

# NRC Webinar San Onofre Nuclear Generating Station Final Enforcement Action and Follow-up Inspection Preliminary Results

March 25, 2019 NRC Region IV, Arlington, TX

#### **NRC Region IV Presenters**

- Linda Howell, Deputy Director
   Division of Nuclear Materials Safety
- Lee Brookhart, Senior Inspector, Team Leader Fuel Cycle and Decommissioning Branch Division of Nuclear Materials Safety

### **Agenda**

Topic	Participants
Opening Remarks	Linda Howell
Final Enforcement Action	Linda Howell
NRC Follow up Inspection Activities	Lee Brookhart
Path Forward	Linda Howell
Questions and Answers/Discussion	All Webinar Participants Michael Bloodgood, Facilitator
Closing Remarks	Linda Howell

 Only in the event of technical difficulties with the webinar, a telephone bridge line will be used:

-Bridge Number: (800) 369-1771

-Passcode: 7382934

-Link to NRC Spotlight web page:
<a href="https://www.nrc.gov/reactors/operating/ops-experience/songs-spec-insp-activities-cask-loading-misalignment.html">https://www.nrc.gov/reactors/operating/ops-experience/songs-spec-insp-activities-cask-loading-misalignment.html</a>

#### **Predecisional Enforcement Conference**

Held on January 24, 2019

 Discussed two apparent violations, safety significance, root causes, and corrective actions

#### **SIGNIFICANCE** = "Severity Level"

#### SEVERITY LEVEL - I

(most significant regulatory concern)

#### SEVERITY LEVEL - II

(very significant regulatory concern)

#### SEVERITY LEVEL - III

(significant regulatory concern)

(Escalated Enforcement)

(Non-Escalated Enforcement)

#### SEVERITY LEVEL - IV

(less significant concern, but more than minor)

#### **Civil Penalty Assessment**

- NRC Enforcement Policy Considers:
  - –Enforcement history
  - —Whether the licensee identified the issue
  - Adequacy of corrective actions

# Violation No. 1 Loss of Redundant Drop Protection Features

10 CFR 72.212(b)(3) requires, in part, that each cask used by the general licensee conforms to the terms, conditions, and specifications of a Certificate of Compliance. The spent fuel storage system's Certificate of Compliance requires that the canister be lifted and carried with redundant drop protection features to prevent uncontrolled lowering of the load.

# Violation No. 1 Loss of Redundant Drop Protection Features

- Severity Level II Violation
- \$116,000 Civil Penalty

# Violation No. 2 Failure to Make Required Notification to NRC

10 CFR 72.75(d)(1) requires, in part, that each licensee notify the NRC within 24 hours after the discovery of events involving spent fuel in which important to safety equipment is disabled or fails to function as designed when required to mitigate the consequences of an accident and redundant safety equipment is not available.

# Violation No. 2 Failure to Make Required Notification to NRC

- Severity Level III Violation
- No Civil Penalty

### Licensee Response to NRC's Enforcement Action

Southern California Edison has three options:

- Accept the violations and pay civil penalty
- Deny the violation(s) or severity levels
- Protest civil penalty in whole or in part

#### **NRC Follow-up Inspection Activities**

- To Determine If:
  - -Root and contributing causes were understood
  - Extent of condition and extent of cause were identified
  - Corrective actions taken to preclude reoccurrence were effective

#### **Licensee Causal Evaluations**

Four causal evaluations performed by Licensee:

- Root Cause for Downloading Incident
- Apparent Cause to Assess Licensee's Oversight
- Common Cause Evaluation
- Root Cause for Reportability

NRC determined that the evaluations were of adequate depth and breadth; however, two weaknesses were identified.

#### **Causal Evaluations Weaknesses**

 Inadequate changes to Executive Oversight Board process

 Issues with Radiation Protection were not formally addressed in causal evaluations

#### **Corrective Actions**

#### From the Four Cause Evaluations:

- -Total of 71 Corrective Actions
- —Total of 9 Corrective Actions to Preclude Repetition
- Total of 8 Effectiveness Reviews

#### NRC Assessment:

The corrective actions were comprehensive to address and prevent reoccurrence; however, six corrective action weakness were identified.

#### **Corrective Actions**

#### **Subject Areas**

- Procedures Changes
- Personnel Enhancements
- Equipment
- Training
- Corrective Action Program
- Demonstrations
- Reportability
- Special Inspection Follow-up Items

#### **Procedures**

- Licensee made changes to spent fuel handling procedures
  - Critical steps with specific criteria
  - Clearly defined personnel roles, responsibilities, and qualifications
  - Load monitoring equipment enhancements
  - Additional required personnel during downloading

#### **Corrective Action Weaknesses**

- Downloading Procedure
  - Lacked contingency steps for equipment failures
  - Incomplete criteria for suspending downloading operations
  - Incomplete steps to maintain seismic qualifications during cask transport from fuel building to the storage pad


#### **Personnel Enhancements**

#### **Previous Personnel on the Storage Pad**

- Vertical Cask Transporter
   Operator
- Spotter in lift basket

### **Revised Personnel on the Storage Pad**

- Vertical Cask Transporter Operator
- Vertical Cask Transporter Platform Rigger
- Rigger-in-Charge in lift basket
- 2<sup>nd</sup> Rigger in 2<sup>nd</sup> lift basket
- Cask Loading Supervisor
- Licensee Oversight Specialist
- Radiation Protection personnel
- Two Vertical Cask Transporter spotters
- Mating Device Operator





### Rigger-in-Charge & 2<sup>nd</sup> Qualified Rigger


#### **Load Indication Enhancements**

#### **Previous Monitoring**

- Vertical Cask Transporter –
   Display Console
- Visual Observation


#### **Revised Monitoring**

- Load Sensing Devices (2)
- Tablet Computers
- Visual and Audible Alarms
- Camera and Video Display
- Vertical Cask Transporter –
   Display Console
- Visual Observation






### **Load Information Displayed on Tablet**



#### **Camera above Transfer Cask**





### Corrective Action Weakness

- Improper classification of new equipment
  - Intermediate slings and devices
- Inadequate procurement of Important to Safety equipment
  - Load cell devices

#### **Training**

- Developed SONGS specific spent fuel training programs and training procedures
- Revised training program for SONGS Oversight Specialists
- Revised Corrective Action Program training
- Developed event notification training

#### **Oversight**

Revised contractor oversight procedures

 Dedicated additional SONGS oversight personnel for contractors

NRC identified a weakness regarding maintenance procedure review

#### **Corrective Action Program**

- Holtec project personnel work directly under SONGS Corrective Action Program
- Established a full-time Quality Assurance Manager Position
- Training conducted to emphasize use of a low-threshold for initiating corrective action process


#### **Demonstrations Observed by NRC**

- Demonstrated moving transfer cask from fuel building to storage pad
  - HI-PORT operations
  - Vertical cask transporter operations
- Demonstrated simulator canister downloading
- Demonstrated simulator canister uploading
- Demonstrated revised fuel building lifting operations

### **Transfer Cask on HI-PORT to Storage Pad**



### **Vertical Cask Transporter Operations**





### **Downloading**

### **Fuel Building Operations**





## Corrective Actions Weakness

 Removal of restraint band from HI-TRAC invalidated seismic analysis

#### Reportability

- Revised Notification Procedure to have a conservative bias
- Developed Reportability Training for Managers and Regulatory Affairs personnel
  - Identify reportable events
  - Identify Important to Safety components
  - Identify potential failures or deviations that require NRC notification
- Biennial Refresher Training

#### **Special Inspection Follow-up Items**

- Drop Evaluation
  - Canister integrity maintained
  - Fuel damage would likely occur
- Scratch Evaluation
  - Inadequate to support change to Final Safety Analysis
     Report
  - Several calculation errors

#### **Path Forward**

- Corrective actions implemented for causal factors and issues identified during Special Inspection
- Outstanding issue is the assessment of ongoing licensee analyses and process used to change the Final Safety Analysis Report (FSAR)
- Enhanced inspection oversight continues
- Licensee continues to suspend fuel loading operations until analysis is complete and NRC has reviewed the results

# NRC Webinar San Onofre Nuclear Generating Station

# BREAK IN SESSION RETURNING SHORTLY



# Questions and Comments Facilitator: Michael Bloodgood

#### Participating via Webinar:

 Type your name, affiliation, and your question into the webinar QUESTION box. The facilitator will pose questions from the QUESTION box to the NRC presenters.

#### Present in Arlington, TX:

 Raise your hand to get the facilitator's attention. Please state your name and affiliation clearly into the microphone before posing your question or comment.

### Feedback, Questions, and Comments

Post Webinar Feedback Link:

https://www.nrc.gov/public-

involve/public-meetings.html

**CONCLUSION OF WEBINAR**