

Advisory Committee on Reactor Safeguards  
Future Plant Designs Subcommittee Meeting on  
Integration of Source Term Activities in Support of Advanced  
Reactor Initiatives  
February 17, 2022

---

## AGENDA

- Opening Remarks
- Staff Introduction
- History and Evolution of LWR Source Term
- NRC analytical tools and past studies
- SCALE/MELCOR non-LWR reference plant analysis

### Break

- Agenda Item IV Continued
- NuScale EPZ Sizing Methodology Topical Report, Rev. 2
- Light water SMR design certification source term approach
- Source term approach for early non-LWR movers

### Lunch

- Accident-consequence-related regulation activities

### Break

- Guidance and information for developing advanced reactor source term
- Guidance for developing advanced reactor source term (long-term)
- Opportunity for Public Comment
- Member Discussion

### Adjourn

# Integration of Source Term Activities in Support of Advance Reactor Initiatives

John Segala

NRR/DANU

February 17, 2022

---

# Staff Introduction

- Determining source terms is a critical component in the NRC's licensing process
- NRC team presenting today:
  - Mark Blumberg – NRR/DRA
  - Michelle Hart – NRR/DANU
  - Jason Schaperow – NRR/DANU
  - Bill Reckley – NRR/DANU
  - Tim Drzewiecki – NRR/DANU
  - Hossein Esmaili – RES/DSA




# History and Evolution of LWR Source Terms

Mark Blumberg

Radiation Protection and Consequence Branch  
Division of Risk Assessment  
Office of Nuclear Reactor Regulation

# LWR Source Term Timeline



---

# History – Regulatory Use of Source Terms

- Siting critical issue
  - Safety & Cost
- Principle hazard – Public Exposure
  - Siting key element in protecting public health
- Earliest reactors used containments
- Atomic Energy Commission proposed siting on population densities
- Ultimately decided siting would be based upon dose calculations

---

# 10 CFR 100.11

- Footnote to 10 CFR 100.11(a) is a performance-based rule to evaluate the defense-in-depth provided by the containment
- Nearly all current reactors were licensed originally to the Technical Information Document (TID) -14844 which provides guidance on the containment source term for the Loss of Coolant Accidents (LOCAs) involving fuel melt
  - Based on heating fuel ‘chips’ in a furnace
  - 100% noble gases (Xe, Kr)
  - 50% iodine (half deposits instantaneously)
  - 1% of other radionuclides as particles
- Iodine Chemical Form
  - 91% as I<sub>2</sub>(g) (elemental); 5% particles; 4% CH<sub>3</sub>I (organic)
- All instantly available from start of accident in the containment
- Source terms for Non-LOCA events are provided in RG 1.195, “Methods and Assumptions for Evaluating Radiological Consequences of Design Basis Accidents at Light Water Reactors”

---

# NUREG-1465 Source Term

- Radionuclide behavior observed during the Three Mile Island Unit 2 accident in 1979 did not appear at all to be like the Technical Information Document (TID)-14844 source term
- NRC initiated research efforts in the area of severe accidents which culminate in publication of NUREG-1150, “Severe Accident Risks: An Assessment for Five U.S. Nuclear Power Plants.” (1990)
- Source term depends on the nature of the accident
- The NUREG-1465, “Accident Sources Terms for Light-Water Nuclear Power Plants” (1995) source term was derived from the risk significant sequences in NUREG-1150

---

# 10 CFR 50.67, RG 1.183

- NRC staff developed RG 1.183 Rev. 0, “Alternative Radiological Source Terms for Evaluating Design Basis Accidents at Nuclear Power Reactors.” (July 2000) to support implementation of 10 CFR 50.67, “Accident Source Term”
  - Applicable to nuclear power reactor applicants and licensees who voluntarily adopt 10 CFR 50.67
  - Provides assumptions and methods that are acceptable to the NRC staff for performing design basis radiological analyses using an AST
  - Used the NUREG-1465 early in-vessel fuel melt source term for LOCAs
  - RG 1.183 also provides Non-LOCA release fractions
  - Identified the significant attributes of an acceptable AST

# TID-14844 vs. NUREG-1465

## BWR Source Term

	NUREG 1465		TID 14844
	Gap	Early In-vessel	
Duration (hours)	.5	1.3	Instant.
Noble Gases (%)	5	95	100
Halogens (%)	5	25	50
	Elemental I2 – 4.85 Aerosol (Csl) – 95 Organic 0.15		Elem. – 91 Aerosol –5 Organic 4

---

# Source Term Updates Proposed in DG-1199

- In October 2009, the NRC issued for public comment DG-1199 as a proposed Rev. 1 of RG 1.183
- Addressed fuel utilization at the time for Non-LOCA accidents
- The NRC staff has elected not to finalize DG-1199 and is issuing DG-1389 as a replacement



---

# Source Term Updates Proposed in DG-1389

- Staff plans to include changes proposed in DG-1199 as modified by public comments
- Provides guidance to address the review of near-term accident tolerant fuel (ATF) designs with burnups up to 68 GWd/MTU peak rod-average) and U-235 enrichments up to 8.0 weight percent.
- Considered impact of fuel fragmentation, relocation and dispersal<sup>1</sup>
- On going research efforts is underway to update the SAND2011-0128 accident source term to accommodate higher burnup and increased enrichments for LOCA releases.

<sup>1</sup> NRC Memorandum, “Letter Report on Evaluation of the Impact of Fuel Fragmentation, Relocation, and Dispersal for the Radiological Design Basis Accidents in Regulatory Guide 1.183 (ADAMS Accession No. ML21197A067)”

---

# Source Term Updates Proposed in DG-1389 (cont.)

- A future RG 1.183 update is expected to accommodate higher burnups and enrichments
- An acceptable analytical procedure for predicting plant-specific non-LOCA radionuclide release fractions has been included and provides flexibility and margin recovery
- Separate BWR and PWR non-LOCA steady state release fractions

---

# Key Messages

- One of the ways the NRC staff and licensees determine what measures and barriers are needed to protect the health and safety of the public is to perform design basis accident dose analyses.
- A key component of these analyses is the determination of the release source term.
- The NRC has developed regulations, source terms and regulatory guidance to provide licensees and the staff with an efficient method of performing these dose analyses.
- Ongoing efforts by the NRC continue to revise these source terms and methods to address modern fuel utilization and the use of accident tolerant fuel.

# NRC Analytical Tools and Past Studies- Severe Accident Progression and Source Term

Hossein Esmaili, RES/DSA  
Jason Schaperow, NRR/DANU

---

## Key Messages

- Decades of NRC and international investments in the state-of-practice SCALE and MELCOR modeling including development, assessment and application
- Importance of analytical capabilities in a system level code and being ready to resolve regulatory issues and help decision making
- Leverage international collaboration through severe accident research and code sharing programs
- Application to a wide variety of nuclear technologies

---


# Outline

- Introduction
- MELCOR Code Overview
- International Collaboration (Severe Accidents & MELCOR)
- Applications to Regulatory Decision-making
  - Examples: Design Certification, SOARCA, Post-Fukushima activities
- Application to New and Advanced Reactors
  - SCALE/MELCOR demonstration calculations

---


# Introduction

# Source Term Development Process





# Code Development & Regulatory Applications



## What Is It?

MELCOR is an engineering-level code that simulates the response of the reactor core, primary coolant system, containment, and surrounding buildings to a severe accident.

## Who Uses It?

MELCOR is used by domestic universities and national laboratories, and international organizations in around 30 countries. It is distributed as part of NRC's Cooperative Severe Accident Research Program (CSARP).

## How Is It Used?

MELCOR is used to support severe accident and source term activities at NRC, including the development of regulatory source terms for LWRs, analysis of success criteria for probabilistic risk assessment models, site risk studies, and forensic analysis of the Fukushima accident.

## How Has It Been Assessed?


MELCOR has been validated against numerous international standard problems, benchmarks, separate effects (e.g., VERCORS) and integral experiments (e.g., Phebus FPT), and reactor accidents (e.g., TMI-2, Fukushima).

---

# MELCOR Overview


# MELCOR History

MELCOR developed at Sandia National Laboratories for NRC since 1982



Version	Date
2.2.21440	December 2021
2.2.18180	December 2020
2.2.14959	October 2019
2.1.11932	November 2018
2.1.9541	February 2017

## MELCOR Code Development



# MELCOR Development

## Fully integrated, engineering-level code





- Thermal-hydraulic response of reactor coolant system, reactor cavity, reactor enclosures, and auxiliary buildings
- Core heat-up, degradation and relocation
- Core-concrete interaction
- Flammable gas production, transport and combustion
- Fission product release and transport behavior

## Level of physics modeling consistent with

- State-of-knowledge
- Necessity to capture global plant response
- Reduced-order and correlation-based modeling often most valuable to link plant physical conditions to evolution of severe accident and fission product release/transport


## Traditional application

- Models constructed by user from basic components (control volumes, flow paths and heat structures)
- Demonstrated adaptability to new reactor designs – HPR, HTGR, SMR, MSR






# MELCOR Flexibility - Common Phenomena



# MELCOR Verification & Validation Basis



Primer & User Guide  
Reference Manual  
Assessment Problems




## TRISO Diffusion Release




IAEA CRP-6 Benchmark  
Fractional Release

Case	1a	1b	2a	2b	3a	3b
US/INL	0.467	1.0	0.026	0.996	1.32E-4	0.208
US/GA	0.453	0.97	0.006	0.968	7.33E-3	1.00
<b>US/SNL</b>	<b>0.465</b>	<b>1.0</b>	<b>0.026</b>	<b>0.995</b>	<b>1.00E-4</b>	<b>0.208</b>
US/NRC	0.463	1.0	0.026	0.989	1.25E-4	0.207
France	0.472	1.0	0.028	0.995	6.59E-5	0.207
Korea	0.473	1.0	0.029	0.995	4.72E-4	0.210
Germany	0.456	1.0	0.026	0.991	1.15E-3	0.218

(1a): Bare kernel (1200 °C for 200 hours)  
 (1b): Bare kernel (1600 °C for 200 hours)  
 (2a): kernel+buffer+iPyC (1200 °C for 200 hours)  
 (2b): kernel+buffer+iPyC (1600 °C for 200 hours)  
 (3a): Intact (1600 °C for 200 hours)  
 (3b): Intact (1800 °C for 200 hours)




Specific to non-LWR application



# MELCOR State-of-the-Practice Modeling

## Timeline for Evolution of MELCOR Modeling Practices



# MELCOR Modernization


Generalized numerical solution engine

Hydrodynamics

In-vessel damage progression


Ex-vessel damage progression

Fission product release and transport




TP = Transfer Process  
 DCH = Decay Heat  
 COR = Core  
 SPR = Containment Spray  
 BUR = Gas Combustion  
 FDI = Fuel Dispersal Interaction  
 CAV = Cavity (MCCI)  
 ESF = Engineered Safety Features  
 MP = Material Properties

RN = Radionuclide  
 HS = Heat Structure  
 CVH = CV Hydrodynamics  
 EDF = External Data File  
 CF = Control Function  
 MES = Special Messages  
 MEX = Executive  
 CVT = CV Thermodynamics  
 NCG = Non Condensable Gas




Separate **Physics** & **Numerics**






# MELCOR Data Requirements

Input Data	HTGR	SFR	MSR	FHR
FP Inventory	SCALE	SCALE	SCALE	SCALE
FP diffusion coefficients (D) and release	Experiments (e.g., AGR) and analysis (e.g., DOE tools)	Experiments		Experiments (e.g., AGR) and analysis (e.g., DOE tools)
Core power shape	Radial/Axial profiles (e.g., SCALE)	Radial/Axial profiles (e.g., SCALE)	Radial/Axial profiles (e.g., SCALE)	Radial/Axial profiles (e.g., SCALE)
Fuel failure	Experiments/other codes (e.g., DOE tools)	Experiments/other codes (e.g., DOE tools)		Experiments/other codes (e.g., DOE tools)
Dust generation & FP transport	Experiments, historical data and other code (e.g., DOE tools)			
FP release under air/water ingress & interaction w/ graphite	Experiments			
Kinetics parameters and reactivity feedback coefficients	Experiments/other codes (e.g., SCALE)	Experiments/other codes (e.g., SCALE)	Experiments/other codes (e.g., SCALE)	Experiments/other codes (e.g., SCALE)
Equilibrium constants for release from pool and vapor pressure data		Experiments/other codes (e.g., DOE tools)	Experiments/other codes (e.g., DOE tools)	Experiments/other codes (e.g., DOE tools)



$$\frac{\partial C}{\partial t} = \frac{1}{r^m} \frac{\partial}{\partial r} \left( r^m D \frac{\partial C}{\partial r} \right) - \lambda C + S$$

D → SCALE  
S → Experiments/Analysis



---



# International Collaboration

# User Groups & Technical Meetings


Cooperative Severe Accident Research Program (CSARP) – June/U.S.A  
 MELCOR Code Assessment Program (MCAP) – June/U.S.A  
 European MELCOR User Group (EMUG) Meeting – Spring/Europe  
 Asian MELCOR User Group (AMUG) Meeting – Fall/Asia



~1000 Code Users  
 Worldwide




# International Severe Accident Projects



# Advanced Fuel Technologies

- Panel of international severe accident experts Phenomena Identification and Ranking Tables (PIRT) that addressed significant phenomenological issues to improve MELCOR
- Source term calculations for HBU/HALEU fuel
- **QUENCH-ATF**: Experiments for ATF cladding materials in the QUENCH facility at Karlsruhe Institute of Technology (KIT) – Near term chromium-coated cladding under design basis accident (DBA) and beyond DBA



NUREG-722  
ENRAC 9/201

Review of Accident  
Tolerant Fuel Concepts  
with Implications to Severe  
Accident Progression and  
Radiological Releases

**NUREG/CR-7282**



NUREG-723  
ENRAC 11/04

Phenomena Identification  
Ranking Tables for  
Accident Tolerant Fuel  
Designs Applicable to  
Severe Accident Conditions



**NUREG/CR-7283**

Office of Nuclear Regulatory Research



# MELCOR SFP Modeling

- **SECY-16-0100:** “National Academy of Sciences Study of the Lessons Learned from the Fukushima Nuclear Accident for Improving Safety and Security of U.S. Nuclear Power Plants”
- **DENOPI (NRC-IRSN/France):** Provide experimental data to validate spray efficacy on cooling spent fuel bundles, and cladding oxidation under a mixture of steam and air environment.
- Enhance MELCOR SFP capabilities




---


# MELCOR Applications

# Design Certification


- Severe accident response and source term
- Containment response to design basis accident




NuScale




APR-1400



AP-1000



US APWR




US EPR



BWRX-300


GE HITACHI







ESBWR



# State-of-the-Art Reactor Consequence Analysis (SOARCA)



# State-of-the-Art Reactor Consequence Analysis (SOARCA)



Uncertainty Analysis

2006


2012

2016



2019

2020




# Uncertainty Analysis (SOARCA) NUREG/CR-7245



# Uncertainty Analysis Applications



# Fukushima Forensics (Unit 3)





# MELCOR Spent Fuel Pool Modeling



NUREG-1744  
SAND-2007-1038

Laminar Hydraulic Analysis of a Commercial Pressurized Water Reactor Fuel Assembly



NUREG-1743  
SAND-2007-2270

Characterization of Thermal-Hydraulic and Ignition Phenomena in Prototypic, Full-Length Boiling Water Reactor Spent Fuel Pool Assemblies After a Postulated Complete Loss-of-Coolant Accident

Office of Nuclear Regulatory Research

Nuclear Safety NEA/  
CSNI, R(2015)2  
May 2015  
www.oecd.org

Status Report on Spent Fuel Pools under Loss-of-Cooling and Loss-of-Coolant Accident Conditions

Final Report

Nuclear Safety  
NEA/CSNI, R(2017)218  
June 2018  
www.oecd.org



Phenomena Identification and Ranking Table

RtD Priorities for Loss-of-Cooling and Loss-of-Coolant Accidents in Spent Nuclear Fuel Pools



Convective Heat Transfer Surfaces:

Ring 1

Clad, Canister / Water Rods, Rack

Ring 2


Clad, Canister / Water Rods, Racks

Radiative Heat Transfer Flow Path:

Fuel → Clad → Canister / Water Rods → Rack → Canister / Water Rods → Clad → Fuel




Ring 1

Ring 2



Multiple fuel rod components in the center assembly (Ring 1) and four peripheral assemblies (Ring 2)

Integral Spray Model







# MELCOR SFP Modeling Basis



NUREG/CR-7216

**Spent Fuel Pool Project Phase II:  
Pre-ignition and Ignition Testing of a 1x4  
Commercial 17x17 Pressurized Water Reactor  
Spent Fuel Assemblies under Complete Loss  
of Coolant Accident Conditions**






Before

After



# MELCOR SFP Model (NUREG-2161)




---

**BREAK**






# MELCOR Results (NUREG-2161)

## Cases that lead to release (OCP1/2/3)





# Containment Protection and Release Reduction (NUREG-2206)

		Pre Core Damage					Post Core Damage					
		RPV Pressure control	RCIC Operation			Anticipatory Venting	Flex Operation		SRV Operation	Venting		
		Availability (hr)	RCIC Availability (hr)	RCIC Suction	Failure Temp (F)	Open SRV after RCIC fails	Setpoint (psig)	Injection @ LH failure	WW Level Control Injection @ 21' (gpm)	Allow SRV stuck open failure?	Location	Setpoint (psig)
Option	Case											
1/2A	1	72	16	SP	230	N	15	-	-	Y	WW	PCPL
1/2A	1S1	72	16	SP	230	N	5	-	-	Y	WW	PCPL
1/2A	2	72	16	SP	230	N	15	-	-	Y	WW	PCPL
1/2A	3	4	4	SP	230	N	15	-	-	N	WW	PCPL
1/2A	4	72	16	SP	240	N	15	-	-	Y	WW	PCPL
1/2A	5	72	16	CST	230	N	15	-	-	Y	WW	PCPL
1/2A	6	72	16	SP	230	N	15	-	-	Y	WW	PSP
3A	7	72	16	SP	230	N	15	RPV	0	Y	WW	PCPL
	7dw	72	16	SP	230	N	15	RPV	0	Y	DW	PCPL
3A	10	72	16	SP	230	N	15	RPV	500	Y	WW/DW	PCPL
3A	11	72	16	SP	230	Y	15	RPV	500	Y	WW/DW	PCPL
4Ai(1)	8	72	16	SP	230	N	15	RPV	throttle	Y	WW	PCPL
4Ai(1)	9	72	16	SP	230	Y	15	RPV	throttle	Y	WW	PCPL
4Ai(1)	12	72	16	SP	230	N	15	RPV	throttle	Y	WW	PCPL
4Ai(1)	13	72	16	CST	230	N	15	RPV	throttle	Y	WW	PCPL
4Ai(1)	14	72	16	SP	230	N	15	RPV	0	Y	WW	PCPL
4Ai(1)	15	72	16	SP	230	N	15	RPV	throttle	Y	WW	PCPL
4Ai(1)	18	72	16	SP	230	N	15	RPV	500	Y	WW/DW	PCPL
4Ai(1)	16	72	16	SP	230	N	15	RPV	500	Y	WW/DW	PCPL
3B	21	230						DW			WW	PCPI
3B	24	230						DW				
	24dw	230						DW				
4Ai(2)	22	230						DW				
	22dw	230						DW				
4Ai(2)	23	230						DW				
4Ai(2)	25	230						DW				
3B	26	230						DW				
4Ai(2)	27	230						DW				
4Ai(2)	28	230						DW				
	28dw	230						DW				
4Ai(2)	32	230						DW				
4Ai(2)	30	230						DW				
	30dw	230						DW				
4Ai(2)	29	230						DW				
	29dw	230						DW				
4Ai(2)	31	230						DW				
	31dw	230						DW				
3A	41	230						RPV				
3B	43	230						DW				
3A	42	230						RPV				
3B	44	230						DW				
4Ai(1)	47	230						RPV				
4Ai(2)	48	230						DW				
3B	45	230						DW				
3B	46	230						DW				
3B	49	230						DW				
4Ai(2)	50	230						DW				
3B	51	230						DW				
3B	52	230						DW				
3B	53	230						DW				




# Containment Protection and Release Reduction (NUREG-2206) - Mark I Results




Water addition at lower head failure has the benefit of mitigating further release, but does not affect the release at the time of venting

Particle size distribution dominated by very small aerosols at the time of venting





# Containment Protection and Release Reduction (NUREG-2206) - Mark I Results



---

# Summary

- Decades of experimental and analytical research in severe accident progression and source term
- Validated state-of-practice MELCOR code ready for application to a wide variety of nuclear technologies including advanced designs
- MELCOR has been an essential tool for resolving safety issues and informing regulatory decision making




---

# MELCOR application to new reactors

# Standard Review Plan


## Staff independent analysis

- Independent assessment of plant response and source term
- Scenarios from the PRA
- Engage with the applicant to resolve differences with the applicant's analysis



# Large LWRs


- ABWR
- AP-600
- System 80+
- AP-1000
- EPR
- APWR
- ESBWR
- APR-1400



ACRS meeting on Integration of Source Term Activities in Support of Advanced Reactor Initiatives, 02/17/2022


# SMRs

- NuScale
- mPower
- Westinghouse SMR
- BWRX-300



# NuScale

- Applicant-developed source term for demonstrating EAB/LPZ dose criteria met
  - Replaced RG 1.183 source term
  - MELCOR, STARNAUA
- NRC independent analysis
  - MELCOR, RADTRAD



---

# SCALE/MELCOR non-LWR source term demonstration project



---

# Outline

- NRC strategy for non-LWR source term analysis
- Project objectives
- Public workshops
- Sample results
  - Heat pipe reactor (HPR)
  - High-temperature gas-cooled reactor (HTGR)
  - Pebble-bed molten-salt-cooled reactor (FHR)
- Summary

# NRC strategy for severe accident analysis

## Evaluation Model and Suite of Codes

USNRC  
United States Nuclear Regulatory Commission  
Protecting People and the Environment

Revision 1  
 January 31, 2020

NRC Non-Light Water Reactor (Non-LWR) Vision and Strategy, Volume 3 – Computer Code Development Plans for Severe Accident Progression, Source Term, and Consequence Analysis

**Volume 3**  
ML20030A178

---

USNRC  
United States Nuclear Regulatory Commission  
Protecting People and the Environment


Revision 1  
 March 02, 2021

NRC Non-Light Water Reactor (Non-LWR) Vision and Strategy, Volume 5 – Radionuclide Characterization, Criticality, Shielding, and Transport in the Nuclear Fuel Cycle

**Volume 5**  
ML21088A047

Code strategy for source term

“NRC Non-Light Water Reactor Vision and Strategy, Volume 3 – Computer Code Development Plans for Severe Accident Progression, Source Term, and Consequence Analysis,” Revision 1, January 2020, ML20030A178



---

# Project objectives

- Understand severe accident behavior and provide insights for regulatory guidance
- Facilitate dialogue on staff's approach for accident progression and source term
- Demonstrate use of SCALE and MELCOR
  - Identify accident characteristics and uncertainties
  - Develop publicly available input models for representative designs

---

# Scope

Full-plant models for representative non-LWRs

- Heat pipe reactor – INL Design A
- High-temperature gas-cooled reactor – PBMR-400
- Pebble-bed molten-salt-cooled – UCB Mark 1
- Molten-salt-fueled reactor – MSRE
- Sodium-cooled fast reactor – ABTR

---

# Approach

1. Use SCALE to calculate core decay heat, radionuclide inventory, reactivity feedback
2. Build MELCOR full-plant input model
3. Select accident scenarios
4. Perform MELCOR simulations for the selected scenarios
5. Public workshops to discuss the modeling and sample results


# Public Workshops

## Public Workshop: SCALE/ MELCOR Non LWR Source Term Demonstration Project

Heat pipe reactor – June 29, 2021

Gas cooled reactor – July 20, 2021

Pebble bed molten-salt-cooled reactor – Sept 14, 2021





For More  
Information



## Coming in 2022

Molten-salt fueled reactor  
Sodium-cooled fast reactor



<https://www.nrc.gov/reactors/new-reactors/advanced/details.html#non-lwr-ana-code-dev>




---


# Sample Results

calculations by ORNL and SNL


# HPR model (INL Design A)



SCALE Model



MELCOR Model



Ring 1 is the control rod guide Rings 2-15 are the active core (each ring = pitch of 1 fuel element)

# HPR – reactivity addition accident with delayed scram

The control drums start rotating at  $t=0$  sec, which leads to an increase in the core power over 0.9 hr


- Negative fuel temperature reactivity feedback limits the rate of power increase

The core steadily heats until the maximum heat flux location reaches the boiling limit

- The heat transfer rate is limited above the boiling limit, which leads to a rapid heatup rate
- The SS cladding is assumed to fail at 1650 K (just below its melting point), which starts the fission product release into the reactor
- The reactor is assumed to trip at 2200 K

Radial heat dissipation and heat loss to the reactor cavity passively cools the core

- No active heat removal (secondary system trips and isolates)




# HPR – reactivity addition accident with delayed scram

Cladding failure at 1650 K resulting in fission product release



- Heat Pipes (HP) that exceeded the boiling limit rapidly heat to cladding failure (1650 K)
- ~20% of the 1134 HPs and fuel elements failed
- HP depressurization on failure drive release from the vessel

Iodine releases also depend on time at temperature


- Fuel release – 1.4% of core inventory
- Environmental release – 0.0008% of core inventory




- Vessel leakage is 1.6 in<sup>2</sup>
- Building leakage is 1.8 in<sup>2</sup>






# HTGR model (PBMR-400)



SCALE Model



MELCOR Model





# HTGR – loss of coolant accident

## Following pipe break

- Control rods insert to terminate fission
- The vessel depressurizes in seconds as the high-pressure helium escapes out both sides of the broken pipe
- Peak velocity in the pebble bed is 45 m/s (normal flow rate is 11-18 m/s)

## Counter-current flow established on the vessel side of the pipe break

- Hot gases from the exit plenum escape on the top side of the broken hot leg pipe and cooler gases enter along the bottom of the pipe







# HTGR – loss of coolant accident

## In-vessel natural circulation flow after blowdown

- Upward flow in the inner region of the core where the fuel temperatures and decay power heating are higher
- Downward flow in the outer region of the core where the fuel temperatures and decay power heating are lower
- Flow increases when the fuel starts to cool

The fuel temperatures in the inner region of the pebble bed shift from cooler at inlet and hot at the outlet due to the flow reversal


- The axial fuel temperatures are affected by the local decay heat power (highest in the center) and the flow direction
  - During normal operation, the fuel at the exit (bottom) is the hottest
  - The exit becomes the coolest location (low power and cooler gases entering from the exit plenum)




# HTGR – loss of coolant accident

The impact of the low TRISO failure fraction leads to small releases


- Iodine diffusivity assumed to be same as krypton
- Assumes most iodine reacts with cesium
- Larger cesium release due its the higher diffusivity
- Ag release to the environment is  $1.2 \times 10^{-3}$  (highest diffusivity)




# FHR model (UCB Mark 1)



SCALE Model



MELCOR Model



---

# FHR – ATWS

## Loss-of-onsite power with failure to SCRAM

- Salt pumps shut off
- Reactor fails to SCRAM
- Secondary heat removal ends
- 0 to 3 trains of DRACS operating

## Includes preliminary analysis with xenon transient





- Guided by ORNL calculations
- Xenon reactivity feedback model being implemented into MELCOR

# FHR – ATWS

Initial fuel heatup has strong negative fuel and moderator feedback that offsets positive reflector feedbacks

Strong negative xenon transient feedback

3xDRACS exceeds core power after 330 s



# FHR – ATWS with variable DRACS


Early power decrease to decay heat level is similar for all cases

- 1xDRACS and 2xDRACS cases exceed decay heat later


Fuel temperatures cool down according to DRACS heat removal rate

- 0xDRACS peak fuel temperature = 990 °C at 10<sup>5</sup> s (T<sub>sat</sub> ~ 1350 °C)

Core Power and DRACS Heat Removal



Peak Fuel Temperatures





---

# Summary

- Demonstrated use of SCALE and MELCOR for safety analysis for 3 classes of non-LWRs
  - Working on demonstrations for 2 more classes
- Simulated the entire accident starting with the initiating event
  - system thermal hydraulic response
  - fuel heat-up
  - heat transfer through the reactor to the surroundings
  - radiological release
- Evaluated effectiveness of passive mitigation features

---

# References ([www.nrc.gov](http://www.nrc.gov))(1/2)

- **NUREG-2161**, Consequence Study of a Beyond-Design-Basis Earthquake Affecting the Spent Fuel Pool for a U.S. Mark I Boiling Water Reactor (2014)
- **NUREG-2206**, Technical Basis for the Containment Protection and Release Reduction Rulemaking for Boiling Water Reactors with Mark I and Mark II Containments (2018)
- **NUREG/BR-0524**, Cooperative Severe Accident Research Program (CSARP)(2015)
- **NUREG/CR-7143**, Characterization of Thermal-Hydraulic and Ignition Phenomena in Prototypic, Full-Length Boiling Water Reactor Spent Fuel Pool Assemblies After a Postulated Complete Loss-of-Coolant Accident (2013)
- **NUREG/CR-7144**, Laminar Hydraulic Analysis of a Commercial Pressurized Water Reactor Fuel Assembly (2013)

---

## References ([www.nrc.gov](http://www.nrc.gov))(2/2)

- **NUREG/CR-7216**, Spent Fuel Pool Project Phase II: Pre-Ignition and Ignition Testing of a 1x4 Commercial 17x17 Pressurized Water Reactor Spent Fuel Assemblies under Complete Loss of Coolant Accident Conditions (2016)
- **NUREG/CR-7245**, State-of-the-Art Reactor Consequence Analyses (SOARCA) Project: Sequoyah Integrated Deterministic and Uncertainty Analyses (2019)
- **NUREG/CR-7282**, Review of Accident Tolerant Fuel Concepts with Implications to Severe Accident Progression and Radiological Releases (2021)
- **NUREG/CR-7283**, Phenomena Identification Ranking Tables for Accident Tolerant Fuel Designs Applicable to Severe Accident Conditions (2021)
- **SECY-16-0100**, “National Academy of Sciences Study of the Lessons Learned from the Fukushima Nuclear Accident for Improving Safety and Security of U.S. Nuclear Power Plants”

---

# Abbreviations

ATF	accident tolerant fuel	LPZ	low-population zone
ATWS	anticipated transient without scram	MSR	molten salt reactor
DBA	design basis accident	NEA	Nuclear Energy Agency
DW	drywell	OCP	operating cycle phase
EAB	exclusion area boundary	ORNL	Oak Ridge National Laboratory
EU	European Union	PBMR	pebble bed modular reactor
DRACS	direct reactor auxiliary cooling system	PIRT	phenomena identification and ranking table
FHR	fluoride salt-cooled high-temperature reactor	PRA	probabilistic risk assessment
HALEU	high-assay low-enriched uranium (fuel)	RPV	reactor pressure vessel
HBU	high burnup (fuel)	SAWA	severe accident water addition
HPR	heat pipe reactor	SAWM	severe accident water management
HTGR	high temperature gas-cooled reactor	SFP	spend fuel pool
INL	Idaho National Laboratory	SFR	sodium-cooled fast reactor
IRSN	Institut de radioprotection et de sûreté nucléaire (France)	SMR	small modular reactor
		SNL	Sandia National Laboratory
		SOARCA	State-of-the-Art Reactor Consequence Analysis

---

**NuScale EPZ Sizing Methodology Topical Report, Rev. 2**  
**Light Water SMR Design Certification Source Term Approach**  
**Source Term Approach for Early non-LWR Movers**

# Accident Source Term in Recent and Near-term Applications

Michelle Hart  
NRR/DANU/UTB2



---

# Outline

- SMR and non-LWR accident source terms recent experience
- Emergency planning zone size justification consequence analyses
- Example: SMR design certification source term approach
- Source term approaches for non-LWR early movers

---

# SMR and Non-LWR Accident Source Terms

## Recent Experience

- SMR topical report reviews and SMR DC application review
- Advanced reactor pre-application interactions, topical report reviews, and license applications
- Source term development contractor reports

---

# Emergency Planning Zone Size Justification Consequence Analyses

- Concept based on NUREG-0396
  - Technical basis for plume exposure and ingestion pathway EPZ radius of ~10 and ~50 miles, respectively
  - Identification of area within which prompt protective actions may be necessary to provide dose savings in the event of a radiological release
- Calculate dose at distance for a spectrum of accidents
  - Analysis includes design basis accidents and severe accidents

---

# Emergency Planning Zone Size Justification Consequence Analyses

- No separate/unique source terms developed especially for EPZ size analysis
  - Re-use source terms and accident release information developed for safety analysis report and PRA

---

# Emergency Planning Zone Size Justification Consequence Analyses

- Methodology to support exemptions to 10-mile requirement
  - Clinch River ESP EPZ size methodology described in SSAR
- Methodology to support plume exposure pathway EPZ size determination on case-by-case basis for reactors <250 MWt
  - NuScale EPZ sizing methodology topical report (under review)
- EPZ size determination required in EP for SMRs and ONTs alternative framework, once issued
  - SECY-22-0001 issued for Commission review and approval
  - Guidance on analysis in appendices to RG 1.242

---

# NuScale EPZ Sizing Methodology Topical Report

- TR-0915-17772, Revision 2, submitted in 2020, currently under review
  - Not part of DC review
  - Applicable to light-water SMRs such as NuScale, although not limited to the NuScale designs
  - Rev. 3 under development
- Analysis methodology to determine plume exposure pathway EPZ size



---

# NuScale EPZ Sizing Methodology Topical Report

- “Source term” refers to fission product release to the environment as a function of time
- Uses source terms from DBAs (DC FSAR Ch. 15) and PRA severe accident scenarios scoped into analysis
  - No separate/unique source terms developed especially for EPZ size analysis
  - Uses CDF from PRA to categorize severe accidents and select accident sequences to evaluate against relevant dose criteria

---

# Example: SMR Design Certification Source Term Approach

- SECY-19-0079, August 16, 2019
  - Describes staff review approach to evaluate accident source terms for both the TR and the NuScale SMR DC application
  - Provides basis for using source term without core damage for environmental qualification

---

# Example: SMR Design Certification Source Term Approach – NuScale TR

- NuScale TR-0915-17565, “Accident Source Term Methodology,” Revision 4, February 2020
  - Methods to develop accident source terms are consistent with RG 1.183 guidance for PWRs except for:
    - Core damage source term for Core Damage Event
    - Iodine spike design basis source term (no fuel damage)

---

# NuScale TR: Core Damage Event

- Derive source term from range of accident scenarios that result in significant damage to the core
  - Informed by NuScale SMR PRA
- NuScale-design-specific analyses using MELCOR to be performed by applicant referencing the TR
- Radionuclide transport phenomena
  - Iodine retention in containment based on pH
  - Aerosol natural deposition in containment

---

# NuScale SMR DC Application: Core Damage Event

- Implemented the NuScale TR methodology to determine the core damage source term
- Core inventory calculated using SCALE code
- Scenario selection
  - Based on NuScale SMR PRA, internal events
  - 5 surrogate scenarios
    - Various failures of ECCS, with decay heat removal system available
    - Intact containment

---

# NuScale SMR DC Application: Core Damage Event

- MELCOR used to estimate release timing and magnitude for each scenario
  - Release onset and duration from scenario with minimum time to core damage
  - Core release fractions taken as median of scenarios
- Time-dependent aerosol removal rates calculated using STARNAUA code
  - Design-specific input thermal hydraulic conditions calculated by MELCOR for surrogate scenario with minimum time to core damage



---

# Source Term Approaches for Non-LWR Early Movers

- Kairos Power
  - MST methodology TR (under review)
    - Methodology for applicants to develop event-specific radiological source terms
      - DBAs for siting and safety analysis
      - AOOs and DBEs for LMP
  - Hermes CP application (under review)
    - Evaluates MHA, deterministic
    - Refers to MST TR

---

# Source Term Approaches for Non-LWR Early Movers

- X-energy
  - Proposed to use developer-made source term code (XSTERM) which includes modeling of radionuclides from generation to release (and dose)
  - TR was submitted, but withdrawn to clarify and resubmit in future (not currently under review)

---

# Source Term Approaches for Non-LWR Early Movers

- Oklo Aurora COL application (review ended)
  - Proposed maximum credible accident without release
- TerraPower
  - Development of source term methodology described in 1/13/2022 public meeting ([ML22011A072](#))
  - Topical report planned for April 2023
- Terrestrial, Westinghouse, Others
  - Source terms to be determined
  - Public website information on [non-LWR pre-application activities](#)

---

# Acronyms

AOO	anticipated operational occurrence
CDF	core damage frequency
COL	combined license
CP	construction permit
DBA	design basis accident
DBE	design basis event
DC	design certification
ECCS	emergency core cooling system
EP	emergency preparedness
EPZ	emergency planning zone
ESP	early site permit
FSAR	final safety analysis report
LMP	Licensing Modernization Project
MHA	maximum hypothetical accident
MST	mechanistic source term
MWt	megawatts thermal
Non-LWR	non-light water reactor
ONTs	other new technologies
PRA	probabilistic risk assessment
PWR	pressurized water reactor
RG	regulatory guide
SMR	small modular reactor
SSAR	site safety analysis report
TR	topical report

---

**LUNCH**

# Accident Consequence-Related Regulation Activities

Michelle Hart  
NRR/DANU/UTB2



---

# Petition for Rulemaking

- PRM-50-121, Voluntary Adoption of Revised Design Basis Accident Dose Criteria
  - Received 11/23/2019, docketed 2/19/2020 ([85 FR 31709](#))
  - Under evaluation – no disposition yet
- Requests voluntary rule to allow power reactor licensees to adopt alternative to the accident dose criteria specified in § 50.67, “Accident source term.”
- Proposes a uniform value of 100 milli-Sieverts (10 rem) for offsite locations and for the control room

---

# Emergency Preparedness for SMRs and Other New Technologies Rulemaking

- Final rule in development
  - New section 10 CFR 50.160, and related/conforming changes
  - ACRS meetings in September and November 2021
- RG 1.242 (to be issued with final rule)
  - Appendices
    - Generalized analysis methodology
    - Information on source terms

---

# Emergency Preparedness for SMRs and Other New Technologies Rulemaking

- Appendix A, “General Methodology for Establishing Plume Exposure Pathway Emergency Planning Zone Size”
  - Provides general guidance on the consequence analysis to support plume exposure pathway EPZ size determination
  - Discusses event selection and consideration of accident likelihood

---

# Emergency Preparedness for SMRs and Other New Technologies Rulemaking

- Appendix B, “Development of Information on Source Terms”
  - Provides guidance to develop source terms for plume exposure pathway EPZ size evaluations

---

# Alternative Physical Security for Advanced Reactors Rulemaking

- Draft rule and guidance in development
- Voluntary alternative physical security requirements commensurate with potential safety and security consequences
- Analyses (guidance under development)
  - Develop relevant scenarios
  - Site-specific potential offsite radiological consequences

---

# Acronyms

CFR	Code of Federal Regulations
EPZ	emergency planning zone
FR	Federal Register
PRM	petition for rulemaking
RG	Regulatory Guide
SMR	small modular reactor



# Guidance and Information for Developing Source Terms for Non-LWRs

Michelle Hart, NRR/DANU/UTB2

Bill Reckley, NRR/DANU/UARP

Tim Drzewiecki, NRR/DANU/UTB1

---

# Outline

- Accident consequence analysis for advanced reactors
- Mechanistic source term
- Recent reports on Non-LWR source term development
- Non-LWR PRA standard and source term
- Licensing Modernization Project and source term
- Overview of method in NUREG-2246, “Fuel Qualification for Advanced Reactors”
- Non-LWR accident source term information website

---

# Accident Consequence Analysis for Advanced Reactors

- Regulatory nexus
  - Siting and safety analysis regulatory requirement
  - Newer uses for advanced reactors
    - LMP
    - Plume exposure pathway EPZ size determination
    - Alternative security requirements – ongoing rulemaking
    - Part 53 – ongoing rulemaking

---

# Accident Consequence Analysis for Advanced Reactors

- Accident source term development considerations
  - Event selection, scenarios
  - Balance of prevention vs. mitigation
  - Relationship to functional containment
    - A barrier, or set of barriers taken together, that effectively limit the physical transport of radioactive material to the environment (SECY-18-0096)
  - Relationship to PRA
  - Uncertainty

---

# Accident Consequence Analysis for Advanced Reactors

- Mechanistic or deterministic evaluation
  - LMP assumes MST and use of PRA
  - Some non-LWRs may choose to provide a postulated MHA, similar to non-power reactor licensees
- No current specific RG on MST or non-LWR source terms, however
  - RG 1.183, regulatory position C.2, “Attributes of an Acceptable AST,” may be useful
  - SECY-93-092 included staff recommendations on non-LWR source terms

---

# Mechanistic Source Term

- SECY-93-092 definition of MST

*A mechanistic source term is the result of an analysis of fission product release based on the amount of cladding damage, fuel damage, and core damage resulting from the specific accident sequences being evaluated. It is developed using best-estimate phenomenological models of the transport of the fission products from the fuel through the reactor coolant system, through all holdup volumes and barriers, taking into account mitigation features, and finally, into the environs.*



---

# SECY-93-092: Provisions for Staff Assurance

- *The performance of the reactor and fuel under normal and off-normal conditions is sufficiently well understood to permit a mechanistic analysis. Sufficient data should exist on the reactor and fuel performance through the research, development, and testing programs to provide adequate confidence in the mechanistic approach.*
- *The transport of fission products can be adequately modeled for all barriers and pathways to the environs, including specific consideration of containment design. The calculations should be as realistic as possible so that the values and limitations of any mechanism or barrier are not obscured.*
- *The events considered in the analyses to develop the set of source terms for each design are selected to bound severe accidents and design-dependent uncertainties*

---

# National Lab Non-LWR Source Term Reports

- Technology inclusive, what to do to develop accident source terms, not specific on how to do it
- No specific methods or phenomenological models
- Do not provide technology-related source terms or releases

---

# Technology-Inclusive Determination of Mechanistic Source Terms for Offsite Dose-Related Assessments for Advanced Nuclear Reactor Facilities

INL/EXT-20-58717, Revision 0, June 2020, [ML20192A250](#)

- Summarizes a risk-informed, performance-based, and technology-inclusive approach to determine source terms
- Graded process
  - Conservative non-mechanistic approach
  - MST calculation methods
    - Design-specific scenarios for a range of licensing basis events
    - Best-estimate models with uncertainty quantification

# MST Formulation



$$I(RN_j) * F(S_i, RN_j, t) * MR(S_i, RN_j, t) * PSR(S_i, RN_j, t) * LPF(S_i, RN_j, t) = ST(S_i, RN_j, t)$$

Figure 1-2 INL/EXT-20-58717, Revision 1. From Illustration of radionuclides retention and removal process for one non-LWR concept (reproduced from SAND2020-0402)

# Technology-Inclusive Source Term Methodology Determination




Figure 3-1 Technology-inclusive source terms determination methodology components (modified from Ref. [18]).

---

# INL Report Methodology Steps

- 1: Identify Regulatory Requirements
- 2: Identify Reference Facility Design
- 3: Define Initial Radionuclide Inventories
4. Perform Bounding Calculations
5. Conduct SHA and Perform Simplified Calculations
6. Consider Risk-informed System Design Changes
7. Select Initial List of LBEs and Conduct PIRT
8. Establish Adequacy of MST Simulation Tools
9. Develop and Update PRA Model
10. Identify or Revise the List of LBEs
11. Select LBEs to Include Design Basis External Hazard Level for Source Term Analysis
12. Perform Source Term Modeling and Simulation for LBEs
13. Review LBEs List for Adequacy of Regulatory Acceptance
14. Document Completion of Source Term Development

---

# Simplified Approach for Scoping Assessment of Non-LWR Source Terms

SAND2020-0402, January 2020, [ML20052D133](#)

- Primarily qualitative means to identify the dominant considerations that affect a release mitigation strategy
- Classifies release mitigation strategies based on a range of barriers, physical attenuation processes, and system performance under sample accident scenarios
- Did NOT develop quantitative estimates of radiological release magnitudes and compositions to the environment
- Looked at high temperature gas reactors, sodium fast reactors, and liquid fueled molten salt reactors




---

# Non-LWR PRA Standard ASME/ANS RA-S-1.4-2021

- Full scope PRA (includes consequence analysis)
- Mechanistic Source Term Analysis (MS) element provides useful information on what to do to develop mechanistic source terms


# Licensing Modernization

- Risk-informed approach to selection and analysis of licensing basis events
- Combined with assessment of cumulative risks
- Key roles for PRA and MST



# Licensing Modernization

Recent NRC activities related to advanced reactors (e.g., functional containment performance criteria, possible changes to emergency planning & security, and DG-1353) recognize the limitations of existing LWR-related guidance, which requires a return to first principles such as fundamental safety functions supporting the retention of radionuclides



See: SECY-18-0096, “Functional Containment Performance Criteria for Non-Light-Water-Reactors,” and INL/EXT-20-58717, “Technology-Inclusive Determination of Mechanistic Source Terms for Offsite Dose-Related Assessments for Advanced Nuclear Reactor Facilities”

# Licensing Modernization

- Flexibility provided on how to develop safety case
- NRC Advanced Reactor Policy Statement encourages use of passive and inherent features





Figure 3-6. Elements of safety design approach incorporated into *Plant Capability Defense-in-Depth*.


# Assessment Frameworks

## Fuel Qualification (FQ)


- Top-down approach to identify criteria (goals) to support a finding that “fuel is qualified”



# FQ Assessment Framework




# G2: Safety Criteria






# G2.2: Radionuclide Release Limits



# G2.2.2 Criteria for Barrier Degradation



# Complete FQ Assessment Framework

GOAL	Fuel is qualified for use
G1	Fuel is manufactured in accordance with a specification
G1.1	Key dimensions and tolerances of fuel components are specified
G1.2	Key constituents are specified with allowance for impurities
G1.3	End state attributes for materials within fuel components are specified or otherwise justified
G2	Margin to safety limits can be demonstrated
G2.1	Margin to design limits can be demonstrated under conditions of normal operation and AOOs
G2.1.1	Fuel performance envelope is defined
G2.1.2	Evaluation model is available (see EM Assessment Framework)
G2.2	Margin to radionuclide release limits under accident conditions can be demonstrated
G2.2.1	Fuel performance envelope is defined
G2.2.1	Radionuclide retention requirements are specified
G2.2.2	Criteria for barrier degradation and failure are suitably conservative
	(a) Criteria are conservative
	(b) Experimental data are appropriate (see ED Assessment Framework)
G2.2.3	Radionuclide retention and release from fuel matrix are modeled conservatively
	(a) Model is conservative
	(b) Experimental data are appropriate (see ED Assessment Framework)
G2.3	Ability to achieve and maintain safe shutdown is assured
G2.3.1	Coolable geometry is ensured
	(a) Criteria to ensure coolable geometry are specified
	(b) Evaluation models are available (see EM Assessment Framework)
G2.3.2	Negative reactivity insertion can be demonstrated
	(a) Criteria are provided to ensure that negative reactivity insertion path is not obstructed
	(b) Evaluation model is available (see EM Assessment Framework)

GOAL	Evaluation model is acceptable for use
EM G1	Evaluation model contains the appropriate modeling capabilities
EM G1.1	Evaluation model is capable of modeling the geometry of the fuel system
EM G1.2	Evaluation model is capable of modeling the material properties of the fuel system
EM G1.3	Evaluation model is capable of modeling the physics relevant to fuel performance
EM G2	Evaluation model has been adequately assessed against experimental data
EM G2.1	Data used for assessment are appropriate (see ED Assessment Framework)
EM G2.2	Evaluation model is demonstrably able to predict fuel failure and degradation mechanisms over the test envelope
EM G2.2.1	Evaluation model error is quantified through assessment against experimental data
EM G2.2.2	Evaluation model error is determined throughout the fuel performance envelope
EM G2.2.3	Sparse data regions are justified
EM G2.2.4	Evaluation model is restricted to use within its test envelope

GOAL	Experimental data used for assessment are appropriate
ED G1	Assessment data are independent of data used to develop/train the evaluation model
ED G2	Data has been collected over a test envelope that covers the fuel performance envelope
ED G3	Experimental data have been accurately measured
ED G3.1	The test facility has an appropriate quality assurance program
ED G3.2	Experimental data are collected using established measurement techniques
ED G3.3	Experimental data account for sources of experimental uncertainty
ED G4	Test specimens are representative of the fuel design
ED G4.1	Test specimens are fabricated consistent with the fuel manufacturing specification
ED G4.2	Distortions are justified and accounted for in the experimental data

\* For illustrative purposes only. Please see Appendix A to [NUREG-2246](#) for a legible list.

---

# Non-LWR Accident Source Term Webpage Information

<https://www.nrc.gov/reactors/new-reactors/advanced/related-documents/nuclear-power-reactor-source-term.html>

- One-stop shop for existing information, on public website under advanced reactors
  - Discussion of accident source terms
  - Linked list of documents relevant to development of non-LWR accident source terms for licensing
- Staff will keep up to date

---

# Acronyms

AST	alternative source term
EPZ	emergency planning zone
INL	Idaho National Laboratory
LBE	licensing basis event
LMP	Licensing Modernization Project
LWR	light water reactor
MHA	maximum hypothetical accident
MST	mechanistic source term
Non-LWR	non-light water reactor
PIRT	phenomena identification and ranking table
PRA	probabilistic risk assessment
RG	regulatory guide
SHA	system hazard analysis

# Guidance for developing advanced reactor source term (long-term)

Bill Reckley  
Michelle Hart  
John Segala  
NRR/DANU

# General Approach

- Maintain traditional LWR approach (RG 1.183) as an acceptable option
- Technology-inclusive methodology available as an option
- Actual implementation is technology/design specific
- NRC not planning to provide analytical inputs to applicants (beyond making available NRC developed models)







Figure 3-1 Technology-inclusive source terms determination methodology components (modified from Ref. [18]).



# DOE/National Laboratories



# NRC Activities



# Next Generation Nuclear Plant (NGNP)

Mechanistic Source Terms White Paper

INL/EXT-10-17997





Figure 2-4. HTGR radionuclide retention system.

# Model Development



## Primer & User Guide Reference Manual Assessment Problems

---

# Applications & Pre-App Interactions



---

# Moving Forward

- Following the scientific work being done by national laboratories and developers
- Engaging with developers
- Continuing to develop NRC models and identify related uncertainties
- Consider additional guidance based on experience with ongoing interactions
- Consider feedback on the new webpage

---

# Opportunity for Public Comment



---

## Member Discussion



---

# Adjourn