



Entergy Nuclear South
Entergy Operations, Inc.
17265 River Road
Killona, LA 70057
Tel 504 739 6440
Fax 504 739-6698
bhousto@entergy.com

Bradford Houston
Director, Nuclear Safety Assurance
Waterford 3

W3F1-2004-0043

May 21, 2004

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

SUBJECT: Supplement to Amendment Request NPF-38-249,
Extended Power Uprate
Waterford Steam Electric Station, Unit 3
Docket No. 50-382
License No. NPF-38

REFERENCES: 1. Entergy Letter dated November 13, 2003, "License Amendment Request NPF-38-249 Extended Power Uprate"
2. NRC Letter dated April 20, 2004, "Waterford Steam Electric Station, Unit 3 (Waterford 3) – Request for Additional Information Related to Revision to Facility Operating License and Technical Specifications - Extended Power Uprate Request (TAC No. MC1355)"

Dear Sir or Madam:

By letter (Reference 1), Entergy Operations, Inc. (Entergy) proposed a change to the Waterford Steam Electric Station, Unit 3 (Waterford 3) Operating License and Technical Specifications to increase the unit's rated thermal power level from 3441 megawatts thermal (MWt) to 3716 MWt.

By letter (Reference 2), the Nuclear Regulatory Commission (NRC) staff requested additional information (RAI) related to probabilistic risk assessment. Entergy's response to these 13 questions is contained in Attachment 1 to this letter.


There are no technical changes proposed. The original no significant hazards consideration included in Reference 1 is not affected by any information contained in this letter. The submittal includes a new commitment as summarized in Attachment 2.

If you have any questions or require additional information, please contact D. Bryan Miller at 504-739-6692.

A001

I declare under penalty of perjury that the foregoing is true and correct. Executed on
May 21, 2004

Sincerely,

A handwritten signature in black ink, appearing to read "Bradford L. Hunt". The signature is written in a cursive style with a large, sweeping initial 'B'.

BLH/DBM/ssf

Attachment:

1. Response to Request for Additional Information
2. List of Regulatory Commitments

cc: Dr. Bruce S. Mallett
U. S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011

NRC Senior Resident Inspector
Waterford 3
P.O. Box 822
Killona, LA 70057

U.S. Nuclear Regulatory Commission
Attn: Mr. Nageswaran Kalyanam MS O-07D1
Washington, DC 20555-0001

Wise, Carter, Child & Caraway
Attn: J. Smith
P.O. Box 651
Jackson, MS 39205

Winston & Strawn
Attn: N.S. Reynolds
1400 L Street, NW
Washington, DC 20005-3502

Louisiana Department of Environmental Quality
Office of Environmental Compliance
Surveillance Division
P. O. Box 4312
Baton Rouge, LA 70821-4312

American Nuclear Insurers
Attn: Library
Town Center Suite 300S
29th S. Main Street
West Hartford, CT 06107-2445

Attachment 1 To

W3F1-2004-0043

Response to Request for Additional Information

**Response to Request for Additional Information
Related to the Extended Power Uprate**

Probabilistic Risk Assessment

Question 1:

Section 2.11: Does the probabilistic risk assessment (PRA) model include equipment unavailability due to maintenance, or was a "zero maintenance" PRA model used? If the latter, justify that the PRA results can be meaningfully compared to the numerical risk acceptance guidelines contained in Regulatory Guide 1.174.

Response 1:

The Section 2.11 PRA evaluation used the base PRA model, which includes maintenance unavailability basic events. The unavailability values are based on plant-specific data.

Question 2:

Page 2.11-2, Loss-of-Offsite Power (LOOP): Please provide the overall LOOP frequency, along with its constituent parts (plant-centered, grid-related, and weather-related frequencies). Describe the basis for estimating the LOOP frequencies and offsite power (OSP) recovery curves, identifying the methodology and data sources used. Justify that the data used is relevant to the Waterford post-extended power uprate (EPU) grid environment.

(Staff comment: NUREG-1784 indicates that since 1997 (when deregulation of the nation's electrical grid commenced), the nationwide plant-centered LOOP frequency has decreased, the grid-related and weather-related LOOP frequencies have remained constant, and OSP recovery times have increased. Since mixing older data with newer data tends to smooth out (de-emphasize) these trends, the post-EPU PRA results may not reasonably portray the post-EPU plant risk.)

Response 2:

The overall LOOP frequency is 2.70E-2 per year. The constituent parts are:

Plant-centered	2.07E-02
Grid	4.80E-03
Weather	1.50E-03

This LOOP frequency was estimated using the following data and method. Industry data reported by EPRI for the time period between 12/1/85 to 12/31/99 [EPRI TR-106306 (LOOP data through 1995), EPRI TR-110398 (LOOP data through 1999)] were reviewed for applicability to Waterford 3. As noted by EPRI, only categories 1a and 1b represent true unavailability of all offsite power; these were the EPRI events considered for inclusion in the LOOP frequency. Although the EPRI data does not classify offsite events according to the plant-centered, grid-related, and weather-related categories, such categories were determined through review of the event descriptions.

LOOP events in these EPRI documents were excluded from the Waterford 3 LOOP frequency if they met the following criteria:

- All events related to snow and ice were discarded since the Waterford site has a mild climate and no record of suffering extreme cold weather-related precipitation.
- All events related to hurricanes were discarded. Procedure OP-909-521, "Severe Weather and Flooding," requires plant shutdown to Mode 5 when a hurricane warning is issued and arrival on site is expected within 12 hours. These hurricane LOOP events are included in the shutdown risk model.
- Events clearly not relevant to Waterford 3 due to differences in plant design were discarded.

During the 12/1/85 to 12/31/99 time frame, 40 LOOP events were counted as applicable to Waterford 3.

In order to determine the number of generating unit years for this time frame, two references were used. Table B from NSAC-203 (LOOP data through 1993) was used to obtain the number of generating unit years from 1986 [95.1 generating unit years], 1987 [102.2 generating unit years], and 1/12 of the generating units for 1985 [$1/12 \times 89.6$ generating unit years]. This yielded 204.8 generating unit years. EPRI TR-1000158 (LOOP data through 1999) was used for the 12 year period from 1988 through 1999, which yielded 1278.0 generating unit years. The total generating unit years for the time frame of 12/1/85 to 12/31/99 was $204.8 + 1,278.0$ or 1,482.8 generating unit years.

Therefore, the LOOP frequency for Waterford was $40/1482.8$ or $2.70E-02$ losses per generating unit year.

The offsite power (OSP) recovery curves were developed using durations from the LOOP events used for the LOOP frequency, with the addition of LOOP events going back to 1965 [NSAC-85 (LOOP data through 1984), NSAC-166 (LOOP data through 1989)]. The OSP recovery curve was formed from a weighted mixture of Weibull probability distribution functions:


$$\Pr\{\text{OSP not recovered by time } t\} = G(t) = p_1G_1(t) + p_2G_2(t) + p_3G_3(t)$$

where $G(t)$ denotes the complementary cumulative distribution function (CCDF) of the mixture, p_j for $j=1,2,3$ denote weighting factors such that $p_1 + p_2 + p_3 = 1$, and $G_j(t)$ for $j=1,2,3$ denote the CCDFs of OSP recovery times associated with unique causes of LOOP. The three categories of LOOP causes were: grid-related ($j=1$), plant-centered ($j=2$), and weather-related ($j=3$). Weibull distributions were used to model the OSP recovery times associated with each category of LOOP (i.e., the $G_j(t)$ functions are Weibull CCDFs). The Weibull probability distribution was used as suggested by NUREG-1032 and NUREG/CR-5032.

The following figure shows the duration of LOOP events used in the Waterford 3 OSP curve, separated by type and as function of time. This data goes through the end of 1999. The grid event durations show no discernible trend. Although the weather events are longer at later times, there are too few events (5) to draw conclusions about trends. (Recall that hurricane events are not included here.) In addition, there is no reason to assume that these few data points represent a trend of lengthening durations rather than simply reflecting the randomness

of these rare events. For example, the 23 hr duration loss in 1998 was tornado at Davis-Besse. Although there are many severe tornado events every year in the U.S., it is highly unlikely that such a tornado will hit a nuclear plant. Since the return period (mean time between occurrences) for such an event is not known, the occurrence of the next such tornado event which strikes a nuclear plant cannot be predicted. In other words, it is impossible to conclude from the weather data that a trend of increasing duration is occurring.

Plant-centered LOOP events, however, do appear to exhibit a trend of increasing duration. This may reflect to some degree increases in the number of nuclear plants in operation from early (e.g., before 1975) to later (1984 and later); with a larger population of plants, it is more likely that the relatively rare long-duration plant-centered LOOPS would occur. In addition, the likelihood of plant-centered LOOP events appears to be plant-specific. Sixteen nuclear plants have experienced multiple plant-centered LOOP events; the remaining plant-centered LOOP events are shared by eighteen plants. Waterford 3 has not experienced any at power LOOP events (plant-centered or otherwise). Therefore, use of the whole set of plant-centered LOOPS, even events going back to 1965, is conservative for Waterford 3.



In summary, grid-centered events do not show an increasing duration trend in the LOOP data used for Waterford 3. Weather-centered events are too rare to be able to determine whether a trend in duration is present. Plant-centered events do exhibit a trend of increasing duration for the industry data, but Waterford 3 has not experienced any LOOP events and thus appears to have lower than average probability of a plant-centered LOOP; use of the pooled plant-centered is therefore reasonable for Waterford 3.

Finally, although NUREG-1784 indicates that LOOP durations have increased since 1997 (with deregulation), examination of the data (Table C-1) indicates that these events have occurred in the Northeast, Midwest, and West Coast—regions where deregulation has occurred. Waterford 3 is in a region where deregulation has not been significant. In Entergy's service area, for example, deregulation proposals have been cancelled or deferred as a result of problems with deregulation in other parts of the country, especially California.

Question 3:

Page 2.11-2, LOOP: Does the PRA consider consequential LOOPS (a LOOP after reactor trip caused by grid collapse due to loss of the plant's generation)? If so, provide the consequential LOOP probability, describe how it was developed, and perform a study to investigate the sensitivity of the overall PRA results to the consequential LOOP probability. If not, justify the omission.

(Staff comment: NUREG-1784 indicates that the fraction of time when the nationwide electrical grid operates in a degraded condition has increased since when deregulation of nation's electrical grid commenced in 1997, and that there [sic] an increased likelihood of suffering consequential LOOPS whenever the grid is degraded. It is not clear how the licensee's PRA has considered the impact of the proposed EPU on grid stability and grid degradation, which in turn affects the likelihood of consequential LOOP events and overall plant risk.)

Response 3:

Consequential LOOP is included in the generic LOOP frequency, which includes LOOP events at nuclear plants as a result of trips at those plants. Nevertheless, the Waterford 3 PRA includes a plant-centered consequential LOOP event based on Waterford experience with failure of the unit auxiliary transformer (UAT) to startup transformer (SUT) transfer (2 failures in 65 reactor trips). The UAT is the transformer that normally supplies plant loads from the main generator; the SUT is the transformer that supplies power to the plant from offsite (the switchyard, which is connected to the grid). After a plant trip, failure of the UAT to SUT transfer for both divisions (A and B) of AC power would produce a LOOP. Note that the two UAT to SUT transfer failures at Waterford were only partial LOOPS.

Since this UAT to SUT transfer failure event is based on actual plant experience, and models the only LOOP-related events that have actually occurred at Waterford 3, it dominates the plant-centered LOOP probability. In other words, the induced LOOP probability should be dominated by the probability of this event that has actually happened at Waterford, rather than by potential events that have not actually happened. The probability of a UAT to SUT transfer failure (partial LOOP) is $1.5E-2$. This probability is calculated as 2 failures / 130 demands, where the number of demands is 65 trips x 2 transfers (demands) per trip.

The UAT to SUT transfer failures are included in the Waterford 3 PSA as independent failures for the two divisions. Common cause failure (CCF) events are included for the SUTs and the SUT breakers, as well as the main generator lockout relays (which activate the transfer); CCF of the UAT to SUT transfer failure—which was estimated from plant data—was not included, since there was no plant-specific data with which to estimate a CCF beta factor. An estimate of the

importance of the induced LOOP, from UAT to SUT transfer failure, was made by performing a sensitivity calculation of the effect of including a common cause failure (CCF) of the UAT to SUT transfers on the risk results. Since both transfer failure events involved failure of 4.16KV breakers, the CCF type that is applicable to the transfer is 4.16KV breaker. A CCF event was added to the model in the locations of the UAT to SUT transfer failures (i.e., as inputs to the same gates). A CCF beta factor of $3.85E-2$ was used, based on NUREG/CR-5497, Table 3-2 (4160 Volt AC Breaker Fail to Close), for a $CCCG=2$. The result was to increase the pre-EPU internal events CDF from $5.522E-6$ to $6.149E-6$, an increase of 11%, and the post-EPU internal events CDF from $5.87E-6$ to $6.497E-6$. Since both pre- and post-EPU CDFs are affected equally (each is increased by $6.27E-7$), the EPU incremental core damage frequency (ICDF), which is the difference between the post- and pre-EPU CDFs, is unchanged. Thus, adding this CCF event for the UAT to SUT transfer failure has no effect on the risk associated with EPU. By extension, since the UAT to SUT transfer failure CCF dominates the consequential LOOP probability, consequential LOOP has little effect on the overall PRA results for EPU.

A final question related to consequential LOOP is whether, as suggested by NUREG-1784, there is an increased likelihood of consequential LOOP as a result of deregulation. Studies of the impact of EPU on the offsite power system have been performed, as described in the EPU submittal, Section 2.3.2.1, and the April 15, 2004, RAI response (Letter, Bradford Houston to U.S. NRC, W3F1-2004-0029, "Supplement to Amendment Request NPF-38-249, Extended Power Uprate, Waterford Steam Electric Station, Unit 3, Docket No. 50-382, License No. NPF-38," April 15, 2004), Question 2. These studies show that the transmission grid will remain stable following EPU. System stability criteria will be met even with the higher grid injection from Waterford 3 and offsite voltage will remain acceptable after a Waterford 3 trip.

Question 4:

Pages 2.11-3 and 2.11-4, Component Failure Rates: As part of the plant modification needed to implement the EPU, new digital atmospheric dump valve (ADV) controllers will be installed. However, this section indicates that no component failure rates were revised. It is not clear that the ADV failure rate for the post-EPU plant will be the same as for the pre-EPU plant. The reliability of the ADVs is important in the post-EPU plant since the licensing basis calculations indicate that the ADVs are needed to mitigate small break loss-of-coolant accidents (SBLOCAs).

Response 4:

The PRA does not use the licensing basis calculations that indicate that the ADVs are needed to mitigate SBLOCAs (see response to Question 5). In the PRA, the ADVs are NOT needed for SBLOCA success.

The Waterford 3 PRA model uses generic data (e.g., NUREG/CR-4639) for components such as controllers. This data does not distinguish between digital and analog controllers, so it is not apparent that a change in failure rate would be necessary. In addition, due to recent issues regarding the EPU SBLOCA analysis (reference Entergy letter W3F1-2004-0035 to the NRC dated May 7, 2004 for further details), Waterford 3 no longer expects to need to install digital ADV controllers. The final determination regarding the need for digital controllers will be communicated to the NRC staff by July 15, 2004. If digital ADV controllers are to be used, a detailed response to this question will be provided at that time.

Question 5:

Page 2.11-4, Success Criteria: A new Technical Specification is being added concerning ADV operability since the licensing basis thermal-hydraulic (T-H) calculations indicate that either 2 ADVs and 1 high pressure safety injection (HPSI) pump or 2 HPSI pumps are required to mitigate an SBLOCA. This section indicates that the post-EPU PRA success criteria for SBLOCAs do not include the ADVs, based on best-estimate T-H calculations performed specifically for the PRA. Why is there is such a difference between the SBLOCA success criteria for the licensing basis and the PRA?

Response 5:

The LOCA model used for the licensing basis has many conservatisms required by 10CFR50 Appendix K, including a 1.2 multiplier on decay heat. The LOCA model used for the PRA includes realistic models and input; it does not, for example, use the multiplier on decay heat. The more realistic model and inputs show that the ADVs are not required for success during a SBLOCA.

Question 6:

Page 2.11-4, Success Criteria: Please describe how the core damage frequency (CDF) contribution from anticipated transients without scram (ATWS) events is determined in the PRA by addressing the following questions:

- a. Does the PRA model of ATWS sequences consider only the reactor trip failure probability, or does it include the failure of other systems (turbine bypass, ADVs, feedwater, etc.) required to mitigate an ATWS?
- b. Were new T-H calculations of the post-EPU plant's behavior during ATWS performed to specifically support the PRA? How do the primary and secondary pressure responses during an ATWS change as a result of the EPU?
- c. How does the increase the boron concentration in the boric acid makeup tank (BAMT) affect the plant's behavior during ATWS? Is emergency boration considered in the PRA's treatment of ATWS?

Response 6:

- a. The PRA model for ATWS includes the systems needed to mitigate an ATWS. These are: (1) primary pressure relief (both pressurizer safety valves open to limit pressure increase and reclose to prevent SBLOCA); (2) emergency boration; and (3) Emergency Feedwater (EFW). Primary pressure relief includes modeling of whether moderator temperature coefficient (MTC) is adverse enough to cause overpressurization, with different critical MTC values for various combinations of turbine trip success or failure and early EFW success or failure.
- b. Yes, new T-H calculations for ATWS were performed using the CENTS code. These calculations were used to determine the critical MTC values (above which MTC is adverse enough to cause overpressurization) and the time available to start emergency boration.

Determination of the specific effect of EPU on primary and secondary pressures is not possible, because we do not have pre-EPU T-H calculations (we use a CEOG standard on ATWS modeling that was based on generic 3400MW-class T-H analysis, which is not reported in the standard). Comparison of the CEOG standard results for critical MTC with the post-EPU T-H calculation results indicates that peak RCS pressure for an MTC of $-1.8E-4$ delta-rho/deg-F increases from about 3150 psia to 3607 psia, although some of this difference may be due to methodology differences. The conclusion of the post-EPU T-H analysis is that the critical MTC is smaller (more negative). This T-H analysis has a negligible effect on the PSA model: the ATWS sequences that use the critical MTC values determined by the T-H analyses have probabilities below the $1E-10$ truncation level. ATWS risk is dominated by two scenarios—(1) ATWS with failure of 1 of 2 primary safety valves to open, leading to overpressurization of the RCS (no matter how good [negative] the MTC is); and (2) ATWS with 1 of 2 primary safety valves sticking open after relief, causing a small LOCA, which is conservatively assumed to cause core damage even with safety injection, because of the core power level. In neither of these scenarios is T-H modeling used; they are both assumed to lead to core damage.

c. The post-EPU T-H analysis included consideration of emergency boration. This analysis conservatively used the pre-EPU minimum boric acid concentration of 3950 ppm instead of the proposed post-EPU minimum concentration of 4900 ppm. Inclusion of this 4900 ppm boron concentration in the post-EPU T-H analysis would improve the predicted plant response. The risk contribution of the emergency boration failure ATWS sequence is very small, below the $1E-10$ truncation.

Question 7:

Page 2.11-4, Success Criteria: This section indicates that new T-H calculations were performed for the PRA using the CENTS code. In general, NRC has approved use of the CENTS code for transient analyses. It is not approved for demonstrating compliance with Section 50.46 of Title 10 of the *Code of Federal Regulations* criteria; however, it is acceptable for use in modeling SBLOCAs (including steam generator tube ruptures - SGTRs) for the purpose of demonstrating compliance to non-LOCA regulatory acceptance criteria. Were new T-H calculations made using CENTS to determine PRA success criteria and operator action timings for medium and large LOCAs? If so, please justify. Also, define the term "core-damage" as used in the PRA and explain how the results of T-H calculations were interpreted to determine whether or not core-damage occurred.

Response 7:

CENTS was not used for medium and large LOCA success criteria and operator action timings; it was only used for the non-LOCA transients (including SGTR). CEFLASH-4AS/PARCH was used for small and medium LOCAs. The licensing-basis large LOCA thermal-hydraulic results were used for the large LOCA sequences.

For non-LOCA transients, core uncover is conservatively assumed to be equivalent to core damage, i.e., core damage is defined as core uncover. For LOCAs, core damage is conservatively assumed to occur when the peak clad temperature reaches 2200 deg-F.

Question 8:

Pages 2.11-6 and 2.11-7, Table 2.11-1, Impact of EPU on human reliability analysis Time Available: Please update this table to include the human failure event probabilities in the pre- and post-EPU PRA models, and the Fussell-Vesely importance measures and the risk achievement worths for the post-EPU PRA model.

Response 8:

The pre-EPU and post-EPU human failure event (HFE) probabilities and post-EPU Fussell-Vesely and risk achievement worth (RAW) importances are shown in the following table. (In the table, "Existing" = pre-EPU and "EPU" = post-EPU.) Some of the HFEs do not appear in the cut sets and thus do not have importance values; these HFEs were adjusted in the model and included in the EPU submittal for completeness. Note that in many cases the post-EPU HFE probability is lower than the pre-EPU probability; the reason for this is that the pre-EPU times are based on more conservative thermal-hydraulic analyses than realistic thermal-analyses performed for the post-EPU case using the CENTS and CEFLASH codes.

The determination of the risk importance of many of the HFEs was complicated by the use of combination events in the Waterford 3 PRA. Since many individual operator actions exhibit dependency when performed close in time (i.e., the HFE probabilities are not independent, but are dependent on the failure of preceding actions), multiple HFEs in a single cut set are replaced by a single combination HFE that has a probability representing the combined probability of failure of the individual HFEs considering their potential dependency. In other words, multiple independent HFEs are not allowed in a cut set. The individual HFE risk importance values in the following table use the maximum importance value for the HFE either individually or in a combination event. In cases where the importance value is taken from the combination event importance, the importance of the individual HFE within that combination event may be overestimated. Importance values that were taken from the combination event importance are shown in bold italics.

In the calculation of the risk impact of EPU, it was found that the changes in HFE probabilities shown in the following table had a very small effect on CDF. Making the changes shown in the table changed the overall Level 1 internal events CDF from 6.732E-6 to 6.729E-6, or a decrease of 3E-9 (as noted above, many of the HFE probabilities are lower for the post-EPU CDF calculation because of the more realistic thermal-hydraulic analyses). Use of realistic pre-PU times (e.g., via use of thermal-hydraulic methods comparable to the post-EPU calculation) would not be expected to produce a significant CDF delta for HFE changes only. The risk impact of EPU is dominated by the changes in LOOP non-recovery probabilities, which were calculated using consistent pre- and post-EPU thermal-hydraulic model times.

Impact of EPU on HRA Time Available

<i>Event Name</i>	<i>Description</i>	<i>Existing Time Available</i>	<i>Existing HFE Probability</i>	<i>EPU Time Available</i>	<i>EPU HFE Probability</i>	<i>EPU HFE Fussell-Vesely</i>	<i>EPU HFE RAW</i>
EHFALPABMP	Failure to energize bus 3AB3-S from bus opposite initial supply	40 min	7.6E-1	2.83 min (Note 1)	1.0	N/A (Note 2)	N/A
EHFALPABSP	Failure to energize bus 3AB3-S from bus opposite initial supply	60 min	1.1E-1	14 min	1.0	1.34E-2	1.01
EHFMANTRNP	Failure to transfer loads to startup transformers when auto transfer fails	50 min	8.6E-2	68.3 min	3.2E-2	2.49E-3	1.61
EHFMTRNLTP	Failure to transfer loads to startup transformers when auto transfer fails, with long time available	9 hr	4.1E-5	14 hr	4.1E-5 (Note 3)	2.16E-4 (Note 4)	2150
EHF-TEDG-P	Failure to Start/Align/Load TEDG	50 min	1.8E-2	68.3 min	5.8E-3	N/A (Note 5)	N/A
HHFALNABMP	Failure to align HPSI pump AB to replace pump A or B following medium LOCA	40 min	4.4E-1	2.83 min (Note 1)	1.0	8.56E-3	1.0
HHFALNABSP	Failure to align HPSI pump AB to replace pump A or B following small LOCA or SGTR	60 min	4.9E-2	14 min	1.0	4.00E-3	1.0

1 The 2.83 min time available does not include the effect of the safety injection tanks, which would extend this time.

2 Not in cut sets.

3 HFE probability is based on cause-based calculation (not time-dependent); time-dependent probability is below 1E-5, due to long time available.

4 In combination with QHFCSPMPP (Failure to make up to CSP from CST) and QHFCSPWCTP (Failure to switch EFW suction to ACCW).

5 Temporary emergency diesel generator (TEDG) not used in EPU model; only applicable to EOOS risk monitor for TEDG configuration.

Impact of EPU on HRA Time Available (cont.)

<i>Event Name</i>	<i>Description</i>	<i>Existing Time Available</i>	<i>Existing HFE Probability</i>	<i>EPU Time Available</i>	<i>EPU HFE Probability</i>	<i>EPU HFE Fussell-Vesely</i>	<i>EPU HFE RAW</i>
IHFSTCOMPP	Failure to Restart Instrument Air Compressor after fast transfer failure	50 min	7.5E-3	68.3 min	1.0E-3 (Note 6)	2.30E-5	1.0
NHFCDMKUPP	Failure to make up to condenser hotwell from CST when automatic makeup fails	50 min	3.9E-2	68.3 min	3.5E-2	N/A (Note 2)	N/A
OHFCONDSTP	Failure to attempt to restore feed to steam generators via condensate pumps	50 min	1.2E-1	68.3 min	7.5E-3	6.72E-4 (Note 7)	323.7
OHFRELTFWP	Failure to attempt to restore feedwater (e.g., via auxiliary feedwater) after late loss of EFW	9 hr	6.5E-5	14 hr	1.0E-5 (Note 3)	1.93E-3 (Note 8)	18,600
OHFRESTFWP	Failure to attempt to restore feedwater (e.g., via auxiliary feedwater)	50 min	9.2E-3	68.3 min	1.8E-3	2.61E-3	2.45

6 Screening value of 1.0 was used.

7 In combination with QHFCSPPEMPP (Failure to align CSP makeup) and QHFCSPWCTP (Failure to switch EFW suction to ACCW).

8 In combination with QHFCSPPEMPP (Failure to make up to CSP from CST) and QHFCSPWCTP (Failure to switch EFW suction to ACCW).

Impact of EPU on HRA Time Available (cont.)

<i>Event Name</i>	<i>Description</i>	<i>Existing Time Available</i>	<i>Existing HFE Probability</i>	<i>EPU Time Available</i>	<i>EPU HFE Probability</i>	<i>EPU HFE Fussell-Vesely</i>	<i>EPU HFE RAW</i>
PHFMFIVOPP	Failure to unisolate MFW to allow feeding steam generators after MSIS	50 min	1.4E-2	68.3 min	1.7E-3	1.82E-4	1740
PHFSGTRBDP	Failure to blow down steam generator to prevent overfilling affected generator	60 min	1.5E-2	>24 hr	7.5E-3	8.94E-4	1.12
QHFCSPEMPP	Failure to align makeup to CSP during EFW operation	9 hr	3.0E-5	9.33 hr	3.0E-5 (Note 3)	1.33E-3 (Note 9)	18,600 (Note 10)
QHFCSPWCTP	Failure to align suction to EFW from WCT after CSP depletion	9 hr	3.1E-3	14 hr	3.1E-3 (Note 3)	3.19E-3	18,600 (Note 11)
RHFSTCVCPP	Failure to start charging pumps to provide backup injection following SGTR	60 min	1.1E-3	3 hr (assumed)	5.1E-4	N/A (Note 2)	N/A

9 In combination with QHFCSPWCTP (Failure to switch EFW suction to ACCW).

10 In combination with QHFCSPWCTP (Failure to switch EFW suction to ACCW) and OHFRELTFWP (Failure to establish backup feedwater flow from AFW).

11 In combination with QHFCSPEMPP (Failure to make up to CSP from CST) and OHFRELTFWP (Failure to establish backup feedwater flow from AFW).

Question 9:

Page 2.11-7, LOOP Recovery: Please provide additional details about the convolution approach used to conduct the LOOP recovery analysis. Using the internal events post-EPU PRA model, conduct a sensitivity analysis to assess the impact of the convolution approach on the results by determining the CDF before any LOOP recoveries are considered.

Response 9:

The LOOP convolution recovery process is used to model recovery of offsite power (OSP). OSP recovery actions are modeled by adding OSP non-recovery events to the LOOP-initiated cut sets, automatically (using the QRecover software) according to pre-defined rules.

PRA model basic events may be sorted into two distinct types according to how their probabilities are determined:

1. Type-1 Events: Time-dependent failures occurring prior to the initiator or time-independent failures occurring at the start of or during the accident. Type-1 events include both standby failures (e.g., "normally-open valve transfers closed prior to a demand") and demand failures (e.g., "pump fails to start on demand" or "pump unavailable due to maintenance"). The probability of a Type-1 event does not depend on the timing of other events in the cut set or the duration of the accident. Operator failures, whether prior to or during the accident, are considered Type-1 events since they are assumed to be independent of the duration of the accident.
2. Type-2 Events: Time-dependent failure occurring during the accident (e.g., "diesel generator fails to continue running" and "OSP not recovered before battery depletion"). The probabilities of Type-2 events depend on the timing of other Type-2 events in the cut set and on the accident duration.

The probabilities of almost all Type-2 events are calculated by assuming that equipment has a constant failure rate. Under this assumption, the time to failure has an exponential distribution and the probability of failure over the interval $[0, T_m]$ is given by:

$$\Pr\{\text{Type} - 2 \text{ event}\} = 1 - \exp(-\lambda T_m)$$

where λ denotes the constant failure rate. The quantity T_m is called the mission time, which is usually assumed to be 24 hours in PRA. The notable exception to the assumption of constant failure rates is OSP recovery since the recovery time is described by a mixture of Weibull distributions.

With respect to cut sets initiated by LOOP and containing run failures, it is difficult to select an appropriate mission time. Following LOOP, the standby diesel generators start and supply emergency electrical power to systems that ensure adequate core cooling. These diesel generators only need to run until OSP is recovered. However, the time when OSP is recovered is random, described by the mixture of Weibull distributions. Therefore, it is not possible to

select a characteristic mission time for direct substitution into the above failure probability equation.

The convolution approach consists of integrating (or convoluting) the product of the probability density functions (pdfs) associated with the run failures in a given cut set with the OSP non-recovery probability. The convolution integral equals the mean probability that OSP is not recovered in time to prevent core damage for the given cut set. In a broad sense, the convolution process may be viewed as a time-averaging approach.

Convolution can be understood by considering a hypothetical plant having a single diesel generator. It is assumed that core damage will occur if a LOOP initiating event occurs, the diesel generator fails to run, and OSP is not recovered within T_c hours after the diesel generator fails. The quantity T_c is the time required to boil away the primary inventory following a total loss of AC power. This cut set might be represented by:

$$\text{cut set} = \text{LOOP} * \text{DGR} * \text{NROSP}$$

in which LOOP is the LOOP initiator, DGR is the diesel run failure event, and NROSP is the non-recovery of OSP in time to prevent core damage.

The frequency of this cut set is given by:

$$f(\text{cut set}) = f(\text{LOOP}) \times P(\text{DGR} * \text{NROSP})$$

The convolution approach is based on understanding the timing interactions of Type-2 events in cut sets. For this simple example it is convenient to define a loss of off-site power recovery factor (RLOSP), given by:

$$RLOSP = \frac{P(\text{DGR} * \text{NROSP})}{P(\text{DGR})} = \frac{\int_0^{\infty} \lambda e^{-\lambda t_D} G(t_D + t_c) dt_D}{1 - e^{-\lambda t_c}}$$

That is, RLOSP is the numerical value assigned to the OSP non-recovery event in the cut set. In the above example, RLOSP is used to determine the cut set frequency as follows:

$$f(\text{cut set}) = f(\text{LOSP}) \times P(\text{DGR} * \text{NROSP}) = f(\text{LOSP}) \times P(\text{DGR}) \times RLOSP$$

The simple example given above may be generalized to address all types of cut sets initiated by LOOP. The frequency of a cut set initiated by LOOP is given by:

$$f(\text{cut set}) = f(\text{LOSP}) \times \left(\prod_{i=1}^m P_i \right) \times \int_R \int \cdots \int \left(\prod_{j=1}^n f_j(t_j) \right) g(t_R) dt_1 dt_2 \cdots dt_n dt_R$$


where:

- f(LOSP) = LOSP frequency
- P_i = failure probability of the i th Type – 1 event
- m = number of Type – 1 events in the cut set
- $f_j(t_j)$ = pdf of the j th Type – 2 event
- t_j = time when the j th Type – 2 event occurs
- n = number of Type – 2 events in the cut set
- $g(t_R)$ = pdf of OSP recovery
- t_R = time when LOSP recovery occurs


The general LOOP recovery factor, RLOSP, is defined as:

$$RLOSP = \frac{\int \int \dots \int \left(\prod_{j=1}^n f_j(t_j) \right) g(t_R) dt_1 dt_2 \dots dt_n dt_R}{\prod_{j=1}^n \int_0^{T_m} f_j(t_j) dt_j}$$

The number of iterated integrals in these equations equals $n + 1$, where n is the number of Type-2 time-dependent failures in the cut set. The additional integral is for the time-dependent LOOP pdf. Note that the integration region, R , is not specified above. The upper and lower limits of each of the iterated integrals may be determined by inspection for each permutation of Type-2 events in the cut set. It is often useful to establish these integration limits by drawing a “time line” for each cut set permutation. The time line provides a means of accounting for timing dependencies that occur between Type-2 events occurring in the cut set. Two example time lines for a simple station blackout cut set follow.



The assumed order of failure is MDEFWP-B, followed by TDEFWP-AB. Core damage occurs if the time when offsite is recovered exceeds the sum of the TDEFWP failure time and the core uncovery time:
 $t_B < t_T$
 $t_R > t_T + t_C \Rightarrow$ core damage



In these time lines, %T5 = LOOP initiator, TDEFW-AB FTR = turbine-driven EFW pump fails to run, and MDEFW-B FTR = motor-driven EFW pump B fails to run.

Quantification of the convolution integral requires specification of the integration limits. However, since there are two possible ways of ordering the timing of the Type-2 events in this example, this quantification requires separate assessment of each ordered case. The two ordered cases are as follows:

$$\begin{aligned} & \%T5 * QMMPPASTRF * QMMPPBRUNF * QTP3PMPABF * ZLOOP_D2 \\ & \%T5 * QMMPPASTRF * QTP3PMPABF * QMMPPBRUNF * ZLOOP_D2 \end{aligned}$$

For both cases, by definition, both the LOOP initiator (%T5) and the MDEFW Pump A failure to start (QMMPPASTRF) event occur at the beginning of the accident. In Case 1, MDEFW Pump B fails to run (QMMPPBRUNF) prior to the TDEFW Pump AB's failure to run (QTP3PMPABFF); in Case 2, TDEFW Pump AB fails to run prior to MDEFW Pump B's failure to run. Since recovery of offsite power terminates the accident, event ZLOOP_D2 (OSP non-recovery) is always placed at the end of the cut set.

Since these permutations define all possible failure-timing combinations and since they are mutually exclusive, the convolution integral for the cut set equals the sum of the convolution integrals associated with its possible permutations. Thus,

$$\begin{aligned} I_{CS} &= P(\text{1st cut set ordering}) + P(\text{2nd cut set ordering}) \\ &= I_{CS1} + I_{CS2} \end{aligned}$$

The last step in the LOOP recovery analysis consists of creating rules for use by QRecover (a post-processor for cut set files that adds recovery events according to user-defined rules). QRecover works by examining each cut set for the presence of basic event combinations, i.e., the LOOP initiator and various combinations of Type-1 and Type-2 basic events. If a basic event combination for which an OSP non-recovery factor is defined (and included in the rules) is present in the cut set, then the associated non-recovery event is added to the cut set.

To determine the sensitivity of the EPU risk assessment result to the LOOP recoveries (OSP non-recovery events), the ZLOOP events (OSP non-recovery events) in the post-EPU cut sets were set to TRUE. When this was done, the post-EPU CDF increased from 5.87E-6 to 9.21E-5. Setting all the ZLOOP events to TRUE is extremely unrealistic, because it has the effect of modeling LOOP events as never recovered, i.e., after a LOOP initiator, offsite power is never restored. A more realistic sensitivity calculation is to increase the ZLOOP event (non-recovery) probabilities by 50%. This increases EPU CDF from 5.87E-6 to 6.81E-6, or a 16% increase.

Question 10:

Pages 2.11-8 through 2.11-10, Level 1 Internal Events Results: Do the results for the internal events PRAs (pre- and post-EPU) include the contribution from internal floods? If not, please provide them.

Response 10:

The submittal does not include internal flooding, since the internal flood analysis (summarized in the IPE submittal in response to Generic Letter 88-20 in August of 1992) used a conservative screening approach that is not affected by power uprate changes. The CDF total for unscreened areas was 1.9E-6. Note that screened scenarios are not included in the CDF total because the CDF values for these scenarios are very conservative, because of the very conservative nature of the screening process. There were four unscreened flooding scenarios. Each one will be discussed in terms of the possible impact of power uprate.

1. Control Room. The flood source, potable water pipes in the control room, is assumed to flood the control room envelope and to propagate and fill the lowest elevation of the reactor auxiliary building (RAB), including safety injection and emergency feedwater pumps (which is assumed to cause core damage without recoveries). This scenario includes 3 operator recoveries, none of which is affected by the power uprate timing changes described for the internal events PRA: (1) isolation of the flood before equipment outside the control room is damaged; timing of the action is dependent on the flooding rate, which has no dependence on power uprate; (2) replenishment of the emergency feedwater water source; this is equivalent to QHFCSPEMPP or QHFCSPWCTP in the internal events model (see response to Question 8), which are not affected by power uprate; (3) tripping the reactor coolant pumps following loss of seal cooling; this is a function of the time to seal failure, which is independent of power uprate.
2. Control Room Emergency Living Quarters. The final CDF for this scenario was 2E-10, which is negligible.
3. RAB-31 (-4 elevation corridors and passageways). This flood is assumed to fill the RAB to the +21 elevation (grade elevation), at which elevation the flood water would flow out of the RAB to the surroundings. An operator action is included to isolate the flood before the flood elevation reaches +21, thus sparing some essential equipment (e.g., switchgear) from flooding. The timing of this action is dependent on the flooding rate, which has no dependence on power uprate.
4. RAB-32 (-35 elevation pipe penetrations and auxiliary component cooling water pumps). This flood is also assumed to fill the RAB to the +21 elevation (grade elevation). An

operator action is included to isolate the flood before the flood elevation reaches +21, thus sparing some essential equipment (e.g., switchgear) from flooding. The timing of this action is dependent on the flooding rate, which has no dependence on power uprate.

Since the flooding analysis is not affected by the EPU timing changes described in the response to Question 8, there is no significant effect of EPU on internal flooding risk.

The flooding analysis used a very coarse method. Flood frequencies were estimated based on gross piping densities. Consequences were estimated by assuming massive flooding of whole floor elevations. Ex-control room operator actions that would have to occur in the flooded areas were assumed failed. No plant design changes since the flooding analysis could affect the analysis. The most significant design change, from a PRA standpoint, that has been made over the years was a change to the operator type (from air operated to motor operated) for the safety injection suction isolation valves from containment; since either operator type is assumed failed under flood conditions, the design change has no effect on the flooding analysis. Other design changes are much less significant and would not affect the flooding analysis.

Question 11:

Page 2.11-16, Evaluation of Probabilistic Safety Assessment (PSA) Model Quality: This section states "A peer review of the individual plant examination results was performed." Confirm that the peer review cited in this statement refers to the peer review done in January 2000 using the Combustion Engineering Owner's Group approach. Provide a list of A-level (4 of 19) and B-level (20 of 80) comments that have not yet been addressed.

Response 11:

The peer review of the individual plant examination (IPE) is not the same as the January 2000 owners group peer review. The IPE was subjected to a number of reviews. In addition to normal engineering and cross-discipline reviews, the IPE received a peer review by PRA experts from a PRA consultant, and comments addressed, prior to its August 1992 submittal to NRC. The NRC review of the IPE, transmitted to Waterford 3 in March 1997, identified a number of weaknesses. All of the weaknesses in the Level 1 analysis (with one exception noted below) were addressed by the June 2003 model update, which included major updating and upgrading of data analysis, common cause failure modeling, LOOP recovery modeling, and human reliability analysis methods and modeling. (NRC comments on the Level 2 are not applicable to the EPU submittal because a conservative LERF calculation, not affected by the Level 2 comments, was used.) The NRC identified a lack of simulator exercises for in-control room operator response times and walkdowns for ex-control room times. Current PRA quality standards identify either walkthroughs, talkthroughs (detailed procedure reviews with operators), or simulator observations as acceptable bases for operator response times (ASME PRA Standard, Supporting Requirement HR-G5, Categories II & III). The Waterford 3 PRA used operator talkthroughs for all post-initiator operator actions.

Most of the A and B comments from the January 2000 owners group peer review were addressed by the June 2003 model update. The remaining open A and B peer review comments are listed in the below table, with explanation as to why they do not impact the EPU risk assessment. Note that, since the EPU submittal was prepared, two peer review comments

(one A and one B) have been closed; thus, there are 3 open A and 19 open B comments in the following table.

Peer Review F&O No.	Change Request Text	Peer Review Priority	Impact on EPU Calculation
IE-09	<p>WSES used primarily generic initiating event frequencies and did not use Bayesian update to include plant specific experience. WSES did make limited use of plant data for selected events but has not updated this data in several years. There is no evidence that WSES has process for reviewing industry precursors or events to ensure that they are addressed in the Waterford 3 PSA.</p> <p>WSES needs to update the initiating frequencies to reflect the latest Waterford 3 operating experience. A program to review industry events for applicability to Waterford should also be instituted.</p>	B	<p>IE analysis was completely re-done, including use of Bayesian update to include plant-specific experience. Comment is open because we have no program to review industry events for applicability to Waterford, although industry experience was used (via the use of generic data from NUREG/CR-5750).</p> <p>The Waterford PSA was updated to "reflect the latest Waterford 3 operating experience", where possible, and included industry generic experience. There is no current requirement (e.g., in the ASME PRA standard) to continually review operating experience; this is done during the periodic model update.</p>
AS-07	<p>WSES does not model simultaneous hot leg and cold leg injection for core flush. Based on early information, WSES estimated that core flush would not be needed for at least 24 hours, so its failure potential was negligible and it did not need to be modeled. However, in the Long Term Cooling Analysis as discussed in sections 6.3.1.4.2, 6.3.2.9.5 and 6.3.3.4 of the FSAR, core flush needs to be established between 2 and 4 hours post-LOCA for successful long term cooling. Figure 6.3-11 shows that if core flush is initiated at 4 hours, a HPSI core flush flow of approximately 275 gpm</p>	B	<p>This comment does not significantly affect the EPU calculation because hot leg injection does not have a significant effect on CDF. Hot leg injection is probably needed for large LOCA (and possibly medium LOCA) to prevent core damage, but these initiators are not significant contributors to CDF.</p>

Peer Review F&O No.	Change Request Text	Peer Review Priority	Impact on EPU Calculation
	<p>is needed to prevent boron precipitation.</p> <p>Simultaneous hot and cold leg injection needs to be modeled for large LOCAs. The need for hot leg injection for medium LOCAs should be evaluated using the information on figure 6.3-12 in the FSAR.</p>		
AS-08	<p>EFW fault-tree shows that EFAS-1 signal is required for SG-1 and SG-2 flow paths to be effective (page 269). No power dependencies are modeled associated with the generation of this signal.</p> <p>Add the appropriate dependencies for generation of the EFAS-1 signal.</p>	B	<p>The potential impact of this comment is small because the addition of power dependency for EFAS should not have a significant effect. The EFAS failure rate is low and power dependency (at the DC bus level) already exists for the pumps.</p>
AS-11	<p>Grid challenge as a result of a transient is not considered. Section 7.0 of EC-589-025, PRA Accident Sequence and Top Logic, states that for SBO "... it can also be initiated by any reactor trip event combined with a failure in the Waterford 3 switchyard to connect to offsite power." These induced LOOPS are only associated with the switchyard. Induced LOOPS other than the switchyard are not considered.</p> <p>Address induced LOOP events.</p>	B	<p>This comment is addressed in the response to Question 3 of this RAI.</p>
AS-16	<p>Plant specific T/H [thermal-hydraulic] analyses to support accident sequence development are virtually non-existent. Thermal-hydraulic calculations are needed for determination of system/function success for accident sequence analysis. Realistic, plant-specific best estimate analyses provide the best information and results in the most accurate risk insights. The analyses performed for the FSAR are conservative and, in some cases, would tend to bias the risk insights somewhat.</p>	B	<p>Plant-specific T/H analyses were performed using the CENTS and CEFLASH codes for EPU. This comment applies to the base PRA model, which will be updated with the results of the EPU T/H analyses when EPU is implemented.</p>

Peer Review F&O No.	Change Request Text	Peer Review Priority	Impact on EPU Calculation
	<p>However, in other cases, the differences between the FSAR and best estimate analyses are masked by the level of detail possible in the PSA models. (e. g. TH analyses can differentiate the lbn delivery of safety pumps, but the PSA will only model pumps in whole units.) Also available is an extensive body of generic TH analyses related to the performance of various plants in response to various challenges. These generic analyses can provide valuable insights and can be used to the extent that they can be demonstrated to be applicable to the plant in question.</p>		
TH-02	<p>A review of the TH analyses performed for SGTR, as referenced in EC-S89-025, R1, showed that the version of the CEPAC code used in these analyses (EC-S90-002, EC-S90-003 and EC-S90-004) was plant specific and limitations of the code were assessed (See EC-S88-014). MAAP was used for several calculations using a WSES specific base deck. However, there was no formally documented assessment of the applicability of MAAP for the application or assessment of limitations. (Note: Per discussions with Nasser Pazooki, MAAP output for containment pressure was informally compared to design basis calculations and found to be somewhat conservative. This comparison was not documented.)</p> <p>Where non-Design basis codes are used to determine parameters for the PSA, there should be some formal assessment of the applicability of the code for the intended application and an assessment of how any known code limitations might affect the results and conclusions.</p>	B	<p>The CENTS code was used for SGTR in the EPU calculation. MAAP was used in the base PRA (as referred to in this comment) only for Level 2, which is not used for the EPU calculation (a conservative LERF calculation was used).</p>

Peer Review F&O No.	Change Request Text	Peer Review Priority	Impact on EPU Calculation
TH-03	<p>No Room Heatup calculations were performed to support decisions with respect to the need for room cooling.</p> <p>This item was identified by the WSES self-assessment.</p> <p>Room heat up calculations need to be performed to support the modeling decisions with respect to the need for room cooling during accident mitigation and to determine timing for human actions as needed.</p>	B	<p>Room heatup calculations have been performed, documented, and reviewed for reasonableness. The comment is open because final review and approval is not completed.</p>
TH-04	<p>The CEPAC T-H analyses that were referenced and reviewed (see EC-S90-001 through EC-S-90-004) were formal calculations that included independent review and signoff. However, the MAAP analyses were less formal and did not appear to include an independent review and signoff.</p> <p>T-H analyses used to support the PRA should have an independent review to ensure that the results are appropriate and defensible.</p>	B	<p>T/H analyses for EPU were formally documented in calculations, with independent review.</p>
SY-10	<p>The following Safety-Related Room Cooling System success criteria do not have technical calculations to support the assumptions:</p> <p>It is assumed that the heat load in the A, B and AB Battery Rooms and EFW Turbine Driven Pump "room" is no higher than the design basis SBO for all postulated severe accident sequences.</p> <p>Dependence on room cooling for HPSI, LPSI and Containment Spray is not necessary during injection mode.</p> <p>Cooling is not needed for CCW heat</p>	B	<p>Room heatup calculations have been performed, documented, and reviewed for reasonableness. The comment is open because final review and approval is not completed.</p>

Peer Review F&O No.	Change Request Text	Peer Review Priority	Impact on EPU Calculation
	<p>exchanger rooms A and B.</p> <p>Provide better justification for exclusion of HVAC requirements.</p>		
SY-11	<p>The PRA model credits recovery from a SBO event. Following recovery, it is assumed that safety related loads would be re-established and perform their intended function including Containment Heat removal (CS and CFCs). However, the CFCs could fail after EFW recovery due to harsh containment environment not analyzed beyond the design basis accident. During that portion of the SBO event where decay heat removal is lost, the PSVs will cycle to removal heat from the RCS. This will cause the pressure and temperature in containment to rise. Without CFCs and CSPs, it is unknown how high temperature and pressure will rise. This environment could cause the actuation of MSIS or in an extreme case cause the failure of the CFCs due to a harsh environment.</p> <p>The Level 1 accident sequence analysis requires either one train of CSS or one train of CFC during re-circulation.</p> <p>CEN-239 states the PSVs open within 12 minutes of a total loss of feed water and do not re-close until 53 minutes of the total loss of feed (pg. 273).</p> <p>General Comment: MAAP results for large break LOCA with only 1 CFC credited (Calculation W3C1-92-0014) shows design containment pressure is exceeded. If the CFCs can not withstand the harsh environment beyond design capacity, the CFCs can not be credited for the applicable sequences in which equipment qualification limits of the</p>	B	<p>The SBO sequence does not assume that containment heat removal (CHR) is available. The effect of CHR failure for SBO sequences that are recovered before core damage would be, worst case, containment failure, but without core damage, this would not be a large release. For SBO sequences that go to core damage, CHR is not credited and containment failure is assumed in the EPU LERF calculation with a conservative probability of 0.1 (this probability is realistically on the order of 0.02, based on NUREG/CR-6595 and NUREG/CR-6475).</p> <p>The Level 1 requirement for CHR is to prevent containment failure, sudden containment depressurization, and loss of safety injection NPSH during successful safety injection recirculation—leading to safety injection failure and core damage. This would require, in addition to CFC failure, failure of both containment spray trains; since the harsh environment in containment can not affect containment spray (no operating parts inside containment; rated head of 485 feet is more than enough for any containment</p>

Peer Review F&O No.	Change Request Text	Peer Review Priority	Impact on EPU Calculation
	CFCs are exceeded.		overpressure condition), it is very unlikely that this would happen, so this issue does not significantly affect the CDF calculation.
SY-13	<p>The Waterford Data Notebook, which is not a controlled document, uses component boundaries defined by SAIC "Generic Data Notebook for Commercial Nuclear Power Plant PRA". The data notebook which uses the SAICs definition of control circuitry and associated failure event codes is misleading as the Waterford PRA does not explicitly model associated control circuit failure for valves, pumps and other motive devices. A review of a cross section of the fault trees revealed that control circuit failures are not included as separate events. Determination that systems adequately modeled relevant control circuitry is not possible without the reference to basis of the generic data.</p> <p>Verify and document if generic data utilized in the model includes control circuit faults. If generic data does not include control circuit faults, update data or explicitly model control circuits.</p>	B	<p>This MCR appears to no longer be applicable. The two primary generic data sources for the Rev. 3 (current) model, NUREG/CR-4550 and NUREG/CR-4639, include start/control circuits in their valve/pump control circuits. There are a handful of generic data failure modes that rely on IEEE 500, for which I don't know whether control circuits are included, but these are either components for which the issue is irrelevant (e.g., electronic components) or for which control circuit failures would be included in other failure modes that used the two primary references. The plant specific failure data also includes control circuits, because it is based on the maintenance rule, for which the system engineers include such failures as a valve or pump failure. This comment was left open until documentation of this basis is completed.</p>
SY-17	<p>The basis for the system dependencies should be directly linked to plant documentation. Currently, the plant documentation is listed in mass at the end of a system notebook.</p> <p>It would be a simple matter to expand the component level dependency matrix to</p>	B	<p>This is a documentation problem, which does not affect the EPU calculation.</p>

Peer Review F&O No.	Change Request Text	Peer Review Priority	Impact on EPU Calculation
	include a reference column where the specific plant document can be listed.		
SY-18	<p>In many cases, the basis for assumptions and success criteria are not listed in the system analysis calculation, EC-S99-002. In the EFW system, there is no reference directly linked to the statement that 50 minutes is available to recover a feed loss. The time available to recover from a feed loss depends on the type of transient. The plant could trip on high, normal, or low SG water level. An EFW assumption is flow diversion through locked valve EFW220 is not modeled, but the plant document which shows this valve is locked shut is not directly referenced.</p> <p>Directly identify references.</p>	B	This is a documentation problem, which does not affect the EPU calculation.
DA-03	<p>There are a few cases (e.g. sump suction check valves), where a per demand failure rate rather than time dependent failure rate is used.</p> <p>WSES should consider modifying demand failure rates to address test interval differences among like components.</p>	B	<p>Actually, most components are modeled with demand failures. What the peer reviewers were talking about were components with very long surveillance intervals, for which the long time between tests could produce significant standby failure probabilities. The sump suction check valve (SI-604A/B) case was the only one they observed.</p> <p>The CDF impact is very small (estimated to be on the order of 4E-8, which is negligible). Since the SI sump suction valves are some of the most risk significant components, other components that might be found to have the same concern with long surveillance intervals would also experience a negligible</p>

Peer Review F&O No.	Change Request Text	Peer Review Priority	Impact on EPU Calculation
			impact if the demand failure model were changed to a standby model.
DE-01	<p>Dependency Matrices can be a valuable tool for reviewers both internal and external to quickly identify system relations. Although a component level dependency matrix is provided for each system. A matrix that readily links cross system dependencies (including IE impacts) is not available.</p> <p>Develop Comprehensive Dependency Matrix. The DBDs can provide a great deal of readily available useful information.</p>	B	This is a documentation problem, which does not affect the EPU calculation.
DE-05	<p>Modeling assumptions and dependencies are not directly linked to plant documentation. For example, High Pressure Injection is assumed not to fail even if the RWSP suction valves are not isolated following RAS. It is possible that the references (pg. 9-6) provide the basis for this assumption, but it is difficult to determine which reference and the location within the reference. Given the analysts has done the research to prove this, it is a simple matter to list the reference within the assumption text and note the significant pages.</p> <p>This is also useful in the system dependency matrix. It would aid in the review to list the specific reference associated with each identified component dependency.</p> <p>Directly link references to plant documentation.</p>	B	This is a documentation problem, which does not affect the EPU calculation.
ST-02	WSES uses a hand calculation for the pressure ratio at yield to determine the containment ultimate failure yielding a	B	The EPU calculation does not use the Level 2. The simplified LERF method used

Peer Review F&O No.	Change Request Text	Peer Review Priority	Impact on EPU Calculation
	<p>P/Pd in the range of between 2.05 and 3.78. A P/Pd value of 3.08 was selected. Although the resulting ultimate pressure appears reasonable, there was limited justification for the selection of this value.</p> <p>Given the ultimate pressure, the containment failure fragility curve was developed based on the guidance in NUREG/CR-3653.</p> <p>The containment failure model does not address the most likely failure location.</p> <p>WSES needs to provide appropriate justification for the P/Pd ratio that was selected to ensure that the calculated ultimate pressure is appropriate. WSES also needs to address the most likely location of the containment failure should one occur.</p>		<p>for the EPU calculation does not use the containment ultimate pressure.</p>
QU-02	<p>Per discussions with two Waterford PRA engineers, the base computer code (CAFTA) has not been formally verified and validated. This process would include solution of a known input and comparing the outputs with known solutions. Also, the known input would challenge various features of the code such that all such features can be verified to be working properly.</p> <p>In addition, installation of CAFTA on individual workstations are not verified and validated.</p>	B	<p>Waterford now uses the qualified (verified and validated) version of Cafta (4.0b) and has tested PRAQUANT. The comment is left open because a fully qualified PRAQUANT version is not yet available.</p>
QU-06	<p>No evidence of uncertainty analysis has been performed. This is confirmed by Waterford.</p> <p>Include uncertainty analysis in next update.</p>	B	<p>This does not impact the EPU calculation of ICDF.</p>

Peer Review F&O No.	Change Request Text	Peer Review Priority	Impact on EPU Calculation
L2-01	<p>It is recognized that the L2 bridging and binning process and the resulting PDS endpoints may have been sufficient for IPE submittal. Since the IPE submittal, the PDS model has not been maintained or reviewed to determine the impact of revisions made to other PRA models. It would be extremely difficult to reproduce the base case results and to ensure the adequacy of changes from start to finish with the current documentation. References to gate names and functional events and calculation cross-references are not current or traceable for revisions made to the level 1 model.</p>	A	<p>The EPU calculation does not use the Level 2. The simplified, conservative LERF method used for the EPU calculation does not use PDS mappings, but uses core damage sequences; i.e., containment heat removal system availability, which is what distinguishes PDSs from core damage sequences, is not credited in the EPU calculation.</p>
L2-02	<p>The framework of Waterford 3 L2 model, which has not been maintained or updated since the IPE submittal, does not directly calculate LERF. The CET treatment of Waterford 3 PRA was developed to calculate the various containment failure modes including bypass events. A one time calculation since the L2 IPE submittal was informally performed to determine LERF by summing the early containment failure and bypass frequencies. The methodology of the LERF calculation, which is neither process defined or documented, does not address population emergency classification and evacuation considerations (see note below). Without consideration of Emergency response, an appreciable LERF assessment can not be achieved.</p> <p>Note: Timing of radiological release and its relation to the time required for Emergency declaration and evacuation timing is important in determining LERF. Simply assuming all late containment failures do not result in LERF without factoring emergency response timing for</p>	A	<p>The EPU calculation did not use the Level 2 model, but rather used a simple LERF method that did not credit the emergency response timing to move potentially early containment failure scenarios into a late failure bin.</p>

Peer Review F&O No.	Change Request Text	Peer Review Priority	Impact on EPU Calculation
	<p>both internal and external initiating events may not prudent and could lead to a non-conservative estimation of LERF. Conversely, an over-estimation of LERF can result from assuming all early containment failures result in LERF.</p> <p>If LERF calculations are performed to support risk-based informed applications, the current L2 model should be re-evaluated and updated to address Emergency response considerations.</p>		
L2-03	<p>The Waterford 3 Level 2 PRA has not been updated or maintained since the IPE submittal. Weak documentation, process definition and model control has made the review difficult. It was concurred by the Waterford 3 PRA staff that reproducing the results or performing any sensitivity runs would be difficult to achieve in a reasonable amount of time. Due to the weak documentation and the unavailability of a on-site Level 2 expert that was involved in all phases of the level 2 IPE model development, all areas of the review are considered not reviewed, except where indicated.</p> <p>The utility may want to consider developing a more simplified approach in determining LERF as outlined in NUREG/CR 6595. The level of significance rating of "A" was assigned to this element if the utility plans to use the current model to provide appreciable risk insights in a fashion that affords flexibility, efficiency and tractability for both permanent and temporary model changes.</p>	A	<p>The EPU calculation did not use the Level 2 model, but used a simplified, conservative LERF method roughly analogous to the NUREG/CR-6595 approach, but more simplified and conservative.</p>

Question 12:

Page 2.11-16, Evaluation of PSA Model Quality: This section states "In addition, the most recent update involved extensive revision..." What quality process (internal reviews, peer reviews, etc.) was used to make these revisions? Also, what quality process was used to check that the modifications made to the PRA in order to assess the risk impact of the EPU were correctly performed?

Response 12:

For the model update, internal reviews and expert panel (Ops, engineering, maintenance, PSA) review of model results were used. For the EPU risk assessment, internal reviews were used. In both cases, formal engineering calculations (following our engineering calculation procedure) were used, which includes independent technical review and supervisor approval. The model update calculation included thorough documentation of all model elements. The EPU calculation included description of the methodology and the details of the calculation, including changes to the PRA model to represent the effect of the EPU. The thermal-hydraulic analysis for EPU was documented by Westinghouse in a formal, independently reviewed calculation.

Question 13:

Page 2.11-16, Evaluation of PSA Model Quality: This section states "In addition, the most recent update involved extensive revision ... in order to bring the PSA up to current PSA standards, including the new ASME [American Society of Mechanical Engineers] PSA standard (Category II)." Please confirm that the Waterford 3 PRA meets Capability Category II defined in the ASME PSA standard by providing supporting evidence such as the results of any self-assessments or peer reviews.

Response 13:

At the time that the update was performed, the ASME standard was only a draft document and undergoing frequent, significant revisions in order to address industry and NRC comments. The contract for the update of the Waterford 3 PRA specified that the update be performed to meet draft ASME PSA Standard (Rev. 12) requirements. It was Entergy's intent that the updated Waterford 3 PRA would meet Capability Category II; however, a review of the Waterford 3 PRA model against the final ASME standard has not yet been performed. Nevertheless, the fact that most of the industry peer review comments have been addressed and that the remaining open comments, as described in the response to Question 11, do not significantly affect the EPU risk assessment, indicates that the Waterford 3 PRA is of sufficient quality for this application.

Attachment 2

W3F1-2004-0043

List of Regulatory Commitments

List of Regulatory Commitments

The following table identifies those actions committed to by Entergy in this document. Any other statements in this submittal are provided for information purposes and are not considered to be regulatory commitments.

COMMITMENT	TYPE (Check one)		SCHEDULED COMPLETION DATE (If Required)
	ONE- TIME ACTION	CONTINUING COMPLIANCE	
In addition, due to recent issues regarding the EPU SBLOCA analysis (reference Entergy letter W3F1-2004-0035 to the NRC dated May 7, 2004 for further details), Waterford 3 no longer expects to need to install digital ADV controllers. The final determination regarding the need for digital controllers will be communicated to the NRC staff by July 15, 2004. If digital ADV controllers are to be used, a detailed response to this question will be provided at that time.	X		July 15, 2004