

June 3, 2005

Mr. R. T. Ridenoure
Vice President - Chief Nuclear Officer
Omaha Public Power District
Fort Calhoun Station FC-2-4 Adm.
Post Office Box 550
Fort Calhoun, NE 68023-0550

SUBJECT: FORT CALHOUN STATION, UNIT 1 - REQUEST FOR ADDITIONAL
INFORMATION (RAI) RELATED TO GENERIC LETTER 2004-02, "POTENTIAL
IMPACT OF DEBRIS BLOCKAGE ON EMERGENCY SUMP RECIRCULATION
AT PRESSURIZED-WATER REACTORS" (TAC NO. MC4686)

Dear Mr. Ridenoure:

By letter dated March 4, 2005, Omaha Public Power District (the licensee) provided the 90-day response to U. S. Nuclear Regulatory Commission (NRC) Generic Letter (GL) 2004-02 for Fort Calhoun Station, Unit 1. The GL requested the licensee perform an evaluation of the emergency core cooling system and containment spray system recirculation functions in light of the information provided in the GL and, if appropriate, take additional actions to ensure system function. Additionally, addressees were requested to submit to the NRC the information specified in the GL.

The NRC staff has completed its preliminary review of your response and has determined it needs additional information requested in the enclosure to complete our review.

This RAI requests additional information about your overall plans and schedules and not any information on detailed plans or extensive analyses. In light of this, please provide the additional information requested in the enclosure within 45 days of receipt of this letter.

If you have any questions, please call me at (301) 415-1445.

Sincerely,
/RAI/

Alan B. Wang, Project Manager, Section 2
Project Directorate IV
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-285

Enclosure: Request for Additional Information

cc w/encl: See next page

June 3, 2005

Mr. R. T. Ridenoure
Vice President - Chief Nuclear Officer
Omaha Public Power District
Fort Calhoun Station FC-2-4 Adm.
Post Office Box 550
Fort Calhoun, NE 68023-0550

SUBJECT: FORT CALHOUN STATION, UNIT 1 - REQUEST FOR ADDITIONAL INFORMATION (RAI) RELATED TO GENERIC LETTER 2004-02, "POTENTIAL IMPACT OF DEBRIS BLOCKAGE ON EMERGENCY SUMP RECIRCULATION AT PRESSURIZED-WATER REACTORS" (TAC NO. MC4686)

Dear Mr. Ridenoure:

By letter dated March 4, 2005, Omaha Public Power District (the licensee) provided the 90-day response to U. S. Nuclear Regulatory Commission (NRC) Generic Letter (GL) 2004-02 for Fort Calhoun Station, Unit 1. The GL requested the licensee perform an evaluation of the emergency core cooling system and containment spray system recirculation functions in light of the information provided in the GL and, if appropriate, take additional actions to ensure system function. Additionally, addressees were requested to submit to the NRC the information specified in the GL.

The NRC staff has completed its preliminary review of your response and has determined it needs additional information requested in the enclosure to complete our review.

This RAI requests additional information about your overall plans and schedules and not any information on detailed plans or extensive analyses. In light of this, please provide the additional information requested in the enclosure within 45 days of receipt of this letter.

If you have any questions, please call me at (301) 415-1445.

Sincerely,
/RA/

Alan B. Wang, Project Manager, Section 2
Project Directorate IV
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-285

Enclosure: Request for Additional Information

cc w/encl: See next page

DISTRIBUTION:

PUBLIC PDIV-2 R/F RidsOgcRp
RidsAcrsAcnwMailCenter RidsNrrDlpmLpdiv2 (DTerao) RidsNrrPMAWang
RidsNrrLADBaxley RidsRgnIVMailCenter DCullison/DSolorio
RidsNrrDlpmDpr RidsNrrDssaDpr MWebb RidsNrrLALFeizollahi

Accession No.: ML051520156 *RAI input from the staff without any major change

OFFICE	PDIV-1/PM PDIII-2/PM	PDIV-1/LA	PDIV-2/PM	DSSA/SPLB/SP*	PDIV-1/SC PDIII-2/SC
NAME	MWebb/JHopkins	DBaxley	AWang	DCullison/DSolorio	DTerao/GSuh
DATE	6/2/2005	6/2/05	6/3/05	5/23/05	6-3-05

OFFICIAL RECORD COPY

Ft. Calhoun Station, Unit 1

cc:

Winston & Strawn
ATTN: James R. Curtiss, Esq.
1400 L Street, N.W.
Washington, DC 20005-3502

Iowa Department of Public Health
401 SW 7th Street, Suite D
Des Moines, IA 50309

Chairman
Washington County Board of Supervisors
P.O. Box 466
Blair, NE 68008

Mr. John Hanna, Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 310
Fort Calhoun, NE 68023

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011-4005

Ms. Sue Semerera, Section Administrator
Nebraska Health and Human Services
Systems
Division of Public Health Assurance
Consumer Services Section
301 Centennial Mall, South
P.O. Box 95007
Lincoln, NE 68509-5007

Mr. David J. Bannister, Manager
Fort Calhoun Station
Omaha Public Power District
Fort Calhoun Station FC-1-1 Plant
P.O. Box 550
Fort Calhoun, NE 68023-0550

Mr. John B. Herman
Manager - Nuclear Licensing
Omaha Public Power District
Fort Calhoun Station FC-2-4 Adm.
P.O. Box 550
Fort Calhoun, NE 68023-0550

Mr. Daniel K. McGhee
Bureau of Radiological Health

REQUEST FOR ADDITIONAL INFORMATION
REGARDING GENERIC LETTER 2004-02,
“POTENTIAL IMPACT OF DEBRIS BLOCKAGE ON
EMERGENCY SUMP RECIRCULATION AT PRESSURIZED-WATER REACTORS”

OMAHA PUBLIC POWER DISTRICT

FORT CALHOUN STATION, UNIT 1

DOCKET NO. 50-285

By letter dated March 4, 2005, Omaha Public Power District (the licensee) provided the 90-day response to U. S. Nuclear Regulatory Commission (NRC) Generic Letter (GL) 2004-02 for Fort Calhoun Station, Unit 1. The GL requested that addressees perform an evaluation of the emergency core cooling system and containment spray system recirculation functions in light of the information provided in the GL and, if appropriate, take additional actions to ensure system function. Additionally, addressees were requested to submit to the NRC the information specified in the GL. The staff has completed its preliminary review of your response and has determined it needs the following additional information to complete our review:

In your 90-day response to GL 2004-02, you indicated that you intend to use future test results, industry guidance, and NRC guidance to account for chemical precipitants in your evaluation and their availability will impact the schedule for performing an evaluation. The cooperative NRC-Electric Power Research Institute tests in progress at the University of New Mexico are designed to determine if chemical effects occur, but are not designed to measure head loss associated with any chemical effects. The staff notes that some chemical effects have been observed in the initial three tests.

For addressing chemical effects, you state the evaluation may occur after the September 1, 2005, response due date, depending on the schedule for testing and the availability of industry guidance. This is contrary to the information request in GL 2004-02, which requests that chemical effects be addressed in the September 1, 2005, response. This delay is also contrary to the staff's position that there are sufficient bases to address sump vulnerability to chemical effects and that the September response will be incomplete if the evaluation is incomplete, the design is not complete, or there is no schedule for upgrades. In this light, please discuss your plans and schedule for evaluating chemical effects. In addition, please discuss any plans for performing testing to support your evaluation of this effect.

ENCLOSURE