

**NUCLEAR REGULATORY COMMISSION**

Title: Advisory Committee on Reactor Safeguards  
Subcommittee on Plant License Renewal

Docket Number: (not applicable)

PROCESS USING ADAMS  
TEMPLATE: ACRS/ACNW-005  
  
SUNSI REVIEW COMPLETE

Location: Rockville, Maryland

Date: Tuesday, July 11, 2006

Work Order No.: NRC-1132

Pages 1-140

NEAL R. GROSS AND CO., INC.  
Court Reporters and Transcribers  
1323 Rhode Island Avenue, N.W.  
Washington, D.C. 20005  
(202) 234-4433

TROY

**ACRS OFFICE COPY  
RETAIN FOR THE LIFE OF THE COMMITTEE**

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S  
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

July 11, 2006

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, taken on July 11, 2006, as reported herein, is a record of the discussions recorded at the meeting held on the above date.

This transcript has not been reviewed, corrected and edited and it may contain inaccuracies.

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION

+ + + + +

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS  
(ACRS)

SUBCOMMITTEE ON PLANT LICENSE RENEWAL

+ + + + +

TUESDAY,

JULY 11, 2006

+ + + + +

ROCKVILLE, MARYLAND

+ + + + +

The Subcommittee met at the Nuclear Regulatory  
Commission, Two White Flint North, Room T2B3, 11545  
Rockville Pike, at 1:30 p.m., Dr. John D. Sieber,  
Chairman, presiding.

COMMITTEE MEMBERS:

JOHN D. SIEBER, Chair

J. SAM ARMIJO, Member

MARIO V. BONACA, Member

OTTO L. MAYNARD, Member

GRAHAM B. WALLIS, Member

NEAL R. GROSS  
COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVENUE, N.W.  
WASHINGTON, D.C. 20005

1 ACRS STAFF PRESENT:

2 MICHAEL JUNGE

3 FRANK GILLESPI

4 JUAN AYALA

5 DAVID JENG

6 MATTHEW MITCHELL

7 REPRESENTATIVES OF PALISADES NUCLEAR PLANT PRESENT:

8 DARREL TURNER

9 JOHN BROSHAK

10 BOB VINCENT

11 PAUL HARDEN

12 MARK CIMOCK

13 LARRY SEAMANS

14 BILL ROBERTS

15 JOHN KNEELAND

16 BRIAN BROGAN

17 ALSO PRESENT:

18 MARK HARTZMAN

19 CORINNE CAREY

20 ALICE HIRT

21 KAY CUMBOW

22 GARY KARCH

23 KEVIN KAMPS

24 MICHAEL KEEGEN

25 KATHRYN BARNES

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

A-G-E-N-D-A

1  
2  
3  
4  
5  
6  
7  
1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18

Welcome and Introductions

Dr. John Sieber, Chair . . . . . 3

Louise Lund, Branch Chief in License Renewal  
Branch A, Division of License Renewal . . . 6

Palisades Nuclear Plant Presentation by Palisades  
Staff . . . . . 8

License Renewal Safety Evaluation Report

Overview of the Plant and Application and  
Discussion of Scoping and Screening Results,  
Juan Ayala, Project Manager . . . . . 63

License Renewal Inspections, Patricia Lougheed,  
Lead Inspector for License Renewal for Region  
III . . . . . 70

Staff's Review of the Aging Management Programs  
and Aging Management Reviews . . . . . 86

Public Comments . . . . . 112

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

## P-R-O-C-E-E-D-I-N-G-S

1:34 P.M.

CHAIRMAN SIEBER: The meeting will now come to order. This is a meeting of the Plant License Renewal Subcommittee. I am Jack Sieber, Chairman of the Plant License Renewal Subcommittee for the Palisades plant. ACRS members in attendance are Dr. Graham Wallis, Dr. William Shack, Dr. Mario Bonaca, Dr. Sam Armijo, and Otto Maynard. Michael Junge, to my right, of the ACRS staff is the designated federal official for this meeting.

The purpose of the meeting is to discuss the license renewal application for the Palisades Nuclear Plant. We will hear presentations from representatives in the Office of Nuclear Reactor and Regulation, the Region III office in Lisle, Illinois, and the Nuclear Management Company. The Subcommittee will gather information, analyze relevant issues and facts, and formulate proposed positions and actions as appropriate for deliberation by the full Committee.

The rules for participation in today's meeting were announced as part of the notice of this meeting previous published in the Federal Register on June 21, 2006. We have received no written comments or request for time to make an oral statement from

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 members of the public regarding today's meeting.

2 A transcript of the meeting is being kept  
3 and will be made available as stated in the Federal  
4 Register notice. Therefore, we request that  
5 participants in this meeting use the microphones  
6 located throughout the meeting room when addressing  
7 the Subcommittee. Participants should first identify  
8 themselves and speak with sufficient clarity and  
9 volume so that they can be readily heard.

10 Matters to be discussed this afternoon is  
11 the license renewal application and its related safety  
12 evaluation report and the inspection and audit report  
13 prepared by our Region III office in Lisle, Illinois,  
14 the licensee and also the Office of Nuclear Reactor  
15 Regulation.

16 The requirements for license renewal are  
17 set forth in Title 10 of the Code of Federal  
18 Regulations, Part 54, and involve aging management of  
19 long-live passive components that are included within  
20 the scope of the rule. We will restrict ourselves to  
21 discussions of the licensee's treatment of and NRR's  
22 review of the aging management and time-limited aging  
23 analysis related to those components in scope.

24 We will now proceed with the meeting and  
25 I call on Ms. Louise Lund of the Office of Nuclear

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 Reactor Regulation to begin.

2 MS. LUND: Thank you. Good afternoon. My  
3 name is Louise Lund. I am the Branch Chief in License  
4 Renewal Branch A in the Division of License Renewal.  
5 We are here to discuss, as previously stated, the  
6 license renewal review for Palisades that form the  
7 basis for our safety evaluation. Beside me also is  
8 Frank Gillespi, our Director for the Division of  
9 License Renewal. Staff has conducted a very detailed  
10 and thorough review of the Palisades Nuclear Plant  
11 license renewal application which was submitted in  
12 March of 2005.

13 Mr. Juan Ayala, here to my right, at the  
14 end of the table, is the project manager for this  
15 review. He will lead the staff's presentation this  
16 afternoon on the draft safety evaluation report. In  
17 addition, we have Ms. Patricia Loughed who is our  
18 team leader for the Region III inspections that were  
19 conducted at Palisades Nuclear Plant and she is  
20 sitting right behind me.

21 We also have several members of the NRR  
22 technical staff here in the audience to provide  
23 additional information and answer your questions. The  
24 staff felt that the Palisades Nuclear Plant  
25 application was of sufficient quality that it resulted

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005



1 in the issuance of 174 formal requests for additional  
2 information which is on the low end of the amount of  
3 RAIs that we have issued for recent plants.

4 I know that the ACRS has been interested  
5 in the number of questions that have come out of these  
6 reviews in the past and believe that part of this  
7 reduction is the result of the generic aging lessons  
8 learned report. This application was submitted using  
9 the draft GALL report that was issued back in January  
10 of 2005.

11 However, it was reconciled with the  
12 September 2005 version of the GALL report. In fact,  
13 it resulted in a 95 percent consistency between their  
14 application and the revised GALL. That made it a good  
15 application for us to review in that respect to see  
16 the consistency.

17 In addition, the staff at Palisades  
18 provided excellent support for our on-site audits in  
19 the inspections that were conducted and also the  
20 headquarters reviews through the conference calls and  
21 the numerous meetings that we had.

22 With that, I would like to turn it over to  
23 Bob Vincent who is the manager of this project at  
24 Palisades to begin the applicant's presentation.

25 MR. TURNER: Good morning. Good afternoon

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 I should say. My name is Darrel Turner and I am the  
2 Manager of Projects at Palisades nuclear site. With  
3 me we brought the License Renewal Project team along  
4 with a couple of guests from Palisades, the Nuclear  
5 Management Company.

6 I would like to introduce those people if  
7 I may. In our audience behind the committee is our  
8 site Vice President Paul Harden. On my right is our  
9 site engineering director Mr. John Broschak. And as  
10 Bob was just introduced, Bob Vincent on my left. He  
11 is the Manager of the License Renewal Project itself.

12 With the project team we've got Mark  
13 Cimock who is the lead for Civil, Structural, and  
14 Mechanical. We have to his left John Kneeland, Time  
15 Limited Aging Analysis lead. To his left is Bill  
16 Roberts, our program lead. To the right is Mark  
17 Cimock is Larry Seamans, our electrical lead for the  
18 project.

19 We are happy to be here and present to you our  
20 Palisades plant and answer your questions. We have a  
21 short introduction here. The next slide, please, Bob.  
22 I'm going to go to the agenda. We are going to talk  
23 a little bit about our plant, a little description,  
24 the licensing history since its inception, some major  
25 improvements that we have accomplished and performed

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 over the last several years, our current plant status,  
2 where we are on operating space.

3 We are going to review our license renewal  
4 methodology that went into the application. I am  
5 going to inform you about our commitment management  
6 system at Palisades. We thought that the ACRS would  
7 be interested in a few technical issues which we are  
8 going to expound upon which you see on the slide.

9 Our plant is owned by Consumers Energy  
10 Company and it is operated and run by the Nuclear  
11 Management Company. We are situated in the Southeast  
12 corner of Lake Michigan just right near the little  
13 town of Covert, Michigan, on a site of 432 acres. We  
14 have a combustion engineering nuclear steam supply  
15 system and our architect engineer for the power plant  
16 was Bechtel. We have two-loop reactor cooling system  
17 with four primary coolant pumps, two steam generators.  
18 Our containment is pre-stressed concrete containment.

19 You may have seen the photo earlier but we  
20 have two banks of cooling towers, two draft cooling  
21 towers, forced draft with 18 cells each. Our ultimate  
22 heat sink is Lake Michigan through our service water  
23 system. Our current license power is 2565.4 MWt. We  
24 have a design electrical output of 820 megawatts  
25 electric net and our probabilistic risk assessment for

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 core damage frequency due to internal events is 2.86  
2 E to the minus fifth. Our large early release  
3 frequency, as we see, is 3.55 E to the minus seventh.

4 CHAIRMAN SIEBER: There's a couple ways of  
5 using forced draft cooling towers. One of them is  
6 using as part of a closed cycle condenser cooling  
7 system. The other way is to use them as an after  
8 cooler for open cycle where they don't run all the  
9 time. Which is yours?

10 MR. TURNER: Our cooling tower fans are  
11 run all the time. It's a closed cycle system.

12 CHAIRMAN SIEBER: You are closed cycle.  
13 Okay.

14 MR. TURNER: Correct.

15 CHAIRMAN SIEBER: Thank you.

16 MEMBER BONACA: On the PRA, this number  
17 2.8 E to the minus fifth for a CE type plant at that  
18 time seems very low. Have you had improvements with  
19 the plant over the years in the auxiliary fuel system  
20 or the charging system of that plant?

21 MR. TURNER: Have we had improvements that  
22 have improved our core damage frequency is the  
23 question?

24 MEMBER BONACA: Yes.

25 MR. TURNER: We have a number of slides

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 that we are going to discuss in just a little bit.

2 MEMBER BONACA: Okay. I'll wait.

3 MR. TURNER: One person I forgot to  
4 introduce, excuse me, please, is Brian Brogan who is  
5 our Probabilistic Risk Assessment Supervisor who  
6 supported the team and we brought him with us.

7 That's a little bit on our plant  
8 description. I would like to turn it over to Bob  
9 Vincent, License Renewal Project Manager, to describe  
10 some of our licensing history.

11 MR. VINCENT: I'm Bob Vincent, License  
12 Renewal Project Leader.

13 CHAIRMAN SIEBER: Could you bring the  
14 microphone over?

15 MR. VINCENT: Thank you for the reminder.

16 CHAIRMAN SIEBER: Okay.

17 MR. VINCENT: I'm Bob Vincent.  
18 Construction for Palisades was issued in 1967 and  
19 consistent with the licensing process of the time.  
20 Palisades received a provisional operating license in  
21 1971. The initial expiration date was in 2007. Then  
22 in 1974 we applied for the full-term operating  
23 license.

24 During the period 1978 to 1983 and  
25 slightly beyond Palisades was one of the 11

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 participants in the System Evaluation Program. The  
2 full-term operating license for the plant was issued  
3 in 1991 with an expiration date of 2007.

4 In 2000 we recovered the construction  
5 period and our expiration date was changed to March  
6 24, 2011, which is the current expiration date. Then  
7 in 2005 our license power level was raised from 2530  
8 to 2575.4 Mwt. That was a measurement uncertainty  
9 recaptured power upgrade. 2565 is the current license  
10 power level in Palisades.

11 At this point I would like to turn it over  
12 to John Broschak to talk about some of the major  
13 improvements and planned upgrades and the current  
14 plant status.

15 MR. BROSCHAK: Good afternoon. My name is  
16 John Broschak and I am the Site Engineering Director  
17 for the Palisades station. I will be providing a  
18 brief overview of some of the more significant and  
19 major plant modifications that have been performed  
20 since original construction.

21 In 1974, '75 the plant was converted from  
22 once-through cooling to cooling towers as described in  
23 the description. At that time the condenser was  
24 retubed from a Admiral T material to a copper nickel  
25 90-10 material. In 1977 and again in 1987 the spent

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 fuel pool storage capacity was expanded. In 1977  
2 additional racks were installed in the pool to raise  
3 the capacity to 798 assemblies. In 1987 some high-  
4 density racks were replaced in the pool to get it up  
5 to 892 usable assemblies and that is the licensed  
6 amount of fuel storage in the spent fuel pool at this  
7 time.

8 CHAIRMAN SIEBER: Do you use neutron  
9 absorbers?

10 MR. BROSHAK: Yes, sir.

11 CHAIRMAN SIEBER: What are there?

12 MR. BROSHAK: I believe it's a boron  
13 material.

14 CHAIRMAN SIEBER: Boroflex?

15 MR. BROSHAK: Mark Cimock, our lead  
16 mechanic, would like to answer that.

17 MR. CIMOCK: This is Mark Cimock with the  
18 Nuclear Management Company. We have some boroflex  
19 racks in our fuel pool but we do not credit them as a  
20 neutron absorber. Our analysis does not credit that.  
21 But we also have a design that actually has boron  
22 carbide plates that are sheaved in stainless steel.  
23 We do credit those for neutron absorption.

24 CHAIRMAN SIEBER: Thank you.

25 MR. BROSHAK: Again John Broschak. Back

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 to the major planned improvements. In 1983 we added  
2 a third auxiliary feedwater pump and upgraded that  
3 system to safety-grade. Also, in 1983 we upgraded the  
4 control room HVAC to safety-grade.

5 MEMBER BONACA: So you do have steam  
6 driven pump?

7 MR. BROSCHAK: Yes, sir.

8 MEMBER BONACA: And two electric driven  
9 pumps?

10 MR. BROSCHAK: Two electric driven  
11 auxiliary feedwater pumps, one steam driven auxiliary  
12 pump.

13 MEMBER BONACA: One is capable of 100  
14 percent?

15 MR. BROSCHAK: Yes, sir.

16 MEMBER BONACA: Okay.

17 CHAIRMAN SIEBER: Do you meet all the  
18 separation criteria for those pumps from a fire  
19 protection standpoint?

20 MR. BROSCHAK: Yes.

21 CHAIRMAN SIEBER: Different rooms?

22 MR. BROSCHAK: Yes, sir.

23 CHAIRMAN SIEBER: Okay.

24 MR. BROSCHAK: In 1985 and 1986 the  
25 initial PRA applications were done at Palisades. Much

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005



1 of this was as the result of the Systematic Evaluation  
2 Program issues that were being addressed, mainly the  
3 main steam isolation valves. PRA was used as a method  
4 for resolving questions that came up as a result of  
5 the failure criteria 4 main steam isolation valves.

6 In 1989, again, as a result of PRA  
7 insights the plant addressed on its own an issue  
8 concerning the lack of diversification of off-site  
9 power. There had been history of lightening strikes  
10 and other environmental conditions that caused loss of  
11 off-site power and through insights using PRA we were  
12 able to add additional diversification to the  
13 switchyard arrangement to basically eliminate that  
14 vulnerability and reduce the risk of the plant to this  
15 type of situation.

16 CHAIRMAN SIEBER: Maybe to explain that a  
17 little bit, you could tell me a little bit more what  
18 equipment you added. Did you add new lines, new  
19 breakers?

20 MR. BROSHAK: Yes. If I could, I'll  
21 refer that to Larry Seamans who is our electrical  
22 lead.

23 CHAIRMAN SIEBER: Come over here to this  
24 microphone.

25 MR. SEAMANS: I am Larry Seamans,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 electrical lead for license renewal. What we added at  
2 that time was on our switchyard buses we had a  
3 connection on one bus and then one hub initially.  
4 That hub connection came through disconnects that had  
5 to be manually disconnected to get the feedback.

6 At that time we added a motor operated  
7 disconnect. We also added on the other bus a separate  
8 feed and then we have the transformer, voltage  
9 regulated transformer, and added a separate  
10 underground feed back to the plant that goes to either  
11 safety bus.

12 MR. VINCENT: Just to add onto that a  
13 little bit more -- Bob Vincent again -- for clarity,  
14 what we have now is basically three sources of off-  
15 site power, two immediate access sources, one through  
16 the original start-up lines which are a set of  
17 overhead lines. The second source is totally from an  
18 independent section of the switchyard with a  
19 transformer in the switchyard and a set of underground  
20 lines that can feed our vital buses directly.

21 Then the third source is back-feed through  
22 the main transformer. With the motor-operated  
23 disconnect Larry mentioned, that is almost immediately  
24 access feed but we have to manually operate the motor-  
25 operated disconnect. We have three prompt access

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 feeds.

2 CHAIRMAN SIEBER: How many transmission  
3 lines into and out of your switchyard?

4 MR. TURNER: The question is how many  
5 transmission lines are into and out of our switchyard.  
6 Larry, I would like to defer that one to you as well.

7 MR. SEAMANS: This is Larry Seamans again  
8 with the Palisades license renewal team. We have  
9 seven total off-site sources that come in.

10 CHAIRMAN SIEBER: Thank you.

11 MR. BROSchak: John Broschak again.  
12 Getting back to the list in the presentation. In 1990  
13 we placed the steam generators and also retubed the  
14 main condenser and feedwater heaters. At that time  
15 the tubing material was changed from the copper nickel  
16 to stainless for the main condenser and feedwater  
17 heaters.

18 DR. SHACK: And you steam generators are?

19 MR. BROSchak: Alloy 600.

20 DR. SHACK: Thermally treated?

21 MR. BROSchak: They were manufactured at  
22 the same time as the original plant construction and  
23 they are alloy 600 thermal treatment.

24 CHAIRMAN SIEBER: I don't know about that.

25 DR. SHACK: The 1990 versions are 600 and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 you don't know whether they are thermally treated or  
2 not?

3 MR. VINCENT: Bob Vincent again. Those  
4 were actually manufactured in 1977/78 time frame so we  
5 kept them in storage for years before we finally did  
6 install them.

7 CHAIRMAN SIEBER: I presume when they were  
8 in storage that they were inert in some way?

9 MR. VINCENT: Absolutely. They were  
10 maintained with inert atmosphere internally.

11 MEMBER BONACA: What's the performance of  
12 the tubes?

13 MR. TURNER: What's the performance of the  
14 tubes is the question?

15 MEMBER BONACA: Yes.

16 MR. BROSHAK: Currently 4.5 percent of  
17 the tubes are plugged approximately on both  
18 generators. That is in reference to the 3 percent  
19 that were preferentially plugged when they were  
20 originally installed. Over the past 16 years of  
21 operation there has been approximately 1.5 percent of  
22 the tubes additional that have been plugged on each of  
23 the steam generators.

24 DR. SHACK: Why did you replace the steam  
25 generators? What was the mode of degradation that did

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1       them in?

2                   MR. VINCENT: Bob Vincent again. Early in  
3 plant life we had chronic steam generator tube  
4 leakages problems. The original steam generators had  
5 carbon steel support plates. Most of the lateral  
6 supports for tubes were carbon steel. That, of  
7 course, created a denting problem.

8                   We also had a wastage problem with the  
9 original tubes primarily down near the tube sheet  
10 under the sludge piles. We had a fair amount of  
11 morpholine due to wastage. Those were the primary  
12 problems early on.

13                   CHAIRMAN SIEBER: Was your early chemical  
14 treatment the TSP treatment?

15                   MR. VINCENT: No. We started out with --  
16 yes. I'm sorry. We did have trisodium phosphate  
17 early on.

18                   CHAIRMAN SIEBER: That's where the wastage  
19 comes from.

20                   MR. VINCENT: Right.

21                   CHAIRMAN SIEBER: What is the treatment  
22 since the new steam generators have been installed?

23                   MR. VINCENT: At this point it's all  
24 volatile.

25                   CHAIRMAN SIEBER: Molar control?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 MR. TURNER: Hydrazide morpholine.

2 CHAIRMAN SIEBER: Yeah, but you try to get  
3 a molar balance.

4 DR. SHACK: Do you follow the EPRI PWR  
5 steam generator water chemistry guidelines?

6 MR. VINCENT: Yes, we do.

7 CHAIRMAN SIEBER: Let me ask about the  
8 main unit condenser. After the first retubing do you  
9 put copper nickel in there. What was the degradation  
10 mechanism that caused you to go to stainless?

11 MR. TURNER: The degradation mechanism  
12 that caused us to go to stainless tubes in the  
13 condenser?

14 CHAIRMAN SIEBER: Right.

15 MR. VINCENT: The short answer to that one  
16 is that I think the 90-10 copper nickel performed  
17 rarely well but we wanted to get rid of copper in the  
18 system.

19 CHAIRMAN SIEBER: So it wasn't  
20 degradation. You just wanted to change the chemistry  
21 of your secondary site.

22 MR. VINCENT: To the best of my memory,  
23 yes.

24 CHAIRMAN SIEBER: Have you ever had a  
25 problem with microbiologically induced corrosion?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 MR. BROSchak: This is John Broschak.  
2 There are some examples of MIC, microbiologically,  
3 induced corrosion throughout the plant. Mark Cimock,  
4 I don't know if you have any specific examples. It is  
5 a program that is monitored by the station and we do  
6 inspections and periodic replacements based on what  
7 inspection results we have.

8 MR. CIMOCK: I don't know if I can add  
9 much more. Again, this is Mark Cimock, NMC. I don't  
10 think I can add much more to that. I think most of  
11 the MIC type issues we've had that have been  
12 permanently on secondary or actually the raw water  
13 systems. I'm not aware of any problems we've had on  
14 the secondary side.

15 CHAIRMAN SIEBER: Usually if you have a  
16 lot of defects in condenser tubes it changes your  
17 steam generator chemistry sometimes enough to give you  
18 lots of problems. That is really the gist of what I  
19 was asking you is how bad was your condenser? How  
20 much damage was it causing to the steam generators  
21 that you still now have? I think what you're telling  
22 me is that the motivation for going to stainless is  
23 not related to degradation of the tubes but to a  
24 desire to change the -- to get rid of copper which  
25 most utilities have tried to do.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 MR. CIMOCK: That's correct.

2 MR. BROSCAK: John Broschak again. Back  
3 to the list. In 1993 Palisades was the first  
4 stationed implement an independent spent fuel storage  
5 installation under a general license in Part 72. We  
6 implemented the VSC-24 system at that time to  
7 supplement pool storage capacity.

8 CHAIRMAN SIEBER: All right.

9 MR. BROSCAK: 1995, again due to PRA  
10 insights, we modified the under-reactor vessel floor  
11 drains to containment sump. This was a matter of  
12 adding ceramic beads so that any designed basis fuel  
13 that would potentially be introduced into the sump  
14 would be prohibited based on interaction with those  
15 ceramic beads.

16 2004 Palisades implemented a second  
17 independent spent fuel storage installation to expand  
18 capacity this time with the new home system. In 2006  
19 just recently Palisades has implemented the most  
20 significant of the SAMA improvement and modifications.  
21 This was the addition of a non-safety backup diesel  
22 generator.

23 This has allowed us to reduce the core  
24 damage frequency from approximately four to 10 to the  
25 minus fifth down to the 2.86 number understanding that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005



1 the PRA model is a living model. That represented  
2 approximately 40 percent reduction in the core damage  
3 frequency by the addition of that non-safety backup  
4 diesel generator.

5 CHAIRMAN SIEBER: So you have three diesel  
6 generators?

7 MR. BROSHAK: That's correct.

8 CHAIRMAN SIEBER: What is either the  
9 kilowatt-hour or horsepower of the non-safety diesel?

10 MR. BROSHAK: Non-safety currently  
11 installed is 2,000 kilowatts. That is the amount we  
12 need to carry the safety loads required under the  
13 conditions that we would use them.

14 CHAIRMAN SIEBER: Okay.

15 MEMBER MAYNARD: Is that a swing diesel  
16 that can work on either a safety train or is it one  
17 that powers into the normal grid and provides like  
18 all-site power would?

19 MR. BROSHAK: I guess the terminology  
20 swing diesel would be appropriate. It can power  
21 either of the safety buses that would be required to  
22 power safety-related loads.

23 CHAIRMAN SIEBER: Can you connect your  
24 safety vessels together?

25 MR. BROSHAK: No, we cannot.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 CHAIRMAN SIEBER: Okay.

2 MR. BROSCAK: Currently the plant status  
3 is operating at 100 percent power in the 19th cycle of  
4 operation. The next refueling outage is scheduled for  
5 the fall of 2007. All NRC performance indicators are  
6 green and there are no current NRC inspection findings  
7 greater than green.

8 At this point I will turn it back over to  
9 Bob Vincent to discuss the license renewal application  
10 methodology.

11 MEMBER BONACA: All in all how would you  
12 characterize the physical conditions of the plant?

13 MR. BROSCAK: Physical condition of the  
14 plant is good to excellent. That is based on feedback  
15 we get from external stakeholders that come to visit.  
16 The physical condition, I would say, is good to  
17 excellent.

18 MEMBER BONACA: We'll ask that question,  
19 of course, to the inspectors later on.

20 MR. BROSCAK: Yes.

21 DR. SHACK: Have you done much replacement  
22 of piping on your secondary side to switch to chrome  
23 molly alloys or are you really relying on your  
24 Corrosion Erosion Program to monitor that?

25 MR. BROSCAK: John Broschak again. We

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 have a combination program of selective replacements  
2 with the chrome molly in addition to active searching  
3 for corrosion and erosion mechanisms and then doing  
4 selective replacements as we identified those so it's  
5 a combination rather than just a wholesale strategic  
6 replacement piping.

7 MR. VINCENT: I am Bob Vincent again. The  
8 license renewal application was dated March 22, 2005.  
9 It was developed using the standard format of NEI 95-  
10 endorsed by the NRC. The GALL revision used for  
11 the application was the 2001 Revision 0 of the GALL  
12 and the Standard Review Plan. In the application we  
13 addressed all of the issued and draft ISGs that were  
14 available publicly at that point.

15 CHAIRMAN SIEBER: How many was that?

16 MR. VINCENT: I believe the number was 15.  
17 As I recall there were about 10 that had been issued  
18 and I think five were in draft form at that point.

19 From the outset we designed the project of  
20 Palisades to be a site-based, site-run project. In  
21 the lead positions we staffed with highly experienced  
22 plant people. In fact, among the leads I think we  
23 represent over 150 years of Palisades site experience  
24 and most of the leads had been through SRO training.

25 I think four had been formerly licensed.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 It was a highly plant-experienced staff. Then we  
2 supplemented that staff with license renewal  
3 experienced people we could find who had worked on  
4 other sites. We thought that brought the best of both  
5 worlds to the project.

6 Scoping, screening, and aging management  
7 reviews were performed to industry standards.  
8 Throughout the project we tried to stay very much in  
9 tune with what was happening in the rest of the  
10 industry. As we saw experience emerge from NRC  
11 reviews and other applications that had been developed  
12 that were applicable to Palisades, we tried to  
13 incorporate that experience.

14 CHAIRMAN SIEBER: What did you do to get  
15 the experience? Did you come to meetings like this  
16 that other licensees were having?

17 MR. VINCENT: Yes. Numerous things.

18 CHAIRMAN SIEBER: I would point out that  
19 we have Exelon and First Energy here watching you  
20 which I think is a great idea.

21 MR. VINCENT: Yes.

22 CHAIRMAN SIEBER: I don't want to relive  
23 all these experiences over and over again.

24 MR. VINCENT: We can sympathize. We were  
25 actively involved with the License Renewal Task Force

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 which was a tremendous benefit to us. We also  
2 participated as reviewers for peer reviews at some  
3 other plants and we had an industry peer review of our  
4 application, provided additional insights using people  
5 who had been experienced in license renewal projects  
6 at other plants, provided more input from other plants  
7 and how they did business. Just numerous things like  
8 that kept us in tune.

9 One area where that made a particular  
10 difference in the final result for Palisades was in  
11 the area of scoping under 54.4(a)(2), non-safety  
12 affecting safety. Rather late in the process we  
13 changed our scoping methodology to adopt to spaces  
14 approach based on experience actually at Dresden and  
15 Quad. That greatly facilitated the NRC reviews in  
16 that area.

17 The system descriptions and the boundaries  
18 in the application were consistent with the FSER. As  
19 I mentioned at the beginning, the AMR results in the  
20 application were reconciled to the GALL Revision 0.  
21 Then shortly after we submitted our application, we  
22 did reassess our AMR results using the draft Revision  
23 1 of the GALL and then again after the final Revision  
24 1 was issued in September we again did a comparison.

25 We provided the results to the ACRS staff

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 to facilitate their reviews and think the use of at  
2 least draft of the GALL helped the process  
3 considerably. Since we were in that transitional  
4 period between Rev. 0 and Rev. 1 of the GALL, the  
5 industry as well as the NRC were interested in  
6 statistics, how much Rev. 1 really helped. We can say  
7 from experience Rev. 1 was a substantial improvement  
8 over Rev. 0. It greatly helped efficiency of the  
9 review.

10 The final result is that aging over the  
11 extended operating period will be managed by 24 Aging  
12 Management Programs at Palisades. Twenty of those are  
13 existing programs based on existing activities. Four  
14 of those programs are new.

15 DR. SHACK: A substantial number of your  
16 existing programs seem to have to have enhancements to  
17 be consistent with GALL. Do you feel that indicates  
18 you had some deficiency in your aging management  
19 approach pre-GALL?

20 MR. VINCENT: Two responses to that. One,  
21 because of the way GALL was formatted, we essentially  
22 repackaged many of our programs. We were performing  
23 many of the activities so we credit that as an  
24 existing program but we essentially repackaged some of  
25 those with a high-level program document that would

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 basically provide the umbrella, administrative  
2 controls over all of the activities.

3 I would say it was more repackaging than  
4 truly changing what we did. There were certainly some  
5 enhancements that came out of the review, things that  
6 we decided should be strengthened in our existing  
7 activities. That was certainly no surprise. We learn  
8 as we go.

9 DR. SHACK: You weren't terribly  
10 successful in managing the aging of your control rod  
11 drive houses. Do you think you have changes in your  
12 programs that would prevent that? Did you make  
13 changes after that?

14 MR. VINCENT: Bill, would you like to  
15 comment on that? I would say in general in the  
16 control rod drive area we are dealing with some design  
17 issues, some early material selection and some --

18 DR. SHACK: Your chemistry controls. Are  
19 you water chemistry controls changed from those days?  
20 At least I read it was attributed to stress corrosion  
21 cracking, chlorides, and stagnate oxygen levels.  
22 Materials will still crack with chlorides and oxygen.

23 MR. VINCENT: I wouldn't want to compare  
24 a compare today with your earlier program. I will say  
25 today we are rigorous about complying with the EPRI

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 standards for primary and secondary controls.  
2 Primary, of course, applies to the control rod drives.  
3 I wouldn't make any claims that we do much better or  
4 worse today than we did back then.

5 Go ahead, Paul.

6 MR. HARDEN: This is Paul Harden, the site  
7 Vice President at Palisades. I can answer the  
8 question on a number of facets. First off, chemistry  
9 controls today are much better than they were early in  
10 plant life. The EPRI guidelines have --

11 DR. SHACK: I mean, it wasn't all that  
12 ancient history.

13 MR. HARDEN: Relative to the control rod  
14 drive housing cracking issue, it requires a couple of  
15 things for the primary water stress version cracking.  
16 One of the environment but the other is the residual  
17 stresses that drive the cracking.

18 The original housings were designed and  
19 manufactured with a technique that left a significant  
20 amount of residual stresses. As a matter of fact,  
21 grinding that had been done on the inside of them to  
22 smooth out welds left lots of stress risers and things  
23 that led to the cracking manifesting itself.

24 When we replaced those housings, we  
25 improved both the materials as well as the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005



1 manufacturing techniques using the latest technology  
2 to ensure that all the stresses that historically due  
3 to the older manufacturing techniques had stress  
4 risers were actually manufactured in a manner that put  
5 it in a compressive stress rather than tensile stress  
6 to reduce the susceptibility.

7 MR. VINCENT: I would like to touch  
8 briefly on commitment management. SER Appendix A does  
9 list the commitments for future action that we made  
10 during the course of the NRC review. We have entered  
11 those commitments into our plant corrective action  
12 tracking program which is the way we manage all our  
13 commitments.

14 In addition, program descriptions, the  
15 TLAA descriptions, and the commitments will be  
16 incorporated into the FSER so we will control the  
17 implementation of those commitments.

18 MEMBER WALLIS: Can I say something about  
19 commitments here? There are 55 commitments or  
20 something like that. Lots of new or enhanced  
21 programs. I was just curious why it took license  
22 renewal to sort of initiate all these programs. I  
23 would have thought they would have been initiated as  
24 matter of cost anyway because they were needed. It  
25 seems as if it took license renewal to get you to do

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 all that.

2 MR. VINCENT: Well, most of the  
3 commitments do represent enhancements to programs that  
4 were already in existence that we decided as a result  
5 of license renewal we wanted to make. Some were made  
6 to bring us into alignment with the GALL. A major  
7 goal during the process was not to make sure  
8 everything aligned with the GALL.

9 We were going to manage our activities in  
10 the way that we thought made economic sense to get the  
11 quality we wanted, etc. Being exactly equivalent to  
12 GALL wasn't necessarily a goal but we did make a  
13 number of changes to be consistent with GALL.

14 I'm not sure that the total number is too  
15 inconsistent with the numbers of commitments that were  
16 made by other licensees. I will point out in that  
17 Appendix A list that during the course of the reviews  
18 we made a number of short-term commitments to provide,  
19 for example, comparison between the GALL version of  
20 the chemistry standards, the EPRI standards for  
21 chemistry, and the version of the EPRI chemistry  
22 standard that we had implemented on site, things like  
23 that.

24 Those were short-term commitments. They  
25 were rough numbers, a dozen of those. Those are also

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 listed in Appendix A but those are closed so the  
2 actual number of commitments for future action is in  
3 the low 40s.

4 CHAIRMAN SIEBER: On the other hand you  
5 have 40 some commitments and basically five years to  
6 do them. Is that correct?

7 MR. VINCENT: That's correct.

8 CHAIRMAN SIEBER: That's a lot of work, or  
9 it can be depending on what the scope of each  
10 commitment is.

11 MR. VINCENT: That's correct.

12 CHAIRMAN SIEBER: Are you prepared to get  
13 that work done before the current license expires?

14 MR. VINCENT: Absolutely. One thing I  
15 would point out, it is not unusual for license renewal  
16 project teams to be dissolved basically at the point  
17 where the license is issued and then rely on the plan  
18 to implement all these new commitments. We have  
19 designed our project so this team will stay in  
20 existence through 2007.

21 By the time we are done in 2007 we will  
22 have implemented all the new programs. We'll turn  
23 over to the plant effective functioning programs. We  
24 won't rely on them to implement this work in the  
25 future.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 CHAIRMAN SIEBER: It seems to me that if  
2 you take the ordinary plant staff and throw in a big  
3 bundle of work like this in a limited amount of time  
4 there will be a question, particularly for somebody  
5 like me who doesn't know the details of every one of  
6 these as to whether you are going to finish.

7 MR. BROSchAK: This is John Broschak.  
8 What I can tell you is the site staff outside of the  
9 license renewal project team has been very engaged and  
10 integrated with these activities. The system  
11 engineers in particular have provided their input and  
12 reviewed the proposed program changes that were to be  
13 made. They certainly aren't as intimate with the  
14 details that the project team is but there has been a  
15 tremendous amount of interaction with the normal plant  
16 staff.

17 Also the way the schedule has been  
18 arranged, we expect to see integration of the project  
19 teams members and to certain strategic positions of  
20 the plant staff. We are very confident that we are  
21 not only going to get these programs into place but we  
22 are very effectively looking at them.

23 MR. TURNER: This is Darrel Turner. I've  
24 got one follow-up just to make it clear. Right from  
25 the onset of the license renewal project when we got

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 into developing the programs in alignment with the  
2 GALL, we included the program engineers, about a dozen  
3 of them, in the plant from which we all came to be  
4 involved with the development of these programs and  
5 revised programs.

6 Not only involved, they were reviewers and  
7 subsequent approvers of the programs along with their  
8 department heads so we've got a good alignment with  
9 the plant people, as John said, to transition over the  
10 next year and a half to slightly less than two years  
11 every one of those commitments.

12 CHAIRMAN SIEBER: I would like to -- at  
13 the risk of disrupting your entire presentation, I  
14 would like to go back to something that you said maybe  
15 15 minutes ago where you adopted the spaces approach  
16 to scoping. I presume that the way you identified  
17 what is in scope is to take PNIDs and take a colored  
18 pen and mark all the things that are in scope in a  
19 spaces environment, particularly where you have walls  
20 which may be a boundary point for two over one  
21 configurations and so forth.

22 PNID really doesn't lend itself to that  
23 kind of thing. How did you deal with determining what  
24 is the anchor point, how do I show it on a drawing,  
25 how do I make sure that somebody in the future who you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 may have just hired understands the document that you  
2 have so they know what is in scope and apply a program  
3 to it. How did you do that?

4 MR. VINCENT: Mark Cimock, our mechanical  
5 lead.

6 MR. CIMOCK: This is Mark Cimock,  
7 mechanical lead with NMC. What you are saying is  
8 true. We started out with PNIDs primarily for the A-1  
9 work and scoping which is very conducive to and even  
10 some A-3. We had not originally done a spaces  
11 approach but we had originally used a couple criteria  
12 that we changed in terms of duration and distance.

13 When we went back, the way that we pretty  
14 much did that, one thing that helped us considerably,  
15 as Bob pointed out, we've all been with the plant for  
16 a long time and the major leads involved know the  
17 plant quite well. We were able to do a couple things.

18 One is that we did sorts of our equipment  
19 database to try to find out what rooms various  
20 components existed in and if there was any other item  
21 that showed up in that room automatically got put in  
22 and we would identify what all those specific  
23 components were. We would connect the dots, if you  
24 will, between them to include the piping.

25 Then we did a final check basically that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 looked for any room that we identified wasn't in scope  
2 we would walk it down to ensure that there wasn't  
3 anything there just to make sure there's no problems  
4 with the equipment database. We are able to do it  
5 with a combination of looking at the paper, looking at  
6 the equipment database, and filling in with selective  
7 walk-downs.

8 As far as how we showed it on the  
9 drawings, that did create some confusion sometimes  
10 because sometimes the color would stop in the middle  
11 of the pipe and then would continue. There were  
12 questions that came out of the RAIs and the audits as  
13 to why did this stop here. It was typically because  
14 that's where changed areas and changed buildings or  
15 rooms.

16 CHAIRMAN SIEBER: When we get to the  
17 Region III discussion of what went on, I'm going to  
18 ask the same question. Was the documentation that the  
19 licensee provided to you to demonstrate that scoping  
20 was properly done, was it clear what was in scope and  
21 what was not based on the documents that you looked  
22 at? You can wait until it's your turn to answer that.  
23 Make a note of that because I think it's important.  
24 I think it's an opportunity to make a mistake. Okay.  
25 Thank you very much. Appreciate it.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 MR. BROSCHAK: This is John Broschak. If  
2 it's all right, I'll get back to the presentation. I  
3 don't feel that we've been detailed but I'll keep to  
4 the script at this point.

5 CHAIRMAN SIEBER: I'll try harder next  
6 time.

7 MR. BROSCHAK: I would like to go over a  
8 few technical issues that we thought would be of  
9 interest to the Subcommittee and address them  
10 directly. Those issues will be pressurized thermal  
11 shock, intergranular separation, also known as  
12 underclad cracking, and some discussion of Generic  
13 Safety Issue 191, or the PWR Sump Performance Issue.

14 For pressurized thermal shock Palisades is  
15 projected to reach the screening criteria in 2014  
16 using the existing rule in 10 C.F.R. 50.61. We have  
17 known this for over 10 years and have employed  
18 aggressive flux reduction strategies through the use  
19 of ultra-low leakage cortizines to minimize the impact  
20 of that flux influence on reactor vessel  
21 embrittlement.

22 We have also participated actively with  
23 NRC research programs developing updated methodologies  
24 for analyzing this issue and evaluating it. We have  
25 alternatives available to manage the issue for the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005



1 period of extended operation. We are also aware of  
2 proposed rulemaking to 10 C.F.R. 50.61 which may  
3 preclude the need for a plant specific management  
4 strategy but we are not counting on that because we  
5 have alternatives that we will implement.

6 CHAIRMAN SIEBER: How many capsules do you  
7 have left?

8 MR. BROSchAK: I'll refer to John  
9 Kneeland, our TLAA Lead.

10 MR. KNEELAND: This is John Kneeland, NMC,  
11 Palisades. We have three what we call wall capsules  
12 remaining in the reactor vessel. They have about a 20  
13 percent lead factor on what the vessel would see. We  
14 also have one that is called a thermal capsule which  
15 sits above the core and does not get the fluence.

16 DR. SHACK: Suppose you got the rule  
17 change and the screening criteria went up? Would you  
18 let a few more neutrons leak out? Does the low-  
19 leakage core really inhibit your operation?

20 MR. KNEELAND: This is John Kneeland  
21 again. It is a cost and we would take that into  
22 account but we would have to evaluate that against how  
23 long we want to operate the vessel.

24 CHAIRMAN SIEBER: In effect, the low-  
25 leakage cores require more fuel and more expensive

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 fuel management techniques. What you are paying for  
2 is neutrons that you would otherwise expend into the  
3 vessel wall. It seems to me that the balance between  
4 the margin that you have in core analysis space and  
5 your ultimate power level versus the fluence that you  
6 put to the vessel wall. It is manageable but it does  
7 cost money to do that.

8 MEMBER WALLIS: Ultra-low leakage sounds  
9 impressive. By how much is it reduced from what it  
10 was before?

11 MR. KNEELAND: This is John Kneeland  
12 again. We have reduced it at least in half.

13 MEMBER WALLIS: It's significant. Ultra-  
14 low sounds --

15 MR. KNEELAND: By ultra-low we mean we  
16 can't do a whole lot more.

17 CHAIRMAN SIEBER: You would be surprised  
18 what you can do when you have to.

19 MEMBER WALLIS: What are these  
20 alternatives you mentioned here?

21 MR. BROSCHAK: We can use site specific  
22 material sampling and analysis and using the existing  
23 master curve methodology to develop a pressure  
24 temperature curve that we could use for the period of  
25 extended operation.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 MEMBER WALLIS: You have scoped that out  
2 and satisfied yourselves that would work out okay?

3 MR. BROSCAK: Yes.

4 MEMBER MAYNARD: What are you using now to  
5 justify 20 additional years of operation. Take it  
6 from 2011 to 2031, I guess. I'm not sure what I'm  
7 hearing here, whether you are taking a position were  
8 there alternatives available to us or whether you're  
9 saying this justifies operation now. We do have other  
10 alternatives available to us.

11 MR. BROSCAK: The rule requires us to  
12 submit our plan three years prior to the expiration of  
13 existing license or the time of reaching the screening  
14 criteria.

15 CHAIRMAN SIEBER: There are a couple of  
16 things that are the issue here. The question is will  
17 you exceed the screening criteria before the end of 40  
18 years? Then part two of that question is will you  
19 exceed it at the end of 60 years? If so, can you  
20 manage the fluence or do you go to the alternative  
21 calculation methods? What space are you in right now  
22 with that vessel?

23 MR. VINCENT: Where we sit currently we  
24 will not exceed the screening criteria by the end of  
25 the current 40-year license.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 CHAIRMAN SIEBER: Okay.

2 MR. VINCENT: If we took no action, we  
3 would exceed the screening criteria during the  
4 extended operating period. We understand the actions  
5 that will need to be taken. We will manage those  
6 actions so in license renewal space we are really  
7 talking about option 3 which is the issue will be  
8 managed for the extended operating period.

9 We can't say today what choice we will  
10 make about which options we will implement. We know  
11 those various technical options are available in the  
12 rule change. If it continues on the commissioner  
13 approved rulemaking schedule, that will give us  
14 another alternative.

15 CHAIRMAN SIEBER: Let's assume that  
16 doesn't occur. That doesn't shut you off but it  
17 narrows the options we have. Right?

18 MR. VINCENT: Clearly the methodology that  
19 the rule bases its limits on is fixed in the rule so  
20 to depart from that methodology will require an  
21 exemption from that rule. The exemptions could be  
22 based, as John mentioned, on master curve technology  
23 which has been implemented at a couple of other  
24 plants.

25 It's not a new technology to the industry.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 There may be some other technical alternatives  
2 including the safety analysis that the rule requires  
3 to justify continued operation beyond the acceptance  
4 criteria embedded in the rule. There are analytical  
5 options that may involve exemptions to the rule.

6 MEMBER WALLIS: You could reduce power.  
7 You could put in a call which is so low leakage that  
8 it actually produces less power than you produce  
9 today.

10 MR. VINCENT: Lower-power core is  
11 certainly an alternative, yes.

12 MEMBER BONACA: You will have to submit a  
13 plan by 2008?

14 MR. BROSCHAK: 2011.

15 MEMBER BONACA: 2011. Oh, three years  
16 before you reach --

17 MR. BROSCHAK: Right.

18 MEMBER BONACA: Okay. So you do have time  
19 to that point. By the time you are walking through  
20 license renewal you have to have a plan.

21 MR. BROSCHAK: Correct.

22 MEMBER MAYNARD: Even though you get a 20-  
23 year extension to the license, that still does not  
24 authorize you to operate outside the rule. If all  
25 these alternatives fell apart, you wouldn't be allow

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 to operate.

2 MR. BROSCAK: Right.

3 CHAIRMAN SIEBER: That's the same  
4 condition they are in right now. If you don't meet  
5 the criteria, it doesn't make any different how long  
6 your license is, you shut down.

7 MEMBER MAYNARD: I think it's important to  
8 note getting the license renewal doesn't authorize  
9 operation outside of safety limits or regulations.

10 CHAIRMAN SIEBER: Another quick question  
11 that you can just give me a number for. In order to  
12 calculate the integrated fluence to the vessel you  
13 have to make an assumption about the capacity factor.  
14 What assumption did you use regarding your capacity  
15 factor from initial operation until now and what  
16 assumption are you using from now until the end of  
17 life?

18 MR. VINCENT: John Kneeland, would you  
19 like to --

20 MR. KNEELAND: This is John Kneeland  
21 again. We used our actual operating capacity for the  
22 past which has been somewhat less than we assume for  
23 the future. For the future we're assuming  
24 approximately a 90 to 91 percent capacity factor.  
25 It's not as much as we'd like.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 CHAIRMAN SIEBER: It's been increasing.

2 MR. KNEELAND: The last several years have  
3 been very good.

4 CHAIRMAN SIEBER: I'll just leave it at  
5 that.

6 MEMBER WALLIS: On the big NRC research  
7 program on PTS, wasn't Palisades one of the cuts they  
8 made or am I forgetting something?

9 MR. VINCENT: No, Palisades is one of the  
10 participants.

11 MEMBER WALLIS: What did they conclude  
12 about PTS for Palisades in the light of their most  
13 recent work?

14 MR. KNEELAND: This is John Kneeland  
15 again. I have only seen a draft of the study so I  
16 can't say for sure what the conclusion is but my  
17 understanding is that PTS would not be considered an  
18 issue.

19 MEMBER WALLIS: Maybe there is some  
20 incentive for NRC to finish up that work.

21 CHAIRMAN SIEBER: Actually, there is more  
22 than one plant in that study. I think the conclusion  
23 was the same for all.

24 MEMBER WALLIS: It was a very thorough  
25 study. It was very impressive to us. We had some

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 comments on it and we were hoping that it would come  
2 formally issued and be useful. We still hope that.

3 CHAIRMAN SIEBER: That would be good.

4 MR. VINCENT: We do, too.

5 MR. BROSHAK: This is John Broschak.

6 CHAIRMAN SIEBER: And the licensee.

7 MR. VINCENT: NUREG is still not a change  
8 in the regulations.

9 CHAIRMAN SIEBER: Right.

10 MEMBER WALLIS: But it might lead to a  
11 change in the regulations.

12 MR. VINCENT: Yes, they are working on  
13 that.

14 CHAIRMAN SIEBER: Continue.

15 MR. BROSHAK: This is John Broschak  
16 again. This has fun but we'll move on to the next  
17 technical issue. Intergranular separation or  
18 underclad cracking is the phenomenon that was  
19 identified in the 1970s and was dispositioned at that  
20 time as being acceptable for a 40-year operation  
21 period.

22 Westinghouse specific plants has produced  
23 a WCAP where they have provided a methodology to NRC  
24 and shown acceptable results in terms of crack growth  
25 or any effect on the reactor vessel for those plants.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005



1 Palisades has been evaluated using the  
2 same mythology and we have produced results that show  
3 that there is little or no crack growth over a 60-year  
4 period and that any potential cracks would have no  
5 effect on the structural integrity of the reactor  
6 vessel. Those results have been reported to the NRC  
7 for review and acceptance.

8 MEMBER ARMIJO: The no-crack growth issue,  
9 was that by analysis, strictly by analysis, or was  
10 there any measurement made?

11 MR. BROCHAK: I'll defer to John  
12 Kneeland.

13 MR. KNEELAND: John Kneeland again. It's  
14 both. We had in-service inspection results that have  
15 shown that some of the cracks that we did see have not  
16 propagated at all between the inspections. We also  
17 did a fatigue crack growth evaluation that is part of  
18 the WCAP.

19 MEMBER ARMIJO: What was the period of  
20 time between those inspections?

21 MR. KNEELAND: Twelve years.

22 MR. BROCHAK: John Broschak. Those  
23 inspections were 1983 and in 1995.

24 CHAIRMAN SIEBER: Now, this item is the  
25 confirmatory item --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 MR. BROSCAK: Correct.

2 CHAIRMAN SIEBER: -- that's listed in the  
3 SER so you have determined that the WCAP is applicable  
4 to your plant and you sent that response into the  
5 staff a week ago?

6 MR. VINCENT: Yes, it was about a week  
7 ago.

8 CHAIRMAN SIEBER: So the staff hasn't had  
9 an opportunity to determine whether you meet the  
10 requirement or not.

11 MS. LUND: This is Louise Lund. The staff  
12 is still reviewing it so we got it in house and it's  
13 been sent over to the technical staff.

14 CHAIRMAN SIEBER: Okay. It's important  
15 that we know what the status is. It is particularly  
16 important that it be resolved before we meet again.  
17 I'm glad that the applicant is doing the work to make  
18 that happen and perhaps there will be a good outcome  
19 from the staff's review. There will be an outcome  
20 from the staff's review. Okay.

21 MR. BROSCAK: John Broschak, technical  
22 issue No. 3, Generic Safety Issue 191, Assessment of  
23 Debris Accumulation on PWR Sump Performance. This  
24 Generic Safety Issue is applicable to all pressurized  
25 water reactors and the methodology defined in Generic

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 Letter 2004-02 is being implemented at Palisades in  
2 accordance with the requirements of that Generic  
3 Letter. Palisades will be installing a passive  
4 strainer system in addition to any other required  
5 modifications.

6 MEMBER WALLIS: That's what you have  
7 already, isn't it?

8 MR. BROSCAK: Correct.

9 MEMBER WALLIS: So you are going to  
10 install a different one?

11 MR. BROSCAK: The methodology and the  
12 assumptions that are now required to fully address the  
13 issue as described in the Generic Letter and in the  
14 NEI guidance documents require a different type of  
15 strainer system.

16 MEMBER WALLIS: How much bigger will it  
17 be? I assume it's going to be bigger.

18 MR. BROSCAK: It's going to be much  
19 bigger.

20 MEMBER WALLIS: By how much? Is it a  
21 factor of 10 or 100 or something like that?

22 MR. BROSCAK: Between a factor of 80 and  
23 100.

24 MEMBER WALLIS: So you're putting in about  
25 as big a strainer as you can fit in. Is that it?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 MR. BROSCAK: We're putting in the size  
2 strainer necessary based on the results of the  
3 methodology.

4 MEMBER WALLIS: A hundred times as big as  
5 it was before? Do you remember how big it was before?

6 MR. BROSCAK: The Palisades arrangement  
7 is underneath of the reactor vessel and has two trains  
8 with subscreens. The approximate size of the  
9 subscreens is 50 square feet.

10 MEMBER WALLIS: But they were tiny before.

11 MR. BROSCAK: They are tiny right now.

12 CHAIRMAN SIEBER: Smaller than they will  
13 be.

14 MEMBER WALLIS: Okay. So they are going  
15 to something like 5,000 square feet.

16 MR. BROSCAK: The order of 3,000.

17 CHAIRMAN SIEBER: Just for the record, I  
18 would point out that this issue would be there whether  
19 you were in license renewal space or not, as well as  
20 the reactor vessel embrittlement issue. There is  
21 nothing that specifically ties this to license  
22 renewal. It is good that you tell us what you are  
23 doing but it really doesn't have a bearing on the  
24 outcome. You've got to do it whether you get your  
25 license renewed or not.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 DR. SHACK: Is the installation primarily  
2 cal-sil or a mix? What kind of fraction of cal-sil  
3 versus fiber glass?

4 MR. BROSCAK: Palisades has a large  
5 amount of cal-sil and a large amount of fiber.

6 MEMBER WALLIS: Are you going to take out  
7 the cal-sil?

8 MR. BROSCAK: At this time we are not  
9 planning to take the cal-sil out.

10 MEMBER WALLIS: It is something you might  
11 consider doing if you had to because cal-sil is one of  
12 the offenders in subscreen blockage.

13 MR. BROSCAK: I agree with you totally  
14 that the debris that's in PWR containments are  
15 offenders in terms of sub-blockage. The complexity of  
16 the issue in terms of particulate or fiber has become  
17 quite a fascinating science in terms of understanding  
18 exactly how the phenomenon works so I can tell you  
19 from the results that I've seen on specific testing  
20 that it does get down to a site specific evaluation of  
21 your particular mix of debris.

22 That is how we have these programs  
23 structured now. We will make the appropriate removal  
24 of insulation and sizing of screens and flow rates  
25 that are necessary to meet the requirements in the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 Generic Letter.

2 MEMBER WALLIS: Any idea of the volume of  
3 insulation that comes off in a large break LOCA?

4 MR. BROSCAK: I do but I would not want  
5 to quote that in this setting off the top of my head.  
6 That has all been submitted on the docket.

7 MEMBER WALLIS: Okay. We've heard numbers  
8 of several thousand cubic feet. Yours maybe is one of  
9 the plants that has a lot.

10 MR. BROSCAK: Those are very qualitative  
11 terms and I would defer to what has already been  
12 submitted on the docket.

13 CHAIRMAN SIEBER: Almost as bad as ultra-  
14 low leakage.

15 MEMBER WALLIS: There's nobody here who  
16 knows the number and more than just a vague statement?  
17 You don't have an expert here who knows how much?

18 MR. BROSCAK: Since this is not a license  
19 renewal we didn't bring those experts with us.

20 MEMBER WALLIS: Something we have to be  
21 concerned about if we are going to allow the plant to  
22 keep operating.

23 MR. BROSCAK: As I have stated here, we  
24 will be in full compliance with the Generic Letter  
25 requirements by the end of 2007. There's no question

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 in my mind. We understand that this is independent.

2 MEMBER WALLIS: But you will claim to be.

3 MR. BROSCAK: No, we will be.

4 MEMBER WALLIS: If the staff knows what  
5 those requirements are. You've got to show that  
6 you're in compliance which is a very vague sort of  
7 statement. You will make a case and then someone is  
8 going to say whether it's good enough or not. I know  
9 you intend to be in compliance.

10 MR. BROSCAK: We tend to be our own worse  
11 critics and make sure that we can make that case to  
12 any external stakeholder. As long as I'm the engineer  
13 director we will make a strong case.

14 DR. SHACK: You're going to do a manual  
15 injection of sodium hydroxide then to control your  
16 sump pH? That will be the intent there rather than  
17 doing it without pH control?

18 MR. BROSCAK: The Subcommittee has  
19 effectively got me off my presentation so I will jump  
20 back in.

21 The third bulleted item is to note that  
22 due to the information notice on potential chemical  
23 effects of the interaction of trisodium phosphate with  
24 cal-sil insulation, Palisades is taking prompt and  
25 aggressive action to remove trisodium phosphate until

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 the final solution from the Generic Letter is in place  
2 in the fall of 2007. That license amendment request  
3 involves removal of trisodium phosphate and  
4 implementation of provisions for manual injection of  
5 sodium hydroxide.

6 It is worthy to note to the Subcommittee  
7 that we have demonstrated through calculation that no  
8 buffer is required to meet both off-site dose and  
9 control room limits and, of course, with federal  
10 regulations. We are choosing to inject the sodium  
11 hydroxide to address potential corrosion issues.

12 MEMBER WALLIS: You have aluminum in this  
13 part?

14 MR. BROSCAK: There is some aluminum in  
15 the containment, yes.

16 MEMBER WALLIS: Sodium hydroxide has  
17 interactions with aluminum that produces stuff.

18 MR. BROSCAK: Correct.

19 MEMBER WALLIS: And affects screens.

20 MR. BROSCAK: And that has all been --

21 MEMBER WALLIS: We don't know much about  
22 it. We know it's in effect but we don't know how to  
23 predict it. It would be interesting to see how you  
24 are going to predict it.

25 MR. BROSCAK: You're right. In addition,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005



1 an alternate buffering system will be installed as  
2 part of the overall solution to the Generic Letter by  
3 the fall of 2007. In other words, we do not intend at  
4 this time to go back to trisodium phosphate.

5 MEMBER WALLIS: You're looking at a  
6 different buffering system all together which would  
7 not necessarily be sodium hydroxide.

8 MR. BROSCAK: Correct. There is a lot of  
9 activity going on with Westinghouse owners group right  
10 now to identify more acceptable buffering agents and  
11 we would intend to use the output of that work,  
12 evaluate for our plan application, and then implement  
13 the appropriate item.

14 DR. SHACK: So your license amendment  
15 hasn't been approved yet?

16 MR. BROSCAK: That license amendment is  
17 under review by the staff at this time.

18 MEMBER WALLIS: Is it a fairly simple to  
19 take out TSP. It's just sort of sacks of something in  
20 containment. You just take it out. Is it a fairly  
21 simple matter to take it out?

22 MR. BROSCAK: Yes, sir. In nuclear power  
23 some things are simple. This one in particular --

24 MEMBER WALLIS: Removing things from  
25 containment can be very tricky but this is a simple

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 one.

2 MR. BROSCAK: These are fairly large  
3 baskets that contain the trisodium phosphate and they  
4 need to be picked up and removed and that's --

5 MEMBER WALLIS: It's not as if they are  
6 inaccessible or anything.

7 MR. BROSCAK: No. In fact, we made  
8 provisions during our last refueling outage to put  
9 them in a lower dose area so that it will be easier to  
10 remove them.

11 MEMBER BONACA: I have a question on the  
12 inaccessible non-EQ medium voltage cables. I know you  
13 have committed to essentially the process of GALL.  
14 One of the inspection reports show that you had  
15 manhole flooded and that you did not really find it,  
16 the NRC inspectors found it. It's hard to understand.  
17 I mean, so you do have a program for license renewal?  
18 Do you have a program now that you are going to  
19 implement?

20 MR. VINCENT: Yes, we do have a program  
21 now. Larry, would you like to talk about underground  
22 cables?

23 MR. SEAMANS: Yes. This is Larry Seamans,  
24 Palisades license renewal. Just prior to the NRC  
25 inspection as part of the license renewal I went out

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 and looked at these manholes and I at that time found  
2 water. There are three manholes. They are all tied  
3 together as far as a drain system. At that point I  
4 had the water removed. We did no more until the NRC  
5 came on site.

6 At that time -- well, I'm sorry. We did  
7 initiate corrective action document at that time also  
8 besides pumping it out to get the long-term corrective  
9 action into place. A little over a month later the  
10 NRC was on-site. We again looked at the holes. The  
11 water in there was significantly less but subsequent  
12 to that we have initiated corrective action that  
13 initiated a periodic activity that removes the water  
14 monthly. After the second removal of the water we  
15 have seen no more accumulation of water in the monthly  
16 reviews.

17 Besides that, the plant about 10 years ago  
18 initiated testing of all of these cables safety  
19 related, even non-safety related, medium voltage  
20 cables that go through these manholes and those are  
21 tested on a frequency of every other refueling outage  
22 currently. The commitment for license renewal is that  
23 we will test them at least every 10 years. It looks  
24 like currently we are on about an every four or five-  
25 year frequency. That is what we do currently.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 CHAIRMAN SIEBER: How do you test?

2 MR. SEAMANS: Larry Seamans again. The  
3 way we test those is with the MEGER. In the future we  
4 are actually going to do a MEGER and a polarization  
5 index. We have also stated that if there is some  
6 other type of testing that comes out and is developed  
7 and is proven that we will commit to doing that new  
8 type of testing also.

9 MEMBER WALLIS: I think it's a very old  
10 technique. My dad used to do that.

11 MR. SEAMANS: But we have some good  
12 results from that, too.

13 MEMBER WALLIS: Lots of your commitments  
14 have to do with inspections of varied tanks and things  
15 like that. Are you satisfied that you got the  
16 technology to do that or are you looking for some  
17 improved methods?

18 MR. VINCENT: Bob Vincent. I think in  
19 general we are not looking for any new technology to  
20 support any of our new programs with the exception  
21 that one of the commitments relates to reactor  
22 internals. Currently we are doing visual inspections  
23 that are required routinely under ASME Section 11, but  
24 we are also -- our commitment is to monitor what is  
25 happening with the MRP.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1           When the industry recommendations come out  
2           on the appropriate future testing or inspection  
3           program for internals, we will provide -- we will  
4           revise our internal program and submit that to the  
5           staff for review. There are only a couple of  
6           commitments that are similar to that one.

7           MEMBER WALLIS: There is an industry-wide  
8           approach to that.

9           MR. VINCENT: That's correct.

10          MEMBER WALLIS: You are satisfied that you  
11          can get enough measurements that are accurate enough  
12          and all that?

13          MR. VINCENT: Buried tanks -- Mark, would  
14          you like to talk about buried tanks?

15          MR. CIMOCK: This is Mark Cimock,  
16          mechanical lead, NMC. We only have one buried tank  
17          part of our program which is actually in a vault.  
18          It's our fuel source tank. Buried tanks really isn't  
19          an issue. The one that we have, like I say, is in a  
20          vault. It does have dry compacted sand around it. It  
21          is a double-walled tank that has moisture detection.  
22          Buried tanks really isn't a problem at Palisades. We  
23          do have a Buried Services Program but that gets into  
24          buried piping and it may be another subject all  
25          together.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 DR. SHACK: Just in your environmental  
2 impact statement you sort of evaluated a number of  
3 severe accident management alternatives that had  
4 positive values. You implemented one of them that  
5 gave you the big benefit. Are you planning on  
6 implementing any of the others?

7 MR. HARDEN: This is Paul Harden, site  
8 vice president. With the severe accident management  
9 alternatives the station is committed and will  
10 continue to evaluate the various alternatives and the  
11 benefit that they provide.

12 However, the list as it is, the benefit  
13 provided is each one individually, as you implement  
14 one you then have to go back and revisit all the  
15 others to reevaluate the benefit because, for example,  
16 the supplemental diesel generator that was installed,  
17 the benefit for many others that we listed is actually  
18 negated by installation of that one so we just  
19 completed implementation of the supplemental diesel  
20 generator.

21 We are committed and we have budget in our  
22 future budgets to continue to evaluate other  
23 alternatives and what benefit they are going to  
24 provide and to look for additional ways to reduce the  
25 overall plant risk profile.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1                   MEMBER MAYNARD:    One of those that I  
2                   didn't understand clearly was on the turbo driven aux  
3                   feedwater pump.  You had installed a turbine driven  
4                   aux feedwater pump but apparently the one that you  
5                   have in there can't be operated manually.  You can't  
6                   control the flow manually so one of the SAMAs was to  
7                   install a control system for that where you could  
8                   control it manually.  Did I misread that?

9                   MR. VINCENT:  Brian Brogran, our PRA lead,  
10                  will address it.

11                  MR. BROGAN:     Brian Brogran from PSA.  
12                  Simply what we are going to do is proceduralize  
13                  throttling that turbine driver during the station  
14                  blackout of that.  We have controls in place.  What we  
15                  have to do is just match flow with decay heat.  It's  
16                  something that we have in other pieces of procedures  
17                  that address Appendix R and other issues but we want  
18                  to formalize it for this specific application.

19                  MEMBER MAYNARD:  Okay.  So the equipment  
20                  is there.  You're talking about procedures and  
21                  criteria.

22                  MR. BROGAN:     That's correct.  It is a  
23                  simple thing to do and we want to proceed with that  
24                  action.

25                  CHAIRMAN SIEBER:  So you're going to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 throttle the steam valve into the program?

2 MR. BROGAN: Correct.

3 CHAIRMAN SIEBER: In what parameter will  
4 you look at that is available at the steam valve to  
5 tell you how much to throttle?

6 MR. BROGAN: We are going to have pressure  
7 indication up stream and down stream and we should be  
8 able to correlate that back into the requisite flow.

9 CHAIRMAN SIEBER: What you are really  
10 trying to achieve is the right level.

11 MR. BROGAN: Correct.

12 CHAIRMAN SIEBER: Not the right flow and  
13 not the right pressure but level.

14 MR. BROGAN: We want to maintain level.

15 CHAIRMAN SIEBER: Whoever is operating  
16 that valve won't know what the level is. You'll have  
17 to be on the telephone or something. Is that correct?

18 MR. BROGAN: Yes, that's correct.

19 CHAIRMAN SIEBER: And you aren't going to  
20 do anything about that. That's a hard thing to do.

21 MR. HARDEN: If I can, this is Paul Harden  
22 again. That list of SAMA candidates, those are  
23 concepts at this point in time. The only one that has  
24 been taken through the study phase to in-depth layout  
25 all the details and what would be required is the one

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005



1 we just finished implementation of with the  
2 supplemental diesel generator.

3 For each one of those, as Brian and his  
4 staff do the work to now go back and reevaluate the  
5 candidates, we'll then take it through a study phase  
6 to scope out what exactly would it take to ensure  
7 ourselves we can do that and do that safely. Then  
8 once we understand what that would take evaluate the  
9 cost benefit from the risk reduction we would gain.

10 CHAIRMAN SIEBER: Okay. I presume you  
11 would prefer I not help you design it.

12 MR. HARDEN: Tell them it's hard to do.

13 CHAIRMAN SIEBER: Any other questions from  
14 the Committee? If not, thank you very much for your  
15 presentation. What I would like to do is start into  
16 the SER overview and perhaps do the scoping and  
17 screening results. Then we can take a break after  
18 that and then we'll come back and do the on-site  
19 inspection results.

20 MS. LUND: Thank you. I'm going to go  
21 ahead and turn this over. Thank you for the Palisades  
22 license renewal staff to give their presentation and  
23 I'm going to turn it over to Mr. Juan Ayala who is the  
24 project manager for the Palisades review with the NRC  
25 staff.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 MR. AYALA: Good afternoon. My name is  
2 Juan Ayala and I am the project manager for the  
3 staff's review of the Palisades license renewal  
4 application. Joining me today I have Patricia  
5 Lougheed who is the inspection team leader from Region  
6 III. Also, I have Robert Hsu who is the audit team  
7 leader. Also present in the audience is members of  
8 the technical staff that are here to answer any  
9 questions I cannot answer for you.

10 These are the topics that we'll be  
11 covering today. I'll start with an overview of the  
12 plant and the application followed by discussion of  
13 the scoping and screening results. I'll turn it over  
14 to Patricia who will talk about the license renewal  
15 inspection and then I'll take over and talk about the  
16 aging management review and the time-limited aging  
17 analyses.

18 The license renewal application was  
19 submitted by letter dated March 22, 2005. Palisades  
20 is a combustion engineering PWR with dry AMB  
21 containment and illustrated at 2565 MWth and 865 MWe.

22 MEMBER WALLIS: You have a different  
23 number from what they have.

24 MR. AYALA: The number that the applicant  
25 had is net capacity.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 MEMBER WALLIS: 820 they have.

2 MR. AYALA: That number is net capacity.  
3 This is what it's rated at.

4 MEMBER WALLIS: They actually operate it  
5 at 820.

6 MR. AYALA: They operate at 865 and then  
7 they use -- I guess if the applicant can answer that  
8 a little bit more.

9 MR. KNEELAND: This is John Kneeland. 820  
10 is the maximum that we put out to the grid so that 865  
11 minus in-house loads equals the 820.

12 MEMBER WALLIS: Ah, okay. It's just nice  
13 to have the same number presented by the staff and the  
14 applicant.

15 MR. AYALA: Okay. I'll continue. Once  
16 again, I'm Juan Ayala. The operating license DRP-20  
17 expires March 24, 2011 and the plant is located five  
18 miles south of South Haven, Michigan.

19 This slide right here shows that the SER  
20 was issued June 1, 2006, with no open items and one  
21 confirmatory item that I'll talk about a little bit  
22 later on. The license conditions are the standard  
23 license conditions for all license renewal  
24 applications that have gone through.

25 There were 174 RAIs issued as was

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 mentioned earlier. That is consistent with the review  
2 from some of the other plants that have gone through  
3 renewal. There were also 412 questions asked during  
4 the AMR and AMP audits.

5 MEMBER WALLIS: How do you keep track of  
6 questions? Do you have a transcript or something?

7 MR. AYALA: We have all the questions --

8 MEMBER WALLIS: Are they written down?

9 CHAIRMAN SIEBER: They are all written  
10 down.

11 MR. AYALA: All the questions are written  
12 down and the applicant has a database that when we ask  
13 a question they keep track of it and they provide  
14 those responses to us.

15 MEMBER WALLIS: You also ask verbal  
16 questions?

17 MR. AYALA: Yes, we do. Those verbal  
18 questions are not captured in the 412. It's just the  
19 questions that we provide in a written format that are  
20 captured here.

21 MEMBER MAYNARD: The applicants usually do  
22 a pretty good job of documenting and keeping track of  
23 all the questions that are asked.

24 MEMBER WALLIS: It would be good to know  
25 that you have 412 adequate answers as well.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 MR. AYALA: Right. All of these --

2 MEMBER WALLIS: Did you get 412 adequate  
3 answers?

4 MR. AYALA: Yes, we did.

5 MEMBER WALLIS: Okay. Thank you.

6 CHAIRMAN SIEBER: Or we wouldn't be here.

7 MR. AYALA: As Louise mentioned earlier,  
8 the application is 95 percent consistent with GALL  
9 Rev. 1. The application was submitted using Rev. 0  
10 and we did reconciliation with the September Rev. 1  
11 and that helped us in the review process. There were  
12 some minor components that were brought into scope and  
13 we will address those at the appropriate time. This  
14 slide here shows the dates of the audits and regional  
15 inspection.

16 During the scoping and screening  
17 methodology the audit team reviewed the current  
18 licensing basis for the aux feedwater system and  
19 determined that the aux feedwater pump pipe insulation  
20 was not included in the scope of license renewal. The  
21 applicant didn't include it and as a result of the  
22 staff's review, the applicant brought this component  
23 to scope of license renewal.

24 In Section 2.2, plant-level scoping, no  
25 omission of systems or structures were found in the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 scope of license renewal. For mechanical system the  
2 staff performed 100 percent scoping review of 29  
3 mechanical systems. During the scoping and screen  
4 review the staff was also on site and performed a  
5 review of some of these mechanical systems.

6 This aided the staff in answering a lot of  
7 the questions and reducing the need for RAIs. As a  
8 result of this, very few items -- I have zero items  
9 there. I was just talking to Patricia and she said  
10 there were two items that refer to the regional  
11 inspection team and she will address those in her  
12 presentation.

13 Some of the components that were brought  
14 into scope are listed on the slide here. There are  
15 quite a few so I'll just show them up there and if you  
16 have any questions on any, I can go into any of those.

17 MEMBER BONACA: There are not a few. For  
18 example, why are the feedwater heaters not included?

19 MR. AYALA: The feedwater heaters --

20 MEMBER BONACA: Is it a issue of  
21 methodology that you didn't capture it or is it just  
22 an individual judgment of the engineer that they were  
23 not being scoped?

24 MR. AYALA: I see that the applicant has  
25 her hand up and I think they want to say something so

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 let me turn it over to them.

2 MR. SEAMANS: For the feedwater heater  
3 it's feedwater heater 1A and 1Bravo. They were in  
4 scope if you looked at the drawings. It happened to  
5 be that in the description that was in the system  
6 description, it did not have them in there. As far as  
7 the components themselves, they were in a list of  
8 equipment but somehow we missed it in the description  
9 and that is what he's talking about. That is where we  
10 missed adding that to that description.

11 MEMBER BONACA: The bottom line is that  
12 you don't feel that these exceptions here mean that  
13 methodology --

14 MR. AYALA: There were several examples in  
15 here where they were in scope in the drawing but they  
16 weren't mentioned in the application and the  
17 description so after talking to them they supplemented  
18 the application and included a description for these  
19 components in there. Since they were through RAIs,  
20 that's why I have them listed up here.

21 MEMBER WALLIS: Air compressors are active  
22 elements, aren't they? It's just the casing or  
23 something that is in license renewal?

24 MR. AYALA: Yes. Active components are  
25 not screened out.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 MEMBER WALLIS: When you say air  
2 compressors, what do you mean? Aren't they active  
3 components?

4 MR. AYALA: Yes. They screened out the  
5 active components per NEI 95-10. What was screened  
6 were the housing and --

7 MEMBER WALLIS: Housing?

8 MR. AYALA: Right. Moving on, in Sections  
9 2.4, Containment, Structures, and Supports, and  
10 Section 2.5, Electrical and Instrumentation and  
11 Control, there were no omissions of components in both  
12 of these sections.

13 In conclusion to the scoping and screening  
14 methodology summary, it is the staff's determination  
15 that the applicant's scoping methodology meets the  
16 requirements of 10 C.F.R. 54.4.

17 CHAIRMAN SIEBER: Okay. I think this is  
18 a -- unless there are questions from the members, this  
19 would be a good time to take a break so let's do that  
20 and come back at quarter after 3:00.

21 (Whereupon, at 3:01 p.m. off the record  
22 until 3:21 p.m.)

23 CHAIRMAN SIEBER: I would like to  
24 introduce from Region III Patricia Lougheed who was in  
25 charge of the inspection process for this. Patricia.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005



1 MS. LOUGHEED: Thank you. As Dr. Sieber  
2 said, my name is Patricia Lougheed. I am the Lead  
3 Inspector for License Renewal for Region III which is  
4 the region which has Palisades in it. I'm not used to  
5 operating the computer so you have to --

6 As is normal for license renewal  
7 inspections we did a two-week inspection that combined  
8 scoping, screening, and aging management. We  
9 scheduled these inspections somewhat to support NRR  
10 reviews, although we ended up doing this before  
11 Monticello which you all looked at a couple of months  
12 ago so this has been a long while since I've actually  
13 been involved with Palisades.

14 As is usual with the Region III  
15 inspection, I had a team of five very experienced  
16 inspectors. We found that this has been a benefit for  
17 the Region III inspections that we have used. The  
18 same people consistently throughout the license  
19 renewal inspections so that we know that from one  
20 plant to another that we are looking at the same type  
21 of things to the same depth. We did do it in  
22 accordance with our inspection procedure.

23 Scoping and screening. To start, I'll  
24 have to admit this slide contains an error. I made  
25 this from my exit slides actually while I was on

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 vacation. I did not have access to my inspection  
2 report and I looked at the inspection report this  
3 morning. We actually looked at 14 systems rather than  
4 11. My team snuck a couple extra in on me from what  
5 was in my original plan.

6 We did look at a combination of  
7 electrical, mechanical, and structural systems with an  
8 emphasis on plant physical walk downs and also on  
9 those systems where we felt there was a safety, non-  
10 safety boundary where components would be in scope or  
11 out of scope.

12 We weren't too worried that the folks in  
13 NRR caught everything that was in scope. What we were  
14 worried about were the ones where the boundaries were  
15 rather nebulous particularly in the A-4 area of non-  
16 safety that could impact safety and that's where we  
17 really concentrated our inspection efforts.

18 Basically I'm going to go into a little  
19 bit more detail here than what is on the slide. The  
20 systems that we found, there was one case in  
21 electrical power where we found a component -- couple  
22 components that had not been scoped in. However, they  
23 were active components so they automatically screened  
24 out as soon as they were scoped in.

25 Juan had mentioned that there were a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 couple areas that NRR did ask us to look at. One of  
2 those had to do with the heating, ventilation, and  
3 cooling, particularly the penetration subcooling HVAC.  
4 That was an area that was out of scope and we looked  
5 at it and the reasons why that system was there and  
6 determined that it did not need to be in scope.

7 We also specifically looked at the HVAC  
8 for the engineer safeguards and the auxiliary  
9 feedwater system because those are safety related  
10 systems and we wanted to verify that the cooling for  
11 them indeed was not needed. We had no problems with  
12 what the licensee had done.

13 We also looked on the spent fuel pump  
14 cooling at the boron carbide panels and the boroflex  
15 panels to verify that those were appropriately  
16 screened in and that appropriate consideration was  
17 taken for the types of panels there were and the use  
18 of the boron. We had no problems with those.

19 CHAIRMAN SIEBER: Let me ask a question..  
20 When the licensee told us -- we asked the licensee a  
21 question about neutron absorbing panels and so forth  
22 and spent fuel pool and they indicated they did not  
23 take credit for boroflex. If you don't take credit  
24 for it, would it be screened out?

25 MS. LOUGHEED: I think that some of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 panels are screened out. I'm going to have to ask  
2 Mark because it's been a while since I've looked at  
3 Palisades.

4 CHAIRMAN SIEBER: Okay.

5 MR. CIMOCK: This is Mark Cimock with NMC.  
6 The fuel racks are in scope for structural support of  
7 the fuel rods but as far as the boroflex component of  
8 them, they were not credited because they were not  
9 considered in the criticality analysis. We actually  
10 did credit some soluble boron and analysis of those.  
11 The other panels that we did take credit for were the  
12 boron carbide encased in stainless steel panels.

13 CHAIRMAN SIEBER: They are in scope.

14 MR. CIMOCK: And they are in scope. The  
15 boron carbide themselves do have an antenna function  
16 of neutron absorption and we've had some back and  
17 forth in the RAI string. There's a long RAI string  
18 but basically the end result was that we felt they had  
19 no aging effect for current management but that we  
20 were going to do some blackness testing to confirm  
21 that both before the end of the current operating  
22 period and within 10 years after the extended period  
23 of operation.

24 CHAIRMAN SIEBER: Okay. Thank you.

25 MS. LOUGHEED: Basically the other

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 question you had asked whether the regional inspectors  
2 were able to clearly to see from the documents we  
3 reviewed where the boundaries lay. We looked at a  
4 number of different things when we were looking at  
5 boundary. The first thing is that from Palisades they  
6 are kind of unique that I would say probably 99  
7 percent of their equipment is in scope.

8 It seemed like everywhere we went things  
9 were actually in scope. In fact, if you read the  
10 inspection report there was one system that we chose  
11 which was shut down cooling which other plants have  
12 said, "That's non-safety related. It doesn't need to  
13 be in scope."

14 In Palisades it was 100 percent in scope.  
15 We looked at the drawings but we primarily were  
16 relying on the system scoping documents. What I  
17 remember and what I just confirmed from the licensee  
18 is that they are planning on taking the information,  
19 or at least some of the information from those scoping  
20 and screening documents I'm putting it into their  
21 plant equipment database and that will be the official  
22 way of telling what components are in scope for the  
23 future rather than a marked-up set of drawings.

24 CHAIRMAN SIEBER: I have a question then  
25 about that. As I recall, plant equipment databases,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 in some places they call them Q lists or what have  
2 you, it consist of components as opposed to lengths of  
3 pipe being in the supports and things like that which  
4 in a lot of plants are typically not in the plant  
5 equipment database because it's not really equipment.

6 It's the stuff in between the pieces of  
7 equipment. What is in your plant equipment database  
8 does it include all these long-lived passive  
9 components and lengths of pipe and so forth that  
10 typically aren't in most folks' equipment list?

11 MR. VINCENT: This is Bob Vincent. You  
12 are correct. The equipment database really has all  
13 the components that have tag numbers, ID numbers.  
14 Clearly in license renewal we have commodities that  
15 don't have tag numbers. While I can't tell you right  
16 this minute how we are going to track things that we  
17 have treated as commodities from an aging management  
18 review perspective, clearly we have to define the  
19 population that's in those commodities and capture  
20 those.

21 Whether that's kind of a new component  
22 type in an equipment database that we call a commodity  
23 and have some definition or whether we use some other  
24 mechanism for that we haven't decided yet.

25 CHAIRMAN SIEBER: So you really don't have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 a system for doing it, right?

2 MR. VINCENT: Other than the reports that  
3 define those commodities currently.

4 CHAIRMAN SIEBER: Drawings that are marked  
5 up.

6 MR. VINCENT: Today that's true.

7 CHAIRMAN SIEBER: Let me ask then if you  
8 look at your Section 11 ASME program, it deals with  
9 the same kinds of things. It doesn't deal with  
10 components. It deals with lengths of pipe and hangers  
11 and other structural members and things like that.

12 The drawings of significance to track all  
13 that is usually isometric drawings and each piece of  
14 pipe will have a line number on it between -- you  
15 know, if it's a piece of pipe that is between  
16 component A and component B, sump pump and the heat  
17 exchanger or valve. You can track things for Section  
18 11 purposes that way. Would you intend to do  
19 something similar to that to track what is in scope  
20 with regard to license renewal?

21 MR. VINCENT: What you are describing for  
22 ASME Class 1, 2, and 3 is correct. We have those pipe  
23 segments identified.

24 CHAIRMAN SIEBER: Well, you've got half  
25 the job done.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 MR. VINCENT: We clearly have those which  
2 leaves non-safety related piping assets that we are  
3 talking about. I can't tell you we are going to use  
4 the same type of approach but we clearly have to  
5 capture those and track those.

6 CHAIRMAN SIEBER: Some place along the  
7 line somebody has to examine what you did with regard  
8 to applying aging management that involves the  
9 examination to specific systems. You need a way to  
10 know, to walk into a room and say, "There's a pipe up  
11 in the ceiling. It's in scope because it's on this  
12 document," as opposed to reading some broad definition  
13 some place and saying, "It must be in scope. I think  
14 it's in scope," but it isn't written down any place.

15 MR. VINCENT: You're right. We absolutely  
16 agree with that. We need a definitive reference to  
17 show exactly what is and what is not.

18 Mark, do you want to add to that?

19 MR. CIMOCK: This is Mark Cimock. I  
20 understand exactly what you're talking about. Right  
21 now the way that this is controlled our scoping and  
22 screening documents, AMR documents, program based  
23 documents are still live. We've been updating them as  
24 RAIs come in and as things change along the way.

25 What you are referring to is the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005



1 conversion to go forward method. We are still looking  
2 at some options and what you are seeing are very good  
3 points and there's a few ways we can do it. We  
4 haven't settled on the one.

5 The way that we are currently doing it is  
6 basically all our AMRs, aging management review  
7 reports, and our scoping and screening reports were  
8 basically generated by a large database that we  
9 captured this all on. For these commodity groups like  
10 the pipe segments and stuff we have created equipment  
11 IDs, if you will, that are license renewal specific.

12 One option obviously is to load that in  
13 with a little more definition, as you were talking  
14 about, point A to point B. The way we currently do it  
15 we might have aux feedwater pipe carbon steel would be  
16 a commodity for pipe that is now -- which parts of  
17 that you look at the color-coded system drawing.

18 What we have to decide, and we haven't  
19 yet, it may be a combination of loading these things  
20 in with a broad description with the color-coded  
21 drawings to show you the details similar to what we  
22 have for ISI type of color-coded drawings. Or it may  
23 be putting that intelligence into the equipment ID.

24 We are still in a transition phase and we  
25 haven't finalized that yet but I can assure you that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 will be very clear so that we know what we do have to  
2 examine and what we don't. As Patricia said, in some  
3 cases like in the aux building for a certain system  
4 everything in the building so you say all aux building  
5 piping.

6 CHAIRMAN SIEBER: That makes it easy. On  
7 the other hand, not everything is like that.

8 MR. VINCENT: Right. It would be easier  
9 probably for us if we were to put it in verbiages to  
10 write exclusionary statements rather than  
11 inclusionary.

12 CHAIRMAN SIEBER: I keep thinking in terms  
13 not so much as the site vice president or those kinds  
14 of jobs like general manager or NRC staff person, but  
15 the poor slob that is out in the plant saying, "I  
16 wonder where that is? I know I have to do this.  
17 Which one?" I would think that some place along the  
18 line there should be some kind of inspection at the  
19 time the renewed license starts that actually looks at  
20 the documentation to see if you can really identify  
21 where all the stuff is.

22 Some of it is easy, you know. All the  
23 ASME stuff is easy because you already did it for the  
24 Section 11 program. All the non-safety stuff unless  
25 everything in the room is in scope, there needs to be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 some other kind of database somewhere along the line.  
2 That gives you something to do in the next five years  
3 along with some other things you might want to do  
4 during that time. That is not a simple job. It's  
5 probably a pretty good size database.

6 MR. VINCENT: This is Bob Vincent again.  
7 I would add to what I said before. In a couple of  
8 areas, though, it is fairly straightforward to track  
9 that. For example, we have a fairly robust system  
10 walk-down program that will a lot more robust once we  
11 make the changes we plan to.

12 Those walk-down programs really cover an  
13 entire system. We'll provide more guidance for the  
14 person doing the walk-down to make sure they cover the  
15 entire system but it will cover the entire system. In  
16 the structural area the structural inspections that  
17 are already done under the maintenance rule are being  
18 enhanced and they are really oriented more to a spaces  
19 type approach.

20 Basically inspect pipe supports,  
21 structural members, concrete, etc. in a space. Again,  
22 that will be all encompassing and we don't necessarily  
23 need to track pipe segment by pipe segment with that  
24 kind of approach. What we have to sort out is where  
25 that approach applies and where we need to track it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 segment by segment.

2 CHAIRMAN SIEBER: I think your point is  
3 well taken, particularly if the Aging Management  
4 Program that you are applying is something like  
5 chemistry. The chemistry applies through the whole  
6 system so you don't need to care if it's this piece of  
7 pipe or that piece of pipe. On the other hand, if it  
8 involves some direct examination, you've got to know  
9 what you're dealing with. I won't belabor the point  
10 but I keep trying to think if I were young again and  
11 I was assigned the job of doing this, how would I do  
12 it.

13 MS. LUND: This is Louise Lund. I just  
14 want to mention before Patricia goes on is that they  
15 do have another license renewal inspection that the  
16 regions do before the period of extended operation and  
17 I know just listening to Patricia and her supervisor,  
18 Anne Marie Stone, I know they have had some  
19 discussions about what the context would be of the  
20 inspections and what we would need to focus on. I  
21 think these discussions have already started.

22 CHAIRMAN SIEBER: That is sort of the  
23 point of my question is to encourage people to think  
24 about that.

25 MS. LUND: That's a good point.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 MS. LOUGHEED: And I did write that down  
2 as a comment of something to add into what we should  
3 look at for the 95003 which is the inspection that's  
4 done just prior to or, if I had my way, right after  
5 the license renewal extension took effect.

6 CHAIRMAN SIEBER: I think it's an  
7 important thing and I apologize for interrupting your  
8 presentation.

9 MS. LOUGHEED: No, it's a good point.

10 CHAIRMAN SIEBER: And I will stay quiet  
11 for at least 30 seconds.

12 MS. LOUGHEED: Okay. Aging Management.  
13 We looked at 14 AMP and two TLAA programs. Our review  
14 differs from NRR a little bit in that we are looking  
15 at what is actually existing in the plant to see if  
16 they are meeting today pretty much what they have  
17 committed to do in the future and to get an  
18 understanding of where the enhancements are to see if  
19 they understand what those enhancements really are and  
20 what needs to be done.

21 I know there was some discussion earlier  
22 about the water in the manholes. I do have to echo  
23 Larry's comment. He did find that back several months  
24 prior to our inspection and did write a corrective  
25 action document.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1                   Unfortunately, what happened was the  
2                   corrective actions kind of fell in the crack a little  
3                   bit so that when we went back out in October he was  
4                   chagrined to find some water in there again.  
5                   Following our finding it the second time, then the  
6                   corrective actions that he had planned from the first  
7                   time did actually take place so there's not water now.

8                   I know that there has been some discussion  
9                   about the MEGERING and the type of testing being done.  
10                  That is one of those areas where there is a commitment  
11                  done or license renewal to improve the testing  
12                  programs. We are going to have to wait for another  
13                  five years or so before they take effect on that.  
14                  They are keeping them dry now which is an important  
15                  thing.

16                  CHAIRMAN SIEBER: It's important, I guess,  
17                  for everybody to recognize that if you have manholes  
18                  and underground cable ducts in a place where it rains  
19                  occasionally, they are going to be wet. If you aren't  
20                  pumping them out, you are missing the boat.

21                  MS. LOUGHEED: And we have found that at  
22                  several region plants. We are actually looking at  
23                  that now as part of our regular -- not part of a  
24                  license renewal program. It's part of our regular  
25                  inspection program.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 CHAIRMAN SIEBER: Okay.

2 MS. LOUGHEED: Again, we spend a lot of  
3 time in the plant during these inspections. We try to  
4 do lock-downs to verify how things are actually being  
5 done rather than relying just on paperwork reviews.  
6 Over all there is not very much here. Palisades we  
7 had very, very few problems with.

8 We found that their programs were very  
9 well put together, their plant staff very  
10 knowledgeable. We felt that what they had done was  
11 definitely adequate for license renewal. We wish they  
12 had gone first so they could have shown some of the  
13 other guys -- I'll leave that.

14 Again, the scoping and screening programs  
15 as well, we didn't have any problems with them. Very  
16 minor issues if at all. We don't see any impediments  
17 to the license renewal process.

18 That concludes my portion. No, it  
19 doesn't. I forgot. I get to talk about current  
20 performance, although that is not really part of the  
21 inspection. That's still current operations. There  
22 is a slide coming up. They are in the licensee  
23 response column, all greens, of our NRC action matrix.  
24 We don't have any cross-cutting issues at this time.  
25 We continue to follow the baseline reactor oversight

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 process where we do routine inspections. That's the  
2 slide.

3 These are the recent inspection findings.  
4 There is one I would kind of like to highlight, one  
5 under barrier integrity that was found in the fourth  
6 quarter of 2005. That actually was a through-wall  
7 leak on a heat exchanger, something which we hope that  
8 the enhancements that are going to be made to the  
9 service water, open cycle cooling water system will  
10 help prevent in the future.

11 However, it was something just to  
12 demonstrate that even if issues slip through and  
13 problems exist that they are identified in a timely  
14 manner and corrected before they become big problems  
15 for the plant.

16 CHAIRMAN SIEBER: Is this is a tube leak?

17 MS. LOUGHEED: I believe it was a tube  
18 leak.

19 CHAIRMAN SIEBER: In what heat exchanger?  
20 Do you know?

21 MS. LOUGHEED: I looked at that yesterday  
22 and I don't remember.

23 MR. HARDEN: This is Paul Harden, Site  
24 Vice President. It was in our non-safety related  
25 containment air cooler coil.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005



1 MS. LOUGHEED: Okay.

2 CHAIRMAN SIEBER: So under an action  
3 sequence where you've got containment pressurization,  
4 leakage would be from containment through that leak to  
5 the outside?

6 MS. LOUGHEED: Right.

7 CHAIRMAN SIEBER: Okay.

8 MS. LOUGHEED: And it was correctly  
9 prompted. Overall I believe none of the other  
10 findings on here really had anything to do with  
11 license or could be conceived to have anything to do  
12 with license renewal.

13 CHAIRMAN SIEBER: I presume that finding  
14 was licensee identified?

15 MS. LOUGHEED: Self-revealing, yes.

16 CHAIRMAN SIEBER: Okay.

17 MS. LOUGHEED: Back to Juan.

18 MR. AYALA: Thank you, Patricia. Now I am  
19 going to go into the staff's review of the Aging  
20 Management Program and aging management reviews. The  
21 staff reviewed 24 Aging Management Programs. Of those  
22 20 are existing AMPs and four are new, as the  
23 applicant stated. Thirteen of those are consistent  
24 with GALL, 10 of them are consistent with exceptions  
25 or enhancements, and one is plant specific.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 CHAIRMAN SIEBER: Could you describe the  
2 one that is plant specific?

3 MR. AYALA: I'm going to get into that one  
4 in a slide.

5 CHAIRMAN SIEBER: Okay. I'll wait.

6 MR. AYALA: Okay. The Buried Services  
7 Corrosion Monitoring Program is a new AMP consistent  
8 with GALL which uses visual inspections of external  
9 surfaces. The applicant had initially committed to  
10 performing visual inspections of buried piping within  
11 10 years after entering the period of operation. As  
12 a result of the staff's review, the applicant will now  
13 perform visual inspections within 10 years prior to  
14 entering the period of extended operation and within  
15 10 years of entering the period of extended operation.

16 There is one below-grade tank, as the  
17 applicant mentioned earlier, and that is the diesel  
18 fuel oil storage tank. As they mentioned, it is  
19 contained in a vault and not exposed to soil.

20 CHAIRMAN SIEBER: Since we are talking  
21 about tanks, if I look at the picture on the  
22 application of the plant, I see a lot of tanks.  
23 Probably tanks like the RWST. In Westinghouse plants  
24 they would call them coolant recovery tanks,  
25 condensate storage tanks and so forth, various tanks

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 that aren't buried but they sit on the ground.

2 Since they sit on the ground you can't  
3 inspect from underneath. You can't dig a tunnel under  
4 the tank to get to the bottom of it so you have to  
5 inspect it from the inside. Some of those tanks will  
6 build up kind of a sludge or something on the bottom  
7 of the tank as it settles out.

8 Are the bottoms of the surface constructed  
9 tanks inspected the same as it would have been if it  
10 were a below-ground tank? Is that part of the Aging  
11 Management Program? Perhaps the licensee can tell me  
12 about that.

13 MR. ROBERTS: Bill Roberts, Programs Lead,  
14 Palisades. Bottom thickness testing?

15 CHAIRMAN SIEBER: Yes.

16 MR. ROBERTS: On the inside. That's what  
17 we plan on doing.

18 CHAIRMAN SIEBER: Okay. That's  
19 ultrasonic?

20 MR. ROBERTS: Right, for thickness.

21 CHAIRMAN SIEBER: Okay.

22 MR. AYALA: Moving on, the Bolting  
23 Integrity Program is an existing program consistent  
24 with enhancements. The applicant is going to revise  
25 their master ISI plan. They are going to evaluate

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 high-strength bolting used in component supports.

2 Non-safety related bolting will be  
3 monitored by the System Monitoring Program and  
4 structural bolting including fastener will be managed  
5 by the Structural Monitoring Program. ASME Class 1,  
6 2, and 3 bolting is inspected by the ASME Section XI  
7 ISI program once per 10-year interval. The inspection  
8 is going to involve bolts two inches or larger.

9 Bolting Integrity Program will incorporate  
10 the guidance of EPRI and the staff determined that the  
11 guidelines reflected industry practice and meets the  
12 recommendations in GALL.

13 CHAIRMAN SIEBER: For structural bolting,  
14 I presume that the indication of a problem is when the  
15 bolting fails for structural bolts. You don't run  
16 around doing ultrasonic examinations through the shank  
17 of the bolt. What is considered a failure in  
18 structural bolting?

19 MR. AYALA: David Jeng --

20 MR. JENG: This is David Jeng of the  
21 Division of Engineering. The concern is about the  
22 high strength structure bolting, 150 psi, and we are  
23 concerned about cutting aspect in so much the regular  
24 material normally control it and managed by the  
25 Structural Monitoring Program. In high-strength

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 structural bolting, then they commit to technical  
2 variation of cracking or not.

3 CHAIRMAN SIEBER: Well, it seems to me  
4 that being able to monitor high-strength bolts is  
5 important because of the seismic issues. If you get  
6 a seismic event, even though the bolting may be  
7 satisfactory for normal plant operation without a  
8 seismic event, the combination of plant operation and  
9 the seismic event raises the stress intensity pretty  
10 high. You may have self-revealing cracks that turn  
11 into failures.

12 MR. JENG: Seismic induced stresses and  
13 other stresses are covered by the design configuration  
14 requirements.

15 CHAIRMAN SIEBER: Okay. Thank you.

16 MR. AYALA: Okay. Moving on to the Boric  
17 Acid Corrosion Program, the applicant stated that this  
18 program was consistent with GALL with enhancements.  
19 Three enhancements that the applicant provided were  
20 also provided as commitments and they are listed on  
21 the slide here.

22 Enhancements are scheduled for  
23 implementation prior to the period of extended  
24 operation and the staff found that with these  
25 commitments the program is consistent with GALL.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1           The Flow-Accelerated Corrosion Program is  
2 an existing program consistent with GALL. The license  
3 renewal application originally stated that the trigger  
4 point for conducting engineering evaluation for non-  
5 safety related piping was less conservative than that  
6 of safety-related piping. As a result of the staff's  
7 review the applicant will use the same criteria that  
8 they used for safety-related piping for non-safety  
9 related piping.

10           The Reactor Vessel Integrity Surveillance  
11 Program. The applicant stated that the program is  
12 consistent with enhancements. The staff reviewed  
13 these enhancements and these enhancements were also  
14 once again submitted as commitments and are listed  
15 here. With the four enhancements the staff found that  
16 the program is consistent with GALL. The next slide  
17 shows the other two commitments and enhancements that  
18 the applicant provided.

19           Moving on, the System Monitoring Program  
20 is a plant-specific program that the applicant had in  
21 the application. It is consistent with GALL and  
22 XIM29, above-ground carbon steel tanks, and is used to  
23 identify the greater conditions on external surfaces,  
24 piping, tanks, and other components and equipment  
25 prior to the loss of systems in components that tend

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 to function.

2 The applicant will credit opportunistic  
3 inspections of external surfaces when insulation is  
4 removed. If insufficient data exist, the applicant  
5 will remove additional insulation from additional  
6 locations to increase the sample. The data will be  
7 available to the regional staff for review and  
8 determination if the sample size is sufficient.

9 Moving on to the aging management reviews.

10 MEMBER BONACA: Before we move to that, I  
11 have a question. Some of these problems you would  
12 expect to have them in place already. I was thinking  
13 about the boric acid corrosion problem that you had on  
14 page 25.

15 MR. AYALA: Yes.

16 MEMBER BONACA: There are three  
17 commitments. One is revise procedures to include  
18 criteria for observing susceptible SSC for boric acid  
19 leakage, etc. I would expect that after Davis-Besse  
20 people have implemented already procedures of this  
21 nature. Are these significant changes for license  
22 renewal or do they have already problem that does this  
23 kind of inspections?

24 MR. AYALA: If I can ask the applicant if  
25 they can address the implementation of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 enhancements.

2 MR. ROBERTS: Bill Roberts, Program Lead,  
3 Palisades. I think that Bob Vincent typified this  
4 earlier. A lot of our commitments is we took maybe a  
5 narrow view and said we think our programs comply but  
6 we are going to say that we need this enhancement  
7 implemented to be fully consistent with the GALL.

8 If I would go through these three  
9 commitments, the first one on the slide there, revise  
10 procedures to include criteria for observing  
11 susceptible SSC for boric acid leakage and degradation  
12 during system walk-downs. We have a separate boric  
13 acid inspection program and separate procedures.

14 What we want to do here is make sure that  
15 the system walk-down procedures also includes a  
16 criteria and so to come full circle we want to make  
17 sure that the boric acid -- we take credit from the  
18 system honoring program and the walk-downs for boric  
19 acid component. We felt that was an enhancement.

20 The second one revised the procedures to  
21 include explicit acceptance criteria. I think our  
22 acceptance criteria was always any signs of boric acid  
23 but we hadn't really spelled that out to the degree  
24 that we think it's necessary to call us consistent  
25 with GALL.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005



1 I think the Region challenged us on that  
2 and we said, "Yeah, you're right. We need to come up  
3 with some more explicit acceptance criteria rather  
4 than just any signs of boric acid. Maybe we need to  
5 do a little more extended condition and determine if  
6 it was a drip from another pipe or internally came  
7 from the pipe that it's on, that kind of thing.

8 The third one, revise the procedures. We  
9 have the maintenance rule structural monitoring  
10 program which, again, looks at the structural aspects  
11 of the plant. This is again reference, I think, to  
12 the walk-down procedures. We want to make sure that  
13 the system walk-down procedure also observe structural  
14 members and components and look for boric acid also.

15 We don't just want the structural  
16 monitoring program to be the only program that's going  
17 to look for boric acid in the structures. We want the  
18 system monitoring program to look at that. That is my  
19 explanation as to why we chose to call those  
20 enhancements and not just flat out say we are  
21 consistent with the GALL from the get go.

22 MEMBER BONACA: Thank you.

23 MR. AYALA: Once again, Juan Ayala.  
24 Moving on to the aging management review results. The  
25 staff performed a 100 percent review of 29 plant

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 systems, 10 structures, and nine commodity groups. In  
2 the auxiliary systems the LRA did not identify any  
3 aging management program for degradation of neutron  
4 absorbing panels. The applicant does not have a  
5 coupon program for the boring carbide panels.

6 As a result of the staff's review the  
7 applicant has committed to performing industry  
8 approved neutron absorption testing to monitor for  
9 degradation. In the interim the applicant also  
10 sampled spent fuel pool water on a monthly basis for  
11 total organic carbon with typical values around 0.2  
12 PPM. This will provide an indication of degradation  
13 of material.

14 For thermal sleeves the applicant stated  
15 that thermal sleeves did not serve an intended  
16 function and no aging was required. As a result of  
17 the staff's review the applicant added the aging  
18 effects for cracking due to stress corrosion cracking  
19 and primary water stress corrosion cracking.

20 The applicant will manage stainless steel  
21 sleeves with the ASME Section XI ISI Program and the  
22 Water Chemistry Programs. Alloy 600 nozzle of sleeves  
23 are managed by the alloy 600 and Water Chemistry  
24 Programs. For feedwater nozzle thermal sleeves, loss  
25 of material due to general corrosion is managed by the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 Water Chemistry Programs and credits inspections of  
2 adjacent nozzles using the ADME Section XI program.  
3 Loss of material due to FAC is credited -- credits the  
4 FAC program and inspections of adjacent nozzles.

5 Moving on to inaccessible concrete. The  
6 applicant stated and the staff verified that below  
7 grade environment is non-aggressive. Periodic testing  
8 of ground water will be performed as part of the  
9 Structures Monitoring Program at least every five  
10 years.

11 The staff found that the applicant had  
12 appropriately addressed the aging effects and  
13 mechanisms as recommended by GALL. As shown on the  
14 table here, the results are well below acceptance  
15 criteria and no adverse trends exist.

16 Moving on to the electrical and I&C  
17 components. The application grouped these as nine  
18 commodity groups and they are listed on the right  
19 here. The staff reviewed these and found that  
20 everything was consistent with GALL and there was no  
21 action required by the applicant.

22 Moving on to the Time-Limited Aging  
23 Analyses, these were the TLAAs described in the  
24 license renewal application. I'm going to first start  
25 by talking about reactor vessel neutron embrittlement.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 There are three analyses affected by irradiation  
2 embrittlement. These are PTS, upper shelf energy, and  
3 pressure temperature limits.

4 I'm going to go into a deeper discussion  
5 on the first two. For the 60-year operation the  
6 applicant used 42.37 EFPY in their calculations. As  
7 the applicant mentioned, the capacity factor that they  
8 are using is 91 percent.

9 RV pressurized thermal shock. Limiting  
10 material is intermediate shell and lower shell axial  
11 welds. As a result of the calculation, the screening  
12 criteria will be exceeded in 2014 and this calculation  
13 was verified by the staff. In the next slide we'll  
14 address the options that the applicant has to address  
15 this concern.

16 Palisades' plan for PTS are as follows:  
17 The applicant can continue to use an ultra-low leakage  
18 core design and submit final PTS resolution three  
19 years before 2014. Some of the options that the  
20 applicant has is that they can further reduce flux and  
21 preheating safety injection water, or perform thermal  
22 annealing of the reactor vessel.

23 MEMBER WALLIS: Has thermal annealing ever  
24 been done on a U.S. reactor?

25 MR. AYALA: No.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 MEMBER WALLIS: This would be a novel  
2 thing to do.

3 PARTICIPANT: It's been done in Europe.

4 MEMBER WALLIS: It's been done in Europe,  
5 yes, but it hasn't been done over here.

6 MR. MITCHELL: This is Matthew Mitchell,  
7 Chief of the Vessels in the Internals Integrity  
8 Branch. I would in response to Dr. Wallis's  
9 observations say that we did a number of years ago  
10 complete an annealing demonstration project at an  
11 unused facility. The technology at least in that  
12 sense for thermal annealing was effectively  
13 demonstrated. You are correct, there has been no  
14 actual annealing of a U.S. vessel.

15 MEMBER WALLIS: Thank you.

16 CHAIRMAN SIEBER: When you do an  
17 annealing, how can you tell when you're done that you  
18 actually annealed it?

19 MR. MITCHELL: Again, Matthew Mitchell.  
20 Part of the process for exercising 5066, the thermal  
21 annealing rule, would require a licensee to undertake  
22 a material program to demonstrate the benefits that  
23 were gained as a result of the annealing process.  
24 That would likely be as a result of testing sample  
25 coupons to a simulated annealing process to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 demonstrate what type of material property recovery  
2 would have been effected by the thermal annealing.

3 CHAIRMAN SIEBER: But that would not  
4 examine the actual vessel itself in any way?

5 MR. MITCHELL: Well --

6 CHAIRMAN SIEBER: Just coupons, right?

7 MR. MITCHELL: There would be other  
8 options available. Of course, one could contemplate  
9 taking actual material samples from the vessel itself.  
10 However, I think that would probably be secondary.

11 CHAIRMAN SIEBER: I would rather not do  
12 that.

13 MR. MITCHELL: Yeah. I think having the  
14 right material available in the appropriately  
15 irradiated condition to then subsequently perform  
16 effectively the annealing process on to demonstrate  
17 property recovery would be probably the preferred  
18 method of demonstration.

19 CHAIRMAN SIEBER: Okay.

20 MR. AYALA: Thank you, Matt, for that.  
21 Once again this is Juan Ayala. Moving onto reactor  
22 vessel upper shelf energy. The limiting plate is the  
23 lower shell plate and it is expected to exceed the  
24 acceptance criteria in 2021. This calculation was  
25 also confirmed by the staff and the options for this

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 concern will be addressed in the next slide.

2 The limiting weld is the intermediate to  
3 lower shell circumferential weld. The analysis for  
4 this was found acceptable and the calculation was  
5 confirmed by the staff. The plan that Palisades has  
6 for addressing upper shelf energy is to submit an  
7 equivalent margin analysis three years before 2021.

8 MEMBER WALLIS: Presumably that works out.  
9 Presumably this 50 ft-lbs is a conservative first  
10 estimate and then when you do a more thorough job you  
11 can prove that it's okay even with a lower value?

12 MR. MITCHELL: Again, Matthew Mitchell.  
13 Like the screening criteria that we are familiar with  
14 in 5061, the 50 ft-lb limit that's in 10 C.F.R. Part  
15 50, Appendix G, has been exceeded by more than one  
16 facility. An equivalent margins analysis has been  
17 routinely successful at demonstrating equivalent  
18 margins of safety down, I would say, significantly  
19 below the values he listed for the limiting plate at  
20 Palisades.

21 MEMBER WALLIS: The difference between  
22 48.97 and 50 doesn't seem like very much. You would  
23 think they could figure out how to improve that  
24 somehow.

25 MR. MITCHELL: It's, shall I say, a matter

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 of literal compliance with the regulation. If you go  
2 below the 50 ft-lbs then it does require an enhanced  
3 analysis. I would suspect such an analysis to be  
4 successful.

5 MR. AYALA: Okay. Moving on, for the  
6 metal fatigue TLAA the CUF for criterion is met for  
7 all components. If there are any locations where  
8 environmental effects of fatigue will not -- where the  
9 minimum will not be reached, the Fatigue Monitoring  
10 Program will ensure that the CUF remains below 1 for  
11 the period of extended operation. The staff found  
12 these evaluations acceptable.

13 DR. SHACK: When they did the  
14 environmental analysis they came up with a CUF of 4.4  
15 or something for the limiting component. The Fatigue  
16 Monitoring Program sits there and counts cycles.  
17 Let's just assume that they count the cycles and the  
18 cycles actually happen to coincide with the stuff that  
19 they did the analysis and sometime the CUF will equal  
20 1. What do you do then?

21 MR. AYALA: Mark Hartzman.

22 MR. HARTZMAN: This is Mark Hartzman from  
23 the Engineering Mechanics Branch. I think the  
24 monitoring program does more than just count cycles.  
25 It actually calculates CUFs on a continuous basis

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005



1           apparently.  Therefore, it's both.  It counts cycles  
2           and when it sees that the CUF is approaching 1 it will  
3           take some sort of measure.

4                     DR. SHACK:  But every time I read this it  
5           sounds as though the Fatigue Monitoring Program is  
6           computing CUF ASME code version and it's not applying  
7           an environmental correction.  I'm not sure exactly how  
8           you make the connection and what you would do if you  
9           do hit the CUF of 1.

10                    MR. HARTZMAN:  They are supposed to  
11           replace or repair -- repair or replace.

12                    DR. SHACK:  They can't inspect and  
13           analyze?

14                    MR. HARTZMAN:  Maybe they can.  Supposedly  
15           the analysis that goes into the Fatigue Monitoring  
16           Program is already what one would call a pencil-  
17           sharpened analysis so, therefore, at that point they  
18           are most likely to either repair or replace.  Maybe  
19           the applicant cares to address that.

20                    DR. SHACK:  Am I right that the CUF that  
21           you're computing in the fatigue monitoring program  
22           does not include an environmental enhancement, or does  
23           it?

24                    MR. HARTZMAN:  I can't address that  
25           because I didn't review that program.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 MR. KNEELAND: This is John Kneeland, NMC.  
2 The numbers that you see due include the environmental  
3 correction factor. The particular number that you're  
4 referencing, the 4.65, I believe it is, we have  
5 updated that calculation in a later submittal. We  
6 used an overly conservative environmental factor in  
7 that particular case. We should have used a much  
8 smaller number and that number is now less than 1.

9 MR. HARTZMAN: At the time the SER was  
10 written we didn't have that information.

11 DR. SHACK: Oh, okay, because you then  
12 manage it through the fatigue program. When you hit  
13 the 1 you just replace the compound.

14 MR. HARTZMAN: Right. Well, repair or  
15 replace.

16 DR. SHACK: Or replace. Right.

17 MR. HARTZMAN: That's the commitment.

18 DR. SHACK: So then the Fatigue Monitoring  
19 Program does include an environmental enhancement  
20 factor?

21 MR. HARTZMAN: That is correct.

22 DR. SHACK: It's never clear to me when I  
23 read that.

24 MR. AYALA: Once again, Juan Ayala.  
25 Moving on to environmental qualification of electrical

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 equipment. The staff reviewed the applicant's TLAA  
2 and determined that it was acceptable and concluded  
3 that the evaluation was acceptable for the EQ  
4 components.

5 Okay. Moving on to underclad crack  
6 growth. This is the only confirmatory item that we  
7 have in the Safety Evaluation Report. This is a new  
8 TLAA that is not in the application and came about as  
9 a result of the staff's audit review. The applicant  
10 addressed the issue of underclad crack as a TLAA that  
11 stated that the bonding fracture mechanics and staff-  
12 approved WCAP would be applicable to Palisades.

13 The staff just received last week a plant  
14 specific WCAP and is in the process of reviewing it.  
15 This plant specific WCAP uses the same methodology  
16 used in the staff-approved WCAP. We will address that  
17 issue in the final SER.

18 To summarize the TLAA's, the TLAA list is  
19 complete and acceptable. The analysis have been found  
20 to either remain valid for the period of extended  
21 operation projected to the end of the period of  
22 extended operation or will be managed during the  
23 period of extended operation. There are also no plant  
24 specific exceptions.

25 In conclusion, the staff has concluded

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 that there is reasonable assurance that the activities  
2 authorized by the renewed license will continue to be  
3 conducted in accordance with the current licensing  
4 basis. That concludes our presentation.

5 MEMBER BONACA: Question for Patricia. I  
6 wasn't here when you started the presentation. I  
7 wanted to ask about the physical conditions of this  
8 plant. You recently -- well, you've been looking at  
9 a number of plants.

10 MS. LOUGHEED: I have to admit that I have  
11 not been at Palisades in a while other than the  
12 inspection in October and Palisades is not a plant  
13 that I normally go to. Having said that, the licensee  
14 is working on improving the physical condition of the  
15 plant. It does meet our minimum standards. I think  
16 there are others. I would hesitate to say it was  
17 excellent but it is definitely not poor in any way.

18 MEMBER BONACA: There was an inspection  
19 report where, for example, they are quoting extensive  
20 corrosion in a diesel --

21 MS. LOUGHEED: Yes. There were a few  
22 components. These are non-safety related components  
23 where there has been corrosion and the licensee was  
24 aware of it. As of right now there is no requirement  
25 for them to monitor that. They did write corrective

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 action documents for it. It was not on any of the  
2 safety related stuff. It was all non-safety related  
3 components.

4 I think the utility has made some  
5 decisions in the recent past because they have decided  
6 to seek a new owner and to seek license renewal,  
7 whereas previously they had been thinking strongly  
8 about shutting down in a few years and that has  
9 affected how they have maintained the plant.

10 MEMBER BONACA: Thank you.

11 CHAIRMAN SIEBER: Any additional questions  
12 from any of the members? Okay. If there are no  
13 questions, I want to thank the staff for their  
14 presentation and their hard work.

15 MR. GILLESPI: I would like to -- I don't  
16 know if you noticed it in the presentation. It takes  
17 us two years to figure out if we did something right  
18 because we're on a 22-month review schedule.  
19 Palisades was nice enough to step up and actually use  
20 a draft GALL document and do a comparison. They did  
21 in this whole process go a bit above and beyond to  
22 help us prove, you might say, the goodness of a GALL  
23 document that doubled in scope. Also to help we've  
24 created a new document.

25 I know ACRS hates to hear this because when we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 created the audit reports it was an extra 700 pages  
2 you had to read. An important document that came out  
3 of the audit process that evolved at Palisades in the  
4 couple of plants that volunteered was the question and  
5 answer database which is on the official record where  
6 the audit team actually looks at the application and  
7 says knowing nothing else but what's in the  
8 application with every question we can think of.

9 Then they send that to the applicant and  
10 that becomes kind of the first step in the audit  
11 process. Additional questions are developed and that  
12 database actually becomes almost a supplement to the  
13 application with the additional detail we are  
14 dependent upon.

15 It has actually become now with current  
16 reactors since Palisades kind of a critical element in  
17 the whole process of documenting what happens in an  
18 audit on the public record as opposed to summarizing  
19 something in an audit report because it's the  
20 applicant's own words that answer the questions.

21 They have contributed to an improvement in  
22 the process and improvement in our openness in how we  
23 are moving forward. Now we have to figure out how to  
24 eliminate. We've created this new thing, this new  
25 database. Now we have to try to hopefully get rid of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 something in the middle there.

2 Maybe the audit report isn't as important  
3 now that we have the question and answer database.  
4 That raises that question. I do want to thank the  
5 licensee for bearing with us and trying something a  
6 little new which we have met, I think, with some  
7 success both in process and documentation.

8 MS. LUND: I just wanted to mention from  
9 a programmatic standpoint we welcomed Patricia to our  
10 staff on a rotational basis just this week and it  
11 really helps us to get regional inspector insight into  
12 our programs. Anyway, she's going to be with us for  
13 the next couple of months.

14 DR. SHACK: Where is this question and  
15 answer database now?

16 MR. GILLESPI: Actually, I know you hate  
17 to hear this, but it's in ADAMS. I know, isn't that  
18 deadly? In fact, I'm going up to Pilgrim and Vermont  
19 Yankee next week. I apologize for not being here  
20 tomorrow for Nine Mile but I'm going to be at Oyster  
21 Creek for the draft environmental safety. P.T. Kuo,  
22 who normally would be here if I'm not here, has been  
23 on three weeks of sick leave for some surgery he had  
24 done.

25 I apologize for not being here tomorrow.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 We are actually going to take copies of the question  
2 and answer database with us to the public meetings  
3 which are the exit meetings, if you would, from the  
4 audits because that really becomes kind of the public  
5 documentation of what took place at the audits.

6 DR. SHACK: This is on the license renewal  
7 website there where you have the application and the  
8 environmental impact statement.

9 MR. GILLESPI: When I sat today with the  
10 guys, I said, "We've got this question and answer  
11 database. It's really good stuff. It's the  
12 licensee's own words about how we responded. They  
13 said, "Well, it's in ADAMS." I had the same reaction  
14 and we are working maybe to get it on the website.  
15 It's just a decision we hadn't made yet but it is a  
16 significant body of information which is very focused  
17 and it is the next stepping-off point from the  
18 application.

19 MS. LUND: Very much like the RAIs. It  
20 gets supplemented over time and then it gets provided  
21 in one lump sum at the end, you know, when all have  
22 been answered. I guess we have been treating it a lot  
23 like the RAI responses in that, you know, it goes all  
24 into ADAMS rather than we don't put RAI responses on  
25 the website. I guess this is something that we just

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005



1 have to kind of consider how to --

2 MR. GILLESPI: I really hesitated to go to  
3 a meeting with the general public and have to give  
4 them an ADAMS number. What we are actually doing is  
5 the two project managers are going to leave their e-  
6 mails and we will e-mail a copy to anyone who actually  
7 wants a copy of that database because it's very  
8 timely. It's like two weeks or three weeks after the  
9 audit it's available and so it's more like instant  
10 gratification of what really went on.

11 CHAIRMAN SIEBER: I actually found  
12 something in ADAMS a couple of weeks ago.

13 DR. SHACK: If they give you the number,  
14 it's okay but how do you get the number?

15 MR. GILLESPI: We are going to give out  
16 the number. We are kind of reexamining a publication  
17 documentation of everything we are doing because we  
18 are doing a lot of good stuff but if it gets hidden in  
19 ADAMS no one knows it. At least to have them  
20 available and maybe sorted in some reasonable way  
21 where we can get information would be good.

22 DR. SHACK: Some place that it could be  
23 Googled.

24 MR. GILLESPI: Yes, some place you could  
25 Google it.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 CHAIRMAN SIEBER: You can Google ADAMS at  
2 its own Google.

3 DR. SHACK: Yes, I know, but there's a  
4 difference between Google and the ADAMS search.

5 CHAIRMAN SIEBER: Well, thanks very much.  
6 Appreciate that.

7 DR. SHACK: Google works.

8 CHAIRMAN SIEBER: Again, thanks to the  
9 staff. Just to follow up on your remarks, I see  
10 improvements in this process both from the standpoint  
11 of the application and the staff including the region-  
12 based staff as we go along. Hopefully by the time we  
13 have done all the plants it will be a really good  
14 process.

15 DR. SHACK: The next go-around.

16 CHAIRMAN SIEBER: I think that is a credit  
17 to licensees and also to the staff to try to make the  
18 process work that is thorough and has meaning for the  
19 application that is being applied to. I give my  
20 congratulations. The documents are getting easier,  
21 better organized and easier for me to read and  
22 understand. That's important. Again, thanks to  
23 everyone here that contributed to this process.

24 Are there additional questions,  
25 statements, or remarks by anyone?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 MS. CAREY: Yes. Can I speak up? Can  
2 anyone hear me? Hello?

3 CHAIRMAN SIEBER: Yes.

4 MS. CAREY: Hi. Do I count?

5 CHAIRMAN SIEBER: I don't know who you  
6 are.

7 MS. CAREY: I'm Corinne Carey in Grand  
8 Rapids, Michigan.

9 CHAIRMAN SIEBER: Oh, good.

10 MS. CAREY: I appreciated your joke there  
11 about actually finding something on ADAMS.  
12 Incidentally, is ADAMS or ATOMS?

13 CHAIRMAN SIEBER: ADAMS.

14 MS. CAREY: Oh, okay.

15 CHAIRMAN SIEBER: Automatic something or  
16 the other.

17 MS. CAREY: I'm relatively an amateur at  
18 all this, of course, but I appreciate that many of you  
19 have spent many long hours in training and all of that  
20 in working out these hopeful solutions to nuclear  
21 power, etc. I am strongly questioning many of the  
22 things about this process.

23 Among other things that you are not  
24 considering the very issue that this nation is at war  
25 about. We are at war on terrorism and you are not

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 considering it on our nuclear plant? This is  
2 incredible to me and how you can call that outside the  
3 scope according to a letter that I've been reading  
4 here from Valkyre. Is that his name? It just seems  
5 to me that you have no right to not change the  
6 procedure. I don't care what your procedure has been  
7 in the past.

8 In fact, there have been times when I have  
9 driven right up to the reactor fence all by myself,  
10 just an ordinary person, etc., etc., partly just to  
11 see what would happen if I did it. Now, of course, I  
12 assume that is not allowable but, in the meantime, how  
13 can you not include the issues of terrorism on 100  
14 some nuclear bombs just sitting and waiting to get hit  
15 that are scattered throughout our country?

16 CHAIRMAN SIEBER: Would you like me to  
17 address that?

18 MS. CAREY: Yes, please.

19 CHAIRMAN SIEBER: As I am sure you are  
20 aware, the responsibility of the Nuclear Regulatory  
21 Commission do extend to a wide variety of things, one  
22 of which is license maintenance, license renewal, and  
23 compliance. Another one is security. We do not mix  
24 and match. When we deal with a specific subject, we  
25 follow the regulations that exist on that subject, but

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 that does not mean that issues like security and so  
2 forth are not being addressed for the Palisades plant  
3 or any other plant.

4 MS. CAREY: Well, I assume it certainly is  
5 but to not include that in the process of renewal for  
6 another 20 years when I understand that the original  
7 engineer design of any nuclear power plant was 30  
8 years. Then the original NRC licensing was done for  
9 40 years which I understand was an industry  
10 requirement or request because of financial need to  
11 break even or however you describe it. But then to  
12 add another 20 years and Grand Rapids is 70 miles down  
13 wind but that's not far enough if things go wrong.

14 CHAIRMAN SIEBER: Well, my grandchildren  
15 live there so I have something at stake, too.

16 MS. CAREY: Then why are you anywhere near  
17 approving it?

18 CHAIRMAN SIEBER: We haven't said whether  
19 we are going to approve it or not.

20 MS. CAREY: No, but you have denied any  
21 kind of legal process that hundreds of  
22 environmentalists and other citizens. They are  
23 citizens. They are not even a lot of them  
24 environmentalists but they are saying, "They're  
25 risking us? They're risking my land, my home, my

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 children, my grandchildren, great-grandchildren."

2 How can you not look at terrorism as part  
3 of that when the world -- when this country has killed  
4 -- has had 25,000 and more of our people die fighting  
5 a war on terrorism and you are not including it in  
6 renewal procedures? Sounds like a nut, doesn't it?

7 MEMBER WALLIS: We are considering it in  
8 a different context, as my colleague explained. We  
9 look at the security of plants but we don't include it  
10 in this particular hearing on license renewal. It's  
11 a different context. We are addressing it in a  
12 different place, but we are certainly addressing the  
13 security and the terrorism issue.

14 MS. CAREY: Well, not in the letter that  
15 I got.

16 MEMBER WALLIS: Well, unfortunately it is  
17 a subject of security so we don't do it in public  
18 because we don't want the terrorist to hear what we  
19 say about security of nuclear plants.

20 MS. CAREY: Well, I appreciate that. We  
21 don't want to give anybody any ideas. Believe me, if  
22 even a little former fourth-grade teacher can think of  
23 some ideas of what could happen, I'm sure that anybody  
24 that was really determined to do something could come  
25 up with some horrible things. But to officially

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 exclude it from the procedure of renewal and to  
2 consider renewing the plant when it's already  
3 embrittled it doesn't make any sense at all.

4 CHAIRMAN SIEBER: Okay. Well, we  
5 certainly appreciate your comments and you are part of  
6 the record here.

7 MS. CAREY: Thank you.

8 CHAIRMAN SIEBER: It will appear in the  
9 transcript.

10 MS. CAREY: Good.

11 CHAIRMAN SIEBER: You can get it under  
12 ADAMS.

13 MS. CAREY: One voice of millions.

14 CHAIRMAN SIEBER: Okay. Thank you very  
15 much.

16 MS. BARNES: May I make a comment? May I  
17 ask a question?

18 MS. CAREY: Are you asking me?

19 MS. BARNES: I'm asking the group there.

20 CHAIRMAN SIEBER: I'm sorry. I can't hear  
21 you very well.

22 MS. BARNES: Oh, yes. Can I make a  
23 comment, ask a question? This is Katherine Barnes.

24 CHAIRMAN SIEBER: Oh, okay. Sure.

25 MS. BARNES: I have a concern. I recently

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 read that there was some flooding of radioactive  
2 effluent onto the soil within the compound in 1990 and  
3 Consumers Power -- I think it was Consumers Power at  
4 that time -- had asked for exemptions to a clean up.  
5 They said by leaving the soil there that they didn't  
6 think it was affecting anybody because the people  
7 didn't have wells and used city water. Because it was  
8 a fenced-in compound they didn't think anybody but  
9 their workers would be there. I was wondering, did  
10 they clean that up or did you allow that to just sit  
11 there?

12 CHAIRMAN SIEBER: I'm not familiar with  
13 that incident so I can't respond to your question.

14 MS. BARNES: Okay. Well, there's --

15 MS. LOUGHEED: Ma'am.

16 MS. BARNES: -- some documentation on it.

17 MS. LOUGHEED: Ma'am, there will be a  
18 meeting in a few weeks of the inspection process  
19 called the Mid-Cycle Assessment. That would be an  
20 excellent meeting to address that question.

21 MS. BARNES: Okay.

22 MS. LOUGHEED: They would be able to  
23 answer it.

24 MS. BARNES: Okay. I have another  
25 question and that is about Pack Sore. I understand it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005



1 has bad wells and is sitting in kind of a cask that is  
2 actually on unstable ground and it is surrounded by  
3 other casks. Now, they know that's a problem cask,  
4 that it could -- that the wells could break, it could  
5 leak.

6 My question is why aren't they dealing  
7 with it? Why are they just having it there and have  
8 they ever assessed how much time it would take them if  
9 that cask started to leak to get all those other casks  
10 out of the way so that they could even deal with it.  
11 Just by letting it sit there is seems like negligence  
12 to me. Why aren't they handling that? Why aren't  
13 they doing something about that cask?

14 MS. LOUGHEED: Again, ma'am, this is  
15 Patricia Lougheed of the Regional Inspection Office.  
16 That is a question that should be asked of the  
17 regional folks that are assessing current operation  
18 and not license renewal. It sounds like you have a  
19 problem with what is going on today.

20 MS. BARNES: This is something that has  
21 been continuing. The cask has been there for quite a  
22 while.

23 MS. LOUGHEED: Right. It's something that  
24 is currently there that you have a problem with that's  
25 current and you don't necessarily want to wait another

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 four or five years before it gets addressed so I would  
2 say --

3 MS. BARNES: I'm just saying that --

4 MS. LOUGHEED: It should be --

5 MS. BARNES: -- if it is part of license  
6 renewal it should be addressed. These are major  
7 issues that could cause major problems.

8 MS. LOUGHEED: Ma'am?

9 MS. BARNES: I just wondered because I  
10 didn't hear any mention of the problem in the  
11 discussion today. To me I believe these are very  
12 important issues.

13 MS. LOUGHEED: I agree that they are  
14 important issues but it sounds like they are current  
15 issues and so you should be taking them up in the mid-  
16 cycle assessment meetings because they are current  
17 problems. I believe that you would find a more  
18 receptive audience than one which is looking at a  
19 licensing process, not a current process.

20 MS. BARNES: This would be part of the  
21 license because these are conditions there.

22 MS. LOUGHEED: Ma'am?

23 MS. BARNES: I live near a re-licensed  
24 plant that disaster is waiting to happen and has  
25 possible soil contamination which by this time, since

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 1990, 16 years ago, has probably leaked into the Great  
2 Lakes.

3 MS. LOUGHEED: So you're saying you are  
4 not concerned today. You are only concerned in 2014.

5 MS. BARNES: I'm concerned with the  
6 relicensing that they are even considering relicensing  
7 a plant that has shown that it's negligent. I mean,  
8 it has had so many near disasters. Besides terrorism  
9 they are not taking other things into account -- the  
10 track record. They are not taking into account the  
11 contamination of soil. They are not taking into  
12 account the problems in the past.

13 They are not taking into account  
14 deteriorating water quality or the cancer pocket, the  
15 health of the residents in that area. There are so  
16 many things that have happened there. At one point  
17 they turned off the alarms because they didn't want to  
18 disturb people so they turned off the alarm system for  
19 a while. There's just a lot of things that have gone  
20 on here.

21 Someone within the nuclear industry that  
22 used to work there, he said he wouldn't work there  
23 anymore, that he didn't like the way they run things.  
24 He said it is well known within the nuclear industry  
25 that Palisades is the most likely to blow of all the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 nuclear power plants in the United States. We have a  
2 right to be concerned.

3 My whole life, my whole family, my  
4 friends, the ecosystem, the Great Lakes, that precious  
5 water, everything is at stake. I think this should be  
6 part of the relicensing because these are important  
7 issues. Your scientists and experts there should be  
8 looking at these things as well.

9 CHAIRMAN SIEBER: Well, unfortunately we  
10 are restricted by the Code of Federal Regulations Part  
11 54 which describes what we review -- when we consider  
12 license renewal. The issues you raise I'm sure are  
13 important to you and a lot of folks. I suggest and  
14 agree with Patricia that it ought to be brought up at  
15 the mid-cycle assessment meeting that the region holds  
16 in the vicinity of the plant. I think that is an  
17 appropriate forum for you to state your concerns.

18 MS. BARNES: Do you know when that meeting  
19 will be, sir?

20 MS. LOUGHEED: This is Patricia Lougheed.  
21 I do not know when that meeting will be but I will be  
22 happy to find out and get back to you.

23 MS. BARNES: Okay. I would very much  
24 appreciate it. Thank you.

25 MS. CAREY: Excuse me. How are you going

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 to get back to us if you don't know who we are and  
2 where we live?

3 MS. LOUGHEED: That's what I was just  
4 about to ask.

5 MS. CAREY: Well, thank you.

6 MS. LOUGHEED: So is there a contact?

7 CHAIRMAN SIEBER: Perhaps that is  
8 something we can do off-line because I would prefer  
9 not to have people's names and addresses in the public  
10 record.

11 MS. CAREY: That's a dilemma.

12 MS. LOUGHEED: I believe --

13 MS. BARNES: The project directors have  
14 our e-mails and phone numbers and such.

15 MS. CAREY: But we don't live anywhere  
16 near together. We are miles apart.

17 CHAIRMAN SIEBER: Okay.

18 MS. LOUGHEED: Juan has the information.

19 CHAIRMAN SIEBER: Okay. Thank you.

20 MS. BARNES: Thank you for letting us  
21 speak.

22 CHAIRMAN SIEBER: Okay. You're welcome  
23 and we appreciate hearing your point of view.

24 MS. CAREY: Yes. Well, we'll continue to  
25 listen if you have other comments.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 CHAIRMAN SIEBER: Well, I think that we  
2 have come to the time in our meeting where we can  
3 close the transcript.

4 MS. HIRT: I also have a question. I'm  
5 Alice Hirt. I live in Holland, Michigan.

6 MS. CUMBOW: And I also have a question.  
7 My name is Kay Cumbow and I live in Brown City,  
8 Michigan.

9 MS. HIRT: My question is -- this is Alice  
10 Hirt -- what are you -- are you still considering the  
11 fact that the waste is piling up on the beach and that  
12 is out of scope also? You don't really seem concerned  
13 that 20 more years of nuclear waste on Lake Michigan  
14 is important? Is that also out of scope, sir?

15 CHAIRMAN SIEBER: What waste are you  
16 referring to?

17 MS. HIRT: The radioactive waste.

18 PARTICIPANT: What waste?

19 MS. HIRT: The waste on the nuclear power  
20 plant that is now sitting on the shores of Lake  
21 Michigan. I am wondering if it is out of scope to be  
22 concerned about the waste piling up there on the beach  
23 for 20 more years if this license is renewed. I would  
24 like to know if that issue is out of scope.

25 CHAIRMAN SIEBER: I don't know whether

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 it's covered in the environmental impact statement or  
2 not. I don't know.

3 MS. HIRT: It's certainly in my scope. I  
4 live within 50 miles of the plant and I have a feeling  
5 that it is out of scope because we have tried to bring  
6 this issue before the Atomic Safety Licensing Board  
7 and we have been ruled out of scope on every issue we  
8 have brought forward. Just want to remind you that we  
9 don't consider it out of scope.

10 MS. BARNES: Also the casks are sitting on  
11 these pads which you mentioned in your meeting. They  
12 are sitting there like a bunch of bowling balls just  
13 waiting to be knocked over. If one goes, then more  
14 will go.

15 MS. CUMBOW: My name is Kay Cumbow and I  
16 also would like to ask a question.

17 CHAIRMAN SIEBER: Go ahead.

18 MS. CUMBOW: I had several actually. One  
19 is that EPRI just had a report published June of this  
20 year that showed intergranular cracking at Davis-  
21 Besse not only in 600 but also in alloy 182. I  
22 wondered how much of 182 is in the Palisades power  
23 plant.

24 Also, the steam generators you mentioned  
25 that they were also -- the new ones that were put in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 in the early 1990s that they were also made with -- I  
2 believe it was in the 1990s -- that they were made  
3 with 600 and that seems like a big red flag because  
4 they had such big problems with them plugging. Also,  
5 you mentioned that there were only four formally  
6 licensed engineers and that seemed like a small number  
7 of engineers that were formally licensed.

8 One of the questions I had was somebody  
9 asked about how to tell if annealing works and they  
10 said that you test the sample coupons but Palisades  
11 has no original sample coupons left in the reactor.

12 One question I had was how efficient is it  
13 to keep on using Palisades as they are using ultra-low  
14 leakage. It just seems like efficiency comes into the  
15 package because we are the taxpayers and taxpayers  
16 subsidize a whole lot of the cost of nuclear power  
17 plants and there are more efficient ways to make  
18 electricity.

19 The other question I had was about  
20 earthquakes because of the proximity to the New Madrid  
21 earthquake zone. The last time there were three huge  
22 earthquakes down there in the New Madrid zone and in  
23 St. Louis those quakes actually made waves on Lake  
24 Michigan and rang church bells in Maine and broke  
25 windows in Washington, D.C. It just seems like that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005



1 should be taken into account, especially because the  
2 pads that hold those huge heavy casks are built right  
3 on sand dunes.

4 The last point I would like to make is  
5 that Palisades does have a pretty incredible history  
6 when the NRC had a watch list Palisades was on and off  
7 that watch list continuously and it seems to me blind  
8 on the part of the Nuclear Regulatory Commission that  
9 they did away with the watch list. It seems like it  
10 didn't make any sense at all.

11 The other thing is that in 1986 Palisades  
12 had actually 4,000 repair orders that were backlogged.  
13 I agree that was back in 1986 but I am just telling  
14 you there is quite a bit of history here and it's not  
15 a pretty history.

16 The other thing was in 1979 there was a  
17 huge leak of radioactive iodine and the NRC actually  
18 went out and checked fishing boats to check people's  
19 fish for radioactive iodine. Palisades was fine  
20 during that time. They were fine because when they  
21 realized they were releasing radioactive iodine, they  
22 did not stop.

23 I could go on and on. The public has  
24 plenty that concerns us like the chemical  
25 contamination that is based on Lake Station, Michigan.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 There's a lot of unanswered questions about this  
2 plant. I would appreciate if somebody could answer  
3 some of the questions that I had -- all the questions  
4 I had.

5 MEMBER WALLIS: Do you want to try that?

6 CHAIRMAN SIEBER: You go ahead.

7 MEMBER WALLIS: I was thinking while you  
8 were speaking about who would be the right person to  
9 answer your questions. I don't think this  
10 subcommittee can answer your questions at this time.  
11 They are more questions for somebody else and it  
12 probably falls to the NRC in some way.

13 Then also what you have said is on the  
14 record. This meeting we are having today is to gather  
15 information. It's not as if we are making a decision  
16 today so how your comments go into the final decision  
17 I think is yet to be decided, but they are on the  
18 record and I don't think they will disappear. Thank  
19 you very much.C

20 MS. CUMBOW: Could I ask your name, sir?

21 MEMBER WALLIS: You want my name?

22 MS. CUMBOW: Um-hum.

23 MEMBER WALLIS: I'm Graham Wallis.

24 MS. CUMBOW: Okay. You know, not knowing  
25 anyone or seeing any name cards it's a little hard to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 know who is talking. What is your position, Mr.  
2 Wallis?

3 MEMBER WALLIS: I am actually the Chairman  
4 of the ACRS.

5 MS. CUMBOW: Of the ECRS.

6 MEMBER WALLIS: ACRS.

7 MS. CUMBOW: Oh, ACRS. Okay. Thank you.

8 MR. KARCH: My name is Gary Karch. I  
9 would like to say that as a member of the public I  
10 have to complain about the quality of the audio on  
11 this conference call that we're connected with.

12 About the only person I could ever hear  
13 clearly aside from these comments right at the end,  
14 which were very clear, one of the only other persons  
15 I heard well was Patricia was the only one I could  
16 hear clearly. It may not have been on purpose but it  
17 seems the net result is that the public could not hear  
18 the proceedings clearly so I wanted to complain about  
19 that.

20 You professionals are capable of talking  
21 about highly technical issues here and you can split  
22 atoms but you can't, you know, create a decent audio  
23 system for the public to hear clearly. Therefore, my  
24 other question is will there be minutes available,  
25 transcript of this proceedings and how soon will that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 be available?

2 CHAIRMAN SIEBER: There is on the NRC  
3 website a copy of transcripts of ACRS meetings and  
4 subcommittee meetings. I don't know how quickly they  
5 appear but I usually read them and it seems to me  
6 like three weeks or four weeks after the meeting is  
7 held that the transcript appears on the website. You  
8 will want to go to the category Electronic Reading  
9 Room on the website.

10 MR. KARCH: Okay.

11 CHAIRMAN SIEBER: When you get there you  
12 look for All Document Collections. When you get there  
13 you look for ACRS and it will have schedules, meeting  
14 agendas, and transcripts.

15 MR. KARCH: Right.

16 CHAIRMAN SIEBER: Look up today's date.

17 MR. KARCH: Okay. Very good.

18 MS. BARNES: Could I ask one more  
19 question? I understand that the precautionary  
20 principle is being applied by the IJC, International  
21 Joint Commission, which is, of course, the treaty  
22 arrangement between the United States and Canada for  
23 the safety and welfare of the Great Lakes. Now, how  
24 does the NRC apply the precautionary principle?

25 CHAIRMAN SIEBER: I have no idea, ma'am.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 MS. BARNES: As I would define  
2 precautionary principle, it is up to the industry and  
3 the NRC and any other corporate or producer of deadly  
4 waste to prove it does no harm rather than the  
5 longstanding position that has been taken which is  
6 that, "Public, you prove that it was our chemical that  
7 you died from," etc. Since the precautionary  
8 principle is getting more and more recognition among  
9 credible regulators and producers of all kinds of  
10 products, how does that currently fit into the NRC  
11 code?

12 CHAIRMAN SIEBER: Well, frankly, until you  
13 discussed it here I had never heard of that.

14 MS. BARNES: Oh.

15 CHAIRMAN SIEBER: So I am not aware of  
16 that.

17 MS. BARNES: Oh. Well, I would appreciate  
18 if you would Google it. It is an extremely important  
19 principle that has been, oh, at least 10 years in  
20 application to my understanding.

21 MS. HIRT: Excuse me. This is Alice Hirt  
22 again and I have one more quick question if I may be  
23 given that chance. I would like to ask  
24 straightforward to the NRC people and the Nuclear  
25 Management people at this meeting today do you have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 original coupons in the reactor vessel that can be  
2 removed to check levels of embrittlement? Could you  
3 answer that please straightforward? Original coupons  
4 of the original material that the vessel was created  
5 from.

6 MS. LOUGHEED: Ma'am, I don't believe we  
7 are prepared to answer that at this meeting.

8 MS. HIRT: It has a lot to do with the  
9 issue.

10 MS. LOUGHEED: Ma'am, I understand that it  
11 has a very -- that it is relevant. I'm just saying we  
12 are not prepared to answer it at this meeting.

13 MS. HIRT: There is no one there that can  
14 address --

15 MS. LOUGHEED: We do not have the right  
16 people.

17 MS. HIRT: -- that issue?

18 MR. KARCH: You came unprepared to answer  
19 questions from the public?

20 MS. LOUGHEED: Yes. This is not a public  
21 meeting. This is a meeting for the ACRS.

22 MS. HIRT: If you cannot answer that, I  
23 would like the answer to that question sent to me as  
24 soon as possible, please. Surely someone can answer  
25 that question. If not this afternoon tomorrow.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 MR. KNEELAND: This is John Kneeland of  
2 the NMC. We answered this question earlier in the  
3 meeting.

4 MS. HIRT: I've been listening ever since  
5 the meeting started. I know you said that there were  
6 three -- I can't say the exact wording. I did hear  
7 everything that was said but that does not answer my  
8 exact question. It did not say they were original,  
9 very original capsules.

10 MR. KNEELAND: They are three of the  
11 original capsules that were fabricated in 1966.

12 MS. BARNES: Those are not original. 1966  
13 is not -- 1966? Do you have written proof of that?

14 MR. KNEELAND: Yes, ma'am.

15 MS. HIRT: We would like to see that,  
16 please.

17 MS. BARNES: We would because we have seen  
18 other things that say that is not so.

19 MS. HIRT: Could you please provide that  
20 to one of us? I'll give you my name and address and  
21 I would like to see that proof, please.

22 MR. KARCH: You did not allow him to  
23 finish what he had. Could you say what you have?

24 MR. KNEELAND: We have three surveillance  
25 capsules remaining in the reactor vessel that have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1       been there since the beginning of plant operation. We  
2       have an additional surveillance capsule that sits just  
3       above the reactor vessel that has been in there since  
4       the beginning of plant operation.

5               MS. BARNES: I have a question. This is  
6       Katherine Barnes again.

7               MS. HIRT: Thank you. I look forward to  
8       seeing that information and documentation.

9               MR. JUNGE: We have somebody here we need  
10       to let speak and ask questions for now if you don't  
11       mind holding your question, please.

12              MR. KAMPS: Thank you. My name is Kevin  
13       Kamps and I work at Nuclear Information and Resource  
14       Service here in Washington, D.C. I have been asked by  
15       a number of intervenors who went before the Atomic  
16       Safety Licensing Board to represent them here today.

17              I just wanted to say that I heard a lot  
18       during the course of this afternoon about plans and  
19       commitments in the future. I think that the ACRS as  
20       a whole should take -- and the NRC staff as well  
21       should take plans and commitments from this company  
22       with a grain of salt.

23              One of the people on the phone brought up  
24       cask No. 4 as an example of promises by this company  
25       that have been broken in the past. The company

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005



1 publicly stated, and it was reported in the local  
2 newspapers that that container would be unloaded  
3 because it had problems. Here we are 12 years later  
4 and that cask is still sitting there.

5 Another very relevant promise that was  
6 stepped away from in the past had to do with the  
7 embrittlement problem. Again, the company said  
8 publicly that it would anneal the reactor vessel and  
9 that has not happened. I think this challenge goes as  
10 much to the NRC as it does to the company and that is  
11 it seems like every time that Palisades comes up  
12 against the embrittlement standard at NRC that  
13 standard is weakened or changed in some way.

14 It is incredible that here we are in the  
15 year 2006. Palisades again is brushing up against the  
16 NRC's screening criteria for pressurized thermal shock  
17 and, wouldn't you know it, there's another proposed  
18 change in the rules. We can only assume that is going  
19 to accommodate Palisades reactor yet again not for 40  
20 years of operations but for 60 years.

21 We are very concerned about the safety  
22 implications of this and we call upon the ACRS and the  
23 NRC to uphold NRC safety regulations. That is the  
24 mission of this agency. The stakes are too high to do  
25 anything else. I would like to point out to the ACRS

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 because they might not be aware of this.

2 The NRC staff might not be aware of this  
3 as well but the company went before regulators in  
4 Michigan on May 10th of this year. The meeting had to  
5 do with the sale of the plant and Patricia brought  
6 that up earlier that this plant is for sale. The  
7 company identified five areas that are leading it to  
8 want to sell this plant.

9 As I understand it, at the end of June  
10 that was the time line, the deadline for submissions,  
11 bids from other companies. I know that Exelon had a  
12 representative here today so I'm curious if they might  
13 be one of the bidders. Detroit Edison has expressed  
14 interest publicly. Anyway, Consumers Energy listed  
15 the following five areas as reasons for wanting to  
16 sell the plant.

17 Reactor vessel head replacement at a cost  
18 of \$100 million. Steam generator replacement.  
19 Reactor vessel embrittlement concerns. Increasing NRC  
20 fees and fire protection regulations. No. 5,  
21 containment coatings on sump strainers. I just find  
22 a disconnect or a contradiction between the company  
23 making all these commitments, promises, plans for the  
24 future while at the same time putting the plant up for  
25 sale.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1           One big picture question I have is does  
2 the company that buys this facility have to comply  
3 with all the commitments that have been made by the  
4 current owner. That is one question. Another  
5 question I have from today's presentation is although  
6 the steam generator was discussed during the course of  
7 today, it wasn't mentioned that there was another  
8 replacement in the works.

9           There's a lot of connection between  
10 current operations and 20 additional years at this  
11 facility. For safety sake and for protection of  
12 public health we hope that they will be rigorously  
13 addressed before this license extension is granted  
14 because we see a lot of promises but I don't think  
15 that promises can be accepted from this company. I  
16 think facts on the ground are the only thing that can  
17 be accepted. Thanks for the opportunity to ask these  
18 questions.

19           CHAIRMAN SIEBER: Okay. Thank you. I  
20 think that we are to the point now where we can close  
21 the record.

22           MR. KEEGEN: Could I raise one question?  
23 This is Michael Keegen in Michigan.

24           CHAIRMAN SIEBER: One question.

25           MR. KEEGEN: Yes, one question. Regarding

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 the third cycle interval in-service inspection of the  
2 reactor internals, my understanding is that will occur  
3 after the relicensing process. How can the ACRS  
4 approve relicensing when they haven't looked under the  
5 hood, so to speak? Did that get addressed? I didn't  
6 hear it.

7 CHAIRMAN SIEBER: Yeah. I'm contemplating  
8 your question. You are, of course, aware that every  
9 plant whether it has a renewed license or an original  
10 license is on a 10-year ISI cycle.

11 MR. KEEGEN: Correct.

12 CHAIRMAN SIEBER: That means that the  
13 basic structure of the plant all the components during  
14 various outages during that 10-year interval are  
15 inspected to make sure that they have integrity. The  
16 idea of having a structured timed program like that is  
17 to be able to measure degradation.

18 If you were to advance one of those 10-  
19 year intervals to now to accommodate license renewal,  
20 then there will be a period where you would not have  
21 information. That would be a concept that violates  
22 the ASME code which is what --

23 MR. KEEGEN: I believe that is what  
24 precisely is occurring. They have requested a delay  
25 of that inspection until beyond their relicensing.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 They have actually over the course of 35 years they  
2 have not done their third 10-year inspection yet and  
3 it is being deferred deferred.

4 CHAIRMAN SIEBER: Well, I think that's an  
5 issue that is current operation and I'm sure that the  
6 staff can address that.

7 MR. KEEGEN: Wouldn't the ACRS be  
8 concerned about having the results of that inspection  
9 prior to issuing a 20-year license renewal? That is  
10 my question.

11 CHAIRMAN SIEBER: I really don't know what  
12 the answer to that question is until the issue is  
13 resolved.

14 MR. KEEGEN: It's unresolved, and yet you  
15 are making a decision for 20 more years of license  
16 extension. That's my point.

17 CHAIRMAN SIEBER: We are not making a  
18 decision.

19 MEMBER WALLIS: Let me suggest this might  
20 be something we will look into because we are not  
21 making a decision today.

22 MR. KEEGEN: Very good. Very good. That  
23 is satisfactory if you look into it and it's part of  
24 the public record.

25 CHAIRMAN SIEBER: Okay.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

1 MR. KEEGEN: Thank you.

2 MS. BARNES: Thank you for letting us  
3 speak.

4 CHAIRMAN SIEBER: You're welcome. Any  
5 other comments? If there are no further comments, I  
6 think that we can close the transcript at this point.  
7 I want to thank everyone who has participated in the  
8 meeting today for their work and their patience with  
9 the process. This meeting is adjourned.

10 (Whereupon, at 4:59 p.m. the meeting was  
11 adjourned.)

12

13

14

15

16

17

18

19

20

21

22

23

24


25

CERTIFICATE

This is to certify that the attached proceedings before the United States Nuclear Regulatory Commission in the matter of:

Name of Proceeding: Advisory Committee on  
Reactor Safeguards  
Subcommittee on Plant License  
Renewal  
Docket Number: n/a  
Location: Rockville, MD

were held as herein appears, and that this is the original transcript thereof for the file of the United States Nuclear Regulatory Commission taken by me and, thereafter reduced to typewriting by me or under the direction of the court reporting company, and that the transcript is a true and accurate record of the foregoing proceedings.

  
\_\_\_\_\_  
Charles Morrison  
Official Reporter  
Neal R. Gross & Co., Inc.

**NEAL R. GROSS**  
COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



# Palisades Nuclear Plant License Renewal Safety Evaluation Report


## **Staff Presentation to the ACRS**

Juan Ayala, Project Manager

Office of Nuclear Reactor Regulation

July 11, 2006





# Introduction

- Overview
- Section 2: Scoping and Screening Review
- License Renewal Inspections
- Section 3: Aging Management Review Results
- Section 4: Time-Limited Aging Analyses (TLAAs)



# Overview


- LRA submitted by letter, dated March 22, 2005
- CE PWR-DRYAMB containment
- 2565 MWth, 865 MWe
- Operating License DRP-20 expires March 24, 2011
- PNP located 5 miles S of South Haven, MI



# Overview

- SER issued June 1, 2006
- No Open Items
- One Confirmatory item
- Four (4) license conditions
- 174 RAIs issued, 412 audit questions
- ≈95% consistent with draft GALL Report, Revision 1
- Minor components brought into scope

# Review Highlights



- AMP GALL Audit
  - June 20 - 24, 2005
- Scoping and Screening Methodology Audit
  - June 27 - July 1, 2005
- AMR GALL Audit
  - August 1 - 5, 2005
- Regional Inspections
  - October 24 - 28, 2005
  - November 14 - 18, 2005

# Section 2: Scoping and Screening Review



## Section 2.1 - Scoping and Screening Methodology

- On-site Audit - June 27 - July 1, 2005
- Staff audit and review concluded that the applicant's methodology satisfies the rule (10 CFR 54.4(a) and 10 CFR 54.21)
  - AFW Pump Room pipe insulation brought into scope

## Section 2.2 – Plant-Level Scoping

- No omission of systems or structures within the scope of license renewal

# Section 2: Scoping and Screening Review



## Section 2.3 – Mechanical Systems

- 29 mechanical systems
- 100% reviewed
- On-site review of mechanical systems
- 0 items referred to Regional inspection team


# Section 2: Scoping and Screening Review



## Section 2.3 – Mechanical Systems

- Components brought into scope
  - Steam generator feedwater ring
  - Boric acid pump filters
  - Air supply line and air reservoirs
  - Solenoid valves
  - First and second stage air compressors, including the load/unload valves
  - Feedwater heaters
  - Primary system make-up storage tank underground piping

# Section 2: Scoping and Screening Review



## Section 2.4 – Containment, Structures, and Supports

- No omission of structures or supports within the scope of license renewal

## Section 2.5 – Electrical and Instrumentation & Control

- No omission of electrical and instrumentation & control systems components within the scope of license renewal



# Section 2: Scoping and Screening Summary



- The applicant's scoping methodology meets the requirements of 10 CFR Part 54
- Scoping and screening results, as amended, included all SSCs within the scope of license renewal and subject to AMR



# **License Renewal Inspections**


**Patricia Lougheed  
Region III**



# Overview


- Two-week onsite inspection from October 24 to November 16, 2005
- Scheduled to support NRR reviews
- Team of five experienced inspectors
- Inspection performed in accordance with NRC Inspection Procedure 71002

# Scoping and Screening



- Reviewed 11 systems
- Looked at electrical, structural, and mechanical systems
- Emphasized plant physical walk downs
- Concentrated on non-safety systems whose failure could impact safety systems

# Scoping and Screening Conclusions



- Systems appropriately scoped
- Some minor inconsistencies identified
- Scoping and screening acceptable for license renewal




# Aging Management

- Reviewed 14 AMP and 2 TLAA programs
- Reviewed
  - existing plant documentation
  - operational experience information
  - corrective actions to current plant issues and
  - proposed enhancements and commitments
- Followed up on NRR review efforts
- Performed plant walk downs

# Aging Management Conclusions



- Aging Management Programs adequate for period of extended operation when enhanced or implemented in accordance with commitments



# Overall Conclusions


- Palisades scoping, screening and aging management programs sufficient for extended operation
- Region III does not see any inspection impediments to renewing the operating license




# Current Performance



- Licensee is in the Licensee Response Column (Column I) of the NRC's Action Matrix
- NRC does not currently have any cross-cutting issues open at Palisades
- Revised Reactor Oversight Process continues to be followed



# Performance Indicators




## Performance Indicators

Unplanned Scrams (G)	Emergency AC Power System Unavailability (G)	Reactor Coolant System Activity (G)	Drill/Exercise Performance (G)	Occupational Exposure Control Effectiveness (G)	RETS/ODCM Radiological Effluent (G)
Scrams With Loss of Normal Heat Removal (G)	High Pressure Injection System Unavailability (G)	Reactor Coolant System Leakage (G)	ERD Drill Participation (G)		
Unplanned Power Changes (G)	Heat Removal System Unavailability (G)		Alert and Notification System (G)		
	Residual Heat Removal System Unavailability (G)				
	Safety System Functional Failures (G)				



# Inspection Findings



## Most Significant Inspection Findings

	Initiating Events	Mitigating Systems	Barrier Integrity	Emergency Preparedness	Occupational Radiation Safety	Public Radiation Safety	Physical Protection (NOT PUBLIC)
1Q/2006	No findings this quarter	G	No findings this quarter	No findings this quarter	No findings this quarter	No findings this quarter	No findings this quarter
4Q/2005	G	No findings this quarter	G	No findings this quarter	No findings this quarter	No findings this quarter	No findings this quarter
3Q/2005	No findings this quarter	G	No findings this quarter	No findings this quarter	No findings this quarter	No findings this quarter	No findings this quarter
2Q/2005	G	G	No findings this quarter	No findings this quarter	G	No findings this quarter	No findings this quarter

Miscellaneous findings

# Section 3: Aging Management Review Results




- 3.1 Reactor Coolant System
- 3.2 Engineered Safety Features
- 3.3 Auxiliary Systems
- 3.4 Steam and Power Conversion Systems
- 3.5 Containments, Structures, and Component Supports
- 3.6 Electrical and I&C Components

# Aging Management Programs (AMPs)



- 24 AMPs
  - 20 existing AMPs, 4 new AMPs
  - Consistent with GALL Report - 13
  - Consistent with GALL Report with exceptions/  
enhancements – 10
  - Plant-specific – 1

# Buried Services Corrosion Monitoring Program




- New AMP Consistent with GALL
  - 10-year frequency
  - If insufficient data exist, focused inspections will be performed
  - Include inspections of opportunity
  - Only one below-grade tank
    - Diesel fuel oil storage tank is contained in a vault and not exposed to soil

# Bolting Integrity Program



- Existing AMP Consistent with enhancements (2)
  - (1) review and revise the ASME ISI master plan and plant maintenance procedures to reflect GALL Report guidance and
  - (2) evaluate high-strength bolting used in component supports for cracking
- System Monitoring Program
  - Non-Safety Related bolting
- Structural Monitoring Program
  - Structural bolting
- ASME Section XI IWB, IWC, IWD, IWF ISI Program
  - ASME Class 1, 2, and 3 bolting



# Boric Acid Corrosion Program

- Enhancements were provided as commitments
- Three (3) Commitments
  - Revise procedures to include criteria for observing susceptible SSC for boric acid leakage and degradation during system walkdown inspections.
  - Revise procedures to include explicit acceptance criteria for boric acid inspections.
  - Revise procedures to include inspection of structural steel and non-ASME component supports for evidence of boric acid residue and boric acid wastage/corrosion.



# Flow-Accelerated Corrosion Program



- Existing program consistent with GALL
- Proposed criteria less conservative for NSR piping
- NSR piping brought to same criteria as safety-related piping

# Reactor Vessel (RV) Integrity Surveillance Program



- Enhancements were submitted as commitments
- Four (4) Commitments
  - Ensure that pressure-temperature and LTOP curves are updated to bound the extended operating period. Curves will be updated and submitted to NRC for approval prior to the period of extended operation
  - Document and establish the requirement to save and store all pulled and tested RV surveillance capsules for future reconstitution use.

# Reactor Vessel (RV) Integrity Surveillance Program



- Four (4) Commitments (continued)
  - Ensure that at least one surveillance capsule remains in the RV and is tested during the period of extended operation to monitor the effects of neutron irradiation.
  - Develop a program level procedure to implement and control Technical Specification and FSAR activities associated with the RV Integrity Surveillance Program.

# System Monitoring Program




- Plant specific AMP consistent with GALL AMP XI.M29, “Aboveground Carbon Steel Tanks”
- Used to identify degraded conditions on external surfaces of piping, tanks, and other components and equipment
- Opportunistic inspections of external surfaces when insulation is removed
- Commitment
  - If there is insufficient data, applicant will remove insulation in additional locations to increase sample size

# Section 3: Aging Management Review Results



- 100% Review
  - 29 plant systems
  - 10 structures
  - 9 commodity groups



# Auxiliary Systems

- SFP Neutron Absorbing Sheets
  - For fuel racks with boron carbide panels, no coupon program exists
  - Applicant has committed to performing industry approved neutron absorption testing to monitor for degradation.
- Thermal Sleeves
  - Aging effects requiring management added for cracking due to SCC and PWSCC
  - Managed with ASME Section XI ISI and Water Chemistry Programs

# Aging Management of In-Scope Inaccessible Concrete



	Acceptance Criteria	PNP		
		1966	1996	2004
pH	>5.5	6.1 - 7.7	N/A	7.0
Chlorides	<500 ppm	4.0 - 39	23	139
Sulfates	<1500 ppm	9.47 - 33.17	15.2	11.5

- Below-grade environment is non-aggressive
- Periodic testing of ground water will be performed as part of the Structures Monitoring Program


# Electrical and I&C Components



- 9 commodity groups reviewed
  - Electrical cables and connections not subject to 10 CFR 50.49 EQ requirements
  - Electrical cables and connections used in instrumentation circuits not subject to 10 CFR 50.49 EQ requirements that are sensitive to reduction in conductor IR
  - Electrical Portion of the Non-EQ Electrical and I&C Penetration Assemblies (Cables and Connections)
  - Fuse Holders
  - Non-Segregated Phase Bus and Connections
  - High-Voltage Transmission Conductors
  - High-Voltage Switchyard Bus and Connections
  - Inaccessible medium-voltage (2kV to 15kV) cables and connections not subject to 10 CFR 50.49 EQ requirements
  - High-Voltage Insulators



# Section 4: Time-Limited Aging Analyses (TLAA)



- 4.1 TLAA Process
- 4.2 Reactor Vessel Neutron Embrittlement
- 4.3 Metal Fatigue
- 4.4 Environmental Qualification of Electrical Equipment
- 4.5 Concrete Containment Tendon Prestress Analysis
- 4.6 Containment Liner Plate and Penetrations Load Cycle
- 4.7 Plant Specific TLAA
  - 4.7.1 Crane Load Cycles
  - 4.7.2 Alloy 600 Nozzle Safe Ends Life Assessment Analysis
  - 4.7.5 Reactor Pump Fly Wheel Fatigue or Crack Growth Analysis
  - 4.7.6 Reactor Vessel Underclad Cracking (New TLAA)



# Section 4 - Overview


- Section 4.2: Reactor Vessel and Internals Neutron Embrittlement
  - Three analyses affected by irradiation embrittlement identified as TLAAs
    - Pressurized Thermal Shock
    - Upper Shelf Energy
    - Pressure Temperature Limits
- Applicant used 42.37 EFPY (60 years)

# Section 4 - Overview



- RV Pressurized Thermal Shock

<b>Limiting Material for PTS</b>	<b>Screening Criteria</b>	<b>Calculated 42.37 EFPY <math>RT_{PTS}</math> value</b>	<b>Conclusion</b>
Intermediate shell and lower shell axial welds (W5214)	270 °F	Applicant: 287 °F (Calculation Confirmed by Staff)	Screening Criterion is exceeded in 2014



# Section 4 - Overview

- Palisades Plan for PTS
  - Continue to use an ultra low leakage core design
  - Submit final PTS resolution three years before 2014 (10 CFR 50.61)
- Options
  - Change of operation: further flux reduction and preheating the safety injection water
  - Thermal annealing of the reactor pressure vessel (10 CFR 50.66)



# Section 4 - Overview

- RV Upper Shelf Energy (USE)


<b>Limiting Plate and Weld for USE</b>	<b>Acceptance Criterion</b>	<b>Calculated USE Value for 42.37 EFPY</b>	<b>Conclusion</b>
Lower shell plate (D-3804-1)	Projected USE > 50 ft-lbs	48.97 ft-lbs (Calculation Confirmed by Staff)	Acceptance criterion is exceeded in 2021
Intermediate to lower shell circ. Weld (9-112)	Projected USE > 50 ft-lbs	50.83 ft-lbs (Calculation Confirmed by Staff)	Acceptable [TLAA satisfies §54.21(c)(1)(ii)]

# Section 4 - Overview




- Palisades Plan for USE
  - Submit Equivalent Margins Analysis (EMA) three years before 2021 (10 CFR 50, Appendix G)

# Section 4.3: Metal Fatigue



- Acceptability Criterion: Cumulative Usage Factor,  $CUF \leq 1.0$  for all ASME Class 1 piping components based on a 60-year life
- Fatigue Monitoring Program will ensure that the CUF remains  $\leq 1$  for PEO
- Staff accepted the evaluations in accordance with 10 CFR 54.21(c)(1)(i), (ii) and (iii)

## Section 4.4: Environmental Qualification (EQ) of Electrical Equipment



- Applicant's EQ Program consistent with GALL AMP X.E1, "Environmental Qualification of Electrical Equipment"
- Staff concluded the EQ Program is adequate to manage the effects of aging on the intended function of electrical components
- The staff accepted the evaluation in accordance with 10 CFR 54.21(c)(1)(iii)



# Reactor Vessel Underclad Cracking



- Confirmatory Item: Underclad Crack Growth
  - Technical basis is WCAP 15338-A which has been approved by the staff
  - Staff is verifying a plant specific WCAP, using the same methodology as WCAP 15338-A, for PNP



# TLAA Summary

- TLAA list was complete and acceptable in accordance with 10 CFR 54.3
- 10 CFR 54.21(c)(1)
  - (i) analyses remain valid for PEO
  - (ii) analyses projected to the end of the PEO
  - (iii) effects of aging will be adequately managed for the PEO
- There are no plant-specific exemptions in accordance with 10 CFR 54.21(c)(2)




# Conclusions


- The staff has concluded that there is reasonable assurance that the activities authorized by the renewed license will continue to be conducted in accordance with the CLB
- Any changes made to the PNP CLB are in accord with the Act and the Commission's regulations and to comply with 10 CFR 54.29(a)

# ***Palisades Nuclear Plant***

*Presentation to ACRS License Renewal Subcommittee*



*July 11, 2006*



*Palisades Nuclear Plant Presentation to ACRS License Renewal Subcommittee*

## **Attendees**

- Darrel Turner – Site Manager of Projects
- John Broschak – Site Engineering Director
- Bob Vincent – License Renewal Project Manager
- Paul Harden – Site Vice President
- Mark Cimock – Mechanical and Civil/Structural Lead
- Larry Seamans – Electrical Lead
- Bill Roberts – Programs Lead
- John Kneeland – TLAA Lead
- Brian Brogan – Site PRA / Safety Analysis Lead




2




## Agenda

- Description of Plant
- Plant Licensing History
- Major Plant Modifications
- Current Plant Status
- License Renewal Methodology
- Commitment Management
- Technical Issues
  - Pressurized Thermal Shock
  - Intergranular Separation
  - GSI-191




## Plant Description

- Owned by Consumers Energy Company
- Operated by Nuclear Management Company
- 432 Acre Site Located in Covert, Michigan
- Combustion Engineering NSSS / Bechtel AE
  - 2 Loops, 4 Primary Coolant Pumps, 2 Steam Generators
- Pre-Stressed Concrete Containment



## Plant Description

- Forced Draft Cooling Towers
- Ultimate Heat Sink is Lake Michigan via Service Water System
- Licensed Power 2565.4 Mwt.
- Design Electrical Output 820 Mwe<sub>net</sub>
- Plant PRA Shows Overall CDF (Internal Events) 2.86E-05/yr; LERF 3.55E-7/yr




## Licensing History

- 1967 - Construction Permit Issued
- 1971 - Provisional Operating License (POL) Issued to Expire in 2007
- 1974 – Applied for Full Term Operating License (FTOL)
- 1978 - 1983 – NRC Systematic Evaluation Program
- 1991 – FTOL Issued to Expire in 2007
- 2000 – License Expiration Changed to March 24, 2011
- 2005 – Licensed Power Raised from 2530 Mwt to 2565.4 Mwt




## Major Plant Modifications/Improvements

- 1974-75 – Converted Once-Through Circulating Water to Cooling Towers, Retubed Condenser
- 1977, 1987 – Expanded Spent Fuel Pool Storage
- 1983 – Added Third Auxiliary Feedwater Pump and Upgraded System to Safety-Grade
- 1983 – Upgraded Control Room HVAC to Safety-Grade



## Major Plant Modifications/Improvements

- 1985-86 – Initial PRA Applications at Palisades
- 1989 – Diversified Connection Paths to Offsite Power Supplies (PRA Insight)
- 1990 – Replaced Steam Generators
- 1990 – Retubed Main Condenser and Feedwater Heaters
- 1993 – Implemented Dry Spent Fuel Storage (VSC-24)



## Major Plant Modifications/Improvements

- 1995 – Modified Under-Reactor Vessel Floor Drains to Containment Sump (PRA Insight)
- 2004 – Implemented Second Dry Spent Fuel Storage System (NUHOMS)
- 2006 – Implemented SAMA Improvement - Non-Safety Backup Diesel Generator ▶



## Current Plant Status


- Operating at 100% Power in 19<sup>th</sup> Cycle
- Next Refueling Outage Fall 2007
- All NRC Performance Indicators are Green ▶
- No NRC Inspection Findings >Green ▶





## License Renewal Application Methodology

- LRA Dated March 22, 2005
- NEI 95-10 Standard Format
- NUREG 1801 (GALL) Revision 0 (2001)
- NUREG 1800 (SRP-LR) was Revision 0 (2001)
- Interim Staff Guidance Documents (ISGs) were Addressed in LRA
- Project was Staffed with Plant-Experienced Leads and LR-Experienced Support




## License Renewal Application Methodology

- Scoping, Screening and Aging Management Reviews Performed to Industry Standards
- Experiences of Prior Applicants Incorporated
- Implemented Spaces Approach for 10 CFR 54.4(a)(2)
- LRA System Descriptions and Boundaries Consistent with FSAR
- AMR Results in LRA Reconciled to GALL Revision 0 (2001)



## **License Renewal Application Methodology**


- Assessed Consistency of Results with January 2005 Draft Revision 1 of GALL
- Reassessed Consistency after Final GALL Revision 1 Issued in September 2005
- 24 Aging Management Programs (4 new, 20 existing) 

## **Commitment Management**

- Commitments for Future Action are Confirmed in SER Appendix A
- Commitments are Tracked in Plant Corrective Action Program
- Program Descriptions, TLAA Descriptions, and Commitments will be Incorporated Into FSAR

## Technical Issues

- Pressurized Thermal Shock
- Intergranular Separation
- GSI-191, Assessment of Debris Accumulation on PWR Sump Performance



## Pressurized Thermal Shock (PTS)

- Reach 10 CFR 50.61 Screening Criterion in 2014
- Aggressive Flux Reduction Implemented by Ultra-low Leakage Core Design
- Participating in NRC Research Program Developing Updated Technical Methodology
- Alternatives are Available to Manage Issue for Period of Extended Operation
- Proposed 10 CFR 50.61 Rule Change may Preclude Need for Plant-Specific Management Strategy



## **Intergranular Separation (Under-Clad Cracking)**

- Generic Industry Question in 1970s – Acceptable for 40 Years
- Westinghouse Evaluated for 60 Years in WCAP-15338 (NRC Accepted Methodology and Results)
- Palisades Evaluated Using Same Methodology
- Palisades Results Consistent with WCAP-15338
  - Little/No Growth Over 60 Years
  - No Effect on Structural Integrity
- Results Reported to NRC for Review and Acceptance




17



## **GSI-191: “Assessment of Debris Accumulation on PWR Sump Performance”**

- GSI-191 Applicable to All PWRs (GL 2004-02)
- Palisades will install Passive Sump Strainers by 12/31/07
- License Amendment requested for Removal of Tri-Sodium Phosphate and Manual Injection of Sodium Hydroxide
- Alternate Buffering System will be installed by 12/31/2007




18






## Backup Slides



## Palisades Aging Management Programs

- Alloy 600 Program
- ASME Section XI IWB, IWC, IWD, IWF Inservice Inspection Program
- Bolting Integrity Program
- Boric Acid Corrosion Program
- Buried Services Corrosion Monitoring Program (new)
- Closed Cycle Cooling Water Program
- Compressed Air Program
- Containment Inservice Inspection Program
- Containment Leakage Testing Program
- Diesel Fuel Monitoring and Storage Program
- Fire Protection Program
- Flow Accelerated Corrosion Program




21



## Palisades Aging Management Programs (cont)

- Non-EQ Electrical Commodities Condition Monitoring Program (new)
- One-Time Inspection Program (new)
- Open Cycle Cooling Water Program
- Overhead Load Handling Systems Inspection Program
- Reactor Vessel Integrity Surveillance Program
- Reactor Vessel Internals Inspection Program
- Steam Generator Tube Integrity Program
- Structural Monitoring Program
- System Monitoring Program
- Water Chemistry Program
- Electrical Equipment Qualification Program
- Fatigue Monitoring Program (new)



22



## SAMA Candidates

The following SAMA Candidates are Being Evaluated:

- Modify Turbine-driven AFW Pump procedures to Support Indefinite Operation Without AC, DC or Air Services
- Add Nitrogen Backup to Critical instrumentation to Reduce Importance of Loss of Instrument Air
- Insulate Emergency Diesel Generator Exhaust Ducts to Reduce Potential for Room Overheating
- Replace Bus Undervoltage Relays with Seismically Qualified Models
- Modify PCS Cooldown Procedures to Reduce Probability of Reactor Coolant Pump Seal Failures



23





## SAMA Candidates (cont)

- Install Direct Drive Diesel Injection Pump to Back Up Turbine-driven AFW Pump
- Install Additional Emergency Diesel Generator
- Install Permanent, Dedicated Cooling Water Line to Emergency Diesel Generators
- Provide Additional Field Flashing Capability to Emergency Diesel Generators
- Replace Air-Operated Containment Sump Valve with Motor-Operated Valve



24









## 2005 Palisades Performance

- Highest Production Year, 5% Higher Than Previous Best
- 9 of Last 10 Years Are Top-10 Generation Years
- NMC Fleet Standardized Organization Fully Implemented at Palisades
- Lowest Yearly Radiation Dose Record, 50% Lower Than Previous Best
- Industry 'Top Quartile' On-Line Corrective Work Order Backlog at 9
- Industry 'Top Quartile' On-Line Elective Maintenance Backlog at 263
- New Reactor Head Has Been Forged



27





# Auxiliary Systems

- SFP Neutron Absorbing Sheets
  - For fuel racks with boron carbide panels, no coupon program exists
  - Applicant has committed to performing industry approved neutron absorption testing to monitor for degradation.
- Thermal Sleeves
  - Aging effects requiring management added for cracking due to SCC and PWSCC
  - Managed with ASME Section XI ISI and Water Chemistry Programs

# Aging Management of In-Scope Inaccessible Concrete



	Acceptance Criteria	PNP		
		1966	1996	2004
pH	>5.5	6.1 - 7.7	N/A	7.0
Chlorides	<500 ppm	4.0 - 39	23	139
Sulfates	<1500 ppm	9.47 - 33.17	15.2	11.5

- Below-grade environment is non-aggressive
- Periodic testing of ground water will be performed as part of the Structures Monitoring Program

# Electrical and I&C Components



- 9 commodity groups reviewed
  - Electrical cables and connections not subject to 10 CFR 50.49 EQ requirements
  - Electrical cables and connections used in instrumentation circuits not subject to 10 CFR 50.49 EQ requirements that are sensitive to reduction in conductor IR
  - Electrical Portion of the Non-EQ Electrical and I&C Penetration Assemblies (Cables and Connections)
  - Fuse Holders
  - Non-Segregated Phase Bus and Connections
  - High-Voltage Transmission Conductors
  - High-Voltage Switchyard Bus and Connections
  - Inaccessible medium-voltage (2kV to 15kV) cables and connections not subject to 10 CFR 50.49 EQ requirements
  - High-Voltage Insulators

# Section 4: Time-Limited Aging Analyses (TLAA)



- 4.1 TLAA Process
- 4.2 Reactor Vessel Neutron Embrittlement
- 4.3 Metal Fatigue
- 4.4 Environmental Qualification of Electrical Equipment
- 4.5 Concrete Containment Tendon Prestress Analysis
- 4.6 Containment Liner Plate and Penetrations Load Cycle
- 4.7 Plant Specific TLAA
  - 4.7.1 Crane Load Cycles
  - 4.7.2 Alloy 600 Nozzle Safe Ends Life Assessment Analysis
  - 4.7.5 Reactor Pump Fly Wheel Fatigue or Crack Growth Analysis
  - 4.7.6 Reactor Vessel Underclad Cracking (New TLAA)



# Section 4 - Overview

- Section 4.2: Reactor Vessel and Internals Neutron Embrittlement
  - Three analyses affected by irradiation embrittlement identified as TLAAAs
    - Pressurized Thermal Shock
    - Upper Shelf Energy
    - Pressure Temperature Limits
- Applicant used 42.37 EFPY (60 years)



# Section 4 - Overview

- RV Pressurized Thermal Shock

<b>Limiting Material for PTS</b>	<b>Screening Criteria</b>	<b>Calculated 42.37 EFPY RT<sub>PTS</sub> value</b>	<b>Conclusion</b>
Intermediate shell and lower shell axial welds (W5214)	270 °F	Applicant: 287 °F (Calculation Confirmed by Staff)	Screening Criterion is exceeded in 2014



# Section 4 - Overview

- Palisades Plan for PTS
  - Continue to use an ultra low leakage core design
  - Submit final PTS resolution three years before 2014 (10 CFR 50.61)
- Options
  - Change of operation: further flux reduction and preheating the safety injection water
  - Thermal annealing of the reactor pressure vessel (10 CFR 50.66)





# Section 4 - Overview

- RV Upper Shelf Energy (USE)

<b>Limiting Plate and Weld for USE</b>	<b>Acceptance Criterion</b>	<b>Calculated USE Value for 42.37 EFPY</b>	<b>Conclusion</b>
Lower shell plate (D-3804-1)	Projected USE > 50 ft-lbs	48.97 ft-lbs (Calculation Confirmed by Staff)	Acceptance criterion is exceeded in 2021
Intermediate to lower shell circ. Weld (9-112)	Projected USE > 50 ft-lbs	50.83 ft-lbs (Calculation Confirmed by Staff)	Acceptable [TLAA satisfies §54.21(c)(1)(ii)]

# Section 4 - Overview




- Palisades Plan for USE
  - Submit Equivalent Margins Analysis (EMA) three years before 2021 (10 CFR 50, Appendix G)

# Section 4.3: Metal Fatigue



- Acceptability Criterion: Cumulative Usage Factor,  $CUF \leq 1.0$  for all ASME Class 1 piping components based on a 60-year life
- Fatigue Monitoring Program will ensure that the CUF remains  $\leq 1$  for PEO
- Staff accepted the evaluations in accordance with 10 CFR 54.21(c)(1)(i), (ii) and (iii)

## Section 4.4: Environmental Qualification (EQ) of Electrical Equipment



- Applicant's EQ Program consistent with GALL AMP X.E1, "Environmental Qualification of Electrical Equipment"
- Staff concluded the EQ Program is adequate to manage the effects of aging on the intended function of electrical components
- The staff accepted the evaluation in accordance with 10 CFR 54.21(c)(1)(iii)

# Reactor Vessel Underclad Cracking



- Confirmatory Item: Underclad Crack Growth
  - Technical basis is WCAP 15338-A which has been approved by the staff
  - Staff is verifying a plant specific WCAP, using the same methodology as WCAP 15338-A, for PNP

# TLAA Summary



- TLAA list was complete and acceptable in accordance with 10 CFR 54.3
- 10 CFR 54.21(c)(1)
  - (i) analyses remain valid for PEO
  - (ii) analyses projected to the end of the PEO
  - (iii) effects of aging will be adequately managed for the PEO
- There are no plant-specific exemptions in accordance with 10 CFR 54.21(c)(2)



# Conclusions

- The staff has concluded that there is reasonable assurance that the activities authorized by the renewed license will continue to be conducted in accordance with the CLB
- Any changes made to the PNP CLB are in accord with the Act and the Commission's regulations and to comply with 10 CFR 54.29(a)