

R4-8B4

**From:** Steven Cochrum  
**To:** David Loveless  
**Date:** 2/26/04 4:02PM  
**Subject:** SW info

There is not a valve SW-117, there is a SW-116. The non-safety related SW components are isolated on low sw press (approx 30psig) by MOV 36 and 37, they can be isolated from the CR if needed. Also, if needed SW-1490 would be isolated if 36/37 failed to isolate (manual only).  
Hope this helps.

P-8