

R4-8B3

Model Changes:

LOOP Update:		
ACP-XHE-NOREC-30	.22	$5.14 \times 10^{-1}$
ACP-XHE-NOREC-4H	.023	$6.8 \times 10^{-2}$
ACP-XHE-NOREC-90	.061	$2.35 \times 10^{-1}$
ACP-XHE-NOREC-BD	.023	$6.8 \times 10^{-2}$
IE-LOOP	$5.20 \times 10^{-6}/hr$	$5.32 \times 10^{-6}/hr$
EPS-DGN-FR-FTRE	0.5 hrs.	0.5 hrs.
EPS-DGN-FR-FTRM	2.5 hrs.	13.5 hrs.
OEP-XHE-NOREC-10H	$2.9 \times 10^{-2}$	$5.6 \times 10^{-2}$
OEP-XHE-NOREC-1H	$1.2 \times 10^{-1}$	$3.93 \times 10^{-1}$
OEP-XHE-NOREC-2H	$6.4 \times 10^{-2}$	$2.49 \times 10^{-1}$
OEP-XHE-NOREC-4H	$4.5 \times 10^{-2}$	$1.36 \times 10^{-1}$
Case Update:		
EPS-DGN-FR-FTRL	$2.5 \times 10^{-4}/hr$	$2.25 \times 10^{-3}/hr$

Ex.  
5

Information in this record was deleted  
in accordance with the Freedom of Information  
Act, exemptions 5  
FOIA-2006-0007

Q-5