

March 12, 2007

CAL No. NRR-07-001

Mr. Gene F. St. Pierre  
Site Vice President  
c/o James M. Peschel  
Seabrook Station  
Seabrook, NH 03874

SUBJECT: CONFIRMATORY ACTION LETTER, SEABROOK STATION, UNIT NO. 1

Dear Mr. St. Pierre:

This letter confirms commitments by Florida Power & Light Company and FPL Energy Seabrook, LLC in regard to Alloy 82/182 butt welds in the pressurizer at Seabrook Unit No. 1.

The discovery, in October 2006, of five circumferential indications in three dissimilar metal (DM) welds on the pressurizer at the Wolf Creek Generating Station (Wolf Creek) raised safety concerns based on the size and location of the indications. At Wolf Creek, three indications were in the pressurizer surge nozzle-to-safe end weld, and two separate indications were in the safety and relief nozzle-to-safe end welds. These findings also indicated that significant concerns might exist with the inspection schedules for addressing the pressurizer weld concerns issued by the industry-sponsored Materials Reliability Program (MRP), in "Primary System Piping Butt Weld Inspection and Evaluation Guideline (MRP-139)."

The Nuclear Regulatory Commission (NRC) is concerned about the pressurizer surge nozzle-to-safe end weld indications, as this is the first time that multiple circumferential primary water stress-corrosion cracking (PWSCC) indications have been identified in a weld. This condition calls into question the degree of safety margin present in past structural integrity evaluations for flawed DM welds susceptible to PWSCC, since multiple stress-corrosion cracking flaws may grow independently and ultimately grow together, significantly reducing the time from flaw initiation to leakage or rupture. The size of the relief nozzle-to-safe end flaw is also of concern, as this flaw has a much larger aspect ratio than those assumed in the estimates used to establish the basis for completing the baseline inspections required by the industry-sponsored MRP. Larger aspect ratios could result in achieving a critical flaw size and rupture before the onset of detectable leakage.

The long-term resolution of this issue is expected to involve changes to the American Society of Mechanical Engineers Boiler and Pressure Vessel Code (ASME Code), and will involve changes to the NRC regulations in Title 10 of the *Code of Federal Regulations* (10 CFR), Part 50, Section 50.55a, "Codes and standards." The development of the NRC regulations, whether the rule adopts the ASME Code standards or defines separate requirements, will likely benefit from additional operating experience, continuing assessments, and analysis being conducted by the NRC and the MRP.

Until NRC regulations are revised, it is necessary to establish a minimum set of enhanced reactor coolant system (RCS) DM butt weld inspection expectations for nickel-based Alloy 82/182 pressurizer surge, spray, safety, and relief nozzle butt welds, including safe end welds, to supplement existing inspection and other requirements of the ASME Code and NRC regulations. In addition, enhanced monitoring of RCS leakage is needed to promptly identify any through-wall flaws in the pressurizer surge, spray, safety, or relief nozzle DM butt welds or safe end DM butt welds to prevent additional degradation from occurring. The above actions provide reasonable assurance that there is no undue risk to the health and safety of the public while the NRC regulations are revised.

The NRC communicated the need for near-term enhancements to the industry through public meetings held on November 30, 2006, December 20, 2006, and February 2, 2007. Licensees submitted letters voluntarily committing to the enhanced inspection and leakage monitoring requirements. After teleconferences with specific licensees held between February 12 through February 23, 2007, the licensees submitted supplemental commitment letters addressing the NRC staff's concerns regarding inspection, compensatory actions, and reporting.

In your letter dated February 21, 2007 (Agencywide Documents Access and Management System (ADAMS) ML070530548), you described actions you will take at the Seabrook Station for the pressurizer DM butt welds containing Alloy 82/182 material.

These commitments address: 1) completion schedules for inspection/mitigation of the welds; 2) RCS leak monitoring frequency, action levels, and actions; and 3) reporting requirements.

The NRC staff has reviewed these actions and commitments and agrees the actions and commitments are appropriate to address the potential of PWSCC of the applicable pressurizer DM butt welds containing Alloy 82/182 material with clarifications on two of the commitments as indicated in bold below regarding acceleration of weld mitigation and reporting.

- FPL Energy Seabrook will accelerate the outage currently scheduled for April 2008 into 2007 if the calculations being developed by NEI and MRP do not demonstrate an adequate level of safety **to the NRC**. This schedule could also be accelerated if new information is obtained during upcoming inspections at other plants that challenge current industry assumptions.
- FPL Energy Seabrook shall report results of any bare metal visual inspections required, **and will provide the results of the pressurizer butt weld inspection or mitigation actions** to NRC 60 days after plant start up.

These clarifications were discussed with and agreed upon by you during a telephone discussion on March 6, 2007, with Michele Evans, Director, Division of Component Integrity, Office of Nuclear Reactor Regulation.

Pursuant to Section 182 of the Atomic Energy Act, 42 U.S.C. 2232, you are required to:

- 1) Notify me immediately if your understanding differs from that set forth above;

- 2) Notify me if for any reason you cannot complete the actions and commitments within the specified schedule and advise me in writing of your modified schedule in advance of the change; and
- 3) Notify me in writing when you have completed the actions and commitments addressed in this Confirmatory Action Letter.

Issuance of this Confirmatory Action Letter does not preclude issuance of an order formalizing the above commitments or requiring other actions on the part of the licensee; nor does it preclude the NRC from taking enforcement action for violations of NRC requirements that may have prompted the issuance of this letter. In addition, failure to take the actions addressed in this Confirmatory Action Letter may result in enforcement action.

In accordance with 10 CFR 2.390 of the NRC's "Rules of Practice," a copy of this letter and your response will be made available electronically for public inspection in the NRC Public Document Room or from the NRC's ADAMS, accessible from the NRC Web site at <http://www.nrc.gov/reading-rm/adams.html>. To the extent possible, your response should not include any personal privacy, proprietary, or safeguards information so that it can be made available to the Public without redaction. If personal privacy or proprietary information is necessary to provide an acceptable response, then please provide a bracketed copy of your response that identifies the information that should be protected and a redacted copy of your response that deletes such information. If you request withholding of such material, you must specifically identify the portions of your response that you seek to have withheld and provide in detail the bases for your claim of withholding (e.g., explain why the disclosure of information will create an unwarranted invasion of personal privacy or provide the information required by 10 CFR 2.390(b) to support a request for withholding confidential commercial or financial information). If safeguards information is necessary to provide an acceptable response, please provide the level of protection described in 10 CFR 73.21.

Sincerely,

**/RA/**

J.E. Dyer, Director  
Office of Nuclear Reactor Regulation

Docket No. 50-443  
License No. NPF-86

cc: See next page

- 2) Notify me if for any reason you cannot complete the actions and commitments within the specified schedule and advise me in writing of your modified schedule in advance of the change; and
- 3) Notify me in writing when you have completed the actions and commitments addressed in this Confirmatory Action Letter.

Issuance of this Confirmatory Action Letter does not preclude issuance of an order formalizing the above commitments or requiring other actions on the part of the licensee; nor does it preclude the NRC from taking enforcement action for violations of NRC requirements that may have prompted the issuance of this letter. In addition, failure to take the actions addressed in this Confirmatory Action Letter may result in enforcement action.

In accordance with 10 CFR 2.390 of the NRC's "Rules of Practice," a copy of this letter and your response will be made available electronically for public inspection in the NRC Public Document Room or from the NRC's ADAMS, accessible from the NRC Web site at <http://www.nrc.gov/reading-rm/adams.html>. To the extent possible, your response should not include any personal privacy, proprietary, or safeguards information so that it can be made available to the Public without redaction. If personal privacy or proprietary information is necessary to provide an acceptable response, then please provide a bracketed copy of your response that identifies the information that should be protected and a redacted copy of your response that deletes such information. If you request withholding of such material, you must specifically identify the portions of your response that you seek to have withheld and provide in detail the bases for your claim of withholding (e.g., explain why the disclosure of information will create an unwarranted invasion of personal privacy or provide the information required by 10 CFR 2.390(b) to support a request for withholding confidential commercial or financial information). If safeguards information is necessary to provide an acceptable response, please provide the level of protection described in 10 CFR 73.21.

Sincerely,

**/RA/**

J.E. Dyer, Director  
Office of Nuclear Reactor Regulation

Docket No. 50-443  
License No. NPF-86

cc: See next page

Distribution:

PUBLIC LPL1-2 R/F  
RidsNrrDorLpl1-2 (HChernoff)  
RidsRgn1MailCenter (PKrohn)  
RidsNrrDciOd  
RidsEdoMailCenter  
MMclaughlin  
RPascarelli  
CCarpenter

RidsNrrPM GMiller  
RidsOgcRp (BJones)  
RidsNrrOd (JDyer)  
RidsNrrDirOd  
JLamb, EDO Region 1  
TLupold, NRR  
RidsNrrAdesOd

RidsNrrLA MO'Brien  
RidsAcrsAcnwMailCenter  
RidsNrrDorIOd (CHaney)  
RidsOEMailCenter  
DScrenci, OPA, Region 1  
ESullivan, NRR  
RidsNrrDciCpnb

**ADAMS Accession No. ML070610585**

\* coordinated with Region I per OE Manual-per MGE

OFFICE	CPNB	LPL1-2/PM	LPL1-2/LA	LPL1-2/BC	TECH ED	DIRS/TA	CPNB/BC
NAME	EJS/TLupold	GEMiller	MO'Brien	HChernoff	HChang	RPascarelli	TChan
DATE	3/5/07	3/7/07	3/7/07	3/7/07	2/28/07	3/5/07	3/5/07
OFFICE	DRP/D RGN 1	D/OE	OGC	DORL/D	DCI/D	AD:ESS	NRR/D
NAME	DLew *	CCarpenter	BJones	CHaney	MEvans	JGrobe	JDyer
DATE	3/7/07	3/5/07	3/5/07	3/7/07	3/5/07	3/7/07	3/7/07

OFFICIAL RECORD COPY

Seabrook Station, Unit No. 1

cc:

Mr. J. A. Stall  
Senior Vice President, Nuclear and  
Chief Nuclear Officer  
Florida Power & Light Company  
P.O. Box 14000  
Juno Beach, FL 33408-0420

Mr. Peter Brann  
Assistant Attorney General  
State House, Station #6  
Augusta, ME 04333

Resident Inspector  
U.S. Nuclear Regulatory Commission  
Seabrook Nuclear Power Station  
P.O. Box 1149  
Seabrook, NH 03874

Town of Exeter  
10 Front Street  
Exeter, NH 03823

Regional Administrator, Region I  
U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406

Office of the Attorney General  
One Ashburton Place, 20th Floor  
Boston, MA 02108

Board of Selectmen  
Town of Amesbury  
Town Hall  
Amesbury, MA 01913

Mr. Robert Poole  
Federal Emergency Management Agency  
Region I  
99 High Street, 6<sup>th</sup> Floor  
Boston, MA 02110

Mr. Tom Crimmins  
Polestar Applied Technology  
One First Street, Suite 4  
Los Altos, CA 94019

Ms. Cristine McComb, Director  
ATTN: John Giarrusso  
Massachusetts Emergency Management Agency  
400 Worcester Road  
Framingham, MA 01702-5399

Ms. Kelly Ayotte, Attorney General  
Mr. Orvil Fitch, Deputy Attorney General  
33 Capitol Street  
Concord, NH 03301

Mr. Christopher M. Pope, Director  
Homeland Security & Emergency Mgmt.  
New Hampshire Department of Safety  
Bureau of Emergency Management  
33 Hazen Drive  
Concord, NH 03301

Mr. M. S. Ross, Managing Attorney  
Florida Power & Light Company  
P.O. Box 14000  
Juno Beach, FL 33408-0420

Mr. Rajiv S. Kundalkar  
Vice President - Nuclear Engineering  
Florida Power & Light Company  
P.O. Box 14000  
Juno Beach, FL 33408-0420

James M. Peschel  
Regulatory Programs Manager  
FPL Energy Seabrook, LLC  
PO Box 300  
Seabrook, NH 03874

Ms. Marjan Mashhadi  
Senior Attorney  
Florida Power & Light Company  
801 Pennsylvania Ave., NW Suite 220  
Washington, DC 20004

Mr. Mark E. Warner  
Vice President, Nuclear Operations Support  
Florida Power & Light Company  
P.O. Box 14000  
Juno Beach, FL 33408-0420