




# **Generic Environmental Impact Statement for License Renewal of Nuclear Plants**



**Supplement 31**



**Regarding  
James A. FitzPatrick Nuclear Power Plant**



**Draft Report for Comment**



**U.S. Nuclear Regulatory Commission  
Office of Nuclear Reactor Regulation  
Washington, DC 20555-0001**



## AVAILABILITY OF REFERENCE MATERIALS IN NRC PUBLICATIONS

### NRC Reference Material

As of November 1999, you may electronically access NUREG-series publications and other NRC records at NRC's Public Electronic Reading Room at <http://www.nrc.gov/reading-rm.html>.

Publicly released records include, to name a few, NUREG-series publications; *Federal Register* notices; applicant, licensee, and vendor documents and correspondence; NRC correspondence and internal memoranda; bulletins and information notices; inspection and investigative reports; licensee event reports; and Commission papers and their attachments.

NRC publications in the NUREG series, NRC regulations, and *Title 10, Energy*, in the Code of *Federal Regulations* may also be purchased from one of these two sources.

1. The Superintendent of Documents  
U.S. Government Printing Office  
Mail Stop SSOP  
Washington, DC 20402-0001  
Internet: [bookstore.gpo.gov](http://bookstore.gpo.gov)  
Telephone: 202-512-1800  
Fax: 202-512-2250
2. The National Technical Information Service  
Springfield, VA 22161-0002  
[www.ntis.gov](http://www.ntis.gov)  
1-800-553-6847 or, locally, 703-605-6000

A single copy of each NRC draft report for comment is available free, to the extent of supply, upon written request as follows:

Address: Office of Administration,  
Printing and Mail Services Branch  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555-0001  
E-mail: [DISTRIBUTION@nrc.gov](mailto:DISTRIBUTION@nrc.gov)  
Facsimile: 301-415-2289

Some publications in the NUREG series that are posted at NRC's Web site address <http://www.nrc.gov/reading-rm/doc-collections/nuregs> are updated periodically and may differ from the last printed version. Although references to material found on a Web site bear the date the material was accessed, the material available on the date cited may subsequently be removed from the site.

### Non-NRC Reference Material

Documents available from public and special technical libraries include all open literature items, such as books, journal articles, and transactions, *Federal Register* notices, Federal and State legislation, and congressional reports. Such documents as theses, dissertations, foreign reports and translations, and non-NRC conference proceedings may be purchased from their sponsoring organization.

Copies of industry codes and standards used in a substantive manner in the NRC regulatory process are maintained at—

The NRC Technical Library  
Two White Flint North  
11545 Rockville Pike  
Rockville, MD 20852-2738

These standards are available in the library for reference use by the public. Codes and standards are usually copyrighted and may be purchased from the originating organization or, if they are American National Standards, from—

American National Standards Institute  
11 West 42<sup>nd</sup> Street  
New York, NY 10036-8002  
[www.ansi.org](http://www.ansi.org)  
212-642-4900

Legally binding regulatory requirements are stated only in laws; NRC regulations; licenses, including technical specifications; or orders, not in NUREG-series publications. The views expressed in contractor-prepared publications in this series are not necessarily those of the NRC.

The NUREG series comprises (1) technical and administrative reports and books prepared by the staff (NUREG-XXXX) or agency contractors (NUREG/CR-XXXX), (2) proceedings of conferences (NUREG/CP-XXXX), (3) reports resulting from international agreements (NUREG/IA-XXXX), (4) brochures (NUREG/BR-XXXX), and (5) compilations of legal decisions and orders of the Commission and Atomic and Safety Licensing Boards and of Directors' decisions under Section 2.206 of NRC's regulations (NUREG-0750).

# **Generic Environmental Impact Statement for License Renewal of Nuclear Plants**

## **Supplement 31**

### **Regarding James A. FitzPatrick Nuclear Power Plant**

#### **Draft Report for Comment**

---

---

Manuscript Completed: May 2007

Date Published: June 2007

**Division of License Renewal  
Office of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555-0001**



## COMMENTS ON DRAFT REPORT

Any interested party may submit comments on this report for consideration by the NRC staff. Comments may be accompanied by additional relevant information or supporting data. Please specify the report number NUREG-1437, Supplement 31, draft, in your comments, and send them by September 05, 2007 to the following address:

Chief, Rulemaking, Directives and Editing Branch  
U.S. Nuclear Regulatory Commission  
Mail Stop T6-D59  
Washington, DC 20555-0001

Electronic comments may be submitted to the NRC by the Internet at [FitzPatrickEIS@nrc.gov](mailto:FitzPatrickEIS@nrc.gov).

For any questions about the material in this report, please contact:

J. Muir  
OWFN 11-F1  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555-0001  
Phone: 301-415-0491  
E-mail: JMM7@nrc.gov

## ABSTRACT

1  
2 The U.S. Nuclear Regulatory Commission (NRC) considered the environmental impacts of  
3 renewing nuclear power plant operating licenses (OLs) for a 20-year period in its *Generic*  
4 *Environmental Impact Statement for License Renewal of Nuclear Plants* (GEIS), NUREG-1437,  
5 Volumes 1 and 2, and codified the results in Part 51 of Title 10 of the *Code of Federal*  
6 *Regulations* (10 CFR Part 51). In the GEIS (and its Addendum 1), the NRC staff identifies  
7 92 environmental issues and reaches generic conclusions related to environmental impacts for  
8 69 of these issues that apply to all plants or to plants with specific design or site characteristics.  
9 Additional plant-specific review is required for the remaining 23 issues. These plant-specific  
10 reviews are to be included in a supplement to the GEIS.

11 This draft supplemental environmental impact statement (draft SEIS) has been prepared in  
12 response to an application submitted to the NRC by Entergy Nuclear FitzPatrick, LLC, and  
13 Entergy Nuclear Operations, Inc. (Entergy) to renew the OL for James A. FitzPatrick Nuclear  
14 Power Plant (JAFNPP) for an additional 20 years under 10 CFR Part 54. This draft SEIS  
15 includes the NRC staff's analysis that considers and weighs the environmental impacts of the  
16 proposed action, the environmental impacts of alternatives to the proposed action, and  
17 mitigation measures available for reducing or avoiding adverse impacts. It also includes the  
18 NRC staff's preliminary recommendation regarding the proposed action.

19 Regarding the 69 issues for which the GEIS reached generic conclusions, neither Entergy nor  
20 the NRC staff has identified information that is both new and significant for any issue that  
21 applies to JAFNPP. In addition, the NRC staff determined that information provided during the  
22 scoping process did not call into question the conclusions in the GEIS. Therefore, the NRC staff  
23 concludes that the impacts of renewing the JAFNPP OL would not be greater than impacts  
24 identified for these issues in the GEIS. For each of these issues, the NRC staff's conclusion in  
25 the GEIS is that the impact is of SMALL<sup>(1)</sup> significance (except for collective offsite radiological  
26 impacts from the fuel cycle and high-level waste and spent fuel, which were not assigned a  
27 single significance level).

28 Regarding the remaining 23 issues, those that apply to JAFNPP are addressed in this draft  
29 SEIS. For each applicable issue, the NRC staff concludes that the significance of the potential  
30 environmental impacts of renewal of the OL would be SMALL. The NRC staff also concludes  
31 that additional mitigation measures are not likely to be sufficiently beneficial as to be warranted.  
32 The NRC staff determined that information provided during the scoping process did not identify  
33 any new issue with a significant environmental impact.

---

(1) Environmental effects are not detectable or are so minor that they will neither destabilize nor noticeably alter any important attribute of the resource.

Abstract

1 The NRC staff's preliminary recommendation is that the Commission determine that the adverse  
2 environmental impacts of license renewal for JAFNPP are not so great that preserving the  
3 option of license renewal for energy-planning decision makers would be unreasonable. This  
4 recommendation is based on (1) the analysis and findings in the GEIS; (2) the Environmental  
5 Report submitted by Entergy; (3) consultation with Federal, State, and local agencies; (4) the  
6 NRC staff's own independent review; and (5) the NRC staff's consideration of public comments  
7 received during the scoping process.

8

9

10

11

12

13

14

15

16

17

18

**Paperwork Reduction Act Statement**

19 This NUREG contains information collection requirements that are subject to the  
20 Paperwork Reduction Act of 1995 (44 U.S.C. 3501 et seq.). These information  
21 collections were approved by the Office of Management and Budget, approval numbers  
22 3150-0004; 3150-0155; 3150-0014; 3150-0011; 3150-0132; 3150-0151.

23

24

**Public Protection Notification**

25 The NRC may not conduct or sponsor, and a person is not required to respond to, a  
26 request for information or an information collection requirement unless the requesting  
27 document displays a currently valid OMB control number.

28

# Contents

Abstract.....	iii
Executive Summary .....	xiv
Abbreviations/Acronyms .....	xix
1.0 Introduction .....	1-1
1.1 Report Contents .....	1-2
1.2 Background .....	1-3
1.2.1 Generic Environmental Impact Statement.....	1-3
1.2.2 License Renewal Evaluation Process .....	1-4
1.3 The Proposed Federal Action.....	1-7
1.4 The Purpose and Need for the Proposed Action.....	1-7
1.5 Compliance and Consultations.....	1-8
1.6 References .....	1-8
2.0 Description of Nuclear Power Plant and Site and Interaction with the Environment.....	2-1
2.1 Facility and Site Description and Proposed Facility Operation During the Renewal Term .....	2-1
2.1.1 External Appearance and Setting.....	2-1
2.1.2 Reactor Systems .....	2-5
2.1.3 Cooling and Auxiliary Water Systems .....	2-5
2.1.4 Radioactive Waste Management Systems and Effluent Control Systems .....	2-7
2.1.4.1 Liquid Waste Processing Systems and Effluent Controls .....	2-8
2.1.4.2 Gaseous Waste Processing Systems and Effluent Controls .....	2-9
2.1.4.3 Solid Waste Processing .....	2-10
2.1.5 Nonradioactive Waste Systems.....	2-10
2.1.5.1 Nonradioactive Waste Streams .....	2-10
2.1.5.2 Pollution Prevention and Waste Minimization.....	2-13
2.1.6 Facility Operation and Maintenance .....	2-13
2.1.7 Power Transmission System .....	2-14
2.2 Facility Interaction with the Environment.....	2-17
2.2.1 Land Use .....	2-17
2.2.2 Water Use.....	2-17
2.2.3 Water Quality.....	2-18

## Contents

2.2.4	Climate, Meteorology, and Air Quality .....	2-22
2.2.4.1	Climate .....	2-22
2.2.4.2	Meteorology .....	2-22
2.2.4.3	Air Quality .....	2-23
2.2.5	Aquatic Resources .....	2-23
2.2.6	Terrestrial Resources .....	2-30
2.2.6.1	Terrestrial Resources at the JAFNPP Site.....	2-30
2.2.6.2	Terrestrial Resources in Transmission Corridors.....	2-33
2.2.6.3	Terrestrial Species of Concern .....	2-34
2.2.7	Radiological Impacts .....	2-38
2.2.8	Socioeconomic Factors .....	2-39
2.2.8.1	Housing.....	2-39
2.2.8.2	Public Services .....	2-40
2.2.8.3	Offsite Land Use .....	2-42
2.2.8.4	Visual Aesthetics and Noise .....	2-43
2.2.8.5	Demography .....	2-44
2.2.8.6	Economy .....	2-46
2.2.9	Historic and Archaeological Resources.....	2-48
2.2.9.1	Cultural Background .....	2-49
2.2.9.2	Historic and Archaeological Resources at JAFNPP .....	2-51
2.2.10	Related Federal Project Activities and Consultations.....	2-53
2.2.10.1	Coastal Zone Management Act .....	2-53
2.2.10.2	Clean Water Act Section 401 Water Quality Certification .....	2-54
2.3	References .....	2-55
3.0	Environmental Impacts of Refurbishment.....	3-1
3.1	References .....	3-4
4.0	Environmental Impacts of Operation .....	4-1
4.1	Cooling System .....	4-2
4.1.1	Entrainment of Fish and Shellfish in Early Life Stages.....	4-10
4.1.2	Impingement of Fish and Shellfish .....	4-15
4.1.3	Heat Shock.....	4-21
4.2	Transmission Lines .....	4-24
4.2.1	Electromagnetic Fields—Acute Effects .....	4-28
4.2.2	Electromagnetic Fields—Chronic Effects .....	4-29
4.3	Radiological Impacts of Normal Operations .....	4-30
4.4	Socioeconomic Impacts of Plant Operations During the License Renewal Term .....	4-32



4.4.1	Housing Impacts.....	4-34
4.4.2	Public Services: Public Utility Impacts.....	4-35
4.4.3	Offsite Land Use.....	4-36
	4.4.3.1 Population-Related Impacts.....	4-36
	4.4.3.2 Tax-Revenue-Related Impacts.....	4-37
4.4.4	Public Services: Transportation Impacts.....	4-37
4.4.5	Historic and Archaeological Resources.....	4-37
4.4.6	Environmental Justice.....	4-39
	4.4.6.1 Minority Population in 2000.....	4-40
	4.4.6.2 Low-Income Population in 2000.....	4-40
	4.4.6.3 Analysis of Impacts.....	4-42
4.5	Groundwater Use and Quality.....	4-44
4.6	Threatened or Endangered Species.....	4-44
	4.6.1 Aquatic Species.....	4-46
	4.6.2 Terrestrial Species.....	4-46
4.7	Evaluation of New and Potentially Significant Information on Impacts of Operations During the Renewal Term.....	4-47
4.8	Cumulative Impacts.....	4-47
	4.8.1 Cumulative Impacts on Aquatic Resources.....	4-47
	4.8.2 Cumulative Impacts on Terrestrial Resources.....	4-50
	4.8.3 Cumulative Impacts on Human Health.....	4-52
	4.8.3.1 Cumulative Impacts Resulting from Continued Operation of the Transmission Lines.....	4-52
	4.8.3.2 Cumulative Radiological Impacts.....	4-52
	4.8.4 Cumulative Socioeconomic Impacts.....	4-53
	4.8.5 Conclusions Regarding Cumulative Impacts.....	4-53
4.9	Summary of Impacts of Operations During the Renewal Term.....	4-53
4.10	References.....	4-54
5.0	Environmental Impacts of Postulated Accidents.....	5-1
	5.1 Postulated Plant Accidents.....	5-1
	5.1.1 Design-Basis Accidents.....	5-1
	5.1.2 Severe Accidents.....	5-3
	5.2 Severe Accident Mitigation Alternatives.....	5-5
	5.2.1 Introduction.....	5-5
	5.2.2 Estimate of Risk.....	5-6
	5.2.3 Potential Plant Improvements.....	5-8
	5.2.4 Evaluation of Risk Reduction and Costs of Improvements.....	5-8

## Contents

5.2.5	Cost-Benefit Comparison.....	5-9
5.2.6	Conclusions.....	5-10
5.3	References.....	5-10
6.0	Environmental Impacts of the Uranium Fuel Cycle and Solid Waste Management.....	6-1
6.1	The Uranium Fuel Cycle.....	6-2
6.2	References.....	6-9
7.0	Environmental Impacts of Decommissioning.....	7-1
7.1	Decommissioning.....	7-2
7.2	References.....	7-4
8.0	Environmental Impacts of Alternatives to License Renewal.....	8-1
8.1	No-Action Alternative.....	8-1
8.2	Alternative Energy Sources.....	8-6
8.2.1	Coal-Fired Generation.....	8-8
8.2.1.1	Once-Through Cooling System.....	8-9
8.2.1.2	Closed-Cycle Cooling System.....	8-18
8.2.2	Natural Gas-Fired Generation.....	8-19
8.2.2.1	Once-Through Cooling System.....	8-20
8.2.2.2	Closed-Cycle Cooling System.....	8-29
8.2.3	Nuclear Power Generation.....	8-29
8.2.3.1	Once-Through Cooling System.....	8-31
8.2.3.2	Closed-Cycle Cooling System.....	8-38
8.2.4	Purchased Electrical Power.....	8-38
8.2.5	Other Alternatives.....	8-39
8.2.5.1	Oil-Fired Generation.....	8-39
8.2.5.2	Wind Power.....	8-39
8.2.5.3	Solar Power.....	8-40
8.2.5.4	Hydropower.....	8-41
8.2.5.5	Geothermal Energy.....	8-42
8.2.5.6	Wood Waste.....	8-42
8.2.5.7	Municipal Solid Waste.....	8-42
8.2.5.8	Other Biomass-Derived Fuels.....	8-44
8.2.5.9	Fuel Cells.....	8-44
8.2.5.10	Delayed Retirement.....	8-44
8.2.5.11	Utility-Sponsored Conservation.....	8-45
8.2.6	Combination of Alternatives.....	8-46
8.3	Summary of Alternatives Considered.....	8-46

8.4	References .....	8-51
9.0	Summary and Conclusions .....	9-1
9.1	Environmental Impacts of the Proposed Action-License Renewal .....	9-4
9.1.1	Unavoidable Adverse Impacts .....	9-5
9.1.2	Irreversible or Irrecoverable Resource Commitments .....	9-5
9.1.3	Short-Term Use Versus Long-Term Productivity .....	9-6
9.2	Relative Significance of the Environmental Impacts of License Renewal and Alternatives .....	9-6
9.3	NRC Staff Conclusions and Recommendations .....	9-8
9.4	References .....	9-8
Appendix A	Comments Received on the Environmental Review .....	A-1
Appendix B	Contributors to the Supplement .....	B-1
Appendix C	Chronology of NRC Staff Environmental Review Correspondence Related to Entergy Nuclear FitzPatrick, LLC, and Entergy Nuclear Operations, Inc., Application for License Renewal of James A. FitzPatrick Nuclear Power Plant .....	C-1
Appendix D	Organizations Contacted .....	D-1
Appendix E	Entergy Nuclear FitzPatrick, LLC, and Entergy Nuclear Operations, Inc., Compliance Status and Consultation Correspondence .....	E-1
Appendix F	GEIS Environmental Issues Not Applicable to James A. FitzPatrick Nuclear Power Plant .....	F-1
Appendix G	NRC Staff Evaluation of Severe Accident Mitigation Alternatives for James A. FitzPatrick Nuclear Power Plant .....	G-1

## Figures

Figure 2-1. Location of JAFNPP, 50-mi Region .....	2-2
Figure 2-2. Location of JAFNPP, 6-mi Region .....	2-3
Figure 2-3. JAFNPP Approximate Site Boundary .....	2-4
Figure 2-4. JAFNPP Transmission Lines.....	2-15
Figure 4-1. Minority Block Groups in 2000 within a 50-mi Radius of JAFNPP .....	4-41
Figure 4-2. Low-Income Block Groups within a 50-mi Radius of JAFNPP .....	4-43

## Tables

Table 2-1.	JAFNPP Transmission Lines, Substations, and Corridors .....	2-15
Table 2-2.	Selected Water Quality Parameters of Lake Ontario .....	2-20
Table 2-3.	Aquatic Species Listed as Endangered, Threatened, or a Species of Special Concern by New York State, Potentially Occurring in Oswego and Onondaga Counties .....	2-29
Table 2-4.	Federally Listed and New York State-Listed Terrestrial Species Potentially Occurring in the Vicinity of JAFNPP and in Associated Transmission Line Corridors .....	2-34
Table 2-5.	JAFNPP Permanent Employee Residence by County in 2006 .....	2-39
Table 2-6.	Number of Occupied, Vacant, and Total Housing Units in Oswego and Onondaga Counties, New York, in 2000 and 2005 .....	2-40
Table 2-7.	Major Public Water Supply Systems in Oswego County, Average Daily Use, and Maximum Daily Capacity .....	2-41
Table 2-8.	Land Use in Oswego and Onondaga Counties .....	2-43
Table 2-9.	Population Growth in Oswego and Onondaga Counties, New York, from 1970 to 2000 and Projected for 2010 and 2020 .....	2-45
Table 2-10.	Major Employers in Oswego County in 2006 .....	2-47
Table 2-11.	Oswego County, Town of Scriba, and Mexico Central Schools Tax Revenues, 2002 to 2005; JAFNPP Property Tax, 2002 to 2005; and JAFNPP Property Tax as a Percentage of Tax Revenues.....	2-48
Table 3-1.	Category 1 Issues for Refurbishment Evaluation .....	3-2
Table 3-2.	Category 2 Issues for Refurbishment Evaluation .....	3-3
Table 4-1.	Category 1 Issues Applicable to the Operation of the JAFNPP Cooling System During the Renewal Term .....	4-3
Table 4-2.	Category 2 Issues Applicable to the Operation of the JAFNPP Cooling System During the Renewal Term .....	4-10
Table 4-3.	Results of Impingement Monitoring at JAFNPP from 1976 through 1997 (Corrected for Flow and Traveling Screen Efficiencies) .....	4-17
Table 4-4.	Results of Impingement Monitoring at JAFNPP, 2004 (Corrected for Flow and Traveling Screen Efficiencies) .....	4-19
Table 4-5.	Category 1 Issues Applicable to the JAFNPP Transmission Lines During the Renewal Term .....	4-25

Contents

Table 4-6.	Category 2 and Uncategorized Issues Applicable to the JAFNPP Transmission Lines During the Renewal Term .....	4-28
Table 4-7.	Category 1 Issues Applicable to Radiological Impacts of Normal Operations During the Renewal Term .....	4-31
Table 4-8.	Category 1 Issues Applicable to Socioeconomics During the Renewal Term .....	4-32
Table 4-9.	Category 2 Issues Applicable to Socioeconomics and Environmental Justice During the Renewal Term .....	4-34
Table 4-10.	Category 2 Issue Applicable to Threatened or Endangered Species During the Renewal Term .....	4-45
Table 5-1.	Category 1 Issues Applicable to Postulated Accidents During the Renewal Term .....	5-3
Table 5-2.	Category 2 Issues Applicable to Postulated Accidents During the Renewal Term .....	5-5
Table 5-3.	JAFNPP Core Damage Frequency .....	5-7
Table 5-4.	Breakdown of Population Dose by Containment Release Mode.....	5-8
Table 6-1.	Category 1 Issues Applicable to the Uranium Fuel Cycle and Solid Waste Management During the Renewal Term .....	6-2
Table 7-1.	Category 1 Issues Applicable to the Decommissioning of JAFNPP Following the Renewal Term.....	7-2
Table 8-1.	Summary of Environmental Impacts of the No-Action Alternative.....	8-3
Table 8-2.	Summary of Environmental Impacts of Coal-Fired Generation at an Alternate Site Using Once-Through Cooling .....	8-10
Table 8-3.	Summary of Environmental Impacts of Coal-Fired Generation at an Alternate Site with Closed-Cycle Cooling .....	8-19
Table 8-4.	Summary of Environmental Impacts of Natural Gas-Fired Generation at the JAFNPP Site and an Alternate Site Using Once-Through Cooling .....	8-21
Table 8-5.	Summary of Environmental Impacts of Natural Gas-Fired Generation at Either the JAFNPP Site or an Alternate Site with Closed-Cycle Cooling .....	8-30
Table 8-6.	Summary of Environmental Impacts of New Nuclear Power Generation at the JAFNPP Site and an Alternate Site Using Once-Through Cooling.....	8-32
Table 8-7.	Summary of Environmental Impacts of a New Nuclear Power Plant Sited at an Alternate Site with Closed-Cycle Cooling .....	8-38
Table 8-8.	Summary of Environmental Impacts of an Assumed Combination of Generation—Does Not Include Impacts from Purchased Generation Once-Through Cooling Alternative .....	8-47

Table 9-1. Summary of Environmental Significance of License Renewal, the No-Action Alternative, and Alternative Methods of Power Generation.....9-7

Table A-1. Individuals Providing Comments During Scoping Comment Period ..... A-3

Table E-1. Consultation Correspondence ..... E-1

Table E-2. Federal, State, Local, and Regional Licenses, Permits, and Other Approvals for the James A. FitzPatrick Nuclear Power Plant (JAFNPP) ..... E-2

Table F-1. GEIS Environmental Issues Not Applicable to James A. FitzPatrick Nuclear Power Plant.....F-1

Table G-1. JAFNPP Core Damage Frequency for Internal Events ..... G-3

Table G-2. Breakdown of Population Dose by Containment Release Mode..... G-4

Table G-3. JAFNPP PSA Historical Summary ..... G-6

Table G-4. Fire Areas and Their Contribution to the Fire CDF..... G-10

Table G-5. SAMA Cost/Benefit Screening Analysis for JAFNPP ..... G-21

## EXECUTIVE SUMMARY

By letter dated July 31, 2006, Entergy Nuclear FitzPatrick, LLC, and Entergy Nuclear Operations, Inc. (Entergy) submitted an application to the U.S. Nuclear Regulatory Commission (NRC) to renew the operating license (OL) for the James A. FitzPatrick Nuclear Power Plant (JAFNPP) for an additional 20-year period. If the OL is renewed, State regulatory agencies and Entergy will ultimately decide whether the plant will continue to operate based on factors such as the need for power or other matters within the State's jurisdiction or the purview of the owners. If the OL is not renewed, then the plant must be shut down on or before the expiration date of the current OL, which is October 17, 2014.

The NRC has implemented Section 102 of the National Environmental Policy Act (NEPA), Title 42, Section 4321, of the *United States Code* (42 USC 4321) in Part 51 of Title 10 of the *Code of Federal Regulations* (10 CFR Part 51). In 10 CFR 51.20(b)(2), the Commission requires preparation of an Environmental Impact Statement (EIS) or a supplement to an EIS for renewal of a reactor OL. In addition, 10 CFR 51.95(c) states that the EIS prepared at the OL renewal stage will be a supplement to the *Generic Environmental Impact Statement for License Renewal of Nuclear Plants* (GEIS), NUREG-1437, Volumes 1 and 2.<sup>(a)</sup>

Upon acceptance of the Entergy application, the NRC began the environmental review process described in 10 CFR Part 51 by publishing a Notice of Intent to prepare an EIS and conduct scoping. The NRC staff held public scoping meetings on October 12, 2006, in Oswego, New York, and conducted a site audit at JAFNPP on December 5 and 6, 2006. In the preparation of this draft supplemental environmental impact statement (SEIS) for JAFNPP, the NRC staff reviewed the Entergy Environmental Report (ER) and compared it to the GEIS, consulted with other agencies, conducted an independent review of the issues following the guidance set forth in NUREG-1555, Supplement 1, *Standard Review Plans for Environmental Reviews for Nuclear Power Plants, Supplement 1: Operating License Renewal*, and considered the public comments received during the scoping process. The public comments received during the scoping process that were considered to be within the scope of the environmental review are provided in Appendix A of this draft SEIS.

The NRC staff will hold two public meetings in Oswego, New York, in August 2007, to describe the preliminary results of the NRC environmental review, to answer questions, and to provide members of the public with information to assist them in formulating comments on this draft

---

(a) The GEIS was originally issued in 1996. Addendum 1 to the GEIS was issued in 1999. Hereafter, all references to the "GEIS" include the GEIS and its Addendum 1.



## Executive Summary

1 SEIS. When the comment period ends, the NRC staff will consider and address all of the  
2 comments received. These comments will be addressed in Appendix A of the final SEIS.

3 This draft SEIS includes the NRC staff's preliminary analysis that considers and weighs the  
4 environmental effects of the proposed action, the environmental impacts of alternatives to the  
5 proposed action, and mitigation measures for reducing or avoiding adverse effects. It also  
6 includes the NRC staff's preliminary recommendation regarding the proposed action.

7 The Commission has adopted the following statement of purpose and need for license renewal  
8 from the GEIS:

9       The purpose and need for the proposed action (renewal of an operating license)  
10       is to provide an option that allows for power generation capability beyond the  
11       term of a current nuclear power plant operating license to meet future system  
12       generating needs, as such needs may be determined by State, utility, and, where  
13       authorized, Federal (other than NRC) decision makers.

14 The evaluation criterion for the NRC staff's environmental review, as defined in 10 CFR  
15 51.95(c)(4) and the GEIS, is to determine

16       ... whether or not the adverse environmental impacts of license renewal are so  
17       great that preserving the option of license renewal for energy planning decision  
18       makers would be unreasonable.

19 Both the statement of purpose and need and the evaluation criterion implicitly acknowledge that  
20 there are factors, in addition to license renewal, that will ultimately determine whether an  
21 existing nuclear power plant continues to operate beyond the period of the current OL.

22 NRC regulations (10 CFR 51.95[c][2]) contain the following statement regarding the content of  
23 SEISs prepared at the license renewal stage:

24       The supplemental environmental impact statement for license renewal is not  
25       required to include discussion of need for power or the economic costs and  
26       economic benefits of the proposed action or of alternatives to the proposed  
27       action except insofar as such benefits and costs are either essential for a  
28       determination regarding the inclusion of an alternative in the range of alternatives  
29       considered or relevant to mitigation. In addition, the supplemental environmental  
30       impact statement prepared at the license renewal stage need not discuss other  
31       issues not related to the environmental effects of the proposed action and the  
32       alternatives, or any aspect of the storage of spent fuel for the facility within the  
33       scope of the generic determination in § 51.23(a) ["Temporary storage of spent  
34       fuel after cessation of reactor operation—generic determination of no significant  
35       environmental impact"] and in accordance with § 51.23(b).

1 The GEIS contains the results of a systematic evaluation of the consequences of renewing an OL  
2 and operating a nuclear power plant for an additional 20 years. It evaluates 92 environmental  
3 issues using the NRC's three-level standard of significance—SMALL, MODERATE, or LARGE—  
4 developed using the Council on Environmental Quality guidelines. The following definitions of the  
5 three significance levels are set forth in footnotes to Table B-1 of 10 CFR Part 51, Subpart A,  
6 Appendix B:

7           SMALL—Environmental effects are not detectable or are so minor that they will  
8           neither destabilize nor noticeably alter any important attribute of the resource.

9           MODERATE—Environmental effects are sufficient to alter noticeably, but not to  
10          destabilize, important attributes of the resource.

11          LARGE—Environmental effects are clearly noticeable and are sufficient to  
12          destabilize important attributes of the resource.

13 For 69 of the 92 issues considered in the GEIS, the analysis in the GEIS reached the following  
14 conclusions:

15 (1) The environmental impacts associated with the issue have been determined to apply either  
16 to all plants or, for some issues, to plants having a specific type of cooling system or other  
17 specified plant or site characteristics.

18 (2) A single significance level (i.e., SMALL, MODERATE, or LARGE) has been assigned to the  
19 impacts (except for collective offsite radiological impacts from the fuel cycle and from high-  
20 level waste and spent fuel disposal).

21 (3) Mitigation of adverse impacts associated with the issue has been considered in the analysis,  
22 and it has been determined that additional plant-specific mitigation measures are not likely  
23 to be sufficiently beneficial to warrant implementation.

24 These 69 issues were identified in the GEIS as Category 1 issues. In the absence of new and  
25 significant information, the NRC staff relied on conclusions in the GEIS for issues designated as  
26 Category 1 in Table B-1 of 10 CFR Part 51, Subpart A, Appendix B.

27 Of the 23 issues that do not meet the criteria set forth above, 21 are classified as Category 2  
28 issues requiring analysis in a plant-specific supplement to the GEIS. The remaining two issues,  
29 environmental justice and chronic effects of electromagnetic fields, were not categorized.  
30 Environmental justice was not evaluated on a generic basis and must be addressed in a plant-  
31 specific supplement to the GEIS. Information on the chronic effects of electromagnetic fields  
32 was not conclusive at the time the GEIS was prepared.

33 This draft SEIS documents the NRC staff's consideration of all 92 environmental issues  
34 identified in the GEIS. The NRC staff considered the environmental impacts associated with

## Executive Summary

1 alternatives to license renewal and compared the environmental impacts of license renewal and  
2 the alternatives. The alternatives to license renewal that were considered include the no-action  
3 alternative (not renewing the OL for JAFNPP) and alternative methods of power generation.  
4 Based on projections made by the U.S. Department of Energy's Energy Information  
5 Administration (DOE/EIA), gas- and coal-fired generation appear to be the most likely power-  
6 generation alternatives if the power from JAFNPP is replaced. These alternatives are evaluated  
7 assuming that the replacement power generation plant is located at either the JAFNPP site or  
8 some other unspecified alternate location.

9 Entergy and the NRC staff have established independent processes for identifying and  
10 evaluating the significance of any new information on the environmental impacts of license  
11 renewal. Neither Entergy nor the NRC staff has identified information that is both new and  
12 significant related to Category 1 issues that would call into question the conclusions in the  
13 GEIS. Similarly, neither the scoping process nor the NRC staff has identified any new issue  
14 applicable to JAFNPP that has a significant environmental impact. Therefore, the NRC staff  
15 relies upon the conclusions of the GEIS for all of the Category 1 issues that are applicable to  
16 JAFNPP.

17 Entergy's license renewal application presents an analysis of the Category 2 issues plus  
18 environmental justice and chronic effects from electromagnetic fields. The NRC staff has  
19 reviewed the Entergy analysis for each issue and has conducted an independent review of each  
20 issue. Six Category 2 issues are not applicable because they are related to plant design  
21 features or site characteristics not found at JAFNPP. Four Category 2 issues are not discussed  
22 in this draft SEIS because they are specifically related to refurbishment. Entergy has stated that  
23 its evaluation of structures and components, as required by 10 CFR 54.21, did not identify any  
24 major plant refurbishment activities or modifications as necessary to support the continued  
25 operation of JAFNPP for the license renewal period. In addition, any replacement of  
26 components or additional inspection activities are within the bounds of normal plant operation  
27 and are not expected to affect the environment outside of the bounds of the plant operations  
28 evaluated in the U.S. Atomic Energy Commission's 1973 *Final Environmental Statement*  
29 *Related to Operation of James A. FitzPatrick Nuclear Power Plant*.

30 Eleven Category 2 issues related to operational impacts and postulated accidents during the  
31 renewal term, as well as environmental justice and chronic effects of electromagnetic fields, are  
32 discussed in detail in this draft SEIS. Four of the Category 2 issues and environmental justice  
33 apply to both refurbishment and to operation during the renewal term and are only discussed in  
34 this draft SEIS in relation to operation during the renewal term. For all 11 Category 2 issues  
35 and environmental justice, the NRC staff concludes that the potential environmental effects are  
36 of SMALL significance in the context of the standards set forth in the GEIS. In addition, the  
37 NRC staff determined that appropriate Federal health agencies have not reached a consensus  
38 on the existence of chronic adverse effects from electromagnetic fields. Therefore, no further  
39 evaluation of this issue is required. For severe accident mitigation alternatives (SAMAs), the  
40 NRC staff concludes that a reasonable, comprehensive effort was made to identify and evaluate

- 1 SAMAs. Based on its review of the SAMAs for JAFNPP and the plant improvements already  
2 made, the NRC staff concludes that none of the candidate SAMAs is cost-beneficial.
- 3 Mitigation measures were considered for each Category 2 issue. Current measures to mitigate  
4 the environmental impacts of plant operation were found to be adequate, and no additional  
5 mitigation measures were deemed sufficiently beneficial to be warranted.
- 6 Cumulative impacts of past, present, and reasonably foreseeable future actions were  
7 considered, regardless of what agency (Federal or non-Federal) or person undertakes such  
8 other actions. For purposes of this analysis, where the JAFNPP license renewal impacts are  
9 deemed to be SMALL, the NRC staff concluded that these impacts would not result in significant  
10 cumulative impacts on potentially affected resources.
- 11 If the JAFNPP OL is not renewed and the plant ceases operation on or before the expiration of  
12 its current OL, then the adverse impacts of likely alternatives would not necessarily be smaller  
13 than those associated with continued operation of JAFNPP. The impacts may be greater in  
14 some areas, depending on the alternatives selected.
- 15 The preliminary recommendation of the NRC staff is that the Commission determine that the  
16 adverse environmental impacts of license renewal for JAFNPP are not so great that preserving  
17 the option of license renewal for energy planning decision makers would be unreasonable. This  
18 recommendation is based on (1) the analysis and findings in the GEIS; (2) the ER submitted by  
19 Entergy; (3) consultation with other Federal, State, and local agencies; (4) the NRC staff's own  
20 independent review; and (5) the NRC staff's consideration of public comments received during  
21 the scoping process.

1

## ABBREVIATIONS/ACRONYMS

2	$\Delta T$	temperature difference
3	°	degree
4	ac	acre(s)
5	AC	alternating current
6	ACC	averted cleanup and decontamination costs
7	AEC	Atomic Energy Commission
8	ALARA	as low as reasonably achievable
9	AOC	averted offsite property damage costs
10	AOE	averted occupational exposure costs
11	AOSC	averted onsite costs
12	ATWS	Anticipated transient without scram
13		
14	BACT	Best available control technology
15	BTU	British thermal unit(s)
16	BWR	boiling-water reactor
17	BWROG	boiling-water reactor owner group
18		
19	C	Celsius
20	CDF	core damage frequency
21	CEQ	Council on Environmental Quality
22	CET	containment event tree
23	CFR	<i>Code of Federal Regulations</i>
24	Ci	curie(s)
25	CMP	coastal management program
26	COE	cost of enhancement
27	CRD	control rod drive
28	CST	condensate storage tank
29	CWA	Clean Water Act
30	CWD	chronic wasting disease
31	CZMA	Coastal Zone Management Act
32		
33	DC	direct current
34	DCH	direct containment heating
35	DBA	design-basis accident
36	DSM	demand-side management
37	DOC	U.S. Department of Commerce

1	DOE	U.S. Department of Energy
2		
3	ECCS	emergency core cooling system
4	EDG	emergency diesel generator
5	EIA	Energy Information Administration
6	EIS	environmental impact statement
7	Entergy	Entergy Nuclear FitzPatrick, LLC, and Entergy Nuclear Operations, Inc.
8	EPA	U.S. Environmental Protection Agency
9	EPRI	Electric Power Research Institute
10	EPZ	emergency planning zone
11	ER	environmental report
12	ESA	Endangered Species Act
13	ESW	emergency service water
14	ETE	evacuation time study
15		
16	F	Fahrenheit
17	FDS	fish deterrence system
18	FES	Final Environmental Statement
19	FSAR	Final Safety Analysis Report
20	ft	foot (feet)
21	ft <sup>3</sup>	cubic foot (feet)
22	ft/m	foot (feet) per minute
23	ft/s	feet (feet) per second
24	FWS	U.S. Fish and Wildlife Service
25		
26	gal	gallon(s)
27	GE	General Electric
28	GEIS	generic environmental impact statement
29	GLFC	Great Lakes Fishery Commission
30	GLWQA	Great Lakes Water Quality Agreement
31	gpd	gallon(s) per day
32	gpm	gallons per minute
33		
34	ha	hectare(s)
35	HCLPF	high confidence low probability of failure
36	HLW	high-level waste
37	HPCI	high pressure coolant injection
38		
39	I&C	instrumentation and control

1	IJC	International Joint Commission
2	IGLD	International Great Lakes Datum
3	in.	inch(es)
4	IPE	individual plant examination
5	IPEEE	individual plant examination of external events
6	ISFSI	independent spent fuel storage installation
7	ISLOCA	interfacing system loss of coolant accident
8	ISLRBC	International St. Lawrence River Board of Control
9		
10	J	Joule
11	JAFNPP	James A. FitzPatrick Nuclear Power Plant
12		
13	km	kilometer(s)
14	Kr	krypton
15	kt(s)	knot(s)
16	kV	kilovolt
17	kWh	kilowatt-hour
18		
19	L	liter
20	LAER	Lowest achievable emissions rate
21	lb	pound(s)
22	LERF	large early release frequency
23	LLMW	low-level mixed waste
24	LOCA	loss of coolant accident
25	LOSP	loss of offsite power
26	LPCI	low pressure coolant injection
27		
28	m	meter(s)
29	mA	milli-ampere(s)
30	MAAP	Modular Accident Analysis Program
31	MACCS2	MELCOR Accident Consequence Code System 2
32	m/s	meter(s) per second
33	m <sup>3</sup>	cubic meter(s)
34	mg/L	milligram(s) per liter
35	mi	mile(s)
36	min	minute(s)
37	ml	milliliter
38	mph	mile(s) per hour
39	mrem	millirem

1	m/s	meter per second
2	MSA	metropolitan statistical area
3	MSIV	main steam isolation valve
4	mSv	milliSievert
5	MT	metric ton(s)
6	MTHM	metric ton of heavy metal
7	MWB	Metropolitan Water Board
8	MWd/MTU	megawatt days per metric ton of uranium
9	MWe	megawatts-electric
10	MWh	megawatt hour
11	MWt	megawatts-thermal
12		
13	NAS	National Academy of Sciences
14	NEPA	National Environmental Policy Act of 1969
15	NESC	National Electrical Safety Code
16	ng/J	nanogram(s) per Joule
17	NHPA	National Historic Preservation Act of 1966
18	NIEHS	National Institute of Environmental Health Sciences
19	NMPNS	Nine Mile Point Nuclear Station
20	NO <sub>x</sub>	nitrogen oxides
21	NOAA	National Oceanic and Atmospheric Administration
22	NPDES	National Pollutant Discharge Elimination System
23	NRC	U.S. Nuclear Regulatory Commission
24	NYCRR	<i>New York State Codes Rules and Regulations</i>
25	NYISO	New York Independent System Operator
26	NYNHP	New York Natural Heritage Program
27	NYPA	New York Power Authority
28	NYPSC	New York Public Service Commission
29	NYSDEC	New York State Department of Environmental Conservation
30	NYSDOS	New York State Department of State
31	NYSERDA	New York State Energy Research and Development Authority
32	NYSHPO	New York State Office of Parks, Recreation, and Historic Preservation
33		
34	OCWA	Onondaga County Water Authority
35	ODCM	<i>Offsite Dose Calculation Manual</i>
36	OL	operating license
37	OMNR	Ontario Ministry of Natural Resources
38	OWS	Oswego Water System
39		



1	PBT	persistent, bioaccumulative, and toxic
2	PCB	polychlorinated biphenyls
3	PCS	power conversion system
4	PDS	plant damage status
5	PGA	peak ground acceleration
6	PM <sub>10</sub>	particulate matter with an aerodynamic diameter less than or equal to 10 microns
7	ppm	parts per million
8	PSA	probabilistic safety assessment
9	PSD	prevention of significant deterioration
10		
11	radwaste	radioactive waste
12	RAI	request for additional information
13	rem	Roentgen Equivalent Man
14	RCIC	reactor core isolation cooling
15	RCRA	Resource Conservation and Recovery Act
16	REMP	Radiological Environmental Monitoring Program
17	RHR	residual heat removal
18	RHRSW	residual heat removal service water
19	ROW	right-of-way
20	RPC	replacement cost
21	RRW	risk reduction worth
22		
23	SAMA	severe accident mitigation alternative
24	SAR	Safety Analysis Report
25	SBO	station blackout
26	SCOL	Salmonid Communities in Oligotrophic Lakes
27	SCR	selective catalytic reduction
28	SEIS	supplemental environmental impact statement
29	SER	Safety Evaluation Report
30	SHPO	State Historic Preservation Office
31	SLCS	Standby Liquid Control System
32	SMA	seismic margin assessment
33	SO <sub>x</sub>	sulfur oxides
34	SPDES	State Pollutant Discharge Elimination System
35	SQUG	Seismic Qualification User Group
36	SRV	safety relief valves
37	SUNY	State University of New York
38	Sv	Sievert
39		

1	TMDL	total maximum daily load
2	TRC	total residual chlorine
3	TSCA	Toxic Substance Control Act
4	TSDF	Treatment, Storage, or Discharge Facility
5		
6	USACE	U.S. Army Corps of Engineers
7	USC	United States Code
8	USCB	U.S. Census Bureau
9	USGS	U.S. Geological Survey
10	USI	Unresolved Safety Issue
11		
12	VOC	volatile organic compound
13		
14	Xe	xenon

1

## 1.0 INTRODUCTION

2 Under the U.S. Nuclear Regulatory Commission's (NRC's) environmental protection regulations  
3 in Part 51 of Title 10 of the *Code of Federal Regulations* (10 CFR Part 51), which implement the  
4 National Environmental Policy Act of 1969 (NEPA), renewal of a nuclear power plant operating  
5 license (OL) requires the preparation of an environmental impact statement (EIS). In preparing  
6 the EIS, the NRC staff is required first to issue the statement in draft form for public comment  
7 and then issue a final statement after considering public comments on the draft. To support the  
8 preparation of the EIS, the NRC staff has prepared a *Generic Environmental Impact Statement*  
9 *for License Renewal of Nuclear Plants* (GEIS), NUREG-1437, Volumes 1 and 2 (NRC 1996;  
10 1999).<sup>(1)</sup> The GEIS is intended to (1) provide an understanding of the types and severity of  
11 environmental impacts that may occur as a result of license renewal of nuclear power plants  
12 under 10 CFR Part 54, (2) identify and assess the impacts that are expected to be generic to  
13 license renewal, and (3) support 10 CFR Part 51 to define the number and scope of issues that  
14 need to be addressed by the applicants in plant-by-plant license renewal proceedings. Use of  
15 the GEIS guides the preparation of complete plant-specific information related to the OL  
16 renewal process.

17 Entergy Nuclear FitzPatrick, LLC, and Entergy Nuclear Operations, Inc. (Entergy) operate the  
18 James A. FitzPatrick Nuclear Power Plant (JAFNPP) in northern New York under OL DPR-59,  
19 which was issued by the NRC. This OL will expire in October 2014. By letter dated July 31,  
20 2006, Entergy submitted an application to the NRC to renew the JAFNPP OL for an additional  
21 20 years under 10 CFR Part 54. Entergy is a licensee for the purposes of its current OL and an  
22 applicant for the renewal of the OL. Pursuant to 10 CFR 54.23 and 51.53(c), Entergy submitted  
23 an Environmental Report (ER; Entergy 2006b), in which Entergy analyzed the environmental  
24 impacts associated with the proposed license renewal action, considered alternatives to the  
25 proposed action, and evaluated mitigation measures for reducing adverse environmental  
26 effects.

27 This report is the plant-specific supplement to the GEIS (the supplemental EIS [SEIS]) for the  
28 Entergy license renewal application. This draft SEIS is a supplement to the GEIS because it  
29 relies, in part, on the findings of the GEIS. The NRC staff will also prepare a separate safety  
30 evaluation report in accordance with 10 CFR Part 54.

---

(1) The GEIS was originally issued in 1996. Addendum 1 to the GEIS was issued in 1999. Hereafter, all references to the "GEIS" include the GEIS and its Addendum 1.

1 **1.1 Report Contents**

2 The following sections of this introduction (1) describe the background for the preparation of this  
3 draft SEIS, including the development of the GEIS and the process used by the NRC staff to  
4 assess the environmental impacts associated with plant operations during license renewal;  
5 (2) describe the proposed Federal action to renew the JAFNPP OL; (3) discuss the purpose and  
6 need for the proposed action; and (4) present the status of Entergy's compliance with  
7 environmental quality standards and requirements that have been imposed by Federal, State,  
8 regional, and local agencies that are responsible for environmental protection.

9 The ensuing chapters of this draft SEIS closely parallel the contents and organization of the  
10 GEIS. Chapter 2 describes the site, power plant, and interactions of the plant with the  
11 environment. Chapters 3 and 4, respectively, discuss the potential environmental impacts of  
12 plant refurbishment and plant operation during the renewal term. Chapter 5 contains an  
13 evaluation of potential environmental impacts of plant accidents and includes consideration of  
14 severe accident mitigation alternatives. Chapter 6 discusses the uranium fuel cycle and solid  
15 waste management. Chapter 7 discusses decommissioning, and Chapter 8 discusses  
16 alternatives to license renewal. Finally, Chapter 9 summarizes the findings of the preceding  
17 chapters and draws conclusions about the adverse impacts that cannot be avoided, the  
18 relationship between short-term uses of man's environment and the maintenance and  
19 enhancement of long-term productivity, and the irreversible or irretrievable commitment of  
20 resources. Chapter 9 also presents the NRC staff's preliminary recommendation with respect to  
21 the proposed license renewal action.

22 Additional information is included in appendixes. Appendix A contains public comments related  
23 to the environmental review for license renewal and NRC staff responses to those comments.  
24 Appendixes B through G, respectively, list the following:

- 25 • The preparers of the supplement,
- 26 • The chronology of NRC staff's environmental review correspondence related to this draft  
27 SEIS,
- 28 • The organizations contacted during the development of this draft SEIS,
- 29 • Entergy's compliance status in Table E-1 (this appendix also contains copies of  
30 consultation correspondence prepared and sent during the evaluation process),
- 31 • GEIS environmental issues that are not applicable to JAFNPP, and
- 32 • Severe accident mitigation alternatives (SAMAs).

## 1 **1.2 Background**

2 Use of the GEIS, which examines the possible environmental impacts that could occur as a  
3 result of renewing individual nuclear power plant OLs under 10 CFR Part 54, and the  
4 established license renewal evaluation process support the thorough evaluation of the impacts  
5 of renewal of OLs.

### 6 **1.2.1 Generic Environmental Impact Statement**

7 The NRC initiated a generic assessment of the environmental impacts associated with the  
8 license renewal term to improve the efficiency of the license renewal process by documenting  
9 the assessment results and codifying the results in the Commission's regulations. This  
10 assessment is provided in the GEIS, which serves as the principal reference for all nuclear  
11 power plant license renewal EISs.

12 The GEIS documents the results of the systematic approach that was taken to evaluate the  
13 environmental consequences of renewing the licenses of individual nuclear power plants and  
14 operating them for an additional 20 years. For each potential environmental issue, the GEIS  
15 (1) describes the activity that affects the environment, (2) identifies the population or resource  
16 that is affected, (3) assesses the nature and magnitude of the impact on the affected population  
17 or resource, (4) characterizes the significance of the effect for both beneficial and adverse  
18 effects, (5) determines whether the results of the analysis apply to all plants, and (6) considers  
19 whether additional mitigation measures would be warranted for impacts that would have the  
20 same significance level for all plants.

21 The NRC's standard of significance for impacts was established using the Council on  
22 Environmental Quality (CEQ) terminology for "significantly" (40 CFR 1508.27, which requires  
23 consideration of both "context" and "intensity"). Using the CEQ terminology, the NRC  
24 established three significance levels—SMALL, MODERATE, or LARGE. The definitions of the  
25 three significance levels are set forth in the footnotes to Table B-1 of 10 CFR Part 51,  
26 Subpart A, Appendix B, as follows:

27 SMALL - Environmental effects are not detectable or are so minor that they will neither  
28 destabilize nor noticeably alter any important attribute of the resource.

29 MODERATE - Environmental effects are sufficient to alter noticeably, but not to destabilize,  
30 important attributes of the resource.

31 LARGE - Environmental effects are clearly noticeable and are sufficient to destabilize  
32 important attributes of the resource.

33 The GEIS assigns a significance level to each environmental issue, assuming that ongoing  
34 mitigation measures would continue.

## Introduction

1 The GEIS includes a determination of whether the analysis of the environmental issue could be  
2 applied to all plants and whether additional mitigation measures would be warranted. Issues  
3 are assigned a Category 1 or a Category 2 designation. As set forth in the GEIS, Category 1  
4 issues are those that meet all of the following criteria:

5 (1) The environmental impacts associated with the issue have been determined to apply  
6 either to all plants or, for some issues, to plants having a specific type of cooling system  
7 or other specified plant or site characteristics.

8 (2) A single significance level (i.e., SMALL, MODERATE, or LARGE) has been assigned to  
9 the impacts (except for collective offsite radiological impacts from the fuel cycle and from  
10 high-level waste and spent fuel disposal).

11 (3) Mitigation of adverse impacts associated with the issue has been considered in the  
12 analysis, and it has been determined that additional plant-specific mitigation measures  
13 are likely not to be sufficiently beneficial to warrant implementation.

14 For issues that meet the three Category 1 criteria, no additional plant-specific analysis is  
15 required in this draft SEIS unless new and significant information is identified.

16 Category 2 issues are those that do not meet one or more of the criteria of Category 1, and  
17 therefore, additional plant-specific review for these issues is required.

18 In the GEIS, the NRC staff assessed 92 environmental issues and determined that 69 qualified  
19 as Category 1 issues, 21 qualified as Category 2 issues, and 2 issues were not categorized.  
20 The two uncategorized issues are environmental justice and chronic effects of electromagnetic  
21 fields. Environmental justice was not evaluated on a generic basis in the GEIS and must be  
22 addressed in the draft SEIS. Information on the chronic effects of electromagnetic fields was  
23 not conclusive at the time the GEIS was prepared.

24 Of the 92 issues, 11 are related only to refurbishment, 6 are related only to decommissioning,  
25 67 apply only to operation during the renewal term, and 8 apply to both refurbishment and  
26 operation during the renewal term. A summary of the findings for all 92 issues in the GEIS is  
27 codified in Table B-1 of 10 CFR Part 51, Subpart A, Appendix B.

### 28 **1.2.2 License Renewal Evaluation Process**

29 An applicant seeking to renew its OL is required to submit an ER as part of its application. The  
30 license renewal evaluation process involves careful review of the applicant's ER and assurance  
31 that all new and potentially significant information not already addressed in or available during  
32 the GEIS evaluation is identified, reviewed, and assessed to verify the environmental impacts of  
33 the proposed license renewal.

- 1 In accordance with 10 CFR 51.53(c)(2) and (3), the ER submitted by the applicant must
- 2 • Provide an analysis of the Category 2 issues in Table B-1 of 10 CFR Part 51, Subpart A,  
3 Appendix B, in accordance with 10 CFR 51.53(c)(3)(ii), and
  - 4 • Discuss actions to mitigate any adverse impacts associated with the proposed action  
5 and environmental impacts of alternatives to the proposed action.

6 In accordance with 10 CFR 51.53(c)(2), the ER does not need to

- 7 • Consider the economic benefits and costs of the proposed action and alternatives to the  
8 proposed action except insofar as such benefits and costs are either (1) essential for  
9 making a determination regarding the inclusion of an alternative in the range of  
10 alternatives considered, or (2) relevant to mitigation
- 11 • Consider the need for power and other issues not related to the environmental effects of  
12 the proposed action and the alternatives
- 13 • Discuss any aspect of the storage of spent fuel within the scope of the generic  
14 determination in 10 CFR 51.23(a) in accordance with 10 CFR 51.23(b)
- 15 • Contain an analysis of any Category 1 issue unless there is significant new information  
16 on a specific issue—this is pursuant to 10 CFR 51.23(c)(3)(iii) and (iv)

17 New and significant information is (1) information that identifies a significant environmental issue  
18 not covered in the GEIS and codified in Table B-1 of 10 CFR Part 51, Subpart A, Appendix B, or  
19 (2) information that was not considered in the analyses summarized in the GEIS and that leads  
20 to an impact finding that is different from the finding presented in the GEIS and codified in  
21 10 CFR Part 51.

22 In preparing to submit its application to renew the JAFNPP OL, Entergy developed a process to  
23 ensure that information not addressed in or available during the GEIS evaluation regarding the  
24 environmental impacts of license renewal for JAFNPP would be properly reviewed before  
25 submitting the ER, and to ensure that such new and potentially significant information related to  
26 renewal of the license would be identified, reviewed, and assessed during the period of NRC  
27 review. Entergy reviewed the Category 1 issues that appear in Table B-1 of 10 CFR Part 51,  
28 Subpart A, Appendix B, to verify that the conclusions of the GEIS remained valid with respect to  
29 JAFNPP. This review was performed by personnel from Entergy and its support organizations  
30 involved in the preparation of a license renewal ER.

31 The NRC staff also has a process for identifying new and significant information. That process  
32 is described in detail in *Standard Review Plans for Environmental Reviews for Nuclear Power  
33 Plants, Supplement 1: Operating License Renewal* NUREG-1555, Supplement 1 (NRC 2000).

## Introduction

1 The search for new information includes (1) review of an applicant's ER and the process for  
2 discovering and evaluating the significance of new information, (2) review of public comments,  
3 (3) review of environmental quality standards and regulations, (4) coordination with Federal,  
4 State, and local environmental protection and resource agencies, and (5) review of the technical  
5 literature. New information discovered by the NRC staff is evaluated for significance using the  
6 criteria set forth in the GEIS. For Category 1 issues where new and significant information is  
7 identified, reconsideration of the conclusions for those issues is limited in scope to the  
8 assessment of the relevant new and significant information; the scope of the assessment does  
9 not include other facets of the issue that are not affected by the new information.

10 Chapters 3 through 7 discuss the environmental issues considered in the GEIS that are  
11 applicable to JAFNPP. At the beginning of the discussion of each set of issues, a table  
12 identifies the issues to be addressed and lists the sections in the GEIS where the issue is  
13 discussed. Category 1 and Category 2 issues are listed in separate tables. For Category 1  
14 issues for which there is no new and significant information, the table is followed by a set of  
15 short paragraphs that state the GEIS conclusion codified in Table B-1 of 10 CFR Part 51,  
16 Subpart A, Appendix B, followed by the NRC staff's analysis and conclusion. For Category 2  
17 issues, in addition to the list of GEIS sections where the issue is discussed, the tables list the  
18 subparagraph of 10 CFR 51.53(c)(3)(ii) that describes the analysis required and the draft SEIS  
19 sections where the analysis is presented. The draft SEIS sections that discuss the Category 2  
20 issues are presented immediately following the table.

21 The NRC prepares an independent analysis of the environmental impacts of license renewal  
22 and compares these impacts with the environmental impacts of alternatives. The evaluation of  
23 the Entergy license renewal application began with publication of a Notice of Acceptance for  
24 docketing and opportunity for a hearing in the *Federal Register* (FR; 71 FR 55032 [NRC 2006])  
25 on September 20, 2006, which also included a Notice of Intent to prepare an EIS and conduct  
26 scoping. Two public scoping meetings were held on October 12, 2006, in Oswego, New York.  
27 Comments received during the scoping period were summarized in the *Environmental Scoping  
28 Summary Report Associated with the Staff's Review of the Application by Entergy for Renewal  
29 of the Operating License for James A. FitzPatrick Nuclear Power* (NRC 2007). Comments that  
30 are applicable to this environmental review are presented in Appendix A.

31 The NRC staff followed the review guidance contained NUREG-1555, Supplement 1 (NRC  
32 2000). The NRC staff and contractors retained to assist the staff conducted a site audit at the  
33 JAFNPP site on December 5 and 6, 2006, to gather information and to become familiar with the  
34 site and its environs. The NRC staff also reviewed the comments received during scoping and  
35 consulted with Federal, State, regional, and local agencies. A list of the organizations consulted  
36 is provided in Appendix D. Other documents related to JAFNPP were reviewed and are  
37 referenced in this draft SEIS.

38 This draft SEIS presents the NRC staff's analysis that considers and weighs the environmental  
39 effects of the proposed renewal of the OL for JAFNPP, the environmental impacts of



1 alternatives to license renewal, and mitigation measures available for avoiding adverse  
2 environmental effects. Chapter 9, "Summary and Conclusions," provides the NRC staff's  
3 preliminary recommendation to the Commission on whether or not the adverse environmental  
4 impacts of license renewal are so great that preserving the option of license renewal for energy-  
5 planning decision makers would be unreasonable.

6 A 75-day comment period on this draft SEIS will begin on the date of publication of the U.S.  
7 Environmental Protection Agency Notice of Filing of the draft SEIS to allow members of the  
8 public to comment on the preliminary results of the NRC staff's review. During this comment  
9 period, two public meetings will be held in Oswego, New York, in August 2007. During these  
10 meetings, the NRC staff will describe the preliminary results of the NRC environmental review  
11 and answer questions to provide members of the public with information to assist them in  
12 formulating their comments.

### 13 **1.3 The Proposed Federal Action**

14 The proposed Federal action is renewal of the OL for JAFNPP. JAFNPP is located in northern  
15 New York on the south shore of Lake Ontario, approximately 7 miles (mi) northeast of Oswego,  
16 New York, 36 mi north-northeast of Syracuse, New York, and 65 mi east of Rochester, New  
17 York. The plant has a single boiling water reactor (BWR) designed by the General Electric  
18 Company with a rated power level of 2536 megawatts thermal (MWt) and a gross power output  
19 of 881 megawatts electric (MWe). Plant cooling is provided by a once-through cooling system  
20 that discharges heated water back to Lake Ontario through a discharge structure. The current  
21 OL for JAFNPP expires on October 17, 2014. By letter dated July 31, 2006, Entergy submitted  
22 an application to the NRC (Entergy 2006a) to renew this OL for an additional 20 years of  
23 operation (i.e., until October 17, 2034).

### 24 **1.4 The Purpose and Need for the Proposed Action**

25 Although a licensee must have a renewed license to operate a reactor beyond the term of the  
26 existing OL, the possession of that license is just one of a number of conditions that must be  
27 met for the licensee to continue plant operation during the term of the renewed license. Once  
28 an OL is renewed, State regulatory agencies and the owners of the plant will ultimately decide  
29 whether the plant will continue to operate based on factors such as the need for power or other  
30 matters within the State's jurisdiction or the purview of the owners.

31 Thus, for license renewal reviews, the NRC has adopted the following definition of purpose and  
32 need (GEIS Section 1.3):

33           The purpose and need for the proposed action (renewal of an operating license)  
34           is to provide an option that allows for power generation capability beyond the

## Introduction

1 term of a current nuclear power plant operating license to meet future system  
2 generating needs, as such needs may be determined by State, utility, and where  
3 authorized, Federal (other than NRC) decision makers.

4 This definition of purpose and need reflects the Commission's recognition that, unless there are  
5 findings in the safety review required by the Atomic Energy Act of 1954 or findings in the NEPA  
6 environmental analysis that would lead the NRC to reject a license renewal application, the  
7 NRC does not have a role in the energy-planning decisions of State regulators and utility  
8 officials as to whether a particular nuclear power plant should continue to operate. From the  
9 perspective of the licensee and the State regulatory authority, the purpose of renewing an OL is  
10 to maintain the availability of the nuclear plant to meet system energy requirements beyond the  
11 current term of the plant's license.

### 12 **1.5 Compliance and Consultations**

13 Entergy is required to hold certain Federal, State, and local environmental permits, as well as  
14 meet relevant Federal and State statutory requirements. In its ER, Entergy provided a list of the  
15 authorizations from Federal, State, and local authorities for current operations as well as  
16 environmental approvals and consultations associated with JAFNPP license renewal.  
17 Authorizations and consultations relevant to the proposed OL renewal action are included in  
18 Appendix E.

19 The NRC staff has reviewed the list and consulted with the appropriate Federal, State, and local  
20 agencies to identify any compliance or permit issues or significant environmental issues of  
21 concern to the reviewing agencies. These agencies did not identify any new and significant  
22 environmental issues. The ER states that Entergy is in compliance with applicable  
23 environmental standards and requirements for JAFNPP. The NRC staff has not identified any  
24 environmental issues that are both new and significant.

### 25 **1.6 References**

26 10 CFR Part 51. *Code of Federal Regulations*, Title 10, *Energy*, Part 51, "Environmental  
27 Protection Regulations for Domestic Licensing and Related Regulatory Functions."

28 10 CFR Part 54. *Code of Federal Regulations*, Title 10, *Energy*, Part 54, "Requirements for  
29 Renewal of Operating Licenses for Nuclear Power Plants."

30 40 CFR Part 1508. *Code of Federal Regulations*, Title 40, *Protection of Environment*,  
31 Part 1508, "Terminology and Index."

32 Atomic Energy Act of 1954 (AEA). 42 USC 2011, et seq.

- 1 Entergy Nuclear FitzPatrick, LLC, and Entergy Nuclear Operations, Inc. (Entergy). 2006a.  
2 *James A. FitzPatrick Nuclear Power Plant — License Renewal Application*. Lycoming,  
3 New York. Accessible at ML062160494.
- 4 Entergy Nuclear FitzPatrick, LLC, and Entergy Nuclear Operations, Inc. (Entergy). 2006b.  
5 *James A. FitzPatrick Nuclear Power Plant — License Renewal Application, Appendix E:*  
6 *Applicant’s Environmental Report, Operating License Renewal Stage*. Lycoming, New York.  
7 Accessible at ML062160557.
- 8 National Environmental Policy Act of 1969 (NEPA). 42 USC 4321, et seq.
- 9 U.S. Nuclear Regulatory Commission (NRC). 1996. *Generic Environmental Impact Statement*  
10 *for License Renewal of Nuclear Plants*. NUREG-1437, Volumes 1 and 2. Office of Nuclear  
11 Regulatory Research, Washington, D.C.
- 12 U.S. Nuclear Regulatory Commission (NRC). 1999. *Generic Environmental Impact Statement*  
13 *for License Renewal of Nuclear Plants Main Report*, “Section 6.3 – Transportation, Table 9.1,  
14 Summary of findings on NEPA issues for license renewal of nuclear power plants, Final Report.”  
15 NUREG-1437, Volume 1, Addendum 1. Office of Nuclear Regulatory Research, Washington,  
16 D.C.
- 17 U.S. Nuclear Regulatory Commission (NRC). 2000. *Standard Review Plans for Environmental*  
18 *Reviews for Nuclear Power Plants, Supplement 1: Operating License Renewal*. NUREG-1555,  
19 Supplement 1. Office of Nuclear Reactor Regulation, Washington, D.C.
- 20 U.S. Nuclear Regulatory Commission (NRC). 2006. “Notice of Acceptance for Docketing of the  
21 Application, Notice of Opportunity for a Hearing and Notice of Intent to Prepare an  
22 Environmental Impact Statement and Conduct Scoping Process for Facility Operating License  
23 No. DPR-59 for an Additional 20-Year Period, Entergy Nuclear Operations, Inc., James A.  
24 Fitzpatrick Nuclear Power Plant.” *Federal Register*. Vol. 71, No. 182, pp. 55032-55035.  
25 September 20, 2006.
- 26 U.S. Nuclear Regulatory Commission (NRC). 2007. *Environmental Scoping Summary Report*  
27 *Associated with the Staff’s Review of the Application by Entergy for Renewal of the Operating*  
28 *License for JAFNPP*. Washington, D.C. Accessible at ML070440393.



1           **2.0 DESCRIPTION OF NUCLEAR POWER PLANT AND SITE AND**  
2                           **INTERACTION WITH THE ENVIRONMENT**

3 James A. FitzPatrick Nuclear Power Plant (JAFNPP) is located in the town of Scriba, New York.  
4 The plant consists of one unit, a boiling water reactor (BWR), which employs a once-through  
5 cooling system. JAFNPP is operated by Entergy Nuclear FitzPatrick, LLC, and Entergy Nuclear  
6 Operations, Inc. (Entergy). The plant and its environs are described in Section 2.1, and the  
7 environment in which the plant is located is presented in Section 2.2.


8           **2.1 Facility and Site Description and Proposed Facility Operation During the**  
9                           **Renewal Term**

10 JAFNPP is located on approximately 702 acres (ac) of land on the south shore of Lake Ontario,  
11 at a location known as Nine Mile Point. The plant is in a rural area, approximately seven miles  
12 (mi) northeast of Oswego, 36 mi north-northwest of Syracuse, and 65 mi east of Rochester,  
13 New York. The largest town within a 50-mi radius is Syracuse. Nine Mile Point Nuclear Station,  
14 Units 1 and 2, operated by Nine Mile Point Nuclear Station, LLC, is immediately west of  
15 JAFNPP. Figures 2-1 and 2-2 show the site location and features within 50 mi and 6 mi,  
16 respectively (Entergy 2006c).

17           **2.1.1 External Appearance and Setting**

18 The area surrounding JAFNPP is generally flat, rising gently from Lake Ontario to the  
19 Appalachian Uplands on the south, and bounded on the east by the Tug Hill Upland. The plant  
20 is at an elevation of 270 feet (ft) above mean sea level. Elevation rises to 310 ft at the  
21 property's southern edge 1 mi away. The JAFNPP site is partially wooded and surrounded  
22 primarily by residential and recreational areas except for the Nine Mile Point Nuclear Station.  
23 There is no residential, agricultural, or industrial development (other than JAFNPP) on the  
24 JAFNPP site. The nearest residence is outside the site boundary approximately 0.7 mi to the  
25 east-southeast.

26 The buildings associated with JAFNPP lie on the northwest part of the site (See Figure 2-3).  
27 The plant consists of a reactor building, turbine building with electrical and heater bays,  
28 administration building and control room, radioactive waste building, screenwell-pumphouse  
29 building with intake and discharge tunnels and structures, diesel generator building, auxiliary  
30 boiler building, main stack, independent spent fuel storage installation (ISFSI), sewage  
31 treatment plant, interim radioactive waste storage building, switchyard, shooting ranges, and  
32 associated transmission lines. The facility is enclosed by a security fence and access to the site  
33 is controlled. Although the plant structures can be seen by recreational users on Lake Ontario,  
34 JAFNPP is not visible to local communities due to the surrounding forest cover.



1

2


**Figure 2-1.** Location of JAFNPP, 50-mi Region (Entergy 2006c)



1

2

**Figure 2-2.** Location of JAFNPP, 6-mi Region (Entergy 2006c)



1

2

**Figure 2-3. JAFNPP Approximate Site Boundary**

3

The plant is accessed by Lake Road, which connects to Oswego County Route 29. A spur of

4

Conrail Railroad is currently blocked for security purposes but could be re-opened to provide rail

5

service to the plant. JAFNPP can also be reached by barge on Lake Ontario.



1 Within a 50-mi radius of JAFNPP there are 17 state parks, 20 state wildlife management areas,  
2 and one national wildlife refuge. The closest public park, Sunset Bay Park, is approximately  
3 1 mi east of JAFNPP on the shore of Lake Ontario. This park has 48 ac of mostly woods and  
4 brush land, a boat launch, nature trail, and picnic area. The next closest public park,  
5 Independence Park, is approximately 2 mi southwest and also on Lake Ontario. This park has  
6 50 ac of wooded land, walking trails, and an observation deck. Scriba Town Park is 5 mi south  
7 of Scriba and includes a picnic area, playground, and swimming facilities.

### 8 **2.1.2 Reactor Systems**

9 JAFNPP is a single-cycle, forced-circulation BWR that produces steam for direct use in the  
10 steam turbine. The rated thermal output of the unit is 2536 megawatts-thermal (MWt),  
11 corresponding to an electrical output of approximately 881 megawatts-electric (MWe). JAFNPP  
12 achieved commercial operation in 1975 (Entergy 2006c).

13 The JAFNPP facility is depicted in Figure 2-3. The reactor building is designed as a low  
14 in-leakage, elevated release secondary containment system that houses the primary  
15 containment system, refueling facilities, and most of the components of the nuclear steam  
16 supply system. The secondary containment system provides secondary containment when the  
17 primary containment system is closed and in service, and provides primary containment when  
18 the primary containment system is open, as in refueling. The secondary containment system  
19 consists of the reactor building, standby gas treatment system, reactor building isolation control  
20 system, and main stack.

21 In the event of a postulated pipe break inside the drywell or a fuel handling accident, the reactor  
22 building is isolated by the reactor building isolation control system to provide a low leakage  
23 barrier. The standby gas treatment system, which is initiated by the same conditions that isolate  
24 the reactor building, exhausts air from the reactor building to maintain a reduced pressure within  
25 the reactor building relative to the outside atmosphere, treats the air to remove particulates and  
26 iodines, and releases the air through the elevated release point, the main stack. These safety  
27 features function to localize, control, mitigate, and terminate such events to limit the public's  
28 exposure levels to below applicable dose guidelines.

29 The fuel for the reactor core consists of slightly enriched uranium dioxide pellets contained in  
30 sealed Zircaloy-2 tubes that were evacuated, backfilled with helium, and sealed with Zircaloy  
31 end plugs welded in each end. The core is designed to permit the energy extraction of  
32 19,000 megawatt-days per metric ton of uranium averaged over the initial core load (Entergy  
33 2006c).

### 34 **2.1.3 Cooling and Auxiliary Water Systems**

35 JAFNPP uses water from Lake Ontario for station cooling. Approximately 91 percent of the  
36 water withdrawn from the lake is used for the circulating water system to cool the station's main  
37 condenser. Approximately 9 percent of the water withdrawn from the lake is used for the station

## Plant and the Environment

1 service water system and other plant systems including the emergency service water system,  
2 the residual heat removal system, and the fire protection system.

3 Water is withdrawn from the lake from an offshore submerged intake structure and through the  
4 intake tunnel to the screenwell-pumphouse building. Water is eventually returned to the lake by  
5 way of a discharge tunnel and an in-lake diffuser system. The cooling and auxiliary water  
6 systems for JAFNPP include the intake structure, intake tunnel, screenwell and pumphouse  
7 building, discharge tunnel, and diffuser. Neither the intake or discharge diffuser structures are  
8 in the shipping lanes of the lake and therefore do not constitute a hazard to commercial  
9 shipping.

10 The offshore intake structure is a reinforced concrete structure located approximately 900 ft  
11 from the shoreline in approximately 25 ft of water. Water is drawn from lower levels of the lake  
12 to prevent the formation of vortices at the surface and minimize the possibility of interactions  
13 with floating ice and the lake fishery. The structure is approximately 14 ft high and the top of the  
14 intake structure is approximately 10 ft below the lake surface. The fan-shaped intake is located  
15 on the shoreward side of the structure. Water is drawn through four openings with a total intake  
16 area of approximately 8 ft by 70 ft. The intake velocity at the intake structure is approximately  
17 1.6 feet per second (ft/s).

18 The intake opening also includes a bar rack, with bars placed 1 foot apart, to prevent large  
19 debris from entering the intake. The bars are heated by induction coils to minimize the  
20 probability of frazil ice adhering to the bars and blocking the intake. The heaters are normally  
21 kept energized except during maintenance. During maintenance, any frazil ice that is drawn  
22 past the intake racks is tempered in the screenwell structure with water from the circulating  
23 water discharge chamber. In the unlikely event that the intake is blocked and the volume of  
24 water needed for normal shutdown cannot be drawn, the flow in the discharge structure can be  
25 reversed using a series of gates, and cooling water can be drawn through the discharge tunnel  
26 to the screenwell-pumphouse building.

27 JAFNPP has installed a high-frequency/high-amplitude acoustic fish deterrence system (FDS)  
28 on the intake structure. The JAFNPP FDS consists of nine overlapping, wide-beam, high-  
29 frequency transducers mounted on the top of the intake structure. The transducers produce a  
30 sound field designed to deter alewives from entering the intake structure and eventually  
31 becoming impinged on the intake screens.

32 From the intake structure, the lake water drops 60 feet below lake level to a tunnel connecting  
33 the intake structure to the onshore screenwell-pumphouse building. The D-shaped tunnel has a  
34 flat bottom, vertical sides, and round top; average water velocity in the tunnel is 4.7 ft/s. From  
35 the intake tunnel, the water rises into the forebay of the screenwell-pumphouse building.

36 The screenwell-pumphouse building, which is the structure immediately north of the turbine  
37 building, houses the trash racks, traveling screens, pumps for the circulating water, services

1 water, emergency service water, residual heat removal, and fire protection systems. The  
2 screenwell-pumphouse also houses the water treatment tanks and associated biofouling control  
3 equipment.

4 From the intake tunnel, water enters the screenwell-pumphouse forebay, travels through vertical  
5 trash bars that excludes debris greater than 3 1/8-inches, then through the vertical traveling  
6 screens with a 3/8-inch mesh. The screenwell behind the vertical traveling screens houses  
7 three circulating water pumps each with a rated flow of 120,000 gpm. The design circulating  
8 water flow is 352,600 gpm through the main condenser.

9 Discharge from the main condenser and service water system is returned to Lake Ontario  
10 through the discharge tunnel and diffuser system in the lake. The design effluent flow rate to  
11 the discharge tunnel is 388,600 gpm, including the design service water pumps discharge of  
12 36,000 gpm. The discharge tunnel starts from the screenwell-pumphouse building and extends  
13 approximately 1400 ft northward into the lake to a junction with the diffuser branch tunnels,  
14 which are generally parallel to the shoreline. The discharge diffuser consists of six diffuser  
15 heads, three on each diffuser branch and spaced approximately 150 feet apart. On top of each  
16 riser is a diffuser head consisting of two horizontal discharge nozzles separated by an included  
17 angle of 42 degrees. Each nozzle is 2.5 ft in diameter and discharges water at an exit velocity  
18 of 14 ft/s in the offshore direction. The centerline of the nozzles is five to six feet above the lake  
19 bottom.

20 Discharges from the cooling water and service water systems are regulated by the New York  
21 State Department of Environmental Conservation (NYSDEC) under State Pollutant Discharge  
22 Elimination System (SPDES) Discharge Permit NY-0020109 (Entergy 2006c).

#### 23 **2.1.4 Radioactive Waste Management Systems and Effluent Control Systems**

24 JAFNPP radioactive waste (radwaste) systems are designed to collect, treat, and dispose of the  
25 radioactive and potentially radioactive wastes that are byproducts of plant operations. The  
26 byproducts are activation products resulting from the irradiation of reactor water and impurities  
27 therein (principally metallic corrosion products) and fission products resulting from defective fuel  
28 cladding or uranium contamination within the reactor coolant system. Operating procedures for  
29 radwaste systems ensure that radioactive wastes are safely processed and discharged from the  
30 plant within the limits set forth in Part 20 of Title 10 of the *Code of Federal Regulations* (10 CFR  
31 Part 20), 10 CFR Part 50, the plant's technical specifications, and JAFNPP's *Offsite Dose*  
32 *Calculation Manual* or ODCM (Entergy 2004c, 2006c).

33 Radioactive wastes resulting from plant operations are classified as liquid, gaseous, or solid.  
34 Liquid radioactive wastes are generated from liquids received directly from portions of the  
35 reactor coolant system or were contaminated by contact with liquids from the reactor coolant  
36 system. Gaseous radioactive wastes are generated from gases or airborne particulates vented  
37 from reactor and turbine equipment containing radioactive material. Solid radioactive wastes

1 are solids from the reactor coolant system, solids that came into contact with reactor coolant  
2 system liquids or gases, or solids used in the reactor coolant system or steam and power  
3 conversion system operation or maintenance (Entergy 2006c).

4 Reactor fuel that has exhausted a certain percentage of its fissile uranium content is referred to  
5 as spent fuel. Spent fuel assemblies are removed from the reactor core and replaced with fresh  
6 fuel assemblies during routine refueling outages, typically every 24 months. Spent fuel  
7 assemblies are then stored for a period of time in the spent fuel pool in the reactor building and  
8 may later be transferred to dry storage at an onsite ISFSI. JAFNPP also provides for onsite  
9 storage of mixed wastes, which contain both radioactive and chemically hazardous materials  
10 (Entergy 2006c).

11 JAFNPP's ODCM contains the methodology and parameters used to calculate offsite doses  
12 resulting from radioactive gaseous and liquid effluents, and the gaseous and liquid effluent  
13 monitoring alarm and trip set points used to verify that the radioactive material being discharged  
14 meets regulatory limits (Entergy 2004c). The ODCM also contains the radioactive effluent  
15 controls and radiological environmental monitoring activities and descriptions of the information  
16 that should be included in the annual Radiological Environmental Operating Report and annual  
17 Radioactive Effluent Release Report required by 10 CFR Part 50, Appendix I, and  
18 10 CFR 50.36a, respectively.

#### 19 *2.1.4.1 Liquid Waste Processing Systems and Effluent Controls*

20 The liquid waste processing system collects, holds, treats, processes, and monitors all liquid  
21 radioactive wastes for reuse or disposal. The system is divided into several subsystems so that  
22 liquid wastes from various sources can be segregated and processed separately. Cross  
23 connections between the subsystems provide additional flexibility for processing the wastes by  
24 alternate methods. The wastes are collected, treated, and disposed of according to their  
25 conductivity and/or radioactivity (Entergy 2006c).

26 Liquid waste is collected in sumps and drain tanks and transferred to the appropriate subsystem  
27 collection tanks for subsequent treatment, disposal, or recycle. The subsystems provide for  
28 filtration, demineralizing, dewatering, and resin filtration; and include a modular fluidized transfer  
29 demineralization and sluice system. Following treatment and batch sampling, the liquid waste is  
30 normally returned to condensate storage tanks for reuse in the plant. Liquid releases to the lake  
31 are infrequent, and limited to the maximum extent possible to satisfy the design objectives of 10  
32 CFR Part 50, Appendix I. Liquid discharges to the lake occur only when radioactive material  
33 activity concentration in the storage tank is equal to or less than  $5 \times 10^{-4}$  curies per milliliter  
34 (Ci/ml) (Entergy 2006c). Liquid discharge concentrations are further reduced by dilution water  
35 before any release to the lake. Chemical waste is dewatered and sent offsite to an approved  
36 disposal site. Controls for limiting the release of radiological liquid effluents are described in the  
37 ODCM (Entergy 2004c).

1 The NRC staff reviewed the JAFNPP radioactive effluent release reports for 2001 through 2005  
2 for liquid effluents (Entergy 2006a, 2005a, 2004a, 2003, 2002a, 2002b). In 2005, 3 million liters  
3 (L) of radiological liquid effluents diluted with 921 million L of water and a total of  $1.34 \times 10^{-2}$  Ci  
4 of tritium diluted to concentrations below  $2 \times 10^{-6}$   $\mu\text{Ci/ml}$  were released (Entergy 2006a). The  
5 releases contained no other fission or activation products, gross alpha radioactivity, or dissolved  
6 and entrained gases. In the fourth quarter of 2002, a total of  $2.75 \times 10^{-3}$  Ci of fission and  
7 activation products and  $3.62 \times 10^{-7}$  Ci of gross alpha radioactivity were released.

8 Based on the liquid waste processing systems and effluent controls and performance from 2001  
9 through 2005, similar small quantities of radioactive liquid effluents are expected from JAFNPP  
10 and are not expected to increase during the renewal period. These releases would result in  
11 doses to members of the public that are well below the as low as reasonably achievable  
12 (ALARA) dose design objectives of 10 CFR Part 50, Appendix I, as discussed in Section 2.2.7.

#### 13 *2.1.4.2 Gaseous Waste Processing Systems and Effluent Controls*

14 The gaseous radwaste processing system processes and disposes of condenser off-gases via  
15 the main stack. Non-radioactive gland seal gas and gases from the start-up mechanical pump  
16 are also discharged via the stack. During routine reactor operation, condenser off-gas is the  
17 major contributor to the activity in the off-gas release. Condenser off-gas entering this system  
18 consists of non-condensables from the main condenser, which consist of hydrogen and oxygen  
19 formed in the reactor by the radiolytic decomposition of water, air in-leakage to the turbine-  
20 condenser, water vapor, and a negligible volume of fission gases. The most important sources  
21 of radioactive gases are activation gases in the reactor coolant and fission gases that leak  
22 through the fuel cladding (Entergy 2006c).

23 The gaseous radwaste processing system controls, filters, and removes radioactive particulates  
24 and iodine from off-gas stream, recombines radiolytic hydrogen and oxygen, provides adequate  
25 holdup time for decay of short-lived radionuclides, and uses charcoal beds for the hold-up and  
26 partial decay of xenon (Xe) and krypton (Kr) gases. The stack design ensures prompt mixing of  
27 gas inlet streams at its base, thereby providing prompt dilution of hydrogen and allowing the  
28 location of sample points as near the base as possible.

29 JAFNPP maintains gaseous in accordance with the procedures and methodology described in  
30 the ODCM. The gaseous radwaste system is used to reduce radioactive materials in gaseous  
31 effluents before discharge to meet the ALARA dose design objectives in 10 CFR Part 50,  
32 Appendix I. Radioactive effluent gases are released at a typical rate of 24 to 28 cubic feet per  
33 minute ( $\text{ft}^3/\text{min}$ ). Two air dilution fans are in the base of the stack, both rated at  $3000 \text{ ft}^3/\text{min}$ .  
34 One dilution fan operates continuously while the other fan is on standby. The flow from the  
35 operating stack dilution fan also ensures that hydrogen is diluted to less than 4 percent by  
36 volume. In addition, the limits in the ODCM are designed to prevent members of the public in  
37 unrestricted areas from being exposed to radioactive materials in excess of the limits specified  
38 in 10 CFR Part 20, Appendix B (Entergy 2006c).

1 The NRC staff reviewed the JAFNPP radioactive effluent release reports for 2001 through 2005  
2 for gaseous effluents (Entergy 2006a, 2005a, 2004a, 2003, 2002a, 2002b). In 2005, the total  
3 fission and activation products released was 4370 Ci; iodine-131 was  $9.35 \times 10^{-3}$  Ci; particulates  
4 were  $3.52 \times 10^{-36}$  Ci; and tritium was 17.1 Ci. These activities are typical of past years and are  
5 not expected to increase during the renewal period. See Section 2.2.7 for a discussion of the  
6 theoretical doses to the maximally exposed individual as a result of these releases.

#### 7 *2.1.4.3 Solid Waste Processing*

8 The solid radwaste processing equipment is located in the radioactive waste building with the  
9 exception of the cleanup phase separator tanks, which are located in the reactor building. Both  
10 wet and dry radioactive solid wastes are processed. Wet solid wastes include backwash sludge  
11 wastes from the reactor water cleanup system, waste from floor drain filters, the fuel pool filter-  
12 demineralizers, spent resins from the waste and condensate demineralizers, and spent media  
13 from modular fluidized transfer demineralization and sluice system. Dry solid wastes include  
14 rags, contaminated clothing, paper, small equipment parts, and solid laboratory wastes (Entergy  
15 2006c).

16 Contaminated waste such as demolished piping, equipment, and components from facility  
17 radiological-controlled areas are first processed at an onsite decontamination unit. If the  
18 material is below the acceptable release limits and after additional cleaning shows no further  
19 reduction of contamination levels, the material may be returned to use or released from the  
20 radiological-controlled area. If the material is not below the release limits and after additional  
21 cleaning shows no further reduction of contamination levels, it will be disposed of as radioactive  
22 waste. In some instances, the solid material is sent to a vendor for decontamination. This  
23 material may be returned for reuse or disposed of as radioactive waste per the vendor's process  
24 (Entergy 2006c).

25 In 2005, JAFNPP made a total of 35 shipments of solid waste to offsite vendors. The solid  
26 waste volumes were 623 cubic meters ( $m^3$ ) of dry compressible waste, contaminated  
27 equipment, and spent resins, with an activity of 131 Ci (Entergy 2006a). No irradiated  
28 components or control rods were shipped. The solid waste volumes and radioactive material  
29 activity levels are typical of annual waste shipments for JAFNPP and are not expected to  
30 increase during the renewal period.

#### 31 **2.1.5 Nonradioactive Waste Systems**

32 JAFNPP generates solid waste, hazardous and universal waste, mixed waste, and wastewaters  
33 from routine facility operations and maintenance activities.

##### 34 *2.1.5.1 Nonradioactive Waste Streams*

35 Solid waste is waste that is neither radioactive nor hazardous as defined by the Resource  
36 Conservation and Recovery Act (RCRA) (40 CFR Part 260). JAFNPP generates solid waste,

1 such as office trash, as part of routine plant maintenance, cleaning activities, and plant  
2 operations. A contract service collects office trash and disposes of the waste offsite. JAFNPP  
3 has an active recycling program for office paper, aluminum cans, and plastic.

4 Hazardous waste is nonradioactive waste that is listed by the U.S. Environmental Protection  
5 Agency (EPA) as hazardous waste or that exhibits characteristics of ignitability, corrosivity,  
6 reactivity, or toxicity (40 CFR Part 261). RCRA regulates the treatment, storage, and/or  
7 disposal of hazardous waste and requires a hazardous waste permit for facilities that treat or  
8 store large quantities of hazardous waste for more than 90 days and for entities that dispose of  
9 hazardous waste at the facility. RCRA regulations are administered in New York State by  
10 NYSDEC.

11 JAFNPP generates a variety of hazardous waste streams including broken fluorescent lamps,  
12 mercury, off-specification or expired chemicals, oil lab wastes, oils and solvents, paint waste,  
13 photographic waste, and polychlorinated biphenyls (PCBs). JAFNPP is a small-quantity  
14 generator of hazardous waste, meaning the plant generates less than 1000 kilograms (kg) of  
15 non-acute hazardous waste in a month and stores less than 6000 kg of this waste at any one  
16 time. A small-quantity generator can also be classified as generating less than 1 kg of acute  
17 hazardous waste in a month and storing less than 1 kg of this waste at one time. In 2004,  
18 JAFNPP generated 5266 kg of hazardous waste. Most of the waste was associated with the  
19 demolition of buildings. Approximately 318 kg of hazardous waste was generated in 2005 and  
20 626 kg in 2006. During 2004 to 2006, NYSDEC conducted two regulatory compliance  
21 inspections of JAFNPP's RCRA program. No hazardous waste permit violations were noted.

22 Universal waste is hazardous waste that has been specified as universal waste by the EPA.  
23 Universal waste, including mercury-containing equipment, batteries, lamps, and pesticides, has  
24 specific regulations (40 CFR Part 273) to ensure proper collection and recycling or treatment.  
25 States may modify the universal waste rule and add additional wastes to their list of universal  
26 wastes. New York State classifies batteries, pesticides, mercury-containing thermostats, and  
27 lamps as universal wastes, which are therefore subject to specific universal waste regulations  
28 (6 NYCRR Subpart 374).

29 JAFNPP generates pesticides, batteries, and fluorescent lamps as universal wastes from  
30 normal facility operations. The batteries and lamps are accumulated in satellite areas and then  
31 moved to a locked storage building, in accordance with State universal waste regulations. The  
32 wastes are disposed of offsite by a contract service. In 2005, JAFNPP generated approximately  
33 7193 kg of spent batteries and 843 kg of spent fluorescent bulbs. In 2006, 2749 kg of spent  
34 batteries and 843 kg of spent bulbs were generated. During the 2004 RCRA inspection, one  
35 universal waste program violation related to the management of spent fluorescent bulbs was  
36 noted but fixed immediately by site personnel (Entergy 2006g).

37 The Toxic Substance Control Act (TSCA) of 1976 (15 USC s/s 2601 et seq.) implemented  
38 regulations for EPA to track specific toxic chemicals used in the U.S. PCBs, a TSCA chemical

1 is found at JAFNPP in limited quantities in transformer oil, lighting ballasts, and capacitors. In  
2 2005, JAFNPP received a fine from EPA for improperly identifying a drum of used oil as non-  
3 hazardous instead of PCB-waste and not disposing of the drum at a TSCA disposal facility. As  
4 a result, Entergy created a fleet-wide TSCA management plan that has been implemented at  
5 JAFNPP.

6 Low-level mixed waste (LLMW) is waste that exhibits hazardous characteristics and contains  
7 low levels of radioactivity. LLMW has been regulated under multiple authorities. EPA or state  
8 agencies regulate the hazardous component of LLMW through RCRA, and either the U.S.  
9 Department of Energy (DOE) or NRC regulates the radioactive component. New York State  
10 has adopted the EPA rule (6 NYCRR Part 374), which provides for a conditional exemption of  
11 LLMW storage, to eliminate dual regulation of LLMW. Storage of LLMW at JAFNPP is  
12 permitted under its NYSDEC Treatment, Storage, or Discharge Facility (TSDF) permit  
13 (No. NYD000765073). The permit was issued in November 1995 and expired in January 2000.  
14 New York Power Authority (NYPA), the owner of JAFNPP at the time, submitted a letter to  
15 NYSDEC (NYPA 2000) with its intention to operate under the conditional exemption.  
16 Subsequently, NYSDEC allowed the existing permit to continue under the State Administrative  
17 Procedures Act (Section 401) until the EPA rule was finalized (NYSDEC 2000a). JAFNPP  
18 submitted a letter to NYSDEC in November 2005 stating that JAFNPP qualified for the LLMW  
19 exemption and would, therefore, like to terminate its Part 373 Permit (Entergy 2005d). The  
20 permit is still pending termination by NYSDEC.

21 JAFNPP generates oil and solvent wastes, off-specification chemicals, and paint wastes (solids  
22 and liquids) from normal facility operation and maintenance. These wastes, when generated,  
23 are stored in locked, marked containment buildings specifically for LLMW. JAFNPP last  
24 shipped LLMW offsite for disposal in 2005. JAFNPP generates small amounts of LLMW at  
25 several accumulation areas in the facility but does not have any stored in the mixed waste  
26 storage building (Entergy 2006g).

27 JAFNPP generates two types of wastewater: sanitary liquid wastes and industrial effluents.  
28 Radioactive liquid waste is addressed in Section 2.1.4. Section 2.2.3 provides more information  
29 on JAFNPP's SPDES permit.

30 JAFNPP operates a sewage treatment plant to treat sanitary wastewater generated by the plant.  
31 The treated water is discharged into a drainage ditch that flows into Lake Ontario and is  
32 regulated as Outfall 012 in the SPDES permit (No. NY-0020109) issued by NYSDEC. Sanitary  
33 sludge from the sewage treatment plant is placed in covered sludge drying beds. The sludge is  
34 removed by a contractor as needed and disposed of at an offsite treatment facility.

35 Industrial effluents are typically combined with cooling water discharges in accordance with  
36 SPDES permit requirements. There are five SPDES-permitted outfalls (Outfalls 001 through  
37 005). Circulating cooling water, service water, intake screen backwash, clarifier blowdown, filter  
38 backwash, clearwell overflow, waste tank discharges, borated water, and emergency diesel



1 generator cooling water are discharged at Outfall 001. Combined storm water and oil-water  
2 separator wastewater are discharged at Outfall 002. Storm water runoff is discharged at  
3 Outfalls 003, 004, and 005. Overflow from the sedimentation containment pond is also  
4 discharged from Outfall 005. JAFNPP's SPDES permit requires specific monitoring and/or  
5 sampling at each of the outfalls.

6 The Emergency Planning and Community Right-to-Know Act (EPCRA) requires applicable  
7 facilities to provide information on hazardous and toxic chemicals to emergency planning  
8 authorities and the EPA. JAFNPP is subject to EPCRA Section 312 reporting and therefore  
9 submits annual reports to local emergency agencies on the following chemicals: carbon dioxide,  
10 diesel fuel, electrohydraulic fluid, fuel oil, gasoline, hydrogen, lube oils, nitrogen, oxygen, resins,  
11 sodium hypochlorite, and transformer oil (Entergy 2006g).

#### 12 *2.1.5.2 Pollution Prevention and Waste Minimization*

13 Currently, JAFNPP has several waste minimization measures in place. JAFNPP recycles  
14 grease from the onsite cafeteria, as well as aluminum, office paper, and used oil. Another  
15 waste minimization measure is the use of shock absorbing concrete (SACON) blocks as  
16 backstops for firing activities at the firing ranges. The SACON blocks capture expended rounds,  
17 preventing potential groundwater or soil lead contamination. The block supplier removes the  
18 spent SACON blocks and recycles them into other concrete products (Entergy 2007a).

19 Entergy has a corporate policy and plan for waste minimization at its nuclear power plants,  
20 including JAFNPP (Entergy 2006b). The plan provides a hierarchy of waste minimization  
21 options that emphasize source reduction, reuse/recycling, treatment to reduce volume and/or  
22 toxicity, and disposal, in that order. A fleet-wide focus group meets to discuss opportunities for  
23 waste minimization and information sharing among the Entergy nuclear facilities. There are  
24 also fleet-wide programs for Waste Management and Chemical Control. It is expected that  
25 Entergy would continue to implement its waste minimization policy and programs during the  
26 license renewal period for JAFNPP. The EPA's Office of Pollution Prevention and Toxics has  
27 established a clearinghouse that provides information regarding management, technical, and  
28 operational approaches to pollution prevention. The EPA's clearinghouse can provide  
29 additional opportunities for waste minimization and pollution prevention at JAFNPP.

#### 30 **2.1.6 Facility Operation and Maintenance**

31 Maintenance activities conducted at JAFNPP include inspection, testing, and surveillance to  
32 maintain the current licensing basis of the facility and to ensure compliance with environmental  
33 and safety requirements. Various programs and activities currently exist at JAFNPP to  
34 maintain, inspect, test, and monitor the performance of facility equipment. These maintenance  
35 activities include inspection requirements for reactor vessel materials, boiler and pressure  
36 vessel in-service inspection and testing, maintenance structures monitoring program, and  
37 maintenance of water chemistry.

1 Additional programs include those implemented to meet technical specification surveillance  
2 requirements, those implemented in response to the U.S. Nuclear Regulatory Commission  
3 (NRC) generic communications, and various periodic maintenance, testing, and inspection  
4 procedures. Certain program activities are performed during the operation of the unit, while  
5 others are performed during scheduled refueling outages. Entergy refuels JAFNPP on a  
6 nominal 24-month interval.

### 7 **2.1.7 Power Transmission System**

8 Two single-circuit, 345-kilovolt (kV) transmission lines, the Edic and Scriba lines, were  
9 constructed to connect JAFNPP to the grid. Both of these lines are owned by NYPA. The Edic  
10 line (Table 2-1) is approximately 70 mi long and was constructed to connect the JAFNPP to the  
11 New York Power Pool transmission grid. This line runs southeasterly from the plant 345-kV  
12 switchyard to the Edic Substation located near Utica, New York (Figure 2-4). NYPA has owned  
13 and operated the transmission line since it was constructed in the early 1970s. A 400-ft wide  
14 right-of-way (ROW) was acquired by NYPA for the Edic 345-kV transmission line although a  
15 width of only 150 ft, totaling 1273 ac, was actually cleared for the line. The remaining ROW was  
16 acquired for the possible construction of future transmission lines. The Edic transmission line  
17 was constructed with steel self-supporting towers spaced about 1200 ft apart. When the ROW  
18 was acquired, about 65 percent of the ROW passed through forests, 29 percent through  
19 agricultural lands, and 6 percent through wetlands. Most of ROW land remains in private  
20 ownership and is used for a variety of compatible purposes.

21 A second single circuit, 345-kV transmission line was also constructed to connect JAFNPP to  
22 the grid. The Scriba line (Table 2-1) is approximately 4900 ft (0.9 mi) in length and runs  
23 southward from the plant's 345-kV switchyard to the National Grid Scriba Substation where it  
24 connects to the 345-kV transmission system.


25 The two 345-kV lines for JAFNPP have transmission capacity in excess of the JAFNPP  
26 generating unit, so either line can be out of service without curtailing the output from the plant.  
27 Both lines exceed the requirements of the National Electric Safety Code for heavy loading  
28 districts, Grade B (Entergy 2006c).

1

**Table 2-1. JAFNPP Transmission Lines, Substations, and Corridors**

Substation	Owner	Number of Lines	kV	Approximate Distance in miles	Corridor Width in feet	Corridor Area in acres	Within Scope of License Renewal
Edic	NYPA	1	345	70	150	1273	Yes
Scriba	NYPA	1	345	0.9	NA	NA	Yes
Lighthouse Hill	National Grid	1	115	26	NA	NA	No
Nine Mile Point Nuclear Station	Constellation	1	115	0.7	NA	NA	No

Source: Entergy 2006c



2

**Figure 2-4. JAFNPP Transmission Lines**

3

1

2 In addition to the two 345-kV transmission lines for power distribution, offsite power is provided  
3 to JAFNPP by two single-circuit 115-kV transmission lines connected to the plant's 115-kV bus.  
4 One 115-kV line (Table 2-1) runs southward from the site and connects to the National Grid  
5 115-kV transmission line that extends to the Lighthouse Hill Hydroelectric Station located about  
6 26 mi east of JAFNPP. In addition to being a hydroelectric generating station and an integral  
7 part of the National Grid 115-kV system, the Lighthouse Hill facility also serves as the  
8 switchyard for several other hydroelectric facilities in the area. The other JAFNPP 115-kV line  
9 (Table 2-1) is approximately 3700 ft in length and is connected to the 115-kV bus at  
10 Constellation Nuclear Nine Mile Point Nuclear Station. The 115-kV bus at Constellation Nuclear  
11 Nine Mile Point Nuclear Station Unit 1 is also connected via a 115-kV transmission line to the  
12 South Oswego Substation (Entergy 2006c).

13 Ownership of the four JAFNPP transmission lines is as follows: (1) Edic Substation 345-kV  
14 transmission line: from 345-kV switchyard to approximately the site property line, JAFNPP owns  
15 the line; from the JAFNPP property line to the Edic Substation, NYPA owns the line; (2) Scriba  
16 Substation 345-kV transmission line: from 345-kV switchyard to approximately the site property  
17 line, JAFNPP owns the line; from the JAFNPP property line to the Scriba Substation, NYPA  
18 owns the line; (3) Lighthouse Hill Hydroelectric Station 115-kV transmission line: from 115-kV  
19 Switchyard to approximately the site property line, JAFNPP owns the line; from the JAFNPP  
20 property line to the Lighthouse Hill Hydroelectric Station, National Grid owns the line; and (4)  
21 Constellation Nuclear Nine Mile Point Nuclear Station 115-kV transmission line: from 115-kV  
22 switchyard to approximately the site property line, JAFNPP owns the line; from the JAFNPP  
23 property line to the Constellation Nuclear Nine Mile Point Nuclear Station 115-kV bus,  
24 Constellation Nuclear Nine Mile Point Nuclear Station owns the line.

25 For the two 345-kV transmission line ROWs, NYPA uses a vegetation management plan  
26 approved by the New York State Public Service Commission. NYPA uses an integrated  
27 vegetation management computer application, which employs geographic information system  
28 technology. The vegetation management program is designed to control tall-growing tree  
29 species and to enhance the abundance of lower-growing desirable vegetation. Field inventories  
30 are conducted annually for the ROW scheduled for clearing the following year. Inventories and  
31 treatment recommendations are reviewed and approved by the NYPA forestry staff. The  
32 majority of clearing is performed using mechanical methods. Herbicide applications are applied  
33 to selected plant species by licensed contractors, and a safe buffer is maintained around  
34 wetlands, and stream and river crossings. A safe buffer is also used around wells and springs  
35 that are used for residential water supplies. Areas where herbicides are used are posted with  
36 information regarding the chemicals that were used and when they were applied. Herbicides  
37 are not applied on NYPA ROWs using aerial application methods (Entergy 2006c).

## 1 **2.2 Facility Interaction with the Environment**

2 Sections 2.2.1 through 2.2.8 provide general descriptions of the environment near JAFNPP as  
3 background information. They also provide detailed descriptions where needed to support the  
4 analysis of potential environmental impacts of refurbishment and operation during the renewal  
5 term, as discussed in Chapters 3 and 4. Section 2.2.9 describes the historic and archaeological  
6 resources in the area, and Section 2.2.10 describes possible impacts associated with other  
7 Federal project activities.

### 8 **2.2.1 Land Use**

9 JAFNPP is located in an unincorporated and primarily rural area approximately seven mi  
10 northeast of Oswego, New York. Syracuse is the largest city within 50 mi of JAFNPP. Lake  
11 Road (County Road 1A) provides road access to the site and transverses JAFNPP property in  
12 an east-west direction just south of the plant. Exclusion distances for the JAFNPP site are  
13 approximately 3000 ft to the east, over 1 mi to the west, and about 1.5 mi to the southern site  
14 boundary. The nearest location with public access to the reactor building and any points of  
15 potential gaseous effluents, with the exception of the lake shoreline, are at the northeast corner  
16 of the property. The nearest residence lies outside the site boundary to the east-southeast at  
17 0.71 miles (Entergy 2006c). See Figure 2-2.

18 JAFNPP features include the reactor building, turbine building, administration building and  
19 control room, ISFSI, and several support facilities. The most prominent feature on the site is the  
20 off-gas stack, which is 385 ft high. Only 3 percent of the site is occupied by JAFNPP structures,  
21 with the remainder consisting of forest shrub, grasslands, and wetlands or ponds (Entergy  
22 2006c). See Figure 2-3.

23 The site lies mainly within the Erie-Ontario Lowlands physiographic province. This province  
24 consists of a relatively flat plain that rises gently from Lake Ontario to the Appalachian Uplands,  
25 which form the province's southern border. Erie-Ontario Lowlands are bounded on the east by  
26 Tug Hill Upland, through which small portions of the transmission line pass. The site is a  
27 generally flat and featureless plain. It has an elevation of 270 ft rising to 310 ft 1 mi away at the  
28 southern extremity. The surface soils are derived from bouldery-ablation tills that immediately  
29 overlay a compact basal till lying on bedrock (AEC 1973).

### 30 **2.2.2 Water Use**

31 Water use associated with the operation of JAFNPP consists of fresh water drawn from Lake  
32 Ontario used primarily for cooling. Water from Lake Ontario is used for the cooling and auxiliary  
33 systems. JAFNPP receives its potable water from the City of Oswego. JAFNPP is not a direct  
34 user of groundwater, and there are no plans for direct groundwater use in the future. There are  
35 no production wells onsite (Entergy 2006c).

1 **2.2.3 Water Quality**

2 JAFNPP is located on the southeastern shore of Lake Ontario, which is the furthest downstream  
3 and smallest of all the Great Lakes, having a surface area of 7340 square miles. It is an  
4 international body of water with the border of the United States and Canada being  
5 approximately midway across the width of the lake. It has an average depth of 283 ft with a  
6 maximum depth of 802 ft (EPA 2006d).

7 The combination of prevailing west-northwest winds over the lake area and the eastern flow of  
8 water from Lake Erie results in the lake being dominated by a counterclockwise horizontal  
9 circulation pattern. Although winds can play a major role in affecting localized lake water flow  
10 patterns, currents on the southern shore of the lake often move in an easterly direction in a  
11 relatively narrow band. Because Lake Ontario is the furthest downstream of all the Great  
12 Lakes, its water quality is influenced not only by human activities on its own shores, but by  
13 impacts on all the other Great Lakes as well. Approximately 80 percent of the influx of water to  
14 Lake Ontario comes directly from Lake Erie via the Niagara River. The remaining 20 percent of  
15 the influx comes from basin tributaries, groundwater and precipitation. Approximately  
16 93 percent of Lake Ontario's water flows out through the St. Lawrence River with the remaining  
17 7 percent being lost to evaporative processes. The estimated water retention time is 6 years  
18 (EPA 2006d).

19 Changes in wind speed and direction on Lake Ontario can also contribute to vertical mixing of  
20 lake water. Strong winds can cause upwelling and sudden oscillations of thermocline depth.  
21 Strong easterly winds along the east-west axis of Lake Ontario will cause a surface drift to the  
22 right, which can result in tilting of the thermocline. When the tilted thermocline is pushed along  
23 the nearshore zone it can become so intense that an outbreak of cold hypolimnion water will  
24 upwell to the surface in the nearshore environment and create a steep temperature gradient in  
25 the lake center. An increase in longshore current velocity can be associated with these events  
26 as well, increasing the dispersion of both pollutants and nutrients from the lake bottom along the  
27 shore (EC 2000).

28 Both meteorological and hydrological processes are responsible for a seasonal thermal  
29 response on the lake. Incoming solar radiation heats the surface waters of the lake, more so in  
30 the summer, while changes in wind speed and direction aid in the mixing of these heated waters  
31 to lower depths in the lake. The mean summer ambient temperature of Lake Ontario in the Nine  
32 Mile Point area is approximately 67° Fahrenheit (F). Most of the lake is vertically stratified  
33 during the summer (June through September) with warm surface waters (epilimnion) averaging  
34 nearly 70°F and cool deeper waters (hypolimnion) ranging between 38.8 and 39.2°F. Mixing of  
35 these strata begins as the thermocline breaks down during September as a result of surface  
36 water cooling and continues until water temperatures are the same throughout the water column  
37 (EC 2000). The date of this overturn varies annually due to short term weather patterns and  
38 storms. The isotherms following the overturn tend to be parallel to the shore resulting in a  
39 freezing of nearshore waters with the deeper offshore waters remaining open.

1 Lake Ontario outflows, and thus lake water levels, are controlled by a series of dams on the  
2 St. Lawrence River under the authority of the International St. Lawrence River Board of Control  
3 (ISLRBC). The ISLRBC requires that Lake Ontario water levels be maintained within a target  
4 range of 243 to 247 ft International Great Lakes Datum to support lake navigation and to provide  
5 water for power production facilities on the lake. The target level of 243 ft is maintained from  
6 April through November when lake water evaporation rates would be highest and the  
7 St. Lawrence River is likely close to low-flow conditions (ISLRBC 2004).

8 Once an oligotrophic system, by 1970 Lake Ontario was almost entirely eutrophic, caused by  
9 high levels of anthropogenic nutrients (primarily phosphorous) and uncontrolled pollutant  
10 discharge to the lake. The eutrophication of Lake Ontario was recognized as a serious water  
11 quality problem by the U.S. and Canada and led to the creation of the bi-national Great Lakes  
12 Water Quality Agreement (GLWQA) in 1972. Since then the lake has seen dramatic  
13 improvement in water quality. Much of this improvement can be attributed to stricter controls on  
14 land use in the Lake Ontario basin and lake-wide management plans sponsored by the GLWQA  
15 that reduced levels of non-point source pollution entering the lake. However, changes in lake  
16 water quality since the 1970s have altered the biological landscape within Lake Ontario.  
17 Nutrient supplies and other environmental pressures have had direct effects on all trophic levels  
18 within the lake ecosystem (Stewart et al. 1999).

19 The New York State Department of Environmental Conservation (NYSDEC) conducted a study  
20 of water quality throughout New York State over the past 30 years, including selected basic  
21 water quality parameters of Lake Ontario; this information is summarized in Table 2-2. Data  
22 was collected in the Nine Mile Point area in 1972 and 1978, the City of Oswego water intake  
23 (approximately 8 mi southwest of JAFNPP) in 1998 and 1999, and at the Monroe County water  
24 intake (approximately 50 mi west of JAFNPP) in 2000 (NYSDEC 2000b).

25 Today, the largest source of pollutants and nutrients (including phosphorous and nitrogen)  
26 entering Lake Ontario is through the Niagara River, which drains Lake Erie. As in the past,  
27 additional nutrients also still enter the lake through runoff from agricultural lands, urban areas,  
28 sewage outflows, and erosional processes. The NYSDEC water quality study indicated that  
29 although over the past 30 years there have been general reductions in some pollutants, such as  
30 phosphorous and dissolved solids, nitrogen inputs to Lake Ontario have increased. Runoff from  
31 agricultural lands and atmospheric deposition are likely significant contributors to lake nitrogen  
32 levels.

33 In another bi-national effort, in 1989 the U.S. and Canada developed the Lake Ontario Toxics  
34 Management Plan. The plan addressed persistent bioaccumulative and toxic chemicals (PBTs),  
35 which include mirex, polychlorinated biphenyls (PCBs) and dioxins (NYSDEC 2000b). PBTs  
36 enter Lake Ontario through various tributaries and have historically accumulated in sediments at  
37 the bottom of the lake. Several portions of Lake Ontario's New York shoreline are classified by  
38 the NYSDEC as "impaired," requiring total maximum daily load (TMDL) development in order to  
39 reduce the input of the specific pollutants (NYSDEC 2006g). Some Lake Ontario biota saw

1 reductions in toxic chemical concentrations from the 1960s through the 1980s that were  
 2 generally attributed to restrictions placed on the manufacture and use of PBTs, but those  
 3 declines have since leveled off. This may be due in part to the sequestration of chemicals in the  
 4 benthic lake sediments. Consumption advisories for certain lake fish species continue to be  
 5 issued by NYSDEC based on PBT levels found in some fish samples (NYSDEC 2000b).

6 **Table 2-2. Selected Water Quality Parameters of Lake Ontario**

Parameter	Year			
	1972 <sup>(a)</sup>	1978 <sup>(b)</sup>	1998-99 <sup>(c)</sup>	2000 <sup>(e)</sup>
pH	8.0	8.4	7.96	7.6
Total alkalinity (mg/L)	72–90	94.2	92	83
Total phosphorus (mg/L)	0.01–0.28	0.027	0.006 <sup>(d)</sup>	0.005 <sup>(d)</sup>
Total dissolved solids (mg/L)	107–186	202	NA	160
Total nitrates (mg/L)	0.04–0.40	< 0.18	NA	0.34
Turbidity	2–6 JTU	3.0 NTU	0.5 NTU	0.09 NTU

mg/L = milligram(s) per liter

(a) Source: AEC 1974

JTU = Jackson Turbidity Unit(s)

(b) Source: NMPC 1985

NTU = Nephelometric Turbidity Unit(s)

(c) Source (except total phosphorus): Heritage Power 2000

(d) Source: EPA 2005

(e) Source (except total phosphorus): MCWA 2001; pH and alkalinity data are from water distribution system and not from ambient lake water

7

8 JAFNPP uses a Betz Clam-Trol CT-1 (a chlorine-based molluscicide) program within their  
 9 service and cooling water systems to control zebra mussels (*Dreissena polymorpha*) and  
 10 quagga mussels (*D. bugensis*). The site-specific SPDES permit limits the administration of the  
 11 molluscicide program to a maximum of four times per year and includes special conditions for  
 12 outfall monitoring during applications and strict discharge limitations (Entergy 2006c). Biofouling  
 13 control at JAFNPP is achieved through the application of sodium hypochlorite in the service  
 14 water system and the condenser waterboxes. Sodium hypochlorite injection occurs  
 15 continuously, but at a concentration and volume that does not result in the exceedance of the  
 16 SPDES limit of 0.2 parts per million (ppm) total residual chlorine (TRC), as measured in the  
 17 discharge canal. Waterbox chlorination is limited to two hours per day, not to exceed a total of  
 18 nine hours per week, and during daytime hours only when ichthyoplankton entrainment levels  
 19 are historically low. The JAFNPP SPDES permit also prescribes a waterbox chlorination  
 20 limitation of 0.2 ppm TRC (Entergy 2006a).



1 Treated effluent from the sanitary waste water treatment system is regulated as Outfall 012  
2 before discharging into a drainage ditch that flows into Lake Ontario. The effluent is monitored  
3 for flow, biochemical oxygen demand, suspended solids, settleable solids, fecal coliform, pH, and  
4 total residual chlorine. Maximum permitted flow is 60,000 gpd as a 30-day average. During  
5 2006, daily flow ranged from 400 to 25,000 gpd (Entergy 2006c).

6 JAFNPP operates in accordance with applicable local, State, and Federal discharge limitations  
7 (Entergy 2006c). The NRC staff review of the past five years of JAFNPP SPDES reports found  
8 no notices of violation.

9 Groundwater is available in the Nine Mile Point area from both confined and unconfined  
10 aquifers. There are four hydrostratigraphic units in existence within the JAFNPP site area: non-  
11 lithified sediments and soils, the Oswego Sandstone, the Pulaski Formation and the Whetstone  
12 Gulf Formation, in descending order. The unconfined aquifer is composed of clay-rich soils  
13 derived from glacial till and the uppermost portion of the Oswego Sandstone. Due to the  
14 increase of interbedded silts and clays within the Oswego Sandstone at depth, the sandstone  
15 becomes relatively impermeable at 20 ft. The first confined aquifer lies in both the lower portion  
16 of the Oswego sandstone and uppermost portion of the Pulaski Formation, which is composed  
17 of sandstone, siltstone and shale. An additional confined aquifer lies within the Pulaski  
18 Formation at depth within a sandstone unit bounded by siltstone and shale. The underlying  
19 Whetstone Gulf Formation has a low permeability as it is dominated by black shales with  
20 interbedded sandstone and siltstones. All three aquifers are confined under pressure and would  
21 result in artesian wells if utilized at the surface.

22 Within a two mile radius of JAFNPP, the local water table elevation varies from 300 to 246 ft  
23 National Geodetic Vertical Datum with an average gradient of 0.7 percent to the north-northwest  
24 (toward Lake Ontario). The normal groundwater level within the site boundary is approximately  
25 255 ft and can have annual variations of up to 2 ft.

26 Groundwater recharge in this area occurs as a result of precipitation and localized seepage  
27 from ponds and swamps through the surface soils into the unconfined aquifer. Due to the low  
28 permeability of the clay-rich soils in the immediate vicinity of the site, most of the precipitation  
29 runs off toward surface culverts or directly toward Lake Ontario. Groundwater recharge to the  
30 Oswego Sandstone most commonly occurs through filtration of water through the unsaturated  
31 zone of the unconfined aquifer and can also occur directly through local outcrops located to the  
32 south and southeast of JAFNPP. Recharge to the lower confined aquifers occurs through  
33 fractures in the Oswego Sandstone or directly through surface outcrops upgradient of the site.  
34 Due to a permeability of  $1 \times 10^{-5}$  cm/s and an average gradient of 0.7 percent, groundwater  
35 velocity within the unconfined aquifer is estimated at a few yards per year.

1 **2.2.4 Climate, Meteorology, and Air Quality**

2 *2.2.4.1 Climate*

3 The climate of western New York State is representative of the humid continental type, warm  
4 summer subtype. The climate is designated Dfb in the Koeppen system and is sometimes  
5 referred to as hemiboreal. Typical of the Dfb climate zone, weather changes between summer  
6 and winter are very large around the JAFNPP site with cold, snowy winters and long, warm (not  
7 hot) summers. Latitude, topography, and proximity to large bodies of water such as Lake  
8 Ontario have a profound effect on the climate and short-term weather.

9 JAFNPP's proximity to Lake Ontario makes it subject to locally extreme amounts of precipitation  
10 in the winter. This phenomenon, called "lake effect snow," is produced when cold arctic air  
11 crosses the warmer lake, absorbing water vapor, which then falls as precipitation on the  
12 adjacent shore. The elevated areas south and east of JAFNPP frequently set daily records for  
13 snowfall in the United States because the lake effect snow is enhanced by orographic uplift.

14 The following climatological data is based on 30 years of observations (from 1971 to 2000) from  
15 the nearest National Oceanic and Atmospheric Administration (NOAA) station in Oswego, New  
16 York (NOAA 2004a). Average minimum temperature in January was 16.7°F, and average  
17 maximum temperature in July was 80.0°F. Month-long average temperatures ranged from  
18 23.6°F in January to 70.8°F in July. Average monthly precipitation ranged from 2.83 in. in  
19 February to 4.47 in. in November. Average annual precipitation was 42.9 in. Precipitation  
20 occurred almost uniformly throughout the year, caused by advancing polar fronts in the winter  
21 and advection of tropical moisture in the summer.

22 *2.2.4.2 Meteorology*

23 Meteorological measurements for JAFNPP are collected nearby at the Nine Mile Point Nuclear  
24 Station through an agreement between the two managing companies (Entergy and  
25 Constellation Nuclear, respectively). Measurements are made from a 200-ft main tower and  
26 also at a nearby shorter tower (approximately 100 ft). At the main tower, winds and temperature  
27 are measured at three levels—at 30, 100, and 200 ft. The Nine Mile Point meteorological  
28 system determines atmospheric stability by using the EPA-approved Delta-T method. More  
29 information on the main tower and the data collected there is in the Nine Mile Point  
30 Environmental Impact Statement(NRC 2006, Section 2.2.4).

31 Severe thunderstorms with winds exceeding 58 mph and/or property damage occur an average  
32 of five days per year in Oswego County (2001 through 2006) (NOAA 2004b). Since 1950, eight  
33 tornadoes have been reported in Oswego County (NOAA 2004b). The strongest tornado

1 reached F3<sup>(1)</sup> strength near the town of Phoenix on May 2, 1983, and resulted in no injuries.  
2 The other seven tornadoes were categorized as F1 or lower. One of these struck a mobile  
3 home, resulting in minor injuries to three people. The probability of a tornado striking JAFNPP  
4 is estimated to be  $3 \times 10^{-3}$  in a reactor's licensing period of 40 years (Entergy 2001).

5 Wind resources are expressed in terms of wind power classes ranging from Class 1 to Class 7.  
6 Each class represents a range of mean wind power density or approximate mean wind speed at  
7 specified heights above the ground. The wind energy resource for most of the Lake Ontario  
8 shoreline of Oswego County is rated between Class 3 and 4 (Renewable Resource Data Center  
9 2004, Figure 3-25). Areas designated as Class 3 or greater are suitable for most wind energy  
10 applications.

#### 11 2.2.4.3 Air Quality

12 JAFNPP is located in Oswego County which is part of the Central Air Quality Control Region 7  
13 of the New York State Department of Environmental Conservation. With the exception of  
14 ozone, Region 7 is designated as being in attainment of or as unclassifiable for all criteria  
15 pollutants, as defined in 40 CFR 81.333. Jefferson County, northeast of Oswego County, is  
16 designated as a nonattainment area for ozone and classified as moderate for the 8-hour ozone  
17 National Ambient Air Quality Standards and marginal for the 1-hour. The Clean Air Act  
18 established Class 1 Federal Areas where visibility is important. No areas designated as  
19 Prevention of Significant Deterioration Class I are within 62 mi of JAFNPP.

20 There are four emergency diesel generators, two diesel fire pumps, and two auxiliary boilers on  
21 the JAFNPP site. The emergency generators and fire pumps are exempt from air permitting  
22 due to the small size and limited usage of these units. Emission from the boilers is regulated  
23 under a Certificate to Operate an Air Contamination Source (7-3556-00020/00012) issued by  
24 NYSDEC. This certificate limits fuel usage, fuel type, and hours of operation of the boilers.

#### 25 2.2.5 Aquatic Resources

26 Lake Ontario is the source of water for the circulating and service water system at JAFNPP.  
27 Station discharge from both the main condenser and service water system is returned to the  
28 lake. Site drainage includes two offsite ditches on either side of the plant and two onsite storm  
29 sewer outfalls; all ditches and outfalls discharge to Lake Ontario and are regulated under the  
30 plant's SPDES permit (Entergy 2006c). There are no natural watercourses onsite. Associated  
31 transmission corridors cross 60 watercourses of which seven are classified by the New York  
32 State Water Resources Commission as suitable for water supplies and 27 for agriculture and  
33 industry (AEC 1973).

---

(1) The Fujita six-point scale (F0 to F5) is used to rate the intensity of a tornado based on the damage it inflicts to structures and vegetation. Lowest intensity is F0; highest is F5.

1 Lake Ontario, the source and the receiving water body for JAFNPP, is last in the chain of Great  
2 Lakes. It is the smallest of the five Great Lakes and with a watershed of 24,720 mi<sup>2</sup>, Lake  
3 Ontario has the highest ratio of watershed land area to lake surface area of all the Great Lakes  
4 (EPA 2006a). The lake's drainage basin is almost evenly split between the province of Ontario  
5 and the state of New York. Approximately 7 percent of the drainage basin is urbanized: major  
6 industrial centers on the lake shore include Hamilton and Toronto in Ontario and Rochester in  
7 New York. Although not categorized as urban, the Syracuse-Oswego area in New York is  
8 relatively densely populated. Forests cover about 49 percent of the basin, with agriculture  
9 practiced over approximately 39 percent. In general, the New York shoreline is less urbanized  
10 than the Canadian shoreline and is not intensively farmed (Stewart et al. 1999).

11 Shipping is a major activity on Lake Ontario and has encouraged the development of  
12 manufacturing industry and port cities. The Port of Oswego, approximately 6 mi west of  
13 JAFNPP, had an overall annual tonnage of 457,770 in 2002. The port has a main channel  
14 depth of 27 ft, and its primary cargoes include aluminum, potash, urea, limestone, salt, cement,  
15 and petroleum products (GLSLSS 2006). Lake Ontario also supports a minor commercial  
16 fishing industry, grossing just \$46,000 in 2004. Recreational fishing is much more important to  
17 the Lake Ontario area, with the total economic value to coastal communities estimated to range  
18 from \$100 million to more than \$200 million per year (EPA 2006c).

19 Lake Ontario has two major basins: Kingston Basin, which is shallow and in the northeastern  
20 corner of the lake, and a deeper main basin that covers the majority of the lake. The bottom of  
21 Lake Ontario is relatively smooth with the exception of the sill that separates the Kingston and  
22 main basins. The main basin is further split into three sub-basins: Rochester, Mississauga, and  
23 Niagara (from east to west). With the majority of the lake's water coming in from the Niagara  
24 River and the prevailing west-southwest winds, circulation in Lake Ontario flows in an easterly  
25 direction along the southern and eastern shores and within sub-basins of the lake (EPA 2006b).

26 Being a relatively deep lake, Lake Ontario experiences seasonally dependent horizontal and  
27 vertical thermal stratification. Stratification occurs when different water temperatures create  
28 different water densities, which prevents mixing. Horizontal stratification occurs in the main  
29 basin between near-shore and offshore zones and lasts from mid-autumn until approximately  
30 mid-June when offshore waters finally warm and mixing can occur. For the remainder of the  
31 summer, main basin waters are vertically stratified, meaning that warm surface waters do not  
32 mix with cool, deeper waters. The vertical stratification begins to break down during September  
33 when surface waters begin to cool and slowly sink and mix with deeper waters. Mixing  
34 continues until an isothermal condition prevails throughout the winter (EPA 2006b). During the  
35 winter months, inshore areas of Lake Ontario freeze, but of all the Great Lakes, Lake Ontario  
36 has the least amount of ice cover, with typically 85 percent of the lake ice-free throughout the  
37 winter. In general, waters are warmer in the southeastern portion of the lake and cooler in the  
38 northwestern portion. Lake water temperatures typically range from 32 to 39.2°F in January and  
39 from 53.6 to 68°F in July (PC 2006).

1 Lake Ontario is oligotrophic with low primary productivity—roughly half that of Lake Erie. Lake  
2 water clarity ranges from 16.4 to 32.8 ft. Over the years, the trophic status of Lake Ontario has  
3 continually been influenced by human activities, including point-source pollution from industry  
4 and waste disposal and non-point source pollution from agriculture and urban development.  
5 The lake is affected not only by its drainage basin but also by being the most downstream Great  
6 Lake. Thus, pollution sources in the upper Great Lakes impact Lake Ontario as well (EPA  
7 2006b).

8 Since the first Euro-Americans arrived in the Great Lakes area, Lake Ontario has experienced  
9 ecological stress that included overfishing, anthropogenic eutrophication, land-use changes,  
10 contaminant discharge, loss and degradation of critical habitat, colonization of invasive species,  
11 and substantial declines and profound changes in fish communities (NYSDEC 2004).

12 Lake Ontario was an oligotrophic system prior to European colonization of the Great Lakes  
13 area. However, with increasing industrial development on the northern shore of the lake and  
14 the subsequent increase in nutrient inputs (anthropogenic sources of phosphorous and  
15 nitrogen), the lake experienced excess algal growth and became mesotrophic with inshore  
16 areas becoming eutrophic. Phosphorous levels peaked in the 1960s and 1970s until water  
17 pollution controls were implemented throughout the Great Lakes. Since then, nutrient levels in  
18 the lake have declined, and the lake has returned to a more balanced oligotrophic state (Mills et  
19 al. 2005; EPA 2006b).

20 Although water quality has improved over the last 20 years in response to lake-wide  
21 management plans, the Lake Ontario ecosystem is still very much in transition. NYSDEC and  
22 the Ontario Ministry of Natural Resources (OMNR) annually stock the lake with salmonids to  
23 support a lucrative sport fishery. Non-native fish populations such as the alewife (*Alosa*  
24 *pseudoharengus*) are highly dynamic with large fluctuations in population from year to year, and  
25 pelagic zooplankton production is continually declining. Oligotrophic fish populations are slowly  
26 recovering, and invasive species such as quagga mussels (*Dreissena bugensis*) and the  
27 cladoceran waterflea (*Cercopagis pengoi*) are thriving (NYSDEC 2004; OMNR 2006).

28 There have been a series of milestones in the management of Lake Ontario. In 1955, the  
29 Canadian/U.S Convention on Great Lakes Fisheries created the Great Lakes Fishery  
30 Commission (GLFC). The GLFC is a bi-national cooperative agency that coordinates fisheries  
31 research and facilitates cooperative fishery management among the state, provincial, tribal, and  
32 federal agencies. The GLFC is responsible for implementing the *Joint Strategic Plan for*  
33 *Management of Great Lakes Fisheries* (GLFC 1994). Eight states bordering the Great Lakes,  
34 the Province of Ontario, two intertribal agencies, and several federal agencies are signatory to  
35 this management plan, working together and leveraging each others' resources to rehabilitate  
36 native lake species, control exotic species, prevent and manage fishery diseases, coordinate  
37 law enforcement, produce new research, publish state-of-the-lake reports, and determine total  
38 allowable catch and allocation agreements and fish stocking levels (GLFC 2006).

## Plant and the Environment

1 The GLFC also funded the 1971 Salmonid Communities in Oligotrophic Lakes (SCOL-1)  
2 symposium, which examined the effects of cultural eutrophication, exploitation, and exotic  
3 species introduction on salmonid communities in the five Great Lakes. In 2004, these issues  
4 were revisited in a second symposium (SCOL-2) with an emphasis on linkages between trophic  
5 levels (GLFC 2007).

6 In 1972, the first Great Lakes Water Quality Agreement (GLWQA) was signed between the  
7 International Joint Commission (IJC) of Canada and the United States. Both countries pledged  
8 to address the deterioration of Great Lakes water quality from point source and non-point  
9 source pollution. A new GLWQA was signed in 1978 that outlined a commitment to restoring  
10 and maintaining the “chemical, physical, and biological integrity” of the Great Lakes. In 1987,  
11 the IJC drafted a protocol that focused on the overall human and aquatic ecosystem health of  
12 the Great Lakes. Remedial action plans and lake-wide management plans were developed that  
13 implemented an ecosystem approach to improving the Great Lakes waters. The plans are  
14 designed to work in concert with local resource management plans, such as those that address  
15 a specific fishery (IJC 2004).

16 Close to JAFNPP, the Little Salmon and Oswego rivers are two of the ten major tributaries that  
17 feed Lake Ontario. Both rivers have been designated by the NYSDOS Division of Coastal  
18 Resources as “Significant Coastal Fish and Wildlife Habitats.” Little Salmon River empties into  
19 Lake Ontario at Mexico Point near the town of Mexico, approximately 10 mi east of JAFNPP.  
20 The river provides an important fish spawning and nursery area and supports large  
21 concentrations of warmwater species including northern pike (*Esox lucius*), largemouth bass  
22 (*Micropterus salmoides*), rock bass (*Ambloplites rupestris*), white sucker (*Catostomus*  
23 *commersonii*), and brown bullhead (*Ameiurus nebulosus*). Little Salmon River is one of the  
24 primary salmonid habitats in eastern Lake Ontario. As a result of NYSDEC’s ongoing sport  
25 fishery stocking program, Chinook salmon (*Oncorhynchus tshawytscha*), coho salmon  
26 (*Oncorhynchus kisutch*), brown trout (*Salmo trutta*), and steelhead trout (*Oncorhynchus*  
27 *mykiss*) can also be found in Little Salmon River during spawning periods (NYSDOS 2006).

28 The Oswego River is located in the city of Oswego, approximately 4 mi west of JAFNPP. Land  
29 along this river has been impacted by extensive human disturbance, including a number of locks  
30 and dams that impede or act as barriers to fish migrating upriver to spawn. However, the river  
31 is still an important habitat for warmwater fish species including alewife, gizzard shad (*Dorsoma*  
32 *cepedianum*), brown bullhead, white perch (*Morone americana*), yellow perch (*Perca*  
33 *flavescens*), smallmouth bass (*Micropterus dolomieu*), largemouth bass, walleye (*Sander*  
34 *vitreus*), pumpkinseed (*Lepomis gibbosus*), and black crappie (*Pomoxis nigromaculatus*). The  
35 river is the primary spawning and nursery area for walleye in the Oswego County area, and in  
36 1982, lake sturgeon (*Acipenser fulvescens*) were also spotted in the river, making it the only  
37 Lake Ontario tributary that historically supported this species. Stocked salmonids also attempt  
38 to use this river for spawning (NYSDOS 2006).

1 Lake Ontario offshore waters have been dominated historically by lake trout (*Salvelinus*  
2 *namaycush*), Atlantic salmon (*Salmo salar*), deepwater sculpin (*Myoxocephalus thompsoni*),  
3 coregonids (*Coregonus* spp.), and burbot (*Lota lota*). By the 1970s, Lake Ontario's major native  
4 fish stocks were near extinction as a result of cumulative ecological stressors including  
5 overfishing, anthropogenic eutrophication, industrial pollution, degradation and loss of habitat,  
6 and colonization of invasive species.

7 The external parasite, sea lamprey (*Petromyzon marinus*), was also seriously impacting fish  
8 populations. Populations of the sea lamprey, an invasive species, sharply increased in the early  
9 1900s, coincident with high numbers of lake trout. It is believed that commercial fishing and sea  
10 lampreys acted together to drive large piscivores in Lake Ontario to near extinction (Mills et al.  
11 2005). Atlantic salmon, deepwater sculpin, lake trout, burbot, and coregonids all but  
12 disappeared, while non-native fish such as alewife, rainbow smelt (*Osmerus mordax*), and white  
13 perch proliferated. Alewife, a planktivore fish that is prey for large piscivores, first appeared in  
14 Lake Ontario by the late 1800s, and in the absence of abundant piscivores, the alewife  
15 population exploded. Rainbow smelt experienced significant increases around the same time  
16 and were implicated in the decline of native cisco (*Coregonus artedii*) populations (Jackson  
17 1997).

18 In 1968, the first year of what were to become annual releases, brown trout, Chinook salmon,  
19 coho salmon, and steelhead trout were stocked to reduce alewife populations and create a sport  
20 fishery. Between 1968 and the late 1980s, salmonid stocking rates rose steadily to more than 8  
21 million individuals per year. Concurrently, water conditions were improving and Lake Ontario  
22 returned to an oligotrophic system, but by 1990, the high rates of salmonid stocking and the low  
23 lake nutrient levels were affecting the Lake Ontario food web—including decreases in the size of  
24 salmon returning to spawn and reduced angler harvest rates, likely due to a reduction in prey.  
25 Current combined NYSDEC and OMNR salmonid stocking rates have been maintained  
26 between 4.0 and 5.5 million individuals per year. Improvements in habitat and water quality  
27 have resulted in the decline of Lake Ontario's carrying capacity at all levels. Food web studies  
28 of the lower trophic levels conducted in the 1980s and 1990s indicated declines in algal  
29 abundance (phytoplankton) and zooplankton biomass and production. Because phytoplankton  
30 and zooplankton rely on the very nutrients that impact water quality, the effect of nutrient  
31 reductions extends into the food web (Jackson 1997; Mills et al. 2003).

32 Currently, growth of stocked salmonids is sustained primarily by alewife populations and to a  
33 lesser degree by rainbow smelt and slimy sculpin (*Cottus cognatus*). Salmonid predation has  
34 been so excessive that the present alewife population has been reduced almost entirely to pre-  
35 reproductive individuals: from the early 1980s to the 1990s, the alewife population declined  
36 42 percent (Jackson 1997). Alewives are the primary planktivores in Lake Ontario, and  
37 historically, intense feeding pressure on large plankton species by the alewife population has  
38 selected for smaller species. The precipitous alewife population decline has subsequently  
39 changed the Lake Ontario plankton community—there has been a shift from smaller to larger  
40 zooplankton species. Zooplankton have an intermediate position in the Lake Ontario food web

1 and are an important link between phytoplankton and fish. Larger zooplanktons also feed on  
2 smaller zooplankton species, and the presence of large zooplankton therefore competes with  
3 other invertebrates and fish for smaller zooplankton prey (NYSDEC 2004).

4 The lower food web declines in Lake Ontario were likely exacerbated by the new presence of  
5 exotic (invasive) species. By the 1990s, exotic species, including the zebra mussel; the quagga  
6 mussel; the amphipod *Echinogammarus ischmus*, a non-native cladoceran; the round goby  
7 (*Neogobius melanostomus*); and the bloody red shrimp (*Hemimysis anomala*) had been  
8 introduced to the Great Lakes via transoceanic shipping. Through their efficient phytoplankton  
9 grazing and ability to cover any available substrate quickly and entirely, zebra and quagga  
10 mussels significantly increased water clarity throughout the 1990s, causing profound impacts  
11 throughout the food web. Historically, the native amphipod *Diporeia* spp. accounted for 60 to 80  
12 percent of Lake Ontario's benthic community. However, the spread of dreissenid mussels  
13 altered Lake Ontario's benthic habitat. *Diporeia* spp. declined after dreissenid introduction,  
14 impacting bottom fish species including native lake whitefish (*Coregonus clupeaformis*) (Mills et  
15 al. 2003). More recent benthic studies indicate that quagga mussels have largely replaced  
16 zebra mussels in all benthic habitats of Lake Ontario; this transition may have occurred due to  
17 round goby predation on zebra mussels. Since first appearing in Lake Ontario in 1998, the  
18 round goby, an aggressive, bottom-dwelling fish, has established itself in Lake Ontario and is  
19 expected to trigger further changes in the benthic community. Additionally, where round gobies  
20 have become abundant, numbers of native bottom-dwelling fish have declined, such as  
21 tessellated darters (*Etheostoma olmstedii*) and sculpins (*Cottidae* spp.) (Stewart et al. 1999).  
22 Despite other improvements in the Lake Ontario ecosystem, the unintentional introduction of  
23 non-native species to the benthic, planktonic and fish communities will likely prevent Lake  
24 Ontario from ever returning to its original state.

25 The reduction in available nutrients combined with the increased penetration of light and  
26 extended, seasonal, warm water periods, has also resulted in the return and increased growth  
27 of submerged aquatic vegetation, primarily filamentous *Cladophora* spp. The vegetation  
28 coverage provides protection and nursery areas for a number of invertebrate and fish species  
29 (NYSDEC 2003). However, the increasing clarity of Lake Ontario water may cause a shift of  
30 some light-sensitive fish species, such as the walleye, to relocate into deeper waters (Stewart et  
31 al. 1999).

32 There are no aquatic species Federally listed as threatened or endangered under the  
33 Endangered Species Act (ESA) in the vicinity of JAFNPP (Entergy 2006b). Through  
34 consultation with the U.S. Fish and Wildlife Service (FWS), no aquatic species (fish, molluscs,  
35 or aquatic plants) were identified as potentially occurring at the site or in watercourses along or  
36 across the associated transmission corridors.

37 Five aquatic species that have been designated by New York State as threatened, endangered,  
38 or a species of special concern and that may occur in the vicinity of JAFNPP are listed in Table  
39 2-3. There were no reported takings of these fish at JFNPP in 2004 (EA 2005).



**Table 2-3.** Aquatic Species Listed as Endangered, Threatened, or a Species of Special Concern by New York State, Potentially Occurring in Oswego and Onondaga Counties

Scientific Name	Common Name	Federal Status	State Status
<i>Acipenser fulvescens</i>	lake sturgeon	—	T
<i>Erimyzon sucetta</i>	lake chubsucker	—	T
<i>Lythrurus umbratilis</i>	redfin shiner	—	S
<i>Myoxocephalus thompsoni</i>	deepwater sculpin	—	E
<i>Prosopium cylindraceum</i>	round whitefish	—	E

— = No listing

S = Species of Special Concern

Source: Entergy 2006c

E = Endangered

T = Threatened

State-threatened lake sturgeon (*Acipenser fulvescens*) are found primarily in freshwater lakes and large rivers in northeastern North America. In New York, lake sturgeon have been found in the St. Lawrence River, Lake Ontario, Lake Erie, the Niagara River, Lake Champlain, Cayuga Lake, the Seneca Canals, and in the Grasse, Oswego, and Oswegatchie rivers. The Oswego River is a historic spawning ground for lake sturgeon and is the only Lake Ontario tributary where lake sturgeon have been found in recent years. One of New York's largest freshwater fish, mature adults are between 3 and 5 ft long and weigh between 10 and 80 pounds (lb). Lake sturgeon subsist primarily on small organisms: leeches, snails, clams and other invertebrates, small fish, and algae. They spawn from May to June in areas with clean, large rubble such as along windswept rocky shores and in the rapids of streams. Young fish grow rapidly but have a slow reproductive cycle: females do not reach sexual maturity until they are 14 to 23 years old, and they spawn only every four to six years during their 80-year lifespan. Lake sturgeon were historically abundant, but as their value increased, population levels decreased significantly due to overfishing. Other threats to lake sturgeon include the construction of dams that cut off upstream spawning grounds, channelization, and pollution (NYSDEC 1999e; WSG 2006).

Lake chubsuckers (*Erimyzon sucetta*), a State-threatened species, are medium-sized with an average length of 8 to 10 in. They are found only in quiet, clear, well-vegetated waters because they are intolerant of turbid or silty conditions. Lake chubsuckers feed along the water bottom on copepods, cladocerans, and aquatic insect larvae. In New York, lake chubsuckers were historically found in embayments along the south shore of Lake Ontario and the eastern shore of Lake Erie. No lake chubsuckers have been caught in New York for more than 60 years. Siltation, wetland drainage, increased water turbidity, and pollution have likely caused the decline or extirpation of this species (ROM 2006; NYSDEC 1999b).

The redfin shiner (*Lythrurus umbratilis*), a State species of special concern, occurs in the Great Lakes and Mississippi River Basin, western New York to Minnesota, south to Louisiana, and Gulf drainages west to Texas. The redfin shiner is essentially a pool dweller but can also be

1 found in moderate- to low-gradient streams with some vegetation and sand or gravel bottoms.  
2 Within New York, the redbfin shiner has been found only at a few sites in Tonawando Creek, the  
3 Niagara River, and Johnson Creek. Redfin shiners are found in schools feeding on filamentous  
4 algae, bits of higher plants, and aquatic and terrestrial insects. They become sexually mature in  
5 their second or third summer and spawn from early June to mid-August in nests within sunfish  
6 nesting territories. One reason for their low occurrence may be that they require clear water  
7 during spawning, but the rest of the year they can tolerate siltation (NYSDEC 1999d; WSG  
8 2006).

9 The State-endangered deepwater sculpin (*Myoxocephalus thompsoni*) is the largest of New  
10 York's freshwater sculpins; they can be up to 9 in. long but average length is 2 to 5 in.  
11 Deepwater sculpin are found in deep, cool lake waters at depths ranging from 240 to 300 ft.  
12 Found in all the Great Lakes except for Erie, the deepwater sculpin was once prolific in Lake  
13 Ontario. Competition with alewife and rainbow smelt, as well as alewife and rainbow smelt  
14 predation on sculpin eggs and larvae, may have caused a decline in the deepwater sculpin  
15 population—the species was thought to be extirpated until catches were reported from 1996 to  
16 1999. The deepwater sculpin is a bottom feeder, so continual exposure to contaminated  
17 sediments may be another possible cause for their decline. NYSDEC identified the non-native  
18 round goby as another potential source of competition for this species (NYSDEC 1999a; OME  
19 1999).

20 The State-endangered round whitefish (*Psosopium cyclindraceum*) has an average length of  
21 8 to 12 in., occasionally reaching 22 in. This species feeds primarily at or near the bottom on  
22 small aquatic organisms, including eggs of lake trout and other fish. Round whitefish were  
23 historically found in all the Great Lakes except Lake Erie; only seven New York State waters are  
24 known to contain round whitefish populations. Lake Ontario once supported a small round  
25 whitefish commercial fishery, but the last commercial catch was in 1942. Round whitefish are  
26 now protected from harvest or possession by the State of New York Endangered Species Law.  
27 Reasons for the species' decline may include predation by yellow perch on round whitefish eggs  
28 and fry, loss or degradation of spawning sites, siltation, and lake acidification (WSG 2006;  
29 NYSDEC 1999c).

## 30 **2.2.6 Terrestrial Resources**

### 31 *2.2.6.1 Terrestrial Resources at the JAFNPP Site*

32 JAFNPP is on a flat plain 20 ft above the shore of Lake Ontario, with hills to the immediate  
33 south of the property (USGS 1982). As part of the Erie and Ontario Lake Plain ecoregion, this  
34 area was shaped by glacial erosion and deposition processes (NYSDEC 2006d). After the last  
35 glacial period, which ended between 19,000 and 11,000 years ago (PRI 2006), the region was  
36 colonized by vegetation that probably consisted of upland forest and wetland communities (NRC  
37 2006).

1 Typical natural communities in this area vary, depending on the underlying geology and soils,  
2 but include beech-maple, maple-basswood, and hemlock-northern hardwood forests;  
3 grasslands; shrub lands; and wetland communities (SUNY Oswego 2006a). When the property  
4 was purchased by Entergy, it was partially forested and being used for recreation and  
5 residential purposes (Entergy 2006). The area was once used as an artillery range (AEC 1973).  
6 Currently, the area immediately around the plant is maintained in a landscaped condition. The  
7 majority of the property (600 ac) is not landscaped and is expected to develop to climax  
8 communities unless further disturbed.

9 Dominant communities on the site include 66 percent forest, 21 percent open grasslands, and  
10 10 percent wetlands and ponds (Entergy 2006c). These areas are in various states of  
11 succession, ranging from early grassland/meadow communities in recently disturbed areas to  
12 secondary growth hardwood forests (Entergy 2006c). Common tree species include sugar  
13 maple (*Acer saccharum*), American beech (*Fagus grandifolia*), Canadian hemlock (*Tsuga*  
14 *canadensis*), white ash (*Fraxinus americana*), basswood/American linden (*Tilia americana*),  
15 black birch / sweet birch (*Betula lenta*), yellow poplar/tulip poplar (*Liriodendron tulipifera*), and  
16 oaks (*Quercus* spp.), including chestnut (*Q. prinus*), red (*Q. rubra*), black (*Q. velutina*), white  
17 (*Q. alba*), and bur oaks (*Q. macrocarpa*) (AEC 1973). Surveys for rare plants have not been  
18 performed at the site.

19 The FWS National Wetlands Inventory database indicates that there are wetland areas on site  
20 (FWS 2006c). While no formal wetland delineation activities have been performed, Entergy  
21 estimates that there are approximately 70 ac of wetlands and ponds on the property (Entergy  
22 2006c). Swamps and arborvitae and cattail marshes are scattered throughout the area near the  
23 site (AEC 1973).

24 A variety of mammals, birds, reptiles, amphibians, and insects are commonly seen at the  
25 JAFNPP site and in the surrounding area. Reptiles including snakes, turtles, and tortoises may  
26 be found in the area, as well as amphibians including frogs, toads, salamanders, and newts  
27 (SUNY Oswego 2006c).

28 Migratory waterfowl frequent the site and congregate near the discharge area offshore. These  
29 include greater scaup (*Aythya marila*), golden eye (*Bucephala clangula*), merganser (*Mergus*  
30 *merganser*), canvasback (*A. valisineria*), and oldsquaw (*Clangula hyemalis*) (Entergy 2006).  
31 The discharge area has been designated by the New York State Natural Heritage Program as  
32 part of a waterfowl winter concentration area. Impingement of diving ducks has not been  
33 observed at JAFNPP but has been an issue at the Nine Mile Point Nuclear Station just west of  
34 JAFNPP (NRC 2006). Removal of zebra mussels (*Dreissena polymorpha*) and other food  
35 sources from intake structures is considered an effective method of reducing the chances of  
36 diving duck injury and mortality.

37 Other birds that may breed in the area include the red-shouldered hawk (*Buteo lineatus*), sharp-  
38 shinned hawk (*Accipiter striatus*), Cooper's hawk (*A. cooperii*), common nighthawk (*Chordeiles*

## Plant and the Environment

1 *minor*), red-headed woodpecker (*Melanerpes erthrocephalus*), horned lark (*Eremophila*  
2 *alpestris*), golden-winged warbler (*Vermivora chrysoptera*), cerulean warbler (*Dendroica*  
3 *cerulean*), vesper sparrow (*Pooecetes gramineus*), and grasshopper sparrow (*Ammodramus*  
4 *savannarum*) (NRC 2006).

5 Common small mammal species in the area include the white-footed mouse (*Peromyscus*  
6 *leucopus*), deer mouse (*P. maniculatus*), woodchuck (*Marmota monax*), meadow jumping  
7 mouse (*Zapus hudsonius*), meadow vole (*Microtus pennsylvanicus*), red squirrel (*Tamiasciurus*  
8 *hudsonicus*), raccoon (*Procyon lotor*), and cottontail rabbit (*Sylvilagus floridanus*) (NMPC 1985).  
9 Larger mammals include red and gray foxes (*Vulpes vulpes*, *Urocyon cinereoargenteus*),  
10 coyotes (*Canis latrans*), and white-tailed deer (*Odocoileus virginianus*) (SUNY Oswego 2006b).

11 No wildlife management plans currently exist for the JAFNPP property. The site likely provides  
12 productive habitat for wildlife, and hunting is not allowed on the property. Some animal mortality  
13 may occur from vehicle collisions. Migratory bird collisions with buildings have been rare and  
14 are not anticipated to be a significant source of injury during the renewal term. Surveys for rare  
15 animals have not been performed at the site.

16 The area around the plant is maintained through a combination of mowing and herbicide  
17 application. Lawns are mowed as needed. Two drainage swales are vegetated with low-  
18 growing herbaceous cover, which should help to reduce and absorb runoff and protect water  
19 quality while providing some habitat for small animals (EPA 2006c). No maintenance activities  
20 occur around wetlands or Lake Ontario. Roundup™ herbicide is used for weed control in  
21 isolated locations by licensed applicators using hand sprayers. Entergy is required to submit  
22 annual pesticide use reports to NYSDEC, listing qualified applicators. These reports estimate  
23 herbicide use at 33 gallons (gal) in 2003, 30 gal in 2004, and 17 gal in 2005 (Entergy 2004b,  
24 2005c, 2006d). When used according to label directions, such herbicide applications are not  
25 expected to have significant environmental impacts.

26 Important terrestrial habitats near JAFNPP include Teal Marsh 4 mi west of the site, a rare  
27 shrub fen 4 mi south of the site, and Butterfly Creek Wetlands 6 mi east of the site (NRC 2006).  
28 Local parks where wildlife may comprise important recreational attractions include Selkirk  
29 Shores State Park five mi east of the site, Fairhaven Beach State Park 20 mi southwest of the  
30 site, and Beaver Lake Nature Center 25 mi south of the site (NYSHPO 2006a; NYSHPO 2006c;  
31 Onondaga County Parks 2006). Little environmental interaction occurs between these areas  
32 and the JAFNPP site, with the exception of bird travel between the site and these locations.

33 Ecological issues of statewide concern include chronic wasting disease (CWD) in white-tailed  
34 deer (NYSDEC 2006a), botulism in shore birds (NYSDEC 2006e), and vegetation damage  
35 resulting from caterpillars (NYSDEC 2006b) and wood wasps (NYSDEC 2006f). The NRC staff  
36 is not aware of any linkage between continued operation of JAFNPP and these issues.

1 2.2.6.2 *Terrestrial Resources in Transmission Corridors*

2 There are four transmission lines that connect JAFNPP to other facilities and substations  
3 (Entergy 2006c). See Table 2-1. Two of the transmission lines, the Edic and Scriba 345-kV  
4 lines, are within the scope of license renewal. The Edic transmission line runs approximately  
5 70 mi southeast to the Edic Substation near Utica, New York. The corridor associated with this  
6 line is 150-ft wide and crosses Erie-Ontario Lake plain and fringe areas of Tug Hill plateau and  
7 the Mohawk Valley (AEC 1973). These areas are predominantly forested, with some  
8 agricultural, low-density residential, and wetland areas (AEC 1973). Important resource areas  
9 crossed by this line include Catfish Creek, Butterfly Creek, the Little Salmon River, Mohawk  
10 River, Nine Mile Creek, numerous wetlands, and various state wildlife management areas  
11 (Microsoft 2005).

12 The Edic line is owned and maintained by NYPA (Entergy 2006c). The NRC staff met with  
13 NYPA personnel on December 4, 2006, to discuss their transmission line maintenance program.  
14 NYPA maps land use and vegetative cover within the transmission corridor using a geographic  
15 information system. This information is used to develop a maintenance plan for each mapped  
16 parcel to remove only tall-growing species that may interfere with line operations, while allowing  
17 other species to grow. Dead trees that may fall into the lines are removed from the edges of the  
18 ROW by corridor maintenance personnel (NYPA 1998). Herbicides are applied to individual  
19 plants by licensed applicators only as needed to ensure that that tall-growing vegetation does  
20 not interfere with line operations. Maintenance personnel follow the NYPA *Systemwide Right-*  
21 *of-Way Management Plan* (NYPA 1998).

22 The transmission line towers are constructed of weathering steel, which requires little  
23 maintenance and is less reflective than galvanized steel (AEC 1973). There is evidence that  
24 some portions of the transmission line corridor are used by off-road vehicles and hunters, but  
25 these activities appear to be limited in area and intensity.

26 Two invasive exotic plant species, common reed (*Phragmites australis*) and Japanese  
27 knotweed (*Polygonum cuspidatum*), have been noted by NYPA personnel as occurring within  
28 the Edic transmission corridor. Common reed is a threat to wetland areas because it crowds  
29 out native vegetation and may negatively alter wildlife habitat. It is commonly controlled to  
30 protect native species of plants and animals and promote a balanced, productive native  
31 ecosystem. This is typically performed using herbicides, but mowing and controlled burns may  
32 be effective in removing it (PCA 2006a). Japanese knotweed is an introduced species that can  
33 rapidly crowd out native plant species and alter native ecosystems. It is commonly controlled  
34 with diluted pesticides applied to a cut stem or to the leaves (PCA 2006b).

35 The eastern portion of the Edic transmission line passes near the towns of Annesville, Lee,  
36 Western, Floyd, Trenton, and Marcy, where chronic wasting disease (CWD) in white-tailed deer  
37 is an issue of concern (NYSDEC 2006c). This disease is contagious between deer and leads to  
38 severe weight loss and death, but there is no evidence that it is transmissible to humans or  
39 livestock (NYSDEC 2006a). NYSDEC is working to control the spread of CWD in this area.

1 Continued operation and maintenance of the lines is not anticipated to contribute appreciably to  
 2 the spread of this disease among the white-tailed deer population.

3 The second transmission line within the scope of this license renewal review is the 345-kV  
 4 Scriba line. The Scriba line is approximately 4900 feet in length and runs southward from the  
 5 JAFNPP 345-kV switchyard over Entergy property, then turns westward, crossing a portion of  
 6 the Nine Mile Point Nuclear Station site and enters the Scriba substation. The portion of the  
 7 transmission corridor that is not on the JAFNPP site is maintained by NYPA, the owner of the  
 8 line. The Scriba line crosses forested and landscaped areas maintained by JAFNPP and NYPA  
 9 using periodic mowing and vegetation control procedures.

10 *2.2.6.3 Terrestrial Species of Concern*

11 Terrestrial species that are listed by the FWS or the State of New York and have the potential to  
 12 occur on or in the vicinity of the JAFNPP site or along the Edic and Scriba transmission  
 13 corridors are presented in Table 2-4.

14 The NRC staff met with NYPA on December 4, 2006. At this meeting, the NRC staff was  
 15 informed that no threatened or endangered species have been reported by maintenance  
 16 personnel as occurring in or near the transmission corridor. Corridor maintenance personnel  
 17 are trained in identifying endangered species and are expected to take measures to avoid  
 18 damage to these species if they are identified within the transmission line corridor during the  
 19 renewal period.

20 Consultation with New York Natural Heritage Program (NYNHP) revealed the existence of two  
 21 important natural heritage areas near the Edic transmission line corridor. The areas consist of  
 22 State-listed upland sandpiper (*Bartramia longicauda*) habitat and a rare fen. In addition, the  
 23 NYNHP staff identified the area immediately offshore from the JAFNPP site as an important  
 24 State-recognized waterfowl winter concentration area. The pied-billed grebe (*Podilymbus*  
 25 *podiceps*) and least bittern (*Ixobrychus exilis*) are known to forage nearby. Both species are  
 26 listed as threatened by the State of New York.

27 **Table 2-4.** Federally Listed and New York State-Listed Terrestrial Species Potentially  
 28 Occurring in the Vicinity of JAFNPP and in Associated Transmission Line Corridors

Scientific Name	Common Name	Federal Status	State Status
<b>Reptiles</b>			
<i>Ambystoma jeffersonianum</i>	Jefferson salamander	—	S
<i>Ambystoma laterale</i>	blue-spotted salamander	—	S
<i>Clemmys guttata</i>	spotted turtle	—	S
<i>Clemmys insculpta</i>	wood turtle	—	S

<i>Clemmys muhlenbergii</i>	bog turtle	T	E
<i>Crotalus horridus</i>	timber rattlesnake	—	T
<i>Sistrurus catenatus catenatus</i>	massasauga rattlesnake	C	E
<b>Birds</b>			
<i>Accipiter cooperli</i>	Cooper's hawk	—	S
<i>Accipiter striatus</i>	sharp-shinned hawk	—	S
<i>Ammodramus henslowii</i>	Henslow's sparrow	—	T
<i>Ammodramus savannarum</i>	grasshopper sparrow	—	S
<i>Aquila chrysaetos</i>	golden eagle	—	E
<i>Asio flammeus</i>	short-eared owl	—	E
<i>Bartramia longicauda</i>	upland sandpiper	—	T
<i>Buteo lineatus</i>	red-shouldered hawk	—	S
<i>Charadrius melodius</i>	piping plover	E	E
<i>Chlidonias niger</i>	black tern	—	E
<i>Chordeiles minor</i>	common nighthawk	—	S
<i>Circus cyaneus</i>	northern harrier	—	T
<i>Cistothorus platensis</i>	sedge wren	—	T
<i>Dendroica cerulean</i>	cerulean warbler	—	S
<i>Eremophila alpestris</i>	horned lark	—	S
<i>Falco peregrinus</i>	peregrine falcon	—	E
<i>Gavia immer</i>	common loon	—	S
<i>Haliaeetus leucocephalus</i>	bald eagle	T	—
<i>Ixobrychus exilis</i>	least bittern	—	T

**Table 2-4** (cont.)

<b>Scientific Name</b>	<b>Common Name</b>	<b>Federal Status</b>	<b>State Status</b>
<b>Birds (cont.)</b>			
<i>Lanius ludovicianus</i>	loggerhead shrike	—	E
<i>Melanerpes erythrocephalus</i>	red-headed woodpecker	—	S
<i>Pandion haliaetus</i>	osprey	—	S
<i>Podilymbus podiceps</i>	pieb-billed grebe	—	T
<i>Sterna hirundo</i>	common tern	—	T
<i>Vermivora chrysoptera</i>	golden-winged warbler	—	S
<b>Mammals</b>			
<i>Myotis leibii</i>	small-footed bat	—	S
<i>Myotis sodalis</i>	Indiana bat	E	E

---

**Plants**

<i>Carex chondorrhiza</i>	creeping sedge	—	T
<i>Eleocharis quadrangulata</i>	angled spikerush	—	E
<i>Eleocharis obtuse</i> var. <i>ovata</i>	blunt spikerush	—	E
<i>Lycopodium complanatum</i>	northern running pine	—	E
<i>Polygonum setaceum</i> var. <i>interjectum</i>	swamp smartweed	—	E
<i>Polystichum archostichoides</i>	Christmas fern	—	S
<i>Thelypteris noveboracensis</i>	New York fern	—	S
<i>Trillium flexipes</i>	nodding trillium	—	E
<i>Trillium sessile</i>	toad-shade	—	E
<i>Trillium</i> spp.	trillium	—	S

---

— = No listing

C = Candidate for federal listing

E = Endangered

S = Species of Special Concern (New York State)

T = Threatened

Source:

Entergy 2006c (except creeping sedge)

NYSDEC 2006g (creeping sedge)

1

2 Federally Protected Species

3 The endangered Indiana bat (*Myotis sodalis*) is a chestnut-brown, medium-sized bat that  
 4 forages for insects near streamside and upland forests (FWS 2006b). These bats roost and  
 5 hibernate in caves or mines, known as hibernacula, or under the loose bark of recently dead  
 6 trees. Reasons for the decline of this species include natural mortality, human disturbance of  
 7 hibernating bats, and deforestation, especially the removal of dead standing trees and trees  
 8 near streams (FWS 1983). Indiana bats may be utilizing large dead trees with loose bark either  
 9 onsite or along the margins of the Edic or Scribal transmission corridors. There have been no  
 10 reports of Indiana bats using dead trees along the transmission corridors; however, there has  
 11 been no systematic survey of this potential habitat.

12 The threatened bog turtle (*Clemmys muhlenbergii*) is a very small black turtle that lives in open  
 13 sedge meadows and fens bordered by wooded areas (FWS 2001). The bog turtle's diet  
 14 consists primarily of insects but also includes plants, frogs, and carrion (Bury 1979). The  
 15 greatest threats to the bog turtle include the degradation and destruction of open wetland  
 16 habitat and illegal collection (Groombridge 1982). Two potential sources of habitat loss within  
 17 the transmission corridor, if such habitat is present, are the colonization by common reed and  
 18 the natural progression by trees. The common reed establishes a dense monoculture that is  
 19 unsuitable for many wetland species, including bog turtles (FWS 2001). Because the bog turtle  
 20 depends on open wetlands without any tree cover, the current transmission corridor  
 21 maintenance program may preserve potential bog turtle habitat. The NRC staff is unaware of



1 any reported occurrences of bog turtles inhabiting wetlands along the Edic or Scriba  
2 transmission corridors; however, there has not been a systematic survey of these lines for this  
3 species.

4 Federally protected species identified in the review of Nine Mile Point include the massasauga  
5 rattlesnake, bald eagle, and piping plover. The massasauga rattlesnake (*Sistrurus catenatus*  
6 *catenatus*) is a candidate species for Federal protection. It lives in wet prairies, sedge  
7 meadows, and early successional fields, and natural succession of woody vegetation may  
8 cause habitat deterioration (NRC 2006). It is not known to occur near the JAFNPP site.

9 The threatened bald eagle (*Haliaeetus leucocephalus*) is a large bird of prey that is usually  
10 found near large bodies of water. The bald eagle is a transient species and is not found in the  
11 vicinity of JAFNPP or associated transmission line rights-of-way.

12 The endangered piping plover (*Charadrius melodius*) is a small, stocky sandy-colored bird  
13 resembling a sandpiper. Like the bald eagle, it may migrate through the area, but are not found  
14 in the vicinity of the JAFNPP site or associated transmission line rights-of-way (NRC 2006).

#### 15 State-Protected Species

16 The NRC staff consulted with NYNHP on December 7, 2006 to determine which State-listed  
17 species were known to occur near JAFNPP and the Edic and Scriba transmission lines. The  
18 NYNHP identified three State-threatened bird species and one State-threatened plant species.  
19 No other State-listed species were identified as occurring near the site on along the Edic and  
20 Scriba transmission corridors.

21 The State-threatened upland sandpiper (*Bartramia longicauda*) is a small brown-and-white  
22 mottled bird that inhabits open, grassy areas, including pastures, upland meadows, and fallow  
23 fields. This species feeds on invertebrates and grains. It has declined due to excessive hunting  
24 in the past and has not recovered from this historical stress (CDEP 2004b). One area of known  
25 upland sandpiper habitat was identified by the NYNHP as occurring near the JAFNPP site.

26 The State-threatened pied-billed grebe (*Podilymbus podiceps*) is a diving duck that forages in  
27 an area near the JAFNPP site. It lives in marshes and ponds and feeds mostly on aquatic  
28 invertebrates, occasionally eating fish, reptiles and amphibians. Although this species is found  
29 throughout North America, it is rare in New York (Cornell Laboratory of Ornithology 2003).

30 The State-threatened least bittern (*Ixobrychus exilis*) is found in emergent vegetation in  
31 freshwater marshes not far from the JAFNPP site. It feeds on small fish, amphibians, insects,  
32 invertebrates, and occasionally shrews and mice. Its decline is attributed to the destruction of  
33 wetland habitat (CDEP 2004a).

34 The State-threatened creeping sedge (*Carex chordorrhiza*) is a wetland plant known to occur  
35 near the JAFNPP site.

1 **2.2.7 Radiological Impacts**

2 JAFNPP conducts an annual Radiological Environmental Monitoring Program (REMP) in which  
3 radiological impacts to employees, the public, and the environment in and around the JAFNPP  
4 site are monitored, documented, and compared to the appropriate standards. The objectives of  
5 the REMP are to:

- 6 • Measure and evaluate the effects of facility operation on the environs and verify the  
7 effectiveness of the controls on radioactive material sources
- 8 • Monitor natural radiation levels in the environs of the JAFNPP site
- 9 • Demonstrate compliance with the requirements of applicable Federal regulatory  
10 agencies, including technical specifications and the ODCM

11 Radiological releases are summarized in two JAFNPP reports: the *Annual Radiological*  
12 *Environmental Operating Report* (Entergy 2005b) and *Annual Radioactive Effluent Release*  
13 *Report* (Entergy 2006a; 2005a; 2004a; 2003; 2002a; 2002b). Limits for all radiological releases  
14 are specified in the JAFNPP ODCM (Entergy 2004c) and used to meet Federal standards and  
15 requirements. The REMP includes monitoring of the waterborne environment (surface,  
16 sediment from shoreline); airborne environment (radioiodine and particulates, direct radiation);  
17 and ingestion pathways (milk, fish, food products). During 2005, 2318 analyses were performed  
18 on collected samples of environmental media and showed no significant or measurable  
19 radiological impact from the operations at JAFNPP (Entergy 2005b).

20 The New York State Department of Health also measures the levels of radiation exposure and  
21 concentration of radioactive material at locations surrounding Nine Mile Point and JAFNPP.  
22 The State measures direct radiation and radioactivity in air, milk, water, sediments, vegetation,  
23 and fish. The State's 10-year monitoring data from 1995 through 2004 shows radiation levels  
24 typical for background levels for air, water, milk, fish, sediment samples, vegetation, and direct  
25 radiation (New York State Department of Health 2007).

26 Historical data on releases from JAFNPP and the resultant dose calculations demonstrate that  
27 the calculated doses to maximally exposed individuals in the vicinity of JAFNPP were a small  
28 fraction of the limits specified in the JAFNPP ODCM (Entergy 2004c) to meet 10 CFR Part 20;  
29 10 CFR Part 50, Appendix I; and EPA radiation standards in 40 CFR Part 190. For 2005, dose  
30 estimates were calculated based on actual liquid and gaseous effluent release data and  
31 conservative models to simulate the transport mechanisms. The results are described in the  
32 *2005 Annual Radioactive Effluent Release Report* (Entergy 2006a). A summary of the  
33 calculated maximum dose to an individual located at the JAFNPP boundary from liquid and  
34 gaseous effluents released during 2005 is as follows:

- 1 • The maximum whole-body dose to an offsite member of the general public from liquid  
2 effluents was  $1.68 \times 10^{-5}$  millirem (mrem), well below the 3-mrem-dose criteria in 10 CFR  
3 Part 50, Appendix I.
  - 4 • The maximum whole-body dose to the likely most-exposed member of the general public  
5 from gaseous effluents was 4.39 mrem, below the 5-mrem-dose criteria in 10 CFR  
6 Part 50, Appendix I.
- 7 The applicant does not anticipate any significant changes to the radioactive effluent releases or  
8 exposures from JAFNPP operations during the renewal period and, the impacts to the  
9 environment are therefore not expected to change.

10 **2.2.8 Socioeconomic Factors**

11 The NRC staff reviewed the JAFNPP Environmental Report (ER) (Entergy 2006c) and  
12 information obtained from County, City, school district, and local economic development staff.  
13 The following sections describe the housing market, community infrastructure, population, and  
14 economy in the region surrounding the JAFNPP site.

15 *2.2.8.1 Housing*

16 JAFNPP employs a permanent workforce of 716 employees (Entergy 2006c). Approximately  
17 78 percent live in Oswego County, New York, and 18 percent in Onondaga County, New York  
18 (Table 2-5). Both counties are in the Syracuse metropolitan statistical area (MSA), which also  
19 includes Cayuga and Madison counties. Given the residential locations of JAFNPP employees,  
20 the most significant impacts of plant operations are likely to occur in Oswego and Onondaga  
21 counties. The focus of the analysis in this draft environmental impact statement (draft SEIS) is  
22 therefore on the impacts of JAFNPP in these two counties.

23

24 **Table 2-5. JAFNPP Permanent Employee**  
25 **Residence by County in 2006**

County	Number of JAFNPP Personnel	Percentage of Total
Oswego	556	77.7%
Onondaga	127	17.7%
Other	33	4.6%
Total	716	100.0%

Source: Entergy 2006c

1  
 2 JAFNPP schedules refueling outages at 24-month intervals. During refueling outages, site  
 3 employment increases by 700 to 900 workers for approximately 30 days. These workers are  
 4 assumed to be from the same geographic areas as the permanent JAFNPP staff.

5 The number of housing units and housing vacancies in Oswego and Onondaga counties in  
 6 2000 and 2005 are shown in Table 2-6. In Oswego County, the total number of housing units  
 7 and occupied units grew at an average annual rate of 0.34 and 0.64 percent, respectively, from  
 8 2000 to 2005. With an annual average population growth rate of 1.1 percent during this period,  
 9 the number of units available grew more slowly than the demand for housing.

10 **Table 2-6.** Number of Occupied, Vacant, and Total Housing Units  
 11 in Oswego and Onondaga Counties, New York, in 2000 and 2005

County	Housing Units	Year		Approximate Change
		2000	2005	
Oswego	Occupied	45,522	46,964	+3.2%
	Vacant	7,309	6,766	-7.4%
	Total	52,831	53,730	+1.7%
Onondaga	Occupied	181,153	183,032	+1.0%
	Vacant	15,480	17,704	+14.4%
	Total	196,633	200,736	+2.1%

Source: USCB 2006a

12  
 13 In Onondaga County, the total number of housing units grew at an annual average rate of  
 14 0.42 percent from 2000 to 2005, while average annual growth of occupied units was slightly less  
 15 at 0.20 percent (USCB 2006a).

16 *2.2.8.2 Public Services*

17 This section contains a discussion of public services including water supply, education, and  
 18 transportation.

19 *Water Supply*

20 Slightly more than half of Oswego County's population receives potable water from one of the  
 21 county's 29 public water districts, with the remaining population receiving water from private  
 22 groundwater wells (NRC 2006). Public water districts in the county obtain water from Lake  
 23 Ontario or a variety of groundwater aquifers and springs and the Onondaga County Water

1 Authority (OCWA) (OCDPCD 1997). Public water suppliers draw water from three principal  
 2 groundwater aquifers (Sand Ridge, Fulton, and Tug Hill) with substantial groundwater resources  
 3 available from other local or regional aquifers that have been largely unused (OCDPCD 1997).  
 4 The three major public water supply systems in Oswego County are the Oswego Water System,  
 5 the City of Fulton, and the Metropolitan Water Board.

6 Table 2-7 lists the daily water consumption and maximum daily capacity for the three major  
 7 public water supply systems in Oswego County.

8 **Table 2-7.** Major Public Water Supply Systems in Oswego County,  
 9 Average Daily Use, and Maximum Daily Capacity

Water Supplier	Average Daily Use in million gpd	Maximum Daily Capacity in million gpd
Oswego Water System	8.0	20.1
City of Fulton	2.4	2.4
Metropolitan Water Board	25.0	62.5

Source: NRC 2006

10  
 11 The Oswego Water System (OWS) provides water service to approximately 23,950 customers  
 12 in the communities of Oswego, Minetto, Scriba, and Volney, and potable water to JAFNPP  
 13 (OCDPCD 1997). Current JAFNPP usage is approximately 137,500 gpd with no restrictions on  
 14 supply (Entergy 2006g). While the OWS could potentially withdraw up to approximately  
 15 62.5 million gpd from Lake Ontario, the design capacity of the water plant is only 20.1 million  
 16 gpd (NRC 2006). County planning officials estimate that the capacity of the OWS is adequate  
 17 to meet the demands of an additional 4000 to 8000 residential customers (OCDPCD 1997).

18 The City of Fulton water supplier serves approximately 12,900 customers. The City has  
 19 10 groundwater wells extracting up to 2.4 million gpd. As average daily demand exceeds  
 20 supply in the city, the City of Fulton has an agreement with the OCWA to obtain up to 3 million  
 21 gpd to cover the extra demand (OCDPCD 1997).

22 The Metropolitan Water Board (MWB) functions as a potable water wholesaler to public water  
 23 districts and water authorities in both Oswego and Onondaga counties. Most of the MWB's  
 24 water is sold to the OCWA, with 25 percent of its pipeline capacity available to Oswego County.  
 25 While the capacity of MWB is 60 million gpd, the MWB withdrew an average of only 25 million  
 26 gpd in 1998, of which 200,000 gpd was provided to communities in Oswego County. The MWB  
 27 therefore has large excess capacity to support future growth in the county (OCDPCD 1997).

## Plant and the Environment

### 1 Education

2 JANFPP is located in the Mexico Central School District, which had an enrollment of  
3 2682 students in 2005. Including the Mexico Central School District, Oswego County contains  
4 9 school districts. In 2000, there were 35,240 students enrolled in schools in the county with an  
5 average class size of 21 students. The average expenditure per student in low-need districts in  
6 New York is approximately \$15,000. Onondaga County has a total of 18 school districts. Total  
7 enrollment in the district is approximately 132,240 students based on data from the 2000  
8 Census Bureau (Entergy 2006g).

### 9 Transportation

10 The road structure in the immediate vicinity of JAFNPP consists primarily of smaller county  
11 roads rather than state or interstate highways. JAFNPP is accessed from the east by Lake  
12 Road, a two-lane paved road east of the intersection of County Route 1A and Lakeview Road  
13 (see Figure 2-2). According to the Oswego County Planning and Community Development  
14 Department, the average daily traffic count for County Route 1A from County Route 1 to Lakeview  
15 Road was 4900 vehicles in 1995 (NRC 2006).

16 Due to the rural nature of JAFNPP's location, there is no state level of service determination for  
17 the county roads that service JAFNPP and the immediate area. The Oswego County  
18 Department of Public Works reviewed traffic patterns for the major roads around the JAFNPP as  
19 part of a reconstruction project for County Route 1A. The County determined that traffic counts  
20 were within acceptable levels (NRC 2006).

### 21 *2.2.8.3 Offsite Land Use*

22 In order to accommodate and regulate growth and development, Oswego and Onondaga  
23 counties have developed county-specific comprehensive growth management plans  
24 characterizing current conditions and setting standards, regulations, and goals for land use and  
25 development. Land-use planning and zoning regulations have been developed by towns,  
26 villages, and municipalities within Oswego and Onondaga counties. Therefore, land use  
27 standards may vary greatly in different regions within the counties. Neither county has  
28 implemented growth control measures that would limit residential housing development.

29 Agriculture remains the predominant land use in the county, but rural residential development  
30 has increased. In all or parts of many towns, residential development surrounding major  
31 employment centers has reached or is approaching suburban density. Most towns in Oswego  
32 County have developed some type of land-use regulation, either zoning or subdivision  
33 regulations. Although elements of the rural landscape remain, the community character is  
34 clearly residential (OCDPCD 1997). Residential growth has been strongest in towns in southern  
35 Oswego County and the town of Scriba in northern Oswego County. Commercial and industrial  
36 land uses, particularly energy production, such as the Nine Mile Point Nuclear Station and Sithe  
37 Industries, which operates a natural gas fueled power plant, have centered near the cities of  
38 Oswego and Fulton and their surrounding areas. State-regulated wetlands account for

1 13 percent of the total land area in Oswego County, and development is restricted in these  
 2 areas (OCDPCD 1999).

3 Onondaga County is somewhat more developed, with an increase of both residential and  
 4 commercial land uses in towns and villages near Syracuse. Growth has been steady  
 5 throughout northern and central Onondaga County. County planning officials expect residential  
 6 growth to continue in northern and central Onondaga County following the *Onondaga County*  
 7 *Settlement Plan* (Syracuse-Onondaga County Planning Agency 2001). This plan proposes to  
 8 control growth within the county by guiding county infrastructure investments only to developed  
 9 areas.

10 Seventeen state parks, 20 state wildlife management areas, and one national wildlife refuge are  
 11 located within a 50-mi radius of JAFNPP. The Montezuma National Wildlife Refuge is north of  
 12 Cayuga Lake in Seneca County, approximately 44 mi southwest of the site (NRC 2006).

13 Land use in Oswego and Onondaga counties is listed in Table 2-8.

14 2.2.8.4 Visual Aesthetics and Noise

15 The area around JAFNPP is generally flat, forested, and rural. The most prominent features on  
 16 the site are the reactor building and the off-gas stack, which is 385 ft high. Due to the forest  
 17 cover in the area, the physical plant is not visible from local communities. However, plant  
 18 structures can be seen by recreational boaters and fishermen on Lake Ontario.

19 **Table 2-8.** Land Use in Oswego and Onondaga Counties

Land Use	Percentage of Total	
	Oswego County (1995)	Onondaga County (2006)
Agriculture, forested, vacant	55%	51%
Residential	36%	29%
Public	6%	10%
Commercial	3%	10%
Total	100%	100%

Sources: Oswego County: OCPCD 1997; Onondaga County: Syracuse-Onondaga County Planning Agency 2006

20

21 Currently, there are no reports of noise complaints from the areas surrounding JAFNPP or from  
 22 recreational users of Lake Ontario. Additionally, noise concerns have not been considered a

1 problem at the site due to the plant's distance from local communities (Entergy 2006c). EPA  
2 recommends that noise levels for residential areas near the boundary of an industrial facility not  
3 exceed an annual equivalent sound level of 55 decibels. There is no expected increase in noise  
4 levels associated with the proposed license renewal activities.

#### 5 *2.2.8.5 Demography*

6 In 2000, approximately 109,440 persons lived within a 20-mi radius of JAFNPP, which equates  
7 to a population density of 87 persons per mi<sup>2</sup>. This density translates to a Category 3 (60 to  
8 120 persons per mi<sup>2</sup> or fewer than 60 persons per mi<sup>2</sup> with at least one community of 25,000 or  
9 more persons within 20 mi) using the generic environmental impact statement (GEIS) measure  
10 of sparseness (Entergy 2006c). At the same time, there were approximately 914,668 persons  
11 living within a 50-mi radius of the plant, for a density of 117 persons per mi<sup>2</sup>. The Syracuse  
12 MSA, located within 50 mi of the site, had a total population in 2000 of 732,117. Therefore,  
13 JAFNPP falls into Category 3 (one or more cities with 100,000 or more persons and fewer than  
14 190 persons per mi<sup>2</sup> within 50 mi) of the NRC sparseness and proximity matrix. A Category 3  
15 value indicates that JAFNPP is in a medium density population area (NRC 2006).

16 Table 2-9 shows population growth rates and projections from 1970 to 2020 in Oswego and  
17 Onondaga counties. Oswego County grew at a relatively slow annual rate of less than  
18 0.1 percent for the period of 1990 to 2000. The average annual growth rate for New York for  
19 this period was 0.5 percent. Only slight increases in population are expected for the period  
20 2000 through 2020. The population declined in Onondaga County during the 1990s and this  
21 trend is expected to continue during the period 2000 to 2020 (NRC 2006).

22 In 2000, Oswego, the largest city in Oswego County, located approximately 5 mi southwest of  
23 JAFNPP had a population of 17,954 persons (USCB 2006a). The second largest city, Fulton,  
24 located approximately 12 mi south of JAFNPP had a population of 11,855 persons. The town of  
25 Scriba had an estimated population of 7331 persons. The U.S. Census Bureau lists 21 other  
26 towns in Oswego County, all of which have populations between 500 and 9000 persons (USCB  
27 2006a). Most of the remaining population lives in unincorporated rural areas (OCDPCD 1997).

28 Although some towns and municipalities surrounding Syracuse have experienced modest  
29 growth, Onondaga County and Syracuse declined in population from 1990 to 2000. In 2000 the  
30 Onondaga Reservation in southern Onondaga County had an estimated population of  
31 1473 persons (NRC 2006).



**Table 2-9.** Population Growth in Oswego and Onondaga Counties, New York, from 1970 to 2000 and Projected for 2010 and 2020

Year	Oswego County		Onondaga County	
	Population	Annual Growth Percent <sup>(a)</sup>	Population	Annual Growth Percent <sup>(a)</sup>
1970	100,897	—	472,835	—
1980	113,931	+1.2	463,920	-0.2
1990	121,771	+0.7	468,973	+0.01
2000	122,377	+0.05	458,336	-0.02
2010	123,400	+0.08	442,531	-0.4
2020	123,591	+0.02	423,235	-0.4

— = No data available.

(a) Annual percent growth rate is calculated over the previous decade.

Sources: Population data for 1970 through 2000 (USCB 2006); projected population data for 2010 and 2020 (NRC 2006a)

3

#### 4 Transient Population

5 Within 50 mi of JAFNPP, colleges and recreational opportunities attract daily and seasonal  
6 visitors who create demand for temporary housing and services. In Oswego County,  
7 6.6 percent of all housing units are considered temporary housing for seasonal, recreational, or  
8 occasional use. By comparison, temporary housing accounts for only 1.0 percent and  
9 3.1 percent of total housing units in Onondaga County and the State of New York, respectively  
10 (NRC 2006).

#### 11 Migrant Farm Workers

12 Migrant farm workers are individuals whose employment requires travel to harvest agricultural  
13 crops. These workers may or may not have a permanent residence. Some migrant workers  
14 may follow the harvesting of crops, particularly fruit, throughout the northeastern U.S. rural  
15 areas. Others may be permanent residents near JAFNPP who travel from farm to farm  
16 harvesting crops.

17 Migrant workers may be members of minority or low-income populations. Because they travel  
18 and can spend a significant amount of time in an area without being actual residents, migrant  
19 workers may be unavailable for counting by census takers. If uncouned, these workers would  
20 be "underrepresented" in USCB minority and low-income population counts.

Plant and the Environment

1 Onondaga and Oswego counties host relatively small numbers of migrant workers. According  
2 to 2002 Census of Agriculture estimates, 1745 temporary farm laborers (those working fewer  
3 than 150 days per year) were employed on 170 farms in Onondaga County, and 718 were  
4 employed on 93 farms in Oswego County (Entergy 2006g).

5 *2.2.8.6 Economy*

6 This section contains a discussion of the economy, including employment and income,  
7 unemployment, and taxes.

8 Employment and Income

9 Between 1990 and 2004, total employment in Oswego County increased 2.5 percent (24,396 to  
10 25,011 persons) and decreased in Onondaga County by 3.6 percent (232,120 to 223,649  
11 persons) (USCB 2006b). Government and health care sectors employed the largest number of  
12 people in both counties followed closely by retail, manufacturing, and the service industry. The  
13 largest employer in Oswego County in 2006 was the State University of New York at Oswego  
14 (SUNY Oswego) with 3934 employees (Table 2-10). The majority of jobs in Oswego County are  
15 located in the cities of Oswego and Fulton (Oswego County 2006).

16 Personal income in Oswego County totaled \$2.9 million in 2004, with a per capita personal  
17 income of \$23,481. In Onondaga County, personal income totaled \$14.7 million, with a per  
18 capita income of \$32,122. Both are lower than the state's per capita personal income in 2004,  
19 which was \$38,364 (FedStats 2006).

20 Unemployment

21 The unemployment rate in Oswego and Onondaga counties in October 2006 was 4.3 and  
22 3.7 percent, respectively. Although there have been fluctuations, the overall rates in both  
23 counties have remained about the same over the past decade. The current rate for the state  
24 (November 2006) is 4.0 percent (NYSDOL 2006).

25 Taxes

26 JAFNPP is assessed annual property taxes by Oswego County, the Town of Scriba, and Mexico  
27 Central Schools. Property taxes paid to Oswego County and the Town of Scriba fund services  
28 such as transportation, education, public health, and public safety. See Table 2-11.

29 The continued availability of JAFNPP and the associated tax base is an important feature in the  
30 ability of the Town of Scriba and Oswego County communities to continue to invest in  
31 infrastructure and to draw industry and new residents.

32

1

**Table 2-10.** Major Employers in Oswego County in 2006

<b>Firm</b>	<b>Number of Employees</b>
SUNY Oswego	3934
County of Oswego	1048
Constellation Energy Group	900
Central Square School District	841
Oswego Health	730
Oswego City School District	723
Novelis Corporation	714
Fulton School District	647
Huhtamaki Packaging	630
Wal-Mart	620
Oswego Opportunities (non-profit)	604
Oswego County Bringing Our Community Education Solutions (BOCES)	569
Entergy Nuclear Northeast	560

Source: Oswego County 2006

2

3 In 2005, Entergy paid approximately \$7.2 million in taxes for JAFNPP. It is estimated that a  
4 minimum of \$38.1 million in taxes will be paid by Entergy for JAFNPP through the original  
5 license period (Entergy 2006c). These property taxes, and other local taxes, along with  
6 JAFNPP operating payroll and locally purchased goods and services, aid the local economy.

7 The energy market in the state of New York has been deregulated to encourage the  
8 development of competition in the production and sale of electricity. A study performed by the  
9 New York State Board of Real Property Services concluded that the value of many power-  
10 generating plants is likely to decline in a deregulated market. Therefore, Entergy expects that  
11 future property taxes assessed through the license renewal term should be similar to or may be  
12 less than the estimated in lieu payments (NRC 2006).

1 **Table 2-11.** Oswego County, Town of Scriba, and Mexico Central Schools Tax Revenues,  
 2 2002 to 2005; JAFNPP Property Tax, 2002 to 2005; and JAFNPP Property Tax  
 3 as a Percentage of Tax Revenues

Entity	Year	Tax Revenues (in millions of dollars)	Property Tax Paid by JAFNPP (in millions of dollars)	JAFNPP Property Tax as Percentage of Tax Revenues
<b>Oswego County</b>	2002	\$152.9	\$2.9	1.9%
	2003	\$156.1	\$2.9	1.9%
	2004	\$172.5	\$2.9	1.7%
	2005	\$162.4	\$2.9	1.8%
	2006	\$161.0	\$2.9	1.8%
<b>Town of Scriba</b>	2002	\$4.0	\$0.4	10.9%
	2003	\$4.9	\$0.4	9.0%
	2004	\$4.3	\$0.4	10.3%
	2005	\$5.1	\$0.4	8.6%
	2006	\$4.6	\$0.4	9.4%
<b>Mexico Central Schools</b>	2002	\$32.4	\$3.9	12.1%
	2003	\$32.7	\$3.9	12.0%
	2004	\$34.1	\$3.9	11.5%
	2005	\$34.0	\$3.9	11.4%
	2006	\$34.0	\$3.9	11.6%

Source: Entergy 2006c (years 2002–2005)  
 Entergy 2006g (year 2006)

4

5 **2.2.9 Historic and Archaeological Resources**

6 This section discusses the cultural background and the known historic and archaeological  
 7 resources at the JAFNPP site and in the surrounding area.

1    2.2.9.1 *Cultural Background*

2    The region around JAFNPP contains prehistoric and historic Native American and Euro-  
3    American cultural resources. There are 43 properties listed in the National Register of Historic  
4    Places within approximately 10 mi of JAFNPP (Entergy 2006c). The nearest National Register  
5    site is the Riverside Cemetery in Scriba; none are located in areas affected by operation of  
6    JAFNPP.

7    Paleo Indians occupied North America from 12,000 to 10,000 years ago, subsisting on hunting  
8    game and gathering plant material. In the New York area, Paleo Indians migrated into an  
9    environment changed by retreating glacial ice. Evidence from archaeological work in the state  
10   suggests that small game and plants played a significant role in the lives of the people. Stone  
11   tools show little variability over wide areas of North and South America, but raw material for  
12   these tools often have sources far from where archaeologists find the tools. Known Paleo-  
13   Indian sites near JAFNPP include the Potts Site southeast of Scriba (Ritchie 1994).

14   During the Archaic Period, from approximately 10,000 years ago to about 3500 years ago,  
15   people underwent local changes to adapt to resources. In the New York area, as forests  
16   evolved from spruce and pine to mixed deciduous communities, populations near present day  
17   JAFNPP probably were low in density to begin with but steadily increased in density as both  
18   resource quality and the cultural means to access resources improved. Archaeologists find  
19   evidence of more occupation by the end of the Archaic Period when climate reached its modern  
20   condition. They interpret the settlement patterns they find as suggestive of an increase in  
21   breadth of resources sought by prehistoric people as they lived in smaller territories. Archaic  
22   people collected, hunted, and gathered most of what they needed for survival in their home  
23   territory. Large base camps found near major water sources provided a focal point for groups  
24   during the hard months. During other seasons, camps divided and people engaged in more  
25   mobile foraging activities. Primary areas of occupation were along the Oswego River about  
26   7 mi to the west of JAFNPP. Small hunting parties may have crossed the JAFNPP site and  
27   hunting encampments could be present. One late Archaic archaeological deposit near the  
28   JAFNPP area is the Oberlander 1 site in Oswego County on the Oneida River (Ritchie 1994).

29   The Transitional Period, from approximately 3500 years ago to about 1000 years ago, is viewed  
30   by New York archaeologists as representing a continuum of change in adaptation by prehistoric  
31   peoples. The central defining characteristic of the period is the introduction of stone (steatite)  
32   vessels at the beginning and the first production of pottery at the end (Ritchie and Funk 1973).  
33   Over the same period, burial treatment became more elaborate, and people once again got  
34   some materials for making stone tools from distant sources (Ritchie and Funk 1973).

35   The "Woodland" culture occupied the region between 3000 years ago until the time of European  
36   contact. In the Woodland culture, Native Americans became regionally distinct cultural entities.  
37   Woodland people ultimately became dependent on maize agriculture, lived in villages, used the  
38   bow and arrow in hunting, and began to regularly make and use pottery. Known examples of  
39   prehistoric sites are rare on the shore of Lake Ontario. Known archaeological resources found

Plant and the Environment

1 in Oswego County are concentrated along the Oswego River, Oneida Lake, along the Salmon  
2 River, and at the mouth of the Salmon River.

3 JAFNPP is situated within a region bordered by Lake Ontario to the north. No major drainage  
4 occurs within 5 mi. Any large prehistoric sites would most likely be found along major  
5 waterways away from JAFNPP. Since JAFNPP is not within the daily foraging radius of any  
6 major river valley, prehistoric people visiting the area could have made overnight camps along  
7 minor streams as they hunted and collected local resources. The terrain to the south and east  
8 of JAFNPP consists of glacial kettle ponds and wetlands surrounded by small knolls and hills.  
9 Paleo-Indian and Archaic Period peoples could have foraged for resources in and around these  
10 kettle ponds. Later prehistoric groups could have used this area for hunting and foraging on a  
11 reduced scale. JAFNPP is also situated on a rocky coastal bluff. This, along with the lack of a  
12 beach, would not have been attractive for fishing. Any archaeological sites found in the vicinity  
13 of the JAFNPP would consist of small scatters of stone tools and debris from making stone  
14 tools, associated with cooking hearths.

15 The Native American societies in the region shared several important characteristics at the time  
16 they were first contacted by Europeans. These included an economic base that combined  
17 hunting and gathering with growing domesticated plants; and an annual settlement that varied in  
18 population size between semi-permanent river-side villages in summer, large camps in winter,  
19 and population dispersal among scattered camps in the spring and fall.

20 The JAFNPP site is located on Onondaga Indian Nation's eighteenth century lands, although  
21 the territorial boundaries between Native American groups were in flux throughout the historic  
22 period and until the mid-nineteenth century. Treaties between New York Indians and the United  
23 States government in 1794 and 1838 eroded tribal territorial holdings in the state of New York.  
24 European settlement and exploration of the region occurred slowly with most of the settlement  
25 activity concentrated away from JAFNPP near the mouth of the Oswego River near Forts  
26 Ontario and Oswego.

27 In 1788, the state purchased large tracts of land from the Onondaga, Oneida, and Cayuga  
28 nations; the lands, which were divided into parcels, included Scriba's Patent, and that included  
29 the JAFNPP. George Scriba, a resident of Holland, New York, took possession of nearly  
30 0.5 million ac of land in the patent. The patent was divided into 16 townships in Oswego  
31 County, and George Scriba began to sell portions to speculators and settlers (Kozub and Carter  
32 2003).

33 The town of Scriba was created in 1811, although settlers in the area arrived as early as 1798.  
34 The scene for the first non-Indian settlement was at "Scriba Corners." The township of Scriba  
35 flourished throughout the nineteenth century with small farms, apple orchards, and a booming  
36 cider industry. Seven homesteads, a railroad line, and a stave factory (for cider barrels) existed  
37 on the JAFNPP tract in 1867 (Stone 1867).

1 The early economy was based on timber harvesting and lumber production. As forests were  
2 cut, residents moved to farming, especially dairy and fruit production (Churchill 1895). The  
3 Oswego Canal opened in 1828 and the Syracuse & Oswego Railroad opened in 1848. The  
4 canal and railroad precipitated surges in the lumber industry and in agriculture (Churchill 1895).  
5 By 1855 more than half of the county's workers were farmers (Wellman 1987). However, by the  
6 late 1800s, the shipping industry in Oswego collapsed, as did agriculture, and farmers began to  
7 leave. It took Oswego County 90 years to return to the population level of 1870. By 1900, at  
8 least 12 residences had located in the JAFNPP area (USGS 1900). The number of farms and  
9 homes remained relatively stable until 1955, when there were 14 residences (USGS 1955).

10 Camp Oswego, also known as the Camp Drum Anti-Aircraft Artillery Firing Range, was located  
11 immediately to the west of JAFNPP on property now occupied by Nine Mile Point Nuclear  
12 Station (USGS 1955). The camp was established during World War II and continued to operate  
13 well into the 1950s as a summer training base. Sometime after 1956, the camp was closed and  
14 the land was later purchased by Niagara-Mohawk Electric Company for construction of the Nine  
15 Mile Point Nuclear Station.

#### 16 2.2.9.2 *Historic and Archaeological Resources at JAFNPP*

17 During preparation and review of the *Final Environmental Statement Related to Operation of*  
18 *James A. Fitzpatrick Nuclear Power Plant* (AEC 1973), it was determined that no known historic  
19 places and archaeological sites existed within the plant site or in the ROW for the transmission  
20 line. The New York State Historic Preservation Office (SHPO) was contacted during the early  
21 stages of site construction for information about archaeological resources in the vicinity of  
22 JAFNPP and received certification that the plant would not have a harmful effect on any sites of  
23 historic and archaeological importance (AEC 1973). Subsequently, Entergy contacted the New  
24 York State Office of Parks, Recreation, and Historic Preservation (NYSHPO) regarding license  
25 renewal for JAFNPP in February 2006 (Entergy 2006c). In April 2006, NYSHPO responded to  
26 Entergy stating that they consider the project area to be "sensitive for archaeological resources"  
27 (NYSHPO 2006b).

28 The JAFNPP site is generally flat, with the area surrounding the plant largely forested and rural  
29 (Entergy 2006c). Aerial photographs show that a considerable portion (approximately one-third)  
30 of the site has been disturbed due to the construction of JAFNPP. After a review of NYSHPO  
31 site files, NRC staff confirmed that no known archaeological and historic architectural sites have  
32 been recorded at JAFNPP. In addition, according to NYSHPO records, there have been several  
33 archaeological studies and surveys conducted in the vicinity of JAFNPP and one actual study of  
34 the site. The results of these studies are summarized chronologically below.

35 The first known archaeological survey in the vicinity of JAFNPP was conducted in 1977 by Pratt  
36 and Pratt Archaeological Associates, Inc., for Niagara Mohawk Power Corporation. This report  
37 consisted of a literature search and survey for siting a power line and substation (Nine Mile  
38 Point Nuclear Station Unit 2—Volney 765-kV line) that crossed JAFNPP property. The literature

1 review found no recorded prehistoric archaeological sites or National Register properties within  
2 the proposed substation site and corridor area. However, the report indicated there was a high  
3 potential for finding historic sites within the project corridor but only a moderate potential that  
4 these sites would be impacted by the proposed project. In 1983, Pratt and Pratt Archaeological  
5 Associates, Inc., published an addendum to the 1977 report, which did not change the  
6 conclusions of the earlier report.

7 In 1987, a comprehensive literature review and cultural resource inventory was conducted at the  
8 JAFNPP site by Hartgen Archeological Associates, Inc. Again, the literature review found no  
9 recorded prehistoric or historic archaeological sites on file at the New York State Museum or  
10 SHPO. However, Hartgen noted that due to environmental conditions, the JAFNPP site and  
11 surrounding area could have been used for foraging and hunting by limited numbers of  
12 prehistoric peoples for short durations, and concluded that there was a low to moderate  
13 probability of prehistoric sites being found on the plant site. The survey also reported that  
14 historic development within the JAFNPP site consisted primarily of scattered homes along North  
15 Lake Road and Oswego County Route 29. As late as 1955, the number of structures identified  
16 on maps within the JAFNPP property was only 16. Given that these historic structures once  
17 stood on the JAFNPP site, the potential for finding historic resources on the site is high.

18 Most of the other archaeological studies and surveys conducted between 1987 and 2004  
19 consisted of literature searches for water and electric transmission line and roadway projects.  
20 These studies and surveys found no significant prehistoric or historic sites within their project  
21 areas.

22 In October 2006, Entergy contracted Enercon Services, Inc., to perform a phase 1A literature  
23 review and archaeological sensitivity assessment for the JAFNPP site. The assessment  
24 included a walk-over of selected undeveloped portions of the JAFNPP site that were identified  
25 as being potentially sensitive for cultural resources. As stated in previous archaeological  
26 reviews, Enercon also concluded that there is a potential for finding prehistoric sites on the  
27 small knolls and hills next to kettle ponds across the eastern and southern portions of the  
28 JAFNPP property. The assessment also concluded that since the site was mostly orchard  
29 farmland prior to the construction of JAFNPP, it is very likely that historic resources associated  
30 with those farms exist on the site.

31 A walk-over of selected undeveloped portions of the JAFNPP site by NRC staff confirmed the  
32 existence of historic resources on the plant site. Early maps of the JAFNPP area indicate that a  
33 number of structures, mostly of nineteenth-century origin, existed on the JAFNPP site prior to  
34 construction. Most of these sites today consist of foundations and probable associated historic  
35 artifact scatters. Prehistoric cultural resources could also be present in the relatively  
36 undisturbed southern and eastern portions of the JAFNPP site in areas next to kettle ponds.



## 1 **2.2.10 Related Federal Project Activities and Consultations**

2 The NRC staff reviewed the possibility that activities of other Federal agencies might impact the  
3 renewal of the operating license for JAFNPP. Any such activity could result in cumulative  
4 environmental impacts and the possible need for a Federal agency to become a cooperating  
5 agency in the preparation of the JAFNPP SEIS.

6 The 7068-ac Montezuma National Wildlife Refuge, located approximately 44 mi southwest of  
7 JAFNPP serves as a major resting area for waterfowl and other waterbirds on their journeys to  
8 and from nesting areas in northeastern and east-central Canada. This refuge is also in the  
9 middle of one of the most active flight lanes in the Atlantic Flyway (FWS 2006a).

10 The Onondaga Reservation, a 5953-ac Indian reservation, is located in Onondaga County. As  
11 of the 2000 census, the Indian reservation had a population of 1473 (Answers.com 2006).

12 JAFNPP shares an eastern boundary with the Nine Mile Point Nuclear Station, a two-unit  
13 electricity-generating nuclear power plant operated by Nine Mile Point Nuclear Station, LLC.  
14 There are also approximately 25 hydropower electricity-generating facilities within 50 mi of the  
15 JAFNPP site.

16 NRC is required under Section 102 of the National Environmental Policy Act of 1969 (NEPA) to  
17 consult with and obtain the comments of any Federal agency that has jurisdiction by law or  
18 special expertise with respect to any environmental impact involved. Federal agency comment  
19 correspondence is included in Appendix E.

### 20 *2.2.10.1 Coastal Zone Management Act*

21 The Coastal Zone Management Act of 1972 (CZMA) grants the National Oceanic and  
22 Atmospheric Administration (NOAA) the authority to encourage and assist states and territories  
23 with developing management programs that preserve, protect, develop, and, when possible,  
24 restore coastal zone resources. A "coastal zone" is generally described as the coastal waters  
25 and the adjacent shore lands strongly influenced by each other and includes islands, transitional  
26 and intertidal areas, salt marshes, wetlands, beaches, and Great Lakes waters (NOAA 2007).

27 Federal activities that are reasonably likely to affect coastal use or resources, such as license  
28 renewal of nuclear power plants, must be consistent with the approved State coastal  
29 management program (CMP). The federal consistency provision is promulgated in Section  
30 307(c)(3)(a) of the CZMA and requires applicants for Federal licenses or permits to certify that  
31 any proposed activity in the coastal zone is consistent with the enforceable policies of the State  
32 CMP (NOAA 2007). A copy of the applicant's consistency certification, as submitted to the  
33 Federal agency, is provided to the State agency responsible for conducting consistency  
34 reviews. Upon receipt of all necessary information, the State has six months to notify the  
35 applicant and Federal agency of whether it concurs with or objects to the applicant's

1 certification. The Federal license or permit being sought by the applicant cannot be granted  
2 without State approval of the consistency certification (DOC 2003).

3 In 1982, NOAA certified New York State's CMP, as codified in 19 NYCRR Parts 600–601.  
4 Implementation of the CMP and a consistency review are performed by the New York State  
5 Department of State Division of Coastal Resources (NYSDOS 2007). JAFNPP is located on a  
6 Great Lakes coastline that falls under the jurisdiction of the CZMA, and license renewal is a  
7 Federal activity that requires a consistency determination. As such, Entergy submitted a copy  
8 of its New York State CMP certification, as contained within Attachment D of the ER (Entergy  
9 2006c), to the State on July 31, 2006. New York State requires review of the draft SEIS prior to  
10 making a consistency determination. To ensure the six-month review time frame is maintained,  
11 upon request of the State, Entergy withdrew its consistency certification and will resubmit the  
12 certification closer to the date of the draft SEIS issuance (Entergy 2006e).

### 13 *2.2.10.2 Clean Water Act Section 401 Water Quality Certification*

14 Under Section 401 of the Clean Water Act of 1977 (CWA), an applicant for a Federal license or  
15 permit to conduct any activity that may result in discharge into navigable waters must obtain  
16 certification from the appropriate state pollution control agency verifying compliance with the  
17 CWA. A license or permit cannot be granted by the Federal agency until this certification has  
18 been obtained or waived by the State. Furthermore, a license or permit cannot be granted if  
19 certification has been denied by the State, interstate agency, or the EPA Administrator. The  
20 401 Water Quality Certification sets forth applicable effluent limitations and prescribes  
21 monitoring requirements to ensure that the applicant remains in compliance with those  
22 limitations. Any Federal license or permit for a 401 Water Quality Certification that has been  
23 obtained may be suspended or revoked by the issuing Federal agency upon judgment that the  
24 facility or licensed activity has violated its certification or any applicable provisions of the CWA.

25 In New York, the NYSDEC Department of Water reviews and issues Section 401 Water Quality  
26 Certifications. JAFNPP's original 401 Certification and Initial Reporting Requirements is dated  
27 June 1, 1973, and accompanied the original licensing action by the NRC. In accordance with  
28 Section 401 regulations, Entergy submitted a Section 401 Water Quality Certification application  
29 to NYSDEC in April 2007 (Entergy 2007b) to accompany the request for license renewal. Upon  
30 receipt of the application, NYSDEC will have 12 months to review the application and grant or  
31 deny a certification. NYSDEC anticipates issuing a decision for JAFNPP in March 2008,  
32 approximately three months prior to the NRC's expected license renewal decision in May 2008  
33 (assuming the standard 22-month NRC license renewal review timeline). Until NYSDEC has  
34 issued a Section 401 Water Quality Certification for JAFNPP, the NRC will not be able to grant  
35 the license renewal.

## 1 **2.3 References**

- 2 6 NYCRR Part 374. Title 6 of the *Codes, Rules, and Regulations of the State of New York*, Part  
3 374.3. "Management of Specific Hazardous Wastes – Standards for Universal Waste."
- 4 10 CFR Part 20. *Code of Federal Regulations*, Title 10, *Energy*, Part 20, "Standards for  
5 Protection Against Radiation."
- 6 10 CFR Part 50. *Code of Federal Regulations*, Title 10, *Energy*, Part 50, "Domestic Licensing of  
7 Production and Utilization Facilities."
- 8 19 NYCRR Parts 600–601. Title 19 of the *Codes, Rules, and Regulations of the State of New*  
9 *York Chapter XIII: Waterfront Revitalization of Coastal Areas and Inland Waterways*, Parts 600 -  
10 603: Local Government Waterfront Revitalization Programs.
- 11 40 CFR Part 81. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 81,  
12 "Designation of Areas for Air Quality Planning Purposes."
- 13 40 CFR Part 190. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 190,  
14 "Environmental Radiation Protection Standards for Nuclear Power Operations."
- 15 40 CFR Part 260. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 260  
16 "Hazardous Waste Management System: General."
- 17 40 CFR Part 261. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 261,  
18 "Identification and Listing of Hazardous Waste."
- 19 40 CFR Part 273. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 273,  
20 "Standards for Universal Waste Management."
- 21 Answers.com. 2006. Onondaga Reservation, New York. Available URL:  
22 <http://www.answers.com/topic/onondaga-reservation-new-york> (accessed September 5, 2006).
- 23 Boyd, D. and J. Biberhofer. 1999. "Large Volume Sampling at Six Lake Ontario Tributaries  
24 During 1997 and 1998: Project Synopsis and Summary of Selected Results." Available URL:  
25 <http://www.ene.gov.on.ca/envision/techdocs/3927e.pdf> (accessed January 16, 2007).  
26 Accessible at ML070160222.
- 27 Bury, R.B. 1979. "Review of the ecology and conservation of the bog turtle, *Clemmys*  
28 *muhlenbergii*." U.S. Department of the Interior, Fish and Wildlife Service, Special Scientific  
29 Report — Wildlife 2 19: 1-9.
- 30 Churchill, J.C. (ed). 1895. *Landmarks of Oswego County New York*. C.D. Mason and  
31 Company: Syracuse, New York.

Plant and the Environment

- 1 Clean Water Act of 1977. Federal Water Pollution Control Act of 1977, 33 USC 1251, et seq.
- 2 Coastal Zone Management Act of 1972. 16 USC 1456(c)(3)(A).
- 3 Connecticut Department of Environmental Protection (CDEP). 2004a. "Least Bittern Fact  
4 Sheet." Available URL: <http://dep.state.ct.us/burnatr/wildlife/factshts/lebitt.htm> (accessed  
5 December 28, 2006). Accessible at ML070120341.
- 6 Connecticut Department of Environmental Protection (CDEP). 2004b. "Upland Sandpiper Fact  
7 Sheet." Available URL: <http://dep.state.ct.us/burnatr/wildlife/factshts/upsand.htm> (accessed  
8 December 28, 2006). Accessible at ML070120339.
- 9 Cornell Laboratory of Ornithology. 2003. "All About Birds: Pied-billed Grebe." Available URL:  
10 [http://www.birds.cornell.edu/AllAboutBirds/BirdGuide/Pied-billed\\_Grebe\\_dtl.html](http://www.birds.cornell.edu/AllAboutBirds/BirdGuide/Pied-billed_Grebe_dtl.html) (accessed  
11 December 28, 2006). Accessible at ML070120343.
- 12 EA Science and Technology. 2005. *2004 SPDES Biological Monitoring Report James A.  
13 FitzPatrick Nuclear Power Plant (Permit No. NY 0020109, Section 10, CP-04.03)*. Newburgh,  
14 New York. Accessible at ML062970416.
- 15 Entergy Nuclear FitzPatrick, LLC, and Entergy Nuclear Operations, Inc. (Entergy). 2001.  
16 *Nuclear James A. Fitzpatrick, James A. Fitzpatrick Nuclear Power Plant Final Safety Analysis  
17 Report*.
- 18 Entergy Nuclear FitzPatrick, LLC, and Entergy Nuclear Operations, Inc. (Entergy). 2002a.  
19 *Effluent and Waste Disposal, Semi-Annual Report, January 1, 2001 – June 30, 2001*. James A.  
20 FitzPatrick Nuclear Power Plant, Docket No. 50-333, License No. DPR-59.
- 21 Entergy Nuclear FitzPatrick, LLC, and Entergy Nuclear Operations, Inc. (Entergy). 2002b.  
22 *Effluent and Waste Disposal, Semi-Annual Report, July 1, 2001 – December 31, 2001*.  
23 James A. FitzPatrick Nuclear Power Plant, Docket No. 50-333, License No. DPR-59.
- 24 Entergy Nuclear FitzPatrick, LLC, and Entergy Nuclear Operations, Inc. (Entergy). 2003.  
25 *Annual Radioactive Effluent Release Report, January 1, 2002 – December 31, 2002*. James A  
26 FitzPatrick Nuclear Power Plant, Docket No. 50-333, License No. DPR-59.
- 27 Entergy Nuclear FitzPatrick, LLC, and Entergy Nuclear Operations, Inc. (Entergy). 2004a.  
28 *Annual Radioactive Effluent Release Report, January 1, 2003 – December 31, 2003*. James A.  
29 FitzPatrick Nuclear Power Plant, Docket No. 50-333, License No. DPR-59.
- 30 Entergy Nuclear FitzPatrick, LLC, and Entergy Nuclear Operations, Inc. (Entergy). 2004b.  
31 Letter to New York State Department of Environmental Conservation transmitting *Pesticide Use  
32 Annual Report – 2003*. Accessible at ML063620528.

- 1 Entergy Nuclear FitzPatrick, LLC, and Entergy Nuclear Operations, Inc. (Entergy). 2004c.  
2 *Offsite Dose Calculation Manual [ODCM]*, James A. FitzPatrick Nuclear Power Plant, DVP-  
3 01.02, Revision 9.
- 4 Entergy Nuclear FitzPatrick, LLC, and Entergy Nuclear Operations, Inc. (Entergy). 2005a.  
5 *Annual Radioactive Effluent Release Report, January 1, 2004 – December 31, 2004*. James A.  
6 FitzPatrick Nuclear Power Plant, Docket No. 50-333, License No. DPR-59.
- 7 Entergy Nuclear FitzPatrick, LLC, and Entergy Nuclear Operations, Inc. (Entergy). 2005b.  
8 *Annual Radiological Environmental Operating Report, January 1, 2005 – December 31, 2005*.  
9 James A. FitzPatrick Nuclear Power Plant, Docket No. 50-333, License No. DPR-59.
- 10 Entergy Nuclear FitzPatrick, LLC, and Entergy Nuclear Operations, Inc. (Entergy). 2005c.  
11 Letter to New York State Dept of Environmental Conservation transmitting *Pesticide Use Annual*  
12 *Report – 2004*. Accessible at ML063620527.
- 13 Entergy Nuclear FitzPatrick, LLC, and Entergy Nuclear Operations, Inc. (Entergy). 2005d.  
14 Letter from P. Sullivan, Entergy, to E. Dassatti, NYSDEC. November 3, 2005. Accessible at  
15 ML063620372.
- 16 Entergy Nuclear FitzPatrick, LLC, and Entergy Nuclear Operations, Inc. (Entergy). 2006a.  
17 *Annual Radioactive Effluent Release Report, January 1, 2005 – December 31, 2005*. James A.  
18 FitzPatrick Nuclear Power Plant, Docket No. 50-333, License No. DPR-59.
- 19 Entergy Nuclear FitzPatrick, LLC, and Entergy Nuclear Operations, Inc. (Entergy). 2006b.  
20 *Entergy Nuclear Waste Minimization Plan*. ENWMP Revision 0. July 2006. Accessible at  
21 ML063630214.
- 22 Entergy Nuclear FitzPatrick, LLC, and Entergy Nuclear Operations, Inc. (Entergy). 2006c.  
23 *James A. FitzPatrick Nuclear Power Plant — License Renewal Application, Appendix E:*  
24 *Applicant's Environmental Report, Operating License Renewal Stage*. Lycoming, New York.  
25 Accessible at ML062160557.
- 26 Entergy Nuclear FitzPatrick, LLC, and Entergy Nuclear Operations, Inc. (Entergy). 2006d.  
27 Letter to New York State Department of Environmental Conservation transmitting *Pesticide Use*  
28 *Annual Report – 2005*. Accessible at ML063620524.
- 29 Entergy Nuclear FitzPatrick, LLC, and Entergy Nuclear Operations, Inc. (Entergy). 2006e.  
30 Letter to New York State Department of State requesting withdrawal of Coastal Zone  
31 Management Consistency Certification. November 20, 2006. Accessible at ML063620296.
- 32 Entergy Nuclear FitzPatrick, LLC, and Entergy Nuclear FitzPatrick, LLC (Entergy). 2006f.  
33 *Proposal For Information Collection To Address Compliance With the Clean Water Act §316(b)*

Plant and the Environment

- 1 *Phase II Regulations at James A. FitzPatrick Nuclear Power Plant (SPDES Permit No. NY*  
2 *0020109) Lycoming, New York.* Lycoming, New York. Accessible at ML063560153.
- 3 Entergy Nuclear FitzPatrick, LLC, and Entergy Nuclear Operations, Inc. (Entergy). 2006g.  
4 White Paper Response for Site Audit Documents Request. Accessible at ML063620277.
- 5 Entergy Nuclear FitzPatrick, LLC, and Entergy Nuclear Operations, Inc. (Entergy). 2007a.  
6 Email from M. Rodgers, Entergy, to J. Muir, NRC. Subject: Firing Range Question and  
7 Answers. January 26, 2007. Accessible at ML070260528.
- 8 Entergy Nuclear FitzPatrick, LLC, and Entergy Nuclear Operations, Inc. (Entergy). 2007b.  
9 Letter from P. Dietrich, Entergy, to NYSDEC regarding submittal of Joint Permit Application, 401  
10 Water Quality Certification. April 10, 2007. Accessible at ML071170388.
- 11 Environment Canada (EC). 2000. State of Lakes Ecosystem Conference. Nearshore Waters  
12 of the Great Lakes. Available at: [http://www.on.ec.gc.ca/solec/nearshore-](http://www.on.ec.gc.ca/solec/nearshore-water/paper/part1.html)  
13 [water/paper/part1.html](http://www.on.ec.gc.ca/solec/nearshore-water/paper/part1.html) (accessed April 9, 2007). Accessible at ML071000457.
- 14 FedStats. 2006. "MapStats: New York." Available URL: [http://www.fedstats.gov/qf/](http://www.fedstats.gov/qf/states/36000.html)  
15 [states/36000.html](http://www.fedstats.gov/qf/states/36000.html) (accessed December 21, 2006). Accessible at ML071130377.
- 16 Great Lakes Fishery Commission (GLFC). 1994. *Joint Strategic Plan for Management of Great*  
17 *Lakes Fisheries.* GLFC: Ann Arbor, Michigan. Available URL: [http://www.glf.org/pubs/](http://www.glf.org/pubs/slgcon.htm)  
18 [sglcon.htm](http://www.glf.org/pubs/slgcon.htm) (accessed January 31, 2007).
- 19 Great Lakes Fishery Commission (GLFC). 2006. *Great Lakes Fishery Commission.* Available  
20 URL: <http://www.glf.org/> (accessed November 29, 2006). Accessible at ML070160387.
- 21 Great Lakes Fishery Commission (GLFC). 2007. Lake Committees: Science Transfer  
22 Program. Available URL: <http://www.glf.org/fishmgmt/stp.php> (accessed February 8, 2007).
- 23 Great Lakes St. Lawrence Seaway System (GLSLSS). 2006. *Port of Oswego.* Available URL:  
24 <http://www.greatlakes-seaway.com/en/ports/portofoswego.html> (accessed October 17, 2006).  
25 Accessible at ML070160395.
- 26 Groombridge, B. 1982. *The IUCN Amphibia-Reptilia Red Data Book: Testudines, Crocodylia,*  
27 *Rhynchocephalia.* International Union for the Conservation of Nature and Natural Resources  
28 (IUCN), Gland, Switzerland. Part 1.
- 29 Heritage Power, LLC. 2000. Heritage Station Application for Certification of a Major Generating  
30 Facility Under Article X of the New York State Public Service Law.
- 31 International Joint Commission (IJC). 2004. *Twelfth Biennial Report on Great Lakes Water*  
32 *Quality.* Available URL: <http://www.ijc.org/php/publications/html/12br/english/report/index.html>  
33 (accessed February 8, 2007). Accessible at ML070390585.

- 1 International St. Lawrence River Board of Control (ISLRBC). 2002a. Lake Ontario St.  
2 Lawrence River Regulation. Available URL: <http://www.islrbc.org/new-Version/brochure.html>  
3 (accessed November 7, 2004). Accessible at ML060940107.
- 4 International St. Lawrence River Board of Control (ISLRBC). 2002b. FAQ. Available URL:  
5 <http://www.islrbc.org/new-Version/faqs.html> (accessed November 7, 2004). Accessible at  
6 ML060940110.
- 7 International St. Lawrence River Board of Control (ISLRBC). 2004. Available URL:  
8 [http://www.ijc.org/en/home/main\\_accueil.htm](http://www.ijc.org/en/home/main_accueil.htm) (accessed November 7, 2004). Accessible at  
9 ML060940115.
- 10 Jackson, L.J. 1997. "Piscivores, Predation, and PCBs in Lake Ontario's Pelagic Food Web."  
11 *Ecological Applications*, (7)3:991-1001. Accessible at ML070170447.
- 12 Kozub, A.Z. and C.C. Carter. 2003. *Cultural Resource Management Program Report 2002*  
13 *Highway Program PIN 23045.50.121 NY 104 Towns of Scriba and New Haven, Oswego*  
14 *County, New York*. Binghamton University, State University of New York; Binghamton, New  
15 York.
- 16 Microsoft Corporation. 2005. "Microsoft Terraserver Imagery." Available URL:  
17 <http://terraserver.homeadvisor.msn.com/default.aspx> (accessed December 27, 2006).
- 18 Mills, E.L., R. Dermott, M. Munawar, S. Millard, O. Johannsson, and L. Rudstam. 2003. *Status*  
19 *of the Lake Ontario Food Web in a Changing Ecosystem: the 2003 Lake Ontario Lower Aquatic*  
20 *Food Web Assessment (LOLA)*. Available URL: [http://epa.gov/greatlakes/lakeont/lola/](http://epa.gov/greatlakes/lakeont/lola/lola2006.pdf)  
21 [lola2006.pdf](http://epa.gov/greatlakes/lakeont/lola/lola2006.pdf) (accessed January 16, 2007). Accessible at ML070160569.
- 22 Mills, E.L., J.M. Casselman, R. Dermott, J.D. Fitzsimons, G. Gal, K.T. Holeck, J.A. Hoyle, O.E.  
23 Johannsson, B.F. Lantry, and J.C. Makarewicz. 2005. *A Synthesis of Ecological and Fish-*  
24 *Community Changes in Lake Ontario, 1970–2000*. Available URL: [http://www.glfc.org/pubs/](http://www.glfc.org/pubs/TechReports/Tr67.pdf)  
25 [TechReports/Tr67.pdf](http://www.glfc.org/pubs/TechReports/Tr67.pdf) (accessed January 16, 2007). Accessible at ML070160214.
- 26 Monroe County Water Authority (MCWA). 2001. "2000 Water Quality Monitoring Program  
27 Summary," *MCWA 2000 Annual Water Quality Report*. Rochester, New York.
- 28 National Environmental Policy Act of 1969 (NEPA). 42 USC 4321, et. seq.
- 29 National Oceanic and Atmospheric Administration (NOAA). 2004a. *Climatology of the U.S. #84*  
30 *– Daily Normals Online Individual Station, Oswego East, New York, NY COOP ID#306314*.  
31 National Climatic Data Center, NOAA. Available URL: [http://cdo.ncdc.noaa.gov/cgi-](http://cdo.ncdc.noaa.gov/cgi-bin/climatenormals/climatenormals.pl)  
32 [bin/climatenormals/climatenormals.pl](http://cdo.ncdc.noaa.gov/cgi-bin/climatenormals/climatenormals.pl) (accessed January 5, 2007).

Plant and the Environment

- 1 National Oceanic and Atmospheric Administration (NOAA). 2004b. *Storm Events*. National  
2 Climatic Data Center, NOAA. Available URL: <http://www4.ncdc.noaa.gov/cgi-win/>  
3 [wwcgi.dll?wwevent~storms](http://www4.ncdc.noaa.gov/cgi-win/wwcgi.dll?wwevent~storms) (accessed January 4, 2007).
- 4 National Oceanic and Atmospheric Administration (NOAA). 2007. *Ocean and Coastal*  
5 *Resource Management: Federal Consistency*. Available URL: [http://www.coastalmanagement.](http://www.coastalmanagement.noaa.gov/consistency/welcome.html)  
6 [noaa.gov/consistency/welcome.html](http://www.coastalmanagement.noaa.gov/consistency/welcome.html) (accessed January 25, 2007).
- 7 New York Power Authority (NYPA). 1998. *Systemwide Right-of-Way Management Plan*.  
8 Accessible at ML063620305.
- 9 New York Power Authority (NYPA). 2000. Letter from J. Kahabka, NYPA, to J. Dolan, Jr.,  
10 NYSDEC. (June 2, 2000). Accessible at ML063620533.
- 11 New York State Department of Environmental Conservation (NYSDEC). 1999a. *Endangered &*  
12 *Threatened Fishes of New York – Deepwater Sculpin*. Available URL: [http://www.dec.state.ny](http://www.dec.state.ny.us/website/dfwmr/fish/fishspecs/endgtext.html#deepwatersculpin)  
13 [.us/website/dfwmr/fish/fishspecs/endgtext.html#deepwatersculpin](http://www.dec.state.ny.us/website/dfwmr/fish/fishspecs/endgtext.html#deepwatersculpin) (accessed January 16, 2007).  
14 Accessible at ML070160375.
- 15 New York State Department of Environmental Conservation (NYSDEC). 1999b. *Endangered &*  
16 *Threatened Fishes of New York – Lake Chubsucker*. Available URL: [http://www.dec.state.ny](http://www.dec.state.ny.us/website/dfwmr/fish/fishspecs/endgtext.html#lakechubsucker)  
17 [.us/website/dfwmr/fish/fishspecs/endgtext.html#lakechubsucker](http://www.dec.state.ny.us/website/dfwmr/fish/fishspecs/endgtext.html#lakechubsucker) (accessed January 16, 2007).  
18 Accessible at ML070160380.
- 19 New York State Department of Environmental Conservation (NYSDEC). 1999c. *Endangered &*  
20 *Threatened Fishes of New York – Round Whitefish*. Available URL: [http://www.dec.state.ny.us/](http://www.dec.state.ny.us/website/dfwmr/fish/fishspecs/endgtext.html#roundwhitefish)  
21 [website/dfwmr/fish/fishspecs/endgtext.html#roundwhitefish](http://www.dec.state.ny.us/website/dfwmr/fish/fishspecs/endgtext.html#roundwhitefish) (accessed January 16, 2007).  
22 Accessible at ML070160371.
- 23 New York State Department of Environmental Conservation (NYSDEC). 1999d. *Redfin Shiner*  
24 *Fact Sheet*. Available URL: [http://www.dec.state.ny.us/website/dfwmr/wildlife/endspec/](http://www.dec.state.ny.us/website/dfwmr/wildlife/endspec/redfinshine.html)  
25 [redfinshine.html](http://www.dec.state.ny.us/website/dfwmr/wildlife/endspec/redfinshine.html) (accessed January 16, 2007). Accessible at ML070160421.
- 26 New York State Department of Environmental Conservation (NYSDEC). 1999e. *New York’s*  
27 *Sturgeon: Lake Sturgeon*. Available URL: [http://www.dec.state.ny.us/website/dfwmr/fish/](http://www.dec.state.ny.us/website/dfwmr/fish/fishspecs/sturtext.html#lakesturgeon)  
28 [fishspecs/sturtext.html#lakesturgeon](http://www.dec.state.ny.us/website/dfwmr/fish/fishspecs/sturtext.html#lakesturgeon) (accessed January 16, 2007). Accessible at  
29 ML070160401.
- 30 New York State Department of Environmental Conservation (NYSDEC). 2000a. Letter from  
31 B. Barrow, NYSDEC, to W. Slade, NYPA. September 15, 2000. Accessible at ML063620533.
- 32 New York State Department of Environmental Conservation (NYSDEC). 2000b. *New York*  
33 *State Water Quality 2000—Submitted Pursuant to Section 305(b) of the Federal Clean Water*  
34 *Act Amendments of 1977 (PL 95-217)*. Albany, New York. October. Available URL:



- 1 <http://www.dec.state.ny.us/website/dow/305b00.pdf> (accessed November 7, 2004). Accessible  
2 at ML060940126.
- 3 New York State Department of Environmental Conservation (NYSDEC). 2001. New York State  
4 Department of Environmental Conservation State Pollutant Discharge Elimination System  
5 Discharge Permit. NY-0020109. August 1, 2001.
- 6 New York State Department of Environmental Conservation (NYSDEC). 2004. *2004 Status of  
7 the Lake Ontario Ecosystem: A Biomonitoring Approach*. Available URL: [http://www.dec.state  
8 .ny.us/website/dfwmr/fish/lorpt04sec20.pdf](http://www.dec.state.ny.us/website/dfwmr/fish/lorpt04sec20.pdf) (accessed January 16, 2007). Accessible at  
9 ML070160338.
- 10 New York State Department of Environmental Conservation (NYSDEC). 2006a. "Current  
11 Situation on Chronic Wasting Disease in New York." Available URL: [http://www.dec.state.ny.us/  
12 websitedfwmr/wildlife/deer/currentcwd.html](http://www.dec.state.ny.us/website/dfwmr/wildlife/deer/currentcwd.html) (accessed December 26, 2006). Accessible at  
13 ML070120324.
- 14 New York State Department of Environmental Conservation (NYSDEC). 2006b. Press release:  
15 "DEC Provides Information on Spring Caterpillar Pests." Available URL: [http://www.dec.state  
16 .ny.us/website/dlf/privland/forprot/health/caterpillar/index.html](http://www.dec.state.ny.us/website/dlf/privland/forprot/health/caterpillar/index.html) (accessed November 14, 2006).  
17 Accessible at ML070120322.
- 18 New York State Department of Environmental Conservation (NYSDEC). 2006c. "Distribution of  
19 Samples Collected Statewide for the Chronic Wasting Disease Surveillance Project." Available  
20 URL: <http://www.dec.state.ny.us/website/dfwmr/wildlife/deer/cwdmap.html> (accessed  
21 December 26, 2006). Accessible at ML070120318.
- 22 New York State Department of Environmental Conservation (NYSDEC). 2006d. "Habitats in  
23 New York State." Available URL: [http://www.dec.state.ny.us/website/dfwmr/swg/habitats.html  
24 Habitats in New York State](http://www.dec.state.ny.us/website/dfwmr/swg/habitats.html) (accessed December 29, 2006). Accessible at ML070120317.
- 25 New York State Department of Environmental Conservation (NYSDEC). 2006e. "Investigation  
26 of Lake Ontario Shore Bird and Fish Deaths Continues." Available URL: [http://www.dec.state  
27 .ny.us/website/environmentdec/2006b/birdfishdeath072006.html](http://www.dec.state.ny.us/website/environmentdec/2006b/birdfishdeath072006.html) (accessed November 14,  
28 2006). Accessible at ML070120316.
- 29 New York State Department of Environmental Conservation (NYSDEC). 2006f. Press release:  
30 "New York State Announces Efforts to Help Control Spread of Sirex Wood Wasp." Available  
31 URL: <http://www.dec.state.ny.us/website/press/pressrel/2006/2006152.html> (accessed  
32 November 14, 2006). Accessible at ML070120313.
- 33 New York State Department of Environmental Conservation (NYSDEC). 2006g. Letter from T.  
34 Seoane, Information Services, New York Natural Heritage Program. Subject: Natural Heritage  
35 Report on Rare Species and Ecological Communities. Not publicly available.

Plant and the Environment

- 1 New York State Department of Environmental Conservation (NYSDEC). 2006g. "2006 Section  
2 303(d) List of Impaired Waters Requiring a TMDL." Available URL <http://www.dec.state.ny.us/>  
3 [website/dow/303d2006.pdf](http://www.dec.state.ny.us/website/dow/303d2006.pdf) (accessed April 9, 2007). Accessible at ML071000465.
- 4 New York State Department of Health. 2007. *1995 – 2004 Annual Report, Report of*  
5 *Environmental Radiation In New York State* (Working Draft). New York State Department of  
6 Health, Bureau of Environmental Radiation Protection.
- 7 New York State Department of Labor (NYSDOL). 2006. "Workforce New York." Available  
8 URL: <http://www.labor.state.ny.us/> (accessed December 21, 2006). Accessible at  
9 ML071130372.
- 10 New York State Department of State Division of Coastal Resources (NYSDOS). 2006.  
11 *Significant Coastal Fish and Wildlife Habitats*. Available URL: [http://www.nyswaterfronts.com/](http://www.nyswaterfronts.com/waterfront_natural_narratives.asp)  
12 [waterfront\\_natural\\_narratives.asp](http://www.nyswaterfronts.com/waterfront_natural_narratives.asp) (accessed January 16, 2007). Accessible at ML070160399.
- 13 New York State Department of State Division of Coastal Resources (NYSDOS). 2007. Coastal  
14 Resources Online: Consistency Review. Available URL: [http://nyswaterfronts.com/](http://nyswaterfronts.com/consistency.asp)  
15 [consistency.asp](http://nyswaterfronts.com/consistency.asp) (accessed January 25, 2007).
- 16 New York State Office of Parks, Recreation and Historic Preservation (NYSHPO). 2006a. "Fair  
17 Haven Beach State Park" Available URL: [http://nysparks.state.ny.us/parks/](http://nysparks.state.ny.us/parks/info.asp?parkID=34) info.asp?parkID=34  
18 (accessed December 27, 2006). Accessible at ML070120311.
- 19 New York State Office of Parks, Recreation and Historic Preservation (NYSHPO). 2006b.  
20 Letter from H. Heter, Historic Preservation Program Specialist, New York State Office of Parks,  
21 Recreation and Historic Preservation, to T.A. Sullivan, Site Vice President, JAFNPP. Subject:  
22 JAFNPP License Renewal, Town of Scriba, Oswego County. April 27, 2006.
- 23 New York State Office of Parks, Recreation and Historic Preservation (NYSHPO). 2006c.  
24 "Selkirk Shores State Park" Available URL: [http://nysparks.state.ny.us/parks/info.asp](http://nysparks.state.ny.us/parks/info.asp?parkID=24)  
25 [?parkID=24](http://nysparks.state.ny.us/parks/info.asp?parkID=24) (accessed December 27, 2006). Accessible at ML070120309.
- 26 Niagara Mohawk Power Corporation (NMPC). 1975. Nine Mile Point Unit 1 316(a)  
27 Demonstration Submission, NPDES Permit NY 0001015. Syracuse, New York.
- 28 Niagara Mohawk Power Corporation (NMPC). 1985. *Environmental Report: Operating License*  
29 *State Nine Mile Point Nuclear Station Unit 2. Volume 1*. February 8, 1985.
- 30 Nine Mile Point Nuclear Station, LLC (NMPNS). 2002a. *Nine Mile Point Nuclear Station—*  
31 *Unit 2 Final Safety Analysis Report (Updated)*. Revision 15, Docket Number 50-410, Lycoming,  
32 New York.

- 1 Onondaga County Parks. 2006. "Beaver Lake Nature Center." Available URL:  
2 <http://onondagacountyparks.com/parks/beaver/> (accessed December 27, 2006). Accessible at  
3 ML070120302.
- 4 Ontario Ministry of the Environment (OME). 1999. *Deepwater Sculpin return to Lake Ontario*.  
5 Available URL: <http://www.ene.gov.on.ca/cons/3628e.pdf> (accessed January 16, 2007).  
6 Accessible at ML070160342.
- 7 Ontario Ministry of Natural Resources (OMNR). 2006. *MNR Fish Stocking Summary 2005*.  
8 Available URL: <http://www.mnr.gov.on.ca/fishing/stocking2005.html> (accessed January 16,  
9 2007). Accessible at ML070160398.
- 10 Oswego County Department of Planning and Community Development (OCDPCD). 1997.  
11 *Oswego County Comprehensive Plan*. OCDPCD, Oswego, New York. Available URL:  
12 <http://www.co.oswego.ny.us/pdf/compplan.pdf> (accessed October 23, 2006). Accessible at  
13 ML071130370.
- 14 Oswego County Department of Planning and Community Development (OCDPCD). 1999.  
15 *Oswego County Development Regulation Guide*. OCDPCD, Oswego, New York. Accessible at  
16 ML071140281.
- 17 Oswego County. 2006. *2007 Oswego County Business Guide*. Oswego, New York.  
18 Accessible at ML071130379. Accessible at ML071140266.
- 19 The Paleontological Research Institution (PRI). 2006. "Formation of the Finger Lakes."  
20 Available URL: [http://www.priweb.org/ed/finger\\_lakes/nystate\\_geo3.html](http://www.priweb.org/ed/finger_lakes/nystate_geo3.html) (accessed  
21 November 28, 2006). Accessible at ML070120391.
- 22 Parks Canada (PC). 2006. *Lake Ontario*. Available URL: [http://www.pc.gc.ca/progs/amnc  
23 -nmca/systemplan/itm4-/gla6\\_e.asp](http://www.pc.gc.ca/progs/amnc-nmca/systemplan/itm4-/gla6_e.asp) (accessed January 16, 2007). Accessible at  
24 ML070160415.
- 25 Plant Conservation Alliance (PCA), Alien Plant Working Group. 2006a. "Common Reed."  
26 Available URL: <http://www.nps.gov/plants/alien/fact/phau1.htm> (accessed December 26, 2006).  
27 Accessible at ML070120384.
- 28 Plant Conservation Alliance (PCA), Alien Plant Working Group. 2006b. "Japanese Knotweed."  
29 Available URL: <http://www.nps.gov/plants/alien/fact/pocu1.htm> (accessed December 26, 2006).  
30 Accessible at ML070120378.
- 31 Renewable Resource Data Center. 2004. New York annual average wind power. Available  
32 URL: <http://rredc.nrel.gov/wind/pubs/atlas/maps/chap3/3-25m.html> (accessed October 20,  
33 2005).

- 1 Ritchie, W.A. and R.E. Funk. 1973. *Aboriginal Settlement Patterns in the Northeast*. University  
2 of New York, Albany.
- 3 Ritchie, W.A. 1994. *The Archaeology of New York State*. Purple Mountain Press, Limited,  
4 New York, New York.
- 5 Royal Ontario Museum (ROM). 2006. *Species at Risk – Lake Chubsucker*. Available URL:  
6 [http://www.rom.on.ca/ontario/risk.php?doc\\_type=fact&lang=&id=76](http://www.rom.on.ca/ontario/risk.php?doc_type=fact&lang=&id=76) (accessed January 16,  
7 2007). Accessible at ML070160411.
- 8 State University of New York (SUNY) at Oswego. 2006a. “Biology of Rice Creek Field Station.”  
9 Available URL: [http://www.oswego.edu/academics/opportunities/rice\\_creek\\_field\\_station/  
10 biology/index.html](http://www.oswego.edu/academics/opportunities/rice_creek_field_station/biology/index.html) (accessed November 14, 2006). Accessible at ML070120376.
- 11 State University of New York (SUNY) at Oswego. 2006b. “Mammals of Rice Creek Field  
12 Station” Available URL: [http://www.oswego.edu/academics/opportunities/rice\\_creek\\_field  
13 \\_station/biology/vertebrates/mammals.html](http://www.oswego.edu/academics/opportunities/rice_creek_field_station/biology/vertebrates/mammals.html) (accessed November 28, 2006). Accessible at  
14 ML070120351.
- 15 State University of New York (SUNY) at Oswego. 2006c. “Reptiles and Amphibians of Rice  
16 Creek Field Station.” Available URL: [http://www.oswego.edu/academics/opportunities/  
17 rice\\_creek\\_field\\_station/biology/vertebrates/herps.html](http://www.oswego.edu/academics/opportunities/rice_creek_field_station/biology/vertebrates/herps.html) (accessed November 14, 2006).  
18 Accessible at ML070120351.
- 19 Stewart, T.J., R.E. Lange, S.D. Orsatti, C.P. Schneider, A. Mathers, and M.E. Daniels. 1999.  
20 “Fish-Community Objectives For Lake Ontario.” *Great Lakes Fish. Comm. Spec. Pub. 99-1*.  
21 Available URL: [://www.glf.org/pubs/SpecialPubs/Sp99\\_1.pdf](http://www.glf.org/pubs/SpecialPubs/Sp99_1.pdf) (accessed January 16, 2006).  
22 Accessible at ML070160345.
- 23 Syracuse-Onondaga County Planning Agency. 2001. *Onondaga County Settlement Plan*. The  
24 Regional Plan and Pilot Projects, Duany Plater-Zyberk and Company, Syracuse, New York.  
25 Accessible at ML071140268.
- 26 Syracuse-Onondaga County Planning Agency. 2006. County Land Use Data.
- 27 Stone, C.K. 1867. *Topographical Atlas of Oswego County*. Philadelphia.
- 28 Toxic Substances Control Act of 1976. 15 USC s/s 2601 et seq.
- 29 United States Department of Commerce (DOC). 2003. Consistency Appeal of Millennium  
30 Pipeline Co., L.P. from an Objection by the State of New York. Available URL: [http://www.ogc  
31 .doc.gov/czma.nsf/F9A7796F451A71048525720400718AAB/\\$File/Milennium+Decision.pdf  
32 ?OpenElement](http://www.ogc.doc.gov/czma.nsf/F9A7796F451A71048525720400718AAB/$File/Milennium+Decision.pdf) (accessed January 25, 2007).
- 33 U.S. Army Corps of Engineers (Buffalo District) (USACE). 2002. *Monthly Bulletin of Great*

- 1 *Lakes Water Levels*. Available URL: <http://huron.1re.usace.army.mil/levels/bltnhmpg.html>  
2 (accessed October 24, 2002). Accessible at ML060960348.
- 3 U.S. Atomic Energy Commission (AEC). 1973. *Final Environmental Statement Related to*  
4 *Operation of James A. JAFNPP Nuclear Power Plant*. Docket No. 50-333. Directorate of  
5 Licensing. Washington, D.C. Accessible at ML062360088.
- 6 U.S. Atomic Energy Commission (AEC). 1974. *Final Environmental Statement Related to the*  
7 *Operation of Nine Mile Nuclear Station Unit 1*. Niagara Mohawk Power Corporation. Docket  
8 No. 50-220. Directorate of Licensing. Washington, D.C. January 1974.
- 9 U.S. Census Bureau (USCB). 2006a. "American Fact Finder." Available URL: <http://factfinder>  
10 [.census.gov](http://factfinder.census.gov) (accessed October 5, 2006). Accessible at ML071130367.
- 11 U.S. Census Bureau (USCB). 2006b. "2004 County Business Patterns (NAICS)." Available  
12 URL: <http://censtats.census.gov/cbpaic/cbpaic.shtml> (accessed October 30, 2006).  
13 Accessible at ML071130362.
- 14 U.S. Department of Agriculture. 2002. New York Agricultural Statistics Service. *Onandago*  
15 *County (New York) Farm Statistics*. Available URL: [www.nass.usda.gov/Statistics\\_by\\_State/](http://www.nass.usda.gov/Statistics_by_State/New_York/County_Profiles/Onondaga.pdf)  
16 [New\\_York/County\\_Profiles/Onondaga.pdf](http://www.nass.usda.gov/Statistics_by_State/New_York/County_Profiles/Onondaga.pdf) (accessed September 25, 2006). Accessible at  
17 ML071140264.
- 18 U.S. Environmental Protection Agency, Environment Canada, New York State Department of  
19 Environmental Conservation, and Ontario Ministry of the Environment (EPA et al.). 1998.  
20 "Stage 1: Problem Definition." *Lakewide Management Plan for Lake Ontario*. Available URL:  
21 <http://www.epa.gov/glnpo/lakeont> (accessed on November 7, 2004). Accessible at  
22 ML060940262.
- 23 U.S. Environmental Protection Agency (EPA). 2005. *Great Lakes Monitoring Limnology*  
24 *Program*. Available URL: <http://www.epa.gov/glnpo/monitoring/limnology/#tp> (accessed  
25 February 8, 2005). Accessible at ML060940275.
- 26 U.S. Environmental Protection Agency (EPA). 2006a. *Great Lakes: Lake Ontario*. Available  
27 URL: <http://www.epa.gov/glnpo/ontario.html> (accessed January 16, 2007). Accessible at  
28 ML070160391.
- 29 U.S. Environmental Protection Agency (EPA). 2006b. *Lake Ontario Lakewide Management*  
30 *Plan Status*. Available URL: <http://epa.gov/glnpo/lakeont/2006/LO2006.pdf> (accessed January  
31 16, 2007). Accessible at ML070160337.
- 32 U.S. Environmental Protection Agency (EPA). 2006c. "Vegetated Buffers." Available URL:  
33 [http://cfpub.epa.gov/npdes/stormwater/menuofbmps/index.cfm?action=factsheet\\_results&view=](http://cfpub.epa.gov/npdes/stormwater/menuofbmps/index.cfm?action=factsheet_results&view=specific&bmp=50)  
34 [specific&bmp=50](http://cfpub.epa.gov/npdes/stormwater/menuofbmps/index.cfm?action=factsheet_results&view=specific&bmp=50) (accessed December 28, 2006). Accessible at ML070120337.

Plant and the Environment

- 1 U.S. Environmental Protection Agency (EPA). 2006d. *The Great Lakes: An Environmental*  
2 *Atlas and Resource Book*. Available URL: <http://www.epa.gov/glnpo/atlas/gl-fact1.html>  
3 (accessed April 9, 2007). Accessible at ML071000465.
- 4 U.S. Fish & Wildlife Service (FWS). 1983. *Recovery Plan for the Indiana Bat*. Available URL:  
5 [http://ecos.fws.gov/docs/recovery\\_plans/2005/051215.pdf](http://ecos.fws.gov/docs/recovery_plans/2005/051215.pdf) (accessed December 29, 2006).  
6 Accessible at ML070110342.
- 7 U.S. Fish & Wildlife Service (FWS). 2001. "Bog Turtle (*Clemmys muhlenbergii*), Northern  
8 Population Recovery Plan." Available URL: [http://ecos.fws.gov/docs/recovery\\_plans/](http://ecos.fws.gov/docs/recovery_plans/2001/010515.pdf)  
9 [2001/010515.pdf](http://ecos.fws.gov/docs/recovery_plans/2001/010515.pdf) (accessed December 28, 2006.) Accessible at ML070110336.
- 10 U.S. Fish and Wildlife Service (FWS). 2006a. *Montezuma National Wildlife Refuge*. Available  
11 URL: <http://www.fws.gov/r5mnwr> (accessed September 5, 2006). Accessible at ML071140281.
- 12 U.S. Fish and Wildlife Service (FWS). 2006b. "Species Profile: Indiana bat (*Myotis sodalis*)"  
13 Available URL: <http://ecos.fws.gov/speciesProfile/SpeciesReport.do?sPCODE=A000> (accessed  
14 December 29, 2006). Accessible at ML070120336.
- 15 U.S. Fish and Wildlife Service (FWS). 2006c. "Wetlands Digital Data." Available URL:  
16 <http://wetlandsfws.er.usgs.gov/NWI/index.html> (accessed November 14, 2006). Accessible at  
17 ML070120330.
- 18 U.S. Geological Survey (USGS). 1900. Fulton, New York. 15-minute quadrangle map  
19 [reprinted 1932].
- 20 U.S. Geological Survey (USGS). 1955. Fulton, New York, N4315-W7615/17.5X15, 15-minute  
21 quadrangle map.
- 22 U.S. Geological Survey (USGS). 1982. West of Texas, New York. 7.5-minute quadrangle map  
23 (1955 edition photo, revised in 1982).
- 24 U.S. Nuclear Regulatory Commission (NRC). 1985. *Final Environmental Statement Related*  
25 *to the Operation of Nine Mile Nuclear Station Unit 2*. Niagara Mohawk Power Corporation,  
26 Rochester Gas and Electric Corporation, Central Hudson Gas and Electric Corporation, New  
27 York State Electric and Gas Corporation, Long Island Lighting Company. Docket No. 50-410.  
28 Office of Nuclear Reactor Regulation. Washington, D.C. May 1985.
- 29 U.S. Nuclear Regulatory Commission (NRC). 1996. *Generic Environmental Impact Statement*  
30 *for License Renewal of Nuclear Plants. NUREG-1437, Volumes 1 and 2*. Washington, D.C.
- 31 U.S. Nuclear Regulatory Commission (NRC). 1999. *Generic Environmental Impact Statement*  
32 *for License Renewal of Nuclear Plants, Main Report*, "Section 6.3 – Transportation, Table 9.1,  
33 Summary of findings on NEPA issues for license renewal of nuclear power plants, Final Report."  
34 NUREG-1437, Volume 1, Addendum 1, Washington, D.C.

- 1 U.S. Nuclear Regulatory Commission (NRC). 2006. *Generic Environmental Impact Statement*  
2 *for License Renewal of Nuclear Plants: Regarding Nine Mile Point Nuclear Station, Units 1*  
3 *and 2*. Final Report. NUREG-1437, Supplement 24. Office of Nuclear Reactor Regulation,  
4 Washington, D.C.
- 5 Wellman, J. (ed). 1987. *Landmarks of Oswego*. Syracuse University Press, Syracuse,  
6 New York.
- 7 Wisconsin Sea Grant (WSG). 2006. *Fish of Lake Ontario*. Available URL: [http://www.seagrant](http://www.seagrant.wisc.edu/greatlakesfish/LakeOntFishIndex.html)  
8 [.wisc.edu/greatlakesfish/LakeOntFishIndex.html](http://www.seagrant.wisc.edu/greatlakesfish/LakeOntFishIndex.html) (accessed January 16, 2007). Accessible at  
9 ML070160384.
- 10 Zilkoski, D.B., J.H. Richards, and G.M. Young. 1992. *Results of the General Adjustment of the*  
11 *North American Vertical Datum of 1988*. National Geodetic Survey.





### 3.0 ENVIRONMENTAL IMPACTS OF REFURBISHMENT

Environmental issues associated with refurbishment activities are discussed in the *Generic Environmental Impact Statement for License Renewal of Nuclear Plants* (GEIS), NUREG-1437, Volumes 1 and 2 (NRC 1996; 1999).<sup>(1)</sup> The GEIS includes a determination of whether the analysis of the environmental issues could be applied to all plants and whether additional mitigation measures would be warranted. Issues are then assigned a Category 1 or a Category 2 designation. As set forth in the GEIS, Category 1 issues are those that meet all of the following criteria:

- (1) The environmental impacts associated with the issue have been determined to apply either to all plants or, for some issues, to plants having a specific type of cooling system or other specified plant or site characteristics.
- (2) A single significance level (i.e., SMALL, MODERATE, or LARGE) has been assigned to the impacts (except for collective offsite radiological impacts from the fuel cycle and from high-level waste and spent fuel disposal).
- (3) Mitigation of adverse impacts associated with the issue has been considered in the analysis, and it has been determined that additional plant-specific mitigation measures are likely not to be sufficiently beneficial to warrant implementation.

For issues that meet the three Category 1 criteria, no additional plant-specific analysis is required in this draft supplemental environmental impact statement (SEIS) unless new and significant information is identified.

Category 2 issues are those that do not meet one or more of the criteria for Category 1 and, therefore, additional plant-specific review of these issues is required.

License renewal actions may require refurbishment activities for the extended plant life. These actions may have an impact on the environment that requires evaluation, depending on the type of action and the plant-specific design. Environmental issues associated with refurbishment determined to be Category 1 issues are listed in Table 3-1.

Environmental issues related to refurbishment considered in the GEIS for which these conclusions could not be reached for all plants, or for specific classes of plants, are Category 2 issues. These are listed in Table 3-2.

---

(1) The GEIS was originally issued in 1996. Addendum 1 to the GEIS was issued in 1999. Hereafter, all references to the "GEIS" include the GEIS and its Addendum 1.

1

**Table 3-1.** Category 1 Issues for Refurbishment Evaluation

<b>ISSUE—10 CFR Part 51, Subpart A, Appendix B, Table B-1</b>	<b>GEIS Sections</b>
<b>SURFACE-WATER QUALITY, HYDROLOGY, AND USE (FOR ALL PLANTS)</b>	
Impacts of refurbishment on surface-water quality	3.4.1
Impacts of refurbishment on surface-water use	3.4.1
<b>AQUATIC ECOLOGY (FOR ALL PLANTS)</b>	
Refurbishment	3.5
<b>GROUND-WATER USE AND QUALITY</b>	
Impacts of refurbishment on ground-water use and quality	3.4.2
<b>LAND USE</b>	
Onsite land use	3.2
<b>HUMAN HEALTH</b>	
Radiation exposures to the public during refurbishment	3.8.1
Occupational radiation exposures during refurbishment	3.8.2
<b>SOCIOECONOMICS</b>	
Public services: public safety, social services, and tourism and recreation	3.7.4; 3.7.4.3; 3.7.4.4; 3.7.4.6
Aesthetic impacts (refurbishment)	3.7.8

2

3 Category 1 and Category 2 issues related to refurbishment that are not applicable to James A.  
 4 FitzPatrick Nuclear Power Plant (JAFNPP) because they are related to plant design features or  
 5 site characteristics not found at the James A FitzPatrick site are listed in Appendix F.

6 The potential environmental effects of refurbishment actions would be identified, and the  
 7 analysis would be summarized within this section, if such actions were planned. Entergy  
 8 Nuclear FitzPatrick, LLC, and Entergy Nuclear Operations, Inc. (Entergy) indicated that it has  
 9 performed an evaluation of structures and components pursuant to Section 54.21 of Title 10 of  
 10 the *Code of Federal Regulations* (10 CFR 54.21) to identify activities that are necessary to  
 11 continue operation of JAFNPP during the requested 20-year period of extended operation.  
 12 These activities include replacement of certain components as well as new inspection activities  
 13 and are described in the Environmental Report (ER; Entergy 2006).

14 However, Entergy stated that the replacement of these components and the additional  
 15 inspection activities are within the bounds of normal plant component replacement and  
 16 inspections; therefore, they are not expected to affect the environment outside the bounds of

1

**Table 3-2.** Category 2 Issues for Refurbishment Evaluation

<b>ISSUE—10 CFR Part 51, Subpart A, Appendix B, Table B-1</b>	<b>GEIS Sections</b>	<b>10 CFR 51.53 (c)(3)(ii) Subparagraph</b>
<b>TERRESTRIAL RESOURCES</b>		
Refurbishment impacts	3.6	E
<b>THREATENED OR ENDANGERED SPECIES (FOR ALL PLANTS)</b>		
Threatened or endangered species	3.9	E
<b>AIR QUALITY</b>		
Air quality during refurbishment (nonattainment and maintenance areas)	3.3	F
<b>SOCIOECONOMICS</b>		
Housing impacts	3.7.2	I
Public services: public utilities	3.7.4.5	I
Public services: education (refurbishment)	3.7.4.1	I
Offsite land use (refurbishment)	3.7.5	I
Public services, transportation	3.7.4.2	J
Historic and archaeological resources	3.7.7	K
<b>ENVIRONMENTAL JUSTICE</b>		
Environmental justice	Not addressed <sup>(a)</sup>	Not addressed <sup>(a)</sup>

(a) Guidance related to environmental justice was not in place at the time the GEIS and the associated revision to 10 CFR Part 51 were prepared. If an applicant plans to undertake refurbishment activities for license renewal, environmental justice must be addressed in the applicant's environmental report and the NRC staff's environmental impact statement.

2

3 plant operations as evaluated in the *Final Environmental Statement Related to Operation of*  
4 *James A. FitzPatrick Nuclear Power Plant* (AEC 1973). In addition, Entergy's evaluation of  
5 structures and components as required by 10 CFR 54.21 did not identify any major plant  
6 refurbishment activities or modifications necessary to support the continued operation of  
7 JAFNPP beyond the end of the existing operating license. Therefore, refurbishment is not  
8 considered in this draft SEIS.

1 **3.1 References**

2 10 CFR Part 51. *Code of Federal Regulations*, Title 10, *Energy*, Part 51, “Environmental  
3 Protection Regulations for Domestic Licensing and Related Regulatory Functions.”

4 10 CFR Part 54. *Code of Federal Regulations*, Title 10, *Energy*, Part 54, “Requirements for  
5 Renewal of Operating Licenses for Nuclear Power Plants.”

6 Entergy Nuclear FitzPatrick, LLC, and Entergy Nuclear Operations, Inc. (Entergy). 2006.  
7 *James A. FitzPatrick Nuclear Power Plant — License Renewal Application, Appendix E: –*  
8 *Applicant’s Environmental Report, Operating License Renewal Stage*. Lycoming, New York.  
9 Accessible at ML062160557.

10 U.S. Atomic Energy Commission (AEC). 1973. *Final Environmental Statement Related to*  
11 *Operation of James A. FitzPatrick Nuclear Power Plant*. Power Authority of the State of New  
12 York. Docket No. 50-333. Washington, D.C. Accessible at ML062360088.

13 U.S. Nuclear Regulatory Commission (NRC). 1996. *Generic Environmental Impact Statement*  
14 *for License Renewal of Nuclear Plants*. NUREG-1437, Volumes 1 and 2. Office of Nuclear  
15 Regulatory Research, Washington, D.C.

16 U.S. Nuclear Regulatory Commission (NRC). 1999. *Generic Environmental Impact Statement*  
17 *for License Renewal of Nuclear Plant*. NUREG-1437, Volume 1, Addendum 1. Office of  
18 Nuclear Regulatory Research, Washington, D.C.

## 4.0 ENVIRONMENTAL IMPACTS OF OPERATION

Environmental issues associated with operation of a nuclear power plant during the renewal term are discussed in the *Generic Environmental Impact Statement for License Renewal of Nuclear Plants* (GEIS), NUREG-1437, Volumes 1 and 2 (NRC 1996a; 1999).<sup>(1)</sup> The GEIS includes a determination of whether the analysis of the environmental issues could be applied to all plants and whether additional mitigation measures would be warranted. Issues are then assigned a Category 1 or a Category 2 designation. As set forth in the GEIS, Category 1 issues are those that meet all of the following criteria:

- (1) The environmental impacts associated with the issue have been determined to apply either to all plants or, for some issues, to plants having a specific type of cooling system or other specified plant or site characteristics.
- (2) A single significance level (i.e., SMALL, MODERATE, OR LARGE) has been assigned to the impacts (except for collective offsite radiological impacts from the fuel cycle and from high-level waste and spent fuel disposal).
- (3) Mitigation of adverse impacts associated with the issue has been considered in the analysis, and it has been determined that additional plant-specific mitigation measures are likely not to be sufficiently beneficial to warrant implementation.

For issues that meet the three Category 1 criteria, no additional plant-specific analysis is required unless new and significant information is identified.

Category 2 issues are those that do not meet one or more of the criteria for Category 1, and therefore, additional plant-specific review of these issues is required.

This chapter addresses the issues related to operation during the renewal term that are listed in Table B-1 of Part 51 of Title 10 of the *Code of Federal Regulations* (10 CFR Part 51), Subpart A, Appendix B and are applicable to the James A. FitzPatrick Nuclear Power Plant (JAFNPP). Section 4.1 addresses issues applicable to the JAFNPP cooling system. Section 4.2 addresses issues related to transmission lines and onsite land use. Section 4.3 addresses the radiological impacts of normal operation, and Section 4.4 addresses issues related to the socioeconomic impacts of normal operation during the renewal term. Section 4.5 addresses issues related to groundwater use and quality, while Section 4.6 discusses the impacts of renewal-term operations on threatened and endangered species. Section 4.7 addresses potential new information that was raised during the scoping period, and Section 4.8 discusses cumulative impacts. The results

---

<sup>1</sup> The GEIS was originally issued in 1996. Addendum 1 to the GEIS was issued in 1999. Hereafter, all references to the "GEIS" include the GEIS and its Addendum 1.

1 of the evaluation of environmental issues related to operation during the renewal term are  
2 summarized in Section 4.9. Finally, Section 4.10 lists the references for Chapter 4. Category 1  
3 and Category 2 issues that are not applicable to JAFNPP because they are related to plant-design  
4 features or site characteristics not found at JAFNPP are listed in Appendix F.

#### 5 **4.1 Cooling System**

6 Category 1 issues in Table B-1 of 10 CFR Part 51, Subpart A, Appendix B, that are applicable to  
7 the JAFNPP cooling system operation during the renewal term are listed in Table 4-1. Entergy  
8 Nuclear FitzPatrick, LLC, and Entergy Nuclear Operations, Inc. (Entergy) stated in its  
9 Environmental Report, *James A. FitzPatrick Nuclear Power Plant — License Renewal*  
10 *Application, Appendix E: Applicant's Environmental Report, Operating License Renewal Stage*  
11 *(JAFNPP ER) (Entergy 2006a)*, that it is not aware of any new and significant information  
12 associated with the renewal of the JAFNPP operating license (OL). The NRC staff has not  
13 identified any new and significant information during its independent review of the JAFNPP ER  
14 (Entergy 2006a), the staff's site audit, the scoping process, or its evaluation of other available  
15 information. Therefore, the NRC staff concludes that there are no impacts related to these  
16 issues beyond those discussed in the GEIS. For all of the issues, the NRC staff concluded in  
17 the GEIS that the impacts are SMALL, and additional plant-specific mitigation measures are not  
18 likely to be sufficiently beneficial to be warranted.

19 A brief description of the NRC staff's review and the GEIS conclusions, as codified in Table B-1,  
20 for each of these issues follows:

- 21 • Altered current patterns at intake and discharge structures. Based on information in the  
22 GEIS, the Commission found that

23       Altered current patterns have not been found to be a problem at operating  
24       nuclear power plants and are not expected to be a problem during the license  
25       renewal term.

26       The NRC staff has not identified any new and significant information during its independent  
27       review of the JAFNPP ER (Entergy 2006a), the staff's site audit, the scoping process, or its  
28       evaluation of other available information. Therefore, the NRC staff concludes that there  
29       would be no impacts of altered current patterns at intake and discharge structures during the  
30       renewal term beyond those discussed in the GEIS.

1  
2**Table 4-1.** Category 1 Issues Applicable to the Operation of the JAFNPP Cooling System During the Renewal Term

<b>ISSUE—10 CFR Part 51, Subpart A, Appendix B, Table B-1</b>	<b>GEIS Section</b>
<b>SURFACE WATER QUALITY, HYDROLOGY, AND USE (FOR ALL PLANTS)</b>	
Altered current patterns at intake and discharge structures	4.2.1.2.1
Altered thermal stratification of lakes	4.2.1.2.3
Temperature effects on sediment transport capacity	4.2.1.2.3
Scouring caused by discharged cooling water	4.2.1.2.3
Eutrophication	4.2.1.2.3
Discharge of chlorine or other biocides	4.2.1.2.4
Discharge of sanitary wastes and minor chemical spills	4.2.1.2.4
Discharge of other metals in wastewater	4.2.1.2.4
Water use conflicts (plants with once-through cooling systems)	4.2.1.3
<b>AQUATIC ECOLOGY (FOR ALL PLANTS)</b>	
Accumulation of contaminants in sediments or biota	4.2.1.2.4
Entrainment of phytoplankton and zooplankton	4.2.2.1.1
Cold shock	4.2.2.1.5
Thermal plume barrier to migrating fish	4.2.2.1.6
Distribution of aquatic organisms	4.2.2.1.6
Premature emergence of aquatic insects	4.2.2.1.7
Gas supersaturation (gas bubble disease)	4.2.2.1.8
Low dissolved oxygen in the discharge	4.2.2.1.9
Losses from predation, parasitism, and disease among organisms exposed to sublethal stresses	4.2.2.1.10
Stimulation of nuisance organisms	4.2.2.1.11
<b>HUMAN HEALTH</b>	
Microbiological organisms (occupational health)	4.3.6
Noise	4.3.7

Environmental Impacts of Operation

- 1 • Altered current patterns at intake and discharge structures. Based on information in the  
2 GEIS, the Commission found that

3 Altered current patterns have not been found to be a problem at operating  
4 nuclear power plants and are not expected to be a problem during the license  
5 renewal term.

6 The NRC staff has not identified any new and significant information during its independent  
7 review of the JAFNPP ER (Entergy 2006a), the staff's site audit, the scoping process, or its  
8 evaluation of other available information. Therefore, the NRC staff concludes that there  
9 would be no impacts of altered current patterns at intake and discharge structures during the  
10 renewal term beyond those discussed in the GEIS.

- 11 • Altered thermal stratification of lakes. Based on information in the GEIS, the Commission  
12 found that

13 Generally, lake stratification has not been found to be a problem at operating  
14 nuclear power plants and is not expected to be a problem during the license  
15 renewal term.

16 The NRC staff has not identified any new and significant information during its independent  
17 review of the JAFNPP ER (Entergy 2006a), the staff's site audit, the scoping process, or its  
18 evaluation of other available information. Therefore, the NRC staff concludes that there  
19 would be no impacts of altered thermal stratification of lakes during the renewal term beyond  
20 those discussed in the GEIS.

- 21 • Temperature effects on sediment transport capacity. Based on information in the GEIS, the  
22 Commission found that

23 These effects have not been found to be a problem at operating nuclear power  
24 plants and are not expected to be a problem during the license renewal term.

25 The NRC staff has not identified any new and significant information during its independent  
26 review of the JAFNPP ER (Entergy 2006a), the staff's site audit, the scoping process, or its  
27 evaluation of other available information. Therefore, the NRC staff concludes that there  
28 would be no impacts of temperature effects on sediment transport capacity during the  
29 renewal term beyond those discussed in the GEIS.

- 30 • Scouring caused by discharged cooling water. Based on information in the GEIS, the  
31 Commission found that

32 Scouring has not been found to be a problem at most operating nuclear power  
33 plants and has caused only localized effects at a few plants. It is not expected to  
34 be a problem during the license renewal term.



1 The NRC staff has not identified any new and significant information during its independent  
 2 review of the JAFNPP ER (Entergy 2006a), the staff's site audit, the scoping process, or its  
 3 evaluation of other available information. Therefore, the NRC staff concludes that there  
 4 would be no impacts of scouring caused by discharged cooling water during the renewal  
 5 term beyond those discussed in the GEIS.

- 6 • Eutrophication. Based on information in the GEIS, the Commission found that

7 Eutrophication has not been found to be a problem at operating nuclear power  
 8 plants and is not expected to be a problem during the license renewal term.

9 The NRC staff has not identified any new and significant information during its independent  
 10 review of the JAFNPP ER (Entergy 2006a), the staff's site audit, the scoping process, or its  
 11 evaluation of other available information including plant monitoring data and technical  
 12 reports. Therefore, the NRC staff concludes that there would be no impacts of  
 13 eutrophication during the renewal term beyond those discussed in the GEIS.

- 14 • Discharge of chlorine or other biocides. Based on information in the GEIS, the Commission  
 15 found that

16 Effects are not a concern among regulatory and resource agencies, and are not  
 17 expected to be a problem during the license renewal term.

18 The NRC staff has not identified any new and significant information during its independent  
 19 review of the JAFNPP ER (Entergy 2006a), the staff's site audit, the scoping process, or its  
 20 evaluation of other available information including the State Pollutant Discharge Elimination  
 21 System (SPDES) permit for JAFNPP. Therefore, the NRC staff concludes that there would  
 22 be no impacts of discharge of chlorine or other biocides during the renewal term beyond  
 23 those discussed in the GEIS.

- 24 • Discharge of sanitary wastes and minor chemical spills. Based on information in the GEIS,  
 25 the Commission found that

26 Effects are readily controlled through [National Pollutant Discharge Elimination  
 27 System] NPDES permit and periodic modifications, if needed, and are not  
 28 expected to be a problem during the license renewal term.

29 The NRC staff has not identified any new and significant information during its independent  
 30 review of the JAFNPP ER (Entergy 2006a), the staff's site audit, the scoping process, or its  
 31 evaluation of other available information including the SPDES permit for JAFNPP.  
 32 Therefore, the NRC staff concludes that there would be no impacts of discharges of sanitary  
 33 wastes and minor chemical spills during the renewal term beyond those discussed in the  
 34 GEIS.

Environmental Impacts of Operation

- 1 • Discharge of other metals in wastewater. Based on information in the GEIS, the  
2 Commission found that

3           These discharges have not been found to be a problem at operating nuclear  
4           power plants with cooling-tower-based heat dissipation systems and have been  
5           satisfactorily mitigated at other plants. They are not expected to be a problem  
6           during the license renewal term.

7           The NRC staff has not identified any new and significant information during its independent  
8           review of the JAFNPP ER (Entergy 2006a), the staff's site audit, the scoping process, or its  
9           evaluation of other available information including the SPDES permit for JAFNPP.  
10          Therefore, the NRC staff concludes that there would be no impacts of discharges of other  
11          metals in wastewater during the renewal term beyond those discussed in the GEIS.

- 12 • Water-use conflicts (plants with once-through cooling systems). Based on information in the  
13 GEIS, the Commission found that

14           These conflicts have not been found to be a problem at operating nuclear power  
15           plants with once-through heat dissipation systems.

16          The NRC staff has not identified any new and significant information during its independent  
17          review of the JAFNPP ER (Entergy 2006a), the staff's site audit, the scoping process, or its  
18          evaluation of other available information. Therefore, the NRC staff concludes that there  
19          would be no impacts of water-use conflicts for plants with once-through cooling systems  
20          during the renewal term beyond those discussed in the GEIS.

- 21 • Accumulation of contaminants in sediments or biota. Based on information in the GEIS, the  
22 Commission found that

23           Accumulation of contaminants has been a concern at a few nuclear power plants  
24           but has been satisfactorily mitigated by replacing copper alloy condenser tubes  
25           with those of another metal. It is not expected to be a problem during the license  
26           renewal term.

27          The NRC staff has not identified any new and significant information during its independent  
28          review of the JAFNPP ER (Entergy 2006a), the staff's site audit, the scoping process, or its  
29          evaluation of available information. Therefore, the NRC staff concludes that there would be  
30          no impacts of accumulation of contaminants in sediments or biota during the renewal term  
31          beyond those discussed in the GEIS.

- 32 • Entrainment of phytoplankton and zooplankton. Based on information in the GEIS, the  
33 Commission found that

1           Entrainment of phytoplankton and zooplankton has not been found to be a  
2           problem at operating nuclear power plants and is not expected to be a problem  
3           during the license renewal term.

4           The NRC staff has not identified any new and significant information during its independent  
5           review of the JAFNPP ER (Entergy 2006a), the staff's site audit, the scoping process, or its  
6           evaluation of other available information. Therefore, the NRC staff concludes that there  
7           would be no impacts of entrainment of phytoplankton and zooplankton during the renewal  
8           term beyond those discussed in the GEIS.

9           • Cold shock. Based on information in the GEIS, the Commission found that

10           Cold shock has been satisfactorily mitigated at operating nuclear plants with  
11           once-through cooling systems, has not endangered fish populations or been  
12           found to be a problem at operating nuclear power plants with cooling towers or  
13           cooling ponds, and is not expected to be a problem during the license renewal  
14           term.

15           The NRC staff has not identified any new and significant information during its independent  
16           review of the JAFNPP ER (Entergy 2006a), the staff's site audit, the scoping process, or its  
17           evaluation of other available information, including JAFNPP's original CWA Section 316(a)  
18           demonstration report (NYPA 1976). Therefore, the NRC staff concludes that there would be  
19           no impacts of cold shock during the renewal term beyond those discussed in the GEIS.

20           • Thermal plume barrier to migrating fish. Based on information in the GEIS, the Commission  
21           found that

22           Thermal plumes have not been found to be a problem at operating nuclear power  
23           plants and are not expected to be a problem during the license renewal term.

24           The NRC staff has not identified any new and significant information during its independent  
25           review of the JAFNPP ER (Entergy 2006a), the staff's site audit, the scoping process, or its  
26           evaluation of other available information, including JAFNPP's original CWA Section 316(a)  
27           demonstration report (NYPA 1976). Therefore, the NRC staff concludes that there would be  
28           no impacts of thermal plume barriers to migrating fish during the renewal term beyond those  
29           discussed in the GEIS.

30           • Distribution of aquatic organisms. Based on information in the GEIS, the Commission found  
31           that

32           Thermal discharge may have localized effects but is not expected to affect the  
33           larger geographical distribution of aquatic organisms.

## Environmental Impacts of Operation

1 The NRC staff has not identified any new and significant information during its independent  
2 review of the JAFNPP ER (Entergy 2006a), the staff's site audit, the scoping process, or its  
3 evaluation of other available information, including JAFNPP's original CWA Section 316(a)  
4 demonstration report (NYPA 1976). Therefore, the NRC staff concludes that there would be  
5 no impacts on distribution of aquatic organisms during the renewal term beyond those  
6 discussed in the GEIS.

- 7 • Premature emergence of aquatic insects. Based on information in the GEIS, the  
8 Commission found that

9 Premature emergence has been found to be a localized effect at some operating  
10 nuclear power plants but has not been a problem and is not expected to be a  
11 problem during the license renewal term.

12 The NRC staff has not identified any new and significant information during its independent  
13 review of the JAFNPP ER (Entergy 2006a), the staff's site audit, the scoping process, or its  
14 evaluation of other available information. Therefore, the NRC staff concludes that there  
15 would be no impacts of premature emergence of aquatic insects during the renewal term  
16 beyond those discussed in the GEIS.

- 17 • Gas supersaturation (gas bubble disease). Based on information in the GEIS, the  
18 Commission found that

19 Gas supersaturation was a concern at a small number of operating nuclear  
20 power plants with once-through cooling systems but has been satisfactorily  
21 mitigated. It has not been found to be a problem at operating nuclear power  
22 plants with cooling towers or cooling ponds and is not expected to be a problem  
23 during the license renewal term.

24 The NRC staff has not identified any new and significant information during its independent  
25 review of the JAFNPP ER (Entergy 2006a), the staff's site audit, the scoping process, or its  
26 evaluation of other available information. Therefore, the NRC staff concludes that there are  
27 no impacts of gas supersaturation during the renewal term beyond those discussed in the  
28 GEIS.

- 29 • Low dissolved oxygen in the discharge. Based on information in the GEIS, the Commission  
30 found that

31 Low dissolved oxygen has been a concern at one nuclear power plant with a  
32 once-through cooling system but has been effectively mitigated. It has not been  
33 found to be a problem at operating nuclear power plants with cooling towers or  
34 cooling ponds and is not expected to be a problem during the license renewal  
35 term.

1 The NRC staff has not identified any new and significant information during its independent  
2 review of the JAFNPP ER (Entergy 2006a), the staff's site audit, the scoping process, or its  
3 evaluation of other available information. Therefore, the NRC staff concludes that there  
4 would be no impacts of low dissolved oxygen during the renewal term beyond those  
5 discussed in the GEIS.

- 6 • Losses from predation, parasitism, and disease among organisms exposed to sublethal  
7 stresses. Based on information in the GEIS, the Commission found that

8 These types of losses have not been found to be a problem at operating nuclear  
9 power plants and are not expected to be a problem during the license renewal  
10 term.

11 The NRC staff has not identified any new and significant information during its independent  
12 review of the JAFNPP ER (Entergy 2006a), the staff's site audit, the scoping process, or its  
13 evaluation of other available information. Therefore, the NRC staff concludes that there  
14 would be no impacts of losses from predation, parasitism, and disease among organisms  
15 exposed to sublethal stresses during the renewal term beyond those discussed in the GEIS.

- 16 • Stimulation of nuisance organisms. Based on information in the GEIS, the Commission  
17 found that

18 Stimulation of nuisance organisms has been satisfactorily mitigated at the single  
19 nuclear power plant with a once-through cooling system where previously it was  
20 a problem. It has not been found to be a problem at operating nuclear power  
21 plants with cooling towers or cooling ponds and is not expected to be a problem  
22 during the license renewal term.

23 The NRC staff has not identified any new and significant information during its independent  
24 review of the JAFNPP ER (Entergy 2006a), the staff's site audit, the scoping process, or its  
25 evaluation of other available information. Therefore, the NRC staff concludes that there  
26 would be no impacts of stimulation of nuisance organisms during the renewal term beyond  
27 those discussed in the GEIS.

- 28 • Microbiological organisms (occupational health). Based on information in the GEIS, the  
29 Commission found that

30 Occupational health impacts are expected to be controlled by continued  
31 application of accepted industrial hygiene practices to minimize worker  
32 exposures.

33 The NRC staff has not identified any new and significant information during its independent  
34 review of the JAFNPP ER (Entergy 2006a), the staff's site audit, the scoping process, or its  
35 evaluation of other available information. Therefore, the NRC staff concludes that there

Environmental Impacts of Operation

1 would be no impacts of microbiological organisms during the renewal term beyond those  
2 discussed in the GEIS.

3 • Noise. Based on information in the GEIS, the Commission found that

4 Noise has not been found to be a problem at operating plants and is not  
5 expected to be a problem at any plant during the license renewal term.

6 The NRC staff has not identified any new and significant information during its independent  
7 review of the JAFNPP ER (Entergy 2006a), the staff's site audit, the scoping process, or its  
8 evaluation of other available information. Therefore, the NRC staff concludes that there  
9 would be no impacts of noise during the renewal term beyond those discussed in the GEIS.

10 The Category 2 issues related to cooling system operation during the renewal term that are  
11 applicable to JAFNPP are listed in Table 4-2 and discussed in the sections that follow.

12 **Table 4-2.** Category 2 Issues Applicable to the Operation of the JAFNPP  
13 Cooling System During the Renewal Term

ISSUE—10 CFR Part 51, Subpart A, Appendix B, Table B-1	GEIS Section	10 CFR 51.53(c)(3)(ii) Subparagraph	SEIS Section
<b>AQUATIC ECOLOGY</b> <b>(FOR PLANTS WITH ONCE-THROUGH AND COOLING POND HEAT-DISSIPATION SYSTEMS)</b>			
Entrainment of fish and shellfish in early life stages	4.2.2.1.2	B	4.1.1
Impingement of fish and shellfish	4.2.2.1.3	B	4.1.2
Heat shock	4.2.2.1.4	B	4.1.3

14

15 **4.1.1 Entrainment of Fish and Shellfish in Early Life Stages**

16 For power plants with once-through cooling systems, the entrainment of fish and shellfish in  
17 early life stages into cooling water systems associated with nuclear power plants is considered  
18 a Category 2 issue that requires site-specific assessment before license renewal. Applicable  
19 Category 2 issues are listed in Table 4-2. The NRC staff reviewed the JAFNPP ER (Entergy  
20 2006a) and related documents, including Entergy's *Proposal for Information Collection* dated  
21 January 31, 2006 (Entergy 2006b), and the *2004 SPDES Biological Monitoring Report for the*  
22 *James A. FitzPatrick Nuclear Power Plant*, dated May 2005 (EA 2005), and visited the JAFNPP  
23 site several times. The NRC staff also reviewed the applicant's most current SPDES permit  
24 (NY-0020109) and the accompanying fact sheet, the State of New York Best Technology  
25 Available (BTA) determination letter dated March 1, 1996, and the State of New York 401  
26 Certification letter dated November 5, 1975 (Entergy 2006a).

1 Section 316(b) of the Clean Water Act of 1977 (CWA), common name of the Federal Water  
2 Pollution Control Act, requires that the location, design, construction, and capacity of cooling  
3 water intake structures reflect the best available technology for minimizing adverse  
4 environmental impacts (33 U.S.C. 1326). Entrainment of fish and shellfish into the cooling water  
5 system is a potential adverse environmental impact that can be minimized by the use of best  
6 available technology. Licensees may be required as part of the NPDES renewal to alter the  
7 intake structure, redesign the cooling system, modify facility operation, or take other mitigative  
8 measures. Licensees must comply with Section 316(b) of the CWA. However, EPA's Phase II  
9 Rule has been suspended and compliance with the rule is based on EPA's best professional  
10 judgment.

11 JAFNPP has a once-through heat dissipation system that uses water from Lake Ontario for  
12 condenser cooling and service water. Under normal operating conditions at JAFNPP, all three  
13 circulating water pumps are operating to produce a combined intake flow of 352,600 gallons per  
14 minute (gpm) (518 million gallons per day [gpd]), as measured through the condensers. Three  
15 50 percent-capacity service water pumps also draw water from the intake bay, downstream of  
16 the traveling screens, at a rate of 36,000 gpm (52 million gpd). At the submerged offshore  
17 intake structure, water velocity at the outer face of the bar racks is 1.2 feet per second (ft/s) and  
18 1.6 ft/s through the bar racks. Once in the D-shaped intake tunnel, average water velocity is  
19 4.7 ft/s. Reinforced invert paving and wire mesh-reinforced gunite lining provides for hydraulic  
20 smoothness throughout the tunnel (Entergy 2006a). Once in the screenwell-pumphouse intake  
21 bay, the water flows through the trash bars and traveling screens. Each traveling screen has a  
22 design capacity flow rate of 125,000 gpm and design approach velocity of 1.2 ft/s; the screens  
23 rotate from 10 to 20 feet per minute (ft/m). Screen wash pumps operate periodically and in  
24 response to pressure differentials to remove debris from the traveling screens. Screen wash  
25 pumps take water from the service water system and spray the traveling screens at a rate of  
26 720 gpm/screen, at a minimum of 80 pounds per square inch (lb/in<sup>2</sup>) gauge pressure (Entergy  
27 2006b).

28 The maximum allowable temperature rise of the cooling system water through the main  
29 condenser is 32.4 degrees Fahrenheit (°F) above ambient water temperature (Entergy 2006a).  
30 Organisms entrained in the intake flow that are small enough to pass through the vertical  
31 traveling screens enter the station cooling system where they are subjected to thermal stress  
32 and mechanical and hydraulic forces. In a study of the Haddam Neck Plant, a nuclear power  
33 plant with a once-through cooling system that formerly operated on the Connecticut River, it was  
34 found that mechanical damage is the main cause of entrainment mortality, while thermal shock  
35 was responsible for only about 20 percent of mortality (Marcy 2004). While some entrainment  
36 survival may occur, for this review NRC staff conservatively assumed that 100 percent of  
37 entrained organisms die.

38 During periods of cold weather, when inlet water temperature is below 45°F, warm discharge  
39 water is recirculated from the discharge tunnel into the intake bay by a tempering gate—the  
40 amount of raw intake water is reduced approximately 16 to 18 percent during this mode of

## Environmental Impacts of Operation

1 operation. Total entrainment loss is directly proportional to both the density of ichthyoplankton  
2 in the nearfield source of water and to the raw water intake flow during the period of  
3 consideration. JAFNPP has compiled monthly actual intake flow data from January 1998  
4 through July 2005, and actual pumping rates have historically been lower than plant-design  
5 flows. This is because the circulating water pumps operate at various head differentials and the  
6 plant's cooling water needs vary in response to reduced generation, environmental conditions,  
7 and periodic maintenance outages. This historical operation is considered representative of the  
8 current and expected future cooling water intake flow operations at JAFNPP (Entergy 2006b).

9 In the late 1960s, the New York Power Authority (NYPA) and the Niagara Mohawk Power  
10 Corporation conducted ecological studies in the nearshore vicinity of the Nine Mile Point  
11 promontory to determine the potential impact of power plants on the Lake Ontario aquatic  
12 ecosystem. Part of this program included weekly monitoring of the distribution of fish eggs and  
13 larvae at contour depths from 20 to 100 ft, from April through December of 1973 through 1979.  
14 Egg collections consisted primarily of alewife (*Alosa pseudoharengus*) and rainbow smelt  
15 (*Osmerus mordax*); larval samples were also dominated by alewife. Alewife were the primary  
16 component of the ichthyoplankton community, followed by rainbow smelt, white perch (*Morone*  
17 *americana*), sculpin (*Cottidae* spp.), and tessellated darter (*Etheostoma olmstedii*). Low  
18 numbers of other species were collected, including yellow perch (*Perca flavescens*), rainbow  
19 smelt, and *Morone* spp., but overall, the data indicated that the Nine Mile Point vicinity was a  
20 significant spawning habitat for only alewife and rainbow smelt. A study of species composition  
21 and distribution of fish larvae collected in the Nine Mile Point area published in 1975 concluded  
22 the area is not a desirable spawning or nursery habitat because of extensive nearshore wave  
23 action and unsuitable bedrock and rubble substrate (TI 1979).

24 The ecological studies revealed that the temporal distribution of eggs and larvae in the Nine  
25 Mile Point vicinity is generally characterized by two spawning groups: those that spawn from  
26 winter to early spring (burbot [*Lota lota*], *Coregonus* spp., rainbow smelt, and yellow perch), and  
27 those that spawn from late spring through summer (alewife, white perch, and carp [*Cyprinus*  
28 *carpio*]). Subsequently, eggs and larvae from these groups are most abundant from April to  
29 June and from July to August, respectively. Eggs and larvae were most abundant at the 20-ft  
30 contour depth; their numbers were lower at deeper contours (TI 1979).

31 Because Nine Mile Point Nuclear Station (NMPNS) Unit 1 is so close to JAFNPP and NMPNS's  
32 intake and cooling systems are similar to JAFNPP's, entrainment data from NMPNS were  
33 reviewed for this analysis. NMPNS sampled water directly from the Unit 1 intake forebay once  
34 or twice a month from 1973 through 1978. The species composition of the intake water was  
35 generally very similar to the species composition of Lake Ontario, except that intake water  
36 ichthyoplankton densities were lower than lake water ichthyoplankton densities and species that  
37 occurred at low frequencies in the lake samples were not detected at all in the intake water  
38 samples. Temporal abundance was also similar (Entergy 2006b).



1 The first year NMPNS Unit 1 entrainment data were collected when both NMPNS Unit 1 and  
2 JAFNPP were operating was 1976. Burbot and *Coregonus* spp. were most frequently entrained  
3 at NMPNS Unit 1 in the early spring, rainbow smelt in mid-spring, and alewife in late spring and  
4 summer. Abundance of entrained fish was highest in the summer due to the large alewife  
5 population: weekly average alewife densities were 0 to 34.4 eggs per cubic meter (m<sup>3</sup>) and 0 to  
6 0.5 larvae per m<sup>3</sup>. Weekly average rainbow smelt densities were 0 to 0.15 eggs per m<sup>3</sup> and 0 to  
7 0.02 larvae per m<sup>3</sup>. Conservatively assuming the maximum weekly density and that NMPNS  
8 Unit 1 was running at full capacity, weekly entrainment totals were estimated at 350 million  
9 alewife eggs and 4.9 million alewife larvae; and 1.5 million rainbow smelt eggs and 205,000  
10 rainbow smelt larvae. For perspective, these numbers were extrapolated using alewife  
11 fecundity data and compared to the estimated standing stock number of alewife in the U.S.  
12 waters of Lake Ontario (12.56 billion in 1976), resulting in an estimated loss of approximately  
13 0.0002 percent of alewife population females and 0.014 percent alewife larvae. An estimated  
14 0.00001 percent female rainbow smelt population loss was calculated for egg entrainment and  
15 0.025 percent for larval entrainment (Entergy 2006b).

16 A 1997 NMPNS entrainment study showed much lower total entrainment numbers than the  
17 1977 data: corrected for flow into the plant, an estimated 86.6 million ichthyoplankton were  
18 entrained from April through August at NMPNS Unit 1. Alewife represented 90.7 percent of the  
19 ichthyoplankton entrainment, followed by the tessellated darter at 4.2 percent (3.6 million) and  
20 the threespine stickleback (*Gasterosteus aculeatus*) at 2.8 percent (2.4 million). Rainbow smelt  
21 accounted for only 0.1 percent. The difference in the 1977 and 1997 entrainment numbers is  
22 likely due primarily to the difference in abundance of alewife and rainbow smelt lake-wide  
23 (Entergy 2006b). Both alewife and rainbow smelt populations throughout Lake Ontario have  
24 likely declined due to excessive salmonid predation and lake-wide food web changes that  
25 occurred primarily in response to *Dreissenid* spp. invasion and lake water quality improvements  
26 (Mills et al. 2003).

27 The status of Lake Ontario's alewife population is of particular concern. As prey fish for stocked  
28 salmonids, alewife support the lake's major sport fisheries, which are strong contributors to local  
29 economies. To put the 1997 alewife entrainment data into perspective, NRC staff calculated  
30 alewife fecundity loss in a similar manner to the 1976 calculations above. In performing these  
31 calculations, NRC used a 1997 Lake Ontario (U.S. waters) alewife standing stock population of  
32 941,300,000 (Entergy 2006a); assumed a 1:1 sex ratio; assumed an alewife average lifetime  
33 fecundity of 26,272 eggs (Entergy 2006b); and conservatively assumed the entire percentage of  
34 entrained alewife ichthyoplankton was composed of eggs. In estimating total entrainment for all  
35 of 1997, NRC staff also conservatively assumed that the April to August rate of entrainment was  
36 maintained throughout the entire year, which due to the spawning habits of alewife and lower  
37 intake flows during winter months, is highly unlikely. By multiplying the number of female  
38 alewife by fecundity and dividing this number by entrainment, the estimated loss of population  
39 fecundity in the U.S. waters of Lake Ontario caused by NMPNS Unit 1 was 0.0015 percent for  
40 1997. This minor percentage of ichthyoplankton loss would not result in a detectable impact on  
41 the lake's alewife population.

## Environmental Impacts of Operation

1 On January 24, 2006, JAFNPP applied for a renewal of its New York SPDES permit, which was  
2 scheduled to expire on August 1, 2006. Until this renewal permit is finalized, the existing permit  
3 (NY-0020109) remains in effect. As stated earlier, no entrainment studies have been completed  
4 by JAFNPP since the original Nine Mile Point promontory baseline ecology studies done in the  
5 1970s. On July 9, 2004, the EPA published a final rule that addressed cooling water intake  
6 structures at existing facilities with flow levels that exceed a minimum threshold value of 50  
7 million gpd (316(b) Phase II regulations). Owners of such facilities that did not utilize closed  
8 cycle cooling were provided a number of compliance alternatives to demonstrate compliance  
9 with the new regulations. The demonstration is implemented through the NPDES permitting  
10 program. To demonstrate compliance, JAFNPP is currently conducting a one-year entrainment  
11 sampling program that was approved by the New York State Department of Environmental  
12 Conservation (NYSDEC). The program began in April 2006 and will conclude in March 2007. A  
13 second year of entrainment sampling may occur to verify the 2006 results. An entrainment  
14 survival study may also be undertaken if it appears there is a high survival rate for  
15 ichthyoplankton. The goal of the entrainment program is to estimate the seasonal and annual  
16 total abundance of fish eggs and larvae that flow into the cooling water intake system. The goal  
17 of the survival study, if undertaken, would be to determine the effects the cooling water intake  
18 system has on entrained organisms (Entergy 2006b). The majority of fish, fish larvae, and eggs  
19 are not expected to survive passage through the JAFNPP cooling system, as cooling water  
20 temperature rises up to 32.4°F above ambient intake water temperature and organisms would  
21 experience significant hydrodynamic changes and mechanic forces (AEC 1973).

22 In the 2006 JAFNPP entrainment sampling program, intake water was sampled weekly from  
23 April to November of 2006 and every two weeks from November 2006 through March 2007.  
24 One daytime and one nighttime sample were taken on the same day each week from the  
25 forebay at two sample depths, 14 ft and 20 ft below the water surface, for a total of 160  
26 entrainment samples. The sampling was conducted using a pump with 3-inch (in.) intake and  
27 discharge hoses and a plankton net suspended in a tank. Each sample was at least 100 m<sup>3</sup>  
28 (26,417 gallons) as calibrated by an in-line flow meter (Entergy 2006b). As of the date of  
29 publication of this draft SEIS, the results of the one year study are not available. Nevertheless,  
30 the NRC staff did review preliminary (unpublished) study data to support this analysis.

31 In reviewing the historical entrainment data at NMPNS Unit 1, it appears that the primary factor  
32 influencing entrainment rates is the abundance of eggs and larvae in the water near the plant  
33 intake. Potential entrainment losses at JAFNPP, when compared to the standing stock of the  
34 lake's fish species, are not likely to adversely affect the Lake Ontario fish community. A study  
35 on entrainment and impingement rates at a nuclear power plant located on the Upper  
36 Mississippi River (LaJeone and Monzingo 2000) concluded that naturally occurring  
37 environmental conditions have a greater effect on fish populations than plant operations, and  
38 fluctuations in the annual impingement and entrainment numbers reflect primarily river  
39 conditions and fish populations' responses to them. The estimated 0.0015 percent fecundity  
40 loss of the female alewife in Lake Ontario (U.S. waters) standing stock from NMPNS Unit 1 in  
41 1997 was a conservative estimate of the potential entrainment impact that is possible at  
42 JAFNPP and would not result in a detectable impact on the alewife fishery. Until the results of

1 the 2006 entrainment study are finalized, there can be no definitive quantification of the current  
2 entrainment impacts on Lake Ontario at JAFNPP. However, based on the results of historical  
3 entrainment studies, similar operations at NMPNS Unit 1, and no change in operations at  
4 JAFNPP during the license renewal term, there is no evidence to suggest that past, current, or  
5 future entrainment of eggs, larvae, or juvenile forms of these species would destabilize or  
6 noticeably alter any important attribute of Lake Ontario. The preliminary data from the recent  
7 entrainment study at JAFNPP supports this conclusion. Therefore, the NRC staff has  
8 determined that the potential impacts of entrainment of fish and shellfish by JAFNPP during the  
9 20-year renewal period would be SMALL. The NRC staff identified potential mitigation  
10 measures, including closed cycle cooling, and derating the facility and scheduling outages  
11 during historic periods of high ichthyoplankton density. However, the NRC staff concluded that  
12 none of the mitigation measures considered would be beneficial enough to reduce the  
13 significance of the adverse entrainment impacts to the Lake Ontario fishery. Under the  
14 provisions of the state NPDES permitting program, however, NYSDEC may impose further  
15 restrictions or require modifications to the cooling system to reduce the impact of entrainment.

#### 16 **4.1.2 Impingement of Fish and Shellfish**

17 For plants with once-through cooling systems, the impingement of fish and shellfish on debris  
18 screens associated with plant cooling systems is considered a Category 2 issue, which requires  
19 a site-specific assessment before license renewal. The NRC staff reviewed the JAFNPP ER  
20 (Entergy 2006a) and related documents, including Entergy's *Proposal for Information Collection*  
21 dated January 31, 2006 (Entergy 2006b), and the *2004 SPDES Biological Monitoring Report for*  
22 *the James A. FitzPatrick Nuclear Power Plant*, dated May 2005 (EA 2005), and visited the  
23 JAFNPP site several times. The NRC staff also reviewed the applicant's most current SPDES  
24 permit (NY-0020109) and the accompanying fact sheet, the State of New York Best Technology  
25 Available (BTA) determination letter dated March 1, 1996, and the 401 Certification letter dated  
26 November 5, 1975 (Entergy 2006a).

27 Section 316(b) of the CWA, requires that the location, design, construction, and capacity of  
28 cooling water intake structures reflect the best available technology for minimizing adverse  
29 environmental impacts (33 U.S.C. 1326). Impingement of fish and shellfish into the cooling  
30 water system is a potential adverse environmental impact that can be minimized by the use of  
31 best technology available. Licensees may be required as part of the NPDES renewal to alter  
32 the intake structure, redesign the cooling system, modify facility operation, or take other  
33 mitigative measures. Licensees must comply with Section 316(b) of the CWA. However, EPA's  
34 Phase II Rule has been suspended and compliance with the rule is based on EPA's best  
35 professional judgment.

36 JAFNPP does not have a fish return system for fish impinged on the traveling screens.  
37 Therefore, impinged fish are not returned to the lake and do not survive (Entergy 2006a).  
38 JAFNPP operates a high-frequency/high-amplitude acoustic fish deterrence system (FDS)  
39 annually from April through October that is specifically designed to deter alewife. Historical  
40 studies have shown that 97 percent of alewife impingement occurs during these months (Ross

## Environmental Impacts of Operation

1 and Dunning 1996). The JAFNPP FDS consists of nine overlapping, wide-beam, high-  
2 frequency transducers mounted on top of the submerged intake structure. The transducers  
3 produce an array sound field, ensuring 360° coverage from the water surface to the lake bottom  
4 and extending at least 33 ft from the perimeter of the intake structure. Per the JAFNPP SPDES  
5 permit, the FDS is dewatered and operational by the first week of April each year and is  
6 removed from service (winterized) each October. The FDS was put into long-term operation in  
7 1998 (EA 2005).

8 Impingement of fish was monitored at JAFNPP annually from 1976 to 1997 and again in 2004.  
9 In issuing the most recent SPDES permit, NYSDEC determined that JAFNPP's impingement  
10 database was adequate to support a transition to a long-term, less intensive monitoring  
11 program, requiring the plant to conduct only one, one-year impingement program during the  
12 five-year permit period from 2001 to 2006 (Entergy 2006a). The results of JAFNPP  
13 impingement monitoring from 1976 to 1997 are summarized in Table 4-3. Generally, alewife  
14 and rainbow smelt account for the majority of individuals impinged from 1976 through 1994.  
15 The threespine stickleback is the third-most frequently impinged species, but larger  
16 impingement numbers did not occur until 1995 to 1997 and 2004 with one anomaly year in 1978  
17 (EA 2005). These impingement trends reflect lake-wide conditions. The abundance of alewife  
18 and rainbow smelt has declined over the past decade due to ecological stressors, invasive  
19 species, and increasing predatory pressure; concurrently the threespine stickleback population  
20 has greatly increased. Fish population studies of Lake Ontario suggest that the lake pelagic fish  
21 community may be undergoing a change (Schaner and Prindle 2004).

22 The *2004 SPDES Biological Monitoring Report for JAFNPP* also suggests that weather  
23 conditions can dramatically affect impingement rates, with other studies supporting this  
24 observation. An exceptionally high number of alewife were impinged in 1976 (almost 4 million  
25 fish) as compared to the rest of the data from 1977 to 1997 and 2004; the latter data is more  
26 representative than the 1976 data of impingement abundance observed during the past two  
27 decades. Although annual die-offs of alewife occur every year, a catastrophic die-off of alewife  
28 occurred in the winter and early spring of 1977, resulting in an estimated 60 to 75 percent loss  
29 of the adult alewife population, explaining the high 1976 impingement numbers (EA 2005).

30 The alewife was the most common species taken during the entire 22-year impingement study.  
31 Rainbow smelt were most abundant in 1978, 1979, 1987, 1990, and 1992, and typically the  
32 second-most abundant species impinged each year. Comparing impingement rates to lake-  
33 wide population estimates for U.S. waters, in 1997 alewife and rainbow smelt impingement at  
34 JAFNPP represented only 0.0015 percent and 0.0012 percent of the populations, respectively  
35 (EA 2005).

**Table 4-3.** Results of Impingement Monitoring at JAFNPP from 1976 through 1997  
(Corrected for Flow and Traveling Screen Efficiencies)

Scientific Name	Common Name	Fish Impingement, 1976–1997		Percentage of Fish Impinged, Average Over 22-Year Period (1976–1997)
		Total Number Fish Impinged <sup>(a)</sup>	Range of Annual Number of Fish Impinged <sup>(a)</sup>	
<i>Alosa pseudoharengus</i>	alewife	7,546,639	1,312–3,916,717	58.73%
<i>Cottus</i> spp.	sculpins	35,232	747–4,916	0.27%
<i>Dorosoma cepedianum</i>	gizzard shad	116,239	26–26,173	0.90%
<i>Etheostoma olmstedii</i>	tessellated darter	34,423	68–6,708	0.27%
<i>Gasterosteus aculeatus</i>	threespine stickleback	3,114,822	78–1,392,763	24.24%
<i>Morone americana</i>	white perch	69,669	53–13,353	0.54%
<i>Notropis atherinoides</i>	spottail shiner	82,245	282–11,683	0.64%
<i>Osmerus mordax</i>	rainbow smelt	1,780,388	1,527–282,373	13.86%
<i>Percopsis omiscomaycus</i>	trout perch	70,120	180–12,183	0.55%

Source: EA 2005

(a) Number of fish taken on the intake screens over a one year period.

3

4 The alewife is of special concern because Lake Ontario's valuable salmonid sport fishery is  
5 primarily dependent on this single-forage species. Alewife populations show high mortality rates  
6 after especially cold winters and have historically experienced mass die-offs. Alewife are easily  
7 stressed and during peak population levels, stress can result in large spring die-offs.  
8 Susceptibility to cold is related to inadequate lipid reserves, and in spring, alewife are in a  
9 weakened condition due to lack of forage in the winter and by the stress related to spawning  
10 (Eshenroder et al. 1995). They are affected by both osmotic stress associated with life in fresh  
11 water and exposure to fluctuating water temperatures when they move to inshore waters (e.g.,  
12 exposure to colder waters during an upwelling event can cause the fish to die). Stressed fish  
13 are more susceptible to impingement because they exhibit little or no motility and are passively  
14 drawn into the intake (UWSGI 2002).

15 This alewife population instability has been compounded by excessive salmonid predation—in  
16 1991 the predator demand was estimated to be equal to the total prey production, and modeling  
17 suggested that a die-off of more than 25 percent above average would cause the alewife  
18 population to crash (Stewart and Schaner 2002). U.S. Geological Survey (USGS) data indicate

## Environmental Impacts of Operation

1 that Lake Ontario alewife numbers are moderate and have remained stable since the mid-  
2 1990s. Abundance is considerably less than it was in the 1980s, but as discussed in  
3 Section 2.2.5 of this draft SEIS, the alewife population decrease was likely caused by excessive  
4 salmonid predation and changes in the Lake Ontario food web (O’Gorman et al. 2005). In  
5 response to the decreasing alewife population, New York State and Ontario, Canada, both  
6 reduced their salmonid stocking programs in 1993. However, in 1997 the stocking rates were  
7 increased slightly again. Additionally, since 1997, increasing natural reproduction of Chinook  
8 salmon (*Oncorhynchus tshawytscha*) has been observed, so predation pressure continues on  
9 the alewife (Schaner and Prindle 2004). O’Gorman et al. (2005) report that although the 2004  
10 alewife population in the U.S. waters of Lake Ontario is well below the long-term (19-year)  
11 average, the wet weight condition of adult alewife in the fall of 2004 was higher than in any year  
12 since 1980, indicating the population was more in balance with the productivity of Lake Ontario.  
13 This recent population stabilization may be occurring because of fewer individuals to compete  
14 for food, a switch in alewife diet from the zebra muscle-decimated amphipod *Diporeia* sp. to the  
15 possum shrimp (*Mysis* sp.), and the population’s subsequent movement toward deeper lake  
16 waters, where they avoid the intake structure altogether (EA 2005).

17 Rainbow smelt impingement rates appear to be influenced by meteorological conditions (strong  
18 winds and increased wave action) and lake-wide population changes due to cannibalism of  
19 young smelt by adult smelt and salmonid predation on adult smelt (EA 2005). Similar to the  
20 alewife population, changes in the Lake Ontario ecosystem brought on by improvements in  
21 water quality and invasive species have altered the distribution of the rainbow smelt population  
22 away from the area of the intake structure and to deeper portions of the Lake where food is  
23 more plentiful (Mills et al. 2005).

24 Impingement abundance of other fish, including white perch, yellow perch, smallmouth bass  
25 (*Micropterus dolomieu*), and salmonids also appears to fluctuate with regard to population  
26 dynamics and short-term meteorological events that influence the impingement process.  
27 Results from the JAFNPP impingement monitoring program in 1976 to 1997 and 2004 indicate  
28 that late fall and winter storms tend to increase impingement of the young-of-year fish for these  
29 species. During the 2004 impingement monitoring, no rare, threatened, or endangered species  
30 were collected at JAFNPP (EA 2005). Data from the 2004 impingement monitoring are  
31 summarized in Table 4-4. The total impingement at JAFNPP in 2004 was 230,534 organisms,  
32 of which threespine stickleback comprised 87.44 percent of total impingement, alewife  
33 7.29 percent, rainbow smelt 0.66 percent, smallmouth bass 0.48 percent, white perch  
34 0.21 percent, yellow perch 0.17 percent, salmonids 0.06 percent, and all others species  
35 3.69 percent (EA 2005).

**Table 4-4.** Results of Impingement Monitoring at JAFNPP, 2004  
(Corrected for Flow and Traveling Screen Efficiencies)

Scientific Name	Common Name	Fish Impingement, 2004		Percentage of Fish Impinged, Annual Average, 2004
		Total Number of Fish Impinged <sup>(a)</sup>	Average Monthly Number of Fish Impinged <sup>(a)</sup>	
<i>Alosa Pseudoharengus</i>	alewife	9,203	767	21.40%
<i>Cottus</i> spp.	sculpins	432	36	1.00%
<i>Dorosoma cepedianum</i>	gizzard shad	35	3	0.08%
<i>Etheostoma olmstedii</i>	tessellated darter	18	2	0.04%
<i>Gasterosteus aculeatus</i>	threespine stickleback	32,543	2,712	75.66%
<i>Morone americana</i>	white perch	71	6	0.17%
<i>Notropis atherinoides</i>	spottail shiner	118	10	0.27%
<i>Osmerus mordax</i>	rainbow smelt	315	26	0.73%
<i>Percopsis omiscomaycus</i>	trout perch	275	23	0.64%

Source: EA 2005

(a) Total number of fish taken on the intake screens during 2004.

3

4 The 2004 alewife and rainbow smelt impingement rates comprise just 0.0074 percent and  
5 0.0001 percent of estimated lake-wide populations, respectively, when compared to 2005 lake-  
6 wide standing stock estimates of alewife and rainbow smelt. These represent very minor losses  
7 to the populations. The 2005 standing stock numbers were estimated by a joint pelagic  
8 planktivore monitoring program conducted by the NYSDEC and the Ontario Ministry of Natural  
9 Resources(OMNR). The NYSDEC/OMNR report indicated that the 2005 alewife population was  
10 the lowest since the bi-national pelagic planktivore monitoring program began in 1997, making  
11 0.0074 percent a conservative estimate; however, the rainbow smelt population had increased  
12 in 2005 from two previous low years (Schaner and LaPan 2005). Threespine stickleback is an  
13 invasive species that has been prominent in the Lake Ontario ecosystem since the early 1990s.  
14 There is no formal monitoring program conducted for this species, but monitoring programs for  
15 pelagic fish of interest (alewife and rainbow smelt) have noted that threespine stickleback have  
16 been the dominant catch in most lake tows (Schaner and Prindle 2004).

17 Since the inception of the JAFNPP impingement monitoring program, a total of 2966 salmonids  
18 (corrected for intake flow and traveling screen efficiencies) have been impinged from 1976

## Environmental Impacts of Operation

1 through 1997, and in 2004. In 2005 alone, the NYSDEC salmonid stocking program stocked  
2 3,554,745 salmonids in Lake Ontario and its tributaries (Eckert 2005). OMNR also conducts its  
3 own stocking program. Concentrated stocking efforts began in 1980, with Ontario and New  
4 York limiting stocking to a total of 8 million salmonids per year. In response to the prey fish  
5 population concerns, current combined stocking levels have been maintained between 4 and  
6 5.5 million salmonids per year since 1993 (Mills et al. 2003).

7 A number of biological, environmental, and meteorological factors may work in concert to  
8 influence yearly variations in impingement species abundance. The recent increase in  
9 threespine stickleback impingements may be partly caused by the lake-wide decrease in alewife  
10 and the dominating presence of zebra mussels. Impingement rates are highest in the spring  
11 and peak in May when approximately 35 percent of all impingement occurs. This corresponds  
12 with fish migrating toward warmer inshore waters to spawn. The timing of the migration may  
13 vary according to meteorological conditions. Impingement rates then begin to fall again in June  
14 as fish migrate back to deeper waters after spawning. Impingement rates once again increase  
15 from October through December, when 21 percent of all impingement occurs. This is thought to  
16 occur because at this time, young-of-year fish, especially alewife and rainbow smelt, grow to a  
17 size that is particularly susceptible to impingement. Certain meteorological conditions, such as  
18 strong westerly and northwesterly winds, wave height, and water temperature, also appear to  
19 influence young-of-year impingement at this time of year (EA 2005).

20 Other factors impacting impingement include the timing and duration of station outages for  
21 refueling and maintenance. During maintenance or refueling outages, typically only one or two  
22 of the three main circulating water pumps are operational, significantly reducing the flow of lake  
23 water into the plant. The reduced flow through the intake generally results in reduced  
24 impingement. In recent years, plants outages have become less frequent and shorter in  
25 duration due to improvements in plant operational efficiency, so outage reduction effects on  
26 impingement are less than those that occurred in the 1980s and 1990s (EA 2005). Warm  
27 discharge water is also recirculated during periods of cold weather, reducing lake water flow into  
28 the plant. JAFNPP has compiled monthly actual intake flow data from January 1998 through  
29 July 2005, and actual pumping rates have historically been lower than plant-design flows. This  
30 is because the circulating water pumps operate at various head differentials and the plant's  
31 cooling water needs vary in response to reduced generation, environmental conditions, and  
32 periodic maintenance outages. These historical data are considered representative of the  
33 current and expected future cooling water intake flow operations at JAFNPP (Entergy 2006b).

34 Generally, meteorological conditions that change fish populations appear to have the most  
35 profound effect on impingement rates at JAFNPP. Periodic die-offs of populations occur due to  
36 a combination of climatic conditions and the physical condition of population individuals. As  
37 mentioned above, this was most prominently seen in the winter/spring 1977 alewife die-off: the  
38 alewife impingement rate dropped from 3,916,717 fish in 1976 to 187,305 in 1977 (EA 2005).



1 Historically, changes in fish populations around JAFNPP have likely been the result of naturally  
2 occurring fluctuations. When the changes are profound (such as a mass winter die-off of  
3 alewife), they are easily observed in the annual estimates of fish impinged at JAFNPP.  
4 However, when the changes are subtle and over a longer period of time, it is difficult to  
5 differentiate between meteorological conditions and daily plant operations, the two main factors  
6 in fish impingement.

7 Due to the susceptibility of alewife to be impinged in the intake area, the delicate nature of  
8 alewife, and the strong fright response to high frequency sound that alewife demonstrate, at the  
9 time of JAFNPP's last SPDES permit issuance, NYSDEC determined the FDS installed at  
10 JAFNPP was the best technology available for reducing impingement impacts (Entergy 2006a).  
11 This determination is documented in a letter from the NYSDEC dated March 1, 1996. Testing of  
12 the FDS occurred in spring of 1991 and 1993, and it was shown to reduce alewife impingement  
13 by over 87 percent. Another deterrence system test was conducted in 1997, and preliminary  
14 results confirmed the FDS reduced alewife impingement by 87 percent (EA 2005). The FDS  
15 has only been proven to deter alewife; no studies have been done to document its effectiveness  
16 on other pelagic species. Since the FDS was installed, there have been no significant alewife  
17 impingement events at JAFNPP.

18 In the JAFNPP *Proposal for Information Collection* dated January 31, 2006 (Entergy 2006b),  
19 submitted to the NYSDEC to satisfy 316(b) Phase II regulations, JAFNPP proposed to obtain no  
20 new impingement data because a recent annual impingement study had been completed in  
21 2004. Since plant operations will not change significantly, these 2004 impingement rates are  
22 indicative of future impingement rates, and are considered by the NRC staff to be too small to  
23 have any observable impact on the lake-wide populations and biomass. Based on the results of  
24 past impingement studies and the operating history of the JAFNPP intake structure and FDS,  
25 the NRC staff concludes that the potential impacts of impingement for fish and shellfish at  
26 JAFNPP are SMALL. The NRC staff identified potential mitigation measures, including installing  
27 a fish return system, closed cycle cooling, and derating the facility and scheduling plant outages  
28 during historic peak impingement periods. However, the NRC staff concluded that none of the  
29 mitigation measures considered would be beneficial enough to reduce the significance of  
30 adverse impingement impacts to the Lake Ontario fishery. Under the provisions of the state  
31 NPDES permitting program, however, NYSDEC may impose further restrictions or require  
32 modifications to the cooling system to reduce the impact of impingement.

### 33 **4.1.3 Heat Shock**

34 Heat shock can be defined as acute thermal stress caused by exposure to a sudden elevation  
35 of water temperature that adversely affects the metabolism and behavior of fish and can lead to  
36 death. Heat shock is most likely to occur when an offline unit returns to service or when a  
37 station has a discharge canal, effectively trapping fish in the flow of the heated discharge from  
38 the plant. For plants with once-through cooling systems, the effects of heat shock are listed as  
39 a Category 2 issue, requiring a plant-specific assessment before license renewal. In the GEIS,  
40 the NRC made impacts on fish and shellfish resources resulting from heat shock a Category 2

## Environmental Impacts of Operation

1 issue for once-through plants because of continuing concerns about thermal-discharge effects  
2 and the possible need to modify thermal discharges in the future in response to changing  
3 environmental conditions. Information to be considered includes (1) the type of cooling system  
4 (whether once-through or cooling pond) and (2) evidence of a CWA Section 316(a) variance or  
5 equivalent State documentation. To perform this evaluation, the NRC staff visited the JAFNPP  
6 site several times, reviewed the JAFNPP ER (Entergy 2006a), reviewed JAFNPP's original  
7 CWA Section 316(a) demonstration report (NYPA 1976), and reviewed JAFNPP's most current  
8 SPDES permit (NY-0020109), which was issued on August 1, 2001, and is in force until a new  
9 permit is issued by NYSDEC (Entergy 2006a).

10 Section 316(a) of the CWA establishes a process whereby the applicant can demonstrate that  
11 the established thermal discharge limitations are more stringent than necessary to protect  
12 balanced indigenous populations of fish and wildlife and obtain facility-specific thermal  
13 discharge limits (33 U.S.C. 1326). The JAFNPP CWA Section 316(a) demonstration was  
14 submitted to the NYSDEC in 1976 by NYPA, the former owner of JAFNPP. The demonstration  
15 was based on pre-operational and post-operational engineering, hydrological, and ecological  
16 data, and concluded that thermal discharge from the plant would not result in any long-term  
17 adverse impacts to the Lake Ontario ecosystem. The JAFNPP CWA Section 316(a)  
18 demonstration followed procedures prescribed by the EPA during meetings between NYPA and  
19 EPA, and as outlined in the draft EPA document, *316(a) Technical Guidance Manual and Guide  
20 for Thermal Effects Sections of Nuclear Facilities Environmental Impact Statements*, dated  
21 May 1, 1977 (EPA 1977). The 316(a) demonstration included a description of the plant,  
22 baseline hydrographic characteristics of Lake Ontario and the site, plant thermal discharge  
23 characteristics, a description of the biological community in the Nine Mile Point vicinity and a  
24 selection of representative fish species, and an evaluation of potential impacts of the plant's  
25 thermal discharge. The potential thermal discharge effects were based on thermal tolerance  
26 and behavior data for the representative fish species, field data collected in the vicinity of  
27 JAFNPP, and a review of literature on the effect of thermal discharges. It was concluded that  
28 the multi-port diffuser design of the JAFNPP discharge structure would prevent the thermal  
29 discharge from harming the biological community in the Nine Mile Point vicinity (NYPA 1976).

30 NYSDEC accepted the conclusions of the 316(a) demonstration in their first issuance of the  
31 JAFNPP SPDES permit containing the CWA Section 316(a) variance specifying alternative  
32 thermal effluent limitations for the plant, and subsequently in renewed permits issued thereafter.  
33 JAFNPP's SPDES permit states that thermal discharge from the plant ensures the "protection  
34 and propagation of a balanced indigenous population of shellfish, fish, and wildlife in Lake  
35 Ontario" and as such, the plant is allowed alternative effluent limitations. These limitations are  
36 included in Part 1, Condition 8 of the plant's SPDES permit and state that the water temperature  
37 at the surface of the lake shall not be raised more than 3°F over the ambient temperature of the  
38 water, with the exception of a 35-acre (ac) ( $1.524.6 \times 10^6 \text{ ft}^2$ ) mixing zone from the point of  
39 discharge. To ensure this condition is met, the permit allows a maximum discharge temperature  
40 of 112°F as measured at the discharge outlet in the screenwell-pumphouse, with a maximum  
41 allowable intake-discharge temperature difference ( $\Delta T$ ) of 32.4°F. The net addition of heat

1 rejected to Lake Ontario is limited to  $6.00 \times 10^9$  British thermal units per hour (BTU/hr) (Entergy  
2 2006a). Total heat rejected to the lake is a function of electrical load—heat rejection increases  
3 with an increase in electrical load. When JAFNPP is operating at full power, the heat rejection  
4 rate is calculated to be  $5.714 \times 10^9$  BTU/hr (NYPA 1976).

5 Because of the proximity of NMPNS (3200 ft west of JAFNPP), the U.S. Atomic Energy  
6 Commission (AEC) in its 1973 *Final Environmental Statement Related to the Operation of*  
7 *James A. FitzPatrick Nuclear Power Plant* determined that under certain conditions JAFNPP  
8 discharge could exceed New York State thermal criteria (AEC 1973). As such, and as a  
9 condition of the plant SPDES permit, JAFNPP conducts a thermal monitoring program  
10 consisting of continual discharge temperature and  $\Delta T$  recording, and has proposed mitigation  
11 measures, such as flow reductions, should corrective action be needed to maintain compliance  
12 with the New York State thermal criteria. To date, no additional mitigation measures have been  
13 necessary. JAFNPP submits quarterly reports to NYSDEC that contain information on daily  
14 electrical output, water use, and intake and discharge water temperatures (Entergy 2006a;  
15 AEC 1973).

16 Heat shock to fish is a function of the temperature increase that the fish are subjected to in the  
17 discharge flow area and the residence time of the fish in the heated discharge flow (Fry 1971;  
18 Dean 1973). Cold shock can occur when fish acclimated to warm effluents are abruptly  
19 exposed to very low ambient temperatures. This may occur during plant outages when  
20 discharge flow is lower than during normal operation (NYPA 1976). According to JAFNPP  
21 personnel, to date, there have been no heat or cold shock events during station operation that  
22 have resulted in the immediate distress or acute mortality of fish. If such an event were  
23 observed by JAFNPP personnel, the incident would have to be reported to NYSDEC as a  
24 condition of the SPDES permit (Section 5b[1][iv]) (Entergy 2006a).

25 The multi-port diffuser design and offshore location of JAFNPP's discharge structure have likely  
26 prevented heat and cold shock events. Analysis of the JAFNPP diffuser design in the 1976  
27 NYPA 316(a) demonstration indicated that the discharge plume (before surfacing) decreases in  
28  $\Delta T$  from 31.5°F to 13.5°F in one second and further decreases to 9°F four seconds after  
29 discharge. Additionally, hydrothermal field surveys confirmed the rapid dilution of the thermal  
30 effluent: the 3°F isotherm would cover a maximum surface area of 27.5 ac ( $1196 \times 10^3$  ft<sup>2</sup>), well  
31 within the maximum 35-ac mixing zone allowed in the JAFNPP SPDES permit Section 316(a)  
32 variance (NYPA 1976).

33 The 316(a) demonstration study reported that voluntary exposure to the heated effluent by  
34 representative fish species would not likely cause mortalities because the velocity of the  
35 discharge stream would not allow fish to maintain themselves long enough in an area where the  
36 discharge water temperature would be lethal. Fish behavior studies have indicated that when  
37 given a range of temperatures, fish demonstrate avoidance responses to unsuitable  
38 temperatures; the offshore, open area location of the JAFNPP discharge structure allows fish to  
39 avoid the heated discharge stream. The design of the multi-port diffuser discharge structure  
40 could entrain fish into the high-velocity discharge jet stream, but it was demonstrated that fish

1 entrained at the point of discharge would be in safe water temperatures in less than one  
2 second, making plume entrainment mortality unlikely. Regarding cold shock, acclimation to  
3 elevated temperatures is a precondition for cold shock mortality. The diffuser jets at JAFNPP  
4 preclude this acclimation as fish are not able to maintain themselves in the area of heated  
5 discharge. Additionally, during plant outages, because of JAFNPP's proximity to NMPNS  
6 (providing another source of heated discharge) and the location of the discharge structure, cold  
7 shock would not be expected to impact fish in the JAFNPP vicinity (NYPA 1976).

8 The NRC staff has reviewed the available information, including that provided by the applicant,  
9 visited the site, and reviewed other public sources of information on heat shock. Plant operating  
10 conditions have not changed significantly since the original 316(a) demonstration, and it can  
11 therefore be reasonably concluded that the extent and distribution of JAFNPP's thermal plume  
12 has remained relatively unchanged. The NRC staff evaluated the potential impacts to aquatic  
13 resources due to heat shock during continued operation and determined that thermal impacts  
14 were unlikely because of the design and location of the JAFNPP discharge structure.  
15 Furthermore, there have been no observable impacts related to plant thermal discharges.  
16 Therefore, it is the NRC staff's conclusion that the potential impacts to fish and shellfish due to  
17 heat shock during the renewal term are SMALL. The NRC staff identified potential mitigation  
18 measures, including closed cycle cooling, helper cooling towers, derating the plant, and certain  
19 operational procedures. However, the NRC staff concluded that none of the mitigation  
20 measures considered would be beneficial enough to reduce the significance of heat shock  
21 impacts to Lake Ontario.

## 22 **4.2 Transmission Lines**

23 The JAFNPP ER (Entergy 2006a) describes two 345-kilovolt (kV) and two 115-kV transmission  
24 lines that connect JAFNPP with the transmission system (see Section 2.1.7 of this draft SEIS for  
25 a description of the transmission lines). Two of the lines, the Edic and the Scriba 345-kV lines,  
26 are within the scope of the license renewal review. Offsite line maintenance for both lines is  
27 accomplished by the lines' owner, NYPA. For the two 345-kV transmission line right-of-ways  
28 (ROWs), NYPA uses a vegetation management plan approved by the New York State Public  
29 Service Commission. NYPA uses an integrated vegetation management computer application,  
30 which employs geographic information system technology. The vegetation management  
31 program is designed to control tall-growing tree species and to enhance the abundance of lower  
32 growing desirable vegetation. Field inventories are conducted annually for the ROW scheduled  
33 for clearing the following year. The inventories and treatment recommendations are reviewed  
34 and approved by the NYPA forestry staff. The majority of clearing is performed using  
35 mechanical methods. Herbicide applications are individually applied to selected plant species  
36 by licensed contractors, and a safe buffer is maintained around wetlands, and stream and river  
37 crossings. A safe buffer is also used around wells and springs that are used for residential  
38 water supplies. Areas where herbicides are used are posted with information regarding the

1 chemicals used and when they were applied. Herbicides are not applied on NYPA ROWs using  
2 aerial application methods.

3 Category 1 issues in 10 CFR Part 51, Subpart A, Appendix B, Table B-1, that are applicable to  
4 transmission lines from JAFNPP are listed in Table 4-5. Entergy stated in the JAFNPP ER that  
5 it was not aware of any new and significant information associated with the renewal of the  
6 JAFNPP OL. The NRC staff has not identified any new and significant information during its  
7 independent review of the JAFNPP ER (Entergy 2006a), the staff's site audit, the scoping  
8 process, or its evaluation of other available information. Therefore, the NRC staff concludes  
9 that there are no impacts related to these issues beyond those discussed in the GEIS. For all of  
10 those issues, the NRC staff concluded in the GEIS that the impacts would be SMALL, and  
11 additional plant-specific mitigation measures are not likely to be sufficiently beneficial to be  
12 warranted.

13 **Table 4-5.** Category 1 Issues Applicable to the JAFNPP Transmission  
14 Lines During the Renewal Term

<b>ISSUE—10 CFR Part 51, Subpart A, Appendix B, Table B-1</b>	<b>GEIS Section</b>
<b>TERRESTRIAL RESOURCES</b>	
Power line right-of-way management (cutting and herbicide application)	4.5.6.1
Bird collisions with power lines	4.5.6.2
Impacts of electromagnetic fields on flora and fauna (plants, agricultural crops, honeybees, wildlife, livestock)	4.5.6.3
Floodplains and wetland on power line right of way	4.5.7
<b>AIR QUALITY</b>	
Air quality effects of transmission lines	4.5.2
<b>LAND USE</b>	
Onsite land use	4.5.3
Power line right of way	4.5.3

15

16 A brief description of the NRC staff's review and GEIS conclusions, as codified in 10 CFR  
17 Part 51, Subpart A, Appendix B, Table B-1, for each of these issues follows:

- 18 • Power line ROW management (cutting and herbicide application). Based on information in  
19 the GEIS, the Commission found that

Environmental Impacts of Operation

1           The impacts of right-of-way maintenance on wildlife are expected to be of small  
2           significance at all sites.

3           The NRC staff has not identified any new and significant information during its independent  
4           review of the JAFNPP ER (Entergy 2006a), the staff's site audit, the scoping process, or its  
5           evaluation of other information. Therefore, the NRC staff concludes that there would be no  
6           impacts of power line ROW maintenance during the renewal term beyond those discussed  
7           in the GEIS.

8           • Bird collisions with power lines. Based on information in the GEIS, the Commission found  
9           that

10           Impacts are expected to be of small significance at all sites.

11           The NRC staff has not identified any new and significant information during its independent  
12           review of the JAFNPP ER (Entergy 2006a), the staff's site audit, the scoping process, or its  
13           evaluation of other information. Therefore, the NRC staff concludes that there would be no  
14           impacts of bird collisions with power lines during the renewal term beyond those discussed  
15           in the GEIS.

16           • Impacts of electromagnetic fields on flora and fauna (plants, agricultural crops, honeybees,  
17           wildlife, livestock). Based on information in the GEIS, the Commission found that

18           No significant impacts of electromagnetic fields on terrestrial flora and fauna  
19           have been identified. Such effects are not expected to be a problem during the  
20           license renewal term.

21           The NRC staff has not identified any new and significant information during its independent  
22           review of the JAFNPP ER (Entergy 2006a), the staff's site audit, the scoping process, or its  
23           evaluation of other information. Therefore, the NRC staff concludes that there would be no  
24           impacts of electromagnetic fields on flora and fauna during the renewal term beyond those  
25           discussed in the GEIS.

26           • Floodplains and wetland on power line ROW. Based on information in the GEIS, the  
27           Commission found that

28           Periodic vegetation control is necessary in forested wetlands underneath power  
29           lines and can be achieved with minimal damage to the wetland. No significant  
30           impact is expected at any nuclear power plant during the license renewal term.

31           The NRC staff has not identified any new and significant information during its independent  
32           review of the JAFNPP ER (Entergy 2006a), the staff's site audit, the scoping process, or its  
33           evaluation of other information. Therefore, the NRC staff concludes that there would be no

1 impacts of power line ROWs on floodplains and wetlands during the renewal term beyond  
2 those discussed in the GEIS.

3 • Air quality effects of transmission lines. Based on the information in the GEIS, the  
4 Commission found that

5 Production of ozone and oxides of nitrogen is insignificant and does not  
6 contribute measurably to ambient levels of these gases.

7 The NRC staff has not identified any new and significant information during its independent  
8 review of the JAFNPP ER (Entergy 2006a), the staff's site audit, the scoping process, or its  
9 evaluation of other information. Therefore, the NRC staff concludes that there would be no  
10 air quality impacts of transmission lines during the renewal term beyond those discussed in  
11 the GEIS.

12 • Onsite land use. Based on the information in the GEIS, the Commission found that

13 Projected onsite land use changes required during the renewal period would be a  
14 small fraction of any nuclear power plant site and would involve land that is  
15 controlled by the applicant.

16 The NRC staff has not identified any new and significant information during its independent  
17 review of the JAFNPP ER (Entergy 2006a), the staff's site audit, the scoping process, or its  
18 evaluation of other information. Therefore, the NRC staff concludes that there would be no  
19 onsite land-use impacts during the renewal term beyond those discussed in the GEIS.

20 • Power line ROW. Based on information in the GEIS, the Commission found that

21 Ongoing use of power line right of ways would continue with no change in  
22 restrictions. The effects of these restrictions are of small significance.

23 The NRC staff has not identified any new and significant information during its independent  
24 review of the JAFNPP ER (Entergy 2006a), the staff's site audit, the scoping process, or its  
25 evaluation of other information. Therefore, the NRC staff concludes that there would be no  
26 impacts of power line ROWs on land use during the renewal term beyond those discussed  
27 in the GEIS.

28 One issue related to transmission lines is a Category 2 issue, and another issue related to  
29 transmission lines is being treated as a Category 2 issue. These issues are listed in Table 4-6  
30 and are discussed in Sections 4.2.1 and 4.2.2.

1 **Table 4-6.** Category 2 and Uncategorized Issues Applicable to the  
 2 JAFNPP Transmission Lines During the Renewal Term

ISSUE—10 CFR Part 51, Subpart A, Appendix B, Table B-1	GEIS Section	10 CFR 51.53(c)(3)(ii) Subparagraph	SEIS Section
<b>HUMAN HEALTH</b>			
Electromagnetic fields—acute effects (electric shock)	4.5.4.1	H	4.2.1
Electromagnetic fields—chronic effects	4.5.4.2	NA	4.2.2

3

4 **4.2.1 Electromagnetic Fields—Acute Effects**

5 Based on the GEIS, the Commission found that electric shock resulting from direct access to  
 6 energized conductors or from induced charges in metallic structures has not been found to be a  
 7 problem at most operating plants and generally is not expected to be a problem during the  
 8 license renewal term. However, site-specific review is required to determine the significance of  
 9 the electric shock potential along the portions of the transmission lines that are within the scope  
 10 of this draft SEIS.

11 In the GEIS, the NRC staff found that without a review of the conformance of each nuclear plant  
 12 transmission line with National Electrical Safety Code (NESC®) criteria, it was not possible to  
 13 determine the significance of the electric shock potential. Evaluation of individual plant  
 14 transmission lines is necessary because the issue of electric shock safety was not addressed in  
 15 the licensing process for some plants. For other plants, land use in the vicinity of transmission  
 16 lines may have changed, or power distribution companies may have chosen to upgrade line  
 17 voltage. To comply with 10 CFR 51.53(c)(3)(ii)(H), the applicant must provide an assessment of  
 18 the potential shock hazard if the transmission lines that were constructed for the specific  
 19 purpose of connecting the plant to the transmission system do not meet the recommendations  
 20 of the NESC® for preventing electric shock from induced currents.

21 As described in Section 2.1.7 of this draft SEIS, two single-circuit 345-kV lines exiting the  
 22 switchyard connect JAFNPP to the transmission grid. One line, approximately 70 miles (mi)  
 23 long, connects to the transmission system at NYPA’s Edic Substation. The other line,  
 24 approximately 4900 ft (0.9 mi) long, connects to the transmission system at the National Grid  
 25 Scriba Substation located on the NMPNS site. Although JAFNPP owns the lines within the site  
 26 property boundary, lines exiting the property boundary are owned and maintained by NYPA.  
 27 These two lines were evaluated concerning adherence to the NESC® steady-state limit  
 28 (Entergy 2006a).

29 As stated above, the NESC® specifies minimum vertical clearances to the ground for electric  
 30 lines. For electric lines operating at voltages exceeding 98-kV alternating current (AC) to



1 ground, the clearance provided must limit the steady-state current due to electrostatic effects to  
2 5 milliamperes (mA) if the largest anticipated vehicle were short-circuited to ground. The largest  
3 vehicle anticipated under JAFNPP's 345-kV lines is a tractor-trailer that is 65 ft long and 13.5 ft  
4 tall, parked along a roadway. The 5-mA design standard limits electric fields within the ROW to  
5 7 to 8 kV/meter (Entergy 2006a).

6 According to the NYPA Transmission Engineering Department, the two 345-kV transmission  
7 lines at JAFNPP are operated and maintained in a manner consistent with the design criteria  
8 listed in the GEIS, Section 4.5.4.1. Specifically, these lines meet a more stringent induced  
9 shock standard than the 5-mA design criterion of NESC® (1981). The State of New York Public  
10 Service Commission (NYPSC) requires that transmission lines in New York be designed so that  
11 the short-circuit current to ground, produced from the largest anticipated vehicle or object, is  
12 limited to less than 4.5 mA. This allows no more than 7.0 kV/meter electric field levels on the  
13 ROWs. In 1991, NYPA demonstrated to the NYPSC that its transmission lines, including the  
14 two 345-kV lines associated with JAFNPP, do not exceed safety levels of 6.5 kV/meter for  
15 electric fields or 4.5 mA for induced shocks (Entergy 2006a).

16 Nuisance shocks are further controlled through NYPA's annual routine inspection of ROWs for  
17 land intrusion, along with its program of informing landowners about induced shock hazards and  
18 assisting them with grounding any metallic structures in or near a ROW.

19 Entergy's assessment concluded that electric shock is of SMALL significance for the JAFNPP  
20 345-kV transmission lines (Entergy 2006a). The lines are operated within their original design  
21 specifications, the ROWs are routinely monitored for any land-use changes, and NYPA has  
22 demonstrated that the 345-kV transmission lines meet the NESC® (1981) requirements for  
23 preventing induced shock hazards. Due to the small significance of the issue, mitigation  
24 measures such as installing warning signs at road crossings or increasing clearances are not  
25 warranted.

26 Based on a review of the available information, including that provided by the applicant (Entergy  
27 2006a), the NRC staff's site audit, the scoping process, and an evaluation of other information,  
28 the staff concludes that the potential impacts for electric shock during the renewal term are  
29 SMALL. The NRC staff identified potential mitigation measures, including installing road signs  
30 at road crossings and increased clearances. However, the NRC staff concluded that none of  
31 the mitigation measures considered would be beneficial enough to reduce the significance of  
32 the adverse impacts to people.

#### 33 **4.2.2 Electromagnetic Fields—Chronic Effects**

34 In the GEIS, the chronic effects of 60-Hz electromagnetic fields from power lines are not  
35 designated as Category 1 or 2 and will not be until a scientific consensus is reached on the  
36 health implications of these fields.

## Environmental Impacts of Operation

1 The potential for chronic effects from these fields continues to be studied and is not known at  
2 this time. The National Institute of Environmental Health Sciences (NIEHS) directs related  
3 research through the U.S. Department of Energy (DOE). An NIEHS report (NIEHS 1999)  
4 contains the following conclusion:

5 The NIEHS concludes that ELF-EMF (extremely low frequency-electromagnetic field)  
6 exposure cannot be recognized as entirely safe because of weak scientific evidence that  
7 exposure may pose a leukemia hazard. In our opinion, this finding is insufficient to warrant  
8 aggressive regulatory concern. However, because virtually everyone in the United States  
9 uses electricity and therefore is routinely exposed to ELF-EMF, passive regulatory action is  
10 warranted such as a continued emphasis on educating both the public and the regulated  
11 community on means aimed at reducing exposures. The NIEHS does not believe that other  
12 cancers or non-cancer health outcomes provide sufficient evidence of a risk to currently  
13 warrant concern.

14 This statement is not sufficient to cause the NRC staff to change its position with respect to the  
15 chronic effects of electromagnetic fields. Footnote 4 to Table B-1 of 10 CFR Part 51, Subpart A,  
16 Appendix B, states

17 If in the future, the Commission finds that, contrary to current indications, a consensus has  
18 been reached by appropriate Federal health agencies that there are adverse health effects  
19 from electromagnetic fields, the Commission will require applicants to submit plant-specific  
20 reviews of those health effects as part of their license renewal applications. Until such time,  
21 applicants for license renewal are not required to submit information on this issue.

22 The NRC staff considers the GEIS finding of "Uncertain" still appropriate and will continue to  
23 follow developments on this issue.

### 24 **4.3 Radiological Impacts of Normal Operations**

25 Category 1 issues in 10 CFR Part 51, Subpart A, Appendix B, Table B-1, that are applicable to  
26 JAFNPP in regard to radiological impacts are listed in Table 4-7. Entergy stated in its ER  
27 (Entergy 2006a) that it is not aware of any new and significant information associated with the  
28 renewal of the JAFNPP OL. The NRC staff has not identified any new and significant  
29 information during its independent review of the JAFNPP ER, the staff's site audit, the scoping  
30 process, or its evaluation of other available information. Therefore, the NRC staff concludes  
31 that there are no impacts related to these issues beyond those discussed in the GEIS. For  
32 these issues, the NRC staff concluded in the GEIS that the impacts are SMALL, and additional  
33 plant-specific mitigation measures are not likely to be sufficiently beneficial to be warranted.

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

**Table 4-7. Category 1 Issues Applicable to Radiological Impacts of Normal Operations During the Renewal Term**

ISSUE—10 CFR Part 51, Subpart A, Appendix B, Table B-1	GEIS Section
<b>HUMAN HEALTH</b>	
Radiation exposures to public (license renewal term)	4.6.2
Occupational radiation exposures (license renewal term)	4.6.3

A brief description of the NRC staff’s review and the GEIS conclusions, as codified in 10 CFR Part 51, Subpart A, Appendix B, Table B-1, for each of these issues follows:

- Radiation exposures to public (license renewal term). Based on information in the GEIS, the Commission found that

Radiation doses to the public will continue at current levels associated with normal operations.

The NRC staff has not identified any new and significant information during its independent review of the JAFNPP ER (Entergy 2006a), the staff’s site audit, the scoping process, or its evaluation of other available information. Therefore, the NRC staff concludes that there would be no impacts of radiation exposures to the public during the renewal term beyond those discussed in the GEIS.

- Occupational radiation exposures (license renewal term). Based on information in the GEIS, the Commission found that

Projected maximum occupational doses during the license renewal term are within the range of doses experienced during normal operations and normal maintenance outages, and would be well below regulatory limits.

The NRC staff has not identified any new and significant information during its independent review of the JAFNPP ER (Entergy 2006a), the staff’s site audit, the scoping process, or its evaluation of other available information. Therefore, the NRC staff concludes that there would be no impacts of occupational radiation exposures during the renewal term beyond those discussed in the GEIS.

There are no Category 2 issues related to radiological impacts of routine operations.

1 **4.4 Socioeconomic Impacts of Plant Operations During the License Renewal Term**

2 Category 1 issues in 10 CFR Part 51, Subpart A, Appendix B, Table B-1, that are applicable to  
 3 socioeconomic impacts during the renewal term are listed in Table 4-8. JAFNPP stated in its  
 4 ER (Entergy 2006a) that it is not aware of any new and significant information associated with  
 5 the renewal of the JAFNPP OL. The NRC staff has not identified any new and significant  
 6 information during its independent review of the JAFNPP ER, the staff's site audit, the scoping  
 7 process, or its evaluation of other available information. Therefore, the NRC staff concludes  
 8 that there are no impacts related to these issues beyond those discussed in the GEIS. For  
 9 these issues, the NRC staff concluded in the GEIS that the impacts are SMALL, and additional  
 10 plant-specific mitigation measures are not likely to be sufficiently beneficial to be warranted.

11 **Table 4-8.** Category 1 Issues Applicable to Socioeconomics During the Renewal Term

ISSUE—10 CFR Part 51, Subpart A, Appendix B, Table B-1	GEIS Section
<b>SOCIOECONOMICS</b>	
Public services: public safety, social services, and tourism and recreation	4.7.3; 4.7.3.3; 4.7.3.4; 4.7.3.6
Public services: education (license renewal term)	4.7.3.1
Aesthetic impacts (license renewal term)	4.7.6
Aesthetic impacts of transmission lines (license renewal term)	4.5.8

12

13 A brief description of the NRC staff's review and the GEIS conclusions, as codified in Table B-1  
 14 of 10 CFR Part 51, Subpart A, Appendix B, for each of these issues follows:

- 15 • Public services: public safety, social services, and tourism and recreation. Based on  
 16 information in the GEIS, the Commission found that

Impacts to public safety, social services, and tourism and recreation are  
 expected to be of small significance at all sites.

17 The NRC staff has not identified any new and significant information during its independent  
 18 review of the JAFNPP ER (Entergy 2006a), the staff's site audit, the scoping process, or its  
 19 evaluation of other available information. Therefore, the NRC staff concludes that there  
 20 would be no impacts on public safety, social services, and tourism and recreation during the  
 21 renewal term beyond those discussed in the GEIS.

- 1 • Public services: education (license renewal term). Based on information in the GEIS, the  
2 Commission found that

Only impacts of small significance are expected.

3 The NRC staff has not identified any new and significant information during its independent  
4 review of the JAFNPP ER (Entergy 2006a), the staff's site audit, the scoping process, or its  
5 evaluation of other available information. Therefore, the NRC staff concludes that there  
6 would be no impacts on education during the renewal term beyond those discussed in the  
7 GEIS.

- 8 • Aesthetic impacts (license renewal term). Based on information in the GEIS, the  
9 Commission found that

No significant impacts are expected during the license renewal term.

10 The NRC staff has not identified any new and significant information during its independent  
11 review of the JAFNPP ER (Entergy 2006a), the staff's site audit, the scoping process, or its  
12 evaluation of other available information. Therefore, the NRC staff concludes that there  
13 would be no aesthetic impacts during the renewal term beyond those discussed in the GEIS.

- 14 • Aesthetic impacts of transmission lines (license renewal term). Based on information in the  
15 GEIS, the Commission found that

No significant impacts are expected during the license renewal term.

16 The NRC staff has not identified any new and significant information during its independent  
17 review of the JAFNPP ER (Entergy 2006a), the staff's site audit, the scoping process, or its  
18 evaluation of other available information. Therefore, the NRC staff concludes that there  
19 would be no aesthetic impacts of transmission lines during the renewal term beyond those  
20 discussed in the GEIS.

21 Table 4-9 lists the Category 2 socioeconomic issues, which require plant-specific analysis, and  
22 environmental justice, which was not addressed in the GEIS.

1  
2

**Table 4-9.** Category 2 Issues Applicable to Socioeconomics and Environmental Justice During the Renewal Term

ISSUE—10 CFR Part 51, Subpart A, Appendix B, Table B-1	GEIS Section	10 CFR 51.53(c)(3)(ii) Subparagraph	SEIS Section
<b>SOCIOECONOMICS</b>			
Housing impacts	4.7.1	I	4.4.1
Public services: public utilities	4.7.3.5	I	4.4.2
Offsite land use (license renewal term)	4.7.4	I	4.4.3
Public services: transportation	4.7.3.2	J	4.4.4
Historic and archaeological resources	4.7.7	K	4.4.5
Environmental justice	Not addressed <sup>(a)</sup>	Not addressed <sup>(a)</sup>	4.4.6

(a) Guidance related to environmental justice was not in place at the time the GEIS and the associated revision to 10 CFR Part 51 were prepared. Therefore, environmental justice must be addressed in the NRC staff's environmental impact statement.

3

#### 4 4.4.1 Housing Impacts

5 In determining housing impacts, the applicant chose to follow Appendix C of the GEIS, which  
6 presents a population characterization method that is based on two factors, sparseness and  
7 proximity (GEIS, Section C.1.4). Sparseness measures population density within 20 mi of the  
8 site, and proximity measures population density and city size within 50 mi. Each factor has  
9 categories of density and size (GEIS, Table C.1). A matrix is used to rank the population  
10 category as low, medium, or high (GEIS, Figure C.1).

11 In 2000, approximately 109,440 persons lived within a 20-mi radius of JAFNPP (Entergy  
12 2006a), which equates to a population density of 87 persons per square mile (mi<sup>2</sup>). This density  
13 translates to Category 3 (60 to 120 persons per mi<sup>2</sup> or fewer than 60 persons per mi<sup>2</sup> with at  
14 least one community of 25,000 or more persons within 20 mi) using the GEIS sparseness factor.  
15 At the same time, there were approximately 914,668 persons living within a 50-mi radius of the  
16 plant, for a density of 117 persons per mi<sup>2</sup>. The Syracuse MSA, located within 50 mi of the site,  
17 had a total population in 2000 of 732,117. Therefore, JAFNPP falls into Category 3 (one or  
18 more cities with 100,000 or more persons and fewer than 190 persons per mi<sup>2</sup> within 50 mi)  
19 using the GEIS proximity factor. A Category 3 value indicates that JAFNPP is in a medium-  
20 density population area (NRC 2006a).

1 Refurbishment activities and continued operations could result in housing impacts due to  
2 increased staffing. However, there are no major refurbishment activities required for JAFNPP  
3 license renewal. Therefore, there would be no refurbishment-related impacts to area housing.

4 Table B-1 of 10 CFR Part 51, Subpart A, Appendix B, states that impacts on housing availability  
5 are expected to be of small significance at plants located in a medium-density population area  
6 where growth-control measures are not in effect. Oswego County is not subject to growth-  
7 control measures that would limit housing development, and Entergy does not anticipate a need  
8 for additional full-time workers during the license renewal period.

9 Since Entergy has no plans to add employees to support plant operations during the license  
10 renewal period, there would be no increase in demand for housing in the vicinity of the JAFNPP  
11 site. Therefore, there would be no housing impacts during the license renewal period and no  
12 mitigation would be required.

#### 13 **4.4.2 Public Services: Public Utility Impacts**

14 Impacts on public utility services are considered SMALL if there is little or no change in the  
15 ability of the system to respond to demand and thus there is no need to add capital facilities.  
16 Impacts are considered MODERATE if service capabilities are overtaxed during periods of peak  
17 demand. Impacts are considered LARGE if services (e.g., water, sewer) are substantially  
18 degraded and additional capacity is needed to meet ongoing demand. The GEIS indicates that,  
19 in the absence of new and significant information to the contrary, the only impacts on public  
20 utilities that could be significant are impacts on public water supplies.

21 Analysis of impacts on the public water supply system considered both plant demand and plant-  
22 related population growth. Section 2.1.8.1 of this draft SEIS describes the JAFNPP permitted  
23 withdrawal rate and actual use of water. The Oswego Water System (OWS) provides potable  
24 water to JAFNPP (OCDPCD 1997). Current plant usage averages 137,500 gpd with no  
25 restrictions on supply. The OWS serves approximately 23,950 customers in the Oswego,  
26 Minetta, Scriba, and Volney. The water plant obtains its water from Lake Ontario and has an  
27 allowable withdrawal allocation of approximately 62.5 million gpd. The full design capacity of  
28 the water plant is 20.1 million gpd, although 8 million gpd is reserved for Sithe Energies, Inc.,  
29 with the remaining 12 million gpd available for other industrial, residential, and commercial  
30 customers. In 2001, consumptive daily demand averaged 8 million gpd, and peak demand was  
31 approximately 10 million gpd (NRC 2006a).

32 Since Entergy has no plans to add employees to support plant operations during the license  
33 renewal period, there would be no increase in demand for public water. Therefore, there would  
34 be no impacts to public water supply during the license renewal period and no mitigation would  
35 be required.

1 **4.4.3 Offsite Land Use**

2 Offsite land use during the license renewal term is a Category 2 issue (10 CFR 51, Subpart A,  
3 Appendix B, Table B-1). Table B-1 of 10 CFR 51 Subpart A, Appendix B notes that "significant  
4 changes in land use may be associated with population and tax revenue changes resulting from  
5 license renewal."

6 Section 4.7.4 of the GEIS defines the magnitude of land-use changes as a result of plant  
7 operation during the license renewal term as follows:

8 SMALL - Little new development and minimal changes to an area's land-use pattern.

9 MODERATE - Considerable new development and some changes to the land-use pattern.

10 LARGE - Large-scale new development and major changes in the land-use pattern.

11 Tax revenue can affect land use because it enables local jurisdictions to provide the public  
12 services (e.g., transportation and utilities) necessary to support development. Section 4.7.4.1 of  
13 the GEIS states that the assessment of tax-driven land-use impacts during the license renewal  
14 term should consider (1) the size of the plant's payments relative to the community's total  
15 revenues, (2) the nature of the community's existing land-use pattern, and (3) the extent to  
16 which the community already has public services in place to support and guide development. If  
17 the plant's tax payments are projected to be small relative to the community's total revenue, tax-  
18 driven land-use changes during the plant's license renewal term would be SMALL, especially  
19 where the community has pre-established patterns of development and has provided adequate  
20 public services to support and guide development. Section 4.7.2.1 of the GEIS states that if tax  
21 payments by the plant owner are less than 10 percent of the taxing jurisdiction's revenue, the  
22 significance level would be SMALL. If the plant's tax payments are projected to be medium to  
23 large relative to the community's total revenue, new tax-driven land-use changes would be  
24 MODERATE. If the plant's tax payments are projected to be a dominant source of the  
25 community's total revenue, new tax-driven land-use changes would be LARGE. This would be  
26 especially true where the community has no pre-established pattern of development or has not  
27 provided adequate public services to support and guide development.

28 *4.4.3.1 Population-Related Impacts*

29 Since Entergy has no plans to add employees to support plant operations during the license  
30 renewal period; there would be no change in land use conditions in the vicinity of the JAFNPP  
31 site. Therefore, there would be no population-related land use impacts during the license  
32 renewal period and no mitigation would be required.



#### 1 4.4.3.2 *Tax-Revenue-Related Impacts*

2 JAFNPP is assessed annual property taxes by Oswego County, the Town of Scriba, and Mexico  
3 Central Schools. Property taxes paid to Oswego County and the Town of Scriba fund such  
4 services as transportation, education, public health, and public safety.

5 Entergy has entered into an agreement with Oswego County, the Town of Scriba, and the  
6 Mexico Central Schools regarding property taxes paid to those entities for JAFNPP. The  
7 agreement stipulates that Entergy, instead of paying property taxes for JAFNPP based on the  
8 assessed value of the plant, will make standardized annual payments in lieu of taxes to the  
9 taxing entities.

10 Since Entergy has indicated that there would be no major plant refurbishment or license  
11 renewal-related construction activities necessary to support the continued operation of the  
12 JAFNPP beyond the end of the existing operating license term during the license renewal  
13 period, there would be no increase in the assessed value of JAFNPP and annual payments to  
14 the Town of Scriba, the Mexico Central Schools, and Oswego County would remain constant  
15 throughout the license renewal period. Based on this information, there would be no tax  
16 revenue-related land-use impacts during the license-renewal period and no mitigation would be  
17 required.

#### 18 **4.4.4 Public Services: Transportation Impacts**

19 Table B-1 of 10 CFR Part 51, Subpart A, Appendix B, states

20 Transportation impacts (level of service) of highway traffic generated during the term of the  
21 renewed license are generally expected to be of small significance. However, the increase  
22 in traffic associated with additional workers and the local road and traffic control conditions  
23 may lead to impacts of moderate or large significance at some sites.

24 All applicants are required by 10 CFR 51.53(c)(3)(ii)(J) to assess the impacts of highway traffic  
25 generated by the proposed project on the level of service of local highways during the term of  
26 the renewed license.

27 Since Entergy has no plans to add employees to support plant operations during the license  
28 renewal period, there would be no change in traffic volume and levels of service on roadways in  
29 the vicinity of the JAFNPP site. Therefore, there would be no transportation impacts during the  
30 license renewal period and no mitigation would be required.

#### 31 **4.4.5 Historic and Archaeological Resources**

32 The National Historic Preservation Act of 1966 (NHPA), as amended, requires Federal agencies  
33 to take into account the potential effects of their undertakings on historic properties. The  
34 historic-review process mandated by Section 106 of the NHPA is outlined in regulations issued

## Environmental Impacts of Operation

1 by the Advisory Council on Historic Preservation in 36 CFR Part 800. The renewal of an OL for  
2 a nuclear power plant is an undertaking that could possibly affect either known or potential  
3 historic properties that may be located on or near the plant site. In accordance with the  
4 provisions of the NHPA, the NRC is required to make a reasonable effort to identify historic  
5 properties in the areas of potential effect. If no historic properties are present or affected, the  
6 NRC is required to notify the State Historic Preservation Office (SHPO) before proceeding. If it  
7 is determined that historic properties are present, the NRC is required to assess and resolve  
8 possible adverse effects of the undertaking.

9 As discussed in Section 2.2.9.2 of this draft SEIS, Entergy contacted the New York State Office  
10 of Parks, Recreation, and Historic Preservation (NYSHPO) on February 9, 2006, regarding  
11 preparation of its application for the license renewal of JAFNPP (Entergy 2006a). In  
12 accordance with 36 CFR 800.8(c), the NRC contacted the NYSHPO (NRC 2006b), the Advisory  
13 Council on Historic Preservation (NRC 2006c), and the appropriate Federally recognized Native  
14 American Tribes with current and historical ties to the region on September 15, 2006.

15 On December 4, 2006, NRC staff conducted a search of the NYSHPO files for the region  
16 around JAFNPP. Although no prehistoric or historic archaeological sites have been recorded on  
17 the JAFNPP property or along the associated transmission line corridors, literature reviews,  
18 surveys, and sensitivity assessments of the JAFNPP site demonstrate there is a potential for  
19 historic and archaeological resources on undisturbed portions of the site. The potential exists  
20 for prehistoric sites to be found in and around the kettle ponds and associated wetland areas.  
21 Early maps of the JAFNPP site indicate that a number of structures, most from the nineteenth  
22 century, existed on the JAFNPP site prior to construction. Most of these structures today  
23 consist of foundations and have probable associated historic artifact scatters. Prehistoric  
24 cultural resources could also be present in the relatively undisturbed southern and eastern  
25 portions of the JAFNPP site next to kettle ponds. A walk-over of selected undeveloped portions  
26 of the JAFNPP site by NRC staff confirmed the existence of historic resources on the plant site.

27 Camp Oswego (also known as Camp Drum Anti-Aircraft Artillery Firing Range) was established  
28 during World War II immediately west of JAFNPP on property that is now occupied by Nine Mile  
29 Point Nuclear Station (USGS 1955). The camp operated well into the 1950s as a summer  
30 training base and closed sometime after 1956. The Niagara-Mohawk Electric Company later  
31 purchased the land for construction of the Nine Mile Point Nuclear Station.

32 Continued operations at JAFNPP during the renewal term would likely protect any  
33 archaeological sites present within the JAFNPP site boundary by protecting the site from  
34 development and providing secured access. However, because there is the potential for  
35 cultural resources to be present at the site, the applicant should take care during normal  
36 operations and maintenance activities related to operations not to inadvertently affect cultural  
37 resources. To avoid such adverse impacts, environmental review procedures have been put in  
38 place at JAFNPP regarding undertakings that involve land-disturbing construction or operational  
39 activities in undisturbed areas. Entergy has no plans to alter current operations during the

1 license renewal period. Additionally, Entergy states that any maintenance activities necessary  
2 to support license renewal would be limited to previously disturbed areas onsite. There is no  
3 planned expansion of the existing facilities and there are no planned refurbishment activities to  
4 support license renewal (Entergy 2006a).

5 Based on the NRC staff's review of NYSHPO files, archaeological reviews, surveys,  
6 assessments, and other information, the NRC staff concludes that the potential impacts on  
7 historic and archaeological resources during the license renewal term would be SMALL. This  
8 conclusion is based on the following: (1) no new ground disturbance or refurbishment activities  
9 would occur during the renewal period, (2) the applicant understands that archaeological and  
10 historic resources could be present at the JAFNPP site, and (3) the applicant has administrative  
11 controls in place to ensure that if cultural resources are found at JAFNPP, they will be protected.  
12 The NRC staff has determined that the impact of license renewal on historic and archaeological  
13 resources would be SMALL, and additional mitigation is not warranted.

#### 14 **4.4.6 Environmental Justice**

15 Under Executive Order 12898 (59 FR 7629), Federal agencies are responsible for identifying  
16 and addressing potential disproportionately high and adverse human health and environmental  
17 impacts on minority and low-income populations. Although the Executive Order is not  
18 mandatory for independent agencies such as the NRC, the NRC has voluntarily committed to  
19 undertake environmental justice reviews. In 2004, the Commission issued a *Policy Statement*  
20 *on the Treatment of Environmental Justice Matters in NRC Regulatory and Licensing Actions*  
21 (NRC 2004).

22 The Council of Environmental Quality (CEQ) provides the following information in *Environmental*  
23 *Justice: Guidance Under the National Environmental Policy Act* (1997):

24 **Disproportionately High and Adverse Human Health Effects.** Adverse health effects are  
25 measured in risks and rates that could result in latent cancer fatalities, as well as other fatal  
26 or nonfatal adverse impacts on human health. Adverse health effects may include bodily  
27 impairment, infirmity, illness, or death. Disproportionately high and adverse human health  
28 effects occur when the risk or rate of exposure to an environmental hazard for a minority or  
29 low-income population is significant (as defined by NEPA [National Environmental Policy  
30 Act]) and appreciably exceeds the risk or exposure rate for the general population or for  
31 another appropriate comparison group (CEQ 1997).

32 **Disproportionately High and Adverse Environmental Effects.** A disproportionately high  
33 environmental impact that is significant (as defined by NEPA) refers to an impact or risk of  
34 an impact on the natural or physical environment in a low-income or minority community that  
35 appreciably exceeds the environmental impact on the larger community. Such effects may  
36 include ecological, cultural, human health, economic, or social impacts. An adverse  
37 environmental impact is an impact that is determined to be both harmful and significant (as

## Environmental Impacts of Operation

1 defined by NEPA). In assessing cultural and aesthetic environmental impacts, impacts that  
2 uniquely affect geographically dislocated or dispersed minority or low-income populations or  
3 American Indian tribes are considered (CEQ 1997).

4 The environmental justice analysis assesses the potential for disproportionately high and  
5 adverse human health or environmental effects on minority and low-income populations that  
6 could result from the operation of JAFNPP during the renewal term. In assessing the impacts,  
7 the following CEQ (1997) definitions of minority individuals and populations and low-income  
8 population were used:

- 9 • Minority individuals. Individuals who identify themselves as members of the following  
10 population groups: Hispanic or Latino, American Indian or Alaska Native, Asian, Black or  
11 African American, Native Hawaiian or Other Pacific Islander, or two or more races meaning  
12 individuals who identified themselves on a Census form as being a member of two or more  
13 races, for example, Hispanic and Asian.
- 14 • Minority populations. Minority populations are identified when (1) the minority population of  
15 an affected area exceeds 50 percent or (2) the minority population percentage of the  
16 affected area is meaningfully greater than the minority population percentage in the general  
17 population or other appropriate unit of geographic analysis.
- 18 • Low-income population. Low-income populations in an affected area are identified with the  
19 annual statistical poverty thresholds from the Census Bureau's Current Population Reports,  
20 Series PB60, on Income and Poverty.

### 21 4.4.6.1 *Minority Population in 2000*

22 According to 2000 census data, 11.5 percent of the population (approximately 109,350  
23 individuals) residing within a 50-mi radius of JAFNPP were minority individuals. The largest  
24 minority group was Black or African American (57,308 or 6 percent), followed by Hispanic or  
25 Latino (10,034 or about 1 percent). About 3.5 percent of Oswego County were minorities, with  
26 Hispanics the largest minority group (1.3 percent). Hispanics resided throughout the 50-mi  
27 radius, but most were in Jefferson County (USCB 2006).

28 Census block groups with minority populations exceeding 20 percent were considered minority  
29 block groups. Based on 2000 census data, Figure 4-1 shows minority block groups within a  
30 50-mi radius of JAFNPP in which more than 20 percent of the block group population is minority  
31 (USCB 2006).

### 32 4.4.6.2 *Low-Income Population in 2000*

33 According to 2000 census data, approximately 45,007 individuals (approximately 4.7 percent)  
34 residing within a 50-mi radius of JAFNPP were identified as living below the Federal poverty  
35 threshold. The 1999 Federal poverty threshold was \$17,029 for a family of four. The median



1

2 **Figure 4-1.** Minority Block Groups in 2000 within a 50-mi Radius of JAFNPP (USCB 2006).

3

## Environmental Impacts of Operation

1 household income for New York in 1999 was \$43,393, while 14.6 percent of the state population  
2 was determined to be living below the 1999 Federal poverty threshold.

3 Oswego County had one of the lowest median incomes (\$36,598) and the highest percentage  
4 (14 percent) of individuals living below the poverty level when compared to the other counties in  
5 the area. Conversely, Onondaga County had one of the highest median incomes (\$40,847) and  
6 the lowest percentage (7.3 percent) of individuals living below the poverty level when compared  
7 to other counties in the area.

8 Census block groups were considered low-income block groups if the percentage of the  
9 population living below the Federal poverty threshold exceeded 14 percent. Based on 2000  
10 Census data, Figure 4-2 shows low-income block groups within a 50-mi radius of JAFNPP  
11 (USCB 2006).

### 12 *4.4.6.3 Analysis of Impacts*


13 Consistent with the impact analysis for the public and occupational health and safety, the  
14 affected populations are defined as minority and low-income populations who reside within a  
15 50-mi radius of JAFNPP. Based on the analysis of impacts for other resource areas, NRC  
16 expects no high and adverse impacts from the operation of JAFNPP during the renewal term.  
17 However, if impacts occur, NRC expects the impacts to affect all populations in the area equally.

18 NRC also analyzed the risk of radiological exposure through the consumption patterns of  
19 special pathway receptors, including subsistence consumption of fish, native vegetation, surface  
20 waters, sediments, and local produce; absorption of contaminants in sediments through the  
21 skin; and inhalation of plant materials. The special pathway receptors analysis is important to  
22 the environmental justice analysis because consumption patterns may reflect the traditional or  
23 cultural practices of minority and low-income populations in the area.

### 24 Subsistence Consumption of Fish and Wildlife

25 Section 4-4 of Executive Order 12898 (1994) directs Federal agencies, whenever practical and  
26 appropriate, to collect and analyze information on the consumption patterns of populations who  
27 rely principally on fish and/or wildlife for subsistence and to communicate the risks of these  
28 consumption patterns to the public. In Section 2.2.8.5 of this draft SEIS, NRC considered  
29 whether there were any means for minority or low-income populations to be disproportionately  
30 affected by examining impacts to American Indian, Hispanic, and other traditional lifestyle  
31 special pathway receptors. Special pathways that took into account the levels of contaminants  
32 in native vegetation, crops, soils and sediments, surface water, fish, and game animals on or  
33 near the JAFNPP site were considered.

34 Entergy has a comprehensive Radiological Environmental Monitoring Program (REMP) at  
35 JAFNPP to assess the impact of site operations on the environment. Samples are collected  
36 from the aquatic and terrestrial pathways applicable to the site. The aquatic pathways include



1

2 **Figure 4-2.** Low-Income Block Groups within a 50-mi Radius of JAFNPP (USCB 2006).

## Environmental Impacts of Operation

1 Lake Ontario fish, surface waters and lakeshore sediment. The terrestrial pathways include  
2 airborne particulates and radioiodine, milk, food products and direct radiation. During 2005,  
3 2318 analyses were performed on collected samples of environmental media as part of the  
4 required REMP and showed no significant or measurable radiological impact from JAFNPP  
5 operations. Cesium-137 was detected in one aquatic sample (shoreline sediment) at very low  
6 levels and was attributed to fallout from past weapons testing. The 2005 results for all samples  
7 are consistent with the previous five-year historical results and exhibit no adverse trends  
8 (Entergy 2005).

9 The results of the 2005 REMP demonstrate that the routine operation at the JAFNPP site had  
10 no significant or measurable radiological impact on the environment. No elevated radiation  
11 levels were detected in the offsite environment as a result of the hydrogen injection program,  
12 storage of radioactive waste, or implementation of the Independent Spent Fuel Storage  
13 Installation. The results of the REMP continue to demonstrate that the operation of the plant did  
14 not result in a significant measurable dose to a member of the general population or adversely  
15 impact the environment as a result of radiological effluents (Entergy 2005). REMP continues to  
16 demonstrate that the dose to a member of the public from the operation of JANFPP remains  
17 significantly below the federally required dose limits specified in 10 CFR Part 20, 40 CFR Part 190,  
18 and 10 CFR Part 72.

19 Based on recent monitoring results, concentrations of contaminants in native vegetation, crops,  
20 soils and sediments, surface water, fish, and game animals in areas surrounding JAFNPP have  
21 been quite low (at or near the threshold of detection) and seldom above background levels  
22 (Entergy 2005). Consequently, no disproportionately high and adverse human health impacts  
23 would be expected in special pathway receptor populations in the region as a result of  
24 subsistence consumption of fish and wildlife.

### 25 **4.5 Groundwater Use and Quality**

26 No Category 1 or Category 2 issues in 10 CFR Part 51, Subpart A, Appendix B, Table B-1, are  
27 potentially applicable to JAFNPP groundwater use and quality during the renewal term. The  
28 NRC staff has not identified any new and significant information during its independent review of  
29 the JAFNPP ER (Entergy 2006a), the staff's site audit, the scoping process, or its evaluation of  
30 other available information. Therefore, the NRC staff concludes that there are no impacts  
31 related to these issues beyond those discussed in the GEIS.

### 32 **4.6 Threatened or Endangered Species**

33 Threatened or endangered species are listed as a Category 2 issue in 10 CFR Part 51,  
34 Subpart A, Appendix B, Table B-1. This issue is listed in Table 4-10.



1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33

**Table 4-10.** Category 2 Issue Applicable to Threatened or Endangered Species During the Renewal Term

ISSUE—10 CFR Part 51, Subpart A, Appendix B, Table B-1	GEIS Section	10 CFR 51.53(c)(3)(ii) Subparagraph	SEIS Section
<b>THREATENED OR ENDANGERED SPECIES (FOR ALL PLANTS)</b>			
Threatened or endangered species	4.1	E	4.6

Entergy contacted the U.S. Fish and Wildlife Service (FWS) on February 9, 2006, regarding threatened and endangered species at the JAFNPP site (Entergy 2006a). No information regarding the transmission lines was provided in this letter. In its response letter to Entergy, dated May 19, 2006, the FWS (Entergy 2006a) identified the Federally and State-listed Indiana bat (*Myotis sodalis*) and the Federally and State-listed bog turtle (*Clemmys muhlenbergii*) as potentially occurring within the transmission corridor. The Indiana bat is known to roost within 11 mi of the site, and the bog turtle is known to occur within 12 mi of the site. The bog turtle was also identified in the JAFNPP Final Environmental Statement (FES) for operation as probably occurring within the marshes that are crossed by JAFNPP to the Edic transmission line (AEC 1973).

On December 7, 2006, NRC staff met with New York Natural Heritage Program (NYNHP) to discuss potential impacts of continued operation on State-listed species. The NYNHP found that upland sandpiper (*Bartramia longicauda*) habitat has been identified near the JAFNPP-to-Edic transmission line corridor. No other State-listed species are known to occur near the JAFNPP facility or transmission corridors. The NYNHP staff have not identified any significant foreseeable impacts on State-protected species or areas that would result from continued operation or maintenance activities during the renewal term.

The NRC staff met with the New York Power Authority (NYPA) on December 4, 2006. At this meeting, the NRC staff was informed that no threatened or endangered species have been reported by maintenance personnel as occurring in or near the transmission corridor. Corridor maintenance personnel are trained in identifying endangered species and are expected to take measures to avoid damage to these species if they are identified within the transmission line corridor during the renewal period.

This Category 2 issue requires consultation with appropriate agencies to determine whether threatened or endangered species are present and whether they would be adversely affected by continued operation of JAFNPP during the license renewal term. The characteristics and habitat of threatened or endangered species in the vicinity of the JAFNPP site are discussed in Sections 2.2.5 and 2.2.6 of this draft SEIS. The NRC initiated informal consultation with the FWS on September 19, 2006, to determine which species may be affected by continued operations and maintenance procedures at the JAFNPP site and the associated transmission

1 lines (NRC 2006d). NRC submitted a Biological Assessment to the FWS, thus consultation with  
2 the FWS in ongoing (NRC 2007).

### 3 **4.6.1 Aquatic Species**

4 No Federally listed or proposed threatened or endangered aquatic species, with the exception  
5 of transient individuals, are known to exist in the vicinity of JAFNPP or the aquatic habitats  
6 crossed by the transmission lines associated with JAFNPP (FWS 2007). There are no plans to  
7 conduct refurbishment or construction activities at JAFNPP during the license renewal term  
8 (Entergy 2006a). The NRC staff's conclusion is that there would be no impacts on threatened  
9 and endangered aquatic species from operation of JAFNPP during the renewal term, and  
10 mitigation is therefore not warranted.

### 11 **4.6.2 Terrestrial Species**

12 Currently, no threatened or endangered species are known as occurring at the JAFNPP site or  
13 within the Edic or Scriba transmission corridors. The State-protected upland sandpiper is  
14 known to occur near the transmission corridor, but no impacts to this species are expected as a  
15 result of continued use or maintenance of the lines. The Federally protected bog turtle and  
16 Indiana bat have the potential to occur at the JAFNPP site.

17 The NRC staff encourages NYPA to report the existence of any Federally or State-listed  
18 endangered species within or near the transmission corridors to NYSDEC and/or FWS if any  
19 such species are identified during the renewal term. If any evidence of injury or mortality of  
20 migratory birds or threatened or endangered species is seen within the corridor during the  
21 renewal period, NYPA is encouraged to promptly report this to the appropriate wildlife  
22 management agencies. Care should also be taken to ensure that the corridor does not provide  
23 a path for invasive plant species to colonize wetland areas that would not otherwise be  
24 colonized without the corridor. In particular, common reed (*Phragmites australis*) may colonize  
25 and degrade undocumented bog turtle habitat (FWS 2001). Likewise, transmission corridor  
26 maintenance activities should be conducted in a manner that avoids damage to wetlands within  
27 and near the corridor. Maintenance personnel should be aware of the foraging and roosting  
28 needs of Indiana bats, and the removal of standing dead trees and trees harboring Indiana bats  
29 should be avoided during times of the year when bats may be present.

30 The NRC staff, after discussions with the FWS, finds that the Indiana bat and the bog turtle may  
31 be present on the JAFNPP site or along the Edic and Scriba transmission corridors. The NRC  
32 staff has determined that the continued operation of the JAFNPP may affect, but is not likely to  
33 adversely affect, either species. Therefore, the NRC staff's preliminary conclusion is that the  
34 potential impacts on Federally protected species of an additional 20 years of JAFNPP operation  
35 would be SMALL. The NRC staff has initiated informal Section 7 consultation under the  
36 Endangered Species Act of 1972 with the FWS for both the Indiana bat and the bog turtle. The

1 consultation is ongoing and may result in additional requirements to ensure protection of these  
2 two species.

#### 3 **4.7 Evaluation of New and Potentially Significant Information on Impacts of** 4 **Operations During the Renewal Term**

5 The NRC staff has not identified new and significant information on environmental issues listed  
6 in 10 CFR Part 51, Subpart A, Appendix B, Table B-1, related to plant operation during the  
7 renewal term. The NRC staff also determined that information provided during the public  
8 comment period did not identify any new issue that requires site-specific assessment. The NRC  
9 staff reviewed the discussion of environmental impacts associated with operation during the  
10 renewal term in the GEIS and has conducted its own independent review, including public  
11 scoping meetings, to identify issues with new and significant information. Processes for  
12 identification and evaluation of new information are described in Section 1.2.2.

#### 13 **4.8 Cumulative Impacts**

14 The NRC staff considered potential cumulative impacts on the environment resulting from the  
15 incremental impact of license renewal when added to other past, present, and reasonably  
16 foreseeable future actions. For the purposes of this analysis, past actions are related to the  
17 resources when JAFNPP was licensed and constructed, present actions are related to the  
18 resources during current operations, and future actions are those that are reasonably  
19 foreseeable through the end of plant operations including the license renewal term. The  
20 geographic area over which past, present, and future actions are assessed is dependent on the  
21 affected resource.

22 The impacts of the proposed action, license renewal, as described in this chapter of the draft  
23 SEIS, are combined with other past, present, and reasonably foreseeable future actions  
24 regardless of which agency (Federal or non-Federal) or entity is undertaking the actions. The  
25 combined impacts are defined as “cumulative” in 40 CFR 1508.7 and include individually minor  
26 but collectively significant actions taking place over a period of time. It is possible that an  
27 impact that may be SMALL by itself could result in a MODERATE or LARGE impact when  
28 considered in combination with the impacts of other actions on the affected resource. Likewise,  
29 if a resource is regionally declining or imperiled, even a SMALL individual impact could be  
30 important if it contributes to or accelerates the overall resource decline.

#### 31 **4.8.1 Cumulative Impacts on Aquatic Resources**

32 This section assesses the impacts of the proposed action that relate to the withdrawal and  
33 discharge of lake water by the JAFNPP once-through cooling system, combined with other past,  
34 present, and reasonably foreseeable future actions that occur within the defined geographic

## Environmental Impacts of Operation

1 area of Lake Ontario. The geographic area considered for the analysis of cumulative impacts  
2 on aquatic resources focuses on the southeastern portion of Lake Ontario within a 50-mi radius  
3 of the Nine Mile Point promontory. This area is large enough to encompass the ecological  
4 resources and potential cumulative impacts of concern but is not too large as to make the  
5 analysis impractical.

6 Like the other Great Lakes, Lake Ontario has experienced significant changes in the structure  
7 and functioning of its aquatic ecosystem since the beginning of the Euro-American historical  
8 period, and the cumulative impacts of past actions have resulted in the existing water quality  
9 and aquatic resource conditions near JAFNPP. Lake Ontario is a dynamic aquatic ecosystem  
10 and over the years has evolved in response to ecological stressors such as overfishing,  
11 contaminant releases from industry, cultural eutrophication, land-use changes, and the  
12 introduction of non-native species. These stressors have profoundly changed the species  
13 composition and abundance of organisms from almost all trophic levels lake-wide. It is likely  
14 these changes to Lake Ontario's aquatic resources have not stabilized, and continuing changes  
15 in this complex ecosystem can be expected in the future. Furthermore, potential impacts of  
16 climate change on Lake Ontario cannot be quantified at this time but could include changes in  
17 water temperature, summer stratification, water quality, water level, productivity, and  
18 subsequently, aquatic species composition and abundance (UCS 2003).

19 Since the 1970s, there have been a number of bi-national management efforts between the  
20 U.S. and Canada to restore the ecological integrity of Lake Ontario, including the creation of the  
21 Great Lakes Fishery Commission (GLFC) and the International Joint Commission, and the  
22 signing of three Great Lakes Water Quality Agreements (Mills et al. 2005). The most recent  
23 agreement took place in 1987 and committed Canada and the U.S. to developing lake-wide  
24 management plans for each of the Great Lakes. Part of this effort includes the creation of  
25 remedial action plans that address areas of concern and sources of 11 lake-wide critical  
26 pollutants. The plans coordinate localized efforts throughout Lake Ontario by other groups such  
27 as the GLFC and State and Province fishery management programs (EPA 1998).

28 While Lake Ontario water quality has vastly improved since the implementation of these bi-  
29 national efforts, the status of its fisheries is still considered to be the most damaged of the five  
30 Great Lakes (USGS 2002). Lake researchers believe there is an incongruity between the goals  
31 of the fishery stakeholders and what Lake Ontario ecosystem can actually support (Stewart et  
32 al. 1999). Furthermore, the colonization of non-native species has so fundamentally changed  
33 the lake's ecosystem that it is unlikely to ever return to its original state. Management of  
34 invasive species at the local level, where resource uses are affected by their presence, is a  
35 major activity by Lake Ontario management groups and a foreseeable continuing focus of these  
36 groups. Contributions to cumulative impacts on Lake Ontario aquatic resources during the  
37 license renewal period can be reasonably expected to be similar to those currently impacting  
38 the lake. However, given the emphasis on lake-wide management plans and remedial action  
39 plans to collaboratively protect and restore the lake and its resources, potential cumulative  
40 effects will likely be carefully assessed and managed over time.

1 Future use of Lake Ontario likely includes its continued use for water supply, waste water  
2 disposal, cooling water for power plants, shipping, and recreational fishing and boating.  
3 Additionally, future continued development of the southeastern Lake Ontario watershed may  
4 impact the lake's water quality. However, the State of New York has a comprehensive water  
5 resources management program, and with coordinated efforts between State agencies and the  
6 above-mentioned bi-national groups, such activities would be regulated to avoid adverse  
7 impacts to the lake. Port Oswego, approximately 6 mi west of JAFNPP, will likely continue to  
8 receive cargo ships. The discharge of ballast water from foreign ships, the primary vector for  
9 invasive species, has become an issue of special importance for lake managers. According to  
10 the National Oceanic and Atmospheric Administration (NOAA), approximately 183 aquatic non-  
11 indigenous species have populated the five Great Lakes (NOAA 2006). In response, when  
12 ships enter the St. Lawrence Seaway, ballast water is now carefully monitored by the U.S.  
13 Coast Guard, the St. Lawrence Seaway Development Corporation, and Transport Canada  
14 Marine Safety (GLSLSS 2007).

15 In addition to JAFNPP, four power-generating facilities near JAFNPP withdraw water from and  
16 discharge water to Lake Ontario—Constellation Energy Group's two-unit Nine Mile Point  
17 Nuclear Station, immediately west of and adjacent to JAFNPP; Dynegy Independence Station, a  
18 1064-MW natural gas-fired combined-cycle cogeneration plant approximately 7 mi southwest of  
19 JAFNPP; NRG Energy, Inc., Oswego Steam Station, an oil and natural gas-fired 1700-MW  
20 peaking plant approximately 7.5 mi southwest of JAFNPP; and Indeck-Oswego Energy Center,  
21 a 50-MW gas-turbine combined-cycle cogeneration facility approximately 6.5 mi southwest of  
22 JAFNPP (Dynegy 2007; NRG 2007; Indeck 2007). It can be reasonably assumed that these  
23 facilities will remain in operation throughout the JAFNPP license renewal period, and water  
24 withdrawals and discharges from these facilities will be regulated by the NYSDEC under the  
25 SPDES permitting process.

26 Additional impacts to the Lake Ontario fishery could occur due to the number of dams on Lake  
27 Ontario tributaries. Brookfield Power operates eight hydroelectric facilities along the Oswego  
28 and Salmon rivers. It is expected that these dams will remain in operation for the duration of the  
29 JAFNPP license renewal period (Brookfield 2006). Dams generally impact fish populations:  
30 migration and other fish movements can be impeded or blocked entirely; quantity, quality, and  
31 access to essential habitat can be affected; and fish may suffer mortality or morbidity while  
32 passing through the turbines or over spillways. Additionally, changes in river discharge regime,  
33 water quality, and primary and secondary productivity caused by the dams may indirectly impact  
34 fish populations (Larinier 2000).

35 A study of species composition and distribution of fish larvae collected in the Nine Mile Point  
36 nearshore waters published in 1975 concluded the coastline area of Lake Ontario was not a  
37 desirable fish spawning or nursery habitat because of extensive nearshore wave action and  
38 unsuitable bedrock and rubble substrate (TI 1979). However, Lake Ontario offshore waters are  
39 important forage areas for the lake's valuable salmonid populations and their prey species, the  
40 alewife and rainbow smelt. Recent studies have suggested that prey fish populations are

## Environmental Impacts of Operation

1 moving offshore in response to changes in Lake Ontario's food web, which have occurred  
2 mostly from the introduction of invasive species to the lake in the early 1990s. Alewife in  
3 particular may be moving to deeper waters to escape forage competition from round goby, a  
4 thriving and aggressive Lake Ontario invasive species (USGS 2002).

5 As discussed in Section 4.1 of this draft SEIS, the NRC staff found no new and significant  
6 information to indicate that the conclusions regarding any of the Category 1 issues related to the  
7 cooling system at JAFNPP are inconsistent with the GEIS (NRC 1996). Assuming no future  
8 changes in station cooling system design or operation, the NRC staff determined that potential  
9 losses of aquatic resources resulting from these Category 2 issues during the license renewal  
10 term would not alter any important attribute of Lake Ontario. Furthermore, the NYSDEC may  
11 impose further restrictions or require modifications to the JAFNPP cooling system to reduce  
12 impacts of entrainment and impingement. The temperature and volume of heated effluent  
13 discharged by JAFNPP to Lake Ontario will continue to be monitored daily by plant personnel  
14 and regulated by the NYSDEC. Additionally, the transmission line ROW maintenance activities  
15 in the vicinity of stream and river crossings employ procedures to minimize erosion and  
16 shoreline disturbance while encouraging vegetative cover. Therefore, impacts from  
17 maintenance of transmission lines associated with JAFNPP would have negligible impact on  
18 aquatic resources related to the Lake Ontario basin.

19 Because Lake Ontario and the Nine Mile Point promontory area are influenced by many  
20 controlling factors, the impact of JAFNPP operations during the license renewal term can only  
21 be qualitatively described with some degree of certainty. The NRC staff concludes, however,  
22 that the SMALL impacts of the JAFNPP cooling system, including entrainment and impingement  
23 of fish and shellfish, heat shock, or any of the cooling system-related Category 1 issues are not  
24 contributing to an overall decline in Lake Ontario water quality or its aquatic resources.  
25 Therefore, the NRC staff concludes that the contribution of impacts associated with the  
26 continued operation of JAFNPP during the renewal period to the cumulative impacts likely to be  
27 experienced in the southeastern portion of Lake Ontario would be SMALL.

### 28 **4.8.2 Cumulative Impacts on Terrestrial Resources**

29 This section analyzes past, present, and future actions that could result in adverse cumulative  
30 impacts on terrestrial resources, including wildlife population, upland habitat, wetlands,  
31 floodplains, invasive species, land use, and protected species. For the purposes of this  
32 analysis, the geographic area that encompasses the past, present, and foreseeable future  
33 actions that could contribute to adverse cumulative impacts on terrestrial resources includes  
34 Oswego and Oneida counties, which contain JAFNPP and its associated transmission corridors  
35 that are within the scope of the license renewal review.

36 Since the initial construction of JAFNPP and the associated transmission line, there have been  
37 changes in land use and land cover with resulting changes on terrestrial ecosystems both at the  
38 JAFNPP site and along the transmission corridor.

1 Initial construction of JAFNPP resulted in a change in land use for part of the property from  
2 residential to industrial. Most of the property was left undeveloped and allowed to mature from  
3 secondary growth forests toward old-growth forests, with some areas continuing as wetlands  
4 and ponds (Entergy 2006b). Construction of the transmission lines to the Edic Substation and  
5 the Lighthouse Hill Hydroelectric Station converted a portion of forested land to low shrubby and  
6 herbaceous cover, with resulting changes in the wildlife and plant species present. In some  
7 locations, this caused a forested area to be fragmented. This effect increases habitat for  
8 species that live on forest edges and reduces habitat for species that live in the interior of forest  
9 parcels. Some species, particularly insects and small mammals, have difficulty crossing  
10 transmission corridors (Forman 2001). Other contributors to forest fragmentation in this region  
11 include construction of the transmission lines associated with Nine Mile Point Nuclear Station,  
12 clearing and continued use of land for farming, road construction and maintenance, and  
13 commercial and residential development. In some areas, abandoned farms adjacent to forests  
14 are developing into forests, reducing the impacts of fragmentation. The NRC staff has not  
15 identified any interior species populations that have significantly decreased in the region as a  
16 result of the cumulative impacts of forest fragmentation. The NRC staff has not found any  
17 information to conclude that continued operation or maintenance activities of JAFNPP or the  
18 associated transmission lines would have significant negative impacts on any non-protected  
19 plant or animal species, including interior species populations. Therefore, the NRC staff  
20 believes that the incremental impact of license renewal on terrestrial species and habitat, would  
21 be minor.

22 NRC staff identified two invasive species in the area that may degrade terrestrial habitat. Their  
23 spread could be accelerated by present and future actions. Common reed is thought to have  
24 been introduced by accident in the late 1700s or early 1800s and has spread across North  
25 America (PCA 2006a). Japanese knotweed (*Polygonum cuspidatum*) was introduced  
26 intentionally in the U.S. in the late 1800s, probably as an ornamental plant, and has spread  
27 throughout the eastern U.S. (PCA 2006b). These two species are spreading throughout New  
28 York at various rates due to natural and human processes, resulting in habitat loss for native  
29 species (PCA 2006a, 2006b). Both species are spread by the wind; Japanese knotweed  
30 usually grows in streamside areas, while common reed colonizes wetlands (PCA 2006a,  
31 2006b). Open areas like transmission corridors have lower wind resistance than forests  
32 (Forman 2001), potentially allowing wind-borne seeds to spread farther through transmission  
33 corridors than adjacent forests. Construction and maintenance of the transmission line corridor  
34 has created a potential pathway for the spread of these species. Potential preventative and  
35 mitigative measures include surveys and programs for monitoring and removing these species  
36 within the corridor and at the JAFNPP site. Given the ability of these species to drastically alter  
37 local ecosystems, the impacts of the introduction and spread of these species could over time  
38 significantly alter the habitat. NRC staff does not believe, however, that the continued operation  
39 and maintenance of the JAFNPP transmission lines contribute significantly to this impact.

40 The FWS has identified the Federally protected Indiana bat and the bog turtle as potentially  
41 occurring near or within the project area, which includes the Edic and Scriba transmission

1 corridors. The NRC staff has initiated informal consultation under Section 7 of the Endangered  
2 Species Act of 1972 with the FWS. As part of that consultation the FWS will assess the  
3 cumulative impacts to both species. The NRC staff has preliminarily determined that continued  
4 operation of the JAFNPP for an additional year may affect but is not likely to adversely affect the  
5 Indiana bat and the bog turtle. The consultation with the FWS is ongoing and may result in  
6 additional requirements to ensure protection of these two species.

7 The NRC staff examined the cumulative effects of forest fragmentation, the spread of invasive  
8 species, and impacts to Federally protected species as they relate to terrestrial resources within  
9 the project area. The NRC staff finds that the impacts could be MODERATE, depending on the  
10 extent of alteration of habitat within the project area due to the spread of invasive Japanese  
11 knotweed and the common reed. However, the NRC staff finds that the direct impacts of  
12 continued operation of JAFNPP and the maintenance of the transmission corridors on terrestrial  
13 resources to be SMALL.

#### 14 **4.8.3 Cumulative Impacts on Human Health**

##### 15 *4.8.3.1 Cumulative Impacts Resulting from Continued Operation of the Transmission Lines*

16 Cumulative impacts resulting from continued operation of the electrical transmission lines  
17 associated with JAFNPP were evaluated to determine whether there was the potential for  
18 adverse cumulative impacts to terrestrial resources, wetlands, floodplains, or aquatic resources.  
19 Other than the existing power transmission lines from JAFNPP and the Nine Mile Point Nuclear  
20 Station, the NRC staff is unaware of any planned activities within the area that could have  
21 additional cumulative impacts. Furthermore, the NRC staff concluded in Section 4.2.1 of this  
22 draft SEIS that the potential impacts for electric shock from existing transmission lines during  
23 the renewal period are SMALL and that no additional mitigation measures are warranted.

24 Therefore, the NRC staff has determined that the cumulative impacts of the continued operation  
25 of the JAFNPP transmission lines are also SMALL and that no additional mitigation is  
26 warranted.

##### 27 *4.8.3.2 Cumulative Radiological Impacts*

28 The radiological dose limits for protection of the public and workers were developed by the EPA  
29 and NRC to address the cumulative impact of acute and long-term exposure to radiation and  
30 radioactive material. The dose limits are codified in 40 CFR Part 190 and 10 CFR Part 20. For  
31 the purpose of this analysis, the area within an 80-km (50-mi) radius of the JAFNPP site was  
32 included. The Radiological Environmental Monitoring Program (REMP) conducted by Entergy  
33 in the vicinity of the JAFNPP site measures radiation and radioactive materials from all sources,  
34 including JAFNPP and the adjacent Nine Mile Point Nuclear Station (owned by Constellation  
35 Nuclear). Results for 2001 through 2005 were reviewed as part of the cumulative impacts  
36 assessment. Additionally, in Sections 2.2.7 and 4.3 of this draft SEIS, the NRC staff concluded  
37 that impacts of radiation exposure to the public and workers (occupational) from operation of



1 JAFNPP during the renewal term would be SMALL. Therefore, both REMP and the NRC staff's  
2 conclusion considered cumulative impacts. The NRC and the State of New York would regulate  
3 any future actions in the vicinity of the JAFNPP site that could contribute to cumulative  
4 radiological impacts.

#### 5 **4.8.4 Cumulative Socioeconomic Impacts**

6 The continued operation of JAFNPP during the license renewal term would not add to any  
7 socioeconomic impacts beyond those already being experienced in the region. The NRC staff  
8 determined that there would be no impacts on housing, public utilities, public services, and  
9 environmental justice. There would also be no impact on offsite land use because no  
10 refurbishment actions are planned at JAFNPP and no incremental sources of plant-related tax  
11 payments are expected. There are no reasonably foreseeable scenarios that would alter these  
12 conclusions in regard to cumulative impacts. Therefore, the NRC staff concludes that there  
13 would be no cumulative socioeconomic impacts from continued operations at JAFNPP and  
14 mitigation would not be required.

#### 15 **4.8.5 Conclusions Regarding Cumulative Impacts**

16 The NRC staff considered the potential impacts resulting from the operation of JAFNPP during  
17 the license renewal term and other past, present, and future actions in the vicinity of JAFNPP.  
18 The NRC staff's preliminary determination is that the potential cumulative impacts resulting from  
19 JAFNPP operation during the license renewal term would generally be SMALL. The NRC will  
20 work with the FWS to determine whether the impacts of license renewal on protected terrestrial  
21 species would significantly add to these impacts.

### 22 **4.9 Summary of Impacts of Operations During the Renewal Term**

23 Neither JAFNPP nor the NRC staff is aware of information that is both new and significant  
24 related to any of the applicable Category 1 issues associated with the JAFNPP operation during  
25 the renewal term. Consequently, the NRC staff concludes that environmental impacts  
26 associated with these issues are bounded by the impacts described in the GEIS. For each of  
27 these issues, the GEIS concluded that the impacts would be SMALL and that additional plant-  
28 specific mitigation measures are not likely to be sufficiently beneficial to warrant implementation.

29 Plant-specific environmental evaluations were conducted for 11 Category 2 issues applicable to  
30 JAFNPP operation during the renewal term and for environmental justice and chronic effects of  
31 electromagnetic fields. For these 11 issues and environmental justice, the NRC staff concluded  
32 that the potential environmental impact of renewal term operations of JAFNPP would be of  
33 SMALL significance in the context of the standards set forth in the GEIS and that additional  
34 mitigation would not be warranted. In addition, the NRC staff determined that a consensus has  
35 not been reached by appropriate Federal health agencies regarding chronic adverse effects

1 from electromagnetic fields. Therefore, the NRC staff did not conduct an evaluation of this  
2 issue.

### 3 **4.10 References**

4 10 CFR Part 20. Code of Federal Regulations, Title 10, *Energy*, Part 20, “Standards for  
5 Protection Against Radiation.”

6 10 CFR Part 51. *Code of Federal Regulations*, Title 10, *Energy*, Part 51, “Environmental  
7 Protection Regulations for Domestic Licensing and Related Regulatory Functions.”

8 10 CFR Part 72. *Code of Federal Regulations*, Title 10, *Energy*, Part 72, “Licensing  
9 Requirements for the Independent Storage of Spent Nuclear Fuel, High-Level Radioactive  
10 Waste, and Reactor-Related Greater Than Class C Waste.”

11 36 CFR Part 800. *Code of Federal Regulations*, Title 36, *Parks, Forests, and Public Property*,  
12 Part 800, “Protection of Historic Properties.”

13 40 CFR Part 190. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 190,  
14 “Environmental Radiation Protection Requirements for Normal Operations of Activities in the  
15 Uranium Fuel Cycle.”

16 40 CFR Part 1508. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part  
17 1508, “Terminology and Index.”

18 Brookfield Power. 2006. New York Lake Ontario Operations Fact Sheet. Available URL:  
19 [http://www.brookfieldpower.com/PowerOperations/pdf/Lake\\_Ontario\\_March\\_2006.pdf](http://www.brookfieldpower.com/PowerOperations/pdf/Lake_Ontario_March_2006.pdf)  
20 (accessed February 16, 2007). Accessible at ML070470373.

21 Clean Water Act of 1977 (CWA). 33 USC 1326 et seq. (Common name of the Federal Water  
22 Pollution Control Act of 1977).

23 Council on Environmental Quality (CEQ). 1997. *Environmental Justice: Guidance Under the*  
24 *National Environmental Policy Act*. Executive Office of the President, Washington, D.C.

25 Dean, J.M. 1973. “The Response of Fish to a Modified Thermal Environment.” *In* Chavin, W.,  
26 ed. *Responses of Fish to Environmental Changes*. Charles C. Thomas: Springfield, Illinois.

27 Dynegy. 2007. Power Generation Facilities Northeast Segment. Available URL:  
28 <http://www.dynegy.com/Generation/Facilities/Northeast.shtml> (accessed February 15, 2007).  
29 Accessible at ML070470449.

- 1 EA Science and Technology (EA). 2005. *2004 SPDES Biological Monitoring Report James A.*  
2 *FitzPatrick Nuclear Power Plant (Permit No. NY 0020109, Section 10, CP-04.03).* Newburgh,  
3 New York. Accessible at ML062970416.
- 4 Eckert, T.H. 2005. *New York Lake Ontario and Upper St. Lawrence River Stocking Program*  
5 *2005.* Available URL: <http://www.dec.state.ny.us/website/dfwmr/fish/lorpt05sec1.pdf> (accessed  
6 January 10, 2007). Accessible at ML070160197.
- 7 Entergy Nuclear FitzPatrick, LLC, and Entergy Nuclear Operations, Inc. (Entergy). 2005.  
8 *Annual Radiological Environmental Operating Report, January 1, 2005 – December 31, 2005.*  
9 James A. FitzPatrick Nuclear Power Plant, Docket No. 50-333, License No. DPR-59.
- 10 Entergy Nuclear FitzPatrick, LLC, and Entergy Nuclear Operations, Inc. (Entergy). 2006a.  
11 *James A. JAFNPP Nuclear Power Plant License Renewal Application, Appendix E – Applicant’s*  
12 *Environmental Report Operating License Renewal Stage James A. JAFNPP Nuclear Power*  
13 *Plant.* Lycoming, New York. Accessible at ML062160557.
- 14 Entergy Nuclear FitzPatrick, LLC, and Entergy Nuclear Operations, Inc. (Entergy). 2006b.  
15 *Proposal For Information Collection To Address Compliance With the Clean Water Act §316(b)*  
16 *Phase II Regulations at James A. FitzPatrick Nuclear Power Plant (SPDES Permit No. NY*  
17 *0020109) Lycoming, New York.* Lycoming, New York. Accessible at ML063560153.
- 18 Eshenroder, R.L., M.E. Holey, T.K. Gorenflo, and R.D. Clark, Jr. 1995. “Fish Community  
19 Objectives for Lake Michigan.” *Great Lakes Fishery Commission Spec. Pub. 95-3.* Available  
20 URL: [http://www.glfsc.org/pubs/SpecialPubs/Sp95\\_3.pdf](http://www.glfsc.org/pubs/SpecialPubs/Sp95_3.pdf) (accessed November 29, 2006).  
21 Accessible at ML070160210.
- 22 Executive Order 12898. 1994. “Federal Actions to Address Environmental Justice in Minority  
23 and Low-Income Populations.” *Federal Register*, Vol. 59, No. 32.
- 24 Forman, R.T.T. 2001. *Land Mosaics: The Ecology of Landscapes and Regions.* Cambridge  
25 University Press: Cambridge, U.K.
- 26 Fox, D.L. 2006. “*Vulpes vulpes* (red fox).” Available URL: [http://animaldiversity.ummz.umich](http://animaldiversity.ummz.umich.edu/site/accounts/information/Vulpes_vulpes.html)  
27 [.edu/ site/accounts/information/Vulpes\\_vulpes.html](http://animaldiversity.ummz.umich.edu/site/accounts/information/Vulpes_vulpes.html) (accessed December 28, 2006). Accessible  
28 at ML070120350.
- 29 Fry, F.E. 1971. “The Effect of Environmental Factors on the Physiology of Fish.” In Hoar, W.S.  
30 and D.J. Randall, eds. 1971. *Fish Physiology, Volume VI, Environmental Relations Behavior.*  
31 Academic Press: New York.
- 32 Great Lakes St. Lawrence Seaway System (GLSLSS). 2007. *Ballast Water.* Available URL:  
33 [http://www.greatlakes-seaway.com/en/navigation/ballast\\_water.html](http://www.greatlakes-seaway.com/en/navigation/ballast_water.html) (accessed February 16,  
34 2007). Accessible at ML070470471.

## Environmental Impacts of Operation

- 1 Indeck Energy Services (Indeck). 2007. Indeck-Oswego Energy Center. Available URL:  
2 <http://www.indeck-energy.com/plants/oswego.html> (accessed February 15, 2007). Accessible  
3 at ML070510069.
- 4 LaJeone, L.J. and R.G. Monzingo. 2000. "316(b) and Quad Cities Station, Commonwealth  
5 Edison Company." *Environmental Science & Policy*, 3:S313-S322. Accessible at  
6 ML070160199.
- 7 Larinier, M. 2000. "Dams and Fish Migration." Available URL: [http://www.dams.org/docs/  
8 kbase/contrib/env247.pdf](http://www.dams.org/docs/kbase/contrib/env247.pdf) (accessed February 16, 2007). Accessible at ML070470392.
- 9 Marcy, B.C., Jr. 2004 (1976). "Early Life History Studies of American Shad in the Lower  
10 Connecticut River and the Effect of the Connecticut Yankee Plant." In *The Connecticut River  
11 Ecological Study (1965-1973) Revisited: Ecology of the Lower Connecticut River 1973-2003*,  
12 P.M. Jacobson, D.A. Dixon, W.C. Leggett, B.C. Marcy, Jr. and R.R. Massengill, eds. American  
13 Fisheries Society, Monograph 9, Bethesda, Maryland.
- 14 Mills, E.L., J.M. Casselman, R. Dermot, J.D. Fitzsimons, G. Gal, K.T. Holeck, J.A. Hoyle, O.E.  
15 Johannsson, B.F. Lantry, and J.C. Maka. 2003. "Lake Ontario: food web dynamics in a  
16 changing ecosystem (1970-2000)." *Canadian Journal of Fisheries and Aquatic Sciences*,  
17 60:471-490. Available URL: <http://www.uoguelph.ca/~cjfas/Millsetal2003.pdf> (accessed  
18 January 10, 2007). Accessible at ML070160203.
- 19 Mills, E.L., J.M. Casselman, R. Dermot, J.D. Fitzsimons, G. Gal, K.T. Holeck, J.A. Hoyle et al.  
20 2005. *A Synthesis of Ecological and Fish-Community Changes in Lake Ontario, 1970-2000*.  
21 Available URL: <http://www.glfc.org/pubs/pub.htm> (accessed October 16, 2006). Accessible at  
22 ML070160214.
- 23 *National Electrical Safety Code (NESC®)*. 1981. Institute of Electrical and Electric Engineers:  
24 New York.
- 25 National Environmental Policy Act (NEPA) of 1969. 42 USC 4321, et seq.
- 26 National Historic Preservation Act (NHPA) of 1966. 16 USC 470, et seq.
- 27 National Institute of Environmental Health Sciences (NIEHS). 1999. "NIEHS Report on Health  
28 Effects from Exposure to Power Line Frequency and Electric and Magnetic Fields." Publication  
29 No. 99-4493, Research Triangle Park, North Carolina.
- 30 National Oceanic and Atmospheric Administration (NOAA). 2006. "Great Lakes Aquatic  
31 Nonindigenous Species List." Available URL: [http://www.glerl.noaa.gov/res/Programs/invasive/  
32](http://www.glerl.noaa.gov/res/Programs/invasive/) (accessed February 22, 2007). Accessible at ML070540091.

- 1 NRG Energy, Inc. (NRG). 2007. NRG Energy Locations. Available URL:  
2 <http://www.nrgenergy.com/> (accessed February 15, 2007). Accessible at ML070510055.
- 3 O’Gorman, R., R.W. Owens, and S.E. Prindle. 2005. *Status of Major Prey Fish Stocks in the*  
4 *U.S. Waters of Lake Ontario, 2004*. Accessed at: [http://www.glsc.usgs.gov/main.php?content](http://www.glsc.usgs.gov/main.php?content=products_publications_reports&title=Publications0&menu=products)  
5 [=products\\_publications\\_reports&title=Publications0&menu=products](http://www.glsc.usgs.gov/main.php?content=products_publications_reports&title=Publications0&menu=products) (accessed November 8,  
6 2006). Accessible at ML070160216.
- 7 Oswego County Department of Planning and Community Development (OCDPCD). 1997.  
8 *Oswego County Comprehensive Plan*. Oswego, New York. Available URL:  
9 <http://www.co.oswego.ny.us/pdf/compplan.pdf> (accessed October 23, 2006). Accessible at  
10 ML071130370.
- 11 Oswego County. 2006. *Oswego County Low Cost Power*, Oswego County Public Utility  
12 Service. Available URL: <http://www.co.oswego.ny.us/energy/index.html> (accessed  
13 September 25, 2006).
- 14 Plant Conservation Alliance (PCA), Alien Plant Working Group. 2006a. “Common Reed.”  
15 Available URL: <http://www.nps.gov/plants/alien/fact/phau1.htm> (accessed December 26, 2006).  
16 Accessible at ML070120384.
- 17 Plant Conservation Alliance (PCA), Alien Plant Working Group. 2006b. “Japanese Knotweed.”  
18 Available URL: <http://www.nps.gov/plants/alien/fact/pocu1.htm> (accessed December 26, 2006).  
19 Accessible at ML070120378.
- 20 Power Authority of the State of New York (NYPA). 1976. James A. FitzPatrick Nuclear Power  
21 Plant 316(a) Demonstration Submission, Permit No. NY0020109. Accessible at ML063620165;  
22 ML063620167.
- 23 Ross, Q.E. and D.J. Dunning. 1996. “Reducing Impingement of Alewives with High-Frequency  
24 Sound at a Power Plant Intake on Lake Ontario.” *North American Journal of Fisheries*  
25 *Management*, 16:548-559. Accessible at ML070160217.
- 26 Schaner, T. and S.R. LaPan. 2005. *Pelagic Planktivores*. Available URL:  
27 <http://www.dec.state.ny.us/website/dfwmr/fish/lorpt05sec3.pdf> (accessed January 10, 2007).  
28 Accessible at ML070160209.
- 29 Schaner, T. and S.E. Prindle. 2004. *Pelagic Planktivores*. Available URL:  
30 <http://www.dec.state.ny.us/website/dfwmr/fish/lorpt04sec3.pdf> (accessed January 10, 2007).  
31 Accessible at ML070160208.

## Environmental Impacts of Operation

- 1 Stewart, T.J. and T. Schaner. 2002. *Lake Ontario Salmonid Introductions 1970 to 1999:*  
2 *Stocking, Fishery and Fish Community Influences.* Available URL:  
3 [http://www.glf.com/lakecom/loc/mgmt\\_unit/01\\_ch12.pdf](http://www.glf.com/lakecom/loc/mgmt_unit/01_ch12.pdf) (accessed January 19, 2007).  
4 Accessible at ML070190123.
- 5 Stewart, T.J., R.E. Lange, S.D. Orsatti, C.P. Schneider, A. Mathers, and M.E. Daniels. 1999.  
6 *Fish-Community Objectives For Lake Ontario.* Available URL: [http://www.glf.com/pubs/](http://www.glf.com/pubs/SpecialPubs/Sp99_1.pdf)  
7 [SpecialPubs/Sp99\\_1.pdf](http://www.glf.com/pubs/SpecialPubs/Sp99_1.pdf) (accessed January 16, 2006). Accessible at ML070160345.
- 8 Texas Instruments Incorporated Ecological Services (TI). 1979. *Niagara Mohawk Power*  
9 *Corporation, Power Authority of the State of New York, 1978 Nine Mile Point Aquatic Ecology*  
10 *Studies.* Dallas, Texas. Accessible at ML063480613.
- 11 Union of Concerned Scientists (USC). 2003. "Confronting Climate Change in the Great Lakes  
12 Region, Ecological Vulnerability to Climate Change: Aquatic Ecosystems." Available URL:  
13 [http://www.ucsusa.org/assets/documents/global\\_warming/chapter3.pdf](http://www.ucsusa.org/assets/documents/global_warming/chapter3.pdf) (accessed February 22,  
14 2007). Accessible at ML070530691.
- 15 University of Wisconsin Sea Grant Institute (UWSGI). 2002. *Why Are the Alewives Dying?*  
16 Accessed at: <http://www.seagrant.wisc.edu/greatlakesfish/alewifeneews.html> on November 29,  
17 2006. Accessible at ML070160349.
- 18 U.S. Atomic Energy Commission (AEC). 1973. *Final Environmental Statement Related to*  
19 *Operation of James A. FitzPatrick Nuclear Power Plant.* Docket No. 50-333, Washington, D.C.  
20 Accessible at ML062360088.
- 21 U.S. Census Bureau (USCB). 2006. "2000 Census Data." Available URL: [www.census.gov](http://www.census.gov)  
22 (accessed December 14, 2006). Accessible at ML071130368.
- 23 U.S. Environmental Protection Agency (EPA). 1977. *Interagency 316(a) Technical Guidance*  
24 *Material and Guide for Thermal Effects Sections of Nuclear Facilities Environmental Impact*  
25 *Statements.* Draft. May 1, 1997. Available URL: [http://esm.versar.com/PPRP/316/1977\\_316a\\_](http://esm.versar.com/PPRP/316/1977_316a_)  
26 [guidance\\_document.pdf](http://esm.versar.com/PPRP/316/1977_316a_guidance_document.pdf) (accessed March 21, 2007).
- 27 U.S. Environmental Protection Agency (EPA). 1998. "Lake Ontario Lakewide Management  
28 Plan Executive Summary." Available URL: <http://www.epa.gov/glnpo/lakeont/index.html>  
29 (accessed February 14, 2007). Accessible at ML070470508.
- 30 U.S. Environmental Protection Agency (EPA). 2004. "National Pollutant Discharge Elimination  
31 System – Final Regulations to Establish Requirements for Cooling Water Intake Structures at  
32 Phase II Existing Facilities: Final Rule." *Federal Register*, Vol. 69, No. 131, pp. 41575-41693.

- 1 U.S. Fish and Wildlife Service (FWS). 2001. "Bog Turtle (*Clemmys muhlenbergii*), Northern  
 2 Population Recovery Plan." Available URL: [http://ecos.fws.gov/docs/recovery\\_plans/2001/](http://ecos.fws.gov/docs/recovery_plans/2001/010515.pdf)  
 3 010515.pdf (accessed December 28, 2006). Accessible at ML070110336.
- 4 U.S. Fish and Wildlife Service (FWS). 2007. "New York USFWS Threatened and Endangered  
 5 Species System (TESS)." Available URL: [http://ecos.fws.gov/tess\\_public/StateListing.do?status](http://ecos.fws.gov/tess_public/StateListing.do?status=listed&state=NY)  
 6 =listed&state=NY (accessed April 9, 2007). Accessible at ML071000492
- 7 U.S. Geological Service (USGS), Great Lakes Science Center. 2002. "Preyfish Population  
 8 Assessment." Available URL: [http://www.glsc.usgs.gov/\\_files/factsheets/2002-](http://www.glsc.usgs.gov/_files/factsheets/2002-3%20Preyfish%20Population%20Assessment.pdf)  
 9 3%20Preyfish%20Population%20Assessment.pdf (accessed February 8, 2007). Accessible at  
 10 ML070390563.
- 11 U.S. Geological Survey (USGS). 1955. Fulton, NY N4315-W7615/17.5X15, 15-minute  
 12 quadrangle map.
- 13 U.S. Nuclear Regulatory Commission (NRC). 1996a. *Generic Environmental Impact Statement*  
 14 *for License Renewal of Nuclear Plants*. NUREG-1437, Volumes 1 and 2. Washington, D.C.
- 15 U.S. Nuclear Regulatory Commission (NRC). 1996b. "Environmental Review for Renewal of  
 16 Nuclear Power Plant Operating Licenses." *Federal Register*, Vol. 61, No. 109, pp. 28467-  
 17 28497, Washington, D.C.
- 18 U.S. Nuclear Regulatory Commission (NRC). 1999. *Generic Environmental Impact Statement*  
 19 *for License Renewal of Nuclear Plants*. NUREG-1437, Volume 1, Addendum 1, Washington,  
 20 D.C.
- 21 U.S. Nuclear Regulatory Commission (NRC). 2004. *Policy Statement on the Treatment of*  
 22 *Environmental Justice Matters in NRC Regulatory and Licensing Actions*. *Federal Register*,  
 23 Vol. 69, pp. 52040–52048. Washington, D.C.
- 24 U.S. Nuclear Regulatory Commission (NRC). 2006a. *Generic Environmental Impact Statement*  
 25 *for License Renewal of Nuclear Plants, Supplement 24, Regarding Nine Mile Point Nuclear*  
 26 *Station, Units 1 and 2—Final Report*.
- 27 U.S. Nuclear Regulatory Commission (NRC). 2006b. Letter from Rani Franovich, Branch Chief  
 28 Division of License Renewal, to Don Klima, Director, Office of Federal Agency Programs  
 29 Advisory Council on Historic Preservation. Subject: James A. Fitzpatrick Nuclear Power Plant  
 30 License Renewal Review. September 15, 2006. Accessible at ML062480229.

## Environmental Impacts of Operation

- 1 U.S. Nuclear Regulatory Commission (NRC). 2006c. Letter from Rani Franovich, Branch Chief  
2 Division of License Renewal, to Bernadette Castro, Commissioner, New York State Office of  
3 Parks, Recreation, and Historic Preservation. Subject: James A. Fitzpatrick Nuclear Power  
4 Plant License Renewal Review. (Project Review OPRHP No. 06PR0982). September 15,  
5 2006. Accessible at ML062480220.
- 6 U.S. Nuclear Regulatory Commission (NRC). 2006d. Letter from Rani Franovich, Branch Chief  
7 Division of License Renewal, to Marvin Moriarty, U.S. Fish and Wildlife Service, Northeast  
8 Regional Office. Subject: Request for list of protected species within the area under evaluation  
9 for the James A. FitzPatrick Nuclear Power Plant license renewal application review.  
10 September 19, 2006. Accessible at ML062630292.
- 11 U.S. Nuclear Regulatory Commission (NRC). 2007. Letter from Rani Franovich, Branch Chief  
12 Division of License Renewal, to Marvin Moriarty, U.S. Fish and Wildlife Service, Northeast  
13 Regional Office. Subject: Biological Assessment for Proposed License Renewal of James A.  
14 FitzPatrick Nuclear Power Plant. May 16, 2007. Accessible at ML071310069.
- 15 Wilke, C.J. 2006. "*Mephitis mephitis* (striped skunk)." Available URL: <http://animaldiversity>  
16 [.ummz.umich.edu/site/accounts/information/Mephitis\\_mephitis.html](http://animaldiversity.ummz.umich.edu/site/accounts/information/Mephitis_mephitis.html) (accessed December 28,  
17 2006). Accessible at ML070120348.



## 5.0 ENVIRONMENTAL IMPACTS OF POSTULATED ACCIDENTS

Environmental issues associated with postulated accidents are discussed in the *Generic Environmental Impact Statement for License Renewal of Nuclear Plants* (GEIS), NUREG-1437, Volumes 1 and 2 (NRC 1996; 1999).<sup>(1)</sup> The GEIS includes a determination of whether the analysis of the environmental issue could be applied to all plants and whether additional mitigation measures would be warranted. Issues are then assigned a Category 1 or a Category 2 designation. As set forth in the GEIS, Category 1 issues are those that meet all of the following criteria:

- (1) The environmental impacts associated with the issue have been determined to apply either to all plants or, for some issues, to plants having a specific type of cooling system or other specified plant or site characteristics.
- (2) Single significance level (i.e., SMALL, MODERATE, or LARGE) has been assigned to the impacts (except for collective off-site radiological impacts from the fuel cycle and from high level waste and spent fuel disposal).
- (3) Mitigation of adverse impacts associated with the issue has been considered in the analysis, and it has been determined that additional plant-specific mitigation measures are likely not to be sufficiently beneficial to warrant implementation.

For issues that meet the three Category 1 criteria, no additional plant-specific analysis is required unless new and significant information is identified.

Category 2 issues are those that do not meet one or more of the criteria for Category 1, and therefore, additional plant-specific review of these issues is required.

This chapter describes the environmental impacts from postulated accidents that might occur during the license renewal term.

### 5.1 Postulated Plant Accidents

Two classes of accidents are evaluated in the GEIS. These are design-basis accidents (DBAs) and severe accidents, as discussed below.

#### 5.1.1 Design-Basis Accidents

---

(1) The GEIS was originally issued in 1996. Addendum 1 to the GEIS was issued in 1999. Hereafter, all references to the "GEIS" include the GEIS and Addendum 1.

## Postulated Accidents

1  
2 In order to receive NRC approval to operate a nuclear power facility, an applicant for an initial  
3 operating license must submit a safety analysis report (SAR) as part of its application. The SAR  
4 presents the design criteria and design information for the proposed reactor and comprehensive  
5 data on the proposed site. The SAR also discusses various hypothetical accident situations and  
6 the safety features that are provided to prevent and mitigate accidents. The NRC staff reviews  
7 the application to determine whether the plant design meets the Commission's regulations and  
8 requirements and includes, in part, the nuclear plant design and its anticipated response to an  
9 accident.

10  
11 DBAs are those accidents that both the licensee and the NRC staff evaluate to ensure that the  
12 plant can withstand normal and abnormal transients, and a broad spectrum of postulated  
13 accidents, without undue hazard to the health and safety of the public. A number of these  
14 postulated accidents are not expected to occur during the life of the plant, but are evaluated to  
15 establish the design basis for the preventive and mitigative safety systems of the facility. The  
16 acceptance criteria for DBAs are described in 10 CFR Part 50 and 10 CFR Part 100.

17  
18 The environmental impacts of DBAs are evaluated during the initial licensing process, and the  
19 ability of the plant to withstand these accidents is demonstrated to be acceptable before  
20 issuance of the operating license (OL). The results of these evaluations are found in license  
21 documentation such as the applicant's final safety analysis report (FSAR), the staff's safety  
22 evaluation report (SER), the final environmental statement (FES), and Section 5.1 of this  
23 supplemental environmental impact statement (SEIS). A licensee is required to maintain the  
24 acceptable design and performance criteria throughout the life of the plant, including any  
25 extended-life operation. The consequences for these events are evaluated for the hypothetical  
26 maximum exposed individual; as such, changes in the plant environment will not affect these  
27 evaluations. Because of the requirements that continuous acceptability of the consequences  
28 and aging management programs be in effect for license renewal, the environmental impacts as  
29 calculated for DBAs should not differ significantly from initial licensing assessments over the life  
30 of the plant, including the license renewal period. Accordingly, the design of the plant relative to  
31 DBAs during the extended period is considered to remain acceptable and the environmental  
32 impacts of those accidents were not examined further in the GEIS.

33  
34 The Commission has determined that the environmental impacts of DBAs are of SMALL  
35 significance for all plants because the plants were designed to successfully withstand these  
36 accidents. Therefore, for the purposes of license renewal, design-basis accidents are  
37 designated as a Category 1 issue in 10 CFR Part 51, Subpart A, Appendix B, Table B-1. The  
38 early resolution of the DBAs makes them a part of the current licensing basis of the plant; the  
39 current licensing basis of the plant is to be maintained by the licensee under its current license  
40 and, therefore, under the provisions of 10 CFR 54.30, is not subject to review under license

1 renewal. This issue, applicable to the James A. FitzPatrick Nuclear Power Plant (JAFNPP), is  
 2 listed in Table 5-1.

3  
 4 **Table 5-1.** Category 1 Issue Applicable to Postulated Accidents During the Renewal Term  
 5

<b>ISSUE—10 CFR Part 51, Subpart A, Appendix B, Table B-1</b>	<b>GEIS Sections</b>
<b>POSTULATED ACCIDENTS</b>	
Design basis accidents	5.3.2; 5.5.1

6  
 7 Based on information in the GEIS, the Commission found that  
 8

The NRC staff has concluded that the environmental impacts of design basis accidents are of small significance for all plants.

9  
 10 Entergy stated in its Environmental Report (ER; Entergy 2006a) that it is not aware of any new  
 11 and significant information associated with the renewal of the JAFNPP OL. The staff has not  
 12 identified any new and significant information during its independent review of the JAFNPP ER  
 13 (Entergy 2006a), the staff’s site audit, the scoping process, or its evaluation of other available  
 14 information. Therefore, the staff concludes that there are no impacts related to design basis  
 15 accidents beyond those discussed in the GEIS.

16  
 17 **5.1.2 Severe Accidents**

18  
 19 Severe nuclear accidents are those that are more severe than DBAs because they could result  
 20 in substantial damage to the reactor core, whether or not there are serious offsite conse-  
 21 quences. In the GEIS, the staff assessed the impacts of severe accidents during the license  
 22 renewal period, using the results of existing analyses and site-specific information to  
 23 conservatively predict the environmental impacts of severe accidents for each plant during the  
 24 renewal period.

25  
 26 Severe accidents initiated by external phenomena such as tornadoes, floods, earthquakes,  
 27 fires, and sabotage have not traditionally been discussed in quantitative terms in FESs and  
 28 were not specifically considered for JAFNPP in the GEIS (NRC 1996). However, in the GEIS  
 29 the staff did evaluate existing impact assessments performed by NRC and by the industry at  
 30 44 nuclear plants in the United States and concluded that the risk from beyond design basis  
 31 earthquakes at existing nuclear power plants is SMALL. Also, the GEIS for license renewal has  
 32 already “performed a discretionary analysis of terrorist acts in connection with license renewal,  
 33 and concluded that the core damage and radiological release from such acts would be no worse

## Postulated Accidents

1 than the damage and release to be expected from internally initiated events.” The GEIS  
2 contains an analysis of terrorist acts in connection with license renewal, and concluded that the  
3 core damage and radiological release from such acts would be no worse than the damage and  
4 release to be expected from internally initiated events. (Amergen Energy, Co. LLC., License  
5 Renewal for Oyster Creek Nuclear station), CLI-07-08, 65 NRC --. (slip op.) (Feb. 26, 2007).  
6 Based on the above, the Commission concludes that the risk from sabotage and beyond design  
7 basis earthquakes at existing nuclear power plants is small and additionally, that the risks from  
8 other external events are adequately addressed by a generic consideration of internally initiated  
9 severe accidents.

10  
11 Based on information in the GEIS, the Commission found that  
12

The probability weighted consequences of atmospheric releases, fallout onto open  
bodies of water, releases to ground water, and societal and economic impacts from  
severe accidents are small for all plants. However, alternatives to mitigate severe  
accidents must be considered for all plants that have not considered such  
alternatives.

13  
14 Therefore, the Commission has designated mitigation of severe accidents as a Category 2 issue  
15 in 10 CFR Part 51, Subpart A, Appendix B, Table B-1. This issue, applicable to JAFNPP, is  
16 listed in Table 5-2.

17  
18 The NRC staff has not identified any new and significant information with regard to the  
19 consequences from severe accidents during its independent review of the JAFNPP ER (Entergy  
20 2006a), the staff's site audit, the scoping process, and its evaluation of other available  
21 information and public comments on the draft SEIS. Therefore, the NRC staff concludes that  
22 there are no impacts of severe accidents beyond those discussed in the GEIS. However, in  
23 accordance with 10 CFR 51.53(c)(3)(ii)(L), the staff has reviewed severe accident mitigation  
24 alternatives (SAMAs) for JAFNPP. The results of its review are discussed in Section 5.2.

1 **Table 5-2.** Category 2 Issue Applicable to Postulated Accidents During the Renewal Term  
2

ISSUE—10 CFR Part 51, Subpart A, Appendix B, Table B-1	GEIS Sections	10 CFR 51.53(c)(3)(ii) Subparagraph	SEIS Section
<b>POSTULATED ACCIDENTS</b>			
Severe Accidents	5.3.3; 5.3.3.2; 5.3.3.3; 5.3.3.4; 5.3.3.5; 5.4; 5.5.2	L	5.2

3

4

5 **5.2 Severe Accident Mitigation Alternatives**

6

7 Section 51.53(c)(3)(ii)(L) requires that license renewal applicants consider alternatives to  
8 mitigate severe accidents if the staff has not previously evaluated SAMAs for the applicant's  
9 plant in an environmental impact statement (EIS) or related supplement or in an environmental  
10 assessment. The purpose of this consideration is to ensure that plant changes (i.e., hardware,  
11 procedures, and training) with the potential for improving severe accident safety performance  
12 are identified and evaluated. SAMAs have not been previously considered for JAFNPP;  
13 therefore, the remainder of Chapter 5 addresses those alternatives.

14 **5.2.1 Introduction**

15 This section presents a summary of the SAMA evaluation for JAFNPP conducted by Entergy  
16 Nuclear FitzPatrick, LLC, and Entergy Nuclear Operations, Inc. (Entergy), and described in the  
17 ER, and the NRC's review of this evaluation. The details of the review are described in the NRC  
18 staff evaluation that was prepared with contract assistance from Pacific Northwest National  
19 Laboratory. The entire evaluation for JAFNPP is presented in Appendix G.

20 The SAMA evaluation for JAFNPP was conducted with a four-step approach. In the first step  
21 Entergy quantified the level of risk associated with potential reactor accidents using the plant-  
22 specific probabilistic safety assessment (PSA) and other risk models.

23 In the second step Entergy examined the major risk contributors and identified possible ways  
24 (SAMAs) of reducing that risk. Common ways of reducing risk are changes to components,  
25 systems, procedures, and training. Entergy initially identified 293 potential SAMAs for JAFNPP.  
26 Entergy screened out 230 SAMAs from further consideration because they are not applicable at  
27 JAFNPP due to design differences, have already been implemented at JAFNPP, or are  
28 addressed by a similar SAMA. The remaining 63 SAMAs were subjected to further evaluation.

## Postulated Accidents

1 In the third step Entergy estimated the benefits and the costs associated with each of the  
2 remaining SAMAs. Estimates were made of how much each SAMA could reduce risk. Those  
3 estimates were developed in terms of dollars in accordance with NRC guidance for performing  
4 regulatory analyses (NRC 1997). The cost of implementing the proposed SAMAs was also  
5 estimated.

6 Finally, in the fourth step, the costs and benefits of each of the remaining SAMAs were  
7 compared to determine whether the SAMA was cost-beneficial, meaning the benefits of the  
8 SAMA were greater than the cost (a positive cost-benefit). Entergy found five SAMAs to be  
9 potentially cost-beneficial (Entergy 2006a). However, based on further consideration of  
10 potentially cost-beneficial SAMAs at other plants, Entergy identified one additional potentially  
11 cost-beneficial SAMA (Entergy 2006b).

12 The potentially cost-beneficial SAMAs do not relate to adequately managing the effects of aging  
13 during the period of extended operation; therefore, they need not be implemented as part of  
14 license renewal pursuant to 10 CFR Part 54. Entergy's SAMA analyses and the NRC's review  
15 are discussed in more detail below.

### 16 **5.2.2 Estimate of Risk**

17 Entergy submitted an assessment of SAMAs for JAFNPP as part of the ER (Entergy 2006a).  
18 This assessment was based on the most recent JAFNPP PSA available at that time, a plant-  
19 specific offsite consequence analysis performed using the MELCOR Accident Consequence  
20 Code System 2 (MACCS2) computer program, and insights from the JAFNPP Individual Plant  
21 Examination (IPE) (NPA 1991) and Individual Plant Examination of External Events (IPEEE)  
22 (NPA 1996).

23 The baseline core damage frequency (CDF) for the purpose of the SAMA evaluation is  
24 approximately  $2.74 \times 10^{-6}$  per year. This CDF is based on the risk assessment for internally-  
25 initiated events. Entergy did not include the contribution to risk from external events within the  
26 JAFNPP risk estimates; however, it did account for the potential risk reduction benefits  
27 associated with external events by increasing the estimated benefits for internal events by a  
28 factor of 4. The breakdown of CDF by initiating event is provided in Table 5-3.

29 As shown in Table 5-3, events initiated by station blackout (SBO) and transients are the  
30 dominant contributors to the CDF. Anticipated transient without scram (ATWS) sequences are  
31 not significant contributors to the CDF.  
32

33 Entergy estimated the dose to the population within 50 mi of the JAFNPP site to be  
34 approximately 0.0163 person-Sv (1.63 person-rem) per year. The breakdown of the total  
35 population dose by containment release mode is summarized in Table 5-4. Containment  
36 failures within the late time frame (greater than 24 hours following event initiation) and the early

1 time frame (0 to 24 hours following event initiation) dominate the population dose risk at  
 2 JAFNPP, contributing about equally to the population dose risk.

3  
 4 The NRC staff has reviewed Entergy's data and evaluation methods and concludes that the  
 5 quality of the risk analyses is adequate to support an assessment of the risk reduction potential  
 6 for candidate SAMAs. Accordingly, the staff based its assessment of offsite risk on the CDFs  
 7 and offsite doses reported by Entergy.  
 8

9 **Table 5-3. JAFNPP Core Damage Frequency**

10

Initiating Event	CDF (per year)	Percent Contribution to CDF
Station Blackout	1.27 x 10 <sup>-6</sup>	46
Transients with loss of containment heat removal	7.78x 10 <sup>-7</sup>	28
Transients with loss of all emergency core cooling system (ECCS) injection	2.66 x 10 <sup>-7</sup>	10
ATWS	1.38x 10 <sup>-7</sup>	5
Loss of a 4.16kv alternate current (AC) safeguard bus	1.18 x 10 <sup>-7</sup>	5
Loss of both direct current (DC) divisions	9.55 x 10 <sup>-8</sup>	3
Loss of coolant accident (LOCAs)	2.83 x 10 <sup>-8</sup>	1
Loss of a division of DC power	2.60 x 10 <sup>-8</sup>	1
Relay room flooding	2.53 x 10 <sup>-8</sup>	1
<b>Total CDF (from internal events)</b>	<b>2.74 x 10<sup>-6</sup></b>	<b>100</b>

11

1  
2

**Table 5-4.** Breakdown of Population Dose by Containment Release Mode

<b>Containment Release Mode</b>	<b>Population Dose (Person-Rem<sup>1</sup> Per Year)</b>	<b>Percent Contribution</b>
Late Containment Failure	0.87	53
Early Containment Failure	0.76	47
Intact Containment	negligible	negligible
<b>Total</b>	<b>1.63</b>	<b>100</b>

3  
4

<sup>1</sup>One person-Rem = 0.01 person-Sv

5  
6

**5.2.3 Potential Plant Improvements**

7  
8  
9  
10  
11  
12

Once the dominant contributors to plant risk were identified, Entergy searched for ways to reduce that risk. In identifying and evaluating potential SAMAs, Entergy considered insights from the plant-specific PSA and SAMA analyses performed for other operating plants that have submitted license renewal applications. Entergy identified 293 potential risk-reducing improvements (SAMAs) to plant components, systems, procedures and training.

13  
14  
15  
16

Entergy removed 230 SAMAs from further consideration because they are not applicable at JAFNPP due to design differences, have already been implemented at JAFNPP, or are addressed by a similar SAMA. A detailed cost-benefit analysis was performed for each of the 63 remaining SAMAs.

17  
18  
19

The staff concludes that Entergy used a systematic and comprehensive process for identifying potential plant improvements for JAFNPP, and that the set of potential plant improvements identified by Entergy is reasonably comprehensive and, therefore, acceptable.

20

**5.2.4 Evaluation of Risk Reduction and Costs of Improvements**

21  
22  
23

Entergy evaluated the risk-reduction potential of the remaining 63 SAMAs. The majority of the SAMA evaluations were performed in a bounding fashion in that the SAMA was assumed to completely eliminate the risk associated with the proposed enhancement.

24  
25  
26  
27  
28

Entergy estimated the costs of implementing the 63 candidate SAMAs through the application of engineering judgment, and use of other licensees' estimates for similar improvements. The cost estimates conservatively did not include the cost of replacement power during extended outages required to implement the modifications, nor did they include contingency costs associated with unforeseen implementation obstacles.



1 The staff reviewed Entergy’s bases for calculating the risk reduction for the various plant  
 2 improvements and concludes that the rationale and assumptions for estimating risk reduction  
 3 are reasonable and generally conservative (i.e., the estimated risk reduction is similar to or  
 4 somewhat higher than what would actually be realized). Accordingly, the staff based its  
 5 estimates of averted risk for the various SAMAs on Entergy’s risk reduction estimates.

6 The staff reviewed the bases for the applicant’s cost estimates. For certain improvements, the  
 7 staff also compared the cost estimates to estimates developed elsewhere for similar  
 8 improvements, including estimates developed as part of other licensees’ analyses of SAMAs for  
 9 operating reactors and advanced light-water reactors. The staff found the cost estimates to be  
 10 consistent with estimates provided in support of other plants’ analyses.

11 The staff concludes that the risk reduction and the cost estimates provided by Entergy are  
 12 sufficient and appropriate for use in the SAMA evaluation.

13 **5.2.5 Cost-Benefit Comparison**

14 The cost-benefit analysis performed by Entergy was based primarily on NUREG/BR-0184 (NRC  
 15 1997) and was conducted consistent with this guidance. NUREG/BR-0058 has recently been  
 16 revised to reflect the agency’s revised policy on discount rates. Revision 4 of NUREG/BR-0058  
 17 states that two sets of estimates should be developed – one at three percent and one at seven  
 18 percent (NRC 2004). Entergy provided both sets of estimates (Entergy 2006a and 2006b).

19  
 20 Entergy identified five potentially cost-beneficial SAMAs in the baseline analysis contained in  
 21 the ER (using a seven percent discount rate, and considering the combined impact of both  
 22 external events and uncertainties). The potentially cost-beneficial SAMAs are:

- 23  
 24 · SAMA 26 – provide additional DC battery capacity to ensure longer battery capability  
 25 during the station blackout event, which would extend high pressure coolant injection  
 26 (HPCI)/ reactor core isolation cooling (RCIC) operability and allow more time for AC  
 27 power recovery.
- 28  
 29 · SAMA 30 – modify plant equipment to provide 16-hour SBO injection to improve  
 30 capability to cope with longer SBO scenarios.
- 31  
 32 · SAMA 36 – modify plant equipment to extend DC power availability in an SBO event,  
 33 which would extend HPCI/RCIC operability and allow more time for AC power recovery.
- 34  
 35 · SAMA 61 – modify plant procedures to allow use of a portable power supply for battery  
 36 chargers, which would improve the availability of the DC power system.
- 37

## Postulated Accidents

1        SAMA 62 – modify plant procedures to open the doors of the emergency diesel  
2        generator (EDG) buildings upon receipt of a high temperature alarm, which improves the  
3        reliability of the EDGs following high temperatures in the EDG buildings.  
4

5        In supplemental information to the ER, Entergy provided a revised assessment based on a  
6        separate accounting of uncertainties (Entergy 2006b). The revised assessment resulted in  
7        identification of the same potentially cost-beneficial SAMAs. However, based on further  
8        consideration of potentially cost-beneficial SAMAs at other plants, Entergy identified one  
9        additional potentially cost-beneficial SAMA (Entergy 2006b). This alternative involves use of a  
10       portable generator (to power battery chargers) to extend the coping time in loss of AC power  
11       events.  
12

13       The NRC staff concludes that, with the exception of the potentially cost-beneficial SAMAs  
14       discussed above, the costs of the SAMAs evaluated would be higher than the associated  
15       benefits.

### 16       **5.2.6       Conclusions**

17       The NRC staff reviewed Entergy's analysis and concluded that the methods used and the  
18       implementation of those methods were sound. The treatment of SAMA benefits and costs  
19       support the general conclusion that the SAMA evaluations performed by Entergy are reasonable  
20       and sufficient for the license renewal submittal. Although the treatment of SAMAs for external  
21       events was somewhat limited by the unavailability of an external event PSA, the likelihood of  
22       there being cost-beneficial enhancements in this area was minimized by improvements that  
23       have been realized as a result of the IPEEE process and increasing the estimated SAMA  
24       benefits for internal events by a multiplier to account for potential benefits in external events.

25       Based on its review of the SAMA analysis, the staff concurs with Entergy's identification of  
26       areas in which risk can be further reduced in a cost-beneficial manner through the  
27       implementation of all or a subset of potentially cost-beneficial SAMAs. Given the potential for  
28       cost-beneficial risk reduction, the staff considers that further evaluation of these SAMAs by  
29       Entergy is warranted. However, none of the potentially cost-beneficial SAMAs relate to  
30       adequately managing the effects of aging during the period of extended operation. Therefore,  
31       they need not be implemented as part of the license renewal pursuant to 10 CFR Part 54.  
32

### 33       **5.3       References**

34  
35       Entergy Nuclear FitzPatrick, LLC, and Entergy Nuclear Operations, Inc. (Entergy). 2006a.  
36       *James A. FitzPatrick Nuclear Power Plant --- License Renewal Application, Appendix E:*  
37       *Applicant's Environmental Report, Operating License Renewal Stage.* Lycoming, New York.  
38       Accessible at ML062160557.  
39

40       Entergy Nuclear Operations, Inc. (Entergy). 2006b. Letter from P. Dietrich, Entergy, to NRC  
41       Document Control Desk. Subject: "Entergy Nuclear Operations, Inc., James A. FitzPatrick

## Postulated Accidents

- 1 Nuclear Power Plant, Docket No. 50-333, License No. DPR-59, License Renewal Application,  
2 Amendment 1," JAFP-06-0167, Lycoming, New York, dated December 6, 2006. Accessible at  
3 ML063480624.  
4
- 5 U.S. Nuclear Regulatory Commission (NRC). 1997. *Regulatory Analysis Technical Evaluation*  
6 *Handbook*. NUREG/BR-0184, Washington, D.C.
- 7 U.S. Nuclear Regulatory Commission (NRC). 2004. *Regulatory Analysis Guidelines of the U.S.*  
8 *Nuclear Regulatory Commission*. NUREG/BR-0058, Rev. 4, Washington, D.C.
- 9 New York Power Authority (NYPA). 1991. "James A. FitzPatrick Nuclear Power Plant Docket  
10 No. 50-333, Individual Plant Examination,"(JPN-91-048), September 1991.  
11
- 12 New York Power Authority (NYPA). 1996. "James A. FitzPatrick Nuclear Power Plant Individual  
13 Plant Examination for External Events," (JAF-RPT-MISC-02211), June 1996, Revision 0.  
14



1           **6.0 ENVIRONMENTAL IMPACTS OF THE URANIUM FUEL CYCLE**  
2                                   **AND SOLID WASTE MANAGEMENT**

3 Environmental issues associated with the uranium fuel cycle and solid waste management are  
4 discussed in the *Generic Environmental Impact Statement for License Renewal of Nuclear*  
5 *Plants* (GEIS), NUREG-1437, Volumes 1 and 2 (NRC 1996; 1999).<sup>(1)</sup> The GEIS includes a  
6 determination of whether the analysis of the environmental issue could be applied to all plants  
7 and whether additional mitigation measures would be warranted. Issues are then assigned a  
8 Category 1 or a Category 2 designation. As set forth in the GEIS, Category 1 issues are those  
9 that meet all of the following criteria:

- 10           (1) The environmental impacts associated with the issue have been determined to apply  
11                 either to all plants or, for some issues, to plants having a specific type of cooling system  
12                 or other specified plant or site characteristics.
- 13           (2) A single significance level (i.e., SMALL, MODERATE, or LARGE) has been assigned to  
14                 the impacts (except for collective offsite radiological impacts from the fuel cycle and from  
15                 high-level waste [HLW] and spent fuel disposal).
- 16           (3) Mitigation of adverse impacts associated with the issue has been considered in the  
17                 analysis, and it has been determined that additional plant-specific mitigation measures  
18                 are likely not to be sufficiently beneficial to warrant implementation.

19 For issues that meet the three Category 1 criteria, no additional plant-specific analysis is  
20 required unless new and significant information is identified.

21 Category 2 issues are those that do not meet one or more of the criteria for Category 1, and  
22 therefore, additional plant-specific review of these issues is required. There are no Category 2  
23 issues related to the uranium fuel cycle and solid waste management.

24 This chapter addresses the issues that are related to the uranium fuel cycle and solid waste  
25 management during the license renewal term that are listed in Table B-1 of 10 CFR Part 51,  
26 Subpart A, Appendix B, and are applicable to James A. FitzPatrick Nuclear Power Plant  
27 (JAFNPP). The generic potential impacts of the radiological and non-radiological environmental  
28 impacts of the uranium fuel cycle and transportation of nuclear fuel and wastes are described in  
29 detail in the GEIS based, in part, on the generic impacts provided in 10 CFR 51.51(b),  
30 Table S-3, "Table of Uranium Fuel Cycle Environmental Data," and in 10 CFR 51.52(c),  
31 Table S-4, "Environmental Impact of Transportation of Fuel and Waste to and from One Light-

---

(1) The GEIS was originally issued in 1996. Addendum 1 to the GEIS was issued in 1999. Hereafter, all references to the "GEIS" include the GEIS and its Addendum 1.

Fuel Cycle

1 Water-Cooled Nuclear Power Reactor.” The U.S. Nuclear Regulatory Commission (NRC) staff  
 2 also addresses the impacts from radon-222 and technetium-99 in the GEIS.

3 **6.1 The Uranium Fuel Cycle**

4 Category 1 issues in 10 CFR Part 51, Subpart A, Appendix B, Table B-1 that are applicable to  
 5 JAFNPP from the uranium fuel cycle and solid waste management are listed in Table 6-1.

6 **Table 6-1. Category 1 Issues Applicable to the Uranium Fuel Cycle and**  
 7 **Solid Waste Management During the Renewal Term**

ISSUE– 10 CFR Part 51, Subpart A, Appendix B, Table B-1	GEIS Section
<b>URANIUM FUEL CYCLE AND WASTE MANAGEMENT</b>	
Offsite radiological impacts (individual effects from other than the disposal of spent fuel and high level waste)	6.1; 6.2.1; 6.2.2.1; 6.2.2.3; 6.2.3; 6.2.4; 6.6
Offsite radiological impacts (collective effects)	6.1; 6.2.2.1; 6.2.3; 6.2.4; 6.6
Offsite radiological impacts (spent fuel and high level waste disposal)	6.1; 6.2.2.1; 6.2.3; 6.2.4; 6.6
Nonradiological impacts of the uranium fuel cycle	6.1; 6.2.2.6; 6.2.2.7; 6.2.2.8; 6.2.2.9; 6.2.3; 6.2.4; 6.6
Low-level waste storage and disposal	6.1; 6.2.2.2; 6.4.2; 6.4.3; 6.4.3.1; 6.4.3.2; 6.4.3.3; 6.4.4; 6.4.4.1; 6.4.4.2; 6.4.4.3; 6.4.4.4; 6.4.4.5; 6.4.4.5.1; 6.4.4.5.2; 6.4.4.5.3; 6.4.4.5.4; 6.4.4.6; 6.6
Mixed waste storage and disposal	6.4.5.1; 6.4.5.2; 6.4.5.3; 6.4.5.4; 6.4.5.5; 6.4.5.6; 6.4.5.6.1; 6.4.5.6.2; 6.4.5.6.3; 6.4.5.6.4; 6.6
Onsite spent fuel	6.1; 6.4.6; 6.4.6.1; 6.4.6.2; 6.4.6.3; 6.4.6.4; 6.4.6.5; 6.4.6.6; 6.4.6.7; 6.6
Nonradiological waste	6.1; 6.5; 6.5.1; 6.5.2; 6.5.3; 6.6
Transportation	6.1; 6.3.1; 6.3.2.3; 6.3.3; 6.3.4; 6.6, Addendum 1

8

9 Entergy Nuclear FitzPatrick, LLC, and Entergy Nuclear Operations, Inc. (Entergy), which  
 10 operate JAFNPP, stated in its Environmental Report (ER) for JAFNPP (Entergy 2006) that it is  
 11 not aware of any new and significant information associated with the renewal of the JAFNPP  
 12 operating license. The NRC staff has not identified any new and significant information during

1 its independent review of the JAFNPP ER (Entergy 2006), the staff's site audit, the scoping  
2 process, or its evaluation of other available information. Therefore, the NRC staff concludes  
3 that there are no impacts related to these issues beyond those discussed in the GEIS. For  
4 these issues, the NRC staff concluded in the GEIS that the impacts are SMALL except for the  
5 collective offsite radiological impacts from the fuel cycle and from HLW and spent fuel disposal,  
6 as discussed below, and that additional plant-specific mitigation measures are not likely to be  
7 sufficiently beneficial to be warranted.

8 A brief description of the NRC staff's review and the GEIS conclusions, as codified in Table B-1,  
9 10 CFR Part 51, for each of these issues follows:

- 10 • Offsite radiological impacts (individual effects from other than the disposal of spent fuel and  
11 high level waste). Based on information in the GEIS, the Commission found that

12 Offsite impacts of the uranium fuel cycle have been considered by the  
13 Commission in Table S-3 of this part [10 CFR 51.51(b)]. Based on information in  
14 the GEIS, impacts on individuals from radioactive gaseous and liquid releases  
15 including radon-222 and technetium-99 are small.

16 The NRC staff has not identified any new and significant information during its independent  
17 review of the JAFNPP ER (Entergy 2006), the staff's site audit, the scoping process, or its  
18 evaluation of other available information. Therefore, the NRC staff concludes that there are  
19 no offsite radiological impacts of the uranium fuel cycle during the renewal term beyond  
20 those discussed in the GEIS.

- 21 • Offsite radiological impacts (collective effects). Based on information in the GEIS, the  
22 Commission found that

23 The 100-year environmental dose commitment to the U.S. population from the  
24 fuel cycle, high level waste and spent fuel disposal excepted, is calculated to be  
25 about 14,800 person rem [Roentgen Equivalent Man], or 12 cancer fatalities, for  
26 each additional 20-year power reactor operating term. Much of this, especially  
27 the contribution of radon releases from mines and tailing piles, consists of tiny  
28 doses summed over large populations. This same dose calculation can  
29 theoretically be extended to include many tiny doses over additional thousands of  
30 years as well as doses outside the U.S. The result of such a calculation would  
31 be thousands of cancer fatalities from the fuel cycle, but this result assumes that  
32 even tiny doses have some statistical adverse health effect which will not ever be  
33 mitigated (for example no cancer cure in the next thousand years), and that  
34 these doses projected over thousands of years are meaningful. However, these  
35 assumptions are questionable. In particular, science cannot rule out the  
36 possibility that there will be no cancer fatalities from these tiny doses. For

## Fuel Cycle

1 perspective, the doses are very small fractions of regulatory limits and even  
2 smaller fractions of natural background exposure to the same populations.

3 Nevertheless, despite all the uncertainty, some judgment as to the regulatory  
4 NEPA [National Environmental Policy Act of 1969] implications of these matters  
5 should be made and it makes no sense to repeat the same judgment in every  
6 case. Even taking the uncertainties into account, the Commission concludes that  
7 these impacts are acceptable in that these impacts would not be sufficiently large  
8 to require the NEPA conclusion, for any plant, that the option of extended  
9 operation under 10 CFR Part 54 should be eliminated. Accordingly, while the  
10 Commission has not assigned a single level of significance for the collective  
11 effects of the fuel cycle, this issue is considered Category 1.

12 The NRC staff has not identified any new and significant information during its independent  
13 review of the JAFNPP ER (Entergy 2006), the staff's site audit, the scoping process, or its  
14 evaluation of other available information. Therefore, the NRC staff concludes that there are  
15 no offsite radiological impacts (collective effects) from the uranium fuel cycle during the  
16 renewal term beyond those discussed in the GEIS.

17 • Offsite radiological impacts (spent fuel and high level waste disposal). Based on information  
18 in the GEIS, the NRC found that

19 For the high level waste and spent fuel disposal component of the fuel cycle,  
20 there are no current regulatory limits for offsite releases of radionuclides for the  
21 current candidate repository site. However, if we assume that limits are  
22 developed along the lines of the 1995 National Academy of Sciences (NAS)  
23 report, "Technical Bases for Yucca Mountain Standards," and that in accordance  
24 with the Commission's Waste Confidence Decision, 10 CFR 51.23, a repository  
25 can and likely will be developed at some site which will comply with such limits,  
26 peak doses to virtually all individuals will be 100 millirem [1 mSv] per year or less.  
27 However, while the Commission has reasonable confidence that these  
28 assumptions will prove correct, there is considerable uncertainty since the limits  
29 are yet to be developed, no repository application has been completed or  
30 reviewed, and uncertainty is inherent in the models used to evaluate possible  
31 pathways to the human environment. The NAS report indicated that 100 millirem  
32 [1 mSv] per year should be considered as a starting point for limits for individual  
33 doses, but notes that some measure of consensus exists among national and  
34 international bodies that the limits should be a fraction of the 100 millirem [1 mSv]  
35 per year. The lifetime individual risk from 100 millirem [1 mSv] annual dose limit  
36 is about  $3 \times 10^{-3}$ .

37 Estimating cumulative doses to populations over thousands of years is more  
38 problematic. The likelihood and consequences of events that could seriously



1       compromise the integrity of a deep geologic repository were evaluated by the  
2       Department of Energy in the "Final Environmental Impact Statement:  
3       Management of Commercially Generated Radioactive Waste," October 1980  
4       [DOE 1980]. The evaluation estimated the 70-year whole-body dose  
5       commitment to the maximum individual and to the regional population resulting  
6       from several modes of breaching a reference repository in the year of closure,  
7       after 1,000 years, after 100,000 years, and after 100,000,000 years.  
8       Subsequently, the NRC and other federal agencies have expended considerable  
9       effort to develop models for the design and for the licensing of a high level waste  
10       repository, especially for the candidate repository at Yucca Mountain. More  
11       meaningful estimates of doses to population may be possible in the future as  
12       more is understood about the performance of the proposed Yucca Mountain  
13       repository. Such estimates would involve very great uncertainty, especially with  
14       respect to cumulative population doses over thousands of years. The standard  
15       proposed by the NAS is a limit on maximum individual dose. The relationship of  
16       potential new regulatory requirements, based on the NAS report, and cumulative  
17       population impacts has not been determined, although the report articulates the  
18       view that protection of individuals will adequately protect the population for a  
19       repository at Yucca Mountain. However, EPA's [Environmental Protection  
20       Agency's] generic repository standards in 40 CFR Part 191 generally provide an  
21       indication of the order of magnitude of cumulative risk to population that could  
22       result from the licensing of a Yucca Mountain repository, assuming the ultimate  
23       standards will be within the range of standards now under consideration. The  
24       standards in 40 CFR Part 191 protect the population by imposing "containment  
25       requirements" that limit the cumulative amount of radioactive material released  
26       over 10,000 years. Reporting performance standards that will be required by  
27       EPA are expected to result in releases and associated health consequences in  
28       the range between 10 and 100 premature cancer deaths with an upper limit of  
29       1,000 premature cancer deaths world-wide for a 100,000 metric tonne [of heavy  
30       metal] (MTHM) repository.

31       Nevertheless, despite all the uncertainty, some judgment as to the regulatory  
32       NEPA implications of these matters should be made and it makes no sense to  
33       repeat the same judgment in every case. Even taking the uncertainties into  
34       account, the Commission concludes that these impacts are acceptable in that  
35       these impacts would not be sufficiently large to require the NEPA conclusion, for  
36       any plant, that the option of extended operation under 10 CFR part 54 should be  
37       eliminated. Accordingly, while the Commission has not assigned a single level of  
38       significance for the impacts of spent fuel and high level waste disposal, this issue  
39       is considered Category 1.

40       On February 15, 2002, based on a recommendation by the Secretary of the Department of  
41       Energy, the President recommended the Yucca Mountain site for the development of a

## Fuel Cycle

1 repository for the geologic disposal of spent nuclear fuel and high-level nuclear waste. The  
2 U.S. Congress approved this recommendation on July 9, 2002, in House Joint Resolution  
3 87, which designated Yucca Mountain as the repository for spent nuclear waste. On  
4 July 23, 2002, the President signed House Joint Resolution 87 into law; Public Law 107-200,  
5 116 Stat. 735 (2002) designates Yucca Mountain as the repository for spent nuclear waste.  
6 This development does not represent new and significant information with respect to the  
7 offsite radiological impacts from license renewal related to disposal of spent nuclear fuel and  
8 high-level nuclear waste.

9 EPA developed Yucca Mountain-specific repository standards, which were subsequently  
10 adopted by the NRC in 10 CFR Part 63. In an opinion, issued July 9, 2004, the U.S. Court  
11 of Appeals for the District of Columbia Circuit (the Court) vacated EPA's radiation protection  
12 standards for the candidate repository, which required compliance with certain dose limits  
13 over a 10,000-year period. The Court's decision also vacated the compliance period in  
14 NRC's licensing criteria for the candidate repository in 10 CFR Part 63. In response to the  
15 Court's decision, EPA issued its proposed revised standards on August 22, 2005  
16 (70 Federal Register [FR] 49014). In order to be consistent with EPA's revised standards,  
17 NRC proposed revisions to 10 CFR Part 63 on September 8, 2005 (70 FR 53313).

18 Therefore, for the high-level waste and spent fuel disposal component of the fuel cycle,  
19 there is some uncertainty with respect to regulatory limits for offsite releases of radioactive  
20 nuclides for the current candidate repository site. However, prior to promulgation of the  
21 affected provisions of the Commission's regulations, we assumed that limits would be  
22 developed along the lines of the 1995 NAS report, *Technical Bases for Yucca Mountain*  
23 *Standards* (NAS 1995), and that in accordance with the Commission's Waste Confidence  
24 Decision, 10 CFR 51.23, a repository that would comply with such limits could and likely  
25 would be developed at some site.

26 Despite the current uncertainty with respect to these rules, some judgment as to the  
27 regulatory NEPA implications of offsite radiological impacts of spent fuel and high-level  
28 waste disposal should be made. The NRC staff concludes that these impacts are  
29 acceptable in that the impacts would not be sufficiently large to require the NEPA conclusion  
30 that the option of extended operation under 10 CFR Part 54 should be eliminated.

31 The NRC staff has not identified any new and significant information during its independent  
32 review of the JAFNPP ER (Entergy 2006), the staff's site audit, the scoping process, or its  
33 evaluation of other available information. Therefore, the NRC staff concludes that there are  
34 no offsite radiological impacts related to spent fuel and HLW disposal during the renewal  
35 term beyond those discussed in the GEIS.

- 1 • Nonradiological impacts of the uranium fuel cycle. Based on information in the GEIS, the  
 2 Commission found that

3       The nonradiological impacts of the uranium fuel cycle resulting from the renewal  
 4       of an operating license for any plant are found to be small.

5       The NRC staff has not identified any new and significant information during its independent  
 6       review of the JAFNPP ER (Entergy 2006), the staff's site audit, the scoping process, or its  
 7       evaluation of other available information. Therefore, the NRC staff concludes that there are  
 8       no nonradiological impacts of the uranium fuel cycle during the renewal term beyond those  
 9       discussed in the GEIS.

- 10 • Low-level waste storage and disposal. Based on information in the GEIS, the Commission  
 11 found that

12       The comprehensive regulatory controls that are in place and the low public doses  
 13       being achieved at reactors ensure that the radiological impacts to the  
 14       environment will remain small during the term of a renewed license. The  
 15       maximum additional on-site land that may be required for low-level waste storage  
 16       during the term of a renewed license and associated impacts will be small.

17       Nonradiological impacts on air and water will be negligible. The radiological and  
 18       nonradiological environmental impacts of long-term disposal of low-level waste  
 19       from any individual plant at licensed sites are small. In addition, the Commission  
 20       concludes that there is reasonable assurance that sufficient low-level waste  
 21       disposal capacity will be made available when needed for facilities to be  
 22       decommissioned consistent with NRC decommissioning requirements.

23       The NRC staff has not identified any new and significant information during its independent  
 24       review of the JAFNPP ER (Entergy 2006), the staff's site audit, the scoping process, or its  
 25       evaluation of other available information. Therefore, the NRC staff concludes that there are  
 26       no impacts of low-level waste storage and disposal associated with the renewal term  
 27       beyond those discussed in the GEIS.

- 28 • Mixed waste storage and disposal. Based on information in the GEIS, the Commission  
 29 found that

30       The comprehensive regulatory controls and the facilities and procedures that are  
 31       in place ensure proper handling and storage, as well as negligible doses and  
 32       exposure to toxic materials for the public and the environment at all plants.  
 33       License renewal will not increase the small, continuing risk to human health and  
 34       the environment posed by mixed waste at all plants. The radiological and  
 35       nonradiological environmental impacts of long-term disposal of mixed waste from

## Fuel Cycle

1 any individual plant at licensed sites are small. In addition, the Commission  
2 concludes that there is reasonable assurance that sufficient mixed waste  
3 disposal capacity will be made available when needed for facilities to be  
4 decommissioned consistent with NRC decommissioning requirements.

5 The NRC staff has not identified any new and significant information during its independent  
6 review of the JAFNPP ER (Entergy 2006), the staff's site audit, the scoping process, or its  
7 evaluation of other available information. Therefore, the NRC staff concludes that there are  
8 no impacts of mixed waste storage and disposal associated with the renewal term beyond  
9 those discussed in the GEIS.

- 10 • Onsite spent fuel. Based on information in the GEIS, the Commission found that

11 The expected increase in the volume of spent fuel from an additional 20 years of  
12 operation can be safely accommodated on site with small environmental effects  
13 through dry or pool storage at all plants if a permanent repository or monitored  
14 retrievable storage is not available.

15 The NRC staff has not identified any new and significant information during its independent  
16 review of the JAFNPP ER (Entergy 2006), the staff's site audit, the scoping process, or its  
17 evaluation of other available information. Therefore, the NRC staff concludes that there are  
18 no impacts of onsite spent fuel associated with license renewal beyond those discussed in  
19 the GEIS.

- 20 • Nonradiological waste. Based on information in the GEIS, the Commission found that

21 No changes to generating systems are anticipated for license renewal. Facilities  
22 and procedures are in place to ensure continued proper handling and disposal at  
23 all plants.

24 The NRC staff has not identified any new and significant information during its independent  
25 review of the JAFNPP ER (Entergy 2006), the staff's site audit, the scoping process, or its  
26 evaluation of other available information. Therefore, the NRC staff concludes that there are  
27 no nonradiological waste impacts during the renewal term beyond those discussed in the  
28 GEIS.

- 29 • Transportation. Based on information contained in the GEIS, the Commission found that

30 The impacts of transporting spent fuel enriched up to 5 percent uranium-235 with  
31 average burnup for the peak rod to current levels approved by NRC up to  
32 62,000 MWd/MTU [megawatt days per metric ton of uranium] and the cumulative  
33 impacts of transporting high-level waste to a single repository, such as Yucca  
34 Mountain, Nevada are found to be consistent with the impact values contained in  
35 10 CFR 51.52)(c), Summary Table S-4—Environmental Impact of Transportation

1 of Fuel and Waste to and from One Light-Water-Cooled Nuclear Power Reactor.  
2 If fuel enrichment or burnup conditions are not met, the applicant must submit an  
3 assessment of the implications for the environmental impact values reported in  
4 §51.52.

5 JAFNPP meets the fuel-enrichment and burnup conditions set forth in Addendum 1 to the  
6 GEIS (NRC 1999). The NRC staff has not identified any new and significant information  
7 during its independent review of the JAFNPP ER (Entergy 2006), the staff's site audit, the  
8 scoping process, or its evaluation of other available information. Therefore, the NRC staff  
9 concludes that there are no impacts of transportation associated with license renewal  
10 beyond those discussed in the GEIS.

## 11 **6.2 References**

12 10 CFR Part 51. *Code of Federal Regulations*, Title 10, *Energy*, Part 51, "Environmental  
13 Protection Regulations for Domestic Licensing and Related Regulatory Functions."

14 10 CFR Part 54. *Code of Federal Regulations*, Title 10, *Energy*, Part 54, "Requirements for  
15 Renewal of Operating Licenses for Nuclear Power Plants."

16 10 CFR Part 63. *Code of Federal Regulations*, Title 10, *Energy*, Part 63, "Disposal of High-  
17 Level Radioactive Wastes in a Geologic Repository at Yucca Mountain, Nevada."

18 40 CFR Part 191. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 191,  
19 "Environmental Radiation Protection Standards for Management and Disposal of Spent Nuclear  
20 Fuel, High-Level and Transuranic Radioactive Waste."

21 70 FR 53313. *70 Federal Register* 53313. 2005, September 8. "Implementation of a Dose  
22 Standard After 10,000 Years; Proposed Rule."

23 70 FR 49014. *70 Federal Register* 49014. 2005, August 22. "Public Health and Environmental  
24 Radiation Protection Standards for Yucca Mountain, Nevada; Proposed Rule."

25 Entergy Nuclear FitzPatrick, LLC, and Entergy Nuclear Operations, Inc. (Entergy). 2006.  
26 *James A. FitzPatrick Nuclear Power Plant — License Renewal Application, Appendix E:*  
27 *Applicant's Environmental Report, Operating License Renewal Stage*. Lycoming, New York.  
28 Accessible at ML062160557.

29 National Academy of Sciences (NAS). 1995. *Technical Bases for Yucca Mountain Standards*.  
30 National Academy Press, Washington, D.C.

31 National Environmental Policy Act (NEPA) of 1969. 42 USC 4321, et seq.

## Fuel Cycle

- 1 Public Law 107-200, 116 Stat. 735. 2002. "Approving the site at Yucca Mountain, Nevada, for  
2 the development of a repository for the disposal of high-level radioactive waste and spent  
3 nuclear fuel, pursuant to the Nuclear Waste Policy Act of 1982."
- 4 U.S. Department of Energy (DOE). 1980. *Final Environmental Impact Statement: Management*  
5 *of Commercially Generated Radioactive Waste*. DOE/EIS-0046F, Washington, D.C.
- 6 U.S. Nuclear Regulatory Commission (NRC). 1996. *Generic Environmental Impact Statement*  
7 *for License Renewal of Nuclear Plants*. NUREG-1437, Volumes 1 and 2. Office of Nuclear  
8 Regulatory Research, Washington, D.C.
- 9 U.S. Nuclear Regulatory Commission (NRC). 1999. *Generic Environmental Impact Statement*  
10 *for License Renewal of Nuclear Plants* NUREG-1437, Volume 1, Addendum 1. Office of  
11 Nuclear Regulatory Research, Washington, D.C.

## 7.0 ENVIRONMENTAL IMPACTS OF DECOMMISSIONING

Environmental impacts from the activities associated with the decommissioning of any reactor before or at the end of an initial or renewed license are evaluated in the *Generic Environmental Impact Statement on Decommissioning of Nuclear Facilities: Supplement 1, Regarding the Decommissioning of Nuclear Power Reactors, NUREG-0586, Supplement 1* (NRC 2002). The NRC staff's evaluation of the environmental impacts of decommissioning presented in NUREG-0586, Supplement 1, identifies a range of impacts for each environmental issue.

The incremental environmental impacts associated with decommissioning activities resulting from continued plant operation during the renewal term are discussed in the *Generic Environmental Impact Statement for License Renewal of Nuclear Plants* (GEIS), NUREG-1437, Volumes 1 and 2 (NRC 1996; 1999).<sup>(1)</sup> The GEIS includes a determination of whether the analysis of the environmental issue could be applied to all plants and whether additional mitigation measures would be warranted. Issues were then assigned a Category 1 or a Category 2 designation. As set forth in the GEIS, Category 1 issues are those that meet all of the following criteria:

- (1) The environmental impacts associated with the issue have been determined to apply either to all plants or, for some issues, to plants having a specific type of cooling system or other specified plant or site characteristics.
- (2) A single significance level (i.e., SMALL, MODERATE, or LARGE) has been assigned to the impacts (except for collective off-site radiological impacts from the fuel cycle and from high level waste and spent fuel disposal).
- (3) Mitigation of adverse impacts associated with the issue has been considered in the analysis, and it has been determined that additional plant-specific mitigation measures are likely not to be sufficiently beneficial to warrant implementation.

For issues that meet the three Category 1 criteria, no additional plant-specific analysis is required unless new and significant information is identified.

Category 2 issues are those that do not meet one or more of the criteria for Category 1, and therefore, additional plant-specific review of these issues is required. There are no Category 2 issues related to decommissioning.

---

(1) The GEIS was originally issued in 1996. Addendum 1 to the GEIS was issued in 1999. Hereafter, all references to the "GEIS" include the GEIS and its Addendum 1.

1 **7.1 Decommissioning**

2 Category 1 issues in Table B-1 of 10 CFR Part 51, Subpart A, Appendix B that are applicable to  
 3 James A. FitzPatrick Nuclear Power Plant (JAFNPP) decommissioning following the renewal  
 4 term are listed in Table 7-1. Entergy Nuclear FitzPatrick, LLC, and Entergy Nuclear Operation,  
 5 Inc. (Entergy) stated in its Environmental Report (ER; Entergy 2006) that it is aware of no new  
 6 and significant information regarding the environmental impacts of JAFNPP license renewal.  
 7 The NRC staff has not identified any new and significant information during its independent  
 8 review of the JAFNPP ER (Entergy 2006), the staff's site audit, the scoping process, or its  
 9 evaluation of other available information. Therefore, the NRC staff concludes that there are no  
 10 impacts related to these issues beyond those discussed in the GEIS. For all of these issues,  
 11 the NRC staff concluded in the GEIS that the impacts are SMALL, and additional plant-specific  
 12 mitigation measures are not likely to be sufficiently beneficial to be warranted.

13 **Table 7-1.** Category 1 Issues Applicable to the Decommissioning of JAFNPP  
 14 Following the Renewal Term

ISSUE—10 CFR Part 51, Subpart A, Appendix B, Table B-1	GEIS Section
DECOMMISSIONING	
Radiation Doses	7.3.1; 7.4
Waste Management	7.3.2; 7.4
Air Quality	7.3.3; 7.4
Water Quality	7.3.4; 7.4
Ecological Resources	7.3.5; 7.4
Socioeconomic Impacts	7.3.7; 7.4

15

16 A brief description of the NRC staff's review and the GEIS conclusions, as codified in Table B-1,  
 17 for each of the issues follows:

- 18 • Radiation doses. Based on information in the GEIS, the Commission found that

19 Doses to the public will be well below applicable regulatory standards regardless  
 20 of which decommissioning method is used. Occupational doses would increase  
 21 no more than 1 man-rem caused by buildup of long-lived radionuclides during the  
 22 license renewal term.

23 The NRC staff has not identified any new and significant information during its independent  
 24 review of the JAFNPP ER (Entergy 2006), the staff's site audit, the scoping process, or its  
 25 evaluation of other available information. Therefore, the NRC staff concludes that there are



1 no radiation dose impacts associated with decommissioning following the license renewal  
2 term beyond those discussed in the GEIS.

3 • Waste management. Based on information in the GEIS, the Commission found that

4 Decommissioning at the end of a 20-year license renewal period would generate  
5 no more solid wastes than at the end of the current license term. No increase in  
6 the quantities of Class C or greater than Class C wastes would be expected.

7 The NRC staff has not identified any new and significant information during its independent  
8 review of the JAFNPP ER (Entergy 2006), the staff's site audit, the scoping process, or its  
9 evaluation of other available information. Therefore, the NRC staff concludes that there are  
10 no impacts from solid waste associated with decommissioning following the license renewal  
11 term beyond those discussed in the GEIS.

12 • Air quality. Based on information in the GEIS, the Commission found that

13 Air quality impacts of decommissioning are expected to be negligible either at the  
14 end of the current operating term or at the end of the license renewal term.

15 The NRC staff has not identified any new and significant information during its independent  
16 review of the JAFNPP ER (Entergy 2006), the staff's site audit, the scoping process, or its  
17 evaluation of other available information. Therefore, the NRC staff concludes that there are  
18 no impacts on air quality associated with decommissioning following the license renewal  
19 term beyond those discussed in the GEIS.

20 • Water quality. Based on information in the GEIS, the Commission found that

21 The potential for significant water quality impacts from erosion or spills is no  
22 greater whether decommissioning occurs after a 20-year license renewal period  
23 or after the original 40-year operation period, and measures are readily available  
24 to avoid such impacts.

25 The NRC staff has not identified any new and significant information during its independent  
26 review of the JAFNPP ER (Entergy 2006), the staff's site audit, the scoping process, or its  
27 evaluation of other available information. Therefore, the NRC staff concludes that there are  
28 no impacts on water quality associated with decommissioning following the license renewal  
29 term beyond those discussed in the GEIS.

30 • Ecological resources. Based on information in the GEIS, the Commission found that

31 Decommissioning after either the initial operating period or after a 20-year  
32 license renewal period is not expected to have any direct ecological impacts.

1 The NRC staff has not identified any new and significant information during its independent  
2 review of the JAFNPP ER (Entergy 2006), the staff's site audit, the scoping process, or its  
3 evaluation of other available information. Therefore, the NRC staff concludes that there are  
4 no impacts on ecological resources associated with decommissioning following the license  
5 renewal term beyond those discussed in the GEIS.

6 • Socioeconomic Impacts. Based on information in the GEIS, the Commission found that

7 Decommissioning would have some short-term socioeconomic impacts. The  
8 impacts would not be increased by delaying decommissioning until the end of a  
9 20-year relicense period, but they might be decreased by population and  
10 economic growth.

11 The NRC staff has not identified any new and significant information during its independent  
12 review of the JAFNPP ER (Entergy 2006), the staff's site audit, the scoping process, or its  
13 evaluation of other available information. Therefore, the NRC staff concludes that there are  
14 no socioeconomic impacts associated with decommissioning following the license renewal  
15 term beyond those discussed in the GEIS.

## 16 **7.2 References**

17 10 CFR Part 51. *Code of Federal Regulations*, Title 10, *Energy*, Part 51, "Environmental  
18 Protection Regulations for Domestic Licensing and Related Regulatory Functions."

19 Entergy Nuclear FitzPatrick, LLC, and Entergy Nuclear Operations, Inc. (Entergy). 2006.  
20 *James A. FitzPatrick Nuclear Power Plant — License Renewal Application, Appendix E: –*  
21 *Applicant's Environmental Report, Operating License Renewal Stage*. Lycoming, New York.  
22 Accessible at ML062160557.

23 U.S. Nuclear Regulatory Commission (NRC). 1996. *Generic Environmental Impact Statement*  
24 *for License Renewal of Nuclear Plants*. NUREG-1437, Volumes 1 and 2, Office of Nuclear  
25 Regulatory Research, Washington, D.C.

26 U.S. Nuclear Regulatory Commission (NRC). 1999. *Generic Environmental Impact Statement*  
27 *for License Renewal of Nuclear Plants, Main Report*. NUREG-1437, Volume 1, Addendum 1.  
28 Office of Nuclear Regulatory Research, Washington, D.C.

29 U.S. Nuclear Regulatory Commission (NRC). 2002. *Generic Environmental Impact Statement*  
30 *on Decommissioning of Nuclear Facilities: Supplement 1, Regarding the Decommissioning of*  
31 *Nuclear Power Reactors*. NUREG-0586, Supplement 1, Volumes 1 and 2. Washington, D.C.

## 8.0 ENVIRONMENTAL IMPACTS OF ALTERNATIVES TO LICENSE RENEWAL

This chapter examines the potential environmental impacts associated with denying the renewal of an operating license (OL) (i.e., the no-action alternative) and the potential environmental impacts from electric power generating sources other than the James A. FitzPatrick Nuclear Power Plant (JAFNPP); the possibility of purchasing electric power from other sources to replace power generated by JAFNPP and the associated environmental impacts; the potential environmental impacts from a combination of generation and conservation measures; and other generation alternatives that were deemed unsuitable for complete replacement of power generated by JAFNPP. The environmental impacts are evaluated using the U.S. Nuclear Regulatory Commission's (NRC's) three-level standard of significance—SMALL, MODERATE, or LARGE—developed using the Council on Environmental Quality guidelines and set forth in the footnotes to Table B-1 of Part 51 of Title 10 of the *Code of Federal Regulations* (10 CFR Part 51), Subpart A, Appendix B:

SMALL - Environmental effects are not detectable or are so minor that they will neither destabilize nor noticeably alter any important attribute of the resource.

MODERATE - Environmental effects are sufficient to alter noticeably, but not to destabilize important attributes of the resource.

LARGE - Environmental effects are clearly noticeable and are sufficient to destabilize important attributes of the resource.

The impact categories evaluated in this chapter are the same as those used in the *Generic Environmental Impact Statement for License Renewal of Nuclear Plants* (GEIS) NUREG-1437, Volumes 1 and 2 (NRC 1996; 1999)<sup>(1)</sup> with the additional impact category of environmental justice.

### 8.1 No-Action Alternative

The NRC's regulations implementing the National Environmental Policy Act (NEPA) of 1969 specify that the no-action alternative be discussed in an NRC environmental impact statement (EIS); see 10 CFR Part 51, Subpart A, Appendix A(4). For license renewal, the no-action alternative refers to a scenario in which the NRC would not renew the JAFNPP OL and JAFNPP

---

(1) The GEIS was originally issued in 1996. Addendum 1 to the GEIS was issued in 1999. Hereafter, all references to the "GEIS" include the GEIS and its Addendum 1.

## Environmental Impacts of Alternatives

1 would then cease facility operations by the end of the current license and initiate the  
2 decommissioning of the power plant.

3 JAFNPP will eventually be required to shut down and to comply with NRC decommissioning  
4 requirements in 10 CFR 50.82 whether or not the OL is renewed. If the JAFNPP OL is  
5 renewed, shutdown of the unit and decommissioning activities will not be avoided but will be  
6 postponed for up to an additional 20 years.

7 The environmental impacts associated with decommissioning following a license renewal period  
8 of up to 20 years or following the no-action alternative would be bounded by the discussion of  
9 impacts in Chapter 7 of the GEIS; Chapter 7 of this draft supplemental environmental impact  
10 statement (draft SEIS); and the *Final Generic Environmental Impact Statement on*  
11 *Decommissioning of Nuclear Facilities*, NUREG-0586, Supplement 1 (NRC 2002). The impacts  
12 of decommissioning after 60 years of operation are not expected to be significantly different  
13 from those occurring after 40 years of operation.

14 Impacts from the decision to permanently cease operations are not considered in NUREG-0586,  
15 Supplement 1 (NRC 2002).<sup>(2)</sup> Therefore, immediate impacts that occur between power plant  
16 shutdown and the beginning of decommissioning are considered here. These impacts will occur  
17 when the unit shuts down regardless of whether the license is renewed or not. These impacts  
18 are discussed below, with the results presented in Table 8-1. Power plant shutdown will result  
19 in a net reduction in power production capacity. The power not generated by JAFNPP during  
20 the license renewal term would likely be replaced by (1) power purchased from other electricity  
21 providers, (2) generating alternatives other than JAFNPP, (3) demand-side management and  
22 energy conservation, or (4) some combination of these options. The environmental impacts of  
23 these options are discussed in Section 8.2.

### 24 • Land Use

25 In Chapter 4 of this draft SEIS, the NRC staff concluded that there would be no impacts of  
26 continued power plant operation on land use. Onsite land use would not be affected  
27 immediately by the cessation of operations. Power plant structures and other facilities are  
28 likely to remain in place until decommissioning. The transmission lines associated with the  
29 project are expected to remain in service after the power plant stop operating. As a result,  
30 maintenance of the rights-of-way (ROWs) would continue as before. Therefore, there would  
31 be no impacts on land use from power plant shutdown.

---

(2) NUREG-0586 Supplement 1 discusses the socioeconomic impacts of plant closure, but the results of the analysis in Appendix J are not incorporated in the analysis presented in the main body of the NUREG.

1

**Table 8-1.** Summary of Environmental Impacts of the No-Action Alternative

<b>Impact Category</b>	<b>Impact</b>	<b>Comment</b>
Land Use	NO IMPACT	No impacts because power plant shutdown is not expected to result in changes to onsite or offsite land use.
Ecology	SMALL	Impacts are expected to be SMALL because there would be a reduction in cooling water flow and the thermal plume from the power plant, and terrestrial impacts are not expected because there would not be any land-use changes.
Water Use and Quality – Surface Water	SMALL	Impacts are expected to be SMALL because surface water intake and discharges would decrease.
Water Use and Quality - Groundwater	NO IMPACT	There is no groundwater use at the site.
Air Quality	SMALL	Impacts are expected to be SMALL because discharges related to power plant operation and worker transportation would decrease.
Waste	SMALL	Impacts are expected to be SMALL because generation of high-level waste would stop, and generation of low-level and mixed waste would decrease.
Human Health	SMALL	Impacts are expected to be SMALL because radiological doses to workers and members of the public, which are within regulatory limits, would be reduced.
Socioeconomics	MODERATE to LARGE	Impacts are expected to be MODERATE to LARGE because of a decrease in employment and tax revenues to local jurisdictions.
Transportation	SMALL	Transportation impacts would be SMALL because the decrease in employment would reduce traffic.
Aesthetics	NO IMPACT	No impacts are expected because power plant structures would remain in place.
Historic and Archaeological Resources	SMALL	Impacts are expected to be SMALL because shutdown of the power plant would not change land use.
Environmental Justice	SMALL to LARGE	Economic impacts are expected to be SMALL to LARGE because loss of employment opportunities is expected.

## Environmental Impacts of Alternatives

### 1 • Ecology

2 In Chapter 4 of this draft SEIS, the NRC staff concluded that the ecological impacts of power  
3 plant operation were SMALL. Cessation of operations would be accompanied by a  
4 reduction in cooling water flow and the thermal plume from the power plant.

5 The impact of power plant closure on the terrestrial ecosystem would be negligible because  
6 the transmission lines to the power plant would remain energized. Therefore, the NRC staff  
7 concludes that ecological impacts from shutdown of the power plant would be SMALL.

### 8 • Water Use and Quality—Surface Water

9 In Chapter 4 of this draft SEIS, the NRC staff concluded that impacts of power plant  
10 operation on surface water use and quality were SMALL. When the power plant stops  
11 operating, there would be an immediate reduction in the consumptive use of water because  
12 of reduction in cooling water flow and in the amount of heat transferred to Lake Ontario.  
13 Therefore, the NRC staff concludes that the impacts on surface water use and quality from  
14 power plant shutdown would be SMALL.

### 15 • Water Use and Quality—Groundwater

16 In Chapter 4 of this draft SEIS, the NRC staff concluded that there would be no impacts on  
17 groundwater use, availability, and quality. Therefore, the NRC staff concludes that there  
18 would be no impact on groundwater use and quality from shutdown of the power plant.

### 19 • Air Quality

20 In Chapter 4 of this draft SEIS, the NRC staff found the impacts of power plant operation on  
21 air quality were SMALL. When the power plant stops operating, there would be a reduction  
22 in emissions from activities related to power plant operation such as use of diesel  
23 generators and worker transportation. Therefore, the NRC staff concludes that the impact  
24 on air quality from shutdown of the power plant would be SMALL.

### 25 • Waste

26 The impacts of waste generated by power plant operation are discussed in Chapter 6 of this  
27 draft SEIS. The impacts of low-level and mixed waste from power plant operation would be  
28 SMALL. When the power plant stops operating, the power plant would stop generating  
29 high-level waste, and the generation of low-level and mixed waste associated with power  
30 plant operation and maintenance would be reduced. Therefore, the NRC staff concludes  
31 that the impact of waste generated after shutdown of the power plant would be SMALL.

1 • Human Health

2 In Chapter 4 of this draft SEIS, the NRC staff concluded that the impacts of power plant  
3 operation on human health were SMALL. After the cessation of operations, the amount of  
4 radioactive material released to the environment in gaseous and liquid forms would be  
5 reduced. Therefore, the NRC staff concludes that the impact of shutdown of the power plant  
6 on human health would be SMALL. In addition, the variety of potential accidents at the  
7 power plant would be reduced to a limited set associated with shutdown events and spent  
8 fuel handling. In Chapter 5 of this draft SEIS, the NRC staff concluded that the impacts of  
9 accidents during operation were SMALL. Therefore, the NRC staff concludes that the  
10 impacts of potential accidents following shutdown of the power plant would be SMALL.

11 • Socioeconomics

12 In Chapter 4 of this draft SEIS, the NRC staff concluded that there would be no  
13 socioeconomic impacts of continued power plant operation. Conversely, there would be  
14 immediate socioeconomic impacts associated with the shutdown of the power plant because  
15 of the reduction in power plant staff. There would also be an immediate reduction in  
16 property tax revenues for Oswego County. The NRC staff concludes that the  
17 socioeconomic impacts of power plant shutdown would range from MODERATE to LARGE.  
18 Some of these impacts would be offset if new power-generating facilities were built at or  
19 near the current site. See Appendix J of NUREG-0586, Supplement 1 (NRC 2002), for  
20 additional discussion of the potential impacts of power plant shutdown.

21 • Transportation

22 In Chapter 4 of this draft SEIS, the NRC staff concluded that the impacts of continued power  
23 plant operation on transportation would be SMALL. Cessation of operations would be  
24 accompanied by a reduction in traffic in the vicinity of the power plant. Most of the reduction  
25 would be associated with a reduction in the power plant workforce but there would also be a  
26 reduction in shipment of material to and from the power plant. Therefore, the NRC staff  
27 concludes that the impacts of power plant closure on transportation would be SMALL.

28 • Aesthetics

29 In Chapter 4 of this draft SEIS, the NRC staff concluded that there would be no aesthetic  
30 impacts of continued power plant operation. Power plant structures and other facilities  
31 would remain in place until decommissioning. Therefore, there would be no aesthetic  
32 impacts from power plant closure.

33 • Historic and Archaeological Resources

34 In Chapter 4 of this draft SEIS, the NRC staff concluded that the impacts of continued power  
35 plant operation on historic and archaeological resources would be SMALL. Onsite land use

## Environmental Impacts of Alternatives

1 would not be affected immediately by the cessation of operations. Power plant structures  
2 and other facilities are likely to remain in place until decommissioning. The transmission  
3 lines associated with the project are expected to remain in service after the power plant  
4 stops operating. As a result, maintenance of transmission line ROWs would continue as  
5 before. Therefore, the NRC staff concludes that the impacts on historic and archaeological  
6 resources from power plant shutdown would be SMALL.

### 7 • Environmental Justice

8 In Chapter 4 of this draft SEIS, the NRC staff concluded that there would be no  
9 disproportionately high and adverse impacts on minority and low-income populations from  
10 the continued operation of the power plant. Shutdown of the power plant would have  
11 disproportionately high and adverse economic impacts on minority and low-income  
12 populations because of the loss of employment opportunities at the site. The NRC staff  
13 concludes that the impacts of power plant shutdown on minority and low-income populations  
14 could range from SMALL to LARGE. Some of these impacts would be offset if new power-  
15 generating facilities are built at or near the current site. See Appendix J of NUREG-0586,  
16 Supplement 1 (NRC 2002), for additional discussion of these impacts.

## 17 **8.2 Alternative Energy Sources**

18 This section discusses the environmental impacts associated with alternative sources of electric  
19 power to replace the power generated by JAFNPP, assuming that the OL is not renewed. The  
20 order of presentation of alternative energy sources in this section does not imply which  
21 alternative would be most likely to occur or would have the least environmental impact.

22 The following power generation alternatives are considered in detail:

- 23 • Coal-fired generation at an alternate site (Section 8.2.1)
- 24 • Natural gas-fired generation at the JAFNPP site and an alternate site (Section 8.2.2)
- 25 • New nuclear generation at the JAFNPP site and an alternate site (Section 8.2.3)

26 The alternative of purchasing power from other sources to replace power generated at JAFNPP  
27 is discussed in Section 8.2.4. Other power-generation alternatives and conservation  
28 alternatives considered by the NRC staff and found not to be reasonable replacements for  
29 JAFNPP baseload power is discussed in Section 8.2.5. Section 8.2.6 discusses the  
30 environmental impacts of a combination of generation and conservation alternatives.

31 Each year the Energy Information Administration (EIA), a component of the U.S. Department of  
32 Energy (DOE), issues an Annual Energy Outlook. The *Annual Energy Outlook 2007 with*  
33 *Projections to 2030* was issued in February 2007 (DOE/EIA 2007). EIA projects that natural



1 gas-fired and coal-fired electricity generation will constitute approximately 90 percent of  
2 electrical capacity additions between 2006 and 2030. Natural gas-fired generation is typically  
3 based on combined-cycle<sup>(3)</sup> or combustion turbine technology, which can supply peak and  
4 intermediate capacity and can also be used to meet baseload<sup>(4)</sup> requirements. Coal-fired power  
5 plants are generally used to meet baseload requirements. Renewable energy sources,  
6 including conventional hydroelectric, geothermal, wood, wood waste, municipal solid waste,  
7 landfill gas, other biomass, solar and wind power are projected by EIA to account for 6 percent  
8 of capacity additions (DOE/EIA 2007).

9 EIA projects that oil-fired generation will continue to decrease in the U.S. through 2030 because  
10 high world oil prices encourage switching from oil-fired generation to natural gas and nuclear  
11 power and reinforce coal's important role in world electric power generation. Similarly, the  
12 relatively high fossil fuel prices of recent years are raising renewed interest in nuclear power  
13 and making renewable energy sources more competitive economically. EIA's projections are  
14 based on the assumption that providers of new generating capacity will seek to minimize cost  
15 while meeting applicable environmental requirements. The cost of new oil-fired generation is  
16 not expected to be competitive with that of coal, natural gas, or renewable energy sources  
17 (DOE/EIA 2007).

18 EIA also projects a small increase in nuclear power generation through 2030, accounting for  
19 0.6 percent of the generation growth (DOE/EIA 2007). The projected growth in nuclear power  
20 generation is not higher because natural gas and coal-fired power plants are projected to be  
21 more economical. In spite of this projection, since 1997, the NRC has certified four new  
22 standard designs for nuclear power plants under procedures in 10 CFR Part 52, Subpart B.  
23 Therefore, a new nuclear power plant alternative for replacing power generated by JAFNPP is  
24 considered in Section 8.2.3. The submission to the NRC of these three applications for  
25 certification indicates continuing interest in the possibility of licensing new nuclear power plants.  
26 The NRC has established a new organization to prepare for and manage future reactor and site  
27 licensing applications.

28 JAFNPP has a gross rating of 881 megawatts-electric (MWe). For the coal alternative, the NRC  
29 staff assumed construction of an 816-MWe power plant. For the natural gas alternative, the  
30 NRC staff assumed construction of an 816-MWe power plant, which is consistent with the  
31 *James A. FitzPatrick Nuclear Power Plant — License Renewal Application, Appendix E:*  
32 *Applicant's Environmental Report, Operating License Renewal Stage* (JAFNPP ER) (Entergy

---

(3) In a combined-cycle unit, hot combustion gas in a combustion turbine rotates the turbine to generate electricity. The hot exhaust from the combustion turbine is routed through a heat-recovery boiler to make steam to generate additional electricity.

(4) A baseload plant normally operates to supply all or part of the minimum continuous load of a system and consequently produces electricity at an essentially constant rate. Nuclear power plants are commonly used for baseload generation, i.e., these units generally run near full load.

1 2006). For the new nuclear alternative, the NRC staff assumed construction of a 1000-MWe  
2 power plant. This assumption will overstate the environmental impacts of replacing the 881  
3 MWe from JAFNPP by roughly 13.5 percent.

#### 4 **8.2.1 Coal-Fired Power Generation**

5 The NRC staff believes that the JAFNPP site would not be a viable location for a representative  
6 coal-fired power plant. The primary consideration pertinent to this determination is the size of  
7 the JAFNPP site. Use of the site would necessitate offsite disposal of combustion waste.  
8 Therefore, the NRC staff assumes that the representative coal-fired power plant would be  
9 located at an alternate site.

10 Consistent with the JAFNPP ER, the NRC staff assumes construction of two 408-MWe units for  
11 a combined capacity of 816 MWe as a potential replacement for JAFNPP. The assumption of  
12 816 MWe is slightly less generating capacity than JAFNPP's capacity of 881 MWe, but the NRC  
13 staff concludes that the differences are not significant and would not change the standard of  
14 significance (SMALL, MODERATE, or LARGE) of any impacts.

15 Unless otherwise indicated, the assumptions and numerical values used in Section 8.2.1 are  
16 from the JAFNPP ER (Entergy 2006). The NRC staff reviewed this information and compared it  
17 to environmental impact information in the GEIS. Although the OL renewal period is only  
18 20 years, the impact of operating the coal-fired alternative for 40 years is considered as a  
19 reasonable projection of the operating life of a coal-fired power plant.

20 The coal-fired power plant would consume approximately 2.36 million tons per year (tons/yr) of  
21 pulverized bituminous coal with an ash content of approximately 7.11 percent (Entergy 2006).  
22 JAFNPP assumes a heat rate<sup>(5)</sup> of 10,200 BTU/kWh and a capacity factor<sup>(6)</sup> of 0.85 in its ER  
23 (Entergy 2006). After combustion, 99.9 percent of the ash would be collected and disposed at  
24 either an onsite or offsite landfill. In addition, approximately 136,995 tons of scrubber sludge  
25 would be disposed of at the power plant site based on annual limestone usage of approximately  
26 46,241 tons. Limestone is used in the scrubbing process for control of sulfur dioxide (SO<sub>2</sub>)  
27 emissions.

---

(5) Heat rate is measure of generating station thermal efficiency. In English units, it is generally expressed in British thermal units (BTUs) per net kilowatt-hour (kWh). It is computed by dividing the total BTU content of the fuel burned for electric generation by the resulting kWh generation. The corresponding metric unit for energy is the Joule (J).

(6) The capacity factor is the ratio of electricity generated, for the period of time considered, to the energy that would have been generated at continuous full-power operation during the same period.

1 *8.2.1.1 Once-Through Cooling System*

2 For purposes of this section, the NRC staff assumed that a coal-fired power plant located at an  
3 alternate site would use a once-through cooling system. The overall impacts of the coal-fired  
4 generating system using once-through cooling are discussed in this section and summarized in  
5 Table 8-2. The extent of impacts at an alternate site would depend on the location of the site.

6 In Section 8.2.1.2, the NRC staff evaluates the impacts of using a closed-cycle cooling system  
7 at an alternate site.

8 • Land Use

9 Development of the coal-fired power plant would require approximately 1387 acres (ac) of  
10 land for the power plant site. Additional land would be necessary to allow for an onsite and  
11 peripheral buffer. The NRC estimates that 1700 ac would be required for a 1000-MWe  
12 power plant. Depending on the location of the power plant, additional land would be  
13 required for offsite infrastructure, particularly transmission lines to connect the power plant to  
14 the grid and facilities for coal and limestone delivery, most likely including a rail spur and  
15 possibly some upgrades to existing or recently abandoned rail lines. Construction of a  
16 barge terminal would also be a reasonable option for a power plant located on Lake Ontario.

17 Land-use changes would also occur offsite in an undetermined coal-mining area to supply  
18 coal for the power plant. In the GEIS, the NRC staff estimated that approximately 22 ac of  
19 land per MWe would be affected for mining the coal and disposing of the waste to support a  
20 coal-fired power plant during its operational life. Therefore, the 816-MWe power plant  
21 proposed in this analysis would require approximately 17,592 ac of land to support the entire  
22 fuel cycle.

23 The location and design of coal-fired power plant facilities at an alternate site would be  
24 subject to substantial regulatory scrutiny and that a reasonable potential exists for the  
25 eventual restoration of disposal areas and the development of compatible uses that would  
26 not affect landfill integrity (e.g., recreation). Under these assumptions, the NRC staff  
27 expects that land-use impacts would be noticeable but would not affect land-use  
28 characteristics at an existing industrial site. Depending particularly on transmission line and  
29 rail line routing, this alternative would result in MODERATE to LARGE land-use impacts.

30 • Ecology

31 Impacts on ecological resources from construction and from operation of the representative  
32 coal-fired power plant would be highly site-specific. However, as much as 1387 ac of  
33 terrestrial habitat would be displaced by the power plant and onsite landfill, and additional  
34 terrestrial habitat would be adversely affected from development of offsite infrastructure  
35 (e.g., transmission line connection, rail spur construction). Impacts would depend on

Environmental Impacts of Alternatives

1  
2

**Table 8-2.** Summary of Environmental Impacts of Coal-Fired Generation at an Alternate Site Using Once-Through Cooling

<b>Impact Category</b>	<b>Impact</b>	<b>Comments</b>
Land Use	MODERATE to LARGE	Would use approximately 1387 ac for the power plant roads, parking areas, office buildings, and transmission line. There would be additional land impacts for coal and limestone mining. The total impact would depend on whether the alternate site had been previously disturbed or had existing infrastructure.
Ecology	MODERATE to LARGE	Impacts would depend on whether the site had been previously developed. Factors to consider include location and ecology of the site, transmission line route, and rail spur route. In total, impacts would include habitat degradation, fragmentation, or loss as a result of construction activities and conversion of land to industrial use. Ecological communities might experience reduced productivity and biological diversity from disturbing previously intact land.
Water Use And Quality —Surface Water	SMALL to MODERATE	Impacts would depend on the volume of water withdrawn and discharged and the characteristics of the surface water body.
Water Use and Quality —Groundwater	SMALL to MODERATE	Impacts would depend on the volume of water withdrawn and discharged and the characteristics of the aquifer.
Air Quality	MODERATE	<ul style="list-style-type: none"> <li>• Sulfur oxides: 2514 tons/yr</li> <li>• Nitrogen oxides: 591 tons/yr</li> <li>• Particulates: 19 tons/yr of PM<sub>10</sub></li> <li>• Carbon monoxide: 591 tons/yr</li> <li>• Small amounts of mercury and other hazardous air pollutants and naturally occurring radioactive materials— mainly uranium and thorium.</li> <li>• Total suspended particulates: 84 tons/yr</li> </ul>
Waste	MODERATE	Total waste volume would be approximately 136,995 tons/yr of ash and scrubber sludge requiring approximately 161 ac for disposal during the 40-year life of the power plant.
Human Health	SMALL	Impacts are uncertain but considered SMALL in the absence of more quantitative data.

1

**Table 8-2 (cont.)**

<b>Impact Category</b>	<b>Impact</b>	<b>Comments</b>
Socioeconomics	SMALL to LARGE	Impacts are expected to be SMALL to LARGE because of a decrease in employment and tax revenues to local jurisdictions.
Transportation	SMALL to LARGE	Transportation impacts associated with construction could be MODERATE to LARGE. Transportation impacts associated with power plant operations would also be site-dependent and would be SMALL to MODERATE. For rail transportation of coal and lime, the impact would be MODERATE to LARGE. For barge transportation, the impact would be SMALL.
Aesthetics	SMALL to LARGE	Impacts would include visual impairment, construction of new transmission lines, and infrastructure for the delivery of coal and limestone. The impact severity would be dependent on location.
Historic and Archaeological Resources	SMALL to MODERATE	Building a coal-fired power plant and other support facilities would require cultural resource studies. Impacts would vary depending on location and presence of historic and archaeological resources.
Environmental Justice	SMALL to LARGE	Impacts to minority and low-income populations would vary depending on the site location of the power plant and other support facilities.

2

3 whether the site had been previously developed. Factors to consider include location and  
 4 ecology of the site, transmission line route, and rail spur route. In total, impacts would  
 5 include habitat degradation, fragmentation, or loss as a result of construction activities and  
 6 conversion of land to industrial use. Ecological communities might experience reduced  
 7 productivity and biological diversity from disturbing previously intact land.

8 Impact to aquatic communities as a result of construction would include some permanent  
 9 alteration of habitat, particularly if a barge terminal were developed for delivery of coal and  
 10 limestone. Fish and benthic communities would be initially disrupted but would be expected  
 11 to reestablish with accompanying localized changes in species composition and distribution  
 12 in response to changes in bottom substrate availability, water depth, and other factors.  
 13 Potential for some adverse impact on aquatic communities would persist through the  
 14 operational period as a result of large boat traffic, periodic maintenance dredging, and  
 15 potential for spills of coal, petroleum products, or other materials. However, construction  
 16 and maintenance dredging would be conducted in accordance with the provisions of  
 17 applicable permits from the U.S. Army Corps of Engineers (USACE) and the New York State

## Environmental Impacts of Alternatives

1 Department of Environmental Conservation (NYSDEC). Similarly, spill prevention measures  
2 would be effective during the operational period. Once-through cooling water withdrawal  
3 and discharge would have adverse aquatic resource impacts.

4 Given this information, the NRC staff concludes that development of the representative coal-  
5 fired power plant at an alternate site in upstate New York would have a MODERATE to  
6 LARGE impact on ecological communities.

### 7 • Water Use and Quality—Surface Water

8 Construction phase impacts on water quality of greatest potential concern at an alternate  
9 site would include (1) erosion and sedimentation associated with land-clearing operations,  
10 and (2) suspension of bottom sediments during construction of cooling water intake and  
11 discharge structures and, if the option were chosen, from construction of barge delivery  
12 facilities. However, land-clearing activities are subject to storm-water protections in  
13 accordance with the State Pollutant Discharge Elimination System (SPDES) program. Work  
14 in waterways would be regulated by the USACE under the Clean Water Act of 1977,  
15 Section 404, and the Rivers and Harbors Appropriation Act of 1899, Section 10, by the  
16 NYSDEC via permits and by the New York Department of State (NYSDOS) under the  
17 State's Coastal Zone Management program (if located within the coastal zone). In addition,  
18 these adverse effects would be localized and temporary. The NRC staff concludes that  
19 impacts on surface water quality associated with construction of the representative power  
20 plant would be SMALL.

21 Potential impacts on water quality and use associated with operation of the representative  
22 power plant would be to some extent site-specific. Cooling water and other wastewater  
23 discharges would be regulated by a SPDES permit regardless of location. The impact on  
24 surface water would depend on the volume of water withdrawn and discharged and the  
25 characteristics of the surface water body. The NRC staff concludes that the impacts of  
26 surface water use and quality from the operation of a representative power plant located at  
27 an alternate site would be SMALL to MODERATE.

### 28 • Water Use and Quality—Groundwater

29 Use of groundwater for a coal-fired power plant at an alternate site is possible.  
30 Groundwater withdrawal would require a permit. Overall, the impact to groundwater at an  
31 alternate site is considered SMALL to MODERATE and would depend on the volume of  
32 water that is withdrawn and discharged and the characteristics of the aquifers.

### 33 • Air Quality

34 The air-quality impacts of coal-fired generation vary considerably from those of nuclear  
35 generation due to emissions of sulfur oxides (SO<sub>x</sub>), nitrogen oxides (NO<sub>x</sub>), particulates,

1 carbon monoxide, hazardous air pollutants such as mercury, and naturally occurring  
2 radioactive materials.

3 Oswego County is designated as unclassifiable or in attainment with all criteria pollutants.  
4 The nearest area of non-attainment is Jefferson County, which is classified as marginal for  
5 ozone. Onondaga County, where Syracuse is located, is a maintenance area for carbon  
6 monoxide and classified as moderate, i.e., less than or equal to 12.7 parts per million (ppm).

7 A new coal-fired generating power plant in upstate New York would likely need a prevention  
8 of significant deterioration (PSD) permit and an operating permit under the Clean Air Act of  
9 1970. The power plant would need to comply with the new source performance standards  
10 for such power plants set forth in 40 CFR 60, Subpart D(a). The standards establish limits  
11 for particulate matter and opacity (40 CFR 60.42[a]), SO<sub>2</sub> (40 CFR 60.43[a]), and NO<sub>x</sub>  
12 (40 CFR 60.44[a]). The facility would be designed to meet best available control technology  
13 (BACT) or lowest achievable emissions rate (LAER) standards, as applicable, for control of  
14 criteria air emissions.

15 The U.S. Environmental Protection Agency (EPA) has various regulatory requirements for  
16 visibility protection in 40 CFR 51, Subpart P, including a specific requirement for review of  
17 any new major stationary source in an area designated as attainment or unclassified under  
18 the Clean Air Act.

19 Section 169A of the Clean Air Act (42 USC 7491) establishes a national goal of preventing  
20 future and remedying existing impairment of visibility in mandatory Class I Federal areas  
21 when impairment results from man-made air pollution. The EPA issued a new regional haze  
22 rule in 1999 (64 FR 35714; July 1, 1999 [EPA 1999]). The rule specifies that for each  
23 mandatory Class I Federal area located within a State, the State must establish goals that  
24 provide for reasonable progress towards achieving natural visibility conditions. The  
25 reasonable progress goals must provide for an improvement in visibility for the most-  
26 impaired days over the period of the implementation plan and ensure no degradation in  
27 visibility for the least-impaired days over the same period [40 CFR 51.308(d)(1)]. If a coal-  
28 fired power plant were located close to a mandatory Class I Federal area, additional air  
29 pollution control requirements would be imposed. It is assumed that an alternate site would  
30 not be chosen near a mandatory Class I Federal area.

31 In 1998, the EPA issued a rule requiring 22 Eastern states, including New York, to revise their  
32 state implementation plans to reduce NO<sub>x</sub> emissions, which contribute to violations of the  
33 national ambient air quality standard for ozone (EPA 1998). The total amount of NO<sub>x</sub> that can  
34 be emitted by each of the 22 Eastern states in the year 2007 ozone season (May 1 to  
35 September 30) is set out at 40 CFR 51.121(e). For New York, the amount is 190,360 tons.

36 Impacts for particular pollutants are as follows:

1       **Sulfur oxides emissions.** A new coal-fired power plant would be subject to the  
2 requirements in Title IV of the Clean Air Act. Title IV was enacted to reduce emissions of  
3 SO<sub>2</sub> and NO<sub>x</sub>, the two principal precursors of acid rain, by restricting emissions of these  
4 pollutants from power plants. Title IV caps aggregate annual power plant SO<sub>2</sub> emissions  
5 and imposes controls on SO<sub>2</sub> emissions through a system of marketable allowances. EPA  
6 issues one allowance for each ton of SO<sub>2</sub> a unit is allowed to emit. New units do not receive  
7 allowances but are required to have allowances to cover their SO<sub>2</sub> emissions. Owners of  
8 new units must therefore acquire allowances from owners of other power plants by  
9 purchasing them or reducing SO<sub>2</sub> emissions at other power plants they own. Allowances  
10 can be banked for use in future years. Thus, a new coal-fired power plant would not add to  
11 net regional SO<sub>2</sub> emissions, although it might do so locally. Regardless, SO<sub>2</sub> emissions  
12 would be greater for the coal alternative than the OL renewal alternative because a nuclear  
13 power plant releases negligible amounts of SO<sub>2</sub> during normal operations.

14 Entergy estimates that by using the BACT to minimize SO<sub>x</sub> emissions, the total annual stack  
15 emissions would be approximately 2514 tons of SO<sub>x</sub> (Entergy 2006).

16       **Nitrogen oxides emissions.** Section 407 of the Clean Air Act establishes technology-  
17 based emission limitations for NO<sub>x</sub> emissions. The market-based allowance system used  
18 for SO<sub>2</sub> emissions is not used for NO<sub>x</sub> emissions. A new coal-fired power plant would be  
19 subject to the new source performance standards for such power plants in 40 CFR  
20 60.44a(d)(1). This regulation, issued on September 16, 1998 (63 FR 49453 [EPA 1998]),  
21 limits the discharge of any gases that contain nitrogen oxides (expressed as NO<sub>2</sub>) in excess  
22 of 200 nanograms per Joule (ng/J) of gross energy output (1.6 pounds per megawatt hour  
23 [lb/MWh]), based on a 30-day rolling average.

24 Entergy estimates that by using NO<sub>x</sub> burners with overfire air and selective catalytic  
25 reduction (SCR), the total annual NO<sub>x</sub> emissions for a new coal-fired power plant would be  
26 approximately 591 tons. Regardless of the control technology, this level of NO<sub>x</sub> emissions  
27 would be greater than the OL renewal alternative because a nuclear power plant releases  
28 negligible amounts of NO<sub>x</sub> during normal operations.

29       **Particulate emissions.** Entergy estimated that for coal-fired generation, the total annual  
30 stack emissions would include 84 tons of total suspended particulates and 19 tons of  
31 particulate matter with an aerodynamic diameter of less than or equal to 10 microns (PM<sub>10</sub>).  
32 Fabric filters or electrostatic precipitators would be used for control. In addition, coal-  
33 handling equipment would introduce fugitive particulate emissions. Particulate emissions  
34 would be greater under the coal alternative than the OL renewal alternative because nuclear  
35 power plants release few particles during normal operation.

36 During the construction of a coal-fired power plant, fugitive dust would be generated. In  
37 addition, exhaust emissions would come from vehicles and motorized equipment used  
38 during the construction process.



1       **Carbon monoxide emissions.** Entergy estimated that for a coal-fired power plant, the total  
2 carbon monoxide emissions would be approximately 591 tons/yr. This level of emissions is  
3 greater than the OL renewal alternative.

4       **Hazardous air pollutants including mercury.** In December 2000, the EPA issued  
5 regulatory findings on emissions of hazardous air pollutants from electric utility steam-  
6 generating units (EPA 2000b). The EPA determined that coal- and oil-fired electric utility  
7 steam-generating units are significant emitters of hazardous air pollutants. Coal-fired power  
8 plants were found by the EPA to emit arsenic, beryllium, cadmium, chromium, dioxins,  
9 hydrogen chloride, hydrogen fluoride, lead, manganese, and mercury (EPA 2000b). The  
10 EPA concluded that mercury is the hazardous air pollutant of greatest concern. The EPA  
11 found that (1) there is a link between coal consumption and mercury emissions, (2) electric  
12 utility steam-generating units are the largest domestic source of mercury emissions, and  
13 (3) certain segments of the U.S. population (e.g., the developing fetus, subsistence fish-  
14 eating populations) are believed to be at potential risk of adverse health effects due to  
15 mercury exposures resulting from consumption of contaminated fish (EPA 2000b).  
16 Accordingly, the EPA added coal- and oil-fired electric utility steam-generating units to the  
17 list of source categories under Section 112(c) of the Clean Air Act for which emission  
18 standards for hazardous air pollutants will be issued (EPA 2000b).

19       **Uranium and thorium.** Coal contains uranium and thorium. Uranium concentrations are  
20 generally in the range of 1 to 10 ppm. Thorium concentrations are generally about 2.5 times  
21 greater than uranium concentrations (Gabbard 1993). One estimate is that a typical coal-  
22 fired power plant released roughly 5.2 tons of uranium and 12.8 tons of thorium in 1982  
23 (Gabbard 1993). The population dose equivalent from the uranium and thorium releases  
24 and daughter products produced by the decay of these isotopes has been calculated to be  
25 significantly higher than that from nuclear power plants (Gabbard 1993).

26       **Carbon dioxide.** A coal-fired power plant would have unregulated carbon dioxide  
27 emissions that would contribute to global warming. The level of emissions from a coal-fired  
28 power plant would be greater than the OL renewal alternative.

29       **Summary.** The GEIS analysis did not quantify emissions from coal-fired power plants but  
30 implies that air impacts would be substantial. The GEIS also mentions global warming from  
31 unregulated carbon dioxide emissions and acid rain from SO<sub>x</sub> and NO<sub>x</sub> emissions as  
32 potential impacts. Adverse human health effects such as cancer and emphysema have  
33 been associated with the products of coal combustion.

34       The NRC staff concludes that the overall impact on air quality from a coal-fired power plant,  
35 located at an alternate site in upstate New York, would be MODERATE. The impacts would  
36 be clearly noticeable but would not destabilize air quality.

## Environmental Impacts of Alternatives

### 1 • Waste

2 Coal combustion generates waste in the form of ash, and equipment for controlling air  
3 pollution generates additional ash and scrubber sludge. The representative coal-fired power  
4 plant would generate approximately 136,995 tons of this waste annually for 40 years. The  
5 waste would be disposed of onsite, accounting for approximately 161 ac of land area over  
6 the 40-year power plant life. Waste impacts to groundwater and surface water would extend  
7 beyond the operating life of the power plant if leachate and runoff from the waste storage  
8 area occurred. Disposal of the waste would noticeably affect land use and groundwater  
9 quality, but with appropriate management and monitoring, it would not destabilize any  
10 resources. After closure of the waste site and revegetation, the land would be available for  
11 other uses. Debris would be generated during construction activities.

12 In 2000, the EPA issued a "Notice of Regulatory Determination on Wastes From the  
13 Combustion of Fossil Fuels" (EPA 2000b). The EPA concluded that some form of national  
14 regulation is warranted to address coal combustion waste products because (1) the  
15 composition of these wastes could present danger to human health and the environment  
16 under certain conditions, (2) the EPA has identified 11 documented cases of proven  
17 damages to human health and the environment by improper management of these wastes  
18 in landfills and surface impoundments, (3) present disposal practices are such that, in 1995,  
19 these wastes were being managed in 40 to 70 percent of landfills and surface  
20 impoundments without reasonable controls in place, particularly in the area of groundwater  
21 monitoring, and (4) the EPA identified gaps in state oversight of coal combustion wastes.  
22 Accordingly, the EPA announced its intention to issue regulations for disposal of coal  
23 combustion waste under Subtitle D of the Resource Conservation and Recovery Act of  
24 1976.

25 For all of the preceding reasons, the appropriate characterization of impacts from waste  
26 generated from burning coal is MODERATE. The impacts would be clearly noticeable but  
27 would not destabilize any important resource.

### 28 • Human Health

29 Coal-fired power generation introduces worker risks from fuel and limestone mining, fuel and  
30 lime/limestone transportation, and disposal of coal combustion waste. In addition, there are  
31 public risks from inhalation of stack emissions. Emission impacts can be widespread, and  
32 health risks can be difficult to quantify. The coal alternative also introduces the risk of coal-  
33 pile fires and attendant inhalation risks.

34 In the GEIS, the NRC staff stated that there would be human health impacts (cancer and  
35 emphysema) from inhalation of toxins and particulates, but the NRC staff did not identify the  
36 significance of these impacts. In addition, uranium and thorium discharges from coal-fired  
37 power plants can potentially produce radiological doses in excess of those arising from  
38 nuclear power plant operations (Gabbard 1993).

1 Regulatory agencies, including the EPA and state agencies, set air emission standards and  
2 requirements based on human health impacts. These agencies also impose site-specific  
3 emission limits as needed to protect human health. As discussed previously, the EPA has  
4 recently concluded that certain segments of the U.S. population (e.g., the developing fetus,  
5 subsistence fish-eating populations) are believed to be at potential risk of adverse health  
6 effects due to mercury exposures from sources such as coal-fired power plants. However,  
7 in the absence of more quantitative data, human health impacts from radiological doses and  
8 inhaling toxins and particulates generated by burning coal are characterized as SMALL.

9 • Socioeconomics

10 It is estimated that the 816-MWe coal-fired power plant would take approximately four years  
11 to construct with a workforce ranging from 979 to 2040 workers (Entergy 2006). The extent  
12 of socioeconomic impacts from the construction of the coal-fired power plant would depend  
13 on its location. As the NRC notes in the GEIS, socioeconomic impacts are expected to be  
14 larger at a rural site than at an urban site because more of the peak construction workforce  
15 would need to move to the area to work. Socioeconomic impacts at a rural site would be  
16 LARGE, while impacts at a site in the vicinity of a more populated metropolitan area (e.g.,  
17 Syracuse) would be SMALL to MODERATE. Impacts during construction would consist of  
18 short-term increased demand for rental housing and public services that could temporarily  
19 offset the loss of jobs and tax revenue from the closure of JAFNPP. Communities in  
20 Oswego County in particular would experience MODERATE to LARGE impacts due to  
21 losses in employment and tax revenues from the closure of JAFNPP, especially if the coal-  
22 fired power plant is constructed outside the area.

23 Overall, the socioeconomic impacts of a coal-fired power plant at an alternate site would be  
24 SMALL to LARGE depending on the location of the plant.

25 • Transportation

26 Transportation-related impacts associated with construction at an alternate site are site-  
27 dependent but would be MODERATE to LARGE. Transportation impacts related to power  
28 plant operations would also be site-dependent and would be SMALL to MODERATE.

29 Coal and lime/limestone would likely be delivered to the site by rail or barge.

30 Socioeconomic impacts associated with rail transportation would likely be MODERATE to  
31 LARGE. For example, there would be highway traffic delays as trains pass road crossings.  
32 Barge delivery of coal and lime/limestone would likely have SMALL socioeconomic impacts.

33 • Aesthetics

34 Potential aesthetic impacts of construction and operation of the coal-fired power plant at an  
35 alternate site would include visual impairment from a large industrial facility. There would  
36 also be an aesthetic impact associated with construction of a new transmission line. Noise

## Environmental Impacts of Alternatives

1 and light from the power plant would be detectable offsite. Aesthetic impacts at the power  
2 plant site would be mitigated if the coal-fired power plant were located in an industrial area  
3 or adjacent to other power plants. Noise impacts from a rail spur, if required, would be most  
4 significant for residents living in the immediate vicinity of the power plant and along the rail  
5 route.

6 These impacts are highly site-specific. Therefore, the NRC staff concluded that depending  
7 on location aesthetic and noise impacts associated with the development and operation of a  
8 coal-fired power plant at an alternate site would range from SMALL to LARGE.

### 9 • Historic and Archaeological Resources

10 Before construction at an alternate site, historic and archaeological studies would be needed  
11 to identify, evaluate, and address the potential impacts of new power plant construction on  
12 cultural resources. These studies would be needed for all areas of potential disturbance at  
13 the proposed power plant site and other support facilities, and along associated corridors  
14 where new construction would occur (e.g., roads, transmission corridors, rail lines, other  
15 ROWs). Historic and archaeological resource impacts can generally be effectively managed  
16 and as such are considered SMALL to MODERATE depending on location and presence of  
17 cultural resources.

### 18 • Environmental Justice

19 Impacts on minority and low-income populations associated with a replacement coal-fired power  
20 plant built at an alternate site in New York State would depend on the location of the site and  
21 population distribution. Impacts on housing availability and prices during power plant  
22 construction could disproportionately affect minority and low-income populations. Closure of  
23 JAFNPP would result in the loss of approximately 716 jobs causing economic conditions that  
24 could affect employment prospects for minority or low-income populations. Depending on plant  
25 location, overall impacts would vary between SMALL and LARGE.

#### 26 *8.2.1.2 Closed-Cycle Cooling System*

27 The environmental impacts of constructing a coal-fired generation system at an alternate site  
28 using closed-cycle cooling with cooling towers would be essentially the same as for a coal-fired  
29 power plant using a once-through cooling system. However, there are some environmental  
30 differences between the closed-cycle and once-through cooling systems. Table 8-3  
31 summarizes the incremental differences.

1  
2**Table 8-3.** Summary of Environmental Impacts of Coal-Fired Generation at an Alternate Site with Closed-Cycle Cooling

<b>Impact Category</b>	<b>Change in Impacts from Once-Through Cooling System</b>
Land Use	25 to 30 additional ac would be required for cooling towers and associated support infrastructure.
Ecology	Impact would depend on ecology at the site. Reduced impact to aquatic ecology.
Water Use and Quality— Surface Water	Discharge of cooling tower blowdown containing dissolved solids. Discharge would be regulated by the State. Decreased water withdrawal and less thermal load on the receiving body of water. Consumptive use of water due to evaporation from cooling towers.
Water Use and Quality— Groundwater	No change
Air Quality	No change
Waste	No change
Human Health	No change
Socioeconomics	No change
Transportation	No change
Aesthetics	Introduction of cooling towers and associated plume. Natural draft towers would be up to 520 ft tall. Mechanical draft towers would be up to 100 ft tall and would have an associated noise impact.
Historic and Archaeological Resources	No change
Environmental Justice	No change

3

**4 8.2.2 Natural Gas-Fired Generation**

5 The environmental impacts of a natural gas-fired alternative are examined in this section. The  
6 NRC staff reviewed Entergy's ER and compared it to environmental impact information in the  
7 GEIS. Although the OL renewal period is only 20 years, the impact of operating the natural gas-  
8 fired alternative for 40 years is considered as a reasonable projection of the operating life of a  
9 natural gas-fired power plant.

## Environmental Impacts of Alternatives

1 Entergy assumed that a replacement natural gas-fired power plant would use combined-cycle  
2 technology. In a combined-cycle unit, hot combustion gases in a combustion turbine rotate the  
3 turbine to generate electricity. Waste combustion heat from the combustion turbine is routed  
4 through a heat-recovery boiler to make steam to generate additional electricity.

5 For operation of a gas-fired facility at the existing JAFNPP site, an additional 25 miles (mi) of  
6 pipeline for gas supply would need to be constructed. Offsite infrastructure needed to locate the  
7 power plant at an alternate site is conjectural but would reasonably include a natural gas supply  
8 pipeline, transmission line, and makeup water and discharge pipelines. The extent to which  
9 such infrastructure would be required is location-specific, but such needs would be considered  
10 in siting the facility and would be subject to regulatory scrutiny under New York's Public Service  
11 Law, Articles VII and X, or comparable process (Entergy 2006).

12 The natural gas-fired alternative is analyzed for both the existing JAFNPP site and for an  
13 unnamed alternate site. Siting a new natural gas-fired power plant at the site of an existing  
14 nuclear power plant would reduce environmental impacts by allowing the new facility to take  
15 advantage of existing infrastructure, including transmission facilities, roads, parking areas, office  
16 buildings, and the existing cooling system (to the extent needed). Approximately 90 ac would  
17 be required to locate the gas-fired power plant at an alternative site.

18 The NRC staff assumed that construction of the gas-fired units would be scheduled to coincide  
19 with the expiration date of the JAFNPP OL. Consistent with the JAFNPP ER (Entergy 2006),  
20 the NRC staff assumed a combined-cycle natural gas facility based on two 408-MWe combined-  
21 cycle units for a total facility size of 816 MWe. This assumption slightly understates the  
22 environmental impacts of replacing the 881 MWe from JAFNPP. As a rough estimate, if a  
23 natural gas-fired power plant of exactly 881 MWe were built, any numerical impacts in this  
24 section, e.g., quantities of air pollutants, might simply be adjusted upward accordingly.  
25 However, given these adjustments, the NRC staff has determined that the differences in  
26 impacts between 816 MWe and 881 MWe of natural gas-fired generation would not be  
27 significant and would not change the standard of significance (SMALL, MODERATE, or LARGE)  
28 of any impacts.

29 The NRC staff assumed that the power plant would use a once-through cooling system. The  
30 impacts of using a closed-cycle cooling system are evaluated in Section 8.2.2.2.

### 31 *8.2.2.1 Once-Through Cooling System*

32 The overall impacts of the natural gas-generating system using a once-through cooling system  
33 are discussed in this section and summarized in Table 8-4. The extent of impacts at an  
34 alternate site would depend on the location of the site.

1 **Table 8-4.** Summary of Environmental Impacts of Natural Gas-Fired Generation at the  
 2 JAFNPP Site and an Alternate Site Using Once-Through Cooling

Impact Category	JAFNPP Site		Alternate Site	
	Impact	Comments	Impact	Comments
Land Use	SMALL to MODERATE	The natural gas-fired power plant would be constructed on undeveloped portions of the JAFNPP site. It would require upwards of 90 ac for power block, roads, parking areas, and a gas pipeline ROW. It would use existing infrastructure, minimizing new land requirements.	SMALL to MODERATE	Land-use requirements would be larger at the alternate site than at the JAFNPP site because of the need for additional infrastructure such as transmission facilities, roads, parking areas, office buildings, and cooling system. The total impact would depend on whether the alternate site had been previously disturbed.
Ecology	MODERATE	The natural gas-fired alternative at the JAFNPP site would be constructed partly on previously disturbed areas and would disturb relatively little acreage at the site. However, a 25-mi gas supply line would need to be constructed, which, assuming a construction ROW of 75 ft, would disrupt up to 230 ac of terrestrial habitat. Ecological impacts would include impacts on threatened or endangered species, wildlife habitat loss and reduced productivity, habitat fragmentation, and a local reduction in biological diversity.	SMALL to MODERATE	Impacts would depend on whether the alternate site is previously developed. Factors to consider include location and ecology of site and transmission line route. Ecological impacts would include impacts on threatened or endangered species, wildlife habitat loss and reduced productivity, habitat fragmentation, and a local reduction in biological diversity.

**Table 8-4 (cont.)**

Impact Category	JAFNPP Site		Alternate Site	
	Impact	Comments	Impact	Comments
Water Use and Quality—Surface Water	SMALL	Combined-cycle units have lower water requirements than nuclear and coal-fired power plants. The natural gas-fired alternative would use the existing once through cooling system.	SMALL to MODERATE	Combined-cycle units have lower water requirements than nuclear and coal-fired power plants. Total impacts would depend on the volume and other characteristics of the receiving body of water.
Water Use and Quality—Groundwater	NO IMPACT	JAFNPP does not have onsite pumpable groundwater wells. Potable water is supplied by the Town of Scriba.	SMALL to MODERATE	The impact to groundwater would depend on the site characteristics, including the amount of groundwater available.
Air Quality	MODERATE	<ul style="list-style-type: none"> <li>• SO<sub>x</sub>: 85 tons/yr</li> <li>• NO<sub>x</sub>: 272 tons/yr</li> <li>• Carbon monoxide: 57 tons/yr</li> <li>• PM<sub>10</sub> particulates: 47 tons/yr</li> <li>• Other: (1) hazardous air pollutants, including arsenic, formaldehyde, and nickel and (2) carbon dioxide emissions, which contribute to global warming</li> </ul>	MODERATE	The impacts at an unnamed alternate site would be the same as those for the JAFNPP site.
Waste	SMALL	Minimal waste product from fuel combination	SMALL	The impacts at an unnamed alternate site would be the same as those for the JAFNPP site.
Human Health	SMALL	Impacts would be minor.	SMALL	The impacts at an unnamed alternate site would be the same as those for the JAFNPP site.



**Table 8-4 (cont.)**

Impact Category	JAFNPP Site		Alternate Site	
	Impact	Comments	Impact	Comments
Socioeconomics	SMALL to LARGE	Impacts are expected to be SMALL to LARGE because of a decrease in employment and tax revenue to local jurisdictions.	SMALL to LARGE	The impacts at an alternate site would be the same as those for the JAFNPP site.
Transportation	MODERATE	Transportation impacts associated with construction would be MODERATE.	MODERATE	Transportation impacts associated with construction would be MODERATE.
Aesthetics	SMALL	Construction and operation of a natural gas-fired power plant at JAFNPP would not alter the overall aesthetic characteristics of the site.	SMALL to LARGE	Construction and operation of a natural gas-fired power plant at an alternate site would change the aesthetic characteristics of the site.
Historic and Archaeological Resources	SMALL to MODERATE	Constructing a natural gas-fired power plant would require cultural resource studies. Impacts would vary depending on the location of the plant on the undeveloped portions of the JAFNPP site and the presence of historic and archaeological resources.	SMALL to MODERATE	The impacts at an alternate site would be the same as those for the JAFNPP site.
Environmental Justice	SMALL to MODERATE	Impacts to minority and low-income populations would vary depending on the location of the power plant site and other support facilities	SMALL to MODERATE	The impacts at an alternate site would be the same as those for the JAFNPP site.

1

2 • Land Use

3 For siting at JAFNPP, existing facilities and infrastructure would be used to the extent  
 4 possible, limiting the amount of new construction that would be required. Specifically, the  
 5 NRC staff assumed that the natural gas-fired replacement power plant alternative would  
 6 require approximately 90 ac of land and would make use of existing transmission facilities,  
 7 roads, and parking areas. Operation of a new combined-cycle facility at the JAFNPP site

## Environmental Impacts of Alternatives

1 would require the construction of approximately 25 mi of natural gas pipeline. It is estimated  
2 that the pipeline would require approximately 230 ac for an easement. The onsite facilities  
3 would represent expansion of an existing industrial land use.

4 For construction at an alternate site, the full land-area requirement for a natural gas-fired  
5 facility would be necessary because no existing infrastructure would be available. Additional  
6 land would be impacted by construction of a transmission line and natural gas pipelines to  
7 serve the power plant. The gas line requirements at an alternate site would depend on the  
8 characteristics and location of the alternate site.

9 Regardless of where the gas-fired power plant was built, additional land would be required  
10 for natural gas wells and collection stations. Partially offsetting these offsite land  
11 requirements would be the elimination of the need for uranium mining to supply fuel for  
12 JAFNPP. In the GEIS, the NRC staff estimated that approximately 1000 ac would be  
13 affected for mining the uranium and processing it during the operating life of a nuclear power  
14 plant.

15 Overall, the land-use impacts of constructing the natural gas-fired power plant at the  
16 JAFNPP site would be SMALL to MODERATE. Overall, the land-use impacts of siting the  
17 natural gas-fired power plant at an alternate site would depend on the chosen site and are  
18 characterized as SMALL to MODERATE.

### 19 • Ecology

20 Entergy expects that development of the gas-fired alternative power plant at the JAFNPP  
21 site would be constructed partly on previously disturbed areas and would disturb relatively  
22 little acreage at the site. However, to accommodate a gas-fired power plant at the JAFNPP  
23 site, a 25-mi gas supply line would need to be constructed, which, assuming a construction  
24 ROW of 75 ft, would disrupt up to 230 ac of terrestrial habitat. Ecological impacts to the  
25 power plant site and utility easements would include impacts on threatened or endangered  
26 species, wildlife habitat loss and reduced productivity, habitat fragmentation, and a local  
27 reduction in biological diversity.

28 The GEIS noted that land-dependent ecological impacts from construction would be SMALL  
29 unless site-specific factors indicated a particular sensitivity and that operational impact  
30 would be smaller than for other fossil fuel technologies of equal capacity. The connection to  
31 a gas pipeline approximately 25 mi from the JAFNPP site is a site-specific factor that would  
32 make the gas-fired alternative's ecological impacts larger than those of license renewal.  
33 Therefore, in this case, ecological impacts of siting a natural gas-fired power plant at the  
34 JAFNPP site would be MODERATE.

35 Impact on ecological resources from construction and operation of the representative natural  
36 gas-fired power plant and associated offsite infrastructure at an alternate site is conjectural.

1 However, ecological resources throughout much of the area would be similar to those for the  
2 JAFNPP site alternative. The NRC staff concludes that the associated impact on ecological  
3 resources would be SMALL to MODERATE.

4 • Water Use and Quality—Surface Water

5 Overall, water requirements for combined-cycle generation are much less than for  
6 conventional generators such as nuclear generators and coal-fired generators. A natural  
7 gas-fired power plant sited at JAFNPP is assumed to use the existing once-through cooling  
8 system. Surface water impacts would be expected to remain SMALL.

9 A natural gas-fired power plant at an alternate site is assumed to use a once-through  
10 cooling system. The impact on surface water would depend on the volume and other  
11 characteristics of the receiving body of water. The impacts would be SMALL to  
12 MODERATE.

13 The NRC staff noted in the GEIS that at either the JAFNPP site or an alternate site, some  
14 erosion and sedimentation probably would occur during construction. Water-quality impacts  
15 from sedimentation during construction are characterized in the GEIS as SMALL. The NRC  
16 staff also noted in the GEIS that operational water quality impacts would be similar to, or  
17 less than, those from other generating technologies.

18 • Water Use and Quality—Groundwater

19 JAFNPP does not have onsite pumpable groundwater wells. Potable water is supplied by  
20 the Town of Scriba and cooling water is taken from Lake Ontario. Therefore, there would be  
21 no groundwater impacts at the JAFNPP site.

22 For a natural gas-fired power plant at an alternate site, any groundwater withdrawal would  
23 require a permit from the local permitting authority. The impact to groundwater would  
24 depend on the site characteristics, including the amount of groundwater available. The  
25 impacts would range between SMALL and MODERATE.

26 • Air Quality

27 Natural gas is a relatively clean-burning fuel. The gas-fired alternative would release similar  
28 types of emissions but in lesser quantities than the coal-fired alternative. Hence, the gas-  
29 fired alternative would be subject to the same type of air-quality regulations as a coal-fired  
30 power plant, discussed in Section 8.2.1. The greatest concerns from combined-cycle  
31 facilities are the emissions of ozone precursors, NO<sub>x</sub>, and volatile organic compounds  
32 (VOCs).

## Environmental Impacts of Alternatives

1 JAFNPP projects the following emissions for the natural gas-fired alternative (Entergy 2006):

- 2 ○ Sulfur oxides: 85 tons/yr
- 3 ○ Nitrogen oxides: 272 tons/yr
- 4 ○ Carbon monoxide: 57 tons/yr
- 5 ○ PM<sub>10</sub> particulates: 47 tons/yr

6 A natural gas-fired power plant would also have unregulated carbon dioxide emissions that  
7 would contribute to global warming. While these emissions have not traditionally been an  
8 important environmental concern, they are becoming increasingly relevant at both the  
9 national and international levels.

10 In December 2000, the EPA issued regulatory findings on emissions of hazardous air  
11 pollutants from electric utility steam-generating units. Natural gas-fired power plants were  
12 found by the EPA to emit arsenic, formaldehyde, and nickel (EPA 2000b). Unlike coal and  
13 oil-fired power plants, the EPA did not determine that emissions of hazardous air pollutants  
14 from natural gas-fired power plants should be regulated under Section 112 of the Clean Air  
15 Act.

16 Construction activities would result in temporary fugitive dust. Exhaust emissions would  
17 also come from vehicles and motorized equipment used during the construction process and  
18 by employee and delivery vehicles during operations.

19 The preceding emissions would likely be the same at JAFNPP or at an alternate site.  
20 Impacts from the above emissions would be clearly noticeable but would not be sufficient to  
21 destabilize air resources as a whole. The overall air-quality impact for a new natural gas-  
22 fired power plant sited at JAFNPP or at an alternate site is considered MODERATE.

### 23 • Waste

24 There would be spent catalyst from NO<sub>x</sub> emissions control and small amounts of solid-waste  
25 products (i.e., ash) from burning natural gas fuel. In the GEIS, the NRC staff concluded that  
26 waste generation from gas-fired technology would be minimal. Gas firing results in very few  
27 combustion by-products because of the clean nature of the fuel. Waste-generation impacts  
28 would be so minor that they would not noticeably alter any important resource attribute.  
29 Construction-related debris would be generated during construction activities.

30 In the winter, it might become necessary for a replacement baseload natural gas-fired power  
31 plant to operate on fuel oil due to lack of gas supply. Oil combustion generates waste in the  
32 form of ash, and equipment for controlling air pollution generates additional ash and  
33 scrubber sludge. The amount of ash and sludge generated would depend on the type and  
34 quantity of fuel oil combusted. Number 2 fuel oil does not produce any appreciable ash.

1 Overall, the waste impacts would be SMALL for a natural gas-fired power plant sited at  
2 JAFNPP or at an alternate site.

3 • Human Health

4 In Table 8-2 of the GEIS, the NRC staff identifies cancer and emphysema as potential  
5 health risks from gas-fired power plants. The risk may be attributable to NO<sub>x</sub> emissions that  
6 contribute to ozone formation, which in turn contribute to health risks. Emissions of NO<sub>x</sub>  
7 from any gas-fired power plant would be regulated. For a power plant sited in New York,  
8 NO<sub>x</sub> emissions would be regulated by the NYSDEC. Human health effects would not be  
9 detectable or would be sufficiently minor that they would neither destabilize nor noticeably  
10 alter any important attribute of the resource. Overall, the impacts on human health of the  
11 natural gas-fired alternative sited at JAFNPP or at an alternate site would be SMALL.

12 • Socioeconomics

13 Construction of a natural gas-fired power plant would take approximately two years. In the  
14 GEIS, peak employment is determined to be approximately 1200 workers. The NRC staff  
15 assumed that construction would take place while JAFNPP continued operation and would  
16 be completed by the time it permanently ceased operations. During construction, the  
17 communities surrounding the JAFNPP site would experience demands on housing and  
18 public services that would have SMALL impacts. These impacts would be tempered by  
19 construction workers commuting from other parts of Oswego and Onondaga counties. After  
20 construction, the communities would be impacted by the loss of jobs. The current JAFNPP  
21 workforce (716 workers) would decline through a decommissioning period to a minimal  
22 maintenance size. The gas-fired power plant would introduce a replacement tax base at  
23 JAFNPP or an alternate site and approximately 50 new permanent jobs. Impacts in Oswego  
24 and Onondaga counties resulting from decommissioning of JAFNPP might be offset to some  
25 degree by potential job opportunities in the Syracuse area.

26 In the GEIS, the NRC staff concluded that socioeconomic impacts from constructing a  
27 natural gas-fired power plant would not be very noticeable and that the small operational  
28 workforce would have the lowest socioeconomic impacts of any nonrenewable technology.  
29 Compared to the coal-fired and nuclear alternatives, the smaller size of the construction  
30 workforce, the shorter construction time frame, and the smaller size of the operations  
31 workforce would minimize socioeconomic impacts. For these reasons, socioeconomic  
32 impacts associated with the construction and operation of a natural gas-fired power plant  
33 would be MODERATE for siting at JAFNPP.

34 The extent of socioeconomic impacts from constructing and operating a natural gas-fired  
35 power plant at an alternate site in upstate New York would depend on its location. Impacts  
36 near large population centers (i.e., Syracuse) would likely be small, with moderate impacts  
37 possible in more rural areas. Communities in Oswego County in particular would

## Environmental Impacts of Alternatives

1 experience MODERATE to LARGE impacts due to losses in employment and tax revenues  
2 from the closure of JAFNPP, especially if the natural gas-fired power plant is constructed  
3 outside the area. Overall, the socioeconomic impacts of a natural gas-fired power plant at an  
4 alternate site would be SMALL to LARGE depending on the location of the plant.

### 5 • Transportation

6 Transportation-related impacts associated with construction and operations would depend  
7 on the population density and transportation infrastructure in the vicinity of the site. The  
8 impacts can be classified as MODERATE for siting at the JAFNPP site or an alternate site.

### 9 • Aesthetics

10 The turbine buildings (106-ft tall) and exhaust stacks (approximately 225-ft tall) would be  
11 visible during daylight hours from offsite. The gas pipeline compressors would also be  
12 visible. However, development of the natural gas-fired power plant at the JAFNPP site  
13 would represent an incremental addition to an existing power plant with similar  
14 characteristics. A forest buffer provides a visual screen to residential developments  
15 bordering the site. Overall, the NRC staff concludes that aesthetic impacts from  
16 development of a natural gas-fired power plant at the JAFNPP site would be SMALL.

17 At an alternate site, the buildings and associated transmission line and gas pipeline  
18 compressors would be visible offsite. The visual impact of a new transmission line would be  
19 especially significant. Aesthetic impacts would be mitigated if the power plant were located  
20 in an industrial area adjacent to other power plants. Overall, the aesthetic impacts  
21 associated with an alternate site are categorized as MODERATE to LARGE. The greatest  
22 contributor to this categorization is the aesthetic impact of the new transmission line.

23 Natural gas generation would introduce mechanical sources of noise that would be audible  
24 offsite. Sources contributing to total noise produced by power plant operation are classified  
25 as continuous or intermittent. Continuous sources include the mechanical equipment  
26 associated with normal power plant operations. Intermittent sources include the use of an  
27 outside loudspeaker and the commuting of power plant employees. However, it is expected  
28 that the power plant would comply with all applicable noise ordinances and standards.  
29 Therefore, the noise impacts of a natural gas-fired power plant at the JAFNPP site would be  
30 SMALL. At an alternate site, these noise impacts would be SMALL to LARGE depending on  
31 the location of the site.

### 32 • Historic and Archaeological Resources

33 At both JAFNPP and an alternate site, a cultural resource inventory would be needed for  
34 any undeveloped portions of the site that had not been previously surveyed. Other  
35 properties, if any, which would be acquired to support the power plant, would also need to

1 be surveyed for cultural resources prior to ground-disturbing activities at the power plant  
2 site.

3 Before construction at JAFNPP or an alternate site, historic and archaeological studies  
4 would be needed to identify, evaluate, and address the potential impacts of new power plant  
5 construction on cultural resources. These studies would likely be needed for all areas of  
6 potential disturbance at the proposed power plant site, other support facilities, and along  
7 associated corridors where new construction would occur (e.g., roads, transmission and  
8 pipeline corridors, other ROWs). Historic and archaeological resource impacts can  
9 generally be effectively managed and as such are considered SMALL to MODERATE  
10 depending on the location and presence of cultural resources.

11 • Environmental Justice

12 Impacts on minority and low-income populations associated with a replacement natural gas-  
13 fired power plant built at JAFNPP or an alternate site in New York State would depend on  
14 the location of the site and population distribution. Impacts on housing availability and prices  
15 during power plant construction could disproportionately affect minority and low-income  
16 populations. Closure of JAFNPP would result in the loss of approximately 716 jobs causing  
17 economic conditions that could affect employment prospects for minority or low-income  
18 populations. Depending on plant location, overall impacts could vary between SMALL and  
19 MODERATE.

20 *8.2.2.2 Closed-Cycle Cooling System*

21 This section discusses the environmental impacts of constructing a natural gas-fired generation  
22 system at either the JAFNPP site or an alternate site using closed-cycle cooling. The impacts  
23 (SMALL, MODERATE, or LARGE) of this option are the same as for a natural gas-fired power  
24 plant using the once-through cooling system. However, there are minor environmental  
25 differences between the closed-cycle and once-through cooling systems. Table 8-5  
26 summarizes the incremental differences.

27 **8.2.3 Nuclear Power Generation**

28 Since 1997, the NRC has certified four new standard designs for nuclear power plants under  
29 10 CFR 52, Subpart B. These designs are the 1300 MWe U.S. Advanced Boiling Water  
30 Reactor (10 CFR 52, Appendix A), the 1300 MWe System 80+ Design (10 CFR 52,  
31 Appendix B), the 600 MWe AP600 Design (10 CFR 52, Appendix C), and AP 1000 (10 CFR 52,  
32 Appendix D). All of these power plants are light-water reactors. Although no applications for a  
33 construction permit or a combined license based on these certified designs have been  
34 submitted to NRC, the submission of the design certification applications indicates continuing  
35 interest in the possibility of licensing new nuclear power plants. Consequently, construction of a  
36 new nuclear power plant at both the JAFNPP site and an alternate site is considered in this

Environmental Impacts of Alternatives

1 section. The NRC staff assumed that the new nuclear power plant would have a 40-year  
 2 lifetime.

3 **Table 8-5.** Summary of Environmental Impacts of Natural Gas-Fired Generation at Either  
 4 the JAFNPP Site or an Alternate Site with Closed-Cycle Cooling

Impact Category	Change in Impacts from Once-Through Cooling System
Land Use	25 to 30 additional ac required for cooling towers and associated support infrastructure.
Ecology	Impact would depend on ecology at the site. Additional impact to terrestrial biota from cooling tower drift. Reduced impact to aquatic ecology.
Water Use and Quality— Surface Water	Discharge of cooling tower blowdown containing dissolved solids. Discharge would be regulated. Decrease water withdrawal and less thermal load on receiving body of water. Increase in consumptive use of water due to evaporation.
Water Use and Quality— Groundwater	No change
Air Quality	No change
Waste	No change
Human Health	No change
Socioeconomics	No change
Transportation	No change
Aesthetics	Introduction of cooling towers and associated plume with noise impacts from operation of cooling towers.
Historic and Archaeological Resources	No change
Environmental Justice	No change

5

6 NRC has summarized environmental data associated with the uranium fuel cycle in Table S-3 of  
 7 10 CFR 51.51. The impacts listed in Table S-3 are representative of the impacts that would be  
 8 associated with a replacement nuclear power plant built to one of the certified designs and sited  
 9 at JAFNPP or an alternate site. The impacts shown in Table S-3 are for a 1000-MWe reactor.  
 10 The environmental impacts associated with transporting fuel and waste to and from a light-water  
 11 cooled nuclear power reactor are summarized in Table S-4 of 10 CFR 51.52. The summary of



1 NRC's findings on NEPA issues for license renewal of nuclear power plants in Table B-1 of  
2 10 CFR 51 Subpart A, Appendix B, is also relevant, although not directly applicable, for  
3 consideration of environmental impacts associated with the operation of a replacement nuclear  
4 power plant. Additional environmental impact information for a replacement nuclear power plant  
5 using once-through cooling is presented in Section 8.2.3.1 and closed-cycle cooling in  
6 Section 8.2.3.2.

### 7 *8.2.3.1 Once-Through Cooling System*

8 The overall impacts of a nuclear generating system using a once-through cooling system are  
9 discussed in this section. The impacts are summarized in Table 8-6. The extent of impacts at  
10 an alternate site would depend on the location of the site.

#### 11 • Land Use

12 The existing facilities and infrastructure at the JAFNPP site would likely be used, limiting the  
13 amount of new construction that would be required. Existing transmission facilities, roads,  
14 parking areas, and cooling system would be used. According to the GEIS, light-water  
15 reactors require approximately 500 to 1000 ac excluding transmission lines (these estimates  
16 are not scaled to any particular facility size). Much of the land that would be used has been  
17 previously disturbed. The JAFNPP site consists of approximately 700 ac and would be  
18 adequate to support a new nuclear facility. There would be no net change in land needed  
19 for uranium mining because land needed to supply the new nuclear power plant would  
20 replace the land no longer needed to supply uranium for fueling the existing reactors at  
21 JAFNPP. Overall, the land use impact of a replacement nuclear power plant at the existing  
22 JAFNPP site would be SMALL. However, the impact would be greater than the OL renewal  
23 alternative.

24 Land-use requirements at an alternate site would be similar to siting at JAFNPP except for  
25 the possible need for additional land for a new transmission line. In addition, it might be  
26 necessary to construct a rail spur to bring in equipment during construction. Depending on  
27 transmission line routing, siting a new nuclear power plant at an alternate site would result in  
28 MODERATE to LARGE land-use impacts.

#### 29 • Ecology

30 Locating a replacement nuclear power plant at the JAFNPP site would alter ecological  
31 resources because of construction and the need to convert currently unused land to  
32 industrial use. In total, impacts would include habitat degradation, fragmentation, or loss as  
33 a result of construction activities and conversion of land to industrial use. Ecological  
34 communities would experience reduced productivity and biological diversity from disturbing  
35 previously intact land. Overall, the ecological impacts of the nuclear alternative at the

Environmental Impacts of Alternatives

1 JAFNPP site would be SMALL. The impact would be greater than the OL renewal  
 2 alternative.

3 **Table 8-6.** Summary of Environmental Impacts of New Nuclear Power Generation at the  
 4 JAFNPP Site and an Alternate Site Using Once-Through Cooling

Impact Category	JAFNPP Site		Alternate Site	
	Impact	Comments	Impact	Comments
Land Use	SMALL	Would require approximately 500 to 1000 ac for the power plant. The new nuclear power plant would require the use of previously disturbed undeveloped portions of the JAFNPP site. Would use the existing infrastructure to the extent possible.	MODERATE to LARGE	Land use requirements would be larger at the alternate site than at the JAFNPP site because of the potential need for land for a transmission line. Overall, impacts would depend on whether the alternate site had been previously disturbed.
Ecology	SMALL	Would use undeveloped areas at current Nine Mile Point site.	MODERATE to LARGE	Impact depends on location and ecology of the site, surface water body used for intake and discharge, and transmission line route; potential habitat loss and fragmentation; and reduced productivity and biological diversity.
Water Use and Quality—Surface Water	SMALL	The nuclear alternative would use the existing once-through cooling system.	SMALL to MODERATE	Impacts would depend on the volume of water withdrawn and the characteristics of the surface body of water.
Water Use and Quality—Groundwater	SMALL	Groundwater is not used at the JAFNPP site.	SMALL to MODERATE	Impacts would depend on the volume of water withdrawn and the characteristics of the groundwater source.
Air Quality	SMALL	Fugitive emissions and emissions from vehicles and equipment during construction. Small amount of emissions from diesel generators and possibly other sources during operation.	SMALL	Same impacts as JAFNPP site.

**Table 8-6 (cont.)**

<b>Impact Category</b>	<b>JAFNPP Site</b>		<b>Alternate Site</b>	
	<b>Impact</b>	<b>Comments</b>	<b>Impact</b>	<b>Comments</b>
Waste	SMALL	Waste impacts for an operating a nuclear power plant are set out in 10 CFR 51, Appendix B, Table B-1. Debris would be generated and removed during construction.	SMALL	Same impacts as JAFNPP site.
Human Health	SMALL	Human health impacts for an operating nuclear power plant are set out in 10 CFR 51, Appendix B, Table B-1.	SMALL	Same impacts as JAFNPP site.
Socioeconomics	SMALL to MODERATE	During construction, impacts would be MODERATE. Up to 2500 workers during peak period of the five-year construction period. During operation, employment levels would be similar to those for JAFNPP. Overall, socioeconomic impacts from operation would be SMALL.	SMALL to LARGE	The characteristics of the construction period and operation at an alternate site would be similar to those at JAFNPP. Socioeconomic impacts to the local community would depend on the location of the alternate site and would vary from SMALL to LARGE.
Transportation	SMALL to LARGE	Transportation impacts associated with construction would be MODERATE to LARGE. Transportation impacts associated with operations would be SMALL.	SMALL to LARGE	Transportation impacts associated with construction would be MODERATE to LARGE. Transportation impacts associated with operations would be SMALL to MODERATE.
Aesthetics	SMALL to MODERATE	There would be visual aesthetic impacts associated with power plant buildings and structures. There would be both intermittent and continuous noise impacts from the power plant during construction and operations.	SMALL to LARGE	The significance of the impacts would depend on the location of the alternate site. An alternate site could require transmission lines, with aesthetic impacts.

**Table 8-6 (cont.)**

Impact Category	JAFNPP Site		Alternate Site	
	Impact	Comments	Impact	Comments
Historic and Archaeological Resources	SMALL to MODERATE	Construction of a new nuclear power plant would require cultural resource studies. Impacts could vary depending on the location of the plant on undeveloped portions of the JAFNPP site and presence of historic and archaeological resources.	SMALL to MODERATE	The impacts at an alternate site would be the same as those for the JAFNPP site.
Environmental Justice	SMALL to MODERATE	Impacts to minority and low-income populations would vary depending on the location of the power plant site and other support facilities.	SMALL to MODERATE	The impacts at an alternate site would be the same as those for the JAFNPP site.

1

2 At an alternate site, there would be construction impacts and new incremental operational  
 3 impacts. Even assuming siting at a previously disturbed area, the impacts might alter the  
 4 ecology. Impacts would include habitat degradation, fragmentation or loss, reduced  
 5 ecosystem productivity (i.e., including wildlife species), and a reduction in biological  
 6 diversity. Construction and maintenance of transmission lines, a rail spur, or a barge  
 7 offloading facility would result in the same types of ecological impacts. Overall, the impacts  
 8 of the nuclear alternative at an alternate site would be MODERATE to LARGE.

9 • Water Use and Quality—Surface Water

10 It is assumed that the replacement nuclear power plant alternative at the JAFNPP site would  
 11 use the existing once-through cooling system, which would minimize incremental water-use  
 12 and quality impacts. Surface-water impacts would be expected to remain SMALL. The  
 13 impacts would be sufficiently minor that they would not noticeably alter any important  
 14 attribute of the resource.

15 For an alternate site, the cooling water would likely be drawn from a surface body of water.  
 16 The impact on the surface water would depend on the volume of water needed and the  
 17 characteristics of the body of water. The impacts would be SMALL to MODERATE.

1 • Water Use and Quality—Groundwater

2 No groundwater is currently used for operation of JAFNPP, and it is unlikely that  
 3 groundwater would be used for an alternative nuclear power plant sited at JAFNPP. Use of  
 4 groundwater for a nuclear power plant sited at an alternate site would be a possibility. Any  
 5 groundwater withdrawal would require a permit from the local permitting authority.

6 Overall, the impacts of the nuclear alternative at the JAFNPP site would be SMALL. The  
 7 impacts of the nuclear alternative at an alternate site would be SMALL to MODERATE.

8 • Air Quality

9 Construction of a new nuclear power plant sited at JAFNPP or an alternate site would result  
 10 in fugitive emissions during the construction process. Exhaust emissions would also come  
 11 from vehicles and motorized equipment used during the construction process. An operating  
 12 nuclear power plant would have minor air emissions associated with diesel generators and  
 13 other minor intermittent sources. These emissions would be regulated by NYSDEC.

14 Overall, emissions and associated impacts to air quality of a nuclear power plant at either  
 15 the JAFNPP site or an alternate site would be SMALL.

16 • Waste

17 The waste impacts associated with operation of a nuclear power plant are set out in  
 18 Table B-1 of 10 CFR 51, Subpart A, Appendix B. Construction-related debris would be  
 19 generated during construction activities and removed to an appropriate disposal site.  
 20 Overall, waste impacts of a new nuclear power plant at either the JAFNPP site or an  
 21 alternate site would be SMALL.

22 • Human Health

23 Human health impacts for an operating nuclear power plant are set out in 10 CFR 51  
 24 Subpart A, Appendix B, Table B-1. Overall, human health impacts of a new nuclear power  
 25 plant at either the JAFNPP site or an alternate site would be SMALL.

26 • Socioeconomics

27 Construction of the new nuclear power plant would be conducted over a period of five years  
 28 with a peak workforce of 2500. Construction would take place while the existing nuclear unit  
 29 would continue operation and would be completed by the time JAFNPP permanently ceased  
 30 operation.

31 If the new nuclear power plant were constructed at the JAFNPP site, the construction  
 32 workers would be in addition to the employees who currently work at the site. Surrounding  
 33 communities would experience significant demands on rental housing and public services.

## Environmental Impacts of Alternatives

1 After construction, the local communities would be impacted by the loss of the construction  
2 jobs. In addition, the large construction workforce and delivery of construction materials  
3 would put significant pressure on existing highways near the JAFNPP site. The construction  
4 workforce would also add to the local tax base. In total, the socioeconomic impacts during  
5 the construction period for the nuclear alternative at the JAFNPP site would be MODERATE.

6 At an alternate site, the construction impacts would be similar to those at the JAFNPP site.  
7 Impacts would be SMALL to LARGE, depending on the location of the alternate site to a  
8 large population center.

9 It is assumed that the replacement nuclear unit would have an operating workforce  
10 comparable to the 716 workers currently working at JAFNPP. The replacement nuclear unit  
11 would provide a new tax base to offset the loss of tax base associated with  
12 decommissioning JAFNPP. For all of these reasons, the socioeconomic impacts for  
13 operating a new nuclear power plant at JAFNPP would be SMALL.

14 The impacts of operating a new nuclear power plant at an alternate site would be generally  
15 larger than those at the JAFNPP site, depending on the proximity of the alternate site to a  
16 large population center. Impacts would be SMALL to LARGE, depending on the location of  
17 the alternate site.

### 18 • Transportation

19 During the five-year construction period, up to 2500 construction workers would be working  
20 at the JAFNPP site in addition to the 716 workers who operate JAFNPP. The addition of the  
21 construction workers and the delivery of construction materials and equipment would place  
22 significant pressure on existing highways. Impacts would be MODERATE to LARGE.  
23 Transportation impacts associated with the operation of JAFNPP would be SMALL.

24 Transportation-related impacts associated with commuting construction workers and the  
25 delivery of construction materials and equipment at an alternate site would be site-  
26 dependent and would be MODERATE to LARGE. Transportation impacts associated with  
27 operations would also be site-dependent and would be SMALL to MODERATE.

### 28 • Aesthetics

29 The nuclear alternative would result in both visual and noise aesthetic impacts. Visual  
30 impacts would result from several structures, including, most prominently, the containment  
31 building. The replacement nuclear units would also likely be visible at night because of  
32 outside lighting. Visual impacts at night would be mitigated by reduced lighting and  
33 appropriate shielding. Overall, the visual aesthetic impacts of the nuclear alternative at the  
34 JAFNPP site would be MODERATE.

1 At an alternate site, the aesthetic impacts would be larger. There would also be aesthetic  
2 impacts associated with the need for new transmission lines. Light from the new nuclear  
3 power plant would be detectable offsite. The impact of light could be mitigated if the power  
4 plant were located in an industrial area adjacent to other power plants. Overall, the  
5 aesthetic impacts associated with an alternate site would be MODERATE to LARGE  
6 including the aesthetic impact of a new transmission line.

7 Nuclear generation would introduce continuous and intermittent sources of noise from power  
8 plant operations. Continuous sources of noise include the mechanical equipment  
9 associated with normal power plant operations. Intermittent sources include the use of  
10 outside loudspeakers and those associated with the workforce. At the JAFNPP site, power  
11 plant-operation noises would be similar to existing noise levels from current power plant  
12 operations. Noise impacts of the nuclear alternative at JAFNPP would be SMALL. At an  
13 alternate site, noise impacts would be SMALL to LARGE, depending on the location of the  
14 site.

15 • Historic and Archaeological Resources

16 At both JAFNPP and an alternate site, a cultural resource inventory would be needed for  
17 any undeveloped portions of the site that had not been previously surveyed. Other  
18 properties, if any, that were acquired to support the power plant would also need to be  
19 surveyed for cultural resources, prior to ground-disturbing activities at the power plant site.

20 Before construction at JAFNPP or an alternate site, studies would be needed to identify,  
21 evaluate, and address the potential impacts of new power plant construction on cultural  
22 resources. These studies would be needed for all areas of potential disturbance at the  
23 proposed power plant site, other support facilities, and along associated corridors where  
24 new construction would occur (e.g., roads, transmission corridors, rail lines, other ROWs).  
25 Historic and archaeological resource impacts would generally be effectively managed and  
26 as such would be SMALL to MODERATE depending on location and presence of cultural  
27 resources.

28 • Environmental Justice

29 Impacts on minority and low-income populations associated with a replacement nuclear  
30 power plant at JAFNPP or an alternate site in New York State would depend on the location  
31 of the site and population distribution. Impacts on housing availability and prices during  
32 power plant construction could disproportionately affect minority and low-income  
33 populations. Closure of JAFNPP and construction of a replacement nuclear power plant at  
34 an alternate site would result in the loss of approximately 716 jobs causing economic  
35 conditions that could affect employment prospects for minority or low-income populations in  
36 the vicinity of JAFNPP. Depending on the plant location, overall impacts could vary  
37 between SMALL and MODERATE.

## Environmental Impacts of Alternatives

### 1 8.2.3.2 Closed-Cycle Cooling System

2 This section discusses the environmental impacts of constructing at an alternate site a nuclear  
3 power plant that uses a closed-cycle cooling system with a cooling tower. The impacts (SMALL,  
4 MODERATE, or LARGE) of this option would be similar to the impacts for a nuclear power plant  
5 using a once-through cooling system. However, there would be minor environmental  
6 differences between the closed-cycle and once-through cooling systems. Table 8-7  
7 summarizes the incremental differences.

8 **Table 8-7.** Summary of Environmental Impacts of a New Nuclear Power Plant Sited at an  
9 Alternate Site with Closed-Cycle Cooling

<b>Impact Category</b>	<b>Change in Impacts from Once-Through Cooling System</b>
Land Use	20 to 30 ac of land would be required on previously disturbed undeveloped land for cooling towers and associated infrastructure.
Ecology	Impacts would depend on ecology at the site. Additional impact to terrestrial ecology from cooling tower drift. Reduced impact to aquatic ecology.
Water Use and Quality— Surface Water	Discharge of cooling tower blowdown containing dissolved solids. Discharge would be regulated by the State of New York. Decreased water withdrawal and less thermal load on receiving body of water. Consumptive use of water due to evaporation from cooling towers.
Water Use and Quality— Groundwater	No change
Air Quality	No change
Waste	No change
Human Health	No change
Socioeconomics	No change
Transportation	No change
Aesthetics	Introduction of cooling towers and associated plume. Natural draft towers would be up to 520 ft tall. Mechanical draft towers would be up to 100 ft tall and would have an associated noise impact.
Historic and Archaeological Resources	No change
Environmental Justice	No change

### 10 **8.2.4 Purchased Electrical Power**

11 If available, purchased power from other sources would potentially obviate the need to renew  
12 the JAFNPP OL. The New York State energy plan (NYSERDA 2002) is designed to promote  
13 competition in energy supply markets by facilitating participation by non-utility suppliers. A



1 regulatory structure is in place to appropriately anticipate and meet electricity demands. The  
2 New York Independent System Operator (NYISO) anticipates that adequate supplies of  
3 electricity will be available to meet anticipated future demands through at least 2021. In theory,  
4 purchased power is a feasible alternative to JAFNPP license renewal. There is no assurance,  
5 however, that sufficient capacity or energy would be available during the entire time frame of  
6 2014 to 2034 to replace the approximately 881 MWe of baseload generation from JAFNPP. For  
7 example, EIA projects that total gross U.S. imports of electricity from Canada and Mexico will  
8 gradually increase from 38.4 billion kWh in year 2001 to 48.9 billion kWh in year 2005 and then  
9 gradually decrease to 24.4 billion kWh in year 2020 (DOE/EIA 2004). On balance, it appears  
10 unlikely that electricity imported from Canada or Mexico would be able to replace JAFNPP's  
11 generating capacity.

12 If power to replace JAFNPP capacity were purchased from sources in the U.S. or from a foreign  
13 country, the generating technology would likely be one of those described in this draft SEIS and  
14 in the GEIS (i.e., coal, natural gas, or nuclear). The description of the environmental impacts of  
15 other technologies in Chapter 8 of the GEIS is representative of the purchased electrical power  
16 alternative to renewal of the JAFNPP OL. Thus, the environmental impacts of imported power  
17 would still occur but would be located elsewhere within the region, nation, or in another country.  
18 For these reasons, the NRC staff does not believe that purchasing power to make up for the  
19 generation at JAFNPP is a meaningful alternative that requires independent analysis.

## 20 **8.2.5 Other Alternatives**

21 Other generation technologies considered by NRC are discussed in Sections 8.2.5.1 through  
22 8.2.5.11.

### 23 *8.2.5.1 Oil-Fired Generation*

24 EIA projects that oil-fired power plants will account for very little of the new generation capacity  
25 in the U.S. through the year 2030 because of higher fuel costs and lower efficiencies (DOE/EIA  
26 2007). Oil-fired operation is more expensive than nuclear or coal-fired operation. Future  
27 increases in oil prices are expected to make oil-fired generation increasingly more expensive  
28 than coal-fired generation. The high cost of oil has prompted a steady decline in its use for  
29 electricity generation. Increasing domestic concerns over oil security will only exacerbate the  
30 move away from oil-fired electricity generation. Therefore, the NRC staff does not consider oil-  
31 fired generation by itself a feasible alternative to the baseload generation of JAFNPP.

### 32 *8.2.5.2 Wind Power*

33 Wind power, by itself, is not suitable for large baseload capacity. As discussed in Section 8.3.1  
34 of the GEIS, wind has a high degree of intermittency, and average annual capacity factors for  
35 wind power plants are relatively low (less than 30 percent). Wind power, in conjunction with  
36 energy storage mechanisms, might serve as a means of providing baseload power. However,

## Environmental Impacts of Alternatives

1 current energy storage technologies are too expensive for wind power to serve as a large  
2 baseload generator.

3 Most of western New York is in wind-power Class 2 or 3, in which the average wind speed is 4.4  
4 to 5.6 meters per second (m/s) (Elliott et al. 1986). There is a narrow band of Class 3 and 4  
5 areas along Lake Ontario. Wind turbines are economical in Class 3 through 7 areas, in which  
6 the average wind speeds are 7.0 to >8.8 m/s (DOE 2005). Wind turbines typically operate at 25  
7 to 35 percent capacity factor compared to 80 to 95 percent for a baseload power plant (NWPPC  
8 2000). Because the largest commercially available wind turbines produce in the range of 1 MW  
9 to 3 MW, 294 to 881 units would be required to replace the JAFNPP generating capacity.

10 As of September 2006, there were approximately 280 MW of grid-connected wind-power  
11 facilities in New York State, with an additional 255 MW of additional capacity in various stages  
12 of planning (AWEA 2006). The New York State Energy Research and Development Authority  
13 (NYSERDA) estimates there is a statewide potential for approximately 17,000 MW of installed  
14 capacity, of which approximately 3200 MW would be available for the peak summer load  
15 (NYSERDA 2002). Access to many of the best wind-power sites would require extensive road  
16 building, clearing (for towers and blades), and leveling (for the tower bases and associated  
17 facilities) in steep terrain. Also, many of the best quality wind sites are on ridges and hilltops  
18 that would have greater archeological sensitivity than surrounding areas. For these reasons,  
19 development of large-scale, land-based wind-power facilities are likely to be costly and would  
20 have MODERATE to LARGE impacts on aesthetics, archaeological resources, land use, and  
21 terrestrial ecology.

22 The offshore wind speeds on Lake Ontario are higher than those onshore and would thus  
23 support greater energy production than onshore facilities. Development of an offshore wind-  
24 power facility would impact shipping lanes, may disrupt the aquatic ecology, and would be  
25 visible for many miles, resulting in considerable aesthetic impacts. These impacts would be  
26 MODERATE to LARGE.

27 For these reasons, the NRC staff concludes that wind power alone is not a feasible substitute at  
28 this time for the baseload generation from JAFNPP. However, the NRC staff recognizes that  
29 wind power projects are being developed in areas with significant wind potential. Therefore, it is  
30 reasonable to include wind power in a combination of alternatives that would replace the  
31 generation from JAFNPP. Combined alternatives are discussed in Section 8.2.6.

### 32 *8.2.5.3 Solar Power*

33 Solar technologies use the sun's energy and light to provide heat, cooling, light, hot water, and  
34 electricity for homes, businesses, and industry. Solar-power technologies, both photovoltaic  
35 and thermal, cannot currently compete with conventional fossil-fuel technologies in grid-  
36 connected applications due to higher capital costs per kilowatt of capacity. The average  
37 capacity factor for photovoltaic cells is approximately 25 percent and for solar thermal systems,

1 25 to 40 percent. These capacity factors are low because solar power is an intermittent  
2 resource, providing power when the sun is strong, whereas JAFNPP provides constant  
3 baseload power. Solar technologies simply cannot make up for the capacity from JAFNPP  
4 when the sun is not shining.

5 There can be substantial impacts to natural resources (e.g., wildlife habitat, land use,  
6 aesthetics) from construction of solar-generating facilities. As stated in the GEIS, land  
7 requirements are high. Based on the land requirement of 14 ac for every 1 MWe generated,  
8 over 12,000 ac would be required to replace the approximately 881 MWe produced by JAFNPP.  
9 There is not enough land for either type of solar electric system at the existing JAFNPP site, and  
10 both would have large environmental impacts at an alternate site.

11 The construction impacts would be similar to those associated with a large wind farm, as  
12 discussed in Section 8.2.5.2. The operating facility would also have considerable aesthetic  
13 impact.

14 Because of the natural resource impacts (land, ecological, and aesthetic), and high technology  
15 costs, solar power is not deemed a feasible baseload alternative to license renewal of JAFNPP.  
16 However, the NRC staff recognizes that distributed solar power does provide generation and  
17 that during the license renewal period, generation from solar power could continue to grow.  
18 Therefore, it is reasonable to include solar power in combinations of alternatives to replace the  
19 generation from JAFNPP. Combined alternatives are discussed in Section 8.2.6.

#### 20 *8.2.5.4 Hydropower*

21 New York State has a technical potential for 2527 MW of additional installed hydroelectric  
22 capacity by the year 2022, only 909 MW of which represents summer peak capacity. If all this  
23 capacity were developed, it would be enough to replace the 881-MW generating capacity of  
24 JAFNPP. However, as stated in Section 8.3.4 of the GEIS, hydropower's percentage of U.S.  
25 generating capacity is expected to decline because hydroelectric facilities have become difficult  
26 to site as a result of public concern about flooding, destruction of natural habitat, and alteration  
27 of natural river courses. DOE/EIA states that potential sites for hydroelectric dams have already  
28 been largely established in the U.S., and environmental concerns are expected to prevent the  
29 development of any new sites (DOE/EIA 2002).

30 The NRC staff estimates in the GEIS that land requirements for hydroelectric power are  
31 approximately 1 million ac per 1000 MWe. Replacement of JAFNPP generating capacity would  
32 require flooding slightly less than this amount of land. Due to the large land-use and related  
33 environmental and ecological resource impacts associated with siting hydroelectric facilities  
34 large enough to replace JAFNPP, the NRC staff concludes that local hydropower is not a  
35 feasible alternative to JAFNPP OL renewal on its own. Any attempts to site hydroelectric  
36 facilities large enough to replace JAFNPP would result in LARGE environmental impacts.

1    8.2.5.5 *Geothermal Energy*

2    Geothermal energy has an average capacity factor of 90 percent and can be used for baseload  
3    power where available. However, the NRC staff states in the GEIS that geothermal technology  
4    is not widely used as baseload generation because of the limited geographical availability of the  
5    resource and immature status of the technology. As illustrated by Figure 8.4 in the GEIS,  
6    geothermal power plants are most likely to be sited in the western continental U.S., Alaska, and  
7    Hawaii where geothermal reservoirs are prevalent. A study commissioned by NYSERDA and  
8    the DOE, completed in 1996, found that there is some potential for geothermal electric power  
9    production in western upstate New York but that high cost inhibits its development (NRC 2006).  
10   Therefore, the NRC staff concludes that geothermal energy is not a feasible alternative to  
11   renewal of the JAFNPP OL.

12   8.2.5.6 *Wood Waste*

13   The use of wood waste to generate electricity is limited largely to states with significant wood  
14   resources, such as California, Georgia, Maine, Michigan, Minnesota, Oregon, and Washington.  
15   Electric power is generated in these states by the pulp, paper, and paperboard industries, which  
16   consume wood and wood waste for energy, benefiting from the use of waste materials that  
17   would otherwise represent a disposal problem.

18   The NRC staff states in the GEIS that a wood-burning facility can provide baseload power and  
19   operate with an average annual capacity factor of around 70 to 80 percent and with 20 to  
20   25 percent efficiency. The required fuels are variable and site-specific. A significant barrier to  
21   using wood waste to generate electricity is the high delivered-fuel cost and high construction  
22   cost per MW of generating capacity. The larger wood-waste power plants generate only 40 to  
23   50 MWe. The overall construction impact per MW of installed capacity is estimated in the GEIS  
24   to be approximately the same as that for a coal-fired power plant, although facilities using wood  
25   waste for fuel would be built on smaller scales. Like coal-fired power plants, wood-waste power  
26   plants require large areas for fuel storage and processing and involve the same type of  
27   combustion equipment.

28   Due to uncertainties associated with obtaining sufficient wood and wood waste to fuel a  
29   baseload generating facility, ecological impacts of large-scale timber cutting (e.g., soil erosion,  
30   loss of wildlife habitat), and high inefficiency, the NRC staff has determined that wood waste is  
31   not a feasible alternative to renewing the JAFNPP OL.

32   8.2.5.7 *Municipal Solid Waste*

33   Municipal waste combustors incinerate waste and use the resultant heat to generate steam, hot  
34   water, or electricity. The combustion process can reduce the volume of waste by up to  
35   90 percent and the weight of the waste by up to 75 percent (EPA 2006). Municipal waste  
36   combustors use three basic types of technologies: mass burn, modular, and refuse-derived fuel  
37   (DOE/EIA 2001). Mass burning technologies are most commonly used in the U.S. This group

1 of technologies process raw municipal solid waste “as is,” with little or no sizing, shredding, or  
2 separation before combustion.

3 Growth in the municipal waste combustion industry slowed dramatically during the 1990s after  
4 rapid growth during the 1980s. The slower growth was due to three primary factors: (1) the Tax  
5 Reform Act of 1986, which made capital-intensive projects such as municipal waste combustion  
6 facilities more expensive relative to less capital-intensive waste disposal alternative such as  
7 landfills; (2) the 1994 Supreme Court decision *C&A Carbone, Inc. v. Town of Clarkstown, New*  
8 *York*, 511 U.S. 383, which struck down local flow control ordinances that required waste to be  
9 delivered to specific municipal waste combustion facilities rather than landfills that may have  
10 had lower fees; and (3) increasingly stringent environmental regulations that increased the  
11 capital cost necessary to construct and maintain municipal waste combustion facilities  
12 (DOE/EIA 2001).

13 The decision to burn municipal waste to generate energy is usually driven by the need for an  
14 alternative to landfills rather than by energy considerations. The use of landfills as a waste  
15 disposal option is likely to increase in the near term, but it is unlikely that many landfills will  
16 begin converting waste to energy because of unfavorable economics, particularly with electricity  
17 prices declining in real terms.

18 Municipal solid waste combustors generate an ash residue that is buried in landfills. The ash  
19 residue is composed of bottom ash and fly ash. Bottom ash is the portion of unburned waste  
20 that falls to the bottom of the grate or furnace. Fly ash is the small particles that rise from the  
21 furnace during combustion. Fly ash is generally removed from flue-gases using fabric filters  
22 and/or scrubbers (DOE/EIA 2001).

23 Currently there are approximately 89 waste-to-energy power plants operating in the U.S. These  
24 power plants generate approximately 2800 MWe or an average of 31.5 MWe per power plant  
25 (IWSA 2006), which is much smaller than needed to replace the 881 MWe of JAFNPP.

26 The NRC staff states in the GEIS that the initial capital costs for municipal solid-waste power  
27 plants are greater than for comparable steam-turbine technology at wood-waste facilities, due to  
28 the need for specialized waste-separation and -handling equipment for municipal solid waste.  
29 Furthermore, the overall construction impact from a waste-fired power plant is estimated in the  
30 GEIS to be approximately the same as that for a coal-fired power plant. Additionally, waste-  
31 fired power plants have the same or greater operational impacts (including impacts on the  
32 aquatic environment, air, and waste disposal). Some of these impacts would be MODERATE  
33 but still larger than the environmental effects of license renewal of JAFNPP. Therefore,  
34 municipal solid waste would not be a feasible alternative to renewal of the JAFNPP OL,  
35 particularly at the scale required.

1 *8.2.5.8 Other Biomass-Derived Fuels*

2 In addition to wood and municipal solid-waste fuels, there are several other concepts for fueling  
3 electric generators, including burning crops, converting crops to a liquid fuel such as ethanol,  
4 and gasifying crops (including wood waste). In the GEIS, the NRC staff points out that none of  
5 these technologies has progressed to the point of being competitive on a large scale or of being  
6 reliable enough to replace a baseload power plant such as JAFNPP. For these reasons, such  
7 fuels do not offer a feasible alternative to renewal of the JAFNPP OL.

8 *8.2.5.9 Fuel Cells*

9 Fuel cells work without combustion and therefore do not have the environmental impacts of  
10 combustion. Power is produced electrochemically by passing a hydrogen-rich fuel over an  
11 anode and air over a cathode and separating the two by an electrolyte. The only by-products  
12 are heat, water, and carbon dioxide. Hydrogen fuel can come from a variety of hydrocarbon  
13 resources by subjecting them to steam under pressure. Natural gas is typically used as the  
14 source of hydrogen.

15 Phosphoric acid fuel cells are generally considered first-generation technology. These fuel cells  
16 are commercially available at approximately \$4500 per kW of installed capacity (DOE 2006).  
17 Higher-temperature second-generation fuel cells achieve higher fuel-to-electricity and thermal  
18 efficiencies. The higher temperatures contribute to improved efficiencies and give the second-  
19 generation fuel cells the capability to generate steam for cogeneration and combined-cycle  
20 operations.

21 DOE has launched a major initiative, the Solid State Energy Conversion Alliance, to bring about  
22 dramatic reductions in fuel cell costs. The goal is to cut the cost to as low as \$400 per kW by  
23 2010, which would make fuel cells competitive for virtually every type of power application (DOE  
24 2006). For comparison, the installed capacity cost for a natural gas-fired, combined-cycle  
25 power plant is about \$400 per kW (DOE 2006). At present, fuel cells are not economically or  
26 technologically competitive with other alternatives for baseload electricity generation and are  
27 consequently not a feasible alternative to renewal of the JAFNPP OL.

28 *8.2.5.10 Delayed Retirement*

29 As noted in the GEIS, extending the lives of existing non-nuclear generating power plants  
30 beyond the time they were originally scheduled to be retired represents another potential  
31 alternative to license renewal. Even without retiring any generating units, Entergy expects to  
32 require additional capacity in the near future. Thus, even if substantial capacity were scheduled  
33 for retirement and would be delayed, some of the delayed retirement would be needed just to  
34 meet load growth.

35 Older power plants that may be candidates for retirement tend to use less efficient generation  
36 and pollution control technologies than modern power plants. Therefore, substantial upgrades

1 are typically required to achieve efficiencies necessary to cost effectively extend operations and  
 2 meet applicable environmental standards.

3 The GEIS states that NYISO load and capacity projections assume that nuclear generating units  
 4 in the State will cease operation upon expiration of their current OLs but do not acknowledge  
 5 retirement of any non-nuclear generating units in the State from 2005 through 2021. Therefore,  
 6 any such retirements that do occur in this period would merely act to further increase projected  
 7 demand.

8 Based on this information, the NRC staff concluded that delayed retirement of other Entergy  
 9 generating units would not be a feasible alternative to renewal of the JAFNPP OL.

10 *8.2.5.11 Utility-Sponsored Conservation*

11 The utility-sponsored conservation alternative refers to a situation in which JAFNPP ceases to  
 12 operate, no new generation is brought online to meet the lost generation, and the lost  
 13 generation is replaced by more efficient use of electricity. More efficient use would arise from  
 14 utility-sponsored conservation programs, potentially including energy audits, incentives to install  
 15 energy-efficient equipment, and informational programs to inform electricity consumers of the  
 16 benefits of, and possibilities for, electricity conservation.

17 Demand-side management resource strategies aimed at increasing energy efficiency on the  
 18 customer side of the electric meter generally fall under the following categories:

- 19 • Energy efficiency-selecting equipment that performs the same work with less energy input
- 20 • Load response-customers who agree to respond to utility requests to reduce use during  
 21 times of utility peak demand
- 22 • Load management, which encourages customers to reduce their usage during peak times  
 23 of day and peak season through the use of time-of-use rates, seasonal rates, and  
 24 interruptible contracts
- 25 • Direct load control, in which a utility interrupts power supply to customer equipment

26 Typically, demand-side management induced load reductions are acknowledged in load  
 27 forecasts and cannot therefore be used as credits to offset the power generated by JAFNPP.  
 28 As a practical matter, it would be impossible to increase the energy savings by an additional  
 29 881 MWe to replace the JAFNPP generating capability, particularly in upstate New York, which  
 30 represents a relatively small fraction of electrical load in the State.

31 Therefore, the NRC staff does not consider energy efficiency, by itself, a feasible alternative to  
 32 license renewal. However, the NRC staff recognizes that energy conservation is promoted and  
 33 that increases in energy efficiency occur as a normal result of replacing older equipment with

1 modern equipment. It is reasonable to include conservation in a combination of generation  
2 sources that would replace JAFNPP. Combined alternatives are discussed in Section 8.2.6.

### 3 **8.2.6 Combination of Alternatives**

4 Even though individual alternatives to JAFNPP might not be sufficient on their own to replace  
5 JAFNPP capacity due to the small size of the resource or lack of cost-effective opportunities, it  
6 is conceivable that a combination of alternatives might be cost-effective.

7 There are many possible combinations of alternatives. As discussed previously, these  
8 combinations would include baseload gas-fired or coal-fired power plants, purchased power,  
9 alternative and renewable technologies, and conservation. For the purpose of this discussion,  
10 one combination of alternatives has been assumed: 600 MWe of generation from a combined-  
11 cycle facility at the JAFNPP site, 81 MWe of energy conservation, and 200 MWe purchased  
12 from other generators. The impacts of other combinations, such as those from combinations  
13 that include wind or solar power, would be different and possibly less than the assumed  
14 combination. In some areas, such as the aesthetic impact of solar panel or wind turbines, the  
15 impacts would be at least as large as the impact of the assumed combination of alternatives. In  
16 other areas, such as waste, impacts would be smaller for these alternative technologies.

17 Table 8-8 contains a summary of the environmental impacts of an assumed combination. The  
18 impacts associated with the combined-cycle natural gas-fired units are based on the gas-fired  
19 generation impact assumptions discussed in Section 8.2.2, adjusted for the reduced generation  
20 capacity. While the demand-side management measures would have few environmental  
21 impacts, operation of the new natural gas-fired power plant would result in increased emissions  
22 and environmental impacts. The environmental impacts associated with power purchased from  
23 other generators would still occur but would be located elsewhere within the region or nation, as  
24 discussed in Section 8.2.4. The impacts of purchased power are not shown in Table 8-8. The  
25 NRC staff concludes that it is very unlikely that the environmental impacts of any reasonable  
26 combination of generating and conservation options would be reduced to the level of impacts  
27 associated with renewal of the JAFNPP OL.

### 28 **8.3 Summary of Alternatives Considered**

29 As indicated in Chapter 4 of this draft SEIS, the environmental impacts of the proposed action,  
30 license renewal of JAFNPP, are SMALL for all impact categories (except collective offsite  
31 radiological impacts from the fuel cycle and from high-level waste and spent fuel disposal, for  
32 which a single significance level was not assigned). The alternative actions, i.e., no-action  
33 alternative (discussed in Section 8.1), new generation alternatives (from coal, natural gas, and  
34 nuclear discussed in Sections 8.2.1 through 8.2.3, respectively), purchased electrical power  
35 (discussed in Section 8.2.4), alternative technologies (discussed in Section 8.2.5), and the  
36 combination of alternatives (discussed in Section 8.2.6) were considered.



1 **Table 8-8.** Summary of Environmental Impacts of an Assumed Combination of Generation—  
 2 Does Not Include Impacts from Purchased Generation Once-Through Cooling Alternative

Impact Category	JAFNPP Site		Alternate Site	
	Impact	Comments	Impact	Comments
Land Use	SMALL to MODERATE	The natural gas-fired power plant would be constructed on undeveloped portions of the JAFNPP site. It would require upwards of 110 ac for power block, offices, roads, parking areas, and a gas pipeline ROW. It would use existing infrastructure, minimizing new land requirements. There would be additional land impacts for construction of an underground gas pipeline.	SMALL to LARGE	Land-use requirements would be larger at an alternate site than at the JAFNPP site because of the need for additional infrastructure such as transmission facilities, roads, parking areas, office buildings, and cooling system. The total impact would depend on whether the alternate site had been previously disturbed.
Ecology	SMALL to MODERATE	The natural gas-fired alternative would use undeveloped areas at the JAFNPP site. There would be potential for significant habitat loss and fragmentation and reduced productivity and biological diversity.	SMALL to LARGE	Impacts would depend on whether the alternate site had been previously developed. Factors to consider include location and ecology of the site and transmission line route. In total, impacts would include habitat degradation, fragmentation or loss as a result of construction activities and conversion of land to industrial use. Ecological communities might experience reduced productivity and biological diversity from disturbing previously intact land.

**Table 8-8 (cont.)**

Impact Category	JAFNPP Site		Alternate Site	
	Impact	Comments	Impact	Comments
Water Use and Quality— Surface Water	SMALL	Combined-cycle units have lower water requirements than nuclear and coal-fired power plants. The natural gas-fired alternative would use existing once-through cooling system to the degree necessary.	SMALL to MODERATE	Combined-cycle units have lower water requirements than nuclear and coal-fired power plants. The natural gas-fired alternative would use closed-cycle cooling to the degree necessary. Total impacts would depend on the volume of water withdrawal, the constituents of the discharge water, the characteristics of the surface water or groundwater source, and the required new intake structures.
Water Use and Quality— Groundwater	SMALL	Use of groundwater is very unlikely.	SMALL to MODERATE	Impact depends on volume of water withdrawal and discharge.
Air Quality	MODERATE	<ul style="list-style-type: none"> <li>• Sulfur oxides: 34 tons/yr</li> <li>• Nitrogen oxides: 109 tons/yr</li> <li>• Carbon monoxide: 7 tons/yr</li> <li>• PM<sub>10</sub> particulates: 126 tons/yr</li> <li>• Other: (1) hazardous air pollutants, including arsenic, formaldehyde, and nickel and (2) carbon dioxide emissions, which contribute to global warming.</li> </ul>	MODERATE	The impacts at an unnamed alternate site would be the same as those for the JAFNPP site.

**Table 8-8** (cont.)

Impact Category	JAFNPP Site		Alternate Site	
	Impact	Comments	Impact	Comments
Waste	SMALL	Minimal waste product from fuel combination.	SMALL	The impacts at an unnamed alternate site would be the same as those for the JAFNPP site.
Human Health	SMALL	Impacts would be minor.	SMALL	The impacts at an unnamed alternate site would be the same as those for the JAFNPP site.
Socioeconomics	SMALL to MODERATE	<p>During power plant construction, impacts would be MODERATE. Construction activities would place noticeable burdens on existing infrastructure, including housing and transportation.</p> <p>During plant operations, employment would decrease from 716 permanent workers to approximately 50. Impacts on housing and vitality of the local economy would be negative. Overall, socioeconomic impacts from operation would be SMALL.</p>	SMALL to LARGE	Construction and operation impacts at an alternate site would be similar to those at the JAFNPP site. Socioeconomic impacts to the local community would depend on the location of the alternate site and would vary from SMALL to MODERATE.
Transportation	MODERATE	Construction-related transportation impacts would be MODERATE.	MODERATE	Transportation impacts of the natural gas-fired alternative at an alternate site would be similar to those at the JAFNPP site.

1

**Table 8-8 (cont.)**

Impact Category	JAFNPP Site		Alternate Site	
	Impact	Comments	Impact	Comments
Aesthetics	SMALL	There would be visual aesthetic impacts associated with power plant buildings and structures. There would be both continuous and intermittent noise impacts from power plant operation.	MODERATE to LARGE	Visual aesthetic impacts would be similar to the JAFNPP site, but the significance of the impacts would depend on the location of the alternate site. The natural gas-fired power plant at an alternate site could require transmission lines, with attendant aesthetic impacts.
Historic and Archeological Resources	SMALL to MODERATE	Cultural resource studies would be needed to identify, evaluate, and address the mitigation of potential cultural resource impacts from the construction of a new power plant.	SMALL to MODERATE	The historic and archaeological resource impacts of the natural gas-fired power plant at an alternate site would be similar to those at the JAFNPP site.
Environmental Justice	SMALL to MODERATE	Impacts to minority and low-income populations would vary depending on the location of the power plant site and other support facilities.	SMALL to MODERATE	The impacts at an alternate site would be the same as those for the JAFNPP site.

2

3 The no-action alternative would require the replacement of electrical generating capacity by  
 4 (1) demand-side management and energy conservation, (2) power purchased from other  
 5 electricity providers, (3) generating alternatives other than JAFNPP, or (4) some combination of  
 6 these options. For each of the new generation alternatives (coal, natural gas, and nuclear), the  
 7 environmental impacts would not be less than the impacts of license renewal. For example, the  
 8 land-disturbance impacts resulting from construction of any new facility would be greater than  
 9 the impacts of continued operation of JAFNPP. The impacts of purchased electrical power  
 10 (imported power) would still occur but would occur elsewhere. Alternative technologies are not  
 11 considered feasible at this time for complete power replacement, and it is very unlikely that the  
 12 environmental impacts of any reasonable combination of generation and conservation options  
 13 would be reduced to the level of impacts associated with renewal of the JAFNPP OL.

1 The NRC staff concludes that the alternative actions, including the no-action alternative, may  
2 have environmental effects in at least some of the impact categories that would reach  
3 MODERATE or LARGE significance.

#### 4 **8.4 References**

5 10 CFR Part 50. *Code of Federal Regulations*, Title 10, *Energy*, Part 50, “Domestic Licensing of  
6 Production and Utilization Facilities.”

7 10 CFR Part 51. *Code of Federal Regulations*, Title 10, *Energy*, Part 51, “Environmental  
8 Protection Regulations for Domestic Licensing and Related Functions.”

9 10 CFR Part 52. *Code of Federal Regulations*, Title 10, *Energy*, Part 52, “Early Site Permits;  
10 Standard Design Certifications; and Combined Licenses for Nuclear Power Plants.”

11 40 CFR Part 51. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 51,  
12 “Requirements for Preparation, Adoption, and Submittal of Implementation Plans.”

13 40 CFR Part 60. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 60,  
14 “Standards of Performance for New Stationary Sources.”

15 American Wind Energy Association (AWEA). 2006. New York State Wind Energy  
16 Development. Available URL: <http://www.awea.org/projects/newyork.html>. (Accessed  
17 December 28, 2006.)

18 *C&A Carbone, Inc. v. Town of Clarkstown, New York*. 511 U.S. 383. 1994. *U.S. Supreme*  
19 *Court Reports*.

20 Clean Air Act of 1970. 42 USC 7401, et seq.

21 Clean Water Act of 1977. Federal Water Pollution Control Act of 1977. 33 USC 1251, et seq.

22 Elliott, D.L., C.G. Holladay, W.R. Barchet, H.P. Foote, and W.F. Sandusky. 1986. *Wind Energy*  
23 *Resource Atlas of the United States*. DOE/CH 10093-4, U.S. Department of Energy,  
24 Washington, D.C. Available URL: <http://rredc.nrel.gov/wind/pubs/atlas> (accessed December 28,  
25 2006).

26 Entergy Nuclear FitzPatrick, LLC, and Entergy Nuclear Operations, Inc. (Entergy). 2006.  
27 *James A. FitzPatrick Nuclear Power Plant — License Renewal Application, Appendix E:*  
28 *Applicant’s Environmental Report, Operating License Renewal Stage*. Lycoming, New York.  
29 Accessible at ML062160557.

## Environmental Impacts of Alternatives

- 1 Gabbard, A. 1993. "Coal Combustion: Nuclear Resource or Danger." *Oak Ridge National*  
2 *Laboratory Review*. Oak Ridge National Laboratory: Oak Ridge, Tennessee. Available URL:  
3 <http://www.ornl.gov/info/ornlreview/rev26-34/text/colmain.html> (accessed October 18, 2004.)
- 4 Integrated Waste Services Association (IWSA). 2006. "America's Own Energy Source."  
5 Available URL: <http://www.wte.org/aoes.shtml> (accessed December 28, 2006.) Accessible at  
6 ML071130360.
- 7 National Environmental Policy Act of 1969 (NEPA). 42 USC 4321, et seq.
- 8 New York State Energy Research and Development Authority (NYSERDA). 2002. *2002 State*  
9 *Energy Plan and Final Environmental Impact Statement*. Available URL: [http://www.nyserdera](http://www.nyserdera.org/sep.html)  
10 [.org/sep.html](http://www.nyserdera.org/sep.html) (accessed October 18, 2004.)
- 11 Northwest Power Planning Council (NWPPC). 2000. "Northwest Power Supply  
12 Adequacy/Reliability Study Phase I Report." Available URL: [http://www.nwcouncil.org/library/](http://www.nwcouncil.org/library/2000/2000-4.pdf)  
13 [2000/2000-4.pdf](http://www.nwcouncil.org/library/2000/2000-4.pdf) (accessed December 28, 2006.)
- 14 Resource Conservation and Recovery Act of 1976. 42 USC 6901, et seq.
- 15 Rivers and Harbors Appropriation Act of 1899. 33 USC 403, et seq.
- 16 U.S. Department of Energy (DOE). 2005. "U.S. Wind Energy Resource Potential Map."  
17 Available URL: [http://www1.eere.energy.gov/windandhydro/wind\\_potential.html](http://www1.eere.energy.gov/windandhydro/wind_potential.html) (accessed  
18 December 28, 2006.) Accessible at ML071130366.
- 19 U.S. Department of Energy (DOE). 2006. "Future Fuel Cells R&D." Available URL:  
20 <http://www.fossil.energy.gov/programs/powersystems/fuelcells> (accessed December 28, 2006.)
- 21 U.S. Department of Energy, Energy Information Administration (DOE/EIA). 2001. *Renewable*  
22 *Energy 2000: Issues and Trends*. DOE/EIA-0628 (2000). Washington, D.C. Available URL:  
23 <http://tonto.eia.doe.gov/ftproot/renewables/06282000.pdf> (accessed December 28, 2006.)
- 24 U.S. Department of Energy, Energy Information Administration (DOE/EIA). 2002. *International*  
25 *Energy Outlook 2002*. DOE/EIA-0484 (2002). Washington, D.C. Available URL:  
26 [http://www.eia.doe.gov/pub/pdf/international/0484\(2002\).pdf](http://www.eia.doe.gov/pub/pdf/international/0484(2002).pdf) (accessed December 28, 2006.)
- 27 U.S. Department of Energy, Energy Information Administration (DOE/EIA). 2004. *Annual*  
28 *Energy Outlook 2004 with Projections to 2025*. Washington, D.C.
- 29 U.S. Department of Energy/Energy Information Administration (DOE/EIA). 2007. *Annual*  
30 *Energy Outlook 2007 with Projections to 2030*. Washington, D.C., February, 2007. Available  
31 URL: <http://www.eia.doe.gov/oiarf/aeo/index.html> (accessed April 12, 2007).

- 1 U.S. Environmental Protection Agency (EPA). 1998. "Revision of Standards of Performance for  
2 Nitrogen Oxide Emissions From New Fossil-Fuel Fired Steam Generating Units; Revisions to  
3 Reporting Requirements for Standards of Performance for New Fossil-Fuel Fired Steam  
4 Generating Units, Final Rule." *Federal Register* Vol. 63, No. 179, pp. 49442-49455.  
5 Washington, D.C. (September 16, 1998.)
- 6 U.S. Environmental Protection Agency (EPA). 1999. "Regional Haze Regulations, Final Rule."  
7 *Federal Register* Vol. 64, No. 126, pp. 35714-35777. Washington, D.C. (July 1, 1999.)
- 8 U.S. Environmental Protection Agency (EPA). 2000a. "Notice of Regulatory Determination on  
9 Wastes From the Combustion of Fossil Fuels." *Federal Register*, Vol. 65, No. 99, pp. 32214-  
10 32237. Washington, D.C.
- 11 U.S. Environmental Protection Agency (EPA). 2000b. "Regulatory Finding on the Emissions of  
12 Hazardous Air Pollutants from Electric Utility Steam Generating Units." *Federal Register*.  
13 Vol. 65, No. 245, pp. 79825-79831. Washington, D.C. (December 20, 2000.)
- 14 U.S. Environmental Protection Agency (EPA). 2006. "Municipal Solid Waste Disposal."  
15 Available URL: <http://www.epa.gov/epaoswer/non-hw/muncpl/disposal.htm> (accessed  
16 December 28, 2006).
- 17 U.S. Nuclear Regulatory Commission (NRC). 1988. *Final Generic Impact Statement on  
18 Decommissioning of Nuclear Facilities*. NUREG-0586. Washington, D.C.
- 19 U.S. Nuclear Regulatory Commission (NRC). 1996. *Generic Environmental Impact Statement  
20 for License Renewal of Nuclear Plants*. NUREG-1437, Volumes 1 and 2. Washington, D.C.
- 21 U.S. Nuclear Regulatory Commission (NRC). 1999. *Final Generic Environmental Impact  
22 Statement for License Renewal of Nuclear Plants: Main Report*. NUREG-1437, Volume 1,  
23 Addendum 1. Washington, D.C.
- 24 U.S. Nuclear Regulatory Commission (NRC). 2002. *Generic Environmental Impact Statement  
25 on Decommissioning of Nuclear Facilities, Supplement 1, Regarding the Decommissioning of  
26 Nuclear Power Reactors*. NUREG-0586, Supplement 1, Volumes 1 and 2. Washington, D.C.





## 9.0 SUMMARY AND CONCLUSIONS

By letter dated July 31, 2006, Entergy Nuclear FitzPatrick, LLC, and Entergy Nuclear Operations, Inc. (Entergy) submitted an application to the U.S. Nuclear Regulatory Commission (NRC) to renew the operating license (OL) for James A. FitzPatrick Nuclear Power Plant (JAFNPP) for an additional 20-year period (Entergy 2006a). If the OL is renewed, State regulatory agencies and Entergy will ultimately decide whether the plant will continue to operate based on factors such as the need for power or other matters within the State's jurisdiction or the purview of the owners. If the OL is not renewed, then the plant must be shut down on or before the expiration of the current OL, which expires on October 17, 2014.

Section 102 of the National Environmental Policy Act (NEPA) (42 USC 4321) directs that an environmental impact statement (EIS) is required for major Federal actions that significantly affect the quality of the human environment. The NRC has implemented Section 102 of NEPA in Part 51 of Title 10 of the *Code of Federal Regulations* (10 CFR Part 51). Part 51 identifies licensing and regulatory actions that require an EIS. In 10 CFR 51.20(b)(2), the Commission requires preparation of an EIS or a supplement to an EIS for renewal of a reactor OL; 10 CFR 51.95(c) states that the EIS prepared at the OL renewal stage will be a supplement to the *Generic Environmental Impact Statement for License Renewal of Nuclear Plants* (GEIS), NUREG-1437, Volumes 1 and 2 (NRC 1996; 1999).<sup>(1)</sup>

Upon acceptance of the Entergy application, the NRC began the environmental review process described in 10 CFR Part 51 by publishing on September 20, 2006, a Notice of Intent to prepare an EIS and conduct scoping (NRC 2006a). The NRC staff held public scoping meetings on October 12, 2006, in Oswego, New York (NRC 2006b), and conducted a site audit in December 2006 (NRC 2007b). The NRC staff reviewed Entergy's environmental report (ER) for JAFNPP (Entergy 2006b) and compared it to the GEIS, consulted with other agencies, and conducted an independent review of the issues following the guidance set forth in NUREG-1555, Supplement 1, *Standard Review Plans for Environmental Reviews for Nuclear Power Plants, Supplement 1: Operating License Renewal* (NRC 2000). The NRC staff also considered the public comments received during the scoping process for preparation of this draft supplemental environmental impact statement (draft SEIS) for JAFNPP (NRC 2007a). The public comments received during the scoping process that were considered to be within the scope of the environmental review are provided in Appendix A of this draft SEIS.

The NRC staff will hold two public meetings in Oswego, New York, in August 2007, to describe the preliminary results of the NRC environmental review, to answer questions, and to provide members of the public with information to assist them in formulating their comments on this draft

---

(1) The GEIS was issued in 1996, and Addendum 1 to the GEIS was issued in 1999. Hereafter, all references to GEIS include Addendum 1.

## Summary and Conclusions

1 SEIS. When the comment period ends, the NRC staff will consider and address all of the  
2 comments received. These comments will be addressed in Appendix A of the final SEIS.

3 This draft SEIS includes the NRC staff's preliminary analysis that considers and weighs the  
4 environmental effects of the proposed action, including cumulative impacts, the environmental  
5 impacts of alternatives to the proposed action, and mitigation measures available for reducing or  
6 avoiding adverse effects. This draft SEIS also includes the NRC staff's preliminary  
7 recommendation regarding the proposed action.

8 The NRC has adopted the following statement of purpose and need for license renewal from the  
9 GEIS:

10 The purpose and need for the proposed action (renewal of an operating license) is to  
11 provide an option that allows for power generation capability beyond the term of a current  
12 nuclear power plant operating license to meet future system generating needs, as such  
13 needs may be determined by State, utility, and, where authorized, Federal (other than NRC)  
14 decision makers.

15 The evaluation criterion for the NRC staff's environmental review, as defined in 10 CFR  
16 51.95(c)(4) and the GEIS, is to determine

17 ... whether or not the adverse environmental impacts of license renewal are so great that  
18 preserving the option of license renewal for energy planning decision makers would be  
19 unreasonable.

20 Both the statement of purpose and need and the evaluation criterion implicitly acknowledge that  
21 there are factors, in addition to license renewal, that will ultimately determine whether an  
22 existing nuclear power plant continues to operate beyond the period of the current OL.

23 NRC regulations [10 CFR 51.95(c)(2)] contain the following statement regarding the content of  
24 SEISs prepared at the license renewal stage:

25 The supplemental environmental impact statement for license renewal is not required to  
26 include discussion of need for power or the economic costs and economic benefits of the  
27 proposed action or of alternatives to the proposed action except insofar as such benefits  
28 and costs are either essential for a determination regarding the inclusion of an alternative in  
29 the range of alternatives considered or relevant to mitigation. In addition, the supplemental  
30 environmental impact statement prepared at the license renewal stage need not discuss  
31 other issues not related to the environmental effects of the proposed action and the  
32 alternatives, or any aspect of the storage of spent fuel for the facility within the scope of the  
33 generic determination in § 51.23(a) and in accordance with § 51.23(b).

34 The GEIS contains the results of a systematic evaluation of the consequences of renewing an  
35 OL and operating a nuclear power plant for an additional 20 years. It evaluates

1 92 environmental issues using the NRC's three-level standard of significance—SMALL,  
2 MODERATE, or LARGE—developed using the Council on Environmental Quality guidelines.  
3 The following definitions of the three significance levels are set forth in the footnotes to  
4 Table B-1 of 10 CFR Part 51, Subpart A, Appendix B:

5 SMALL - Environmental effects are not detectable or are so minor that they will neither  
6 destabilize nor noticeably alter any important attribute of the resource.

7 MODERATE - Environmental effects are sufficient to alter noticeably, but not to destabilize,  
8 important attributes of the resource.

9 LARGE - Environmental effects are clearly noticeable and are sufficient to destabilize  
10 important attributes of the resource.

11 For 69 of the 92 issues considered in the GEIS, the NRC staff analysis in the GEIS shows the  
12 following:

13 (1) The environmental impacts associated with the issue have been determined to apply  
14 either to all plants or, for some issues, to plants having a specific type of cooling system  
15 or other specified plant or site characteristics.

16 (2) A single significance level (i.e., SMALL, MODERATE, or LARGE) has been assigned to  
17 the impacts (except for collective off-site radiological impacts from the fuel cycle and  
18 from high-level waste [HLW] and spent fuel disposal).

19 (3) Mitigation of adverse impacts associated with the issue has been considered in the  
20 analysis, and it has been determined that additional plant-specific mitigation measures  
21 are likely not to be sufficiently beneficial to warrant implementation.

22 These 69 issues were identified in the GEIS as Category 1 issues. In the absence of new and  
23 significant information, the NRC staff relied on conclusions in the GEIS for issues designated  
24 Category 1 in Table B-1 of 10 CFR Part 51, Subpart A, Appendix B. The NRC staff also  
25 determined that information provided during the public comment period did not identify any new  
26 issue that requires site-specific assessment.

27 Of the 23 issues that do not meet the criteria set forth above, 21 are classified as Category 2  
28 issues requiring analysis in a plant-specific supplement to the GEIS. The remaining two issues,  
29 environmental justice and chronic effects of electromagnetic fields, were not categorized.  
30 Environmental justice was not evaluated on a generic basis in the GEIS and must be addressed  
31 in the draft SEIS. Information on the chronic effects of electromagnetic fields was not  
32 conclusive at the time the GEIS was prepared.

33 This draft SEIS documents the NRC staff's consideration of all 92 environmental issues  
34 identified in the GEIS. The NRC staff considered the environmental impacts associated with

## Summary and Conclusions

1 alternatives to license renewal and compared the environmental impacts of license renewal and  
2 the alternatives. The alternatives to license renewal that were considered include the no-action  
3 alternative (not renewing the OL for JAFNPP) and alternative methods of power generation.  
4 These alternatives were evaluated assuming that the replacement power generation plant is  
5 located at either the JAFNPP site or some other unspecified location.

### 6 **9.1 Environmental Impacts of the Proposed Action-License Renewal**

7 Entergy and the NRC staff have established independent processes for identifying and  
8 evaluating the significance of any new information on the environmental impacts of license  
9 renewal. Neither Entergy nor the NRC staff has identified information that is both new and  
10 significant related to Category 1 issues that would call into question the conclusions in the  
11 GEIS. Similarly, neither the scoping process, Entergy, nor the NRC staff has identified any new  
12 issue applicable to JAFNPP that has a significant environmental impact. Therefore, the NRC  
13 staff relies upon the conclusions of the GEIS for all Category 1 issues that are applicable to  
14 JAFNPP.

15 Entergy's license renewal application presents an analysis of the Category 2 issues that are  
16 applicable to JAFNPP, plus environmental justice (Entergy 2006b). The NRC staff has  
17 reviewed the Entergy analysis for each issue and has conducted an independent review of each  
18 issue plus environmental justice. Six Category 2 issues are not applicable because they are  
19 related to plant design features or site characteristics not found at JAFNPP. Four Category 2  
20 issues are not discussed in this draft SEIS because they are specifically related to  
21 refurbishment. Entergy has stated that its evaluation of structures and components, as required  
22 by 10 CFR 54.21, did not identify any major plant refurbishment activities or modifications as  
23 necessary to support the continued operation of JAFNPP, for the license renewal period  
24 (Entergy 2006b). In addition, any replacement of components or additional inspection activities  
25 are within the bounds of normal plant component replacement and, therefore, are not expected  
26 to affect the environment outside of the bounds of the plant operations evaluated in the *Final*  
27 *Environmental Statement Related to Operation of James A. FitzPatrick Nuclear Power Plant*  
28 (AEC 1973).

29 Eleven Category 2 issues related to operational impacts and postulated accidents during the  
30 renewal term, as well as environmental justice and chronic effects of electromagnetic fields, are  
31 discussed in detail in this draft SEIS. Four of the Category 2 issues and environmental justice  
32 apply to both refurbishment and to operation during the renewal term and are only discussed in  
33 this draft SEIS in relation to operation during the renewal term. For all 11 Category 2 issues  
34 and environmental justice, the NRC staff concludes that the potential environmental effects are  
35 of SMALL significance in the context of the standards set forth in the GEIS. For severe accident  
36 mitigation alternatives (SAMAs), the NRC staff concludes that a reasonable, comprehensive  
37 effort was made to identify and evaluate SAMAs. Based on its review of the SAMAs for

1 JAFNPP, and the plant improvements already made, the NRC staff concludes that none of the  
2 candidate SAMAs are cost-beneficial.

3 Mitigation measures were considered for each Category 2 issue. Current measures to mitigate  
4 the environmental impacts of plant operation were found to be adequate, and no additional  
5 mitigation measures were deemed sufficiently beneficial to be warranted.

6 Cumulative impacts of past, present, and reasonably foreseeable future actions were  
7 considered, regardless of what agency (Federal or non-Federal) or person undertakes such  
8 other actions. For purposes of this analysis, where JAFNPP license renewal impacts are  
9 deemed to be SMALL, the NRC staff concluded that these impacts would not result in significant  
10 cumulative impacts on potentially affected resources.

11 The following sections discuss unavoidable adverse impacts, irreversible or irretrievable  
12 commitments of resources, and the relationship between local short-term use of the  
13 environment and long-term productivity.

#### 14 **9.1.1 Unavoidable Adverse Impacts**

15 An environmental review conducted at the license renewal stage differs from the review  
16 conducted in support of a construction permit because the plant is in existence at the license  
17 renewal stage and has operated for a number of years. As a result, adverse impacts associated  
18 with the initial construction have been avoided, have been mitigated, or have already occurred.  
19 The environmental impacts to be evaluated for license renewal are those associated with  
20 refurbishment and continued operation during the renewal term.

21 The adverse impacts of continued operation identified are considered to be of SMALL  
22 significance, and none warrants implementation of additional mitigation measures. The adverse  
23 impacts of likely alternatives if JAFNPP ceases operation at or before the expiration of the  
24 current OL will not be smaller than those associated with continued operation of this unit, and  
25 they may be greater for some impact categories in some locations.

#### 26 **9.1.2 Irreversible or Irretrievable Resource Commitments**

27 The commitment of resources related to construction and operation of the JAFNPP during the  
28 current license period was made when the plant was built. The resource commitments to be  
29 considered in this draft SEIS are associated with continued operation of the plant for an  
30 additional 20 years. These resources include materials and equipment required for plant  
31 maintenance and operation, the nuclear fuel used by the reactors, and ultimately, permanent  
32 offsite storage space for the spent fuel assemblies.

33 The most significant resource commitments related to operation during the renewal term are the  
34 fuel and the permanent storage space. JAFNPP replaces approximately one third of its fuel  
35 assemblies during routine refueling outages, typically every 24 months (Entergy 2006b).

## Summary and Conclusions

1 The likely power-generation alternatives if JAFNPP ceases operation on or before the expiration  
2 of the current OL will require a commitment of resources for construction of the replacement  
3 plants as well as for fuel to run the plants.

### 4 **9.1.3 Short-Term Use Versus Long-Term Productivity**

5 An initial balance between short-term use and long-term productivity of the environment at the  
6 JAFNPP site was set when the plant was approved and construction began. That balance is  
7 now well established. Renewal of the OL for JAFNPP and continued operation of the plant will  
8 not alter the existing balance but may postpone the availability of the site for other uses. Denial  
9 of the application to renew the OL will lead to shutdown of the plant and will alter the balance in  
10 a manner that depends on subsequent uses of the site. For example, the environmental  
11 consequences of turning the JAFNPP site into a park or an industrial facility are quite different.

## 12 **9.2 Relative Significance of the Environmental Impacts of License Renewal** 13 **and Alternatives**

14 The proposed action is renewal of the OL for JAFNPP. Chapter 2 describes the site, power  
15 plant, and interactions of the plant with the environment. As noted in Chapter 3, no  
16 refurbishment and no refurbishment impacts are expected at JAFNPP. Chapters 4 through 7  
17 discuss environmental issues associated with renewal of the OL. Environmental issues  
18 associated with the no-action alternative and alternatives involving power generation and use  
19 reduction are discussed in Chapter 8.

20 The significance of the environmental impacts from the proposed action (approval of the  
21 application for renewal of the OL), the no-action alternative (denial of the application),  
22 alternatives involving nuclear or gas- or coal-fired generation of power at the JAFNPP site and  
23 an unspecified "alternate site," and a combination of alternatives are compared in Table 9-1.  
24 Continued use of a closed-cycle cooling system for JAFNPP is assumed for Table 9-1.

25 Substitution of once-through cooling for the recirculating cooling system in the evaluation of the  
26 nuclear and gas- and coal-fired generation alternatives would result in somewhat greater  
27 environmental impacts in some impact categories.

28 Table 9-1 shows that the significance of the environmental effects of the proposed action is  
29 SMALL for all impact categories (except for collective offsite radiological impacts from the fuel  
30 cycle and from HLW and spent fuel disposal, for which a single significance level was not  
31 assigned [see Chapter 6]). The alternative actions, including the no-action alternative, may  
32 have environmental effects in at least some impact categories that reach MODERATE or  
33 LARGE significance.

**Table 9-1. Summary of Environmental Significance of License Renewal, the No-Action Alternative, and Alternative Methods of Power Generation**

Impact Category	Proposed Action	No-Action Alternative	Coal-Fired Generation		Natural-Gas-Fired Generation		New Nuclear Generation		Combination of Alternatives	
			Denial of Renewal	Alternate Site	JAFNPP site	Alternate Site	JAFNPP Site	Alternate Site	JAFNPP Site	Alternate Site
Land Use	SMALL	NO IMPACT	MODERATE to LARGE	SMALL to MODERATE	SMALL to MODERATE	SMALL	MODERATE to LARGE	SMALL to MODERATE	SMALL to MODERATE	SMALL to LARGE
Ecology	SMALL	SMALL	MODERATE to LARGE	SMALL to MODERATE	MODERATE to MODERATE	SMALL	MODERATE to LARGE	SMALL to MODERATE	SMALL to MODERATE	SMALL to LARGE
Water Use and Quality—Surface Water	SMALL	SMALL	SMALL to MODERATE	SMALL to MODERATE	SMALL	SMALL	SMALL to MODERATE	SMALL	SMALL	SMALL to MODERATE
Water Use and Quality—Groundwater	SMALL	SMALL	SMALL to MODERATE	SMALL to MODERATE	NO IMPACT	SMALL	SMALL to MODERATE	SMALL	SMALL	SMALL to MODERATE
Air Quality	SMALL	SMALL	MODERATE	MODERATE	MODERATE	SMALL	MODERATE	SMALL	MODERATE	MODERATE
Waste	SMALL	SMALL	MODERATE	MODERATE	SMALL	SMALL	SMALL	SMALL	SMALL	SMALL
Human Health	SMALL <sup>(a)</sup>	SMALL	SMALL	SMALL	SMALL	SMALL	SMALL	SMALL	SMALL	SMALL
Socioeconomics	SMALL	MODERATE to LARGE	SMALL to LARGE	SMALL to LARGE	SMALL to LARGE	SMALL to MODERATE	SMALL to LARGE	SMALL to MODERATE	SMALL to MODERATE	SMALL to LARGE
Transportation	SMALL	SMALL	SMALL to LARGE	MODERATE	MODERATE	SMALL to LARGE	SMALL to MODERATE	MODERATE	MODERATE	MODERATE
Aesthetics	SMALL	NO IMPACT	SMALL to LARGE	SMALL to LARGE	SMALL	SMALL to MODERATE	SMALL to LARGE	SMALL to MODERATE	SMALL	MODERATE to LARGE
Historic and Archaeological Resources	SMALL	SMALL	SMALL to MODERATE	SMALL to MODERATE	SMALL to MODERATE	SMALL to MODERATE	SMALL to MODERATE	SMALL to MODERATE	SMALL to MODERATE	SMALL to MODERATE
Environmental Justice	SMALL	SMALL to LARGE	SMALL to LARGE	SMALL to MODERATE	SMALL to MODERATE	SMALL to MODERATE	SMALL to MODERATE	SMALL to MODERATE	SMALL to MODERATE	SMALL to MODERATE

(a) Except for collective offsite radiological impacts from the fuel cycle and from HLW and spent-fuel disposal, for which a significance level was not assigned. See Chapter 6 for details.

1 **9.3 NRC Staff Conclusions and Recommendations**

2 Based on (1) the analysis and findings in the GEIS, (2) the ER submitted by Entergy (Entergy  
3 2006b), (3) consultation with Federal, State, and local agencies, (4) the NRC staff's own  
4 independent review, and (5) the NRC staff's consideration of public comments received, the  
5 preliminary recommendation of the NRC staff is that the Commission determine that the  
6 adverse environmental impacts of license renewal for JAFNPP are not so great that preserving  
7 the option of license renewal for energy planning decision makers would be unreasonable.

8 **9.4 References**

9 10 CFR Part 51. *Code of Federal Regulations*, Title 10, *Energy*, Part 51, "Environmental  
10 Protection Regulations for Domestic Licensing and Related Regulatory Functions."

11 10 CFR Part 54. *Code of Federal Regulations*, Title 10, *Energy*, Part 54, "Requirements for  
12 Renewal of Operating Licenses for Nuclear Power Plants."

13 Entergy Nuclear FitzPatrick, LLC, and Entergy Nuclear Operations, Inc. (Entergy). 2006a.  
14 *James A. FitzPatrick Nuclear Power Plant License Renewal Application*. Lycoming, New York.  
15 Accessible at ML062160494.

16 Entergy Nuclear FitzPatrick, LLC, and Entergy Nuclear Operations, Inc. (Entergy). 2006b.  
17 *James A. FitzPatrick Nuclear Power Plant — License Renewal Application, Appendix E:*  
18 *Applicant's Environmental Report, Operating License Renewal Stage*. Lycoming, New York.  
19 Accessible at ML062160557.

20 National Environmental Policy Act of 1969 (NEPA). 42 USC 4321, et seq.

21 U.S. Atomic Energy Commission (AEC). 1973. Final Environmental Statement Related to  
22 Operation of James A. FitzPatrick Nuclear Power Plant Power Authority of the State of New  
23 York. Docket No. 50-333. Washington, D.C. Accessible at ML062360088.

24 U.S. Nuclear Regulatory Commission (NRC). 1996. Generic Environmental Impact Statement  
25 for License Renewal of Nuclear Plants. NUREG-1437, Volumes 1 and 2, Washington, D.C.

26 U.S. Nuclear Regulatory Commission (NRC). 1999. Generic Environmental Impact Statement  
27 for License Renewal of Nuclear Plants Main Report, "Section 6.3 – Transportation, Table 9.1,  
28 Summary of findings on NEPA issues for license renewal of nuclear power plants, Final Report."  
29 NUREG-1437, Volume 1, Addendum 1. Office of Nuclear Regulatory Research, Washington,  
30 D.C.



- 1 U.S. Nuclear Regulatory Commission (NRC). 2000. Standard Review Plans for Environmental  
2 Reviews for Nuclear Power Plants, Supplement 1: Operating License Renewal. NUREG-1555,  
3 Supplement 1, Washington, D.C.
- 4 U.S. Nuclear Regulatory Commission (NRC). 2006a. "Notice of Acceptance for Docketing of  
5 the Application, Notice of Opportunity for Hearing and Notice of Intent to prepare an  
6 Environmental Impact Statement and Conduct Scoping Process of Facility Operating License  
7 No. DPR-59 for an Additional 20-Year Period, Entergy Nuclear Operations, Inc., James A.  
8 FitzPatrick Nuclear Power Plant." Federal Register: Vol. 71, No. 182, pp. 55032-55035.  
9 Washington, D.C.
- 10 U.S. Nuclear Regulatory Commission (NRC). 2006b. NRC press release announcing Public  
11 License Renewal Process and Environmental Scoping Meeting Associated with the Application  
12 to Renew the Operating License for JAFNPP. Accessible at ML062760465
- 13 U.S. Nuclear Regulatory Commission (NRC). 2007a. Letter to M. Kansler, Entergy. Subject:  
14 Environmental Scoping Summary Report. March 2, 2007. Accessible at ML070440393.
- 15 U.S. Nuclear Regulatory Commission (NRC). 2007b. *Environmental Scoping Summary Report*  
16 *Associated with the Staff's Review of the Application by Entergy for Renewal of the Operating*  
17 *License for JAFNPP*. Washington, D.C. Accessible at ML070440393.

18



## **Appendix A**

### **Comments Received on the Environmental Review**



1 **Appendix A:**  
2 **Comments Received on the Environmental Review**

3 On September 20, 2006, the U.S. Nuclear Regulatory Commission (NRC) published a Notice of  
4 Intent in the *Federal Register* (71 FR 55032) to notify the public of the NRC staff's intent to  
5 prepare a plant-specific supplement to the *Generic Environmental Impact Statement for License*  
6 *Renewal of Nuclear Plants* (GEIS), NUREG-1437, Volumes 1 and 2 (NRC 1996; 1999),<sup>(1)</sup>  
7 related to the renewal application for the James A. FitzPatrick Nuclear Power Plant (JAFNPP)  
8 operating license and to conduct scoping. The plant-specific supplement to the GEIS has been  
9 prepared in accordance with the National Environmental Policy Act (NEPA), Council on  
10 Environmental Quality (CEQ) guidance, and Title 10 of the *Code of Federal Regulations*, Part  
11 51 (10 CFR Part 51). As outlined by NEPA, the NRC initiated the scoping process with the  
12 issuance of the *Federal Register* Notice. The NRC invited the applicant; Federal, State, and  
13 local government agencies; Native American tribal organizations; local organizations; and  
14 individuals to participate in the scoping process by providing oral comments at the scheduled  
15 public meetings and/or submitting comments by November 14, 2006.

16 The scoping process included two public scoping meetings, which were held at the Town of  
17 Scriba Municipal Building in Oswego, New York, on October 12, 2006. The NRC issued press  
18 releases and distributed flyers locally. Approximately 14 members of the public attended the  
19 meetings. Both sessions began with NRC staff members providing a brief overview of the  
20 license renewal process. Following the NRC's prepared statements, the meetings were open  
21 for public comments. Three attendees provided either oral comments or written statements that  
22 were recorded and transcribed by a certified court reporter, and written comments were  
23 appended to the transcript. The transcripts of the meetings are an attachment to the meeting  
24 summary, which was issued on October 30, 2006 (meeting transcripts, ML063030195 and  
25 ML063030209; meeting summary, ML062980148). The documents are publicly available and  
26 can be found at the Agencywide Documents Access and Management System (ADAMS) at  
27 <http://adamswebsearch.nrc.gov/dologin.html> or through the NRC's Electronic Reading Room  
28 link at <http://www.nrc.gov>. Persons who do not have access to ADAMS or who encounter  
29 problems in accessing the documents located in ADAMS should contact the NRC's Public  
30 Document Room staff at 1-800-397-4209 or 301-415-4737, or by email at [pdr@nrc.gov](mailto:pdr@nrc.gov).

31 At the conclusion of the scoping period, the NRC staff reviewed the transcripts and all written  
32 material received and identified individual comments. Each set of comments from a given  
33 commenter was given a unique alpha identifier (Commenter ID letter), allowing each set of  
34 comments from a commenter to be traced back to the transcript, letter, or email in which the  
35 comments were submitted. Specific comments were numbered sequentially within each  
36 comment set. All of the comments received and the NRC staff responses are included in the  
37 JAFNPP Scoping Summary Report dated March 2, 2007 (ML070440393).

## Appendix A

1 Comments were consolidated and categorized according to the topic within the proposed  
2 supplement to the GEIS or according to the general topic if outside the scope of the GEIS.  
3 Comments with similar specific objectives were combined to capture the common essential  
4 issues that had been raised in the source comments. Once comments were grouped according  
5 to subject area, the NRC staff determined the appropriate action for the comment.

6 Table A-1 identifies the individuals who provided comments applicable to the environmental  
7 review and the Commenter ID associated with each person's set(s) of comments. The  
8 individuals are listed in the order in which they spoke at the public meeting, and in the  
9 alphabetical order for the comments received by letter. To maintain consistency with the  
10 Scoping Summary Report, the unique identifier used in that report for each set of comments is  
11 retained in this appendix. The Commenter ID is preceded by FNP, which stands for James A.  
12 FitzPatrick Nuclear Power Plant scoping. Accession numbers indicate the location of the written  
13 comments in ADAMS.

14 Specific comments were categorized and consolidated by topic. Comments with similar specific  
15 objectives were combined to capture the common essential issues raised by the commenters.  
16 The comments fall into one of the following general groups:

- 17 • Specific comments that address environmental issues within the purview of the NRC  
18 environmental regulations related to license renewal. These comments address  
19 Category 1 or Category 2 issues or issues that were not addressed in the GEIS. They  
20 also address alternatives and related Federal actions.
- 21 • General comments (1) in support of or opposed to nuclear power or license renewal or  
22 (2) on the renewal process, the NRC's regulations, and the regulatory process. These  
23 comments may or may not be specifically related to the JAFNPP license renewal  
24 application.
- 25 • Questions that do not provide new information.
- 26 • Specific comments that address issues that do not fall within or are specifically excluded  
27 from the purview of NRC environmental regulations related to license renewal. These  
28 comments typically address issues such as the need for power, emergency  
29 preparedness, security, current operational safety issues, and safety issues related to  
30 operation during the renewal period.

31 Comments applicable to this environmental review and the NRC staff's responses are  
32 summarized in this appendix. The parenthetical alpha-numeric identifier after each comment  
33 refers to the comment set (Commenter ID) and the comment number. This information, which  
34 was extracted from the JAFNPP Scoping Summary Report, is provided for the convenience of  
35 those interested in the scoping comments applicable to this environmental review. The  
36 comments that are general or outside the scope of the environmental review for JAFNPP are

1 not included here. More detail regarding the disposition of general or inapplicable comments  
 2 can be found in the summary report. The ADAMS accession number for the Scoping Summary  
 3 Report is ML070440393. This accession number is provided to facilitate access to the document  
 4 through the Public Electronic Reading Room (ADAMS) at <http://www.nrc.gov/reading-rm.html>.

5 Comments in this section are grouped into the following categories:

- 6 A.1.1 Aquatic Ecology
- 7 A.1.2 Socioeconomics
- 8 A.1.3 Postulated Accidents
- 9 A.1.4 Uranium Fuel Cycle and Waste Management

10

11 **Table A-1.** Individuals Providing Comments During Scoping Comment Period

Commenters' ID	Commenter	Affiliation (If stated)	Comment Source, ADAMS Accession Number <sup>(a)</sup>
FNP-A	Ed Putnam	Candidate, New York State Assembly	Afternoon Scoping Meeting
FNP-B	Tim Judson	Citizens Awareness Network (CAN)	Evening Scoping Meeting
FNP-C	Tom Dellwo	CAN	Evening Scoping Meeting
FNP-D	Joseph J. Heath	General Counsel, Onondaga Nation	Letter (ML063240283)
FNP-E	Christopher M. Hogan	Project Manager, New York State Department of Environmental Conservation	Letter (ML063240331)

(a) The afternoon and evening transcripts can be found under accession numbers ML063030195 and ML063030209, respectively.

## 12 **Comments Received During Scoping**

### 13 **A.1.1 Aquatic Ecology Issues**

14 **Comment:** [Environmental Report] Appendix E; Section 4.2: Entrainment of Fish and Shellfish  
 15 in Early Life Stages, and Section 4.3: Impingement of Fish and Shellfish Statements regarding  
 16 previous Departmental Best Technology Available (BTA) decisions for FitzPatrick are  
 17 overstated. While in 1996 and 2001 the Department determined that the high frequency/high  
 18 amplitude acoustic fish deterrent system (FDS) was BTA for reducing impingement, the  
 19 Department did not state that the FDS was BTA for reducing entrainment. In fact, the letter  
 20 Entergy used as a reference specifically states, "Moreover, the fish deterrent system has not  
 21 been evaluated as an entrainment mitigative device..." In addition, while the State Pollution  
 22 Discharge Elimination System (SPDES) Permit Fact Sheet that accompanied the 1996 and

## Appendix A

1 2001 SPDES permits discussed the *potential* benefit of the FDS for reducing alewife  
2 entrainment, it referenced the need for studies to determine the effectiveness of the FDS  
3 system on larval life stages of alewives. Requirements for these studies were made part of the  
4 SPDES permit, but Department records indicate that the study was never conducted.

5 Even if the study had been completed and the Department had made a BTA determination  
6 regarding entrainment, documented changes in the fish community in Lake Ontario (as  
7 described in Appendix E, Section 2.2.4 of the license renewal application) compel a review of  
8 previous determinations to determine if changes are warranted. To that end, Entergy is  
9 currently conducting biological sampling at FitzPatrick to determine the extent of current  
10 impacts. Data from this sampling will be included in a *Comprehensive Demonstration Study*  
11 that Entergy must submit to the Department in early 2008. A new BTA decision will be based, in  
12 part, on the *Comprehensive Demonstration Study*. Thus, conclusory statements that  
13 entrainment impacts do not warrant mitigation are premature. Decisions regarding the need for  
14 mitigation will be addressed via the SPDES permit process. (FNP-E-1)

15 **Comment:** [Environmental Report] Section 6.2 Mitigation. Entergy's contention that "the current  
16 permits, practices, and programs that mitigate the environmental impacts of plant operations are  
17 adequate (page 6-1)" are not necessarily accurate. For example, the decision regarding  
18 adequacy of mitigative measures for addressing impacts from impingement and entrainment will  
19 be addressed via the SPDES permit process. That permit process will address the adequacy of  
20 current practices and, if necessary, will result in requirements for additional measures to reduce  
21 impacts. In addition and as explained above, statements in Table 6-1 regarding past BTA  
22 determinations are overstated. (FNP-E-2)

23 **Comment:** Counter to statements contained in Section 4.2.6, Section 4.3.6, and Table 6-  
24 1, federal regulations do not require limiting the focus of mitigation requirements to impacts on  
25 fish *populations* (see 10 CFR 51.53(c) and 10 CFR 51.45(c)). In fact, the federal regulations  
26 dealing with impingement and entrainment at power plants focus on the reduction in the  
27 numbers of individual organisms (see 40 CFR 125-Subparts I and J). (FNP-E-3)

28 **Response:** *These comments are related to information regarding entrainment and impingement*  
29 *of fish and shellfish, as provided in the applicant's Environmental Report. Aquatic ecology will*  
30 *be discussed in Chapters 2 and 4 of the SEIS.*

### 31 A.1.2 Socioeconomic Issues

32 **Comment:** One of the economic factors which affects the retention of current industry in central  
33 New York and which also affects the attraction of new industry to this region is the provision of  
34 inexpensive, trustworthy, and accessible power. We need this company to be a player in this  
35 attempt to bolster the economy of central New York. The Oswego County Public Utility Service  
36 offers "low cost electrical energy" to new and expanding business in Oswego County, in the  
37 hope that it will inspire new jobs and retain existing jobs through the low-cost electricity provided



1 by Entergy at the FitzPatrick plant. This is a positive initiative, which has begun to be shared  
2 with the local economic community.

3 A similar form of utility incentive for domestic usage would be a welcome message to the  
4 residents of this region. It seems inconsistent that this community, which houses nuclear power  
5 plants, does not experience significant benefit from the presence. The economic downturn in  
6 this region is desperately in need of signs of recovery, and thus nuclear power industry has the  
7 capability of leading the way. (FNP-A-10)

8 **Response:** *The comments are related to the socioeconomic impacts specific to JAFNPP.*  
9 *Socioeconomic impacts such as taxes are Category 2 issues and will be addressed in Chapters*  
10 *2 and 4 of the SEIS.*

### 11 **A.1.3 Postulated Accidents**

12 **Comment:** The operation of nuclear power plants is not without the potential for accidents, with  
13 serious consequences for both short and long term health in surrounding communities.  
14 (FNP-D-3)

15 **Response:** *The GEIS evaluated severe accidents and design basis accidents, and concluded*  
16 *the impact was small. During the environmental review of JAFNPP, the NRC will determine*  
17 *whether there is any new and significant information bearing on the previous analyses in the*  
18 *GEIS. Section 5.1.2 of the plant-specific SEIS for JAFNPP will address this issue. In addition,*  
19 *alternatives to mitigate severe accidents must be considered on a plant-specific basis for all*  
20 *plants that have not previously considered such alternatives. The applicant provided a severe*  
21 *accident mitigation alternatives (SAMA) analysis as part of the license renewal application for*  
22 *JAFNPP. The NRC staff's review of the SAMA analysis will be discussed in Section 5.2 and*  
23 *Appendix G of the SEIS for JAFNPP.*

### 24 **A.1.4 Uranium Fuel Cycle and Waste Management Issues**

25 **Comment:** From start to finish, the production of nuclear energy is fraught with hazards. The  
26 mining and enrichment of uranium produces radioactive isotopes that contaminate and degrade  
27 the surrounding environment. (FNP-D-2)

28 **Comment:** Finally, creation of nuclear energy leads to the accumulation of extremely  
29 hazardous, radioactive material that persists in the environment for tens of thousands of years.  
30 Additionally, this process creates byproducts, which, in a worst-case scenario, could be  
31 obtained and used to create dangerous weapons. (FNP-D-4)

32 **Response:** *Environmental impacts associated with the uranium fuel cycle were addressed in*  
33 *the GEIS. The GEIS concluded those impacts including the off-site radiological impact of*

Appendix A

- 1 *storage, transportation, and disposal of spent fuel and other radioactive waste are Category 1*
- 2 *issues. The impact of these Category 1 issues was judged to be small in the GEIS. During the*
- 3 *environmental review of JAFNPP, the NRC determine whether there is any new and significant*
- 4 *information bearing on the previous analysis.*

## **Appendix B**

### **Contributors to the Supplement**



**Appendix B:**  
**Contributors to the Supplement**

1  
2  
3  
4  
5  
6  
7

The overall responsibility for the preparation of this supplement was assigned to the Office of Nuclear Reactor Regulation, U.S. Nuclear Regulatory Commission (NRC). The supplement was prepared by members of the Office of Nuclear Reactor Regulation with assistance from other NRC organizations, Lawrence Livermore National Laboratory, and Pacific Northwest National Laboratory.

Name	Affiliation	Function or Expertise
<b>NUCLEAR REGULATORY COMMISSION</b>		
Rani L. Franovich	Nuclear Reactor Regulation	Branch Chief
Jessie M. Muir	Nuclear Reactor Regulation	Project Manager, Nonradiological Waste
Samuel Hernandez	Nuclear Reactor Regulation	Backup Project Manager, Alternatives
Jeffrey Rikhoff	Nuclear Reactor Regulation	Socioeconomics, Cultural Resources, Environmental Justice
Richard Emch	Nuclear Reactor Regulation	Radiation Protection
Stephen Klementowicz	Nuclear Reactor Regulation	Radiation Protection
Jennifer A. Davis	Nuclear Reactor Regulation	Cultural Resources
Scott Werts	Nuclear Reactor Regulation	Hydrology, Air, Alternatives
Michael Masnik	Nuclear Reactor Regulation	Aquatic and Terrestrial Ecology
Sarah Lopas	Nuclear Reactor Regulation	Aquatic Ecology
Evan Keto	Nuclear Reactor Regulation	Terrestrial Ecology, Threatened and Endangered Species
Robert Palla	Nuclear Reactor Regulation	Severe Accident Mitigation Alternatives
<b>LAWRENCE LIVERMORE NATIONAL LABORATORY<sup>(a)</sup></b>		
Bruce McDowell		Team Leader
Lily Baldwin		Deputy Team Leader, Hydrology, Water Use and Quality
Hank Khan		Health Physics
Crystal Quinly		Land Use
Diana Burke		Lead Editor
Lisa Crawford		Socioeconomics, Alternatives
Frank Gouveia		Meteorology, Air Quality

Appendix B

<b>Name</b>	<b>Affiliation</b>	<b>Function or Expertise</b>
<b>PACIFIC NORTHWEST NATIONAL LABORATORY (b)</b>		
Steve Short		Severe Accident Mitigation Alternatives
Bruce Schmitt		Severe Accident Mitigation Alternatives
Fred Leverenz		Severe Accident Mitigation Alternatives

(a) Lawrence Livermore National Laboratory is operated for the U.S. Department of Energy by the University of California.

(b) Pacific Northwest National Laboratory is operated for the U.S. Department of Energy by Battelle.

## **Appendix C**

### **Chronology of NRC Staff Environmental Review Correspondence Related to Entergy Nuclear FitzPatrick, LLC, and Entergy Nuclear Operations, Inc., Application for License Renewal of James A. FitzPatrick Nuclear Power Plant**





1 **Appendix C:**  
2 **Chronology of NRC Staff Environmental Review Correspondence**  
3 **Related to Entergy Nuclear FitzPatrick, LLC, and Entergy Nuclear**  
4 **Operations, Inc., Application for License Renewal of**  
5 **James A. FitzPatrick Nuclear Power Plant**

6 This appendix contains a chronological listing of correspondence between the U.S. Nuclear  
7 Regulatory Commission (NRC) and Entergy Nuclear FitzPatrick, LLC, and Entergy Nuclear  
8 Operations, Inc. (Entergy) and other correspondence related to the NRC staff's environmental  
9 review, under Title 10 of the *Code of Federal Regulations*, Part 51 (10 CFR Part 51), of the  
10 Entergy application for renewal of the James A. FitzPatrick Nuclear Power Plant (JAFNPP)  
11 operating license. All documents, with the exception of those containing proprietary information,  
12 are publicly available at the NRC Public Document Room (PDR), located at One White Flint  
13 North, 11555 Rockville Pike, Rockville, Maryland, 20852, or from the NRC's Agencywide  
14 Documents Access and Management System (ADAMS). The ADAMS Public Electronic  
15 Reading Room is accessible at <http://adamswebsearch.nrc.gov/dologin.htm>. The ADAMS  
16 accession numbers for each document are included below. Persons who do not have access to  
17 ADAMS, or who encounter problems in accessing the documents located in ADAMS, should  
18 contact the NRC's PDR reference staff by telephone at 1-800-397-4209 or 301-415-4737, or by  
19 e-mail at [pdr@nrc.gov](mailto:pdr@nrc.gov).

20	July 27, 2006	Summary of meeting held on June 26, 2006, between NRC and
21		Entergy to discuss submittal of JAFNPP license renewal application.
22		(Accession No. ML062090176)
23	July 31, 2006	Letter from P. Dietrich, Entergy, submitting the application for renewal of
24		the operating license for the JAFNPP. (Accession No. ML062160491)
25	July 31, 2006	<i>James A. FitzPatrick Nuclear Power Plant — License Renewal</i>
26		<i>Application, Appendix E: Applicant's Environmental Report, Operating</i>
27		<i>License Renewal Stage.</i> (Accession No. ML062160557)
28	August 4, 2006	NRC press release announcing the availability of the license renewal
29		application for JAFNPP. (Accession No. ML062160240)
30	August 7, 2006	Letter to P. Dietrich, Entergy, Receipt and Availability of the License
31		Renewal Application for JAFNPP. (Accession No. ML062190106)

## Appendix C

1	August 11, 2006	<i>Federal Register</i> Notice of Receipt and Availability of Application for
2		Renewal of JAFNPP (Operating License No. DPR-59) for an Additional
3		20-Year Period (71 FR 55032). (Accession No. ML071000081)
4	September 7, 2006	Letter to M. Bennett, Penfield Library, regarding the maintenance of
5		reference material at the SUNY Oswego—Penfield Library, related to
6		the JAFNPP license renewal application. (Accession No.
7		ML062500286)
8	September 7, 2006	Letter to C. Ferlito, Oswego Public Library, regarding the maintenance
9		of reference material at the Oswego Public Library, related to the
10		JAFNPP license renewal application. (Accession No. ML062500247)
11	September 14, 2006	Determination of Acceptability and Sufficiency for Docketing, Proposed
12		Review Schedule, and Opportunity for a Hearing Regarding the
13		Application from Entergy Nuclear Operations, Inc., for the renewal of
14		the operating license for JAFNPP. (Accession No. ML062570127)
15	September 15, 2006	Letter to D. L. Kilma, Advisory Council on Historic Preservation
16		(AChP), the JAFNPP License Renewal Application Review.
17		(Accession No. ML062480229)
18	September 15, 2006	Letter to B. Castro, New York State Historic Preservation Office,
19		Request for Comments Concerning the JAFNPP License Renewal
20		Application Review. (Accession No. ML062480220)
21	September 15, 2006	Letter to L. Henry, Tuscarora Nation, Request for Comments
22		Concerning the JAFNPP License Renewal Application Review.
23		(Accession No. ML062480205)
24	September 15, 2006	Letter to W. Jacobs, Cayuga Nation, Request for Comments
25		Concerning the JAFNPP License Renewal Application Review.
26		(Accession No. ML062480069)
27	September 15, 2006	Letter to R. Halbritter, Oneida Indian Nation, Request for Comments
28		Concerning the JAFNPP License Renewal Application Review.
29		(Accession No. ML062480063)
30		

- 1 September 15, 2006 Letter to I. Powless, Jr., Onondaga Indian Nation, Request for  
2 Comments Concerning the JAFNPP License Renewal Application  
3 Review. (Accession No. ML062480057)
- 4 September 15, 2006 Letter to B. Snyder, Seneca Nation of Indians, Request for Comments  
5 Concerning the JAFNPP License Renewal Application Review.  
6 (Accession No. ML062480035)
- 7 September 15, 2006 Letter to J. Ransom, St. Regis Mohawk Tribe, Request for Comments  
8 Concerning the JAFNPP License Renewal Application Review.  
9 (Accession No. ML062480053)
- 10 September 15, 2006 Letter to R. Hill, Tonawanda Band of Senecans, Request for  
11 Comments Concerning the JAFNPP License Renewal Application  
12 Review. (Accession No. ML062480044)
- 13 September 19, 2006 Letter to M. Moriarty, U.S. Fish and Wildlife Service Northeast  
14 Regional Office, Request for List of Protected Species Within the Area  
15 Under Evaluation for the JAFNPP License Renewal Application  
16 Review. (Accession No. ML062630292)
- 17 September 20, 2006 Notice of Acceptance for Docketing of the Application, Notice of  
18 Opportunity for Hearing and Notice of Intent To Prepare an  
19 Environmental Impact Statement and Conduct Scoping Process for  
20 Facility Operating License No. DPR-59 for an Additional 20-Year  
21 Period, Entergy Nuclear Operations, Inc., James A. FitzPatrick Nuclear  
22 Power Plant (71 FR 55032). (Accession No. ML071000085)
- 23 September 20, 2006 NRC press release announcing the opportunity to request a hearing on  
24 application to renew operating license for JAFNPP. (Accession No.  
25 ML062630056)
- 26 September 25, 2006 Meeting Notice, Forthcoming Meeting to Discuss the License Renewal  
27 Process and Environmental Scoping for JAFNPP License Renewal  
28 Application Review. (Accession No. ML062680355)
- 29 September 26, 2006 Notice of Intent to Prepare an Environmental Impact Statement and  
30 Conduct Scoping Process for License Renewal for JAFNPP.  
31 (Accession No. ML062480235)

32

## Appendix C

1	October 3, 2006	NRC press release announcing Public License Renewal Process and
2		Environmental Scoping Meeting Associated with the Application to
3		Renew the Operating License for JAFNPP. (Accession No.
4		ML062760465)
5	October 3, 2006	Transcripts of the Proceedings of the JAFNPP Public Scoping
6		Meetings. (Accession Nos. ML063030195 [afternoon], ML063030209
7		[evening])
8	October 30, 2006	Summary of Public Environmental Scoping Meetings Related to the
9		Review of the JAFNPP License Renewal Application. (Accession No.
10		ML062980148)
11	November 7, 2006	Letter to K. Lynch, New York State Department of Environmental
12		Conservation (NYSDEC) Region 7, Request for List of State Protected
13		Species Within the Area Under Evaluation for the JAFNPP License
14		Renewal Application Review. (Accession No. ML062960276)
15	November 7, 2006	Letter to P. Dietrich, Entergy, Request for Additional Information
16		Regarding the Review of the License Renewal Application for
17		JAFNPP. (Accession No. ML062850382)
18	November 13, 2006	Letter from J. Heath, General Council for the Onondaga Nation,
19		concerning the JAFNPP license renewal application. (Accession No.
20		ML063240283)
21	November 14, 2006	Letter from C. Hogan, NYSDEC, in response to request for comments
22		on the JANFPP License Renewal Environmental Report. (Accession
23		No. ML 063240331)
24	November 27, 2006	Letter to M. Kansler, Entergy, Environmental Site Audit Regarding the
25		JAFNPP License Renewal Application. (Accession No. ML063250406)
26	November 29, 2006	Letter to M. Kansler, Entergy, Request for Additional Information
27		Regarding Severe Accident Mitigation Alternatives for JAFNPP.
28		(Accession No. ML063060257)
29		

1 November 30, 2006 Letter from T. Seoane, NYDEC Natural Heritage Program, Report on  
2 Rare or State-Listed Animals, Significant Natural Communities, and  
3 Other Habitats in Regards to the JAFNPP License Renewal  
4 Application Review. (Not publicly available)

5 December 6, 2006 Letter from P. Dietrich, Entergy, JAFNPP License Renewal  
6 Application, Amendment 1. (Accession No. ML063480585)

7 December 6, 2006 JAFNPP License Renewal Application Amendment 1 Attachments.  
8 (Accession No. ML063480596)

9 December 7, 2006 Letter from A. Wonderley, Oneida Indian Nation, in response to  
10 JAFNPP Environmental Review of License Renewal Application.  
11 (Accession No. ML063480314)

12 January 8, 2007 Letter to M. Kansler, Entergy, Environmental Project Manager and  
13 Schedule Change for the License Renewal Environmental Review of  
14 JAFNPP. (Accession No. ML063550121)

15 January 26, 2007 Summary of Site Audit Related to the Review of the License Renewal  
16 Application for JAFNPP. (Accession No. ML070220055)

17 January 29, 2007 Letter from P. Dietrich, Entergy, License Renewal Application  
18 Amendment 4 Concerning SAMA Request of Additional Information.  
19 (Accession No. ML070370170)

20 March 2, 2007 Letter to M. Kansler, Entergy, Environmental Scoping Summary Report  
21 (Accession No. ML070440393)

22 March 7, 2007 Letter to E Alkiewicz, NYPA, Information Regarding Transmission Line  
23 Corridor Inspection for the JAFNPP License Renewal Application  
24 Review. (Accession No. ML070400200)

25 May 21, 2007 Letter to M. Moriarty, USFWS, regarding the Biological Assessment for  
26 Proposed License Renewal of James A. FitzPatrick Nuclear Power  
27 Plant. (Accession No. ML071310069)



## **Appendix D**

### **Organizations Contacted**





1 **Appendix D:**  
2 **Organizations Contacted**

3 During the course of the U.S. Nuclear Regulatory Commission staff's independent review of  
4 environmental impacts from operations during the renewal term, the following Federal, State,  
5 regional, local, and Native American Tribal agencies were contacted:

6 Advisory Council on Historic Preservation, Washington, DC

7 Cayuga Nation, Akron, New York

8 City of Oswego, Oswego, New York

9 County of Oswego, Oswego, New York

10 New York Department of State, Albany, New York

11 New York Power Authority, White Plains, New York

12 New York State Department of Environmental Conservation, Albany, New York

13 New York State Department of Health, Albany New York

14 New York State Energy Research and Development Authority, Albany, New York

15 New York State Historic Preservation Office, Waterford, New York

16 Onondaga Indian Nation, Nedrow, New York

17 Oneida Indian Nation, Verona, New York

18 Seneca Nation of Indians, Irving, New York

19 St. Regis Mohawk Tribe, Akwesasne, New York

20 Tonawanda Band of Senecans, Basom, New York

21 Town of Scriba, Scriba, New York

22 Tuscarora Indian Nation, Lewiston, New York

23 US Fish and Wildlife Service, Northeast Regional Office, Hadley, New York



## **Appendix E**

**Entergy Nuclear FitzPatrick, LLC, and Entergy Nuclear Operations, Inc.,  
Compliance Status and Consultation Correspondence**



## Appendix E: Entergy Nuclear FitzPatrick, LLC, and Entergy Nuclear Operations, Inc., Compliance Status and Consultation Correspondence

Consultation correspondence related to the evaluation of the application for renewal of the operating license for James A. FitzPatrick Nuclear Power Plant (JAFNPP) is identified in Table E-1. Copies of the consultation correspondence are included at the end of this appendix.

The licenses, permits, and other approvals obtained from Federal, State, regional, and local authorities for JAFNPP, are listed in Table E-2.

**Table E-1. Consultation Correspondence**

Source	Recipient	Date of Letter
U.S. Nuclear Regulatory Commission (R. Franovich)	New York State Historic Preservation Office (B. Castro)	September 15, 2006
U.S. Nuclear Regulatory Commission (R. Franovich) <sup>(a)</sup>	Onondaga Indian Nation (I. Powless, Jr.)	September 15, 2007
U.S. Nuclear Regulatory Commission (R. Franovich)	U.S. Fish and Wildlife Service Northeast Regional Office (M. Moriarty)	September 19, 2006
U.S. Nuclear Regulatory Commission (R. Franovich)	New York State Department of Environmental Conservation (K. Lynch)	November 7, 2006
New York State Department of Environmental Conservation Natural Heritage Program (T. Seoane) <sup>(b)</sup>	U.S. Nuclear Regulatory Commission (S. Hernandez)	November 30, 2006
U.S. Nuclear Regulatory Commission (R. Franovich)	U.S. Fish and Wildlife Service Northeast Regional Office (M. Moriarty)	May 21, 2007

(a) Similar letters were sent to other Native American Tribes listed in Appendix C.

(b) Not publicly available.

**Table E-2. Federal, State, Local, and Regional Licenses, Permits, and Other Approvals for the James A. FitzPatrick Nuclear Power Plant (JAFNPP)**

Agency	Authority	Requirement	Number	Expiration Date	Authorized Activity
NRC	Atomic Energy Act, 10 CFR 50	License to operate	DPR-59	October 17, 2014	Authorization to operate JAFNPP.
DOT	49 CFR 107, Subpart G	Hazardous Materials Certificate of Registration	0517066000010	June 30, 2007	Authorization to ship radioactive and hazardous materials.
NYSDEC	6 NYCRR Part 201	Certificate to Operate an Air Contamination Source	7-3556-0020/00012	Not Applicable	Authorization to operate air emission sources (diesel generators and boilers).
NYSDEC	6 NYCRR Part 372	Hazardous Waste Generator Identification	NYD000765073	Not Applicable	Authorization for hazardous waste generation.
NYSDEC	6 NYCRR Part 675	Water Withdrawal Registration	NYGLWR-4004	November 20, 2008	Authorization to withdraw water from Lake Ontario.
NYSDEC	6 NYCRR Part 596	Hazardous Substance Bulk Storage Registration Certificate	7-000117	August 16, 2008	Authorization for onsite bulk storage of hazardous substances.
NYSDEC	6 NYCRR Part 750	State Pollutant Discharge Elimination System (SPDES) Permit	NY-0020109	August 1, 2006 <sup>(a)</sup>	Permit to discharge wastewaters to waters of the State.
NYSDEC	6 NYCRR Part 612	Petroleum Bulk Storage Registration Certificate	7-140600	November 20, 2010	Authorization for onsite bulk storage of petroleum products.
NYSDEC	6 NYCRR Part 373	Hazardous Waste Part 373 Permit	7-3556-0020/0004-0	Not Applicable	Authorization to the accumulation and temporary storage onsite of mixed waste for >90 days.

Table E-2. (cont.)

Agency	Authority	Requirement	Number	Expiration Date	Authorized Activity
NYSDEC	6 NYCRR Part 325	Pesticide Application Business Registration	79632	July 31, 2008	Authorization to apply pesticide.
CVDEM	Title 44, Code of Virginia, Chapter 3.3, Section 44-146.30	Application for Registration to Transport Hazardous Radioactive Materials	EF-S0083107	August 31, 2007	Authorization to transport radioactive waste into the Commonwealth of Virginia.
SCDHEC	Act No.429 of 1980, South Carolina Radioactive Waste Transportation and Disposal Act	South Carolina Radioactive Waste Transport Permit	0031-31-07	December 31, 2007	Authorization to transport radioactive waste into the State of South Carolina.
TDEC	Tennessee Department of Environment and Conservation Regulations	Tennessee Radioactive Waste-License-for-Delivery	T-NY003-L07	December 31, 2007	Authorization for the shipment of radioactive material into Tennessee to a disposal/processing facility.

## CFR Code of Federal Regulations

CVDEM Commonwealth of Virginia (Department of Emergency Management)

DOT U.S. Department of Transportation

JAFNPP James A. FitzPatrick Nuclear Power Plant

NRC Nuclear Regulatory Commission

NYCRR New York State Codes Rules and Regulations

NYSDEC New York State Department of Environmental Conservation

SCDHEC South Carolina Department of Health and Environmental Control

TDEC Tennessee Department of Environment and Conservation

(a) JAFNPP continues to operate under the existing permit while NYSDEC completes the SPDES permit renewal.

September 15, 2006

Ms. Bernadette Castro, SHPO  
Parks, Recreation & Historic Preservation  
Agency Building #1  
Empire State Plaza  
Albany, NY 12238

SUBJECT: JAMES A. FITZPATRICK NUCLEAR POWER PLANT LICENSE RENEWAL  
APPLICATION REVIEW (SHPO NO. 06PR0982)

Dear Ms. Castro:

The U.S. Nuclear Regulatory Commission (NRC) staff is reviewing an application to renew the operating license for James A. FitzPatrick Nuclear Power Plant (JAFNPP), which is located on Lake Ontario in Oswego County, approximately seven miles northeast of the City of Oswego, New York. JAFNPP is operated by Entergy Nuclear Operations, Inc. (Entergy). The application for renewal was submitted by Entergy in a letter dated July 31, 2006, pursuant to Title 10 of the *Code of Federal Regulations* Part 54 (10 CFR Part 54).

The NRC has established that, as part of the staff's review of any nuclear power plant license renewal action, a site-specific Supplemental Environmental Impact Statement (SEIS) to its "Generic Environmental Impact Statement for License Renewal of Nuclear Plants," NUREG-1437, will be prepared under the provisions of 10 CFR Part 51, the NRC regulation that implements the National Environmental Policy Act of 1969 (NEPA). In accordance with 36 CFR 800.8(c), the SEIS will include analyses of potential impacts to historic and cultural resources.

In the context of the National Historic Preservation Act of 1966, as amended, the NRC staff has determined that the area of potential effect (APE) for a license renewal action is the area at the power plant site and its immediate environs that may be impacted by post-license renewal land-disturbing operations or projected refurbishment activities associated with the proposed action. The APE may extend beyond the immediate environs in those instances where post-license renewal land-disturbing operations or projected refurbishment activities specifically related to license renewal may potentially have an effect on known or proposed historic sites. This determination is made irrespective of ownership or control of the lands of interest.

On October 12, 2006, the NRC will conduct two public NEPA scoping meetings at the Town Municipal Building, 42 Creamery Road, Oswego, New York 13126. You and your staff are invited to attend. Your office will receive a copy of the draft SEIS along with a request for comments. The staff expects to publish the draft SEIS in August 2007.



B. Castro

-2-

If you have any questions or require additional information, please contact Mr. Samuel Hernandez, Environmental Project Manager, by phone at 301-415-4049 or by e-mail at [shq@nrc.gov](mailto:shq@nrc.gov).

Sincerely,

**/RA/**

Rani Franovich, Branch Chief  
Environmental Branch B  
Division of License Renewal  
Office of Nuclear Reactor Regulation

Docket No. 50-333

cc: See next page

Appendix E

B. Castro

-2-

If you have any questions or require additional information, please contact Mr. Samuel Hernandez, Environmental Project Manager, by phone at 301-415-4049 or by e-mail at [shq@nrc.gov](mailto:shq@nrc.gov).

Sincerely,

**/RA/**

Rani Franovich, Branch Chief  
Environmental Branch B  
Division of License Renewal  
Office of Nuclear Reactor Regulation

Docket No. 50-333

cc: See next page

**DISTRIBUTION:**

F. Gillespie / P.T. Kuo (RidsNrrDir)  
R. Franovich (RidsNrrDirRebb)  
E. Benner (RidsNrrDirReba)  
J. Davis  
R. Schaff  
S. Hernandez  
J. Muir  
S. Werts  
B. McDowell (mcdowell5@lnl.gov)  
T. Le  
J. Boska  
G. Hunegs  
M. Zabler  
RidsOGCMailRoom

**Adams Accession No. ML062480220**

OFFICE	GS:REBB:DLR	LA:DLR	PM:REBB:DLR	BC:REBB:DLR
NAME	J. Muir	I. King	S. Hernandez	R. Franovich
DATE	09/ 05 /06	09/ 05 /06	09/ 12 /06	09/ 15 /06

OFFICIAL RECORD COPY

FitzPatrick Nuclear Power Plant

cc:

Mr. Gary J. Taylor  
Chief Executive Officer  
Entergy Operations, Inc.  
1340 Echelon Parkway  
Jackson, MS 39213

Mr. John T. Herron  
Sr. VP and Chief Operating Officer  
Entergy Nuclear Operations, Inc.  
440 Hamilton Avenue  
White Plains, NY 10601

Mr. Peter T. Dietrich  
Site Vice President  
Entergy Nuclear Operations, Inc.  
James A. FitzPatrick Nuclear Power Plant  
P.O. Box 110  
Lycoming, NY 13093

Mr. Kevin J. Mulligan  
General Manager, Plant Operations  
Entergy Nuclear Operations, Inc.  
James A. FitzPatrick Nuclear Power Plant  
P.O. Box 110  
Lycoming, NY 13093

Mr. Oscar Limpas  
Vice President Engineering  
Entergy Nuclear Operations, Inc.  
440 Hamilton Avenue  
White Plains, NY 10601

Mr. Christopher Schwarz  
Vice President, Operations Support  
Entergy Nuclear Operations, Inc.  
440 Hamilton Avenue  
White Plains, NY 10601

Mr. John F. McCann  
Director, Licensing  
Entergy Nuclear Operations, Inc.  
440 Hamilton Avenue  
White Plains, NY 10601

Resident Inspector's Office  
James A. FitzPatrick Nuclear Power Plant  
U. S. Nuclear Regulatory Commission  
P.O. Box 136  
Lycoming, NY 13093

Ms. Charlene D. Faison  
Manager, Licensing  
Entergy Nuclear Operations, Inc.  
440 Hamilton Avenue  
White Plains, NY 10601

Mr. Michael J. Colomb  
Director of Oversight  
Entergy Nuclear Operations, Inc.  
440 Hamilton Avenue  
White Plains, NY 10601

Mr. David Wallace  
Director, Nuclear Safety Assurance  
Entergy Nuclear Operations, Inc.  
James A. FitzPatrick Nuclear Power Plant  
P.O. Box 110  
Lycoming, NY 13093

Mr. James Costedio  
Manager, Regulatory Compliance  
Entergy Nuclear Operations, Inc.  
James A. FitzPatrick Nuclear Power Plant  
P.O. Box 110  
Lycoming, NY 13093

Assistant General Counsel  
Entergy Nuclear Operations, Inc.  
440 Hamilton Avenue  
White Plains, NY 10601

Mr. Charles Donaldson, Esquire  
Assistant Attorney General  
New York Department of Law  
120 Broadway  
New York, NY 10271

## Appendix E

### FitzPatrick Nuclear Power Plant

cc:

Regional Administrator, Region I  
U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406

Mr. Steven Lyman  
Oswego County Administrator  
46 East Bridge Street  
Oswego, NY 13126

Mr. Peter R. Smith, President  
New York State Energy, Research,  
and Development Authority  
17 Columbia Circle  
Albany, NY 12203-6399

Mr. Paul Eddy  
New York State Dept. of Public Service  
3 Empire State Plaza  
Albany, NY 12223-1350

Supervisor  
Town of Scriba  
Route 8, Box 382  
Oswego, NY 13126

Mr. James H. Sniezek  
BWR SRC Consultant  
5486 Nithsdale Drive  
Salisbury, MD 21801-2490

Mr. Michael D. Lyster  
BWR SRC Consultant  
5931 Barclay Lane  
Naples, FL 34110-7306

Mr. Garrett D. Edwards  
814 Waverly Road  
Kennett Square, PA 19348

Mr. Rick Plasse  
Project Manager, License Renewal  
Entergy Nuclear Operations, Inc.  
James A. FitzPatrick Nuclear Power Plant  
P.O. Box 110  
Lycoming, NY 13093

Mr. James Ross  
Nuclear Energy Institute  
1776 I Street, N.W. Suite 400  
Washington, DC 20006-3708

Mr. Randolph Bateman (Acting)  
Mayor of Oswego, NY  
13 West Oneida Street  
Oswego, NY 13126

Ms. Mary Bennett  
Penfield Library  
Suny-Oswego  
7060 State Route 104  
Oswego, NY 13126

Ms. Carol Ferlito  
Oswego Public Library  
140-142 East Second Street  
Oswego, NY 13126

September 15, 2006

The Honorable Irving Powless, Jr., Chief  
Onondaga Indian Nation  
Box 319B  
Nedrow, NY 13120

SUBJECT: REQUEST FOR COMMENTS CONCERNING THE JAMES A. FITZPATRICK  
NUCLEAR POWER PLANT LICENSE RENEWAL APPLICATION REVIEW

Dear Chief Powless:

The U.S. Nuclear Regulatory Commission (NRC) is seeking input for its environmental review of an application from Entergy Nuclear Operations, Inc., (Entergy) for the renewal of the operating license for the James A. FitzPatrick Nuclear Power Plant (JAFNPP), located on Lake Ontario in Oswego County, approximately seven miles northeast of the city of Oswego, New York. JAFNPP is in close proximity to lands that may be of interest to the Onondaga Indian Nation. As described below, the NRC's process includes an opportunity for public and inter-governmental participation in the environmental review. We want to ensure that you are aware of our efforts and, pursuant to Title 10 of the *Code of Federal Regulations* Part 51.28(b) (10 CFR 51.28(b)), the NRC invites the Onondaga Indian Nation to provide input to the scoping process relating to the NRC's environmental review of the application. In addition, as outlined in 36 CFR 800.8(c), the NRC plans to coordinate compliance with Section 106 of the National Historic Preservation Act of 1966 through the requirements of the National Environmental Policy Act of 1969.

Under NRC regulations, the original operating license for a nuclear power plant is issued for up to 40 years. The license may be renewed for up to an additional 20 years if NRC requirements are met. The current operating license for JAFNPP will expire in October 17, 2014. Entergy submitted its application for renewal of the JAFNPP operating license in a letter dated July 31, 2006.

The NRC is gathering information for a JAFNPP site-specific supplement to its "Generic Environmental Impact Statement for License Renewal of Nuclear Plants" (GEIS), NUREG-1437. The supplement will contain the results of the review of the environmental impacts on the area surrounding the JAFNPP site that are related to terrestrial ecology, aquatic ecology, hydrology, cultural resources, and socioeconomic issues (among others) and will contain a recommendation regarding the environmental acceptability of the license renewal action. Enclosed for your information is a map showing the location of the JAFNPP site.

The NRC will hold two public scoping meetings for the JAFNPP license renewal supplement to the GEIS on October 12, 2006, at the Town Municipal Building, 42 Creamery Road, Oswego, New York 13126. There will be two sessions to accommodate interested parties. The first session will convene at 1:30 p.m. and will continue until 4:30 p.m., as necessary. The second session will convene at 7:00 p.m., with a repeat of the overview portions of the meeting, and will continue until 10:00 p.m., as necessary. Additionally, the NRC staff will host informal discussions one hour before the start of each session. To be considered, comments must be provided either at the transcribed public meetings or in writing. No formal comments on the proposed scope of the supplement to the GEIS will be accepted during informal discussions.

The license renewal application (LRA) is publicly available at the NRC Public Document Room (PDR), located at One White Flint North, 11555 Rockville Pike, Rockville, Maryland, 20852, or from the NRC's Agencywide Documents Access and Management System (ADAMS). The ADAMS Public Electronic Reading Room is accessible at <http://adamswebsearch.nrc.gov/dologin.htm>. The accession number for the LRA is ML062160557. Persons who do not have access to ADAMS, or who encounter problems in accessing the documents located in ADAMS, should contact the NRC's PDR reference staff by telephone at 1-800-397-4209, or 301-415-4737, or by e-mail at [pdr@nrc.gov](mailto:pdr@nrc.gov).

The JAFNPP LRA is also available on the internet at <http://www.nrc.gov/reactors/operating/licensing/renewal/applications/fitzpatrick.html>. In addition, the following public libraries have agreed to make the LRA available for public inspection: Penfield Library SUNY, 7060 State Route 104, Oswego, New York 13126; and **Oswego Public Library, 140-142 East Second Street, Oswego, New York 13126.**

The GEIS, which documents the NRC's assessment of the scope and impact of environmental effects that would be associated with license renewal at any nuclear power plant site, can also be found on the NRC's website or at the NRC's PDR.

Please submit any comments that the Onondaga Indian Nation may have to offer on the scope of the environmental review by November 14, 2006. Written comments should be submitted by mail to the Chief, Rules and Directives Branch, Division of Administrative Services, Mail Stop T-6D59, U.S. Nuclear Regulatory Commission, Washington D.C. 20555-0001. Electronic comments may be submitted to the NRC by e-mail at [FitzPatrickEIS@nrc.gov](mailto:FitzPatrickEIS@nrc.gov). At the conclusion of the scoping process, the NRC staff will prepare a summary of the significant issues identified and the conclusions reached, and mail a copy to you.

The staff expects to publish the draft supplement to the GEIS in August 2007. The NRC will hold another set of public meetings in the site vicinity to solicit comments on the draft. A copy of the draft supplemental environmental impact statement (SEIS) will be sent to you for your

I. Powless

-3-

review and comment. After consideration of public comments received on the draft, the NRC will prepare a final SEIS. The issuance of a final SEIS for JAFNPP is planned for April 2008. If you need additional information regarding the environmental review process, please contact Mr. Samuel Hernandez, Environmental Project Manager, at 301-415-4049 or by e-mail at [shq@nrc.gov](mailto:shq@nrc.gov).

Sincerely,

**/RA/**

Rani L. Franovich, Branch Chief  
Environmental Branch B  
Division of License Renewal  
Office of Nuclear Reactor Regulation

Docket No. 50-333

Enclosure:  
JAFNPP Location Map

cc w/encl: See next page

Appendix E

I. Powless

-3-

review and comment. After consideration of public comments received on the draft, the NRC will prepare a final SEIS. The issuance of a final SEIS for JAFNPP is planned for April 2008. If you need additional information regarding the environmental review process, please contact Mr. Samuel Hernandez, Environmental Project Manager, at 301-415-4049 or by e-mail at [shq@nrc.gov](mailto:shq@nrc.gov).

Sincerely,

**/RA/**

Rani L. Franovich, Branch Chief  
Environmental Branch B  
Division of License Renewal  
Office of Nuclear Reactor Regulation

Docket No. 50-333

Enclosure:  
JAFNPP Location Map

cc w/encl: See next page

DISTRIBUTION: See next page

Adams Accession No. **ML062480057**

Document Name: E:\Filenet\ML062480057.wpd

OFFICE	LA:DLR	GS:DLR:REBB	PM:DLR:REBB	BC:DLR:REBB
NAME	Y. Edmonds	J. Muir	S. Hernandez	R.Franovich
DATE	09/06/06	09/07/06	09/12/06	09/15/06

OFFICIAL RECORD COPY





Enclosure

Appendix E

Letter to I. Powless, dated: September 15, 2006

SUBJECT: REQUEST FOR COMMENTS CONCERNING THE JAMES A. FITZPATRICK  
NUCLEAR POWER PLANT LICENSE RENEWAL APPLICATION REVIEW

DISTRIBUTION:

Email

F. Gillespie / P.T. Kuo (RidsNrrDir)

J. Schlueter (STP)

R. Bores, RI

R. Franovich (RidsNrrDirRebb)

E. Benner (RidsNrrDirReba)

R. Schaaf

S. Hernandez

J. Muir

S. Werts

B. Mcdowell (mcdowell5@llnl.gov)

T. Le

J. Boska

G. Hunegs

N. Sheehan, RI

M. Zabler

RidsOGCMailRoom

DLR/REBB

DLR/REBA

FitzPatrick Nuclear Power Plant

cc:

Mr. Gary J. Taylor  
Chief Executive Officer  
Entergy Operations, Inc.  
1340 Echelon Parkway  
Jackson, MS 39213

Mr. John T. Herron  
Sr. VP and Chief Operating Officer  
Entergy Nuclear Operations, Inc.  
440 Hamilton Avenue  
White Plains, NY 10601

Mr. Peter T. Dietrich  
Site Vice President  
Entergy Nuclear Operations, Inc.  
James A. FitzPatrick Nuclear Power Plant  
P.O. Box 110  
Lycoming, NY 13093

Mr. Kevin J. Mulligan  
General Manager, Plant Operations  
Entergy Nuclear Operations, Inc.  
James A. FitzPatrick Nuclear Power Plant  
P.O. Box 110  
Lycoming, NY 13093

Mr. Oscar Limpias  
Vice President Engineering  
Entergy Nuclear Operations, Inc.  
440 Hamilton Avenue  
White Plains, NY 10601

Mr. Christopher Schwarz  
Vice President, Operations Support  
Entergy Nuclear Operations, Inc.  
440 Hamilton Avenue  
White Plains, NY 10601

Mr. John F. McCann  
Director, Licensing  
Entergy Nuclear Operations, Inc.  
440 Hamilton Avenue  
White Plains, NY 10601

Resident Inspector's Office  
James A. FitzPatrick Nuclear Power Plant  
U. S. Nuclear Regulatory Commission  
P.O. Box 136  
Lycoming, NY 13093

Ms. Charlene D. Faison  
Manager, Licensing  
Entergy Nuclear Operations, Inc.  
440 Hamilton Avenue  
White Plains, NY 10601

Mr. Michael J. Colomb  
Director of Oversight  
Entergy Nuclear Operations, Inc.  
440 Hamilton Avenue  
White Plains, NY 10601

Mr. David Wallace  
Director, Nuclear Safety Assurance  
Entergy Nuclear Operations, Inc.  
James A. FitzPatrick Nuclear Power Plant  
P.O. Box 110  
Lycoming, NY 13093

Mr. James Costedio  
Manager, Regulatory Compliance  
Entergy Nuclear Operations, Inc.  
James A. FitzPatrick Nuclear Power Plant  
P.O. Box 110  
Lycoming, NY 13093

Assistant General Counsel  
Entergy Nuclear Operations, Inc.  
440 Hamilton Avenue  
White Plains, NY 10601

Mr. Charles Donaldson, Esquire  
Assistant Attorney General  
New York Department of Law  
120 Broadway  
New York, NY 10271

Appendix E

FitzPatrick Nuclear Power Plant

cc:

Regional Administrator, Region I  
U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406

Mr. Steven Lyman  
Oswego County Administrator  
46 East Bridge Street  
Oswego, NY 13126

Mr. Peter R. Smith, President  
New York State Energy, Research,  
and Development Authority  
17 Columbia Circle  
Albany, NY 12203-6399

Mr. Paul Eddy  
New York State Dept. of Public Service  
3 Empire State Plaza  
Albany, NY 12223-1350

Supervisor  
Town of Scriba  
Route 8, Box 382  
Oswego, NY 13126

Mr. James H. Sniezek  
BWR SRC Consultant  
5486 Nithsdale Drive  
Salisbury, MD 21801-2490

Mr. Michael D. Lyster  
BWR SRC Consultant  
5931 Barclay Lane  
Naples, FL 34110-7306

Mr. Garrett D. Edwards  
814 Waverly Road  
Kennett Square, PA 19348

Mr. Rick Plasse  
Project Manager, License Renewal  
Entergy Nuclear Operations, Inc.  
James A. FitzPatrick Nuclear Power Plant  
P.O. Box 110  
Lycoming, NY 13093

Mr. James Ross  
Nuclear Energy Institute  
1776 I Street, N.W. Suite 400  
Washington, DC 20006-3708

Mr. Randolph Bateman (Acting)  
Mayor of Oswego, NY  
13 West Oneida Street  
Oswego, NY 13126

Ms. Mary Bennett  
Penfield Library  
Suny-Oswego  
7060 State Route 104  
Oswego, NY 13126

Ms. Carol Ferlito  
Oswego Public Library  
140-142 East Second Street  
Oswego, NY 13126

September 19, 2006

Marvin Moriarty  
Northeast Regional Office  
U.S. Fish and Wildlife Service  
300 Westgate Center Drive  
Hadley, MA 01035-9589

SUBJECT: REQUEST FOR LIST OF PROTECTED SPECIES WITHIN THE AREA UNDER  
EVALUATION FOR THE JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
LICENSE RENEWAL APPLICATION REVIEW

Dear Mr. Moriarty:

The U.S. Nuclear Regulatory Commission (NRC) is reviewing an application submitted by Entergy Nuclear Operations, Inc. (Entergy) for the renewal of the operating license for James A. Fitzpatrick Nuclear Power Plant (JAFNPP). JAFNPP is located on Lake Ontario in Oswego County, approximately seven miles northeast of the City of Oswego, New York (Latitude 43.52 N, Longitude 76.39 W). As part of the review of the license renewal application (LRA), the NRC is preparing a Supplemental Environmental Impact Statement (SEIS) under the provisions of Title 10 of the *Code of Federal Regulations* Part 51 (10 CFR Part 51), the NRC regulations that implements the National Environmental Policy Act (NEPA) of 1969. The SEIS includes an analysis of pertinent environmental issues, including endangered or threatened species and impacts to fish and wildlife. This letter is being submitted under the provisions of the Endangered Species Act of 1973, as amended, and the Fish and Wildlife Coordination Act of 1934, as amended.

Entergy has stated that if a renewed license is granted, it has no plans to alter current operations over the license renewal period, and that JAFNPP would use existing plant facilities and transmission lines and would not require additional construction or disturbance of new areas. The JAFNPP site covers approximately 702 acres, of which approximately 21 acres is industrial. The area surrounding JAFNPP is largely forested and rural, characterized by rolling terrain rising gently up from the lake.

JAFNPP uses a once-through open-cycle cooling system with an intake and discharge on Lake Ontario. The shore-facing intake is located approximately 900 feet offshore. Water coming into the intake passes through trash racks and traveling water screens. JAFNPP operates a fish deterrence system installed at the offshore intake structure from April to October of each year as required by their New York SPDES Permit.

The discharge water is returned to the lake through a discharge tunnel and diffuser system. The discharge structure is located approximately 1,400 feet offshore. The transmission lines in the scope of NRC's environmental review for license renewal are those that were originally constructed for the specific purpose of connecting the plant to the transmission system.

M. Moriarty

-2-

A single 345-kilovolt (kV) transmission line was built to connect JAFNPP to the New York Power Pool transmission grid. The line runs from the plant switchyard to the Edic Substation located in Utica, New York. The transmission line right-of-way is 400 feet wide although only 150 feet were cleared for a total of 1,273 acres. The corridor passes through land that is primarily pine forest and swamp forest. There is also a short 345-kV transmission line from JAFNPP and the Nine Mile Point Nuclear Station. It runs 4,900 feet from the plants switchyard to the National Grid Scriba Substation. In addition to the 345-kV lines, offsite power is provided to JAFNPP by two single circuit 115-kV transmission lines connected to the plant's 115-kV bus.

To support the SEIS preparation process and to ensure compliance with Section 7 of the Endangered Species Act, the NRC requests information on Federally listed, proposed, and candidate species and critical habitat that may be in the vicinity of JAFNPP and its associated transmission line right-of-way. In addition, please provide any information you consider appropriate under the provisions of the Fish and Wildlife Coordination Act.

We plan to hold two public NEPA scoping meetings at 1:30 p.m. and 7:00 p.m. on October 12, 2006, at the Scriba Town Municipal Building, 42 Creamery Road, Oswego, New York, 13126. On December 04, 2006, we plan to conduct a site audit at the JAFNPP facility. You and your staff are invited to attend both public meetings and the site audit. Your office will receive a copy of the draft SEIS along with a request for comments. The anticipated publication date for the draft SEIS is August 2007.

If you have any questions concerning the NRC staff review of the license renewal application, please contact Mr. Samuel Hernandez, Environmental Project Manager at 301-415-4049 or by e-mail at [shq@nrc.gov](mailto:shq@nrc.gov).

Sincerely,

*/RA/*

Rani Franovich, Branch Chief  
Environmental Branch B  
Division of License Renewal  
Office of Nuclear Reactor Regulation

Docket No. 50-333

Enclosures:

1. JAFNPP Location Map
2. Transmission Lines Map

cc w/encls: See next page

M. Moriarty

-2-

A single 345-kilovolt (kV) transmission line was built to connect JAFNPP to the New York Power Pool transmission grid. The line runs from the plant switchyard to the Edic Substation located in Utica, New York. The transmission line right-of-way is 400 feet wide although only 150 feet were cleared for a total of 1,273 acres. The corridor passes through land that is primarily pine forest and swamp forest. There is also a short 345-kV transmission line from JAFNPP and the Nine Mile Point Nuclear Station. It runs 4,900 feet from the plants switchyard to the National Grid Scriba Substation. In addition to the 345-kV lines, offsite power is provided to JAFNPP by two single circuit 115-kV transmission lines connected to the plant's 115-kV bus.

To support the SEIS preparation process and to ensure compliance with Section 7 of the Endangered Species Act, the NRC requests information on Federally listed, proposed, and candidate species and critical habitat that may be in the vicinity of JAFNPP and its associated transmission line right-of-way. In addition, please provide any information you consider appropriate under the provisions of the Fish and Wildlife Coordination Act.

We plan to hold two public NEPA scoping meetings at 1:30 p.m. and 7:00 p.m. on October 12, 2006, at the Scriba Town Municipal Building, 42 Creamery Road, Oswego, New York, 13126. On December 04, 2006, we plan to conduct a site audit at the JAFNPP facility. You and your staff are invited to attend both public meetings and the site audit. Your office will receive a copy of the draft SEIS along with a request for comments. The anticipated publication date for the draft SEIS is August 2007.

If you have any questions concerning the NRC staff review of the license renewal application, please contact Mr. Samuel Hernandez, Environmental Project Manager at 301-415-4049 or by e-mail at [shq@nrc.gov](mailto:shq@nrc.gov).

Sincerely,

**/RA/**

Rani Franovich, Branch Chief  
Environmental Branch B  
Division of License Renewal  
Office of Nuclear Reactor Regulation

Docket No. 50-333

## Enclosures:

1. JAFNPP Location Map
2. Transmission Lines Map

cc w/encls: See next page

DISTRIBUTION: See next page

Adams Accession No. **ML062630292**

Document Name: E:\Filenet\ML062630292.wpd

OFFICE	GS:DLR:REBB	LA:DLR	PM:DLR:REBB	BC:DLR:REBB
NAME	J. Muir SHQ for	Y. Edmonds	S. Hernandez	R. Franovich
DATE	09/19/06	09/18/06	09/19/06	09/19/06

OFFICIAL RECORD COPY



Appendix E

Letter to M. Moriarty from Rani Franovich, dated September 19, 2006

SUBJECT: REQUEST FOR LIST OF PROTECTED SPECIES WITHIN THE AREA UNDER  
EVALUATION FOR THE JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
LICENSE RENEWAL APPLICATION REVIEW

**DISTRIBUTION:**


F. Gillespie / P.T. Kuo (RidsNrrDlr)  
R. Franovich (RidsNrrDlrRebb)  
E. Benner (RidsNrrDlrReba)  
R. Schaaf  
S. Hernandez  
J. Muir  
S. Werts  
B. Mcdowell (mcdowell5@lml.gov)  
N. Lee  
J. Boska  
G. Hunegs  
N. Sheehan, RI  
RidsOGCMailRoom





Enclosure 1

Appendix E



FitzPatrick Nuclear Power Plant

cc:

Mr. Gary J. Taylor  
Chief Executive Officer  
Entergy Operations, Inc.  
1340 Echelon Parkway  
Jackson, MS 39213

Mr. John T. Herron  
Sr. VP and Chief Operating Officer  
Entergy Nuclear Operations, Inc.  
440 Hamilton Avenue  
White Plains, NY 10601

Mr. Peter T. Dietrich  
Site Vice President  
Entergy Nuclear Operations, Inc.  
James A. FitzPatrick Nuclear Power Plant  
P.O. Box 110  
Lycoming, NY 13093

Mr. Kevin J. Mulligan  
General Manager, Plant Operations  
Entergy Nuclear Operations, Inc.  
James A. FitzPatrick Nuclear Power Plant  
P.O. Box 110  
Lycoming, NY 13093

Mr. Oscar Limpas  
Vice President Engineering  
Entergy Nuclear Operations, Inc.  
440 Hamilton Avenue  
White Plains, NY 10601

Mr. Christopher Schwarz  
Vice President, Operations Support  
Entergy Nuclear Operations, Inc.  
440 Hamilton Avenue  
White Plains, NY 10601

Mr. John F. McCann  
Director, Licensing  
Entergy Nuclear Operations, Inc.  
440 Hamilton Avenue  
White Plains, NY 10601

Resident Inspector's Office  
James A. FitzPatrick Nuclear Power Plant  
U. S. Nuclear Regulatory Commission  
P.O. Box 136  
Lycoming, NY 13093

Ms. Charlene D. Faison  
Manager, Licensing  
Entergy Nuclear Operations, Inc.  
440 Hamilton Avenue  
White Plains, NY 10601

Mr. Michael J. Colomb  
Director of Oversight  
Entergy Nuclear Operations, Inc.  
440 Hamilton Avenue  
White Plains, NY 10601

Mr. David Wallace  
Director, Nuclear Safety Assurance  
Entergy Nuclear Operations, Inc.  
James A. FitzPatrick Nuclear Power Plant  
P.O. Box 110  
Lycoming, NY 13093

Mr. James Costedio  
Manager, Regulatory Compliance  
Entergy Nuclear Operations, Inc.  
James A. FitzPatrick Nuclear Power Plant  
P.O. Box 110  
Lycoming, NY 13093

Assistant General Counsel  
Entergy Nuclear Operations, Inc.  
440 Hamilton Avenue  
White Plains, NY 10601

Mr. Charles Donaldson, Esquire  
Assistant Attorney General  
New York Department of Law  
120 Broadway  
New York, NY 10271

## Appendix E

FitzPatrick Nuclear Power Plant

cc:

Regional Administrator, Region I  
U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406  
FitzPatrick Nuclear Power Plant

Mr. Peter R. Smith, President  
New York State Energy, Research,  
and Development Authority  
17 Columbia Circle  
Albany, NY 12203-6399

Mr. Paul Eddy  
New York State Dept. of Public Service  
3 Empire State Plaza  
Albany, NY 12223-1350

Supervisor  
Town of Scriba  
Route 8, Box 382  
Oswego, NY 13126

Mr. James H. Sniezek  
BWR SRC Consultant  
5486 Nithsdale Drive  
Salisbury, MD 21801-2490

Mr. Michael D. Lyster  
BWR SRC Consultant  
5931 Barclay Lane  
Naples, FL 34110-7306

Mr. Garrett D. Edwards  
814 Waverly Road  
Kennett Square, PA 19348

Mr. Rick Plasse  
Project Manager, License Renewal  
Entergy Nuclear Operations, Inc.  
James A. Fitzpatrick Nuclear Power Plant  
P.O. Box 110  
Lycoming, NY 13093

Mr. James Ross  
Nuclear Energy Institute  
1776 I Street, N.W. Suite 400  
Washington, DC 20006-3708

Mr. Randolph Bateman  
Mayor of Oswego, NY (Acting)  
13 West Oneida Street  
Oswego, NY 13126

Ms. Mary Bennett  
Penfield Library  
SUNY-Oswego  
7060 State Route 104  
Oswego, NY 13126

Ms. Carol Ferlito  
Oswego Public Library  
140-142 East Second Street  
Oswego, NY 13126

November 7, 2006

Kenneth P. Lynch  
Region 7 Office  
New York State Department of Environmental Conservation  
615 Erie Boulevard West  
Syracuse, NY 13204-2400

SUBJECT: REQUEST FOR LIST OF STATE PROTECTED SPECIES WITHIN THE AREA  
UNDER EVALUATION FOR THE JAMES A. FITZPATRICK NUCLEAR POWER  
PLANT LICENSE RENEWAL APPLICATION REVIEW

Dear Mr. Lynch:

The U.S. Nuclear Regulatory Commission (NRC) is reviewing an application submitted by Entergy Nuclear Operations, Inc. (Entergy), for the renewal of the operating license for James A. Fitzpatrick Nuclear Power Plant (JAFNPP). JAFNPP is located on Lake Ontario in Oswego County, approximately seven miles northeast of the City of Oswego, New York (Latitude 43.52 N, Longitude 76.39 W). As part of the review of the license renewal application (LRA), the NRC is preparing a Supplemental Environmental Impact Statement (SEIS) under the provisions of Title 10 of the *Code of Federal Regulations* Part 51 (10 CFR Part 51), the NRC regulation that implements the National Environmental Policy Act (NEPA) of 1969. The SEIS includes an analysis of pertinent environmental issues, including endangered or threatened species and impacts to fish and wildlife.

Entergy has stated that if a renewed license is granted, it has no plans to alter current operations over the license renewal period, and that JAFNPP would use existing plant facilities and transmission lines and would not require additional construction or disturbance of new areas. The JAFNPP site covers approximately 702 acres, of which approximately 21 acres is industrial. The area surrounding JAFNPP is largely forested and rural, characterized by rolling terrain rising gently up from the lake.

JAFNPP uses a once-through open-cycle cooling system with intake and discharge structures on Lake Ontario. The shore-facing intake is located approximately 900 feet offshore. Water coming into the intake passes through trash racks and traveling water screens. JAFNPP operates a fish deterrence system installed at the offshore intake structure from April to October of each year as required by their New York SPDES permit.

The discharge water is returned to the lake through a discharge tunnel and diffuser system. The discharge structure is located approximately 1,400 feet offshore. The transmission lines in the scope of NRC's environmental review for license renewal are those that were originally constructed for the specific purpose of connecting the plant to the transmission system.

A single 345-kilovolt (kV) transmission line was built to connect JAFNPP to the New York Power Pool transmission grid. The line runs from the plant switchyard to the Edic Substation located in Utica, New York. The transmission line right-of-way is 400 feet wide although only 150 feet were cleared for a total of 1,273 acres. The corridor passes through land that is primarily pine forest and swamp forest in Oswego and Oneida Counties. There is also a short 345-kV transmission line from JAFNPP and the Nine Mile Point Nuclear Station. It runs 4,900 feet from the plant's switchyard to the National Grid Scriba Substation in Oswego County. In addition to the 345-kV lines, offsite power is provided to JAFNPP by two single circuit 115-kV transmission lines connected to the plant's 115-kV bus.

To support the SEIS preparation process, the NRC requests information on state listed, proposed, and candidate species and critical habitat that may be in the vicinity of JAFNPP and its associated transmission line right-of-ways. In addition, please provide any information you consider appropriate that might help the NRC to evaluate impacts that extended operation of JAFNPP for up to an additional 20 years under the terms of a license renewal might impose on state listed species.

On December 04, 2006, we plan to conduct a site audit at the JAFNPP facility. You and your staff are invited to attend the site audit. Your office will receive a copy of the draft SEIS along with a request for comments. The anticipated publication date for the draft SEIS is August 2007.

If you have any questions concerning the NRC staff review of the LRA, please contact Mr. Samuel Hernandez, Environmental Project Manager at 301-415-4049 or via e-mail at [shq@nrc.gov](mailto:shq@nrc.gov).

Sincerely,

**/RA/**

Rani Franovich, Branch Chief  
Environmental Branch B  
Division of License Renewal  
Office of Nuclear Reactor Regulation

Docket No. 50-333

Enclosures:

1. JAFNPP Location Map
2. Transmission Lines Map

cc w/encls: See next page

-2-

A single 345-kilovolt (kV) transmission line was built to connect JAFNPP to the New York Power Pool transmission grid. The line runs from the plant switchyard to the Edic Substation located in Utica, New York. The transmission line right-of-way is 400 feet wide although only 150 feet were cleared for a total of 1,273 acres. The corridor passes through land that is primarily pine forest and swamp forest in Oswego and Oneida Counties. There is also a short 345-kV transmission line from JAFNPP and the Nine Mile Point Nuclear Station. It runs 4,900 feet from the plant's switchyard to the National Grid Scriba Substation in Oswego County. In addition to the 345-kV lines, offsite power is provided to JAFNPP by two single circuit 115-kV transmission lines connected to the plant's 115-kV bus.

To support the SEIS preparation process, the NRC requests information on state listed, proposed, and candidate species and critical habitat that may be in the vicinity of JAFNPP and its associated transmission line right-of-ways. In addition, please provide any information you consider appropriate that might help the NRC to evaluate impacts that extended operation of JAFNPP for up to an additional 20 years under the terms of a license renewal might impose on state listed species.

On December 04, 2006, we plan to conduct a site audit at the JAFNPP facility. You and your staff are invited to attend the site audit. Your office will receive a copy of the draft SEIS along with a request for comments. The anticipated publication date for the draft SEIS is August 2007.

If you have any questions concerning the NRC staff review of the LRA, please contact Mr. Samuel Hernandez, Environmental Project Manager at 301-415-4049 or via e-mail at [shq@nrc.gov](mailto:shq@nrc.gov).

Sincerely,  
/RA/

Rani Franovich, Branch Chief  
Environmental Branch B  
Division of License Renewal  
Office of Nuclear Reactor Regulation

Docket No. 50-333

Enclosures:

1. JAFNPP Location Map
2. Transmission Lines Map

cc w/encls: See next page

DISTRIBUTION: See next page

Adams Accession No. ML062960276

OFFICE	GS:DLR:REBA	LA:DLR	PM:DLR:REBB	BC:DLR:REBB
NAME	BHarris	SFigueroa	SHernandez	RFranovich
DATE	10/26/06	10/27/06	10/30/06	11/07/06

OFFICIAL RECORD COPY

Appendix E

Letter to K. Lynch from Rani Franovich, dated November 7, 2006

SUBJECT: REQUEST FOR LIST OF STATE PROTECTED SPECIES WITHIN THE AREA  
UNDER EVALUATION FOR THE JAMES A. FITZPATRICK NUCLEAR POWER  
PLANT LICENSE RENEWAL APPLICATION REVIEW

**DISTRIBUTION:**


F. Gillespie / P.T. Kuo (RidsNrrDir)  
R. Franovich (RidsNrrDirRebb)  
E. Benner (RidsNrrDirReba)  
R. Schaaf  
S. Hernandez  
J. Muir  
S. Werts  
B. Harris  
B. Mcdowell (mcdowell5@llnl.gov)  
N. Lee  
J. Boska  
G. Hunegs  
N. Sheehan, RI  
RidsOGCMailRoom





Enclosure 1

Appendix E



Enclosure 2

FitzPatrick Nuclear Power Plant

cc:

Mr. Gary J. Taylor  
Chief Executive Officer  
Entergy Operations, Inc.  
1340 Echelon Parkway  
Jackson, MS 39213

Mr. John T. Herron  
Sr. VP and Chief Operating Officer  
Entergy Nuclear Operations, Inc.  
440 Hamilton Avenue  
White Plains, NY 10601

Mr. Peter T. Dietrich  
Site Vice President  
Entergy Nuclear Operations, Inc.  
James A. FitzPatrick Nuclear Power Plant  
P.O. Box 110  
Lycoming, NY 13093

Mr. Kevin J. Mulligan  
General Manager, Plant Operations  
Entergy Nuclear Operations, Inc.  
James A. FitzPatrick Nuclear Power Plant  
P.O. Box 110  
Lycoming, NY 13093

Mr. Oscar Limpias  
Vice President Engineering  
Entergy Nuclear Operations, Inc.  
440 Hamilton Avenue  
White Plains, NY 10601

Mr. Christopher Schwarz  
Vice President, Operations Support  
Entergy Nuclear Operations, Inc.  
440 Hamilton Avenue  
White Plains, NY 10601

Mr. John F. McCann  
Director, Licensing  
Entergy Nuclear Operations, Inc.  
440 Hamilton Avenue  
White Plains, NY 10601

Resident Inspector's Office  
James A. FitzPatrick Nuclear Power Plant  
U. S. Nuclear Regulatory Commission  
P.O. Box 136  
Lycoming, NY 13093

Ms. Charlene D. Faison  
Manager, Licensing  
Entergy Nuclear Operations, Inc.  
440 Hamilton Avenue  
White Plains, NY 10601

Mr. Michael J. Colomb  
Director of Oversight  
Entergy Nuclear Operations, Inc.  
440 Hamilton Avenue  
White Plains, NY 10601

Mr. David Wallace  
Director, Nuclear Safety Assurance  
Entergy Nuclear Operations, Inc.  
James A. FitzPatrick Nuclear Power Plant  
P.O. Box 110  
Lycoming, NY 13093

Mr. James Costedio  
Manager, Regulatory Compliance  
Entergy Nuclear Operations, Inc.  
James A. FitzPatrick Nuclear Power Plant  
P.O. Box 110  
Lycoming, NY 13093

Assistant General Counsel  
Entergy Nuclear Operations, Inc.  
440 Hamilton Avenue  
White Plains, NY 10601

Mr. Charles Donaldson, Esquire  
Assistant Attorney General  
New York Department of Law  
120 Broadway  
New York, NY 10271

Appendix E

FitzPatrick Nuclear Power Plant

-2-

cc:

Regional Administrator, Region I  
U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406

Mr. James Ross  
Nuclear Energy Institute  
1776 I Street, N.W. Suite 400  
Washington, DC 20006-3708

Mr. Peter R. Smith, President  
New York State Energy, Research,  
and Development Authority  
17 Columbia Circle  
Albany, NY 12203-6399

Mr. Randolph Bateman  
Mayor of Oswego, NY (Acting)  
13 West Oneida Street  
Oswego, NY 13126

Mr. Paul Eddy  
New York State Dept. of Public Service  
3 Empire State Plaza  
Albany, NY 12223-1350

Ms. Mary Bennett  
Penfield Library  
SUNY-Oswego  
7060 State Route 104  
Oswego, NY 13126

Supervisor  
Town of Scriba  
Route 8, Box 382  
Oswego, NY 13126

Mr. James H. Sniezek  
BWR SRC Consultant  
5486 Nithsdale Drive  
Salisbury, MD 21801-2490

Mr. Michael D. Lyster  
BWR SRC Consultant  
5931 Barclay Lane  
Naples, FL 34110-7306

Mr. Garrett D. Edwards  
814 Waverly Road  
Kennett Square, PA 19348

Mr. Rick Plasse  
Project Manager, License Renewal  
Entergy Nuclear Operations, Inc.  
James A. Fitzpatrick Nuclear Power Plant  
P.O. Box 110  
Lycoming, NY 13093

## **Appendix F**

### **GEIS Environmental Issues Not Applicable to James A. FitzPatrick Nuclear Power Plant**



**Appendix F:**  
**GEIS Environmental Issues Not Applicable**  
**to James A. FitzPatrick Nuclear Power Plant**

Table F-1 lists those environmental issues identified in the *Generic Environmental Impact Statement for License Renewal of Nuclear Plants* (GEIS), NUREG-1437, Volumes 1 and 2 (NRC 1996; 1999),<sup>(1)</sup> and Title 10 of the *Code of Federal Regulations*, Part 51 (10 CFR Part 51), Subpart A, Appendix B, Table B-1, that are not applicable to James A. FitzPatrick Nuclear Power Plant (JAFNPP) because of plant or site characteristics.

**Table F-1.** GEIS Environmental Issues Not Applicable  
to James A. FitzPatrick Nuclear Power Plant

ISSUE—10 CFR Part 51, Subpart A, Appendix B, Table B-1	Category	GEIS Sections	Comment
<b>SURFACE WATER QUALITY, HYDROLOGY, AND USE (FOR ALL PLANTS)</b>			
Altered salinity gradients	1	4.2.1.2.2; 4.4.2.2	The JAFNPP cooling system does not discharge to an estuary.
Water-use conflicts (plants with cooling ponds or cooling towers using makeup water from a small river with low flow)	2	4.3.2.1: 4.4.2.1	The JAFNPP cooling system does not use makeup water from a small river with low flow.
<b>AQUATIC ECOLOGY (FOR PLANTS WITH COOLING TOWER BASED HEAT DISSIPATION SYSTEMS)</b>			
Entrainment of fish and shellfish in early life stages	1	4.3.3	This issue is related to heat-dissipation systems that are not installed at JAFNPP.
Impingement of fish and shellfish	1	4.3.3	This issue is related to heat-dissipation systems that are not installed at JAFNPP.
Heat shock	1	4.3.3	This issue is related to heat-dissipation systems that are not installed at JAFNPP.

(1) The GEIS was originally issued in 1996. Addendum 1 to the GEIS was issued in 1999. Hereafter, all references to the “GEIS” include the GEIS and its Addendum 1.

Appendix F

<b>ISSUE—10 CFR Part 51, Subpart A, Appendix B, Table B-1</b>	<b>Category</b>	<b>GEIS Sections</b>	<b>Comment</b>
Groundwater use conflicts (potable and service water, and dewatering; plants that use <100 gallons per minutes [gpm])	1	4.8.1.1; 4.8.1.2	JAFNPP does not use groundwater.
Groundwater use conflicts (potable and service water, and dewatering; plants that use >100 gpm)	2	4.8.1.1; 4.8.2.1	JAFNPP does not use groundwater.
Groundwater-use conflicts (plants using cooling towers withdrawing makeup water from a small river)	2	4.8.1.3; 4.4.2.1	This issue is related to heat-dissipation systems that are not installed at JAFNPP.
Groundwater-use conflicts (Ranney wells)	2	4.8.1.4	JAFNPP do not have or use Ranney wells.
Groundwater quality degradation (Ranney wells)	1	4.8.2.2	JAFNPP do not have or use Ranney wells.
Groundwater quality degradation (saltwater intrusion)	1	4.8.2.1	The JAFNPP cooling system does not discharge to an estuary.
Groundwater quality degradation (cooling ponds in salt marshes)	1	4.8.3	This issue is related to heat-dissipation systems that are not installed at JAFNPP.
Groundwater quality degradation (cooling ponds at inland sites)	2	4.8.3	This issue is related to heat-dissipation systems that are not installed at JAFNPP.
<b>TERRESTRIAL RESOURCES</b>			
Cooling tower impacts on crops and ornamental vegetation	1	4.3.4	This issue is related to heat-dissipation systems that are not installed at JAFNPP.
Cooling tower impacts on native plants	1	4.3.5.1	This issue is related to heat-dissipation systems that are not installed at JAFNPP.
Bird collisions with cooling towers	1	4.3.5.2	This issue is related to heat-dissipation systems that are not installed at JAFNPP.
Cooling pond impacts on terrestrial resources	1	4.4.4	This issue is related to heat-dissipation systems that are not installed at JAFNPP.



ISSUE—10 CFR Part 51, Subpart A, Appendix B, Table B-1	Category	GEIS Sections	Comment
<b>HUMAN HEALTH</b>			
Microbial organisms (public health) (plants using lakes or canals, or cooling towers or cooling ponds that discharge to a small river).	2	4.3.6	The JAFNPP cooling system does not discharge to a small river.

1 **F.1 References**

2 10 CFR Part 51. *Code of Federal Regulations*, Title 10, *Energy*, Part 51, “Environmental  
3 Protection Regulations for Domestic Licensing and Related Regulatory Functions.”

4 U.S. Nuclear Regulatory Commission (NRC). 1996. *Generic Environmental Impact Statement*  
5 *for License Renewal of Nuclear Plants*. NUREG-1437, Volumes 1 and 2, Washington, D.C.

6 U.S. Nuclear Regulatory Commission (NRC). 1999. *Generic Environmental Impact Statement*  
7 *for License Renewal of Nuclear Plants: Main Report, Section 6.3, Transportation, Table 9.1,*  
8 *Summary of findings on NEPA issues for license renewal of nuclear power plants, Final Report.*  
9 NUREG-1437, Volume 1, Addendum 1, Washington, D.C.



## **Appendix G**

### **NRC Staff Evaluation of Severe Accident Mitigation Alternatives for James A. FitzPatrick Nuclear Power Plant**



1 **Appendix G:**  
2 **NRC Staff Evaluation of Severe Accident Mitigation Alternatives for**  
3 **James A. FitzPatrick Nuclear Power Plant**

4  
5 **G.1 Introduction**

6 Entergy Nuclear FitzPatrick, LLC, and Entergy Nuclear Operations, Inc. (Entergy) submitted an  
7 assessment of severe accident mitigation alternatives (SAMAs) for the James A. FitzPatrick  
8 Nuclear Power Plant (JAFNPP) as part of the environmental report (ER) (Entergy 2006a).  
9 Supplemental information on the SAMA assessment was provided in Amendment 1 to the  
10 license renewal application (Entergy 2006b). This assessment was based on the most recent  
11 JAFNPP probabilistic safety assessment (PSA) available at that time, a plant-specific offsite  
12 consequence analysis performed using the MELCOR Accident Consequence Code System 2  
13 (MACCS2) computer code, and insights from the JAFNPP individual plant examination (IPE)  
14 (NPA 1991) and individual plant examination of external events (IPEEE) (NPA 1996). In  
15 identifying and evaluating potential SAMAs, Entergy considered SAMA candidates that  
16 addressed the major contributors to core damage frequency (CDF) and population dose at  
17 JAFNPP, as well as SAMA candidates for other operating plants which have submitted license  
18 renewal applications. Entergy identified 293 potential SAMA candidates. This list was reduced  
19 to 63 unique SAMA candidates by eliminating SAMAs that: are not applicable to JAFNPP due  
20 to design differences, have already been implemented at JAFNPP, or are similar in nature and  
21 could be combined with another SAMA candidate. Entergy assessed the costs and benefits  
22 associated with each of the potential SAMAs, and concluded in the ER that several of the  
23 candidate SAMAs evaluated are potentially cost-beneficial.

24 Based on a review of the SAMA assessment, the U.S. Nuclear Regulatory Commission (NRC)  
25 issued a request for additional information (RAI) to Entergy, by letter dated November 29, 2006  
26 (NRC 2006). Key questions concerned: major plant and modeling changes incorporated within  
27 each evolution of the PSA model; source term and release time category assumptions used in  
28 the Level 2 analysis; justification for the multiplier used for external events; identification of  
29 SAMAs to reduce the fire CDF; and further information on several specific candidate SAMAs  
30 and low cost alternatives. Entergy submitted additional information by letters dated December  
31 6, 2006 (Entergy 2006b) and January 29, 2007 (Entergy 2007). In the responses, Entergy  
32 provided: a summary of the major changes made to each PSA model version and resultant  
33 changes to dominant risk contributors to CDF; a discussion of the Level 2 analysis and the  
34 process for assigning severe accident source terms and binning release categories; a revised  
35 assessment of the baseline SAMA benefits considering a multiplier to account for external  
36 events exclusive of uncertainties; a discussion of measures that have been taken to reduce risk  
37 in dominant fire zones and why the fire CDF for those zones cannot be further reduced in a cost  
38 effective manner; and additional information regarding several specific SAMAs. Entergy's  
39 responses addressed the NRC staff's concerns.

1 **G.2 Estimate of Risk for JAFNPP**

2 Entergy's estimates of offsite risk at JAFNPP are summarized in Section G.2.1. The summary  
3 is followed by the NRC staff's review of Entergy's risk estimates in Section G.2.2.

4 **G.2.1 Entergy's Risk Estimates**

5 Two distinct analyses are combined to form the basis for the risk estimates used in the SAMA  
6 analysis: (1) the JAFNPP Level 1 and 2 PSA model, which is an updated version of the IPE  
7 (NPA 1991), and (2) a supplemental analysis of offsite consequences and economic impacts  
8 (essentially a Level 3 PSA model) developed specifically for the SAMA analysis. The SAMA  
9 analysis is based on the most recent JAFNPP Level 1 and Level 2 PSA model available at the  
10 time of the ER, referred to as the JAFNPP PSA (Revision 2, October 2004 model). The scope  
11 of the JAFNPP PSA does not include external events.

12 The baseline CDF for the purpose of the SAMA evaluation is approximately  $2.74 \times 10^{-6}$  per year.  
13 The CDF is based on the risk assessment for internally-initiated events. Entergy did not include  
14 the contribution from external events within the JAFNPP risk estimates; however, it did account  
15 for the potential risk reduction benefits associated with external events by multiplying the  
16 estimated benefits for internal events by a factor of 4.<sup>(1)</sup> This is discussed further in Sections  
17 G.2.2 and G.6.2.

18 The breakdown of CDF by initiating event is provided in Table G-1 (Entergy 2006a). As shown  
19 in this table, events initiated by station blackout and transients are the dominant contributors to  
20 the CDF. Anticipated transient without scram (ATWS) sequences are insignificant contributors  
21 to the CDF.

22 The Level 2 JAFNPP PSA model that forms the basis for the SAMA evaluation represents an  
23 updated version of the original IPE Level 2 model. The current Level 2 model utilizes a single  
24 containment event tree (CET) containing both phenomenological and systemic events. The  
25 Level 1 core damage sequences are binned into one of 48 Plant Damage State (PDS) bins  
26 which provide the interface between the Level 1 and Level 2 CET analysis. CET nodes are  
27 evaluated using supporting fault trees and logic rules.

28 The result of the Level 2 PSA is a set of 7 release categories with their respective frequency  
29 and release characteristics. The results of this analysis for JAFNPP are provided in  
30 Table E.1-10 of the ER (Entergy 2006a). The frequency of each release category was obtained  
31 by summing the frequency of the individual accident progression CET endpoints binned into the  
32 release category. Source terms were developed for each of the 7 release categories using the

---

<sup>(1)</sup> In the ER, Entergy bounded the combined impact of external events and uncertainties by applying a multiplier of 16 to the estimated SAMA benefits for internal events. In supplemental information to the ER, Entergy revised the analysis to include a multiplier of 4 to account for potential SAMA benefits in both internal and external events, and provided a separate accounting of uncertainties.

1 results of Modular Accident Analysis Program (MAAP 4.04) computer code calculations. These  
 2 release categories and source terms were further collapsed into three distinct source term bins  
 3 to represent no containment failure, early releases, and late releases.

4 **Table G-1.** JAFNPP Core Damage Frequency for Internal Events

<b>Initiating Event</b>	<b>CDF (per year)</b>	<b>Percent Contribution to CDF</b>
Station Blackout	$1.27 \times 10^{-6}$	46
Transients with loss of containment heat removal	$7.78 \times 10^{-7}$	28
Transients with loss of all emergency core cooling system (ECCS) injection	$2.66 \times 10^{-7}$	10
ATWS	$1.38 \times 10^{-7}$	5
Loss of a 4.16kv alternating current (AC) safeguard bus	$1.18 \times 10^{-7}$	5
Loss of both direct current (DC) divisions	$9.55 \times 10^{-8}$	3
Loss of coolant accidents (LOCAs)	$2.83 \times 10^{-8}$	1
Loss of a division of DC power	$2.60 \times 10^{-8}$	1
Relay room flooding	$2.53 \times 10^{-8}$	1
<b>Total CDF (internal events)</b>	<b><math>2.74 \times 10^{-6}</math></b>	<b>100</b>

5  
 6 The offsite consequences and economic impact analyses use the MACCS2 code to determine  
 7 the offsite risk impacts on the surrounding environment and public. Inputs for these analyses  
 8 include plant-specific and site-specific input values for core radionuclide inventory, source term  
 9 and release characteristics, site meteorological data, projected population distribution (within a  
 10 50-mile radius) for the year 2034, emergency response evacuation modeling, and economic  
 11 data. The core radionuclide inventory is derived from a reference core inventory for a boiling  
 12 water reactor (BWR) in MACCS2. Core inventory was scaled to account for the JAFNPP-  
 13 specific power level, and long-lived radionuclide inventory was increased by 25 percent to  
 14 reflect the expected core exposure and fuel management practices at JAFNPP (Entergy 2007).  
 15 The magnitude of the onsite impacts (in terms of clean-up and decontamination costs and  
 16 occupational dose) is based on information provided in NUREG/BR-0184 (NRC 1997a).

17 In the ER, Entergy estimated the dose to the population within 50 miles of the JAFNPP site to

18

Appendix G

1 be approximately 1.63 person-rem per year. The breakdown of the total population dose by  
2 containment release mode is summarized in Table G-2. Containment failures within the late  
3 time frame (greater than 24 hours following event initiation) and the early time frame (0 to 24  
4 hours following event initiation) dominate the population dose risk at JAFNPP, contributing  
5 about equally to the population dose risk.

6 **Table G-2.** Breakdown of Population Dose by Containment Release Mode

<b>Containment Release Mode</b>	<b>Population Dose (Person-Rem<sup>1</sup> Per Year)</b>	<b>Percent Contribution</b>
Late Containment Failure	0.87	53
Early Containment Failure	0.76	47
Intact Containment	negligible	negligible
<b>Total</b>	<b>1.63</b>	<b>100</b>

7 <sup>1</sup>One person-Rem = 0.01 person-Sv

8 **G.2.2 Review of Entergy's Risk Estimates**

9 Entergy's determination of offsite risk at JAFNPP is based on the following three major elements  
10 of analysis:

- 11 · The Level 1 and 2 risk models that form the bases for the 1991 IPE submittal (NPA  
12 1991), and the external event analyses of the 1996 IPEEE submittal (NPA 1996),
- 13 · The major modifications to the IPE model that have been incorporated in the JAFNPP  
14 PSA, and
- 15 · The MACCS2 analyses performed to translate fission product source terms and release  
16 frequencies from the Level 2 PSA model into offsite consequence measures.

17 Each of these analyses was reviewed to determine the acceptability of Entergy's risk estimates  
18 for the SAMA analysis, as summarized below.

19 The NRC staff's review of the JAFNPP IPE is described in an NRC report dated May 9, 1994  
20 (NRC 1994). Based on a review of the IPE submittal and responses to RAIs, the NRC staff  
21 concluded that the IPE submittal met the intent of GL 88-20 (NRC 1988); that is, the licensee's  
22 IPE process is capable of identifying severe accident risk contributors or vulnerabilities.

23 No vulnerabilities were identified in the IPE. However, the licensee noted that a number of  
24 actions were under evaluation as a result of the IPE process that would reduce the risk of core  
25 damage and loss of containment function. Specific improvements identified for implementation

26



1 included: increasing the reactor core isolation cooling (RCIC) turbine exhaust set points,  
2 repowering the RCIC enclosure exhaust fans from AC to DC, and fire protection system  
3 modifications to provide emergency diesel generator (EDG) jacket water cooling directly or  
4 through the emergency service water (ESW) system. Over 10 additional items were identified  
5 for follow-on evaluation by the licensee (NRC 1994).

6 There have been two revisions to the IPE model since the 1991 IPE submittal, specifically, a  
7 complete revision of the model in 1998 (Revision 1) in partial response to the boiling-water  
8 reactor owner group (BWROG) peer review, and a revision in October 2004 (Revision 2)  
9 completing the response to the BWROG peer review. The Revision 2 model reflects the  
10 JAFNPP configuration and design as of December 2003 and uses component failure and  
11 unavailability data as of December 2002. A comparison of internal events CDF between the  
12 1991 IPE and the current PSA model indicates an increase of about 40 percent in the total CDF  
13 (from  $1.9 \times 10^{-6}$  per year to  $2.7 \times 10^{-6}$  per year). A listing of those changes that resulted in the  
14 greatest impact on the internal events CDF was provided by Entergy in supplemental  
15 information to the ER (Entergy 2006b) and in response to an RAI (Entergy 2007) and is  
16 summarized in Table G-3.

17 The CDF value from the 1991 IPE ( $1.92 \times 10^{-6}$  per year) is near the lower end of the range of  
18 the CDF values reported in the IPEs for other BWR 3/4 plants. Figure 11.2 of NUREG-1560  
19 shows that the IPE-based total internal events CDF for BWR 3/4 plants ranges from  $9 \times 10^{-8}$  per  
20 year to  $8 \times 10^{-5}$  per year, with an average CDF for the group of  $2 \times 10^{-5}$  per year (NRC 1997b).  
21 It is recognized that other plants have updated the values for CDF subsequent to the IPE  
22 submittals to reflect modeling and hardware changes. The current internal events CDF results  
23 for JAFNPP are comparable to that for other plants of similar vintage and characteristics.

24 The NRC staff considered the peer reviews performed for the JAFNPP PSA, and the potential  
25 impact of the review findings on the SAMA evaluation. In the ER (Entergy 2006a) and in  
26 response to an NRC staff RAI (Entergy 2007), Entergy described the previous peer reviews,  
27 including independent consultant team reviews of draft versions of the IPE and Revision 1, as  
28 well as the BWROG Peer Review of a draft of Revision 1 conducted in December 1997. The  
29 BWROG review concluded that the JAFNPP PSA can be effectively used to support risk ranking  
30 of systems, structures, and components, and to support applications involving risk significance  
31 determinations when supported by deterministic analyses and when noted items are addressed.  
32 Entergy stated that all major issues and observations from the BWROG Peer Review have been  
33 addressed and incorporated into the current PSA (Revision 2).

34 Given that the JAFNPP internal events PSA model has been peer-reviewed and the peer review  
35 findings were all addressed, and that Entergy has satisfactorily addressed NRC staff questions  
36 regarding the PSA, the NRC staff concludes that the internal events Level 1 PSA model is of  
37 sufficient quality to support the SAMA evaluation.

**Table G-3.** JAFNPP PSA Historical Summary

<b>PSA Version</b>	<b>Summary of Changes from Prior Model</b>	<b>CDF (per year)</b>
1991	IPE Submittal	$1.92 \times 10^{-6}$
1998 (Revision 1)	<ul style="list-style-type: none"> <li>- Incorporated impact of design changes (supply EDG jacket cooling water through the ESW system cross-tie, bonnet vents on the low-pressure coolant injection (LPCI) and core spray injection valves, keylock bypass switches, normal position of residual heat removal (RHR) minimum flow bypass valve, and RCIC enclosure fan power supply changed to an AC inverter feed from a DC power source)</li> <li>- Revised model to include catastrophic common cause failure of both 125V DC battery control boards, and other common cause equipment failures</li> <li>- Revised model to assume loss of all AC power in the same division in which there is a loss of DC power</li> <li>- Revised internal flooding analysis to include a relay room flooding scenario</li> <li>- Revised transient sequences to directly result in core damage if manual depressurization of the reactor vessel fails</li> <li>- Revised model to assume core damage occurs given failure to initiate Standby Liquid Control System (SLCS)</li> <li>- Updated initiating event frequencies and component failure and unavailability database</li> </ul>	$2.44 \times 10^{-6}$

1

**Table G-3. JAFNPP PSA Historical Summary (cont.)**

PSA Version	Summary of Changes from Prior Model	CDF (per year)
2004 (Revision 2)	<ul style="list-style-type: none"> <li>- Reduced station battery depletion time from 8 to 4 hours, and updated non-recovery probabilities for loss of offsite power</li> <li>- Revised model to include additional accident initiators: loss of non-safeguard 4.16kV AC Buses, loss of condensate system, loss of instrument air system, loss of ultimate heat sink, and loss of reactor water level instrumentation</li> <li>- Revised model to assume loss of both high-pressure coolant injection (HPCI) and RCIC during accidents involving a loss of containment heat removal</li> <li>- Revised system fault tree models to include additional electrical and instrumentation and control (I&amp;C) component common cause failures</li> <li>- Reevaluated dependencies between post-initiator human actions and recovery actions</li> <li>- Updated initiating event frequencies and component failure data for instrument, master and slave trip units</li> </ul>	2.74 x 10 <sup>-6</sup>

2

3 As indicated above, the current JAFNPP PSA does not include external events. In the absence  
4 of such an analysis, Entergy used the JAFNPP IPEEE to identify the highest risk accident  
5 sequences and the potential means of reducing the risk posed by those sequences, as  
6 discussed below.

7 The JAFNPP IPEEE was submitted in June 1996 (NPA 1996), in response to Supplement 4 of  
8 Generic Letter 88-20 (NRC 19961b). While no fundamental weaknesses or vulnerabilities to  
9 severe accident risk in regard to the external events were identified, a listing of improvement  
10 opportunities was developed as discussed below. In a letter dated September 21, 2000, the  
11 NRC staff concluded that the submittal met the intent of Supplement 4 to Generic Letter 88-20,  
12 and that the licensee's IPEEE process is capable of identifying the most likely severe accidents  
13 and severe accident vulnerabilities (NRC 2000a).

14

15

Appendix G

1 The JAFNPP IPEEE seismic analysis (NPA 1996) utilized a seismic margin assessment (SMA)  
2 approach following NRC guidance (NRC 1991) and Electric Power Research Institute (EPRI)  
3 guidance (EPRI 1991). This method is qualitative and does not provide numerical estimates of  
4 the CDF contributions from seismic initiators. The seismic analysis was completed in  
5 conjunction with the Seismic Qualification User Group (SQUG) program (SQUG 1992). The  
6 overall seismic approach employed plant walkdowns to identify vulnerabilities, development of  
7 seismic fragility values for components and structures, and quantification of high confidence low  
8 probability of failure (HCLPF) for initiating events. A relay chatter evaluation was performed  
9 using the standard approach for an Unresolved Safety Issue (USI) A-46 (NRC 2000b) program  
10 plant. The conclusions of the JAFNPP IPEEE seismic margin analysis are:

- 11 The overall plant HCLPF capacity at JAFNPP is 0.22g peak ground acceleration (PGA). This  
12 value reflects implemented improvements to strengthen block walls in the Emergency Diesel  
13 Generator Building, which increased the plant HCLPF value from 0.17g to 0.22g. Several  
14 buildings and structures have HCLPF values at the 0.22g level. Thus, further increases in  
15 seismic capacity would require multiple plant modifications.
- 16 A vulnerability to fire or explosion as a result of the seismic-induced failure of the hydrogen line  
17 in the turbine building was identified. A note was added to procedure AOP-14, "Earthquake,"  
18 stating that the piping can be isolated by closing the hydrogen supply valve 89A-H2HAS-1.  
19 Based on this procedure change, the applicant concludes that seismic-induced flooding and  
20 fires do not pose major risks.
- 21 No unique decay heat removal vulnerabilities to seismic events were found.
- 22 No unique seismic-induced containment failure mechanisms were identified.

23 The NRC review and closeout of USI A-46 for JAFNPP is documented in a letter dated April 12,  
24 2000 (NRC 2000b). Based on the information provided by the applicant, the NRC staff finds  
25 that seismic risks are not dominant contributors to external event risk and that the treatment of  
26 seismic events is reasonable for the purposes of the SAMA analysis.

27 The JAFNPP IPEEE fire analysis employed EPRI's fire-induced vulnerability evaluation (FIVE)  
28 methodology to perform a qualitative and quantitative screening review and then a probabilistic  
29 risk analysis to estimate the CDF contribution for the areas that did not screen out. After  
30 qualitative screening, fire event initiation frequencies were determined for the unscreened areas  
31 for use in quantitative screening along with the assumption that all equipment in a compartment  
32 was damaged by the fire. Using results from the IPE, a conservative CDF for the compartment  
33 was determined and areas with a CDF of less than  $1 \times 10^{-6}$  per year (or  $1 \times 10^{-7}$  per year if  
34 containment bypass may result) were screened out. Fire propagation and suppression analysis  
35 was then conducted on the unscreened compartments. Fire-induced CDFs were determined by  
36 propagating the fire initiating events and associated equipment failures determined by the fire  
37 propagation and suppression analysis through event trees similar to those in the IPE. The

38

1 potential impact on containment performance and isolation was evaluated following the core  
2 damage evaluation. The JAFNPP fire CDF results are presented in Table E.1-12 of the ER for  
3 the ten fire areas considered in the analysis, and the fire zones/compartments within each fire  
4 area. The total fire CDF, found by summing the values for all compartments, is  $2.56 \times 10^{-5}$  per  
5 year. The ten fire areas and their contributions to the fire CDF are listed in Table G-4.

6 In the IPEEE, three opportunities for improvements with respect to fire events were identified.  
7 These improvements involve: (1) addition of a bypass switch to allow opening of the LPCI and  
8 core spray injection valves and an associated procedure for use of these switches during plant  
9 fires, (2) changes to administrative procedures to impose strict limitations on unattended  
10 combustible materials in the cable spreading room, and (3) relocation of heat detectors in the  
11 cable spreading room to limit contribution from transient fires. In supplemental information to  
12 the ER, Entergy indicated that the first two of these improvements have been implemented as  
13 recommended in the IPEEE. The third improvement is considered to be addressed by the  
14 changes to administrative procedures to limit unattended combustible material loading in the  
15 room. Entergy stated that none of these improvements are credited in the IPEEE fire CDF  
16 (Entergy 2006b).

17 In the ER, Entergy states that the IPEEE CDF values are screening values and that a more  
18 realistic fire CDF may be about a factor of three lower (or  $8.53 \times 10^{-6}$  per year) based on  
19 conservatism in several areas as qualitatively assessed in the ER. In supplemental  
20 information, Entergy presented the results of a sensitivity analysis to quantitatively justify the  
21 factor of three reduction (Entergy 2006b). The sensitivity analysis included the following: (1)  
22 lower probability of occurrence of spurious actuation or failure due to hot shorts and open  
23 circuits within cable jackets in the Cable Spreading Room, Reactor Building East Crescent, and  
24 Relay Room and (2) lower ignition frequency for a fire in the Main Control Room. The results of  
25 this sensitivity analysis are shown for the four impacted areas in the last two columns of the  
26 table below. These reductions would quantitatively justify a reduction in the fire CDF by a factor  
27 of 2.3.

28 Entergy noted that this fire CDF would be further reduced by IPEEE improvements not included  
29 in the CDF estimate, including monitoring and controlling the quantity of combustible materials  
30 in critical process areas. These measures would reduce the fire CDF in all dominant fire zones.  
31 Based on the results of the sensitivity analysis and the existence of remaining conservatisms,  
32 the NRC staff finds the use of a fire CDF of  $8.53 \times 10^{-6}$  per year to be reasonable for the  
33 purposes of the SAMA analysis.

34 The NRC staff inquired about additional steps taken to reduce fire risk and the possibility of  
35 additional SAMAs that might be feasible to reduce the fire risk. Entergy provided a listing of fire-  
36 related SAMAs that have been implemented. Most of these SAMAs are improvements in the  
37 fire protection program, which would decrease the fire risk, but are not explicitly credited in the  
38 fire risk analysis. In addition, all but one of the six dominant fire zones (i.e., zones within the  
39 above-mentioned fire areas with a compartment frequency greater than  $1.0 \times 10^{-6}$  per year) are

40

1  
2  
3  
4**Table G-4.** Fire Areas and Their Contribution to the Fire CDF

<u>Fire Area Description</u>	<u>CDF (per year)</u>	
	<u>IPEEE</u>	<u>Sensitivity Analysis<sup>(a)</sup></u>
Cable Spreading Room	$6.71 \times 10^{-6}$	$4.66 \times 10^{-7}$
Relay Room	$5.81 \times 10^{-6}$	$6.8 \times 10^{-7}$
Reactor Building	$3.43 \times 10^{-6}$	$2.46 \times 10^{-6}$
Control Room	$3.00 \times 10^{-6}$	$7.17 \times 10^{-7}$
Cable Tunnels	$1.96 \times 10^{-6}$	no change
Diesel Generator Building	$1.93 \times 10^{-6}$	no change
Battery Room	$1.45 \times 10^{-6}$	no change
Turbine Building	$1.29 \times 10^{-6}$	no change
Standby Gas Treatment Building	$3.72 \times 10^{-8}$	no change
Electric Bays	$8.98 \times 10^{-10}$	no change
TOTAL	$2.56 \times 10^{-5}$	$1.10 \times 10^{-5}$

5

<sup>(a)</sup> Source: Entergy 2006b

6 equipped with fire detection systems, three of the six dominant fire zones have fire suppression  
7 systems, and the Main Control Room, which has neither fire detection or fire suppression  
8 systems, is always occupied ensuring prompt fire detection and manual suppression. Entergy  
9 stated that no further cost-effective changes were identified to reduce CDF in the dominant fire  
10 zones (Entergy 2006b). The NRC staff concludes that the opportunity for fire-related SAMAs  
11 has been adequately explored and that it is unlikely that there are any potentially cost-beneficial,  
12 fire-related SAMA candidates.

13 The IPEEE analysis of high winds, floods and other external events followed the screening and  
14 evaluation approaches specified in Supplement 4 to GL 88-20 (NRC 1991b) and did not identify  
15 any sequences or vulnerabilities that exceeded the  $1.0 \times 10^{-6}$  per year criterion (NPA 1996).  
16 However, the licensee identified a condition where low pressures associated with hurricanes,  
17 tornadoes, and high winds could threaten the integrity of the air intake duct work supplying the

1 EDG room. Operating procedures were developed to open switchgear room doors or to open  
2 damaged duct work if necessary to ensure adequate ventilation of the switchgear room and  
3 adequate supply of combustion air to the EDGs. Based on this result, Entergy concluded that  
4 these other external hazards would not be expected to impact the conclusions of the SAMA  
5 analysis and did not consider them further.

6 Based on the aforementioned results, the external events CDF is approximately 3.1 times the  
7 internal events CDF (based on a fire CDF of  $8.53 \times 10^{-6}$  per year and an internal events CDF of  
8  $2.74 \times 10^{-6}$  per year). Accordingly, the total CDF (from internal and external events) would be  
9 approximately 4.1 times the internal events CDF. In revised SAMA analyses submitted in  
10 response to an RAI, Entergy multiplied the benefit that was derived from the internal events  
11 model by a factor of 4 to account for the combined contribution from internal and external  
12 events. The NRC staff agrees with the applicant's overall conclusion concerning the impact of  
13 external events and concludes that the applicant's use of a multiplier of 4 to account for external  
14 events is reasonable for the purposes of the SAMA evaluation.

15 The NRC staff reviewed the general process used by Entergy to translate the results of the  
16 Level 1 PSA into containment releases, as well as the results of the Level 2 analysis, as  
17 described in the ER and in response to NRC staff requests for additional information (Entergy  
18 2006a, 2007). The current Level 2 model utilizes a single CET containing both  
19 phenomenological and systemic events. The Level 1 core damage sequences are binned into  
20 one of 48 PDS bins based on binning criteria reflecting the state of the reactor, containment and  
21 cooling systems as the accident progresses. The PDSs provide the interface between the Level  
22 1 and Level 2 analysis. CET nodes are evaluated using supporting fault trees and logic rules.

23 Entergy characterized the releases for the spectrum of possible radionuclide release scenarios  
24 using a set of 7 release categories based on the timing and magnitude of the release and  
25 whether or not the containment remains intact. The frequency of each release category was  
26 obtained by summing the frequency of the individual accident progression CET endpoints  
27 binned into the release category. The release characteristics for each release category were  
28 developed by grouping the hundreds of source terms generated for internal initiators into the 7  
29 categories based on similar properties. Source term release fractions were developed for each  
30 of the 7 release categories using the results of Modular Accident Analysis Program (MAAP  
31 4.04) computer code calculations. The release categories, their frequencies, and release  
32 characteristics are presented in Tables E.1-8, E.1-10, and E.1-11 of the ER, respectively  
33 (Entergy 2006a). These release categories and source terms were further collapsed into three  
34 distinct source term bins to represent no containment failure, early releases, and late releases.

35 The NRC staff noted that in collapsing the 7 release categories into three source term bins,  
36 releases occurring between 0 to 8 hours and between 8 to 24 hours were grouped into one bin.  
37 In response to an RAI, Entergy performed a sensitivity study that showed that this simplification  
38 results in less than a 2 percent change on population dose (Entergy 2007). Based on these  
39 results the NRC staff concludes that the applicant's characterization of releases is adequate for  
40 the purposes of the SAMA evaluation.

## Appendix G

1 The NRC staff's review of the Level 2 IPE concluded that it addressed the most important  
2 severe accident phenomena normally associated with the Mark I containment type, and  
3 identified no significant problems or errors (NRC 1994). It should be noted, however, that the  
4 current Level 2 model is a revision to that of the IPE. The Level 2 PSA model was included in  
5 the independent consultant and BWROG peer reviews mentioned previously. The changes to  
6 the Level 2 model to update the methodology and to address peer review recommendations are  
7 described in Section E.1.4.2.2 of the ER. Based on the NRC staff's review of the Level 2  
8 methodology, and the fact that the Level 2 model was reviewed in more detail as part of the  
9 BWROG peer review, and updated to address the review findings, the NRC staff concludes that  
10 the Level 2 PSA provides an acceptable basis for evaluating the benefits associated with  
11 various SAMAs.

12 Entergy used the MACCS2 code and scaled the reference BWR core inventory for the JAFNPP  
13 plant-specific power level. Entergy also increased the long-lived radionuclide core inventory by  
14 25 percent to address JAFNPP specific fuel enrichment and burnup. In response to an NRC  
15 staff RAI, Entergy identified that the 25-percent increase was based on a best estimate  
16 inventory of long-lived isotopes (such as Sr-90, Cs-134 and Cs-137) from an ORIGEN computer  
17 code calculation assuming 4.66 percent enrichment and average burnup based on expected  
18 fuel management practices (Entergy 2007). The best-estimate evaluation resulted in an  
19 increase of approximately 25 percent in the inventories of the aforementioned radionuclides.  
20 The NRC staff considers the methods and assumptions for power scaling and 25 percent  
21 increase in long-lived inventory reasonable and acceptable for purposes of the SAMA  
22 evaluation.

23 The NRC staff reviewed the process used by Entergy to extend the containment performance  
24 (Level 2) portion of the PSA to an assessment of offsite consequences (essentially a Level 3  
25 PSA). This included consideration of the source terms used to characterize fission product  
26 releases for the applicable containment release categories and the major input assumptions  
27 used in the offsite consequence analyses. The MACCS2 code was utilized to estimate offsite  
28 consequences. Plant-specific input to the code includes the source terms for each release  
29 category and the reactor core radionuclide inventory (both discussed above), site-specific  
30 meteorological data, projected population distribution within a 50-mile radius for the year 2034,  
31 emergency evacuation modeling, and economic data. This information is provided in  
32 Attachment E to the ER (Entergy 2006a).

33 Entergy used site-specific meteorological data for the 1994 calendar year as input to the  
34 MACCS2 code. The data were collected from the onsite meteorological monitoring system and  
35 regional National Weather System (NWS) stations. In response to an NRC staff RAI, Entergy  
36 identified the location of the National Weather System stations as being at Fulton-Oswego  
37 County Airport and NWS Station No. 14733 in Buffalo, NY (Entergy 2007). Based on a review  
38 of meteorological data between 1985 and 2001, Entergy stated that it considered the year 1994  
39 data to be the most representative set of data because it contained no significant extremes and  
40 reflected average meteorological conditions at the site (Entergy 2006a). Missing data was  
41 obtained from either the upper elevation on the met tower or from estimates based on adjacent  
42 valid measurements of the missing hour. The NRC staff notes that previous SAMA analyses



1 results have shown little sensitivity to year-to-year differences in meteorological data and  
2 concludes that the use of the 1994 meteorological data in the SAMA analysis is reasonable.

3 The population distribution the applicant used as input to the MACCS2 analysis was estimated  
4 for the year 2034, based on the New York Statistical Information System projections from year  
5 2000 to 2030 (Brown 2005). The 2000 population was adjusted to account for transient  
6 population. These data were used to project county-level resident populations to the year 2034  
7 using a least squares fit method. The NRC staff considers the methods and assumptions for  
8 estimating population reasonable and acceptable for purposes of the SAMA evaluation.

9 The emergency evacuation model was modeled as a single evacuation zone extending out 16  
10 kilometers (10 miles) from the plant. Entergy assumed that 100 percent of the population would  
11 move at an average speed of approximately 2.0 meters per second (4.4 miles per hour) with a  
12 delayed start time of 2.25 hours (Entergy 2006a). This assumption is similar to the model used  
13 in NUREG-1150 study (NRC 1990), which assumed evacuation of 99.5 percent of the  
14 population within the emergency planning zone (EPZ). Sensitivity analyses were performed in  
15 which the evacuation delay time was increased to 4.5 hours, and the evacuation speed was  
16 decreased to 1.0 meters per second. The results were less than a one percent increase in the  
17 total population dose. The NRC staff questioned why the evacuation speed of 2.0 meters per  
18 second (4.4 miles per hour) was different than that used for the Nine Mile Point SAMA analysis  
19 (NRC 2006). In response, Entergy stated that the JAFNPP evacuation speed was based on  
20 evacuation times provided in the 2003 version of the evacuation time study (ETE) (KLD  
21 Associates 2003), whereas the Nine Mile Point evacuation time estimate was based on an ETE  
22 study performed in 1993 (Entergy 2007). The NRC staff also asked Entergy to address the  
23 potential impact on the population dose if 5 percent of the population fails to evacuate the EPZ  
24 (NRC 2006). In response, Entergy performed a sensitivity analysis that showed only a slight  
25 increase in population dose (less than 1 percent for the late release) would result (Entergy  
26 2007). The NRC staff concludes that the evacuation assumptions and analysis are reasonable  
27 and acceptable for the purposes of the SAMA evaluation.

28 Much of the site-specific economic data was provided from the 2002 Census of Agriculture  
29 (USDA 2002). These included the value of farm and non-farm wealth. Other data such as daily  
30 cost for an evacuated person, population relocation cost, daily cost for a person who is  
31 relocated, cost of farm and non-farm decontamination, and property depreciation were provided  
32 from the Code Manual for MACCS2 (NRC 1997c). The data from the default values given in the  
33 MACCS2 code manual were adjusted using the consumer price index of 179.9, the average  
34 value for 2002. Information on regional crops were obtained from the 2002 Census of  
35 Agriculture. Crops for each county were mapped into the seven MACCS2 crop categories.

36 The NRC staff concludes that the methodology used by Entergy to estimate the offsite  
37 consequences for JAFNPP provides an acceptable basis from which to proceed with an  
38 assessment of risk reduction potential for candidate SAMAs. Accordingly, the NRC staff based  
39 its assessment of offsite risk on the CDF and offsite doses reported by Entergy.

1 **G.3 Potential Plant Improvements**

2 The process for identifying potential plant improvements, an evaluation of that process, and the  
3 improvements evaluated in detail by Entergy are discussed in this section.

4 **G.3.1 Process for Identifying Potential Plant Improvements**

5 Entergy's process for identifying potential plant improvements (SAMAs) consisted of the  
6 following elements:

- 7 · Review of the most significant basic events from the current, plant-specific PSA,
- 8 · Review of potential plant improvements identified in the JAFNPP IPE and IPEEE,
- 9 · Review of SAMA candidates identified for license renewal applications for six other U.S.  
10 General Electric (GE) plants, and
- 11 · Review of other NRC and industry documentation discussing potential plant  
12 improvements.

13 Based on this process, an initial set of 293 candidate SAMAs, referred to as Phase I SAMAs,  
14 was identified. In Phase I of the evaluation, Entergy performed a qualitative screening of the  
15 initial list of SAMAs and eliminated SAMAs from further consideration using the following  
16 criteria:

- 17 · The SAMA is not applicable at JAFNPP due to design differences,
- 18 · The SAMA has already been implemented at JAFNPP, or
- 19 · The SAMA is similar in nature and could be combined with another SAMA candidate.

20 Based on this screening, 230 SAMAs were eliminated leaving 63 for further evaluation. The  
21 remaining SAMAs, referred to as Phase II SAMAs, are listed in Table E.2-1 of the ER (Entergy  
22 2006a). In Phase II, a detailed evaluation was performed for each of the 63 remaining SAMA  
23 candidates, as discussed in Sections G.4 and G.6 below. To account for the potential impact of  
24 external events, the estimated benefits based on internal events were multiplied by a factor of 4,  
25 as previously discussed.

26 **G.3.2 Review of Entergy's Process**

27 Entergy's efforts to identify potential SAMAs focused primarily on areas associated with internal  
28 initiating events. The initial list of SAMAs generally addressed the accident sequences  
29 considered to be important to CDF from functional, initiating event, and risk reduction worth  
30 (RRW) perspectives at JAFNPP, and included selected SAMAs from prior SAMA analyses for  
31 other plants.

1 Entergy provided a tabular listing of the PSA basic events sorted according to their RRW  
2 (Entergy 2006a). SAMAs impacting these basic events would have the greatest potential for  
3 reducing risk. Entergy used a RRW cutoff of 1.005, which corresponds to about a one-half  
4 percent change in CDF given 100-percent reliability of the SAMA. This equates to a benefit of  
5 approximately \$2,500 (after the benefits have been multiplied to account for external events).  
6 Entergy also provided and reviewed the large early release frequency (LERF)-based RRW  
7 events down to a RRW of 1.005. Entergy correlated the top Level 1 and Level 2 events with the  
8 SAMAs evaluated in the ER, and showed that all of the significant basic events are addressed  
9 by one or more SAMAs (Entergy 2006a).

10 NRC staff noted that no Phase II SAMAs were recommended for event NR-LOSP-7HR, non-  
11 recovery of offsite power in seven hours, which is the highest risk reduction worth non-initiator  
12 event. The NRC staff asked the applicant to identify and evaluate SAMAs for this event (NRC  
13 2006). In response to the RAI, Entergy stated that procedure and training improvements for  
14 restoring power to vital equipment following a recovery of the offsite power supply have been  
15 implemented, but that hardware improvements that could facilitate recovery of offsite power  
16 would merely shift NR-LOSP-7HR to a slightly later time on the power recovery curve and  
17 therefore would have little impact on the RRW of the event (Entergy 2007). Entergy further  
18 noted that other Phase II SAMAs (26 through 36 and 62), if implemented, would reduce the  
19 CDF contribution from this basic event. These SAMAs would enhance AC or DC system  
20 reliability or otherwise cope with loss of offsite power and SBO events. These Phase II SAMAs  
21 were evaluated in the ER.

22 NRC staff also noted that no Phase I or Phase II SAMAs were recommended for event IE-  
23 RRFLOOD, transient caused by internal flooding in the relay room, although a procedure  
24 change has been implemented to address the event. In an NRC staff RAI, the applicant was  
25 asked to provide justification for why no SAMAs were identified to address internal flooding  
26 events (NRC 2006). Entergy responded that additional methods of mitigating this flood event  
27 would entail either moving the fire protection line or installing a guard pipe to channel floodwater  
28 out of the relay room, both of which were judged to be costly relative to the risk significance of  
29 the related flood scenarios (Entergy 2007). The remaining flood scenarios are not risk-  
30 significant (i.e., above the 1.005 RRW threshold for SAMA identification).

31 For a number of the Phase II SAMAs listed in the ER, the information provided did not  
32 sufficiently describe the proposed modification. Therefore, the NRC staff asked the applicant to  
33 provide more detailed descriptions of the modifications for several of the Phase II SAMAs  
34 candidates (NRC 2006). In response to the RAI, Entergy provided the requested information  
35 (Entergy 2007).

36 The NRC staff questioned the ability of some of the candidate SAMAs to accomplish their  
37 intended objectives (NRC 2006a). In response to the RAIs, Entergy addressed the NRC staff's  
38 concerns by either re-evaluating the existing SAMA using revised modeling assumptions, or by  
39 evaluating an alternative (additional) SAMA (Entergy 2007). This is discussed further in Section  
40 G.6.2.

## Appendix G

1 The NRC staff also questioned Entergy about lower cost alternatives to some of the SAMAs  
2 evaluated, including: the use of a redundant diesel fire pump to address event FXT-ENG-FR-  
3 76PI (failure of diesel driven fire pump 76P-1), the use of a local hand wheel or gas bottle  
4 supplies for manual venting of containment, and the use of a portable generator to provide  
5 alternate DC power feeds (NRC 2006). In supplemental information and in response to the  
6 RAIs, Entergy addressed the suggested lower cost alternatives, some of which are covered by  
7 an existing procedure, or are addressed by a new SAMA (Entergy 2006b, 2007). This is  
8 discussed further in Section G.6.2.

9 In the ER, Entergy states that in both the IPE and IPEEE, several enhancements related to  
10 severe accident insights were recommended and implemented, and that these enhancements  
11 were included in the comprehensive list of Phase I SAMA candidates. However, the list of  
12 Phase I SAMA candidates was not provided in the ER. Therefore, the NRC staff requested that  
13 the applicant indicate whether the enhancement has been implemented, and whether credit for  
14 the enhancement is taken in the current PSA model (used for the SAMA analysis) (NRC 2006).  
15 In supplemental information to the ER, Entergy indicated that Phase I SAMAs 253, 256, 262,  
16 and 280 through 293 include enhancements recommended in the IPE and IPEEE (Entergy  
17 2006b). Entergy further indicated that most of these SAMAs have been implemented and that  
18 SAMA 280 was determined to be unnecessary. Those enhancements that have not been  
19 implemented or determined to not be necessary (SAMAs 281 through 284) were retained for  
20 consideration during Phase II. In response to the RAI, Entergy noted that except for Phase I  
21 SAMAs 94, 101, 120, and 267, the implemented Phase I SAMAs mentioned in the ER have  
22 been credited in the current PSA model (Entergy 2007). The absence of these four  
23 implemented modifications from the PSA model adds conservatism to the benefit estimates for  
24 Phase II SAMAs.

25 Based on this information, the NRC staff concludes that the set of SAMAs evaluated in the ER,  
26 together with those identified in supplemental information to the ER and in response to NRC  
27 staff RAIs, addresses the major contributors to internal event CDF.

28 Entergy did not identify JAFNPP-specific candidate SAMAs for seismic events. In the JAFNPP  
29 IPEEE seismic analysis, the overall plant HCLPF value was determined to be 0.22g. This value  
30 reflects implemented improvements to strengthen block walls EGB-272-6, 7, 9, and 10 in the  
31 Emergency Diesel Generator Building, which increased the plant HCLPF value from 0.17g to  
32 0.22g. Several buildings and structures have HCLPF values at the 0.22g level. Thus, further  
33 increases in seismic capacity would require multiple plant modifications. The JAFNPP IPEEE  
34 also identified that there is a fire-induced seismic vulnerability due to failure of the hydrogen line  
35 in the turbine building. The NRC staff requested that the applicant provide details on actions  
36 taken to reduce this risk and whether a SAMA to further reduce this risk is cost-beneficial (NRC  
37 2006). In their response, Entergy stated the hydrogen supply is protected by excess flow valves  
38 outside the turbine building that are intended to limit hydrogen release in the event of a line  
39 break (Entergy 2007). Entergy also indicated that this event has already been further mitigated  
40 by making a modification to plant abnormal procedure AOP-14, "Earthquake," to require that

41

1 plant operators close hydrogen supply valve 89A-H2HAS-1 following a seismic event (Phase I  
2 SAMA 286). Finally, Entergy notes that the turbine building fire risk provided in the ER (which  
3 does not reflect the implemented plant procedure) is less than  $1 \times 10^{-6}$  per year, and cannot be  
4 further reduced in a cost-effective manner. Based on the licensee's IPEEE, the A-46 efforts to  
5 identify and address seismic outliers, the modifications that have already been implemented,  
6 and the expected cost associated with further seismic risk analysis and potential plant  
7 modifications, the NRC staff concludes that the opportunity for seismic-related SAMAs has been  
8 adequately explored and that it is unlikely that there are any cost-beneficial, seismic-related  
9 SAMA candidates.

10 Entergy also did not identify any JAFNPP-specific candidate SAMAs for fire events. The fire  
11 risk at JAFNPP is dominated by ten fire areas, eight of which have fire CDF contributions in  
12 excess of  $1 \times 10^{-6}$  per year, with the largest contributor being the Cable Spreading Room. The  
13 NRC staff asked the applicant to explain what measures were taken to further reduce risk and  
14 why the fire risk cannot be further reduced in a cost-effective manner (NRC 2006). In  
15 supplemental information to the ER, Entergy stated that the fire area CDFs are conservative  
16 and presented the results of a sensitivity analysis that reduced modeling conservatisms  
17 (Entergy 2006b). This analysis, as discussed previously in Section G.2.2, reduced the  
18 individual CDF contributions for three of the top four dominant fire areas to below the  
19  $1 \times 10^{-6}$  per year threshold. Entergy also noted that the fire CDF is further reduced by IPEEE  
20 improvements not included in the CDF estimate, such as restraining or relocating flammables  
21 cabinets, monitoring and controlling the quantity of combustible materials in critical process  
22 areas, and monitoring and control of pre-staging of outage materials (Phase I SAMAs 287  
23 through 289). These measures would reduce the fire CDF in all dominant fire zones.  
24 Therefore, modifications to further reduce the fire CDF are unlikely to be cost-beneficial  
25 (Entergy 2006b). Entergy also stated that all but one of the six dominant fire zones are  
26 equipped with fire detection systems, three of the six dominant fire zones have fire suppression  
27 systems, and the Main Control Room, which has neither fire detection or fire suppression  
28 systems, is always occupied ensuring prompt fire detection and manual suppression (Entergy  
29 2006b). Therefore, no cost-effective hardware changes or other modifications were identified.

30 As stated earlier, other external hazards (high winds, external floods, and transportation and  
31 nearby facility accidents) are below the threshold screening frequency and are not expected to  
32 impact the conclusions of the SAMA analysis. However, the licensee identified a condition  
33 where low pressures associated with hurricanes, tornadoes, and high winds could threaten the  
34 integrity of the air intake duct work supplying the EDG room. Operating procedures were  
35 developed to open switchgear room doors or to open damaged duct work if necessary to ensure  
36 adequate ventilation of the switchgear room and adequate supply of combustion air to the  
37 EDGs. No plant modifications were identified for these external hazards. The NRC staff  
38 concludes that the applicant's rationale for eliminating fire and other external hazards  
39 enhancements from further consideration is reasonable.

40

41

## Appendix G

1 The NRC staff notes that the set of SAMAs submitted is not all inclusive, since additional,  
2 possibly even less expensive, design alternatives can always be postulated. However, the NRC  
3 staff concludes that the benefits of any additional modifications are unlikely to exceed the  
4 benefits of the modifications evaluated and that the alternative improvements would not likely  
5 cost less than the least expensive alternatives evaluated, when the subsidiary costs associated  
6 with maintenance, procedures, and training are considered.

7 The NRC staff concludes that Entergy used a systematic and comprehensive process for  
8 identifying potential plant improvements for JAFNPP, and that the set of potential plant  
9 improvements identified by Entergy is reasonably comprehensive and, therefore, acceptable.  
10 This search included reviewing insights from the plant-specific risk studies, and reviewing plant  
11 improvements considered in previous SAMA analyses. While explicit treatment of external  
12 events in the SAMA identification process was limited, it is recognized that the prior  
13 implementation of plant modifications for fire risks and the absence of external event  
14 vulnerabilities reasonably justifies examining primarily the internal events risk results for this  
15 purpose.

### 16 **G.4 Risk Reduction Potential of Plant Improvements**

17 Entergy evaluated the risk-reduction potential of the 63 remaining SAMAs that were applicable  
18 to JAFNPP. The majority of the SAMA evaluations were performed in a bounding fashion in  
19 that the SAMA was assumed to completely eliminate the risk associated with the proposed  
20 enhancement. Such bounding calculations overestimate the benefit and are conservative.

21 Entergy used model re-quantification to determine the potential benefits. The CDF and  
22 population dose reductions were estimated using the JAFNPP PSA model. The changes made  
23 to the model to quantify the impact of SAMAs are detailed in Section E.2.3 of Attachment E to  
24 the ER (Entergy 2006a). Table G-5 lists the assumptions considered to estimate the risk  
25 reduction for each of the evaluated SAMAs, the estimated risk reduction in terms of percent  
26 reduction in CDF and population dose, and the estimated total benefit (present value) of the  
27 averted risk. The estimated benefits reported in Table G-4 reflect the combined benefit in both  
28 internal and external events, as well as a number of changes to the analysis methodology  
29 subsequent to the ER. The determination of the benefits for the various SAMAs is further  
30 discussed in Section G.6.

31 The NRC staff questioned the assumptions used in evaluating the benefits or risk reduction  
32 estimates of certain SAMAs provided in the ER (NRC 2006). SAMAs 8, 14, and 22 were each  
33 modeled by assuming that reactor building failures were completely eliminated, yet the results  
34 presented in the ER indicated no reduction in offsite dose. In response to the RAI, Entergy  
35 revised the estimated benefit values submitted in the ER for these SAMAs and all other SAMAs  
36 which directly impact the containment event tree model and alter the distribution of releases  
37 within a release bin (Entergy 2007). In response to this RAI, Entergy also changed the CDF  
38 reductions for Phase II SAMAs 11, 16, 17, and 39 to 0 percent to correct erroneous entries in  
39 the ER. The CDF reduction values for these SAMAs are now consistent with that for SAMA 25,  
40 which resolves another NRC staff RAI questioning that the benefit estimates for these SAMAs

1 should not have been different (NRC 2006). Table G-4 reflects all of these revisions. Revision  
2 of these benefit estimates had no impact on the original conclusions.

3 For SAMA 57, control containment venting within a narrow band of pressure, the staff noted that  
4 the analysis assumptions were not directly related to the impact of the SAMA on CDF. In  
5 supplemental information to the ER, Entergy described a sensitivity analysis to assure that the  
6 benefit values reported for this SAMA are conservative. The sensitivity analysis resulted in a  
7 decrease in the assessed benefit; Entergy thus concluded that the benefit values reported in  
8 Table S-1 of the supplemental submittal (and in Table G-4) are conservative (Entergy 2006b).

9 For SAMA 61, develop a procedure to use a portable power supply for battery chargers, the  
10 staff noted that the events eliminated in the analysis were not included in the list of risk  
11 significant events in ER Table E.1-2. In response to an NRC staff RAI, Entergy reevaluated the  
12 benefit by eliminating the failures of both DC battery chargers and both 125-V DC battery  
13 control boards, which resulted in an increase in the assessed benefit (Entergy 2007).

14 The NRC staff has reviewed Entergy's bases for calculating the risk reduction for the various  
15 plant improvements and concludes that the rationale and assumptions for estimating risk  
16 reduction are reasonable and generally conservative (i.e., the estimated risk reduction is higher  
17 than what would actually be realized). Accordingly, the NRC staff based its estimates of averted  
18 risk for the various SAMAs on Entergy's risk reduction estimates.

## 19 **G.5 Cost Impacts of Candidate Plant Improvements**

20 Entergy estimated the costs of implementing the 63 candidate SAMAs through the application of  
21 engineering judgment, and use of other licensees' estimates for similar improvements. The cost  
22 estimates conservatively did not include the cost of replacement power during extended  
23 outages required to implement the modifications, nor did they include contingency costs  
24 associated with unforeseen implementation obstacles. The cost estimates provided in the ER  
25 did not account for inflation. For those SAMAs whose implementation costs were originally  
26 developed for severe accident mitigation design alternative analyses (i.e., during the design  
27 phase of the plant), additional costs associated with performing design modifications to the  
28 existing plant were not included.

29 The NRC staff reviewed the bases for the applicant's cost estimates (presented in Section E.2.3  
30 of Attachment E to the ER), in supplemental information to the ER (Entergy 2006b), and in  
31 response to NRC staff RAIs (Entergy 2007). For certain improvements, the NRC staff also  
32 compared the cost estimates to estimates developed elsewhere for similar improvements,  
33 including estimates developed as part of other applicant's analyses of SAMAs for operating  
34 reactors and advanced light-water reactors. The NRC staff noted that several of the cost  
35 estimates provided by the applicant were drawn from previous SAMA analyses for a dual-unit  
36 site. For those cost estimates that were taken from a dual-unit SAMA analysis, Entergy reduced  
37 the estimated costs by half. The staff reviewed the costs and found them to be reasonable, and  
38 generally consistent with estimates provided in support of other plants' analyses.

## Appendix G

- 1 The NRC staff questioned the estimated cost of \$400,000 for implementation of SAMA 57,  
2 control containment venting within a narrow band of pressure, for what appears to be a  
3 procedure and training issue (NRC 2006). In supplemental information to the ER, Entergy  
4 further described this modification as requiring detailed engineering studies, potential hardware  
5 modifications, procedure changes, simulator changes, and training (Entergy 2006b). Based on  
6 this additional information, the NRC staff considers the estimated cost to be reasonable and  
7 acceptable for purposes of the SAMA evaluation.
- 8 The NRC staff concludes that the cost estimates provided by Entergy are sufficient and  
9 appropriate for use in the SAMA evaluation.



Table G-5. SAMA Cost/Benefit Screening Analysis for JAFNPP (a)

SAMA	Assumptions	% Risk Reduction		Total Benefit Using 7% Discount Rate		Total Benefit Using 3% Discount Rate		Cost (\$)
		CDF	Dose	(\$) <sup>(b)</sup>	(\$) <sup>(b)</sup>	(\$) <sup>(b)</sup>	(\$) <sup>(b)</sup>	
Common cause failures of the SW system	CDF contribution due to common cause failure of ESW pumps was eliminated	1	1	5,000	6,000			
1 - Add a service water pump								5,900,000
Decay Heat Removal Capability – Torus Cooling	Completely eliminate loss of torus cooling mode of RHR system events	8	9	40,000	52,000			
2 - Install an independent method of suppression pool cooling								5,800,000
15 - Dedicated suppression pool cooling								5,800,000
Decay Heat Removal Capability – Drywell Spray	Completely eliminate loss of drywell spray mode of RHR system events	8	9	40,000	51,000			5,800,000
10 - Install a passive containment spray system								

**Table G-5. SAMA Cost/Benefit Screening Analysis for JAFNPP (cont.)**

SAMA	Assumptions	% Risk Reduction		Total Benefit		Cost (\$)
		CDF	Population Dose	Using 7% Discount Rate	Using 3% Discount Rate	
				(\$) <sup>(b)</sup>	(\$) <sup>(b)</sup>	
Filtered Vent	Reduce successful torus venting accident progression source terms by a factor of two	0	4	16,000	23,000	
3 - Install a filtered containment vent to provide fission product scrubbing.						1,500,000
Option 1: Gravel bed filter						
Option 2: Multiple venturi scrubber						
20 - Install a filtered vent						1,500,000
Containment Vent for ATWS Decay Heat Removal	Completely eliminate ATWS sequences associated with containment bypass	3	8	28,000	38,000	
4 - Install a containment vent large enough to remove anticipated transient without scram (ATWS) decay heat						>1,000,000
52 - Install an ATWS sized vent						>1,000,000

Table G-5. SAMA Cost/Benefit Screening Analysis for JAFNPP (cont.)

SAMA	Assumptions	% Risk Reduction		Total Benefit		Total Benefit Using 3% Discount Rate	Cost (\$)
		CDF	Population Dose	Using 7% Discount Rate	Using 3% Discount Rate		
Molten Core Debris Removal <sup>(c)</sup>	Completely eliminate containment failures due to core-concrete interaction (not including liner failure)	0	64	34,000	48,000		
5 - Create a large concrete crucible with heat removal potential under the base mat to contain molten core debris							> 100,000,000
6 - Create a water cooled rubble bed on the pedestal.							19,000,000
9 - Create a core melt source reduction system							> 5,000,000
24 - Install a reactor cavity flooding system							8,750,000
Flooding the Rubble Bed <sup>(c)</sup>	Completely eliminate dry core-concrete interactions	0	22	12,000	16,000		2,500,000
23 - Provide a means of flooding the rubble bed							

**Table G-5. SAMA Cost/Benefit Screening Analysis for JAFNPP (cont.)**

SAMA	Assumptions	% Risk Reduction		Total Benefit Using 7% Discount Rate		Total Benefit Using 3% Discount Rate		Cost (\$)
		CDF	Population Dose	(\$) <sup>(b)</sup>	(\$) <sup>(b)</sup>	(\$) <sup>(b)</sup>	(\$) <sup>(b)</sup>	
Base Mat Melt-Through <sup>(c)</sup>	Completely eliminate containment failures due to base mat melt-through	0	~0	~0	~0	~0	>5,000,000	
12 - Increase the depth of the concrete base mat or use an alternative concrete material to ensure melt-through does not occur								
Reactor Vessel Exterior Cooling <sup>(c)</sup>	Reduce probability of vessel failure by a factor of two	0	3	2,000	2,000	2,000	2,500,000	
13 - Provide a reactor vessel exterior cooling system								
Drywell Head Flooding	Completely eliminate drywell head failures due to high temperature	0	0	0	0	0		
7 - Provide modification for flooding the drywell head								>1,000,000
19 - Increase the temperature margin for seals								12,000,000

Table G-5. SAMA Cost/Benefit Screening Analysis for JAFNPP (cont.)

SAMA	Assumptions	% Risk Reduction		Total Benefit		Total Benefit Using 3% Discount Rate	Cost (\$)
		CDF	Population Dose	Using 7% Discount Rate	Using 3% Discount Rate		
21 - Provide a method of drywell head flooding							>1,000,000
Reactor Building Effectiveness <sup>(c)</sup>	Completely eliminate reactor building failures	0	31	17,000	24,000		
8 - Enhance fire protection system and SGTS hardware and procedures							>2,500,000
14 - Construct a building connected to primary containment that is maintained at a vacuum							>1,000,000
22 - Use alternate method of reactor building spray							>2,500,000
Strengthen Containment <sup>(c)</sup>	Completely eliminate all energetic containment failure modes (Direct containment heating [DCH], steam explosions, late over-pressurization)	0	28	13,000	19,000		
11 - Strengthen primary and secondary containment							12,000,000

**Table G-5. SAMA Cost/Benefit Screening Analysis for JAFNPP (cont.)**

SAMA	Assumptions	% Risk Reduction		Total Benefit		Total Benefit Using 3% Discount Rate	Cost (\$)
		CDF	Population Dose	Using 7% Discount Rate	Using 3% Discount Rate		
16 - Create a larger volume in containment							8,000,000
17 - Increase containment pressure capability (sufficient pressure to withstand severe accidents)							12,000,000
25 - Add ribbing to the containment shell							12,000,000
Vacuum Breakers	Completely eliminate vacuum breaker failures	~0	7	22,000	31,000		>500,000
18 - Install improved vacuum breakers (redundant valves in each line)							
<b>DC Power</b>	<b>Increase time available to recover offsite power (before HPCI and RCIC are lost) from 14 to 24 hours during SBO scenarios</b>	<b>39</b>	<b>44</b>	<b>209,000</b>	<b>270,000</b>		<b>500,000</b>
<b>26 - Provide additional DC battery capacity</b>							

Table G-5. SAMA Cost/Benefit Screening Analysis for JAFNPP (cont.)

SAMA	Assumptions	% Risk Reduction		Total Benefit		Total Benefit Using 3% Discount Rate	Cost (\$)
		CDF	Population Dose	Using 7% Discount Rate	Using 3% Discount Rate		
27 - Use fuel cells instead of lead-acid batteries				(b)	(b)		>1,000,000
<b>30 - Provide 16-hour SBO injection</b>							<b>500,000</b>
34 - Install fuel cells							>1,000,000
<b>36 - Extended SBO provisions</b>							<b>500,000</b>
Improved DC System							
28-Incorporate an alternate battery charging capability	Completely eliminate loss of DC battery chargers	3	~0	8,000	10,000		90,000
29 - Modification for improving DC bus reliability	Completely eliminate loss of 125 VDC bus B initiator	1	1	5,000	6,000		500,000
<b>61 - power supply for battery chargers<sup>(d)</sup></b>	<b>Completely eliminate loss of DC battery chargers and battery control boards</b>	<b>2</b>	<b>2</b>	<b>10,000</b>	<b>13,000</b>		<b>10,000</b>
Dedicated DC Power and Additional Batteries and Divisions	Completely eliminate loss of DC battery control board BCB-2A	1	1	5,000	6,000		
32 - Add a dedicated DC power supply							3,000,000

**Table G-5. SAMA Cost/Benefit Screening Analysis for JAFNPP (cont.)**

SAMA	Assumptions	% Risk Reduction		Total Benefit		Total Benefit Using 3% Discount Rate	Cost (\$)
		CDF	Population Dose	Using 7% Discount Rate	Using 3% Discount Rate		
33 - Install additional batteries or divisions							3,000,000
35-Install DC Buss cross-ties.							300,000
Alternate Pump Power Source	Completely eliminate SBO diesel generator failures	1	1	3,000	4,000		>1,000,000
31 - Provide an alternate pump power source							
Locate RHR Inside Containment	Completely eliminate all RHR ISLOCA sequences	1	1	3,000	4,000		>500,000
37 - Locate RHR inside containment							
Interfacing System Loss of Coolant Accident (ISLOCA)	Completely eliminate all ISLOCA events	1	2	7,000	10,000		100,000
38 - Increase frequency of valve leak testing							



Table G-5. SAMA Cost/Benefit Screening Analysis for JAFNPP (cont.)

SAMA	Assumptions	% Risk Reduction		Total Benefit		Total Benefit Using 3% Discount Rate	Cost (\$)
		CDF	Population Dose	Using 7% Discount Rate	Using 3% Discount Rate		
Main Steam Isolation Valve (MSIV) Design	Completely eliminate containment bypass due to MSIV leakage failures	0	20	9,000	13,000	>1,000,000	
39 - Improve MSIV design <sup>(c)</sup>							
Main Feedwater	Completely eliminate loss of feedwater initiator	1	1	3,000	4,000		
40-Install a digital feedwater upgrade							
Backup Water for feedwater/condensate injection						1,500,000	
41-Create ability to connect to existing or alternate water sources to feedwater/condensate	Completely eliminate contribution due to failure of alternate injection from feedwater/condensate	1	1	3,000	4,000	170,000	
43-Install motor driven feedwater pump	Completely eliminate the failure of feedwater turbine driven pumps	~0	0	0	0	1,650,000	

**Table G-5. SAMA Cost/Benefit Screening Analysis for JAFNPP (cont.)**

SAMA	Assumptions	% Risk Reduction		Total Benefit		Total Benefit Using 3% Discount Rate	Cost (\$)
		CDF	Population Dose	Using 7% Discount Rate	Using 3% Discount Rate		
Diesel to condensate storage tank (CST) Makeup Pumps	Completely eliminate switchover from CST to torus failures	2	~0	2,000	3,000	135,000	
42 - Install an independent diesel for the CST makeup pumps							
High Pressure Injection System	HPCI system is always available	3	1	8,000	10,000		
44 - Provide an additional high pressure injection pump with independent diesel						>1,000,000	
45 - Install independent AC high pressure injection system						>1,000,000	
46 - Install a passive high pressure system						>1,000,000	
48 - Install an additional active high pressure system						>1,000,000	
49 - Add a diverse injection system						>1,000,000	

Table G-5. SAMA Cost/Benefit Screening Analysis for JAFNPP (cont.)

SAMA	Assumptions	% Risk Reduction		Total Benefit		Total Benefit Using 3% Discount Rate	Cost (\$)
		CDF	Population Dose	Using 7% Discount Rate	Using 3% Discount Rate		
Improve the Reliability of High Pressure Injection System	Reduce HPCI system failure probability by a factor of 3	2	~0	6,000	7,000		
47 - Improved high pressure systems							>1,000,000
Increase reliability of instrument air after loss of offsite power (LOSP)	Reduce probability of failure of normal electric power supply to air compressors by a factor of 10	~0	0	0	0		
50-Modify EOPs for ability to align diesel power to more air compressors							1,200,000
Safety relief valve (SRVs) Reseat	Completely eliminate stuck open SRV events	4	4	18,000	23,000		
51 - Increase SRV reseat reliability							2,200,000

**Table G-5. SAMA Cost/Benefit Screening Analysis for JAFNPP (cont.)**

SAMA	Assumptions	% Risk Reduction		Total Benefit		Total Benefit Using 3% Discount Rate	Cost (\$)
		CDF	Population Dose	Using 7% Discount Rate	Using 3% Discount Rate		
Diversity of Explosive Valves	Completely eliminate common cause failures of SLC explosive valves	~0	0	0	0	0	
53 - Diversify explosive valve operation							>200,000
Prevent catastrophic containment failure	Reduce CDF contribution in scenarios where containment venting is successful by a factor of 2	2	2	10,000	14,000		
54-Implement passive overpressure relief							>500,000
Improve control rod drive (CRD) reactor vessel injection reliability	Eliminate failure of CRD reactor vessel injection	~0	0	0	0		
55-Change CDR flow control valve failure position to the "fail-safest" position							>140,000
Large Break LOCA	Completely eliminate large break LOCAs	~0	0	0	0		>100,000
56 - Provide digital large break LOCA protection							

Table G-5. SAMA Cost/Benefit Screening Analysis for JAFNPP (cont.)

SAMA	Assumptions	% Risk Reduction		Total Benefit		Cost (\$)
		CDF	Population Dose	Using 7% Discount Rate	Using 3% Discount Rate	
				(\$) <sup>(b)</sup>	(\$) <sup>(b)</sup>	
Controlled Containment Venting	Reduce probability of operator to recognize the need to vent the torus by a factor of 3	14	16	74,000	95,000	400,000
57 - Control containment venting within a narrow band of pressure						
RHR heat removal	Completely eliminate CDF contribution from failure of cross-tie from fire protection to RHR heat exchanger "A"	~0	1	2,000	3,000	150,000
58- Provide tap from fire protection to RHR heat exchanger "B" via RHRSW header B						
Injection and containment heat removal	Complete eliminate failure from residual heat removal service water (RHRSW )loop B	11	12	56,000	73,000	400,000
59- Provide a cross-tie between RHRSW trains downstream of the RHRSW pump discharge valves						

**Table G-5. SAMA Cost/Benefit Screening Analysis for JAFNPP (cont.)**

SAMA	Assumptions	% Risk Reduction		Total Benefit Using 7% Discount Rate (\$) <sup>(b)</sup>	Total Benefit Using 3% Discount Rate (\$) <sup>(b)</sup>	Cost (\$)
		CDF	Population Dose			
Turbine Bypass	Eliminate CDF contribution due to loss of power conversion system (PCS) initiator	10	7	42,000	52,000	
60-Improve turbine bypass valve capability						745,000
<b>Emergency Diesel Generators</b>		<b>21</b>	<b>24</b>	<b>116,000</b>	<b>149,000</b>	
<b>62-Develop a procedure to open the doors of the EDG buildings upon receipt of a high temperature alarm</b>	<b>Reduce probability of EDG to run failures by a factor of three.</b>					<b>10,000</b>
Reactor Vessel Instrumentation	Completely eliminate CDF contribution due to loss of reactor vessel water level reference leg	2	2	7,000	9,000	
63-Provide additional reactor vessel monitoring and actuation system						1,200,000

2 (a) **SAMAs in bold are potentially cost-beneficial**

3 (b) Unless noted otherwise by Footnote (c) or (d), estimated benefits taken from Table S-1 in the supplemental information to the ER (Entergy 2006b)

4 (c) Estimated benefits taken from a revised assessment provided in response to RAI 5.7 (Entergy 2007)

5 (d) Estimated benefits taken from a revised assessment provided in response to RAI 5.1 (Entergy 2007)

## 1 **G.6 Cost-Benefit Comparison**

2 Entergy's cost-benefit analysis and the NRC staff's review are described in the following  
3 sections.

### 4 **G.6.1 Entergy's Evaluation**

5 The methodology used by Entergy was based primarily on NRC's guidance for performing cost-  
6 benefit analysis, i.e., NUREG/BR-0184, *Regulatory Analysis Technical Evaluation Handbook*  
7 (NRC 1997a). The guidance involves determining the net value for each SAMA according to the  
8 following formula:

9 Net Value = (APE + AOC + AOE + AOSC) - COE where,

10 APE = present value of averted public exposure (\$)

11 AOC = present value of averted offsite property damage costs (\$)

12 AOE = present value of averted occupational exposure costs (\$)

13 AOSC = present value of averted onsite costs (\$)

14 COE = cost of enhancement (\$).

15 If the net value of a SAMA is negative, the cost of implementing the SAMA is larger than the  
16 benefit associated with the SAMA and it is not considered cost-beneficial. Entergy's derivation  
17 of each of the associated costs is summarized below.

18 NUREG/BR-0058 has recently been revised to reflect the agency's policy on discount rates.  
19 Revision 4 of NUREG/BR-0058 states that two sets of estimates should be developed, one at 3  
20 percent and one at 7 percent (NRC 2004).

#### 21 Averted Public Exposure (APE) Costs

22 The APE costs were calculated using the following formula:

23 APE = Annual reduction in public exposure ( $\Delta$ person-rem/year)

24 x monetary equivalent of unit dose (\$2000 per person-rem)

25 x present value conversion factor (10.76 based on a 20-year period with a

26 7-percent discount rate).

27 As stated in NUREG/BR-0184 (NRC 1997a), it is important to note that the monetary value of  
28 the public health risk after discounting does not represent the expected reduction in public

## Appendix G

1 health risk due to a single accident. Rather, it is the present value of a stream of potential  
2 losses extending over the remaining lifetime (in this case, the renewal period) of the facility.  
3 Thus, it reflects the expected annual loss due to a single accident, the possibility that such an  
4 accident could occur at any time over the renewal period, and the effect of discounting these  
5 potential future losses to present value. For the purposes of initial screening, which assumes  
6 elimination of all severe accidents due to internal events, Entergy calculated an APE of  
7 approximately \$35,000 for the 20-year license renewal period.

### 8 Averted Offsite Property Damage Costs (AOC)

9 The AOCs were calculated using the following formula:

$$\begin{aligned} 10 \quad & \text{AOC} = \text{Annual CDF reduction} \\ 11 \quad & \quad \times \text{offsite economic costs associated with a severe accident (on a per-event basis)} \\ 12 \quad & \quad \times \text{present value conversion factor.} \end{aligned}$$

13 For the purposes of initial screening, which assumes all severe accidents due to internal events  
14 are eliminated, Entergy calculated an annual offsite economic risk of about \$3,300 based on the  
15 Level 3 risk analysis. This results in a discounted value of approximately \$36,000 for the 20-  
16 year license renewal period.

### 17 Averted Occupational Exposure (AOE) Costs

18 The AOE costs were calculated using the following formula:

$$\begin{aligned} 19 \quad & \text{AOE} = \text{Annual CDF reduction} \\ 20 \quad & \quad \times \text{occupational exposure per core damage event} \\ 21 \quad & \quad \times \text{monetary equivalent of unit dose} \\ 22 \quad & \quad \times \text{present value conversion factor.} \end{aligned}$$

23 Entergy derived the values for averted occupational exposure from information provided in  
24 Section 5.7.3 of the regulatory analysis handbook (NRC 1997a). Best estimate values provided  
25 for immediate occupational dose (3300 person-rem) and long-term occupational dose (20,000  
26 person-rem over a 10-year cleanup period) were used. The present value of these doses was  
27 calculated using the equations provided in the handbook in conjunction with a monetary  
28 equivalent of unit dose of \$2000 per person-rem, a real discount rate of 7 percent, and a time  
29 period of 20 years to represent the license renewal period. For the purposes of initial screening,  
30 which assumes all severe accidents due to internal events are eliminated, Entergy calculated an  
31 AOE of approximately \$1,000 for the 20-year license renewal period.

### 32 Averted Onsite Costs



1 Averted onsite costs (AOSC) include averted cleanup and decontamination costs and averted  
2 power replacement costs. Repair and refurbishment costs are considered for recoverable  
3 accidents only and not for severe accidents. Entergy derived the values for AOSC based on  
4 information provided in Section 5.7.6 of NUREG/BR-0184, the regulatory analysis handbook  
5 (NRC 1997a).

6 Entergy divided this cost element into two parts – the onsite cleanup and decontamination cost,  
7 also commonly referred to as averted cleanup and decontamination costs, and the replacement  
8 power cost.

9 Averted cleanup and decontamination costs (ACC) were calculated using the following formula:

$$\begin{aligned} 10 \quad & \text{ACC} = \text{Annual CDF reduction} \\ 11 \quad & \quad \times \text{ present value of cleanup costs per core damage event} \\ 12 \quad & \quad \times \text{ present value conversion factor.} \end{aligned}$$

13 The total cost of cleanup and decontamination subsequent to a severe accident is estimated in  
14 the regulatory analysis handbook to be  $\$1.5 \times 10^9$  (undiscounted). This value was converted to  
15 present costs over a 10-year cleanup period and integrated over the term of the proposed  
16 license extension. For the purposes of initial screening, which assumes all severe accidents  
17 due to internal events are eliminated, Entergy calculated an ACC of approximately \$32,000 for  
18 the 20-year license renewal period.

19 Long-term replacement power costs (RPC) were calculated using the following formula:

$$\begin{aligned} 20 \quad & \text{RPC} = \text{Annual CDF reduction} \\ 21 \quad & \quad \times \text{ present value of replacement power for a single event} \\ 22 \quad & \quad \times \text{ factor to account for remaining service years for which replacement power is} \\ 23 \quad & \quad \text{required} \\ 24 \quad & \quad \times \text{ reactor power scaling factor} \end{aligned}$$

25 For the purposes of initial screening, which assumes all severe accidents due to internal events  
26 are eliminated, Entergy calculated an RPC of approximately \$22,000 for the 20-year license  
27 renewal period.

28 Using the above equations, Entergy estimated the total present dollar value equivalent  
29 associated with completely eliminating severe accidents from internal events at JAFNPP to be  
30 about \$125,000. Use of a multiplier of 4 to account for external events increases the value to  
31 \$500,000 and represents the dollar value associated with completely eliminating all internal and  
32 external event severe accident risk at JAFNPP.

1 Entergy's Results

2 If the implementation costs for a candidate SAMA exceeded the calculated benefit, the SAMA  
3 was considered not to be cost-beneficial. In the baseline analysis contained in the ER (using a  
4 7 percent discount rate, and considering the combined impact of both external events and  
5 uncertainties), Entergy identified five potentially cost-beneficial SAMAs. The potentially cost-  
6 beneficial SAMAs are:

7 · SAMA 26 – provide additional DC battery capacity to ensure longer battery capability  
8 during the station blackout event, which would extend HPCI/RCIC operability and allow  
9 more time for AC power recovery.

10 · SAMA 30 – modify plant equipment to provide 16-hour SBO injection to improve  
11 capability to cope with longer SBO scenarios.

12 · SAMA 36 – modify plant equipment to extend DC power availability in an SBO event,  
13 which would extend HPCI/RCIC operability and allow more time for AC power recovery.

14 · SAMA 61 – modify plant procedures to allow use of a portable power supply for battery  
15 chargers, which would improve the availability of the DC power system.

16 · SAMA 62 – modify plant procedures to open the doors of the EDG buildings upon  
17 receipt of a high temperature alarm, which improves the reliability of the EDGs following  
18 high temperatures in the EDG buildings.

19 Entergy performed additional analyses to evaluate the impact of alternative discount rates and  
20 remaining plant life on the results of the SAMA assessment. No additional SAMA candidates  
21 were determined to be potentially cost-beneficial (Entergy 2006a). In supplemental information  
22 to the ER, Entergy provided a revised assessment based on a separate accounting of  
23 uncertainties. The revised assessment resulted in identification of the same potentially cost-  
24 beneficial SAMAs. However, based on further consideration of potentially cost-beneficial  
25 SAMAs at other plants, Entergy identified one additional potentially cost-beneficial SAMA for  
26 JAFNPP (Entergy 2006b). The potentially cost-beneficial SAMAs, and Entergy's plans for  
27 further evaluation of these SAMAs are discussed in more detail in Section G.6.2.

28 **G.6.2 Review of Entergy's Cost-Benefit Evaluation**

29 The cost-benefit analysis performed by Entergy was based primarily on NUREG/BR-0184 (NRC  
30 1997a) and was conducted consistent with this guidance.

31 In the ER, Entergy evaluated the reduction in risk for each SAMA in the context of an upper  
32 bound analysis which combined the impact of external events with the impact of uncertainty.  
33 The impact of external events was considered by applying a multiplier of 4.1 to the estimated  
34 SAMA benefits in internal events  $(1 + [\text{fire CDF of } 8.53 \times 10^{-6} \text{ per year}] / [\text{internal events CDF of}$

1 2.74 x 10<sup>-6</sup> per year]). The impact of uncertainties was considered by applying an additional  
2 multiplier of 3.83, which represents the ratio of the 95th percentile CDF to the mean CDF for  
3 internal events. Entergy bounded the combined impact of external events and uncertainties by  
4 applying a multiplier of 16 to the estimated SAMA benefits in internal events.

5 In an RAI, the NRC staff requested that the baseline evaluation be revised to include only the  
6 impact of internal and external events (without uncertainties), and that the impact of analysis  
7 uncertainties on the SAMA evaluation results be considered separately (NRC 2006). In  
8 supplemental information to the ER, Entergy revised the baseline benefit values by applying a  
9 multiplier of 4 to the estimated SAMA benefits in internal events to account for potential SAMA  
10 benefits in both internal and external events (Entergy 2006b).

11 As a result of the revised baseline analysis (using a multiplier of 4 and a 7 percent real discount  
12 rate), Entergy found that the same five SAMA candidates (mentioned above) remained  
13 potentially cost-beneficial. No additional SAMA candidates were found to be potentially cost-  
14 beneficial. When benefits were evaluated using a 3 percent discount rate, as recommended in  
15 NUREG/BR-0058, Revision 4 (NRC 2004), no additional SAMAs were determined to be  
16 potentially cost-beneficial.

17 Entergy considered the impact that possible increases in benefits from analysis uncertainties  
18 would have on the results of the SAMA assessment. In the ER, Entergy presents the results of  
19 an uncertainty analysis of the internal events CDF which indicates that the 95 percentile value is  
20 a factor of 3.83 times the mean CDF. Entergy re-examined the Phase II SAMAs to determine if  
21 any would be potentially cost-beneficial if the revised baseline benefits were increased by an  
22 additional factor of 4. No additional SAMAs were identified.

23 The NRC staff questioned the ability of several of the candidate SAMAs identified in the ER to  
24 accomplish their intended objectives or provide the estimated risk reductions (NRC 2006). In  
25 response to the RAI, Entergy provided revised or new evaluations as discussed below.

26 • Phase II SAMA 57, control containment venting within a narrow pressure band, was  
27 identified as a potential SAMA to further reduce the risk contribution from basic event  
28 NVP-XHE-FO-LVENT, operator fails to vent containment using the direct torus vent.  
29 This SAMA would be subject to the same failure-to-vent human error as in the basic  
30 event. The NRC staff questioned both the risk reduction estimate provided by Entergy  
31 for this SAMA, as well as whether an alternative SAMA to create a passive vent system  
32 might be more effective in reducing the risk from this event and be cost-beneficial (NRC  
33 2006).

34 In the ER, Entergy estimated the benefit of controlling containment venting within a  
35 narrow pressure band by reducing the probability of operator failure to vent by a factor of  
36 3. In supplemental information to the ER, Entergy included a sensitivity analysis in  
37 which continued vessel injection from LPCI or Core Spray was credited for those  
38 sequences in which torus venting is successful and alternative injection systems fail after  
39 torus venting (Entergy 2006b). Since the available net positive suction head (NPSH) is

Appendix G

1 likely to be less than the required NPSH with the vent open, a failure probability of 0.9  
2 was assigned for this new success path. The PSA model change resulted in about a  
3 0.5-percent reduction in CDF, a 0.6-percent reduction in population dose, and a benefit  
4 (including the impact of uncertainties) of approximately \$10,000. Entergy concluded that  
5 the original benefit values reported for SAMA 57 (and reported in Table G-4) are more  
6 conservative (Entergy 2006b). Therefore, this SAMA continues to not be cost-beneficial  
7 at JAFNPP.

8 The NRC staff also asked the applicant to provide an evaluation of the costs and  
9 benefits of converting the vent system to a passive design. In response, Entergy  
10 evaluated a new SAMA that would convert the existing torus vent to a passive torus vent  
11 (Entergy 2007). The benefit of this SAMA was conservatively estimated by removing  
12 operator failure to implement torus venting (NVP-XHE-FO-LVENT was set to zero).  
13 Entergy estimated that this modification would result in a CDF reduction of about 18  
14 percent, a population dose reduction of about 20 percent, and a benefit (7 percent  
15 baseline with uncertainty) of approximately \$377,000. However, Entergy estimated the  
16 cost of implementing this SAMA to be greater than \$1M. Therefore, this SAMA  
17 alternative would not be cost-beneficial at JAFNPP.

- 18 • Phase II SAMA 61, develop a procedure to use a portable power supply for battery  
19 chargers, was identified as a potential SAMA to improve DC system reliability. The staff  
20 questioned the risk reduction estimate provided by Entergy for this SAMA since the  
21 events identified as being eliminated for the analysis were not included in the list of risk  
22 significant events in ER Table E.1-2. In response to an NRC staff RAI, Entergy  
23 performed a revised evaluation by eliminating failures of both DC battery chargers and  
24 both 125-V DC battery boards. The PSA model change resulted in about a 2-percent  
25 reduction in CDF, a 2-percent reduction in population dose, and a benefit (including the  
26 impact of uncertainties) of approximately \$40,000. Entergy concluded that this SAMA  
27 remains potentially cost-beneficial (Entergy 2007).

28 The NRC staff noted that for certain SAMAs considered in the ER, there may be alternatives  
29 that could achieve much of the risk reduction at a lower cost. Several of these alternatives were  
30 evaluated by Entergy subsequent to the ER, and described in the supplemental information to  
31 the ER (Entergy 2006b). One such alternative involves use of a portable generator to extend  
32 the coping time in loss of AC power events (to power battery chargers). Based on a bounding  
33 analysis in which the probability of non-recovery of offsite power for 7 hours was changed to 24  
34 hours for SBO scenarios, this alternative was estimated to result in a CDF reduction of about 39  
35 percent, a population reduction of 44 percent, and a benefit (including impact of uncertainties) of  
36 \$838,000. Since the estimated cost of implementing and using the portable generator is  
37 \$712,000, Entergy concluded that this SAMA is potentially cost-beneficial to JAFNPP.

38 The NRC staff asked the applicant to evaluate several additional lower cost alternatives to the  
39 SAMAs considered in the ER. These alternatives included: (1) use a portable generator to  
40 provide alternate DC feed to panels supplied only by the DC bus, (2) addition of a redundant  
41 diesel fire pump to address event FXT-ENG-FR-76P1, diesel driven fire water pump 76P-1 fails

1 to continue to run (an alternative to SAMA 49, which involves addition of an entire new injection  
2 system), and (3) several additional alternatives (NRC 2006). Entergy provided a further  
3 evaluation of these alternatives, as summarized below.

- 4 • Use of a portable generator to provide power to an individual 125 VDC Motor Control  
5 Center (MCC), which would support returning HPCI to service in the event its bus was to  
6 fail -- Based on a bounding analysis in which failure of the HPCI system was eliminated,  
7 this alternative was estimated to result in a CDF reduction of about 3 percent, a  
8 population dose reduction of 1 percent, and a benefit (including impact of uncertainties)  
9 of \$34,000 (Entergy 2006b). However, Entergy estimated the cost of implementing this  
10 alternative to be approximately \$700K. Therefore, this alternative would not be cost-  
11 beneficial at JAFNPP.
- 12 • Use of a third redundant diesel fire pump to address event FXT-ENG-FR-76PI -- Based  
13 on a bounding analysis in which events FXT-EG-FR-76PI and FPS-MAI-MA-P4 are set  
14 to zero in the PSA model, this alternative was estimated to result in a CDF reduction of  
15 about 1 percent, a population dose reduction of 1 percent, and a benefit (including the  
16 impact of uncertainties) of \$20,000. However, Entergy estimated the cost of  
17 implementing this alternative to be approximately \$2M (Entergy 2007). Therefore, this  
18 alternative would not be cost-beneficial at JAFNPP.
- 19 • Entergy indicated that the remaining low cost alternatives identified in the RAI are  
20 already implemented or already addressed by existing plant procedures.

21

22 In response to an NRC staff RAI, Entergy indicated that the five potentially cost-beneficial  
23 SAMAs identified in the ER plus the one additional potentially cost-beneficial SAMA identified in  
24 the supplemental information to the ER have all been entered into the licensee's engineering  
25 request process to be evaluated for implementation (Entergy 2007). SAMAs 26, 30, 36 and the  
26 one additional SAMA were combined into a single engineering request to determine and  
27 implement the best approach to extend station battery capacity. SAMA 61 has been approved  
28 as a minor modification and is scheduled for installation for late 2007. SAMA 62 was  
29 implemented in November 2006 by revising applicable annunciator response procedures.

30 The NRC staff notes that all of the potentially cost-beneficial SAMAs identified in either  
31 Entergy's baseline analysis or uncertainty analysis are included within the set of SAMAs that  
32 Entergy plans to further evaluate. The NRC staff concludes that, with the exception of the  
33 potentially cost-beneficial SAMAs discussed above, the costs of the other SAMAs evaluated  
34 would be higher than the associated benefits.

## 35 **G.7 Conclusions**

36 Entergy compiled a list of 293 SAMAs based on a review of: the most significant basic events  
37 from the plant-specific PSA, insights from the plant-specific IPE and IPEEE, Phase II SAMAs

## Appendix G

1 from license renewal applications for other plants, and review of other NRC and industry  
2 documentation. A qualitative screening removed SAMA candidates that (1) were not applicable  
3 at JAFNPP due to design differences, (2) had already been implemented at JAFNPP, or (3)  
4 were similar and could be combined with another SAMA. Based on this screening, 230 SAMAs  
5 were eliminated leaving 63 candidate SAMAs for evaluation.

6 For the remaining SAMA candidates, a more detailed design and cost estimate were developed  
7 as shown in Table G-4. The cost-benefit analyses showed that five of the SAMA candidates  
8 were potentially cost-beneficial in the baseline analysis (Phase II SAMAs 26, 30, 36, 61, and  
9 62). Entergy performed additional analyses to evaluate the impact of parameter choices and  
10 uncertainties on the results of the SAMA assessment. No additional SAMAs were identified as  
11 potentially cost-beneficial in the ER. However, as a result of additional analysis, Entergy  
12 concluded that one additional SAMA is potentially cost-beneficial, i.e., use of a portable  
13 generator to extend the coping time in loss of AC power events. Entergy has indicated that the  
14 potentially cost-beneficial SAMAs have been entered into the engineering request process to be  
15 evaluated for implementation. The NRC staff concluded that all of these SAMAs are potentially  
16 cost-beneficial.

17 The NRC staff reviewed the Entergy analysis and concludes that the methods used and the  
18 implementation of those methods was sound. The treatment of SAMA benefits and costs  
19 support the general conclusion that the SAMA evaluations performed by Entergy are reasonable  
20 and sufficient for the license renewal submittal. Although the treatment of SAMAs for external  
21 events was somewhat limited, the likelihood of there being cost-beneficial enhancements in this  
22 area was minimized by improvements that have been realized as a result of the IPEEE process,  
23 and inclusion of a multiplier to account for external events.

24 The NRC staff concurs with Entergy's identification of areas in which risk can be further reduced  
25 in a cost-beneficial manner through the implementation of the identified, potentially cost-  
26 beneficial SAMAs. Given the potential for cost-beneficial risk reduction, the NRC staff agrees  
27 that further evaluation of these SAMAs by Entergy is warranted. However, these SAMAs do not  
28 relate to adequately managing the effects of aging during the period of extended operation.  
29 Therefore, they need not be implemented as part of license renewal pursuant to Title 10 of the  
30 *Code of Federal Regulations*, Part 54.

### 31 **G.8 References**

32 Brown, W. 2005. "Baseline Population Projections Nysis Projects SEP02," New York Statistical  
33 Information System, Ithaca, New York, available online at:  
34 <http://www.nysis.cornell.edu/data.html/> [accessed May 12, 2005].

35 Entergy Nuclear FitzPatrick, LLC, and Entergy Nuclear Operations, Inc. (Entergy). 2006a.  
36 *James A. FitzPatrick Nuclear Power Plant --- License Renewal Application, Appendix E:*  
37 *Applicant's Environmental Report, Operating License Renewal Stage.* Lycoming, New York.  
38 Accessible at ML062160557.

1 Entergy Nuclear FitzPatrick, LLC, and Entergy Nuclear Operations, Inc. (Entergy). 2006b.  
2 Letter from Pete Dietrich, Entergy, to NRC Document Control Desk. Subject: "Entergy Nuclear  
3 Operations, Inc., James A. FitzPatrick Nuclear Power Plant, Docket No. 50-333, License No.  
4 DPR-59, License Renewal Application, Amendment 1," JAFP-06-0167, Lycoming, New York,  
5 dated December 6, 2006. Accessible at ML063480624.

6 Entergy Nuclear FitzPatrick, LLC, and Entergy Nuclear Operations, Inc. (Entergy). 2007. Letter  
7 from Pete Dietrich, Entergy, to NRC Document Control Desk. Subject: "Entergy Nuclear  
8 Operations, Inc., James A. FitzPatrick Nuclear Power Plant, Docket No. 50-333, License No.  
9 DPR-59, License Renewal Application, Amendment 4," JAFP-07-0013, Lycoming, New York,  
10 dated January 29, 2007. Accessible at ML070370170.

11 Electric Power Research Institute (EPRI). 1991 "A Methodology for Assessment of Nuclear  
12 Power Plant Seismic Margin," EPRI NP-6041-SL, Revision 1, Palo Alto, CA, August 1991.

13 KLD Associates, Inc. 2003. "Nine Mile Point/JA Fitzpatrick Nuclear Facility Development of  
14 Evacuation Time Estimates," Report KLD TR 370.359, Commack, New York, August 2003.

15 New York Power Authority (NYPA). 1991. "James A. FitzPatrick Nuclear Power Plant Docket  
16 No. 50-333, Individual Plant Examination,"(JPN-91-048), September 1991.

17 New York Power Authority (NYPA). 1996. "James A. FitzPatrick Nuclear Power Plant Individual  
18 Plant Examination for External Events," (JAF-RPT-MISC-02211), June 1996, Revision 0.

19 New York Power Authority (NYPA). 2004. Utility Participation and Internal Review Team James  
20 A. Fitzpatrick PSA, Revision 2, October 2004.

21 Seismic Qualification Users Group (SQUG). 1992. "Generic Implementation Procedure (GIP) for  
22 Seismic Verification of Nuclear Plant Equipment," Revision 2, Corrected, February 14, 1992.

23 U.S. Department of Agriculture (USDA). 2002. "2002 Census of Agriculture." Available online  
24 at: [http://www.nass.usda.gov/Census\\_of\\_Agriculture/index.asp](http://www.nass.usda.gov/Census_of_Agriculture/index.asp). (Accessed April 26, 2005).  
25 Accessible at ML071200083.

26 U.S. Nuclear Regulatory Commission (NRC). 1988. Generic Letter 88-20, "Individual Plant  
27 Examination for Severe Accident Vulnerabilities," November 23, 1988.

28 U.S. Nuclear Regulatory Commission (NRC). 1990. *Severe Accident Risks: An Assessment  
29 for Five U.S. Nuclear Power Plants*. NUREG-1150, Washington, D.C.

30 U.S. Nuclear Regulatory Commission (NRC). 1991. "Procedural and Submittal Guidance for the  
31 Individual Plant Examination of External Events (IPEEE) for Severe Accident Vulnerabilities,"  
32 NUREG-1407, Washington, D.C., June 1991.

## Appendix G

- 1 U.S. Nuclear Regulatory Commission (NRC). 1991b. Generic Letter No. 88-20, Supplement 4,  
2 "Individual Plant Examination of External Events for Severe Accident Vulnerabilities," NUREG-  
3 1407, Washington, D.C., June 28, 1991.
- 4 U.S. Nuclear Regulatory Commission (NRC). 1994. "Staff Evaluation of the FitzPatrick  
5 Individual Plant Examination (IPE) (Internal Events Only), (TAC No. M74411)," Washington,  
6 D.C., May 9, 1994.
- 7 U.S. Nuclear Regulatory Commission (NRC). 1997a. *Regulatory Analysis Technical Evaluation*  
8 *Handbook*. NUREG/BR-0184, Washington, D.C.
- 9 U.S. Nuclear Regulatory Commission (NRC). 1997b. *Individual Plant Examination Program:*  
10 *Perspectives on Reactor Safety and Plant Performance*. NUREG-1560, Washington, D.C.
- 11 U.S. Nuclear Regulatory Commission (NRC). 1997c. *Code Manual for MACCS2: Volume 1,*  
12 *User's Guide*. NUREG/CR-6613, Washington, D.C.
- 13 U.S. Nuclear Regulatory Commission (NRC). 2000a. "James A. FitzPatrick Nuclear Power  
14 Plant - Review of Individual Plant Examination of External Events (IPEEE) Submittal (TAC No.  
15 M83622)," Washington, D.C., September 21, 2000. Not publicly available.
- 16 U.S. Nuclear Regulatory Commission (NRC). 2000b. Letter from Guy S. Vissing, U.S. NRC, to  
17 James Knubel, JAFNPP. Subject: *James A. FitzPatrick Nuclear Power Plant - Plant-Specific*  
18 *Safety Evaluation Report for Unresolved Safety Issue (USI) A-46 Program Implementation at*  
19 *FitzPatrick Nuclear Power Plant (TAC No. M69446)*, April 12, 2000. Accessible at  
20 ML003702154.
- 21 U.S. Nuclear Regulatory Commission (NRC). 2004. *Regulatory Analysis Guidelines of the U.S.*  
22 *Nuclear Regulatory Commission*. NUREG/BR-0058, Rev. 4, Washington, D.C.
- 23 U.S. Nuclear Regulatory Commission. 2006. Letter from Samuel Hernandez, U.S. NRC, to  
24 Michael Kansler, Entergy. Subject: Request for Additional Information Regarding Severe  
25 Accident Mitigation Alternatives for James A. FitzPatrick Nuclear Power Station (TAC No.  
26 MD2667), November 29, 2006. Accessible at ML063060257.



**BIBLIOGRAPHIC DATA SHEET**

(See instructions on the reverse)

NUREG-1437, Supplement 31

2. TITLE AND SUBTITLE

Generic Environmental Impact Statement for License Renewal of Nuclear Plants  
Supplement 31  
Regarding James A. FitzPatrick Nuclear Power Plant  
Draft Report

3. DATE REPORT PUBLISHED

MONTH

YEAR

June

2007

4. FIN OR GRANT NUMBER

5. AUTHOR(S)

See Appendix B of Report

6. TYPE OF REPORT

Technical

7. PERIOD COVERED (Inclusive Dates)

8. PERFORMING ORGANIZATION - NAME AND ADDRESS (If NRC, provide Division, Office or Region, U.S. Nuclear Regulatory Commission, and mailing address; if contractor, provide name and mailing address.)

Division of License Renewal, Office of Nuclear Reactor Regulations, U.S. Nuclear Regulatory Commission,  
Washington, DC 20555-0001

9. SPONSORING ORGANIZATION - NAME AND ADDRESS (If NRC, type "Same as above"; if contractor, provide NRC Division, Office or Region, U.S. Nuclear Regulatory Commission, and mailing address.)

Same as 8 above.

10. SUPPLEMENTARY NOTES

Docket No. 50-333; Operation License No. DPR-59

11. ABSTRACT (200 words or less)

This draft supplemental environmental impact statement (SEIS) has been prepared in response to an application submitted to the NRC by Entergy Nuclear FitzPatrick, LLC and Entergy Nuclear Operations, Inc. (Entergy) to renew the operating licenses for James A. FitzPatrick Nuclear Power Plant (JAFNPP) for an additional 20 years under 10 CFR Part 54. The draft SEIS includes the NRC staff's analysis that considers and weighs the environmental impacts of the proposed action, the environmental impacts of alternatives to the proposed action, and mitigation measures available for reducing or avoiding adverse impacts. It also includes the staff's preliminary recommendation regarding the proposed action.

The NRC staff's preliminary recommendation is that the Commission determine that the adverse environmental impacts of license renewal for JAFNPP are not so great that preserving the option of license renewal for energy-planning decision makers would be unreasonable. This recommendation is based on (1) the analysis and findings in the GEIS; (2) the Environmental Report submitted by Entergy; (3) consultation with Federal, State, and local agencies; (4) the staff's own independent review; and (5) the staff's consideration of public comments received during the scoping process.

12. KEY WORDS/DESCRIPTORS (List words or phrases that will assist researchers in locating the report.)

James A. FitzPatrick Nuclear Power Plant,  
FitzPatrick,  
JAFNPP,  
GEIS,  
SEIS,  
EIS,  
Environmental Impact Statement

13. AVAILABILITY STATEMENT

unlimited

14. SECURITY CLASSIFICATION

(This Page)

unclassified

(This Report)

unclassified

15. NUMBER OF PAGES

16. PRICE



Federal Recycling Program