

NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards
 Thermal Hydraulic Phenomena Subcommittee

Docket Number: (n/a)

Location: Rockville, Maryland

Date: Tuesday, September 23, 2008

Work Order No.: NRC-2418

Pages 1-376

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1323 Rhode Island Avenue, N.W.
Washington, D.C. 20005
(202) 234-4433

1 UNITED STATES OF AMERICA

2 NUCLEAR REGULATORY COMMISSION

3 + + + + +

4 ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

5 (ACRS)

6 + + + + +

7 SUBCOMMITTEE ON THERMAL HYDRAULIC PHENOMENA:

8 UPDATE ON GS-191, "ASSESSMENT OF DEBRIS ACCUMULATION

9 ON PWR SUMP PERFORMANCE" -

10 STATUS AND FUTURE ACTIVITIES

11 + + + + +

12 TUESDAY

13 SEPTEMBER 23, 2008

14 + + + + +

15 The Subcommittee met at the Nuclear
16 Regulatory Commission, Two White Flint North, Room
17 T2B3, 11545 Rockville Pike, at 8:30 a.m., Dr. Sanjoy
18 Banerjee, Chairman, presiding.

19 COMMITTEE MEMBERS PRESENT:

20 SANJOY BANERJEE, Chairman

21 SAID ABDEL-KHALIK, Member

22 MICHAEL CORRADINI, Member

23 OTTO L. MAYNARD, Member

24 MICHAEL T. RYAN, Member

25 WILLIAM J. SHACK, Member

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

ACRS STAFF:

DAVID BESSETTE, Designated Federal

OFFICIAL CONSULTANTS:

THOMAS S. KRESS

GRAHAM B. WALLIS

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

C-O-N-T-E-N-T-S

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

<u>AGENDA ITEM</u>	<u>PAGE</u>
Opening Remarks	4
NRR Opening Remarks	6
Update on GS-191 - Status and Future Activities	8
Test Results - Revision of WCAP-16793	78
Test Results - Revision of WCAP-16793 (cont.)	196
NRR Activities Related to WCAP-16793	276
Remarks from Union of Concerned Scientists	266
Subcommittee Discussion	350
Adjourn	

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

P R O C E E D I N G S

(8:31 a.m.)

OPENING REMARKS

CHAIRMAN BANERJEE: The meeting will now come to order.

This is a meeting of the advisory committee on reactor safeguards, thermal hydraulic phenomena subcommittee.

I am Sanjay Banerjee, chairman of the subcommittee. Members in attendance are Said Abdel-Khalik; Michael Corradini; Otto Maynard; Michael Ryan; and William Shack, just in time.

I would also like to welcome ACRS consultants, and actually former ACRS chairs, Tom Kress and Graham Wallis.

David Bessette is the designated federal official for this meeting. The purpose of today's meeting is to review the status of resolution of generic safety issue 191, assessment of debris accumulation on pressurized water reactor sump performance.

We will hear presentations from the staff and from the PWR owners' group.

The subcommittee will gather information,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 analyze relevant issues and facts, and formulate
2 proposed positions and actions as appropriate for
3 deliberation by the full committee.

4 The rules for participation in today's
5 meeting have been announced as part of the notice of
6 this meeting previously published in the Federal
7 Register.

8 We have received a request for time to
9 make a statement from the Union of Concerned
10 Scientists.

11 A transcript of the meeting is being kept,
12 and will be made available as stated in the Federal
13 Register notice.

14 We request that participants in this
15 meeting use one of the available microphones when
16 addressing the subcommittee. The speakers should first
17 identify themselves, and speak with sufficient clarity
18 and volume so that they can be readily heard.

19 And with that, I think we can start.

20 MEMBER SHACK: Mr. Chairman, I just want to
21 note that I have a conflict of interest on the portion
22 of the work dealing with the chemical affects, since
23 Argonne National Laboratory has been involved in that
24 work.

25 CHAIRMAN BANERJEE: Sure. And I request

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that we try to proceed in a fairly orderly fashion,
2 because I'd really like to get this meeting finished
3 more or less on time.

4 So with that, I'll turn this over to NRR.

5 Is Bill Ruland going to address us?

6 MR. RULAND: Yes, thank you, Mr. Chairman.

7 NRR OPENING REMARKS

8 MR. RULAND: Good morning. I'm Bill
9 Ruland. I'm the division director for the Division of
10 Safety Systems in NRR.

11 Thank you for the opportunity today to
12 present our current status of the staff's efforts on
13 GSI-191, and our strategy on coming to ultimate
14 closure for this issue.

15 We believe the topics we are going to
16 present today are responsive to the subcommittee's
17 wishes.

18 The staff and industry have come a long
19 way toward closure, and it's taken some time of
20 course, although there is still considerable work to
21 be done. And just a partial list of kind of what our
22 status is: All PWRs have now installed significantly
23 larger strainers, and we know that some of the ACRS
24 members have seen these new strainers firsthand.

25 Many have done, or will do, additional

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 modifications such as removing insulation, replacing
2 sump buffers, et cetera.

3 Generally the staff has found most vendor
4 testing protocols as either conservative or
5 prototypical of post-LOCA conditions.

6 Many have completed or will complete in
7 the near future their strainer testing, and also some
8 people will have to retest.

9 The staff review of submittals is ongoing,
10 and some of our requests for additional information
11 have been issued, with more under development.

12 As you will hear today progress has also
13 been made on the in-vessel downstream effects topical
14 report.

15 The staff asks the ACRS to consider a
16 letter that supports the staff's strategy and process
17 to closure for Generic Letter 2004-02 that will be
18 described to you today.

19 And I'd like to introduce the staff that
20 will be starting the presentation. To your ultimate
21 right is Donnie Harrison, who is acting for Mike
22 Scott. As you recall Mike has been the branch chief
23 in charge of the GSI-191 branch for some time. He was
24 a former staff member on the ACRS. He's on rotation
25 up to Region 1 right now. And Donnie, who works for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 me in the balance of plant section, in the balance of
2 plant branch, is now filling in for Mike.

3 Donnie has over 25 years of nuclear
4 experience, and he has mostly in the PRA area, and
5 Donnie was the PRA member of the GSI-191 team early
6 on. So he has some familiarity with the issue, and
7 he is coming up to speed.

8 By and large the rest of the staff that is
9 dealing with GSI-191 has been stable. And we hope to
10 provide you the information today that you are
11 interested in hearing.

12 Donnie, and could you introduce the rest
13 of the staff, the NRC staff, please?

14 UPDATE ON GS-191 - STATUS AND FUTURE ACTIVITIES

15 MR. HARRISON: Again, I'm Donnie Harrison.
16 To my right is Steve Smith. He is going to be
17 speaking today on the sump strainer head loss testing.

18 Paul Klein will be speaking on chemical
19 effects, and then John Burke will be speaking on the
20 chemical effects phenomenon and the identification
21 ranking table, the PIRT. So and then after the
22 Westinghouse presentation, we will come back. And
23 Bill, I'm going to mispronounce your name, Krotiuk,
24 will be presenting on the staff's work on in vessel
25 downstream effects.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 To get us going, we put together this
2 picture just so we can see kind of how the flow is of
3 where we are in the process. All the licensees have
4 provided supplemental submittals in the February-March
5 timeframe on Generic Letter 2004-02. The staff is
6 looking at that information, and 14 different
7 technical areas, and as part of that review the staff,
8 in their performing of the detailed review, are
9 developing requests for additional information.

10 As they put together an entire package for
11 a plant, they then feed all those - that information
12 to an integration review team that consists primarily
13 of three senior staff members and a senior level
14 scientist and a senior GG-15 staff member that are
15 familiar with the GSI-191 to evaluate all the requests
16 for additional information, the information from the
17 licensee and they, the commission directed us to
18 perform what's referred to as a holistic review. They
19 kind of stepped back from the issue, look at it in
20 total, and kind of weigh the uncertainties in one area
21 with maybe the conservatisms in another area to make a
22 final recommendation or determination by the team.

23 DR. WALLIS: In this team the same for all
24 licensee submittals?

25 MR. HARRISON: Many of the members are the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 same, but the team is not necessarily the same. They
2 have like four or five members with three at a time -

3 DR. WALLIS: I was just wondering how you
4 are going to assure consistency across the board.

5 MR. HARRISON: There has been at least one
6 member that has been on every one of the teams.
7 Another member has been on every one except for one.
8 And then there is another member that has been on
9 almost all of them. It's been a fairly stable group.

10 There is only - the early ones I think had four
11 people that rotated among the three. The latter ones
12 are different four people, the same three plus a
13 different four. So there is fairly good consistency
14 of that review team, because it's review from one
15 application to another.

16 They make their determination. They write
17 up and document their results. They interact back
18 with the staff that actually did the detailed
19 technical review, especially if they are determining
20 that certain RAIs are not necessary to be able to make
21 a finding that the sumps will have adequate reasonable
22 assurance of performance.

23 And there is a loop that goes back and
24 forth with the technical staff and the IRT members.
25 They document their results, including minority

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 opinions, if there is a minority opinion. That comes
2 to the management for an ultimate decision on either
3 pursuing additional information from the licensee or
4 documenting why the generic letter is adequately
5 closed.

6 So this loops back around if there are
7 additional questions back to the licensee to provide
8 additional information; we'll come back to the process
9 again.

10 With that loop, then at what point does
11 the licensee reach an endpoint? And the simple part
12 is, basically when they have responded to all the RAIs
13 and provided all the information that is considered
14 sufficient ultimately by the IRT and the management
15 that they provide reasonable assurance that the sump
16 will actually perform.

17 DR. WALLIS: Now could you clarify, all of
18 this is accessible to the public?

19 MR. HARRISON: All the documentation goes
20 into a closure package, and I believe, I'm not sure,
21 maybe the staff could help me on this, is all that
22 information made publicly available, the IRT
23 documentation?

24 MR. RULAND: To my knowledge it is not
25 public at the moment. At this juncture, it's pre-

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 decisional.

2 DR. WALLIS: But eventually it will be?

3 MR. RULAND: We are going to take a look at
4 the packages and decide what parts of it can be
5 released to the public, and what should be pre-
6 decisional. Individual staff questions that staff has
7 decided that staff has asked kind of the - basically
8 the interrogatories may or may not be public. But the
9 final IRT package where they document their decision
10 about their bases, that will be public.

11 DR. WALLIS: So a student in a university
12 could get hold of a package and see what you did?

13 MR. RULAND: They would not necessarily get
14 all the questions that the technical staff asked
15 themselves.

16 DR. WALLIS: But they would get the
17 submittal and the decision?

18 MR. RULAND: That's correct.

19 DR. WALLIS: And the rationale for the
20 decision?

21 MR. RULAND: That's correct.

22 DR. WALLIS: Thank you.

23 CHAIRMAN BANERJEE: would they get any
24 proprietary information

25 MR. RULAND: No.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN BANERJEE: Like some licensees
2 obviously will do their own testing, right? So I
3 don't think that will be public.

4 MR. HARRISON: Right, we will still follow
5 all the normal rules on, if it's proprietary
6 information, you'd have to have a non-proprietary
7 version.

8 CHAIRMAN BANERJEE: So there would be data?

9 MR. HARRISON: There will be data. There
10 will be information.

11 DR. WALLIS: It won't just be words. It'll
12 be sort of hard core stuff that really proves
13 something.

14 MR. LEHNING: This is John Lehning of the
15 staff from NRC. There will be data. Most of the
16 numbers, like the final head loss values, that all is
17 nonproprietary. That is part of their licensing
18 basis, and stuff we review. So there would be a
19 substantial amount of data in those submittals.

20 And the licensee submittals are typically
21 already publicly available and on our website, so
22 those already are going to be reviewable.

23 MR. RULAND: And of course the RAIs are
24 publicly available.

25 MR. HARRISON: Right, when we issue RAIs

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 those become publicly available. There's also - the
2 licensees would need a response to any open items that
3 we identify during staff audits of specific plant
4 testing. There would need to be a final supplemental
5 response after all the testings and evaluations are
6 completed by the licensee to indicate that they
7 believe they've completed all that is necessary to
8 show that the sump performance is adequate.

9 And then there is this in-vessel
10 downstream effect that we are going to hear about from
11 Westinghouse. That W-CAP is still under review, or
12 under revision. It'll be coming to the staff in the
13 near future. All the licensees that rely on that W-
14 CAP will need to respond once that has been reviewed
15 and issued by the staff.

16 DR. WALLIS: Are we going to review that
17 again?

18 MR. HARRISON: That would be the
19 prerogative.

20 MR. KLEIN: Dr. Wallis, Paul Klein from
21 NRI. I think there is still a number of tests to be
22 performed, and I guess the expectation would be to
23 provide that data in the future along with the staff
24 assessment.

25 So at this point the topical report will

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 be revised, and the staff will review that revision,
2 issue a safety evaluation. So there is more
3 information to be gained in the future in that area.

4 CHAIRMAN BANERJEE: I guess he's asking,
5 will it come back to the ACRS? I guess it will.

6 MR. RULAND: That's your call.

7 MR. KLEIN: If you would like, I'm sure we
8 can come back.

9 MR. HARRISON: That would be your
10 prerogative, your decision.

11 Following the licensee's activity, the
12 closure activities for the staff includes reviewing
13 the supplemental information, RAI responses, in
14 accordance, following that closure process, a diagram.

15 The regions have conducted and will continue to
16 conduct inspections of the implementation of any
17 modifications that a licensee proposes; any other
18 commitments such as procedure changes or water
19 management or whatever the licensee proposes the
20 regional inspectors will follow that.

21 After we have gone through the process the
22 staff will issue a closure letter for each licensee
23 when we believe there is sufficient information to
24 close the issue for that plant. After we've closed
25 all the issues for all the plants, we will then come

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 back and issue a closure letter formally for the
2 generic letter.

3 I recognize that some of these closure
4 letters will be written for licensees that may have
5 proposed modifications in the future for their plant.

6 And so in some cases a plant may say, I'm going to
7 take fiber out of my plant, and remove insulation, in
8 a future cycle. That modification may not have been
9 performed when we actually close out that plant's
10 generic letter of response. However we will continue
11 to track the commitments for that plant to achieve
12 completion of their activities.

13 And the expectation is that we will
14 complete the generic letter activities next year,
15 2009.

16 Just a current status of where we are
17 again: all licensees have installed significantly
18 larger sump strainers. Many licensees have removed
19 insulation or replaced their sump buffer, some
20 licensees will be doing that in the near future.

21 And strainer testing activities have been
22 completed for many licensees. Some licensees will
23 continue to need to do some additional testing.

24 CHAIRMAN BANERJEE: So about how many
25 licensees, or roughly what percentage have completed

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 their strainer testing?

2 MR. HARRISON: Do you want to answer that,
3 Steve?

4 MR. SMITH: I could probably give you a
5 rough -

6 CHAIRMAN BANERJEE: Very rough.

7 MR. SMITH: Probably about - well, some are
8 going to have opportunities to answer RAIs, but I'd
9 say probably half are done.

10 CHAIRMAN BANERJEE: But the staff has sort
11 of satisfied themselves that these were roughly
12 typical and represent -

13 MR. SMITH: Well, I think that a lot more
14 than half are going to get RAIs, and will have to
15 satisfactorily respond to those before we would say
16 yes.

17 CHAIRMAN BANERJEE: So half have completed
18 testing but not necessarily got closure?

19 MR. SMITH: I think a lot more than half
20 have completed testing. I mean everyone, just about
21 every licensee has done testing, right? But my
22 feeling is that about half might be done; maybe less;
23 maybe more. We have to see the responses that come
24 back after we ask the questions.

25 MEMBER CORRADINI: So beyond testing, the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 other things in the second bullet, how many have
2 modified their insulation or changed their buffering,
3 which are more upstream things that would potentially
4 preclude -

5 MR. KLEIN: I can speak to the buffer
6 changes. There has been probably at least half a
7 dozen and probably less than 10 plants that have
8 changed buffer to try and reduce chemical effects.

9 MEMBER CORRADINI: And the insulation?
10 What buffer do they use now? Or do they just not use
11 it?

12 MR. KLEIN: The most common change has been
13 to switch to sodium tetraboride. Nobody has come in
14 and said that they are not using a buffer.

15 DR. KRESS: Okay, that's good. Because you
16 are trading one problem for another. Have there been
17 any studies of the sodium tetraboride, the chemical
18 effect?

19 MR. KLEIN: We have done a number of tests
20 at ANL that suggest sodium tetraboride may be one of
21 the best buffers. It really depends on the -

22 DR. KRESS: I'm sure it's a good buffer,
23 but does it - from the standpoint of not having
24 chemical effects on the sump.

25 MR. KLEIN: Yes, that's what I meant.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 DR. KRESS: Thank you.

2 (Comments off the record.)

3 CHAIRMAN BANERJEE: Carry on, Donnie.

4 MR. HARRISON: Most licensees requested
5 extensions beyond - the generic letter had an original
6 date to complete by December, 2007. Nearly all the
7 licensees requested extensions beyond that to either
8 perform integrated head loss testing including the
9 chemical effects to provide some downstream effects
10 analysis or to perform plant modifications.

11 MEMBER CORRADINI: I ask the second part of
12 this just to - the insulation part, did anybody have
13 some background there?

14 MR. SMITH: I don't have - John was going
15 to jump up here. He may have a number; I don't know.

16 MR. LEHNING: This is John Lehning from NRC
17 staff. A significant number of plants have done some
18 type of insulation modifications. Most plants haven't
19 like a wholesale replaced 100 percent of the
20 insulation in containment. But I'd say over half of
21 plants have done some sort of fiber removal,
22 miscellaneous material, or calcium silicate, have
23 taken that out in selected locations to mitigate
24 certain breaks.

25 CHAIRMAN BANERJEE: So the numbers as of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 last year that I have, now these might be out of date,
2 six plants were going to be engaged in software
3 changes; 15 insulation change outs; 20 major ECCS
4 mods; and 19 were looking at containment sprays.

5 These might be 2007 numbers. But they
6 probably change in 2008. And these were sort of
7 planned. Whether they were actually done, I don't
8 know.

9 MEMBER CORRADINI: Thank you very much.

10 MR. HARRISON: All plants submitted
11 supplemental responses to the generic letter in
12 February-March timeframe, and the staff is currently
13 in the process of reviewing those supplements and
14 providing RAIs or going to the RIT list to see if
15 there can be a determination to close out the generic
16 letter.

17 Currently the staff has informed a number
18 of licensees that are typically low fiber plants that
19 the staff has a few additional questions for them.
20 They could be looked at as essentially they have gone
21 through the process. We are not looping back around
22 with very many questions.

23 Those other plants we expect to receive
24 more RAIs, more questions on their testing and their
25 different technical issues in the 14 areas. In

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 addition most licensees are getting a place order RAI
2 dealing with the in-vessel downstream effects, since
3 most plants relied on the W-CAP to resolve that
4 aspect.

5 CHAIRMAN BANERJEE: Have any plants
6 actually resolved the downstream effects at the moment
7 with their own testing in lieu of W-CAP?

8 MR. HARRISON: I believe there was one
9 licensee's plant where we informed them that we would
10 not be asking them any questions. And that was
11 because they did not have a sufficient fiber loading
12 to create a problem downstream, as well as at the sump
13 spring. So --

14 CHAIRMAN BANERJEE: I guess what I'm asking
15 is, are all plants relying on this W-CAP to close out
16 this issue, or proceeding on their own?

17 MR. HARRISON: If not all nearly all.

18 MR. SMITH: There was one plant that did
19 significant testing on their own. Other than that
20 most plants are going to rely on the W-CAP.

21 CHAIRMAN BANERJEE: Just one plant?

22 MR. SMITH: Yes.

23 CHAIRMAN BANERJEE: And was this sort of
24 typical or any other plants, or was it just very
25 unique, this plant?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. SMITH: They are all kind of unique as
2 far as the debris loading is concerned. But it's a
3 typical bottom nozzle type of protective grid. They
4 will get into this a lot later on, the Westinghouse
5 presentation, and we have a later presentation that
6 will talk about this in-vessel in a lot more detail,
7 we'll have pictures on it.

8 MR. HARRISON: So to come to closure on my
9 part of the presentation, the staff established a
10 process for closing the Generic Letter 2004-02. We
11 believe that if we follow that process we will come to
12 closure.

13 DR. WALLIS: When you refer to this
14 process, this process is this diagram?

15 MR. HARRISON: Essentially the diagram,
16 yes.

17 DR. WALLIS: But that doesn't tell us
18 anything about what technical questions are going to
19 be asked, and have to be answered. Presumably you
20 have a much more detailed process which says, you've
21 got to show us ABCDEFG and all that sort of thing?

22 MR. HARRISON: The process - yes, when you
23 look at the box that deals with the detailed review
24 area, there are 14 different technical areas that are
25 being reviewed in detail.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 DR. WALLIS: Okay, so that is the
2 interesting part of the real process to me.

3 MR. HARRISON: Right, that part, and then
4 the feeding into the IRT are -

5 DR. WALLIS: And are you going to tell us
6 about that?

7 MR. HARRISON: We will hit on pieces of it,
8 but we are really focused here on the strainer
9 testing, which is going to be -

10 DR. WALLIS: But how do you relate the
11 testing to the reality in the plant?

12 CHAIRMAN BANERJEE: Do you have a list of
13 those 14 areas of review?

14 MR. RULAND: Not only do we have those 14
15 areas, we have some topical reports that have been
16 reviewed and approved for those areas. We have review
17 guidance for the individual reviewers.

18 So we provided substantial guidance to the
19 technical staff in doing this review.

20 MR. HARRISON: I'll give you a complete
21 list, but some of the items are - it ranges from the
22 break selection, debris generation, latent debris,
23 debris transport, head loss, coatings, structural
24 analysis.

25 DR. WALLIS: And then there is guidance on

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 all of these issues?

2 MR. HARRISON: There is a content guide.

3 CHAIRMAN BANERJEE: So can we do this? If
4 you would give Professor Wallis a list of these, and
5 if he needs any more information on any of these you
6 can ask for it. And get back on this.

7 DR. WALLIS: Is it just for me?

8 CHAIRMAN BANERJEE: Well, if there are any
9 other people on the committee who wants to see it.
10 Maybe the thing to do is to give it to David Besette,
11 and then that is available to anybody who wants to see
12 it.

13 But let's make sure at least that whatever
14 Professor Wallis wants gets to David Besette.

15 DR. WALLIS: That is a big open-ended -

16 CHAIRMAN BANERJEE: We have to bring it to
17 closure at some point.

18 MR. RULAND: David, when we provide this -
19 this is a substantial amount of information you are
20 asking for. So we will work with the committee to try
21 to provide this.

22 MR

23 . BANARJEE: Let's start with the 14 areas, just the
24 list. And then if much more is needed we will ask for
25 it.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. HARRISON: We'll do that. And just to
2 conclude again, there have been significant
3 modifications to prevent strainer blockage, and as you
4 will hear in a little bit there has been considerable
5 work on establishing conservative test protocols -

6 DR. WALLIS: I have another question, I'm
7 sorry. I'm going to get these areas. Do I get them
8 this morning, so I can ask questions about them? Or
9 do I have to wait?

10 MR. HARRISON: I can give you a list at the
11 break. And then we will come back with a content
12 guide later.

13 Again, I think we've established
14 conservative test protocols that can be used to show
15 satisfactory strainer performance, as I've said
16 before, and we are going to talk about today. The
17 investment downstream effects will be resolved as part
18 of the W-CAP review.

19 And with that I'll turn it over to Steve
20 Smith to talk about the head loss testing.

21 CHAIRMAN BANERJEE: Now before we go on,
22 you've got until 10:45 to finish. How many slides do
23 you have for your part of the presentation that you
24 need to get through by 10:45?

25 MR. HARRISON: We have 20 slides in the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 chemical effects area.

2 MR. SMITH: Approximately 45.

3 CHAIRMAN BANERJEE: Forty-five? Okay. It
4 should be possible, as long as the committee lets them
5 get through it, subcommittee.

6 DR. WALLIS: You're suggesting we don't ask
7 questions.

8 CHAIRMAN BANERJEE: You can ask questions,
9 not on every slide though.

10 MR. SMITH: If you could limit them to two
11 questions each that would be perfect.

12 MR. HARRISON: And easy questions we can
13 answer faster.

14 CHAIRMAN BANERJEE: Okay, let's go, Steve.

15 UPDATE ON GS-191 - STATUS AND FUTURE ACTIVITIES

16 MR. SMITH: Okay, Steve Smith. We are
17 going to talk about strainer testing.

18 Just an overview of what we are going to
19 be talking about. Strainer testing is being conducted
20 by almost all licensees to ensure that they have
21 adequate NPSH margin. They are using plant-specific
22 debris loads, and they are in sections of their plant-
23 specific strainer to do the testing, scaled down
24 sections.

25 We will go over the list, we will go over

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the current state of head loss testing. I will show
2 you a list of the strainer vendors and testers who are
3 doing strainer testing.

4 We will summarize the results of our
5 generic letter 2004-02 head loss reviews, and how we
6 see the process going forward. And we will talk about
7 the biggest areas of concerns that we identified as we
8 were going through the head loss testing process and
9 trying to get the vendors and the staff to see eye to
10 eye on good test procedures. And then we'll share
11 some information on review guidance that we put out
12 for head loss testing, and we'll go over the path
13 forward.

14 CHAIRMAN BANERJEE: Is this a fairly large
15 thing, or is it something that we close which is - we
16 could transmit - the review guidance that you have
17 given us?

18 MR. SMITH: The review guidance, it's about
19 60 pages. And we have review guidance for head loss
20 testing, chemical effects, and we also have review
21 guidance in the coatings area. So those are three
22 specific areas that we've put review guidance out to
23 help the industry with the testing, and how they do
24 the evaluations.

25 CHAIRMAN BANERJEE: Okay, let's move on.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 If we want to see some of this we can.

2 MR. SMITH: Okay.

3 The current status of head loss testing,
4 we believe that most of the strainer testers and
5 vendors have developed protocols that will give either
6 prototypical or conservative head loss results when
7 they test a strainer.

8 Because there are a lot of significant
9 unknowns in how the bed will form in the plant, and
10 other factors that affect the head loss, the staff has
11 pushed the vendors into what we believe are relatively
12 conservative test protocols.

13 DR. WALLIS: Question?

14 MR. SMITH: Yes.

15 DR. WALLIS: What is conservative for head
16 loss may not be conservative for bypass.

17 MR. SMITH: That's true.

18 DR. WALLIS: How do you cover this sort of
19 two-dimensional space?

20 MR. SMITH: In general the bypass testing
21 and the head loss testing are separate tests, okay?
22 And we'll talk about bypass testing later today in the
23 other presentation, okay?

24 There are some vendors -

25 DR. KRESS: But you think the head loss is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the critical issue compared to that?

2 MR. SMITH: Well, both issues are critical
3 and important. The bypass is important for the
4 downstream in-vessel effects.

5 DR. KRESS: But you think you could
6 optimize the head loss and still live with the bypass
7 problem? Is that the approach?

8 MR. SMITH: I think what we try to do is,
9 we try to make the bypass testing be conservative, and
10 the head loss testing be conservative. And they are
11 done separately. So does that make sense?

12 CHAIRMAN BANERJEE: The screen area is
13 quite a bit larger than the core flow area, so you've
14 got to have a screen to take something out.

15 MR. SMITH: And one thing that we've seen,
16 the tests that we've recently observed have been a lot
17 better than earlier tests that were conducted.

18 Some vendors haven't provided adequate
19 assurance that their current protocols will provide
20 conservative and prototypical results, and those - the
21 people who are using - or the licensees that are using
22 these protocols are going to get some probably
23 relatively difficult RAIs from us.

24 DR. WALLIS: I can see how you can perhaps
25 get assurance of conservatism. I don't understand how

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 you make sure it's prototypical, because you have all
2 kinds of flow patterns and distributions within the
3 sump region.

4 MR. SMITH: I agree.

5 DR. WALLIS: Which really cannot all be
6 duplicated in a test, can they?

7 MR. SMITH: And that's why we would say it
8 would range anywhere from conservative to
9 prototypical.

10 DR. WALLIS: Well, maybe the word,
11 prototypical, shouldn't be there, because I'm not sure
12 you could do it. Conservative I understand, I think.

13 MR. SMITH: I would say if you ask these
14 guys back here they probably think we are really
15 conservative. But it probably tends more towards
16 conservatism.

17 DR. WALLIS: I would think so. Are there
18 any that are truly prototypical?

19 MR. SMITH: Well, some of the testing I
20 think is actually quite prototypical. However there
21 are a lot of other conservative assumptions that go
22 into the entire analysis, and that is how much debris
23 is generated; what the debris looks like. I mean
24 there are a lot of unknowns there, so we are pretty
25 conservative with a lot of those inputs.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN BANERJEE: I guess prototypical
2 might mean prototypical conditions in terms of
3 approach philosophies or whatever.

4 DR. WALLIS: Yes, some things will be
5 prototypical, but not everything perhaps.

6 CHAIRMAN BANERJEE: But the debris loading
7 and all might be very conservative.

8 MR. SMITH: The third item there is that
9 some plants are relying on testing that was conducted
10 prior to the development of the more conservative
11 protocols. And these licensees are also going to get
12 some RAIs if they don't upgrade their testing with the
13 newer protocols.

14 CHAIRMAN BANERJEE: But roughly you were
15 saying about half of them have done things which even
16 though they'll get some RAIs back they've done it
17 under conservative prototypical conditions, and about
18 half of them are still doing it?

19 MR. SMITH: That's probably about right.
20 We'll have to see how the responses come back.

21 CHAIRMAN BANERJEE: I'm just trying to get
22 a feel for the magnitude of the problem right now.

23 MR. SMITH: Right. A lot of the testing -
24 most of the testing that has been done this year by
25 licensees has been conservative. Testing that was

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 done before 2007, or 2007 and before, may not have
2 been done under a conservative procedure.

3 CHAIRMAN BANERJEE: And these take chemical
4 effects and all these exhaust things into account?

5 MR. SMITH: Yes.

6 CHAIRMAN BANERJEE: Using surrogates if
7 necessary?

8 MR. SMITH: Yes.

9 CHAIRMAN BANERJEE: Okay.

10 MR. SMITH: And we have witnessed a number
11 of head loss tests at each vendor or tester, and we've
12 incorporated the lessons that we've learned from these
13 into our review guidance and into our reviews of the
14 generic letter submittals.

15 Okay, this is a list of the people who are
16 doing the trainer testing. Five of them, the first
17 five are also vendors, or associated with vendors, and
18 the second, the bottom two are just test vendors that
19 have done tests for a relatively small number of
20 clients.

21 MR. RULAND: Mr. Chairman, just as a piece
22 of information, we have a detailed matrix that
23 basically contains the status of every plant, RAIs, et
24 cetera. So we'll give you a copy, and we'll make sure
25 that we distribute that to the committee.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN BANERJEE: Thank you.

2 MR. SMITH: We have reviewed most of the
3 supplemental responses that have come in from the
4 plants, probably two-thirds to three-fourths of the
5 supplemental responses; the other ones are still under
6 review. But most of the licensees are getting RAIs in
7 the head loss area.

8 CHAIRMAN BANERJEE: The test vendors are
9 the actual people who make screens? Or are they
10 separate?

11 MR. SMITH: The testers, the top five
12 there, the five main test vendors, are associated,
13 some, like Alion tests the Enercon screeners, right,
14 but these other ones here test their own screeners,
15 the next four.

16 DR. WALLIS: So the people testing are the
17 same people as the people who sell?

18 MR. SMITH: Yes.

19 DR. KRESS: Sounds like a conflict of
20 interest.

21 CHAIRMAN BANERJEE: That's the first five,
22 right?

23 MR. SMITH: Yes.

24 CHAIRMAN BANERJEE: Wylie and Fauske are
25 independent; they don't make it?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. SMITH: Wylie and Fauske are
2 independent; that's correct. And that's why we're
3 going out to watch these guys, because you don't want
4 to have any conflict of interest there.

5 Okay, for the licensees that tested with
6 the more recent and conservative procedures, they are
7 not getting a lot of RAIs. They are probably getting
8 some RAIs to document some things that maybe they left
9 out, or just to ensure that they actually used a
10 conservative procedure when they did the test.

11 And then for the plants that did testing
12 with older protocols that weren't as conservative,
13 they are going to get significant RAIs, and some of
14 these plants are going to need to do some additional
15 testing probably to adequately address the RAIs; at
16 least that's our feeling. We have to wait until the
17 information comes in from the plants, but that's the
18 way we feel about that right now.

19 DR. KRESS: Have we heard what the current
20 protocol is? Are we going to hear that?

21 MR. SMITH: It's probably, it's kind of
22 complicated. There are a lot of things that go into
23 it, and there's - every plant has a different debris
24 load, and each strainer type may have some different
25 ways that it would be tested. Some vendors use -

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 allow settling of debris during the testing, so they
2 have different things they have to deal with. Each -

3 DR. KRESS: Is this protocol documented in
4 some sort of document?

5 MR. SMITH: Each vendor has their own
6 protocol, and they tailor that protocol to each plant
7 that they test. So there is a lot of variability to
8 how the plants are tested, depending on their plant-
9 specific -

10 DR. KRESS: You guys have reviewed all
11 these protocols?

12 MR. SMITH: We have not reviewed every
13 plant's protocol. We have reviewed at least one of
14 every test vendor's protocol, and usually more than
15 one, and how that related to a specific plant. And we
16 assume that if they are testing Plant X properly, that
17 they probably are going to do okay on Plant Y.

18 CHAIRMAN BANERJEE: I guess one of the
19 things that the subcommittee had concerns on was to
20 allow the settling to occur, because it's very hard to
21 estimate in plant conditions, or turbulence
22 conditions. So one bounding thing would be to say
23 that you estimate a certain amount of debris, which of
24 course is an estimate, allow it all to be suspended
25 and brought to the - so that would be sort of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 extremely conservative, of course. But it would be a
2 bounding case.

3 MR. SMITH: Yes.

4 CHAIRMAN BANERJEE: And in some cases we
5 sort of suggested you might want to do that rather
6 than allow for settling. Now clearly what you are
7 saying is that some of the vendors are taking account
8 of this settling.

9 MR. SMITH: Yes.

10 CHAIRMAN BANERJEE: In their flumes, they
11 are allowing it. That is very hard to guarantee for a
12 prototypical -

13 MR. SMITH: I have a slide that will talk
14 about that a little bit. There is one vendor in
15 particular that uses settling for all their tests, and
16 in general, most of the other vendors do the stir
17 test, although not in all cases.

18 CHAIRMAN BANERJEE: I mean in reality of
19 course there will be settling. It's very hard to
20 estimate.

21 MR. SMITH: Right, that's why we've been
22 kind of hard on the vendors that use settling. We
23 look at that a little bit more closely. Although
24 there are issues that can occur when you are stirring
25 something and you have too much current near the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 strainer it could wash the strainer clean and cause
2 the head loss to be lower. So there are pluses and
3 minutes to the ways tests are done. There are a lot
4 of different -

5 CHAIRMAN BANERJEE: Okay, well, let's move
6 on, but I think we understand that you are taking
7 cognizance of this.

8 MR. RULAND: Just for clarification, the
9 staff is not - there were no topical reports submitted
10 for these protocols, and the staff did not review and
11 approve them. What the staff did was observe the
12 testing and made comments to the vendors until we were
13 satisfied that our issues were addressed. And it's
14 because of the nature of how this issue has played
15 out, right. The strainers were first installed, and
16 then the engineering was done subsequent, and we've
17 been trying our best to get this done. So it's a
18 little unusual; it's not the typical staff approach.

19 CHAIRMAN BANERJEE: Right, but we agreed to
20 that.

21 MEMBER MAYNARD: And I believe you said
22 earlier, you have detailed guidance for your review of
23 these?

24 MR. SMITH: Yes, we have a content guide
25 which is sort of a general guidance for us, how to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 review what comes in. But we have something called a
2 review guidance, which is what I said we have in three
3 areas. And in the head loss area, that has taken into
4 account everything that we have learned. It covers
5 the testing that's done, and it also covers like what
6 you do with the data afterwards, how you evaluate it,
7 things like that; you know, test termination criteria,
8 how you can extrapolate and see where this thing would
9 go after 30 days, things like that.

10 DR. WALLIS: Well, that's the important
11 part, isn't it?

12 MR. SMITH: Yes.

13 DR. WALLIS: I mean testing is one thing,
14 but you have to be clear, what is the output of the
15 test that is useful?

16 MR. SMITH: It's both very important. I
17 mean the test has to be good, and what you do with the
18 data also has to be good.

19 DR. WALLIS: You almost have to start with
20 what you need from the test. You need to duplicate
21 certain plant conditions. You want to get the maximum
22 head loss, maximum possible flow or something.

23 MR. SMITH: That's correct.

24 DR. WALLIS: And specify what your output
25 needs to be.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. SMITH: That's correct.

2 DR. WALLIS: And you are sure you are doing
3 that?

4 MR. SMITH: Yes.

5 DR. WALLIS: Can we see that too, somehow?
6 Can we see the guidance for what has to come out of
7 the test?

8 MR. SMITH: I think the review guidance
9 would be something that you would be very interested
10 in looking at.

11 DR. WALLIS: Could we see that?

12 MR. SMITH: I've got that on my list as
13 well.

14 DR. WALLIS: Because I was a bit surprised
15 that nothing was said prior to this meeting we could
16 look at.

17 MR. SMITH: It's public.

18 DR. WALLIS: They're very useful when you
19 have these meetings, if we can look at what we are
20 going to discuss beforehand.

21 MR. SMITH: This review guidance is public,
22 right?

23 DR. WALLIS: Yes, but I'm not going to look
24 through all the public information and find something.
25 You have to give it to me.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN BANERJEE: Well, Graham, we tried
2 - I mean I guess this meeting was work in progress.
3 We tried to get the slides in advance, but there was
4 some reason why you couldn't, David, right?

5 DR. WALLIS: It's very inefficient. If you
6 send me something after the meeting and I look at it
7 and I have questions that could have been asked at the
8 meeting, then we have to have another meeting.

9 CHAIRMAN BANERJEE: Well, let's limit the
10 number of meetings.

11 MR. SMITH: I think the important thing is
12 that we will have the review guidance for you, but
13 it's important that it's available for the licensees
14 and vendors, because they are the ones who really need
15 to use it. So we'll get the information.

16 These are - this slide is a list of the
17 key technical issues. I'm not going to say it's all
18 of them, because there are a lot. But these are the
19 main technical issues, the most significant areas that
20 we identified issues with when we went out to review
21 strainer testing at vendors.

22 And most fo the strainer testers or
23 vendors have revised their procedures to address these
24 issues.

25 This slide is on the head loss review

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 guidance that we were talking about. And I agree,
2 this is a very important document. It was issued, I'm
3 not sure when the original issue was, but we updated
4 it in March - September, '07, okay was the original
5 issue - we updated it in March to incorporate a lot of
6 the lessons learned that we learned when we went out
7 to see strainer testing.

8 As we said it's publicly available and it
9 covers testing and evaluations. And we think that if
10 the licensees and vendors use this review guidance
11 that they are going to end up with a conservative test
12 result and evaluation of the result.

13 ON the path forward, plants that have
14 RAIs, we are reviewing the generic letter responses
15 now. Plants are getting RAIs on this, and they are
16 going to have to provide acceptable responses to the
17 RAIs, which may require additional analysis or
18 testing.

19 Some licensees that have had unacceptable
20 test results using the more conservative tests have
21 realized that they are going to have to do something.

22 So what we are doing, generally these licensees are
23 coming in for extensions, so when they come in and ask
24 for an extension to do additional work in their plant,
25 we ask them to test for success. So that's sort of a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 new - I guess that's a little term we came up with.
2 And that means, what they are going to do is, they are
3 going to go to their test vendor, and they are going
4 to test various plant configurations until they come
5 up with an acceptable test for their screener.

6 And then once they figure out what that
7 acceptable plant configuration is they are going to go
8 forward and modify their plant. So what we are doing
9 in this case is, we are preventing them from going
10 out, saying we are going to take X insulation out,
11 testing that condition, doing that, and then coming
12 back in a year and saying that they are going to have
13 to do another modification. We are going to make sure
14 that they are getting to the end of the modification
15 process by doing the test to success.

16 Some plants are in the test to success
17 they will either be doing analytical changes, or they
18 will be physically removing debris sources from
19 containment in general, insulation, or they may be
20 installing debris interceptors or other modifications
21 to reduce the debris getting to the strainer.

22 And in general the plants are committing
23 to do this at the next available refueling outage.

24 CHAIRMAN BANERJEE: There will also be a
25 change to the buffer.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. SMITH: There could be a change to the
2 buffer, that's correct. Some plants are changing the
3 buffer.

4 Now we have some movies to show you -
5 actually not full-length movies, but short movies
6 here. The first shows debris introduction at CCI.
7 This shows very fine debris, which we believe is the
8 most conservative, the finer debris, and you can see
9 the debris going in.

10 DR. WALLIS: It's still a bucket technique?

11 MR. SMITH: It's a bucket technique, but
12 you can see how this goes in, and it's basically a
13 cloud, and it transports slowly to the strainer, and
14 it's going to cover the strainer rather uniformly.

15 DR. WALLIS: Is it sinking?

16 MR. SMITH: Now, I will say, since you say
17 it seems to be sinking, this is now particulate going
18 in. Since these -

19 DR. WALLIS: This is in a plume which
20 doesn't have much turbulence.

21 (Simultaneous speakers.)

22 MR. SMITH: In general the turbulence is
23 relatively low, depending on the location in the sump
24 flow. I mean there could be drainage coming down into
25 the sump creating turbulence. But the velocities are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 very slow in the sump.

2 CHAIRMAN BANERJEE: Well there was some
3 German test that was done. The water falls.

4 MR. SMITH: The water falling from the
5 break.

6 CHAIRMAN BANERJEE: Yes, that creates quite
7 a lot of turbulence.

8 MR. SMITH: Okay, what these guys do in
9 their test is that -

10 DR. WALLIS: Who are these guys?

11 MR. SMITH: This is CCI, okay. And I think
12 some of the HR went for that. After the debris goes
13 in, if any debris settles on the bottom of the plume,
14 they stir it up, with a drill-driven propeller. So
15 this is one of those tests that you were talking about
16 where all the debris eventually gets to the strainer.

17 DR. WALLIS: So these are ones done in
18 Switzerland, are they?

19 MR. SMITH: Yes, Switzerland.

20 MEMBER CORRADINI: So the intent here is to
21 keep whatever they put in fluidized and in the liquid?

22 MR. SMITH: That's correct. So it's
23 conservative with respect to - none of the debris -
24 there is always going to be a little bit of settling.

25 But almost none of the debris is allowed to settle in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the bottom of the flume, and it all makes it to the
2 strainer.

3 MEMBER CORRADINI: So to go back to Tom's
4 question about this, so when they do a test such as
5 this their intent is to look at the configuration
6 within some sort of reasonable bounds that give the
7 maximum head loss?

8 MR. SMITH: That's correct.

9 MEMBER CORRADINI: And then they would -
10 with a given strainer design?

11 MR. SMITH: Yes, and plant loading, yes,
12 plant debris loading, yes.

13 MEMBER CORRADINI: And the plant debris
14 loading is specified by some sort of cookbook
15 formulaic predetermination of break size, area, stuff
16 influence -

17 MR. SMITH: Zone of influence, yes.

18 MEMBER CORRADINI: How it essentially gets
19 fragmented.

20 MR. SMITH: That's correct.

21 MEMBER CORRADINI: And that's all
22 predetermined by some reg guides that they follow?
23 I'm trying to understand how did they determine the
24 initial conditions that they are trying to stimulate?

25 MR. SMITH: I'm not sure it's a reg guide

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 on the debris -

2 MEMBER CORRADINI: What are they following
3 so that you feel comfortable?

4 MR. LEHNING: This is John Lehning from the
5 staff. Typically what plants have done is follow the
6 Nuclear Energy Institute 04-2004-07 guidance, and the
7 staff has written an SE on that. In some of them they
8 have other modifications to that, but that is the
9 basic method.

10 DR. KRESS: It's a large plate LOCA with an
11 area of influence here?

12 MR. SMITH: Yes. Zone of influence.

13 CHAIRMAN BANERJEE: I mean if you want to
14 go back to that point, I was reading the old ACRS
15 letters on this, John, and there was quite a dispute
16 on this zone of influence, impact velocities. Was
17 that ever resolved? I don't know what state it was
18 resolved at. I was just going over the history even
19 before my time.

20 MR. LEHNING: This is John Lehning again.
21 I wasn't at that meeting, but what our position was is
22 that this spherical model and the air jet testing that
23 was done is conservative. And there was an appendix
24 to the safety evaluation that discussed the reasons
25 that we came to that conclusion. And I know that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 there were differences of opinion on that during the
2 ACRS meetings. And one of the things that we are
3 looking at in a scoping study now in the boiling water
4 reactors is that we know that air jet testing was done
5 for that, and then now some two-face testing was done
6 for the PWRs to refine some of those ZOIs, and one of
7 the things that is part of that scoping study was to
8 look at the differences between those two, air versus
9 a two-phase. And I know there were other things with
10 that, the issues the ACRS had. I don't know that
11 those are a part of that, though.

12 CHAIRMAN BANERJEE: It might be worth going
13 back over that letter. Because those issues related
14 to I think some of the Sandia tests, and the two-phase
15 - you know, the water impact or whatever. So it was
16 interesting reading. I hadn't seen this letter. But
17 it was obviously not a closed question or a closed
18 issue.

19 All right, we can move on. So your point
20 is well taken, Mike, but there is some sort of way to
21 do it right now.

22 MR. SMITH: All right, we have one more
23 film. This is going to show a chemical debris
24 addition also at CCI, and this is basically just to
25 show you the flow pattern in the test flume, and it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 illustrates - it's a little bit more complicated
2 modeling, because this strainer has both a front and a
3 back side. The back side is against the containment
4 wall.

5 Now you won't see the backside for a
6 minute, but we will get around there.

7 DR. WALLIS: So this is now being injected
8 through a tube?

9 MR. SMITH: Yes, being injected through a
10 tube, the chemical surrogate is being put in, and what
11 we saw from this is that the chemical - and I have a
12 couple of pictures that I will show later - that the
13 chemical debris increases the head loss significantly,
14 and it causes the fiber to really compress.

15 DR. WALLIS: Now it seems to be there are
16 fibers on the screen already.

17 MR. SMITH: Yes, the chemical debris,
18 almost all testers put that in later.

19 DR. WALLIS: The chemical debris doesn't
20 sink; it just goes along with the flow.

21 MR. SMITH: Yes, it's pretty buoyant.

22 CHAIRMAN BANERJEE: And this is the WCAP
23 surrogate?

24 MR. KLEIN: It does sink over time.

25 CHAIRMAN BANERJEE: Is this a CCI surrogate? Why

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 do you put some in with a bucket and some in with a
2 tube?

3 MR. SMITH: The vendors have - you know,
4 they put different things in. Whatever probably works
5 best for them is what they do. And as long as it
6 seems to be going in in a prototypical manner that is
7 going to create prototypical -

8 DR. WALLIS: This is a different kind of
9 screen here? Looks like a vertical screen; is that
10 what we're looking at?

11 MR. SMITH: This is a vertical pocket
12 strainer.

13 DR. WALLIS: You're actually setting up a
14 circulation in front of it.

15 MR. SMITH: And this may be how the actual
16 flow pattern - because this - over here models the
17 containment wall, okay. So they have a big strainer,
18 and water flows in -

19 DR. WALLIS: Which I think is one of our
20 concerns, that the way the stuff approaches the screen
21 depends on the local geometry and all sorts of things
22 which are very different in different parts of the
23 plant.

24 CHAIRMAN BANERJEE: He says most of the
25 stuff is still suspended by this vortex, right?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. SMITH: Yes.

2 CHAIRMAN BANERJEE: It doesn't very much -
3 at least I didn't see very much settling.

4 MR. SMITH: And again if any debris
5 settles, they do stir it to get it back up in
6 suspension and allow it to get on the strainer, so
7 it's rather conservative from that perspective.

8 DR. KRESS: Where does the downstream water
9 go?

10 MR. SMITH: The downstream water, it goes
11 through the strainer, and it cycles back -

12 DR. KRESS: It resurfaces?

13 MR. SMITH: - into the upstream of the
14 strainer, yes.

15 Most of the tests are done that way.

16 MEMBER ABDEL-KHALIK: Are transient data
17 collected, or do they just generally wait until some
18 kind of steady state?

19 MR. SMITH: In general I believe all the
20 vendors are using a data collection system that
21 collects the data every - you know, between one and 10
22 seconds. So they are collecting flow rate. They are
23 collecting temperature. They are collecting head
24 loss, at a minimum.

25 CHAIRMAN BANERJEE: That's available, but

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 not necessarily being examined.

2 MR. SMITH: This is a bigger picture of the
3 flume that we just observed a test being done. And
4 this is not the same strainer. This is the strainer
5 we saw at the first. And there is a pump over here
6 that collects the water and pumps it back in here. So
7 basically we saw the debris going in over here and
8 collecting on the strainer. That's just to give you
9 an idea of how the testing is done.

10 DR. KRESS: What actually was the chemical
11 that was introduced?

12 MR. SMITH: I'm not sure what the chemical
13 was. Matt, do you remember?

14 MR. YODER: This is Matt Yoder, Division of
15 Component Integrity. For the test they used - the
16 white chemical surrogate was WCAP aluminum
17 oxyhydroxide.

18 DR. KRESS: It was a particulate?

19 MR. YODER: You could characterize it as a
20 particulate. But this is - maybe Paul can step in. I
21 don't think we would consider it a particulate. It's
22 more a hydrated - I guess we'd consider it an
23 amorphous hydrated precipitate, and it acts somewhat
24 like a particulate, but we think it can drive head
25 loss much higher than some standard particulates.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 It really is a function of the
2 filterability of the bed, so you can add chemical
3 precipitates to a test and see no head loss response,
4 or you can add chemical effects, precipitate, to a
5 test and see very high pressure drops.

6 DR. WALLIS: How about repeatability of
7 these? I mean I remember the tests that were done at
8 Pacific Labs where you put the stuff in different ways
9 in different order and you got order of magnitude
10 different results, which seems rather bothersome,
11 because it means you've got to do a lot of tests to
12 make sure you've covered the range of possible results
13 for the same stuff.

14 MR. SMITH: That's correct. And I think
15 repeatability is potentially a good question. But
16 what we do is, even though some vendors do several
17 tests for each plant under the same conditions, so we
18 have an idea of repeatability for them.

19 For vendors that don't do several tests,
20 we look at if they have plants that have similar
21 debris loads and how those compare.

22 The other thing that we do, you mentioned
23 the order of putting the surrogates in, we believe
24 that if the particulate is put in first it results in
25 a higher head loss. So generally our review guidance

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 says you should put the particulate in first unless
2 you have just a very limited amount of fiber; then you
3 can put it in together, because that would be
4 according to -

5 DR. WALLIS: But of course if you put the
6 fine stuff in first it goes through, and it goes
7 around the loop, it comes back and has another go at
8 the screen.

9 MR. SMITH: Yes.

10 DR. WALLIS: So it's not as simple as just
11 what you put in first, is it?

12 MR. SMITH: Well, the particulate in
13 general will pass through the strainer, and then a lot
14 of it even passes through the fibrous bed several
15 times until it gets taken out.

16 CHAIRMAN BANERJEE: Have any of these
17 vendors tried to develop a crude sort of model to try
18 to explain these results? Or do they just depend on
19 just pure testing?

20 Like what Graham says is something you
21 could put into some sort of a crude model.

22 MR. SMITH: We have this old 6224
23 correlation.

24 CHAIRMAN BANERJEE: Well, that's just a
25 correlation.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. KLEIN: We're not aware of anybody who
2 has developed a model because of the variability in
3 plant-specific debris. I think it would just be very
4 difficult.

5 MR. SMITH: No model other than the old
6 correlation.

7 DR. WALLIS: So without a model you have to
8 explain to us how you extrapolate to the plant.

9 CHAIRMAN BANERJEE: It was represented as
10 peace, I guess.

11 MR. RULAND: As everybody here knows, this
12 problem, ESI 191, frankly could be several lifetimes
13 worth of research. And we have decided, based on our
14 technical judgment, that these tests are good enough.
15 They are not perfect, but I think based on our
16 technical judgment these are good enough. And we
17 cannot - we need to resolve this issue, and we need to
18 resolve it with reasonable assurance.

19 So what you are seeing is the staff's
20 judgment about what is reasonable assurance to decide
21 whether the sumps are adequate or not.

22 Thank you.

23 CHAIRMAN BANERJEE: Hopefully a little
24 conservative.

25 MR. KLEIN: I think one of the ways to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 relate it to the plant is, it's a plant-specific
2 debris mixture. The plants typically, the vendors
3 test for the limiting condition whether that's a thin
4 bed or a maximum type debris, and then it's introduced
5 in a way that through testing we've observed produces
6 the highest head loss.

7 MR. SMITH: And we use a plant prototypical
8 of screen approach velocities, things like that, is
9 what we ensure.

10 DR. WALLIS: This reasonable assurance for
11 the stuff, that's very good. You are professional
12 people; you need to be assured. How do you achieve
13 reasonable assurance for members of the public?

14 MR. SMITH: Well, hopefully that's the same
15 thing.

16 DR. WALLIS: Well, I'm not sure as to how
17 you make it the same thing, because the public would
18 have to have access to the same information you have.
19 They'd have to think along the same lines.

20 MR. KLEIN: The public will have access to
21 most of the information that is nonproprietary at the
22 end of this process. So they will be able to look at
23 test results; they'll be able to see the staff's
24 assessment of an individual licensee and draw their
25 own independent conclusion.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN BANERJEE: Carry on - sorry, is
2 there another question?

3 DR. KRESS: Suppose we're wrong on all
4 this, and the plant undergoes a large plant LOCA, and
5 you notice the head loss is approaching something
6 unacceptable for net positive section head, is there
7 something then that an operator can do? Like reverse
8 the flow or some -

9 MR. SMITH: Some plants have a back flush
10 procedure written into their beyond design basis
11 procedures. I don't think all plants have done that.

12 But the other thing that has shown to be
13 effective, is just stopping and restarting the pump
14 sometimes. In the testing. It's never been done in
15 the plant of course.

16 MR. LEHNING: This is John Lehning from the
17 staff. In addition to that we look at the design
18 basis case, typically, without any accident pressure,
19 or even the air pressure before the accident occurs.

20 So in looking at that there are a number
21 of other margins that exist beyond what most plants
22 would even credit before they got to that point of
23 losing MPSH.

24 DR. KRESS: Well, that would be part of
25 this assurance that Graham raised on this.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. SMITH: Okay, this is basically a
2 picture from the first film we saw. This is post
3 drain down, so there is no water in the plume here.
4 This is a relatively low fiber plant. They would have
5 less than what we would call a thin bed. We found
6 that a thin bed could be a lot less, what we used to
7 call a thin bed was one-eighth of an inch of fiber.
8 We know that we can get high head loss with a lot less
9 than one-eighth of an inch of fiber now.

10 But after this test was completed and it
11 was drained down, we could see clean areas in the tops
12 and some of the sides of the strainers here. Most of
13 what you see here is chemical and particulate debris.

14 The fiber is really compressed onto these.

15 And this test I understand met the
16 acceptance criteria, although we haven't seen the
17 final evaluation for it yet.

18 CHAIRMAN BANERJEE: The white stuff is
19 obviously not the fiber. It's the fiber than that
20 back -

21 MR. SMITH: The fiber is under that. You
22 can't see it, right.

23 DR. WALLIS: What we see here is the
24 chemical on top of this?

25 MR. SMITH: You see some particulate and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 chemical, yes.

2 MR. YODER: This is Matt Yoder just to
3 clarify it. If you recall from the video we watched
4 there was a lot of gray particulate; that was epoxies.

5 So what you are seeing here is that epoxy particulate
6 mixed in with the white WCAP-type chemical surrogate,
7 and then that stuff is laying on top of the fiber. So
8 that's why it looks gray with some white showing
9 through.

10 CHAIRMAN BANERJEE: Now, before that stuff
11 started to - some of that fiber, going back to Said's
12 question really, did you all already get a very high
13 head loss with just that tin fiber matt?

14 MR. SMITH: The head loss for this test
15 overall didn't end up being extremely high. I think
16 it was a little over a foot of head loss. I'm just
17 recalling off the top of my head.

18 CHAIRMAN BANERJEE: Okay, but I guess the
19 question was, was that foot then already there before
20 this other stuff went on it? With just the tin fiber
21 bed?

22 MR. SMITH: No, in this case the fiber and
23 the particulate were added together, from the movie.
24 Remember, they put the fiber and the particulate in
25 basically at the same time.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN BANERJEE: Built up sort of almost
2 together.

3 MR. SMITH: Built up almost together,
4 that's correct.

5 And the other thing to note here is that
6 this particular licensee did not have to do a separate
7 thin bed test because their amount of fiber was so
8 small already they didn't have to do a separate test.

9 But licensees that have a lot of fiber also have to
10 test for a thin bed to make sure that doesn't give
11 them a higher head loss, because if you get a lot of
12 particulate built up in a smaller amount of fiber, it
13 can create almost like a clay or dirt-like bed that
14 creates a high head loss.

15 DR. WALLIS: Now there seems to be more
16 junk on the bottom of this pocket than on the top.

17 MR. SMITH: Yes.

18 DR. WALLIS: And on the far end there is
19 much less than on the sides. So clearly there is some
20 kind of flow pattern and distribution going on inside
21 the pocket. You can't just assume it's uniform.
22 There is something going on which distributes stuff
23 nonuniformly within the pocket itself.

24 MR. SMITH: It's possible. I would think
25 gravity has to play some effect.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 DR. WALLIS: Gravity has to play some
2 effect. It's low velocity. It looks as if it does,
3 because there is more stuff on the bottom.

4 MR. YODER: Matt Yoder again. So one thing
5 to keep in mind is that this is after drain down.
6 Some of this debris has fallen from the sides and top
7 to the bottom.

8 But then the other thing to consider is,
9 they are trying to credit this stuff, you know, maybe
10 accumulating more on the bottom so you have more open
11 area on the top, so that's one of the benefits of this
12 design and of a lot of the designs that you can have
13 some open areas and then have some other areas that
14 are completely engulfed in debris, because you can
15 still get flow through those cleaner areas.

16 CHAIRMAN BANERJEE: Yes, approach velocity
17 at the face is much lower - higher than the normal
18 velocity at the walls.

19 MR. SMITH: At the screen, yes.

20 CHAIRMAN BANERJEE: Because you have got
21 much more surface area in there. So you've got stuff
22 in, but then it might settle inside.

23 Anyway let's move on.

24 MR. SMITH: Okay, this is a picture we
25 say. Basically this is the movie; same picture that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 we saw in the movie. This is before the chemical
2 debris was put in.

3 And as you can see the fiber is really
4 fluffy in this picture, and it covers basically the
5 face of the strainer. You can see one place where the
6 DP got kind of high and it compressed -

7 DR. WALLIS: It seems to have layers as if
8 it were put on in stages . It has layers to it,
9 striations. It's got layers.

10 MR. SMITH: I don't think it's put on in
11 layers.

12 MR. YODER: I think what you are seeing
13 there is, this is the same kind of a grid that we just
14 saw in the other picture. What you are seeing there
15 is the outer faces of that grid kind of forming. The
16 lines that you are seeing there, I think that's what
17 you are seeing, not necessarily layers of different
18 batches forming.

19 MR. SMITH: It's a little bit hard to see
20 because it is out of proportion because you are
21 shooting through water. And it's actually a
22 rectangular piece there; it just doesn't look like it.

23 But there are pockets, so there's a grid there.

24 And at this point in the test the head
25 loss is relatively low.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 In the next picture, I'm sorry this
2 picture is not good. But this is after remember we
3 put the chemicals in in the movie. This shows what
4 happens. And you can see that as the chemicals
5 collect on the fiber it compresses the fiber and the
6 head loss goes up significantly.

7 DR. WALLIS: How big was the fiber before
8 this? Can you show on the movie, on the picture here,
9 where is the outer limit of the fiber bed was?

10 MR. SMITH: I'd say the fiber bed was
11 probably about an inch thick or so; does that sound
12 about right?

13 DR. WALLIS: No, on this picture here, was
14 it way out? The previous picture showed it -

15 MR. SMITH: It was probably out - something
16 - you know -

17 DR. WALLIS: So it's a different scale or
18 something? The previous picture showed it way out.

19 MR. SMITH: It's a different angle.

20 DR. WALLIS: It showed a thick thing like
21 that. The nuts give you some scale. Now how can we
22 look at -

23 MR. SMITH: The problem is, this picture is
24 shot from more - looking directly into the fiber bed.
25 With all the chemicals in there we couldn't shoot

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 from the same angle; we had to shoot right in an angle
2 like this, so I think it's hard to really tell.

3 DR. WALLIS: It looks as if it's shrunk; it
4 looks as if the whole bed is shrunk.

5 MR. SMITH: The fiber definitely compresses
6 when you get particulate or chemical debris it really
7 compresses, and that's what causes the higher head
8 losses.

9 DR. WALLIS: So why does it go into
10 pockets? It has to do with the design of the screen?

11 MR. SMITH: Right.

12 DR. WALLIS: The screen has pockets in it?

13 MR. SMITH: The pockets were always there;
14 they were just not visible because the fiber was -

15 DR. WALLIS: So the screen has pockets on
16 it?

17 MR. SMITH: Yes.

18 So the next one we talked about -

19 DR. WALLIS: Well, that's qualitative. Now
20 can you explain the result in a quantitative way. I
21 mean this is a very interesting thing. Questions
22 always arise about, what does this mean about what you
23 do in the plant? Are you going to require that they
24 assume the worst possible sequence of events or
25 something or what?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. SMITH: I think that's what we are
2 doing. The test is, we have the ability to know. We
3 make it as conservative as we can.

4 CHAIRMAN BANERJEE: What does this third
5 bullet mean, compared to CFD flows? I mean glows
6 generated by computational fluid dynamics?

7 MR. SMITH: What we do is, what this
8 particular vendor does, I'll just give a quick
9 explanation. The debris goes in way back here. The
10 strainer is here. It's I think about 40 feet from the
11 - this end of the flume to this end of the flume, so
12 the debris has to go 30 to 40 feet to reach the
13 strainer. This is one that allows settling.

14 What this vendor does is, they have taken
15 their CFD that is used for transport analysis in the
16 plant, and they have taken that CFD and they have
17 determined what the velocities are at places close to
18 the strainer, within 30 feet of the strainer. And
19 they build this flume to make the velocities change as
20 it's predicted by the CFD, and that's why the flume
21 gets wider and narrower, just to make the velocities
22 more representative of what would be in the plant.

23 MEMBER CORRADINI: So let me make sure I
24 understand this then. So what they do is, they try to
25 mimic their plant geometry with some sort of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 computational tool. Then they take the computed local
2 velocities from the computational tool and try to
3 reproduce them in this test plume?

4 MR. SMITH: That is correct.

5 MEMBER CORRADINI: And do they measure the
6 velocity so they know they get what they think they
7 get?

8 MR. SMITH: What they measure is, they
9 measure volumetric flow rate.

10 MEMBER CORRADINI: No, I'm talking about in
11 the flume. I want to know if they go through this
12 whole loop I want to know if they actually measured
13 what the computation said they should get.

14 MR. SMITH: They don't measure the velocity
15 in the flume.

16 MR. DINGLER: Steve, this is Mo Dingle.
17 For this one they actually measure the flow at each
18 individual point to validate it since this was the
19 first test they ran.

20 CHAIRMAN BANERJEE: I remember some very
21 hokey velocity measurements for sections that in the
22 past -

23 MEMBER CORRADINI: That's not judgmental,
24 is it?

25 CHAIRMAN BANERJEE: That's not judgmental,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 no. I assure you it would be hokey under any
2 judgment. So I'm sort of concerned about this
3 personally, but I don't want to hold up the discussion
4 because of this, what the prototypicality of this
5 might be compared to -

6 MR. SMITH: I will say that the vendor
7 attempts to put some conservatism into the - into
8 their comparison between the two. And I think that we
9 have questions. John might be better to -

10 MR. LEHNING: This is John Lehning from the
11 staff. It is something that we are aware of and we
12 are looking at carefully, and we've discussed this
13 particular aspect with the vendor in several phone
14 calls and made clear the idea that there needs to be
15 some conservatism not only from velocity but from
16 turbulence and other things like that.

17 CHAIRMAN BANERJEE: Okay.

18 MEMBER CORRADINI: So, I'm sorry, what is
19 conservative relative to turbulence? How do I know
20 it's conservative relative to the turbulence?

21 MR. LEHNING: This is John Lehning again
22 from the staff. We would use the CFD calculation
23 prediction of turbulence, and use that as a basis in a
24 test to compare that.

25 CHAIRMAN BANERJEE: But you wouldn't -

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 sorry, I didn't mean to interrupt you.

2 MEMBER CORRADINI: No, no, go ahead. You
3 are going to tell me the answer, so I just want to get
4 the answer.

5 CHAIRMAN BANERJEE: Yes, I'm just
6 wondering, I mean the CFD might not be very accurate
7 prediction. So clearly to be conservative you'd
8 probably want to enhance the turbulence in some way if
9 that's possible.

10 MEMBER CORRADINI: Okay, that's what I
11 thought.

12 CHAIRMAN BANERJEE: Is that what you mean
13 by being conservative with regard to the turbulence,
14 to assure more suspension?

15 MR. LEHNING: That's the idea. I think
16 that the way the CFD calculations are typically done,
17 they try to maximize those quantities and flow rates.

18 So our thought would be, because these CFDs are used
19 for transport overall not just for this that the
20 turbulence ought to be conservative in that CFD, and
21 then this test ought not to have less turbulence than
22 the CFD would predict.

23 CHAIRMAN BANERJEE: Yes, the whole issue in
24 this is of course what happens when the bottom
25 resuspends materials, the sheer stresses and the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 fluctuations. So in some sense it was stirred up now
2 and then, it would make me feel a lot more comfortable
3 than letting it settle out over this distance.

4 MR. SMITH: One thing that we did with this
5 test is, in discussing with how this test was run, we
6 were very specific with how the debris needs to be
7 prepared. We made the fine debris. We requested that
8 the fine debris be introduced first so that it would
9 not get hung up - like if larger debris had settled to
10 the bottom it would not get hung up on that; it would
11 have a better chance of transporting.

12 So we tried to add as many conservatisms
13 to the test method as we could.

14 CHAIRMAN BANERJEE: So this test requires
15 this settling in order to get an acceptable head loss?

16 MR. SMITH: I won't say that. I will say
17 that this test uses settling to determine whether an
18 acceptable head loss occurs or not. I'm not sure if
19 they stirred everything up maybe it would still pass.
20 Depending on the plant; I don't know.

21 MEMBER ABDEL-KHALIK: Now they try to match
22 the velocities that they calculates with the CFD code.

23 What is the characteristic dimension for this
24 process?

25 MR. LEHNING: The way that they do that for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 plants, they try to look at several what they consider
2 representative flow streams. So it is not necessarily
3 reproducing the exact geometry there, but intending to
4 look at directions where the debris may be
5 approaching, and then trying to take an average value
6 biased in a conservative way from their standpoint by
7 weighting the higher flow velocity channels.

8 MEMBER ABDEL-KHALIK: But there has to be a
9 length scale that determines this process, that
10 governs this process. And how do you match that?

11 CHAIRMAN BANERJEE: There has to be a
12 Reynolds number.

13 MR. LEHNING: I think that - I can't answer
14 - I don't know exactly. Maybe they have a vendor
15 representative that can talk about that. But I just
16 know that the way they do it is by matching velocity
17 rather than a length scale, and then by using the
18 velocity and turbulence as a basis to say the
19 transport is going to behave in about the same way as
20 in the plant.

21 DR. WALLIS: So what is the Reynolds number
22 in a test like this in various places?

23 MR. SMITH: We haven't calculated it.

24 DR. WALLIS: I mean you've got very low
25 velocities.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN BANERJEE: Very large length
2 scales.

3 DR. WALLIS: So it's a much lower Reynolds
4 number than in the plant because of the length scale.

5 Does this really have a big effect on the flow
6 pattern? These are questions you must have been
7 asking, I'm sure.

8 CHAIRMAN BANERJEE: The concern is that too
9 much stuff might settle out, really; that's the bottom
10 line. Because in a plant you've got all sorts of
11 vertical structures which re-entrain stuff, you know,
12 going around bends, and this, that and the other,

13 CFD is very very unreliable, because
14 probably they are using epsilon models which don't
15 sustain the Reynolds, which give rise to secondary
16 flows. So there is a whole bunch of stuff which
17 brings this under suspicion. And the concern you are
18 hearing, I think, is exactly that, that you know you
19 might be overestimating these types of settlings.

20 You may not; I mean it's hard to know.
21 Because the vortices also trap these particulates, you
22 know, you see them -

23 MEMBER CORRADINI: So let me ask you an
24 empirical question. Let's say I didn't believe the
25 computational quality, but I do two different scales,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 one larger and smaller scale, with the velocity
2 scaling to show that you've got the same settling.

3 In other words, throw out the models.
4 Let's take a protocol methodology that says, I've got
5 scale one and I've got scale two. I match velocities.

6 And I see they are based on matching velocities; the
7 same drop out. Or they are not the same drop out.
8 Some sort of empirical verification that things look
9 reasonable. That is kind of what I think we are all
10 going at.

11 CHAIRMAN BANERJEE: But even that is one
12 dimensional.

13 MEMBER CORRADINI: But still at least you
14 have an empirical observation that your thinking
15 process empirically is holding water, so to speak.

16 MR. SMITH: I am not aware of any testing
17 like that. The only thing that could be similar to
18 that is, there has been testing done with various
19 types of debris alone to determine at what velocity
20 that would generally settle out at. Like it's been
21 done with Nucon tread, various sizes, you know, RMI,
22 particulates, things like that.

23 MR. LEHNING: Just to add on to that, there
24 have been flume tests that have been conducted, and
25 there have also been what is called integrated

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 transport tests that were done on scale tanks that
2 were intended to represent a containment.

3 But I don't know that it looked at length
4 scales and Reynolds numbers to the extent that we are
5 going into now.

6 MEMBER CORRADINI: But I think Sanjay, the
7 chairman, said it right: the only reason we are
8 fussing about this is, we want to make sure you don't
9 get preferentially settling out because you reduce
10 scale but rather, you are trying to preserve something
11 so as you feel comfortable, you feel comfortable
12 because you have it scaled right; that's all.

13 CHAIRMAN BANERJEE: Yes, we had no problems
14 with your previous tests, because obviously you are
15 suspending most of the stuff. Here there is a
16 question of how much is dropping out.

17 MR. SMITH: I can tell you that - I don't
18 think this will answer all your questions. But tests
19 that have been run in this flume have ended up with
20 extremely high head losses that have required the
21 licensees to go back and reduce their debris loads.
22 So debris is transporting, and it's getting on the
23 strainer, and it's resulting in very high head losses
24 in some cases.

25 CHAIRMAN BANERJEE: Okay, I think we should

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 move on. You've heard what our concerns are.

2 DR. KRESS: When they go back and reassess
3 their debris loads, are they looking at the zone of
4 influence?

5 MR. SMITH: Yes. They may remove debris
6 from within the zone of influence. Some licensees are
7 installing debris interceptors instead of doing that,
8 because they think that is a more economical solution.
9 So various things are done.

10 But yes, they look at the zone of
11 influence.

12 DR. KRESS: And they have to decide where
13 the largest break LOCA is going to occur to do that?

14 MR. SMITH: What they would have to do is,
15 they would have to remove from every potential zone of
16 influence. So basically everything close in, you
17 know, into the reactors or steam generators, would
18 have to be moved.

19 DR. WALLIS: Can I go back to what you just
20 said? You said they got very high head losses if all
21 the debris went to the screen? So even with these
22 enormous screens which are 100 times as big as before,
23 if you put all the debris uniformly on the screen they
24 get head losses that are too high?

25 MR. SMITH: Yes, that's correct.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 DR. WALLIS: So they have to work then on
2 depositing the debris somewhere else, or not having so
3 much debris, or taking out insulation, or something?

4 MR. SMITH: That is right. Now I'm not
5 saying that their screens won't work now -

6 DR. WALLIS: But if you make the worst
7 possible assumptions.

8 MR. SMITH: Under the worst possible
9 assumptions, they need to - right.

10 All right, this is a picture of what we
11 would consider to be a nonprototypical debris
12 addition. And what you see here is, this is finely
13 prepared fiber, but it is very concentrated in the
14 bucket, so it's agglomerated. And the potential is
15 that it could fall down into the bottom of the flume
16 and not transport to the strainer.

17 So that's the concern we had with this.

18 DR. WALLIS: Well, using the bucket at all
19 is not so good. Because if you put in a large chunk
20 of stuff then the whole plume goes down. I mean a
21 plume from a bucket will tend to sink, because the
22 weight of each one of these things adds weight to the
23 plume. It's not the same as distributing it
24 uniformly.

25 MR. SMITH: What we've seen is, you can use

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 a bucket. For example the film we saw had that one
2 in. As long as the debris is not - as long as the
3 debris is not overly concentrated. As long as the
4 debris is almost flowing like water; that's what we
5 consider to be a more prototypical addition.

6 DR. WALLIS: Even then if you flow that in
7 from a bucket you get then a jet from a bucket which
8 is heavier than the surroundings; it sinks.

9 MR. SMITH: That's true. The momentum of
10 the water is going to carry it to the bottom, yes.

11 But I think that even under those
12 conditions, like where we saw it going from the bucket
13 in the film, that it's a relatively prototypical -

14 DR. WALLIS: So pouring rapidly from the
15 bucket is different from pouring slowly from the
16 bucket?

17 MR. SMITH: That causes more turbulence. I
18 don't know if that's good or bad.

19 DR. WALLIS: Are they instructed to pour
20 slowly or what?

21 CHAIRMAN BANERJEE: Slowly causes less
22 turbulence, but who knows. But you have asked the
23 vendor to change the introduction, right?

24 MR. SMITH: Right, what we requested this
25 vendor to do was to really test the concentration of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 debris, a lot more water with it, mix it up prior to
2 putting it into the flume.

3 CHAIRMAN BANERJEE: You reduce the density
4 so you try to reduce the settling?

5 MR. SMITH: Yes.

6 CHAIRMAN BANERJEE: But in general
7 introducing it as a plume is not a great idea, because
8 that is not a very prototypical way of introducing the
9 debris, and the plume itself has a density of its own
10 that drives it down.

11 MR. SMITH: That's correct.

12 Okay, and conclusions, we think that these
13 trainer testing methods have improved, and up to this
14 point some licensees have demonstrated acceptable
15 strainer performance as shown by conservative testing
16 as we have talked about.

17 Some licensees have learned that their
18 strainers won't survive these conservative tests that
19 we are doing, and they are working to reduce their
20 debris loads in the plant.

21 And some licensees are going to attempt to
22 stand on the current test results by responding to
23 questions that we've asked review of their submittals,
24 and we are just going to have to take their responses
25 on a case-by-case basis, and determine if we think the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 answers are acceptable.

2 CHAIRMAN BANERJEE: Now let me ask a
3 question regarding the chemical effects. If let's say
4 there are no chemical effects, and these tests were
5 done, would they still get unacceptable head losses
6 with these high debris loads?

7 MR. SMITH: I have observed tests without
8 chemical effects that ended up with very high head
9 losses.

10 CHAIRMAN BANERJEE: So it didn't require
11 the chemical effects to do that?

12 MR. SMITH: Yes. But one thing is that I
13 think, just from observing a number of tests, the
14 chemical tests work similarly to the worst
15 particulates, like CalSil or Microtherm or something
16 like that. So once you get the bed formed in a
17 certain way; you get all the little spaces filled up;
18 I don't know the chemical effects would have a huge
19 effect on that bed. It might not create a much higher
20 head loss.

21 DR. WALLIS: Well, some of the chemical
22 effects tests that have been reported by new research
23 sponsored by NRC seemed to show the bed essentially
24 being completely blocked, and the head loss rate went
25 up by a factor of 100, and the flow rate went down by

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 a factor of 10; essentially the thing is being -

2 MR. SMITH: Yes, I haven't seen one that
3 caused the flow rate to go down on one of these
4 complex strainers. In the vertical loops I think
5 there is a lot -

6 DR. WALLIS: Because it's uniformly
7 distributed?

8 MR. SMITH: Yes, it's a lot more uniform,
9 so you get a lot higher head loss.

10 CHAIRMAN BANERJEE: Thank you very much.
11 That was very information. Good progress has been
12 made since our last meeting.

13 So is it now Paul? Go ahead.

14 TEST RESULTS - REVISION OF WCAP-16793

15 MR. KLEIN: Good morning. I'm going to get
16 started on an update on the chemical effects.

17 I'd like to acknowledge the contributions
18 of my co-reviewer in the area, Matt Yoder; and also
19 the work that was done to support this presentation by
20 the people at ANL. Next slide please.

21 Today I'd like to break this presentation
22 into two major pieces. The first half discusses
23 industry's integrated head loss testing including
24 chemical effects, and we will talk a little bit about
25 some of the industry test approaches, and also our

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 assessment of the different approaches, and some of
2 the technical issues that have been identified over
3 time.

4 And the second half will focus on some
5 technical support that we have received from ANL, and
6 most of that testing was done in the 2007 and 2008
7 timeframe, so this is new information to the
8 subcommittee.

9 CHAIRMAN BANERJEE: Is this all vertical,
10 or did you do some horizontal as well?

11 MR. KLEIN: This was all vertical head loss
12 testing, and then a series of bench tests as well.

13 And then we will summarize the current
14 status at the end. Next slide.

15 Just a very quick progression of chemical
16 effects. Initially the IST series identified the
17 chemical precipitates could form in representative
18 environments, but those tests were not - did not have
19 an objective of measuring head loss.

20 So once we saw that precipitates could
21 form in some of the environments, we needed to move
22 into the head loss area. The initial tests that were
23 done by ANL and also some of the industry vendors
24 tended to be the vertical loop head loss tests.

25 And the early test results indicated you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 could get very high head losses when you apply
2 chemical precipitate on top of a fiber bed.

3 Since that time the industry approach to
4 chemical effect testing has been quite varied. I
5 think Steve in his earlier talk had shown a slide of
6 the main test vendors, and there is also two other
7 vendors that have done tests for single licensees.

8 So today I'd like to walk through the
9 industry test protocols. I've grouped them into five
10 main approaches that we will discuss in the next five
11 slides.

12 CHAIRMAN BANERJEE: How many - I know that
13 CCI is in Switzerland. Are the AREVA tests done in
14 this country?

15 MR. KLEIN: Yes, the AREVA PCI tests are
16 done in Massachusetts in Alden Laboratories.

17 CHAIRMAN BANERJEE: And ACL I guess is in -

18 MR. KLEIN: ACL is done at Chalk River.

19 CHAIRMAN BANERJEE: Okay.

20 MR. KLEIN: CCI is done in Switzerland.
21 The GEH tests have been done in New Jersey at a
22 subcontractor.

23 CHAIRMAN BANERJEE: And roughly how many
24 tests are done, I mean typically. Just to give us an
25 idea in each of these vendors.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. KLEIN: How many tests?

2 CHAIRMAN BANERJEE: Well let's say ACL, how
3 many systems?

4 MR. KLEIN: I think like ACL has done the
5 Dominion plants, and I think one other plant.

6 CHAIRMAN BANERJEE: So that's roughly how
7 many?

8 MR. KLEIN: It's pretty well distributed
9 among those top five.

10 CHAIRMAN BANERJEE: Fairly uniformly?

11 MR. KLEIN: Yes.

12 CHAIRMAN BANERJEE: That's what I was
13 looking for. And what about Wylie and Fauske? Are
14 they just one test each?

15 MR. KLEIN: Yes, they are for one licensee.
16 Wylie covered I think two plants, and the Fauske
17 covered one plant.

18 CHAIRMAN BANERJEE: These were completely
19 independent tests in some sense?

20 MR. KLEIN: Yes, there is a lot of
21 similarity in for example the Fauske test was a flume
22 test with WCAP precipitate added, so it was similar to
23 what we've seen approach in some of these other ones,
24 and we'll try to get to that in the next few slides
25 here.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN BANERJEE: Let's go on.

2 MR. KLEIN: Typically the way testing is
3 performed is it I think as Steve showed, a nonchemical
4 debris addition is done until a baseline debris bed is
5 established, and then chemicals are either added
6 directly or precipitate is added to try and account
7 for the chemical effects.

8 So test method one is the - uses the WCAP
9 16530 methodology, and in this case the surrogate
10 precipitate is prepared outside the test loop.

11 In this method one the objective is to
12 transport all debris including precipitate to the test
13 strainer. There is a list of the vendors that use
14 that approach.

15 As Steve mentioned, a lot of times there
16 will be agitation either mechanically or by flow, or
17 even people go disturb the flume bed during the course
18 of the test to make sure stuff is transported to the
19 debris bed.

20 CHAIRMAN BANERJEE: You mentioned earlier,
21 excuse me, the vertical test loops were to small scale
22 with the little disk. Now you are talking about
23 strainers. Now I would think you would have to do
24 both, because the worst case presumably is completely
25 uniform distribution, which is possible in a vertical

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 strainer if you have good enough mixing presumably.

2 So if you are taking credit for vertical
3 being different from horizontal, you've got to have
4 some way of modeling the stratification and settling
5 it seems to me; otherwise they should be the same.

6 MR. KLEIN: I think I am going to try to
7 shift some of the data from the vertical head loss
8 test, with the vertical head loss loop tests you have
9 no settlement. You typically get all the precipitate
10 that layers on top of the fibrous debris bed and
11 saturates the bed. And I think that's why you can see
12 much higher head loss response in those tests compared
13 to tests where you have a much larger strainer
14 segment, and the debris is dispersed, and the debris
15 bed typically is somewhat different than -

16 CHAIRMAN BANERJEE: It says, sticking at
17 the bottom and the top.

18 MR. KLEIN: You might have a nonuniform
19 flow such that you have quite a variance in debris
20 beds.

21 CHAIRMAN BANERJEE: But also within the
22 pocket itself, there is some, even if the external
23 turbulence is high within the pocket.

24 DR. WALLIS: If it has pockets. If it's
25 just a vertical stream -

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN BANERJEE: Then what you are
2 saying is -

3 DR. WALLIS: But it gets us back to the
4 question we keep coming back to, which is the flow
5 distribution in the real plant, and how uniform is the
6 deposit on the screen in the real plant with the
7 typical mixing that will occur in the real plant.

8 CHAIRMAN BANERJEE: Well, if you suspend
9 all the debris -

10 DR. WALLIS: Which is the same as
11 horizontal, shouldn't it?

12 CHAIRMAN BANERJEE: Well, within the pocket
13 itself it may not be.

14 DR. WALLIS: If it's a pocket strainer.

15 CHAIRMAN BANERJEE: If it's a pocket
16 strainer, yes. So I think those tests that you showed
17 of the pocket strainers seemed -

18 MR. KLEIN: All the strainers are
19 relatively complex shape. I mean they all have shelves
20 or whatever you want to call on them. Some of them
21 are -

22 CHAIRMAN BANERJEE: If they are just
23 vertical screens, I think what Graham is saying is
24 right; it may not matter that much.

25 DR. WALLIS: So you throw out all the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 results of the vertical head loss experiments?

2 MR. KLEIN: I think we use those to inform
3 the results of the other testing. And the other
4 testing, we make that as conservative - like we
5 discussed before, we make that as conservative as we
6 can.

7 DR. WALLIS: Does it ever approach the
8 vertical head loss loop results there?

9 MR. KLEIN: I haven't compared it.

10 I think, well, we have seen some very high
11 head losses in the larger scale tests, but typically
12 no. Typically chemical effects do not drive head loss
13 nearly as much as in the vertical head loss loop.

14 MEMBER SHACK: You clearly don't want to
15 design a strainer with horizontal surfaces.

16 DR. WALLIS: So you've got to understand,
17 why the difference, and why that difference would not
18 occur in a plant - why the difference would occur, why
19 the plant would not be like the vertical test. You
20 have to sort of assure yourself, get a reasonable
21 assurance the plant is not going to behave like the
22 vertical test loops.

23 MR. KLEIN: Yes, and I think one thing to
24 keep in mind, too, we always make the assumption that
25 you get tons of chemical precipitate that form, and in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 reality in the plant that probably will not occur,
2 because we are not crediting any type of solubility,
3 and in fact, in some of these cases for the plants,
4 you won't have the chemical precipitate to deal with,
5 even though it's predicted by the WCAP model and you
6 run a test and you measure head loss with that. So I
7 think it's important to keep that in mind.

8 For example during the ICET tests the
9 aluminum base precipitates really only showed up after
10 the solution was cold from the test temperature, and
11 we didn't see a whole lot of activity with the
12 aluminum hydroxides at the 140 degrees.

13 DR. WALLIS: Well, that would be true
14 equally well in the vertical test loop.

15 MR. LEHNING: This is John Lehning from the
16 staff. I think that the real reason to have
17 confidence in these differences between the vertical
18 loop and these other prototypical strainers if the
19 module testing that is done is just the full body of
20 testing that we've seen between these vertical loop.
21 And we've seen - or there have been conducted hundreds
22 of tests in this other geometry, and we have seen
23 these in basically all of these different tests, and
24 we know that the module array testing in the big tank
25 is designed to be, and is more prototypical of what's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 in the plant, and that has to do with nonuniformities
2 in the flow and using the actual geometries of the
3 strainers, and so that gives us that confidence.

4 CHAIRMAN BANERJEE: Well, I guess what
5 Graham is really saying, and maybe this is the issue,
6 that whatever you are doing, there should be a
7 rationale for accepting certain results and not; and
8 they should be clearly stated.

9 I'm sure that there are very strong
10 effects of a horizontal system compared to a vertical
11 system, but it should be clarified as to why you sort
12 of think that one is more prototypical than the other.

13 MR. KLEIN: I think when we get to the
14 completion of this we will have a very well documented
15 basis for why we think chemical effects have been
16 handled conservatively in these tests.

17 CHAIRMAN BANERJEE: Okay, let's move on.

18 MR. KLEIN: Okay, second slide.

19 The second test method is similar to the
20 first in that the WCAP surrogate precipitate is
21 generated outside the loop and added. The main
22 difference here is that the settlement is permitted,
23 so the technical issues become somewhat different
24 here, and of course some of the key things involved,
25 understanding that you have concerted flume flow

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 characteristics, and that your settlement in you8r
2 precipitate is not occurring in a way that would be
3 unprototypical of the plant. So I think what we've
4 seen for the most part, we have a very stringent
5 criteria on precipitate settling, in any type test
6 where settling is permitted. So I think you saw from
7 some of the video as well that there was almost not
8 initial settlement of precipitate solution when it's
9 added.

10 MEMBER ABDEL-KHALIK: I'd like to go back
11 to the issue that was raised earlier. On this slide
12 what would you consider to be conservative flow
13 characteristics for a flume?

14 MR. KLEIN: I think I will defer to John
15 Lehning on that question?

16 MR. LEHNING: I probably am going to - this
17 is John Lehning from the staff - I'll probably repeat
18 myself. But we would look at the computation fluid
19 dynamics calculation that had been done and assure
20 ourselves that the velocity and turbulence and flow
21 characteristics are conservative with respect to that
22 CFD calculation for the purpose of transporting
23 debris.

24 MEMBER ABDEL-KHALIK: What specific
25 parameters do you compare that would tell you that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 this is conservative vis-a-vis something else?

2 MR. LEHNING: The main things are velocity
3 and turbulence.

4 MEMBER SHACK: How much do they actually
5 try to predict in this calculation? Are they taking
6 credit for trapping settlement all through the
7 containment? Or do they take all the load up to 30
8 feet from the sump screen, and you've got full debris
9 there, and then they account only for the settling in
10 that well defined and well characterized geometry?

11 MR. LEHNING: There are two parts to that.
12 They do credit settlement in other areas of the
13 containment in their normal debris transport
14 calculation based on the CFD or whatever methodology
15 they're using; then they have that loading, and they
16 say we are going to add this to the test flume, and
17 then based on the CFD flows, whatever settles out
18 there in that region is also credited via the head
19 loss measurement.

20 CHAIRMAN BANERJEE: So I think you have our
21 concerns, John, about this.

22 With regard to the big stuff falling out,
23 no issue with that. It's really the fine material,
24 and to have that settle out due to a CFD calculation,
25 there is so little really understood about this, even

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 hindered settling and suspensions is very poorly
2 understood.

3 And it seems that what you are hearing
4 from us is it might be more conservative just to allow
5 all the fine stuff to go to the screen than to have it
6 settle out. That is for what it's worth.

7 MR. KLEIN: I think in general the fine
8 stuff does transport. From what we've seen when it
9 gets put in it's going down the flume, and it does get
10 to the strainer, and that is the reason why we set
11 certain parameters for the debris addition order, so
12 the fine stuff will go in first, so that it wouldn't
13 get hung up on larger debris that was already settled
14 in the plume.

15 MR. LEHNING: So I think we understand that
16 concern. That is something we are looking at
17 carefully, and we appreciate that comment.

18 MR. KLEIN: I think too it's not
19 necessarily a less conservative test if you end up
20 with a thin bed of fine fiber that is transported to
21 the strainer and then a chemical load on top of that.

22 There have been several licensees that had high head
23 loss with that test protocol. Next slide, please.

24 The third test method is somewhat
25 different in that the debris bed is generated in a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 similar way but the precipitate is formed in the loop.

2 This is the CCI-type approach. Instead of preparing
3 a WCAP surrogate outside the loop and then adding that
4 you add chemicals to the loop that cause the
5 precipitation process, and then that is - you saw in
6 the video that is transported to the strainer.

7 DR. WALLIS: When you have these chemical
8 effects in the loop, or in the sump, is gas involved?

9 MR. KLEIN: Not that I'm aware of.

10 DR. WALLIS: In the aluminum reactions,
11 isn't gas evolved?

12 MEMBER SHACK: Not in these particular ones
13 that you are using for these particular reactions. If
14 you are actually corroding aluminum, you are
15 generating hydrogen.

16 DR. WALLIS: Sodium hydroxide, you
17 presumably make gas.

18 MR. KLEIN: I think in these cases you are
19 adding the aluminum as dissolved species with sodium
20 aluminate, sodium silicate, and calcium chloride.

21 DR. WALLIS: You don't make bubbles when
22 you have the chemical reactions?

23 MR. KLEIN: I don't think so.

24 DR. WALLIS: Never? Because bubbles will
25 change things. They will make the particulate buoyant

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 and have other effects.

2 MR. KLEIN: The transport of the chemical
3 species to the strainer typically hasn't been a
4 problem in the tests. There doesn't seem to be
5 widespread settling of chemical precipitates in these
6 tests, and if there is they - our expectation is
7 unless they are trying to credit settling, they would
8 get that precipitate to the strainer anyway.

9 CHAIRMAN BANERJEE: This concern about
10 bubbles has been raised before. The issue really is,
11 I agree that the chemical precipitates are not going
12 to be affected much. Are there other debris which
13 could be like flakes and things which settle - might
14 settle out but do not due to that? Has there been any
15 assessment of that?

16 MR. KLEIN: Well, with respect to bubble
17 formation from aluminum corrosion, keep in mind that
18 most of the aluminum is above the flooded area in
19 containment. So your greater contribution is from
20 what's in the atmosphere, being wetted by sprays.

21 CHAIRMAN BANERJEE: All right, let me just
22 understand the timing situation. We want to also do
23 the chemical effects PIRT as part of this
24 presentation. So you've got quite a lot to get
25 through.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. KLEIN: Twenty three slides to go.

2 CHAIRMAN BANERJEE: Yes, and we've got only
3 about half an hour. All right.

4 MR. KLEIN: I will try to move more quickly
5 through the remaining slides here.

6 One of the issues that came up with
7 injecting chemicals of course is the way in which you
8 add them can affect the precipitate characteristics.
9 So one of the things we have been working with
10 individual licensees with this particular technique is
11 trying to get them to demonstrate that their test
12 produced precipitate that was expected by the bench
13 testing that supported the larger scale tests.

14 So we are evaluating this particular
15 method on a case-by-case basis. Next slide.

16 The fourth test method you develop the
17 chemical environment over a longer term. It's
18 typically done by adding dissolved aluminum over time
19 to try to match the plant specific projections for
20 aluminum dissolution over time. This is done by a
21 couple of different vendors as you see there.

22 Some of the issues: there was an issue
23 with one of these vendors with transport of
24 nonchemical debris to the strainer, which I'm not
25 going to elaborate on since it is not related to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 chemical effects.

2 The other question that comes into play
3 here is how well your debris bed filters the
4 chemicals. And also for this type of approach where
5 you are evolving the chemistry over time, the
6 expectation from the staff is that you have a very
7 solid technical basis to support your plant specific
8 additions.

9 And in both of these approaches the
10 affected licensees did a number of smaller scale tests
11 to assess the corrosion rate of aluminum and develop
12 their own projections for aluminum over time that was
13 separate from the WCAP approach.

14 And this again is a -

15 CHAIRMAN BANERJEE: And the staff looked at
16 this carefully?

17 MR. KLEIN: Yes, we have received reports
18 from each of the test vendors, or each licensee, I
19 should say, that provided the results of their tests.

20 And then we had a series of discussions with each of
21 them.

22 We are reviewing these on a case-by-case
23 basis. The goal here is to make sure a licensee has
24 demonstrated why their overall tests produces a
25 conservative evaluation foe chemical effects.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Test method five is similar to a mini-ICET
2 type test, the environments develop by leaching
3 debris, either metallic corrosion or leaching from
4 nonmetallic insulation materials over time.

5 Several issues related to this approach
6 had to do with primarily debris bed formation. The
7 objective fo the test was to develop a chemical
8 effects bump up factor for this given test that could
9 be applied to a previous array test in a tank that did
10 not include chemical effects.

11 Overall the summary is that based on the
12 number of issues that were involved, we indicated that
13 - we've reached the conclusion that an alternate
14 approach is needed in this case, so we've contacted
15 the affected licensees, and we are expecting to hear
16 back from them in October what the alternate approach
17 may be. Next slide.

18 DR. WALLIS: What is the hope that the
19 alternative approach will be okay? Are there some
20 indications that there is one?

21 MR. KLEIN: It's more than a hope. We
22 think that there has been enough information generated
23 through the course of chemical effects testing, and
24 there is review guidance available, that there will be
25 a success path developed by that particular set of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 licensees.

2 Next slide. I'm sorry, current slide.
3 You are given the varied industry approaches to
4 chemical effects testing, and pretty much the dynamic
5 nature of how these test protocols have evolved over
6 time, and or tried to get some technical support in
7 the chemical effects area.

8 And in particular we established contracts
9 with environmental management support to contact Dr.
10 Bob Whitman, and also with ANL. Dr. Whitman has been
11 helping us with his chemistry expertise and also in
12 helping to review some of the GL supplements that have
13 been received by the licensees.

14 ANL's support has been more related to
15 testing. They also supported the chemical effects
16 review guidance that was developed.

17 In particular some of the things that we
18 asked them to do given the number of different ways
19 that precipitates are formed in the industry,
20 approaches, we asked them to try and do some type of
21 relative assessment in the vertical loop head loss
22 test.

23 We also asked them to evaluate long term
24 solubility of aluminum, in the relevant environments,
25 including the potential for precipitation possibly

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 occurring by rapid thermal cycling.

2 And we also asked them to evaluate the
3 stability of the WCAP surrogate as a function of pH,
4 since we noticed that in some of the industry flume
5 tests even though it would start with a more neutral
6 pH dissolution of CalSil or other insulation debris
7 could cause the pH to drift more alkaline over time.
8 So we wanted to make sure that we weren't adding what
9 we thought was a very conservative surrogate, and then
10 over time having it dissolve in higher pH.

11 DR. WALLIS: Weren't there some French
12 tests in which the fiber glass dissolved
13 significantly? I think I read about something there,
14 they weighed the fiber glass before and after, and
15 quite a bit of it had dissolved.

16 MR. KLEIN: I think you will see some
17 dissolution of fiber glass, particularly in the higher
18 pHs, like if you have a sodium hydroxide type buffer.

19 DR. WALLIS: That doesn't lead to
20 precipitation?

21 MR. KLEIN: It can add to your chemical
22 load; that's one of the things that needs to be
23 accounted for when they look at how much precipitate
24 is predicted on a plant specific basis. The
25 spreadsheet looks at your pH and then looks at how

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 those different materials performed in the very
2 smaller scale tests that Westinghouse performed.

3 DR. WALLIS: But did you look at this other
4 data from overseas?

5 MR. KLEIN: No, I don't believe so.

6 DR. WALLIS: I was surprised. It was one
7 of the surprising results of the French tests seemed
8 to be -

9 MEMBER SHACK: Actually one of the
10 surprises of the integrated test is that the corrosion
11 is less because the aluminum in the fiber glass - you
12 get more fiber glass corrosion if there is no aluminum
13 around. But when you have the aluminum it suppresses
14 the fiber, so typically the industry calculations of
15 chemical loads are conservative, because they don't
16 take account of those kind of inhibiting effects.

17 MR. KLEIN: That's a good point, Bill. I
18 think what we saw in the ICET series was almost a
19 competition between aluminum and leaching from fiber
20 glass. And if you got substantial amounts of aluminum
21 from higher pHs it tended to form a coating on the
22 fiber glass and slow down the dissolution process
23 substantially so the amount of silica that leaches for
24 example was much less than predicted.

25 DR. WALLIS: But then there were some

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 plants with no aluminum to inhibit this -

2 MR. KLEIN: We think overall if you look at
3 the WCAP methodology and the single effects tests that
4 they did, when you add that as a whole you have a very
5 conservative predicted chemical load. And that has
6 been confirmed by some of these test methods where
7 instead of adding a predictive WCAP amount they put
8 this material into elevated temperature, elevated pH
9 environments for 30 days, and the amount of
10 precipitate that formed was much much less than was
11 predicted by the WCAP methodology.

12 Next slide, I believe. I just wanted to
13 point out the work that ANL has done has been
14 published within three different technical letter
15 reports, and those are all publicly available; the
16 session numbers are shown in this slide. Next slide.

17 I wanted to show just some samples of
18 some of the vertical loop head loss tests with ANL.
19 What this particular slide shows is the WCAP aluminum
20 oxyhydroxide pressure drop as a function of time on
21 the top; and then on the bottom is the WCAP sodium
22 aluminum silicate. The top slide was generated in
23 high purity water; the bottom slide is in tap water.
24 And I think the main takeaway is within the test
25 conditions of the ANL vertical loop a very little

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 amount of aluminum transformed into a precipitate
2 causes a very high head loss. Next slide.

3 I wanted to discuss the tests that were
4 done, instead of adding dissolved aluminum with
5 aluminum coupons because we wanted to try and
6 benchmark that as well. So we had two different
7 aluminum alloys that were used in these tests, the
8 6061 on the left, and the 1100 series on the right.

9 These are low magnification scale
10 electronic microscope images, with back scatter
11 electron techniques, so that the lighter areas that
12 are shown there are trying to highlight some of the
13 inner metallic particles that are within the alloy
14 matrix. And we will discuss their contribution to
15 head loss here in another slide or two.

16 The right picture here just shows how
17 these coupons were inserted into the loop. You can
18 see they were stacked vertically. At the top of the
19 aluminum stack, there is some fiber glass, because we
20 wanted to see potential interactions between dissolved
21 aluminum and fiber glass over time. Because we think
22 what happens in containment - or I shouldn't say what
23 happens in containment - but what can happen in
24 testing when you have dissolved aluminum, it doesn't
25 all necessarily precipitate out on your fiber that is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 on the strainer; it can precipitate out on other areas
2 as well, fiber that is in the flume, particulate that
3 is in the flume. Next slide.

4 This shows the head loss results from the
5 6061 test, and you can see that over time - we put
6 these in at 140 degrees, and I think the pH was about
7 9.3, to try to get accelerate aluminum corrosion. We
8 measured that over time, and at different points in
9 time the aluminum plates would be taken out or put
10 back in, and then the temperature would be dropped to
11 try and cause the aluminum precipitation.

12 And I think what we are trying to show
13 here is that again it looks like about six or seven
14 ppm of aluminum causes substantial head loss. But the
15 one thing that we noticed in these tests that we
16 didn't see in our earlier tests with the dissolved
17 aluminum is that the fiber bed here shown on the right
18 looked quite different. Typically I think we have
19 shown you fiber beds that had a white precipitate on
20 top. In this case the inner metallic particles that
21 came out of the coupons caused a grayish color on the
22 bed that was not observed before.

23 So those particles did have - they played
24 a role in the head loss in two ways: they acted as an
25 additional source of particulate; and we also think

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that they acted as a nucleation site for precipitation
2 of aluminum hydroxide.

3 DR. WALLIS: What's that, the increase and
4 pressure drop when you take out the plates at about
5 240 hours?

6 MR. KLEIN: At 240 hours you have already
7 started the -

8 DR. WALLIS: It seems to be leveling off
9 and then it gets another kick.

10 MR. KLEIN: I think it's the temperature
11 drop.

12 DR. WALLIS: Oh, it was a temperature drop.
13 Oh it was a temperature drop? Okay, thank you.

14 MR. KLEIN: Next slide.

15 CHAIRMAN BANERJEE: So what's the bottom
16 line here?

17 MR. KLEIN: I think the bottom line we are
18 trying to show on this slide here, which is, we tried
19 to look for these different type of precipitates, or
20 with just the aluminum corrosion by itself, the
21 relative efficiency and increase in head loss. And I
22 think what we are seeing is that the WCAP surrogate
23 continues to be a very efficient product in driving
24 head loss, and that it seems that some of the other
25 industry approaches as well are reasonable or may be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 conservative compared to putting aluminum in solution
2 and corroding that material and then causing a
3 precipitate to form as you drop temperature.

4 That last bullet, WCAP sodium aluminum
5 silicate in high purity water, really is not relevant
6 to the industry test since they don't test in high
7 purity water. Next slide.

8 DR. WALLIS: Well, this inner metallic
9 thing indicates that you have got to be careful. I
10 think every time you do a test you find something new.

11 You think you've got aluminum, and you find it isn't
12 quite totally aluminum, so there is another effect.

13 MR. KLEIN: So our goal is to always find
14 something new.

15 DR. WALLIS: Yes, that's right. So don't
16 let ANL do too many tests. They are going to find
17 something every time.

18 MR. KLEIN: I'm going to talk in the next
19 couple of slides about some of the solubility tests,
20 and then how we factored in that aluminum two-pronged
21 test to some of the solubility curves that we've
22 drawn.

23 The goal in these tests was to do two
24 things: it was to study the solubility. There already
25 has been a fair amount of testing that was done by ANL

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 and others in this area. But the one twist that we
2 wanted to put on top of that was to cycle the
3 temperature, so you can see on this plot on the right,
4 which is just showing a typical temperature profile
5 for one of these tests, we tried to go from the very
6 initial high temperatures to almost room temperature
7 over the course of a 30-day test, which is
8 representative of typical ECCS mission time.

9 What we did in addition was, at various
10 points along the way, tried to put a more rapid
11 cooling cycle on to try to simulate fluid passing
12 through a heat exchanger. Then we heated it back up
13 to simulate it going through either the core or out
14 into the break to the higher temperature fluid.

15 I think the bottom line here is that for
16 the cycling that we did, although we know that
17 temperature can cause precipitation, in these tests we
18 saw that a rapid cooling did not cause a widespread
19 precipitation event, because our concern was that with
20 all the solubility data that has been generated, a lot
21 of it is done with either control temperature changes
22 or single temperatures. And so wanted to make sure we
23 weren't missing something.

24 MEMBER ABDEL-KHALIK: what's a typical
25 transit time of a coolant through a heat exchanger?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. KLEIN: It's relatively short order. I
2 don't know, Steve or John want to jump in here?

3 MR. SMITH: I don't know what it is.

4 MEMBER ABDEL-KHALIK: So why would 30
5 minutes be appropriate?

6 MR. KLEIN: Oh, the 30 minutes included a
7 10-minute cool down, and a 20 minute heat up. The 10
8 minute is probably longer than you would have for a
9 transit, but one of the reasons we think it's a
10 conservative test is that there is also an aging
11 process that occurs, so a more rapid cool down was
12 very difficult to obtain experimentally, and then
13 heating it back up without changing the whole test.

14 Our belief is there will not be a massive
15 precipitation caused by a very short term cool down
16 followed by an immediate heat up. We think if a
17 precipitation event would have occurred, the delta T
18 that was incurred by these tests followed by the
19 amount of time where that solution was cold would have
20 produced an event.

21 DR. WALLIS: I'm just trying to understand
22 what you're saying.

23 CHAIRMAN BANERJEE: I guess your question
24 is aimed at what happens between the heat exchanger
25 and the core.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 DR. WALLIS: I am trying to understand
2 this. You showed here that you can cool over a period
3 of 30 minutes and nothing happens.

4 MR. KLEIN: It's cooled over a period of
5 typically about 10 minutes, and then heated back up.

6 DR. WALLIS: But when you do a test in a
7 loop, if you cool the water the pressure drop goes up
8 almost immediately

9 MEMBER SHACK: All this is true for a range
10 of pHs and concentrations. We wouldn't guarantee
11 this is necessarily true for all pHs and all
12 concentrations.

13 DR. WALLIS: Is this why we have this sort
14 of scatter plot in the next slide?

15 MEMBER SHACK: That's why you have the
16 scatter plot in the next slide.

17 DR. WALLIS: Well, that's one of the
18 things. When you see all this stuff, you say, well,
19 it's very complicated isn't it. What are you going to
20 do?

21 MR. KLEIN: I think the important thing to
22 keep in mind is, this is interesting in an academic
23 sense, and it could be important to a plant, but keep
24 in mind that in the industry test protocols they are
25 assuming precipitation occurs for the most part. They

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 are adding the precipitate either as a premixed
2 precipitate, or generating it inside the loop.

3 DR. WALLIS: I have no way of understanding
4 if it's interesting or not academically. I know it
5 may be interesting practically. So what are you going
6 to do about this? Are you going to provide some
7 conservative method or something?

8 MR. KLEIN: Well, I think the goal fo the
9 solubility tests were to provide us a tool to help
10 assess individual plant-specific analyses, so if a
11 plant comes in and they say they have added WCAP
12 surrogate to the full projected amount, or they have
13 generated it inside a loop, we would accept that as
14 conservative.

15 If a plant comes in and says, we don't
16 think we'll form any precipitate, and here's why; we
17 believe this will provide us the information we need
18 to do an independent check on that, and if we aren't
19 convinced then we would ask a series of questions that
20 would ask the licensee to demonstrate why that's the
21 case.

22 CHAIRMAN BANERJEE: I guess there is
23 another implication of this that goes back to Said's
24 question, that when you have it passing through the
25 heat exchangers and then getting to the core inlet,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 whether there would be dissolved aluminum that could
2 precipitate out due to that cool down. And that what
3 you are really saying is the period is too short,
4 right?

5 MR. KLEIN: Yes, we think the period is too
6 short, and if you are concerned about the in-vessel
7 chemical effects, the assumption is that all species
8 are available; that nothing gets trapped at the
9 strainer, so the full chemical load passes to the
10 reactor vessel and then is available to play it out in
11 there.

12 CHAIRMAN BANERJEE: But due to the cool
13 down there isn't a precipitate formed after the heat
14 exchange?

15 MR. KLEIN: That is not the experience with
16 these tests.

17 CHAIRMAN BANERJEE: But that's what you are
18 saying. Okay, let's move on.

19 MR. KLEIN: Okay, let's move on. Next
20 slide. I'll cover this very quickly. I just briefly
21 wanted to show some effects of pH at the top, and
22 aluminum concentration at the bottom. And maybe the
23 take away is that these things are important; that
24 higher pH tends to favor dissolution of aluminum. And
25 obviously as you go to lower concentrations of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 aluminum, that also favors dissolution compared to a
2 precipitate.

3 Next slide. We've taken the body of
4 information that was available from ANL tests, some of
5 the industry talk over port tests, and the ICET tests
6 as well. ANL tried to develop for us a plot of
7 aluminum hydroxide precipitation as a function of pH
8 and temperature. The Y axis here is a pH plus minus
9 the log of the molar concentration of aluminum, which
10 is not as easy to work with as some other units. So
11 what we tried to do is plot a couple of additional
12 plots on here at a temperature of 140 degrees and a pH
13 of 8 -

14 DR. WALLIS: So this is a test matrix plot,
15 this isn't a data plot is it?

16 MR. KLEIN: This is really a data plot from
17 a number of different tests.

18 DR. WALLIS: It's data?

19 MR. KLEIN: Yes, these are all tests that
20 have been performed by ANL or industry.

21 DR. WALLIS: So this is what you got at
22 various temperatures?

23 MR. KLEIN: Yes, and the key thing we are
24 trying to show is that - I should have maybe mentioned
25 this first - the solid symbols here represent tests

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 where precipitate formed. The open symbols represent
2 tests where precipitate did not form, so that the
3 aluminum stayed in solution.

4 And this data ends up being very useful
5 when you are trying to understand potential solubility
6 of aluminum in these environments. And you can see,
7 the other thing to point out here is that the two
8 tests where we ran the aluminum coupons labeled here
9 as the 6061 and the 1100 test, tended to be above
10 those other values, and we think that was due to the
11 potentially acting as a nucleation site for formation
12 of aluminum hydroxide on those inner metallic
13 particles.

14 CHAIRMAN BANERJEE: So the ICET tests one
15 and five -

16 MR. KLEIN: The ICET tests were plotted at
17 I believe 140 degrees at the test temperature, and we
18 didn't see evidence of precipitation at that test
19 temperature. We saw it upon pulling it.

20 CHAIRMAN BANERJEE: So the circles
21 correspond to the experiment which is being described
22 in the previous slides, the flask sitting on top?

23 MR. KLEIN: Yes, those experiments as well
24 as some experiments done by the owners' group to
25 support a topical report as well as some of the data

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 taken from the ICET tests where we had long-term 30-
2 day data if you will of dissolved aluminum at
3 different pHs at 140 degrees.

4 MEMBER SHACK: Every test that we could
5 find in borated water, which is what we are interested
6 in.

7 DR. WALLIS: The lines then illustrate
8 something drawn by you as a criterion for practical
9 use, or just a line that looks interesting?

10 MR. KLEIN: Looks interesting here I think.

11 The lines were drawn initially I think before the
12 aluminum coupon data was added to the plot, and we are
13 just trying to show that there might be two different
14 ways of fitting the data, depending on the
15 temperature.

16 DR. WALLIS: What are these anomalous ANL
17 loop things on the left here? Those white ones in the
18 middle of all the blacks?

19 MR. KLEIN: I think those are probably
20 cases where we would have predicted precipitate would
21 have formed based on the given set of test conditions
22 but it didn't actually occur.

23 DR. WALLIS: So what are you going to do
24 about that?

25 MR. KLEIN: That's a good things.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER SHACK: It's the black things that
2 occur where you don't want them that you worry about.

3 MR. KLEIN: We would have assumed in those
4 cases that precipitate would form.

5 DR. WALLIS: The two black ones up there?

6 MR. KLEIN: It's the two black ones that we
7 are going to take into account as we go to the next
8 slide, and we try to put this into a more useful form
9 for the staff here, where we are not plotting aluminum
10 solubility as a function of pH, and then each of those
11 lines represents a different temperature band, and
12 it's important to know that in this case these lines
13 are developed bounding all that data on the previous
14 slides including the aluminum coupons, and what we saw
15 is, when we included that data that affected our
16 bounding solubility by about a factor of two.

17 Next slide. So to try and just summarize
18 first of all the ANL tests. They did the vertical
19 head loss loop tests, and we think that has helped us
20 better understand some of the relative performance of
21 the different test methods that the industry is using.

22 We saw from those tests that the aluminum inner
23 metallics can influence head loss in two ways as
24 mentioned, and also in causing about the factor of two
25 reduction in solubility as previously mentioned.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 We think the longer term solubility tests
2 will really help us particularly if individual
3 licensees come in and try to make a solubility
4 argument. Most of them I believe are testing with
5 precipitate, although some may try that, and so we
6 wanted to try and get out in front of that if you
7 would and have some way to independently assess their
8 claims.

9 And then the last thing that I didn't
10 really cover in detail, that I mentioned previously,
11 that we did some tests to evaluate the WCAP aluminum
12 oxyhydroxide surrogate at more alkaline conditions for
13 a test duration of what we thought could cover most of
14 the - well, probably all of the industry tests where
15 WCAP surrogate is used. And we saw that at the
16 highest pH that we've observed in any of those tests
17 in the plumes, there is a little bit of an effect,
18 although the WCAP surrogate remained stable. And it
19 still only takes a small amount of equivalent aluminum
20 precipitating to produce significant head loss in the
21 ANL loop under those conditions.

22 So in summary we have observed tests,
23 chemical effects tests, at each vendor facility, both
24 the main five and the other two vendors that have done
25 tests for a relatively few number of licensees. We

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 think that the whole body of evidence indicates that
2 it is clear that the vertical head loss loop tests at
3 ANL are more susceptible to large head losses from
4 chemical precipitates compared to the larger scale
5 more complex strainer type tests.

6 Most plants at this point are using test
7 methods that are acceptable to the staff. There are
8 some issues that remain, and there are some licensees
9 that will be interacting with the staff here in the
10 near term to try and reach a test protocol that we do
11 find acceptable.

12 Overall the tests have confirmed that the
13 WCAP methodology is conservative both with respect to
14 how the precipitate behaves and more importantly just
15 the sheer amount of precipitate that's predicted
16 compared to what forms under tests where they are
17 actually modeling the containment temperature and pH
18 and temperature profiles.

19 We intend to perform a few chemical effect
20 audits to assess the overall evaluation at selected
21 plants. Earlier the staff had performed about 10
22 audits or so to look across the board at all the
23 technical areas, for the most part licensees were
24 still in process with chemical effects. We thought it
25 was important to go back to some of these plants and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 look from the beginning to the end of how they assess
2 chemical effects to make sure we are comfortable with
3 the overall approach.

4 And finally we will be working with
5 research on some of the remaining peer review items
6 that John is going to discuss in the next
7 presentation.

8 CHAIRMAN BANERJEE: I hate to ask you this
9 question. But when we were in Germany they showed us
10 that any zinc that was available in the form of
11 galvanized iron or whatever would have an effect. Do
12 you have an zinc in the system? And is our chemistry
13 at all similar, or is it different?

14 MR. KLEIN: The chemistry is different in
15 that I believe they do not use a buffer. So in the
16 German tests that I'm familiar with they tested with
17 acidic pH and under that type of environment and under
18 flow conditions simulating fluid coming from a break
19 they did get accelerated corrosion of galvanized
20 grating that produced a zinc oxide product that drove
21 head loss in that case.

22 In our particular buffered environments
23 we've seen very very little corrosion of zinc, both in
24 the ICET tests and in the Westinghouse test, so we
25 think it is a different case compared to theirs.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN BANERJEE: Okay thanks.

2 I think that Donnie if you agree we will
3 take a break now and just come back and finish your
4 last presentation after the break. And then because
5 the Westinghouse - the WCAP presentation, they are
6 going to just continue I can see. So we will just
7 take breaks whenever.

8 So let's take a 15-minute break. Try to
9 be back by 11:00. Thanks.

10 (Whereupon at 10:48 a.m. the proceeding in the above-
11 entitled matter went off the record and
12 resumed at 11:00 a.m.)

13 CHAIRMAN BANERJEE: Okay, let's go back
14 into session. Now with the last of the presentations
15 in this set, which will be made by John Burke, I
16 guess.

17 MR. BURKE: Yes, that's correct.

18 CHAIRMAN BANERJEE: Although I see Rob
19 Tregoning is around somewhere.

20 MR. BURKE: Yes.

21 CHAIRMAN BANERJEE: So this will be on
22 chemical effects PIRT update, correct?

23 Please try to keep it to 15 minutes. Now
24 Graham Wallis is the chair, so this is your
25 opportunity.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 (Laughter.)

2 MR. BURKE: All right, good morning. I'm
3 John Burke in the Office of Research.

4 What I'm going to talk about today are the
5 most recent research efforts related to GSI-191 in the
6 area of chemical of effects.

7 And this is an update. The last time we
8 met with the subcommittee was in 2007, and what we
9 discussed, the chemical effects peer review, and the
10 phenomenon identification ranking table, or the PIRT
11 exercise, which was conducted in 2006 and 2007.

12 Today I'm going to briefly talk about the
13 results of the PIRT exercise, and then a scoping study
14 that we did on 10 topics from the PIRT.

15 Next slide. And just refresher, we did
16 the PIRT in 2006. The PIRT was used to identify
17 knowledge gaps that existed at that time. The focus
18 was on phenomena not previously addressed by NRC-
19 sponsored research. And through that effort 41
20 phenomena were ranked as having potentially high
21 significance by at least one of the PIRT's panelists.

22 And just - it was important to bring out here that
23 none of those issues that were identified warranted
24 immediate action. They were all considered long term
25 action.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 And the PIRT report, or the NUREG report
2 for that effort is in final review and should be
3 issued by the end of the year.

4 And another thing I wanted to mention is,
5 from the last briefing we made in I believe it was
6 March or May of 2007, the conclusions haven't changed,
7 as we have finalized the report. So that's all I'm
8 going to talk about that PIRT report. Next.

9 The 41 phenomena ranked as having the
10 highest potential impact significance on ECCS
11 performance were reviewed by the staff. And that was
12 a joint NRR and research working group. And that
13 working group did that in the spring of 2007. Next
14 slide.

15 And the staff reviewing those 41 issues,
16 the staff came up with 10 topic areas that warranted
17 additional study. A separate NUREG report is being
18 prepared to document the review of those 10 issues.
19 Next.

20 And those are the 10 issues. And we have
21 Pacific Northwest National Lab doing that scoping
22 study. And that is - what I thought I would talk
23 about here are three of the more interesting findings
24 from that scoping study. I don't have time to talk
25 about each of the 10, but I picked three that I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 thought you might find interesting.

2 And the first one is radiation effects.
3 And the radiation effects if the effect of the post-
4 LOCA radiation field on the sump chemical environment
5 and the constituents. And what I mean by that is the
6 radiation from the fuel and the reactor vessel, or the
7 activated species in the containment pool or on the
8 strainer.

9 The study concluded that the radiation
10 effects on the sump pool pH were minor in comparison
11 with the effects of the pH buffering.

12 However, knowledge of the radiation
13 influence on the redox potential is limited, and the
14 PNNL recommended a mixed potential modeling to further
15 assess it.

16 CHAIRMAN BANERJEE: What does that mean,
17 mixed potential modeling?

18 MR. BURKE: I will have to have my answer
19 man over there.

20 MR. TREGONING: This is Rob Tregoning from
21 the staff. Essentially you are looking at all the
22 species in containment. And each one has an
23 associated electrical potential, and you are modeling
24 all of those potentials, and the integrated effects
25 from combining all of those various individual species

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 together. So that in a nutshell is what a mixed
2 potential model is.

3 CHAIRMAN BANERJEE: But you have got the
4 individual redox potentials?

5 MR. TREGONING: Yes.

6 CHAIRMAN BANERJEE: And - then I guess
7 there is some sort of an interaction term that has to
8 be taken into account?

9 MR. TREGONING: Yes, there are many
10 interaction terms.

11 CHAIRMAN BANERJEE: Many, many interaction
12 terms.

13 MEMBER SHACK: Depending on how many you
14 have patience to work through.

15 MR. TREGONING: Depending on how many
16 species you have that you are trying to model.

17 CHAIRMAN BANERJEE: But aren't there sort
18 of codes way to do this, or something automatically?

19 MR. TREGONING: Yes.

20 CHAIRMAN BANERJEE: It seems like sort of a
21 standard thermodynamics problem.

22 DR. KRESS: Actually, Melcor has a model
23 for this.

24 MEMBER SHACK: I'm not sure they have
25 radiation influence typically though.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. TREGONING: I don't know if I'd
2 characterize it as standard. It's certainly something
3 that has been done, certainly in BWR reactor
4 environments this type of modeling was done and used
5 as part of the justification for developing acceptable
6 criteria for hydrogen additions to essential impede
7 corrosion of sensitized stainless steel.

8 So it has been done in the past. But I
9 wouldn't characterize that type of modeling,
10 especially of a complex system like the post-LOCA
11 environment is, as being something that is standard or
12 typical. It would be a relatively complex analysis to
13 say the least.

14 MR. BURKE: Okay, the next item was the
15 biological fouling of the ECCS sump strainer, and that
16 could be either bacterial, algal, fungal or other
17 biological growth during the 30-day mission time.

18 There are many stressors to biological
19 growth in the post-LOCA environment such as the rapid
20 temperature change, or the presence of borated water,
21 or lack of light, or the high radiation field, or low
22 levels of carbon. However there are microbes that are
23 known to exist under one or more of these stressors,
24 and the growth rate of any potential bacterial growth
25 is unknown under the combined stressors for a 30-day

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 mission time.

2 So again, PNNL was recommending some
3 additional studies in this area to determine what is
4 that growth rate, or what could grow in that combined
5 field.

6 And the last one I wanted to talk about
7 today was crud release. And that is the effect - or
8 the potential increases in the quantity of metal
9 oxides in the sump pool released from the fuel
10 cladding, or a reactor vessel component during the
11 LOCA, and then the subsequent chemical and/or
12 radiation effects of that increase.

13 The crud burst during a LOCA is expected
14 to be a - is expected to consist of relatively dense
15 solid particulates that like I said release from the
16 fuel cladding. The quantity is expected to be small
17 however compared with other debris particulate such as
18 the insulation debris or the coating debris that we
19 talked about earlier this morning.

20 The additional effect of the crud release
21 is considered to be insignificant unless the other
22 sources of particulate are inconsequential.

23 DR. WALLIS: What is the size of these
24 particulates?

25 MR. BURKE: The crud particulate? I don't

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 remember.

2 DR. WALLIS: If they are dense and big they
3 presumably fall out. If they are dense and minute -

4 MR. BURKE: It was - they did their
5 scoping calculations based on actual measurements of
6 crud off of fuel assemblies. I don't remember the
7 numbers.

8 DR. WALLIS: But they are not minute, are
9 they? They are fairly chunky?

10 MEMBER ABDEL-KHALIK: Tens of microns.

11 DR. WALLIS: They're not micron sized, are
12 they?

13 MR. BURKE: I would expect them to mostly
14 settle out, yes.

15 CHAIRMAN BANERJEE: Now there was one of
16 these 10 areas you've shown that I think the committee
17 at one point was interested in also because of in
18 vessel effects; that is the retrograde solubility and
19 solid step position. Now what's the status of our
20 understanding on that? That also affects this
21 downstream blockage effects.

22 MR. BURKE: The retrograde solubility by
23 itself was not considered to be that significant. But
24 then if you combine - Paul Klein talked about that a
25 little bit the other day, the studies at ANL that show

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that we would not expect any chemicals to precipitate
2 out in the heat exchangers.

3 CHAIRMAN BANERJEE: When you get heating in
4 the core, I think there was concern about calcium. I
5 don't remember which things. This is 1-1/2 years back
6 obviously.

7 MR. TREGONING: This is Rob Tregoning of
8 the staff. The retrograde solubility analysis, one of
9 the things we were trying to look at with that was
10 seeing if we had substantially more - and I think Paul
11 in the previous presentation demonstrated some testing
12 with the effects of normal solubility, the effect of
13 additional precipitates at lower temperatures.

14 We certainly knew a lot of these
15 silicates, or a lot of silicates, aluminums, calciums,
16 can be retrograde soluble as well. So we did some
17 thermodynamic modeling to try to see what sorts of
18 additional quantities we could get at these higher
19 temperatures.

20 And really what we showed is that there
21 seems to be a pretty good balance between the
22 retrograde and the normal solubility species. So we
23 would see some - so the total species load didn't
24 change that much, but the form may change at the
25 higher temperature.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 So if you had a certain - let me give an
2 example - if you had a certain number of aluminum
3 species for instance at lower temperatures, when you
4 went up with high temperatures associated with the
5 core, some of that existing species may dissolve, but
6 then others would reform such that your total solid
7 load was about the same. That was the one thing that
8 we demonstrated in the modeling.

9 Of course the biggest amount of
10 precipitation that you saw in these models were the
11 borated salts, the things that you would get due to
12 again essentially evaporation of water, and then
13 leaving borated salts behind. That was the biggest
14 loading that you saw in any of these models. It
15 dwarfed the other chemical effects that you saw.

16 CHAIRMAN BANERJEE: There is also a concern
17 related to that which I think Tom Kress raised which
18 if you didn't get good mixing between the core and the
19 lower plenum that you would eventually deplete the
20 core of boron, right?

21 DR. KRESS: Yes, but I think someone
22 pointed out that they produced sodium pentaborate
23 instead of boric acid. And that sort of took away my
24 concern about that.

25 CHAIRMAN BANERJEE: Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 DR. WALLIS: Now Rob you said that it as
2 you say heated up. You dissolve something and you
3 precipitate something else, so the amount stays the
4 same. But I thought we were concerned about
5 deposition on the hot surface, which is very
6 different. It's all suspended if what you say is
7 okay, but if the surface is hot, and if the
8 precipitation occurs in the form of something sticking
9 to the surface, that is very different isn't it?

10 MR. TREGONING: That is certainly a
11 different phenomena; that's correct.

12 DR. WALLIS: And I thought that that was
13 part of our concern, that some things might flake out
14 in the core?

15 MR. KLEIN: Paul Klein from NRR. Part of
16 the industry approach accounts for plating of species
17 in the fuel -

18 DR. WALLIS: Accounts for this retrograde
19 solubility when they do that?

20 MR. KLEIN: Yes.

21 MR. TREGONING: The models that we did
22 didn't have any way specifically to model deposition
23 per se, but we knew that that was an issue that had
24 been covered in the WCAP in-vessel support. And again
25 it's something that the industry is addressing as part

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 of their generic letter evaluations.

2 CHAIRMAN BANERJEE: Okay, let's move on.

3 MR. BURKE: All right, then concluding, the
4 staff continues to disposition all of the phenomena
5 identified in the PIRT exercise. And the significance
6 of several of these phenomena is currently being
7 assessed. Again, none of these were evaluated as
8 warranting immediate action. The initial scoping
9 study has been conducted, and like I said we will have
10 two NUREG reports that will be issued by the end of
11 the year.

12 Additional evaluations may be necessary to
13 assess the remaining uncertainties. As part of the
14 disposition the staff is also considering plant-
15 specific post-LOCA environments. Results from
16 additional vendor testing conducted since the scoping
17 study like an example of that would be the reports
18 Paul discussed at Argonne. None of that information
19 was used in this study.

20 And then conservatisms that have been used
21 to address the generic letter response.

22 CHAIRMAN BANERJEE: Okay, thank you. If
23 there are no more questions I'd like to thank the
24 staff for very interesting and informative
25 presentations.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 And I think we should now move on to the
2 next phase. Thanks.

3 And we've already got the material by the
4 way that Donnie promised. So whoever wants to get
5 hold of it -

6 DR. WALLIS: So we have to read it in five
7 seconds?

8 CHAIRMAN BANERJEE: Well, read it over
9 lunch.

10 And now I think we will hear from the BWR
11 owners' group. Now what I think I'd like to do is
12 still take a lunch break at 12:30. And then probably
13 take a 45-minute lunch break. So we'll ask you to
14 sort of move forward, and at some natural point we can
15 take a break.

16 (Off the record comments.)

17 TEST RESULTS - REVISION OF WCAP-16793

18 MR. ANDREYCHEK: Thank you very much for
19 the opportunity to be here this morning, and to make
20 this presentation. This presentation is an update to
21 what we presented back in March earlier this year.

22 I'd like to cover today a little bit of
23 background information. Talk a little bit about the
24 debris collection at the core inlet; fuel assembly
25 testing that we have done, and we did this on an

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 expedited basis to try to provide some information and
2 demonstrate some information for that.

3 We will talk a little bit about
4 forecasting, and forecasted pollution in GSI-191.

5 As a way of background, WCAP-16793 was
6 developed to provide a basis for providing long-term
7 core cooling for PWR designs. To demonstrate with
8 reasonable assurances of long-term core cooling to
9 satisfy the requirements of 10 CFR 5046, we were going
10 to use available tools and information and draw from -
11 and address all PWR designs, the design of the open
12 lattice structure of the PWR fuel, and design and test
13 performance replacement pump containment sump screens
14 that have been done by all licensees. And the results
15 are to be applicable to the whole fleet of PWRs
16 regardless of the design.

17 With regards to some background on sump
18 screens, replacement sump screen hole sizes are on the
19 order of approximately a 1/16th of an inch to an 1/8th
20 of an inch. Most of them tend to be less than an
21 eighth of an inch. Some debris that arrives at the
22 sump may be smaller than the openings and penetrate
23 the openings. Any debris that passes through the sump
24 screens can therefore be transported to the RCS, the
25 emergency core cooling system, and could potential

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 there reach the core.

2 Debris that is not ingested - one thing to
3 remember, the debris is not ingested into the ECCS
4 until after we go into recirculation of the sump,
5 which is approximately 20 to 30 minutes after the
6 break.

7 At the time of switch over, again, 20 to
8 60 minutes after the break, the core is fully
9 recovered. Typically we recover cores in PWRs we do a
10 large break LOCA within approximately 180 or so
11 seconds, and the peak clad temperatures began to turn
12 over, and so clad is of course recovered at that time.

13 The core mixture level, i.e. the two-phase
14 levels above the top of the core at that time, and the
15 actual vessel level core flow rate and debris
16 transport into the core are dependent upon the break
17 location. If it's a code-like break we will tend to
18 get less flow into the core.

19 If we take a look at the code-leg break,
20 this picture, schematic, does depict a code leg break.

21 The downcomer is full to at least the bottom of the
22 code leg. The core level is established by the
23 hydrostatic balance between the water level in the
24 downcomer and the resistance to flow as well as the
25 two-phase mixture in the core itself. And also, for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 B&W plants, there is a potential for some flow through
2 vent valves at the top of the downcomer.

3 For code leg breaks, depending upon the
4 design of the plant, and depending on the number of
5 trains of ECCS you have operating, it can have a range
6 of between 1,000 to 3,000 gpm minimum ECCS flow, 6,000
7 - 8,000 gpm maximum ECCS flow.

8 Now the amount of flow that is needed to
9 match boil off for a code leg break at approximately
10 20 or so minutes after the break occurs is on the
11 order of about 350 gmp for a Westinghouse 4-Loop
12 plant, large 4-Loop plant. It tends to be about a
13 maximum that you would expect to see.

14 Excess flow dumps out the break location,
15 and is recycled into the sump and back around through
16 the sump screen. And once back in containment sump,
17 again if it's recycled through the sump screen it has
18 an additional opportunity to be filtered by the sump
19 screen. Next slide, please.

20 For a code leg break most of the debris
21 flow will go back up to through the break and be
22 filtered. And the calculations shown here are rather
23 simplistic calculation. So the break flow, we are
24 looking at the flow going out the break. Once you've
25 done the recirculation, 6,000 gpm which is the minimum

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 ECCS, for maximum - maximum ECCS flow - a little hard
2 to follow there - minus 300 gpm break flow - or flow
3 into the core. It means you are recirculating
4 approximately 5,650 gpm.

5 So you are looking at about 94 percent of
6 the flow that you can get is actually recirculating
7 back around through the screen.

8 DR. WALLIS: This is assuming every thing
9 is fine? Assuming the pumps are pumping, right?

10 MR. ANDREYCHEK: That's correct. That's
11 assuming you got maximum ECCS flow. The next major
12 bullet we look at the minimum ECCS flow. And again we
13 are looking at approximately 1,000 gpm total ECCS flow
14 under minimum conditions with 350 or so gpm matching
15 boil off. If you got 650 gpm recirculated back into
16 containment sump through the sump screen.

17 So we are looking there at approximately
18 65, 66 percent of the flow that is being recirculated
19 back through the sump screen and being refiltered.

20 Any questions on that?

21 Next slide, please.

22 The hot leg break, all the flow, all the
23 ECCS flow that is provided to the core flows through
24 the core. It's the only flow path we have right now.

25 And as a consequence all the debris that is available

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 in the ECCS flow will be ducted through and to the
2 core.

3 Next.

4 CHAIRMAN BANERJEE: You show a little
5 background with the debris that has settled. Now this
6 is very fine debris coming in past the screens, right?

7 MR. ANDREYCHEK: .

8 CHAIRMAN BANERJEE: So why do you think it
9 will settle? Why do you show that?

10 MR. ANDREYCHEK: Well, if there is some
11 very dense debris it will have a tendency to settle.
12 And there were some calculations done, and there is a
13 paper that was provided in fact about 1985-86
14 timeframe that demonstrates under ECCS flow
15 conditions, debris having a density of approximately
16 95-96 pounds per cubic feet, and sizes greater than 40
17 or so mils will have a tendency to settle in the lower
18 plenum. It's a public paper.

19 CHAIRMAN BANERJEE: I think that is fine,
20 but if I recall your arguments from the previous -
21 you were saying one cubic feet of some sort of
22 material would get through that had a pretty low
23 density, but 1,000 square feet -

24 MR. ANDREYCHEK: Can you save that question
25 for about five slides, because I think we answer that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 question. I appreciate that question.

2 For the testing we are doing we don't take
3 into account any debris settling, okay. So I think
4 that also addresses, in another way perhaps, your
5 question.

6 Next slide. So again we are looking for
7 hot leg break, once the debris reaches the reactor
8 vessel lower plenum, it can either settle in the lower
9 plenum - that's your question - or it may be
10 transported to the core.

11 The three areas of possible concern for
12 transport to the core include the debris adherence to
13 the fuel cladding surface which was discussed earlier
14 today; collection of debris on the inlet to the core,
15 and therefore resistance to flow in the core; or
16 resistance to the flow at space at spacer grids due to
17 the collection of debris at spacer grids in the core
18 itself. I think those are the three that we would
19 agree upon are the areas of concern. We are going to
20 talk about all three of them.

21 If fibrous debris should enter the core,
22 it will not tightly adhere to the fuel. There is a
23 report that demonstrates this, it's NUKON OFC-1
24 report, which has been provided previously I believe.

25 It took a rod heated to about 2,200 degrees

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Fahrenheit, submerged it in a fibrous slurry. There
2 was nuclear boiling of the heated rod in a slurry;
3 another test. Filmed boiling of a heated rod in a
4 slurry. And all demonstrated that fibrous debris does
5 not adhere tightly. NRC did review and accept the
6 NUKON OFC-1 report in a safety evaluation.

7 CHAIRMAN BANERJEE: What is the
8 applicability of this? Because when you do this you
9 are getting film boiling clearly, whereas if debris is
10 transported into the core, you've got perhaps nuclear
11 boiling certainly or no boiling at all, and you might
12 have a much higher wall temperature than the slurry
13 temperature.

14 So while certainly the report is probably
15 acceptable for what it is, where you've got film
16 boiling on a rod surface, I don't see what the
17 applicability fo this is to the case we are talking
18 here.

19 MR. DINGLER: We wanted to show this, that
20 the fiber itself won't appear. We have as a couple
21 more slides coming up assume scaling; we added a bump
22 up factor for fiber that put us here, scaling in that
23 that was talked about, and we call it DM LOCA, that
24 shows that the amount that could get on the fuel
25 assembly, we estimate that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 So I think that answers your question.
2 Again, a good lead-in for the next couple more slides
3 down the road.

4 CHAIRMAN BANERJEE: Well, I'll wait. But
5 when you've got film boiling you've got a vapor lapse.

6 MR. DINGLER: We covered it both ways. One
7 way, film boiling, we don't have, and then with the
8 non-film boiling we used the calculation that shows
9 that the debris deposited on the fuel will not get
10 above a certain level.

11 CHAIRMAN BANERJEE: Well, let's move on.

12 MR. ANDREYCHEK: Okay, thank you.

13 With regard to the fuel assembly testing,
14 fuel assembly debris and electrodes are included in
15 broad and nozzle fuel assemblies.

16 Now in order to demonstrate what we are
17 looking at we did bring some show and tell items
18 today.

19 Yes, it is rather sharp. But that is a
20 typical bottom nozzle debris. Be careful; that is
21 heavy.

22 The purpose behind the debris catching
23 device is on - I don't know what fuel design it is,
24 whether it be a Westinghouse design, a CE design or a
25 B&W design - is to capture debris that could

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 potentially get into the fuel under normal operating
2 conditions and cause wear and fretting and reach the
3 fuel rod under normal operating conditions.

4 And fuel failure is certainly a high
5 impact item that -

6 DR. WALLIS: So this is this way around?

7 MR. ANDREYCHEK: That is correct.

8 DR. WALLIS: The spikes are upward?

9 MR. ANDREYCHEK: That is correct.

10 CHAIRMAN BANERJEE: Some of the things I
11 saw had little cross pieces around the holes?

12 MR. ANDREYCHEK: Yes, and I tried to get
13 examples of that. The cross pieces, that's the
14 protective grid for the Westinghouse design that
15 actually either bisects or quarters those little
16 holes.

17 CHAIRMAN BANERJEE: So you've got little
18 thingies like that?

19 MR. ANDREYCHEK: That is correct, sir; that
20 is correct.

21 And the next slide demonstrates that.
22 This next slide is an attempt to show how the
23 protective grid would fit right over the top of the
24 bottom nozzle, and how it would in this case quarter.
25 The little circle that is drawn in the upper right-

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 hand corner of the hole, of the flow hole there, is an
2 attempt to show this if this particle had a
3 cylindrical cross section, what the maximum dimension
4 would be that would fit through there.

5 Types of debris of course that we are
6 looking at that might reach the core from the RCS
7 would be fibrous debris, particulates, and chemical
8 precipitates, two different types.

9 For postulated debris build up at the core
10 inlet, we'd need to - if we wanted to determine if
11 sufficient flow would reach the core and continue to
12 remove the decay heat through the potential debris
13 bed. So we must demonstrate that the available
14 pressure drop that the core could take is greater than
15 the pressure drop we'd see across any debris bed that
16 we'd build up at the core.

17 So in order to look at this, what we are
18 looking at is the available driving head is based on
19 the, again, the hydrostatic balance between the
20 downcomer and the core. The delta P available sequel
21 to the elevation head minus the available minus the
22 flow. So the available head - go to the next slide,
23 please - I wanted to show these two diagrams to give
24 you an idea of the overall layout of the plants. What
25 we are looking at here on the left-hand side is the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Westinghouse and CE design; on the right-hand side is
2 the B&W design. Next.

3 DR. WALLIS: So we are talking about a few
4 feet of head or how much?

5 MR. ANDREYCHEK: Well, we are going to get
6 to that in just a moment. We will have the equations
7 in just a moment. I wanted to provide you with some
8 of the inputs that we were looking at.

9 We reference all of the dimensions here to
10 the bottom of the core. We talked about the fuel as
11 12 feet relative to the bottom of the core. The
12 bottom of the hot leg is about 16.06 feet; the bottom
13 of the cold leg is 16.16 feet. And the spill over
14 elevation to the shortest steam generator tube is
15 about 49-1/2 feet.

16 That gives us the basis for solving some
17 calculations on the next couple of slides. For cold
18 leg break we are looking at a liquid density of
19 approximately 60 pounds mass per cubic feet, and this
20 occurs well out into the transient at about 20
21 minutes. Core saturated with voiding in the fluid, or
22 the liquid; core mixtures; and level is taken to be
23 the top of the core. And with a core average void
24 fraction of point five, we are going to calculate -

25 CHAIRMAN BANERJEE: Is that sort of - the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 liquid is coming in at what temperature? Is it
2 saturated?

3 MR. ANDREYCHEK: Approximately saturated,
4 yes, at 20 minutes, yes. Approximately.

5 CHAIRMAN BANERJEE: The coolers just bring
6 it down to saturation?

7 MR. ANDREYCHEK: No the coolers will bring
8 it down to maybe 20 or 30 degrees below saturation.
9 So it's slightly cooler.

10 CHAIRMAN BANERJEE: So it's subcooled?

11 MR. ANDREYCHEK: Slightly subcooled, yes.

12 CHAIRMAN BANERJEE: And even if you have
13 voiding, I mean in a sort of a boiling situation, the
14 average void is not 50 percent; it could be much
15 closer to maybe 20 or 30 percent at most. It will be
16 much lower generally.

17 So let's say if your core was covered and
18 there was a two-phase level somewhere, right at the
19 top it might be about 30 percent which is what you
20 would expect in a bubbly flow. If you had annular
21 flow or something that would be different.

22 But if you had a level with bubbles
23 underneath it, and not annular flow. So I mean this
24 might be way too high, the average void fraction.

25 DR. WALLIS: It should be calculated.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN BANERJEE: It should be
2 calculated, not assumed. And we know how to do that
3 calculation, and I would say it's - the core average
4 void would be much closer to 10 percent or maybe 15.
5 It'd be surprised if it was much over that.

6 DR. WALLIS: Well, everything is
7 interrelated. Really you ought to assume, have a
8 resistance at the bottom, and then calculate the flow
9 rate in the voids. Everything is interrelated. You
10 can't ever assume part of the answer and then
11 calculate the flow rate.

12 CHAIRMAN BANERJEE: All you have to do is
13 make sure he was not our consultant and yours, and he
14 could just do it in five minutes. And probably do it
15 much better than any computer code. Or read his book;
16 that's even better.

17 MR. ANDREYCHEK: You know I tried to get a
18 copy of his book a couple of years ago. It's out of
19 print.

20 CHAIRMAN BANERJEE: A thousand dollars
21 right now.

22 DR. WALLIS: A thousand dollars on eBay.
23 You can go to eBay and get it.

24 MR. ANDREYCHEK: I know, I know. I saw the
25 price on eBay. I was a little astounded. I was

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 looking for the publisher price.

2 CHAIRMAN BANERJEE: I will lend you my
3 copy, or rent it to you.

4 (Laughter.)

5 MR. ANDREYCHEK: Was it lend or rent? I'm
6 not sure which it is.

7 CHAIRMAN BANERJEE: I'll lend it to you.

8 DR. KRESS: I have a corrected version.

9 MR. ANDREYCHEK: The .5 actually came from
10 some calculations that were done for long-term core
11 cooling. And I saw assumed for these calculations;
12 they were based on COBRA TRAC calculations that we had
13 to be honest, and they were assumed for these
14 calculations.

15 DR. WALLIS: Without the pressure drop
16 across this bed you would have more flow rate,
17 wouldn't you?

18 MR. ANDREYCHEK: Yes.

19 DR. WALLIS: So alpha is dependent on how
20 much bed you have? It's not independent variable?

21 MR. ANDREYCHEK: That's true, but if you
22 bear with me what I'm trying to do here is not
23 calculate the pressure drop across the core. I'm
24 saying here is the maximum pressure drop we would
25 expect to have available, assuming there is no debris.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 As long as we are - and that's what I'm looking for.
2 So a cold leg break.

3 DR. WALLIS: Well, it's the minimum alpha
4 you expect.

5 MR. ANDREYCHEK: That's correct.

6 DR. WALLIS: The bigger alpha gives you
7 more pressure drop?

8 MR. ANDREYCHEK: Yes.

9 CHAIRMAN BANERJEE: No, the higher the
10 alpha is the more flow you would get because the
11 driving head goes up.

12 MR. ANDREYCHEK: Yes.

13 CHAIRMAN BANERJEE: So if you take it as
14 alpha as one, you would have a much lower driving
15 head.

16 MR. ANDREYCHEK: That's right.

17 CHAIRMAN BANERJEE: So that would be a
18 conservative calculation.

19 MR. ANDREYCHEK: That's correct.

20 CHAIRMAN BANERJEE: Put alpha - sorry,
21 alpha equal to zero. That would be a reasonable
22 calculation.

23 MR. ANDREYCHEK: So if you had no voiding
24 in the core, you are just basically saying -

25 CHAIRMAN BANERJEE: It's just sensible

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 heat.

2 MR. ANDREYCHEK: Correct. But if you bear
3 with -

4 CHAIRMAN BANERJEE: We will bear with you.

5 MR. ANDREYCHEK: Thank you, appreciate it.

6 We go through the calculation basically for a cold
7 leg break. We are looking at approximately 2.5 psi
8 available at a core average void fraction of .5. If
9 it's a core average void fraction of something
10 different, it would be something a little different,
11 available driving head.

12 CHAIRMAN BANERJEE: Well, if you took it as
13 zero, what would it be? You can do that sum. I
14 guess, Dave, we can work that up, right? Put alpha
15 equal to zero; see what happens. Keep going.

16 MR. ANDREYCHEK: Okay, thank you.

17 For the hot leg break there we're looking
18 at the height of the steam generator tubes providing
19 additional head, driving head; we are looking at about
20 13.9 psi.

21 DR. WALLIS: I've forgotten what you mean
22 by the steam generator -

23 MR. ANDREYCHEK: Can we go back about four
24 or five slides.

25 CHAIRMAN BANERJEE: The steam generators

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 could be voided, right?

2 MR. ANDREYCHEK: Not if we've got - if you
3 will bear with me for a second, there you go. May I?

4 So if we have a hot leg break, flow is
5 going to come out of the hot leg here. So flow is
6 going to come in to the cold leg during cold leg
7 recirculation. So what we are going to end up with is
8 water. If you begin to develop resistance across the
9 bottom of the core, the water will tend to flow
10 backwards up into the steam generators to the lowest
11 elevation of the U-tube. So you will develop water
12 head, driving head, equal to the minimum elevation in
13 the steam generators.

14 CHAIRMAN BANERJEE: So it doesn't go out of
15 the break, the water?

16 MR. ANDREYCHEK: If it's a hot leg break it
17 can't. It has to go through - everything has to go
18 through the core, until you go up to the very top,
19 because you are injecting water into the cold leg. So
20 the only path to the break in the hot leg is either
21 through the core to the break, or up over the top of
22 the steam generator to the U-tube spilling over to the
23 hot leg.

24 MEMBER MAYNARD: To get the maximum
25 driving head you are assuming that the bottom of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 core is totally blocked.

2 MR. ANDREYCHEK: Or blocked sufficiently
3 that we begin to develop flow, build up water head up
4 into the steam generator.

5 MEMBER MAYNARD: If you're getting flow
6 through the core that you are not going to have back
7 flowing up to the top of the tubes.

8 MR. ANDREYCHEK: Yes.

9 CHAIRMAN BANERJEE: So you're saying that
10 as it can't get to the hot leg it just drives itself
11 over -

12 MR. ANDREYCHEK: Correct.

13 CHAIRMAN BANERJEE: And eventually if it
14 drives itself over to the other side, then you balance
15 the head on both sides?

16 MR. ANDREYCHEK: That's correct.

17 CHAIRMAN BANERJEE: So then you have no
18 head.

19 MR. ANDREYCHEK: That would suggest you
20 have nothing driving it into the core, and then we run
21 into a situation which you studied in your book on
22 counter-current flow limiting phenomena, because you'd
23 have water coming in the hot leg down on top of the
24 core which gives you a very different question to
25 answer. And I'd rather not get into that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN BANERJEE: Well, you just fill up
2 the steam generator, right, eventually?

3 MR. ANDREYCHEK: You'd have to overflow the
4 u-tubes and go into the hot leg.

5 CHAIRMAN BANERJEE: Yes, so at that point
6 the two sides balance? Or am I getting something -

7 MR. ANDREYCHEK: No, they balance; we
8 agree.

9 CHAIRMAN BANERJEE: So then you have no
10 head due to that. Because you fill both sides.

11 MR. ANDREYCHEK: You can't fill both sides.

12 CHAIRMAN BANERJEE: Why not? There is not
13 enough water?

14 MR. ANDREYCHEK: No, you flow out the
15 break. You basically begin to flow water out the
16 break.

17 CHAIRMAN BANERJEE: Right, so you've gone
18 over the top.

19 MR. ANDREYCHEK: Right.

20 CHAIRMAN BANERJEE: And now you are going
21 over the break.

22 MR. ANDREYCHEK: That's correct.

23 CHAIRMAN BANERJEE: So you are saying you
24 can't fill this up because there is going to be
25 counter-current flow of air?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. ANDREYCHEK: No, bear with me. All I'm
2 saying in this calculation is, the maximum driving
3 head that I have available to put water into the
4 bottom of the core is equal to the minimum height of
5 the steam generators to the bottom of the core, which
6 is 13 -

7 CHAIRMAN BANERJEE: Maybe the maximum, but
8 in reality let's say the inlet of the core is really
9 blocked. Now you are starting to drive up stuff into
10 the risers of the steam generators. You are going to
11 fill it to the top; it's going to spill over the top.

12 It will be a two-phase flow region, and eventually
13 that area is going to fill unless you are putting air
14 back into that side, right?

15 MR. ANDREYCHEK: No, we are not putting air
16 up into the steam generator at all.

17 CHAIRMAN BANERJEE: Then where is - what
18 are you, putting steam into it?

19 MR. ANDREYCHEK: No.

20 CHAIRMAN BANERJEE: Once it spills over the
21 top it goes into the outlet plenum, right?

22 MR. ANDREYCHEK: It goes into the hot legs
23 into the outlet plenum, yes.

24 CHAIRMAN BANERJEE: But the - all that
25 water has to now get out of that hot leg, which can

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 get filled?

2 MR. ANDREYCHEK: Yes.

3 CHAIRMAN BANERJEE: And what I don't know
4 is what will happen to the down side of the steam
5 generator. So in an extreme calculation you could
6 assume it was full.

7 MR. ANDREYCHEK: I see where you are going.

8 CHAIRMAN BANERJEE: If it's full, then you
9 have just balanced it, so it doesn't matter. Once it
10 goes over the top, if you fill both sides of a steam
11 generator what does it matter.

12 MR. ANDREYCHEK: I think I understand, but
13 I don't see how you would -

14 MEMBER MAYNARD: But if it goes over the
15 top of the lowest tube, then the water is either going
16 to go out the break or go into the core.

17 MR. ANDREYCHEK: Right.

18 CHAIRMAN BANERJEE: Well, the water could
19 just fill up the downside of the steam generator.

20 MEMBER MAYNARD: No, there is nothing to
21 hold it.

22 CHAIRMAN BANERJEE: The only way is if you
23 have a counter-current flow to hold it.

24 MR. ANDREYCHEK: But there is no counter-
25 current flow in those steam generators, because it is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 going out the break.

2 CHAIRMAN BANERJEE: You are not going to
3 fill it due to some magic mechanism?

4 MR. ANDREYCHEK: I don't see us filling the
5 steam generator tubes on the downhill side.

6 CHAIRMAN BANERJEE: Suppose it starts
7 filling over. Now unless you have something to - you
8 are saying these tubes don't fill; they will half fill
9 and water will run down them?

10 MR. ANDREYCHEK: No, I'm saying that they
11 will fill on the cold leg side totally. And because
12 the tubes are a multiplicity of pipes, there are a
13 number of pipes, you are going to reach the minimum,
14 the lowest tube first; you will begin to flow over the
15 minimum height too. And you've still got the other
16 tubes that aren't necessarily getting water yet. You
17 will basically overflow the top of the tube, and it
18 will flow into the hot leg.

19 DR. WALLIS: And that's as high as you will
20 go.

21 MR. ANDREYCHEK: That's exactly right.

22 DR. WALLIS: It just spills into the hot
23 leg.

24 MR. ANDREYCHEK: It spills into the hot
25 leg, yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN BANERJEE: It spills down the
2 downside, right?

3 MR. ANDREYCHEK: Yes.

4 CHAIRMAN BANERJEE: Okay, so that means
5 these tubes are partially filled only; that's what
6 you're arguing? Some water is coming down them, sort
7 of dribbling down them or what?

8 MR. ANDREYCHEK: It could be very quickly
9 coming down them. But I'm not counting that for a
10 head driving water into the core.

11 CHAIRMAN BANERJEE: Well, but there is
12 water on the downside.

13 MR. ANDREYCHEK: Yes, there is.

14 CHAIRMAN BANERJEE: As there is on the
15 upside. All I'm saying is that an extreme calculation
16 can be that there is as much water on the downside as
17 the upside which exactly balances the head.

18 MR. ANDREYCHEK: I can't see that.

19 MEMBER MAYNARD: You can't do that unless
20 you don't have a break. You'd basically be filling up
21 the hot leg side.

22 CHAIRMAN BANERJEE: I am not sure that you
23 can't do it without - it depends on how the - you know
24 something has - you could - a small tube, you could
25 just fill it with water like a tap coming down.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. ANDREYCHEK: Yes, I understand that.

2 CHAIRMAN BANERJEE: And how much?

3 MR. ANDREYCHEK: We have a very different
4 system in the sense that we've got thousands of tubes,
5 and you are talking about one or a number of smaller
6 tubes. But the rest of the tubes are still vented
7 because we haven't filled them up to the top where
8 they spill over.

9 So I don't think we've lost the head at
10 all.

11 CHAIRMAN BANERJEE: When you fill up one
12 tube, then you fill up the next, then you fill up the
13 next. I guess what you are saying is, some tubes will
14 be empty.

15 MR. ANDREYCHEK: That's correct.

16 MR. DINGLER: And then once they are filled
17 or flowing by gravity out the break also.

18 CHAIRMAN BANERJEE: Anyway, we'll accept
19 this for the moment. Carry on.

20 MR. ANDREYCHEK: I think I understand your
21 question better now.

22 DR. WALLIS: It's a good thing that a loop
23 seal isn't in the hot leg.

24 MR. ANDREYCHEK: That's correct.

25 DR. WALLIS: You might get a different

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 situation.

2 MR. ANDREYCHEK: That is correct.

3 CHAIRMAN BANERJEE: Then for sure you'd get
4 it.

5 MR. ANDREYCHEK: So we - that's basically -
6 there's the slide. So what we have available if you
7 accept my use of alpha void fraction of .5 as 2.5 psi
8 driving head for a cold leg break. And for the hot
9 leg break we have approximately 14 psi maximum, given
10 the height of the steam generator.

11 DR. WALLIS: With an alpha over 20 you
12 might find you didn't have this pressure drop.

13 MR. ANDREYCHEK: You are entirely correct.

14 DR. WALLIS: So I think you need to work
15 that out.

16 MR. ANDREYCHEK: Okay.

17 DR. WALLIS: I'm doing a rough calculation
18 just to see where it goes. Go ahead.

19 DR. WALLIS: You'd get something through.
20 Because if there is no flow you'd get alpha one.

21 MR. ANDREYCHEK: That's right.

22 MR. DINGLER: And we have the calculation
23 because that is part of the license basis. We just
24 didn't bring it for this one.

25 MR. ANDREYCHEK: So the head loss to the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 debris bed must be less than either one of these two
2 values to provide reasonable assurance that flow
3 required to remove core decay heat will continue to
4 reach the core.

5 Next slide. The pressure drop is a
6 function of both the debris type and the debris
7 amount. And based on everything we've heard so far
8 today, certainly the amount of debris and the type of
9 debris that reaches the core could be combinations of
10 multiple types of material and amounts.

11 We know that that needs to be accounted
12 for in a test program in order to come up with a
13 prudent approach to doing the test.

14 CHAIRMAN BANERJEE: Well, I've got a rough
15 number. If your alpha, if you were full of liquid you
16 would something on the order of one-third to one-
17 quarter of the driving head, correct, the 4.2? It
18 would go down to about one psi.

19 MR. ANDREYCHEK: I accept that.

20 CHAIRMAN BANERJEE: Okay.

21 DR. WALLIS: Remind what the area for flow
22 is across this cold plate, the total area? We used to
23 know that and I've forgotten it.

24 MR. ANDREYCHEK: The total area across - if
25 you are looking at the total area below the core

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 itself it is approximately 100 square feet -

2 DR. WALLIS: No, it's only about 50 because
3 you've got 50 percent of the -

4 MR. ANDREYCHEK: That's correct. That's
5 correct.

6 DR. WALLIS: Fifty square feet. I remember
7 something like that.

8 MR. ANDREYCHEK: And then the core itself
9 is approximately 50 square feet.

10 DR. WALLIS: And some of these screens are
11 thousands of square feet.

12 MR. ANDREYCHEK: That is correct.

13 CHAIRMAN BANERJEE: So the concern we had
14 is that you have a second screen. One basically in
15 series which is much smaller than your first screen.

16 MR. ANDREYCHEK: Understood. Understood.
17 Okay, next slide.

18 When considering pressure drop from
19 debris, the particulates will generally be smaller
20 than the fuel filter openings, and those are the -
21 you've seen the grids which can be used as
22 approximately fuel filter openings. Consequently we
23 need to have a fiber bed present in order to collect
24 particulates within the core entrance, or even within
25 the core itself. Otherwise the particulates will pass

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 through the core, and we won't get quote blockage.

2 The foaming slides provide the basis for
3 investigating the amounts and types of debris that
4 we're going to look at.

5 DR. WALLIS: This means that the particles
6 are not in anyway sticky. They won't stick to the
7 hole, and you can get holes blocked by small
8 particles.

9 MR. ANDREYCHEK: By sticky particles, yes.

10 DR. WALLIS: I mean it could happen in your
11 arteries and things like that, if something sticks.
12 If it doesn't stick.

13 MR. ANDREYCHEK: That's correct.

14 CHAIRMAN BANERJEE: What are the - I've
15 forgotten now - with the cross pieces what is the
16 equivalent hole diameter there?

17 MR. ANDREYCHEK: Well, again, the largest
18 spherical diameter or cylindrical diameter is
19 approximately .07 for a Westinghouse design.

20 CHAIRMAN BANERJEE: But was that because
21 your screens are one-eighth to one-sixteenth, correct?

22 MR. ANDREYCHEK: That's correct.

23 CHAIRMAN BANERJEE: So I'm just trying to
24 do that. One eighth is -

25 MR. ANDREYCHEK: Point one two five.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN BANERJEE: Point one two five. So
2 these holes are smaller than the holes in the sump
3 screens.

4 MR. ANDREYCHEK: There are only two sump
5 screens that I'm aware of that have been installed
6 that have a one-eighth inch diameter.

7 CHAIRMAN BANERJEE: So most of them are
8 what, one-sixteenth?

9 MR. ANDREYCHEK: Most of them are point one
10 or smaller; point one inches or smaller.

11 CHAIRMAN BANERJEE: So even if it's point
12 one, these holes are smaller?

13 MR. ANDREYCHEK: Potentially, yes.

14 CHAIRMAN BANERJEE: Than the point zero
15 seven, correct?

16 MR. ANDREYCHEK: Yes.

17 CHAIRMAN BANERJEE: So you've got a screen
18 upstream with bigger holes than the core inlet holes.

19 MR. ANDREYCHEK: Potentially.

20 CHAIRMAN BANERJEE: Not potentially; that
21 really is what you are telling me.

22 MR. ANDREYCHEK: Okay.

23 CHAIRMAN BANERJEE: Okay. Keep going.

24 MR. ANDREYCHEK: Additionally, testing of
25 sump screens -

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 DR. WALLIS: So metallic insulation smaller
2 than point one inch could get through the screen but
3 wouldn't get into the core?

4 MR. ANDREYCHEK: The flow rates that we are
5 looking at, based on -

6 DR. WALLIS: Wouldn't be transported?

7 MR. ANDREYCHEK: That's right.

8 DR. WALLIS: You just talked about fibers.
9 You have to dismiss the other one as well.

10 MR. ANDREYCHEK: If I look at particulates,
11 and particularly from reflective metallic insulation,
12 the density of that is so high that it doesn't
13 transport well to the sump screen. That was shown in
14 USIA-43 that closed out in 1985.

15 CHAIRMAN BANERJEE: I think the discussion
16 we are having about the sump screens up until now is
17 that much of the very fine stuff gets there, right?

18 MR. ANDREYCHEK: Yes.

19 CHAIRMAN BANERJEE: Probably; I mean we
20 don't know for sure. But some part of this very fine
21 stuff will get through, and of course we don't know
22 exactly what gets through, but in the previous
23 discussions we had we said that - at least it was
24 maintained that about one cubic foot -

25 DR. WALLIS: Per thousand square feet.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN BANERJEE: - per thousand square
2 feet would get through, and this was of a very low
3 density. If I remember it's less than 2.5 pounds per
4 feet cubed, if my memory serves me right. So this
5 stuff would probably not settle; it would just go
6 through.

7 MR. ANDREYCHEK: And that's fibrous debris
8 typically.

9 CHAIRMAN BANERJEE: Okay. And we were not
10 talking about the heavy little particles or whatever.

11 MR. ANDREYCHEK: No.

12 CHAIRMAN BANERJEE: Because they would be
13 out anyway.

14 MR. ANDREYCHEK: That's correct. We were
15 talking about -

16 CHAIRMAN BANERJEE: They would probably get
17 to the core.

18 MR. DINGLER: And that's why we even got
19 the lengths and the diameters of what we were seeing
20 coming from actual bypass testing, and we have those
21 presented on a data slide for you.

22 MR. ANDREYCHEK: When we get to the
23 testing, you will see, we will be able to describe
24 briefly what we've done in terms of fibrous debris.

25 CHAIRMAN BANERJEE: I guess what you are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 doing is, you are setting a sort of stage here for the
2 later data. But if you had shown us the data to
3 support this stage it might have been easier to accept
4 it.

5 But let's assume that you will show us
6 some data.

7 MR. DINGLER: You're right. In other words
8 we didn't know what to do, do the data first and then
9 background, or reverse.

10 CHAIRMAN BANERJEE: Data is always good.
11 With this stuff it is difficult to accept without
12 having the data. And we look at the data, and we come
13 back.

14 MR. ANDREYCHEK: I would appreciate your
15 patience please.

16 So from the testing of the sump screens we
17 have seen that small amounts of fibrous debris may
18 collect particles to chemical precipitates, produce
19 large head losses which has been called the thin bed
20 effect.

21 Similarly large amounts of fiber mass may
22 collect large amounts of particles and chemical
23 precipitates and general large head losses, and
24 similarly is called a thick bed.

25 Therefore our testing needs to consider

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 both small amounts of fiber as well as large amounts
2 of fiber. Next slide.

3 If sufficient amounts of particulates and
4 chemical products are not available to collect in a
5 fiber bed, the voids in the fiber bed won't be filled,
6 and the flow through the bed will continue and core
7 coolant will be maintained. And that is also drawn in
8 part from some of the screen testing data that was
9 done where you have a fiber bed without any
10 particulates; without any chemical precipitants. And
11 you still get a reasonable amount of flow at minimal
12 pressure drop through the bay. And I think, Bill,
13 you've seen that in some of the testing you have done
14 at Argonne.

15 Therefore, at large volumes of
16 particulates and chemical precipitants will also be
17 investigated.

18 CHAIRMAN BANERJEE: Yes, and also the
19 previous testing that they presented with horizontal
20 screens is not really applicable to this. This is
21 much closer to the Argonne, because this is like a
22 vertical loop, correct?

23 MR. ANDREYCHEK: That's correct. It's
24 reversed. Instead of the flow going down, it's going
25 up. We agree. Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 So what we looked at for - to approximate
2 the hot leg break, the maximum flow into the core is
3 provided, which also provides the maximum hydraulic
4 drag in the lower plenum to drag materials up into the
5 core entrance. We also know that concentration of
6 chemical products builds over time, and that was
7 demonstrated in the integrated chemical effects
8 testing that was done several years ago by Los Alamos
9 and the University of New Mexico.

10 Next slide. And with regards to head loss
11 in calcium phosphate or calcium-based products,
12 calcium-based products could form early in the
13 accident at elevated temperatures. The head loss
14 testing that was done at Argonne demonstrated that
15 with the NUKON fiber bed and approach velocities to
16 the fiber bed at approximately a tenth of a foot per
17 second, the aluminum based chemical products generate
18 larger pressure drop at the same concentration than
19 the calcium based chemical precipitates.

20 And Bill, I want to make sure that that is
21 the correct statement. I believe that is consistent
22 with the information you folks put out previously.

23 MEMBER SHACK: I have to think about that,
24 although it's hard to imagine anything more effective
25 than your WCAP surrogate.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 DR. WALLIS: Because it is bad to have a
2 lot of CalSil and a lot of STP.

3 MR. ANDREYCHEK: We are not going to
4 disagree with that. So the information we have
5 available demonstrates the use of aluminum surrogates
6 provides for a conservatively large or high head loss
7 across a fiber bed.

8 Next slide, please. Now before we go into
9 the actual testing itself, I'm going to talk a little
10 bit about LOCADM. That was a topic that we talked
11 about briefly last meeting in March.

12 It's an automated spreadsheet calculation,
13 of post-LOCA material deposition on fuel cladding.
14 The model conservatively assumes that all of the fiber
15 and chemical products that have passed through the
16 sump screen and transported to the fuel in a packet as
17 it were of water, or liquid, that then boils,
18 everything in that packet of water is deposited onto
19 the fuel surface. It's a very conservative approach.

20 We verified the hand calculation, or the
21 automated calculation, by comparison of calculation
22 test data. And what you have here on the slide is the
23 LOCADM calculation. Which is this line compared to
24 the data, and this was compared to a model that was -

25 DR. WALLIS: This is deposition on the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 fuel?

2 MR. ANDREYCHEK: Yes, sir.

3 DR. WALLIS: I'm not quite sure what you
4 mean by conservative. Conservatively it all goes in
5 and deposits, but where does it deposit? If it
6 deposits all on one fuel rod, presumably that fuel rod
7 is going to overheat.

8 MR. ANDREYCHEK: Well, it deposits -

9 DR. WALLIS: Everywhere.

10 MR. ANDREYCHEK: Everywhere in the boiling
11 region, based on -

12 DR. WALLIS: Uniformly?

13 MR. ANDREYCHEK: - based on the amount of
14 boiling that is going on, and it's uniformly over a
15 region of the core that is in boiling.

16 DR. WALLIS: So it varies from channel to
17 channel? The hot channel gets more of this stuff?

18 MR. ANDREYCHEK: That's correct. That is
19 correct.

20 The LOCADM code does account for local
21 power radial distribution in the fuel. And it does
22 look at the hot channel.

23 DR. WALLIS: So this fouling resistance is
24 at the worst place, is that what it is you are
25 plotting here?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. ANDREYCHEK: In this particular case we
2 took a look at this particular piece of data and said,
3 what would our code predict relative to the data given
4 the conditions on the -

5 DR. WALLIS: On this particular test?

6 MR. ANDREYCHEK: - on this particular
7 test, yes, sir.

8 CHAIRMAN BANERJEE: Now, I'm just trying to
9 organize the presentation, because we don't want to go
10 too far beyond the 12:30 time.

11 MR. DINGLER: I think we've got this
12 afternoon on this.

13 CHAIRMAN BANERJEE: Right, right, and with
14 a lunch break. When are you actually going to get to
15 your experiments? Which slides?

16 MR. ANDREYCHEK: The very next slide.

17 MR. DINGLER: The next slide. Do you want
18 to take a break?

19 CHAIRMAN BANERJEE: No, I don't want to
20 take a break now. If you've got new data, where is
21 that starting?

22 MR. DINGLER: That is coming up in the next
23 couple of slides.

24 MR. ANDREYCHEK: Next couple of slides,
25 sir.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN BANERJEE: Okay, all right. And
2 your testing and stuff, when is that starting? We
3 want to have enough time for all the tests you have
4 done to look at that, so is that slide 39 or 40, or
5 when is that?

6 MR. ANDREYCHEK: The summary of the data is
7 on 42.

8 CHAIRMAN BANERJEE: On 42? These are your
9 new tests?

10 MR. ANDREYCHEK: That is correct, sir.

11 CHAIRMAN BANERJEE: Okay, so we want to
12 make sure we have enough time for that. So before we
13 - there were certain issues that were raised at the
14 last meeting which I think we need to make sure we
15 address at this meeting. One was this bypass amount,
16 that was an important issue, which we would like to
17 see your data on. Second issue was if you did get a
18 fairly uniform bed formed at the inlet, what sort of
19 pressure losses would you get, and the sort of testing
20 you've done related to that.

21 So we want to be sure that we have enough
22 time on that, and not get hung up on hand calculations
23 and all that sort of stuff. The key thing we are
24 looking for is new data, not new calculations.

25 MR. DINGLER: The bypass data is slide 37

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 and 38, and then our results of our last tests -

2 CHAIRMAN BANERJEE: The new testing you
3 have done?

4 MR. DINGLER: Yes, 40 to 42.

5 CHAIRMAN BANERJEE: Okay, so let's move on,
6 and make sure we get there.

7 MR. ANDREYCHEK: Okay. If there are no
8 other questions, I'd like to go to the next slide.

9 The fuel assembly debris capture tests
10 that are being done. There is a head loss test
11 protocol developed to support WCAP-16793, and the
12 testing is going to investigate combinations of debris
13 materials, fibrous particulate and chemical, and we
14 are also going to look at the potential for thin bed
15 loading.

16 DR. WALLIS: What is silicon carbide?

17 MR. ANDREYCHEK: Silicon carbide is a
18 material that stays in solution; it doesn't settle out
19 very well. It's small in diameter.

20 DR. WALLIS: This is not like the real
21 stuff is it?

22 MR. ANDREYCHEK: I'm not sure I understand
23 what you mean.

24 DR. WALLIS: The stuff that's in the sump?

25 MR. ANDREYCHEK: It's small diameter that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 gets into a fiber bed and will give you a very high
2 head very quickly. So it's a conservative
3 approximation.

4 DR. WALLIS: But it is different stuff?
5 It's chemically different from the stuff in the -

6 MR. ANDREYCHEK: Absolutely; no argument on
7 that.

8 CHAIRMAN BANERJEE: Now why is it - are
9 they already doing this for the pressure losses
10 through the sump screens?

11 MR. ANDREYCHEK: Yes.

12 CHAIRMAN BANERJEE: So they're using
13 silicon carbide?

14 MR. ANDREYCHEK: Some members have, yes.

15 CHAIRMAN BANERJEE: And NRC is accepting
16 that.

17 MEMBER SHACK: And this is just a surrogate
18 for random particle of debris off the floor.

19 MR. ANDREYCHEK: That's correct.

20 MEMBER SHACK: If you got CalSil you use
21 CalSil, but if you -

22 CHAIRMAN BANERJEE: Ah, I didn't realize
23 that.

24 MEMBER SHACK: - have other garbage
25 particulate you are using this just because it's -

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN BANERJEE: Thank you for the
2 clarification. I thought you were substituting this
3 for CalSil.

4 MR. ANDREYCHEK: No, and in fact we'll talk
5 - the test protocol does allow for both calcium
6 silicate and Min-K to be used in addition to silicon
7 carbide as a surrogate material.

8 DR. WALLIS: Presumably it doesn't have any
9 on it. This is a silicon carbide?

10 MR. ANDREYCHEK: Yes, sir, silicon.

11 DR. WALLIS: It has an E on it.

12 MR. ANDREYCHEK: My error; I misspelled it.
13 I left my dictionary at home.

14 CHAIRMAN BANERJEE: Leaving the "e" out, to
15 this debris preparation you have to add then materials
16 like CalSil?

17 MR. ANDREYCHEK: That is correct.

18 CHAIRMAN BANERJEE: So it's just missing
19 that?

20 MR. ANDREYCHEK: That is correct.

21 Okay, with regards to debris
22 characteristics, the fiber lengths that we're testing
23 is approximately 77 percent of the fiber is less than
24 500 microns. Approximately 18 percent is between 500
25 to 1,000 microns, and 5 percent is greater than 1,000

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 microns.

2 Now you are going to ask where we got
3 those numbers from, and we'll address that in just a
4 moment, so please bear with me.

5 Particulates are silicon carbide, and
6 again, Graham will talk about the dimensions of the
7 silicon carbide there being on the order of 10
8 millimeters plus or minus - or micrometers, excuse me.

9 Ten micrometers, excuse me.

10 (Laughter.)

11 MR. ANDREYCHEK: You know, I'm getting
12 nervous speaking in front of you folks here. Bear
13 with me just a little. Give me a little bit of slack
14 please.

15 DR. WALLIS: Well, the trouble is, it's in
16 print here. People can quote anomalies. This is 10
17 micrometers, is it?

18 MR. ANDREYCHEK: Yes.

19 (Comments off the record.)

20 MR. ANDREYCHEK: Again, the small size does
21 provide for maximum lifting and penetration into the
22 fiber beds. And the chemical surrogate is aluminum
23 oxyhydroxide.

24 CHAIRMAN BANERJEE: This is your usual
25 surrogate that you use?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. ANDREYCHEK: Yes, sir.

2 DR. WALLIS: I don't think it's a maximum
3 lift. It's a large lift.

4 MR. ANDREYCHEK: A large lift, yes.

5 DR. WALLIS: It's not a maximum.

6 CHAIRMAN BANERJEE: And what about the
7 CalSil or whatever?

8 MR. ANDREYCHEK: For the first series of
9 tests we ran, Dr. Banarjee, we did not use calcium
10 silicate. We just used the fiberglass, the silicon
11 carbide and the aluminum oxyhydroxide.

12 CHAIRMAN BANERJEE: That's the first set?

13 MR. ANDREYCHEK: That's correct.

14 CHAIRMAN BANERJEE: Thank you. Carry on.

15 MR. ANDREYCHEK: The initial tests we
16 intended to use a vendor - a different vendor of
17 nozzle bottom configurations, populate flow rates, and
18 again the fiberglass particulates and chemical
19 surrogates.

20 DR. WALLIS: You are talking about these
21 tests as if they are something in the future; is that
22 right?

23 MR. DINGLER: Right now we have conducted
24 three tests, and we are well into two One was just
25 conducted Friday and we still have the data to be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 prepared.

2 DR. WALLIS: So there are a lot more tests
3 coming?

4 MR. DINGLER: And we have 14 more tests to
5 go.

6 CHAIRMAN BANERJEE: So are you going to
7 tell us before the end of the day about what you are
8 planning to do?

9 MR. ANDREYCHEK: Yes.

10 CHAIRMAN BANERJEE: So you've done three?

11 MR. DINGLER: We are going to tell you
12 about two. One we didn't get the data enough to put
13 some slides in the presentation. We will tell you
14 about the two. We are also going to tell you where we
15 plan to go from now.

16 CHAIRMAN BANERJEE: Carry on.

17 MR. ANDREYCHEK: Okay, the output from the
18 initial tests, it would be a selection of the limiting
19 fuel design for further tests; correlation of a
20 pressure drop between the various bottom nozzle
21 designs for a given vendor. And we intend to
22 investigate and evaluate the adjustments to the plant
23 that are needed or warranted as testing is performed.

24 CHAIRMAN BANERJEE: What about the spacer
25 plates and the grid plates and things? Are you going

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 to do some testing with that?

2 MR. ANDREYCHEK: Yes, we will. And if you
3 bear with me again just a moment we will get to that.

4 CHAIRMAN BANERJEE: Could we add that to
5 this?

6 MR. ANDREYCHEK: Yes, sir.

7 MR. DINGLER: That on page 39.

8 DR. WALLIS: Now when we were in Germany we
9 saw some tests, didn't we? We saw actually -

10 CHAIRMAN BANERJEE: I think things got
11 stuck more in the space plates and things.

12 DR. WALLIS: Is that stuff that is
13 available? We asked for it to be available.

14 MR. ANDREYCHEK: We have not seen it.

15 DR. WALLIS: We saw a test where they had a
16 screen, downstream they had this bottle of the bottom
17 of a core. And we saw this fuzz deposited on the
18 bottom of the core plate.

19 CHAIRMAN BANERJEE: It wasn't the core. It
20 was on the grid plates, and I don't know what industry
21 testing is shown here, but I would have thought that
22 if there is this one utility which has done some
23 tests, I don't know if you can speak about those, but
24 I would have thought they would have seen the same
25 phenomenon.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 DR. WALLIS: I would think they would.

2 CHAIRMAN BANERJEE: Yes, they would, which
3 is that the grid plates would get pretty jammed.

4 MR. ANDREYCHEK: Let me ask a question if I
5 may, if you can share the information. I believe -
6 what was the material, the fibrous material they were
7 testing at the time?

8 CHAIRMAN BANERJEE: As far as I know it was
9 fiberglass, but I'm not sure. Or was it something
10 else? Somebody will know the answer which I don't.

11 MR. GEIGER: Ervin Geiger, NRR. Yes, the
12 use typical mineral wall. I did have all those tests,
13 but I think they were proprietary, so I couldn't
14 really share them with anybody.

15 CHAIRMAN BANERJEE: And the other
16 proprietary tests which you know about were conducted
17 by a utility in the U.S. What do they have?

18 MR. GEIGER: Of course they didn't test as
19 many spacer grids. They just had the first spacer
20 grid. And I think they will get into later what they
21 observed, but they tested a number of spacer grids.
22 And Westinghouse had made the same observation that
23 you had, fiber distributed throughout all the spacer
24 grids. But I think they will come to it later.

25 MR. ANDREYCHEK: In the interest of trying

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 to address a concern about what was actually in the
2 test, would you jump to slide 39 please?

3 CHAIRMAN BANERJEE: That would be great.

4 MR. DINGLER: And what we want to do is
5 show you, we are testing a four-foot assembly with
6 these things, and I'll let him explain each one of
7 them. But that is a mock up of our test facility
8 right there.

9 MR. ANDREYCHEK: This is what we actually
10 did, actually had tested.

11 CHAIRMAN BANERJEE: That is very helpful.

12 MR. ANDREYCHEK: You have the bottom
13 nozzle, which was passed around; protective grid which
14 sits right above the bottom nozzle, right here; first
15 support grid, which is a couple of inches above it.
16 And these are actual distances. We have another
17 support grid, which is approximately the right
18 direction; intermediate flow mixer, which is a smaller
19 grid but has a lot of devices to redirect flow, strip
20 the bubbles off the surface of the fuel; support grid;
21 another top support grid; and the top nozzle.

22 And then the flow is ducted out of the top
23 up here and back into the mixing tank.

24 DR. WALLIS: This is full scale, one
25 assembly.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. ANDREYCHEK: It's not full height, but
2 it's full scale, yes, it's the right size as I'm
3 looking at the cross section, it's the right size;
4 it's the right number of rods, so on and so forth.

5 MEMBER ABDEL-KHALIK: And the gap between
6 the assembly and the walls?

7 MR. ANDREYCHEK: The gap between the
8 assemblies and the walls for this test was modeled as
9 one-half the prototypic gap in the reactor plant which
10 is 20 mils, and one-half of the 40 mils, which is
11 prototypical. But we did model that gap. And it's
12 actually set - it's set using ultrasound devices to
13 measure the distances to make sure we got it set
14 correctly.

15 CHAIRMAN BANERJEE: Where are these
16 experiments being done?

17 MR. ANDREYCHEK: They are being done in
18 Pittsburgh at the Westinghouse Science and Technology
19 Center.

20 MR. DINGLER: Then we will have some other
21 tests by AREVA Fuel which they can't see at another
22 facility.

23 MR. ANDREYCHEK: We have to put our
24 blinders on.

25 CHAIRMAN BANERJEE: We can always clear the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 room of Westinghouse, and then we can clear the room -
2 we've done that.

3 MR. ANDREYCHEK: And for the purposes of
4 getting closer identification, this was the core
5 support simulation. Bottom nozzle. This is about
6 four inches. Bottom nozzle. Protective grid, and the
7 first support grid.

8 MR. DINGLER: So we wanted to give you
9 that before we go on, so you understand what we are
10 testing.

11 CHAIRMAN BANERJEE: And you are testing
12 eventually different sort of configurations for the
13 debris filtering bottom.

14 MR. DINGLER: As you can see in the NRC
15 presentation, Westinghouse has a guardian grid for CE.
16 They have a P grid, an alternate P grid, and some
17 plants have an open without any P grids.

18 AREVA has four different ones, a trapper
19 fine mesh, a trapper medium mesh, and I can't remember
20 all of them, but there are four different types for
21 AREVA, plus the openings of five plus four for that.
22 I just want to make sure we get the most conservative
23 on those to test them.

24 CHAIRMAN BANERJEE: Right, so you do what
25 appears to be the most conservative, and then other

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 people would have to show that they - that it is
2 conservative for them?

3 MR. DINGLER: What we're finding, based on
4 again limited tests of three, two I want to show you
5 that the bottom assemblies may not make too much of a
6 difference. As you saw in the German test it's
7 catching elsewhere. So we are evaluating that after
8 each test, and seeing which way is the best to go to
9 get the most bang for our dollar on testing.

10 MR. ANDREYCHEK: Next slide. We already
11 did this one.

12 Okay, so what we are testing is we are
13 using, we will be testing more with aluminum nozzle
14 design, bottom nozzle design, like Mo just described,
15 with hot leg flow rates. We'll be looking at
16 fiberglass particulate, the chemical surrogates. Then
17 we will be looking at the same with calcium silicate
18 added, and then finally the same three debris sources
19 with Min-K, a micro-porous insulation type.

20 Sorry that we didn't get to that earlier.

21 CHAIRMAN BANERJEE: Right, so it's like
22 three or four series of tests?

23 MR. ANDREYCHEK: That is correct.

24 MR. DINGLER: That is correct.

25 MR. ANDREYCHEK: And we have had NRC

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 involvement in this. Test protocols have been shared
2 with the NRC, and we have addressed their comments.
3 And we did have a visitation from the NRC last week, a
4 visit to the facility and witness a test.

5 And if I can identify the guilty parties
6 as Paul Klein, Steve Smith and Irv Geiger were the
7 visitors.

8 You wanted to see some bypass data. This
9 is the sump screen bypass data when we did an industry
10 -

11 CHAIRMAN BANERJEE: This, these series of
12 tests of course assume a certain amount of bypass or
13 whatever; is that it? Or do you vary the amount of
14 bypass?

15 MR. ANDREYCHEK: We are varying the amount
16 of fiber, and we will talk about that on slide 42
17 about the two tests that were run, and how the fiber
18 varied.

19 MR. DINGLER: When we went out and we
20 surveyed the plants, and we asked them to tell us what
21 bypass they got. They went everywhere from actual
22 testing to calculated to using a generic bypass that's
23 in one of the SEs. So in other words we've asked the
24 plants to give us that information so we didn't make
25 any assumptions about what we got. So we got about

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 53, 52 plants that gave us information.

2 CHAIRMAN BANERJEE: So when you say generic
3 number of bypass per 1,000 foot square of screen area
4 are not used, what do you mean by that?

5 MR. ANDREYCHEK: At the last meeting in
6 March I suggested approximately one cubic foot of bier
7 per 1,000 square foot was a reasonable number. What
8 we found in looking at the data was that the volume of
9 fiber bypass was not something that we could use
10 reasonably. A better number to use, a better measure
11 to use, was mass; how much fiber mass bypass do you
12 have?

13 And that translates into what the debris
14 loading would be, much clearer to me at least, on what
15 would be the debris loading on the screen. So we are
16 presenting data on slide 42 based on fiber mass
17 loading.

18 CHAIRMAN BANERJEE: Does this mean that
19 plants who have gone from very high screen areas to
20 make sure they have no pressure losses have done a
21 good job on that front are going to have much higher
22 debris loadings now?

23 MR. ANDREYCHEK: I don't think so.

24 MR. DINGLER: Not necessarily. What we are
25 finding out is in the debris loading, the fiber

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 loading and the particulate - I'll use one plant for
2 specifics that I'm very familiar with - that we saw
3 when the bed got on the screen within probably 20
4 turnovers, the water turned from mucky Missouri water
5 to clean drinking water. So it filtered out.

6 So in other words it depends on your
7 debris loading and that, so when the plants did their
8 bypass testing, if a plant did actual bypass testing
9 they found that the debris loading going to the core
10 was relatively small. If they didn't do the bypass
11 testing, they made an assumption. One plant assumed
12 110 pounds of particulate per assembly bypass. We
13 know that is - that is not necessarily what you see,
14 but that's the data that was presented. We know one
15 plant gave us 68 pounds of fiber for assembly. We
16 know that is not quite adequate either, because I know
17 the debris of that plant, and it's similar to the
18 others, and that's way outrageous.

19 So when we found out that was calculated,
20 or it was assumed.

21 CHAIRMAN BANERJEE: So the question really
22 is if you are saying that things are very murky, and
23 then it was clear in 20 turnovers, you've got a screen
24 with say point one inch holes, and now you've got
25 another screen with a much smaller surface area with

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 point zero seven inch holes or whatever.

2 Now wouldn't you expect the murky stuff to
3 get caught in the second screen?

4 MR. DINGLER: And that's what we're testing
5 for.

6 CHAIRMAN BANERJEE: So you'd have to start
7 with the murky stuff?

8 MR. DINGLER: And that's what we're
9 assuming, that the murky - because the bypass, you
10 take the integral, you take the amount, you take the
11 total amount of bypass, and we are looking at that.

12 CHAIRMAN BANERJEE: Well, the total amount,
13 it depends on when you are taking it. But it's the
14 Missouri water you want to test, right, not the
15 drinking water.

16 MR. ANDREYCHEK: That's true, and I think
17 when we get to slide 42, and we start looking at the
18 data, we'll talk about the sequence that we added
19 material, and I think that will address your question.

20 CHAIRMAN BANERJEE: Because you've got a
21 much finer screen actually downstream.

22 MR. DINGLER: The one I'm talking about,
23 that sump screen is smaller, the main sump screen is
24 smaller than the fuel sump screen.

25 MEMBER SHACK: But still it's the first

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 pass through the screen that you are interested in;
2 not the 20th pass.

3 MR. DINGLER: And what we are finding is,
4 the NRC said that they found that the most head loss
5 was particulate at first. We are introducing this
6 particulate first, then fiber, and we are seeing a big
7 difference in just that too on the head loss.

8 CHAIRMAN BANERJEE: There are people with
9 screens smaller than 50 square feet open area?

10 MR. DINGLER: No, I meant the hole opening.
11 I have a screen that is smaller than the fuel
12 assembly.

13 CHAIRMAN BANERJEE: The core is always the
14 limiting -

15 MR. DINGLER: That's an old one.

16 CHAIRMAN BANERJEE: I mean in the early
17 stages the core is always the limiting screen.

18 MR. DINGLER: Yes, that's correct. Yes.

19 CHAIRMAN BANERJEE: That's the concern, I
20 guess, whether the core takes all the stuff or the
21 screen takes out the stuff.

22 MR. ANDREYCHEK: I think you will find -
23 and again, Steve, if I'm missing something here, you
24 can correct me - but typically the lower the approach
25 velocity the less that you actually get passing

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 through the screen. The screen becomes very effective
2 at collecting material.

3 MR. SMITH: That's correct. This is Steve
4 Smith from NRR, your question, your original question,
5 do the bigger screens have more fiber passing through.

6 And in general the bigger the screen the more fiber
7 will pass through. But also in general the higher
8 velocity the more fiber will pass through. So bigger
9 screens generally have lower velocity, so they
10 generally play against each other.

11 CHAIRMAN BANERJEE: Thank you. That's
12 actually very useful. Appreciate that, thank you.

13 DR. WALLIS: I had a question about this
14 slide, though. You are stopping your classification
15 here at .0394 inches. I would think what is
16 interesting is any fiber that is longer than .07,
17 which is the hole diameter of the bottom of this core
18 filter plate.

19 So I would want to know, are the 5 percent
20 of them that are maybe .1 inches long? You don't have
21 that.

22 MR. ANDREYCHEK: We don't have a maximum
23 dimension there.

24 DR. WALLIS: I would think that would be
25 important. Because all you need is a few of them to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 start blocking the hole, then you can build up like a
2 bed.

3 MR. ANDREYCHEK: I understand the concern.

4 I don't think that that - if you will let us get into
5 the data, and I think you are going to see that it
6 doesn't really matter. What we are looking for, and
7 we didn't necessarily - first off, you are not going
8 to get large fibers, long large fibers through the
9 sump screens.

10 DR. WALLIS: I don't know. I don't have
11 any measurements.

12 MR. ANDREYCHEK: I realize that. I realize
13 that. You have to have a smart fiber that orients
14 itself -

15 DR. WALLIS: Yes, but there are some that
16 get oriented with the flow.

17 MR. ANDREYCHEK: I'm not going to argue
18 that. But what we have is this data. This is what
19 was given to us; this is what we have to work with.

20 DR. WALLIS: But is it good enough?

21 MR. ANDREYCHEK: I think it is, and bear
22 with me and I think you will see why.

23 DR. WALLIS: Let's suppose the 10 percent
24 were .15 inches, or bigger. Would that concern you?

25 MR. ANDREYCHEK: I think the answer is, no,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 it wouldn't. Based on the data we've seen; bear with
2 me, please.

3 CHAIRMAN BANERJEE: Why don't we note that
4 as a point to be addressed, and now let's move on to
5 this table. Don't go past this table.

6 MEMBER SHACK: This table is the data that
7 the plant supplied you?

8 MR. ANDREYCHEK: That's correct.

9 MEMBER SHACK: Their estimate of what
10 bypasses their screens?

11 MR. ANDREYCHEK: That's correct. And
12 typically three categories were used, depending on the
13 vendor. This is what was reported to us.

14 CHAIRMAN BANERJEE: I guess what we are
15 asking is, when you are presenting us this data from
16 the plants, what stage of their filtering with these
17 sump screens was this data taken at? Because what is
18 of importance is what gets through in the very early
19 stages. Is this when it is late stage? Or an early
20 stage? I guess one needs to qualify this.

21 MR. DINGLER: It was taken on a periodic
22 like every 10 minutes, every 15 minutes, periods, it
23 was taken, a sample was taken and collected.

24 CHAIRMAN BANERJEE: So is this data
25 available for us to take a look at? Could you make it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 available?

2 MR. DINGLER: We can't make it available.
3 You can ask the NRC.

4 CHAIRMAN BANERJEE: Right, right. I mean
5 can you make it available so we can eventually look at
6 it via NRC, or via DFO or via whoever it is.

7 MR. DINGLER: That's got to go through the
8 NRC. I can't make it available.

9 CHAIRMAN BANERJEE: You can't make it
10 available to the NRC?

11 MR. DINGLER: As the owners' group I
12 cannot, no.

13 CHAIRMAN BANERJEE: Unless they send you a
14 request for it?

15 DR. WALLIS: It occurs in one shot. I mean
16 you get the stuff coming along, you've got a shot at
17 bypass, and then you get a filter built on the screen
18 and there is no more bypass is my understanding.

19 MEMBER SHACK: But his argument was, this
20 was a cumulative number. So 90 percent of it probably
21 was on the first pass, but he's got it summed over the
22 20 passes, so at least it's a conservative number from
23 that point of view.

24 CHAIRMAN BANERJEE: Okay, that makes sense.
25 So these are numbers which are somewhat -

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. DINGLER: What they did was, they
2 individually measured each length.

3 DR. WALLIS: So if the operator back
4 flushes the screen, then do you get another shot at
5 bypass the next time he turns the pumps on?

6 MR. DINGLER: I can't comment on that,
7 because we haven't done any tests on that.

8 DR. WALLIS: That's exactly what happens.

9 MR. GEIGER: This is Erv Geiger. Just one
10 clarification. In the licensee submittals on this
11 topic, typically under the downstream effects, they do
12 address the bypass that they've measured and so on and
13 the distribution of particle sizes and so on. So we
14 do get that information, and if we don't we can issue
15 an RAI to get an idea of exactly what kind of a fiber
16 bypass they had and particulate and all fo that. And
17 we have been seeing that.

18 DR. WALLIS: You don't have active screens
19 that clean themselves. Because as they clean
20 themselves, they make more bypass.

21 MR. GEIGER: And I don't think anybody has
22 taken back flush as a credit for anything, so.

23 CHAIRMAN BANERJEE: Okay. Well, let's
24 assume that these are relatively conservative numbers.
25 We can revisit it later on.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. ANDREYCHEK: Okay, thank you.

2 MR. DINGLER: Here is where we start
3 talking bypassing. Do you want to continue on this or
4 stop for lunch?

5 CHAIRMAN BANERJEE: I think what we want to
6 do probably is we'll break for lunch when you finish
7 the bypass part of it, and wait until after lunch for
8 the testing.

9 MR. DINGLER: Okay, I just wanted to make
10 sure how far you want us to go.

11 CHAIRMAN BANERJEE: That will be a good
12 point to break.

13 MR. ANDREYCHEK: This slide show the bypass
14 data that was reported to us by licensees. Thirty one
15 or so licensees have reported that they get under two-
16 tenths of a pound fiber bypass per fuel assembly.

17 DR. WALLIS: One pound per fuel assembly.

18 MR. ANDREYCHEK: Say again.

19 DR. WALLIS: One pound, which is about half
20 a cubic foot or something.

21 MR. DINGLER: And what we found is that the
22 high - the one pound and over one pound was assumed or
23 calculated but not actually tested. So we are going
24 back -

25 DR. WALLIS: That is a lot of -

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. DINGLER: And when you look at the
2 total data that we got, it looks out of place, very
3 out of place.

4 MR. ANDREYCHEK: If you look at a frequency
5 distribution, that one sticks way out on an end
6 somewhere.

7 MR. DINGLER: Anything over about point
8 three, point five, gets out of range; point six,
9 somewhere in there.

10 CHAIRMAN BANERJEE: This is total fiber,
11 correct?

12 MR. ANDREYCHEK: That's correct.

13 CHAIRMAN BANERJEE: But now there is this
14 group D, which seems very different in some ways from
15 your other groups.

16 MR. ANDREYCHEK: Yes.

17 CHAIRMAN BANERJEE: Right? With much
18 shorter fiber. What is this - are there certain
19 characteristics to these plants which make for shorter
20 fibers?

21 MR. ANDREYCHEK: I'd have to go back and
22 look at the details on that. I don't have that
23 information right at hand.

24 MEMBER SHACK: I mean they don't use some
25 particular distinctive sump screen design that you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 know of for example?

2 MR. ANDREYCHEK: Again, it's been awhile
3 since we put this together. I would be speaking out
4 of turn if I gave you something. I'd rather not; I'd
5 rather check it and get back to you.

6 MEMBER MAYNARD: We don't know whether it's
7 a plant design or a screen design.

8 CHAIRMAN BANERJEE: And how much insulation
9 you have, what type of insulation you have, there are
10 all sorts of things.

11 I guess what would be useful to us at
12 least is to give us some characteristics of what A, B,
13 C, D, E, F are. I mean, not R, the alphabet R. Are
14 they some of these low fiber plants? Are they using
15 very peculiar screens or different screens? That
16 would be very useful to know?

17 DR. WALLIS: Or a different mixture just to
18 break up the fibers.

19 CHAIRMAN BANERJEE: Also, you know, when
20 you are looking at this distribution without solid
21 distributing them over the type of screens being used,
22 there are low bypass screens being used, for example.
23 Are they pretty low bypass screens. You know there
24 are different designs, so there should be some
25 correlation.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 For example, that over one pound could be
2 particular to a certain type of screen.

3 MR. DINGLER: I can speak to those, because
4 we did calculate for thin list screens to manufacture,
5 because we didn't have all the information. But we
6 did look at in our survey was it calculated, was it
7 actually measured, or did they use some other method.
8 And they listed those. And the ones that are over the
9 one was not the actual calculated, and they didn't
10 take tests. They were assumed for by another method.

11 So we do know those, and that's why I feel
12 comfortable saying to you guys, those are outliers and
13 we have to go back and talk to them.

14 CHAIRMAN BANERJEE: Right, now on this A,
15 B, C, D, whatever, I don't know exactly how you
16 delineated these plants. Maybe they are by screen
17 type, or by screen type and debris type.

18 MR. DINGLER: To be honest with you it's
19 when we received the data.

20 CHAIRMAN BANERJEE: Yes.

21 MR. ANDREYCHEK: It's by plant, not by
22 screen manufacturer or anything else. It's just Plant
23 A came in first, so they got to be the first one on
24 the table.

25 CHAIRMAN BANERJEE: So D is just there -

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER SHACK: Fourth guy on the list.

2 (Laughter.)

3 CHAIRMAN BANERJEE: I see. So it would be
4 useful at least then if you could also put in this
5 table how much bypass they found. It would be useful
6 to know what A,B,C,D were. Were they low fiber
7 plants? Was there some particular screen design? And
8 then how much bypass, to understand the correlation if
9 any between these numbers.

10 MR. ANDREYCHEK: We have used it, but we
11 didn't present it.

12 MEMBER MAYNARD: I think specifically to
13 know what's different about the D group. It doesn't
14 matter - what's unique about it.

15 CHAIRMAN BANERJEE: Right, we need to
16 understand where this stuff is looking so different.

17 MR. ANDREYCHEK: I understand.

18 Okay, we go to particulate survey. We are
19 looking again at particulate mass per fuel assembly.
20 Typically we were looking at less than 14 pounds per
21 fuel assembly, something like 36 plants came in
22 between 14 and 25 pounds. We had two plants greater
23 than 25 pounds, or two plants.

24 The reason we put it in this context was
25 to give you an idea of the frequency distribution that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 we were looking at, and where the plants tend to come
2 in at.

3 And also we used this to identify which
4 plants we need to go back and talk to and say, well,
5 how did you come up with these numbers? What did you
6 do here? And realized that this is going to affect
7 you.

8 MEMBER SHACK: It seems like enormous
9 numbers again.

10 MR. DINGLER: We had one plant had 110 per
11 assembly.

12 MR. ANDREYCHEK: A hundred and ten pounds
13 per assembly.

14 MR. DINGLER: It was assumed.

15 CHAIRMAN BANERJEE: Now you are looking at
16 - I need to go back to this table. The A to F, they
17 are simply, one two three - these are just seven
18 plants that came in.

19 MR. DINGLER: We had 50; we didn't have
20 room to give everything.

21 CHAIRMAN BANERJEE: So this is just a
22 sample?

23 MR. ANDREYCHEK: That's correct.

24 DR. WALLIS: A hundred a ten pounds per
25 assembly wouldn't fit in your test loop, would it?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. ANDREYCHEK: We'd need a sludge pump.

2 CHAIRMAN BANERJEE: Okay, I think this
3 might be a good time to take a break, since it's
4 12:30.

5 MEMBER SHACK: I think these guys are
6 smoking in there.

7 CHAIRMAN BANERJEE: You are not allowed to
8 smoke in these plants. So I think we will break now.

9 DR. WALLIS: Are we off the record?

10 CHAIRMAN BANERJEE: No, we are not off the record
11 yet. So let's go off the record.

12 (Whereupon at 12:32 p.m. the proceeding in the above-
13 entitled matter went off the record and
14 resumed at 1:17 p.m.)

15

16

17

18

19

20

21

22

23

24

25

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1
2 AFTERNOON SESSION

3 (1:17 p.m.)

4 CHAIRMAN BANERJEE: So let's go back into
5 session. And you're up, both of you.

6 MR. ANDREYCHEK: Thank you.

7 When we broke for lunch, we were just
8 about ready to start discussion data. We've showed
9 the slide -- what did you do there? There you go.10 We showed the two slides previously of the
11 overall test facility for debris capture of fuel
12 assembly, and then the closeup of the bottom nozzle.

13 So if you can go to the next slide.

14 MR. DINGLER: I'm on sheet 41.

15 MR. ANDREYCHEK: Forty-one is all right.
16 Everybody okay with that? Okay.17 The two tests that we ran that we are
18 discussing today, we tested a low particulate, low
19 fiber plant, and a high particulate, low fiber plant.

20 The scaling was based on 193 assemblies in the core.

21 Again, hot leak flow rates of approximately 8630 gpm,
22 a total particulate mass to the bottom of 180 pounds
23 mass for the low particulate case, 270 -- 2700 pounds
24 mass for the high particulate case.

25 Fiber mass was 22.2 pounds -- 22.5 pounds

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 for both cases, and the total chemical precipitate
2 mass was 28 pounds mass for both cases.

3 MEMBER MAYNARD: You say scale. You
4 actually have like 28 pounds mass?

5 MR. ANDREYCHEK: Total for the core.

6 MEMBER MAYNARD: For the core?

7 MR. ANDREYCHEK: That's correct.

8 MEMBER MAYNARD: And for one assembly --

9 MR. ANDREYCHEK: Right. And the next page
10 is going to show you the scaled down version.

11 CHAIRMAN BANERJEE: Is that divided by
12 193?

13 MR. ANDREYCHEK: That is correct. That's
14 why we have the 193.

15 MR. DINGLER: And then made it into
16 grains?

17 MR. ANDREYCHEK: That's correct. There's
18 an additional --

19 MEMBER SHACK: I was going to ask you
20 guys, you still using pound mass?

21 MR. ANDREYCHEK: Well, for the fiber and
22 for the chemical, but for the particulate, since it
23 was so large, we kept it at pounds mass.

24 For the particulate in the first case,
25 we're looking at 3 pounds mass per assembly, or modify

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that by 454 grams to come up with it.

2 Fiber was 53 pounds -- 53 grams -- see,
3 you've got me confused now.

4 In both cases, in the chemical was 66
5 grams in both cases.

6 The flow rate per assembly for this
7 assembly is 44.7 gpm. Which material was added. We
8 added the particulate first. In the case of the three
9 pound mass case, it was added one slug.

10 Now the way it was added was we took the
11 three pounds, mixed it in fluid, and added fluid to a
12 recirculation tank. The total volume of fluid in the
13 facility is approximately 250 gallons. So we mixed --
14 took some of the fluid out, mixed the three pounds of
15 mass, put it back into the facility, so it was already
16 somewhat dispersed. It wasn't clumped, it wasn't a
17 big dry mass that was added. It was already in
18 solution, and that kept it from agglomerating.

19 In the second case, the second test, we
20 used four additions of three pounds mass, again doing
21 the same type of a mixture, taking some of the fluid
22 from the facility, mixing it up, and then adding it
23 back in, so we would not agglomerate the mass, the
24 particulate mass.

25 DR. WALLIS: All this was done before you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 put the fibers in?

2 MR. ANDREYCHEK: That is correct.

3 DR. WALLIS: All right.

4 MR. ANDREYCHEK: All the particulate was
5 added, and the facility allowed to recirculate several
6 times before we started adding fiber, so we had a good
7 mixture of particulate throughout.

8 MEMBER ABDEL-KHALIK; I'd like to go back
9 to the issue of internal consistency of these
10 calculations that was raised earlier.

11 At this flow rate of roughly 45 gallons
12 per minute per assembly, 20 minutes after the reactor
13 trip, you're not going to get any boiling from that
14 assembly.

15 MR. ANDREYCHEK: You may not. You're
16 probably correct, yes.

17 MEMBER ABDEL-KHALIK; So that the driving
18 pressure difference will be significantly less than
19 whatever the value that you calculated for the hot leg
20 break and for the cold leg break, the 14-1/2 or the 2-
21 1/2.

22 So how do you reconcile these analyses?
23 How do you make them internally consistent?

24 MR. ANDREYCHEK: Let's deal with -- you
25 were dealing with the hot leg flow rate, okay. And

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 for the hot leg flow rate, flow case, we are assuming
2 -- we agree there's no boiling. So what we're looking
3 at is the elevation head difference between the top of
4 the steam generator and the hot leg. That's -- excuse
5 me, or the bottom of the core. That's the delta P
6 that we're dealing with. We're not dealing with
7 boiling. We're just saying given that you're having
8 hot leg -- have a hot leg break, all of the flow from
9 the ECCS must go through --

10 MEMBER ABDEL-KHALIK; That's a
11 gravitational pressure difference between the hot leg
12 and the cold leg?

13 MR. ANDREYCHEK: Not for a hot leg break.

14 MEMBER ABDEL-KHALIK; Okay.

15 MR. ANDREYCHEK: Not for a hot leg break.

16 Basically for the hot leg break, let's assume --
17 let's see if we can draw a simple analogy.

18 Fundamentally for a hot leg break, you've
19 got a flow in the core and the break.

20 MEMBER ABDEL-KHALIK; Right.

21 MR. ANDREYCHEK: Okay. Now whatever comes
22 in is going to go out the break. When you begin to
23 build up a resistance to flow at the end of the core,
24 such that you have a surplus of flow compared to
25 leaking it out the break, because you are basically

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 just dealing with form loss is getting out the core
2 with the hot leg break, and then flow around and back
3 out again at whatever flow rate.

4 When you begin to build up a resistance at
5 the entrance to the core, you've got to ask yourself
6 where's the water go? And for a hot leg break, the
7 water has got to go into the cold leg, build up in the
8 cold leg and start to go up into the steam generator,
9 and that's the 13 or 14 psi we're talking about. The
10 water head that builds up to the top of the U-tubes in
11 the steam generator.

12 CHAIRMAN BANERJEE: There are two comments
13 on that, of course. One is that that head is not
14 available to the core; right?

15 MR. ANDREYCHEK: That's correct.

16 CHAIRMAN BANERJEE: Second, even if it is
17 completely blocked, what I was saying was that it
18 would -- it's a very uneven phenomena because you'd
19 have a few of these tubes which are at the lowest
20 elevation.

21 MR. ANDREYCHEK: Uh-huh.

22 CHAIRMAN BANERJEE: Would spill over. Now
23 I don't know how high this flows up, but my feeling
24 would be that once they spilled over, let's say one
25 tube, for example --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. ANDREYCHEK: Okay.

2 CHAIRMAN BANERJEE: -- I think you would
3 get that tube full on both sides, you know. It's --
4 it depends on the flow rate, but if it was one tube,
5 I'm pretty damned sure you'd get it full on both
6 sides, so the head would vanish.

7 Then you'd have to establish that you
8 would not really -- you just use that flow path, and
9 you would activate another tube and push stuff up.

10 You see what I mean? It's not that
11 obvious to me that you can count on that head. But I
12 haven't sat down and looked at it.

13 MEMBER MAYNARD: The thing -- it's really
14 -- since you have a hot leg break, it's the top of
15 that tube at the top of the bend is cut off there.
16 The water is just spilling out at that point. It has
17 to be spilling over the tube and down into the hot
18 leg.

19 CHAIRMAN BANERJEE: Let's say you fill up
20 one or more tubes. The one that goes over the top
21 establishes the flow. Now depending on the flow rate,
22 you might be filling the down side as well as the up
23 side. And I haven't sat down and looked at what is
24 the flow rate to keep the tube full on both sides.

25 You see what I mean?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. ANDREYCHEK: Yeah.

2 CHAIRMAN BANERJEE: If it's only one tube,
3 you just fill the tube on both sides.

4 MEMBER MAYNARD: But still you're going to
5 have that -- they're just looking at what is the
6 pressure available at the bottom of the core. So even
7 if it fills both of them up or the -- still the
8 driving head at the bottom of the core is going to be
9 on the bottom of the debris bed. Not necessarily the
10 pressure on the core, it's what the pressure is at the
11 bottom of the --

12 CHAIRMAN BANERJEE: All I'm saying is the
13 driving head -- see, the reason you're filling this is
14 there's nowhere to go. So once it starts over one
15 tube and it starts to go, it will drop on all the
16 other tubes; right? And this tube will be just
17 filled. And it will give you a flow path.

18 MEMBER MAYNARD: But that leg is open to
19 the --

20 CHAIRMAN BANERJEE: The down side won't --
21 it may be full. I have to sit down and do the
22 calculation, look at the true numbers and stuff, but
23 it could be that all you've got is a couple of tubes
24 siphoning, and the pressure is down. You see, this is
25 the argument I was making; right?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER MAYNARD: You're talking about
2 other gpm. So it's certainly going to fill those
3 tubes.

4 CHAIRMAN BANERJEE: Yes. So it just -- I
5 can't sit down and work out -- it would seem to me
6 that the determining thing is the pressure drop
7 through those tubes. If you have, let's say, four or
8 five tubes of this elevation, sit down and do the
9 calculation. I haven't done it. That's why I was
10 saying that once we sit down and do it, we figure it
11 out.

12 MEMBER MAYNARD: Once it goes out through
13 here, comes up back here, recycles and comes out, it
14 will go out --

15 CHAIRMAN BANERJEE: It will rob the break,
16 but you can -- I'm just saying what is -- how many
17 tubes would be filled on both sides? So let me give
18 this argument.

19 Initially it starts to fill; okay?

20 MR. ANDREYCHEK: Right. Uh-huh.

21 CHAIRMAN BANERJEE: That's true. Okay?
22 Now one or two tubes start to go. I've done this
23 reflux condensation test myself.

24 MR. ANDREYCHEK: Uh-huh.

25 CHAIRMAN BANERJEE: So I know what

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 happens.

2 MR. ANDREYCHEK: Sure.

3 CHAIRMAN BANERJEE: You fill them, you
4 spill, and both sides get full, and you just establish
5 a siphon. Now it just drops. So you're getting flow
6 out of there. Instead of going through the core, it's
7 happily going through this spot and out of the break.

8 The head is not going to be affected. You see what I
9 mean? It's just a siphon.

10 DR. WALLIS: If you can establish a
11 siphon. What they're hoping is that you'll never get
12 high enough to get the spillover.

13 MR. ANDREYCHEK: And what we've said is
14 that the limit on the pressure drop is the point where
15 we begin to spill over. That's the limit on the
16 pressure drop.

17 DR. WALLIS: Not necessarily because you
18 fill the siphon.

19 MR. ANDREYCHEK: That's correct.

20 CHAIRMAN BANERJEE: Yes, once you get it
21 over the top, the pressure drop will just drop -- zap,
22 to zero. Whatever is the pressure loss in that tube.

23 At least that's the way I see it. That's the
24 argument I was making.

25 MR. ANDREYCHEK: You create a scenario

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that that might well be the case, and we've set out --
2 we've established a limit that says we're not going to
3 get there. This is our limit. This is the pressure
4 drop.

5 CHAIRMAN BANERJEE: So the point is this.

6 Let's say you had a complete cold blockage. At some
7 point you're going to siphon those tubes because the
8 water has nowhere to go.

9 MR. ANDREYCHEK: Well, what you're saying,
10 you're going to fill, you're going to spill because
11 you can't get water into the bottom of the core. We
12 would agree. If you've got complete blockage at the
13 bottom of the core.

14 CHAIRMAN BANERJEE: Now what you've done
15 is you've activated an alternative flow path --

16 MR. ANDREYCHEK: We agree.

17 CHAIRMAN BANERJEE: -- which is just
18 siphoning away happily, and you'll get no significant
19 pressure loss other than the pressure loss in that
20 tube itself.

21 MR. ANDREYCHEK: Well, I would suggest
22 that what you've got is a head loss and you're driving
23 water up, and it comes down, out the tube. Now if
24 you've got a three-loop or a four-loop PWR, or
25 whatever, two-loop PWR, what you're going to have is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 certainly whatever is in the -- whatever flow is given
2 to the broken leg will flow out the broken hot leg.
3 But the rest of the water isn't -- has to go into the
4 upper plenum and then is available --

5 CHAIRMAN BANERJEE: But, you know, what
6 will happen is that -- I've done this experiment,
7 that's what I'm saying. It will -- as you have given
8 it a low resistance flow path --

9 MR. ANDREYCHEK: Uh-huh.

10 CHAIRMAN BANERJEE: -- the water will just
11 go through there. It won't go up the other things at
12 all.

13 MR. ANDREYCHEK: We agree.

14 CHAIRMAN BANERJEE: It won't go anywhere.

15 MR. ANDREYCHEK: We agree. But we're not
16 getting to that point. We're not establishing the
17 siphon in effect. We're staying below that.

18 CHAIRMAN BANERJEE: With a complete flow
19 blockage, you will.

20 MR. ANDREYCHEK: But we are not getting a
21 complete flow blockage. That's what we're arguing
22 against. We're not going to get there. We're setting
23 limits for the amount of debris that could be put into
24 the core such that we don't exceed the pressure drop.

25 What you are suggesting is beyond the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 limits that we're setting, and we don't want to go
2 there. We want to set limits so that we don't get
3 there.

4 CHAIRMAN BANERJEE: Well, obviously, we
5 would like to see the core not being blocked.

6 MR. ANDREYCHEK: That's correct. And
7 that's what we're saying, we want to make -- our
8 limits establish conditions for debris that preclude
9 us from blocking the core.

10 CHAIRMAN BANERJEE: Well, what I think
11 said, me, all of us are arguing is that maybe for a
12 period you might get this high head, but it's not a --
13 once you get that, it's not sustainable, you see.
14 What would happen is that, yes, you might drive the
15 head up if you really block the core. Then you'd just
16 get alternative paths which would give you a low head
17 path.

18 Now this is for the hot leg break; right?

19 MR. ANDREYCHEK: That's correct.

20 CHAIRMAN BANERJEE: What happens with the
21 cold leg break? Are the tests of much less pressure
22 drop available?

23 MR. ANDREYCHEK: Yeah.

24 CHAIRMAN BANERJEE: So are you going to
25 talk about that as well?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 DR. WALLIS: There's much less pressure
2 drop there, too.

3 CHAIRMAN BANERJEE: Yes.

4 MR. ANDREYCHEK: It went from 97 percent
5 there -- or 94 percent, two-thirds of debris that's
6 recycled, and that's the -- we have not -- the test
7 program says that the hot leg break gives us the worst
8 case for debris deposited into the core, and that's
9 what we're looking at.

10 CHAIRMAN BANERJEE: The highest flow
11 rates?

12 MR. ANDREYCHEK: The highest flow rates,
13 the highest potential for depositing debris in the
14 core, for matching the core boiloff, the amount of
15 time that it takes to get debris into the core is much
16 longer.

17 CHAIRMAN BANERJEE: Let's do this, because
18 I think we are not going to solve this problem now. I
19 think we need to take a look at different scenarios,
20 cold leg and hot leg, and see really which is the
21 limiting situations and it may well be that this is
22 it. But there could be alternative scenarios which
23 could give you worse situations. It's hard to know
24 even if you're throwing out a certain percentage of
25 the debris or the cold leg. It may still be in a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 situation because of much lower head that you could be
2 more -- I don't know. I'm just saying it's what
3 looking at these scenarios in some, you know,
4 quantitative way to make sure.

5 And even with the hot leg break, if you
6 truly do get complete blockage, you've got a low
7 resistance flow path eventually that will be
8 established over the area tube and you'll just get --

9 DR. WALLIS: He's already agreed he's got
10 complete blockage instead. It's not that; he doesn't
11 want to get there.

12 MR. ANDREYCHEK: That's right, we don't
13 want to get there.

14 CHAIRMAN BANERJEE: But then there's the
15 question of what is that amount of blockage which will
16 give you the flow. You know, that's the issue there.

17 DR. WALLIS: And that's what the testing
18 is for.

19 MR. ANDREYCHEK: Exactly.

20 DR. WALLIS: So that debris loading will
21 always keep us below that.

22 CHAIRMAN BANERJEE: Well, I don't think
23 you do, because you get water coming in from the top.

24 MR. ANDREYCHEK: Right. And then we get
25 into a countercurrent flow-limiting situation.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN BANERJEE: So that's at these
2 heat rates?

3 MR. ANDREYCHEK: That's right.

4 CHAIRMAN BANERJEE: And you are not going
5 to get necessarily water coming in because all you
6 will activate is the steam generator connected to the
7 hot leg, and all your water is just going to go out of
8 the hot leg without going through the core.

9 MR. ANDREYCHEK: But you've got more than
10 one hot leg. At least two legs.

11 CHAIRMAN BANERJEE: It doesn't matter.
12 You have no driving pressure to get it up the steam
13 generators. Once you establish a siphon, zap,
14 everything falls.

15 DR. WALLIS: But then it comes back over
16 the siphon to the other hot leg.

17 CHAIRMAN BANERJEE: It depends. It will
18 only go out of the steam generator -- well, never
19 mind. We'll sit down and work the scenario.

20 MR. ANDREYCHEK: Okay. We're getting back
21 to the data now.

22 DR. WALLIS: Your scenario is not really
23 very complete.

24 CHAIRMAN BANERJEE: We don't know if it
25 is. I think what we have established is please look

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 at --

2 MR. ANDREYCHEK: Okay.

3 MR. DINGLER: What we have, we just don't
4 have the data.

5 DR. KRESS: If they stopped their
6 calculation short of that head, say chose seven feet
7 or 10 feet, then you don't have to worry about
8 spillover, unless your fluctuations in flow are
9 greater -- see, if you've got fluctuations in flow and
10 you stop just at that very top, you are going to spill
11 over, and set a siphon up, I think.

12 CHAIRMAN BANERJEE: It's going to be
13 exactly what I said.

14 DR. KRESS: Yes, I know, but I think for
15 some margin, you have to stop that head a little short
16 of that point.

17 CHAIRMAN BANERJEE: To me what would be
18 satisfying is to take the 1 psi that you have
19 available on the cold leg break, take all the debris
20 through the core and show it works.

21 DR. KRESS: Ah, you can't beat that.

22 CHAIRMAN BANERJEE: If you do that, it
23 seems a nice limiting scenario.

24 DR. KRESS: Yes, I agree.

25 CHAIRMAN BANERJEE: You know, then we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 don't have the screw up -- sorry, fuss around with all
2 this stuff.

3 MEMBER ABDEL-KHALIK: You know, the 8630
4 gallons per minute, that's the runout capacity of the
5 pumps?

6 MR. ANDREYCHEK: Pretty much so, yeah.

7 MEMBER ABDEL-KHALIK: So let's say the
8 core is not fully blocked, but partially blocked, and
9 you're injecting water into the cold leg, so some of
10 it will go through the core and out through the hot
11 leg, and some of it will actually go into the steam
12 generator tubes.

13 MR. ANDREYCHEK: Okay.

14 MEMBER ABDEL-KHALIK: The question in my
15 mind is so you have two parallel paths in this case
16 that the pump is feeding, and the question is what is
17 the relative flow rate between the two under various
18 blockage conditions.

19 MR. ANDREYCHEK: Well, first off, when you
20 say what's the relative feeding tube path, the steam
21 generator acts like a holding tank, as it were, to
22 take some of the flow that can't be passed through the
23 core. It's building up, if you want to look at it
24 this way, perhaps -- bear with me on this --
25 gradually. It's not feeding two paths that are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 dumping out to the environment.

2 MEMBER ABDEL-KHALIK: Why not?

3 MR. ANDREYCHEK: Because you're not
4 feeding over the steam generator at that point. You
5 haven't filled up the steam generator.

6 MEMBER ABDEL-KHALIK: I mean you have one
7 entry point --

8 MR. ANDREYCHEK: Uh-huh.

9 MEMBER ABDEL-KHALIK: -- and one exit
10 point, which is the hole.

11 MR. ANDREYCHEK: Okay.

12 MEMBER ABDEL-KHALIK: And you can get to
13 the hole in one of two ways: going through the core,
14 out through the upper plenum, out through the hot leg
15 and out through the break; or you can go through the
16 core by going cold leg into the steam generator, out
17 the hot leg, back into the break.

18 MR. ANDREYCHEK: If there's a sufficient
19 amount of resistance in the core, and we're saying
20 we're going to limit the resistance at the core
21 entrance so that we don't get there.

22 Yes, you'll build up some water, but if
23 you don't get there because you can't feed it, there's
24 not enough resistance at the core entrance, then you
25 don't get to that point.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN BANERJEE: I think what -- to
2 sort of move on, say, I think the point has been made
3 that we need to explore a number of scenarios and look
4 at what is really the bounding scenario.

5 Now it could be that this is truly
6 bounding. The one that could be intuitively bounding
7 would be, as I said, just to take that -- take a void
8 fraction of essentially zero -- zero, I would say, if
9 you really want to bound this, which gives you a
10 pressure loss of -- available pressure head of 1 psi
11 or something, and put all your debris in, and if it
12 works, then we are all happy boys or girls. Right?

13 MR. ANDREYCHEK: Yes.

14 CHAIRMAN BANERJEE: It may not need very
15 much more than that. Or at least that's my feeling
16 right now, but it needs to be dealt with in a
17 considered way.

18 MR. ANDREYCHEK: Okay.

19 CHAIRMAN BANERJEE: Looking at all the
20 scenarios and looking at what might be a bounding
21 scenario. Bounding set of scenarios, if you wish.

22 MR. ANDREYCHEK: Okay.

23 CHAIRMAN BANERJEE: Let's move on from
24 that.

25 MR. ANDREYCHEK: Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN BANERJEE: And there will be --
2 sorry.

3 DR. WALLIS: What was the pressure drop in
4 these two types?

5 MR. DINGLER: We cannot give that
6 information out --

7 DR. WALLIS: But you can see it's under
8 13?

9 MR. DINGLER: Yes.

10 DR. WALLIS: But you only need 2-1/2 for -
11 - you've only got 2-1/2 for the cold leg break?

12 MR. DINGLER: We need 14 for -- 14 is the
13 max. For a hot leg break. If we close this as
14 proprietary, then we can give you the information.

15 DR. WALLIS: But you said you need 2-1/2
16 for the --

17 MR. ANDREYCHEK: For the cold leg break.

18 MR. DINGLER: This is hot leg.

19 DR. WALLIS: So this would block the cold
20 leg break?

21 MR. ANDREYCHEK: Yes, it would.

22 MR. DINGLER: If we had cold leg flows and
23 stuff like that. Yes.

24 DR. WALLIS: And you can't tell us how
25 much it's under 13?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. DINGLER: We can if we close the
2 meeting.

3 DR. WALLIS: And you can't tell us which
4 of them was higher?

5 MR. DINGLER: We've got to close the
6 meeting.

7 CHAIRMAN BANERJEE: Well, if you like,
8 Graham, what we can do is let them run through the
9 presentation --

10 DR. WALLIS: You can tell me personally,
11 can't you?

12 CHAIRMAN BANERJEE: No, no, we are going
13 to --

14 (Laughter.)

15 CHAIRMAN BANERJEE: -- close, if you wish.

16 DR. WALLIS: Can you tell me personally?

17 CHAIRMAN BANERJEE: What I suggest is we
18 try to finish a little bit earlier and I'll close the
19 meeting for 15 minutes, then you can give us --

20 MR. DINGLER: I apologize, but --

21 CHAIRMAN BANERJEE: That's fine, but this
22 is proprietary. Whatever. We'll take care of it,
23 okay?

24 So what we want to do now is to talk about
25 your observations for this set of tests, noting that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 there could be other scenarios.

2 MR. ANDREYCHEK: Okay. So what we
3 observed was that we had seen that behavior -- we did
4 not observe that. The fiber provides certainly
5 collection sites for debris, and from what we
6 observed, it appears to be the driver for the head
7 loss that we observed.

8 Specifically we noticed almost no head
9 loss increase when we flipped the particulate, in even
10 the high particulate case.

11 The chemical precipitates tended to behave
12 as another source of particulates. The initial
13 results would indicate to us that the chemical
14 precipitates did not increase head loss.

15 DR. WALLIS: Now did all the fiber get --
16 clog the holes? Did all the fiber end up in the
17 holes?

18 MR. ANDREYCHEK: Actually if you take a
19 look at the very last bullet, it says it as though the
20 fiber appears to be distributed in grids along the
21 height of the bundle. So it --

22 DR. WALLIS: So it didn't get all stuck at
23 the bottom?

24 MR. ANDREYCHEK: It did not.

25 MR. DINGLER: Let me show the picture

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 again.

2 DR. WALLIS: Well, that's an important
3 observation if anyone is going to calculate anything.

4 They need to know where the fibers go.

5 MR. ANDREYCHEK: That's right.

6 MR. DINGLER: Based on two tests.

7 DR. WALLIS: Do you have any photographs
8 of where the fibers were or anything? Did you take
9 any --

10 MR. ANDREYCHEK: That's what I'm going to
11 show right here in this picture. What we saw, we
12 certainly saw fibers down here at the bottom surface
13 and in the hole. We saw fibers on the protective
14 grid. We saw some fibers here at the first grid,
15 fibers here, fibers here, fibers here, and some, a
16 little bit lesser, perhaps, fibers up here at the very
17 top.

18 There tended to be -- when we have -- when
19 we go to look, we did an optical probe that we could
20 insert into the bundle. But when we began to remove
21 some of the fuel rods simulations to look inside the
22 bundle, it appeared to us that there was a reasonably
23 equitable distribution of fiber and particulate and
24 chemical surrogate material throughout the bundle.

25 Now there was also some particulate that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 stayed in solution, and I believe one of you gentlemen
2 asked about gap, and we modeled the gap at the bottom
3 nozzle as it would be in the plant. And the gaps
4 between the grid straps all the way up the height were
5 modeled as they would be in the plant. And so what we
6 see is bypass flow up through some of those gaps. As
7 you begin to collect the one flow restriction, you
8 begin to -- you know, fiber bypasses and particulates
9 bypass, and you go to the next one, and so on and so
10 forth.

11 CHAIRMAN BANERJEE: Do you have any
12 pressure taps on these walls?

13 MR. ANDREYCHEK: Yes, we do.

14 CHAIRMAN BANERJEE: You can actually look
15 at the pressure losses.

16 MR. ANDREYCHEK: Yes, we have.

17 CHAIRMAN BANERJEE: Yes. And tell where
18 the stuff is going; right?

19 MR. ANDREYCHEK: Yes, we have.

20 MR. DINGLER: And that's the data that
21 we're still evaluating.

22 MR. ANDREYCHEK: That's correct.

23 MEMBER SHACK: Now let me just get the
24 sequence. You add the particulates first, and what do
25 you see happen just at that point?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. DINGLER: Very little head loss.

2 MR. ANDREYCHEK: That's correct.

3 MR. DINGLER: Almost zero.

4 MEMBER SHACK: Okay, and now it's
5 recirculating in the tank. That's correct. Now you
6 dump the fiber in.

7 MR. DINGLER: That's right. And our head
8 loss starts increasing.

9 MEMBER SHACK: Okay.

10 MR. ANDREYCHEK: And if you notice on
11 slide 42, we start adding fiber in small batches.
12 We're looking at five grams a pop, let the loop turn
13 over a couple of times. We add another five grams,
14 and then another five grams, and then another five
15 grams. We do that eight times, and then we add a
16 little larger, it's 13 grams -- 13 grams -- to get us
17 to total fiber mass addition. And that allows us to
18 build up -- we were looking again -- the reason --

19 CHAIRMAN BANERJEE: These are relatively
20 low fiber plants then; right?

21 MR. ANDREYCHEK: That's correct.

22 CHAIRMAN BANERJEE: Okay.

23 MR. ANDREYCHEK: That's correct. Now we
24 did -- the last test we ran, we haven't had a chance
25 to reduce the data, used about 90 grams of fiber, a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 little higher amount of fiber.

2 CHAIRMAN BANERJEE: And how much pressure
3 loss are you getting, frictional pressure loss due to
4 the increase in pressure loss, if you like?

5 MR. ANDREYCHEK: Well --

6 CHAIRMAN BANERJEE: Can you say that, or
7 is it proprietary?

8 MR. DINGLER: It's proprietary.

9 CHAIRMAN BANERJEE: Okay.

10 MR. ANDREYCHEK: Sorry. I just wanted to
11 give you --

12 CHAIRMAN BANERJEE: No, that's fine.

13 MEMBER ABDEL-KHALIK: Does this loop have
14 a PD pump?

15 MR. DINGLER: What do you mean by a --

16 MR. ANDREYCHEK: Positive displacement?

17 MEMBER ABDEL-KHALIK: Positive
18 displacement pump.

19 MR. ANDREYCHEK: No, it does not.

20 MEMBER ABDEL-KHALIK: So it's a
21 centrifugal pump?

22 MR. ANDREYCHEK: Yes, sir.

23 MEMBER ABDEL-KHALIK: So how do you
24 control the flow?

25 MR. ANDREYCHEK: We control the flow by

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 using a flow restriction that tightens down on the
2 flow path so that we are not chewing things up any
3 further in terms of -- or clogging a valve, or if we
4 have for a flow measurement device, we're using a
5 magnetic flow device, so we don't have a turbine meter
6 that will get clogged by fiber.

7 MEMBER ABDEL-KHALIK: And presumably these
8 are constant flow rate experiments; right?

9 MR. ANDREYCHEK: That's correct.

10 MR. DINGLER: And we maintain -- tweaked
11 the things so it maintains constant.

12 MR. ANDREYCHEK: That's correct. There's
13 a flow restriction on the feedback loop that allows
14 the restriction to open up in the flow path such that
15 it does not restrict flow, and we maintain a constant
16 monitor flow, and we track it and see if the flow
17 remains constant over the test.

18 CHAIRMAN BANERJEE: There's not a --
19 there's no bypass flow around the pump?

20 MR. ANDREYCHEK: No. No. There is a pump
21 to keep things in the 200 or so gallon mixing tank in
22 solution so we don't get settle-out in the tank, but
23 that's separate from the circulation through the test
24 facility proper.

25 DR. WALLIS: At the end of the test, all

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 this material is trapped, is it? There's no more
2 circulating around, there's no --

3 MR. ANDREYCHEK: No, there's still
4 particulates through the system.

5 DR. WALLIS: So it's still going around at
6 the end of the test?

7 MR. ANDREYCHEK: Uh-huh. And there still
8 may be some fiber in that.

9 DR. WALLIS: Do you have a measure of
10 that?

11 MR. ANDREYCHEK: No.

12 DR. WALLIS: So we don't know how many got
13 caught and how many are still going around?

14 MR. ANDREYCHEK: No, we don't have that
15 measure, no.

16 MEMBER SHACK: And when you add the
17 chemical particulate, you don't really see any
18 significant pressure increase over what you got from
19 the fiber?

20 MR. ANDREYCHEK: We have not. In fact,
21 what we've seen is --

22 MR. DINGLER: We've seen a little, but not
23 much. You know, what you saw was a big jump, we're
24 seeing -- well, it starts leveling off before we add
25 the chemical and it just slightly then levels off

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 again, so we see no --

2 MEMBER SHACK: Is this just going up as
3 bypass flow on the sides of the --

4 MR. DINGLER: It may. Based on what we're
5 seeing, I don't think so. In other words, you can see
6 some of that what I was told in the filters and stuff
7 like that, so.

8 MR. ANDREYCHEK: In fact, in some of the
9 cases we've seen actually a pressure decrease when the
10 chemicals are added. The pressure drop actually went
11 down.

12 MR. DINGLER: And some of this we saw in
13 the big sump screens, too. When you added a
14 particulate first, then the fiber, the chemical in the
15 limited number of tests I saw, five, six or 10 of
16 them, had very little sharp increase. If you add the
17 fiber first, we saw a big increase within the
18 chemical. So it looks like on that that it's the
19 particulate and fiber. There are still increases
20 ahead, but it's still -- we didn't see that big jump
21 that we saw with the one that you saw.

22 DR. KRESS: How do you explain the
23 decreased pressure?

24 MR. DINGLER: We're still evaluating the
25 data. We can't right now.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. ANDREYCHEK: It's a good question. We
2 asked the same question.

3 DR. KRESS: Of course you would.

4 CHAIRMAN BANERJEE: But you saw that you
5 also see it on the sump screens?

6 MR. DINGLER: Saw what?

7 CHAIRMAN BANERJEE: The same sort of
8 behavior on some sump screens.

9 MR. DINGLER: Yeah.

10 CHAIRMAN BANERJEE: When you added the
11 chemical particulate, did the pressure drop actually
12 way down?

13 MR. DINGLER: No, we saw not a steady
14 increase.

15 CHAIRMAN BANERJEE: I see.

16 MR. DINGLER: A sharp increase. In other
17 words, again, I've only seen five to seven, five to 10
18 sump screen tests, and when you add the fiber or the
19 particulate first, then the fiber, the chemical didn't
20 show a big increase. That's what I've seen in five to
21 10 tests.

22 CHAIRMAN BANERJEE: Paul Klein, do you
23 have a comment to make?

24 MR. KLEIN: Paul Klein. I just wanted to
25 make one observation that we've seen in some of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 strainer tests when you add the precipitate. You can
2 get bad redistribution during that process and it can
3 affect head loss. So it's possible that you might
4 open bore holes, for example, in the bed, or if you
5 don't have -- I think in some of these low fiber
6 initial tests, you may not have an effective filtering
7 bed for chemical precipitate, so you can add it, but
8 the fiber might already be saturated with some of
9 their earlier particulate, and they're just not much
10 effect compared to the ANL test loop.

11 MEMBER ABDEL-KHALIK: So if you have a
12 flow anomaly in the lower plenum, does that mean that
13 single bundle experiments may not be representative of
14 what happens in the whole core?

15 DR. WALLIS: Well, probably the answer is
16 yes. Now if you have -- in your test, did you get a
17 uniform distribution across or did you get some of
18 these holes essentially open because of this bore hole
19 phenomenon? I would wonder if you can get a really
20 uniform --

21 MR. DINGLER: We didn't see the bore
22 holes.

23 CHAIRMAN BANERJEE: Can't see?

24 MR. DINGLER: We can't see them, that's
25 right. But based on when we pulled it out, there are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 some tests that the NRC will give you that saw more of
2 a uniform compaction bed on the bottom of the -- on
3 the bottom nozzle that it passed around than what
4 we're seeing.

5 DR. WALLIS: When you pull it out, it's
6 like pulling out a piece of felt, is it? Or what is
7 it?

8 MR. ANDREYCHEK: Actually, in order for us
9 to disassemble the facility, we -- the rig is set up
10 so that we actually pulled the entire assembly out of
11 the flow chamber, and then we lay it down sideways so
12 we can begin to disassemble it.

13 What we've -- let it set overnight so that
14 water drains off and whatnot, so we don't basically
15 draw suction and pull stuff off of it. We try to do -
16 - be as reasonable as we can at pulling it out, but
17 what we see is that some of the material stays in
18 place on the bottom. Is it all the material that's
19 there at the end of the test? I couldn't tell you for
20 sure. I don't know. Again, we can't see into the
21 facility.

22 CHAIRMAN BANERJEE: But it's not compacted
23 like into a felt?

24 MR. ANDREYCHEK: No, not that we saw so
25 far on the three tests.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN BANERJEE: But I think we've seen
2 some tests where it was --

3 MR. GEIGER: What we pulled out from the
4 holes, it was like little clumps of felt, like little
5 cylinders of felt, and even around the upper parts you
6 could -- you know, it is like clumped up -- clumped to
7 get the fibers fairly tightly so it was like felt, and
8 it was just filled with particulate and things, too.
9 But I mean if you looked at the eddy currents and
10 things, I mean there were currents going every which
11 way through the fuel and around it.

12 CHAIRMAN BANERJEE: But it wasn't blocking
13 up all layers -- were all layers blocked?

14 MR. GEIGER: It looked like it has a
15 uniform layer across it. Yeah. Because unfortunately
16 we don't have photographs, but it was all -- because
17 the carbide is a very gray material, so it was a very
18 uniform gray. It almost looked like somebody had
19 spray painted it with, you know, a gray paint.

20 CHAIRMAN BANERJEE: Yes, it would be nice
21 to see some photographs of things, but I'm sure you're
22 in the early stage now.

23 MR. ANDREYCHEK: Yes.

24 CHAIRMAN BANERJEE: You're seeing these
25 things.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 So let me understand what you are
2 observing. You do some visual observations after the
3 tests are finished. You do some pressure loss
4 measurements while the tests are going on, and then
5 after the visual, do you do any analysis of what you
6 pull out to see how much particulate, how much fiber,
7 whatever it is, of what's happening there?

8 MR. ANDREYCHEK: We've not done that.

9 CHAIRMAN BANERJEE: Do you intend to take
10 a look at stuff clogging the tapes or something?

11 MR. ANDREYCHEK: Our current plans are to
12 look at the pressure drop data and evaluate the
13 pressure drop data only.

14 CHAIRMAN BANERJEE: Only the pressure
15 drop.

16 MR. ANDREYCHEK: Only the pressure drop
17 data.

18 CHAIRMAN BANERJEE: And what about the
19 visuals? You'll do some visuals, right, to see where
20 it is and --

21 MR. ANDREYCHEK: We'll do some visuals.
22 We'll document with photographs as to what's collected
23 where and how much, visually only. We're not trying
24 to scrape the material off and weigh it at any given
25 elevation. And part of the reason for that is is that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 in order to get at the material inside the inner
2 bundle, we basically dislodge pieces of it when we
3 pull the bundle apart in order to get at it and clean
4 it.

5 DR. WALLIS: I would think the bed would
6 be thicker where the holes are, because that's where
7 the flow is. The flow is bringing the fibers in and
8 they will build up and so bulge into the hole, won't
9 they?

10 MR. ANDREYCHEK: Go back to the bottom
11 one. There you go.

12 I think you have a good point, but what we
13 see as you begin -- this is what I believe is
14 happening -- is you begin to build -- that's your
15 fiber here. We've got these flow holes along the side
16 and these holes in the skirt, as it were, so flow will
17 tend to go through the gap that we've maintained and
18 to go up and around.

19 So while you're right, you will tend to
20 collect fiber perhaps initially --

21 DR. WALLIS: Where the flow is, yeah.

22 MR. ANDREYCHEK: -- where the flow is
23 coming up, you are also going to have your least
24 resistance flow path that wants to take it around and
25 take it up the side and then back into the bundle.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 And that's what is the mechanism, I believe, based on
2 my preliminary evaluation of the data, that gets us to
3 --

4 DR. WALLIS: Well, the reason I'm asking
5 these sorts of questions is because I'm not sure what
6 is at the pressure. If the pressure dropped, you
7 could have a situation where you have one hole, one
8 hole which is blown through.

9 MR. ANDREYCHEK: Uh-huh.

10 DR. WALLIS: And you have a blanket over
11 all the other holes.

12 MR. ANDREYCHEK: Uh-huh.

13 DR. WALLIS: That could be what's
14 determining the pressure drop, just the flow, the
15 resistance of that one hole.

16 Now if it's one hole or two or three,
17 that's a statistical thing, and you wouldn't expect it
18 to be the same in every experiment, if that's the
19 mechanism.

20 So if you don't have a uniform bed, I
21 would be concerned about the randomness of which hole
22 happens to be open and how many, if that's what
23 happens.

24 MR. ANDREYCHEK: I guess I would ask to
25 understand what the concern is, whether it's one or

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 three holes.

2 DR. WALLIS: My concern is there's flow
3 coming in, which is sort of not uniform, not
4 necessarily.

5 MR. ANDREYCHEK: Okay.

6 DR. WALLIS: And so there may be -- the
7 mechanism may be you block up holes one after the
8 other, and you leave one or two that never get
9 blocked.

10 MR. ANDREYCHEK: Okay.

11 DR. WALLIS: That could be what happens.
12 In that case, whether you leave one or two or three is
13 going to make all the difference in the world to the
14 pressure drop, and that's a statistical thing which
15 may not be as deterministic as you could determine in
16 one experiment. You see what I mean?

17 CHAIRMAN BANERJEE: So, in other words, if
18 you keep repeating this same experiment, let's say, if
19 that's what happens.

20 DR. WALLIS: If that's what happens, you'd
21 get different results. Sometimes you get one hole,
22 sometimes you get two.

23 MR. ANDREYCHEK: But I think -- and bear
24 with me; maybe I'm not understanding it correctly --
25 but that would suggest that the only way you're going

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 to get flow is through that hole?

2 DR. WALLIS: No, no, I said that might be
3 the way you get the flow. You get flow through the
4 rest of it as well.

5 MR. ANDREYCHEK: Exactly.

6 DR. WALLIS: But you could have some which
7 are completely open.

8 CHAIRMAN BANERJEE: A few open holes will
9 give youm as I say, a flow path that has low
10 resistance.

11 MR. ANDREYCHEK: Over that particular
12 span, but again if we're looking at over the entire
13 height of the test rig, we're tending to get
14 repeatable total pressure drops across the entire
15 height. I'm not so sure that one grid matters that
16 much.

17 DR. WALLIS: It doesn't matter, it's what
18 governs the pressure drop. Is it a uniform bed, or is
19 it a bed that which is pretty well blocked in some
20 places and very thin or open in others?

21 MR. DINGLER: As Mr. Geiger says, it's
22 uniform, but it wasn't a heavy compacted uniform bed.

23 DR. WALLIS: How is that, sir?

24 MR. DINGLER: In other words, what we're
25 seeing is it was lightly -- a very small bed, again --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 I can't remember the data at this point.

2 What we saw in another test by another
3 utility, it was a much thicker compacted bed. We need
4 to look and see why is that different? Is it because
5 we're testing four foot and they were testing not four
6 foot? I don't know at this point. That's a data
7 point that we have to look at.

8 CHAIRMAN BANERJEE: Well, there is also a
9 question of how much fiber load your plant has and
10 --

11 MR. DINGLER: And they had less fiber than
12 we did, so we've got to figure out what's going on.

13 CHAIRMAN BANERJEE: Well, that's
14 interesting. Anyway, so we're really reviewing your
15 test protocol right now and what you're doing. And so
16 the key issues, I suppose, are related to what are the
17 tests you're planning, and what are you measuring. So
18 I think you've already got some feedback that you
19 might look at what might be really the limiting
20 scenarios, and with regard to the measurements, the
21 only thing that you're measuring right now is the
22 pressure losses, and Professor Wallis and some others
23 suggested it might be also useful to have a look at
24 what things are circulating around, what percentage of
25 the material you're catching and what you're not

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 catching.

2 Now it could be that you could look at
3 what is continuing to circulate to give you a measure
4 of what has been caught on the grids. You know, I
5 don't know how you could do it. These are just
6 suggestions. I mean that was one thing that came out.

7 MR. ANDREYCHEK: It sounds like a
8 filtration efficiency.

9 CHAIRMAN BANERJEE: Yes.

10 MR. ANDREYCHEK: For practical purposes.

11 CHAIRMAN BANERJEE: Right. So, you know,
12 that could be something that you might look at.

13 MR. WALLIS: I've just been trying to do
14 some rough calculation here, and it looks as if you
15 have enough fiber to build up a bed which might be
16 something like an inch thick. Is that -- am I
17 completely wrong here?

18 MR. ANDREYCHEK: Based on what volume?

19 MR. WALLIS: You said two pounds per cubic
20 foot, density of 2-1/2 roughly. If I take that and
21 spread it over this area with 53 grams, I found I can
22 get something like an inch thick.

23 MR. ANDREYCHEK: See, I think there's --
24 that's one of the reasons that we've gotten away from
25 using a volume of fiber, because the volume --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. WALLIS: But it's the idea of what's
2 happening. I mean it's very different to me if you
3 have an inch thick of fiber than if you have, you
4 know, a thousandth of an inch.

5 MR. ANDREYCHEK: I understand, but what
6 you're looking at is a piece of fiberglass, low
7 density fiberglass, and saying this is what it weighs,
8 this is the size of it.

9 What we're dealing with is finely chopped-
10 up fiber. So now, you're right, and to be honest, you
11 were looking at a void -- if you take a look at this -
12 - using paper we have given you previously on
13 compaction, we're looking at something that's probably
14 60 percent compacted of the density of glass. And the
15 density of glass is about 159 pounds per cubic feet,
16 so we're dealing with the density of this --

17 MR. WALLIS: It's a --

18 MR. ANDREYCHEK: This is about 90 or so
19 pounds, approximately, if we're dealing with the
20 density of this finely chopped-up stuff. So when you
21 start looking at that perspective, then I think if you
22 were using that as a basis, you'd come up with a much
23 thinner --

24 MR. WALLIS: Much thinner bed.

25 MR. ANDREYCHEK: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. WALLIS: Okay.

2 CHAIRMAN BANERJEE: The thing is the
3 density of fiberglass, which you quoted, or somebody
4 last time, was giving us 2.4 pounds per cubic foot.
5 This is as manufactured fiberglass.

6 MR. ANDREYCHEK: Uh-huh. That's NUKON
7 insulation, yes, sir.

8 CHAIRMAN BANERJEE: Correct. So -- but
9 that's porous.

10 MR. ANDREYCHEK: That's correct.

11 CHAIRMAN BANERJEE: So you'd get flow
12 through that. So when it compacts, you could get it
13 down to that of ordinary glass, which would be --

14 MR. ANDREYCHEK: One hundred fifty-nine
15 pounds per cubic feet if it were straight glass.

16 MR. WALLIS: You won't get a compression
17 like that in any of the --

18 CHAIRMAN BANERJEE: You might get it a
19 compaction factor of three or four, or whatever, but
20 more likely you're going to have a couple of times and
21 all the spaces are going to get filled up with
22 particles; right?

23 MR. DINGLER: And that's one of the
24 reasons we try to stay away from cubic feet because
25 what --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN BANERJEE: Yes, but I think what
2 Professor Wallis is trying to establish is what is
3 going to be the dimensions of this bed. So let's
4 assume that we had all of it and it's double the
5 density and fill it up with just rough calculation.
6 So with 2.4 or 2.5 or 2 -- you're arriving at what, a
7 one-inch thick bed; right? What was your number,
8 Graham?

9 MR. SMITH: This is Steve Smith, NRR.

10 I did some quick calculations when we were
11 up visiting, and you are correct, the first 40 grams
12 that went in, if you put it over the 8-1/2 inch
13 square, that would be about an inch thick, and then
14 the 13 grams on top of that would be additional.

15 However, this fiber is -- and that would
16 be based on as manufactured, and it's not that, so
17 it's going to be something less than that. We don't
18 know exactly what it's going to be.

19 MR. WALLIS: It's 14 pounds of
20 particulates is quite a volume, too.

21 MR. SMITH: Well, it's quite a bit less
22 because it's much denser. But this is being spread
23 out not only over this 8 x 8 square fuel, it's in six
24 or seven places in the fuel. So theoretically maybe
25 an eighth of an inch spread out over the entire thing,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 and then it gets compressed, so that's more likely the
2 volume that you're looking at.

3 MR. ZIGLER: Mr. Chairman, allow me a
4 comment and a clarification, please, sir.

5 CHAIRMAN BANERJEE: Yes, go ahead.

6 MR. ZIGLER: My name is Gil Zigler. I'm
7 with Alliance Science & Technology. I've been doing
8 head loss testing for a number of years.

9 The results of their experiment is
10 perfectly comparable with the type of fiberglass
11 shards used for head loss testing that they did.

12 When you are down to the size distribution
13 that was used in this test, those head loss test
14 results are perfectly normal.

15 So please do not confuse, Dr. Wallis, if I
16 may say so, test results used with fiberglass strands
17 as with test results used with fiberglass shards.
18 They are two different complete animals in their
19 behavior patterns.

20 CHAIRMAN BANERJEE: Well, the longer ones
21 that Graham was talking about, the strands, over a --
22 I don't remember, 1000 microns, would give you very
23 different behavior from the shards?

24 MR. ZIGLER: Absolutely, sir. You can see
25 that on the results in BWR testing in the OECD NEA

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 results that we did back in the late '90s and early
2 2000s on it, and that's where an experimeter from
3 Finland did some wonderful testing on different size
4 hole size for bridging capabilities, and that's what
5 we're seeing here, is their test results are perfectly
6 consistent with the kind of debris that they used for
7 their testing.

8 CHAIRMAN BANERJEE: With the size
9 distribution of --

10 MR. ZIGLER: Absolutely, yes. The test
11 results are perfectly compatible.

12 Thank you, Mr. Chairman.

13 CHAIRMAN BANERJEE: Well, that would
14 probably open up this question of the size
15 distribution now, but let's move on.

16 So what that brings up again is in
17 addition to measuring the stuff which is circulating
18 around, probably we need to also understand how you
19 established the size distribution which Professor
20 Wallis was worrying about right at the beginning, you
21 know, which we said we'll revisit at the end, so we'll
22 go back to that.

23 Anyway, so let's continue.

24 MR. ANDREYCHEK: Okay. So how are we
25 going to use the data, and our intent for the use of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the data is to establish an acceptance criteria for
2 the amount of debris that can be delivered to the RCS
3 postaccident. Total bypass mass of fiber, total
4 bypass mass of particulate, and total bypass mass of
5 chemical precipitate.

6 If a plant can't meet these limits or
7 acceptance criteria, then they have several actions
8 that they can choose to take.

9 One is to reduce the debris loading that
10 would reach the reactor coolant system by either
11 reducing debris generation or reducing the transport.

12 And, of course, reducing debris generation has two
13 aspects to it.

14 One is to remove material, and the other
15 is to demonstrate that it is a higher resistance to
16 jet impact loading than previously allowed,
17 particularly in NEI-0407.

18 The other is to perform some plant-
19 specific tests that demonstrate the pressure drop with
20 their plant-specific debris mix under the flow rates
21 needed to be considered, give them sufficient amount
22 of margin to the driving rod.

23 CHAIRMAN BANERJEE: Well, the last point
24 is that they should conduct their own tests?

25 MR. ANDREYCHEK: They may choose to do

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that. That's correct.

2 CHAIRMAN BANERJEE: Making their own
3 bundles.

4 MR. ANDREYCHEK: Or, more specifically,
5 using their plant-specific debris mix.

6 CHAIRMAN BANERJEE: Oh, I see. Okay.
7 Yes.

8 MR. ANDREYCHEK: That would be my -- one
9 option they have available to them.

10 MEMBER ABDUL-KHALIK: Would the acceptance
11 criteria that you list on this slide presumably
12 correspond to the maximum available pressure drop?

13 MR. ANDREYCHEK: That's correct.

14 MEMBER ABDUL-KHALIK: Now that pressure
15 drop comes about because you have a mixture of all
16 three. So how do you establish limits for each one
17 individually?

18 MR. ANDREYCHEK: We would be looking
19 parametrically, as we already started looking at the
20 amount of fiber, or changing the amount of
21 particulate, low fiber, low particulate, then high
22 particulate, and then we'll look at parametrically the
23 chemical effects and calcium silicate as well as MEN-
24 K.

25 MEMBER ABDUL-KHALIK: So how would a plant

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 use that information to combine, you know, an X amount
2 of fiber plus a Y amount of particulate plus a Z
3 amount of chemical precipitate?

4 MR. ANDREYCHEK: It would look at what the
5 results are and see where they fall underneath the --
6 where they fall under the data blanket that we've
7 generated.

8 MR. WALLIS: So you're developing a three-
9 dimensional surface of some sort?

10 MR. ANDREYCHEK: Of bins.

11 CHAIRMAN BANERJEE: Of bins. Bins in 3-D.

12 MR. WALLIS: Well, that's a surface.
13 That's really a surface.

14 CHAIRMAN BANERJEE: It's a cross-surface.

15 MR. WALLIS: A cross-surface.

16 CHAIRMAN BANERJEE: And in the order, does
17 it matter? I mean, or are you sort of ordering the
18 things which we've just heard seem to matter, right?
19 It seems, adding the fiber or the particulates. Is
20 that a parameter that's important or not?

21 MR. ANDREYCHEK: We are -- we are not
22 playing with the order of sequence. We are following
23 the NRC guidance for screen testing, which says
24 particulate first, then fiber, then chemical. That's
25 been what the accepted --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. WALLIS: When this was done with the
2 vertical test facilities, people tried to do this,
3 establish a surface where there was a nice formed
4 surface with these three variables, but it turned out
5 the surface had bumps and protrusions depending upon
6 how you did the test and whether or not you got a thin
7 bed and that kind of thing. It wasn't a nice smooth
8 surface. You could make the surface stick out a bump
9 here or there depending on how you did the test. That
10 was in the vertical tests.

11 MR. DINGLER: And if you go to sheet 43,
12 based on three tests -- and we've still got to look at
13 it, in that we didn't see a thin bed.

14 MR. WALLIS: You didn't see it.

15 MR. DINGLER: We didn't see a thin bed.
16 And we particularly added material in very small
17 increments to make sure we passed through it.

18 CHAIRMAN BANERJEE: But I guess that must
19 depend on how long -- you know, it goes back to that
20 question that Professor Wallis had about the size
21 distribution. If you had a lot of long fibers that
22 could potentially set up a thin bed, so the size
23 distribution becomes quite critical. I don't know.
24 We have to review this a little bit more and think
25 about it.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 It's good that we are getting this
2 information and, you know, after about a week or two
3 of digesting it, I'm sure we'll get some --

4 MR. DINGLER: And one thing I can say
5 that's not proprietary, on the two tests we did, it
6 looked like the increased particulate kept the fiber
7 the same, the increase in head loss was minimal. So
8 it looks like higher particulate is not driving the
9 head loss as much as the fiber.

10 CHAIRMAN BANERJEE: You haven't yet done
11 higher fiber; right?

12 MR. DINGLER: We -- --

13 CHAIRMAN BANERJEE: You have, but you
14 haven't got the results.

15 MR. DINGLER: We haven't got the results.
16 We had a higher fiber loading in all the other two.
17 We just haven't got the results yet.

18 CHAIRMAN BANERJEE: So eventually you'll
19 be giving us quantitative data to look at, right, in
20 your report. Okay.

21 Can we move on? Is it okay?

22 MR. ANDREYCHEK: Okay.

23 CHAIRMAN BANERJEE: And now we are off the
24 head loss and we are on to something else.

25 MR. ANDREYCHEK: We are on to something

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 else.

2 There was a question about hot spots the
3 last time we met. This slide briefly summarizes the
4 hot spot discussion. The source of heat from decay
5 heat --

6 CHAIRMAN BANERJEE: Just before we go on,
7 there are two things that I should flag right now.
8 One is that at some point we should have a sort of a
9 test matrix to look at, if that's possible. You've
10 said it qualitatively in words.

11 MR. ANDREYCHEK: We have.

12 CHAIRMAN BANERJEE: You have certainly got
13 one, and in that I guess we need to know what flow
14 rates you're using and what particle loadings you're
15 using and what fiber and chemical and whatever else
16 you're adding to it.

17 MR. DINGLER: In our protocol we had that.
18 We jumped two tests. We changed the sequence so we
19 had data because we weren't going to come in front of
20 you without some data.

21 CHAIRMAN BANERJEE: You are very wise.

22 (Laughter.)

23 CHAIRMAN BANERJEE: But now that you've
24 got this kid glove treatment --

25 (Laughter.)

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN BANERJEE: -- that would not have
2 been the case if you came without any data.

3 MR. DINGLER: I figured that would be it.

4 CHAIRMAN BANERJEE: So now with this data,
5 of course, we feel much more reassured. We would like
6 to see -- I think we would like to see the whole test
7 matrix that you're planning, and certainly we can give
8 you some comments or give the staff some comments on
9 that.

10 The second thing that I think we would
11 like to see, if it's possible in some way, is this --
12 all the data that you showed in your table -- I guess
13 it's on page 36, where you showed a few plants.

14 Now somewhere you've got a compilation of
15 all this data. That would be, I think, useful to look
16 at, but in addition to that, we commented that maybe
17 some brief description of what the plant was -- high
18 fiber, low fiber -- this sort of thing would be
19 useful.

20 MR. DINGLER: What we'll do, since I'm not
21 -- at this point I didn't ask permission to give the
22 plant names, so A, B, and C, and then list this, and
23 then high fiber, low fiber.

24 CHAIRMAN BANERJEE: Yes, high fiber, low
25 fiber, high particulate, low particulate. And then

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 you had some data on the quantity of bypass related to
2 that plant. So we want distributions in this, but we
3 haven't got was it over one pound, less than one
4 pound, whatever.

5 MR. ANDREYCHEK: It's on page 37.

6 CHAIRMAN BANERJEE: Yes, but the
7 information on page 37 and 38, if it could be related
8 to your A, B, C.

9 MR. DINGLER: Yes, we will do that.

10 CHAIRMAN BANERJEE: Okay. We are just
11 asking for information right now, for informational
12 purposes.

13 So I think with that, and then the test
14 matrix, that would give us some, you know, background
15 to go on.

16 MR. GEIGER: Now did you make measurements
17 to see what your distribution of likes were in your
18 fiber batches?

19 MR. ANDREYCHEK: Yes, we did.

20 MR. GEIGER: But you didn't give us that?

21 MR. ANDREYCHEK: No, again --

22 MR. GEIGER: Oh.

23 CHAIRMAN BANERJEE: So then can you answer
24 that question?

25 MR. ANDREYCHEK: Yes, we can.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN BANERJEE: As well for the closed
2 session?

3 MR. ANDREYCHEK: Yes, we can.

4 CHAIRMAN BANERJEE: Okay, so what we are
5 going to do is let's try to get through the rest of
6 this by 3 o'clock if we can, that's 45 minutes, and
7 then we'll close the session for half an hour, maybe.

8 Or do we need more than half an hour for the closed
9 session?

10 MR. DINGLER: I don't think so, unless you
11 guys ask a lot of questions.

12 CHAIRMAN BANERJEE: Well, there might be.

13 (Laughter.)

14 CHAIRMAN BANERJEE: Because, you know --

15 MR. WALLIS: When do we get the final
16 story? I mean you're working on this, you've got a
17 lot more experiments to run. Eventually you're going
18 to put it all together, you're going to rewrite the
19 NUREG. We want to see it sometime before it goes out
20 and is used.

21 CHAIRMAN BANERJEE: Well, of course we
22 would have the right to see it.

23 MR. WALLIS: So this is sort of a progress
24 report today.

25 MR. ANDREYCHEK: Yes, it is.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. WALLIS: And we haven't had written
2 material to review, we haven't been able to look at
3 the details and sort of see if we believe them or not.

4 So we need something substantial some time.

5 CHAIRMAN BANERJEE: Well, I think the
6 purpose of this is we are going to have to write a
7 letter to the Commission --

8 MR. WALLIS: That we've made progress, but
9 we've got a lot more to come or something?

10 CHAIRMAN BANERJEE: Well, I think we can
11 identify as we did in last year's TRACE letter that,
12 you know, progress -- the progress that has been, what
13 is being planned, and whether we endorse the plan or
14 not. I mean that's the open question that we'll have,
15 or our comments on the plan.

16 So at some point I guess we should -- and
17 the staff may help us -- identify what progress has
18 been made towards resolving this issue. You know, we
19 should clearly state that, and then what is still to
20 be done.

21 MR. WALLIS: We can't write something
22 which says we can see that they now have enough
23 material to resolve the GSI.

24 CHAIRMAN BANERJEE: But that's not the
25 purpose.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. WALLIS: Well, I thought we were going
2 to get there some day.

3 CHAIRMAN BANERJEE: We are still hoping
4 to.

5 (Laughter.)

6 CHAIRMAN BANERJEE: But I think all we can
7 do at this point is to say that this is where we are,
8 this is what still needs to be done, and whether we
9 agree with it or not, or what our comments on it are,
10 and that's really what we can do in our letter.

11 And I guess this will be still -- is it
12 part of the Commission briefing in November?

13 MR. GEIGER: Yes, it is.

14 CHAIRMAN BANERJEE: All right.

15 MR. GEIGER: We get to talk to the
16 commissioners about it.

17 CHAIRMAN BANERJEE: Okay. So we should
18 have a coherent story.

19 MR. DINGLER: You mean Bill has to have
20 one?

21 CHAIRMAN BANERJEE: No, I have to have
22 one.

23 (Laughter.)

24 CHAIRMAN BANERJEE: Which is difficult.

25 MR. WALLIS: Are you talking to the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Commission?

2 CHAIRMAN BANERJEE: I think we are, yes.

3 MR. WALLIS: On Thursday?

4 CHAIRMAN BANERJEE: No, in November.

5 MR. WALLIS: Oh, November, okay.

6 CHAIRMAN BANERJEE: Yes, we have time.

7 (Laughter.)

8 CHAIRMAN BANERJEE: We really do want to
9 make sure we have a coherent story. Okay.

10 Please continue.

11 MR. ANDREYCHEK: Okay, thank you.

12 With regard to hot spots, again the source
13 of the heat for the hot spots is decay heat in the
14 fuel, and it's decreasing over time postaccident.

15 These hot spots can arise only if flow is
16 restricted locally. Local temperature increases would
17 be mitigated by boiloff in regions around the hot
18 spots. Heat will be dissipated by grids which will
19 tend to act like radiators or conductors, as well as
20 axial conduction to sustain the quench and replacing
21 boiloff will maintain clad temperatures below the 800
22 degree F that we've identified as a cladding peak
23 temperature limit post-LOCA once we've recovered the
24 core and gone on to research from the sump.

25 We have some conservative calculations in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 clad temperatures that demonstrate the coolability of
2 the clad with deposition on the clad surface and
3 blockage at the grid.

4 In addition to that, the LOCA DM
5 calculations that we do calculate what kind of
6 deposition we'd get at a very conservatively low
7 thermal conductivity rate that shows that, one, we
8 don't get a lot of deposition, and what deposition we
9 get still provides a clad temperature well below 800
10 degrees Fahrenheit.

11 These other sensitivity calculations that
12 we did looking at assuming no flowthrough of grid
13 strap and conduction through the -- actually along the
14 fuel rods as well as through the grid strap proper,
15 give us some indication that we have acceptably low
16 temperatures.

17 Next slide, please.

18 This slide is a 1-D clad hot spot
19 calculation. What we are looking at on the right-hand
20 side, we have assumed a .36 inch diameter fuel rod.
21 We assigned a heat flux from a calculation, an ECCS
22 calculation, on the inside surface to model the
23 cladding thickness. We have added an oxide layer and
24 a crud layer, and then we added the precipitant as a
25 parametric in 10 mil increments.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 We used the decay heat for the heat flux
2 right at 20 minutes post-LOCA, so we had a high heat
3 flux which would tend to decrease over time, due to
4 the natural decay of heat.

5 And we said, okay, what temperatures would
6 we get? The top table gives you the value of a .36
7 inch diameter rod, and you can see that we are looking
8 at, with 15 mils thickness, a maximum temperature of
9 560 degrees Fahrenheit, with a thermal conductivity of
10 0.1.

11 DR. KRESS: What did you use for H?

12 MR. ANDREYCHEK: The H was approximately
13 580 Btu or -- I'm sorry, 600 or so Btu degree F on the
14 outside surface. I can give you the specific numbers.
15 I don't have them. But it's in the neighborhood.

16 DR. KRESS: Close enough.

17 MR. ANDREYCHEK: Okay. And the same is
18 true when we looked at different rod diameters, which
19 is in the table below on the left-hand side. We
20 looked at a .7, a .416, and a .4220 D rod, looked at
21 what the effects of thick rods, and certainly when we
22 get to 50 mils, it would be about 714 degrees
23 Fahrenheit for a .4220 D rod, with 50 mils.

24 DR. KRESS: Was there concern about H
25 being influenced by deposition of fibers and things on

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 spacers so that local H is lower?

2 MR. ANDREYCHEK: We were looking at
3 something about midspan, to be honest about it. We
4 were looking -- and we did not couple a blockage at a
5 grid with a flow above the grid in the bundle. We
6 were not looking at multiple --

7 DR. KRESS: Isn't that part of the
8 concern? That blockage of the grid could prevent the
9 flow going past the bundle?

10 MR. ANDREYCHEK: Well, it might have been
11 at one time, but again, what I'm looking at -- and
12 when I looked at the testing that we just did when we
13 looked at what kind of flows we get, we certainly get
14 a pressure drop, but we're getting flow at each of the
15 grid spans. So I think the test data, when we couple
16 that with the calculations we've done, tend to
17 mitigate that concern.

18 DR. KRESS: But you have cross-flow, don't
19 you?

20 MR. ANDREYCHEK: Exactly.

21 DR. KRESS: That wasn't simulated in your
22 test.

23 MR. ANDREYCHEK: It is not, no. Although
24 because it's an open lattice amongst the fuel
25 assemblies, we do -- within the fuel assembly proper,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 we see the flow running through the bundle.

2 When we look at the -- a two-dimensional
3 model we were using to look at what happens between
4 the grid straps, these temperatures plotted on this
5 curve are behind peak temperature -- underneath or
6 behind a grid strap. We're looking at the conduction
7 available. Actually we're not seeing a temperature
8 better than about 425 degrees Fahrenheit with a .1
9 thermal conductivity through this blockage. And I
10 would suggest that that is a very, very small thermal
11 conductivity because even though we've seen from the
12 testing we get some mass collection there, again we
13 are not seeing that it's totally blocked.

14 DR. KRESS: When you calculate this, you
15 have to look at the width of the grid that the
16 conduction takes place?

17 MR. ANDREYCHEK: I'm sorry. Say that
18 again, please?

19 DR. KRESS: When you're talking about part
20 of the grid straps, you have to assume there's kind of
21 no flow to cool above it, for some length above it.
22 It seems like you have to assume some length in this
23 calculation. I was wondering how you arrived at that.

24 MR. ANDREYCHEK: Well, again, because of
25 the fact we're getting flow across the bundle, I don't

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 see that we -- I don't think that's an appropriate
2 assumption.

3 DR. KRESS: But the width is just the
4 thickness of the grid.

5 MR. ANDREYCHEK: Of the grid strap. And
6 we have a two-inch thick grid strap.

7 DR. KRESS: Okay. It's two inches.

8 MR. ANDREYCHEK: Yes, sir.

9 DR. KRESS: That answers my question, the
10 two inches.

11 MR. ANDREYCHEK: Okay. And I do have some
12 numbers for you. The conductive heat transfer at the
13 OD was 650, a little higher than what I had originally
14 estimated. The oxide level was approximately .1
15 inches -- I'm sorry, 100 microns, and the crud was 100
16 microns.

17 DR. KRESS: Now in this calculation, the
18 thicker the crud and deposits are, the better off you
19 are?

20 MR. ANDREYCHEK: Actually, no, because
21 what we looked at was using the thermal conductivity -
22 - we were using the oxide thermal conductivity as .1 -
23 - it was 1.27 Btu and the crud was .03, so you do have
24 a little bit of --

25 DR. KRESS: The thicker it is, the more

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 area you've got to transfer the heat.

2 MR. ANDREYCHEK: Yes. Yes.

3 DR. KRESS: So the thicker, you're better
4 off.

5 MR. ANDREYCHEK: Yes. I guess you're
6 right in that case, yes. But we're still talking not
7 large area increases because we're only looking at
8 .004 inches in the diameter increase. So we're not
9 talking large orders of magnitude area increases.

10 Boric acid precipitation for a postulated
11 hot leg break, for all practical purposes, because the
12 flow rate is through the core, there's no opportunity
13 for boric acid buildup. As along as we're getting
14 flow through the core, the core is being flushed and
15 the boric acid is not a buildup.

16 For a postulated cold leg break, the only
17 flow into the core is based on makeup of the boiloff,
18 and boric acid and sodium borate carryover in the
19 steam from the boiling process is low. Therefore, you
20 do get the buildup of the boric acid and borates in
21 the core.

22 The current licensing basis calculations
23 are in place to define the time for operators to
24 initiate action to dilute the core.

25 Next slide, please.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 To assure the licensing basis calculations
2 remain valid, the following considerations are taken
3 into account:

4 One, half of the lower plenum of the
5 reactor vessel remains available for mixing. It's
6 typically what's used in Westinghouse and I believe
7 some CE plants. AREVA has a different criteria that
8 involves a different flow area, and I'm not familiar
9 enough to go into great detail discussing that.

10 The existing EOP, emergency operating
11 procedures, direct plant operators to initiate hot leg
12 recirc or core flushing flow to maintain a flushing of
13 the reactor volume.

14 Based on what we currently know, once the
15 plant operators initiate hot leg recirculation, core
16 fluid is diluted and mixing of boric acid solution in
17 the core is maintained below precipitation limits.

18 Potential impact for debris on boric acid
19 solution mixing is to be addressed in another PWR
20 Owners Group program outside of GSI 191, and that
21 project authorization is PA-ASC-0264, and that program
22 -- Mo, you might want to make a statement about what
23 that program is and how long it's been -- you know,
24 what its intent is.

25 MR. DINGLER: There was a question based

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 on current licensing that we have plants on power
2 upgrade. We had some questions on the boric acid
3 there, so this program was taken out to evaluate that
4 current license, and now GSI-191 debris input is going
5 to be used as an input to that program to evaluate the
6 boric acid, you may call it dilution, you may call it
7 stagnation, whatever you want to call it, as an input
8 to that program, and they're developing a peer review
9 panel. The peer review WCAP was submitted to the NRC
10 on information. Donnie and I -- Donnie Harrison,
11 talked, we talked at lunch about how to find it, to
12 send in this information only to document control
13 room. We'll try to find out who it was sent to, but
14 that program is going to use the GSI-191 to make
15 inputs and then do the whole licensing issues on boric
16 acid and solve that once and for all.

17 Right now it's a two-phased program. One
18 is define what the issues are, phase one, and get with
19 the NRC staff to make sure they're onboard with the
20 phase one, and then phase two is after they get a
21 course of action is to go ahead and solve the issue.
22 That's the current plan for that program right now.

23 CHAIRMAN BANERJEE: I'm sorry, I may have
24 missed it, but the last meeting, there were some
25 discussion about mixing between the core and the lower

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 plenum. Did you address this right now, or that's
2 something --

3 MR. ANDREYCHEK: Well, the way that it's
4 being addressed is that we do have -- we do take
5 credit for one-half of the lower plenum remaining
6 available for mixing purposes.

7 MR. DINGLER: And then when we go to hot
8 leg recirc on the OP space, we flush the core back
9 out. And based on what we know today, that will still
10 react because there is a potential that this debris
11 could be -- and also staff has some questions on the
12 methodology for the last 15 years or whatever. We got
13 this other project to put it to bed once and for all.

14 CHAIRMAN BANERJEE: The fact that the
15 core, let's say if you assume there was substantial
16 blockage of the core inlet, there is no potential
17 impact on the -- I mean how do we know that half the
18 lower plenum is available for mixing? That was a
19 question that was raised. It's just coming back to
20 me. I wonder how you're answering that.

21 MR. DINGLER: What we believe is -- well,
22 what the plant has got to do is take credit for the
23 path, is they've got to look at the amount of debris
24 coming in and make sure that's not over one-half.
25 That's one item.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 The other one is we're looking at when we
2 go back to hot leg recirc, will that flush some of the
3 stuff out of the core, or the debris in that. So
4 we're looking at that and opening things back up a
5 little for us. And that's how we're taking credit for
6 it right now.

7 You know, based on what we know, we do not
8 believe there's an issue.

9 Now based on this additional project, as
10 you all know, when you do further investigations,
11 something may come up. But we don't know at this
12 time. I'm sorry, but, you know, based on what we know
13 today, we're still operable, still functional.

14 CHAIRMAN BANERJEE: Okay. Let's move on
15 then.

16 MR. ANDREYCHEK: Okay. Just a note on
17 defense in depth with regard to the current licensing
18 basis for boric acid solution calculations, we don't
19 take credit in current licensing basis calculations
20 for some buffering agents that will neutralize boric
21 acid and raise the solubility limits of boric acid.
22 There's no boron carryover and the entrained liquid
23 around the loop for cold leg break. It stays
24 concentrated in the core. No boron carryover in the
25 steam out the -- through the hot leg and out the steam

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 generator for a cold leg break and we're using
2 Appendix K decay heat levels which maximize the
3 boiling, and that therefore maximizes for cold leg
4 break the amount of flow into the core which would
5 tend to increase the concentration quicker since
6 you're boiling off faster.

7 We also consider the assumptions, defense
8 in depth, we considered the following conservative
9 assumptions used in the GSI-191 degree transport, and
10 that is that all debris are assumed to arrive at the
11 core inlet at the time of switchover, i.e., even in
12 the testing we're doing, we're saying we get a
13 tremendous amount of debris in a very short period of
14 time right to the core. So we're building the bed,
15 the debris bed, as quickly as possible, and the decay
16 heat decrease with the time reducing the velocities in
17 the reactor vessel lower plenum, again, for a cold leg
18 break.

19 So we have got some conservatisms in the
20 boric acid considerations that aren't explicitly
21 accounted for in the licensing basis calculations.

22 So in summary, WCAP-16793-NP and
23 supporting work, we believe has demonstrated
24 reasonable assurance of long-term core cooling.

25 MR. DINGLER: The word will.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. ANDREYCHEK: Will.

2 CHAIRMAN BANERJEE: I think "has" is
3 perhaps --

4 MR. DINGLER: Hey, we're positive here.

5 MR. ANDREYCHEK: Will. Will. That fuel
6 assembly is currently being performed to establish
7 debris limits for plants. For plants that demonstrate
8 that they satisfy those limits are done, there's no
9 additional work that they need to do. And plants that
10 do not satisfy the limits can take remedial actions,
11 among which remedial actions are to reduce the amount
12 of debris generation associated with their plant,
13 reduce the debris transport by a number of means, and
14 perform plant-specific head loss testing, specifically
15 using their plant-specific debris loading.

16 CHAIRMAN BANERJEE: Thank you. I'm going
17 to consult for a moment as to whether we should just
18 take a break now and then come to the closed session,
19 or whether we should have the closed session and then
20 take a break, because there is a visitor from the
21 Union of Concerned Scientists, and I don't want him to
22 sit out in the hallway. If necessary, we can take a
23 brief break now, and then close the session later.
24 Let me talk to him and see if he wants to --

25 MR. GEIGER: Why don't we at least take

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the break, and then --

2 CHAIRMAN BANERJEE: Okay. So let's take a
3 break now, and then right after the break, we'll
4 either close the session or we'll have the statement
5 and then we'll close the session.

6 Fifteen minutes.

7 (Recess.)

8 CHAIRMAN BANERJEE: Please get organized,
9 and we are going to go back into session, so we are
10 going to have a presentation by Mr. Lochbaum of the
11 Union of Concerned Scientists. Mr. Lochbaum is here,
12 so go to it.

13 MR. LOCHBAUM: Thank you for accommodating
14 me on what was clearly a tight schedule, and I will
15 try to be brief.

16 What I wanted to show you today was a DVD
17 of an event that occurred over a decade ago at Point
18 Beach, and I think that event has some relevance to
19 the GSI-191 issue. It's a very short video.

20 CHAIRMAN BANERJEE: Can we enlarge this
21 and blow it up?

22 MR. LOCHBAUM: Once I get it running.
23 This is -- in May of 1996, a worker preparing to weld
24 a lid on -- the shield lid on a dry cask at Point
25 Beach ignited some hydrogen gas, caused a hydrogen

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 burn event. The following day that cask was lowered
2 back into the spent fuel pool at Point Beach. This is
3 a video from the NRC's Public Document Room we
4 obtained under the Freedom of Information Act of the
5 cask shield lid being removed from the cask after it
6 had been lowered back into the spent fuel pool the
7 following day.

8 The -- this is -- they put a camera in a
9 remote submersible rig and this is sitting essentially
10 right at the cask flange, a very close-up view of the
11 cask lid being removed.

12 The video I extracted here is four
13 minutes. I'll leave the DVD with you. The full thing
14 in the PDR is about three hours long and tests
15 everyone's patience.

16 But for some background on that event, the
17 hydrogen was created by an unexpected chemical
18 reaction between the borated spent fuel pool water and
19 an epoxy coating applied to the inner surface of the
20 dry cask.

21 The first indication of that unexpected
22 chemical reaction was the hydrogen burn, when the guy
23 doing the welding lit it off, and it caused the three-
24 ton cask lid to go up in the air a bit, come down
25 cockeyed, but there was no injuries. It was a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 considerable surprise, I imagine.

2 As the lid is being removed in the next
3 minute or so, you will see, in addition to the
4 hydrogen gas that was produced by the unexpected
5 chemical reaction, there was an awful lot of white
6 precipitate matter just floating around once the cask
7 bottom reaches the surface. It's an incredible amount
8 of material that was also created as a byproduct of
9 that chemical reaction, and I didn't realize it until
10 I reviewed this tape of just how much material was
11 there.

12 MR. WALLIS: These are bubbles are
13 hydrogen, are they?

14 MR. LOCHBAUM: No, it could be nitrogen or
15 it could be air, too, because they refilled the cask
16 once they lowered it back into the pool.

17 MR. WALLIS: This is after the event?

18 MR. LOCHBAUM: This is after the event,
19 the following day.

20 MR. WALLIS: It could be helium.

21 MR. LOCHBAUM: It's the white material you
22 start seeing floating out now in quite copious
23 quantities. Later in the video, not in this segment,
24 they actually bring the camera up and look at the
25 lower surface of the cask lid as it's been lifted up,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 and it's an amazing amount of material still stuck --
2 you can see some of the edge there, some of that white
3 material. There's an awful lot of material stuck to
4 that cask lid.

5 And I think the lesson that this event, I
6 think, plays to GSI-191 is I have to assume that as
7 they were loading -- this is a VSC-24 cask, holds 24
8 fuel assemblies. Even if you are able to move 12
9 assemblies an hour, which is a tremendous pace, it
10 takes over two hours to load one of these things.

11 In that two-hour period you are moving a
12 fuel assembly one by one into that, I've got to assume
13 that the hydrogen bubbles or this white snow wasn't
14 there or somebody would have noticed it.

15 So it seems most likely that the reaction
16 that produced the hydrogen in this white precipitate
17 was at a very slow rate while the cask was being
18 loaded. I just can't believe that workers missed that
19 much debris floating around, which means that the
20 chemical reaction either started or accelerated after
21 the lid was put on, after the cask was lifted out of
22 the spent fuel pool.

23 There's a picture of the top. It's just a
24 tremendous amount of debris. And it just doesn't seem
25 credible that that was being created as the cask was

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 being loaded, and it was the stuff -- that chemical
2 reaction started after the lid was placed on, after it
3 was moved out, either because the temperature went
4 off, because it's no longer being cooled by the
5 overall spent fuel pool cooling system and it was just
6 convective cooling, or because you partially drained
7 the water as you do in sealing the lid on.

8 So it was the introduction of air or both,
9 the higher temperature and the air as a catalyst that
10 caused the chemical reaction that produced this
11 material in the hydrogen gas.

12 The relevance of that event to GSI-191 is
13 we've heard a lot of testing that's been done or will
14 be done, and this was also predated -- the testing
15 predated this event, and nobody wanted this to happen,
16 and yet it did happen.

17 So we're a little bit concerned that the
18 testing that's been done so far is at ambient
19 temperature, some temperature -- we saw some slides
20 this morning, where they did some cycling from 140
21 degrees down.

22 In a GSI-191 type event, the water that's
23 sprayed from the broken pipe and from the containment
24 spray system can be well above 140 degrees.

25 It may not just be the chemical reaction

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 between whatever is submerged in that water. It could
2 be whatever material -- what equipment, coatings, and
3 so on that were sprayed in the process of that
4 accident that produces this debris.

5 It's not -- and this, again, this is a
6 cask, it was intended to be put in borated water. It
7 had a very small set of variables. There's only so
8 many materials, so many coatings applied to that cask.

9 The vendor, the licensee, and the NRC staff all
10 missed the chemical reaction that this event
11 demonstrated.

12 During the actual use of the cask, the
13 loading, there were no evident signs, I'm assuming, I
14 think it's reasonable to assume that there were no
15 readily available signs of this chemical reaction that
16 was about to occur, and yet it did occur.

17 When you have as many variables, as many
18 coatings that are used in the various plants across
19 the country, it seems more likely that we're going to
20 have these kind of surprises than less likely.

21 I mean Dr. Wallis and others asked
22 questions about are these tests that are being
23 performed bounding, limiting, conservative, whatever.

24 Given the number of variables and the coatings, the
25 temperatures, the air as a -- all these things, it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 just seems that this event shows that there's a pretty
2 high likelihood or an unreasonably high likelihood
3 that we haven't covered all the bases, and while we
4 can do all this testing and show the things in the lab
5 won't produce flow blockage and stuff, in reality I
6 don't know.

7 I hope -- first of all, I hope we never
8 have a loss of coolant accident where we have to test
9 this thing, but if we do, will what we see be what
10 Point Beach saw when they tried to weld the lid on, or
11 will it be what predated that, where we had basically
12 all the big answers -- questions answered, and we
13 didn't have such a big surprise.

14 From what I've seen, to be fair, it's
15 still a work in progress, and staff and the industry
16 may cover all the bases at the end, but it seems like
17 right now we haven't tested all the configurations,
18 all the coatings, all the factors that could lead to
19 this kind of chemical reaction that produces copious
20 amounts of precipitate which could clearly challenge
21 both the in-vessel and the containment sump screens
22 themselves.

23 So that's basically -- I'll leave the DVD.

24 The full thing is actually in the PDR, so you can see
25 I didn't doctor or anything like that to the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 photographs, but we think that this issue is relevant
2 to the GSI-191 issue, and we're hoping to see some
3 integration of all these testing results to give some
4 confidence that a surprise that may be down the road
5 is relatively small, it's not as big as this one.

6 So --

7 DR. KRESS: Did anybody collect the debris
8 and try to identify what it actually was chemically?

9 MR. LOCHBAUM: The -- when we looked --
10 and to be fair, we were in the same boat. When this
11 event occurred, we looked at it for what other dry
12 casks might be affected. We didn't, until the last
13 few weeks did the light go in my head, well, this also
14 has beyond dry cask issues.

15 When the data was collected, it was how
16 many casks used that epoxy coating, how many of the
17 ones that are already loaded could have had this white
18 precipitant loaded that could affect heat transfer in
19 a sealed cask. It wasn't drawing the bigger questions
20 from that.

21 So --

22 MR. GEIGER: Well, this one says zinc-
23 based coating, which would be more reactive,
24 presumably, than most epoxy coatings. There's plenty
25 of zinc-based coatings around.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN BANERJEE: And it was acidic.

2 MR. WALLIS: Acidic. I think we talked
3 about zinc earlier, and as long as you've got the
4 buffer there, but like before it's mixed with the
5 buffer, you can get some reactions up in the
6 containment.

7 MR. GEIGER: Well, sodium hydroxide is
8 generally in the spray.

9 MR. WALLIS: Yes, but before that.

10 MR. LOCHBAUM: In the containment spray,
11 not in the spray out of the broken pipe.

12 CHAIRMAN BANERJEE: I think it would be
13 interesting to at least know what that investigation
14 showed, you know.

15 MR. LOCHBAUM: We looked at it, to answer
16 Dr. Kress's question, from the dry cask event, and we
17 actually have a -- again, one of the NRC Public
18 Document Rooms for various reasons, and we couldn't
19 find it in there. Because this event occurred in
20 1996, there's not many documents on it in ADAMS, but
21 if you go back to the old microfilm, again, most of
22 the questions were what other dry casks may have been
23 affected and so on.

24 So I don't -- there's not -- there may be
25 some other data that's not in the public document --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN BANERJEE: So the investigation
2 alluded to there, you couldn't find the results of
3 that investigation?

4 MR. LOCHBAUM: Other than identifying who
5 else might have been using similar materials. And for
6 the event, that was the right questions asked, but I
7 think there's bigger questions.

8 CHAIRMAN BANERJEE: Sure, they wanted to
9 make sure it didn't happen again.

10 MR. LOCHBAUM: Right. And also this
11 occurred in May of 1996. It actually predates GSI-191
12 by a few months -- not many months, but a few months.

13 So with that, I appreciate your
14 indulgence.

15 CHAIRMAN BANERJEE: Thank you very much.

16 MR. LOCHBAUM: In putting me on the
17 schedule, and --

18 CHAIRMAN BANERJEE: Thank you for your
19 comments and please, you know --

20 MR. LOCHBAUM: That's your copy. I'll
21 leave that here. Thank you.

22 CHAIRMAN BANERJEE: Okay. In that case, I
23 think what we do now is we'll close the meeting, and
24 I'll ask the appropriate people to ensure that whoever
25 should not be in the room is not in the room, because

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 I don't know who should or should not be.

2 (Whereupon, at 2:59 p.m., the subcommittee
3 went into closed session, and rejoined the open
4 session at 3:40 p.m., where the following proceedings
5 were had:)

6 CHAIRMAN BANERJEE: All right, we're going
7 to go back in session. Back in session. And now
8 we're going to hear from NRR staff with regard to
9 activities related to this WCAP.

10 MR. SMITH: Yes.

11 CHAIRMAN BANERJEE: Or the WCAP to come.

12 MR. SMITH: WCAP to come.

13 It's Steve Smith again, and Bill Curdiak
14 is going to help me out with some of the work that
15 Research did, some of the analytical models on fuel
16 blockage.

17 A lot of this you guys already talked
18 about, so I'm not -- I'm just going to try and go
19 briefly through the presentation and not dwell on
20 areas that have already been discussed, so basically
21 we're going to talk about -- next slide -- fuel
22 blockage testing and considerations. I think this has
23 been discussed pretty well.

24 We'll talk about some industry testing,
25 and then we're going to talk about the analytical

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 models that Research has worked on.

2 Basically the fuel inlet designs that we
3 are working with -- and here's from Westinghouse and
4 AREVA. The Westinghouse designs are relatively
5 similar to each other. There are some differences.
6 The AREVA designs have some differences between them.

7 We haven't seen any testing done on the AREVA designs
8 yet, so we're really not sure, you know, what the
9 results will be once we get testing on that.

10 We have seen testing on the Westinghouse
11 designs.

12 MR. WALLIS: Do you know what the fine
13 mesh is like?

14 MR. SMITH: It's a fine mesh screen,
15 basically.

16 MR. WALLIS: Well, how fine is it?

17 MR. SMITH: It makes me a little more
18 nervous than the other -- than the other designs.

19 MR. WALLIS: You can't tell the
20 Westinghouse guys what it looks like; right?

21 MR. SMITH: They know. They know what it
22 looks like. They sent us the information. I mean the
23 PWR --

24 (Laughter.)

25 MR. SMITH: The PWR Owners Group, not

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Westinghouse.

2 (Laughter.)

3 MR. SMITH: They can only tell each other
4 certain things. I'm not sure --

5 MR. WALLIS: Maybe AREVA will start
6 sending you Westinghouse information.

7 (Laughter.)

8 MR. SMITH: We can get it.

9 (Laughter.)

10 CHAIRMAN BANERJEE: Going back to that
11 previous slide, roughly what proportion of the fuel
12 that you're talking about belongs in these categories?

13 MR. SMITH: I don't know. I have been
14 told that the fine mesh is not even a full core.
15 There's only some fuel assemblies and a core that has
16 the fine mesh on it. So that is a consideration.

17 MR. DINGLER: This is Mo.

18 The fine mesh, there's two plants and two
19 considering it. There's about 38 with Westinghouse
20 fuel and about two-thirds, one-third split with the
21 fuel. Westinghouse has two-thirds, AREVA is about a
22 third, approximately, give or take in there.

23 CHAIRMAN BANERJEE: As these plants go to
24 a higher and higher performance fuel for various
25 reasons, do you expect they will have more complex

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 sort of structures? What's done today somehow has to
2 bound what will happen later; right?

3 MR. DINGLER: What we're finding is the
4 initiative the CEOs have taken with NPO to have no
5 leakage by 2010 is counterreactive to what we're doing
6 in GSI-191.

7 CHAIRMAN BANERJEE: They want to open up
8 the fuel more?

9 MR. DINGLER: No, they want to close the
10 fuel more for normal leakage, which is fighting
11 against us in GSI-191.

12 CHAIRMAN BANERJEE: But that's what I was
13 meaning, yes.

14 MR. DINGLER: We're seeing that, and we're
15 going -- having some talks with the CEOs that, you
16 know --

17 MR. WALLIS: Well, this is sort of a
18 different problem.

19 CHAIRMAN BANERJEE: Okay, let's go ahead.

20 MR. SMITH: Okay, the various fuel inlet
21 designs and testing we've seen, Diablo Canyon
22 performed significant testing on the Westinghouse
23 alternate P-grid, and we have a lot of data that is
24 actually in a public trip report that we put out, so
25 we can share that data.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 They also did some testing with reloads
2 for -- with the P-grid versus the alternate P-grid,
3 and it looks like the P-grid is actually a more
4 limiting -- it's going to capture -- create a higher
5 DP.

6 Now their testing was not like the
7 Westinghouse test that you saw with the four foot
8 assembly. It was only one -- it was only the bottom
9 nozzle with the grid on top of it and then one
10 intermediate strap on top of it, and we'll have a
11 picture of that to show you.

12 CHAIRMAN BANERJEE: And they kept going
13 until basically they've taken out all the --

14 MR. SMITH: Right. And they keep
15 recirculating, so it's probably a more limiting test
16 that gathered all the debris in one small area, and
17 we'll show you some pictures of that.

18 And based on the testing that we have
19 seen, both at -- that Diablo did and the Westinghouse
20 testing, it looks like we are not going to get a thin
21 bed across the bottom of the fuel inlet. The debris
22 is going to spread out and get caught on all the
23 straps going up the fuel inlet.

24 CHAIRMAN BANERJEE: Did they use the sort
25 of high -- relatively what appeared to be high flow

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 rates for what the Owners Group showed up to now, or

2 --

3 MR. SMITH: They used both cold leg and
4 hot leg flow rates. They did about half of each.
5 They did some at 5 gpm and theirs wasn't quite as
6 high. I think it was like 41 gpm was their hot leg
7 break, and their cold leg was a 5 gpm flow rate. So
8 they did some. And their head losses -- we'll go into
9 it, but they were quite a bit lower. I mean they're
10 usually measuring inches of head loss. So -- but they
11 had a lower fibrous debris load also.

12 CHAIRMAN BANERJEE: They're a no-fiber
13 plant?

14 MR. SMITH: Yes. Yes.

15 MR. WALLIS: Okay, this thin bed, it's
16 never been clear to me what a thin bed is. Its
17 thinness is not the key.

18 MR. SMITH: No, it's not.

19 MR. WALLIS: The key is that somehow the
20 particles fill up the holes in the fibers and give you
21 something which blocks the flow much more effectively
22 than if it's randomly distributed, or is some other
23 fraction of distribution.

24 MR. SMITH: It's the ratio --

25 MR. WALLIS: Oh, it's the ratio.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. SMITH: And also how it -- how the bed
2 builds, you know, how the bed builds.

3 MR. WALLIS: And it can be at the bottom
4 or the top or throughout or anywhere, as long as you
5 get this critical mix of things.

6 MR. SMITH: Right. It seems to be less
7 likely than if you already have a lot of fiber there
8 that you're going to get that because the particulate
9 tends to migrate through.

10 MR. WALLIS: Right.

11 MR. SMITH: But if you have a small amount
12 of fiber with a lot --

13 MR. WALLIS: With a lot of particulates.

14 MR. SMITH: Yes, it seems to be more
15 likely to have that happen.

16 MR. WALLIS: But it could be a thin layer
17 in a thicker bed, too. I mean there are ways in which
18 you can make a thin bed sort of on top of a thick bed.

19 It's not a magical thing about just, you know, a
20 certain thickness that --

21 MR. SMITH: I guess it's possible, but I
22 think it's less likely. It's less likely.

23 MR. WALLIS: Until we really know what it
24 is and how to predict it, be careful about talking
25 about --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. SMITH: The thin bed is really hard to
2 define, I agree with that.

3 MR. WALLIS: All right.

4 MR. SMITH: There's been a lot of
5 discussions.

6 CHAIRMAN BANERJEE: Well, it's a
7 qualitative description.

8 MR. SMITH: Yes.

9 CHAIRMAN BANERJEE: Where you get a rather
10 high pressure loss, even though the bed is very thick.

11 MR. WALLIS: I would call it a saturated
12 layer or something, something that sort of fills the
13 pores in the layer and makes it much more effective as
14 a blockage element than --

15 MR. SMITH: If we had started calling it
16 that about five years ago, it probably would have made
17 our job a lot easier trying to discuss with industry
18 exactly what it is. Because when you say thin bed,
19 you know, we say there's -- people think that there's
20 a minimum amount of fiber, that if you have less than
21 that, you won't get a high head loss, but we haven't
22 seen that to be the case.

23 CHAIRMAN BANERJEE: Okay, let's move on.

24 MR. SMITH: Okay. I think we already
25 talked about a lot of the bullets on this slide. We

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 talked about how they do the fibers bypass testing.

2 The testing to date that has been done for
3 the fuel -- one thing I don't know if that was brought
4 up -- they assumed that there was no -- the
5 particulate and the chemicals do not get filtered out,
6 so they put the flow of chemical and particulate load
7 scaled down to the single bundle into the test, and
8 then the fiber is -- does assume whatever would bypass
9 the screen.

10 So the fibrous load is reduced from what
11 gets created during the event. However, the chemicals
12 and the particulate loading does not get reduced.

13 CHAIRMAN BANERJEE: How did they establish
14 the fiber loading based on their tests, based on
15 bypass?

16 MR. SMITH: Yes, the Diablo Canyon fiber
17 loading was established based on bypass testing that
18 they did with their strainer.

19 CHAIRMAN BANERJEE: So I guess then we go
20 back to that old question of -- how much goes through
21 as a function of time. So they used a cumulative
22 amount and stuck it in there.

23 MR. SMITH: And how much goes through is a
24 function of time and the rate, I think, is a function
25 of time, because as time goes on, less and less goes

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 through, because the debris bed gets more and more
2 efficient at filtering things out as the -- as time
3 goes on.

4 CHAIRMAN BANERJEE: So in the testing that
5 was done for Diablo Canyon, it was a once-through
6 screen that they were using? They were not
7 recirculating the flow in the screen?

8 MR. SMITH: It was continuously
9 recirculating, so anything that got through the fuel
10 assembly went back through the loop and came back to
11 the bottom.

12 CHAIRMAN BANERJEE: No, I'm talking about
13 when they established their bypass.

14 MR. SMITH: When they established their
15 bypass --

16 CHAIRMAN BANERJEE: It was a once-through?

17 MR. SMITH: No, it was recirculating.

18 CHAIRMAN BANERJEE: Oh, it was
19 recirculating?

20 MR. SMITH: Yes.

21 CHAIRMAN BANERJEE: And then they might
22 have got a very high bypass in the beginning, but it
23 eventually got taken out?

24 MR. SMITH: In general, the bypass is much
25 higher right at the beginning, because there's no

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 fiber on the strainer.

2 CHAIRMAN BANERJEE: This is what is still
3 troubling us. I guess it is troubling me; I don't
4 know if it's troubling the rest of the committee.
5 That if, let's say, you -- what you were calling the
6 cumulative bypass was truly just a once through the
7 screen and that's all that got through, and we were
8 having a constant generation here, then of course
9 that's a conservative number.

10 But if what gets through the sump screen
11 and not the core is recirculated back, then what
12 bypasses an hour later will be much less than what
13 bypasses right at the beginning?

14 MR. GEIGER: But if it's added to the
15 first one, you get the total.

16 CHAIRMAN BANERJEE: I'm just trying to
17 understand what this cumulative means. Is it that
18 you're taking out samples of the liquid being bypassed
19 all the time?

20 MR. SMITH: You're getting an amount of
21 fiber per a volume of liquid, and then --

22 CHAIRMAN BANERJEE: As a function of time?

23 MR. SMITH: As -- yes, because you take
24 samples all the while the test is going on.

25 The other thing that makes the testing,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the bypass testing more probably conservative is that
2 they do not generally put particulate in during the
3 bypass testing. So that allows more fiber to pass
4 through the strainer, because a bed with particulate
5 in it is a much better filter.

6 CHAIRMAN BANERJEE: But that's exactly
7 opposite to what Mo was saying. He was saying he's
8 seen tests with fiber only which passes less fiber
9 than fiber and particulates, and we couldn't
10 understand why that was. And there was a theory being
11 put forward by Mike here, who -- something, some
12 interaction occurring.

13 MR. SMITH: I think that in general that
14 probably wouldn't happen, but I guess it's possible
15 that it happened -- I don't know. I don't know what
16 test Mo was looking at when he saw that.

17 CHAIRMAN BANERJEE: But he said that. You
18 heard him say it.

19 MR. SMITH: In general -- in general -- I
20 must not have been paying good enough attention.

21 MR. GEIGER: Your anecdotal evidence says
22 it goes the other way.

23 MR. SMITH: In general --

24 CHAIRMAN BANERJEE: Which makes no sense.

25 MR. SMITH: -- the bed is a much better

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 filter once it gets some particulate in it.

2 CHAIRMAN BANERJEE: So let me understand
3 how this cumulative bypass is established, once and
4 for all.

5 So as soon as this test stops and all this
6 stuff stops coming through, what you start to do is
7 you start to capture grab samples or isokinetic
8 samples?

9 MR. SMITH: Yes.

10 CHAIRMAN BANERJEE: So you actually get
11 the fiber loading coming through the bed as a function
12 of time, but now that flow is recirculated back to the
13 bed, so the bed starts to build up more and more
14 fiber.

15 In reality, it may not because that -- the
16 core is also a filter. You see what I mean? So all
17 that stuff might not come back to the bed.

18 MR. SMITH: That's true.

19 CHAIRMAN BANERJEE: A portion of it gets
20 caught in the core. So when you say it's a
21 conservative number, is it really conservative or not?

22 MR. SMITH: I think overall it probably
23 is. We discussed on the cold leg break some -- a lot
24 of the debris would come back, and the amount of fiber
25 that is bypassing the strainer is generally quite

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 small. I mean percentagewise of what is upstream of
2 the strainer, it's usually a couple percent --

3 CHAIRMAN BANERJEE: Once-through takes
4 care of that.

5 MR. SMITH: -- goes through.

6 MR. WALLIS: It's not even that much.

7 CHAIRMAN BANERJEE: Right at the
8 beginning. Even right at the beginning.

9 MR. SMITH: Some plants have assumed 5
10 percent. One plant I actually saw testing that said 9
11 percent went through, which I thought was really high.

12 I don't know how that was determined, but it may have
13 been a very conservative test that was done. But most
14 of them are much lower.

15 MR. WALLIS: Nine percent of 35 pickup
16 trucks is something like three and a half pickup
17 trucks.

18 (Laughter.)

19 CHAIRMAN BANERJEE: So, okay, I'm still --
20 because the core is not in series with the screen when
21 you recirculate that, with the cold leg break you're
22 saying maybe three-quarters or two-thirds comes back.

23 So your first approximation, what you're saying is
24 that it's okay.

25 And does the bypass vary strongly with

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 time? Or is it fairly constant?

2 MR. SMITH: It's very strongly time. It's
3 much more at the beginning.

4 CHAIRMAN BANERJEE: So then my question is
5 sort of important.

6 MR. WALLIS: I'm very puzzled by all these
7 qualitative statements we keep hearing. I like this 5
8 percent, 9 percent. I mean it doesn't seem to be
9 consistent with other things we're hearing, and so
10 tell me --

11 CHAIRMAN BANERJEE: You have data; right?

12 MR. WALLIS: -- some facts here that we --

13 CHAIRMAN BANERJEE: Do you have data on
14 how this varies with time? Do you have some sample
15 data?

16 MR. ROLAND: Could we -- could I suggest
17 to help with this discussion that we could provide the
18 committee a description of precisely how we determine
19 this particular factor? Could we do that, rather than
20 -- because I -- it's not clear that we're talking
21 about the same terms. There's a whole set of language
22 that is unique to this specific matter. Could we -- I
23 would ask the staff, if you would indulge us,
24 Chairman, to prepare something for the committee's use
25 precisely to describe exactly what this phenomenon is.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Could we do that? And maybe that might add some
2 clarity to it.

3 CHAIRMAN BANERJEE: Excellent.

4 MR. WALLIS: Well, just some kind of a
5 diagram --

6 MR. ROLAND: Like a diagram, exactly.

7 MR. WALLIS: -- to help pick up --

8 MR. ROLAND: Yes, we need --

9 MR. WALLIS: This tiny little bit that
10 goes to the core --

11 MR. ROLAND: Yes, Dr. Wallis. We need to
12 provide some clarity here.

13 MR. WALLIS: I'm very confused by this
14 slide. What does the last bullet mean? It means that
15 everything that comes to -- that the strainer might as
16 well not be there?

17 MR. SMITH: For particulate and chemical
18 debris, yes.

19 CHAIRMAN BANERJEE: That's quite clear, it
20 said that.

21 MR. SMITH: It's just the fibers.

22 MR. WALLIS: There's no filtering at all
23 of particulates?

24 MR. SMITH: That's the assumption.

25 MR. WALLIS: In reality there is.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. SMITH: Yes, in reality there would be
2 some. There would be some filtering.

3 CHAIRMAN BANERJEE: Well, the real issue
4 is I think if you do what Bill suggested, it will
5 clarify a lot of things. And the things that I would
6 like to see clarified is how you are making these
7 measurements, how they have been made, how they are
8 varying with time, and what you really mean by
9 cumulative, as just integrating these over a period of
10 time.

11 Anyway, once we have that, then we'll have
12 a much better understanding of the situation.

13 MR. SMITH: Okay.

14 MR. WALLIS: It's very strange, really,
15 because in order to get the NPSH calculation
16 conservative, you put all the chemicals in the
17 strainer, and then in order to get this conservative,
18 you put all the chemicals in the core.

19 MR. SMITH: Right.

20 MR. WALLIS: How do they get caught in the
21 strainer? They must --

22 MR. SMITH: There is -- there are a number
23 of conservatisms associated with this whole process,
24 and it's just because of the unknowns. That's why we
25 put the conservatisms in.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN BANERJEE: Well, let's move on to
2 the next slide, please.

3 MR. SMITH: Okay. This one I think we can
4 just go past because we've discussed it all.

5 We had some early testing of the guardian
6 grid that was done by a plant, and actually talking
7 about testing that's been done to date. The staff
8 isn't really taking that testing because there wasn't
9 really good data, so we're not going to consider that
10 testing.

11 We have Diablo Canyon testing that was
12 done, and I have more details coming up on that.

13 The PWR Owners Group did some generic
14 testing using a three-inch cylinder and we're not sure
15 how that really applies, and now they've moved on to a
16 more -- to a more prototypical test loop, and you saw
17 what they talked about earlier, so I don't need to say
18 too much about that, probably.

19 On -- the Diablo Canyon testing was done
20 on an alternate P-grid. It was performed at CDI up in
21 New Jersey. The staff was up there and witnessed a
22 lot of the testing. The debris was prototypical for
23 the plant, and they varied the debris load to see what
24 would give them the highest head losses.

25 In some cases they doubled some of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 debris loads, like they doubled their fiber load on
2 one test, they doubled their CaiSil load on some
3 tests, they put extra chemicals in on some tests.

4 They had a bottom nozzle with the
5 protective grid on top of it and then one intermediate
6 grid strap slightly above that, and they tested, as we
7 have discussed, both hot and cold leg flows, and their
8 head losses came out within the allowable limits.

9 CHAIRMAN BANERJEE: And they had a
10 centrifugal pump?

11 MR. SMITH: They had a centrifugal pump.
12 They had a flow control on it also that maintained
13 flow constant.

14 CHAIRMAN BANERJEE: Did the pump chop up
15 any of this stuff, do you know?

16 MR. SMITH: I guess the pump could have
17 chopped some of it up. The debris went through the
18 pump.

19 CHAIRMAN BANERJEE: Right. Right. But
20 the fiber lengths, did they change or anything like
21 that?

22 MR. SMITH: I don't know if the fiber
23 lengths changed after they went through the pump.
24 They used actual debris that they put through their
25 strainer, they put this upstream of a strainer, put it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 through the strainer, and collected it after it came
2 out, and they actually used that debris, so they used
3 real prototypical bypass fiber for their test rather
4 than putting it in a blender and measuring it to make
5 sure. They actually used a real bypass fiber.

6 CHAIRMAN BANERJEE: Okay.

7 MR. SMITH: This is just a schematic. The
8 debris is all added into the plant here. It gets --
9 like we said, it gets pumped through a flow meter and
10 flow control device. They have a little flow diverter
11 here to make sure nothing settles out in the bottom,
12 and then it goes up through the test article.

13 Anything that bypasses would go back
14 around and go through the pump again.

15 In addition, they have some agitation in
16 this tank here, so that nothing would settle out.

17 MR. WALLIS: It doesn't look like the
18 picture.

19 MR. SMITH: Well, this is just like a
20 cartoon depiction.

21 MR. WALLIS: It just looks as if the two
22 grids are on top of each other in the sketch, and they
23 seem to be separated in the picture.

24 MR. SMITH: Oh, in the picture, you're
25 right, the grids are very close together. You cannot

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 -- in this picture here, you cannot see the bottom
2 nozzle. It's behind that piece of aluminum.

3 MR. WALLIS: It's behind there. Okay.

4 MR. SMITH: It's behind the piece of
5 aluminum.

6 MR. WALLIS: Okay.

7 MR. SMITH: And that's all you see, is the
8 P-grid or protective grid, and then a little piece of
9 like simulated fuel rods and then intermediate strap
10 that you see here. That's why that looks a little bit
11 funny.

12 MR. WALLIS: Okay.

13 MR. SMITH: And then the next picture
14 shows basically a clean pretest, which this was passed
15 around, so I think you guys have seen this up close
16 and personal.

17 And this is just another -- this is a view
18 of it from the top.

19 Yes, keep going.

20 This is -- after testing, this shows how
21 some of the holes in --

22 MR. WALLIS: So what's -- excuse me. What
23 was handed around was the bottom nozzle.

24 MR. SMITH: The bottom nozzle and --

25 MR. WALLIS: But the P-grid was never

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 handed around.

2 MR. SMITH: You're right, the P-grid was
3 not handed around.

4 MR. WALLIS: I don't know what it looks
5 like.

6 MR. SMITH: It looks like about half of
7 the strap that you saw, flat on one side, and it's
8 flipped upside down and put on -- the flat side is put
9 against the --

10 MR. WALLIS: Well, that's the key thing,
11 isn't it? That's the thing that captures the stuff?

12 MR. SMITH: That's what is supposed to
13 catch the stuff.

14 MR. WALLIS: That's the one that wasn't
15 handed out.

16 MR. SMITH: I guess that must be
17 proprietary.

18 But what the testing did show, in response
19 to that comment about what it's supposed to catch the
20 stuff, it is supposed to catch the stuff, but what we
21 saw in the testing that had the multiple grid straps
22 is that the debris actually spreads out throughout the
23 assembly. So the P-grid is not actually that great at
24 catching the type of debris that we're putting in
25 there.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 And this just shows how some of the debris
2 collected in the bottom nozzle, and then the next
3 picture is probably a little bit -- this shows a side
4 view of some of the debris.

5 MR. WALLIS: It doesn't look very uniform.

6 MR. SMITH: No, it's not. I think that it
7 wouldn't -- I think that it would get more uniform if
8 a lot more fiber was put in. I think that would
9 create uniformity of --

10 MR. WALLIS: Well, doesn't this flow
11 diverter set up some vortices in the middle chamber
12 before all this stuff you're showing us here?

13 MR. SMITH: I think -- it probably does.
14 It probably does set up some vortices. I don't know
15 how that would compare to the real plant. I don't
16 know.

17 MR. LANDRY: This is Ralph Landry from the
18 staff.

19 No, the flow diverter is there to prevent
20 vortices and to prevent any kind of channeling of flow
21 and directing the flow. The flow diverter is a cone
22 on top of the pipe that comes up --

23 MR. WALLIS: The flow goes up along the
24 bottom and around like this?

25 MR. LANDRY: The flow comes up, hits the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 flow diverter, and goes around and then comes up, so
2 that you develop a uniform field of flow coming up
3 into the test article rather than jetting straight up
4 at the test article.

5 MR. WALLIS: How does it make the uniform
6 flow if it's directing it along the bottom of the --

7 MR. SMITH: We observed -- I'll tell you,
8 at the 5 gpm flow rate -- at the 40 gpm flow rate, I
9 imagine you probably are going to get some turbulence
10 up there, but at the 5 gpm flow rate, we were up and
11 observed, and it appears that the debris comes in and
12 flows up quite -- you know -- evenly and there's not a
13 lot of flowing around. At the 40 gpm flow rate, I
14 imagine there probably is some --

15 MR. WALLIS: So the fact that some of the
16 holes get blocked and others do not is a kind of
17 statistical thing? They stop, it keeps growing, and
18 then they just get blocked and some of them don't?

19 MR. SMITH: Well, I think what actually
20 happens is this: Some of the -- they may all get
21 blocked, but the debris gets pushed through some of
22 them and up further into the assembly.

23 And then the next picture, I think, will
24 show you -- this shows how the debris is actually
25 collected. That is the bottom of the P-grid. This is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the bottom of the P-grid, so debris that came through
2 these nozzles collected on the bottom of this P-grid,
3 and it's pretty -- it's just kind of like funky, I
4 guess; I don't know.

5 MR. WALLIS: The white stuff that we see
6 on the bottom there is what fell off the P-grid onto
7 the -- whatever the other thing is, the cold leg or
8 something?

9 MR. SMITH: Yes. It was like sandwiched
10 in between there so when you pull the two apart --

11 MR. WALLIS: So when you open it up, it's
12 misleading because some of it's on one and some of
13 it's on the other.

14 MR. SMITH: Those pieces are like
15 sandwiched together, so you --

16 MR. WALLIS: It looks as if it was pretty
17 well uniformly covered, and then some of it stuck to
18 the other surface when you opened it up.

19 MR. SMITH: That's right.

20 CHAIRMAN BANERJEE: In proportion to what
21 the Owners Group showed us, was this more fiber or
22 less fiber than they had?

23 MR. SMITH: This is less fiber. Their
24 design basis loading per fuel assembly was about 13
25 grams, whereas the Owners Group was testing with 53 in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the test that we saw. So this is a low fiber plant.

2 The one difference is that I think that we
3 collected probably more debris in a smaller area on
4 this test, whereas the 53 grams was spread out between
5 several grid straps.

6 MR. WALLIS: It looks as if the P-grid
7 grabbed enough fibers to start packing them up into
8 the bottom nozzle.

9 MR. SMITH: Yes.

10 Diablo also did a test which I didn't put
11 on there, but they did a test where they actually
12 duct-taped off the bottom nozzle so that it was
13 totally blocked, so that you only had flow bypassing
14 around, coming through the larger holes, these larger
15 holes, it would come up and out these larger holes and
16 bypass, and they -- at the 5 gpm flow rate, it was a
17 relative -- there was enough bypass that they had a
18 relative head loss, but they couldn't get up to the
19 full 40 gpm flow rate with the test rig there because
20 I think they had like a 5 psi limit and they didn't
21 want to exceed that and break the rig. I'm not sure
22 what the limit was, but there was a limit that they
23 couldn't exceed so they stopped just below it.

24 MR. WALLIS: Well, at 5 psi, it assures
25 that it will always be less 13.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. LANDRY: The limit was 120 inches of
2 water.

3 MR. SMITH: One hundred twenty inches of
4 water. Okay.

5 MR. LANDRY: They hit 119 at 36 gpm.

6 MR. WALLIS: What's 110 inches in psi?

7 MEMBER ABDUL-KHALIK: About four.

8 MR. LANDRY: That's just under a third of
9 an atmosphere.

10 (Laughter.)

11 MR. LANDRY: Thirty-four feet of water per
12 atmosphere, that's 10 feet of water, so it's just
13 under a third of an atmosphere.

14 MR. WALLIS: It's tiny compared with what
15 you're interested in.

16 CHAIRMAN BANERJEE: No, it's sort of -- an
17 atmosphere is 5 psi.

18 MR. WALLIS: This magical 13.9 psi.

19 CHAIRMAN BANERJEE: They're not interested
20 in the 13.9. That's still under --

21 MR. WALLIS: They're showing it's less
22 than that.

23 CHAIRMAN BANERJEE: Let's go on.

24 MR. SMITH: The next slide shows debris
25 types, and with the limited amount of fiber that we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 see here, it appeared that the things that would
2 really drive head loss, if the CaiSil was increased or
3 if these chemical precipitants were increased, those
4 would tend to drive the head loss up. So it wasn't
5 really such a -- dirt and silicon carbide did not
6 drive the head loss as much as the CaiSil and
7 chemicals seemed to drive it a lot more, which is
8 pretty typical of what we've seen with other like
9 vertical loop testing. They seem to be a lot -- drive
10 head loss more than just other particulates.

11 Okay. And then the PWR Owners Group
12 testing, I don't know that we really need to talk over
13 this a whole lot because I think they already
14 presented it, you know, a lot more than this to you.

15 MR. WALLIS: This picture that shows the
16 bottom nozzle and P-grid, slide 15.

17 MR. SMITH: Uh-huh.

18 MR. WALLIS: That is only the P-grid that
19 is shown there? It looks awfully thick.

20 MR. SMITH: Well, the P-grid is what is
21 facing you. The simulated fuel is still there and
22 it's still holding --

23 MR. WALLIS: So it's not just the P-grid,
24 it's the P-grid plus the fuel plus the spacers?

25 MR. SMITH: Plus the spacers, that's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 right.

2 MR. WALLIS: Aah, that's -- okay.

3 MR. SMITH: I'm sorry. The title was a
4 little misleading.

5 MR. WALLIS: It looks as if there's a lot
6 of debris on the fuel between the P-grid and the
7 spacer, filling up the whole thing on the top.

8 MR. SMITH: Yes, that may have occurred
9 because of the --

10 MR. WALLIS: It's an edge effect, is it,
11 or what is it?

12 MR. SMITH: I don't know. I'd be
13 guessing.

14 CHAIRMAN BANERJEE: Well, in general, the
15 distribution looks like it's more around the edges.
16 If you looked at two or three slides back --

17 MR. LANDRY: When we were there, when they
18 took those -- this whole rig apart, the distribution
19 of material in the bottom of the P-grid was very
20 uniform all the way across the P-grid. And when they
21 took the top grid, the intermediate spacer grid off,
22 there was a film on the bottom of that grid also, but
23 it was significantly thinner than the film material on
24 the P-grid. But it too was a uniform grid covering.
25 So the material, as Steve has said, was filtering out

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 as you went up grid to grid, but of course there are
2 only two grids there.

3 MR. WALLIS: Well, what we see here is a
4 big white sort of sandwich there between the two. Is
5 that an illusion of some sort? Between the P-grid and
6 the spacers --

7 MR. LANDRY: No, those are rods.

8 MR. SMITH: Those are fuel, those are
9 simulated fuel rods.

10 CHAIRMAN BANERJEE: They are white, you
11 see.

12 MR. WALLIS: But it fills the whole space.

13 MEMBER ABDUL-KHALIK: There is junk
14 between them.

15 MR. SMITH: Well, there's some. There's
16 some open area between and there's some --

17 MR. WALLIS: No, no, if you go up top, you
18 look at the sandwich.

19 MR. SMITH: This?

20 MR. WALLIS: That strip there. It's pure
21 white.

22 MR. SMITH: I'll show you a picture of the
23 clean one and you can see what --

24 MR. HARRISON: You can see it here from
25 the side.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. LANDRY: The amount that was captured
2 between the rods themselves was very, very little.

3 MR. WALLIS: That's an illusion then.

4 MR. LANDRY: Right. This is just from
5 looking at a messy piece of equipment that's been
6 disassembled. As it was taken apart, we were there to
7 watch, and we saw that there was very little material
8 captured rod to rod. Virtually everything was
9 captured by the grid itself. And when those Delron
10 rods were pulled out, material did not come out with
11 them. It stayed in the grid.

12 MR. WALLIS: It looks like enough to make
13 a thin bed.

14 MR. LANDRY: We measured -- we took a
15 piece off and measured it. It was about an eighth of
16 an inch on the P-grid.

17 MR. WALLIS: So are we getting back to
18 what the chairman asked for last time, which was
19 studies of a uniformly blocked core?

20 CHAIRMAN BANERJEE: A thin bed.

21 MR. WALLIS: We seem to be getting back to
22 that, don't we?

23 CHAIRMAN BANERJEE: Well, 1/8th inch
24 obviously is not enough to cause you real problems,
25 but --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. SMITH: I think that that question
2 about a uniformly blocked core is a perfect lead-in to
3 Bill's discussion of the models that Research did.

4 MR. WALLIS: We've come a long way from
5 saying there was no effect to saying this, it seems to
6 me. What it means, we have to figure out.

7 CHAIRMAN BANERJEE: Well, the amount of
8 fiber that you used here was -- give me a rough idea.
9 Was it about a quarter of what the Owners Group was
10 testing, or --

11 MR. SMITH: Thirteen grams versus 53, so
12 approximately a quarter.

13 CHAIRMAN BANERJEE: Okay. And typically
14 even though you saw it fairly uniformly distributed,
15 it was less than an eighth of an inch thick?

16 MR. SMITH: On the P-grid, yes.

17 CHAIRMAN BANERJEE: And, I don't know,
18 maybe we should ask the Owners Group. Did they do an
19 analysis sort of when they disassembled the stuff?
20 Did you guys see it sort of fairly uniformly
21 distributed like this, a certain thickness of fiber or
22 what did it look like?

23 MR. ANDREYCHEK: When we disassembled the
24 rods, we didn't do a, quote, analysis. It was
25 observed to be relatively uniformly distributed by

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 pressure drop across the grid spaces. And that's
2 using the pressure drop measurement to indicate
3 collection of debris, and it was a relatively uniform
4 pressure drop across the -- give or take a tenth or
5 two of a psi -- across the -- each of the grid straps
6 in the test bundle.

7 CHAIRMAN BANERJEE: How did you know it
8 was relatively uniform? I mean --

9 MR. ANDREYCHEK: We actually had pressure
10 drop measurements. That's --

11 CHAIRMAN BANERJEE: I know you had that,
12 but --

13 MR. ANDREYCHEK: I'm saying by pressure
14 drop --

15 CHAIRMAN BANERJEE: I'm saying the
16 observation at that -- well, as Professor Wallis was
17 saying, if you had some channels which were not very
18 blocked, most of the flow would go through them, and
19 by the pressure drop measurement, you wouldn't know
20 it's uniformly distributed or nonuniformly
21 distributed.

22 MR. ANDREYCHEK: That's true.

23 CHAIRMAN BANERJEE: So the issue here is
24 when you observed it postexperiment, it looks
25 relatively uniformly distributed. Did you do some

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 observations postexperiment?

2 MR. ANDREYCHEK: Yes, and there was debris
3 at each elevation. We didn't focus to see whether or
4 not it was uniformly distributed, but there is debris
5 at each of the elevations, and it was spaced
6 throughout the bundle.

7 CHAIRMAN BANERJEE: Are you able to
8 observe whether, when you disassembled the bundle,
9 whether it's uniformly distributed, or does it totally
10 disturb the distribution when you disassemble it?

11 MR. DINGLER: When we pulled it out, it
12 wasn't as, let's say -- I hate the word, use quotes,
13 compacted like Diablo, so it came loose a little
14 easier than that when we pulled them out. So it was a
15 little tougher for us to see it because it wasn't --
16 as you see it here, when we pulled it apart, some was
17 stuck on the top, and some -- my understanding is we
18 didn't see that.

19 CHAIRMAN BANERJEE: You didn't. Okay.

20 MR. WALLIS: Well, since this looks like a
21 pretty uniform distribution, I would expect you would
22 get good comparison between the pressure drop in terms
23 of the flow rate and the same constituents and so on.
24 Were the tests done at ANL and PNNL in the vertical
25 loop, which is very similar? There really ought to be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 a comparison made for the same constituents
2 and the same method of introduction, same area. Was
3 the pressure drop the same or close? Was it orders of
4 magnitude different or what? I've read about this
5 from the vertical loop test. It looks very, very
6 similar.

7 MR. SMITH: The vertical -- it would be
8 difficult to get the proportion of debris on this
9 strainer, on the vertical loop strainer, the same as
10 --

11 MR. WALLIS: Why?

12 MR. SMITH: Because we don't know exactly
13 how thick or where this debris bed exactly was, and
14 there's bypass flow around this, around parts of this.
15 It's a lot more complicated than a simple vertical
16 loop would -- you know, that's completely blocked off.

17 MR. WALLIS: And so bypass flow --

18 CHAIRMAN BANERJEE: I think Bill is going
19 to answer the modeling questions. So why don't we --

20 MR. SMITH: Bill will answer the modeling.
21 I think Paul maybe wants to jump in.

22 MR. WALLIS: You want to make the
23 comparison because there's always then going to be the
24 suspicion that there weren't enough tests here to pick
25 up some of the phenomena which you observed in the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 vertical loop test.

2 MR. SMITH: I think it would be really
3 difficult to compare the two, but we can look at it.

4 MR. WALLIS: I think you should.

5 MR. KLEIN: With respect to the Diablo-
6 specific test, I think they did on the order of 18
7 tests or so, so there is quite a bit of data there in
8 their plant-specific debris, but the difficulty with
9 benchmarking that to the earlier ANL stuff is that you
10 had calcium silicate and other insulation materials
11 that weren't in the ANL test loop, so it makes
12 comparison between the two more difficult.

13 MR. WALLIS: So what use then -- aren't
14 these old tests supposed to shed light on what
15 happens? Now they're no good because they somehow
16 contain different materials or something?

17 MR. KLEIN: I think that --

18 MR. WALLIS: I thought that we learned a
19 lot from the ANL tests.

20 MR. KLEIN: We did learn a lot.

21 MR. WALLIS: Now you're saying that
22 because they can't be compared with these, we should
23 ignore them?

24 MR. KLEIN: No, I'm not suggesting that.
25 I think the ANL tests informed us -- they provided a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 lot of information with respect to chemical effects.

2 I think we have to be somewhat careful in
3 comparing ANL tests with fiber and WCAP surrogate with
4 a test that has fiber and calcium silicate and latent
5 debris and WCAP surrogate.

6 MR. WALLIS: ANL got these interesting
7 tests where you go along with the pressure drop and
8 the flow; right? Then they do something, and whoop,
9 the pressure drop is 20 times as big. That never
10 happens here; right?

11 MR. KLEIN: I think what -- I think what
12 you're starting to see in some of the evidence, it's
13 accumulating in the assembling tests, is that fiber
14 seems to be the controlling factor, it seemed like
15 with -- say you look at the first three Owners Group
16 tests as a whole, and it seems like there's plenty of
17 particulate and chemical particulate in those tests.
18 If you didn't see a sensitivity in a greater amount of
19 particulate with test two compared to test one, I
20 think as you added more fiber and created a bed
21 somewhere that was a better filtering bed, you're
22 starting to see some increase in head loss now with
23 chemical precipitate where you didn't see that in test
24 one.

25 MR. WALLIS: So you ought to be able to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 get something like the ANL tests and then show that
2 it's so atypical.

3 MEMBER SHACK: Well, I think the thing
4 that you're thinking of in the ANL test is where we
5 did tests where the initiation of the precipitation
6 occurred during the test as we were changing
7 concentrations.

8 Here they are adding the precipitate
9 externally. This is like our Westinghouse surrogate
10 test where we get exactly the same thing they get, you
11 know, we add a little bit of surrogate, and --

12 MR. WALLIS: So the surrogate doesn't
13 duplicate what happens when you got --

14 MEMBER SHACK: Well, it -- what Paul tried
15 to say was that, you know, when we look at equivalent
16 amount of aluminum removed, the surrogate is more
17 conservative than any other way we've found to induce
18 the precipitate. Whether we induced the precipitate
19 by adding chemical amounts of aluminum, whether we add
20 the aluminum by corroding aluminum plates in place --

21 MR. WALLIS: That's amounts of aluminum,
22 but how about -- it can be conservative for delta P.

23 MEMBER SHACK: When I say it's
24 conservative, the delta P that you get for the
25 equivalent amount of aluminum for one ppm of aluminum

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 is higher from the WCAP surrogate than anything else
2 we have ever tested.

3 MR. WALLIS: Well, they should be able to
4 duplicate your tests, so you go along and add a little
5 bit more aluminum and --

6 MR. KLEIN: Well, you have a more complex
7 geometry here in that you have perhaps multiple beds
8 at different elevations that are accumulating fiber,
9 so it is somewhat different than flat plate and the
10 vertical loop.

11 MR. WALLIS: The dominant bed is this one
12 we see here, is the dominant bed, which is the one on
13 the -- at the P-grid.

14 MR. LEHNING: This is John.

15 I just wanted to add to some of the other
16 points already made. And one of the things is that it
17 wasn't throwing out that ANL data. I think like was
18 said, that was used to say this WCAP precipitate is
19 conservative by using those tests and running those
20 values, and that's what's being used in these tests.

21 I think in addition to some of the
22 different types of debris being used, the debris is
23 different sizes. This is the bypassed size of fiber
24 versus the amount that would collect on the strainer.

25 The geometry used to collect the fiber, and the flow

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 patterns would be different as well, too.

2 So given all those differences, you
3 wouldn't be able to quantitatively say that the same
4 amount of debris on this type of set-up here in this
5 fuel assembly would be the same as you would get in
6 this vertical loop.

7 I mean you could use insights, and that's
8 the way we're using that ANL. We're not ignoring that
9 data.

10 MR. WALLIS: The vertical loop did show
11 that there was a critical condition where you suddenly
12 got a very high pressure drop, and although this was
13 not thoroughly explained, it happened. There was some
14 sort of combination of circumstances where it
15 happened.

16 I would expect, therefore, it would happen
17 here with the right combination of circumstances.

18 MR. LEHNING: What was being tested in
19 those ANL loops, I think was said already, at the
20 onset of precipitation and things like that. So you
21 decrease the temperature or -- I'm not exactly sure
22 which test we're talking about -- and then it spiked.

23 And here -- and that test was used to
24 basically say that WCAP precipitate had -- would have
25 the similar type of impact as was seen in those tests,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 and that's what we're using here.

2 I mean if you had everything the same, you
3 could go back and say if we set up like an ANL loop
4 and then added in WCAP precipitate for a similar
5 quantity in that set-up that you should get to the
6 same end point, but you may not get this big jump.
7 But this is a different set-up with a different type
8 of debris, different sizes of debris, different
9 strainer to collect it on, and so one wouldn't
10 necessarily be able to get to that same end point.

11 MR. WALLIS: Of course, when they do the
12 full test matrix, they may get something like what ANL
13 got with the spike.

14 MR. KLEIN: They may as they get to higher
15 fiber loads.

16 MR. GEIGER: If I may add my two cents,
17 since I observed this. Erv Geiger.

18 What I observed and nobody has mentioned
19 yet is that in observing these tests, there were eddy
20 currents and counterflows and everything going every
21 which way, which when the flow came up through that
22 bottom nozzle assembly and it hit that P-grid, it
23 could go underneath sideways and break up the debris.

24 So there were many flow paths, and I think there was
25 enough turbulence to -- as soon as the pressure drop

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 got too high just to break up some of that, to break
2 through.

3 CHAIRMAN BANERJEE: Did you see that at
4 the lower flow rates as well, the 5 gpm, or even at
5 the --

6 MR. GEIGER: Even at the 5 gpm, yes. And
7 as it loaded up, you could see on the sides of the
8 wall, and actually in the corners, you'd have flow
9 coming up and going down and going through and going
10 every which way. So it was -- it was a fascinating
11 experiment to watch and, you know, I was trying to
12 figure out a way to explain exactly what was going on.

13 But you could see the surrogate, the chemical
14 surrogate material as it like migrated in different
15 areas, and you could actually see where the current
16 was all -- going every which way. So it wasn't like,
17 you know, in the ANL test you have a nice uniform flow
18 coming up or going down through that matrix, right? I
19 mean it was fairly uniform. For this thing, it was
20 just churning every which way.

21 MEMBER SHACK: As uniform as we could make
22 it, yes.

23 CHAIRMAN BANERJEE: Well, the particles
24 mixed the flow, so it would probably make for a
25 uniform debris loading, which is what you observed.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. GEIGER: And the bypass around the
2 sides made a big difference, because you could get
3 bypass through slides and it would go back in through
4 the matrix, and attempt to break all of that up. That
5 was my observation.

6 CHAIRMAN BANERJEE: Can we let Bill --

7 MR. SMITH: Yes, we've been promising you
8 Bill. He's ready.

9 MR. KROTIUK: Actually I did this
10 assessment to look at the uniform distribution at the
11 inlet of the core, and I used a TRACE calculation, but
12 I also did an independent hand calculation on an Excel
13 spreadsheet.

14 CHAIRMAN BANERJEE: Excellent. Exactly
15 what we wanted.

16 MR. KROTIUK: Right. But I thought, you
17 know, it would be interesting to compare the two. So
18 this slide I'm just describing the models. It has a
19 fairly detailed core model for TRACE, and in both
20 calculations I assumed that the recirc started at 120
21 seconds, so that's really when you got instant -- I
22 assumed there was an instantaneous debris bed formed
23 at that point in time.

24 Okay. The hand calculation was basically
25 just an approach where I was trying to balance,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 similar to what Dr. Wallis was saying. It's based on
2 trying to balance the pressure drops and energy going
3 into the core, such that you could calculate the rate
4 on a flow rate and get an appropriate flow rate.

5 Two-phase pressure drops were included in
6 there. I had a simple homogenous Martinelli-Nelson
7 type correlation.

8 CHAIRMAN BANERJEE: Did you take
9 subcooling into account?

10 MR. KROTIUK: Yes, subcooling was taken
11 into account, so there was a part of the bottom of the
12 core that was actually subcooled, and we actually
13 calculated where that location was.

14 CHAIRMAN BANERJEE: Well, since you kept
15 quiet during the discussion with the Owners Group,
16 what was your average void fraction?

17 MR. KROTIUK: It was a function of flow
18 rates.

19 CHAIRMAN BANERJEE: What was the maximum?

20 MR. KROTIUK: Let me just take a look.
21 Okay, it was a function of flow rate and a function of
22 the bed thickness that was assumed, and it --

23 CHAIRMAN BANERJEE: That's your personal
24 spreadsheet; right? It's not --

25 MR. KROTIUK: Yes, it's not here. This

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 report is available. I just --

2 CHAIRMAN BANERJEE: Anyway, tell us the
3 numbers.

4 MR. WALLIS: Did you have chemical
5 effects, Bill?

6 MR. KROTIUK: No. Okay, let me just --
7 before I do that, let me just say what my assumptions
8 were, okay, just so that, you know --

9 What I did is that I did the calculation
10 for an unblocked core and then 1.2 inch, 2.4, and 4
11 inches of Nukon/CaiSil. The pressure drop that I
12 assumed -- that I should say calculated for the debris
13 bed was based on the PNL testing.

14 CHAIRMAN BANERJEE: This was not 6224 or
15 anything?

16 MR. KROTIUK: No, it was not 62-- well,
17 no, it was not 6224. Based on the PNL test data and
18 then using the model that I had developed for NUREGS
19 1862, where I assumed the saturated, as you were
20 saying, the saturated portion of the debris bed, I
21 then used that calculation to extrapolate up to the
22 larger thicknesses and also to extrapolate up to a
23 higher operating temperature, because the tests at
24 PNNL were run at a lower temperature.

25 CHAIRMAN BANERJEE: Without chemical

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 effects?

2 MR. KROTIUK: Without chemical effects,
3 right.

4 So in order -- I put the -- what I ended
5 up doing, since when you're doing these calculations
6 for a pressure drop across the debris bed, you'll
7 essentially have a pressure drop that's somewhat
8 linearly dependent upon velocity as opposed to a V-
9 squared.

10 And so --

11 CHAIRMAN BANERJEE: Because it's in that
12 region?

13 MR. KROTIUK: It's in that region, right.

14 Yes.

15 CHAIRMAN BANERJEE: It's not --

16 MR. WALLIS: The PNNL data, was this the -
17 - did you then -- and you said you had nonuniform bed?

18 MR. KROTIUK: Nonuniform bed.

19 MR. WALLIS: And you had the worst case?

20 MR. KROTIUK: I don't know if I had the
21 worst case or not. I can't answer that. I'd have to
22 go look at the data again, but I chose what I thought
23 was a good case to look at.

24 MR. WALLIS: So you have a sort of a
25 saturated bed?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. KROTIUK: I have a saturated bed.

2 MR. WALLIS: So you had a thin bed effect,
3 so --

4 MR. KROTIUK: Right. What is called a
5 thin bed, which I have called in previous -- and you
6 picked up on it, I call it a saturated bed.

7 MR. WALLIS: And the proportions of
8 Nukon/CaiSil were based on what?

9 MR. KROTIUK: The proportions of
10 Nukon/CaiSil were based on the test that was done at
11 PNNL, and then I extrapolated up to give the
12 appropriate thickness.

13 MR. WALLIS: How does that compare with
14 the Owners Group proportion? Or they didn't use
15 CaiSil, did they?

16 MR. SMITH: They haven't used CaiSil yet.
17 That's in the plants.

18 MR. KROTIUK: I can't compare that. I
19 don't know the comparison.

20 CHAIRMAN BANERJEE: Go on. I think it's
21 interesting.

22 MR. KROTIUK: Okay.

23 CHAIRMAN BANERJEE: So we know what you
24 did.

25 MR. KROTIUK: And then for the hand

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 calculation, what I did is that I just did steady
2 state calculations at 1200 seconds, which is timer
3 recirc, and then at 2000 seconds. The tracer on it
4 went out longer than that.

5 Now I've sort of lost my track. You have
6 to ask me something.

7 MR. SMITH: Was that the void fraction?

8 MR. KROTIUK: The void fraction, right,
9 yes.

10 CHAIRMAN BANERJEE: You can go on and tell
11 me as you go on.

12 MR. KROTIUK: The void fraction -- ah,
13 geez, I didn't print it out here. I have the exit
14 void fraction.

15 CHAIRMAN BANERJEE: Tell me the exit void
16 fraction.

17 MR. KROTIUK: The exit void fraction for
18 these cases varied pretty high. It was almost 100
19 percent.

20 CHAIRMAN BANERJEE: So it was just
21 basically all steam?

22 MR. KROTIUK: Basically, yes. But --

23 CHAIRMAN BANERJEE: But essentially
24 boiloff?

25 MR. KROTIUK: Yes, but I didn't uncover

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the core. I'll go over that. There was one case
2 where --

3 CHAIRMAN BANERJEE: That is reassuring.

4 MR. KROTIUK: Yes.

5 (Laughter.)

6 MR. WALLIS: This value is uncompressed,
7 is it, or --

8 MR. KROTIUK: That's sort of a nominal bed
9 thickness, right.

10 MR. WALLIS: With the pressure drop, it
11 gets thinner?

12 MR. KROTIUK: Right. It gets thinner. I
13 looked at it -- you know, this came up with a nominal
14 number to use. But it does vary as a function of
15 various things, velocity and whatever.

16 Let's look at the -- first the results
17 here. There's a TRACE calculation. And -- oh, one
18 other thing I wanted to say, in order to be able to
19 incorporate this correlation to -- for the pressure
20 drop across the debris bed, since it's really directly
21 proportional to velocity, I did include into TRACE a
22 modification to include a loss coefficient for the
23 debris bed that was a function of the bed thickness,
24 and was --

25 CHAIRMAN BANERJEE: Based on the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 correlation?

2 MR. KROTIUK: Based on the correlation,
3 right. So it was bed thickness and approach
4 velocities.

5 So then in essence what happens is the
6 pressure drop was dependent upon velocity. It comes
7 out to be 1.1 power. Close to 1.

8 CHAIRMAN BANERJEE: I think you're filling
9 the peak clad temperatures, but clearly you have
10 things like the collapsed liquid level.

11 MR. KROTIUK: Yes, I have collapse liquid
12 level. I just didn't include all that information. I
13 have written a report, and that report is available.
14 I can give you the numbers so that you can take a look
15 at it.

16 CHAIRMAN BANERJEE: And the report has all
17 this stuff in it?

18 MR. KROTIUK: The report has all that
19 stuff in it, yes. Okay.

20 MR. WALLIS: How do your fiber quantities
21 compare with the 53 grams per assembly in the --

22 MR. KROTIUK: Yes, I was -- you know, when
23 you went to lunch, I actually was doing that
24 calculation to try to see, and I couldn't come up with
25 a good comparison right now because everything I did

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 was in kilograms per square meter.

2 MR. WALLIS: But you know the material --

3 MR. KROTIUK: Yes, I know the total amount
4 of material and in fact entered it --

5 MR. WALLIS: But you calculated it?

6 MR. KROTIUK: Yes, I just haven't taken it
7 that far.

8 CHAIRMAN BANERJEE: Didn't you know that
9 we'd be asking you questions like that?

10 MR. KROTIUK: Yes. In fact, I have a
11 back-up slide with it. But I -- it's in the report
12 and I could actually --

13 CHAIRMAN BANERJEE: Is it exactly what we
14 wanted?

15 MR. KROTIUK: Yes. I just haven't taken
16 the step --

17 CHAIRMAN BANERJEE: All right.

18 MR. KROTIUK: -- to come up, because I
19 didn't really know --

20 MEMBER SHACK: Well, it may be hard to do
21 the one-to-one comparison because yours are based on a
22 much longer and unchopped fiber length, where their
23 fiber length distribution --

24 MR. KROTIUK: Was finer.

25 MEMBER SHACK: -- was finer, and so your

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 --

2 MR. KROTIUK: That's that.

3 MEMBER SHACK: -- model really is a little
4 different than their model.

5 MR. KROTIUK: So I used the data that I
6 had, and that was available data.

7 Okay. Back to TRACE results.

8 This table here with the TRACE calculation
9 shows the peak clad temperature that was calculated,
10 and actually for the TRACE -- it's a transient
11 calculation.

12 For the unblocked, for this case, the --
13 you could see that we were down and look at degrees
14 Fahrenheit, you know, 280 degrees Fahrenheit. And
15 somewhere between 2.4 and 4.8 inches thickness of the
16 bed, the temperature started to increase and there was
17 a peak clad temperature -- I have 4.8 inches that was
18 almost 200 -- I'm sorry, 960 degrees Fahrenheit.

19 CHAIRMAN BANERJEE: Well, these peak clad
20 temperatures and things depend a lot on the heat
21 transfer models and stuff like that.

22 MR. KROTIUK: Right.

23 CHAIRMAN BANERJEE: That's the collapsed
24 liquid levels, which are more.

25 MR. KROTIUK: Yes. And again, to report,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 I do have the collapsed liquid levels. And then again
2 as a comparison I compared these results to the hand
3 calculation. Obviously in a hand calculation I did
4 not calculate a peak clad temperature because it was
5 just heat addition and boiloff.

6 But what I was able to do was to compare
7 the -- I would just say the collapsed level of the
8 liquid in the core, and then we related that back to
9 some of the experiments that we've run, the RBHT and
10 the data experiments, and come up with an assessment
11 of when you would get a -- you know, an uncovering of
12 the top of the core based on the void fraction
13 measurement, void fraction calculation, and the data -
14 - the test results, and just doing a correlation.

15 CHAIRMAN BANERJEE: When you set this up,
16 you didn't tell us, was this for a hot leg break or a
17 cold leg break?

18 MR. KROTIUK: I'm sorry. Yes, it was for
19 a cold leg break.

20 CHAIRMAN BANERJEE: Okay.

21 MR. KROTIUK: Sorry.

22 CHAIRMAN BANERJEE: So you took into
23 account the bypass flow out of the cold leg?

24 MR. KROTIUK: That's correct. Yes. Yes,
25 it took into account the bypass flow out of the cold

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 leg, yes.

2 CHAIRMAN BANERJEE: And -- yes, I think
3 this is the more restrictive case. Okay. Go ahead.

4 MR. KROTIUK: But the interesting thing is
5 that the hand calculation in terms of the collapse
6 level and the point at which you start getting the
7 core uncovering -- because for that last case, the TRACE
8 was showing you were starting to get the core uncovering
9 for that 4.8 inch thick bed, and there was an
10 agreement, basically agreement within I'd say 10 to 20
11 percent between the hand calculation and the --

12 CHAIRMAN BANERJEE: I would think your
13 hand calculation of this is good because the whole
14 thing is dominated by the pressure drop.

15 MR. KROTIUK: That's right. It's balance
16 of the pressure drop and balance of heat.

17 CHAIRMAN BANERJEE: So this was the
18 question we asked you the last meeting, or asked
19 somebody.

20 MR. KROTIUK: Asked somebody, right.

21 MEMBER ABDUL-KHALIK: How does the core
22 flow rate change as you move along in this thickness?

23 MR. KROTIUK: In what way? I mean it was
24 a fraction of what? I don't quite understand.

25 MEMBER ABDUL-KHALIK: As the thickness of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 this layer changes.

2 MR. KROTIUK: Oh, okay. Got you.

3 MEMBER ABDUL-KHALIK: How did the core
4 flow rate change?

5 MR. KROTIUK: Okay. For instance, I'll
6 talk about the calculations at 1200 seconds, which is
7 just set recirc. For the unblocked core, it was like
8 about 115 kilograms per second. For the 1.2 inch, it
9 was like 78; 2.4 was 61; and 4.8 was 45.

10 CHAIRMAN BANERJEE: It's fairly linear
11 because you're in the part of that sort of equation
12 which is in the laminar region, so this is delta P --

13 MR. KROTIUK: That's right. That's
14 correct.

15 MR. WALLIS: So there's no sudden effect;
16 it's just a steady increase?

17 MR. KROTIUK: No. It's a steady increase,
18 yes. To the flow rate.

19 CHAIRMAN BANERJEE: That's because it's
20 such a low flow rate.

21 MR. KROTIUK: Yes. The flow rate is
22 completely dominated by gravitational effects, you
23 know, and the balance with the pressure drop.

24 CHAIRMAN BANERJEE: And you took into
25 account the voiding in the core, of course,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 automatically?

2 MR. KROTIUK: Yes, we took into account
3 the voiding in the core, so the bottom of the core had
4 all subcooled liquid, and then there was a two-phase
5 region calculated at a place where you had to
6 transition from a subcooled liquid to starting the
7 voiding. I made some approximation, obviously, since
8 this is a hand calculation regarding the distribution
9 of the void in the --

10 MR. WALLIS: You just used the homogenous
11 model?

12 MR. KROTIUK: Homogenous model, right.
13 Homogenous model, right.

14 MR. WALLIS: So you have a theory which
15 lets you predict this?

16 MR. KROTIUK: That's correct.

17 MR. WALLIS: I haven't seen anything like
18 that from anybody else today. All this data is coming
19 and we're going to do something with it. We think
20 we're going to be conservative. We're going to have
21 enough to demonstrate we're conservative.

22 MR. KROTIUK: I guess the question is --

23 MR. WALLIS: But you have a theory that
24 says this is the way that the core blockage evolves
25 with time, and this is the maximum temperature we get,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 and so on.

2 CHAIRMAN BANERJEE: Well, the theory
3 assumes a bed. I mean the whole difficulty is
4 predicting what happens to the bed.

5 MR. WALLIS: The strategy of the utility
6 seems to be to take some limiting case and show that
7 that's -- they'll never get there. It's not to
8 actually make a prediction of the way in which the
9 temperature varies throughout the transient. Is that
10 right? He's predicting the way the temperature varies
11 throughout the transient. I don't think that what
12 I've seen today is leading to something you can put
13 into a code to predict the way things vary throughout
14 a transient. Is that right?

15 MEMBER ABDUL-KHALIK: He assumes that the
16 bed forms instantaneously.

17 CHAIRMAN BANERJEE: The difficulty is with
18 the bed.

19 MR. WALLIS: He talks about the worst
20 case.

21 CHAIRMAN BANERJEE: I don't know if it's
22 the worst case. But it's a case, you know, and he's
23 done more or less what we asked for at the last
24 meeting.

25 MR. WALLIS: He's closest to a realistic

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 evaluation.

2 CHAIRMAN BANERJEE: I don't know about
3 that.

4 (Laughter.)

5 CHAIRMAN BANERJEE: So what you're really
6 saying, what is the pressure loss across the bed at
7 your 4.8 inches?

8 MR. KROTIUK: The pressure loss across the
9 bed is around 4 psi.

10 CHAIRMAN BANERJEE: And the pressure loss
11 is roughly linear at this velocity?

12 MR. KROTIUK: Yes, looking at it, it's
13 pretty linear, right.

14 CHAIRMAN BANERJEE: To be expected. Yes.

15 MR. KROTIUK: It's pretty linear, yes.

16 CHAIRMAN BANERJEE: Okay. I think he has
17 answered the question.

18 MEMBER ABDUL-KHALIK: So how does that
19 square with what they said earlier, that the maximum
20 available delta P is -- for a cold leg break is only
21 2-1/2 psi?

22 MR. KROTIUK: When I did this calculation
23 with the unblocked case, my available pressure drop at
24 that higher flow rate was 7.8 psi.

25 MR. WALLIS: He's got a higher void

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 fraction in the core, probably.

2 CHAIRMAN BANERJEE: But in the unblocked
3 case you don't have a higher void fraction.

4 MR. KROTIUK: No, that's right, that's
5 right, you wouldn't. You'd have a lower void
6 fraction.

7 CHAIRMAN BANERJEE: There must be -- we
8 need to look at it in detail of how you did it, and
9 clearly we need to look at the driving heads available
10 and things like that.

11 MR. KROTIUK: Right.

12 MR. WALLIS: Well, I think that the staff
13 has to decide, are they going to ask the utilities to
14 do this kind of a calculation where they actually
15 predict in a realistic way the way the temperature
16 evolves, or are they going to settle for an
17 overarching conservative estimate of some kind.

18 CHAIRMAN BANERJEE: I guess it's really up
19 to the utilities, whichever way they want to do it.

20 MR. WALLIS: No, I think the staff has
21 some way of saying what they want, too, don't they?

22 CHAIRMAN BANERJEE: They can certainly
23 give some guidance, probably. But let's go back to
24 this calculation to ensure that we understand it,
25 because I think it's a very useful calculation.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 What -- the difference seems to be a
2 matter of 15 feet of water, roughly, or maybe 10 feet
3 of water. So let's try to understand this better in
4 terms of driving head.

5 MR. KROTIUK: Uh-huh.

6 CHAIRMAN BANERJEE: Their argument for 1.2
7 psi seemed to be correct at the time they gave it.
8 Your argument -- with their whatever void fraction
9 they had, which we thought --

10 MR. KROTIUK: Yes, I think it was a 50
11 percent. I know I'm not 50 percent.

12 CHAIRMAN BANERJEE: Now let's say you have
13 a case which is close to that, so how is it that you
14 have so much higher driving head? That's really the
15 --

16 MR. KROTIUK: Well, the driving head that
17 I defined was simply the gravitational head from
18 basically the level of the cold leg down to the bottom
19 of the core. And so that's just a roh gh.

20 CHAIRMAN BANERJEE: But that assumed that
21 the core was completely voided.

22 MR. KROTIUK: No, the core is partially
23 voided.

24 CHAIRMAN BANERJEE: Partially voided.

25 MR. KROTIUK: Right.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN BANERJEE: So when you say the
2 driving head, you haven't subtracted out the static
3 head in the core? Is that what you're meaning? So
4 it's just from the top of the -- the bottom of your
5 hot leg or cold leg or whatever it is.

6 MR. KROTIUK: Right, right, right.

7 CHAIRMAN BANERJEE: To the bottom of the
8 core. That's what you're calling driving head.

9 MR. KROTIUK: That's what I'm calling it.

10 CHAIRMAN BANERJEE: There is a difference
11 here, okay?

12 MR. KROTIUK: Okay.

13 CHAIRMAN BANERJEE: As long as I
14 understood the difference. That's exactly right.

15 MR. KROTIUK: I didn't catch that.

16 CHAIRMAN BANERJEE: Okay. It's fine. Now
17 we understand -- do you understand?

18 MEMBER ABDUL-KHALIK: No. That's his
19 delta P across the bed is 4 psi, which is higher than
20 the total available driving head that they've
21 calculated.

22 MR. WALLIS: That's because they have a
23 void fraction of 50 percent in the core.

24 CHAIRMAN BANERJEE: If it was 100 percent,
25 which is what would happen --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. WALLIS: Then they get 7.6 or
2 something, whatever it was.

3 MEMBER ABDUL-KHALIK: Well, 100 percent is
4 the void fraction at the top of the core. He says
5 it's a subcooled layer in the bottom of the core, he
6 has some intermediate layer with lower void fraction.

7 The 50 percent is an average void fraction for the
8 whole core height. I don't know what the average void
9 fraction.

10 MR. KROTIUK: Yes, I never calculated it.

11 MEMBER ABDUL-KHALIK: It may or may not
12 be, you know, less than or greater than 50 percent. I
13 don't know.

14 CHAIRMAN BANERJEE: So you've saying it's
15 7.8 psi at the bottom of the core. That's -- between
16 the cold leg and -- that's just --

17 MR. KROTIUK: Okay, between the cold leg,
18 from the -- from the cold leg to the bottom of the
19 core.

20 MR. WALLIS: That's just a matter of
21 height of water; right?

22 MR. KROTIUK: Right. And then that's also
23 assuming the numbers -- you know, you have to look at
24 the numbers that I assumed for height and, you know,
25 dimensions and all that. So, you know, it's, you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 know, typical numbers that --

2 CHAIRMAN BANERJEE: Plus 15 feet of water?

3 MR. KROTIUK: Something of that nature,
4 yes.

5 CHAIRMAN BANERJEE: Okay.

6 MR. WALLIS: Now there are uncertainties
7 in your calculation?

8 MR. KROTIUK: True.

9 MR. WALLIS: And they're fairly big?

10 MR. KROTIUK: It's hard for me to quantify
11 that.

12 MR. WALLIS: Yes, but if you put
13 uncertainties in, then you could perhaps get
14 overheating with a significantly thinner bed. I know
15 there are fairly big uncertainties in these
16 predictions.

17 MR. KROTIUK: Uh-huh.

18 MR. WALLIS: So if you looked at sort of
19 the 95th percentile or something, you might well find
20 it to be conservative, but you'd have to have a much
21 smaller amount of debris.

22 One uncertainty is chemical effects.
23 Which are not in there. So if you put in chemical
24 effects, it might be that --

25 CHAIRMAN BANERJEE: Well, whatever gives

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 you 4.2 psi. That's the answer we're looking for.
2 And so we've got the answer, really. If you've got
3 4.2 psi or pressure loss, you've answered the question
4 we asked.

5 MR. WALLIS: You've given the Owners Group
6 more pressure drop. You've given them 4.2 now.

7 MR. ANDREYCHEK: We appreciate that.

8 (Laughter.)

9 MR. WALLIS: What do we do with this?

10 CHAIRMAN BANERJEE: If they get 4.2 psi
11 pressure loss --

12 MR. WALLIS: What do we do now, having
13 heard this?

14 MR. KROTIUK: I think we need to take a
15 look at this.

16 CHAIRMAN BANERJEE: I think this is a
17 pretty good bounding -- this is exactly what we are
18 looking for.

19 MR. WALLIS: But it's CaiSil. It's
20 different stuff.

21 CHAIRMAN BANERJEE: It doesn't matter.
22 It's the 4.2 pressure loss, which is really the
23 important factor. How we arrive at that doesn't
24 matter.

25 MR. WALLIS: Well, it does matter how

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 thick the bed has to be.

2 CHAIRMAN BANERJEE: It doesn't matter
3 because the 4.2 could come from a tin bed with
4 chemicals or -- we don't know how it's going to
5 happen.

6 MR. WALLIS: Well, he's just done two-
7 phase flow then. I mean he's just --

8 CHAIRMAN BANERJEE: Well, at least he's
9 done the two-phase flow right. So that's fine.

10 MR. WALLIS: What he's saying is that you
11 can get thicknesses which are not unreasonable,
12 perhaps, which might lead to overheating.

13 CHAIRMAN BANERJEE: Well, that's a --

14 MR. WALLIS: The message about the debris
15 is important, isn't it? Not just how you do the two-
16 phase flow in the core.

17 DR. KRESS: Well, we don't know that it's
18 4.2 because we went all the way up from 2.4 to 4.8.
19 It might be somewhere in between.

20 CHAIRMAN BANERJEE: It's somewhere in
21 between.

22 DR. KRESS: In between those.

23 CHAIRMAN BANERJEE: Yes. But what you are
24 really saying is that if you do a little bit better
25 calculation with TRACE, which is giving you something

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 better than the homogenous model, it's still -- your
2 first approximation is close to the homogenous model.

3 So if I sat down and I had to do this by hand, now I
4 know the homogenous model works reasonably well. Even
5 I could do it.

6 MR. WALLIS: But to use TRACE or to use
7 your hand calculation, you have to have a theory of
8 how to predict delta P. You have a set of equations
9 which --

10 MR. KROTIUK: Right.

11 MR. WALLIS: -- which predicts delta P.

12 MR. KROTIUK: Correct.

13 MR. WALLIS: All right. These guys have
14 tests.

15 MR. KROTIUK: Oh, okay.

16 CHAIRMAN BANERJEE: Well, they can use the
17 tests.

18 MR. WALLIS: I don't see the connection.
19 Is the staff going -- you can't use TRACE unless you
20 have an equation, presumably, or something to predict
21 how the pressure drop varies.

22 CHAIRMAN BANERJEE: If they measure a
23 pressure drop, somewhere between 2.4 and 4.2 psi, we
24 know there's a chance of uncovering. It's as simple as
25 that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 DR. KRESS: You could have put in delta P
2 as the independent variable.

3 CHAIRMAN BANERJEE: He just put it in.

4 MR. WALLIS: See, if you had a big enough
5 test matrix, you might be able to do that.

6 DR. KRESS: No, he can just put it in as
7 an independent variable. And you'd come up with an
8 answer for delta P --

9 MR. WALLIS: How do you get that delta P?
10 For what conditions do you get that delta P?

11 DR. KRESS: Oh, that's a key question,
12 yes.

13 MR. WALLIS: He's got a theory to tell
14 you.

15 DR. KRESS: Yes, just for some sort of
16 debris, but not --

17 CHAIRMAN BANERJEE: Well, he's given us
18 two pieces of information which are valuable: what
19 the pressure loss can be in a uniform bed, of course;
20 and the other -- I guess the only theory part of it is
21 that it varies linearly, the bed thickness. The delta
22 P --

23 MR. KROTIUK: Excuse me. To clarify the
24 question in my own mind -- I'm sorry.

25 MEMBER ABDUL-KHALIK: But that delta P

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that you calculate is calculated using an empirical
2 correlation that you put in --

3 MR. KROTIUK: In the debris bed, right.
4 It's using an empirical correlation that's based on
5 test data.

6 DR. KRESS: Okay. Yeah, but you've fooled
7 around with that by having it compressed with the
8 flow. You changed the parameters with the flow rate,
9 didn't you?

10 MR. KROTIUK: No, that's a function of the
11 calculational method to calculate -- to, you know,
12 you're using an equation called the Ergon equation,
13 and this is basically a modification of the Ergon
14 equation that I developed in NUREG 1862, and it's a
15 iterative process to come up with the saturated
16 thickness of CaiSil, say, in the fiber bed. So it's
17 an iterative process.

18 But then to use it in the hand calculation
19 in TRACE, I came up with a curve because I didn't want
20 to include that into the -- all the calculations. I
21 came up with a curve fit to approximate it.

22 MR. WALLIS: So you have done a prediction
23 based on PNNL experiments of the particular stuff they
24 used.

25 MR. KROTIUK: That's correct.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. WALLIS: How are you going to make a
2 prediction, if any, for the real case in a plot?

3 MR. LANDRY: If I may. This is Ralph
4 Landry again.

5 CHAIRMAN BANERJEE: Yes.

6 MR. LANDRY: I think we're losing
7 perspective of what the goal was in this calculation.
8 It's the old adage, when you're up to your neck in
9 alligators, it's difficult to remember that the goal
10 was to drain the swamp.

11 In March when we came in, we had a
12 calculation that was done with TRACE that assumed a 95
13 percent blockage of the core inlet. There was a 5
14 percent area slot that the flow came into the bottom
15 of the core.

16 The core -- the flow was redistributed
17 throughout the core and kept the core cool. And the
18 question was, that's fine, but how do you know that
19 that's a realistic flow through the core, and how do
20 you relate that to a blockage of the entire core, or
21 distributed blockage?

22 We went to Research and said how can we do
23 this? Can we go in and take a 5 percent flow area in
24 every cell coming into the core, and Bill said, I've
25 got a better idea, let me devise a porous membrane

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 across the bottom of the core and we'll have then a
2 restricted flow through the entire bottom of the core,
3 and see how much restriction we can take across the
4 entire bottom of the core and still have adequate
5 cooling.

6 That was the goal.

7 CHAIRMAN BANERJEE: And you've done it.

8 MR. LANDRY: The goal was to see could we
9 have some representation of a porous membrane, a thin
10 bed, whatever you want to call it, across the bottom
11 of the entire core of the TRACE model. Could you get
12 enough flow, or how thick and how much resistance do
13 you have to have in this membrane to get to the point
14 that you can't keep the core cool? That was the goal.

15 Not to develop a theory or doing a calculation.

16 Bill had to go back and find a way to get
17 something that represented a porosity or a resistance,
18 and that's when he went to the PNNL data. He had to
19 come up with a way to represent the porosity
20 distributed across the bottom of the core, so he could
21 restrict the flow to see. Then as he elevated --

22 MR. WALLIS: Well, that's trivial. That's
23 trivial. All you need to know is what's the
24 resistance to bring the flow rate down to the point
25 where you get --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. LANDRY: But, Graham, that was the
2 purpose of those --

3 CHAIRMAN BANERJEE: That was the question.

4 MR. LANDRY: -- analyses.

5 MR. WALLIS: Well, that's true, but you
6 don't need any model of --

7 CHAIRMAN BANERJEE: That's what he did, he
8 just used the homogenous model.

9 MR. LANDRY: And now you are talking about
10 an entirely different problem. The goal was to
11 measure or to do a calculation that said we could keep
12 the core cool with a certain amount of restriction.
13 That's been done.

14 MR. WALLIS: I'm very puzzled by what you
15 said. Maybe I misheard you, but I understand that
16 with an unblocked core you get 115 kilograms a second.
17 With a blocked core that overheats, you get 45
18 kilograms per second. That doesn't sound to me like
19 94 percent blockage. Ninety-four percent blockage is
20 a much bigger effect than he's got here. I can't
21 reconcile the two pieces of evidence.

22 CHAIRMAN BANERJEE: You are talking about
23 the previous case calculations?

24 MR. WALLIS: The previous thing, which
25 said you can block 94 percent or 98 or something,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 whatever it was --

2 MR. LANDRY: It was 95 percent.

3 MR. WALLIS: -- and that will cool the
4 core.

5 MR. LANDRY: But, Graham, we weren't --
6 we're not trying to get at that now. The purpose here
7 wasn't to reconcile the calculation that was done
8 previously. The purpose was to determine is there a
9 restriction on the inlet to the core that you could
10 sort of relate to a porous membrane, and then get to
11 the point where you can't adequately cool the core.
12 That was our goal.

13 MR. WALLIS: His restriction that doesn't
14 adequately cool the core reduces the flow rate through
15 the core by a factor of less than three. It seems to
16 me that 94 percent blockage is going to have a bigger
17 effect than that, so I cannot reconcile --

18 CHAIRMAN BANERJEE: No, it doesn't
19 necessarily because what you're having is -- this is
20 why the 95 percent was very confusing. It's not the
21 same as putting a uniform thing with a pressure loss
22 because a lot of stuff can be going through that
23 little hole, which is what was worrying us.

24 MR. WALLIS: So it's not really --

25 CHAIRMAN BANERJEE: You can get a lot of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 flow.

2 MR. WALLIS: It's just putting the same
3 flow rate through the little hole?

4 CHAIRMAN BANERJEE: Well, it's not
5 proportional to the flow area, remember.

6 MR. KROTIUK: Yes, I think you have to
7 remember that the pressure drop through the debris bed
8 could be different than the pressure drop through that
9 5 percent little hole.

10 CHAIRMAN BANERJEE: The 5 percent hole has
11 no resistance. Everything goes through it.

12 MR. WALLIS: At the critical condition
13 where the core overheats, the pressure drop through
14 the hole or through the bed should be the same.

15 CHAIRMAN BANERJEE: So if you made a -- so
16 let's the orifice equation, okay, and if you look at
17 it, this hole might give you enough flow to -- more
18 than enough to cool the core.

19 MR. WALLIS: But we know we've got to get
20 the balance between the pressure drop through the core
21 and the pressure -- when the core is overheating, the
22 pressure drop through the core is a fixed number,
23 pretty well; right? Now the pressure drop through the
24 downcomer is a fixed number. So all we need to know
25 is the pressure drop we can get across a hole or a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 bed.

2 CHAIRMAN BANERJEE: In his case, he's
3 saying it's somewhere between 2.4 and 4.2 psi. The
4 pressure drop through a 5 percent opening may not --

5 MR. WALLIS: PSI?

6 CHAIRMAN BANERJEE: It may be less than
7 that. It may be much less than 2.4 psi. That's all
8 I'm saying.

9 MR. WALLIS: And give you the -- it
10 doesn't make sense.

11 CHAIRMAN BANERJEE: I'll talk to you about
12 it later.

13 MR. WALLIS: You'll talk to me later.
14 Okay.

15 CHAIRMAN BANERJEE: Yes. Okay. I think
16 you've done exactly what we wanted, and the issue of
17 how this is used as a model is a separate issue.
18 You've answered the question we had.

19 So I think that is enough for that. Now
20 do you have some other things you want to talk?

21 MR. SMITH: Basically Bill was our grand
22 finale, and he did a great job.

23 (Laughter.)

24 MR. SMITH: But the conclusions are that,
25 as we know, that there's testing underway now for both

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the Westinghouse and the CE and the AREVA fuels, and
2 the testing is going to determine acceptable debris
3 loading for the various fuel designs.

4 And I think the other conclusion that I
5 have, after today, I think you guys have brought up
6 some good points that we need to consider while we're
7 reviewing this data and, you know, I think we're going
8 to work with Research on what the allowable potential
9 head loss could be. I think that's a very important
10 piece of the puzzle.

11 MR. HARRISON: And providing this
12 information to the committee as well.

13 CHAIRMAN BANERJEE: So now we need to
14 spend a little time discussing -- if you like, you can
15 stay up -- what we do for the full committee meeting,
16 and so in this case we usually ask each of the
17 subcommittee members, first of all, to sort of
18 summarize their views on the whole day, and give you
19 some feedback.

20 Now how much time do we have at the full
21 committee meeting?

22 MR. SMITH: I believe two hours.

23 (Discussion off the record.)

24 CHAIRMAN BANERJEE: So what we need to do
25 now is to discuss our views and maybe it will help

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 you, the staff, I mean, to prepare for the full
2 committee meeting, and what the subcommittee feels
3 might be important.

4 So why don't we start with Tom.

5 DR. KRESS: This is for what? What we're
6 going to present to the full committee?

7 CHAIRMAN BANERJEE: Yes, the full
8 committee has to write a letter, so just to set the
9 stage. We will be writing a letter in our October
10 meeting, and this letter really needs to summarize the
11 three subcommittee meetings in some way.

12 Now, of course, because we've had three
13 subcommittee meetings, but we don't necessarily need
14 to dwell on what has happened before, but really give
15 the staff's resolution of the PSI-191 as of the time
16 of the full committee meeting. The history is
17 important, but it's not all, you know, that germane.

18 We need to be able to give a sort of a
19 status report and, if possible, to give some review of
20 the staff's plan to close the issue, and what the full
21 committee feels about it.

22 I think that's really the important part,
23 the whole thing.

24 So taking that into account, what I'd like
25 to do is to get some feedback from the subcommittee

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 over the next 15 minutes to half an hour, and then
2 have some interaction with the staff on that before we
3 close the meeting. So that's the purpose.

4 DR. KRESS: I certainly would have a big
5 part of this be the current tests that are ongoing
6 because what I see as the strategy is to get enough
7 empirical data for specific plant types and specific
8 filters so that you can use that empirical data to put
9 limits on the amount of debris you can have.

10 Now so this is a start on that process,
11 and I think that needs to be the main part of the
12 meeting, actually.

13 The -- I would like to see them give some
14 indication of how many more tests they think are going
15 to be needed to more fully put this thing to bed. I
16 don't think we got a good feel for that today.

17 But I think with the -- I would also
18 present the stuff on the settling out tests that were
19 run because I think those -- getting back to the
20 settling out before you go through the screen. I
21 think the committee will have some questions about
22 those, particularly the Skelly effects, so I think
23 that ought to be presented. But it doesn't take too
24 long for that.

25 This TRACE calculation, that's of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 interest, and it can be very short, so it could be
2 fitted in, and it has some useful information, I
3 thought.

4 So that's basically my feeling of what you
5 need.

6 CHAIRMAN BANERJEE: Okay. Let's go to the
7 other end and we'll come back, since Bill has
8 vanished.

9 Graham.

10 MR. WALLIS: Well, as always, progress has
11 been made. What we heard from the Owners Group tells
12 me that there are a lot more tests coming, that they
13 are rewriting the NUREG, and it may change quite a bit
14 from what we saw before. So I cannot tell how
15 complete the final methods will be and whether they
16 will be adequate. I need to see more evidence. So
17 I've learned that they're doing things. They've got a
18 plan. I'm not sure that they know until they start
19 doing more tests how messy the results are going to
20 be. Because it may turn, as we have learned from
21 other tests, you know, when you do two tests and
22 everything looks fine, you do four tests and you find
23 you've got something you can't explain, and so on.

24 So I'm waiting to see, really. I'm glad,
25 very glad they're doing these tests, you know, because

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 realistic geometries and hopefully fairly realistic,
2 conservatively realistic, if that means anything,
3 debris. But I really have to wait and see.

4 The staff is, I think, well aware of all
5 the issues. They've been with us long enough, they've
6 seen enough things that they are aware of the issues.

7 What I still don't know is how they are
8 going to review these submittals, which are going to
9 come in all kinds of forms and all kinds of rationale.

10 There isn't really a standard way to compute these
11 things, which everyone agrees on.

12 So until we see how the staff actually
13 confronts something which claims to be showing
14 adequate assurance, I don't really know that the
15 problem has been resolved.

16 So I am still a bit mystified about just
17 how the staff is going to evaluate what is a very
18 difficult problem with all kinds of aspects.

19 I think they understand what's involved,
20 but they have some evidence, they have some ways of
21 getting a handle on these things. But I don't really
22 know how they're going to put it all together.

23 CHAIRMAN BANERJEE: What do you think, do
24 you have any thoughts on what they should present at
25 the full committee meeting?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. WALLIS: Well, I think you have to say
2 that there's been progress.

3 CHAIRMAN BANERJEE: Well, I mean they have
4 to present, the staff have to present.

5 MR. WALLIS: For the staff to present?

6 CHAIRMAN BANERJEE: I can't presume what
7 the full committee will write at the end of --

8 MR. WALLIS: I think it would be good if
9 the staff could very clearly say that when we met with
10 you last time, we knew this. Since then we've made
11 this progress. And this is where we need to go.

12 Can you do that in half an hour?

13 CHAIRMAN BANERJEE: Two hours.

14 MR. WALLIS: And do you know where you
15 need to go until you see the details? Do you know
16 enough about the form of these submittals to know
17 where you need to go before you can really truly
18 evaluate them?

19 CHAIRMAN BANERJEE: Well, there's always
20 going to be surprises, so they have to have a plan at
21 any given time which they can revise, obviously.

22 MR. WALLIS: I think what they should
23 present to the committee is this is where we were when
24 we met you last, this is the progress we've made, and
25 this is what we need to do. And I think just perhaps

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 a review area or discussion quickly would help, saying
2 these items are where we have concerns.

3 CHAIRMAN BANERJEE: So I think some part
4 of it can be what you're saying, that this is the
5 progress we've made. It would be nice if the progress
6 we've made is punctuated with some data.

7 MR. WALLIS: Absolutely. Not just words.

8 CHAIRMAN BANERJEE: Yes. You sort of get
9 a negative reaction, you know. You know the
10 committee.

11 MR. WALLIS: We now know that if you can
12 be assured you won't get more than full psi pressure
13 drop across this thing, everything will be fine.

14 CHAIRMAN BANERJEE: Right. Whatever it
15 is, you know, it needs -- well, maybe 2.4 is safer.
16 Whatever. The more data in reporting where we are
17 today, the warmer the reception obviously will be.

18 But also what Graham is saying about the
19 plan to close the issue out, I think that's very
20 valuable, but you can only base it on your best
21 knowledge today. I mean what else can you do? And if
22 some surprise occurs, well, one will deal with it.

23 MR. ROLAND: When you say data --

24 CHAIRMAN BANERJEE: The status.

25 MR. ROLAND: Meaning where we stand for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the specific plant?

2 CHAIRMAN BANERJEE: No, I think it's
3 always nice to have some indicative data, you know, of
4 things, like, for example, the stuff you showed us
5 today on some of the data you got on downstream
6 effects. It doesn't have to take long, but briefly if
7 one could show some data, it's always nice. The
8 committee -- the committee, I know -- likes this
9 feeling of activity that there's actually something
10 happening and it's just all words.

11 MR. ROLAND: Well, obviously you know
12 there's lots happening.

13 CHAIRMAN BANERJEE: Yes.

14 MR. ROLAND: The problem I'm having in
15 thinking about the data, as the committee no doubt has
16 discovered well before this meeting, this is highly
17 plant specific. So what is acceptable at one
18 particular plant may or may not be acceptable at
19 another one.

20 So what we'll try to -- you know, what
21 we'll try to maybe -- and we've been asked, actually,
22 by our management over and over again, Bill, tell me
23 what the closure path is, and they have asked us for
24 charts -- can you bin the plants. And they have asked
25 us many times to try to put bounds on this other than

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the answer I just gave you, which it depends. It
2 depends on each individual plant.

3 And really we have not been successful,
4 but I -- one of the reasons we showed you the pictures
5 and the film today was because we think that is
6 representative of data, that licensees are in fact
7 collecting data, but on those specific -- it all
8 depended on that specific plant and the data for that
9 plant.

10 So what we can give is anecdotes. You
11 know, okay, examples and data attached to those
12 examples. That we can provide.

13 CHAIRMAN BANERJEE: Well, I think --

14 MR. WALLIS: Some criteria which are not
15 plant specific. You need to have a prediction of
16 pressure drop across the screen. Are you going to
17 have -- you're going to have to say we will accept
18 data taken in a flume where someone with a bucket
19 pours stuff in and pours it in in a way which we
20 believe to be conservative. You have to have a
21 statement that says we're going to accept that kind of
22 result and use it.

23 CHAIRMAN BANERJEE: Well, there is
24 guidance; right?

25 MR. WALLIS: Otherwise, you will be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 questioning that forever.

2 MR. ROLAND: That's exactly the problem we
3 have faced. And one of the reasons we have chosen
4 this holistic review that the commission told us to do
5 is because of the incredible site-specific nature of
6 all these evaluations.

7 We have done this holistic review, and
8 because it changes at every plant, we make this
9 judgment. And that's the way we have chosen to do it.

10 MR. WALLIS: I don't think the site-
11 specific problem is as big as the extrapolation from
12 the tests to any site. That's the real question. If
13 you know how to do that, you can evaluate the site
14 specific.

15 CHAIRMAN BANERJEE: Well, I think it is to
16 some extent site specific. In the situations where
17 you mix up everything and do a rather conservative
18 prototypical test, you're probably getting pretty good
19 conservative bounding estimates there.

20 So my sense of it is that you'll have
21 different approaches for different plants and
22 different types of things, but you are trying to do --
23 you are trying to make tests as prototypical as
24 possible, and in some cases it's easier because, you
25 know, you can mix everything up and make it happen.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 And that's certainly something worth showing, at least
2 the successes there.

3 And it is worth saying also that in some
4 way it's more difficult to handle situations where you
5 have to appeal to a lot of dropout or changes in
6 insulation or whatever.

7 I think that would be fine. I mean you're
8 telling it like it is, and I think just tell us like
9 it is, but not taking too long over it. I'm just
10 saying anecdotally, you know.

11 MR. ROLAND: Yes, sir.

12 CHAIRMAN BANERJEE: It will take longer
13 and longer, anyway.

14 But I don't want to preclude, so I'm just
15 dealing with Graham's comment because Otto will have
16 another set, and I'm sure Mike will have another set,
17 so --

18 MR. ROLAND: I understand.

19 CHAIRMAN BANERJEE: -- let's wait till we
20 get through it.

21 MR. ROLAND: Okay.

22 CHAIRMAN BANERJEE: Otto, carry on.

23 MEMBER MAYNARD: Well, first of all, I'm
24 glad to see additional testing being done, and I know
25 that we're kind of in the early stages of it, part way

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 through it, so I think it's a good opportunity, and
2 I'm glad we got a chance to review that, and provide
3 some off-the-cuff comments, kind of, first impressions
4 and things, and I think that will help both the staff
5 and the licensees to maybe take a harder look at some
6 of these areas and make sure some of these things are
7 being cured.

8 So I'm encouraged by that. I think that
9 there's probably going to be a need for more
10 justification for some of the observations and
11 results, and I think maybe more than what they might
12 have anticipated. I think I'd be careful of just
13 assuming that something is obvious or it's just -- you
14 know, well, that's just what we observed. I think
15 it's going to have to also include the whys and, you
16 know, why is -- some simple thing, you know, why is a
17 four-foot tall one good enough as opposed to a full-
18 length 12-foot long one. You know, if you see a
19 pressure drop when something is added rather than a
20 pressure increase, why?

21 And I think that's going to help both the
22 future of the licensees and also the staff in
23 reviewing other plants' applicability to the WCAP. I
24 think it's going to be important to understand what
25 the limitations of the testing were, why, how much

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 does it really encompass, and I think that will make
2 the rest of the process much better.

3 Because the WCAP is not the end. I mean
4 that provides one set of data, but then the applicants
5 or licensees have to come in and justify why they fall
6 into that, and the staff has to review and have some
7 type of acceptance criteria and guidance as to what
8 they're going to accept, showing that it's consistent
9 with that.

10 So I think there is still a lot of work,
11 but I am encouraged. I think in general it's on a
12 path to get in that direction. I think there's still
13 a lot of little details to be worked out, but I do see
14 that as a better path than trying to justify it with
15 the existing data as to that everything is okay.

16 I agree with Tom on the settling. I
17 think, you know, a little bit more needs to be done
18 there.

19 First of all, I believe that's what being
20 done is probably conservative. I'm not sure I have a
21 high degree of confidence in CFD results for this
22 situation, and there may need to be some more
23 explanation or something more done to kind of justify
24 that.

25 Like I said, I'm not saying I don't think

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 --

2 CHAIRMAN BANERJEE: I don't want to enter
3 into a long argument at the full committee on CFD
4 calculations when we have bigger fish to fry.

5 MEMBER MAYNARD: As far as -- and I think
6 that ultimately there's never going to be a program
7 put in place that addresses every detail of this issue
8 in a way that guarantees every aspect is totally
9 conservative. I think it's going to end up being in
10 the overall big picture of things, everything that's
11 been done, overconservatism here, maybe it's not as
12 conservative here, but it's going to result in a
13 judgment of reasonable assurance for the existing
14 licensees.

15 I don't think that necessarily has to be
16 the end or the definitive end of looks at this thing.

17 We've got new plants coming down the line, new
18 designs and stuff, and I think that, you know, this --
19 I know everybody would like to see this thing put to
20 bed, but I'm not sure it's totally going to get to --
21 I think that for the existing plants and for the
22 existing conditions, I think it's going to just result
23 in, you know, at some point a decision of reasonable
24 assurance is going to come out of this.

25 As far as for the meeting, you know, the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 three things that I would say, I do think the staff's
2 review process for this, I think their process is
3 important, and the real brief deal at the beginning
4 where they have talked about the process, you know,
5 the consistence of membership, the people doing the
6 reviews, to show some consistency as to what's
7 reviewed at one plant versus another.

8 I don't know you necessarily have to have
9 the guidance documents here, but, you know, to
10 demonstrate that there are guidance documents for
11 which one of these review areas so that there is a
12 process and a method for reviewing the licensees'
13 submittals.

14 I think the Owners Group tests and plans
15 needs to be a part of the discussion there, where
16 that's going, and that personally I know we've gotten
17 quite a discussion, but I thought the staff's TRACE
18 results were exactly what we had asked for.

19 CHAIRMAN BANERJEE: Exactly.

20 MEMBER MAYNARD: And, you know, there was
21 one set that was for, okay, if you assume the entire
22 thing other than 95 percent is blocked and there's one
23 opening there, they did that last time. This time
24 they have answered the question, well, what if it's a
25 uniformly distributed bed, you know, how thick a bed

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 can you withstand or take care of, and I think they
2 did that. So I thought that was good.

3 So those are the three things that I would
4 suggest.

5 CHAIRMAN BANERJEE: Okay. Mike?

6 MEMBER RYAN: Thanks.

7 I guess my comments are very similar to
8 what Otto and others have said, in that I would like
9 to hear and understand a little bit more about why
10 things are conservative or bounding. We used those
11 terms a lot today, and I think it would be very
12 helpful if I understand a little bit more detail of
13 why you've made that decision or judgment that
14 something is bounding and conservative.

15 And it would also be helpful to ask the
16 opposite question: When wouldn't it be conservative?

17 What would be the circumstances, conditions or
18 features to a problem that would take you out of that
19 conservatism, so people could get an understanding of
20 the range of where that reality might be.

21 Again, I appreciate, as Otto mentioned,
22 there's a wide range of conditions and systems and so
23 forth in plants that can cause that to be quite a
24 variable, but, you know, it's very helpful, I think,
25 to try and offer some insights as to that,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 particularly for members of the full committee that
2 worry about such things as uncertainty analysis and
3 PRAs and so forth.

4 So I think that would be very helpful.

5 Again, as much as you can deal with the
6 range of materials that are involved in various plants
7 and how they behave physically in the flow system.
8 You know, do they build up as a thin film or a thick
9 layer, and are there voids in some of the physics of
10 all that accumulation and flowthrough of accumulations
11 would be helpful to me just to see a little bit more
12 detail.

13 Again, it may exist already and I'm not as
14 conversant with some of the history on this issue as I
15 might be. But that, I think, would help the full
16 committee to understand that a little bit more.

17 CHAIRMAN BANERJEE: Okay. Thanks.

18 Said.

19 MEMBER ABDUL-KHALIK: I think most of the
20 comments I was going to make have already been made.
21 But in my mind, sort of the biggest question is the
22 prototypicality of experiments. How does one use the
23 results of an experiment to extrapolate to actual
24 plant conditions in all the experiments that we have
25 seen today?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 And perhaps that process is what this
2 review committee goes through, and if that is the
3 case, I'd like to understand this process.

4 The second question -- first of all, I
5 liked very much the calculation that was presented by
6 Bill towards the end because that's very much what we
7 asked for at the last meeting. And it sort of
8 answered a lot of the questions, but it also brought
9 some additional questions.

10 I mean, you know, we were told by the
11 Owners Group that criteria will be developed based on
12 these delta P limits for maximum loadings, and that
13 puts a lot of weight to whatever values for these
14 delta Ps that you will come up with, and if there is
15 an obvious discrepancy between your hand calculation
16 and what the calculation that was presented by Bill
17 says as far as the delta P in the bed --

18 MR. ANDREYCHEK: We're going to figure it
19 out. One was 18 feet and one was 16, so we've just
20 got to figure out where to get the 18.

21 MEMBER ABDUL-KHALIK: Well, I think it's
22 important -- he was doing a calculation for a cold leg
23 break and he came up with a delta P of four point
24 something psi which tells me that the total available
25 pressure drop is higher than the 4 psi, and you're

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 saying that the available delta P is 2.5 psi. I think
2 it would be important to clarify that discrepancy,
3 given the fact that, hey, this is going to be the
4 basis for whatever criteria you're going to develop.

5 And the third thing is, you know, if
6 you're going to develop these criteria, how do you
7 combine these three limits? I'd like to see a better
8 understanding for how a combination of the three
9 different types of loadings can be extracted from
10 limits on individual material loadings.

11 Thank you.

12 CHAIRMAN BANERJEE: Thanks.

13 So I think you've got a pretty good idea
14 of what we'd like to hear, and of course I would tend
15 to believe the TRACE calculations, so I wouldn't
16 belabor that point too much. You know, so I'd go with
17 that and not waste too much time with other stuff.

18 But certainly that is even very briefly
19 worth presenting, I think, to the committee, so that's
20 been echoed by several people who just reaffirmed
21 that.

22 I do feel that you've given us status
23 reports before of how you've moved forward to try and
24 close this, and you have even addressed the full
25 committee before. So this is the second time you're

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 addressing the full committee. The last time we
2 didn't write a letter.

3 But I think it's still worthwhile just
4 reminding them very briefly of the status of the
5 activities that have taken place, that so many
6 reactors have done stream changes, so many people have
7 done and removed insulations; you know, the sort of
8 the usual things that you've been telling us. People
9 have done things with their buffer.

10 I don't think you need to dwell long on
11 this.

12 MR. ROLAND: But it sounds like what we
13 said today, but add some numbers.

14 CHAIRMAN BANERJEE: Add some numbers.

15 MR. ROLAND: Okay.

16 CHAIRMAN BANERJEE: Yes. And do it very
17 briefly so we understand very quickly where we are at,
18 and my sense of it is that several people have been
19 asking about the testing that is being done, the
20 prototypicality of those tests; something to address
21 that and maybe show a little bit of data, if you can,
22 on the pressure loss testing and how chemical effects
23 are being taken into account. You know, whatever it
24 is to reassure the committee that this is an area
25 which is under control, and clearly, to me, there is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 no simple answer to this, and you have to handle it in
2 some holistic way, which is what the commission's
3 direction originally was, and I think in our letter,
4 one of our formal letters, which I was reading, we
5 endorsed that, by the way.

6 MR. ROLAND: Right.

7 CHAIRMAN BANERJEE: So it's very much in
8 line with what you said. But I do think that you must
9 address with these pressure loss tests, with the
10 screens, the prototypicality of the tests, how you're
11 addressing that, and the sort of applicability to the
12 full scale systems. I mean you can do it briefly.

13 So I see sort of a part of this
14 presentation dealing with the issue of what happens
15 through these screens, and hopefully we are well
16 advanced, because now we've got these screens in place
17 and we're really testing to ensure that these screens
18 are adequate, we don't get too high pressure losses,
19 and if necessary, whatever actions have to be taken to
20 take care of the situation will be taken care of.

21 The second issue seems to be the
22 downstream effects. And there I think let's assume
23 that you can deal with the pressure loss across the
24 screens. There are some new series of tests and so on
25 that are being planned by the industry.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 And so I would think that it would be good
2 to present what the plan is, to the extent that it's
3 available, and the rationale for that plan based on
4 the best available knowledge today, whatever that is.

5 I mean if you find surprises, obviously we'll have to
6 revise that plan.

7 But based on what we know today, this is
8 the plan, this is why this is the plan, you know, this
9 is what we know about the sort of loadings that we are
10 getting from the bypass, and we are going to survey
11 this range of conditions, this sort of stuff.

12 I think it would make a fairly good story,
13 you know. What we've seen is you've got data on
14 bypass from several plants now. We haven't seen the
15 whole data set -- hopefully the subcommittee will see
16 the whole data set. You've got size distributions for
17 particles, you've got a pretty good idea of, you know,
18 the loadings from different plants.

19 I feel much better about this than --
20 personally than I did when this thing first came
21 through. Okay? So we've advanced a long way. So I
22 think that story needs to be told with the plan.

23 And then any other issues that you feel
24 you'd like to inform the committee about with regard
25 to closure. If there is any issue as to why we should

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 keep all these plants operating while they are still
2 trying to meet the requirements. And if you are going
3 to discuss some other aspects like what you'll do to
4 assure that they will meet your requirements that
5 you're setting forth in an expeditious manner, that
6 might be something to say. I would say it. Okay?

7 So I think, with that, what we're really
8 looking for is for the committee to write a letter
9 endorsing your plan to close the issue. I mean it can
10 be as short as that.

11 MR. ROLAND: Thank you for this help.

12 (Laughter.)

13 CHAIRMAN BANERJEE: I hope that's said --

14 MR. ROLAND: No, no, seriously. I think
15 we know what you're looking for. You know, one of the
16 things we did in this presentation, we really didn't
17 get through a lot of history about -- you know, to
18 bring some of the other members up to speed that
19 haven't been with this issue all along. So we kind of
20 just launched right into it without a lot of
21 background about, you know, what is a sump and all
22 that kind of background. And I'm thinking that we
23 take that same approach, or probably a little more
24 information, about just maybe five minutes about
25 background about, you know, put it in context, how

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 long the issue has been out there, what we've been
2 doing. So I'm thinking we ought to add a little more
3 context upfront to our presentation than we did there.

4 It can't be long.

5 CHAIRMAN BANERJEE: No. You won't have
6 any time.

7 MR. ROLAND: It's got to be five minutes
8 of, you know, of history. So I think we need to do
9 something like that also that we didn't do here. And
10 if any members needed that, I apologize. But because
11 of the time constraints here, we made that -- that was
12 a conscious decision on our part.

13 My sense is -- and that, you know, maybe
14 we can go back and kind of look at the distribution of
15 data we're getting, and maybe we can give you a sense
16 of kind of the range we're looking at as opposed to,
17 you know, specifically what we have found at a
18 particular plant. And I haven't asked our staff yet
19 if that's even doable, but that's something we can
20 think about. You know --

21 CHAIRMAN BANERJEE: Whatever you do,
22 there'll be questions regarding the prototypicality of
23 these tests.

24 MR. ROLAND: Right.

25 CHAIRMAN BANERJEE: And the applicability

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 to the plants. So I think that's the issue that
2 really needs to get addressed.

3 MR. ROLAND: And I'd just like to ask all
4 the -- the rest of the GSI-191 staff here if there's
5 any questions that they have about their understanding
6 of what they believe the committee is looking for, for
7 the full committee.

8 Well, they're either -- this is not a
9 bashful bunch, so I guess they don't have any other
10 questions.

11 What I propose --

12 CHAIRMAN BANERJEE: Or they're asleep by
13 now.

14 MR. ROLAND: I don't think they're asleep.

15 What I propose is we would kind of try to
16 map out what our approach is, and I'll talk to Ed and
17 through Ed through you to kind of come up with a
18 generic approach of how we intend to do that.

19 Would that be okay?

20 CHAIRMAN BANERJEE: That works.

21 MR. ROLAND: Okay. And I'd like to also
22 just think both the GSI-191 staff, the Owners Group,
23 and the committee itself for continuing to plug away
24 at this issue because, you know, in my mind this is
25 the design basis safety issue. If you wanted to come

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 up with something as complex as possible to test how a
2 regulator would deal with, my estimation is you would
3 do this. This is the system you'd come up with.

4 We would love to have 2200 degrees, 17 percent
5 oxidation, or some similar line in the sand that we
6 could all agree is acceptable or not. It would make
7 our job easier. And, in fact, that's not what we
8 have, and we have virtually the complete opposite.

9 But it is through experience in these
10 reviews that we have been kind of gaining that
11 insight, and I think you heard during this meeting
12 that we kind of are approaching a limit on our
13 understanding of testing, but while it's still not
14 perfect, what we have is a far better idea of what
15 makes a good test today than we did even six months
16 ago.

17 So I would just like to agree with the
18 committee that we are making progress, albeit
19 sometimes for the staff and us, it doesn't feel that
20 way. And it definitely doesn't feel that way for my
21 management when they talk to me about this.

22 CHAIRMAN BANERJEE: We understand.

23 Well, I think there are no other comments,
24 I'd like to --

25 MR. WALLIS: Well, I have a comment.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN BANERJEE: Yes.

2 MR. WALLIS: When we meet again --

3 CHAIRMAN BANERJEE: Yes.

4 MR. WALLIS: -- I hope we're very close to
5 the end, and I hope we'll have documents to review
6 ahead of time so that we can be sure that we are sure
7 that you're near the end. Today everything was all
8 "we didn't have time to look for paperwork." Maybe
9 what we read will be very, very short, but we don't
10 know yet.

11 So, please, next time --

12 MR. ROLAND: Yes, sir, I got it, Doctor.

13 MR. WALLIS: -- be closer to the end and
14 have documents ahead of time.

15 MR. ROLAND: Okay.

16 CHAIRMAN BANERJEE: Well, I was just going
17 to thank all of you for taking your time. It's been a
18 very productive meeting, I think, and I'd like to
19 thank the Owners Group, the staff, and my fellow
20 subcommittee members for making it out here.

21 And with that, I'm going to adjourn the
22 meeting.

23 (Whereupon, at 5:33 p.m., the subcommittee
24 was adjourned.)

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

WCAP-16793-NP, “Evaluation of Long-Term Cooling Considering Particulate, Fibrous and Chemical Debris in the Recirculating Fluid”

**PWR Owners Group
September 23, 2008**



Agenda

- Background
- Debris Collection at Core Inlet
- Fuel Assembly Testing
- Boric Acid & GSI-191

Background

- GL 2004-02 issued to identify and request utilities to address the effect of debris from the sump on Long-Term Core Cooling (LTCC)
- Utility responses to GL must include:
 - Basis for concluding that adequate ECCS flow is available for LTCC in spite of increased resistance to flow downstream of the screens (i.e. downstream effects)
 - Description of modifications, if needed, to provide for adequate ECCS flow
- Industry guidance for fuel effects
 - WCAP-16793-NP

Background - WCAP-16793-NP Basis

- Provide an evaluation of long-term core cooling for the PWR design in the presence of debris ingested from the sump following a LOCA that provides reasonable assurance that decay heat is removed
- Demonstrate that there is reasonable assurance long-term core cooling requirements of 10 CFR 50.46 are satisfied with debris and chemical products in the recirculating coolant delivered from the containment sump to the core
- Use available tools and information
- Draw from and address
 - The design of the PWR from all US vendors,
 - The design of the open-lattice fuel from all US vendors,
 - The design and tested performance of replacement containment sump screens from all US vendors, and, tested performance of materials inside containment
- Applicable to the fleet of PWRs, regardless of the design (B&W, CE, or Westinghouse)

Background - Sump Screen

- Replacement sump screen openings are on the order of 1/16" to 1/8"
- Some debris that arrives at the sump screen may be smaller than the openings and penetrate the screen
- Any debris that passes through the sump screen can then be transported to the RCS, which could reach the core
- Debris is not ingested until after ECCS suction source is realigned to containment sump


Background - Core Conditions

- At the time of sump switchover (20-60 minutes after large break LOCA)
 - Core is fully recovered (i.e. covered with a 2 phase mixture)
 - Core mixture level above the top of the core
 - Actual vessel level, core flow rate, and debris transport are dependent on break location

Background – Break

Cold Leg Breaks

- Downcomer (DC) is full to at least the bottom of the cold leg
- Core level is established by the manometric balance between the DC liquid level and the core level and RCS pressure through the loops (or reactor vessel vent valves for B&W plants)




Background - Break

Cold Leg Breaks (cont.)

- ECCS flow enters the intact cold legs and upper downcomer at flow rates on the order of
 - 1000-3000 gpm for min ECCS
 - 6000-8000 gpm for max ECCS
- ECCS flow to the core is only what is required to make up for liquid lost due to boiling in the core.
 - At time of sump switchover, core boiloff rate is ~350 gpm for a Westinghouse 4-Loop plant
- Excess flow goes around the top of the downcomer to the break
- Once back in the containment sump, debris is again filtered by sump screen before returning to the RCS

Flow Rate to Match Boil-off versus Time for a Westinghouse 4-Loop PWR



Background - Break


Cold Leg Breaks (cont.)

- Most debris will flow to the break with the dominant flow field
 - For maximum ECCS, most of the ECCS fluid and debris exits from the break and returns to the sump
 - Flow to break = (total ECCS) – (boil-off rate) = 6000 – 350 = 5650 gpm
 - Percentage of ECCS fluid & debris that returns to the sump = (flow to break) / (total ECCS) = 5650 / 6000 ~ 94%
 - For minimum ECCS, ~2/3 of ECCS fluid and debris exits from break and returns to the containment sump
 - Flow to break = (total ECCS) – (boil-off rate) = 1000 – 350 = 650 gpm
 - Percentage of ECCS fluid & debris that returns to the sump = (flow to break) / (total ECCS) = 650 / 1000 ~ 65%

Background - Break

Hot Leg Breaks

- ECCS must pass through the core to exit the break
- Core flow rate is equal to the ECCS flow rate
- All debris will progress to the RV lower plenum



Background - Break

- Once the debris reaches the RV lower plenum
 - It may settle in the lower plenum, or,
 - It may transport to the core
- Three areas of possible concern for transport to the core include
 - Debris adherence to fuel cladding surface
 - Resistance to Flow at the Core Inlet
 - Resistance to Flow at Spacer Grids
- This presentation examines all three items

Collecting Fibrous Debris on Cladding


- Fibrous debris, should it enter the core region, will not tightly adhere to the surface of fuel cladding
 - NUKON OFC-1 Report
 - Submersion of a rod heated to 2200°F in a fiber slurry
 - Nucleate boiling of a heated rod in a slurry
 - Film boiling of a heated rod in a slurry
 - NRC reviewed and accepted the NUKON OFC-1 Report

Background - Fuel Assembly

- Fuel assembly inlet debris filters are included in the bottom of fuel assemblies
 - Designed to help reduce fuel assembly fretting problems during normal operation and reduce normal operation fuel failures
 - Fuel failures are high impact issues that affect normal plant operation and the cost of operations
- The Westinghouse P-grid design will be presented as an example to show the size of the openings

Background - Fuel Assembly

Protective Grid



Flow Resistance Due to Debris at Core Inlet

Types of debris that might reach the RCS:

- Fiber
- Particulates
- Chemical precipitates

Flow Resistance Due to Debris at Core Inlet

- For a postulated debris build up at the core inlet:
 - To determine if sufficient flow will reach the core to remove core decay heat through a potential debris bed at the core inlet
 - It must be demonstrated that the head available to drive flow into the core is greater than the head loss across the debris bed at the core inlet

$$\Delta P_{\text{available}} > \Delta P_{\text{debris}}$$

Available Head at Core Inlet

- The available driving head is based on the manometric balance between the downcomer and core

- $\Delta P_{\text{available}} = \Delta P_{\text{dz}} - \Delta P_{\text{flow}}$


Where:

$\Delta P_{\text{available}}$ = total available driving head at the core inlet


ΔP_{dz} = pressure difference available to drive flow through the core due to liquid level difference between the downcomer and core

ΔP_{flow} = pressure drop due to flow losses in the RCS (hot leg, steam generator, and cold leg to break)

Available Head at Core Inlet



RSG (W/CE design)



OTSG (B&W design)

Schematics demonstrate relative elevations of core and steam generators

Available Head at Core Inlet

- Elevations listed are typical of a W 4-loop plant design
- All elevations are with respect to the bottom of the core

Location	Variable	Elevation (ft)
Bottom of core (location of possible blockage)	$Z_{\text{core inlet}}$	0.0
Top of active fuel	Z_{TAF}	12.0
Bottom of hot leg	Z_{HL}	16.06
Bottom of cold leg	Z_{CL}	16.16
Spillover elevation of shortest SG tube	Z_{SG}	49.5

Available Head at Core Inlet

- Cold Leg Break

- Liquid density, $\rho = 60 \text{ lbm/ft}^3$
- Core is saturated with voiding
- The core mixture level is taken at the top of the core.
- Calculate core collapsed liquid level using an average void fraction, α , in the core:

$$\alpha = 0.50$$

- As the transient progresses
 - Voiding will decrease
 - So will core boil-off rate, which will decrease flow losses
- Using 50% with high flow losses offsets less voiding with lower flow losses

Available Head at Core Inlet

- Cold Leg Break (cont.)
 - Pressure difference available to drive flow through the core due to liquid level difference between the downcomer and core is:
 - $\Delta P_{dz} = [Z_{CL} - (1 - \alpha)(Z_{TAF} - Z_{core\ inlet})](\rho)$
 - $\Delta P_{dz} = [16.16 - (1 - 0.5)(12 - 0)](60/144) = 4.2\text{ psi}$
 - The pressure drop due to flow losses through the reactor coolant system, based on the boil-off rate, is:
 - $\Delta P_{flow} \sim 1.7\text{ psi}$
 - Total available driving head is:
 - $\Delta P_{available} = 4.2 - 1.7 = 2.5\text{ psi}$

Available Head at Core Inlet

- Hot Leg Break

- Liquid density, $\rho = 60 \text{ lbm/ft}^3$
- For conservatism, core mixture level is taken at the bottom of the hot leg with no voiding
- Pressure difference available to drive flow through the core due to liquid level difference between the downcomer and core is:
 - $\Delta P_{dz} = (Z_{SG} - Z_{HL})(\rho)$
 - $\Delta P_{dz} = (49.5 - 16.06)(60/144) = 13.9 \text{ psi}$
- With the break in the hot leg, flow losses from the core to the break are:
 - $\Delta P_{flow} \sim 0 \text{ psi}$
- Total available driving head is:
 - $\Delta P_{available} = 13.9 - 0 = 13.9 \text{ psi}$

Available Head at Core Inlet

- The available driving head at the core inlet is then:
 - Cold leg break: $\Delta P_{\text{available}} \sim 2.5 \text{ psi}$
 - Hot leg break: $\Delta P_{\text{available}} \sim 14 \text{ psi}$
- The head loss through a debris bed must be less than these values to provide reasonable assurance that the flow required to remove core decay heat will continue to reach the core.

Pressure Drop from Debris

- The head loss through a possible debris buildup at the core inlet is a function of the amount and type of debris that reaches the reactor coolant system:

$$\Delta P_{\text{debris}} = f(\text{debris type, debris amount})$$

- Multiple combinations of debris can reach the RCS.
 - The amount and combinations at any given time are related to the plant design and timing of the arrival of the various debris
 - The combination of types of materials in plants and the variability of arrival times suggest that a bounding or limiting representation is a prudent approach

Pressure Drop from Debris

- Particulates will generally be smaller than the fuel filter openings
- Consequently, a fiber bed must be present to collect the particulates at the core entrance
 - Otherwise, the particulates will simply pass through and no blockage will occur
- The following slides provide the basis for investigating the amounts of each type of debris

Fibrous Debris

- Testing of sump screens has shown small amount of fibrous debris may collect particulates and chemical precipitates to produce a large head loss
 - This bed has been called a “thin bed”
- Additionally, large fiber masses may collect large masses of particulates and chemical precipitates and generate a large head loss
 - This bed has been called a “thick bed”
- Therefore, fiber masses that must be investigated experimentally range from small to large

Particulates & Chemical Precipitates

- If sufficient amounts of particulates and chemical products are not available:
 - Voids in the fiber bed will not be filled,
 - Flow through the bed will continue
 - Core cooling is maintained
- Therefore, large volumes of particulates and chemical precipitates should also be investigated

Chemical Effects at the Core Inlet

For a postulated hot-leg break:


- Maximum flow into core results in maximum hydraulic drag on debris at core entrance
- Concentration of chemical products builds over time (demonstrated by ICET program)

Head Loss and Calcium Phosphate

- Calcium-based chemical product could form early in the accident and at elevated temperatures
- Head-loss testing at Argonne National Laboratory (ANL)
 - Test conditions:
 - NUKON fiber bed
 - Approach velocity of 0.1 ft/sec
 - Results indicate aluminum chemical products generate larger pressure drop at same concentration than calcium phosphate
- Demonstrates use of aluminum surrogates provide for a conservatively large or high head loss

LOCADM - Validation of Core “Boiler Scale” Model

- LOCADM is an automated (spreadsheet) calculation of post-LOCA material deposition
- Model conservatively assumes that all fiber and chemical products passed by the sump screen and transported to fuel surfaces by boiling will deposit
- Verification of the model performed by comparison of calculations to test data
- As shown in the comparison to the right, deposition is conservatively predicted



Fahmi Brahim, Wolfgang Augustin, Matthias Bohnet, "Numerical simulation of the fouling process" International Journal of Thermal Sciences 42 (2003) 323-334

Fuel Assembly Debris Capture Tests

- Head loss test protocol developed to support WCAP-16793-NP
- Testing will investigate:
 - Combinations of debris materials (fibrous, particulate and chemical)
 - Thin bed debris loading
- Output of test program is an acceptance criteria:
 - Maximum debris masses which, if passed through the reactor containment building sump screen, will result in an acceptable pressure drop at the core inlet
 - Plants demonstrate acceptable long term core cooling by showing that plant-specific sump screen bypass masses are bounded by the limits in the acceptance criteria

Key Features of Test Protocol

- Debris Preparation Identified
 - Fibrous debris – three size ranges
 - Particulate debris – silicone carbide 10mm \pm 2 mm
 - Chemical surrogates – WCAP-16530-NP-A
- Test Method Identified
 - Sequence of debris addition (particulate first, then fiber and chemical surrogates last)
- Test Termination Criteria Identified
 - Maximum Pressure Drop: 13 psid
 - Achieving a Steady Pressure Drop:
 - Less than 1% change in pressure drop over the last 30 minute time interval, and,
 - Minimum of 10 flume turnovers after all the debris had been inserted into the test flume.
 - Criteria to allow terminate testing if Steady Pressure Drop not reached

Debris Characteristics - Fuel Assembly Test

Fiber Sizes		
Fiber Length	Target	Range
< 500 μm	77%	67% - 87%
500 μm < 1000 μm	18%	8% - 28%
\geq 1000 μm	5%	0% - 15%

- Particulates: Silicon carbide:
 - $10^{\mu\text{m}} \pm 2^{\mu\text{m}}$
 - Small size provides for maximum lift and penetration into fiber bed

- Chemical Surrogate: Aluminum Oxyhydroxide (AlOOH)
 - Shown by Argonne National Laboratory to produce the highest pressure drop among all of the chemical precipitates
 - Ensure AlOOH surrogate meets settling criteria of WCAP-16530-NP-A and its modification in the associated SER

Fuel Assembly Debris Capture Tests

- Initial tests plan to use:
 - Vendor bottom nozzle configurations
 - Hot-leg break flow rates
 - Fiberglass, particulate and chemical surrogate debris
- Output from initial tests:
 - Selection of a limiting fuel design for further tests
 - Correlation of pressure drop between the various bottom nozzles designs of a vendor
 - Intend to evaluate if adjustments to the plan are warranted as testing is performed

Fuel Assembly Debris Capture Tests

- Debris for testing with limiting nozzle design and hot-leg flow rates:
 - Fiberglass, particulate and chemical surrogate debris
 - Fiberglass, particulate, chemical surrogate debris and calcium silicate
 - Fiberglass, particulate, chemical surrogate debris and Min-K
 - Amount of debris
 - Will be set by sump screen bypass data provided by licensees
 - Generic number of bypass per 1000 ft² of screen area not used
- NRC Involvement:
 - Test Protocol has been shared with NRC
 - Comments received and addressed
 - NRC visited and observed a test

Summary of Fibrous Debris Dimensions from Replacement Screen Bypass Testing

Plant Designation	Bypass Test Number	Distribution of Bypass Fiber Lengths				
		< 100 μm (0.0040 in)	< 300 μm (0.0118 in)	< 500 μm (0.0197 in)	< 1000 μm (0.0394 in)	> 1000 μm (0.0394 in)
A	1			63%	21%	16%
	2			66%	25%	9%
B	1			48.4%	39.3%	12.3%
C	1			63.1%	27.3%	9.6%
D	1	16%	78%			6%
	2	17%	75%			8%
	3	17%	75%			8%
	4	17%	75%			8%
	5	17%	75%			8%
E	1			50%	45%	5%
	2			89%	11%	0%
F	1			90%	10%	0%
	2			84%	14%	2.0%
	3			94.2%	4.7%	1.1%
	4			96%	4%	0%
F	1			80%	18.5%	1.5%
	2			95%	4.5%	0.5%


Cumulative numbers

from plants




Fiber Survey Data

Survey Fiber Data per Fuel Assembly




Particulate Survey Data

Particulate Survey Data per Fuel Assembly



Test Rig – Westinghouse F/A


- Assembly Height: 4 ft
- Top Nozzle
- Inconel top grid
- Intermediate grid
- Intermediate Flow Mixing (IFM) grid
- Intermediate grid
- Inconel bottom grid
- Standard p-grid
- Debris Filtering Bottom Nozzle



Test Rig – Westinghouse F/A

Close-up view of:

- First Support Grid
- Fuel Rods
- Protective Grid
- Bottom Nozzle



Test Parameters

- **Conditions for Low Particulate /Low Fiber**

- Scaled based on 193 assemblies in core
- Hot-leg flow rates 8630 gpm
- Total Particulate mass 580 lb_M
- Total Fiber mass 22.5 lb_M
- Total Chemical Precipitate mass 28 lb_M

- **Conditions for High Particulate /Low Fiber**

- Scaled based on 193 assemblies in core
- Hot-leg flow rates 8630 gpm
- Total Particulate mass 2700 lb_M
- Total Fiber mass 22.5 lb_M 0.1 lb 45g
- Total Chemical Precipitate mass 28 lb_M

Summary of First Two Tests

Data still being evaluated.

- Test CIB02
 - Particulate: 3 lb_M
 - Fiber: 53 gm
 - Chemical: 66 gm
 - Flow rate: 44.7 gpm
- Test CIB03
 - Particulate: 14 lb_M
 - Fiber: 53 gm
 - Chemical: 66 gm
 - Flow rate: 44.7 gpm
- Sequence
 - Particulate addition
 - 1 addition of 3 lb_M
 - Fibrous addition
 - 8 additions of 5 gm of fiber
 - 1 addition of 13 gm of fiber
 - Chemical addition
 - 3 additions of 11 gm of chemical surrogate
- Sequence
 - Particulate addition
 - 4 additions of 3 lb_M
 - 1 addition of 2 lb_M
 - Fibrous addition
 - 8 additions of 5 gm of fiber
 - 1 addition of 13 gm of fiber
 - Chemical addition
 - 3 additions of 11 gm of chemical surrogate

In both tests, pressure drop under 13 psid

Preliminary Test Observations

- “Thin bed” behavior not observed in tests to date
- Fiber:
 - Provides collection sites for debris
 - Is the driver for head loss
- Chemical precipitates:
 - Are another source of particulates
 - Initial results show chemical precipitates do not increase head loss
 - Rather, in some cases, some decrease in head loss observed after chemical addition
- Debris appears to be distributed at grids along the height of the bundle

Use of Core Inlet Head Loss Testing

- The test results will establish an acceptance criteria for debris in the RCS:
 - Total bypass fiber mass (lb_m)
 - Total bypass particulate mass (lb_m)
 - Total bypass chemical precipitate mass (lb_m)
- If a plant cannot meet these criteria, the following actions may be taken
 - Reduce debris load reaching RCS
 - Reduce debris generation
 - Reduce debris transport
 - Perform tests to demonstrate that the pressure drop through the plant-specific debris bed is less than the available driving head


Effect of Debris Collection on Hot Spots

- Source of heat post-LOCA is from decay heat in the fuel rod
 - This source is limited to the fuel in the rod and decreases with time
 - “Hot spots” can arise only if the local flow is severely restricted
 - Local temperature increases would be mitigated by boil-off in the region
 - Heat will be dissipated:
 - Grids act as radiators
 - Axial conduction along the fuel rod
 - Sustaining quench and replacing boil-off maintains clad temperatures $< 800^{\circ}\text{F}$
- Conservative calculations of clad temperatures demonstrate coolability of clad with deposition on clad surface and blockage at a grid:
 - High decay heat levels set by initiation of recirculation from sump
 - Between grids, chemical product and debris deposition less than 50 mils yields clad temperatures $< 800^{\circ}\text{F}$
 - Assuming no flow through the grid yields clad temperatures $< 800^{\circ}\text{F}$ behind grids

1-D Clad Hot Spot Calculations


Clad/Oxide Interface Temperature vs. Chemical Precipitate Thickness				
Chemical Precipitate Thickness (mils)	$k_{\text{precipitate}}$ (BTU/hr-ft-°F)			
	0.1	0.3	0.5	0.9
0	273°F	273°F	273°F	273°F
10	336°F	293°F	285°F	279°F
20	396°F	313°F	296°F	286°F
30	453°F	331°F	308°F	291°F
40	508°F	350°F	318°F	297°F
50	560°F	367°F	328°F	302°F

Clad/Oxide Interface Temperature vs. Chemical Precipitate Thickness		
Chemical Precipitate Thickness (mils)	$k_{\text{precipitate}} = 0.1$ BTU/hr-ft-°F	
	0.422" OD rod	0.416" OD rod
0	283.6°F	283.6°F
10	377.0°F	376.9°F
20	466.4°F	466.2°F
30	552.1°F	551.9°F
40	634.5°F	634.1°F
50	713.8°F	713.2°F



2-D Clad Hot Spot Calculations

Peak Temperatures were calculated under Grid Straps



Boric Acid Precipitation

- Following a LOCA, borated ECCS water is injected to RCS
- For a postulated **Hot Leg** break:
 - All of the cold side ECCS injection travels through the core to the break
 - No opportunity for boric acid or sodium borate to concentrate in the core
 - Therefore, these breaks are not a concern with respect to boric acid concentration
- For a postulated **Cold Leg** break:
 - Core flow is only that needed to make up for core boiling
 - Boric acid and sodium borate carry-over in steam is low; therefore they concentrate in core
- Current licensing basis calculations are in place to define the time to initiate an operator action to dilute the core

Boric Acid Precipitation and GSI-191


- To assure the licensing basis calculations will remain valid considering debris that reaches the RCS, plants meet the following conditions:
 - ½ of the RV lower plenum remains available for mixing
 - Existing Emergency Operating Procedures (EOPs) direct plant operators to initiate Hot-Leg Recirculation/Core Flushing Flow
- Based on what is currently known, once plant operators initiate Hot-Leg Recirculation/Core Flushing Flow via the EOPs:
 - Core fluid is diluted, and,
 - Mixing of the boric acid solution in the core is maintained
- The potential impact of debris on boric acid solution mixing is to be addressed in another PWR Owners Group program outside GSI-191 (Project Authorization PA-ASC-0264) *define the issue & solve it.*

Boric Acid Precipitation and GSI-191

- Defense in depth is provided by considering the following conservative assumptions used in the licensing basis boric acid precipitation calculations:
 - No credit for sump buffering agents that will neutralize the boric acid and raise the solubility limit
 - No boron carry-over in entrained liquid around the loop
 - No boron carry-over in steam
 - Appendix K decay heat (1971 ANS + 20%) used
- Defense in depth is provided by considering the following conservative assumptions used in the GSI-191 debris transport calculations:
 - All debris (fiber, particulate, & chemical) are assumed to arrive at the core inlet at the time of sump switchover
 - Core decay heat decreases with time, reducing the velocities in the RV lower plenum

Summary

- WCAP-16793-NP and supporting work ~~has~~ *may* demonstrated reasonable assurance of LTCC
- Fuel assembly testing is currently being performed to establish debris limits for plants
- Plants that can demonstrate they satisfy those limits are done; no additional action needed
- Plants that do not satisfy the limits can take remedial actions:
 - Reduce debris generation
 - Reduce debris transport
 - Perform plant-specific fuel head loss testing



U.S.NRC

UNITED STATES NUCLEAR REGULATORY COMMISSION

Protecting People and the Environment

**Status and Closure Strategy for
Generic Safety Issue (GSI) 191
Pressurized Water Reactor Sump Performance**

**Presented by:
Donnie Harrison
Office of Nuclear Reactor Regulation**


**Presented to:
Advisory Committee on Reactor Safeguards
Thermal-Hydraulics Subcommittee
September 23, 2008**



Today's Discussions

- Broad overview of current status and closure process for GL 2004-02
- Status on Technical Issues
 - Emergency Core Cooling System (ECCS) Sump Strainer Head Loss Testing
 - Chemical Effects
 - In-vessel Downstream Effects

Closure Process





End Point for Reviews

- Each licensee will provide, as applicable:
 - Responses to RAIs on the licensee’s GL supplemental submittals
 - Responses to open items identified in NRC staff audits
 - Final supplemental response after all testing and evaluations completed
 - Submittal addressing in-vessel downstream effects after WCAP-16793-NP issued



Closure Activities

- The staff reviews supplemental information/RAI responses in accordance with the closure process
- The Regions inspect implementation of modifications and other commitments
- The staff will issue a closure letter to each licensee when sufficient information is provided to close the issue for that plant
- After all licensees have been issued closure letters, GL 2004-02 will be formally closed
- Some modifications will be made after planned issue closure
 - NRC will track all commitments to completion
- The staff expects to complete all technical review activities to support closure next year



Current Status of GSI-191

- All licensees have installed significantly larger ECCS sump strainers
- Many licensees have done, or will do, other modifications, for example:
 - remove insulation
 - replace sump buffer
- Strainer testing activities have been completed for many licensees



Current Status (Continued)

- Most licensees requested extensions beyond December 2007 to complete certain corrective actions
 - Integrated head loss testing, including chemical effects
 - Downstream effects analyses
 - Plant modifications
- All plants submitted supplemental responses to GL 2004-02 in February/March 2008
- The staff is nearing completion of the review of the licensee supplemental responses




Current Review Results

- The staff has informed several licensees with “low-fiber” plants that the staff has few additional questions for those plants
- Most other plants have received, or will receive, RAIs
- “Placeholder” RAI for in-vessel downstream effects, since most plants relied on WCAP-16793-NP



Conclusion

- The staff has a process for closure of GL 2004-02
- Significant modifications to prevent unacceptable strainer blockage
- Conservative test protocols and evaluations that will show satisfactory performance of strainers
- In-vessel downstream effects resolved as part of WCAP-16793 review



U.S.NRC

UNITED STATES NUCLEAR REGULATORY COMMISSION

Protecting People and the Environment

ECCS Sump Strainer Head Loss Testing

Presented by:

Stephen Smith

Office of Nuclear Reactor Regulation

Presented to:

Advisory Committee on Reactor Safeguards

Thermal-Hydraulics Subcommittee

September 23, 2008



Strainer Testing Overview

- Strainer testing is being conducted to ensure adequate NPSH margin for ECCS and CSS pumps under accident conditions
- To be discussed:
 - Current status of testing
 - Strainer vendors and test labs
 - Staff review of GL 2004-02 responses in the head loss area
 - Areas of concern regarding head loss testing
 - Review guidance for head loss testing and evaluation
 - Path forward



Head Loss Testing Current Status

- Most strainer vendors/testers have now developed procedures that the staff agrees are capable of producing prototypical or conservative head loss results
 - Recently observed tests have had fewer issues identified than earlier tests
- Some vendors have not provided adequate assurance that their current protocols are prototypical or conservative
- Some plants are relying on testing that was conducted prior to the development of current vendor test protocols
- Staff has witnessed a number of head loss tests at each vendor
 - Lessons learned have been incorporated into staff review of licensee test activities and GL 2004-02 submittals



Head Loss Test Vendors

- Five main test vendors for U.S. PWRs
 - Alion Science and Technology
 - Atomic Energy of Canada, Limited (AECL)
 - Control Components, Incorporated (CCI) *- Switzerland*
 - General Electric – Hitachi (GEH)
 - Performance Contracting, Incorporated (PCI)
- Additional test vendors
 - Enercon Services / Wyle Laboratories
 - Westinghouse / Fauske and Associates



GL 2004-02 Responses – Head Loss Testing

- Most GL 2004-02 supplemental responses reviewed to date have had RAIs proposed in the head loss testing area
 - Few RAIs typically proposed for licensees that tested recently using updated test procedures
 - Significant RAIs proposed for plants that performed testing that is not consistent with current staff guidance for head loss testing
 - Additional testing may be necessary for some plants to adequately address these RAIs



Head Loss Testing Key Technical Issues

- Debris Preparation
- Debris Introduction
- Thin Bed Test Protocol
- Test Flume Flow Patterns



Head Loss Testing Review Guidance

- Staff Issued Updated Head Loss Testing Review Guidance in March 2008
 - Incorporates recent lessons learned from industry head loss testing discussed previously
 - Publically available
 - Tests and evaluations conducted per this guidance should result in a conservative or prototypical result that may be used for plant strainer qualification



Path Forward

- Plants that have RAIs will have to provide acceptable responses, additional analyses, or retest to assure adequate strainer performance
- Some licensees that have had unacceptable test results using conservative protocols are “testing for success” by identifying and testing several contingency plans until success is achieved, e.g.:
 - Analytical changes to reduce calculated debris loading
 - Physically removing debris sources from containment
 - Installing debris interceptors or other plant modifications
 - Plant will be modified at upcoming outage to be consistent with successful test condition

At the Movies

- CCI Debris Introduction
 - Finer debris, more uniformly covering strainer will lead to higher head losses
- CCI Chemical Debris Addition
 - Shows flow pattern in test flume
 - Illustrates modeling of strainer in test flume
 - Chemical debris increases head loss and results in debris bed compaction

CCI Test Flume Overview



- Strainer testing at CCI
- Post-drain down
- Low fiber plant
- Some clean strainer area observed following test
 - Met acceptance criteria

post drain down



- Strainer at CCI prior to chemical addition
- Fiber covers face of strainer
- Relatively low head loss






- Strainer following chemical addition
- High concentration of chemical debris suspended in fluid indicates adequate transport
- Fiber collapses into pockets
- Head loss increases




- PCI test flume overview
- Models flow near strainer
- Compared to CFD flows
- Test allows debris settlement
- Debris added 30 to 40 feet from strainer module

Comments - measure velocities?






- Example of non-prototypical debris addition
- Excessive agglomeration due to high fibrous debris concentration
- Excessive settling of debris could occur
- Agglomerated debris less likely to uniformly cover strainer
- Vendor changed debris introduction, based on staff feedback





Conclusions

- Strainer testing methods have improved
- Some licensees have demonstrated acceptable strainer performance as shown by prototypical or conservative tests
- Some licensees are working to reduce debris loads
 - Retesting with reduced debris loads is required
- Some licensees will attempt to stand on current test results by responding to staff RAIs
 - Staff will consider the additional information provided on a case by case basis




Chemical Effects Status

Paul Klein, Matt Yoder
Office of Nuclear Reactor Regulation

Chi Bum Bahn, Ken Kasza, Bill Shack, Ken Natesan
Argonne National Laboratory

ACRS Subcommittee on Thermal-Hydraulic Phenomena
September 23, 2008



Outline

- Chemical Effects Testing
 - Description of industry test approaches
 - NRC Staff assessment and technical issues
- Argonne National Laboratory (ANL) Testing to Support NRR
 - Vertical head loss loop testing
 - Bench testing
- Summary

Chemical Effects Testing Progression



- Initial chemical effects head loss testing performed in vertical head loss loops
- Industry test approach varies by strainer vendor:
 - Atomic Energy of Canada Limited (AECL) *Chalk River*
 - Alion Science and Technology
 - Control Components Inc. (CCI) *Switz*
 - General Electric Hitachi (GEH) *NJ*
 - AREVA/Performance Contracting Inc. (PCI) *-MA*
- Single licensee tests at Fauske & Associates and Wyle Laboratory

Test Methods (1): WCAP Precipitate Addition

- Precipitate generated outside the test loop. Test objective is the transport of all debris, including precipitate, to the test strainer
 - Alion – Warrenville facility
 - CCI – some licensees
 - GEH – some licensees
 - Fauske – one licensee
- Technical Issues
 - Verification of acceptable precipitate settlement rates
 - Verification that plant specific debris and chemical precipitate transport to the test strainer occurs
- Staff Assessment – WCAP-16530 methodology is acceptable to the staff, safety evaluation report issued December 2007.

Test Methods (2): WCAP Precipitate with Settling

- Precipitate generated outside test loop. The test approach allows for representative settling of debris, including precipitate, upstream of the test strainer.
 - GEH – some licensees
 - AREVA/PCI
- Technical Issues
 - Representative/conservative flume flow characteristics
 - Precipitate settlement characteristics
- Staff Assessment – acceptable to the staff, provided flume flow characteristics are justified and a more restrictive precipitate settlement acceptance criterion is met

Test Methods (3): In-Situ Precipitate Formation

- Precipitate generated by addition of dissolved aluminum, calcium, and silicates to test flume containing borated, buffered water simulating plant-specific environment
 - CCI – some licensees

- Technical Issues
 - Argonne Laboratory testing ANL tests showed precipitate characteristics can be sensitive to local concentration effects during addition of chemicals
 - Precipitate transport to the strainer

- Staff Assessment – staff is evaluating on a licensee specific basis. Licensee to demonstrate adequacy of precipitate formation process

Test Methods (4): Long Term Chemical Addition

- Thirty day tests with simulated post-LOCA environment (e.g., borated, buffered water). Dissolved aluminum additions to the loop over time to match the plant specific chemistry
 - AECL
 - Wyle Laboratory
- Technical Issues
 - Transport of non-chemical debris to the strainer (Wyle)
 - Adequacy of the debris bed formed on the strainer
 - Technical basis for plant-specific chemical additions
- Staff Assessment – staff is reviewing on a licensee specific basis. Licensee to demonstrate why test conservatively evaluates chemical effects

Test Methods (5): Long Term Leaching Test

- Thirty day tests with chemistry developed by leaching from debris interaction with the simulated LOCA environment
 - Alion - VUEZ facility

- Technical Issues
 - Adequacy of the debris bed formed on the strainer
 - Validity of chemical effects factor developed from these tests

- Staff Assessment – based on questions, including non-chemical debris bed formation, the staff has concluded that an alternate approach is needed




ANL Technical Support to NRR

- Given the varied industry approach to chemical effects testing, NRR requested technical support from Argonne National Laboratory
 - Compare head losses from:
 - (1) WCAP-16530 precipitate,
 - (2) precipitate formed by corrosion of aluminum coupons,
 - (3) precipitate from chemical additions

- Evaluate the long term solubility of aluminum in alkaline, borated solutions, including potential effects of thermal cycling



- Evaluate the stability of WCAP-16530 AlOOH precipitate as a function of pH



References


- ANL Technical Letter Reports covered in this presentation
 - C. B. Bahn, K. E. Kasza, W. J. Shack, and K. Natesan, *Technical Letter Report on Evaluation of Chemical Effects: Studies on Precipitates Used in Strainer Head Loss Testing*, ADAMS Accession No. ML080600180, U.S. Nuclear Regulatory Commission, Washington D.C., January 2008.
 - C. B. Bahn, K. E. Kasza, W. J. Shack, and K. Natesan, *Technical Letter Report on Evaluation of Long-term Aluminum Solubility in Borated Water Following a LOCA*, ADAMS Accession No. ML081550043, U.S. Nuclear Regulatory Commission, Washington D.C., February 2008.
 - C. B. Bahn, K. E. Kasza, W. J. Shack, and K. Natesan, *Technical Letter Report on Evaluation of Head Loss by Products of Aluminum Alloy Corrosion*, ADAMS Accession No. ML082330153, U.S. Nuclear Regulatory Commission, Washington D.C., August 2008.

Head Loss Testing – WCAP Aluminum Oxyhydroxide (top) Sodium Aluminum Silicate (bottom)




- The median particle size of WCAP SAS surrogate is ~ 3 times bigger than that of WCAP AIOOH.
- This surrogate is not as stable as WCAP AIOOH surrogate in high purity water.
- WCAP AIOOH and SAS surrogates caused significant head loss with the amount equivalent to 1.5 and 2 ppm Al, respectively.

Head Loss Tests With Aluminum Coupons




Al 6061 BSE Image





Al 1100 BSE Image

- Coupons suspended in test loop at 140°F and 9.3 pH
- Al alloy plates have intermetallic particles such as (FeAl), (FeSiAl), (FeCuAl)
- Alloy 6061 intermetallic particle size (max. $\sim 10 \mu\text{m}$) is larger than Alloy 1100 (max. $\sim 4 \mu\text{m}$)




Head Loss Tests w/ Al Alloy 6061



Alloy 6061 Test Bed

- Intermetallic particles released by corrosion of the alloy matrix caused head loss at 140 F even though dissolved Al was below the solubility limit; additional head loss was experienced due to the formation of $\text{Al}(\text{OH})_3$ when the temperature was decreased




Vertical Loop Test Results

- Industry Test Precipitates Characteristics
 - Per unit mass of Al removed from the solution, the WCAP AlOOH surrogate appears to be more efficient in increasing head loss than the $\text{Al}(\text{OH})_3$ formed by corrosion of Al.


- Efficiency in increasing head loss for ANL test conditions:
 - WCAP AlOOH
 - WCAP Sodium Aluminum Silicate – “tap water”
 - In-situ formation $\text{Al}(\text{OH})_3$, CCI approach
 - 6061 Aluminum, 1100 Aluminum
 - WCAP Sodium Aluminum Silicate – high purity water

Aluminum Hydroxide Solubility




- Aluminum solubility in borated water was studied for a typical ECCS mission time.
- Temperature was varied with time to simulate long-term cooling with thermal cycling to simulate ECCS fluid temperature change passing through heat exchanger and reactor core
- 30-minute thermal cycles over temperature ranges of 140-80 F, 120-80 F, and 100-80 F did not cause aluminum hydroxide precipitation from a solution at pHs ranging 7.0-8.5 and total Al concentrations ranging 45-98 ppm


Long-Term Aluminum Hydroxide Precipitation Tests



(pH=7.0)




(pH=7.50)



(pH=8.0)

Test Solution pH @ 98 ppm Al



(98 ppm)



(70 ppm)




(55 ppm)



(40 ppm)


Total Al Contents @ pH=7.5 & 120 F


Long-term Al Hydroxide Precipitation Tests: Al Hydroxide Precipitation Map



- Long-term solubility test results for various pHs and Al concentrations represented in a Al hydroxide precipitation map that plots pH and Al concentration vs. temperature.
- Solubility increases with pH and temperature
- Loop tests with Al alloy plates seem to suggest lower solubility than the chemical Al tests. This may be due to heterogeneous nucleation of Al hydroxide on intermetallic particles and/or on the surfaces of preexisting precipitates.

Aluminum Solubility as a Function of Temperature and pH (includes Al coupons test)





ANL Tests - Summary

- Vertical head loss loop test results have helped the NRC staff understand the relative performance of different industry chemical effects test methods
- Aluminum intermetallics can influence head loss (particulate and possible precipitate nucleation site) causing about a factor of two reduction in solubility curves
- Longer term aluminum solubility test results will help inform the staff's review of plant-specific chemical effects evaluations
- Vertical loop head loss test with a glass fiber bed at pH=9.0 showed the WCAP AlOOH surrogate was stable over 5 days. At elevated pH, the equivalent of 3.0 ppm aluminum precipitating was needed to produce significant head loss.

Summary – Chemical Effects Status

- NRC Staff has observed tests at each vendor facility
- Vertical head loss loop tests are typically more susceptible to large head losses from chemical precipitates compared to larger scale strainer tests
- Most plants are using test methods that are acceptable to the staff, although some technical issues remain that will be resolved with individual licensees
- Testing at Argonne and at vendor facilities continues to indicate that the WCAP-16530-NP methodology is conservative with respect to the amount and the properties of precipitates
- NRC staff to perform a few chemical effects audits to assess overall evaluations at selected plants
- NRR and RES staff working on remaining peer review items



United States Nuclear Regulatory Commission

Protecting People and the Environment

Chemical Effects PIRT Update

John Burke

Rob Tregoning

Office of Nuclear Regulatory Research

ACRS Subcommittee on Thermal-Hydraulic Phenomena

September 23, 2008

Chemical Effects PIRT-Background

- PIRT exercise conducted in mid 2006.
- PIRT was used to identify knowledge gaps existing at that time.
 - The focus was on phenomena not previously addressed by NRC-sponsored research
 - 41 phenomena were ranked as having potential high significance by at least one PIRT panelist
 - No issues were identified that warranted immediate action
 - The PIRT NUREG report is in final review.

Chemical Effects: Evaluation of PIRT Results

- The 41 phenomena ranked as having the highest potential significant impact on ECCS performance were reviewed by a staff working group
 - Assess potential impact on ECCS performance
 - Determine if the phenomenon was already being addressed by current or planned activities.

Chemical Effects: Evaluation of PIRT Results

- Staff concluded that 10 topic areas warranted additional study
- A separate NUREG/CR scoping study was prepared by PNNL to document the evaluation of these 10 topic areas.
- The 10 topic areas are as follows

Chemical Effects PIRT Review

1. Radiation effects (radiolysis)*
2. Carbonation of concrete
3. Alloy corrosion
4. Galvanic corrosion
5. Biological fouling *
6. Co-precipitation & other synergistic solids formation *
7. Inorganic agglomeration*
8. Crud release
9. Retrograde solubility and solids deposition*
10. Organic materials*

* PNNL recommended additional evaluation/study to more fully understand these phenomena

Chemical Effects: Evaluation of PIRT Results

Radiation: Effects of the post-LOCA radiation on the sump chemical environment and constituents (e.g., irradiation from fuel in the reactor vessel, and activated species in containment pool and on the strainer).

- The study concluded radiation effects on sump pool pH were minor in comparison with effects of pH buffering.
- However, knowledge of radiation influence on redox potential is limited and is a complex phenomenon.
 - Mixed potential modeling could be used to further assess it.

Chemical Effects: Evaluation of PIRT Results

- Biological Fouling: Fouling of the ECCS sump strainer due to bacterial, algal, fungal or other biological growth during the 30-day post-LOCA mission time.
 - There are many stressors to biological growth in a post-LOCA environment, e.g. rapid temperature change, borated water, no light, high radiation fields, low levels of available carbon, etc.
 - However, there are microbes that are known to exist under one or more of these stressors. Growth rate under combined stressors during a 30-day mission time is unknown.

Chemical Effects Evaluation of PIRT

Results

- Crud Release: Effects related to potential post-LOCA metal oxide releases from fuel cladding or RCS components.
 - Crud burst during a LOCA is expected to consist of relatively dense solid particulates.
 - The quantity is expected to be small compared with other debris particulate (e.g., insulation or coating debris)
 - The additional effect of crud release is considered to be insignificant unless other particulate sources are inconsequential

Chemical Effects : Path Forward

- Staff continues to disposition all the phenomena originally identified in the PIRT.
- The significance of several phenomena is currently being assessed
 - Again, none of these phenomena were evaluated as warranting immediate action.
 - Initial scoping study has been conducted
 - Additional evaluation may be used to assess remaining uncertainties
- As part of the disposition staff is also considering
 - Plant-specific post-LOCA environments and conditions
 - Results from additional vendor testing conducted since the conclusion of this scoping study
 - Conservatisms that have been used to address GL 2004-02.



United States Nuclear Regulatory Commission

Protecting People and the Environment

In-Vessel Downstream Effects Fuel Inlet Blockage

Presented by:

Stephen Smith (NRR)

William Krotiuk (RES)

Office of Nuclear Reactor Regulation

Presented to:

Advisory Committee on Reactor Safeguards

Thermal-Hydraulics Subcommittee

September 23, 2008

Fuel Blockage Testing and Considerations

- Fuel Inlet Designs
- Debris at Fuel Inlet
 - Fibrous
 - Particulate
 - Chemical
- Industry Testing
 - Early CE Guardian Grid
 - Diablo Canyon
 - PWROG
- RES Analytical Models

Fuel Inlet Designs

- Westinghouse
 - P-Grid
 - Alternate P-Grid
 - Guardian Grid (CE)
- Areva
 - Fuelguard™
 - Trapper™ Coarse Mesh
 - Trapper™ Fine Mesh

Fuel Inlet Designs

- Diablo Canyon performed significant testing for the Alternate P-grid
- Diablo canyon specific testing also showed that P-grid develops higher dP than Alternate P-Grid
- P-Grid, Guardian Grid, and Alternate P-Grid do not appear susceptible to thin bed based on inlet area, however, a thin bed type phenomenon could occur at several locations in the fuel assembly
- Areva designs have not been tested yet

Debris at Fuel Inlet

- Debris load is plant specific
- Fibrous bypass (pass through) determined by strainer testing
- Fibrous test debris characteristics are similar to actual bypassed debris
- Testing to date has assumed no filtering of particulate or chemical debris by strainer
 - This is a conservative assumption because some debris will filter out on the strainer
 - Chemical loading determined per WCAP-16530

Strainer Fiber Bypass Testing

- Vendor Specific
- Staff expects testing to be prototypical or conservative
- Generally performed with fiber only, which is conservative


Industry Fuel Inlet Testing to Date

- **Early Testing of Guardian Grid**
 - Documentation Missing (no dP data)
 - Questionable debris preparation
- **Diablo Canyon Testing of Alternate P-grid**
 - More details on following slides
- **PWROG Generic Test**
 - Used 3 inch diameter cylinder with screen
 - Likely conservative with respect to Westinghouse/CE designs
 - Degree of conservatism not yet established
- **PWROG Fuel Specific Test**
 - More details on following slides


Diablo Canyon Testing

- Westinghouse Alternate P-grid
- Testing Performed at CDI
- Witnessed by staff
- Prototypical Debris for Plant
- Varied Debris Loads
- Bottom Nozzle and One Intermediate Grid Strap
- Hot Leg and Cold Leg Flows Tested
- Tested head losses were within allowable limits


CDI Diablo Canyon Test Loop




Fuel Assembly Model in Test Column




Diablo Bottom Nozzle Pre-Test




Diablo Test Unit Pre-Test




Diablo Bottom Nozzle Post-Test



Diablo Test Unit Post-Test



Bottom Nozzle and P-Grid



Diablo Canyon Debris

- Debris Types
 - Nukon
 - Dirt Mixture
 - Marinite
 - Silicon Carbide
 - Calcium Silicate
 - Aluminum Oxyhydroxide
 - Sodium Aluminum Silicate
- Tested combinations of debris loads that conservatively bound plant conditions

PWROG Testing


- Staff observed testing at Westinghouse
- Standard P-grid was tested
- Testing used hot leg break flow rate
- Debris preparation and introduction was acceptable
 - Observed only fiber and particulate introduction
 - Chemical precipitate settlement was acceptable
- Observations indicate that test program can result in prototypical or conservative results
- Other Westinghouse designs will be tested to ensure that results are bounded
- Testing of Areva fuel designs to be conducted in the future
- PWROG plans to increase debris loads to bound as many plants as possible
- Staff will continue to review data and test information as it becomes available

Office of Research Core Blockage Assessment

- **RES performed a core blockage assessment**
 - In response to ACRS concerns regarding treatment of core inlet blockage in industry models
 - Assumes uniform debris bed across core inlet instead of a percentage of open area
 - Bill Krotiuk to present the assessment

PWR Core Blockage Assessment

- Calculations performed for Typical Four Loop PWR Plant
 - TRACE Calculation
 - Full primary and secondary system
 - Core has 8 radial, 4 ring and 14 elevation segments.
 - No bypass flow between core and volume outside baffles.
 - 80% double ended cold leg break
 - Full HP and LP injection
 - Recirculation starts at 1200 sec.
 - Independent Hand Calculation
 - Considers one and two-phase core and vessel flow resistances.



PWR Core Blockage Assessment

- Uniform Nukon/CalSil debris bed thicknesses assumed instantaneously present at core entrance at recirculation start.
 - Cases analyzed
 - Unblocked
 - Nominal 1.2 inch thick Nukon/CalSil bed
 - Nominal 2.4 inch thick Nukon/CalSil bed
 - Nominal 4.8 inch thick Nukon/CalSil bed
 - Debris bed form loss coefficient relation developed from test data.
 - $\Delta p_{\text{bed}} = f(\text{bed thickness, approach velocity})$
- Two analysis methods used.
 - TRACE code version developed to use debris bed loss coefficient.
 - Transient calculation run to 2600 s after start of LOCA.
 - Independent Hand Calculation performed at
 - 1200 s (start of recirculation)
 - 2000 s

PWR Core Blockage Assessment

- **Results**

- TRACE Calculation

Nominal Nukon/CalSil Debris Bed Thickness (inch)	Peak Clad Temperature Following Recirculation (°K)	Peak Clad Temperature Following Recirculation (°F)
Unblocked	410.0	278.3
1.2	411.0	280.1
2.4	411.7	281.3
4.8	787.5	957.8

- Core uncovery and clad heat-up occurs for debris bed thicknesses greater than critical thickness value (between 2.4 and 4.8 inches).

- Independent Hand Calculation

- Good agreement with TRACE calculation
 - Void fraction at core outlet reaches 100% at 2000 s for 4.8 inch bed; therefore core heat-up is possible.

Conclusions

- Westinghouse and CE fuel testing is currently underway
- Areva fuel testing is scheduled to begin later this year.
- Testing will determine acceptable debris loading for various fuel designs, postulated conditions, and debris mixtures