

ArevaEPRDCPEm Resource

From: Pederson Ronda M (AREVA NP INC) [Ronda.Pederson@areva.com]
Sent: Thursday, July 16, 2009 1:57 PM
To: Tesfaye, Getachew
Cc: BENNETT Kathy A (OFR) (AREVA NP INC); DELANO Karen V (AREVA NP INC); NOXON David B (AREVA NP INC)
Subject: Response to U.S. EPR Design Certification Application RAI No. 227, FSAR Ch 19, Supplement 1
Attachments: RAI 227 Supplement 1 Response US EPR DC.pdf

Getachew,

AREVA NP Inc. provided responses to 12 of the 20 questions of RAI No. 227 on July 6, 2009. The attached file, "RAI 227 Supplement 1 Response U.S. EPR DC" provides a technically correct and complete response to one of the remaining 8 questions.

Appended to this file are affected pages of the U.S. EPR Final Safety Analysis Report in redline-strikeout format which support the response to RAI 227 Question 19-285.

The following table indicates the respective pages in the response document, "RAI 227 Supplement 1 Response U.S. EPR DC," that contain AREVA NP's response to the subject questions.

Question #	Start Page	End Page
RAI 227 — 19-285	2 A-1 B-1	3 A-90 B-130

A complete answer is not provided for 7 of the 20 questions. The schedule for a technically correct and complete response to these questions was provided previously and remains as indicated below.

Question #	Response Date
RAI 227 — 19-284	September 18, 2009
RAI 227 — 19-287	September 18, 2009
RAI 227 — 19-292	September 18, 2009
RAI 227 — 19-293	September 18, 2009
RAI 227 — 19-294	September 18, 2009
RAI 227 — 19-295	September 18, 2009
RAI 227 — 19-298	August 28, 2009

Sincerely,

Ronda Pederson

ronda.pederson@areva.com

Licensing Manager, U.S. EPR Design Certification

AREVA NP Inc.

An AREVA and Siemens company

3315 Old Forest Road

Lynchburg, VA 24506-0935

Phone: 434-832-3694

Cell: 434-841-8788

From: WELLS Russell D (AREVA NP INC)
Sent: Monday, July 06, 2009 6:08 PM
To: 'Getachew Tesfaye'
Cc: Pederson Ronda M (AREVA NP INC); BENNETT Kathy A (OFR) (AREVA NP INC); DELANO Karen V (AREVA NP INC)
Subject: Response to U.S. EPR Design Certification Application RAI No. 227, FSAR Ch 19

Getachew,

Attached please find AREVA NP Inc.'s response to the subject request for additional information (RAI). The attached file, "RAI 227 Response US EPR DC.pdf" provides technically correct and complete responses to 12 of the 20 questions.

Appended to this file are affected pages of the U.S. EPR Final Safety Analysis Report in redline-strikeout format which support the response to RAI 227 Questions 19-299 and 19-300.

The following table indicates the respective pages in the response document, "RAI 227 Response US EPR DC.pdf," that contain AREVA NP's response to the subject questions.

Question #	Start Page	End Page
RAI 227 — 19-284	2	3
RAI 227 — 19-285	4	4
RAI 227 — 19-286	5	5
RAI 227 — 19-287	6	6
RAI 227 — 19-288	7	10
RAI 227 — 19-289	11	11
RAI 227 — 19-290	12	12
RAI 227 — 19-291	13	13
RAI 227 — 19-292	14	14
RAI 227 — 19-293	15	15
RAI 227 — 19-294	16	16
RAI 227 — 19-295	17	17
RAI 227 — 19-296	18	19
RAI 227 — 19-297	20	22
RAI 227 — 19-298	23	23
RAI 227 — 19-299	24	26
RAI 227 — 19-300	27	32
RAI 227 — 19-301	33	33
RAI 227 — 19-302	34	35
RAI 227 — 19-303	36	37

A complete answer is not provided for 8 of the 20 questions. The schedule for a technically correct and complete response to these questions is provided below.

Question #	Response Date
RAI 227 — 19-284	September 18, 2009
RAI 227 — 19-285	July 20, 2009
RAI 227 — 19-287	September 18, 2009
RAI 227 — 19-292	September 18, 2009
RAI 227 — 19-293	September 18, 2009
RAI 227 — 19-294	September 18, 2009

RAI 227 — 19-295	September 18, 2009
RAI 227 — 19-298	August 28, 2009

(Russ Wells on behalf of)

Ronda Pederson

ronda.pederson@areva.com

Licensing Manager, U.S. EPR Design Certification

New Plants Deployment

AREVA NP, Inc.

An AREVA and Siemens company

3315 Old Forest Road

Lynchburg, VA 24506-0935

Phone: 434-832-3694

Cell: 434-841-8788

From: Getachew Tesfaye [mailto:Getachew.Tesfaye@nrc.gov]

Sent: Friday, June 05, 2009 3:29 PM

To: ZZ-DL-A-USEPR-DL

Cc: Theresa Clark; Hanh Phan; Edward Fuller; Lynn Mrowca; Prosanta Chowdhury; Joseph Colaccino; ArevaEPRDCPEm Resource

Subject: U.S. EPR Design Certification Application RAI No. 227 (2564, 2598),FSAR Ch. 19

Attached please find the subject requests for additional information (RAI). A draft of the RAI was provided to you on May 15, 2009, and discussed with your staff on May 29, 2009. Draft RAI Questions 19-296, 19-300, and 19-302 were modified as a result of that discussion. The schedule we have established for review of your application assumes technically correct and complete responses within 30 days of receipt of RAIs. For any RAIs that cannot be answered within 30 days, it is expected that a date for receipt of this information will be provided to the staff within the 30 day period so that the staff can assess how this information will impact the published schedule.

Thanks,

Getachew Tesfaye

Sr. Project Manager

NRO/DNRL/NARP

(301) 415-3361

Hearing Identifier: AREVA_EPR_DC_RAIs
Email Number: 667

Mail Envelope Properties (5CEC4184E98FFE49A383961FAD402D310110FAC3)

Subject: Response to U.S. EPR Design Certification Application RAI No. 227, FSAR Ch
19, Supplement 1
Sent Date: 7/16/2009 1:57:08 PM
Received Date: 7/16/2009 1:57:12 PM
From: Pederson Ronda M (AREVA NP INC)

Created By: Ronda.Pederson@areva.com

Recipients:

"BENNETT Kathy A (OFR) (AREVA NP INC)" <Kathy.Bennett@areva.com>
Tracking Status: None
"DELANO Karen V (AREVA NP INC)" <Karen.Delano@areva.com>
Tracking Status: None
"NOXON David B (AREVA NP INC)" <David.Noxon@areva.com>
Tracking Status: None
"Tesfaye, Getachew" <Getachew.Tesfaye@nrc.gov>
Tracking Status: None

Post Office: AUSLYNCMX02.adom.ad.corp

Files	Size	Date & Time
MESSAGE	5217	7/16/2009 1:57:12 PM
RAI 227 Supplement 1 Response US EPR DC.pdf		455270

Options

Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

Response to

**Request for Additional Information No. 227 (2564, 2598), Supplement 1
6/05/2009**

U. S. EPR Standard Design Certification

AREVA NP Inc.

Docket No. 52-020

SRP Section: 19 - Probabilistic Risk Assessment and Severe Accident Evaluation

Application Section: 19

**QUESTIONS for PRA Licensing, Operations Support and Maintenance Branch 1
(AP1000/EPR Projects) (SPLA)**

Question 19-285:

(Follow-up to Question 19-125) The significant sequences (i.e., those with a sequence frequency greater than 1 percent of internal events or shutdown core damage frequency (CDF) or those that have an aggregate contribution of 95 percent of CDF when ranked by frequency) provided in response to Question 19-125 yield different insights than the cutset groups listed in FSAR Table 19.1-7. For example:

- The response to Question 19-125 states that sequence 14 in the loss-of-offsite-power (LOOP) event tree has a sequence frequency of $8.58E-8$ per year (/yr), about 30 percent of the internal events point estimate for CDF. In comparison, the first cutset group in FSAR Table 19.1-7 includes cutsets from this sequence that are included in the top 100 cutsets, and represents only about 19 percent of the internal events CDF.
- The top five cutset groups based on the percent contributions listed in FSAR Table 19.1-7 are 1 (LOOP-14), 9 (SLOCA-17), 17 (ATWS-12), 8 (SLOCA-34), and 18 (GT-15). In contrast, the top five sequences based on the response to Question 19-125 are LOOP-14, GT-15, SLOCA-17, SLOCA-34, and LOOP-45.

The staff uses the significant cutsets and sequences to communicate important scenarios both to other reviewers and to the public in the Safety Evaluation Report (SER). In addition, the staff uses individual cutsets to understand the modeling of systems and operator actions. Therefore, the staff needs to see both cutsets and sequences and understand the reasons for any discrepancies in the rankings.

- a. Revise the FSAR to include a ranking of significant sequences (those provided in response to Question 19-125), with a description of each. The representative cutsets and sequence descriptions currently provided in FSAR Table 19.1-7 are one way of describing the sequences.
- b. Provide (in the RAI response only) the top 10 cutsets for each significant sequence, or the cutsets contributing 95 percent to the sequence frequency, whichever is less.
- c. Provide (in the RAI response only) the top 200 core damage cutsets for internal events, internal fire, internal flooding, shutdown, and the total at-power and shutdown model.

Response to Question 19-285:**Response to Question 19-285a:**

The following tables (with table descriptions added to the sections where they are referenced) will be added to the U.S. EPR FSAR:

- Table 19.1-127—U.S. EPR Important Sequences – Level 1 Internal Events (Referenced in Section 19.1.4.1.2.3).
- Table 19.1-128—U.S. EPR Important Sequences – Level 1 Flooding Events (Referenced in Section 19.1.5.2.2.3).
- Table 19.1-129—U.S. EPR Important Sequences – Level 1 Fire Events (Referenced in Section 19.1.5.3.2.3).
- Table 19.1-130—U.S. EPR Important Sequences – Level 1 Shutdown (Referenced in Section 19.1.6.2.3).

Response to Question 19-285b:

The top 10 cutsets (or fewer if cutsets contribute to at least 95 percent of sequence frequency) for each significant sequence for internal events, internal fire, internal flooding, and shutdown are provided in Appendix A to this response.

Response to Question 19-285c:

The top 200 core damage cut sets for internal events, internal fire, internal flooding, shutdown, and total at-power are provided in Appendix B to this response.

FSAR Impact:

U.S. EPR FSAR Tier 2, tables 19.1-127, 19.1-128, 19.1-129, and 19.1-130 will be added as described in the response to 19-285a and indicated on the enclosed markup.

U.S. EPR FSAR, Tier 2, Sections 19.1.4.1.2.3, 19.1.5.2.2.3, 19.1.5.3.2.3 and 19.1.6.2.3 will be revised as described in the response and indicated on the enclosed markup.

**Response to
Request for Additional Information No. 227**

**Question 19-285
Appendix A
Top 10 Cutsets for Significant Sequences**

Minimal Cutsets

Top Event probability Q = 9.359E-09

No.	Prob.	%	Event	Description
1	3.932E-09	42.01	IE LOMFW STUCK ROD	Initiator - Total Loss of Main Feedwater Stuck Control Rods
2	3.325E-09	35.53	IE LOC STUCK ROD	Initiator - Loss of Main Condenser (Includes MSIV Closure etc.) Stuck Control Rods
3	2.083E-09	22.25	IE LBOP STUCK ROD	Initiator - Loss of Balance of Plant - Closed Loop Cooling Water or Aux Cooling Water Stuck Control Rods

Minimal Cutsets

Top Event probability Q = 6.780E-09

No.	Prob.	%	Event	Description
1	4.112E-10	6.07	IE GT	Initiator - General Transient (Includes Turbine Trip and Reactor Trip)
			LOOPCON+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram
			XKA10____DFR_D -ALL	CCF of EDGs to Run
			XKA50____DFR	ELEC, SBO Diesel Generator XKA50, Fails to Run
			XKA80____DFR	ELEC, SBO Diesel Generator XKA80, Fails to Run
2	3.959E-10	5.84	IE GT	Initiator - General Transient (Includes Turbine Trip and Reactor Trip)
			BTD01_BAT__ST_D -ALL	CCF of Safety Related Batteries on Demand
			LOOPCON+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram
3	3.024E-10	4.46	IE GT	Initiator - General Transient (Includes Turbine Trip and Reactor Trip)
			EFWS PM1	EFWS Train 1 Unavailable due to Preventive Maintenance
			LOOPCON+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram
			XKA10____DFR_D -ALL	CCF of EDGs to Run
			XKA80____DFR	ELEC, SBO Diesel Generator XKA80, Fails to Run
4	3.024E-10	4.46	IE GT	Initiator - General Transient (Includes Turbine Trip and Reactor Trip)
			EFWS PM4	EFWS Train 4 Unavailable due to Preventive Maintenance
			LOOPCON+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram
			XKA10____DFR_D -ALL	CCF of EDGs to Run
			XKA50____DFR	ELEC, SBO Diesel Generator XKA50, Fails to Run
5	3.024E-10	4.46	IE GT	Initiator - General Transient (Includes Turbine Trip and Reactor Trip)
			LOOPCON+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram
			SBODG5 PM1	SBO-DG Train 1 Unavailable due to Preventive Maintenance
			XKA10____DFR_D -ALL	CCF of EDGs to Run
			XKA80____DFR	ELEC, SBO Diesel Generator XKA80, Fails to Run
6	3.024E-10	4.46	IE GT	Initiator - General Transient (Includes Turbine Trip and Reactor Trip)
			LOOPCON+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram
			SBODG8 PM4	SBO-DG Train 4 Unavailable due to Preventive Maintenance
			XKA10____DFR_D -ALL	CCF of EDGs to Run
			XKA50____DFR	ELEC, SBO Diesel Generator XKA50, Fails to Run

GT:0014

No.	Prob.	%	Event	Description
7	2.186E-10	3.22	IE GT LOOPCON+REC XKA10____DFR_D CCF of EDGs to Run -ALL XKA50____DFR_B CCF of SBO DGs to Run -ALL	Initiator - General Transient (Includes Turbine Trip and Reactor Trip) Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram
8	1.352E-10	1.99	IE GT CL-TXS-OSCCF LOOPCON+REC	Initiator - General Transient (Includes Turbine Trip and Reactor Trip) SW CCF of TXS operating system or multiple diversity groups Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram
9	8.978E-11	1.32	IE GT LAS11AP001EFR LOOPCON+REC XKA10____DFR_D CCF of EDGs to Run -ALL XKA80____DFR	Initiator - General Transient (Includes Turbine Trip and Reactor Trip) EFWS, Train 1 Motor Driven Pump LAS11AP001, Fails to Run Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram ELEC, SBO Diesel Generator XKA80, Fails to Run
10	8.978E-11	1.32	IE GT LAS41AP001EFR LOOPCON+REC XKA10____DFR_D CCF of EDGs to Run -ALL XKA50____DFR	Initiator - General Transient (Includes Turbine Trip and Reactor Trip) EFWS, Train 4 Motor Driven Pump LAS41AP001, Fails to Run Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram ELEC, SBO Diesel Generator XKA50, Fails to Run

Minimal Cutsets

Top Event probability Q = 2.018E-08

No.	Prob.	%	Event	Description
1	2.715E-09	13.45	IE GT	Initiator - General Transient (Includes Turbine Trip and Reactor Trip)
			LOOPCON+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			QKA10GH001_FS_B-ALL	CCF of the Air Cooled SCWS Chiller Units to Start
2	2.555E-09	12.66	IE GT	Initiator - General Transient (Includes Turbine Trip and Reactor Trip)
			LOOPCON+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			QKA10GH001_FS	SCWS, Train 1 Chiller Unit QKA10GH001, Fails to Start on Demand
			SAC04/QKA40 PM4	Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance
3	2.555E-09	12.66	IE GT	Initiator - General Transient (Includes Turbine Trip and Reactor Trip)
			LOOPCON+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			QKA40GH001_FS	SCWS, Train 4 Chiller Unit QKA40GH001, Fails to Start on Demand
			SAC01/QKA10 PM1	Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
4	4.126E-10	2.04	IE GT	Initiator - General Transient (Includes Turbine Trip and Reactor Trip)
			LOOPCON+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			QKA10GH001_FS	SCWS, Train 1 Chiller Unit QKA10GH001, Fails to Start on Demand
			QKA40GH001_FS	SCWS, Train 4 Chiller Unit QKA40GH001, Fails to Start on Demand
5	3.908E-10	1.94	IE GT	Initiator - General Transient (Includes Turbine Trip and Reactor Trip)
			LOOPCON+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			QKA10GH001_FR_B-ALL	CCF of the Air Cooled SCWS Chiller Units to Run
6	3.677E-10	1.82	IE GT	Initiator - General Transient (Includes Turbine Trip and Reactor Trip)
			LOOPCON+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			QKA40GH001_FR	SCWS, Train 4 Chiller Unit QKA40GH001, Fails to Run
			SAC01/QKA10 PM1	Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance

GT:0015

No.	Prob.	%	Event	Description
7	3.677E-10	1.82	IE GT LOOPCON+REC OPF-SAC-2H QKA10GH001_FR SAC04/QKA40 PM4	Initiator - General Transient (Includes Turbine Trip and Reactor Trip) Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram Operator Fails to Recover Room Cooling Locally SCWS, Train 1 Chiller Unit QKA10GH001, Fails to Run Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance
8	3.428E-10	1.70	IE GT 31BTD01_BATST LOOPCON+REC OPF-SAC-2H SAC04/QKA40 PM4	Initiator - General Transient (Includes Turbine Trip and Reactor Trip) ELEC, 250V 1E 2-hr Battery 31BTD01, Fails on Demand Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram Operator Fails to Recover Room Cooling Locally Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance
9	3.428E-10	1.70	IE GT 34BTD01_BATST LOOPCON+REC OPF-SAC-2H SAC01/QKA10 PM1	Initiator - General Transient (Includes Turbine Trip and Reactor Trip) ELEC, 250V 1E 2-hr Battery 34BTD01, Fails on Demand Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram Operator Fails to Recover Room Cooling Locally Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
10	2.029E-10	1.01	IE GT LOOPCON+REC OPF-SAC-2H QKA40AP107EFS SAC01/QKA10 PM1	Initiator - General Transient (Includes Turbine Trip and Reactor Trip) Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram Operator Fails to Recover Room Cooling Locally SCWS, Train 4 Motor Driven Safety Chiller Pump QKA40AP107, Fails to Start on Demand Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance

LOOP:0011

Minimal Cutsets

Top Event probability Q = 6.389E-09

No.	Prob.	%	Event	Description
1	2.260E-10	3.54	IE LOOP	Initiator - Loss Of Offsite Power
			BTD01_BAT__ST_D	CCF of Safety Related Batteries on Demand -124
			CCWS/ESWS PM3	CCWS/ESWS Train 3 Pump Unavailable due to Preventive Maintenance
			REC OSP 2HR	Failure to Recover Offsite Power Within 2 Hours
2	2.260E-10	3.54	IE LOOP	Initiator - Loss Of Offsite Power
			BTD01_BAT__ST_D	CCF of Safety Related Batteries on Demand -134
			CCWS/ESWS PM2	CCWS/ESWS Train 2 Pump Unavailable due to Preventive Maintenance
			REC OSP 2HR	Failure to Recover Offsite Power Within 2 Hours
3	1.507E-10	2.36	IE LOOP	Initiator - Loss Of Offsite Power
			BTD01_BAT__ST_D	CCF of Safety Related Batteries on Demand -124
			LHSI PM3	LHSI Train 3 Unavailable due to Preventive Maintenance
			REC OSP 2HR	Failure to Recover Offsite Power Within 2 Hours
4	1.507E-10	2.36	IE LOOP	Initiator - Loss Of Offsite Power
			BTD01_BAT__ST_D	CCF of Safety Related Batteries on Demand -134
			LHSI PM2	LHSI Train 2 Unavailable due to Preventive Maintenance
			REC OSP 2HR	Failure to Recover Offsite Power Within 2 Hours
5	1.130E-10	1.77	IE LOOP	Initiator - Loss Of Offsite Power
			BTD01_BAT__ST_D	CCF of Safety Related Batteries on Demand -124
			REC OSP 2HR	Failure to Recover Offsite Power Within 2 Hours
			SAC03/QKA30 PM3	Normal SAC03/QKA30 Train Unavailable due to Preventive Maintenance
6	1.130E-10	1.77	IE LOOP	Initiator - Loss Of Offsite Power
			BTD01_BAT__ST_D	CCF of Safety Related Batteries on Demand -134
			REC OSP 2HR	Failure to Recover Offsite Power Within 2 Hours
			SAC02/QKA20 PM2	Normal SAC02/QKA20 Train Unavailable due to Preventive Maintenance

LOOP:0011

No.	Prob.	%	Event	Description
7	9.236E-11	1.45	IE LOOP	Initiator - Loss Of Offsite Power
			EFWS PM1	EFWS Train 1 Unavailable due to Preventive Maintenance
			LHSI PM1	LHSI Train 1 Unavailable due to Preventive Maintenance
			OPF-XTLDSBO-NS C	Operator Fails to Connect and Load SBO DGs to Div 1 or 4 During Non-SBO Conditions
			REC OSP 2HR	Failure to Recover Offsite Power Within 2 Hours
			XKA10____DFR_D	CCF of EDGs to Run -234
8	9.236E-11	1.45	IE LOOP	Initiator - Loss Of Offsite Power
			EFWS PM4	EFWS Train 4 Unavailable due to Preventive Maintenance
			LHSI PM4	LHSI Train 4 Unavailable due to Preventive Maintenance
			OPF-XTLDSBO-NS C	Operator Fails to Connect and Load SBO DGs to Div 1 or 4 During Non-SBO Conditions
			REC OSP 2HR	Failure to Recover Offsite Power Within 2 Hours
			XKA10____DFR_D	CCF of EDGs to Run -123
9	9.236E-11	1.45	IE LOOP	Initiator - Loss Of Offsite Power
			EFWS PM3	EFWS Train 3 Unavailable due to Preventive Maintenance
			LHSI PM3	LHSI Train 3 Unavailable due to Preventive Maintenance
			OPF-XTLDSBO-NS C	Operator Fails to Connect and Load SBO DGs to Div 1 or 4 During Non-SBO Conditions
			REC OSP 2HR	Failure to Recover Offsite Power Within 2 Hours
			XKA10____DFR_D	CCF of EDGs to Run -124
10	9.236E-11	1.45	IE LOOP	Initiator - Loss Of Offsite Power
			EFWS PM2	EFWS Train 2 Unavailable due to Preventive Maintenance
			LHSI PM2	LHSI Train 2 Unavailable due to Preventive Maintenance
			OPF-XTLDSBO-NS C	Operator Fails to Connect and Load SBO DGs to Div 1 or 4 During Non-SBO Conditions
			REC OSP 2HR	Failure to Recover Offsite Power Within 2 Hours
			XKA10____DFR_D	CCF of EDGs to Run -134

LOOP:0014

Minimal Cutsets

Top Event probability Q = 8.578E-08

No.	Prob.	%	Event	Description
1	1.220E-08	14.22	IE LOOP OPF-SAC-2H QKA10GH001_FS_ B-ALL REC OSP 2HR	Initiator - Loss Of Offsite Power Operator Fails to Recover Room Cooling Locally CCF of the Air Cooled SCWS Chiller Units to Start Failure to Recover Offsite Power Within 2 Hours
2	1.148E-08	13.38	IE LOOP OPF-SAC-2H QKA10GH001_FS REC OSP 2HR SAC04/QKA40 PM4	Initiator - Loss Of Offsite Power Operator Fails to Recover Room Cooling Locally SCWS, Train 1 Chiller Unit QKA10GH001, Fails to Start on Demand Failure to Recover Offsite Power Within 2 Hours Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance
3	1.148E-08	13.38	IE LOOP OPF-SAC-2H QKA40GH001_FS REC OSP 2HR SAC01/QKA10 PM1	Initiator - Loss Of Offsite Power Operator Fails to Recover Room Cooling Locally SCWS, Train 4 Chiller Unit QKA40GH001, Fails to Start on Demand Failure to Recover Offsite Power Within 2 Hours Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
4	1.854E-09	2.16	IE LOOP OPF-SAC-2H QKA10GH001_FS QKA40GH001_FS REC OSP 2HR	Initiator - Loss Of Offsite Power Operator Fails to Recover Room Cooling Locally SCWS, Train 1 Chiller Unit QKA10GH001, Fails to Start on Demand SCWS, Train 4 Chiller Unit QKA40GH001, Fails to Start on Demand Failure to Recover Offsite Power Within 2 Hours
5	1.756E-09	2.05	IE LOOP OPF-SAC-2H QKA10GH001_FR_ B-ALL REC OSP 2HR	Initiator - Loss Of Offsite Power Operator Fails to Recover Room Cooling Locally CCF of the Air Cooled SCWS Chiller Units to Run Failure to Recover Offsite Power Within 2 Hours
6	1.652E-09	1.93	IE LOOP OPF-SAC-2H QKA40GH001_FR REC OSP 2HR SAC01/QKA10 PM1	Initiator - Loss Of Offsite Power Operator Fails to Recover Room Cooling Locally SCWS, Train 4 Chiller Unit QKA40GH001, Fails to Run Failure to Recover Offsite Power Within 2 Hours Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
7	1.652E-09	1.93	IE LOOP OPF-SAC-2H QKA10GH001_FR REC OSP 2HR SAC04/QKA40 PM4	Initiator - Loss Of Offsite Power Operator Fails to Recover Room Cooling Locally SCWS, Train 1 Chiller Unit QKA10GH001, Fails to Run Failure to Recover Offsite Power Within 2 Hours Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance

LOOP:0014

No.	Prob.	%	Event	Description
8	1.540E-09	1.80	IE LOOP 34BTD01_BATST OPF-SAC-2H REC OSP 2HR SAC01/QKA10 PM1	Initiator - Loss Of Offsite Power ELEC, 250V 1E 2-hr Battery 34BTD01, Fails on Demand Operator Fails to Recover Room Cooling Locally Failure to Recover Offsite Power Within 2 Hours Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
9	1.540E-09	1.80	IE LOOP 31BTD01_BATST OPF-SAC-2H REC OSP 2HR SAC04/QKA40 PM4	Initiator - Loss Of Offsite Power ELEC, 250V 1E 2-hr Battery 31BTD01, Fails on Demand Operator Fails to Recover Room Cooling Locally Failure to Recover Offsite Power Within 2 Hours Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance
10	9.116E-10	1.06	IE LOOP OPF-SAC-2H QKA40AP107EFS REC OSP 2HR SAC01/QKA10 PM1	Initiator - Loss Of Offsite Power Operator Fails to Recover Room Cooling Locally SCWS, Train 4 Motor Driven Safety Chiller Pump QKA40AP107, Fails to Start on Demand Failure to Recover Offsite Power Within 2 Hours Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance

LOOP:0029

Minimal Cutsets

Top Event probability Q = 5.382E-09

No.	Prob.	%	Event	Description
1	6.281E-11	1.17	IE LOOP	Initiator - Loss Of Offsite Power
			32BTB01_BATST	ELEC, 250V Non 1E 12-hr Battery 32BTB01, Fails on Demand
			OPF-XTDIV-NSC	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
			REC OSP 1HR	Failure to Recover Offsite Power Within 1 Hour
			XKA10____DFR_D	CCF of EDGs to Run
			-234	
2	6.281E-11	1.17	IE LOOP	Initiator - Loss Of Offsite Power
			31BTB01_BATST	ELEC, 250V Non 1E 12-hr Battery 31BTB01, Fails on Demand
			OPF-XTDIV-NSC	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
			REC OSP 1HR	Failure to Recover Offsite Power Within 1 Hour
			XKA10____DFR_D	CCF of EDGs to Run
			-123	
3	3.782E-11	0.70	IE LOOP	Initiator - Loss Of Offsite Power
			JEB20AA010EFC	RCP, RCP2 Leakoff Isolation MOV JEB20AA010, Fails to Close on Demand
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			OPF-XTDIV-NSC	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
			REC OSP 1HR	Failure to Recover Offsite Power Within 1 Hour
			SAC01/QKA10 PM1	Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
XKA30____DFR	ELEC, Emergency Diesel Generator XKA30, Fails to Run			
4	3.782E-11	0.70	IE LOOP	Initiator - Loss Of Offsite Power
			JEB40AA020EFC	RCP Seal, RCP4 Seal Nitrogen Venting Isolation MOV JEB40AA020, Fails to Close on Demand
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			OPF-XTDIV-NSC	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
			REC OSP 1HR	Failure to Recover Offsite Power Within 1 Hour
			SAC04/QKA40 PM4	Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance
XKA20____DFR	ELEC, Emergency Diesel Generator XKA20, Fails to Run			

LOOP:0029

No.	Prob.	%	Event	Description
5	3.782E-11	0.70	IE LOOP	Initiator - Loss Of Offsite Power
			JEB40AA010EFC	RCP, RCP4 Leakoff Isolation MOV JEB40AA010, Fails to Close on Demand
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			OPF-XTDIV-NSC	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
			REC OSP 1HR	Failure to Recover Offsite Power Within 1 Hour
			SAC04/QKA40 PM4	Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance
			XKA20____DFR	ELEC, Emergency Diesel Generator XKA20, Fails to Run
6	3.782E-11	0.70	IE LOOP	Initiator - Loss Of Offsite Power
			JEB20AA020EFC	RCP Seal, RCP2 Seal Nitrogen Venting Isolation MOV JEB20AA020, Fails to Close on Demand
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			OPF-XTDIV-NSC	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
			REC OSP 1HR	Failure to Recover Offsite Power Within 1 Hour
			SAC01/QKA10 PM1	Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
			XKA30____DFR	ELEC, Emergency Diesel Generator XKA30, Fails to Run
7	3.782E-11	0.70	IE LOOP	Initiator - Loss Of Offsite Power
			JEB30AA020EFC	RCP Seal, RCP3 Seal Nitrogen Venting Isolation MOV JEB30AA020, Fails to Close on Demand
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			OPF-XTDIV-NSC	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
			REC OSP 1HR	Failure to Recover Offsite Power Within 1 Hour
			SAC04/QKA40 PM4	Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance
			XKA20____DFR	ELEC, Emergency Diesel Generator XKA20, Fails to Run
8	3.782E-11	0.70	IE LOOP	Initiator - Loss Of Offsite Power
			JEB30AA010EFC	RCP, RCP3 Leakoff Isolation MOV JEB30AA010, Fails to Close on Demand
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			OPF-XTDIV-NSC	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
			REC OSP 1HR	Failure to Recover Offsite Power Within 1 Hour
			SAC04/QKA40 PM4	Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance
			XKA20____DFR	ELEC, Emergency Diesel Generator XKA20, Fails to Run

LOOP:0029

No.	Prob.	%	Event	Description
9	3.782E-11	0.70	IE LOOP	Initiator - Loss Of Offsite Power
			JEB10AA020EFC	RCP Seal, RCP1 Seal Nitrogen Venting Isolation MOV JEB10AA020, Fails to Close on Demand
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			OPF-XTDIV-NSC	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
			REC OSP 1HR	Failure to Recover Offsite Power Within 1 Hour
			SAC01/QKA10 PM1	Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
			XKA30_____DFR	ELEC, Emergency Diesel Generator XKA30, Fails to Run
10	3.782E-11	0.70	IE LOOP	Initiator - Loss Of Offsite Power
			JEB10AA010EFC	RCP, RCP1 Leakoff Isolation MOV JEB10AA010, Fails to Close on Demand
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			OPF-XTDIV-NSC	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
			REC OSP 1HR	Failure to Recover Offsite Power Within 1 Hour
			SAC01/QKA10 PM1	Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
			XKA30_____DFR	ELEC, Emergency Diesel Generator XKA30, Fails to Run

Minimal Cutsets

Top Event probability Q = 5.481E-09

No.	Prob.	%	Event	Description
1	4.351E-11	0.79	IE LOOP	Initiator - Loss Of Offsite Power
			JEB30AA020EFC	RCP Seal, RCP3 Seal Nitrogen Venting Isolation MOV JEB30AA020, Fails to Close on Demand
			OPE-FB-40M	Operator Fails to Initiate Feed & Bleed for SLOCA
			OPF-XTDIV-NSC	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
			REC OSP 1HR	Failure to Recover Offsite Power Within 1 Hour
			XKA10____DFR_D -234	CCF of EDGs to Run
2	4.351E-11	0.79	IE LOOP	Initiator - Loss Of Offsite Power
			JEB20AA010EFC	RCP, RCP2 Leakoff Isolation MOV JEB20AA010, Fails to Close on Demand
			OPE-FB-40M	Operator Fails to Initiate Feed & Bleed for SLOCA
			OPF-XTDIV-NSC	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
			REC OSP 1HR	Failure to Recover Offsite Power Within 1 Hour
			XKA10____DFR_D -123	CCF of EDGs to Run
3	4.351E-11	0.79	IE LOOP	Initiator - Loss Of Offsite Power
			JEB30AA010EFC	RCP, RCP3 Leakoff Isolation MOV JEB30AA010, Fails to Close on Demand
			OPE-FB-40M	Operator Fails to Initiate Feed & Bleed for SLOCA
			OPF-XTDIV-NSC	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
			REC OSP 1HR	Failure to Recover Offsite Power Within 1 Hour
			XKA10____DFR_D -234	CCF of EDGs to Run
4	4.351E-11	0.79	IE LOOP	Initiator - Loss Of Offsite Power
			JEB20AA020EFC	RCP Seal, RCP2 Seal Nitrogen Venting Isolation MOV JEB20AA020, Fails to Close on Demand
			OPE-FB-40M	Operator Fails to Initiate Feed & Bleed for SLOCA
			OPF-XTDIV-NSC	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
			REC OSP 1HR	Failure to Recover Offsite Power Within 1 Hour
			XKA10____DFR_D -123	CCF of EDGs to Run

LOOP:0030

No.	Prob.	%	Event	Description
5	4.351E-11	0.79	IE LOOP	Initiator - Loss Of Offsite Power
			JEB40AA010EFC	RCP, RCP4 Leakoff Isolation MOV JEB40AA010, Fails to Close on Demand
			OPE-FB-40M	Operator Fails to Initiate Feed & Bleed for SLOCA
			OPF-XTDIV-NSC	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
			REC OSP 1HR	Failure to Recover Offsite Power Within 1 Hour
			XKA10____DFR_D	CCF of EDGs to Run -234
6	4.351E-11	0.79	IE LOOP	Initiator - Loss Of Offsite Power
			JEB10AA010EFC	RCP, RCP1 Leakoff Isolation MOV JEB10AA010, Fails to Close on Demand
			OPE-FB-40M	Operator Fails to Initiate Feed & Bleed for SLOCA
			OPF-XTDIV-NSC	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
			REC OSP 1HR	Failure to Recover Offsite Power Within 1 Hour
			XKA10____DFR_D	CCF of EDGs to Run -123
7	4.351E-11	0.79	IE LOOP	Initiator - Loss Of Offsite Power
			JEB10AA020EFC	RCP Seal, RCP1 Seal Nitrogen Venting Isolation MOV JEB10AA020, Fails to Close on Demand
			OPE-FB-40M	Operator Fails to Initiate Feed & Bleed for SLOCA
			OPF-XTDIV-NSC	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
			REC OSP 1HR	Failure to Recover Offsite Power Within 1 Hour
			XKA10____DFR_D	CCF of EDGs to Run -123
8	4.351E-11	0.79	IE LOOP	Initiator - Loss Of Offsite Power
			JEB40AA020EFC	RCP Seal, RCP4 Seal Nitrogen Venting Isolation MOV JEB40AA020, Fails to Close on Demand
			OPE-FB-40M	Operator Fails to Initiate Feed & Bleed for SLOCA
			OPF-XTDIV-NSC	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
			REC OSP 1HR	Failure to Recover Offsite Power Within 1 Hour
			XKA10____DFR_D	CCF of EDGs to Run -234

LOOP:0030

No.	Prob.	%	Event	Description
9	2.083E-11	0.38	IE LOOP	Initiator - Loss Of Offsite Power
			CCWS/ESWS PM2	CCWS/ESWS Train 2 Pump Unavailable due to Preventive Maintenance
			JEB20AA010EFC	RCP, RCP2 Leakoff Isolation MOV JEB20AA010, Fails to Close on Demand
			OPE-FB-40M	Operator Fails to Initiate Feed & Bleed for SLOCA
			OPF-XTDIV-NSC	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
			REC OSP 1HR	Failure to Recover Offsite Power Within 1 Hour
			XKA10____DFR	ELEC, Emergency Diesel Generator XKA10, Fails to Run
			XKA30____DFR	ELEC, Emergency Diesel Generator XKA30, Fails to Run
10	2.083E-11	0.38	IE LOOP	Initiator - Loss Of Offsite Power
			CCWS/ESWS PM3	CCWS/ESWS Train 3 Pump Unavailable due to Preventive Maintenance
			JEB30AA010EFC	RCP, RCP3 Leakoff Isolation MOV JEB30AA010, Fails to Close on Demand
			OPE-FB-40M	Operator Fails to Initiate Feed & Bleed for SLOCA
			OPF-XTDIV-NSC	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
			REC OSP 1HR	Failure to Recover Offsite Power Within 1 Hour
			XKA20____DFR	ELEC, Emergency Diesel Generator XKA20, Fails to Run
			XKA40____DFR	ELEC, Emergency Diesel Generator XKA40, Fails to Run

LOOP:0044

Minimal Cutsets

Top Event probability Q = 1.117E-08

No.	Prob.	%	Event	Description
1	1.359E-09	12.16	IE LOOP EFWS PM1 REC OSP 2HR XKA10____DFR_D -ALL XKA80____DFR	Initiator - Loss Of Offsite Power EFWS Train 1 Unavailable due to Preventive Maintenance Failure to Recover Offsite Power Within 2 Hours CCF of EDGs to Run ELEC, SBO Diesel Generator XKA80, Fails to Run
2	1.359E-09	12.16	IE LOOP EFWS PM4 REC OSP 2HR XKA10____DFR_D -ALL XKA50____DFR	Initiator - Loss Of Offsite Power EFWS Train 4 Unavailable due to Preventive Maintenance Failure to Recover Offsite Power Within 2 Hours CCF of EDGs to Run ELEC, SBO Diesel Generator XKA50, Fails to Run
3	6.074E-10	5.44	IE LOOP CL-TXS-OSCCF REC OSP 2HR	Initiator - Loss Of Offsite Power SW CCF of TXS operating system or multiple diversity groups Failure to Recover Offsite Power Within 2 Hours
4	4.034E-10	3.61	IE LOOP LAS41AP001EFR REC OSP 2HR XKA10____DFR_D -ALL XKA50____DFR	Initiator - Loss Of Offsite Power EFWS, Train 4 Motor Driven Pump LAS41AP001, Fails to Run Failure to Recover Offsite Power Within 2 Hours CCF of EDGs to Run ELEC, SBO Diesel Generator XKA50, Fails to Run
5	4.034E-10	3.61	IE LOOP LAS11AP001EFR REC OSP 2HR XKA10____DFR_D -ALL XKA80____DFR	Initiator - Loss Of Offsite Power EFWS, Train 1 Motor Driven Pump LAS11AP001, Fails to Run Failure to Recover Offsite Power Within 2 Hours CCF of EDGs to Run ELEC, SBO Diesel Generator XKA80, Fails to Run
6	2.966E-10	2.66	IE LOOP LAS11AP001EFR REC OSP 2HR SBODG8 PM4 XKA10____DFR_D -ALL	Initiator - Loss Of Offsite Power EFWS, Train 1 Motor Driven Pump LAS11AP001, Fails to Run Failure to Recover Offsite Power Within 2 Hours SBO-DG Train 4 Unavailable due to Preventive Maintenance CCF of EDGs to Run
7	2.966E-10	2.66	IE LOOP EFWS PM4 LAS11AP001EFR REC OSP 2HR XKA10____DFR_D -ALL	Initiator - Loss Of Offsite Power EFWS Train 4 Unavailable due to Preventive Maintenance EFWS, Train 1 Motor Driven Pump LAS11AP001, Fails to Run Failure to Recover Offsite Power Within 2 Hours CCF of EDGs to Run

LOOP:0044

No.	Prob.	%	Event	Description
8	2.966E-10	2.66	IE LOOP EFWS PM1 LAS41AP001EFR REC OSP 2HR XKA10____DFR_D -ALL	Initiator - Loss Of Offsite Power EFWS Train 1 Unavailable due to Preventive Maintenance EFWS, Train 4 Motor Driven Pump LAS41AP001, Fails to Run Failure to Recover Offsite Power Within 2 Hours CCF of EDGs to Run
9	2.966E-10	2.66	IE LOOP LAS41AP001EFR REC OSP 2HR SBODG5 PM1 XKA10____DFR_D -ALL	Initiator - Loss Of Offsite Power EFWS, Train 4 Motor Driven Pump LAS41AP001, Fails to Run Failure to Recover Offsite Power Within 2 Hours SBO-DG Train 1 Unavailable due to Preventive Maintenance CCF of EDGs to Run
10	1.107E-10	0.99	IE LOOP EFWS PM4 REC OSP 2HR XKA10____DFR_D -ALL XKA50____DFS	Initiator - Loss Of Offsite Power EFWS Train 4 Unavailable due to Preventive Maintenance Failure to Recover Offsite Power Within 2 Hours CCF of EDGs to Run ELEC, SBO Diesel Generator XKA50, Fails to Start on Demand

LOOP:0045

Minimal Cutsets

Top Event probability Q = 1.665E-08

No.	Prob.	%	Event	Description
1	1.848E-09	11.10	IE LOOP	Initiator - Loss Of Offsite Power
			REC OSP 2HR	Failure to Recover Offsite Power Within 2 Hours
			XKA10____DFR_D	CCF of EDGs to Run
			-ALL	
			XKA50____DFR	ELEC, SBO Diesel Generator XKA50, Fails to Run
XKA80____DFR	ELEC, SBO Diesel Generator XKA80, Fails to Run			
2	1.779E-09	10.69	IE LOOP	Initiator - Loss Of Offsite Power
			BTD01_BAT__ST_D	CCF of Safety Related Batteries on Demand
			-ALL	
			REC OSP 2HR	Failure to Recover Offsite Power Within 2 Hours
3	1.359E-09	8.16	IE LOOP	Initiator - Loss Of Offsite Power
			REC OSP 2HR	Failure to Recover Offsite Power Within 2 Hours
			SBODG5 PM1	SBO-DG Train 1 Unavailable due to Preventive Maintenance
			XKA10____DFR_D	CCF of EDGs to Run
			-ALL	
XKA80____DFR	ELEC, SBO Diesel Generator XKA80, Fails to Run			
4	1.359E-09	8.16	IE LOOP	Initiator - Loss Of Offsite Power
			REC OSP 2HR	Failure to Recover Offsite Power Within 2 Hours
			SBODG8 PM4	SBO-DG Train 4 Unavailable due to Preventive Maintenance
			XKA10____DFR_D	CCF of EDGs to Run
			-ALL	
XKA50____DFR	ELEC, SBO Diesel Generator XKA50, Fails to Run			
5	9.820E-10	5.90	IE LOOP	Initiator - Loss Of Offsite Power
			REC OSP 2HR	Failure to Recover Offsite Power Within 2 Hours
			XKA10____DFR_D	CCF of EDGs to Run
			-ALL	
XKA50____DFR_B	CCF of SBO DGs to Run			
-ALL				
6	3.746E-10	2.25	IE LOOP	Initiator - Loss Of Offsite Power
			OPF-XTLDSBO-2H	Operator Fails to Connect and Load SBO DGs to Div 1 and 4
			REC OSP 2HR	Failure to Recover Offsite Power Within 2 Hours
			XKA10____DFR_D	CCF of EDGs to Run
-ALL				
7	2.260E-10	1.36	IE LOOP	Initiator - Loss Of Offsite Power
			BTD01_BAT__ST_D	CCF of Safety Related Batteries on Demand
			-134	
			CCWS/ESWS PM2	CCWS/ESWS Train 2 Pump Unavailable due to Preventive Maintenance
REC OSP 2HR	Failure to Recover Offsite Power Within 2 Hours			

LOOP:0045

No.	Prob.	%	Event	Description
8	2.260E-10	1.36	IE LOOP BTD01_BAT__ST_D CCF of Safety Related Batteries on Demand -124 CCWS/ESWS PM3 REC OSP 2HR	Initiator - Loss Of Offsite Power CCWS/ESWS Train 3 Pump Unavailable due to Preventive Maintenance Failure to Recover Offsite Power Within 2 Hours
9	2.085E-10	1.25	IE LOOP OPF-SAC-2H QKA10AP107EFS_DCCF of SCWS Pumps to Start -ALL REC OSP 2HR	Initiator - Loss Of Offsite Power Operator Fails to Recover Room Cooling Locally Failure to Recover Offsite Power Within 2 Hours
10	1.507E-10	0.91	IE LOOP BTD01_BAT__ST_D CCF of Safety Related Batteries on Demand -134 EDG PM2 REC OSP 2HR	Initiator - Loss Of Offsite Power EDG Train 2 Unavailable due to Preventive Maintenance Failure to Recover Offsite Power Within 2 Hours

LOOP:0052**Minimal Cutsets**

Top Event probability Q = 5.307E-09

No.	Prob.	%	Event	Description
1	1.359E-10	2.56	IE LOOP 31BTB01_BATST PROB SEAL LOCA REC OSP 1HR XKA10____DFR_D -ALL	Initiator - Loss Of Offsite Power ELEC, 250V Non 1E 12-hr Battery 31BTB01, Fails on Demand Probability of Seal LOCA Occurring Given a Loss of Seal Cooling Failure to Recover Offsite Power Within 1 Hour CCF of EDGs to Run
2	1.359E-10	2.56	IE LOOP 32BTB01_BATST PROB SEAL LOCA REC OSP 1HR XKA10____DFR_D -ALL	Initiator - Loss Of Offsite Power ELEC, 250V Non 1E 12-hr Battery 32BTB01, Fails on Demand Probability of Seal LOCA Occurring Given a Loss of Seal Cooling Failure to Recover Offsite Power Within 1 Hour CCF of EDGs to Run
3	5.068E-11	0.96	IE LOOP JEB30AA020EFC OPF-XTDIVSBO-2H PROB SEAL LOCA REC OSP 1HR XKA10____DFR_D -ALL	Initiator - Loss Of Offsite Power RCP Seal, RCP3 Seal Nitrogen Venting Isolation MOV JEB30AA020, Fails to Close on Demand Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During SBO Considitions Probability of Seal LOCA Occurring Given a Loss of Seal Cooling Failure to Recover Offsite Power Within 1 Hour CCF of EDGs to Run
4	5.068E-11	0.96	IE LOOP JEB10AA010EFC OPF-XTDIVSBO-2H PROB SEAL LOCA REC OSP 1HR XKA10____DFR_D -ALL	Initiator - Loss Of Offsite Power RCP, RCP1 Leakoff Isolation MOV JEB10AA010, Fails to Close on Demand Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During SBO Considitions Probability of Seal LOCA Occurring Given a Loss of Seal Cooling Failure to Recover Offsite Power Within 1 Hour CCF of EDGs to Run
5	5.068E-11	0.96	IE LOOP JEB30AA010EFC OPF-XTDIVSBO-2H PROB SEAL LOCA REC OSP 1HR XKA10____DFR_D -ALL	Initiator - Loss Of Offsite Power RCP, RCP3 Leakoff Isolation MOV JEB30AA010, Fails to Close on Demand Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During SBO Considitions Probability of Seal LOCA Occurring Given a Loss of Seal Cooling Failure to Recover Offsite Power Within 1 Hour CCF of EDGs to Run

LOOP:0052

No.	Prob.	%	Event	Description
6	5.068E-11	0.96	IE LOOP	Initiator - Loss Of Offsite Power
			JEB20AA020EFC	RCP Seal, RCP2 Seal Nitrogen Venting Isolation MOV JEB20AA020, Fails to Close on Demand
			OPF-XTDIVSBO-2H	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During SBO Considitions
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
			REC OSP 1HR	Failure to Recover Offsite Power Within 1 Hour
			XKA10____DFR_D	CCF of EDGs to Run -ALL
7	5.068E-11	0.96	IE LOOP	Initiator - Loss Of Offsite Power
			JEB40AA020EFC	RCP Seal, RCP4 Seal Nitrogen Venting Isolation MOV JEB40AA020, Fails to Close on Demand
			OPF-XTDIVSBO-2H	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During SBO Considitions
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
			REC OSP 1HR	Failure to Recover Offsite Power Within 1 Hour
			XKA10____DFR_D	CCF of EDGs to Run -ALL
8	5.068E-11	0.96	IE LOOP	Initiator - Loss Of Offsite Power
			JEB40AA010EFC	RCP, RCP4 Leakoff Isolation MOV JEB40AA010, Fails to Close on Demand
			OPF-XTDIVSBO-2H	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During SBO Considitions
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
			REC OSP 1HR	Failure to Recover Offsite Power Within 1 Hour
			XKA10____DFR_D	CCF of EDGs to Run -ALL
9	5.068E-11	0.96	IE LOOP	Initiator - Loss Of Offsite Power
			JEB20AA010EFC	RCP, RCP2 Leakoff Isolation MOV JEB20AA010, Fails to Close on Demand
			OPF-XTDIVSBO-2H	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During SBO Considitions
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
			REC OSP 1HR	Failure to Recover Offsite Power Within 1 Hour
			XKA10____DFR_D	CCF of EDGs to Run -ALL
10	5.068E-11	0.96	IE LOOP	Initiator - Loss Of Offsite Power
			JEB10AA020EFC	RCP Seal, RCP1 Seal Nitrogen Venting Isolation MOV JEB10AA020, Fails to Close on Demand
			OPF-XTDIVSBO-2H	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During SBO Considitions
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
			REC OSP 1HR	Failure to Recover Offsite Power Within 1 Hour
			XKA10____DFR_D	CCF of EDGs to Run -ALL

LOOP:0053

Minimal Cutsets

Top Event probability Q = 7.236E-09

No.	Prob.	%	Event	Description
1	3.620E-10	5.00	IE LOOP	Initiator - Loss Of Offsite Power
			JEB30AA010EFC	RCP, RCP3 Leakoff Isolation MOV JEB30AA010, Fails to Close on Demand
			OPE-FCD-40MSBO	Operator Fails to Initiate Fast Cooldown for RCP During SBO Conditions
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
			REC OSP 1HR	Failure to Recover Offsite Power Within 1 Hour
			XKA10____DFR_D	CCF of EDGs to Run -ALL
2	3.620E-10	5.00	IE LOOP	Initiator - Loss Of Offsite Power
			JEB30AA020EFC	RCP Seal, RCP3 Seal Nitrogen Venting Isolation MOV JEB30AA020, Fails to Close on Demand
			OPE-FCD-40MSBO	Operator Fails to Initiate Fast Cooldown for RCP During SBO Conditions
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
			REC OSP 1HR	Failure to Recover Offsite Power Within 1 Hour
			XKA10____DFR_D	CCF of EDGs to Run -ALL
3	3.620E-10	5.00	IE LOOP	Initiator - Loss Of Offsite Power
			JEB20AA020EFC	RCP Seal, RCP2 Seal Nitrogen Venting Isolation MOV JEB20AA020, Fails to Close on Demand
			OPE-FCD-40MSBO	Operator Fails to Initiate Fast Cooldown for RCP During SBO Conditions
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
			REC OSP 1HR	Failure to Recover Offsite Power Within 1 Hour
			XKA10____DFR_D	CCF of EDGs to Run -ALL
4	3.620E-10	5.00	IE LOOP	Initiator - Loss Of Offsite Power
			JEB40AA010EFC	RCP, RCP4 Leakoff Isolation MOV JEB40AA010, Fails to Close on Demand
			OPE-FCD-40MSBO	Operator Fails to Initiate Fast Cooldown for RCP During SBO Conditions
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
			REC OSP 1HR	Failure to Recover Offsite Power Within 1 Hour
			XKA10____DFR_D	CCF of EDGs to Run -ALL
5	3.620E-10	5.00	IE LOOP	Initiator - Loss Of Offsite Power
			JEB10AA010EFC	RCP, RCP1 Leakoff Isolation MOV JEB10AA010, Fails to Close on Demand
			OPE-FCD-40MSBO	Operator Fails to Initiate Fast Cooldown for RCP During SBO Conditions
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
			REC OSP 1HR	Failure to Recover Offsite Power Within 1 Hour
			XKA10____DFR_D	CCF of EDGs to Run -ALL

LOOP:0053

No.	Prob.	%	Event	Description
6	3.620E-10	5.00	IE LOOP	Initiator - Loss Of Offsite Power
			JEB20AA010EFC	RCP, RCP2 Leakoff Isolation MOV JEB20AA010, Fails to Close on Demand
			OPE-FCD-40MSBO	Operator Fails to Initiate Fast Cooldown for RCP During SBO Conditions
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
			REC OSP 1HR	Failure to Recover Offsite Power Within 1 Hour
			XKA10____DFR_D	CCF of EDGs to Run -ALL
7	3.620E-10	5.00	IE LOOP	Initiator - Loss Of Offsite Power
			JEB40AA020EFC	RCP Seal, RCP4 Seal Nitrogen Venting Isolation MOV JEB40AA020, Fails to Close on Demand
			OPE-FCD-40MSBO	Operator Fails to Initiate Fast Cooldown for RCP During SBO Conditions
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
			REC OSP 1HR	Failure to Recover Offsite Power Within 1 Hour
			XKA10____DFR_D	CCF of EDGs to Run -ALL
8	3.620E-10	5.00	IE LOOP	Initiator - Loss Of Offsite Power
			JEB10AA020EFC	RCP Seal, RCP1 Seal Nitrogen Venting Isolation MOV JEB10AA020, Fails to Close on Demand
			OPE-FCD-40MSBO	Operator Fails to Initiate Fast Cooldown for RCP During SBO Conditions
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
			REC OSP 1HR	Failure to Recover Offsite Power Within 1 Hour
			XKA10____DFR_D	CCF of EDGs to Run -ALL
9	1.008E-10	1.39	IE LOOP	Initiator - Loss Of Offsite Power
			JEB40 SSSF	Mechanical Failure of the Stand Still Seal for RCP4
			OPE-FCD-40MSBO	Operator Fails to Initiate Fast Cooldown for RCP During SBO Conditions
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
			REC OSP 1HR	Failure to Recover Offsite Power Within 1 Hour
			XKA10____DFR_D	CCF of EDGs to Run -ALL
10	1.008E-10	1.39	IE LOOP	Initiator - Loss Of Offsite Power
			JEB10 SSSF	Mechanical Failure of the Stand Still Seal for RCP1
			OPE-FCD-40MSBO	Operator Fails to Initiate Fast Cooldown for RCP During SBO Conditions
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
			REC OSP 1HR	Failure to Recover Offsite Power Within 1 Hour
			XKA10____DFR_D	CCF of EDGs to Run -ALL

LOOP:0056

Minimal Cutsets

Top Event probability Q = 5.627E-09

No.	Prob.	%	Event	Description
1	5.594E-09	99.42	IE LOOP BTD01_BAT__ST_D -ALL	Initiator - Loss Of Offsite Power CCF of Safety Related Batteries on Demand

SGTR:0018

Minimal Cutsets

Top Event probability Q = 9.717E-09

No.	Prob.	%	Event	Description
1	3.936E-09	40.51	IE SGTR	Initiator - Steam Generator Tube Rupture
			LBA40AA002PFC	MSS, Train 4 Main Steam Isolation Valve LBA40AA002, Fails to Close on Demand
			OPE-RHR-4H	Operator Fails to Initiate RHR Within 4 Hours
2	3.388E-09	34.86	IE SGTR	Initiator - Steam Generator Tube Rupture
			LBA43AA101EFC	MSS, Train 4 MSRCV LBA43AA101, Fails to Close on Demand
			OPD-RHR4H/SGTR 1H	Dependency (MED) Between Operator Actions for Stabilizing SGTR and Initiating RHR
			OPF-SGTR-1H	Operator Fails to Isolate SGTR and Initiate Cooldown
3	2.832E-10	2.91	IE SGTR	Initiator - Steam Generator Tube Rupture
			LBA40AA002POP	MSS, Train 4 Main Steam Isolation Valve LBA40AA002, Fails to Remain Closed (SO)
			OPE-RHR-4H	Operator Fails to Initiate RHR Within 4 Hours
4	2.574E-10	2.65	IE SGTR	Initiator - Steam Generator Tube Rupture
			LBA42AA191SPO	MSS, Train 4 Main Steam Safety Relief Valve LBA42AA191, Premature Opening
			OPE-RHR-4H	Operator Fails to Initiate RHR Within 4 Hours
5	2.574E-10	2.65	IE SGTR	Initiator - Steam Generator Tube Rupture
			LBA41AA191SPO	MSS, Train 4 Main Steam Safety Relief Valve LBA41AA191, Premature Opening
			OPE-RHR-4H	Operator Fails to Initiate RHR Within 4 Hours
6	1.520E-10	1.56	IE SGTR	Initiator - Steam Generator Tube Rupture
			34BRA____RFR	ELEC, 480V AC to 24V DC Rectifier for MCC 34BRA Control Power, Fails to Run
			OPD-RHR4H/SGTR 1H	Dependency (MED) Between Operator Actions for Stabilizing SGTR and Initiating RHR
			OPF-SGTR-1H	Operator Fails to Isolate SGTR and Initiate Cooldown
7	8.581E-11	0.88	IE SGTR	Initiator - Steam Generator Tube Rupture
			BRW70BUW71OFL	ELEC, 24V DC I&C Power Rack 34BRW70/34BUW71, Fails During Operation
			OPE-RHR-4H	Operator Fails to Initiate RHR Within 4 Hours
8	6.950E-11	0.72	IE SGTR	Initiator - Steam Generator Tube Rupture
			LBA10AA002PFC_D CCF to Close Main Steam Isolation Valves -24	
			OPE-RHR-4H	Operator Fails to Initiate RHR Within 4 Hours

SGTR:0018

No.	Prob.	%	Event	Description
9	6.950E-11	0.72	IE SGTR LBA10AA002PFC_D CCF to Close Main Steam Isolation Valves -14 OPE-RHR-4H	Initiator - Steam Generator Tube Rupture Operator Fails to Initiate RHR Within 4 Hours
10	6.950E-11	0.72	IE SGTR LBA10AA002PFC_D CCF to Close Main Steam Isolation Valves -34 OPE-RHR-4H	Initiator - Steam Generator Tube Rupture Operator Fails to Initiate RHR Within 4 Hours

Minimal Cutsets

Top Event probability Q = 6.777E-09

No.	Prob.	%	Event	Description
1	5.000E-09	73.78	IE SLBI CL-PS-B-SWCCF	Initiator - Steam Break Inside Containment SW CCF of Protection System diversity group B
2	3.342E-10	4.93	IE SLBI ALU-B CCF NS-ALL	Initiator - Steam Break Inside Containment CCF of ALU-B Protection System Computer Processors (Non-Self-Monitored)
3	3.342E-10	4.93	IE SLBI APU4 CCF NS-ALL	Initiator - Steam Break Inside Containment CCF of APU-4 Protection System Computer Processors (Non-Self-Monitored)
4	1.000E-10	1.48	IE SLBI CL-TXS-OSCCF	Initiator - Steam Break Inside Containment SW CCF of TXS operating system or multiple diversity groups
5	9.036E-11	1.33	IE SLBI ALU-B CCF SM-ALL	Initiator - Steam Break Inside Containment CCF of ALU-B Protection System Computer Processors (Self-Monitored)
6	9.036E-11	1.33	IE SLBI APU4 CCF SM-ALL	Initiator - Steam Break Inside Containment CCF of APU-4 Protection System Computer Processors (Self-Monitored)
7	4.024E-11	0.59	IE SLBI CLE23EQ002LB01N S CLF23EQ002LB01N S CLG23EQ002LB01N S	Initiator - Steam Break Inside Containment Digital output module fails (non-self-monitored) S Digital output module fails (non-self-monitored) S Digital output module fails (non-self-monitored) S
8	4.024E-11	0.59	IE SLBI CLF23EQ002LB01N S CLG23EQ002LB01N S CLH23EQ002LB01N S	Initiator - Steam Break Inside Containment Digital output module fails (non-self-monitored) S Digital output module fails (non-self-monitored) S Digital output module fails (non-self-monitored) S
9	4.024E-11	0.59	IE SLBI CLE23EQ002LB01N S CLF23EQ002LB01N S CLH23EQ002LB01N S	Initiator - Steam Break Inside Containment Digital output module fails (non-self-monitored) S Digital output module fails (non-self-monitored) S Digital output module fails (non-self-monitored) S

SLBI:0017

No.	Prob.	%	Event	Description
10	4.024E-11	0.59	IE SLBI	Initiator - Steam Break Inside Containment
			CLE23EQ002LB01N	Digital output module fails (non-self-monitored)
			S	
			CLG23EQ002LB01N	Digital output module fails (non-self-monitored)
			S	
			CLH23EQ002LB01N	Digital output module fails (non-self-monitored)
			S	

Minimal Cutsets

Top Event probability Q = 6.487E-09

No.	Prob.	%	Event	Description
1	5.000E-09	77.08	IE SLBI CL-PS-B-SWCCF	Initiator - Steam Break Inside Containment SW CCF of Protection System diversity group B
2	3.342E-10	5.15	IE SLBI ALU-B CCF NS-ALL	Initiator - Steam Break Inside Containment CCF of ALU-B Protection System Computer Processors (Non-Self-Monitored)
3	3.342E-10	5.15	IE SLBI APU4 CCF NS-ALL	Initiator - Steam Break Inside Containment CCF of APU-4 Protection System Computer Processors (Non-Self-Monitored)
4	1.000E-10	1.54	IE SLBI CL-TXS-OSCCF	Initiator - Steam Break Inside Containment SW CCF of TXS operating system or multiple diversity groups
5	9.036E-11	1.39	IE SLBI APU4 CCF SM-ALL	Initiator - Steam Break Inside Containment CCF of APU-4 Protection System Computer Processors (Self-Monitored)
6	9.036E-11	1.39	IE SLBI ALU-B CCF SM-ALL	Initiator - Steam Break Inside Containment CCF of ALU-B Protection System Computer Processors (Self-Monitored)
7	4.024E-11	0.62	IE SLBI CLE23EQ002LB01N S CLG23EQ002LB01N S CLH23EQ002LB01N S	Initiator - Steam Break Inside Containment Digital output module fails (non-self-monitored) S Digital output module fails (non-self-monitored) S Digital output module fails (non-self-monitored) S
8	4.024E-11	0.62	IE SLBI CLF23EQ002LB01N S CLG23EQ002LB01N S CLH23EQ002LB01N S	Initiator - Steam Break Inside Containment Digital output module fails (non-self-monitored) S Digital output module fails (non-self-monitored) S Digital output module fails (non-self-monitored) S
9	4.024E-11	0.62	IE SLBI CLE23EQ002LB01N S CLF23EQ002LB01N S CLG23EQ002LB01N S	Initiator - Steam Break Inside Containment Digital output module fails (non-self-monitored) S Digital output module fails (non-self-monitored) S Digital output module fails (non-self-monitored) S

SLBI:0030

No.	Prob.	%	Event	Description
10	4.024E-11	0.62	IE SLBI	Initiator - Steam Break Inside Containment
			CLE23EQ002LB01N	Digital output module fails (non-self-monitored)
			S	
			CLF23EQ002LB01N	Digital output module fails (non-self-monitored)
			S	
			CLH23EQ002LB01N	Digital output module fails (non-self-monitored)
			S	

Minimal Cutsets

Top Event probability Q = 1.038E-08

No.	Prob.	%	Event	Description
1	5.000E-09	48.16	IE SLBI CL-PS-B-SWCCF	Initiator - Steam Break Inside Containment SW CCF of Protection System diversity group B
2	6.723E-10	6.48	IE SLBI SG4 PRES CCF-ALL	Initiator - Steam Break Inside Containment CCF of SG4 pressure sensors
3	4.180E-10	4.03	IE SLBI SG4 PRES CCF-124	Initiator - Steam Break Inside Containment CCF of SG4 pressure sensors
4	4.180E-10	4.03	IE SLBI SG4 PRES CCF-234	Initiator - Steam Break Inside Containment CCF of SG4 pressure sensors
5	4.180E-10	4.03	IE SLBI SG4 PRES CCF-134	Initiator - Steam Break Inside Containment CCF of SG4 pressure sensors
6	4.180E-10	4.03	IE SLBI SG4 PRES CCF-123	Initiator - Steam Break Inside Containment CCF of SG4 pressure sensors
7	3.342E-10	3.22	IE SLBI APU4 CCF NS-ALL	Initiator - Steam Break Inside Containment CCF of APU-4 Protection System Computer Processors (Non-Self-Monitored)
8	3.342E-10	3.22	IE SLBI ALU-B CCF NS-ALL	Initiator - Steam Break Inside Containment CCF of ALU-B Protection System Computer Processors (Non-Self-Monitored)
9	1.000E-10	0.96	IE SLBI CL-TXS-OSCCF	Initiator - Steam Break Inside Containment SW CCF of TXS operating system or multiple diversity groups
10	9.036E-11	0.87	IE SLBI ALU-B CCF SM-ALL	Initiator - Steam Break Inside Containment CCF of ALU-B Protection System Computer Processors (Self-Monitored)

Minimal Cutsets

Top Event probability Q = 1.946E-08

No.	Prob.	%	Event	Description
1	6.659E-09	34.22	IE SLOCA LBA13AA001PFO_D -ALL OPE-FB-40M	Initiator - Small LOCA (0.6 to 3-Inch Diameter) CCF to Open Main Steam Relief Isolation Valves Operator Fails to Initiate Feed & Bleed for SLOCA
2	2.269E-09	11.66	IE SLOCA MSRIVSCPFO_P-A LL OPE-FB-40M	Initiator - Small LOCA (0.6 to 3-Inch Diameter) CCF to Open Main Steam Relief Isolation Pneumatic Pilot Valves Operator Fails to Initiate Feed & Bleed for SLOCA
3	8.970E-10	4.61	IE SLOCA CL-PS-B-SWCCF OPE-FB-40M	Initiator - Small LOCA (0.6 to 3-Inch Diameter) SW CCF of Protection System diversity group B Operator Fails to Initiate Feed & Bleed for SLOCA
4	7.856E-10	4.04	IE SLOCA CCWS/ESWS PM3 LOOPCONL+REC OPE-FB-40M OPF-XTDIV-NSC XKA20____DFR	Initiator - Small LOCA (0.6 to 3-Inch Diameter) CCWS/ESWS Train 3 Pump Unavailable due to Preventive Maintenance Consequential LOOP and Failure of Recovery Within 1 Hour for LOCA IEs Operator Fails to Initiate Feed & Bleed for SLOCA Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions ELEC, Emergency Diesel Generator XKA20, Fails to Run
5	7.856E-10	4.04	IE SLOCA CCWS/ESWS PM2 LOOPCONL+REC OPE-FB-40M OPF-XTDIV-NSC XKA30____DFR	Initiator - Small LOCA (0.6 to 3-Inch Diameter) CCWS/ESWS Train 2 Pump Unavailable due to Preventive Maintenance Consequential LOOP and Failure of Recovery Within 1 Hour for LOCA IEs Operator Fails to Initiate Feed & Bleed for SLOCA Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions ELEC, Emergency Diesel Generator XKA30, Fails to Run
6	7.564E-10	3.89	IE SLOCA MSRIVSOOFO_P-A LL OPE-FB-40M	Initiator - Small LOCA (0.6 to 3-Inch Diameter) CCF to Open Main Steam Relief Isolation Solenoid Pilot Valves Operator Fails to Initiate Feed & Bleed for SLOCA
7	5.237E-10	2.69	IE SLOCA EDG PM3 LOOPCONL+REC OPE-FB-40M OPF-XTDIV-NSC XKA20____DFR	Initiator - Small LOCA (0.6 to 3-Inch Diameter) EDG Train 3 Unavailable due to Preventive Maintenance Consequential LOOP and Failure of Recovery Within 1 Hour for LOCA IEs Operator Fails to Initiate Feed & Bleed for SLOCA Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions ELEC, Emergency Diesel Generator XKA20, Fails to Run

SLOCA:0017

No.	Prob.	%	Event	Description
8	5.237E-10	2.69	IE SLOCA	Initiator - Small LOCA (0.6 to 3-Inch Diameter)
			EDG PM2	EDG Train 2 Unavailable due to Preventive Maintenance
			LOOPCONL+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for LOCA IEs
			OPE-FB-40M	Operator Fails to Initiate Feed & Bleed for SLOCA
			OPF-XTDIV-NSC	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions
XKA30_____DFR	ELEC, Emergency Diesel Generator XKA30, Fails to Run			
9	3.606E-10	1.85	IE SLOCA	Initiator - Small LOCA (0.6 to 3-Inch Diameter)
			LOOPCONL+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for LOCA IEs
			OPE-FB-40M	Operator Fails to Initiate Feed & Bleed for SLOCA
			OPF-XTDIV-NSC	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions
			XKA20_____DFR	ELEC, Emergency Diesel Generator XKA20, Fails to Run
XKA30_____DFR	ELEC, Emergency Diesel Generator XKA30, Fails to Run			
10	1.394E-10	0.72	IE SLOCA	Initiator - Small LOCA (0.6 to 3-Inch Diameter)
			CCWS/ESWS PM3	CCWS/ESWS Train 3 Pump Unavailable due to Preventive Maintenance
			LOOPCONL+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for LOCA IEs
			OPE-FB-40M	Operator Fails to Initiate Feed & Bleed for SLOCA
			OPF-XTDIV-NSC	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions
PEB20AP001EFS	ESWS, Train 2 Motor Driven Pump PEB20AP001, Fails to Start on Demand			

SLOCA:0020

Minimal Cutsets

Top Event probability Q = 6.241E-09

No.	Prob.	%	Event	Description
1	6.178E-09	98.98	IE SLOCA JNG13AA005CFO_ D-ALL	Initiator - Small LOCA (0.6 to 3-Inch Diameter) CCF to Open LHSI/MHSI Common Injection Check Valves

SLOCA:0034

Minimal Cutsets

Top Event probability Q = 1.734E-08

No.	Prob.	%	Event	Description
1	6.822E-09	39.35	IE SLOCA JND10AP001EFR_D CCF of MHSI Pumps to Run -ALL OPE-FCD-40M	Initiator - Small LOCA (0.6 to 3-Inch Diameter) Operator Fails to Initiate Fast Cooldown for SLOCA
2	8.970E-10	5.17	IE SLOCA CL-PS-B-SWCCF OPE-FCD-40M	Initiator - Small LOCA (0.6 to 3-Inch Diameter) SW CCF of Protection System diversity group B Operator Fails to Initiate Fast Cooldown for SLOCA
3	8.294E-10	4.78	IE SLOCA JND10AP001EFS_D CCF of MHSI Pumps to Start -ALL OPE-FCD-40M	Initiator - Small LOCA (0.6 to 3-Inch Diameter) Operator Fails to Initiate Fast Cooldown for SLOCA
4	8.031E-10	4.63	IE SLOCA JNG13AA005CFO_D-ALL OPE-FCD-40M	Initiator - Small LOCA (0.6 to 3-Inch Diameter) CCF to Open LHSI/MHSI Common Injection Check Valves Operator Fails to Initiate Fast Cooldown for SLOCA
5	4.321E-10	2.49	IE SLOCA CCWS/ESWS PM2 JND10AP001EFR_D CCF of MHSI Pumps to Run -134 OPE-FCD-40M	Initiator - Small LOCA (0.6 to 3-Inch Diameter) CCWS/ESWS Train 2 Pump Unavailable due to Preventive Maintenance Operator Fails to Initiate Fast Cooldown for SLOCA
6	4.321E-10	2.49	IE SLOCA CCWS/ESWS PM3 JND10AP001EFR_D CCF of MHSI Pumps to Run -124 OPE-FCD-40M	Initiator - Small LOCA (0.6 to 3-Inch Diameter) CCWS/ESWS Train 3 Pump Unavailable due to Preventive Maintenance Operator Fails to Initiate Fast Cooldown for SLOCA
7	2.881E-10	1.66	IE SLOCA JND10AP001EFR_D CCF of MHSI Pumps to Run -124 MHSI PM3 OPE-FCD-40M	Initiator - Small LOCA (0.6 to 3-Inch Diameter) MHSI Train 3 Unavailable due to Preventive Maintenance Operator Fails to Initiate Fast Cooldown for SLOCA
8	2.881E-10	1.66	IE SLOCA JND10AP001EFR_D CCF of MHSI Pumps to Run -123 MHSI PM4 OPE-FCD-40M	Initiator - Small LOCA (0.6 to 3-Inch Diameter) MHSI Train 4 Unavailable due to Preventive Maintenance Operator Fails to Initiate Fast Cooldown for SLOCA

SLOCA:0034

No.	Prob.	%	Event	Description
9	2.881E-10	1.66	IE SLOCA JND10AP001EFR_D CCF of MHSI Pumps to Run -234 MHSI PM1 OPE-FCD-40M	Initiator - Small LOCA (0.6 to 3-Inch Diameter) MHSI Train 1 Unavailable due to Preventive Maintenance Operator Fails to Initiate Fast Cooldown for SLOCA
10	2.881E-10	1.66	IE SLOCA JND10AP001EFR_D CCF of MHSI Pumps to Run -134 MHSI PM2 OPE-FCD-40M	Initiator - Small LOCA (0.6 to 3-Inch Diameter) MHSI Train 2 Unavailable due to Preventive Maintenance Operator Fails to Initiate Fast Cooldown for SLOCA

Minimal Cutsets

Top Event probability Q = 3.200E-08

No.	Prob.	%	Event	Description
1	3.200E-08	100.00	IE FLD-ANN ALL	Initiator - Flood in the RB Annulus (Contained)
			PROB ANNULUS	Probability that the Annulus connection boxes will withstand a contained Flood

Minimal Cutsets

Top Event probability Q = 8.659E-09

No.	Prob.	%	Event	Description
1	8.933E-11	1.03	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB30AA020EFC	RCP Seal, RCP3 Seal Nitrogen Venting Isolation MOV JEB30AA020, Fails to Close on Demand
			KAA12AA005EFO_DCCF to Open CCWS to LHSI HTX Cooling MOV -ALL	
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
2	8.933E-11	1.03	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB40AA020EFC	RCP Seal, RCP4 Seal Nitrogen Venting Isolation MOV JEB40AA020, Fails to Close on Demand
			KAA12AA005EFO_DCCF to Open CCWS to LHSI HTX Cooling MOV -ALL	
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
3	8.933E-11	1.03	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB30AA010EFC	RCP, RCP3 Leakoff Isolation MOV JEB30AA010, Fails to Close on Demand
			KAA12AA005EFO_DCCF to Open CCWS to LHSI HTX Cooling MOV -ALL	
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
4	8.933E-11	1.03	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB40AA010EFC	RCP, RCP4 Leakoff Isolation MOV JEB40AA010, Fails to Close on Demand
			KAA12AA005EFO_DCCF to Open CCWS to LHSI HTX Cooling MOV -ALL	
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
5	7.478E-11	0.86	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB40AA020EFC	RCP Seal, RCP4 Seal Nitrogen Venting Isolation MOV JEB40AA020, Fails to Close on Demand
			PED10AN002EFS_DCCF to Start Standby Cooling Tower Fans -ALL	
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
6	7.478E-11	0.86	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB30AA010EFC	RCP, RCP3 Leakoff Isolation MOV JEB30AA010, Fails to Close on Demand
			PED10AN002EFS_DCCF to Start Standby Cooling Tower Fans -ALL	
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling

IE FLD-SAB14 FB:0017

No.	Prob.	%	Event	Description
7	7.478E-11	0.86	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB30AA020EFC	RCP Seal, RCP3 Seal Nitrogen Venting Isolation MOV JEB30AA020, Fails to Close on Demand
			PED10AN002EFS_DCCF to Start Standby Cooling Tower Fans -ALL	
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
8	7.478E-11	0.86	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB40AA010EFC	RCP, RCP4 Leakoff Isolation MOV JEB40AA010, Fails to Close on Demand
			PED10AN002EFS_DCCF to Start Standby Cooling Tower Fans -ALL	
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
9	4.823E-11	0.56	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB30AA020EFC	RCP Seal, RCP3 Seal Nitrogen Venting Isolation MOV JEB30AA020, Fails to Close on Demand
			JNG13AA005CFO_D-123	CCF to Open LHSI/MHSI Common Injection Check Valves
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
10	4.823E-11	0.56	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB40AA020EFC	RCP Seal, RCP4 Seal Nitrogen Venting Isolation MOV JEB40AA020, Fails to Close on Demand
			JNG13AA005CFO_D-123	CCF to Open LHSI/MHSI Common Injection Check Valves
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling

Minimal Cutsets

Top Event probability Q = 8.979E-09

No.	Prob.	%	Event	Description
1	1.620E-10	1.80	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB40AA010EFC	RCP, RCP4 Leakoff Isolation MOV JEB40AA010, Fails to Close on Demand
			JND10AP001EFR_D	CCF of MHSI Pumps to Run -123
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
2	1.620E-10	1.80	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB40AA020EFC	RCP Seal, RCP4 Seal Nitrogen Venting Isolation MOV JEB40AA020, Fails to Close on Demand
			JND10AP001EFR_D	CCF of MHSI Pumps to Run -123
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
3	1.620E-10	1.80	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB30AA010EFC	RCP, RCP3 Leakoff Isolation MOV JEB30AA010, Fails to Close on Demand
			JND10AP001EFR_D	CCF of MHSI Pumps to Run -123
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
4	1.620E-10	1.80	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB30AA020EFC	RCP Seal, RCP3 Seal Nitrogen Venting Isolation MOV JEB30AA020, Fails to Close on Demand
			JND10AP001EFR_D	CCF of MHSI Pumps to Run -123
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
5	1.535E-10	1.71	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB30AA020EFC	RCP Seal, RCP3 Seal Nitrogen Venting Isolation MOV JEB30AA020, Fails to Close on Demand
			JND10AP001EFR_D	CCF of MHSI Pumps to Run -ALL
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
6	1.535E-10	1.71	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB40AA020EFC	RCP Seal, RCP4 Seal Nitrogen Venting Isolation MOV JEB40AA020, Fails to Close on Demand
			JND10AP001EFR_D	CCF of MHSI Pumps to Run -ALL
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling

IE FLD-SAB14 FB:0031

No.	Prob.	%	Event	Description
7	1.535E-10	1.71	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB30AA010EFC	RCP, RCP3 Leakoff Isolation MOV JEB30AA010, Fails to Close on Demand
			JND10AP001EFR_D	CCF of MHSI Pumps to Run -ALL
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
8	1.535E-10	1.71	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB40AA010EFC	RCP, RCP4 Leakoff Isolation MOV JEB40AA010, Fails to Close on Demand
			JND10AP001EFR_D	CCF of MHSI Pumps to Run -ALL
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
9	4.823E-11	0.54	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB40AA010EFC	RCP, RCP4 Leakoff Isolation MOV JEB40AA010, Fails to Close on Demand
			JNG13AA005CFO_D-123	CCF to Open LHSI/MHSI Common Injection Check Valves
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
10	4.823E-11	0.54	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB30AA010EFC	RCP, RCP3 Leakoff Isolation MOV JEB30AA010, Fails to Close on Demand
			JNG13AA005CFO_D-123	CCF to Open LHSI/MHSI Common Injection Check Valves
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling

Minimal Cutsets

Top Event probability Q = 1.253E-08

No.	Prob.	%	Event	Description
1	7.800E-09	62.25	IE FIRE-SAB-MECH OPF-SAC-2H PAS SAC01/QKA10 PM1	Initiator - Fire in the Pump Room of Any Safeguard Building Operator Fails to Recover Room Cooling Locally Process Automation System (PAS) Fails (Estimate) Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
2	2.808E-09	22.41	IE FIRE-SAB-MECH LOOPFCSD+REC OPF-SAC-2H SAC01/QKA10 PM1	Initiator - Fire in the Pump Room of Any Safeguard Building Consequential LOOP and Failure of Recovery Within 1 Hour for Fire IEs Leading to a Controlled Shutdn Operator Fails to Recover Room Cooling Locally Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
3	4.535E-10	3.62	IE FIRE-SAB-MECH LOOPFCSD+REC OPF-SAC-2H QKA10GH001_FS	Initiator - Fire in the Pump Room of Any Safeguard Building Consequential LOOP and Failure of Recovery Within 1 Hour for Fire IEs Leading to a Controlled Shutdn Operator Fails to Recover Room Cooling Locally SCWS, Train 1 Chiller Unit QKA10GH001, Fails to Start on Demand
4	3.744E-10	2.99	IE FIRE-SAB-MECH LOOP24+REC OPF-SAC-2H SAC01/QKA10 PM1	Initiator - Fire in the Pump Room of Any Safeguard Building Loss Of Offsite Power During Mission Time and Failure of Recovery Within 1 Hour Operator Fails to Recover Room Cooling Locally Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
5	1.814E-10	1.45	IE FIRE-SAB-MECH OPF-SAC-2H PAS QKA10GH001_FR	Initiator - Fire in the Pump Room of Any Safeguard Building Operator Fails to Recover Room Cooling Locally Process Automation System (PAS) Fails (Estimate) SCWS, Train 1 Chiller Unit QKA10GH001, Fails to Run
6	9.062E-11	0.72	IE FIRE-SAB-MECH OPF-SAC-2H PAS SAC31AN001EFR	Initiator - Fire in the Pump Room of Any Safeguard Building Operator Fails to Recover Room Cooling Locally Process Automation System (PAS) Fails (Estimate) SAC, Normal Air Exhaust Fan SAC31AN001, Fails to Run

IE FIRE-SAB-078:0015

No.	Prob.	%	Event	Description
7	9.062E-11	0.72	IE FIRE-SAB-MECH OPF-SAC-2H PAS SAC01AN001EFR	Initiator - Fire in the Pump Room of Any Safeguard Building Operator Fails to Recover Room Cooling Locally Process Automation System (PAS) Fails (Estimate) SAC, Normal Air Supply Fan SAC01AN001, Fails to Run
8	6.529E-11	0.52	IE FIRE-SAB-MECH LOOPFCSD+REC OPF-SAC-2H QKA10GH001_FR	Initiator - Fire in the Pump Room of Any Safeguard Building Consequential LOOP and Failure of Recovery Within 1 Hour for Fire IEs Leading to a Controlled Shutdn Operator Fails to Recover Room Cooling Locally SCWS, Train 1 Chiller Unit QKA10GH001, Fails to Run
9	6.171E-11	0.49	IE FIRE-SAB-MECH OPF-SAC-2H PAS QKA10AP107EFR	Initiator - Fire in the Pump Room of Any Safeguard Building Operator Fails to Recover Room Cooling Locally Process Automation System (PAS) Fails (Estimate) SCWS, Train 1 Motor Driven Safety Chiller Pump QKA10AP107, Fails to Run

Minimal Cutsets

Top Event probability Q = 1.717E-08

No.	Prob.	%	Event	Description
1	8.854E-10	5.16	IE FIRE-SAB14-AC CVCS VCT KAA12AA005EFO_DCCF to Open CCWS to LHSI HTX Cooling MOV -ALL PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) CVCS Switchover to IRWST May Not Be Required Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
2	7.412E-10	4.32	IE FIRE-SAB14-AC CVCS VCT PED10AN002EFS_DCCF to Start Standby Cooling Tower Fans -ALL PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) CVCS Switchover to IRWST May Not Be Required Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
3	4.609E-10	2.68	IE FIRE-SAB14-AC CVCS VCT PED10AN002EFS_DCCF to Start Standby Cooling Tower Fans -123 PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) CVCS Switchover to IRWST May Not Be Required Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
4	3.607E-10	2.10	IE FIRE-SAB14-AC CVCS VCT KAA12AA005EFO_DCCF to Open CCWS to LHSI HTX Cooling MOV -123 PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) CVCS Switchover to IRWST May Not Be Required Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
5	1.579E-10	0.92	IE FIRE-SAB14-AC CVCS VCT LHSI PM1 PEB20AP001EFS_B CCF of ESWS Pumps 2 and 3 to Start (Standby) -ALL PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) CVCS Switchover to IRWST May Not Be Required LHSI Train 1 Unavailable due to Preventive Maintenance Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
6	1.536E-10	0.89	IE FIRE-SAB14-AC CCWS/ESWS PM3 CVCS VCT JNG10AA006MEC3 JNG20AA006MEC3 PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) CCWS/ESWS Train 3 Pump Unavailable due to Preventive Maintenance CVCS Switchover to IRWST May Not Be Required LHSI, LHSI CL1 Discharge Manual CHECK Valve JNG10AA006, Left in Wrong Position LHSI, LHSI CL2 Discharge Manual CHECK Valve JNG20AA006, Left in Wrong Position Probability of Seal LOCA Occurring Given a Loss of Seal Cooling

IE FIRE-SAB1072:0019

No.	Prob.	%	Event	Description
7	1.184E-10	0.69	IE FIRE-SAB14-AC CVCS VCT PEB20AP001EFS_B -ALL PROB SEAL LOCA SAC01/QKA10 PM1	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) CVCS Switchover to IRWST May Not Be Required CCF of ESWS Pumps 2 and 3 to Start (Standby) Probability of Seal LOCA Occurring Given a Loss of Seal Cooling Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
8	1.076E-10	0.63	IE FIRE-SAB14-AC CVCS VCT KAA20AP001EFS_B -ALL LHSI PM1 PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) CVCS Switchover to IRWST May Not Be Required CCF of CCWS Pumps 2 and 3 to Start (Standby) LHSI Train 1 Unavailable due to Preventive Maintenance Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
9	1.067E-10	0.62	IE FIRE-SAB14-AC CVCS VCT PED10AN002EFR_ D-ALL PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) CVCS Switchover to IRWST May Not Be Required CCF to Run Standby Cooling Tower Fans Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
10	1.067E-10	0.62	IE FIRE-SAB14-AC CVCS VCT PED10AN001EFR_ D-ALL PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) CVCS Switchover to IRWST May Not Be Required CCF to Run Normally Running Cooling Tower Fans Probability of Seal LOCA Occurring Given a Loss of Seal Cooling

Minimal Cutsets

Top Event probability Q = 5.785E-08

No.	Prob.	%	Event	Description
1	6.133E-09	10.60	IE FIRE-SAB14-AC	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4)
			32BRA____RFR	ELEC, 480V AC to 24V DC Rectifier for MCC 32BRA Control Power, Fails to Run
			CVCS VCT	CVCS Switchover to IRWST May Not Be Required
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
2	6.133E-09	10.60	IE FIRE-SAB14-AC	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4)
			31BRA____RFR	ELEC, 480V AC to 24V DC Rectifier for MCC 31BRA Control Power, Fails to Run
			CVCS VCT	CVCS Switchover to IRWST May Not Be Required
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
3	4.320E-09	7.47	IE FIRE-SAB14-AC	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4)
			CCWS/ESWS PM2	CCWS/ESWS Train 2 Pump Unavailable due to Preventive Maintenance
			LOOPFCSD+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for Fire IEs Leading to a Controlled Shutdn
			OPF-XTDIV-NSC	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions
PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling			
4	2.880E-09	4.98	IE FIRE-SAB14-AC	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4)
			EDG PM2	EDG Train 2 Unavailable due to Preventive Maintenance
			LOOPFCSD+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for Fire IEs Leading to a Controlled Shutdn
			OPF-XTDIV-NSC	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions
PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling			
5	1.983E-09	3.43	IE FIRE-SAB14-AC	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4)
			LOOPFCSD+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for Fire IEs Leading to a Controlled Shutdn
			OPF-XTDIV-NSC	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
XKA20____DFR	ELEC, Emergency Diesel Generator XKA20, Fails to Run			
6	1.485E-09	2.57	IE FIRE-SAB14-AC	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4)
			CVCS VCT	CVCS Switchover to IRWST May Not Be Required
			LBA13AA001PFO_D CCF to Open Main Steam Relief Isolation Valves -ALL	
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling

IE FIRE-SAB1072:0032

No.	Prob.	%	Event	Description
7	9.600E-10	1.66	IE FIRE-SAB14-AC 32BMT02___TFL CVCS VCT OPF-XTIE BC PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) ELEC, 6.9kV-480V Transformer 32BMT02, Fails During Operation CVCS Switchover to IRWST May Not Be Required Operator Fails to Align Backup Battery Charger to BUC Bus Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
8	9.600E-10	1.66	IE FIRE-SAB14-AC 31BMB___OFL CVCS VCT OPF-XTIE BC PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) ELEC, 480V Load Center 31BMB, Fails During Operation CVCS Switchover to IRWST May Not Be Required Operator Fails to Align Backup Battery Charger to BUC Bus Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
9	9.600E-10	1.66	IE FIRE-SAB14-AC 32BMB___OFL CVCS VCT OPF-XTIE BC PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) ELEC, 480V Load Center 32BMB, Fails During Operation CVCS Switchover to IRWST May Not Be Required Operator Fails to Align Backup Battery Charger to BUC Bus Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
10	9.600E-10	1.66	IE FIRE-SAB14-AC 31BRA___OFL CVCS VCT PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) ELEC, 480V MCC 31BRA, Fails During Operation CVCS Switchover to IRWST May Not Be Required Probability of Seal LOCA Occurring Given a Loss of Seal Cooling

Minimal Cutsets

Top Event probability Q = 7.520E-09

No.	Prob.	%	Event	Description
1	7.973E-10	10.60	IE FIRE-SAB14-AC 31BRA____RFR CVCS VCT OPE-FB-40M PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) ELEC, 480V AC to 24V DC Rectifier for MCC 31BRA Control Power, Fails to Run CVCS Switchover to IRWST May Not Be Required Operator Fails to Initiate Feed & Bleed for SLOCA Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
2	7.973E-10	10.60	IE FIRE-SAB14-AC 32BRA____RFR CVCS VCT OPE-FB-40M PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) ELEC, 480V AC to 24V DC Rectifier for MCC 32BRA Control Power, Fails to Run CVCS Switchover to IRWST May Not Be Required Operator Fails to Initiate Feed & Bleed for SLOCA Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
3	5.616E-10	7.47	IE FIRE-SAB14-AC CCWS/ESWS PM2 LOOPFCSD+REC OPE-FB-40M OPF-XTDIV-NSC PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) CCWS/ESWS Train 2 Pump Unavailable due to Preventive Maintenance Consequential LOOP and Failure of Recovery Within 1 Hour for Fire IEs Leading to a Controlled Shutdn Operator Fails to Initiate Feed & Bleed for SLOCA Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
4	3.744E-10	4.98	IE FIRE-SAB14-AC EDG PM2 LOOPFCSD+REC OPE-FB-40M OPF-XTDIV-NSC PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) EDG Train 2 Unavailable due to Preventive Maintenance Consequential LOOP and Failure of Recovery Within 1 Hour for Fire IEs Leading to a Controlled Shutdn Operator Fails to Initiate Feed & Bleed for SLOCA Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
5	2.578E-10	3.43	IE FIRE-SAB14-AC LOOPFCSD+REC OPE-FB-40M OPF-XTDIV-NSC PROB SEAL LOCA XKA20____DFR	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) Consequential LOOP and Failure of Recovery Within 1 Hour for Fire IEs Leading to a Controlled Shutdn Operator Fails to Initiate Feed & Bleed for SLOCA Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions Probability of Seal LOCA Occurring Given a Loss of Seal Cooling ELEC, Emergency Diesel Generator XKA20, Fails to Run

IE FIRE-SAB1072:0033

No.	Prob.	%	Event	Description
6	1.930E-10	2.57	IE FIRE-SAB14-AC CVCS VCT LBA13AA001PFO_D -ALL OPE-FB-40M PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) CVCS Switchover to IRWST May Not Be Required CCF to Open Main Steam Relief Isolation Valves Operator Fails to Initiate Feed & Bleed for SLOCA Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
7	1.248E-10	1.66	IE FIRE-SAB14-AC 32BMB____OFL CVCS VCT OPE-FB-40M OPF-XTIE BC PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) ELEC, 480V Load Center 32BMB, Fails During Operation CVCS Switchover to IRWST May Not Be Required Operator Fails to Initiate Feed & Bleed for SLOCA Operator Fails to Align Backup Battery Charger to BUC Bus Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
8	1.248E-10	1.66	IE FIRE-SAB14-AC 31BDA____OFL OPE-FB-40M OPF-XTLDSBO-NS C PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) ELEC, 6.9kV Switchgear 31BDA, Fails During Operation Operator Fails to Initiate Feed & Bleed for SLOCA Operator Fails to Connect and Load SBO DGs to Div 1 or 4 During Non-SBO Conditions Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
9	1.248E-10	1.66	IE FIRE-SAB14-AC 31BDC____OFL CVCS VCT OPE-FB-40M PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) ELEC, 6.9kV SWGR 31BDC, Fails During Operation CVCS Switchover to IRWST May Not Be Required Operator Fails to Initiate Feed & Bleed for SLOCA Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
10	1.248E-10	1.66	IE FIRE-SAB14-AC 31BDB____OFL CVCS VCT OPE-FB-40M OPF-XTIE BC PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) ELEC, 6.9kV SWGR 31BDB, Fails During Operation CVCS Switchover to IRWST May Not Be Required Operator Fails to Initiate Feed & Bleed for SLOCA Operator Fails to Align Backup Battery Charger to BUC Bus Probability of Seal LOCA Occurring Given a Loss of Seal Cooling

IE FIRE-SWGR:0013

Minimal Cutsets

Top Event probability Q = 2.156E-08

No.	Prob.	%	Event	Description
1	8.963E-10	4.16	IE FIRE-SWGR OPF-SAC-2H QKA10GH001_FR_ B-ALL	Initiator - Fire in the Switchgear Building Operator Fails to Recover Room Cooling Locally CCF of the Air Cooled SCWS Chiller Units to Run
2	8.433E-10	3.91	IE FIRE-SWGR OPF-SAC-2H QKA40GH001_FR SAC01/QKA10 PM1	Initiator - Fire in the Switchgear Building Operator Fails to Recover Room Cooling Locally SCWS, Train 4 Chiller Unit QKA40GH001, Fails to Run Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
3	8.433E-10	3.91	IE FIRE-SWGR OPF-SAC-2H QKA10GH001_FR SAC04/QKA40 PM4	Initiator - Fire in the Switchgear Building Operator Fails to Recover Room Cooling Locally SCWS, Train 1 Chiller Unit QKA10GH001, Fails to Run Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance
4	8.433E-10	3.91	IE FIRE-SWGR OPF-SAC-2H QKA40GH001_FR SAC02/QKA20 PM2	Initiator - Fire in the Switchgear Building Operator Fails to Recover Room Cooling Locally SCWS, Train 4 Chiller Unit QKA40GH001, Fails to Run Normal SAC02/QKA20 Train Unavailable due to Preventive Maintenance
5	8.433E-10	3.91	IE FIRE-SWGR OPF-SAC-2H QKA30GH001_FR SAC01/QKA10 PM1	Initiator - Fire in the Switchgear Building Operator Fails to Recover Room Cooling Locally SCWS, Train 3 Chiller Unit QKA30GH001, Fails to Run Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
6	8.433E-10	3.91	IE FIRE-SWGR OPF-SAC-2H QKA20GH001_FR SAC04/QKA40 PM4	Initiator - Fire in the Switchgear Building Operator Fails to Recover Room Cooling Locally SCWS, Train 2 Chiller Unit QKA20GH001, Fails to Run Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance
7	8.433E-10	3.91	IE FIRE-SWGR OPF-SAC-2H QKA10GH001_FR SAC03/QKA30 PM3	Initiator - Fire in the Switchgear Building Operator Fails to Recover Room Cooling Locally SCWS, Train 1 Chiller Unit QKA10GH001, Fails to Run Normal SAC03/QKA30 Train Unavailable due to Preventive Maintenance
8	5.736E-10	2.66	IE FIRE-SWGR LOOPCON+REC XKA10____DFR_D -ALL	Initiator - Fire in the Switchgear Building Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram CCF of EDGs to Run

IE FIRE-SWGR:0013

No.	Prob.	%	Event	Description
9	4.214E-10	1.95	IE FIRE-SWGR	Initiator - Fire in the Switchgear Building
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			SAC04/QKA40 PM4	Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance
			SAC31AN001EFR	SAC, Normal Air Exhaust Fan SAC31AN001, Fails to Run
10	4.214E-10	1.95	IE FIRE-SWGR	Initiator - Fire in the Switchgear Building
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			SAC01/QKA10 PM1	Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
			SAC03AN001EFR	SAC, Normal Air Supply Fan SAC03AN001, Fails to Run

Minimal Cutsets

Top Event probability Q = 2.733E-08

No.	Prob.	%	Event	Description
1	2.626E-08	96.07	IE FIRE-MS-VR	Initiator - Fire in One of Two MF/MS Valve Rooms With Spurious Opening of 1 MSRV
			MSIV TR3 ISO-FIRE	MSIV 3 Fails to Isolate Due to Fire in MS/FW Valve Room
			MSIV TR4 ISO-FIRE	MSIV 4 Fails to Isolate Due to Fire in MS/FW Valve Room
			OPE-RHR-4H	Operator Fails to Initiate RHR Within 4 Hours

SD LOCA C:0029 CBD

Minimal Cutsets

Top Event frequency F = 1.313E-09

No.	Freq.	%	Event	Description
1	1.917E-11	1.46	IE SD LOCA CBD JND10AP001EFR_D CCF of MHSI Pumps to Run -ALL JNG20AA192SPO JNK11AA009EFO OPF-ISORHRFD-CB Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB	Initiator - LOCA During Shutdown State CBd LHSI, LHSI/RHR Train 20 Overpressure Protection Safety Valve JNG20AA192, Premature Opening IRWST, SAHR Sump Containment Isolation MOV JNK11AA009, Fails to Open on Demand
2	1.917E-11	1.46	IE SD LOCA CBD JND10AP001EFR_D CCF of MHSI Pumps to Run -ALL JNG10AA192SPO JNK11AA009EFO OPF-ISORHRFD-CB Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB	Initiator - LOCA During Shutdown State CBd LHSI, LHSI/RHR Train 10 Overpressure Protection Safety Valve JNG10AA192, Premature Opening IRWST, SAHR Sump Containment Isolation MOV JNK11AA009, Fails to Open on Demand
3	1.917E-11	1.46	IE SD LOCA CBD JNA20AA191SPO JND10AP001EFR_D CCF of MHSI Pumps to Run -ALL JNK11AA009EFO OPF-ISORHRFD-CB Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB	Initiator - LOCA During Shutdown State CBd RHR, LHSI Train 2 Safety Valve JNA20AA191, Premature Opening IRWST, SAHR Sump Containment Isolation MOV JNK11AA009, Fails to Open on Demand
4	1.917E-11	1.46	IE SD LOCA CBD JNA10AA191SPO JND10AP001EFR_D CCF of MHSI Pumps to Run -ALL JNK11AA009EFO OPF-ISORHRFD-CB Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB	Initiator - LOCA During Shutdown State CBd RHR, LHSI Train 1 Safety Valve JNA10AA191, Premature Opening IRWST, SAHR Sump Containment Isolation MOV JNK11AA009, Fails to Open on Demand
5	1.917E-11	1.46	IE SD LOCA CBD JND10AP001EFR_D CCF of MHSI Pumps to Run -ALL JNG30AA192SPO JNK11AA009EFO OPF-ISORHRFD-CB Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB	Initiator - LOCA During Shutdown State CBd LHSI, LHSI/RHR Train 30 Overpressure Protection Safety Valve JNG30AA192, Premature Opening IRWST, SAHR Sump Containment Isolation MOV JNK11AA009, Fails to Open on Demand

SD LOCA C:0029 CBD

No.	Freq.	%	Event	Description
6	1.917E-11	1.46	IE SD LOCA CBD JNA30AA191SPO JND10AP001EFR_D -ALL JNK11AA009EFO OPF-ISORHRFD-CB	Initiator - LOCA During Shutdown State CBd RHR, LHSI Train 3 Safety Valve JNA30AA191, Premature Opening CCF of MHSI Pumps to Run IRWST, SAHR Sump Containment Isolation MOV JNK11AA009, Fails to Open on Demand Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB
7	1.917E-11	1.46	IE SD LOCA CBD JMQ40AA001EFO JNA10AA191SPO JND10AP001EFR_D -ALL OPF-ISORHRFD-CB	Initiator - LOCA During Shutdown State CBd SAHR, Suction Line Containment Isolation MOV JMQ40AA001, Fails to Open on Demand RHR, LHSI Train 1 Safety Valve JNA10AA191, Premature Opening CCF of MHSI Pumps to Run Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB
8	1.917E-11	1.46	IE SD LOCA CBD JMQ42AA001EFO JNA10AA191SPO JND10AP001EFR_D -ALL OPF-ISORHRFD-CB	Initiator - LOCA During Shutdown State CBd SAHR, Active Cooling Line MOV JMQ42AA001, Fails to Open on Demand RHR, LHSI Train 1 Safety Valve JNA10AA191, Premature Opening CCF of MHSI Pumps to Run Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB
9	1.917E-11	1.46	IE SD LOCA CBD JMQ42AA001EFO JND10AP001EFR_D -ALL JNG10AA192SPO OPF-ISORHRFD-CB	Initiator - LOCA During Shutdown State CBd SAHR, Active Cooling Line MOV JMQ42AA001, Fails to Open on Demand CCF of MHSI Pumps to Run LHSI, LHSI/RHR Train 10 Overpressure Protection Safety Valve JNG10AA192, Premature Opening Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB
10	1.917E-11	1.46	IE SD LOCA CBD JMQ40AA001EFO JNA30AA191SPO JND10AP001EFR_D -ALL OPF-ISORHRFD-CB	Initiator - LOCA During Shutdown State CBd SAHR, Suction Line Containment Isolation MOV JMQ40AA001, Fails to Open on Demand RHR, LHSI Train 3 Safety Valve JNA30AA191, Premature Opening CCF of MHSI Pumps to Run Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB

SD LOCA C:0029 CBU

Minimal Cutsets

Top Event frequency F = 6.495E-10

No.	Freq.	%	Event	Description
1	1.437E-11	2.21	IE SD LOCA CBU JNA20AA191SPO JND10AP001EFR_D CCF of MHSI Pumps to Run -ALL JNK11AA009EFO OPF-ISORHRFD-CB Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB	Initiator - LOCA During Shutdown State CBU RHR, LHSI Train 2 Safety Valve JNA20AA191, Premature Opening IRWST, SAHR Sump Containment Isolation MOV JNK11AA009, Fails to Open on Demand
2	1.437E-11	2.21	IE SD LOCA CBU JNA10AA191SPO JND10AP001EFR_D CCF of MHSI Pumps to Run -ALL JNK11AA009EFO OPF-ISORHRFD-CB Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB	Initiator - LOCA During Shutdown State CBU RHR, LHSI Train 1 Safety Valve JNA10AA191, Premature Opening IRWST, SAHR Sump Containment Isolation MOV JNK11AA009, Fails to Open on Demand
3	1.437E-11	2.21	IE SD LOCA CBU JND10AP001EFR_D CCF of MHSI Pumps to Run -ALL JNG20AA192SPO JNK11AA009EFO OPF-ISORHRFD-CB Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB	Initiator - LOCA During Shutdown State CBU LHSI, LHSI/RHR Train 20 Overpressure Protection Safety Valve JNG20AA192, Premature Opening IRWST, SAHR Sump Containment Isolation MOV JNK11AA009, Fails to Open on Demand
4	1.437E-11	2.21	IE SD LOCA CBU JND10AP001EFR_D CCF of MHSI Pumps to Run -ALL JNG10AA192SPO JNK11AA009EFO OPF-ISORHRFD-CB Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB	Initiator - LOCA During Shutdown State CBU LHSI, LHSI/RHR Train 10 Overpressure Protection Safety Valve JNG10AA192, Premature Opening IRWST, SAHR Sump Containment Isolation MOV JNK11AA009, Fails to Open on Demand
5	1.437E-11	2.21	IE SD LOCA CBU JMQ40AA001EFO JND10AP001EFR_D CCF of MHSI Pumps to Run -ALL JNG10AA192SPO OPF-ISORHRFD-CB Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB	Initiator - LOCA During Shutdown State CBU SAHR, Suction Line Containment Isolation MOV JMQ40AA001, Fails to Open on Demand LHSI, LHSI/RHR Train 10 Overpressure Protection Safety Valve JNG10AA192, Premature Opening

SD LOCA C:0029 CBU

No.	Freq.	%	Event	Description
6	1.437E-11	2.21	IE SD LOCA CBU	Initiator - LOCA During Shutdown State CBU
			JMQ40AA001EFO	SAHR, Suction Line Containment Isolation MOV JMQ40AA001, Fails to Open on Demand
			JND10AP001EFR_D	CCF of MHSI Pumps to Run -ALL
			JNG20AA192SPO	LHSI, LHSI/RHR Train 20 Overpressure Protection Safety Valve JNG20AA192, Premature Opening
			OPF-ISORHRFD-CB	Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB
7	1.437E-11	2.21	IE SD LOCA CBU	Initiator - LOCA During Shutdown State CBU
			JMQ42AA001EFO	SAHR, Active Cooling Line MOV JMQ42AA001, Fails to Open on Demand
			JNA20AA191SPO	RHR, LHSI Train 2 Safety Valve JNA20AA191, Premature Opening
			JND10AP001EFR_D	CCF of MHSI Pumps to Run -ALL
			OPF-ISORHRFD-CB	Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB
8	1.437E-11	2.21	IE SD LOCA CBU	Initiator - LOCA During Shutdown State CBU
			JMQ40AA001EFO	SAHR, Suction Line Containment Isolation MOV JMQ40AA001, Fails to Open on Demand
			JNA20AA191SPO	RHR, LHSI Train 2 Safety Valve JNA20AA191, Premature Opening
			JND10AP001EFR_D	CCF of MHSI Pumps to Run -ALL
			OPF-ISORHRFD-CB	Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB
9	1.437E-11	2.21	IE SD LOCA CBU	Initiator - LOCA During Shutdown State CBU
			JMQ42AA001EFO	SAHR, Active Cooling Line MOV JMQ42AA001, Fails to Open on Demand
			JNA10AA191SPO	RHR, LHSI Train 1 Safety Valve JNA10AA191, Premature Opening
			JND10AP001EFR_D	CCF of MHSI Pumps to Run -ALL
			OPF-ISORHRFD-CB	Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB
10	1.437E-11	2.21	IE SD LOCA CBU	Initiator - LOCA During Shutdown State CBU
			JMQ42AA001EFO	SAHR, Active Cooling Line MOV JMQ42AA001, Fails to Open on Demand
			JND10AP001EFR_D	CCF of MHSI Pumps to Run -ALL
			JNG20AA192SPO	LHSI, LHSI/RHR Train 20 Overpressure Protection Safety Valve JNG20AA192, Premature Opening
			OPF-ISORHRFD-CB	Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB

SD LOCA C:0030 CBD

Minimal Cutsets

Top Event frequency F = 6.068E-09

No.	Freq.	%	Event	Description
1	6.446E-10	10.62	IE SD LOCA CBD JNA10AA191SPO JNG13AA005CFO_ D-ALL OPF-ISORHRFD-CB	Initiator - LOCA During Shutdown State CBd RHR, LHSI Train 1 Safety Valve JNA10AA191, Premature Opening CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves) Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB
2	6.446E-10	10.62	IE SD LOCA CBD JNA30AA191SPO JNG13AA005CFO_ D-ALL OPF-ISORHRFD-CB	Initiator - LOCA During Shutdown State CBd RHR, LHSI Train 3 Safety Valve JNA30AA191, Premature Opening CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves) Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB
3	6.446E-10	10.62	IE SD LOCA CBD JNA20AA191SPO JNG13AA005CFO_ D-ALL OPF-ISORHRFD-CB	Initiator - LOCA During Shutdown State CBd RHR, LHSI Train 2 Safety Valve JNA20AA191, Premature Opening CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves) Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB
4	6.446E-10	10.62	IE SD LOCA CBD JNG10AA192SPO JNG13AA005CFO_ D-ALL OPF-ISORHRFD-CB	Initiator - LOCA During Shutdown State CBd LHSI, LHSI/RHR Train 10 Overpressure Protection Safety Valve JNG10AA192, Premature Opening CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves) Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB
5	6.446E-10	10.62	IE SD LOCA CBD JNG13AA005CFO_ D-ALL JNG20AA192SPO OPF-ISORHRFD-CB	Initiator - LOCA During Shutdown State CBd CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves) LHSI, LHSI/RHR Train 20 Overpressure Protection Safety Valve JNG20AA192, Premature Opening Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB
6	6.446E-10	10.62	IE SD LOCA CBD JNG13AA005CFO_ D-ALL JNG30AA192SPO OPF-ISORHRFD-CB	Initiator - LOCA During Shutdown State CBd CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves) LHSI, LHSI/RHR Train 30 Overpressure Protection Safety Valve JNG30AA192, Premature Opening Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB

SD LOCA C:0030 CBD

No.	Freq.	%	Event	Description
7	1.074E-10	1.77	IE SD LOCA CBD JND30AA003CIR JNG13AA005CFO_ D-ALL OPF-ISORHRFD-CB	Initiator - LOCA During Shutdown State CBd MHSI, MHSI Pump 30 Discharge Manual CHECK Valve JND30AA003, Internal Rupture CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves) Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB
8	1.074E-10	1.77	IE SD LOCA CBD JND10AA003CIR JNG13AA005CFO_ D-ALL OPF-ISORHRFD-CB	Initiator - LOCA During Shutdown State CBd MHSI, MHSI Pump 10 Discharge Manual CHECK Valve JND10AA003, Internal Rupture CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves) Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB
9	1.074E-10	1.77	IE SD LOCA CBD JND20AA003CIR JNG13AA005CFO_ D-ALL OPF-ISORHRFD-CB	Initiator - LOCA During Shutdown State CBd MHSI, MHSI Pump 20 Discharge Manual CHECK Valve JND20AA003, Internal Rupture CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves) Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB
10	8.137E-11	1.34	IE SD LOCA CBD JNA30AA191SPO JNK10AT001SPG_P -ALL OPF-ISORHRFD-CB	Initiator - LOCA During Shutdown State CBd RHR, LHSI Train 3 Safety Valve JNA30AA191, Premature Opening CCF of IRWST Sump Strainers - Plugged Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB

SD LOCA C:0030 CBU

Minimal Cutsets

Top Event frequency F = 3.039E-09

No.	Freq.	%	Event	Description
1	4.835E-10	15.91	IE SD LOCA CBU	Initiator - LOCA During Shutdown State CBU
			JNG10AA192SPO	LHSI, LHSI/RHR Train 10 Overpressure Protection Safety Valve JNG10AA192, Premature Opening
			JNG13AA005CFO_ D-ALL	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves)
			OPF-ISORHRFD-CB	Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB
2	4.835E-10	15.91	IE SD LOCA CBU	Initiator - LOCA During Shutdown State CBU
			JNA20AA191SPO	RHR, LHSI Train 2 Safety Valve JNA20AA191, Premature Opening
			JNG13AA005CFO_ D-ALL	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves)
			OPF-ISORHRFD-CB	Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB
3	4.835E-10	15.91	IE SD LOCA CBU	Initiator - LOCA During Shutdown State CBU
			JNG13AA005CFO_ D-ALL	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves)
			JNG20AA192SPO	LHSI, LHSI/RHR Train 20 Overpressure Protection Safety Valve JNG20AA192, Premature Opening
			OPF-ISORHRFD-CB	Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB
4	4.835E-10	15.91	IE SD LOCA CBU	Initiator - LOCA During Shutdown State CBU
			JNA10AA191SPO	RHR, LHSI Train 1 Safety Valve JNA10AA191, Premature Opening
			JNG13AA005CFO_ D-ALL	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves)
			OPF-ISORHRFD-CB	Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB
5	8.058E-11	2.65	IE SD LOCA CBU	Initiator - LOCA During Shutdown State CBU
			JND20AA003CIR	MHSI, MHSI Pump 20 Discharge Manual CHECK Valve JND20AA003, Internal Rupture
			JNG13AA005CFO_ D-ALL	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves)
			OPF-ISORHRFD-CB	Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB
6	8.058E-11	2.65	IE SD LOCA CBU	Initiator - LOCA During Shutdown State CBU
			JND10AA003CIR	MHSI, MHSI Pump 10 Discharge Manual CHECK Valve JND10AA003, Internal Rupture
			JNG13AA005CFO_ D-ALL	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves)
			OPF-ISORHRFD-CB	Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB

SD LOCA C:0030 CBU

No.	Freq.	%	Event	Description
7	6.103E-11	2.01	IE SD LOCA CBU JNA20AA191SPO JNK10AT001SPG_P -ALL OPF-ISORHRFD-CB Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB	Initiator - LOCA During Shutdown State CBU RHR, LHSI Train 2 Safety Valve JNA20AA191, Premature Opening CCF of IRWST Sump Strainers - Plugged -ALL OPF-ISORHRFD-CB Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB
8	6.103E-11	2.01	IE SD LOCA CBU JNA10AA191SPO JNK10AT001SPG_P -ALL OPF-ISORHRFD-CB Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB	Initiator - LOCA During Shutdown State CBU RHR, LHSI Train 1 Safety Valve JNA10AA191, Premature Opening CCF of IRWST Sump Strainers - Plugged -ALL OPF-ISORHRFD-CB Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB
9	6.103E-11	2.01	IE SD LOCA CBU JNG20AA192SPO JNK10AT001SPG_P -ALL OPF-ISORHRFD-CB Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB	Initiator - LOCA During Shutdown State CBU LHSI, LHSI/RHR Train 20 Overpressure Protection Safety Valve JNG20AA192, Premature Opening CCF of IRWST Sump Strainers - Plugged -ALL OPF-ISORHRFD-CB Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB
10	6.103E-11	2.01	IE SD LOCA CBU JNG10AA192SPO JNK10AT001SPG_P -ALL OPF-ISORHRFD-CB Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB	Initiator - LOCA During Shutdown State CBU LHSI, LHSI/RHR Train 10 Overpressure Protection Safety Valve JNG10AA192, Premature Opening CCF of IRWST Sump Strainers - Plugged -ALL OPF-ISORHRFD-CB Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB

Minimal Cutsets

Top Event frequency F = 1.351E-09

No.	Freq.	%	Event	Description
1	1.612E-10	11.93	IE SD LOCA DD	Initiator - LOCA During Shutdown State Dd
			JNG13AA005CFO_ D-ALL	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves)
			JNG20AA192SPO	LHSI, LHSI/RHR Train 20 Overpressure Protection Safety Valve JNG20AA192, Premature Opening
			OPF-ISORHRFD-D	Operator Fails to Isolate RHR Flow Diversion (LOCA) in State D
2	1.612E-10	11.93	IE SD LOCA DD	Initiator - LOCA During Shutdown State Dd
			JNG13AA005CFO_ D-ALL	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves)
			JNG30AA192SPO	LHSI, LHSI/RHR Train 30 Overpressure Protection Safety Valve JNG30AA192, Premature Opening
			OPF-ISORHRFD-D	Operator Fails to Isolate RHR Flow Diversion (LOCA) in State D
3	1.612E-10	11.93	IE SD LOCA DD	Initiator - LOCA During Shutdown State Dd
			JNA10AA191SPO	RHR, LHSI Train 1 Safety Valve JNA10AA191, Premature Opening
			JNG13AA005CFO_ D-ALL	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves)
			OPF-ISORHRFD-D	Operator Fails to Isolate RHR Flow Diversion (LOCA) in State D
4	1.612E-10	11.93	IE SD LOCA DD	Initiator - LOCA During Shutdown State Dd
			JNA20AA191SPO	RHR, LHSI Train 2 Safety Valve JNA20AA191, Premature Opening
			JNG13AA005CFO_ D-ALL	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves)
			OPF-ISORHRFD-D	Operator Fails to Isolate RHR Flow Diversion (LOCA) in State D
5	1.612E-10	11.93	IE SD LOCA DD	Initiator - LOCA During Shutdown State Dd
			JNG10AA192SPO	LHSI, LHSI/RHR Train 10 Overpressure Protection Safety Valve JNG10AA192, Premature Opening
			JNG13AA005CFO_ D-ALL	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves)
			OPF-ISORHRFD-D	Operator Fails to Isolate RHR Flow Diversion (LOCA) in State D
6	2.686E-11	1.99	IE SD LOCA DD	Initiator - LOCA During Shutdown State Dd
			JND30AA003CIR	MHSI, MHSI Pump 30 Discharge Manual CHECK Valve JND30AA003, Internal Rupture
			JNG13AA005CFO_ D-ALL	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves)
			OPF-ISORHRFD-D	Operator Fails to Isolate RHR Flow Diversion (LOCA) in State D
7	2.686E-11	1.99	IE SD LOCA DD	Initiator - LOCA During Shutdown State Dd
			JND10AA003CIR	MHSI, MHSI Pump 10 Discharge Manual CHECK Valve JND10AA003, Internal Rupture
			JNG13AA005CFO_ D-ALL	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves)
			OPF-ISORHRFD-D	Operator Fails to Isolate RHR Flow Diversion (LOCA) in State D

SD LOCA D E:0003 DD

No.	Freq.	%	Event	Description
8	2.686E-11	1.99	IE SD LOCA DD	Initiator - LOCA During Shutdown State Dd
			JND20AA003CIR	MHSI, MHSI Pump 20 Discharge Manual CHECK Valve JND20AA003, Internal Rupture
			JNG13AA005CFO_ D-ALL	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves)
			OPF-ISORHRFD-D	Operator Fails to Isolate RHR Flow Diversion (LOCA) in State D
9	2.034E-11	1.51	IE SD LOCA DD	Initiator - LOCA During Shutdown State Dd
			JNA10AA191SPO	RHR, LHSI Train 1 Safety Valve JNA10AA191, Premature Opening
			JNK10AT001SPG_P -ALL	CCF of IRWST Sump Strainers - Plugged
			OPF-ISORHRFD-D	Operator Fails to Isolate RHR Flow Diversion (LOCA) in State D
10	2.034E-11	1.51	IE SD LOCA DD	Initiator - LOCA During Shutdown State Dd
			JNA20AA191SPO	RHR, LHSI Train 2 Safety Valve JNA20AA191, Premature Opening
			JNK10AT001SPG_P -ALL	CCF of IRWST Sump Strainers - Plugged
			OPF-ISORHRFD-D	Operator Fails to Isolate RHR Flow Diversion (LOCA) in State D

Minimal Cutsets

Top Event frequency F = 3.079E-09

No.	Freq.	%	Event	Description
1	4.835E-10	15.70	IE SD LOCA DU JNA10AA191SPO JNG13AA005CFO_ D-ALL OPF-ISORHRFD-D	Initiator - LOCA During Shutdown State Du RHR, LHSI Train 1 Safety Valve JNA10AA191, Premature Opening CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves) Operator Fails to Isolate RHR Flow Diversion (LOCA) in State D
2	4.835E-10	15.70	IE SD LOCA DU JNG10AA192SPO JNG13AA005CFO_ D-ALL OPF-ISORHRFD-D	Initiator - LOCA During Shutdown State Du LHSI, LHSI/RHR Train 10 Overpressure Protection Safety Valve JNG10AA192, Premature Opening CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves) Operator Fails to Isolate RHR Flow Diversion (LOCA) in State D
3	4.835E-10	15.70	IE SD LOCA DU JNA20AA191SPO JNG13AA005CFO_ D-ALL OPF-ISORHRFD-D	Initiator - LOCA During Shutdown State Du RHR, LHSI Train 2 Safety Valve JNA20AA191, Premature Opening CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves) Operator Fails to Isolate RHR Flow Diversion (LOCA) in State D
4	4.835E-10	15.70	IE SD LOCA DU JNG13AA005CFO_ D-ALL JNG20AA192SPO OPF-ISORHRFD-D	Initiator - LOCA During Shutdown State Du CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves) LHSI, LHSI/RHR Train 20 Overpressure Protection Safety Valve JNG20AA192, Premature Opening Operator Fails to Isolate RHR Flow Diversion (LOCA) in State D
5	8.058E-11	2.62	IE SD LOCA DU JND20AA003CIR JNG13AA005CFO_ D-ALL OPF-ISORHRFD-D	Initiator - LOCA During Shutdown State Du MHSI, MHSI Pump 20 Discharge Manual CHECK Valve JND20AA003, Internal Rupture CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves) Operator Fails to Isolate RHR Flow Diversion (LOCA) in State D
6	8.058E-11	2.62	IE SD LOCA DU JND10AA003CIR JNG13AA005CFO_ D-ALL OPF-ISORHRFD-D	Initiator - LOCA During Shutdown State Du MHSI, MHSI Pump 10 Discharge Manual CHECK Valve JND10AA003, Internal Rupture CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves) Operator Fails to Isolate RHR Flow Diversion (LOCA) in State D
7	6.103E-11	1.98	IE SD LOCA DU JNG10AA192SPO JNK10AT001SPG_P -ALL OPF-ISORHRFD-D	Initiator - LOCA During Shutdown State Du LHSI, LHSI/RHR Train 10 Overpressure Protection Safety Valve JNG10AA192, Premature Opening CCF of IRWST Sump Strainers - Plugged Operator Fails to Isolate RHR Flow Diversion (LOCA) in State D

SD LOCA D E:0003 DU

No.	Freq.	%	Event	Description
8	6.103E-11	1.98	IE SD LOCA DU JNA10AA191SPO JNK10AT001SPG_P -ALL OPF-ISORHRFD-D	Initiator - LOCA During Shutdown State Du RHR, LHSI Train 1 Safety Valve JNA10AA191, Premature Opening CCF of IRWST Sump Strainers - Plugged Operator Fails to Isolate RHR Flow Diversion (LOCA) in State D
9	6.103E-11	1.98	IE SD LOCA DU JNA20AA191SPO JNK10AT001SPG_P -ALL OPF-ISORHRFD-D	Initiator - LOCA During Shutdown State Du RHR, LHSI Train 2 Safety Valve JNA20AA191, Premature Opening CCF of IRWST Sump Strainers - Plugged Operator Fails to Isolate RHR Flow Diversion (LOCA) in State D
10	6.103E-11	1.98	IE SD LOCA DU JNG20AA192SPO JNK10AT001SPG_P -ALL OPF-ISORHRFD-D	Initiator - LOCA During Shutdown State Du LHSI, LHSI/RHR Train 20 Overpressure Protection Safety Valve JNG20AA192, Premature Opening CCF of IRWST Sump Strainers - Plugged Operator Fails to Isolate RHR Flow Diversion (LOCA) in State D

SD RHR C:0012 CAD

Minimal Cutsets

Top Event frequency F = 6.844E-10

No.	Freq.	%	Event	Description
1	7.599E-11	11.10	IE SD RHR CAD	Initiator - RHR in Power State CAAd
			OPF-XTDIV-NSC	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions
			QKA10GH001_FS	SCWS, Train 1 Chiller Unit QKA10GH001, Fails to Start on Demand
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR_D	CCF of EDGs to Run -234
2	2.086E-11	3.05	IE SD RHR CAD	Initiator - RHR in Power State CAAd
			CAA10AP001EFS	CCWS, Train 1 Motor Driven Pump KAA10AP001, Fails to Start on Demand
			OPF-XTDIV-NSC	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR_D	CCF of EDGs to Run -234
3	1.670E-11	2.44	IE SD RHR CAD	Initiator - RHR in Power State CAAd
			OPF-XTDIV-NSC	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions
			QKA10GH001_FS	SCWS, Train 1 Chiller Unit QKA10GH001, Fails to Start on Demand
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA20____DFR	ELEC, Emergency Diesel Generator XKA20, Fails to Run
			XKA30____DFR	ELEC, Emergency Diesel Generator XKA30, Fails to Run
			XKA40____DFR	ELEC, Emergency Diesel Generator XKA40, Fails to Run
4	1.520E-11	2.22	IE SD RHR CAD	Initiator - RHR in Power State CAAd
			OPF-XTLDSBO-NSC	Operator Fails to Connect and Load SBO DGs to Div 1 or 4 During Non-SBO Conditions
			QKA40GH001_FS	SCWS, Train 4 Chiller Unit QKA40GH001, Fails to Start on Demand
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR_D	CCF of EDGs to Run -123
5	1.094E-11	1.60	IE SD RHR CAD	Initiator - RHR in Power State CAAd
			OPF-XTDIV-NSC	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions
			QKA10GH001_FR	SCWS, Train 1 Chiller Unit QKA10GH001, Fails to Run
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR_D	CCF of EDGs to Run -234

SD RHR C:0012 CAD

No.	Freq.	%	Event	Description
6	1.030E-11	1.51	IE SD RHR CAD	Initiator - RHR in Power State CAAd
			OPF-XTDIV-NSC	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions
			PEB10AP001EFS_D -234	CCF of the ESWS Pumps to Start
			QKA10GH001_FS	SCWS, Train 1 Chiller Unit QKA10GH001, Fails to Start on Demand
7	8.665E-12	1.27	SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			IE SD RHR CAD	Initiator - RHR in Power State CAAd
			JMQ42AA001EFO	SAHR, Active Cooling Line MOV JMQ42AA001, Fails to Open on Demand
			KAA10AP001EFRS D-ALL	CCF of the CCWS Pumps to Run
8	8.665E-12	1.27	OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			IE SD RHR CAD	Initiator - RHR in Power State CAAd
			JMQ40AA001EFO	SAHR, Suction Line Containment Isolation MOV JMQ40AA001, Fails to Open on Demand
			KAA10AP001EFRS D-ALL	CCF of the CCWS Pumps to Run
9	8.665E-12	1.27	OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			IE SD RHR CAD	Initiator - RHR in Power State CAAd
			JNK11AA009EFO	IRWST, SAHR Sump Containment Isolation MOV JNK11AA009, Fails to Open on Demand
			KAA10AP001EFRS D-ALL	CCF of the CCWS Pumps to Run
10	8.267E-12	1.21	OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			IE SD RHR CAD	Initiator - RHR in Power State CAAd
			QKA40GH001_FS	SCWS, Train 4 Chiller Unit QKA40GH001, Fails to Start on Demand
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR_D -123	CCF of EDGs to Run
			XKA50____DFR	ELEC, SBO Diesel Generator XKA50, Fails to Run

SD RHR C:0012 CBD

Minimal Cutsets

Top Event frequency F = 9.226E-10

No.	Freq.	%	Event	Description
1	1.013E-10	10.98	IE SD RHR CBD	Initiator - RHR in Power State CBd
			OPF-XTDIV-NSC	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions
			QKA10GH001_FS	SCWS, Train 1 Chiller Unit QKA10GH001, Fails to Start on Demand
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR_D	CCF of EDGs to Run -234
2	2.781E-11	3.01	IE SD RHR CBD	Initiator - RHR in Power State CBd
			KAA10AP001EFS	CCWS, Train 1 Motor Driven Pump KAA10AP001, Fails to Start on Demand
			OPF-XTDIV-NSC	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR_D	CCF of EDGs to Run -234
3	2.227E-11	2.41	IE SD RHR CBD	Initiator - RHR in Power State CBd
			OPF-XTDIV-NSC	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions
			QKA10GH001_FS	SCWS, Train 1 Chiller Unit QKA10GH001, Fails to Start on Demand
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA20____DFR	ELEC, Emergency Diesel Generator XKA20, Fails to Run
			XKA30____DFR	ELEC, Emergency Diesel Generator XKA30, Fails to Run
			XKA40____DFR	ELEC, Emergency Diesel Generator XKA40, Fails to Run
4	2.026E-11	2.20	IE SD RHR CBD	Initiator - RHR in Power State CBd
			OPF-XTLDSBO-NSC	Operator Fails to Connect and Load SBO DGs to Div 1 or 4 During Non-SBO Conditions
			QKA40GH001_FS	SCWS, Train 4 Chiller Unit QKA40GH001, Fails to Start on Demand
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR_D	CCF of EDGs to Run -123
5	1.458E-11	1.58	IE SD RHR CBD	Initiator - RHR in Power State CBd
			OPF-XTDIV-NSC	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions
			QKA10GH001_FR	SCWS, Train 1 Chiller Unit QKA10GH001, Fails to Run
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR_D	CCF of EDGs to Run -234

SD RHR C:0012 CBD

No.	Freq.	%	Event	Description
6	1.374E-11	1.49	IE SD RHR CBD	Initiator - RHR in Power State CBd
			OPF-XTDIV-NSC	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions
			PEB10AP001EFS_D -234	CCF of the ESWS Pumps to Start
			QKA10GH001_FS	SCWS, Train 1 Chiller Unit QKA10GH001, Fails to Start on Demand
7	1.155E-11	1.25	SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			IE SD RHR CBD	Initiator - RHR in Power State CBd
			JMQ42AA001EFO	SAHR, Active Cooling Line MOV JMQ42AA001, Fails to Open on Demand
			KAA10AP001EFRS D-ALL	CCF of the CCWS Pumps to Run
8	1.155E-11	1.25	OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			IE SD RHR CBD	Initiator - RHR in Power State CBd
			JMQ40AA001EFO	SAHR, Suction Line Containment Isolation MOV JMQ40AA001, Fails to Open on Demand
			KAA10AP001EFRS D-ALL	CCF of the CCWS Pumps to Run
9	1.155E-11	1.25	OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			IE SD RHR CBD	Initiator - RHR in Power State CBd
			JNK11AA009EFO	IRWST, SAHR Sump Containment Isolation MOV JNK11AA009, Fails to Open on Demand
			KAA10AP001EFRS D-ALL	CCF of the CCWS Pumps to Run
10	1.102E-11	1.19	OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			IE SD RHR CBD	Initiator - RHR in Power State CBd
			QKA40GH001_FS	SCWS, Train 4 Chiller Unit QKA40GH001, Fails to Start on Demand
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR_D -123	CCF of EDGs to Run
			XKA50____DFR	ELEC, SBO Diesel Generator XKA50, Fails to Run

SD RHR C:0012 CBU

Minimal Cutsets

Top Event frequency F = 6.848E-10

No.	Freq.	%	Event	Description
1	7.599E-11	11.10	IE SD RHR CBU	Initiator - RHR in Power State CBU
			OPF-XTDIV-NSC	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions
			QKA10GH001_FS	SCWS, Train 1 Chiller Unit QKA10GH001, Fails to Start on Demand
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR_D -234	CCF of EDGs to Run
2	2.086E-11	3.05	IE SD RHR CBU	Initiator - RHR in Power State CBU
			CAA10AP001EFS	CCWS, Train 1 Motor Driven Pump CAA10AP001, Fails to Start on Demand
			OPF-XTDIV-NSC	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR_D -234	CCF of EDGs to Run
3	1.670E-11	2.44	IE SD RHR CBU	Initiator - RHR in Power State CBU
			OPF-XTDIV-NSC	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions
			QKA10GH001_FS	SCWS, Train 1 Chiller Unit QKA10GH001, Fails to Start on Demand
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA20____DFR	ELEC, Emergency Diesel Generator XKA20, Fails to Run
			XKA30____DFR	ELEC, Emergency Diesel Generator XKA30, Fails to Run
			XKA40____DFR	ELEC, Emergency Diesel Generator XKA40, Fails to Run
4	1.520E-11	2.22	IE SD RHR CBU	Initiator - RHR in Power State CBU
			OPF-XTLDSBO-NSC	Operator Fails to Connect and Load SBO DGs to Div 1 or 4 During Non-SBO Conditions
			QKA40GH001_FS	SCWS, Train 4 Chiller Unit QKA40GH001, Fails to Start on Demand
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR_D -123	CCF of EDGs to Run
5	1.094E-11	1.60	IE SD RHR CBU	Initiator - RHR in Power State CBU
			OPF-XTDIV-NSC	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions
			QKA10GH001_FR	SCWS, Train 1 Chiller Unit QKA10GH001, Fails to Run
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR_D -234	CCF of EDGs to Run

SD RHR C:0012 CBU

No.	Freq.	%	Event	Description
6	1.030E-11	1.50	IE SD RHR CBU	Initiator - RHR in Power State CBU
			OPF-XTDIV-NSC	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions
			PEB10AP001EFS_D -234	CCF of the ESWS Pumps to Start
			QKA10GH001_FS	SCWS, Train 1 Chiller Unit QKA10GH001, Fails to Start on Demand
7	8.665E-12	1.27	SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			IE SD RHR CBU	Initiator - RHR in Power State CBU
			JMQ40AA001EFO	SAHR, Suction Line Containment Isolation MOV JMQ40AA001, Fails to Open on Demand
			KAA10AP001EFRS D-ALL	CCF of the CCWS Pumps to Run
8	8.665E-12	1.27	OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			IE SD RHR CBU	Initiator - RHR in Power State CBU
			JNK11AA009EFO	IRWST, SAHR Sump Containment Isolation MOV JNK11AA009, Fails to Open on Demand
			KAA10AP001EFRS D-ALL	CCF of the CCWS Pumps to Run
9	8.665E-12	1.27	OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			IE SD RHR CBU	Initiator - RHR in Power State CBU
			JMQ42AA001EFO	SAHR, Active Cooling Line MOV JMQ42AA001, Fails to Open on Demand
			KAA10AP001EFRS D-ALL	CCF of the CCWS Pumps to Run
10	8.267E-12	1.21	OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			IE SD RHR CBU	Initiator - RHR in Power State CBU
			QKA40GH001_FS	SCWS, Train 4 Chiller Unit QKA40GH001, Fails to Start on Demand
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR_D -123	CCF of EDGs to Run
			XKA50____DFR	ELEC, SBO Diesel Generator XKA50, Fails to Run

SD RHR C:0015 CAD

Minimal Cutsets

Top Event frequency F = 4.513E-09

No.	Freq.	%	Event	Description
1	1.845E-09	40.89	IE SD RHR CAD	Initiator - RHR in Power State CAd
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR_D -ALL	CCF of EDGs to Run
			XKA50____DFR	ELEC, SBO Diesel Generator XKA50, Fails to Run
2	2.464E-10	5.46	IE SD RHR CAD	Initiator - RHR in Power State CAd
			PEB10AP001EFS_D -ALL	CCF of the ESWS Pumps to Start
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA50____DFR	ELEC, SBO Diesel Generator XKA50, Fails to Run
3	1.968E-10	4.36	IE SD RHR CAD	Initiator - RHR in Power State CAd
			OPF-XTDIVSBO-2H	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During SBO Considitions
			SA-ESWS UHS4 SBO	Failure of SA-ESWS/UHS4 in SBO Conditions
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR_D -ALL	CCF of EDGs to Run
4	1.504E-10	3.33	IE SD RHR CAD	Initiator - RHR in Power State CAd
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR_D -ALL	CCF of EDGs to Run
			XKA50____DFS	ELEC, SBO Diesel Generator XKA50, Fails to Start on Demand
5	1.252E-10	2.77	IE SD RHR CAD	Initiator - RHR in Power State CAd
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFS_D -ALL	CCF of EDGs to Start
			XKA50____DFR	ELEC, SBO Diesel Generator XKA50, Fails to Run
6	1.070E-10	2.37	IE SD RHR CAD	Initiator - RHR in Power State CAd
			OPF-XTDIVSBO-2H	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During SBO Considitions
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR_D -ALL	CCF of EDGs to Run
			XKA80____DFR	ELEC, SBO Diesel Generator XKA80, Fails to Run

SD RHR C:0015 CAD

No.	Freq.	%	Event	Description
7	9.665E-11	2.14	IE SD RHR CAD SD LOOP24+REC	Initiator - RHR in Power State CAd Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour BTD01_BAT__ST_D CCF of Safety Related Batteries on Demand -ALL
8	5.336E-11	1.18	IE SD RHR CAD SD LOOP24+REC XKA10____DFR_D XKA50____DFR_B	Initiator - RHR in Power State CAd Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour CCF of EDGs to Run -ALL CCF of SBO DGs to Run -ALL
9	4.699E-11	1.04	IE SD RHR CAD SD LOOP24+REC XKA10____DFR XKA10____DFR_D XKA50____DFR	Initiator - RHR in Power State CAd Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour ELEC, Emergency Diesel Generator XKA10, Fails to Run CCF of EDGs to Run -234 ELEC, SBO Diesel Generator XKA50, Fails to Run
10	4.699E-11	1.04	IE SD RHR CAD SD LOOP24+REC XKA10____DFR_D XKA20____DFR XKA50____DFR	Initiator - RHR in Power State CAd Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour CCF of EDGs to Run -134 ELEC, Emergency Diesel Generator XKA20, Fails to Run ELEC, SBO Diesel Generator XKA50, Fails to Run

Minimal Cutsets

Top Event frequency F = 2.987E-09

No.	Freq.	%	Event	Description
1	1.230E-09	41.18	IE SD RHR CAU	Initiator - RHR in Power State CAu
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR_D -ALL	CCF of EDGs to Run
			XKA50____DFR	ELEC, SBO Diesel Generator XKA50, Fails to Run
2	1.642E-10	5.50	IE SD RHR CAU	Initiator - RHR in Power State CAu
			PEB10AP001EFS_D -ALL	CCF of the ESWS Pumps to Start
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA50____DFR	ELEC, SBO Diesel Generator XKA50, Fails to Run
3	1.312E-10	4.39	IE SD RHR CAU	Initiator - RHR in Power State CAu
			OPF-XTDIVSBO-2H	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During SBO Conditions
			SA-ESWS UHS4 SBO	Failure of SA-ESWS/UHS4 in SBO Conditions
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR_D -ALL	CCF of EDGs to Run
4	1.003E-10	3.36	IE SD RHR CAU	Initiator - RHR in Power State CAu
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR_D -ALL	CCF of EDGs to Run
			XKA50____DFS	ELEC, SBO Diesel Generator XKA50, Fails to Start on Demand
5	8.346E-11	2.79	IE SD RHR CAU	Initiator - RHR in Power State CAu
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFS_D -ALL	CCF of EDGs to Start
			XKA50____DFR	ELEC, SBO Diesel Generator XKA50, Fails to Run
6	7.136E-11	2.39	IE SD RHR CAU	Initiator - RHR in Power State CAu
			OPF-XTDIVSBO-2H	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During SBO Conditions
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR_D -ALL	CCF of EDGs to Run
			XKA80____DFR	ELEC, SBO Diesel Generator XKA80, Fails to Run

SD RHR C:0015 CAU

No.	Freq.	%	Event	Description
7	6.444E-11	2.16	IE SD RHR CAU SD LOOP24+REC	Initiator - RHR in Power State CAu Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			BTD01_BAT__ST_D -ALL	CCF of Safety Related Batteries on Demand
8	3.557E-11	1.19	IE SD RHR CAU SD LOOP24+REC	Initiator - RHR in Power State CAu Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR_D -ALL	CCF of EDGs to Run
			XKA50____DFR_B -ALL	CCF of SBO DGs to Run
9	3.133E-11	1.05	IE SD RHR CAU SD LOOP24+REC	Initiator - RHR in Power State CAu Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR_D -124	CCF of EDGs to Run
			XKA30____DFR	ELEC, Emergency Diesel Generator XKA30, Fails to Run
			XKA50____DFR	ELEC, SBO Diesel Generator XKA50, Fails to Run
10	3.133E-11	1.05	IE SD RHR CAU SD LOOP24+REC	Initiator - RHR in Power State CAu Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR_D -134	CCF of EDGs to Run
			XKA20____DFR	ELEC, Emergency Diesel Generator XKA20, Fails to Run
			XKA50____DFR	ELEC, SBO Diesel Generator XKA50, Fails to Run

SD RHR C:0015 CBD

Minimal Cutsets

Top Event frequency F = 6.041E-09

No.	Freq.	%	Event	Description
1	2.461E-09	40.73	IE SD RHR CBD	Initiator - RHR in Power State CBd
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR_D -ALL	CCF of EDGs to Run
			XKA50____DFR	ELEC, SBO Diesel Generator XKA50, Fails to Run
2	3.285E-10	5.44	IE SD RHR CBD	Initiator - RHR in Power State CBd
			PEB10AP001EFS_D -ALL	CCF of the ESWS Pumps to Start
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA50____DFR	ELEC, SBO Diesel Generator XKA50, Fails to Run
3	2.623E-10	4.34	IE SD RHR CBD	Initiator - RHR in Power State CBd
			OPF-XTDIVSBO-2H	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During SBO Considitions
			SA-ESWS UHS4 SBO	Failure of SA-ESWS/UHS4 in SBO Conditions
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR_D -ALL	CCF of EDGs to Run
4	2.005E-10	3.32	IE SD RHR CBD	Initiator - RHR in Power State CBd
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR_D -ALL	CCF of EDGs to Run
			XKA50____DFS	ELEC, SBO Diesel Generator XKA50, Fails to Start on Demand
5	1.669E-10	2.76	IE SD RHR CBD	Initiator - RHR in Power State CBd
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFS_D -ALL	CCF of EDGs to Start
			XKA50____DFR	ELEC, SBO Diesel Generator XKA50, Fails to Run
6	1.427E-10	2.36	IE SD RHR CBD	Initiator - RHR in Power State CBd
			OPF-XTDIVSBO-2H	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During SBO Considitions
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR_D -ALL	CCF of EDGs to Run
			XKA80____DFR	ELEC, SBO Diesel Generator XKA80, Fails to Run

SD RHR C:0015 CBD

No.	Freq.	%	Event	Description
7	1.289E-10	2.13	IE SD RHR CBD BTD01_BAT__ST_D SD LOOP24+REC	Initiator - RHR in Power State CBd CCF of Safety Related Batteries on Demand -ALL Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
8	7.114E-11	1.18	IE SD RHR CBD SD LOOP24+REC XKA10____DFR_D XKA50____DFR_B	Initiator - RHR in Power State CBd Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour CCF of EDGs to Run -ALL CCF of SBO DGs to Run -ALL
9	6.265E-11	1.04	IE SD RHR CBD SD LOOP24+REC XKA10____DFR_D XKA40____DFR XKA50____DFR	Initiator - RHR in Power State CBd Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour CCF of EDGs to Run -123 ELEC, Emergency Diesel Generator XKA40, Fails to Run ELEC, SBO Diesel Generator XKA50, Fails to Run
10	6.265E-11	1.04	IE SD RHR CBD SD LOOP24+REC XKA10____DFR_D XKA30____DFR XKA50____DFR	Initiator - RHR in Power State CBd Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour CCF of EDGs to Run -124 ELEC, Emergency Diesel Generator XKA30, Fails to Run ELEC, SBO Diesel Generator XKA50, Fails to Run

Minimal Cutsets

Top Event frequency F = 4.513E-09

No.	Freq.	%	Event	Description
1	1.845E-09	40.89	IE SD RHR CBU	Initiator - RHR in Power State CBU
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR_D -ALL	CCF of EDGs to Run
			XKA50____DFR	ELEC, SBO Diesel Generator XKA50, Fails to Run
2	2.464E-10	5.46	IE SD RHR CBU	Initiator - RHR in Power State CBU
			PEB10AP001EFS_D -ALL	CCF of the ESWS Pumps to Start
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA50____DFR	ELEC, SBO Diesel Generator XKA50, Fails to Run
3	1.968E-10	4.36	IE SD RHR CBU	Initiator - RHR in Power State CBU
			OPF-XTDIVSBO-2H	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During SBO Conditions
			SA-ESWS UHS4 SBO	Failure of SA-ESWS/UHS4 in SBO Conditions
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR_D -ALL	CCF of EDGs to Run
4	1.504E-10	3.33	IE SD RHR CBU	Initiator - RHR in Power State CBU
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR_D -ALL	CCF of EDGs to Run
			XKA50____DFS	ELEC, SBO Diesel Generator XKA50, Fails to Start on Demand
5	1.252E-10	2.77	IE SD RHR CBU	Initiator - RHR in Power State CBU
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFS_D -ALL	CCF of EDGs to Start
			XKA50____DFR	ELEC, SBO Diesel Generator XKA50, Fails to Run
6	1.070E-10	2.37	IE SD RHR CBU	Initiator - RHR in Power State CBU
			OPF-XTDIVSBO-2H	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During SBO Conditions
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR_D -ALL	CCF of EDGs to Run
			XKA80____DFR	ELEC, SBO Diesel Generator XKA80, Fails to Run

SD RHR C:0015 CBU

No.	Freq.	%	Event	Description
7	9.665E-11	2.14	IE SD RHR CBU SD LOOP24+REC	Initiator - RHR in Power State CBU Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour BTD01_BAT__ST_D CCF of Safety Related Batteries on Demand -ALL
8	5.336E-11	1.18	IE SD RHR CBU SD LOOP24+REC XKA10____DFR_D -ALL XKA50____DFR_B -ALL	Initiator - RHR in Power State CBU Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour CCF of EDGs to Run CCF of SBO DGs to Run
9	4.699E-11	1.04	IE SD RHR CBU SD LOOP24+REC XKA10____DFR_D -124 XKA30____DFR XKA50____DFR	Initiator - RHR in Power State CBU Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour CCF of EDGs to Run ELEC, Emergency Diesel Generator XKA30, Fails to Run ELEC, SBO Diesel Generator XKA50, Fails to Run
10	4.699E-11	1.04	IE SD RHR CBU SD LOOP24+REC XKA10____DFR XKA10____DFR_D -234 XKA50____DFR	Initiator - RHR in Power State CBU Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour ELEC, Emergency Diesel Generator XKA10, Fails to Run CCF of EDGs to Run ELEC, SBO Diesel Generator XKA50, Fails to Run

SD RHR C:0016 CBD

Minimal Cutsets

Top Event frequency F = 6.401E-10

No.	Freq.	%	Event	Description
1	8.004E-11	12.50	IE SD RHR CBD	Initiator - RHR in Power State CBd
			OPD-SAC2H/SAC1H	Dependency (MED) Between OAs for Starting HVAC Maintenance Trains Recovering Room Cooling Locally
			OPF-SAC-1H	Operator Fails to Start Maintenance HVAC Trains After Failure of Normal SAC Safety Train
			SAC31AN001EFR_ D-ALL	CCF to Run Normal Air Exhaust Fans
2	8.004E-11	12.50	IE SD RHR CBD	Initiator - RHR in Power State CBd
			OPD-SAC2H/SAC1H	Dependency (MED) Between OAs for Starting HVAC Maintenance Trains Recovering Room Cooling Locally
			OPF-SAC-1H	Operator Fails to Start Maintenance HVAC Trains After Failure of Normal SAC Safety Train
			SAC01AN001EFR_ D-ALL	CCF to Run Normal Air Supply Fans
3	4.977E-11	7.77	IE SD RHR CBD	Initiator - RHR in Power State CBd
			OPD-SAC2H/SAC1H	Dependency (MED) Between OAs for Starting HVAC Maintenance Trains Recovering Room Cooling Locally
			OPF-SAC-1H	Operator Fails to Start Maintenance HVAC Trains After Failure of Normal SAC Safety Train
			SAC31AN001EFR_ D-123	CCF to Run Normal Air Exhaust Fans
4	4.977E-11	7.77	IE SD RHR CBD	Initiator - RHR in Power State CBd
			OPD-SAC2H/SAC1H	Dependency (MED) Between OAs for Starting HVAC Maintenance Trains Recovering Room Cooling Locally
			OPF-SAC-1H	Operator Fails to Start Maintenance HVAC Trains After Failure of Normal SAC Safety Train
			SAC01AN001EFR_ D-123	CCF to Run Normal Air Supply Fans
5	3.846E-11	6.01	IE SD RHR CBD	Initiator - RHR in Power State CBd
			OPD-SAC2H/SAC1H	Dependency (MED) Between OAs for Starting HVAC Maintenance Trains Recovering Room Cooling Locally
			OPF-SAC-1H	Operator Fails to Start Maintenance HVAC Trains After Failure of Normal SAC Safety Train
			QKA10AP107EFR_ D-ALL	CCF of SCWS Pumps to Run
6	3.484E-11	5.44	IE SD RHR CBD	Initiator - RHR in Power State CBd
			OPD-SAC2H/SAC1H	Dependency (MED) Between OAs for Starting HVAC Maintenance Trains Recovering Room Cooling Locally
			OPF-SAC-1H	Operator Fails to Start Maintenance HVAC Trains After Failure of Normal SAC Safety Train
			QKA10AP107EFR_ D-123	CCF of SCWS Pumps to Run

SD RHR C:0016 CBD

No.	Freq.	%	Event	Description
7	2.953E-11	4.61	IE SD RHR CBD 31BTB01_BATST SD LOOP24+REC XKA10_____DFR_D -ALL	Initiator - RHR in Power State CBd ELEC, 250V Non 1E 12-hr Battery 31BTB01, Fails on Demand Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour CCF of EDGs to Run
8	1.510E-11	2.36	IE SD RHR CBD OPF-SAC-2H QKA10AP107EFS_DCCF -ALL SD LOOP24+REC	Initiator - RHR in Power State CBd Operator Fails to Recover Room Cooling Locally DCCF of SCWS Pumps to Start Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
9	1.100E-11	1.72	IE SD RHR CBD OPF-SAC-2H QKA10AP107EFS_DCCF -124 SD LOOP24+REC	Initiator - RHR in Power State CBd Operator Fails to Recover Room Cooling Locally DCCF of SCWS Pumps to Start Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
10	7.630E-12	1.19	IE SD RHR CBD OPF-SAC-2H SAC31AN001EFR_ D-ALL SD LOOP24+REC	Initiator - RHR in Power State CBd Operator Fails to Recover Room Cooling Locally CCF to Run Normal Air Exhaust Fans Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour

Minimal Cutsets

Top Event frequency F = 1.191E-09

No.	Freq.	%	Event	Description
1	1.004E-10	8.43	IE SD RHR DU	Initiator - RHR in Power State Du
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR_D	CCF of EDGs to Run
			-ALL	
			XKA50____DFR	ELEC, SBO Diesel Generator XKA50, Fails to Run
			XKA80____DFR	ELEC, SBO Diesel Generator XKA80, Fails to Run
2	9.665E-11	8.11	IE SD RHR DU	Initiator - RHR in Power State Du
			BTD01_BAT__ST_D	CCF of Safety Related Batteries on Demand
			-ALL	
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
3	6.003E-11	5.04	IE SD RHR DU	Initiator - RHR in Power State Du
			OPD-SAC2H/SAC1H	Dependency (MED) Between OAs for Starting HVAC Maintenance Trains Recovering Room Cooling Locally
			OPF-SAC-1H	Operator Fails to Start Maintenance HVAC Trains After Failure of Normal SAC Safety Train
			SAC01AN001EFR_	CCF to Run Normal Air Supply Fans
			D-ALL	
4	6.003E-11	5.04	IE SD RHR DU	Initiator - RHR in Power State Du
			OPD-SAC2H/SAC1H	Dependency (MED) Between OAs for Starting HVAC Maintenance Trains Recovering Room Cooling Locally
			OPF-SAC-1H	Operator Fails to Start Maintenance HVAC Trains After Failure of Normal SAC Safety Train
			SAC31AN001EFR_	CCF to Run Normal Air Exhaust Fans
			D-ALL	
5	5.336E-11	4.48	IE SD RHR DU	Initiator - RHR in Power State Du
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR_D	CCF of EDGs to Run
			-ALL	
			XKA50____DFR_B	CCF of SBO DGs to Run
			-ALL	
6	4.068E-11	3.41	IE SD RHR DU	Initiator - RHR in Power State Du
			JNG13AA005CFO_	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves)
			D-ALL	
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA40____DFR	ELEC, Emergency Diesel Generator XKA40, Fails to Run

SD RHR D:0003 DU

No.	Freq.	%	Event	Description
7	3.809E-11	3.20	IE SD RHR DU KAA10AP001EFRS D-ALL OPF-LHSIRHR-DU	Initiator - RHR in Power State Du CCF of the CCWS Pumps to Run Operator Fails to Start LHSI Pump in DU, given a loss of RHR
8	3.192E-11	2.68	IE SD RHR DU JND10AP001EFR_D -ALL JNG10AP001EFR_D -ALL	Initiator - RHR in Power State Du CCF of MHSI Pumps to Run CCF of LHSI Pumps to Run
9	2.885E-11	2.42	IE SD RHR DU OPD-SAC2H/SAC1H OPF-SAC-1H QKA10AP107EFR_ D-ALL	Initiator - RHR in Power State Du Dependency (MED) Between OAs for Starting HVAC Maintenance Trains Recovering Room Cooling Locally Operator Fails to Start Maintenance HVAC Trains After Failure of Normal SAC Safety Train CCF of SCWS Pumps to Run
10	2.563E-11	2.15	IE SD RHR DU OPF-LHSIRHR-DU PEB10AP001EFR_D -ALL	Initiator - RHR in Power State Du Operator Fails to Start LHSI Pump in DU, given a loss of RHR CCF of the ESWS Pumps to Run

SD RHR ISLOCA E:0002

Minimal Cutsets

Top Event frequency F = 7.919E-10

No.	Freq.	%	Event	Description
1	3.432E-10	43.34	IE SD RHR ISLOCA E	RHR ISLOCA During Shutdown State E
			OPF-ISORHRBRK	Operator Fails to Isolate RHR Pipe Break
			PAS	Process Automation System (PAS) Fails (Estimate)
			RHR TR2 PIPE BRK	Pipe Break in RHR Train 2
2	3.432E-10	43.34	IE SD RHR ISLOCA E	RHR ISLOCA During Shutdown State E
			OPF-ISORHRBRK	Operator Fails to Isolate RHR Pipe Break
			PAS	Process Automation System (PAS) Fails (Estimate)
			RHR TR1 PIPE BRK	Pipe Break in RHR Train 1
3	3.777E-11	4.77	IE SD RHR ISLOCA E	RHR ISLOCA During Shutdown State E
			JNA20AA001EFC	RHR, LHSI Pump 20 Hot Leg Isolation MOV JNA20AA001, Fails to Close on Demand
			JNA20AA002EFC	RHR, LHSI Pump 20 Hot Leg Isolation MOV JNA20AA002, Fails to Close on Demand
			RHR TR2 PIPE BRK	Pipe Break in RHR Train 2
4	3.777E-11	4.77	IE SD RHR ISLOCA E	RHR ISLOCA During Shutdown State E
			JNA10AA001EFC	RHR, LHSI Pump 10 Hot Leg Isolation MOV JNA10AA001, Fails to Close on Demand
			JNA10AA002EFC	RHR, LHSI Pump 10 Hot Leg Isolation MOV JNA10AA002, Fails to Close on Demand
			RHR TR1 PIPE BRK	Pipe Break in RHR Train 1

SD ULD CB:0003 CBD D

Minimal Cutsets

Top Event frequency F = 7.182E-09

No.	Freq.	%	Event	Description
1	3.388E-09	47.18	IE SD ULD CBD D	Initiator - Uncontrolled Level Drop in Shutdown State CBd (Demand)
			KBA14AA004EFC_B CCF to Close CVCS Low Pressure Reducing Station MOVs -ALL	
			OPE-ISOC SLPRS	Operator Fails to Isolate the CVCS Low Pressure Reducing Station
2	1.891E-09	26.33	IE SD ULD CBD D	Initiator - Uncontrolled Level Drop in Shutdown State CBd (Demand)
			KBA14AA004EFC	CVCS, Low Pressure Reducing Station Isolation MOV KBA14AA004, Fails to Close on Demand
			OPE-ISOC SLPRS	Operator Fails to Isolate the CVCS Low Pressure Reducing Station
			OPF-ULD	Operator Fails to Stop Draindown at Mid-Loop
3	6.502E-10	9.05	IE SD ULD CBD D	Initiator - Uncontrolled Level Drop in Shutdown State CBd (Demand)
			KBA14AA004EFC	CVCS, Low Pressure Reducing Station Isolation MOV KBA14AA004, Fails to Close on Demand
			KBA14AA106EFC	CVCS, CVCS Low Power Reducing Station MOV KBA14AA106, Fails to Close on Demand
			OPE-ISOC SLPRS	Operator Fails to Isolate the CVCS Low Pressure Reducing Station
4	5.500E-10	7.66	IE SD ULD CBD D	Initiator - Uncontrolled Level Drop in Shutdown State CBd (Demand)
			OPE-ISOC SLPRS	Operator Fails to Isolate the CVCS Low Pressure Reducing Station
			OPF-ULD	Operator Fails to Stop Draindown at Mid-Loop
			PAS	Process Automation System (PAS) Fails (Estimate)
5	1.891E-10	2.63	IE SD ULD CBD D	Initiator - Uncontrolled Level Drop in Shutdown State CBd (Demand)
			KBA14AA106EFC	CVCS, CVCS Low Power Reducing Station MOV KBA14AA106, Fails to Close on Demand
			OPE-ISOC SLPRS	Operator Fails to Isolate the CVCS Low Pressure Reducing Station
			PAS	Process Automation System (PAS) Fails (Estimate)
6	1.844E-10	2.57	IE SD ULD CBD D	Initiator - Uncontrolled Level Drop in Shutdown State CBd (Demand)
			KBA14AA004PANS	CVCS, LP Reducing Iso MOV KBA14AA004, PAC A Priority Module (Type AV42) Fails (Non-Self-Monitored)
			OPE-ISOC SLPRS	Operator Fails to Isolate the CVCS Low Pressure Reducing Station
			OPF-ULD	Operator Fails to Stop Draindown at Mid-Loop

Minimal Cutsets

Top Event frequency F = 6.721E-10

No.	Freq.	%	Event	Description
1	2.758E-10	41.03	IE SD ULD CBD D JNG13AA005CFO_ D-ALL KBA14AA004EFC_B -ALL	Initiator - Uncontrolled Level Drop in Shutdown State CBd (Demand) CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves) CCF to Close CVCS Low Pressure Reducing Station MOVs
2	1.539E-10	22.90	IE SD ULD CBD D JNG13AA005CFO_ D-ALL KBA14AA004EFC OPF-ULD	Initiator - Uncontrolled Level Drop in Shutdown State CBd (Demand) CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves) CVCS, Low Pressure Reducing Station Isolation MOV KBA14AA004, Fails to Close on Demand Operator Fails to Stop Draindown at Mid-Loop
3	5.292E-11	7.87	IE SD ULD CBD D JNG13AA005CFO_ D-ALL KBA14AA004EFC KBA14AA106EFC	Initiator - Uncontrolled Level Drop in Shutdown State CBd (Demand) CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves) CVCS, Low Pressure Reducing Station Isolation MOV KBA14AA004, Fails to Close on Demand CVCS, CVCS Low Power Reducing Station MOV KBA14AA106, Fails to Close on Demand
4	4.477E-11	6.66	IE SD ULD CBD D JNG13AA005CFO_ D-ALL OPF-ULD PAS	Initiator - Uncontrolled Level Drop in Shutdown State CBd (Demand) CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves) Operator Fails to Stop Draindown at Mid-Loop Process Automation System (PAS) Fails (Estimate)
5	3.481E-11	5.18	IE SD ULD CBD D JNK10AT001SPG_P -ALL KBA14AA004EFC_B -ALL	Initiator - Uncontrolled Level Drop in Shutdown State CBd (Demand) CCF of IRWST Sump Strainers - Plugged CCF to Close CVCS Low Pressure Reducing Station MOVs
6	1.943E-11	2.89	IE SD ULD CBD D JNK10AT001SPG_P -ALL KBA14AA004EFC OPF-ULD	Initiator - Uncontrolled Level Drop in Shutdown State CBd (Demand) CCF of IRWST Sump Strainers - Plugged CVCS, Low Pressure Reducing Station Isolation MOV KBA14AA004, Fails to Close on Demand Operator Fails to Stop Draindown at Mid-Loop
7	1.539E-11	2.29	IE SD ULD CBD D JNG13AA005CFO_ D-ALL KBA14AA106EFC PAS	Initiator - Uncontrolled Level Drop in Shutdown State CBd (Demand) CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves) CVCS, CVCS Low Power Reducing Station MOV KBA14AA106, Fails to Close on Demand Process Automation System (PAS) Fails (Estimate)

SD ULD CB:0039 CBD D

No.	Freq.	%	Event	Description
8	1.501E-11	2.23	IE SD ULD CBD D	Initiator - Uncontrolled Level Drop in Shutdown State CBd (Demand)
			JNG13AA005CFO_	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First
			D-ALL	Isolation Valves)
			KBA14AA004PANS	CVCS, LP Reducing Iso MOV KBA14AA004, PAC A Priority Module (Type AV42) Fails (Non-Self-Monitored)
			OPF-ULD	Operator Fails to Stop Draindown at Mid-Loop
9	6.681E-12	0.99	IE SD ULD CBD D	Initiator - Uncontrolled Level Drop in Shutdown State CBd (Demand)
			JNK10AT001SPG_P	CCF of IRWST Sump Strainers - Plugged
			-ALL	
			KBA14AA004EFC	CVCS, Low Pressure Reducing Station Isolation MOV KBA14AA004, Fails to Close on Demand
			KBA14AA106EFC	CVCS, CVCS Low Power Reducing Station MOV KBA14AA106, Fails to Close on Demand
10	5.651E-12	0.84	IE SD ULD CBD D	Initiator - Uncontrolled Level Drop in Shutdown State CBd (Demand)
			JNK10AT001SPG_P	CCF of IRWST Sump Strainers - Plugged
			-ALL	
			OPF-ULD	Operator Fails to Stop Draindown at Mid-Loop
			PAS	Process Automation System (PAS) Fails (Estimate)

Minimal Cutsets

Top Event frequency F = 7.182E-09

No.	Freq.	%	Event	Description
1	3.388E-09	47.18	IE SD ULD DU D KBA14AA004EFC_B CCF to Close CVCS Low Pressure Reducing Station MOVs -ALL OPE-ISOC SLPRS	Initiator - Uncontrolled Level Drop in Shutdown State Du (Demand) CVCS, Low Pressure Reducing Station Isolation MOV KBA14AA004, Fails to Close on Demand Operator Fails to Isolate the CVCS Low Pressure Reducing Station
2	1.891E-09	26.33	IE SD ULD DU D KBA14AA004EFC OPE-ISOC SLPRS OPF-ULD	Initiator - Uncontrolled Level Drop in Shutdown State Du (Demand) CVCS, Low Pressure Reducing Station Isolation MOV KBA14AA004, Fails to Close on Demand Operator Fails to Isolate the CVCS Low Pressure Reducing Station Operator Fails to Stop Draindown at Mid-Loop
3	6.502E-10	9.05	IE SD ULD DU D KBA14AA004EFC KBA14AA106EFC OPE-ISOC SLPRS	Initiator - Uncontrolled Level Drop in Shutdown State Du (Demand) CVCS, Low Pressure Reducing Station Isolation MOV KBA14AA004, Fails to Close on Demand CVCS, CVCS Low Power Reducing Station MOV KBA14AA106, Fails to Close on Demand Operator Fails to Isolate the CVCS Low Pressure Reducing Station
4	5.500E-10	7.66	IE SD ULD DU D OPE-ISOC SLPRS OPF-ULD PAS	Initiator - Uncontrolled Level Drop in Shutdown State Du (Demand) Operator Fails to Isolate the CVCS Low Pressure Reducing Station Operator Fails to Stop Draindown at Mid-Loop Process Automation System (PAS) Fails (Estimate)
5	1.891E-10	2.63	IE SD ULD DU D KBA14AA106EFC OPE-ISOC SLPRS PAS	Initiator - Uncontrolled Level Drop in Shutdown State Du (Demand) CVCS, CVCS Low Power Reducing Station MOV KBA14AA106, Fails to Close on Demand Operator Fails to Isolate the CVCS Low Pressure Reducing Station Process Automation System (PAS) Fails (Estimate)
6	1.844E-10	2.57	IE SD ULD DU D KBA14AA004PANS OPE-ISOC SLPRS OPF-ULD	Initiator - Uncontrolled Level Drop in Shutdown State Du (Demand) CVCS, LP Reducing Iso MOV KBA14AA004, PAC A Priority Module (Type AV42) Fails (Non-Self-Monitored) Operator Fails to Isolate the CVCS Low Pressure Reducing Station Operator Fails to Stop Draindown at Mid-Loop

Minimal Cutsets

Top Event frequency F = 6.740E-10

No.	Freq.	%	Event	Description
1	2.758E-10	40.91	IE SD ULD DU D JNG13AA005CFO_ D-ALL KBA14AA004EFC_B -ALL	Initiator - Uncontrolled Level Drop in Shutdown State Du (Demand) CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves) CCF to Close CVCS Low Pressure Reducing Station MOVs
2	1.539E-10	22.84	IE SD ULD DU D JNG13AA005CFO_ D-ALL KBA14AA004EFC OPF-ULD	Initiator - Uncontrolled Level Drop in Shutdown State Du (Demand) CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves) CVCS, Low Pressure Reducing Station Isolation MOV KBA14AA004, Fails to Close on Demand Operator Fails to Stop Draindown at Mid-Loop
3	5.292E-11	7.85	IE SD ULD DU D JNG13AA005CFO_ D-ALL KBA14AA004EFC KBA14AA106EFC	Initiator - Uncontrolled Level Drop in Shutdown State Du (Demand) CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves) CVCS, Low Pressure Reducing Station Isolation MOV KBA14AA004, Fails to Close on Demand CVCS, CVCS Low Power Reducing Station MOV KBA14AA106, Fails to Close on Demand
4	4.477E-11	6.64	IE SD ULD DU D JNG13AA005CFO_ D-ALL OPF-ULD PAS	Initiator - Uncontrolled Level Drop in Shutdown State Du (Demand) CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves) Operator Fails to Stop Draindown at Mid-Loop Process Automation System (PAS) Fails (Estimate)
5	3.481E-11	5.16	IE SD ULD DU D JNK10AT001SPG_P -ALL KBA14AA004EFC_B -ALL	Initiator - Uncontrolled Level Drop in Shutdown State Du (Demand) CCF of IRWST Sump Strainers - Plugged CCF to Close CVCS Low Pressure Reducing Station MOVs
6	1.943E-11	2.88	IE SD ULD DU D JNK10AT001SPG_P -ALL KBA14AA004EFC OPF-ULD	Initiator - Uncontrolled Level Drop in Shutdown State Du (Demand) CCF of IRWST Sump Strainers - Plugged CVCS, Low Pressure Reducing Station Isolation MOV KBA14AA004, Fails to Close on Demand Operator Fails to Stop Draindown at Mid-Loop
7	1.539E-11	2.28	IE SD ULD DU D JNG13AA005CFO_ D-ALL KBA14AA106EFC PAS	Initiator - Uncontrolled Level Drop in Shutdown State Du (Demand) CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves) CVCS, CVCS Low Power Reducing Station MOV KBA14AA106, Fails to Close on Demand Process Automation System (PAS) Fails (Estimate)

SD ULD D:0006 DU D

No.	Freq.	%	Event	Description
8	1.501E-11	2.23	IE SD ULD DU D	Initiator - Uncontrolled Level Drop in Shutdown State Du (Demand)
			JNG13AA005CFO_	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First
			D-ALL	Isolation Valves)
			KBA14AA004PANS	CVCS, LP Reducing Iso MOV KBA14AA004, PAC A Priority Module
			(Type AV42) Fails (Non-Self-Monitored)	
			OPF-ULD	Operator Fails to Stop Draindown at Mid-Loop
9	6.681E-12	0.99	IE SD ULD DU D	Initiator - Uncontrolled Level Drop in Shutdown State Du (Demand)
			JNK10AT001SPG_P	CCF of IRWST Sump Strainers - Plugged
			-ALL	
			KBA14AA004EFC	CVCS, Low Pressure Reducing Station Isolation MOV KBA14AA004,
			Fails to Close on Demand	
			KBA14AA106EFC	CVCS, CVCS Low Power Reducing Station MOV KBA14AA106, Fails
				to Close on Demand
10	5.651E-12	0.84	IE SD ULD DU D	Initiator - Uncontrolled Level Drop in Shutdown State Du (Demand)
			JNK10AT001SPG_P	CCF of IRWST Sump Strainers - Plugged
			-ALL	
			OPF-ULD	Operator Fails to Stop Draindown at Mid-Loop
			PAS	Process Automation System (PAS) Fails (Estimate)

**Response to
Request for Additional Information No. 227**

**Question 19-285
Appendix B
Top 200 Core Damage Cutsets**

Minimal Cutsets

Top Event probability Q = 2.886E-07

No.	Prob.	%	Event	Description
1	1.220E-08	4.23	IE LOOP OPF-SAC-2H QKA10GH001_FS_B-ALL REC OSP 2HR	Initiator - Loss Of Offsite Power Operator Fails to Recover Room Cooling Locally CCF of the Air Cooled SCWS Chiller Units to Start Failure to Recover Offsite Power Within 2 Hours
2	1.148E-08	3.98	IE LOOP OPF-SAC-2H QKA40GH001_FS REC OSP 2HR SAC01/QKA10 PM1	Initiator - Loss Of Offsite Power Operator Fails to Recover Room Cooling Locally SCWS, Train 4 Chiller Unit QKA40GH001, Fails to Start on Demand Failure to Recover Offsite Power Within 2 Hours Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
3	1.148E-08	3.98	IE LOOP OPF-SAC-2H QKA10GH001_FS REC OSP 2HR SAC04/QKA40 PM4	Initiator - Loss Of Offsite Power Operator Fails to Recover Room Cooling Locally SCWS, Train 1 Chiller Unit QKA10GH001, Fails to Start on Demand Failure to Recover Offsite Power Within 2 Hours Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance
4	6.822E-09	2.36	IE SLOCA JND10AP001EFR_D-ALL OPE-FCD-40M	Initiator - Small LOCA (0.6 to 3-Inch Diameter) CCF of MHSI Pumps to Run Operator Fails to Initiate Fast Cooldown for SLOCA
5	6.659E-09	2.31	IE SLOCA LBA13AA001PFO_D-ALL OPE-FB-40M	Initiator - Small LOCA (0.6 to 3-Inch Diameter) CCF to Open Main Steam Relief Isolation Valves Operator Fails to Initiate Feed & Bleed for SLOCA
6	6.178E-09	2.14	IE SLOCA JNG13AA005CFO_D-ALL	Initiator - Small LOCA (0.6 to 3-Inch Diameter) CCF to Open LHSI/MHSI Common Injection Check Valves
7	5.594E-09	1.94	IE LOOP BTD01_BAT__ST_D-ALL	Initiator - Loss Of Offsite Power CCF of Safety Related Batteries on Demand
8	5.000E-09	1.73	IE SLBI CL-PS-B-SWCCF	Initiator - Steam Break Inside Containment SW CCF of Protection System diversity group B
9	3.936E-09	1.36	IE SGTR LBA40AA002PFC OPE-RHR-4H	Initiator - Steam Generator Tube Rupture MSS, Train 4 Main Steam Isolation Valve LBA40AA002, Fails to Close on Demand Operator Fails to Initiate RHR Within 4 Hours
10	3.932E-09	1.36	IE LOMFW STUCK ROD	Initiator - Total Loss of Main Feedwater Stuck Control Rods
11	3.388E-09	1.17	IE SGTR LBA43AA101EFC OPD-RHR4H/SGTR1H OPF-SGTR-1H	Initiator - Steam Generator Tube Rupture MSS, Train 4 MSRCV LBA43AA101, Fails to Close on Demand Dependency (MED) Between Operator Actions for Stabilizing SGTR and Initiating RHR Operator Fails to Isolate SGTR and Initiate Cooldown

MCS Results

EPRDC050

INTERNAL

No.	Prob.	%	Event	Description
12	3.325E-09	1.15	IE LOC STUCK ROD	Initiator - Loss of Main Condenser (Includes MSIV Closure etc.) Stuck Control Rods
13	2.715E-09	0.94	IE GT LOOPCON+REC OPF-SAC-2H QKA10GH001_FS_B-ALL	Initiator - General Transient (Includes Turbine Trip and Reactor Trip) Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram Operator Fails to Recover Room Cooling Locally CCF of the Air Cooled SCWS Chiller Units to Start
14	2.555E-09	0.89	IE GT LOOPCON+REC OPF-SAC-2H QKA40GH001_FS SAC01/QKA10 PM1	Initiator - General Transient (Includes Turbine Trip and Reactor Trip) Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram Operator Fails to Recover Room Cooling Locally SCWS, Train 4 Chiller Unit QKA40GH001, Fails to Start on Demand Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
15	2.555E-09	0.89	IE GT LOOPCON+REC OPF-SAC-2H QKA10GH001_FS SAC04/QKA40 PM4	Initiator - General Transient (Includes Turbine Trip and Reactor Trip) Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram Operator Fails to Recover Room Cooling Locally SCWS, Train 1 Chiller Unit QKA10GH001, Fails to Start on Demand Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance
16	2.269E-09	0.79	IE SLOCA MSRIVSCPFO_P-ALL OPE-FB-40M	Initiator - Small LOCA (0.6 to 3-Inch Diameter) CCF to Open Main Steam Relief Isolation Pneumatic Pilot Valves Operator Fails to Initiate Feed & Bleed for SLOCA
17	2.083E-09	0.72	IE LBOP STUCK ROD	Initiator - Loss of Balance of Plant - Closed Loop Cooling Water or Aux Cooling Water Stuck Control Rods
18	1.854E-09	0.64	IE LOOP OPF-SAC-2H QKA10GH001_FS QKA40GH001_FS REC OSP 2HR	Initiator - Loss Of Offsite Power Operator Fails to Recover Room Cooling Locally SCWS, Train 1 Chiller Unit QKA10GH001, Fails to Start on Demand SCWS, Train 4 Chiller Unit QKA40GH001, Fails to Start on Demand Failure to Recover Offsite Power Within 2 Hours
19	1.848E-09	0.64	IE LOOP REC OSP 2HR XKA10____DFR_D-ALL XKA50____DFR XKA80____DFR	Initiator - Loss Of Offsite Power Failure to Recover Offsite Power Within 2 Hours CCF of EDGs to Run ELEC, SBO Diesel Generator XKA50, Fails to Run ELEC, SBO Diesel Generator XKA80, Fails to Run
20	1.756E-09	0.61	IE LOOP OPF-SAC-2H QKA10GH001_FR_B-ALL REC OSP 2HR	Initiator - Loss Of Offsite Power Operator Fails to Recover Room Cooling Locally CCF of the Air Cooled SCWS Chiller Units to Run Failure to Recover Offsite Power Within 2 Hours
21	1.652E-09	0.57	IE LOOP OPF-SAC-2H QKA40GH001_FR REC OSP 2HR SAC01/QKA10 PM1	Initiator - Loss Of Offsite Power Operator Fails to Recover Room Cooling Locally SCWS, Train 4 Chiller Unit QKA40GH001, Fails to Run Failure to Recover Offsite Power Within 2 Hours Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance

MCS Results

EPRDC050

INTERNAL

No.	Prob.	%	Event	Description
22	1.652E-09	0.57	IE LOOP OPF-SAC-2H QKA10GH001_FR REC OSP 2HR SAC04/QKA40 PM4	Initiator - Loss Of Offsite Power Operator Fails to Recover Room Cooling Locally SCWS, Train 1 Chiller Unit QKA10GH001, Fails to Run Failure to Recover Offsite Power Within 2 Hours Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance
23	1.540E-09	0.53	IE LOOP 31BTD01_BATST OPF-SAC-2H REC OSP 2HR SAC04/QKA40 PM4	Initiator - Loss Of Offsite Power ELEC, 250V 1E 2-hr Battery 31BTD01, Fails on Demand Operator Fails to Recover Room Cooling Locally Failure to Recover Offsite Power Within 2 Hours Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance
24	1.540E-09	0.53	IE LOOP 34BTD01_BATST OPF-SAC-2H REC OSP 2HR SAC01/QKA10 PM1	Initiator - Loss Of Offsite Power ELEC, 250V 1E 2-hr Battery 34BTD01, Fails on Demand Operator Fails to Recover Room Cooling Locally Failure to Recover Offsite Power Within 2 Hours Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
25	1.359E-09	0.47	IE LOOP EFWS PM1 REC OSP 2HR XKA10____DFR_D-ALL XKA80____DFR	Initiator - Loss Of Offsite Power EFWS Train 1 Unavailable due to Preventive Maintenance Failure to Recover Offsite Power Within 2 Hours CCF of EDGs to Run ELEC, SBO Diesel Generator XKA80, Fails to Run
26	1.359E-09	0.47	IE LOOP EFWS PM4 REC OSP 2HR XKA10____DFR_D-ALL XKA50____DFR	Initiator - Loss Of Offsite Power EFWS Train 4 Unavailable due to Preventive Maintenance Failure to Recover Offsite Power Within 2 Hours CCF of EDGs to Run ELEC, SBO Diesel Generator XKA50, Fails to Run
27	1.359E-09	0.47	IE LOOP REC OSP 2HR SBODG8 PM4 XKA10____DFR_D-ALL XKA50____DFR	Initiator - Loss Of Offsite Power Failure to Recover Offsite Power Within 2 Hours SBO-DG Train 4 Unavailable due to Preventive Maintenance CCF of EDGs to Run ELEC, SBO Diesel Generator XKA50, Fails to Run
28	1.359E-09	0.47	IE LOOP REC OSP 2HR SBODG5 PM1 XKA10____DFR_D-ALL XKA80____DFR	Initiator - Loss Of Offsite Power Failure to Recover Offsite Power Within 2 Hours SBO-DG Train 1 Unavailable due to Preventive Maintenance CCF of EDGs to Run ELEC, SBO Diesel Generator XKA80, Fails to Run
29	1.222E-09	0.42	IE SLOCA KAA12AA005EFO_D-ALL SAHR PM4	Initiator - Small LOCA (0.6 to 3-Inch Diameter) CCF to Open CCWS to LHSI HTX Cooling MOV SAHR Train Unavailable due to Preventive Maintenance
30	1.212E-09	0.42	IE IND SGTR OPE-RHR-4H	Initiator - Induced Steam Generator Tube Rupture Operator Fails to Initiate RHR Within 4 Hours

MCS Results

EPRDC050

INTERNAL

No.	Prob.	%	Event	Description
31	1.023E-09	0.35	IE SLOCA PED10AN002EFS_D-ALL SAHR PM4	Initiator - Small LOCA (0.6 to 3-Inch Diameter) CCF to Start Standby Cooling Tower Fans SAHR Train Unavailable due to Preventive Maintenance
32	9.820E-10	0.34	IE LOOP REC OSP 2HR XKA10____DFR_D-ALL XKA50____DFR_B-ALL	Initiator - Loss Of Offsite Power Failure to Recover Offsite Power Within 2 Hours CCF of EDGs to Run CCF of SBO DGs to Run
33	9.116E-10	0.32	IE LOOP OPF-SAC-2H QKA10AP107EFS REC OSP 2HR SAC04/QKA40 PM4	Initiator - Loss Of Offsite Power Operator Fails to Recover Room Cooling Locally SCWS, Train 1 Motor Driven Safety Chiller Pump QKA10AP107, Fails to Start on Demand Failure to Recover Offsite Power Within 2 Hours Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance
34	9.116E-10	0.32	IE LOOP OPF-SAC-2H QKA40AP107EFS REC OSP 2HR SAC01/QKA10 PM1	Initiator - Loss Of Offsite Power Operator Fails to Recover Room Cooling Locally SCWS, Train 4 Motor Driven Safety Chiller Pump QKA40AP107, Fails to Start on Demand Failure to Recover Offsite Power Within 2 Hours Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
35	8.970E-10	0.31	IE SLOCA CL-PS-B-SWCCF OPE-FB-40M	Initiator - Small LOCA (0.6 to 3-Inch Diameter) SW CCF of Protection System diversity group B Operator Fails to Initiate Feed & Bleed for SLOCA
36	8.970E-10	0.31	IE SLOCA CL-PS-B-SWCCF OPE-FCD-40M	Initiator - Small LOCA (0.6 to 3-Inch Diameter) SW CCF of Protection System diversity group B Operator Fails to Initiate Fast Cooldown for SLOCA
37	8.810E-10	0.31	IE LBOP OPF-SAC-2H SAC01AN001EFR_D-ALL	Initiator - Loss of Balance of Plant - Closed Loop Cooling Water or Aux Cooling Water Operator Fails to Recover Room Cooling Locally CCF to Run Normal Air Supply Fans
38	8.810E-10	0.31	IE LBOP OPF-SAC-2H SAC31AN001EFR_D-ALL	Initiator - Loss of Balance of Plant - Closed Loop Cooling Water or Aux Cooling Water Operator Fails to Recover Room Cooling Locally CCF to Run Normal Air Exhaust Fans
39	8.294E-10	0.29	IE SLOCA JND10AP001EFS_D-ALL OPE-FCD-40M	Initiator - Small LOCA (0.6 to 3-Inch Diameter) CCF of MHSI Pumps to Start Operator Fails to Initiate Fast Cooldown for SLOCA
40	8.256E-10	0.29	IE LOOP OPF-SAC-2H REC OSP 2HR SAC04/QKA40 PM4 SAC31AN001EFR	Initiator - Loss Of Offsite Power Operator Fails to Recover Room Cooling Locally Failure to Recover Offsite Power Within 2 Hours Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance SAC, Normal Air Exhaust Fan SAC31AN001, Fails to Run

MCS Results

EPRDC050

INTERNAL

No.	Prob.	%	Event	Description
41	8.256E-10	0.29	IE LOOP OPF-SAC-2H REC OSP 2HR SAC01/QKA10 PM1 SAC04AN001EFR	Initiator - Loss Of Offsite Power Operator Fails to Recover Room Cooling Locally Failure to Recover Offsite Power Within 2 Hours Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance SAC, Normal Air Supply Fan SAC04AN001, Fails to Run
42	8.256E-10	0.29	IE LOOP OPF-SAC-2H REC OSP 2HR SAC01/QKA10 PM1 SAC34AN001EFR	Initiator - Loss Of Offsite Power Operator Fails to Recover Room Cooling Locally Failure to Recover Offsite Power Within 2 Hours Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance SAC, Normal Air Exhaust Fan SAC34AN001, Fails to Run
43	8.256E-10	0.29	IE LOOP OPF-SAC-2H REC OSP 2HR SAC01AN001EFR SAC04/QKA40 PM4	Initiator - Loss Of Offsite Power Operator Fails to Recover Room Cooling Locally Failure to Recover Offsite Power Within 2 Hours SAC, Normal Air Supply Fan SAC01AN001, Fails to Run Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance
44	7.943E-10	0.28	IE LOOP OPF-SAC-2H QKA40GH001PANS REC OSP 2HR SAC01/QKA10 PM1	Initiator - Loss Of Offsite Power Operator Fails to Recover Room Cooling Locally SCWS, Train 4 Chiller Unit QKA40GH001, PAC A Priority Module (Type AV42) Fails (Non-Self-Monitored) Failure to Recover Offsite Power Within 2 Hours Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
45	7.943E-10	0.28	IE LOOP OPF-SAC-2H QKA10GH001PANS REC OSP 2HR SAC04/QKA40 PM4	Initiator - Loss Of Offsite Power Operator Fails to Recover Room Cooling Locally SCWS, Train 1 Chiller Unit QKA10GH001, PAC A Priority Module (Type AV42) Fails (Non-Self-Monitored) Failure to Recover Offsite Power Within 2 Hours Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance
46	7.856E-10	0.27	IE SLOCA CCWS/ESWS PM2 LOOPCONL+REC OPE-FB-40M OPF-XTDIV-NSC XKA30____DFR	Initiator - Small LOCA (0.6 to 3-Inch Diameter) CCWS/ESWS Train 2 Pump Unavailable due to Preventive Maintenance Consequential LOOP and Failure of Recovery Within 1 Hour for LOCA IEs Operator Fails to Initiate Feed & Bleed for SLOCA Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions ELEC, Emergency Diesel Generator XKA30, Fails to Run
47	7.856E-10	0.27	IE SLOCA CCWS/ESWS PM3 LOOPCONL+REC OPE-FB-40M OPF-XTDIV-NSC XKA20____DFR	Initiator - Small LOCA (0.6 to 3-Inch Diameter) CCWS/ESWS Train 3 Pump Unavailable due to Preventive Maintenance Consequential LOOP and Failure of Recovery Within 1 Hour for LOCA IEs Operator Fails to Initiate Feed & Bleed for SLOCA Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions ELEC, Emergency Diesel Generator XKA20, Fails to Run
48	7.798E-10	0.27	IE SLOCA JNK10AT001SPG_P-ALL	Initiator - Small LOCA (0.6 to 3-Inch Diameter) CCF of IRWST Sump Strainers - Plugged

MCS Results

EPRDC050

INTERNAL

No.	Prob.	%	Event	Description
49	7.747E-10	0.27	IE LOOP LAS41AP001EFR OPF-SAC-2H REC OSP 2HR SAC01/QKA10 PM1 XKA30____DFR	Initiator - Loss Of Offsite Power EFWS, Train 4 Motor Driven Pump LAS41AP001, Fails to Run Operator Fails to Recover Room Cooling Locally Failure to Recover Offsite Power Within 2 Hours Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance ELEC, Emergency Diesel Generator XKA30, Fails to Run
50	7.747E-10	0.27	IE LOOP LAS11AP001EFR OPF-SAC-2H REC OSP 2HR SAC04/QKA40 PM4 XKA20____DFR	Initiator - Loss Of Offsite Power EFWS, Train 1 Motor Driven Pump LAS11AP001, Fails to Run Operator Fails to Recover Room Cooling Locally Failure to Recover Offsite Power Within 2 Hours Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance ELEC, Emergency Diesel Generator XKA20, Fails to Run
51	7.564E-10	0.26	IE SLOCA MSRIVSOOFO_P-ALL OPE-FB-40M	Initiator - Small LOCA (0.6 to 3-Inch Diameter) CCF to Open Main Steam Relief Isolation Solenoid Pilot Valves Operator Fails to Initiate Feed & Bleed for SLOCA
52	7.519E-10	0.26	IE SLOCA LOOPCONL+REC XKA10____DFR_D-ALL	Initiator - Small LOCA (0.6 to 3-Inch Diameter) Consequential LOOP and Failure of Recovery Within 1 Hour for LOCA IEs CCF of EDGs to Run
53	6.774E-10	0.23	IE GT OPF-EBS-30M STUCK ROD	Initiator - General Transient (Includes Turbine Trip and Reactor Trip) Operator Fails to Manually Actuate EBS (SLB & ATWS) Stuck Control Rods
54	6.723E-10	0.23	IE SLBI SG4 PRES CCF-ALL	Initiator - Steam Break Inside Containment CCF of SG4 pressure sensors
55	6.074E-10	0.21	IE LOOP CL-TXS-OSCCF REC OSP 2HR	Initiator - Loss Of Offsite Power SW CCF of TXS operating system or multiple diversity groups Failure to Recover Offsite Power Within 2 Hours
56	5.622E-10	0.19	IE LOOP OPF-SAC-2H QKA40AP107EFR REC OSP 2HR SAC01/QKA10 PM1	Initiator - Loss Of Offsite Power Operator Fails to Recover Room Cooling Locally SCWS, Train 4 Motor Driven Safety Chiller Pump QKA40AP107, Fails to Run Failure to Recover Offsite Power Within 2 Hours Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
57	5.622E-10	0.19	IE LOOP OPF-SAC-2H QKA10AP107EFR REC OSP 2HR SAC04/QKA40 PM4	Initiator - Loss Of Offsite Power Operator Fails to Recover Room Cooling Locally SCWS, Train 1 Motor Driven Safety Chiller Pump QKA10AP107, Fails to Run Failure to Recover Offsite Power Within 2 Hours Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance
58	5.358E-10	0.19	IE SLBO LBA10AA002PFC_D-ALL OPF-EBS-30M	Initiator - Steam Break Downstream of MSIV CCF to Close Main Steam Isolation Valves Operator Fails to Manually Actuate EBS (SLB & ATWS)

MCS Results

EPRDC050

INTERNAL

No.	Prob.	%	Event	Description
59	5.237E-10	0.18	IE SLOCA	Initiator - Small LOCA (0.6 to 3-Inch Diameter)
			EDG PM3	EDG Train 3 Unavailable due to Preventive Maintenance
			LOOPCONL+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for LOCA IEs
			OPE-FB-40M	Operator Fails to Initiate Feed & Bleed for SLOCA
			OPF-XTDIV-NSC	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions
			XKA20____DFR	ELEC, Emergency Diesel Generator XKA20, Fails to Run
60	5.237E-10	0.18	IE SLOCA	Initiator - Small LOCA (0.6 to 3-Inch Diameter)
			EDG PM2	EDG Train 2 Unavailable due to Preventive Maintenance
			LOOPCONL+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for LOCA IEs
			OPE-FB-40M	Operator Fails to Initiate Feed & Bleed for SLOCA
			OPF-XTDIV-NSC	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions
			XKA30____DFR	ELEC, Emergency Diesel Generator XKA30, Fails to Run
61	5.016E-10	0.17	IE LOOP	Initiator - Loss Of Offsite Power
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			REC OSP 2HR	Failure to Recover Offsite Power Within 2 Hours
			SAC01/QKA10 PM1	Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
			SAC34AN001EFS	SAC, Normal Air Exhaust Fan SAC34AN001, Fails to Start on Demand
62	5.016E-10	0.17	IE LOOP	Initiator - Loss Of Offsite Power
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			REC OSP 2HR	Failure to Recover Offsite Power Within 2 Hours
			SAC04/QKA40 PM4	Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance
			SAC31AN001EFS	SAC, Normal Air Exhaust Fan SAC31AN001, Fails to Start on Demand
63	5.016E-10	0.17	IE LOOP	Initiator - Loss Of Offsite Power
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			REC OSP 2HR	Failure to Recover Offsite Power Within 2 Hours
			SAC01/QKA10 PM1	Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
			SAC04AN001EFS	SAC, Normal Air Supply Fan SAC04AN001, Fails to Start on Demand
64	5.016E-10	0.17	IE LOOP	Initiator - Loss Of Offsite Power
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			REC OSP 2HR	Failure to Recover Offsite Power Within 2 Hours
			SAC01AN001EFS	SAC, Normal Air Supply Fan SAC01AN001, Fails to Start on Demand
			SAC04/QKA40 PM4	Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance
65	4.979E-10	0.17	IE SLBO	Initiator - Steam Break Downstream of MSIV
			LBA10AA002PFC_D-234	CCF to Close Main Steam Isolation Valves
			OPF-EBS-30M	Operator Fails to Manually Actuate EBS (SLB & ATWS)
66	4.979E-10	0.17	IE SLBO	Initiator - Steam Break Downstream of MSIV
			LBA10AA002PFC_D-124	CCF to Close Main Steam Isolation Valves
			OPF-EBS-30M	Operator Fails to Manually Actuate EBS (SLB & ATWS)
67	4.979E-10	0.17	IE SLBO	Initiator - Steam Break Downstream of MSIV
			LBA10AA002PFC_D-123	CCF to Close Main Steam Isolation Valves
			OPF-EBS-30M	Operator Fails to Manually Actuate EBS (SLB & ATWS)

MCS Results

EPRDC050

INTERNAL

No.	Prob.	%	Event	Description
68	4.979E-10	0.17	IE SLBO LBA10AA002PFC_D-134 OPF-EBS-30M	Initiator - Steam Break Downstream of MSIV CCF to Close Main Steam Isolation Valves Operator Fails to Manually Actuate EBS (SLB & ATWS)
69	4.321E-10	0.15	IE SLOCA CCWS/ESWS PM3 JND10AP001EFR_D-124 OPE-FCD-40M	Initiator - Small LOCA (0.6 to 3-Inch Diameter) CCWS/ESWS Train 3 Pump Unavailable due to Preventive Maintenance CCF of MHSI Pumps to Run Operator Fails to Initiate Fast Cooldown for SLOCA
70	4.321E-10	0.15	IE SLOCA CCWS/ESWS PM2 JND10AP001EFR_D-134 OPE-FCD-40M	Initiator - Small LOCA (0.6 to 3-Inch Diameter) CCWS/ESWS Train 2 Pump Unavailable due to Preventive Maintenance CCF of MHSI Pumps to Run Operator Fails to Initiate Fast Cooldown for SLOCA
71	4.234E-10	0.15	IE LBOP OPF-SAC-2H QKA10AP107EFR_D-ALL	Initiator - Loss of Balance of Plant - Closed Loop Cooling Water or Aux Cooling Water Operator Fails to Recover Room Cooling Locally CCF of SCWS Pumps to Run
72	4.215E-10	0.15	IE LOOP EFWS PM4 OPF-SAC-2H QKA10GH001_FS REC OSP 2HR XKA30____DFR	Initiator - Loss Of Offsite Power EFWS Train 4 Unavailable due to Preventive Maintenance Operator Fails to Recover Room Cooling Locally SCWS, Train 1 Chiller Unit QKA10GH001, Fails to Start on Demand Failure to Recover Offsite Power Within 2 Hours ELEC, Emergency Diesel Generator XKA30, Fails to Run
73	4.215E-10	0.15	IE LOOP EFWS PM1 OPF-SAC-2H QKA40GH001_FS REC OSP 2HR XKA20____DFR	Initiator - Loss Of Offsite Power EFWS Train 1 Unavailable due to Preventive Maintenance Operator Fails to Recover Room Cooling Locally SCWS, Train 4 Chiller Unit QKA40GH001, Fails to Start on Demand Failure to Recover Offsite Power Within 2 Hours ELEC, Emergency Diesel Generator XKA20, Fails to Run
74	4.180E-10	0.14	IE SLBI SG4 PRES CCF-124	Initiator - Steam Break Inside Containment CCF of SG4 pressure sensors
75	4.180E-10	0.14	IE SLBI SG4 PRES CCF-234	Initiator - Steam Break Inside Containment CCF of SG4 pressure sensors
76	4.180E-10	0.14	IE SLBI SG4 PRES CCF-134	Initiator - Steam Break Inside Containment CCF of SG4 pressure sensors
77	4.180E-10	0.14	IE SLBI SG4 PRES CCF-123	Initiator - Steam Break Inside Containment CCF of SG4 pressure sensors
78	4.126E-10	0.14	IE GT LOOPCON+REC OPF-SAC-2H QKA10GH001_FS QKA40GH001_FS	Initiator - General Transient (Includes Turbine Trip and Reactor Trip) Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram Operator Fails to Recover Room Cooling Locally SCWS, Train 1 Chiller Unit QKA10GH001, Fails to Start on Demand SCWS, Train 4 Chiller Unit QKA40GH001, Fails to Start on Demand

MCS Results

EPRDC050

INTERNAL

No.	Prob.	%	Event	Description
79	4.112E-10	0.14	IE GT	Initiator - General Transient (Includes Turbine Trip and Reactor Trip)
			LOOPCON+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram
			XKA10____DFR_D-ALL	CCF of EDGs to Run
			XKA50____DFR	ELEC, SBO Diesel Generator XKA50, Fails to Run
			XKA80____DFR	ELEC, SBO Diesel Generator XKA80, Fails to Run
80	4.034E-10	0.14	IE LOOP	Initiator - Loss Of Offsite Power
			LAS41AP001EFR	EFWS, Train 4 Motor Driven Pump LAS41AP001, Fails to Run
			REC OSP 2HR	Failure to Recover Offsite Power Within 2 Hours
			XKA10____DFR_D-ALL	CCF of EDGs to Run
			XKA50____DFR	ELEC, SBO Diesel Generator XKA50, Fails to Run
81	4.034E-10	0.14	IE LOOP	Initiator - Loss Of Offsite Power
			LAS11AP001EFR	EFWS, Train 1 Motor Driven Pump LAS11AP001, Fails to Run
			REC OSP 2HR	Failure to Recover Offsite Power Within 2 Hours
			XKA10____DFR_D-ALL	CCF of EDGs to Run
			XKA80____DFR	ELEC, SBO Diesel Generator XKA80, Fails to Run
82	3.959E-10	0.14	IE GT	Initiator - General Transient (Includes Turbine Trip and Reactor Trip)
			BTD01_BAT__ST_D-ALL	CCF of Safety Related Batteries on Demand
			LOOPCON+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram
83	3.908E-10	0.14	IE GT	Initiator - General Transient (Includes Turbine Trip and Reactor Trip)
			LOOPCON+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			QKA10GH001_FR_B-ALL	CCF of the Air Cooled SCWS Chiller Units to Run
84	3.746E-10	0.13	IE LOOP	Initiator - Loss Of Offsite Power
			OPF-XTLDSBO-2H	Operator Fails to Connect and Load SBO DGs to Div 1 and 4
			REC OSP 2HR	Failure to Recover Offsite Power Within 2 Hours
			XKA10____DFR_D-ALL	CCF of EDGs to Run
85	3.677E-10	0.13	IE GT	Initiator - General Transient (Includes Turbine Trip and Reactor Trip)
			LOOPCON+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			QKA10GH001_FR	SCWS, Train 1 Chiller Unit QKA10GH001, Fails to Run
			SAC04/QKA40 PM4	Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance
86	3.677E-10	0.13	IE GT	Initiator - General Transient (Includes Turbine Trip and Reactor Trip)
			LOOPCON+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			QKA40GH001_FR	SCWS, Train 4 Chiller Unit QKA40GH001, Fails to Run
			SAC01/QKA10 PM1	Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
87	3.632E-10	0.13	IE LOOP	Initiator - Loss Of Offsite Power
			34BNB01__RFR	ELEC, 480V AC to 24V DC Rectifier for MCC 34BNB01 Control Power, Fails to Run
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			REC OSP 2HR	Failure to Recover Offsite Power Within 2 Hours
			SAC01/QKA10 PM1	Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance

MCS Results

EPRDC050

INTERNAL

No.	Prob.	%	Event	Description
88	3.632E-10	0.13	IE LOOP	Initiator - Loss Of Offsite Power
			31BNB01___RFR	ELEC, 480V AC to 24V DC Rectifier for MCC 31BNB01 Control Power, Fails to Run
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			REC OSP 2HR	Failure to Recover Offsite Power Within 2 Hours
			SAC04/QKA40 PM4	Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance
89	3.620E-10	0.13	IE LOOP	Initiator - Loss Of Offsite Power
			JEB30AA010EFC	RCP, RCP3 Leakoff Isolation MOV JEB30AA010, Fails to Close on Demand
			OPE-FCD-40MSBO	Operator Fails to Initiate Fast Cooldown for RCP During SBO Conditions
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
			REC OSP 1HR	Failure to Recover Offsite Power Within 1 Hour
			XKA10___DFR_D-ALL	CCF of EDGs to Run
90	3.620E-10	0.13	IE LOOP	Initiator - Loss Of Offsite Power
			JEB40AA010EFC	RCP, RCP4 Leakoff Isolation MOV JEB40AA010, Fails to Close on Demand
			OPE-FCD-40MSBO	Operator Fails to Initiate Fast Cooldown for RCP During SBO Conditions
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
			REC OSP 1HR	Failure to Recover Offsite Power Within 1 Hour
			XKA10___DFR_D-ALL	CCF of EDGs to Run
91	3.620E-10	0.13	IE LOOP	Initiator - Loss Of Offsite Power
			JEB20AA020EFC	RCP Seal, RCP2 Seal Nitrogen Venting Isolation MOV JEB20AA020, Fails to Close on Demand
			OPE-FCD-40MSBO	Operator Fails to Initiate Fast Cooldown for RCP During SBO Conditions
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
			REC OSP 1HR	Failure to Recover Offsite Power Within 1 Hour
			XKA10___DFR_D-ALL	CCF of EDGs to Run
92	3.620E-10	0.13	IE LOOP	Initiator - Loss Of Offsite Power
			JEB10AA020EFC	RCP Seal, RCP1 Seal Nitrogen Venting Isolation MOV JEB10AA020, Fails to Close on Demand
			OPE-FCD-40MSBO	Operator Fails to Initiate Fast Cooldown for RCP During SBO Conditions
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
			REC OSP 1HR	Failure to Recover Offsite Power Within 1 Hour
			XKA10___DFR_D-ALL	CCF of EDGs to Run
93	3.620E-10	0.13	IE LOOP	Initiator - Loss Of Offsite Power
			JEB30AA020EFC	RCP Seal, RCP3 Seal Nitrogen Venting Isolation MOV JEB30AA020, Fails to Close on Demand
			OPE-FCD-40MSBO	Operator Fails to Initiate Fast Cooldown for RCP During SBO Conditions
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
			REC OSP 1HR	Failure to Recover Offsite Power Within 1 Hour
			XKA10___DFR_D-ALL	CCF of EDGs to Run
94	3.620E-10	0.13	IE LOOP	Initiator - Loss Of Offsite Power
			JEB20AA010EFC	RCP, RCP2 Leakoff Isolation MOV JEB20AA010, Fails to Close on Demand
			OPE-FCD-40MSBO	Operator Fails to Initiate Fast Cooldown for RCP During SBO Conditions
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
			REC OSP 1HR	Failure to Recover Offsite Power Within 1 Hour
			XKA10___DFR_D-ALL	CCF of EDGs to Run

MCS Results

EPRDC050

INTERNAL

No.	Prob.	%	Event	Description
95	3.620E-10	0.13	IE LOOP	Initiator - Loss Of Offsite Power
			JEB40AA020EFC	RCP Seal, RCP4 Seal Nitrogen Venting Isolation MOV JEB40AA020, Fails to Close on Demand
			OPE-FCD-40MSBO	Operator Fails to Initiate Fast Cooldown for RCP During SBO Conditions
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
			REC OSP 1HR	Failure to Recover Offsite Power Within 1 Hour
XKA10_____DFR_D-ALL	CCF of EDGs to Run			
96	3.620E-10	0.13	IE LOOP	Initiator - Loss Of Offsite Power
			JEB10AA010EFC	RCP, RCP1 Leakoff Isolation MOV JEB10AA010, Fails to Close on Demand
			OPE-FCD-40MSBO	Operator Fails to Initiate Fast Cooldown for RCP During SBO Conditions
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
			REC OSP 1HR	Failure to Recover Offsite Power Within 1 Hour
XKA10_____DFR_D-ALL	CCF of EDGs to Run			
97	3.606E-10	0.12	IE SLOCA	Initiator - Small LOCA (0.6 to 3-Inch Diameter)
			LOOPCONL+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for LOCA IEs
			OPE-FB-40M	Operator Fails to Initiate Feed & Bleed for SLOCA
			OPF-XTDIV-NSC	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions
			XKA20_____DFR	ELEC, Emergency Diesel Generator XKA20, Fails to Run
XKA30_____DFR	ELEC, Emergency Diesel Generator XKA30, Fails to Run			
98	3.467E-10	0.12	IE LOMFW	Initiator - Total Loss of Main Feedwater
			LOOPCON+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
QKA10GH001_FS_B-ALL	CCF of the Air Cooled SCWS Chiller Units to Start			
99	3.428E-10	0.12	IE GT	Initiator - General Transient (Includes Turbine Trip and Reactor Trip)
			31BTD01_BATST	ELEC, 250V 1E 2-hr Battery 31BTD01, Fails on Demand
			LOOPCON+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
SAC04/QKA40 PM4	Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance			
100	3.428E-10	0.12	IE GT	Initiator - General Transient (Includes Turbine Trip and Reactor Trip)
			34BTD01_BATST	ELEC, 250V 1E 2-hr Battery 34BTD01, Fails on Demand
			LOOPCON+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
SAC01/QKA10 PM1	Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance			
101	3.342E-10	0.12	IE SLBI	Initiator - Steam Break Inside Containment
			ALU-B CCF NS-ALL	CCF of ALU-B Protection System Computer Processors (Non-Self-Monitored)
102	3.342E-10	0.12	IE SLBI	Initiator - Steam Break Inside Containment
			APU4 CCF NS-ALL	CCF of APU-4 Protection System Computer Processors (Non-Self-Monitored)

MCS Results

EPRDC050

INTERNAL

No.	Prob.	%	Event	Description
103	3.341E-10	0.12	IE LOOP	Initiator - Loss Of Offsite Power
			LAS11AP001EFR	EFWS, Train 1 Motor Driven Pump LAS11AP001, Fails to Run
			LAS21AP001EFR	EFWS, Train 2 Motor Driven Pump LAS21AP001, Fails to Run
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			REC OSP 2HR	Failure to Recover Offsite Power Within 2 Hours
			SAC04/QKA40 PM4	Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance
104	3.341E-10	0.12	IE LOOP	Initiator - Loss Of Offsite Power
			LAS31AP001EFR	EFWS, Train 3 Motor Driven Pump LAS31AP001, Fails to Run
			LAS41AP001EFR	EFWS, Train 4 Motor Driven Pump LAS41AP001, Fails to Run
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			REC OSP 2HR	Failure to Recover Offsite Power Within 2 Hours
			SAC01/QKA10 PM1	Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
105	3.326E-10	0.12	IE LOMFW	Initiator - Total Loss of Main Feedwater
			CF LOMFW/SSS	Common Factor LOMFW/SSS
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			SAC31AN001EFR_D-ALL	CCF to Run Normal Air Exhaust Fans
106	3.326E-10	0.12	IE LOMFW	Initiator - Total Loss of Main Feedwater
			CF LOMFW/SSS	Common Factor LOMFW/SSS
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			SAC01AN001EFR_D-ALL	CCF to Run Normal Air Supply Fans
107	3.262E-10	0.11	IE LOMFW	Initiator - Total Loss of Main Feedwater
			LOOPCON+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			QKA40GH001_FS	SCWS, Train 4 Chiller Unit QKA40GH001, Fails to Start on Demand
			SAC01/QKA10 PM1	Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
108	3.262E-10	0.11	IE LOMFW	Initiator - Total Loss of Main Feedwater
			LOOPCON+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			QKA10GH001_FS	SCWS, Train 1 Chiller Unit QKA10GH001, Fails to Start on Demand
			SAC04/QKA40 PM4	Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance
109	3.024E-10	0.10	IE GT	Initiator - General Transient (Includes Turbine Trip and Reactor Trip)
			EFWS PM4	EFWS Train 4 Unavailable due to Preventive Maintenance
			LOOPCON+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram
			XKA10____DFR_D-ALL	CCF of EDGs to Run
			XKA50____DFR	ELEC, SBO Diesel Generator XKA50, Fails to Run
110	3.024E-10	0.10	IE GT	Initiator - General Transient (Includes Turbine Trip and Reactor Trip)
			LOOPCON+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram
			SBODG5 PM1	SBO-DG Train 1 Unavailable due to Preventive Maintenance
			XKA10____DFR_D-ALL	CCF of EDGs to Run
			XKA80____DFR	ELEC, SBO Diesel Generator XKA80, Fails to Run

MCS Results

EPRDC050

INTERNAL

No.	Prob.	%	Event	Description
111	3.024E-10	0.10	IE GT LOOPCON+REC SBODG8 PM4 XKA10____DFR_D-ALL XKA50____DFR	Initiator - General Transient (Includes Turbine Trip and Reactor Trip) Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram SBO-DG Train 4 Unavailable due to Preventive Maintenance CCF of EDGs to Run ELEC, SBO Diesel Generator XKA50, Fails to Run
112	3.024E-10	0.10	IE GT EFWS PM1 LOOPCON+REC XKA10____DFR_D-ALL XKA80____DFR	Initiator - General Transient (Includes Turbine Trip and Reactor Trip) EFWS Train 1 Unavailable due to Preventive Maintenance Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram CCF of EDGs to Run ELEC, SBO Diesel Generator XKA80, Fails to Run
113	2.966E-10	0.10	IE LOOP EFWS PM1 LAS41AP001EFR REC OSP 2HR XKA10____DFR_D-ALL	Initiator - Loss Of Offsite Power EFWS Train 1 Unavailable due to Preventive Maintenance EFWS, Train 4 Motor Driven Pump LAS41AP001, Fails to Run Failure to Recover Offsite Power Within 2 Hours CCF of EDGs to Run
114	2.966E-10	0.10	IE LOOP EFWS PM4 LAS11AP001EFR REC OSP 2HR XKA10____DFR_D-ALL	Initiator - Loss Of Offsite Power EFWS Train 4 Unavailable due to Preventive Maintenance EFWS, Train 1 Motor Driven Pump LAS11AP001, Fails to Run Failure to Recover Offsite Power Within 2 Hours CCF of EDGs to Run
115	2.966E-10	0.10	IE LOOP LAS41AP001EFR REC OSP 2HR SBODG5 PM1 XKA10____DFR_D-ALL	Initiator - Loss Of Offsite Power EFWS, Train 4 Motor Driven Pump LAS41AP001, Fails to Run Failure to Recover Offsite Power Within 2 Hours SBO-DG Train 1 Unavailable due to Preventive Maintenance CCF of EDGs to Run
116	2.966E-10	0.10	IE LOOP LAS11AP001EFR REC OSP 2HR SBODG8 PM4 XKA10____DFR_D-ALL	Initiator - Loss Of Offsite Power EFWS, Train 1 Motor Driven Pump LAS11AP001, Fails to Run Failure to Recover Offsite Power Within 2 Hours SBO-DG Train 4 Unavailable due to Preventive Maintenance CCF of EDGs to Run
117	2.932E-10	0.10	IE LOC LOOPCON+REC OPF-SAC-2H QKA10GH001_FS_B-ALL	Initiator - Loss of Main Condenser (Includes MSIV Closure etc.) Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram Operator Fails to Recover Room Cooling Locally CCF of the Air Cooled SCWS Chiller Units to Start
118	2.881E-10	0.10	IE SLOCA JND10AP001EFR_D-124 MHSI PM3 OPE-FCD-40M	Initiator - Small LOCA (0.6 to 3-Inch Diameter) CCF of MHSI Pumps to Run MHSI Train 3 Unavailable due to Preventive Maintenance Operator Fails to Initiate Fast Cooldown for SLOCA
119	2.881E-10	0.10	IE SLOCA JND10AP001EFR_D-123 MHSI PM4 OPE-FCD-40M	Initiator - Small LOCA (0.6 to 3-Inch Diameter) CCF of MHSI Pumps to Run MHSI Train 4 Unavailable due to Preventive Maintenance Operator Fails to Initiate Fast Cooldown for SLOCA

MCS Results

EPRDC050

INTERNAL

No.	Prob.	%	Event	Description
120	2.881E-10	0.10	IE SLOCA JND10AP001EFR_D-234 MHSI PM1 OPE-FCD-40M	Initiator - Small LOCA (0.6 to 3-Inch Diameter) CCF of MHSI Pumps to Run MHSI Train 1 Unavailable due to Preventive Maintenance Operator Fails to Initiate Fast Cooldown for SLOCA
121	2.881E-10	0.10	IE SLOCA JND10AP001EFR_D-134 MHSI PM2 OPE-FCD-40M	Initiator - Small LOCA (0.6 to 3-Inch Diameter) CCF of MHSI Pumps to Run MHSI Train 2 Unavailable due to Preventive Maintenance Operator Fails to Initiate Fast Cooldown for SLOCA
122	2.876E-10	0.10	IE LBOP LAS11AP001EFS_D-ALL OPE-FB-90M	Initiator - Loss of Balance of Plant - Closed Loop Cooling Water or Aux Cooling Water CCF of EFWS Pumps to Start Operator Fails to Initiate Feed & Bleed for Transient
123	2.832E-10	0.10	IE SGTR LBA40AA002POP OPE-RHR-4H	Initiator - Steam Generator Tube Rupture MSS, Train 4 Main Steam Isolation Valve LBA40AA002, Fails to Remain Closed (SO) Operator Fails to Initiate RHR Within 4 Hours
124	2.759E-10	0.10	IE LOC LOOPCON+REC OPF-SAC-2H QKA10GH001_FS SAC04/QKA40 PM4	Initiator - Loss of Main Condenser (Includes MSIV Closure etc.) Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram Operator Fails to Recover Room Cooling Locally SCWS, Train 1 Chiller Unit QKA10GH001, Fails to Start on Demand Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance
125	2.759E-10	0.10	IE LOC LOOPCON+REC OPF-SAC-2H QKA40GH001_FS SAC01/QKA10 PM1	Initiator - Loss of Main Condenser (Includes MSIV Closure etc.) Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram Operator Fails to Recover Room Cooling Locally SCWS, Train 4 Chiller Unit QKA40GH001, Fails to Start on Demand Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
126	2.726E-10	0.09	IE LOOP CCWS/ESWS PM2 LAS11AP001EFR OPF-SAC-2H QKA40GH001_FS REC OSP 2HR	Initiator - Loss Of Offsite Power CCWS/ESWS Train 2 Pump Unavailable due to Preventive Maintenance EFWS, Train 1 Motor Driven Pump LAS11AP001, Fails to Run Operator Fails to Recover Room Cooling Locally SCWS, Train 4 Chiller Unit QKA40GH001, Fails to Start on Demand Failure to Recover Offsite Power Within 2 Hours
127	2.726E-10	0.09	IE LOOP CCWS/ESWS PM3 LAS41AP001EFR OPF-SAC-2H QKA10GH001_FS REC OSP 2HR	Initiator - Loss Of Offsite Power CCWS/ESWS Train 3 Pump Unavailable due to Preventive Maintenance EFWS, Train 4 Motor Driven Pump LAS41AP001, Fails to Run Operator Fails to Recover Room Cooling Locally SCWS, Train 1 Chiller Unit QKA10GH001, Fails to Start on Demand Failure to Recover Offsite Power Within 2 Hours
128	2.669E-10	0.09	IE LOOP OPF-SAC-2H QKA10GH001_FS QKA40GH001_FR REC OSP 2HR	Initiator - Loss Of Offsite Power Operator Fails to Recover Room Cooling Locally SCWS, Train 1 Chiller Unit QKA10GH001, Fails to Start on Demand SCWS, Train 4 Chiller Unit QKA40GH001, Fails to Run Failure to Recover Offsite Power Within 2 Hours

MCS Results

EPRDC050

INTERNAL

No.	Prob.	%	Event	Description
129	2.669E-10	0.09	IE LOOP OPF-SAC-2H QKA10GH001_FR QKA40GH001_FS REC OSP 2HR	Initiator - Loss Of Offsite Power Operator Fails to Recover Room Cooling Locally SCWS, Train 1 Chiller Unit QKA10GH001, Fails to Run SCWS, Train 4 Chiller Unit QKA40GH001, Fails to Start on Demand Failure to Recover Offsite Power Within 2 Hours
130	2.576E-10	0.09	IE SLBI LBA10AA002PFC_D-ALL OPF-EBS-30M	Initiator - Steam Break Inside Containment CCF to Close Main Steam Isolation Valves Operator Fails to Manually Actuate EBS (SLB & ATWS)
131	2.576E-10	0.09	IE MSSV LBA10AA002PFC_D-ALL OPF-EBS-30M	Initiator - Spurious Opening of Steam Safety Valve CCF to Close Main Steam Isolation Valves Operator Fails to Manually Actuate EBS (SLB & ATWS)
132	2.574E-10	0.09	IE SGTR LBA41AA191SPO OPE-RHR-4H	Initiator - Steam Generator Tube Rupture MSS, Train 4 Main Steam Safety Relief Valve LBA41AA191, Premature Opening Operator Fails to Initiate RHR Within 4 Hours
133	2.574E-10	0.09	IE SGTR LBA42AA191SPO OPE-RHR-4H	Initiator - Steam Generator Tube Rupture MSS, Train 4 Main Steam Safety Relief Valve LBA42AA191, Premature Opening Operator Fails to Initiate RHR Within 4 Hours
134	2.488E-10	0.09	IE LOOP 31BTD01_BATST OPF-SAC-2H QKA40GH001_FS REC OSP 2HR	Initiator - Loss Of Offsite Power ELEC, 250V 1E 2-hr Battery 31BTD01, Fails on Demand Operator Fails to Recover Room Cooling Locally SCWS, Train 4 Chiller Unit QKA40GH001, Fails to Start on Demand Failure to Recover Offsite Power Within 2 Hours
135	2.488E-10	0.09	IE LOOP 34BTD01_BATST OPF-SAC-2H QKA10GH001_FS REC OSP 2HR	Initiator - Loss Of Offsite Power ELEC, 250V 1E 2-hr Battery 34BTD01, Fails on Demand Operator Fails to Recover Room Cooling Locally SCWS, Train 1 Chiller Unit QKA10GH001, Fails to Start on Demand Failure to Recover Offsite Power Within 2 Hours
136	2.446E-10	0.08	IE LBOP LAS11AP001EFR_D-ALL OPE-FB-90M	Initiator - Loss of Balance of Plant - Closed Loop Cooling Water or Aux Cooling Water CCF of EFWS Pumps to Run Operator Fails to Initiate Feed & Bleed for Transient
137	2.394E-10	0.08	IE MSSV LBA10AA002PFC_D-124 OPF-EBS-30M	Initiator - Spurious Opening of Steam Safety Valve CCF to Close Main Steam Isolation Valves Operator Fails to Manually Actuate EBS (SLB & ATWS)
138	2.394E-10	0.08	IE SLBI LBA10AA002PFC_D-234 OPF-EBS-30M	Initiator - Steam Break Inside Containment CCF to Close Main Steam Isolation Valves Operator Fails to Manually Actuate EBS (SLB & ATWS)
139	2.394E-10	0.08	IE MSSV LBA10AA002PFC_D-134 OPF-EBS-30M	Initiator - Spurious Opening of Steam Safety Valve CCF to Close Main Steam Isolation Valves Operator Fails to Manually Actuate EBS (SLB & ATWS)

MCS Results

EPRDC050

INTERNAL

No.	Prob.	%	Event	Description
140	2.394E-10	0.08	IE MSSV LBA10AA002PFC_D-234 OPF-EBS-30M	Initiator - Spurious Opening of Steam Safety Valve CCF to Close Main Steam Isolation Valves Operator Fails to Manually Actuate EBS (SLB & ATWS)
141	2.394E-10	0.08	IE SLBI LBA10AA002PFC_D-124 OPF-EBS-30M	Initiator - Steam Break Inside Containment CCF to Close Main Steam Isolation Valves Operator Fails to Manually Actuate EBS (SLB & ATWS)
142	2.394E-10	0.08	IE SLBI LBA10AA002PFC_D-134 OPF-EBS-30M	Initiator - Steam Break Inside Containment CCF to Close Main Steam Isolation Valves Operator Fails to Manually Actuate EBS (SLB & ATWS)
143	2.360E-10	0.08	IE LOOP OPF-SAC-2H QKA10AP107EFS_D-14 REC OSP 2HR	Initiator - Loss Of Offsite Power Operator Fails to Recover Room Cooling Locally CCF of SCWS Pumps to Start Failure to Recover Offsite Power Within 2 Hours
144	2.288E-10	0.08	IE SLBO CL-PS-B-SWCCF OPF-EBS-30M	Initiator - Steam Break Downstream of MSIV SW CCF of Protection System diversity group B Operator Fails to Manually Actuate EBS (SLB & ATWS)
145	2.260E-10	0.08	IE LOOP BTD01_BAT__ST_D-124 CCWS/ESWS PM3 REC OSP 2HR	Initiator - Loss Of Offsite Power CCF of Safety Related Batteries on Demand CCWS/ESWS Train 3 Pump Unavailable due to Preventive Maintenance Failure to Recover Offsite Power Within 2 Hours
146	2.260E-10	0.08	IE LOOP BTD01_BAT__ST_D-134 CCWS/ESWS PM2 REC OSP 2HR	Initiator - Loss Of Offsite Power CCF of Safety Related Batteries on Demand CCWS/ESWS Train 2 Pump Unavailable due to Preventive Maintenance Failure to Recover Offsite Power Within 2 Hours
147	2.189E-10	0.08	IE LOCCW-ALL JEB40AA010EFC OPE-FCD-40M PROB SEAL LOCA	Initiator - Loss of CCWS/ESWS - Total Loss of 4 Divisions RCP, RCP4 Leakoff Isolation MOV JEB40AA010, Fails to Close on Demand Operator Fails to Initiate Fast Cutdown for SLOCA Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
148	2.189E-10	0.08	IE LOCCW-ALL JEB10AA020EFC OPE-FCD-40M PROB SEAL LOCA	Initiator - Loss of CCWS/ESWS - Total Loss of 4 Divisions RCP Seal, RCP1 Seal Nitrogen Venting Isolation MOV JEB10AA020, Fails to Close on Demand Operator Fails to Initiate Fast Cutdown for SLOCA Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
149	2.189E-10	0.08	IE LOCCW-ALL JEB30AA020EFC OPE-FCD-40M PROB SEAL LOCA	Initiator - Loss of CCWS/ESWS - Total Loss of 4 Divisions RCP Seal, RCP3 Seal Nitrogen Venting Isolation MOV JEB30AA020, Fails to Close on Demand Operator Fails to Initiate Fast Cutdown for SLOCA Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
150	2.189E-10	0.08	IE LOCCW-ALL JEB40AA020EFC OPE-FCD-40M PROB SEAL LOCA	Initiator - Loss of CCWS/ESWS - Total Loss of 4 Divisions RCP Seal, RCP4 Seal Nitrogen Venting Isolation MOV JEB40AA020, Fails to Close on Demand Operator Fails to Initiate Fast Cutdown for SLOCA Probability of Seal LOCA Occurring Given a Loss of Seal Cooling

MCS Results

EPRDC050

INTERNAL

No.	Prob.	%	Event	Description
151	2.189E-10	0.08	IE LOCCW-ALL	Initiator - Loss of CCWS/ESWS - Total Loss of 4 Divisions
			JEB30AA010EFC	RCP, RCP3 Leakoff Isolation MOV JEB30AA010, Fails to Close on Demand
			OPE-FCD-40M PROB SEAL LOCA	Operator Fails to Initiate Fast Cooldown for SLOCA Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
152	2.189E-10	0.08	IE LOCCW-ALL	Initiator - Loss of CCWS/ESWS - Total Loss of 4 Divisions
			JEB10AA010EFC	RCP, RCP1 Leakoff Isolation MOV JEB10AA010, Fails to Close on Demand
			OPE-FCD-40M PROB SEAL LOCA	Operator Fails to Initiate Fast Cooldown for SLOCA Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
153	2.189E-10	0.08	IE LOCCW-ALL	Initiator - Loss of CCWS/ESWS - Total Loss of 4 Divisions
			JEB20AA020EFC	RCP Seal, RCP2 Seal Nitrogen Venting Isolation MOV JEB20AA020, Fails to Close on Demand
			OPE-FCD-40M PROB SEAL LOCA	Operator Fails to Initiate Fast Cooldown for SLOCA Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
154	2.189E-10	0.08	IE LOCCW-ALL	Initiator - Loss of CCWS/ESWS - Total Loss of 4 Divisions
			JEB20AA010EFC	RCP, RCP2 Leakoff Isolation MOV JEB20AA010, Fails to Close on Demand
			OPE-FCD-40M PROB SEAL LOCA	Operator Fails to Initiate Fast Cooldown for SLOCA Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
155	2.186E-10	0.08	IE GT	Initiator - General Transient (Includes Turbine Trip and Reactor Trip)
			LOOPCON+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram
			XKA10____DFR_D-ALL XKA50____DFR_B-ALL	CCF of EDGs to Run CCF of SBO DGs to Run
156	2.085E-10	0.07	IE LOOP	Initiator - Loss Of Offsite Power
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			QKA10AP107EFS_D-ALL	CCF of SCWS Pumps to Start
			REC OSP 2HR	Failure to Recover Offsite Power Within 2 Hours
157	2.029E-10	0.07	IE GT	Initiator - General Transient (Includes Turbine Trip and Reactor Trip)
			LOOPCON+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			QKA10AP107EFS	SCWS, Train 1 Motor Driven Safety Chiller Pump QKA10AP107, Fails to Start on Demand
			SAC04/QKA40 PM4	Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance
158	2.029E-10	0.07	IE GT	Initiator - General Transient (Includes Turbine Trip and Reactor Trip)
			LOOPCON+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			QKA40AP107EFS	SCWS, Train 4 Motor Driven Safety Chiller Pump QKA40AP107, Fails to Start on Demand
			SAC01/QKA10 PM1	Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
159	1.997E-10	0.07	IE LOOP	Initiator - Loss Of Offsite Power
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			REC OSP 2HR	Failure to Recover Offsite Power Within 2 Hours
			SAC31AN001EFR_D-14	CCF to Run Normal Air Exhaust Fans

MCS Results

EPRDC050

INTERNAL

No.	Prob.	%	Event	Description
160	1.997E-10	0.07	IE LOOP OPF-SAC-2H REC OSP 2HR SAC01AN001EFR_D-14	Initiator - Loss Of Offsite Power Operator Fails to Recover Room Cooling Locally Failure to Recover Offsite Power Within 2 Hours CCF to Run Normal Air Supply Fans
161	1.837E-10	0.06	IE GT LOOPCON+REC OPF-SAC-2H SAC04/QKA40 PM4 SAC31AN001EFR	Initiator - General Transient (Includes Turbine Trip and Reactor Trip) Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram Operator Fails to Recover Room Cooling Locally Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance SAC, Normal Air Exhaust Fan SAC31AN001, Fails to Run
162	1.837E-10	0.06	IE GT LOOPCON+REC OPF-SAC-2H SAC01/QKA10 PM1 SAC34AN001EFR	Initiator - General Transient (Includes Turbine Trip and Reactor Trip) Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram Operator Fails to Recover Room Cooling Locally Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance SAC, Normal Air Exhaust Fan SAC34AN001, Fails to Run
163	1.837E-10	0.06	IE GT LOOPCON+REC OPF-SAC-2H SAC01/QKA10 PM1 SAC04AN001EFR	Initiator - General Transient (Includes Turbine Trip and Reactor Trip) Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram Operator Fails to Recover Room Cooling Locally Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance SAC, Normal Air Supply Fan SAC04AN001, Fails to Run
164	1.837E-10	0.06	IE GT LOOPCON+REC OPF-SAC-2H SAC01AN001EFR SAC04/QKA40 PM4	Initiator - General Transient (Includes Turbine Trip and Reactor Trip) Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram Operator Fails to Recover Room Cooling Locally SAC, Normal Air Supply Fan SAC01AN001, Fails to Run Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance
165	1.837E-10	0.06	IE LBOP LOOPCON+REC OPF-SAC-2H QKA10GH001_FS_B-ALL	Initiator - Loss of Balance of Plant - Closed Loop Cooling Water or Aux Cooling Water Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram Operator Fails to Recover Room Cooling Locally CCF of the Air Cooled SCWS Chiller Units to Start
166	1.817E-10	0.06	IE LOOP EFWS PM3 LAS41AP001EFR OPF-SAC-2H QKA10GH001_FS REC OSP 2HR	Initiator - Loss Of Offsite Power EFWS Train 3 Unavailable due to Preventive Maintenance EFWS, Train 4 Motor Driven Pump LAS41AP001, Fails to Run Operator Fails to Recover Room Cooling Locally SCWS, Train 1 Chiller Unit QKA10GH001, Fails to Start on Demand Failure to Recover Offsite Power Within 2 Hours
167	1.817E-10	0.06	IE LOOP EFWS PM4 LAS31AP001EFR OPF-SAC-2H QKA10GH001_FS REC OSP 2HR	Initiator - Loss Of Offsite Power EFWS Train 4 Unavailable due to Preventive Maintenance EFWS, Train 3 Motor Driven Pump LAS31AP001, Fails to Run Operator Fails to Recover Room Cooling Locally SCWS, Train 1 Chiller Unit QKA10GH001, Fails to Start on Demand Failure to Recover Offsite Power Within 2 Hours

MCS Results

EPRDC050

INTERNAL

No.	Prob.	%	Event	Description
168	1.817E-10	0.06	IE LOOP	Initiator - Loss Of Offsite Power
			EDG PM2	EDG Train 2 Unavailable due to Preventive Maintenance
			LAS11AP001EFR	EFWS, Train 1 Motor Driven Pump LAS11AP001, Fails to Run
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			QKA40GH001_FS	SCWS, Train 4 Chiller Unit QKA40GH001, Fails to Start on Demand
REC OSP 2HR	Failure to Recover Offsite Power Within 2 Hours			
169	1.817E-10	0.06	IE LOOP	Initiator - Loss Of Offsite Power
			EFWS PM1	EFWS Train 1 Unavailable due to Preventive Maintenance
			LAS21AP001EFR	EFWS, Train 2 Motor Driven Pump LAS21AP001, Fails to Run
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			QKA40GH001_FS	SCWS, Train 4 Chiller Unit QKA40GH001, Fails to Start on Demand
REC OSP 2HR	Failure to Recover Offsite Power Within 2 Hours			
170	1.817E-10	0.06	IE LOOP	Initiator - Loss Of Offsite Power
			EFWS PM2	EFWS Train 2 Unavailable due to Preventive Maintenance
			LAS11AP001EFR	EFWS, Train 1 Motor Driven Pump LAS11AP001, Fails to Run
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			QKA40GH001_FS	SCWS, Train 4 Chiller Unit QKA40GH001, Fails to Start on Demand
REC OSP 2HR	Failure to Recover Offsite Power Within 2 Hours			
171	1.817E-10	0.06	IE LOOP	Initiator - Loss Of Offsite Power
			EDG PM3	EDG Train 3 Unavailable due to Preventive Maintenance
			LAS41AP001EFR	EFWS, Train 4 Motor Driven Pump LAS41AP001, Fails to Run
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			QKA10GH001_FS	SCWS, Train 1 Chiller Unit QKA10GH001, Fails to Start on Demand
REC OSP 2HR	Failure to Recover Offsite Power Within 2 Hours			
172	1.797E-10	0.06	IE LOOP	Initiator - Loss Of Offsite Power
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			OPF-XTLDSBO-NSC	Operator Fails to Connect and Load SBO DGs to Div 1 or 4 During Non-SBO Conditions
			REC OSP 2HR	Failure to Recover Offsite Power Within 2 Hours
			SAC04/QKA40 PM4	Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance
			XKA10____DFR	ELEC, Emergency Diesel Generator XKA10, Fails to Run
XKA20____DFR	ELEC, Emergency Diesel Generator XKA20, Fails to Run			
173	1.797E-10	0.06	IE LOOP	Initiator - Loss Of Offsite Power
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			OPF-XTLDSBO-NSC	Operator Fails to Connect and Load SBO DGs to Div 1 or 4 During Non-SBO Conditions
			REC OSP 2HR	Failure to Recover Offsite Power Within 2 Hours
			SAC01/QKA10 PM1	Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
			XKA30____DFR	ELEC, Emergency Diesel Generator XKA30, Fails to Run
XKA40____DFR	ELEC, Emergency Diesel Generator XKA40, Fails to Run			
174	1.768E-10	0.06	IE GT	Initiator - General Transient (Includes Turbine Trip and Reactor Trip)
			LOOPCON+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			QKA10GH001PANS	SCWS, Train 1 Chiller Unit QKA10GH001, PAC A Priority Module (Type AV42) Fails (Non-Self-Monitored)
SAC04/QKA40 PM4	Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance			

MCS Results

EPRDC050

INTERNAL

No.	Prob.	%	Event	Description
175	1.768E-10	0.06	IE GT	Initiator - General Transient (Includes Turbine Trip and Reactor Trip)
			LOOPCON+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			QKA40GH001PANS	SCWS, Train 4 Chiller Unit QKA40GH001, PAC A Priority Module (Type AV42) Fails (Non-Self-Monitored)
			SAC01/QKA10 PM1	Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
176	1.728E-10	0.06	IE LBOP	Initiator - Loss of Balance of Plant - Closed Loop Cooling Water or Aux Cooling Water
			LOOPCON+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			QKA40GH001_FS	SCWS, Train 4 Chiller Unit QKA40GH001, Fails to Start on Demand
			SAC01/QKA10 PM1	Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
177	1.728E-10	0.06	IE LBOP	Initiator - Loss of Balance of Plant - Closed Loop Cooling Water or Aux Cooling Water
			LOOPCON+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			QKA10GH001_FS	SCWS, Train 1 Chiller Unit QKA10GH001, Fails to Start on Demand
			SAC04/QKA40 PM4	Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance
178	1.724E-10	0.06	IE GT	Initiator - General Transient (Includes Turbine Trip and Reactor Trip)
			LAS41AP001EFR	EFWS, Train 4 Motor Driven Pump LAS41AP001, Fails to Run
			LOOPCON+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			SAC01/QKA10 PM1	Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
			XKA30____DFR	ELEC, Emergency Diesel Generator XKA30, Fails to Run
179	1.724E-10	0.06	IE GT	Initiator - General Transient (Includes Turbine Trip and Reactor Trip)
			LAS11AP001EFR	EFWS, Train 1 Motor Driven Pump LAS11AP001, Fails to Run
			LOOPCON+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			SAC04/QKA40 PM4	Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance
			XKA20____DFR	ELEC, Emergency Diesel Generator XKA20, Fails to Run
180	1.721E-10	0.06	IE MLOCA	Initiator - Medium Break LOCA (3 to 6-Inch Diameter)
			JNG13AA005CFO_D-123	CCF to Open LHSI/MHSI Common Injection Check Valves
181	1.705E-10	0.06	IE LOOP	Initiator - Loss Of Offsite Power
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			QKA40AP107EEL	SCWS, Train 4 Motor Driven Safety Chiller Pump QKA40AP107, External Leakage
			REC OSP 2HR	Failure to Recover Offsite Power Within 2 Hours
			SAC01/QKA10 PM1	Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
182	1.705E-10	0.06	IE LOOP	Initiator - Loss Of Offsite Power
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			QKA10AP107EEL	SCWS, Train 1 Motor Driven Safety Chiller Pump QKA10AP107, External Leakage
			REC OSP 2HR	Failure to Recover Offsite Power Within 2 Hours
			SAC04/QKA40 PM4	Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance

MCS Results

EPRDC050

INTERNAL

No.	Prob.	%	Event	Description
183	1.698E-10	0.06	IE LOOP CCWS/ESWS PM3 LBA11AA191SFO_H-ALL OPF-XTDIV-NSC XKA20_____DFR	Initiator - Loss Of Offsite Power CCWS/ESWS Train 3 Pump Unavailable due to Preventive Maintenance CCF to Open Main Steam Safety Relief Valves Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions ELEC, Emergency Diesel Generator XKA20, Fails to Run
184	1.698E-10	0.06	IE LOOP CCWS/ESWS PM2 LBA11AA191SFO_H-ALL OPF-XTDIV-NSC XKA30_____DFR	Initiator - Loss Of Offsite Power CCWS/ESWS Train 2 Pump Unavailable due to Preventive Maintenance CCF to Open Main Steam Safety Relief Valves Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions ELEC, Emergency Diesel Generator XKA30, Fails to Run
185	1.667E-10	0.06	IE LOCCW-CH1L LAS11AP001EFR LOOPCSD+REC OPF-SAC-2H SAC04/QKA40 PM4	Initiator - Loss of CCWS/ESWS - Leak in Common Header 1 EFWS, Train 1 Motor Driven Pump LAS11AP001, Fails to Run Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to a Controlled Shutdown Operator Fails to Recover Room Cooling Locally Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance
186	1.598E-10	0.06	IE LOMFW CF LOMFW/SSS OPF-SAC-2H QKA10AP107EFR_D-ALL	Initiator - Total Loss of Main Feedwater Common Factor LOMFW/SSS Operator Fails to Recover Room Cooling Locally CCF of SCWS Pumps to Run
187	1.520E-10	0.05	IE SGTR 34BRA_____RFR OPD-RHR4H/SGTR1H OPF-SGTR-1H	Initiator - Steam Generator Tube Rupture ELEC, 480V AC to 24V DC Rectifier for MCC 34BRA Control Power, Fails to Run Dependency (MED) Between Operator Actions for Stabilizing SGTR and Initiating RHR Operator Fails to Isolate SGTR and Initiate Cooldown
188	1.518E-10	0.05	IE LOOP OPF-SAC-2H QKA10AP107EFS_D-134 REC OSP 2HR	Initiator - Loss Of Offsite Power Operator Fails to Recover Room Cooling Locally CCF of SCWS Pumps to Start Failure to Recover Offsite Power Within 2 Hours
189	1.518E-10	0.05	IE LOOP OPF-SAC-2H QKA10AP107EFS_D-124 REC OSP 2HR	Initiator - Loss Of Offsite Power Operator Fails to Recover Room Cooling Locally CCF of SCWS Pumps to Start Failure to Recover Offsite Power Within 2 Hours
190	1.507E-10	0.05	IE LOOP BTD01_BAT__ST_D-134 EDG PM2 REC OSP 2HR	Initiator - Loss Of Offsite Power CCF of Safety Related Batteries on Demand EDG Train 2 Unavailable due to Preventive Maintenance Failure to Recover Offsite Power Within 2 Hours
191	1.507E-10	0.05	IE LOOP BTD01_BAT__ST_D-134 LHSI PM2 REC OSP 2HR	Initiator - Loss Of Offsite Power CCF of Safety Related Batteries on Demand LHSI Train 2 Unavailable due to Preventive Maintenance Failure to Recover Offsite Power Within 2 Hours

MCS Results

EPRDC050

INTERNAL

No.	Prob.	%	Event	Description
192	1.507E-10	0.05	IE LOOP BTD01_BAT__ST_D-134 MHSI PM2 REC OSP 2HR	Initiator - Loss Of Offsite Power CCF of Safety Related Batteries on Demand MHSI Train 2 Unavailable due to Preventive Maintenance Failure to Recover Offsite Power Within 2 Hours
193	1.507E-10	0.05	IE LOOP BTD01_BAT__ST_D-124 MHSI PM3 REC OSP 2HR	Initiator - Loss Of Offsite Power CCF of Safety Related Batteries on Demand MHSI Train 3 Unavailable due to Preventive Maintenance Failure to Recover Offsite Power Within 2 Hours
194	1.507E-10	0.05	IE LOOP BTD01_BAT__ST_D-124 LHSI PM3 REC OSP 2HR	Initiator - Loss Of Offsite Power CCF of Safety Related Batteries on Demand LHSI Train 3 Unavailable due to Preventive Maintenance Failure to Recover Offsite Power Within 2 Hours
195	1.507E-10	0.05	IE LOOP BTD01_BAT__ST_D-124 EDG PM3 REC OSP 2HR	Initiator - Loss Of Offsite Power CCF of Safety Related Batteries on Demand EDG Train 3 Unavailable due to Preventive Maintenance Failure to Recover Offsite Power Within 2 Hours
196	1.506E-10	0.05	IE LOOP REC OSP 2HR XKA10____DFR_D-ALL XKA50____DFS XKA80____DFR	Initiator - Loss Of Offsite Power Failure to Recover Offsite Power Within 2 Hours CCF of EDGs to Run ELEC, SBO Diesel Generator XKA50, Fails to Start on Demand ELEC, SBO Diesel Generator XKA80, Fails to Run
197	1.506E-10	0.05	IE LOOP REC OSP 2HR XKA10____DFR_D-ALL XKA50____DFR XKA80____DFS	Initiator - Loss Of Offsite Power Failure to Recover Offsite Power Within 2 Hours CCF of EDGs to Run ELEC, SBO Diesel Generator XKA50, Fails to Run ELEC, SBO Diesel Generator XKA80, Fails to Start on Demand
198	1.475E-10	0.05	IE LOOP LAS11AP001EFR_D-12 OPF-SAC-2H REC OSP 2HR SAC04/QKA40 PM4	Initiator - Loss Of Offsite Power CCF of EFWS Pumps to Run Operator Fails to Recover Room Cooling Locally Failure to Recover Offsite Power Within 2 Hours Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance
199	1.475E-10	0.05	IE LOOP LAS11AP001EFR_D-34 OPF-SAC-2H REC OSP 2HR SAC01/QKA10 PM1	Initiator - Loss Of Offsite Power CCF of EFWS Pumps to Run Operator Fails to Recover Room Cooling Locally Failure to Recover Offsite Power Within 2 Hours Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
200	1.472E-10	0.05	IE SLOCA PED10AN001EFR_D-ALL SAHR PM4	Initiator - Small LOCA (0.6 to 3-Inch Diameter) CCF to Run Normally Running Cooling Tower Fans SAHR Train Unavailable due to Preventive Maintenance

Minimal Cutsets

Top Event probability Q = 1.763E-07

No.	Prob.	%	Event	Description
1	2.626E-08	14.90	IE FIRE-MS-VR	Initiator - Fire in One of Two MF/MS Valve Rooms With Spurious Opening of 1 MSRIV
			MSIV TR3 ISO-FIRE	MSIV 3 Fails to Isolate Due to Fire in MS/FW Valve Room
			MSIV TR4 ISO-FIRE	MSIV 4 Fails to Isolate Due to Fire in MS/FW Valve Room
			OPE-RHR-4H	Operator Fails to Initiate RHR Within 4 Hours
2	2.520E-08	14.30	IE FIRE-MCR	Initiator - Fire in the Main Control Room
			OPE-MCR-RSS-90M	Operator Fails to Transfer to the RSS in 90 Mins Given A MCR Fire
3	7.800E-09	4.43	IE FIRE-SAB-MECH	Initiator - Fire in the Pump Room of Any Safeguard Building
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			PAS	Process Automation System (PAS) Fails (Estimate)
			SAC01/QKA10 PM1	Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
4	6.133E-09	3.48	IE FIRE-SAB14-AC	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4)
			31BRA_____RFR	ELEC, 480V AC to 24V DC Rectifier for MCC 31BRA Control Power, Fails to Run
			CVCS VCT	CVCS Switchover to IRWST May Not Be Required
PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling			
5	6.133E-09	3.48	IE FIRE-SAB14-AC	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4)
			32BRA_____RFR	ELEC, 480V AC to 24V DC Rectifier for MCC 32BRA Control Power, Fails to Run
			CVCS VCT	CVCS Switchover to IRWST May Not Be Required
PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling			
6	4.320E-09	2.45	IE FIRE-SAB14-AC	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4)
			CCWS/ESWS PM2	CCWS/ESWS Train 2 Pump Unavailable due to Preventive Maintenance
			LOOPFCSD+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for Fire IEs Leading to a Controlled Shutdn
			OPF-XTDIV-NSC	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions
PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling			
7	2.880E-09	1.63	IE FIRE-SAB14-AC	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4)
			EDG PM2	EDG Train 2 Unavailable due to Preventive Maintenance
			LOOPFCSD+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for Fire IEs Leading to a Controlled Shutdn
			OPF-XTDIV-NSC	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions
PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling			
8	2.808E-09	1.59	IE FIRE-SAB-MECH	Initiator - Fire in the Pump Room of Any Safeguard Building
			LOOPFCSD+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for Fire IEs Leading to a Controlled Shutdn
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
SAC01/QKA10 PM1	Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance			

MCS Results

EPRDC050

FIRE

No.	Prob.	%	Event	Description
9	1.983E-09	1.12	IE FIRE-SAB14-AC LOOPFCSD+REC OPF-XTDIV-NSC PROB SEAL LOCA XKA20____DFR	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) Consequential LOOP and Failure of Recovery Within 1 Hour for Fire IEs Leading to a Controlled Shutdn Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions Probability of Seal LOCA Occurring Given a Loss of Seal Cooling ELEC, Emergency Diesel Generator XKA20, Fails to Run
10	1.485E-09	0.84	IE FIRE-SAB14-AC CVCS VCT LBA13AA001PFO_D-ALL PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) CVCS Switchover to IRWST May Not Be Required CCF to Open Main Steam Relief Isolation Valves Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
11	9.600E-10	0.54	IE FIRE-SAB14-AC 31BDB____OFL CVCS VCT OPF-XTIE BC PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) ELEC, 6.9kV SWGR 31BDB, Fails During Operation CVCS Switchover to IRWST May Not Be Required Operator Fails to Align Backup Battery Charger to BUC Bus Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
12	9.600E-10	0.54	IE FIRE-SAB14-AC 31BMB____OFL CVCS VCT OPF-XTIE BC PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) ELEC, 480V Load Center 31BMB, Fails During Operation CVCS Switchover to IRWST May Not Be Required Operator Fails to Align Backup Battery Charger to BUC Bus Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
13	9.600E-10	0.54	IE FIRE-SAB14-AC 32BMB____OFL CVCS VCT OPF-XTIE BC PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) ELEC, 480V Load Center 32BMB, Fails During Operation CVCS Switchover to IRWST May Not Be Required Operator Fails to Align Backup Battery Charger to BUC Bus Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
14	9.600E-10	0.54	IE FIRE-SAB14-AC 31BDC____OFL CVCS VCT PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) ELEC, 6.9kV SWGR 31BDC, Fails During Operation CVCS Switchover to IRWST May Not Be Required Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
15	9.600E-10	0.54	IE FIRE-SAB14-AC 31BMT02__TFL CVCS VCT OPF-XTIE BC PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) ELEC, 6.9kV-480V Transformer 31BMT02, Fails During Operation CVCS Switchover to IRWST May Not Be Required Operator Fails to Align Backup Battery Charger to BUC Bus Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
16	9.600E-10	0.54	IE FIRE-SAB14-AC 32BRA____OFL CVCS VCT PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) ELEC, 480V MCC 32BRA, Fails During Operation CVCS Switchover to IRWST May Not Be Required Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
17	9.600E-10	0.54	IE FIRE-SAB14-AC 31BRA____OFL CVCS VCT PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) ELEC, 480V MCC 31BRA, Fails During Operation CVCS Switchover to IRWST May Not Be Required Probability of Seal LOCA Occurring Given a Loss of Seal Cooling

MCS Results

EPRDC050

FIRE

No.	Prob.	%	Event	Description
18	9.600E-10	0.54	IE FIRE-SAB14-AC 32BMT02___TFL CVCS VCT OPF-XTIE BC PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) ELEC, 6.9kV-480V Transformer 32BMT02, Fails During Operation CVCS Switchover to IRWST May Not Be Required Operator Fails to Align Backup Battery Charger to BUC Bus Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
19	9.600E-10	0.54	IE FIRE-SAB14-AC 31BDA___OFL OPF-XTLDSBO-NSC PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) ELEC, 6.9kV Switchgear 31BDA, Fails During Operation Operator Fails to Connect and Load SBO DGs to Div 1 or 4 During Non-SBO Conditions Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
20	9.600E-10	0.54	IE FIRE-SAB14-AC 32BDB___OFL CVCS VCT OPF-XTIE BC PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) ELEC, 6.9kV SWGR 32BDB, Fails During Operation CVCS Switchover to IRWST May Not Be Required Operator Fails to Align Backup Battery Charger to BUC Bus Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
21	9.600E-10	0.54	IE FIRE-SAB14-AC BRW32BUW33OFL CVCS VCT PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) ELEC, 24V DC I&C Power Rack 32BRW32/32BUW33, Fails During Operation CVCS Switchover to IRWST May Not Be Required Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
22	9.600E-10	0.54	IE FIRE-SAB14-AC BRW10BUW11OFL CVCS VCT PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) ELEC, 24V DC I&C Power Rack 31BRW10/31BUW11, Fails During Operation CVCS Switchover to IRWST May Not Be Required Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
23	8.963E-10	0.51	IE FIRE-SWGR OPF-SAC-2H QKA10GH001_FR_B-ALL	Initiator - Fire in the Switchgear Building Operator Fails to Recover Room Cooling Locally CCF of the Air Cooled SCWS Chiller Units to Run
24	8.854E-10	0.50	IE FIRE-SAB14-AC CVCS VCT KAA12AA005EFO_D-ALL PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) CVCS Switchover to IRWST May Not Be Required CCF to Open CCWS to LHSI HTX Cooling MOV Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
25	8.433E-10	0.48	IE FIRE-SWGR OPF-SAC-2H QKA10GH001_FR SAC04/QKA40 PM4	Initiator - Fire in the Switchgear Building Operator Fails to Recover Room Cooling Locally SCWS, Train 1 Chiller Unit QKA10GH001, Fails to Run Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance
26	8.433E-10	0.48	IE FIRE-SWGR OPF-SAC-2H QKA10GH001_FR SAC03/QKA30 PM3	Initiator - Fire in the Switchgear Building Operator Fails to Recover Room Cooling Locally SCWS, Train 1 Chiller Unit QKA10GH001, Fails to Run Normal SAC03/QKA30 Train Unavailable due to Preventive Maintenance
27	8.433E-10	0.48	IE FIRE-SWGR OPF-SAC-2H QKA20GH001_FR SAC04/QKA40 PM4	Initiator - Fire in the Switchgear Building Operator Fails to Recover Room Cooling Locally SCWS, Train 2 Chiller Unit QKA20GH001, Fails to Run Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance

MCS Results

EPRDC050

FIRE

No.	Prob.	%	Event	Description
28	8.433E-10	0.48	IE FIRE-SWGR OPF-SAC-2H QKA40GH001_FR SAC02/QKA20 PM2	Initiator - Fire in the Switchgear Building Operator Fails to Recover Room Cooling Locally SCWS, Train 4 Chiller Unit QKA40GH001, Fails to Run Normal SAC02/QKA20 Train Unavailable due to Preventive Maintenance
29	8.433E-10	0.48	IE FIRE-SWGR OPF-SAC-2H QKA30GH001_FR SAC01/QKA10 PM1	Initiator - Fire in the Switchgear Building Operator Fails to Recover Room Cooling Locally SCWS, Train 3 Chiller Unit QKA30GH001, Fails to Run Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
30	8.433E-10	0.48	IE FIRE-SWGR OPF-SAC-2H QKA40GH001_FR SAC01/QKA10 PM1	Initiator - Fire in the Switchgear Building Operator Fails to Recover Room Cooling Locally SCWS, Train 4 Chiller Unit QKA40GH001, Fails to Run Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
31	7.412E-10	0.42	IE FIRE-SAB14-AC CVCS VCT PED10AN002EFS_D-ALL PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) CVCS Switchover to IRWST May Not Be Required CCF to Start Standby Cooling Tower Fans Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
32	7.052E-10	0.40	IE FIRE-PZR LBA13AA001PFO_D-ALL	Initiator - Fire in the Pressurizer Compartment With Spurious Opening of 1 PSRV CCF to Open Main Steam Relief Isolation Valves
33	6.948E-10	0.39	IE FIRE-SAB14-AC CVCS VCT LBA13AA001PFO_D-124 PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) CVCS Switchover to IRWST May Not Be Required CCF to Open Main Steam Relief Isolation Valves Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
34	6.297E-10	0.36	IE FIRE-MS-VR LBA10AA002PFC MSIV TR3 ISO-FIRE MSIV TR4 ISO-FIRE OPF-EBS-30M	Initiator - Fire in One of Two MF/MS Valve Rooms With Spurious Opening of 1 MSRV MSS, Train 1 Main Steam Isolation Valve LBA10AA002, Fails to Close on Demand MSIV 3 Fails to Isolate Due to Fire in MS/FW Valve Room MSIV 4 Fails to Isolate Due to Fire in MS/FW Valve Room Operator Fails to Manually Actuate EBS (SLB & ATWS)
35	6.297E-10	0.36	IE FIRE-MS-VR LBA20AA002PFC MSIV TR3 ISO-FIRE MSIV TR4 ISO-FIRE OPF-EBS-30M	Initiator - Fire in One of Two MF/MS Valve Rooms With Spurious Opening of 1 MSRV MSS, Train 2 Main Steam Isolation Valve LBA20AA002, Fails to Close on Demand MSIV 3 Fails to Isolate Due to Fire in MS/FW Valve Room MSIV 4 Fails to Isolate Due to Fire in MS/FW Valve Room Operator Fails to Manually Actuate EBS (SLB & ATWS)
36	5.760E-10	0.33	IE FIRE-SAB14-AC CCWS/ESWS PM2 LOOP24+REC OPF-XTDIV-NSC PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) CCWS/ESWS Train 2 Pump Unavailable due to Preventive Maintenance Loss Of Offsite Power During Mission Time and Failure of Recovery Within 1 Hour Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions Probability of Seal LOCA Occurring Given a Loss of Seal Cooling

MCS Results

EPRDC050

FIRE

No.	Prob.	%	Event	Description
37	5.760E-10	0.33	IE FIRE-SAB14-AC EDG PM1 LOOPFCSD+REC OPF-XTLDSBO-NSC PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) EDG Train 1 Unavailable due to Preventive Maintenance Consequential LOOP and Failure of Recovery Within 1 Hour for Fire IEs Leading to a Controlled Shutdn Operator Fails to Connect and Load SBO DGs to Div 1 or 4 During Non-SBO Conditions Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
38	5.755E-10	0.33	IE FIRE-MS-VR KAA12AA005EFO_D-ALL MSIV TR3 ISO-FIRE MSIV TR4 ISO-FIRE	Initiator - Fire in One of Two MF/MS Valve Rooms With Spurious Opening of 1 MSRIV CCF to Open CCWS to LHSI HTX Cooling MOV MSIV 3 Fails to Isolate Due to Fire in MS/FW Valve Room MSIV 4 Fails to Isolate Due to Fire in MS/FW Valve Room
39	5.736E-10	0.33	IE FIRE-SWGR LOOPCON+REC XKA10____DFR_D-ALL	Initiator - Fire in the Switchgear Building Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram CCF of EDGs to Run
40	5.059E-10	0.29	IE FIRE-SAB14-AC CVCS VCT MSRIVSCPFO_P-ALL PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) CVCS Switchover to IRWST May Not Be Required CCF to Open Main Steam Relief Isolation Pneumatic Pilot Valves Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
41	4.818E-10	0.27	IE FIRE-MS-VR MSIV TR3 ISO-FIRE MSIV TR4 ISO-FIRE PED10AN002EFS_D-ALL	Initiator - Fire in One of Two MF/MS Valve Rooms With Spurious Opening of 1 MSRIV MSIV 3 Fails to Isolate Due to Fire in MS/FW Valve Room MSIV 4 Fails to Isolate Due to Fire in MS/FW Valve Room CCF to Start Standby Cooling Tower Fans
42	4.800E-10	0.27	IE FIRE-SAB14-AC 32BDA____OFL CVCS VCT OPF-XTDIV-NSC PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) ELEC, 6.9kV SWGR 32BDA, Fails During Operation CVCS Switchover to IRWST May Not Be Required Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Divison 3 During Non-SBO Conditions Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
43	4.780E-10	0.27	IE FIRE-SAB14-AC CVCS VCT JNG13AA005CFO_D-123 PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) CVCS Switchover to IRWST May Not Be Required CCF to Open LHSI/MHSI Common Injection Check Valves Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
44	4.697E-10	0.27	IE FIRE-SAB14-AC CLF24EQ001LB03NS CLF24EQ002LB01NS CVCS VCT PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) Digital output module fails (non-self-monitored) Digital output module fails (non-self-monitored) CVCS Switchover to IRWST May Not Be Required Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
45	4.697E-10	0.27	IE FIRE-SAB14-AC CLE24EQ001LB01NS CLE24EQ002LB03NS CVCS VCT PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) Digital output module fails (non-self-monitored) Digital output module fails (non-self-monitored) CVCS Switchover to IRWST May Not Be Required Probability of Seal LOCA Occurring Given a Loss of Seal Cooling

MCS Results

EPRDC050

FIRE

No.	Prob.	%	Event	Description
46	4.697E-10	0.27	IE FIRE-SAB14-AC CLF24EQ001LB01NS CLF24EQ002LB03NS CVCS VCT PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) Digital output module fails (non-self-monitored) Digital output module fails (non-self-monitored) CVCS Switchover to IRWST May Not Be Required Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
47	4.697E-10	0.27	IE FIRE-SAB14-AC CLE24EQ001LB03NS CLE24EQ002LB01NS CVCS VCT PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) Digital output module fails (non-self-monitored) Digital output module fails (non-self-monitored) CVCS Switchover to IRWST May Not Be Required Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
48	4.697E-10	0.27	IE FIRE-SAB14-AC CLE24EQ001LB03NS CLE24EQ002LB02NS CVCS VCT PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) Digital output module fails (non-self-monitored) Digital output module fails (non-self-monitored) CVCS Switchover to IRWST May Not Be Required Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
49	4.697E-10	0.27	IE FIRE-SAB14-AC CLF24EQ001LB01NS CLF24EQ002LB01NS CVCS VCT PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) Digital output module fails (non-self-monitored) Digital output module fails (non-self-monitored) CVCS Switchover to IRWST May Not Be Required Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
50	4.697E-10	0.27	IE FIRE-SAB14-AC CLF24EQ001LB02NS CLF24EQ002LB02NS CVCS VCT PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) Digital output module fails (non-self-monitored) Digital output module fails (non-self-monitored) CVCS Switchover to IRWST May Not Be Required Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
51	4.697E-10	0.27	IE FIRE-SAB14-AC CLE24EQ001LB02NS CLE24EQ002LB01NS CVCS VCT PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) Digital output module fails (non-self-monitored) Digital output module fails (non-self-monitored) CVCS Switchover to IRWST May Not Be Required Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
52	4.697E-10	0.27	IE FIRE-SAB14-AC CLF24EQ001LB02NS CLF24EQ002LB03NS CVCS VCT PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) Digital output module fails (non-self-monitored) Digital output module fails (non-self-monitored) CVCS Switchover to IRWST May Not Be Required Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
53	4.697E-10	0.27	IE FIRE-SAB14-AC CLE24EQ001LB01NS CLE24EQ002LB02NS CVCS VCT PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) Digital output module fails (non-self-monitored) Digital output module fails (non-self-monitored) CVCS Switchover to IRWST May Not Be Required Probability of Seal LOCA Occurring Given a Loss of Seal Cooling

MCS Results

EPRDC050

FIRE

No.	Prob.	%	Event	Description
54	4.697E-10	0.27	IE FIRE-SAB14-AC CLE24EQ001LB03NS CLE24EQ002LB03NS CVCS VCT PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) Digital output module fails (non-self-monitored) Digital output module fails (non-self-monitored) CVCS Switchover to IRWST May Not Be Required Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
55	4.697E-10	0.27	IE FIRE-SAB14-AC CLE24EQ001LB02NS CLE24EQ002LB03NS CVCS VCT PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) Digital output module fails (non-self-monitored) Digital output module fails (non-self-monitored) CVCS Switchover to IRWST May Not Be Required Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
56	4.697E-10	0.27	IE FIRE-SAB14-AC CLE24EQ001LB01NS CLE24EQ002LB01NS CVCS VCT PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) Digital output module fails (non-self-monitored) Digital output module fails (non-self-monitored) CVCS Switchover to IRWST May Not Be Required Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
57	4.697E-10	0.27	IE FIRE-SAB14-AC CLF24EQ001LB03NS CLF24EQ002LB02NS CVCS VCT PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) Digital output module fails (non-self-monitored) Digital output module fails (non-self-monitored) CVCS Switchover to IRWST May Not Be Required Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
58	4.697E-10	0.27	IE FIRE-SAB14-AC CLF24EQ001LB03NS CLF24EQ002LB03NS CVCS VCT PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) Digital output module fails (non-self-monitored) Digital output module fails (non-self-monitored) CVCS Switchover to IRWST May Not Be Required Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
59	4.697E-10	0.27	IE FIRE-SAB14-AC CLE24EQ001LB02NS CLE24EQ002LB02NS CVCS VCT PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) Digital output module fails (non-self-monitored) Digital output module fails (non-self-monitored) CVCS Switchover to IRWST May Not Be Required Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
60	4.697E-10	0.27	IE FIRE-SAB14-AC CLF24EQ001LB01NS CLF24EQ002LB02NS CVCS VCT PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) Digital output module fails (non-self-monitored) Digital output module fails (non-self-monitored) CVCS Switchover to IRWST May Not Be Required Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
61	4.697E-10	0.27	IE FIRE-SAB14-AC CLF24EQ001LB02NS CLF24EQ002LB01NS CVCS VCT PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) Digital output module fails (non-self-monitored) Digital output module fails (non-self-monitored) CVCS Switchover to IRWST May Not Be Required Probability of Seal LOCA Occurring Given a Loss of Seal Cooling

MCS Results

EPRDC050

FIRE

No.	Prob.	%	Event	Description
62	4.609E-10	0.26	IE FIRE-SAB14-AC CVCS VCT PED10AN002EFS_D-123 PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) CVCS Switchover to IRWST May Not Be Required CCF to Start Standby Cooling Tower Fans Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
63	4.535E-10	0.26	IE FIRE-SAB-MECH LOOPFCSD+REC OPF-SAC-2H QKA10GH001_FS	Initiator - Fire in the Pump Room of Any Safeguard Building Consequential LOOP and Failure of Recovery Within 1 Hour for Fire IEs Leading to a Controlled Shutdown Operator Fails to Recover Room Cooling Locally SCWS, Train 1 Chiller Unit QKA10GH001, Fails to Start on Demand
64	4.214E-10	0.24	IE FIRE-SWGR OPF-SAC-2H SAC01/QKA10 PM1 SAC33AN001EFR	Initiator - Fire in the Switchgear Building Operator Fails to Recover Room Cooling Locally Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance SAC, Normal Air Exhaust Fan SAC33AN001, Fails to Run
65	4.214E-10	0.24	IE FIRE-SWGR OPF-SAC-2H SAC04/QKA40 PM4 SAC32AN001EFR	Initiator - Fire in the Switchgear Building Operator Fails to Recover Room Cooling Locally Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance SAC, Normal Air Exhaust Fan SAC32AN001, Fails to Run
66	4.214E-10	0.24	IE FIRE-SWGR OPF-SAC-2H SAC01/QKA10 PM1 SAC04AN001EFR	Initiator - Fire in the Switchgear Building Operator Fails to Recover Room Cooling Locally Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance SAC, Normal Air Supply Fan SAC04AN001, Fails to Run
67	4.214E-10	0.24	IE FIRE-SWGR OPF-SAC-2H SAC01/QKA10 PM1 SAC34AN001EFR	Initiator - Fire in the Switchgear Building Operator Fails to Recover Room Cooling Locally Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance SAC, Normal Air Exhaust Fan SAC34AN001, Fails to Run
68	4.214E-10	0.24	IE FIRE-SWGR OPF-SAC-2H SAC01/QKA10 PM1 SAC03AN001EFR	Initiator - Fire in the Switchgear Building Operator Fails to Recover Room Cooling Locally Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance SAC, Normal Air Supply Fan SAC03AN001, Fails to Run
69	4.214E-10	0.24	IE FIRE-SWGR OPF-SAC-2H SAC02/QKA20 PM2 SAC34AN001EFR	Initiator - Fire in the Switchgear Building Operator Fails to Recover Room Cooling Locally Normal SAC02/QKA20 Train Unavailable due to Preventive Maintenance SAC, Normal Air Exhaust Fan SAC34AN001, Fails to Run
70	4.214E-10	0.24	IE FIRE-SWGR OPF-SAC-2H SAC03/QKA30 PM3 SAC31AN001EFR	Initiator - Fire in the Switchgear Building Operator Fails to Recover Room Cooling Locally Normal SAC03/QKA30 Train Unavailable due to Preventive Maintenance SAC, Normal Air Exhaust Fan SAC31AN001, Fails to Run
71	4.214E-10	0.24	IE FIRE-SWGR OPF-SAC-2H SAC02/QKA20 PM2 SAC04AN001EFR	Initiator - Fire in the Switchgear Building Operator Fails to Recover Room Cooling Locally Normal SAC02/QKA20 Train Unavailable due to Preventive Maintenance SAC, Normal Air Supply Fan SAC04AN001, Fails to Run

MCS Results

EPRDC050

FIRE

No.	Prob.	%	Event	Description
72	4.214E-10	0.24	IE FIRE-SWGR OPF-SAC-2H SAC04/QKA40 PM4 SAC31AN001EFR	Initiator - Fire in the Switchgear Building Operator Fails to Recover Room Cooling Locally Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance SAC, Normal Air Exhaust Fan SAC31AN001, Fails to Run
73	4.214E-10	0.24	IE FIRE-SWGR OPF-SAC-2H SAC01AN001EFR SAC04/QKA40 PM4	Initiator - Fire in the Switchgear Building Operator Fails to Recover Room Cooling Locally SAC, Normal Air Supply Fan SAC01AN001, Fails to Run Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance
74	4.214E-10	0.24	IE FIRE-SWGR OPF-SAC-2H SAC01AN001EFR SAC03/QKA30 PM3	Initiator - Fire in the Switchgear Building Operator Fails to Recover Room Cooling Locally SAC, Normal Air Supply Fan SAC01AN001, Fails to Run Normal SAC03/QKA30 Train Unavailable due to Preventive Maintenance
75	4.214E-10	0.24	IE FIRE-SWGR OPF-SAC-2H SAC02AN001EFR SAC04/QKA40 PM4	Initiator - Fire in the Switchgear Building Operator Fails to Recover Room Cooling Locally SAC, Normal Air Supply Fan SAC02AN001, Fails to Run Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance
76	3.966E-10	0.22	IE FIRE-SAB14-AC LOOPFCSD+REC OPF-XTLDSBO-NSC PROB SEAL LOCA XKA10____DFR	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) Consequential LOOP and Failure of Recovery Within 1 Hour for Fire IEs Leading to a Controlled Shutdn Operator Fails to Connect and Load SBO DGs to Div 1 or 4 During Non-SBO Conditions Probability of Seal LOCA Occurring Given a Loss of Seal Cooling ELEC, Emergency Diesel Generator XKA10, Fails to Run
77	3.840E-10	0.22	IE FIRE-SAB14-AC EDG PM2 LOOP24+REC OPF-XTDIV-NSC PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) EDG Train 2 Unavailable due to Preventive Maintenance Loss Of Offsite Power During Mission Time and Failure of Recovery Within 1 Hour Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
78	3.744E-10	0.21	IE FIRE-SAB-MECH LOOP24+REC OPF-SAC-2H SAC01/QKA10 PM1	Initiator - Fire in the Pump Room of Any Safeguard Building Loss Of Offsite Power During Mission Time and Failure of Recovery Within 1 Hour Operator Fails to Recover Room Cooling Locally Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
79	3.607E-10	0.20	IE FIRE-SAB14-AC CVCS VCT KAA12AA005EFO_D-123 PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) CVCS Switchover to IRWST May Not Be Required CCF to Open CCWS to LHSI HTX Cooling MOV Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
80	3.518E-10	0.20	IE FIRE-SAB14-AC LOOPFCSD+REC OPF-XTDIV-NSC PEB20AP001EFS PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) Consequential LOOP and Failure of Recovery Within 1 Hour for Fire IEs Leading to a Controlled Shutdn Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions ESWS, Train 2 Motor Driven Pump PEB20AP001, Fails to Start on Demand Probability of Seal LOCA Occurring Given a Loss of Seal Cooling

MCS Results

EPRDC050

FIRE

No.	Prob.	%	Event	Description
81	3.182E-10	0.18	IE FIRE-SAB14-AC	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4)
			LOOPFCSD+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for Fire IEs Leading to a Controlled Shutdn
			OPF-XTDIV-NSC	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions
82	3.133E-10	0.18	PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
			XKA20____DFS	ELEC, Emergency Diesel Generator XKA20, Fails to Start on Demand
			IE FIRE-SAB14-AC	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4)
83	2.948E-10	0.17	EDG PM1	EDG Train 1 Unavailable due to Preventive Maintenance
			LOOPFCSD+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for Fire IEs Leading to a Controlled Shutdn
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
84	2.920E-10	0.17	XKA50____DFR	ELEC, SBO Diesel Generator XKA50, Fails to Run
			IE FIRE-CSR	Initiator - Fire in the Cable Spreading Room (Room Under Main Control Room)
			LOOPCON+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram
85	2.920E-10	0.17	OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			SAC01/QKA10 PM1	Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
			IE FIRE-MS-VR	Initiator - Fire in One of Two MF/MS Valve Rooms With Spurious Opening of 1 MSRIV
86	2.920E-10	0.17	JNA10AA003EFO_D-ALL	CCF to Open LHSI Pump Suction from RCS MOVs
			MSIV TR3 ISO-FIRE	MSIV 3 Fails to Isolate Due to Fire in MS/FW Valve Room
			MSIV TR4 ISO-FIRE	MSIV 4 Fails to Isolate Due to Fire in MS/FW Valve Room
87	2.891E-10	0.16	JNA10AA002EFO_D-ALL	CCF to Open LHSI Pump Suction from RCS Angled MOVs
			MSIV TR3 ISO-FIRE	MSIV 3 Fails to Isolate Due to Fire in MS/FW Valve Room
			MSIV TR4 ISO-FIRE	MSIV 4 Fails to Isolate Due to Fire in MS/FW Valve Room
88	2.891E-10	0.16	JNA10AA001EFO_D-ALL	CCF to Open LHSI Pump Suction from RCS MOVs
			MSIV TR3 ISO-FIRE	MSIV 3 Fails to Isolate Due to Fire in MS/FW Valve Room
			MSIV TR4 ISO-FIRE	MSIV 4 Fails to Isolate Due to Fire in MS/FW Valve Room
89	2.891E-10	0.16	LBA30AA002PFC	MSS, Train 3 Main Steam Isolation Valve LBA30AA002, Fails to Close on Demand
			MSIV TR4 ISO-FIRE	MSIV 4 Fails to Isolate Due to Fire in MS/FW Valve Room
			OPE-RHR-4H	Operator Fails to Initiate RHR Within 4 Hours
90	2.891E-10	0.16	LBA20AA002PFC	MSS, Train 2 Main Steam Isolation Valve LBA20AA002, Fails to Close on Demand
			MSIV TR4 ISO-FIRE	MSIV 4 Fails to Isolate Due to Fire in MS/FW Valve Room
			OPE-RHR-4H	Operator Fails to Initiate RHR Within 4 Hours

MCS Results

EPRDC050

FIRE

No.	Prob.	%	Q Event	Description
89	2.891E-10	0.16	IE FIRE-MS-VR	Initiator - Fire in One of Two MF/MS Valve Rooms With Spurious Opening of 1 MSRV
			LBA10AA002PFC	MSS, Train 1 Main Steam Isolation Valve LBA10AA002, Fails to Close on Demand
			MSIV TR4 ISO-FIRE OPE-RHR-4H	MSIV 4 Fails to Isolate Due to Fire in MS/FW Valve Room Operator Fails to Initiate RHR Within 4 Hours
90	2.880E-10	0.16	IE FIRE-SAB14-AC 1BDC_1BDB1BOP	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) ELEC, 6.9kV SWGR 31BDC to 6.9kV SWGR 31BDB Circuit Breaker, Fails to Remain Closed (SO)
			CVCS VCT	CVCS Switchover to IRWST May Not Be Required
			OPF-XTIE BC PROB SEAL LOCA	Operator Fails to Align Backup Battery Charger to BUC Bus Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
91	2.880E-10	0.16	IE FIRE-SAB14-AC 1BRU011BRABOP	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) ELEC, Inverter 31BRU01 to 480V MCC 31BRA Circuit Breaker, Fails to Remain Closed (SO)
			CVCS VCT	CVCS Switchover to IRWST May Not Be Required
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
92	2.880E-10	0.16	IE FIRE-SAB14-AC 1BMT021BMBBOP	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) ELEC, Transformer 31BMT02 to 480V Load Center 31BMB Circuit Breaker, Fails to Remain Closed (SO)
			CVCS VCT	CVCS Switchover to IRWST May Not Be Required
			OPF-XTIE BC PROB SEAL LOCA	Operator Fails to Align Backup Battery Charger to BUC Bus Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
93	2.880E-10	0.16	IE FIRE-SAB14-AC 1BDB1BMT02BOP	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) ELEC, 6.9kV SWGR 31BDB to Transformer 31BMT02 Circuit Breaker, Fails to Remain Closed (SO)
			CVCS VCT	CVCS Switchover to IRWST May Not Be Required
			OPF-XTIE BC PROB SEAL LOCA	Operator Fails to Align Backup Battery Charger to BUC Bus Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
94	2.880E-10	0.16	IE FIRE-SAB14-AC 1BDC_1BDB2BOP	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) ELEC, 6.9kV SWGR 31BDC to 6.9kV SWGR 31BDB Circuit Breaker, Fails to Remain Closed (SO)
			CVCS VCT	CVCS Switchover to IRWST May Not Be Required
			OPF-XTIE BC PROB SEAL LOCA	Operator Fails to Align Backup Battery Charger to BUC Bus Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
95	2.880E-10	0.16	IE FIRE-SAB14-AC 2BRU012BRABOP	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) ELEC, Inverter 32BRU01 to 480V MCC 32BRA Circuit Breaker, Fails to Remain Closed (SO)
			CVCS VCT	CVCS Switchover to IRWST May Not Be Required
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
96	2.880E-10	0.16	IE FIRE-SAB14-AC 2BDB2BMT02BOP	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) ELEC, 6.9kV SWGR 32BDB to Transformer 32BMT02 Circuit Breaker, Fails to Remain Closed (SO)
			CVCS VCT	CVCS Switchover to IRWST May Not Be Required
			OPF-XTIE BC PROB SEAL LOCA	Operator Fails to Align Backup Battery Charger to BUC Bus Probability of Seal LOCA Occurring Given a Loss of Seal Cooling

MCS Results

EPRDC050

FIRE

No.	Prob.	%	Event	Description
97	2.880E-10	0.16	IE FIRE-SAB14-AC 2BMT02BMBBOP CVCS VCT OPF-XTIE BC PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) ELEC, Transformer 32BMT02 to 480V Load Center 32BMB Circuit Breaker, Fails to Remain Closed (SO) CVCS Switchover to IRWST May Not Be Required Operator Fails to Align Backup Battery Charger to BUC Bus Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
98	2.870E-10	0.16	IE FIRE-SWGR OPF-SAC-2H QKA30AP107EFR SAC01/QKA10 PM1	Initiator - Fire in the Switchgear Building Operator Fails to Recover Room Cooling Locally SCWS, Train 3 Motor Driven Safety Chiller Pump QKA30AP107, Fails to Run Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
99	2.870E-10	0.16	IE FIRE-SWGR OPF-SAC-2H QKA40AP107EFR SAC02/QKA20 PM2	Initiator - Fire in the Switchgear Building Operator Fails to Recover Room Cooling Locally SCWS, Train 4 Motor Driven Safety Chiller Pump QKA40AP107, Fails to Run Normal SAC02/QKA20 Train Unavailable due to Preventive Maintenance
100	2.870E-10	0.16	IE FIRE-SWGR OPF-SAC-2H QKA20AP107EFR SAC04/QKA40 PM4	Initiator - Fire in the Switchgear Building Operator Fails to Recover Room Cooling Locally SCWS, Train 2 Motor Driven Safety Chiller Pump QKA20AP107, Fails to Run Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance
101	2.870E-10	0.16	IE FIRE-SWGR OPF-SAC-2H QKA10AP107EFR SAC03/QKA30 PM3	Initiator - Fire in the Switchgear Building Operator Fails to Recover Room Cooling Locally SCWS, Train 1 Motor Driven Safety Chiller Pump QKA10AP107, Fails to Run Normal SAC03/QKA30 Train Unavailable due to Preventive Maintenance
102	2.870E-10	0.16	IE FIRE-SWGR OPF-SAC-2H QKA40AP107EFR SAC01/QKA10 PM1	Initiator - Fire in the Switchgear Building Operator Fails to Recover Room Cooling Locally SCWS, Train 4 Motor Driven Safety Chiller Pump QKA40AP107, Fails to Run Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
103	2.870E-10	0.16	IE FIRE-SWGR OPF-SAC-2H QKA10AP107EFR SAC04/QKA40 PM4	Initiator - Fire in the Switchgear Building Operator Fails to Recover Room Cooling Locally SCWS, Train 1 Motor Driven Safety Chiller Pump QKA10AP107, Fails to Run Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance
104	2.808E-10	0.16	IE FIRE-SAB14-AC LOOPFCSD+REC OPF-SAC-2H SAC01/QKA10 PM1	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) Consequential LOOP and Failure of Recovery Within 1 Hour for Fire IEs Leading to a Controlled Shutdn Operator Fails to Recover Room Cooling Locally Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
105	2.783E-10	0.16	IE FIRE-MS-VR JNG10AA004EFC_D-ALL MSIV TR3 ISO-FIRE MSIV TR4 ISO-FIRE	Initiator - Fire in One of Two MF/MS Valve Rooms With Spurious Opening of 1 MSRV CCF to Close LHSI to Tangential Miniflow MOTOR Operated Check Valves MSIV 3 Fails to Isolate Due to Fire in MS/FW Valve Room MSIV 4 Fails to Isolate Due to Fire in MS/FW Valve Room

MCS Results

EPRDC050

FIRE

No.	Prob.	%	Event	Description
106	2.644E-10	0.15	IE FIRE-SAB14-AC	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4)
			LOOP24+REC	Loss Of Offsite Power During Mission Time and Failure of Recovery Within 1 Hour
			OPF-XTDIV-NSC	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
			XKA20____DFR	ELEC, Emergency Diesel Generator XKA20, Fails to Run
107	2.520E-10	0.14	IE FIRE-SAB14-AC	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4)
			LOOPFCSD+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for Fire IEs Leading to a Controlled Shutdn
			OPF-XTDIV-NSC	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions
			PEB20AA005EFO	ESWS, Train 2 Pump Discharge Isolation MOV PEB20AA005, Fails to Open on Demand
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
108	2.403E-10	0.14	IE FIRE-PZR	Initiator - Fire in the Pressurizer Compartment With Spurious Opening of 1 PSRV
			MSRIVSCPFO_P-ALL	CCF to Open Main Steam Relief Isolation Pneumatic Pilot Valves
109	2.157E-10	0.12	IE FIRE-SAB14-AC	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4)
			LOOPFCSD+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for Fire IEs Leading to a Controlled Shutdn
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
			XKA10____DFR	ELEC, Emergency Diesel Generator XKA10, Fails to Run
			XKA50____DFR	ELEC, SBO Diesel Generator XKA50, Fails to Run
110	2.087E-10	0.12	IE FIRE-SAB14-AC	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4)
			CVCS VCT	CVCS Switchover to IRWST May Not Be Required
			JND10AP001EFR_D-123	CCF of MHSI Pumps to Run
			OPE-FCD-40M	Operator Fails to Initiate Fast Cooledown for SLOCA
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
111	2.000E-10	0.11	IE FIRE-SAB14-AC	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4)
			CL-TXS-OSCCF	SW CCF of TXS operating system or multiple diversity groups
112	2.000E-10	0.11	IE FIRE-SAB14-AC	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4)
			CL-PS-B-SWCCF	SW CCF of Protection System diversity group B
			CVCS VCT	CVCS Switchover to IRWST May Not Be Required
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
113	1.978E-10	0.11	IE FIRE-SAB14-AC	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4)
			CVCS VCT	CVCS Switchover to IRWST May Not Be Required
			JND10AP001EFR_D-ALL	CCF of MHSI Pumps to Run
			OPE-FCD-40M	Operator Fails to Initiate Fast Cooledown for SLOCA
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
114	1.814E-10	0.10	IE FIRE-SAB-MECH	Initiator - Fire in the Pump Room of Any Safeguard Building
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			PAS	Process Automation System (PAS) Fails (Estimate)
			QKA10GH001_FR	SCWS, Train 1 Chiller Unit QKA10GH001, Fails to Run

MCS Results

EPRDC050

FIRE

No.	Prob.	%	Event	Description
115	1.791E-10	0.10	IE FIRE-SAB14-AC CVCS VCT JNG13AA005CFO_D-ALL PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) CVCS Switchover to IRWST May Not Be Required CCF to Open LHSI/MHSI Common Injection Check Valves Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
116	1.705E-10	0.10	IE FIRE-SWGR LAS31AP001EFR LAS41AP001EFR OPF-SAC-2H SAC01/QKA10 PM1	Initiator - Fire in the Switchgear Building EFWS, Train 3 Motor Driven Pump LAS31AP001, Fails to Run EFWS, Train 4 Motor Driven Pump LAS41AP001, Fails to Run Operator Fails to Recover Room Cooling Locally Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
117	1.705E-10	0.10	IE FIRE-SWGR LAS11AP001EFR LAS21AP001EFR OPF-SAC-2H SAC04/QKA40 PM4	Initiator - Fire in the Switchgear Building EFWS, Train 1 Motor Driven Pump LAS11AP001, Fails to Run EFWS, Train 2 Motor Driven Pump LAS21AP001, Fails to Run Operator Fails to Recover Room Cooling Locally Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance
118	1.686E-10	0.10	IE FIRE-SAB14-AC CVCS VCT MSRIVSOOFO_P-ALL PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) CVCS Switchover to IRWST May Not Be Required CCF to Open Main Steam Relief Isolation Solenoid Pilot Valves Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
119	1.586E-10	0.09	IE FIRE-SAB14-AC LOOPFCSD+REC PROB SEAL LOCA SBODG5 PM1 XKA10_____DFR	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) Consequential LOOP and Failure of Recovery Within 1 Hour for Fire IEs Leading to a Controlled Shutdn Probability of Seal LOCA Occurring Given a Loss of Seal Cooling SBO-DG Train 1 Unavailable due to Preventive Maintenance ELEC, Emergency Diesel Generator XKA10, Fails to Run
120	1.579E-10	0.09	IE FIRE-SAB14-AC CVCS VCT LHSI PM1 PEB20AP001EFS_B-ALL PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) CVCS Switchover to IRWST May Not Be Required LHSI Train 1 Unavailable due to Preventive Maintenance CCF of ESWS Pumps 2 and 3 to Start (Standby) Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
121	1.544E-10	0.09	IE FIRE-BATT LOOPFCSD+REC OPF-SAC-2H SAC01/QKA10 PM1	Initiator - Fire in One of the Four Battery Rooms Consequential LOOP and Failure of Recovery Within 1 Hour for Fire IEs Leading to a Controlled Shutdn Operator Fails to Recover Room Cooling Locally Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
122	1.536E-10	0.09	IE FIRE-SAB14-AC CCWS/ESWS PM3 CVCS VCT JNG10AA006MEC3 JNG20AA006MEC3 PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) CCWS/ESWS Train 3 Pump Unavailable due to Preventive Maintenance CVCS Switchover to IRWST May Not Be Required LHSI, LHSI CL1 Discharge Manual CHECK Valve JNG10AA006, Left in Wrong Position LHSI, LHSI CL2 Discharge Manual CHECK Valve JNG20AA006, Left in Wrong Position Probability of Seal LOCA Occurring Given a Loss of Seal Cooling

MCS Results

EPRDC050

FIRE

No.	Prob.	%	Event	Description
123	1.451E-10	0.08	IE FIRE-SAB14-AC OPF-SAC-2H PROB SEAL LOCA QKA10GH001_FR SAC05 PM1	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) Operator Fails to Recover Room Cooling Locally Probability of Seal LOCA Occurring Given a Loss of Seal Cooling SCWS, Train 1 Chiller Unit QKA10GH001, Fails to Run Maintenance SAC Safety System Train 5 Unavailable due to Preventive Maintenance
124	1.440E-10	0.08	IE FIRE-SAB14-AC 2BDA_2BDB2BOP CVCS VCT OPF-XTDIV-NSC OPF-XTIE BC PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) ELEC, 6.9kV SWGR 32BDA to 6.9kV SWGR 32BDB Circuit Breaker, Fails to Remain Closed (SO) CVCS Switchover to IRWST May Not Be Required Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions Operator Fails to Align Backup Battery Charger to BUC Bus Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
125	1.440E-10	0.08	IE FIRE-SAB14-AC 2BDA_2BDB1BOP CVCS VCT OPF-XTDIV-NSC OPF-XTIE BC PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) ELEC, 6.9kV SWGR 32BDA to 6.9kV SWGR 32BDB Circuit Breaker, Fails to Remain Closed (SO) CVCS Switchover to IRWST May Not Be Required Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions Operator Fails to Align Backup Battery Charger to BUC Bus Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
126	1.339E-10	0.08	IE FIRE-MS-VR LBA10AA002PFC_D-ALL OPF-EBS-30M	Initiator - Fire in One of Two MF/MS Valve Rooms With Spurious Opening of 1 MSRIV CCF to Close Main Steam Isolation Valves Operator Fails to Manually Actuate EBS (SLB & ATWS)
127	1.245E-10	0.07	IE FIRE-MS-VR LBA10AA002PFC_D-124 OPF-EBS-30M	Initiator - Fire in One of Two MF/MS Valve Rooms With Spurious Opening of 1 MSRIV CCF to Close Main Steam Isolation Valves Operator Fails to Manually Actuate EBS (SLB & ATWS)
128	1.245E-10	0.07	IE FIRE-MS-VR LBA10AA002PFC_D-234 OPF-EBS-30M	Initiator - Fire in One of Two MF/MS Valve Rooms With Spurious Opening of 1 MSRIV CCF to Close Main Steam Isolation Valves Operator Fails to Manually Actuate EBS (SLB & ATWS)
129	1.245E-10	0.07	IE FIRE-MS-VR LBA10AA002PFC_D-134 OPF-EBS-30M	Initiator - Fire in One of Two MF/MS Valve Rooms With Spurious Opening of 1 MSRIV CCF to Close Main Steam Isolation Valves Operator Fails to Manually Actuate EBS (SLB & ATWS)
130	1.184E-10	0.07	IE FIRE-SAB14-AC CVCS VCT PEB20AP001EFS_B-ALL PROB SEAL LOCA SAC01/QKA10 PM1	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) CVCS Switchover to IRWST May Not Be Required CCF of ESWS Pumps 2 and 3 to Start (Standby) Probability of Seal LOCA Occurring Given a Loss of Seal Cooling Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance

MCS Results

EPRDC050

FIRE

No.	Prob.	%	Event	Description
131	1.164E-10	0.07	IE FIRE-MS-VR	Initiator - Fire in One of Two MF/MS Valve Rooms With Spurious Opening of 1 MSRIV
			JNG13AA005CFO_D-ALL	CCF to Open LHSI/MHSI Common Injection Check Valves
			MSIV TR3 ISO-FIRE	MSIV 3 Fails to Isolate Due to Fire in MS/FW Valve Room
			MSIV TR4 ISO-FIRE	MSIV 4 Fails to Isolate Due to Fire in MS/FW Valve Room
132	1.112E-10	0.06	IE FIRE-MS-VR	Initiator - Fire in One of Two MF/MS Valve Rooms With Spurious Opening of 1 MSRIV
			LBA10AA002PFC_D-12	CCF to Close Main Steam Isolation Valves
			MSIV TR4 ISO-FIRE	MSIV 4 Fails to Isolate Due to Fire in MS/FW Valve Room
			OPF-EBS-30M	Operator Fails to Manually Actuate EBS (SLB & ATWS)
133	1.112E-10	0.06	IE FIRE-MS-VR	Initiator - Fire in One of Two MF/MS Valve Rooms With Spurious Opening of 1 MSRIV
			LBA10AA002PFC_D-13	CCF to Close Main Steam Isolation Valves
			MSIV TR4 ISO-FIRE	MSIV 4 Fails to Isolate Due to Fire in MS/FW Valve Room
			OPF-EBS-30M	Operator Fails to Manually Actuate EBS (SLB & ATWS)
134	1.112E-10	0.06	IE FIRE-MS-VR	Initiator - Fire in One of Two MF/MS Valve Rooms With Spurious Opening of 1 MSRIV
			LBA10AA002PFC_D-23	CCF to Close Main Steam Isolation Valves
			MSIV TR4 ISO-FIRE	MSIV 4 Fails to Isolate Due to Fire in MS/FW Valve Room
			OPF-EBS-30M	Operator Fails to Manually Actuate EBS (SLB & ATWS)
135	1.088E-10	0.06	IE FIRE-SAB14-AC	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4)
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
			QKA20GH001_FR	SCWS, Train 2 Chiller Unit QKA20GH001, Fails to Run
			SAC01/QKA10 PM1	Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
136	1.088E-10	0.06	IE FIRE-SAB14-AC	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4)
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
			QKA10GH001_FR	SCWS, Train 1 Chiller Unit QKA10GH001, Fails to Run
			SAC02/QKA20 PM2	Normal SAC02/QKA20 Train Unavailable due to Preventive Maintenance
137	1.076E-10	0.06	IE FIRE-SAB14-AC	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4)
			CVCS VCT	CVCS Switchover to IRWST May Not Be Required
			KAA20AP001EFS_B-ALL	CCF of CCWS Pumps 2 and 3 to Start (Standby)
			LHSI PM1	LHSI Train 1 Unavailable due to Preventive Maintenance
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
138	1.067E-10	0.06	IE FIRE-SAB14-AC	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4)
			CVCS VCT	CVCS Switchover to IRWST May Not Be Required
			PED10AN001EFR_D-ALL	CCF to Run Normally Running Cooling Tower Fans
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
139	1.067E-10	0.06	IE FIRE-SAB14-AC	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4)
			CVCS VCT	CVCS Switchover to IRWST May Not Be Required
			PED10AN002EFR_D-ALL	CCF to Run Standby Cooling Tower Fans
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling

MCS Results

EPRDC050

FIRE

No.	Prob.	%	Event	Description
140	1.024E-10	0.06	IE FIRE-SAB14-AC CVCS VCT JNG10AA006MEC3 JNG20AA006MEC3 LHSI PM3 PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) CVCS Switchover to IRWST May Not Be Required LHSI, LHSI CL1 Discharge Manual CHECK Valve JNG10AA006, Left in Wrong Position LHSI, LHSI CL2 Discharge Manual CHECK Valve JNG20AA006, Left in Wrong Position LHSI Train 3 Unavailable due to Preventive Maintenance Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
141	1.019E-10	0.06	IE FIRE-SWGR OPF-SAC-2H SAC01AN001EFR_D-24	Initiator - Fire in the Switchgear Building Operator Fails to Recover Room Cooling Locally CCF to Run Normal Air Supply Fans
142	1.019E-10	0.06	IE FIRE-SWGR OPF-SAC-2H SAC31AN001EFR_D-24	Initiator - Fire in the Switchgear Building Operator Fails to Recover Room Cooling Locally CCF to Run Normal Air Exhaust Fans
143	1.019E-10	0.06	IE FIRE-SWGR OPF-SAC-2H SAC31AN001EFR_D-14	Initiator - Fire in the Switchgear Building Operator Fails to Recover Room Cooling Locally CCF to Run Normal Air Exhaust Fans
144	1.019E-10	0.06	IE FIRE-SWGR OPF-SAC-2H SAC01AN001EFR_D-13	Initiator - Fire in the Switchgear Building Operator Fails to Recover Room Cooling Locally CCF to Run Normal Air Supply Fans
145	1.019E-10	0.06	IE FIRE-SWGR OPF-SAC-2H SAC01AN001EFR_D-14	Initiator - Fire in the Switchgear Building Operator Fails to Recover Room Cooling Locally CCF to Run Normal Air Supply Fans
146	1.019E-10	0.06	IE FIRE-SWGR OPF-SAC-2H SAC31AN001EFR_D-13	Initiator - Fire in the Switchgear Building Operator Fails to Recover Room Cooling Locally CCF to Run Normal Air Exhaust Fans
147	9.531E-11	0.05	IE FIRE-SAB14-AC CLE24EQ001LB01NS CLE24EQ002LF20NS CVCS VCT PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) Digital output module fails (non-self-monitored) Digital input module fails (non-self monitored) CVCS Switchover to IRWST May Not Be Required Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
148	9.531E-11	0.05	IE FIRE-SAB14-AC CLE24EQ001LB03NS CLE24EQ002LF20NS CVCS VCT PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) Digital output module fails (non-self-monitored) Digital input module fails (non-self monitored) CVCS Switchover to IRWST May Not Be Required Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
149	9.531E-11	0.05	IE FIRE-SAB14-AC CLF24EQ001LB03NS CLF24EQ002LF20NS CVCS VCT PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) Digital output module fails (non-self-monitored) Digital input module fails (non-self monitored) CVCS Switchover to IRWST May Not Be Required Probability of Seal LOCA Occurring Given a Loss of Seal Cooling

MCS Results

EPRDC050

FIRE

No.	Prob.	%	Event	Description
150	9.531E-11	0.05	IE FIRE-SAB14-AC CLF24EQ001LF20NS CLF24EQ002LB03NS CVCS VCT PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) Digital input module fails (non-self monitored) Digital output module fails (non-self-monitored) CVCS Switchover to IRWST May Not Be Required Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
151	9.531E-11	0.05	IE FIRE-SAB14-AC CLE24EQ001LF20NS CLE24EQ002LB01NS CVCS VCT PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) Digital input module fails (non-self monitored) Digital output module fails (non-self-monitored) CVCS Switchover to IRWST May Not Be Required Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
152	9.531E-11	0.05	IE FIRE-SAB14-AC CLF24EQ001LB01NS CLF24EQ002LF20NS CVCS VCT PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) Digital output module fails (non-self-monitored) Digital input module fails (non-self monitored) CVCS Switchover to IRWST May Not Be Required Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
153	9.531E-11	0.05	IE FIRE-SAB14-AC CLE24EQ001LB02NS CLE24EQ002LF20NS CVCS VCT PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) Digital output module fails (non-self-monitored) Digital input module fails (non-self monitored) CVCS Switchover to IRWST May Not Be Required Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
154	9.531E-11	0.05	IE FIRE-SAB14-AC CLF24EQ001LF20NS CLF24EQ002LB01NS CVCS VCT PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) Digital input module fails (non-self monitored) Digital output module fails (non-self-monitored) CVCS Switchover to IRWST May Not Be Required Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
155	9.531E-11	0.05	IE FIRE-SAB14-AC CLF24EQ001LF20NS CLF24EQ002LB02NS CVCS VCT PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) Digital input module fails (non-self monitored) Digital output module fails (non-self-monitored) CVCS Switchover to IRWST May Not Be Required Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
156	9.531E-11	0.05	IE FIRE-SAB14-AC CLE24EQ001LF20NS CLE24EQ002LB02NS CVCS VCT PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) Digital input module fails (non-self monitored) Digital output module fails (non-self-monitored) CVCS Switchover to IRWST May Not Be Required Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
157	9.531E-11	0.05	IE FIRE-SAB14-AC CLE24EQ001LF20NS CLE24EQ002LB03NS CVCS VCT PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) Digital input module fails (non-self monitored) Digital output module fails (non-self-monitored) CVCS Switchover to IRWST May Not Be Required Probability of Seal LOCA Occurring Given a Loss of Seal Cooling

MCS Results

EPRDC050

FIRE

No.	Prob.	%	Event	Description
158	9.531E-11	0.05	IE FIRE-SAB14-AC CLF24EQ001LB02NS CLF24EQ002LF20NS CVCS VCT PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) Digital output module fails (non-self-monitored) Digital input module fails (non-self monitored) CVCS Switchover to IRWST May Not Be Required Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
159	9.500E-11	0.05	IE FIRE-PZR CL-PS-B-SWCCF	Initiator - Fire in the Pressurizer Compartment With Spurious Opening of 1 PSRV SW CCF of Protection System diversity group B
160	9.393E-11	0.05	IE FIRE-PZR JND10AP001EFR_D-ALL OPE-FCD-40M	Initiator - Fire in the Pressurizer Compartment With Spurious Opening of 1 PSRV CCF of MHSI Pumps to Run Operator Fails to Initiate Fast Cooldown for SLOCA
161	9.382E-11	0.05	IE FIRE-SAB14-AC CCWS/ESWS PM3 CVCS VCT JNG10AA006MEC3 PEB20AP001EFS PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) CCWS/ESWS Train 3 Pump Unavailable due to Preventive Maintenance CVCS Switchover to IRWST May Not Be Required LHSI, LHSI CL1 Discharge Manual CHECK Valve JNG10AA006, Left in Wrong Position ESWS, Train 2 Motor Driven Pump PEB20AP001, Fails to Start on Demand Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
162	9.364E-11	0.05	IE FIRE-SAB14-AC 31BTD01_BATST LOOPFCSD+REC PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) ELEC, 250V 1E 2-hr Battery 31BTD01, Fails on Demand Consequential LOOP and Failure of Recovery Within 1 Hour for Fire IEs Leading to a Controlled Shutdn Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
163	9.296E-11	0.05	IE FIRE-SAB14-AC CCWS/ESWS PM3 CVCS VCT JNG10AA006MEC3 PED20AN002EFS PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) CCWS/ESWS Train 3 Pump Unavailable due to Preventive Maintenance CVCS Switchover to IRWST May Not Be Required LHSI, LHSI CL1 Discharge Manual CHECK Valve JNG10AA006, Left in Wrong Position UHS, Cooling Tower Train 2 Cooling Fan PED20AN002, Fails to Start on Demand Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
164	9.296E-11	0.05	IE FIRE-SAB14-AC CCWS/ESWS PM3 CVCS VCT JNG20AA006MEC3 PED10AN002EFS PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) CCWS/ESWS Train 3 Pump Unavailable due to Preventive Maintenance CVCS Switchover to IRWST May Not Be Required LHSI, LHSI CL2 Discharge Manual CHECK Valve JNG20AA006, Left in Wrong Position UHS, Cooling Tower Train 1 Cooling Fan PED10AN002, Fails to Start on Demand Probability of Seal LOCA Occurring Given a Loss of Seal Cooling

MCS Results

EPRDC050

FIRE

No.	Prob.	%	Event	Description
165	9.296E-11	0.05	IE FIRE-SAB14-AC CCWS/ESWS PM2 CVCS VCT JNG30AA006MEC3 PED10AN002EFS PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) CCWS/ESWS Train 2 Pump Unavailable due to Preventive Maintenance CVCS Switchover to IRWST May Not Be Required LHSI, LHSI CL3 Discharge Manual CHECK Valve JNG30AA006, Left in Wrong Position UHS, Cooling Tower Train 1 Cooling Fan PED10AN002, Fails to Start on Demand Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
166	9.252E-11	0.05	IE FIRE-SAB-MECH JND10AP001EFR OPF-SAC-2H PAS SAC02/QKA20 PM2	Initiator - Fire in the Pump Room of Any Safeguard Building MHSI, MHSI Train 1 Motor Driven Pump JND10AP001, Fails to Run Operator Fails to Recover Room Cooling Locally Process Automation System (PAS) Fails (Estimate) Normal SAC02/QKA20 Train Unavailable due to Preventive Maintenance
167	9.062E-11	0.05	IE FIRE-SAB-MECH OPF-SAC-2H PAS SAC01AN001EFR	Initiator - Fire in the Pump Room of Any Safeguard Building Operator Fails to Recover Room Cooling Locally Process Automation System (PAS) Fails (Estimate) SAC, Normal Air Supply Fan SAC01AN001, Fails to Run
168	9.062E-11	0.05	IE FIRE-SAB-MECH OPF-SAC-2H PAS SAC31AN001EFR	Initiator - Fire in the Pump Room of Any Safeguard Building Operator Fails to Recover Room Cooling Locally Process Automation System (PAS) Fails (Estimate) SAC, Normal Air Exhaust Fan SAC31AN001, Fails to Run
169	8.704E-11	0.05	IE FIRE-SWGR OPF-SAC-2H QKA40AP107EEL SAC01/QKA10 PM1	Initiator - Fire in the Switchgear Building Operator Fails to Recover Room Cooling Locally SCWS, Train 4 Motor Driven Safety Chiller Pump QKA40AP107, External Leakage Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
170	8.704E-11	0.05	IE FIRE-SWGR KAB30AA191SPO OPF-SAC-2H SAC04/QKA40 PM4	Initiator - Fire in the Switchgear Building CCWS, CCWS CH1 RCP1/2 TB Return Safety Valve KAB30AA191, Premature Opening Operator Fails to Recover Room Cooling Locally Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance
171	8.704E-11	0.05	IE FIRE-SWGR OPF-SAC-2H QKA30AP107EEL SAC01/QKA10 PM1	Initiator - Fire in the Switchgear Building Operator Fails to Recover Room Cooling Locally SCWS, Train 3 Motor Driven Safety Chiller Pump QKA30AP107, External Leakage Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
172	8.704E-11	0.05	IE FIRE-SWGR OPF-SAC-2H QKA10AP107EEL SAC04/QKA40 PM4	Initiator - Fire in the Switchgear Building Operator Fails to Recover Room Cooling Locally SCWS, Train 1 Motor Driven Safety Chiller Pump QKA10AP107, External Leakage Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance
173	8.704E-11	0.05	IE FIRE-SWGR OPF-SAC-2H QKA20AP107EEL SAC04/QKA40 PM4	Initiator - Fire in the Switchgear Building Operator Fails to Recover Room Cooling Locally SCWS, Train 2 Motor Driven Safety Chiller Pump QKA20AP107, External Leakage Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance

MCS Results

EPRDC050

FIRE

No.	Prob.	%	Event	Description
174	8.704E-11	0.05	IE FIRE-SWGR	Initiator - Fire in the Switchgear Building
			KAB10AA192SPO	CCWS, CCWS CH1 Return Safety Valve KAB10AA192, Premature Opening
			OPF-SAC-2H SAC04/QKA40 PM4	Operator Fails to Recover Room Cooling Locally Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance
175	8.704E-11	0.05	IE FIRE-SWGR	Initiator - Fire in the Switchgear Building
			KAB20AA192SPO	CCWS, CCWS CH2 Return Safety Valve KAB20AA192, Premature Opening
			OPF-SAC-2H SAC01/QKA10 PM1	Operator Fails to Recover Room Cooling Locally Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
176	8.704E-11	0.05	IE FIRE-SWGR	Initiator - Fire in the Switchgear Building
			KAB70AA191SPO	CCWS, CVCS HP Cooler 2 Return Safety Valve KAB60AA191, Premature Opening
			OPF-SAC-2H SAC01/QKA10 PM1	Operator Fails to Recover Room Cooling Locally Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
177	8.704E-11	0.05	IE FIRE-SWGR	Initiator - Fire in the Switchgear Building
			KAB20AA193SPO	CCWS, FPCS Train 2 Cooling Header Safety Valve KAB20AA193, Premature Opening
			OPF-SAC-2H SAC01/QKA10 PM1	Operator Fails to Recover Room Cooling Locally Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
178	8.704E-11	0.05	IE FIRE-SWGR	Initiator - Fire in the Switchgear Building
			OPF-SAC-2H QKA40AP107EEL	Operator Fails to Recover Room Cooling Locally SCWS, Train 4 Motor Driven Safety Chiller Pump QKA40AP107, External Leakage
			SAC02/QKA20 PM2	Normal SAC02/QKA20 Train Unavailable due to Preventive Maintenance
179	8.704E-11	0.05	IE FIRE-SWGR	Initiator - Fire in the Switchgear Building
			KAB10AA193SPO	CCWS, FPCS Train 1 Cooling Header Safety Valve KAB10AA193, Premature Opening
			OPF-SAC-2H SAC04/QKA40 PM4	Operator Fails to Recover Room Cooling Locally Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance
180	8.704E-11	0.05	IE FIRE-SWGR	Initiator - Fire in the Switchgear Building
			KAB30AA192SPO	CCWS, CCWS CH2 RCP3/4 TB Return Safety Valve KAB30AA192, Premature Opening
			OPF-SAC-2H SAC01/QKA10 PM1	Operator Fails to Recover Room Cooling Locally Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
181	8.704E-11	0.05	IE FIRE-SWGR	Initiator - Fire in the Switchgear Building
			OPF-SAC-2H QKA10AP107EEL	Operator Fails to Recover Room Cooling Locally SCWS, Train 1 Motor Driven Safety Chiller Pump QKA10AP107, External Leakage
			SAC03/QKA30 PM3	Normal SAC03/QKA30 Train Unavailable due to Preventive Maintenance
182	8.704E-11	0.05	IE FIRE-SWGR	Initiator - Fire in the Switchgear Building
			KAB60AA191SPO	CCWS, CVCS HP Cooler 1 Return Safety Valve KAB60AA191, Premature Opening
			OPF-SAC-2H SAC04/QKA40 PM4	Operator Fails to Recover Room Cooling Locally Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance

MCS Results

EPRDC050

FIRE

No.	Prob.	%	Event	Description
183	8.506E-11	0.05	IE FIRE-PZR JNG13AA005CFO_D-ALL	Initiator - Fire in the Pressurizer Compartment With Spurious Opening of 1 PSRV CCF to Open LHSI/MHSI Common Injection Check Valves
184	8.432E-11	0.05	IE FIRE-SAB14-AC CCWS/ESWS PM3 CVCS VCT PED10AN002EFS_D-12 PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) CCWS/ESWS Train 3 Pump Unavailable due to Preventive Maintenance CVCS Switchover to IRWST May Not Be Required CCF to Start Standby Cooling Tower Fans Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
185	8.432E-11	0.05	IE FIRE-SAB14-AC CCWS/ESWS PM2 CVCS VCT PED10AN002EFS_D-13 PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) CCWS/ESWS Train 2 Pump Unavailable due to Preventive Maintenance CVCS Switchover to IRWST May Not Be Required CCF to Start Standby Cooling Tower Fans Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
186	8.073E-11	0.05	IE FIRE-SAB14-AC CVCS VCT KAA20AP001EFS_B-ALL PROB SEAL LOCA SAC01/QKA10 PM1	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) CVCS Switchover to IRWST May Not Be Required CCF of CCWS Pumps 2 and 3 to Start (Standby) Probability of Seal LOCA Occurring Given a Loss of Seal Cooling Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
187	8.011E-11	0.05	IE FIRE-PZR MSRIVSOOFO_P-ALL	Initiator - Fire in the Pressurizer Compartment With Spurious Opening of 1 PSRV CCF to Open Main Steam Relief Isolation Solenoid Pilot Valves
188	7.680E-11	0.04	IE FIRE-SAB14-AC CVCS VCT JNG10AA006MEC3 JNG20AA006MEC3 PROB SEAL LOCA SAC03/QKA30 PM3	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) CVCS Switchover to IRWST May Not Be Required LHSI, LHSI CL1 Discharge Manual CHECK Valve JNG10AA006, Left in Wrong Position LHSI, LHSI CL2 Discharge Manual CHECK Valve JNG20AA006, Left in Wrong Position Probability of Seal LOCA Occurring Given a Loss of Seal Cooling Normal SAC03/QKA30 Train Unavailable due to Preventive Maintenance
189	7.680E-11	0.04	IE FIRE-SAB14-AC EDG PM1 LOOP24+REC OPF-XTLDSBO-NSC PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) EDG Train 1 Unavailable due to Preventive Maintenance Loss Of Offsite Power During Mission Time and Failure of Recovery Within 1 Hour Operator Fails to Connect and Load SBO DGs to Div 1 or 4 During Non-SBO Conditions Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
190	7.526E-11	0.04	IE FIRE-SWGR LAS11AP001EFR_D-34 OPF-SAC-2H SAC01/QKA10 PM1	Initiator - Fire in the Switchgear Building CCF of EFWS Pumps to Run Operator Fails to Recover Room Cooling Locally Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
191	7.526E-11	0.04	IE FIRE-SWGR LAS11AP001EFR_D-12 OPF-SAC-2H SAC04/QKA40 PM4	Initiator - Fire in the Switchgear Building CCF of EFWS Pumps to Run Operator Fails to Recover Room Cooling Locally Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance

MCS Results

EPRDC050

FIRE

No.	Prob.	%	Event	Description
192	7.378E-11	0.04	IE FIRE-SAB14-AC CVCS VCT JNG10AP001EFS_D-ALL PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) CVCS Switchover to IRWST May Not Be Required CCF of LHSI Pumps to Start Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
193	7.249E-11	0.04	IE FIRE-SAB14-AC OPF-SAC-2H PROB SEAL LOCA SAC01AN001EFR SAC05 PM1	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) Operator Fails to Recover Room Cooling Locally Probability of Seal LOCA Occurring Given a Loss of Seal Cooling SAC, Normal Air Supply Fan SAC01AN001, Fails to Run Maintenance SAC Safety System Train 5 Unavailable due to Preventive Maintenance
194	7.249E-11	0.04	IE FIRE-SAB14-AC OPF-SAC-2H PROB SEAL LOCA SAC05 PM1 SAC31AN001EFR	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) Operator Fails to Recover Room Cooling Locally Probability of Seal LOCA Occurring Given a Loss of Seal Cooling Maintenance SAC Safety System Train 5 Unavailable due to Preventive Maintenance SAC, Normal Air Exhaust Fan SAC31AN001, Fails to Run
195	7.160E-11	0.04	IE FIRE-SAB14-DC LOOPFCSD+REC OPF-SAC-2H SAC01/QKA10 PM1	Initiator - Fire in the DC Cabinets Room of Safeguard Building 1 (or 4) - I&C Rooms Included Consequential LOOP and Failure of Recovery Within 1 Hour for Fire IEs Leading to a Controlled Shutdn Operator Fails to Recover Room Cooling Locally Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
196	7.110E-11	0.04	IE FIRE-TB OPF-SAC-2H SAC01AN001EFR_D-ALL	Initiator - Fire in the Turbine Building Operator Fails to Recover Room Cooling Locally CCF to Run Normal Air Supply Fans
197	7.110E-11	0.04	IE FIRE-TB OPF-SAC-2H SAC31AN001EFR_D-ALL	Initiator - Fire in the Turbine Building Operator Fails to Recover Room Cooling Locally CCF to Run Normal Air Exhaust Fans
198	7.036E-11	0.04	IE FIRE-SAB14-AC LOOPFCSD+REC OPF-XTLDSBO-NSC PEB10AP001EFS PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) Consequential LOOP and Failure of Recovery Within 1 Hour for Fire IEs Leading to a Controlled Shutdn Operator Fails to Connect and Load SBO DGs to Div 1 or 4 During Non-SBO Conditions ESWS, Train 1 Motor Driven Pump PEB10AP001, Fails to Start on Demand Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
199	6.936E-11	0.04	IE FIRE-MS-VR MSIV TR3 ISO-FIRE MSIV TR4 ISO-FIRE PED10AN002EFR_D-ALL	Initiator - Fire in One of Two MF/MS Valve Rooms With Spurious Opening of 1 MSRIV MSIV 3 Fails to Isolate Due to Fire in MS/FW Valve Room MSIV 4 Fails to Isolate Due to Fire in MS/FW Valve Room CCF to Run Standby Cooling Tower Fans
200	6.936E-11	0.04	IE FIRE-MS-VR MSIV TR3 ISO-FIRE MSIV TR4 ISO-FIRE PED10AN001EFR_D-ALL	Initiator - Fire in One of Two MF/MS Valve Rooms With Spurious Opening of 1 MSRIV MSIV 3 Fails to Isolate Due to Fire in MS/FW Valve Room MSIV 4 Fails to Isolate Due to Fire in MS/FW Valve Room CCF to Run Normally Running Cooling Tower Fans

Minimal Cutsets

Top Event probability Q = 6.135E-08

No.	Prob.	%	Event	Description
1	3.200E-08	52.16	IE FLD-ANN ALL PROB ANNULUS	Initiator - Flood in the RB Annulus (Contained) Probability that the Annulus connection boxes will withstand a contained Flood
2	2.262E-09	3.69	IE FLD-SAB14 FB OPF-SAC-2H PAS SAC01/QKA10 PM1	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building Operator Fails to Recover Room Cooling Locally Process Automation System (PAS) Fails (Estimate) Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
3	5.723E-10	0.93	IE FLD-TB OPF-SAC-2H SAC31AN001EFR_D-ALL	Initiator - Flood in the Turbine Building Operator Fails to Recover Room Cooling Locally CCF to Run Normal Air Exhaust Fans
4	5.723E-10	0.93	IE FLD-TB OPF-SAC-2H SAC01AN001EFR_D-ALL	Initiator - Flood in the Turbine Building Operator Fails to Recover Room Cooling Locally CCF to Run Normal Air Supply Fans
5	5.460E-10	0.89	IE FLD-EFW OPF-SAC-2H PAS SAC01/QKA10 PM1	Initiator - EFW Pipe Break Operator Fails to Recover Room Cooling Locally Process Automation System (PAS) Fails (Estimate) Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
6	4.072E-10	0.66	IE FLD-SAB14 FB LOOPCSD+REC OPF-SAC-2H SAC01/QKA10 PM1	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to a Controlled Shutdown Operator Fails to Recover Room Cooling Locally Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
7	2.750E-10	0.45	IE FLD-TB OPF-SAC-2H QKA10AP107EFR_D-ALL	Initiator - Flood in the Turbine Building Operator Fails to Recover Room Cooling Locally CCF of SCWS Pumps to Run
8	1.868E-10	0.30	IE FLD-TB LAS11AP001EFS_D-ALL OPE-FB-90M	Initiator - Flood in the Turbine Building CCF of EFWS Pumps to Start Operator Fails to Initiate Feed & Bleed for Transient
9	1.620E-10	0.26	IE FLD-SAB14 FB JEB40AA020EFC JND10AP001EFR_D-123 PROB SEAL LOCA	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building RCP Seal, RCP4 Seal Nitrogen Venting Isolation MOV JEB40AA020, Fails to Close on Demand CCF of MHSI Pumps to Run Probability of Seal LOCA Occurring Given a Loss of Seal Cooling

MCS Results

EPRDC050

FLOOD

No.	Prob.	%	Event	Description
10	1.620E-10	0.26	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB30AA020EFC	RCP Seal, RCP3 Seal Nitrogen Venting Isolation MOV JEB30AA020, Fails to Close on Demand
			JND10AP001EFR_D-123	CCF of MHSI Pumps to Run
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
11	1.620E-10	0.26	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB40AA010EFC	RCP, RCP4 Leakoff Isolation MOV JEB40AA010, Fails to Close on Demand
			JND10AP001EFR_D-123	CCF of MHSI Pumps to Run
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
12	1.620E-10	0.26	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB30AA010EFC	RCP, RCP3 Leakoff Isolation MOV JEB30AA010, Fails to Close on Demand
			JND10AP001EFR_D-123	CCF of MHSI Pumps to Run
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
13	1.589E-10	0.26	IE FLD-TB	Initiator - Flood in the Turbine Building
			LAS11AP001EFR_D-ALL	CCF of EFWS Pumps to Run
			OPE-FB-90M	Operator Fails to Initiate Feed & Bleed for Transient
14	1.535E-10	0.25	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB30AA010EFC	RCP, RCP3 Leakoff Isolation MOV JEB30AA010, Fails to Close on Demand
			JND10AP001EFR_D-ALL	CCF of MHSI Pumps to Run
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
15	1.535E-10	0.25	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB30AA020EFC	RCP Seal, RCP3 Seal Nitrogen Venting Isolation MOV JEB30AA020, Fails to Close on Demand
			JND10AP001EFR_D-ALL	CCF of MHSI Pumps to Run
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
16	1.535E-10	0.25	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB40AA020EFC	RCP Seal, RCP4 Seal Nitrogen Venting Isolation MOV JEB40AA020, Fails to Close on Demand
			JND10AP001EFR_D-ALL	CCF of MHSI Pumps to Run
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
17	1.535E-10	0.25	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB40AA010EFC	RCP, RCP4 Leakoff Isolation MOV JEB40AA010, Fails to Close on Demand
			JND10AP001EFR_D-ALL	CCF of MHSI Pumps to Run
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
18	1.260E-10	0.21	IE FLD-EFW	Initiator - EFW Pipe Break
			LOOPCSD+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to a Controlled Shutdown
			OPE-FB-90M	Operator Fails to Initiate Feed & Bleed for Transient

MCS Results

EPRDC050

FLOOD

No.	Prob.	%	Event	Description
19	1.193E-10	0.19	IE FLD-TB	Initiator - Flood in the Turbine Building
			LOOPCON+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram
			OPF-SAC-2H QKA10GH001_FS_B-ALL	Operator Fails to Recover Room Cooling Locally CCF of the Air Cooled SCWS Chiller Units to Start
20	1.123E-10	0.18	IE FLD-TB	Initiator - Flood in the Turbine Building
			LOOPCON+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			QKA10GH001_FS SAC04/QKA40 PM4	SCWS, Train 1 Chiller Unit QKA10GH001, Fails to Start on Demand Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance
21	1.123E-10	0.18	IE FLD-TB	Initiator - Flood in the Turbine Building
			LOOPCON+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			QKA40GH001_FS SAC01/QKA10 PM1	SCWS, Train 4 Chiller Unit QKA40GH001, Fails to Start on Demand Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
22	1.086E-10	0.18	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			LOOP24+REC	Loss Of Offsite Power During Mission Time and Failure of Recovery Within 1 Hour
			OPF-SAC-2H SAC01/QKA10 PM1	Operator Fails to Recover Room Cooling Locally Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
23	9.828E-11	0.16	IE FLD-EFW	Initiator - EFW Pipe Break
			LOOPCSD+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to a Controlled Shutdown
			OPF-SAC-2H SAC04/QKA40 PM4	Operator Fails to Recover Room Cooling Locally Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance
24	9.828E-11	0.16	IE FLD-EFW	Initiator - EFW Pipe Break
			LOOPCSD+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to a Controlled Shutdown
			OPF-SAC-2H SAC01/QKA10 PM1	Operator Fails to Recover Room Cooling Locally Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
25	8.933E-11	0.15	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB40AA020EFC	RCP Seal, RCP4 Seal Nitrogen Venting Isolation MOV JEB40AA020, Fails to Close on Demand
			KAA12AA005EFO_D-ALL PROB SEAL LOCA	CCF to Open CCWS to LHSI HTX Cooling MOV Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
26	8.933E-11	0.15	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB30AA020EFC	RCP Seal, RCP3 Seal Nitrogen Venting Isolation MOV JEB30AA020, Fails to Close on Demand
			KAA12AA005EFO_D-ALL PROB SEAL LOCA	CCF to Open CCWS to LHSI HTX Cooling MOV Probability of Seal LOCA Occurring Given a Loss of Seal Cooling

MCS Results

EPRDC050

FLOOD

No.	Prob.	%	Event	Description
27	8.933E-11	0.15	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB30AA010EFC	RCP, RCP3 Leakoff Isolation MOV JEB30AA010, Fails to Close on Demand
			KAA12AA005EFO_D-ALL PROB SEAL LOCA	CCF to Open CCWS to LHSI HTX Cooling MOV Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
28	8.933E-11	0.15	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB40AA010EFC	RCP, RCP4 Leakoff Isolation MOV JEB40AA010, Fails to Close on Demand
			KAA12AA005EFO_D-ALL PROB SEAL LOCA	CCF to Open CCWS to LHSI HTX Cooling MOV Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
29	8.250E-11	0.13	IE FLD-TB	Initiator - Flood in the Turbine Building
			CL-PS-A-SWCCF	SW CCF of Protection System diversity group A
			OPE-FB-90M	Operator Fails to Initiate Feed & Bleed for Transient
30	7.478E-11	0.12	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB40AA010EFC	RCP, RCP4 Leakoff Isolation MOV JEB40AA010, Fails to Close on Demand
			PED10AN002EFS_D-ALL PROB SEAL LOCA	CCF to Start Standby Cooling Tower Fans Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
31	7.478E-11	0.12	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB30AA020EFC	RCP Seal, RCP3 Seal Nitrogen Venting Isolation MOV JEB30AA020, Fails to Close on Demand
			PED10AN002EFS_D-ALL PROB SEAL LOCA	CCF to Start Standby Cooling Tower Fans Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
32	7.478E-11	0.12	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB40AA020EFC	RCP Seal, RCP4 Seal Nitrogen Venting Isolation MOV JEB40AA020, Fails to Close on Demand
			PED10AN002EFS_D-ALL PROB SEAL LOCA	CCF to Start Standby Cooling Tower Fans Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
33	7.478E-11	0.12	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB30AA010EFC	RCP, RCP3 Leakoff Isolation MOV JEB30AA010, Fails to Close on Demand
			PED10AN002EFS_D-ALL PROB SEAL LOCA	CCF to Start Standby Cooling Tower Fans Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
34	6.576E-11	0.11	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			LOOPCSD+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to a Controlled Shutdown
			OPF-SAC-2H QKA10GH001_FS	Operator Fails to Recover Room Cooling Locally SCWS, Train 1 Chiller Unit QKA10GH001, Fails to Start on Demand

MCS Results

EPRDC050

FLOOD

No.	Prob.	%	Event	Description
35	5.259E-11	0.09	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			PAS	Process Automation System (PAS) Fails (Estimate)
			QKA10GH001_FR	SCWS, Train 1 Chiller Unit QKA10GH001, Fails to Run
36	4.823E-11	0.08	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB40AA010EFC	RCP, RCP4 Leakoff Isolation MOV JEB40AA010, Fails to Close on Demand
			JNG13AA005CFO_D-123	CCF to Open LHSI/MHSI Common Injection Check Valves
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
37	4.823E-11	0.08	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB30AA020EFC	RCP Seal, RCP3 Seal Nitrogen Venting Isolation MOV JEB30AA020, Fails to Close on Demand
			JNG13AA005CFO_D-123	CCF to Open LHSI/MHSI Common Injection Check Valves
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
38	4.823E-11	0.08	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB30AA010EFC	RCP, RCP3 Leakoff Isolation MOV JEB30AA010, Fails to Close on Demand
			JNG13AA005CFO_D-123	CCF to Open LHSI/MHSI Common Injection Check Valves
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
39	4.823E-11	0.08	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB40AA020EFC	RCP Seal, RCP4 Seal Nitrogen Venting Isolation MOV JEB40AA020, Fails to Close on Demand
			JNG13AA005CFO_D-123	CCF to Open LHSI/MHSI Common Injection Check Valves
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
40	4.650E-11	0.08	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB40AA010EFC	RCP, RCP4 Leakoff Isolation MOV JEB40AA010, Fails to Close on Demand
			PED10AN002EFS_D-123	CCF to Start Standby Cooling Tower Fans
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
41	4.650E-11	0.08	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB30AA020EFC	RCP Seal, RCP3 Seal Nitrogen Venting Isolation MOV JEB30AA020, Fails to Close on Demand
			PED10AN002EFS_D-123	CCF to Start Standby Cooling Tower Fans
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
42	4.650E-11	0.08	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB30AA010EFC	RCP, RCP3 Leakoff Isolation MOV JEB30AA010, Fails to Close on Demand
			PED10AN002EFS_D-123	CCF to Start Standby Cooling Tower Fans
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling

MCS Results

EPRDC050

FLOOD

No.	Prob.	%	Event	Description
43	4.650E-11	0.08	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB40AA020EFC	RCP Seal, RCP4 Seal Nitrogen Venting Isolation MOV JEB40AA020, Fails to Close on Demand
			PED10AN002EFS_D-123	CCF to Start Standby Cooling Tower Fans
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
44	4.509E-11	0.07	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB30 SSSF	Mechanical Failure of the Stand Still Seal for RCP3
			JND10AP001EFR_D-123	CCF of MHSI Pumps to Run
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
45	4.509E-11	0.07	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB40 SSSF	Mechanical Failure of the Stand Still Seal for RCP4
			JND10AP001EFR_D-123	CCF of MHSI Pumps to Run
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
46	4.272E-11	0.07	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB40 SSSF	Mechanical Failure of the Stand Still Seal for RCP4
			JND10AP001EFR_D-ALL	CCF of MHSI Pumps to Run
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
47	4.272E-11	0.07	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB30 SSSF	Mechanical Failure of the Stand Still Seal for RCP3
			JND10AP001EFR_D-ALL	CCF of MHSI Pumps to Run
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
48	3.910E-11	0.06	IE FLD-EFW	Initiator - EFW Pipe Break
			JEB40AA010EFC	RCP, RCP4 Leakoff Isolation MOV JEB40AA010, Fails to Close on Demand
			JND10AP001EFR_D-123	CCF of MHSI Pumps to Run
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
49	3.910E-11	0.06	IE FLD-EFW	Initiator - EFW Pipe Break
			JEB40AA020EFC	RCP Seal, RCP4 Seal Nitrogen Venting Isolation MOV JEB40AA020, Fails to Close on Demand
			JND10AP001EFR_D-123	CCF of MHSI Pumps to Run
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
50	3.910E-11	0.06	IE FLD-EFW	Initiator - EFW Pipe Break
			JEB30AA020EFC	RCP Seal, RCP3 Seal Nitrogen Venting Isolation MOV JEB30AA020, Fails to Close on Demand
			JND10AP001EFR_D-123	CCF of MHSI Pumps to Run
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
51	3.910E-11	0.06	IE FLD-EFW	Initiator - EFW Pipe Break
			JEB30AA010EFC	RCP, RCP3 Leakoff Isolation MOV JEB30AA010, Fails to Close on Demand
			JND10AP001EFR_D-123	CCF of MHSI Pumps to Run
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling

MCS Results

EPRDC050

FLOOD

No.	Prob.	%	Event	Description
52	3.704E-11	0.06	IE FLD-EFW	Initiator - EFW Pipe Break
			JEB30AA020EFC	RCP Seal, RCP3 Seal Nitrogen Venting Isolation MOV JEB30AA020, Fails to Close on Demand
			JND10AP001EFR_D-ALL PROB SEAL LOCA	CCF of MHSI Pumps to Run Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
53	3.704E-11	0.06	IE FLD-EFW	Initiator - EFW Pipe Break
			JEB30AA010EFC	RCP, RCP3 Leakoff Isolation MOV JEB30AA010, Fails to Close on Demand
			JND10AP001EFR_D-ALL PROB SEAL LOCA	CCF of MHSI Pumps to Run Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
54	3.704E-11	0.06	IE FLD-EFW	Initiator - EFW Pipe Break
			JEB40AA020EFC	RCP Seal, RCP4 Seal Nitrogen Venting Isolation MOV JEB40AA020, Fails to Close on Demand
			JND10AP001EFR_D-ALL PROB SEAL LOCA	CCF of MHSI Pumps to Run Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
55	3.704E-11	0.06	IE FLD-EFW	Initiator - EFW Pipe Break
			JEB40AA010EFC	RCP, RCP4 Leakoff Isolation MOV JEB40AA010, Fails to Close on Demand
			JND10AP001EFR_D-ALL PROB SEAL LOCA	CCF of MHSI Pumps to Run Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
56	3.639E-11	0.06	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB40AA010EFC	RCP, RCP4 Leakoff Isolation MOV JEB40AA010, Fails to Close on Demand
			KAA12AA005EFO_D-123 PROB SEAL LOCA	CCF to Open CCWS to LHSI HTX Cooling MOV Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
57	3.639E-11	0.06	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB30AA020EFC	RCP Seal, RCP3 Seal Nitrogen Venting Isolation MOV JEB30AA020, Fails to Close on Demand
			KAA12AA005EFO_D-123 PROB SEAL LOCA	CCF to Open CCWS to LHSI HTX Cooling MOV Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
58	3.639E-11	0.06	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB40AA020EFC	RCP Seal, RCP4 Seal Nitrogen Venting Isolation MOV JEB40AA020, Fails to Close on Demand
			KAA12AA005EFO_D-123 PROB SEAL LOCA	CCF to Open CCWS to LHSI HTX Cooling MOV Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
59	3.639E-11	0.06	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB30AA010EFC	RCP, RCP3 Leakoff Isolation MOV JEB30AA010, Fails to Close on Demand
			KAA12AA005EFO_D-123 PROB SEAL LOCA	CCF to Open CCWS to LHSI HTX Cooling MOV Probability of Seal LOCA Occurring Given a Loss of Seal Cooling

MCS Results

EPRDC050

FLOOD

No.	Prob.	%	Event	Description
60	3.406E-11	0.06	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			CCWS/ESWS PM3	CCWS/ESWS Train 3 Pump Unavailable due to Preventive Maintenance
			JEB40AA020EFC	RCP Seal, RCP4 Seal Nitrogen Venting Isolation MOV JEB40AA020, Fails to Close on Demand
			JND10AP001EFR	MHSI, MHSI Train 1 Motor Driven Pump JND10AP001, Fails to Run
			JND20AP001EFR	MHSI, MHSI Train 2 Motor Driven Pump JND20AP001, Fails to Run
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
61	3.406E-11	0.06	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			CCWS/ESWS PM3	CCWS/ESWS Train 3 Pump Unavailable due to Preventive Maintenance
			JEB40AA010EFC	RCP, RCP4 Leakoff Isolation MOV JEB40AA010, Fails to Close on Demand
			JND10AP001EFR	MHSI, MHSI Train 1 Motor Driven Pump JND10AP001, Fails to Run
			JND20AP001EFR	MHSI, MHSI Train 2 Motor Driven Pump JND20AP001, Fails to Run
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
62	3.406E-11	0.06	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			CCWS/ESWS PM3	CCWS/ESWS Train 3 Pump Unavailable due to Preventive Maintenance
			JEB30AA020EFC	RCP Seal, RCP3 Seal Nitrogen Venting Isolation MOV JEB30AA020, Fails to Close on Demand
			JND10AP001EFR	MHSI, MHSI Train 1 Motor Driven Pump JND10AP001, Fails to Run
			JND20AP001EFR	MHSI, MHSI Train 2 Motor Driven Pump JND20AP001, Fails to Run
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
63	3.406E-11	0.06	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			CCWS/ESWS PM3	CCWS/ESWS Train 3 Pump Unavailable due to Preventive Maintenance
			JEB30AA010EFC	RCP, RCP3 Leakoff Isolation MOV JEB30AA010, Fails to Close on Demand
			JND10AP001EFR	MHSI, MHSI Train 1 Motor Driven Pump JND10AP001, Fails to Run
			JND20AP001EFR	MHSI, MHSI Train 2 Motor Driven Pump JND20AP001, Fails to Run
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
64	3.406E-11	0.06	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			CCWS/ESWS PM2	CCWS/ESWS Train 2 Pump Unavailable due to Preventive Maintenance
			JEB30AA020EFC	RCP Seal, RCP3 Seal Nitrogen Venting Isolation MOV JEB30AA020, Fails to Close on Demand
			JND10AP001EFR	MHSI, MHSI Train 1 Motor Driven Pump JND10AP001, Fails to Run
			JND30AP001EFR	MHSI, MHSI Train 3 Motor Driven Pump JND30AP001, Fails to Run
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
65	3.406E-11	0.06	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			CCWS/ESWS PM2	CCWS/ESWS Train 2 Pump Unavailable due to Preventive Maintenance
			JEB40AA010EFC	RCP, RCP4 Leakoff Isolation MOV JEB40AA010, Fails to Close on Demand
			JND10AP001EFR	MHSI, MHSI Train 1 Motor Driven Pump JND10AP001, Fails to Run
			JND30AP001EFR	MHSI, MHSI Train 3 Motor Driven Pump JND30AP001, Fails to Run
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling

MCS Results

EPRDC050

FLOOD

No.	Prob.	%	Event	Description
66	3.406E-11	0.06	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			CCWS/ESWS PM2	CCWS/ESWS Train 2 Pump Unavailable due to Preventive Maintenance
			JEB30AA010EFC	RCP, RCP3 Leakoff Isolation MOV JEB30AA010, Fails to Close on Demand
			JND10AP001EFR	MHSI, MHSI Train 1 Motor Driven Pump JND10AP001, Fails to Run
67	3.406E-11	0.06	JND30AP001EFR	MHSI, MHSI Train 3 Motor Driven Pump JND30AP001, Fails to Run
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
			IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			CCWS/ESWS PM2	CCWS/ESWS Train 2 Pump Unavailable due to Preventive Maintenance
68	3.360E-11	0.05	JEB40AA020EFC	RCP Seal, RCP4 Seal Nitrogen Venting Isolation MOV JEB40AA020, Fails to Close on Demand
			JND10AP001EFR	MHSI, MHSI Train 1 Motor Driven Pump JND10AP001, Fails to Run
			JND30AP001EFR	MHSI, MHSI Train 3 Motor Driven Pump JND30AP001, Fails to Run
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
69	2.800E-11	0.05	IE FLD-EFW	Initiator - EFW Pipe Break
			LOOP24+REC	Loss Of Offsite Power During Mission Time and Failure of Recovery Within 1 Hour
			OPE-FB-90M	Operator Fails to Initiate Feed & Bleed for Transient
70	2.683E-11	0.04	OPE-FB-90M	Operator Fails to Initiate Feed & Bleed for Transient
			OPF-EFW-1H	Operator Fails to Isolate Leaking EFW Tank and Initiate DWS Make-up
			PAS	Process Automation System (PAS) Fails (Estimate)
			IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
71	2.628E-11	0.04	JND10AP001EFR	MHSI, MHSI Train 1 Motor Driven Pump JND10AP001, Fails to Run
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			PAS	Process Automation System (PAS) Fails (Estimate)
			SAC02/QKA20 PM2	Normal SAC02/QKA20 Train Unavailable due to Preventive Maintenance
72	2.628E-11	0.04	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			PAS	Process Automation System (PAS) Fails (Estimate)
			SAC01AN001EFR	SAC, Normal Air Supply Fan SAC01AN001, Fails to Run
73	2.621E-11	0.04	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			PAS	Process Automation System (PAS) Fails (Estimate)
			SAC31AN001EFR	SAC, Normal Air Exhaust Fan SAC31AN001, Fails to Run
74	2.621E-11	0.04	IE FLD-EFW	Initiator - EFW Pipe Break
			LOOP24+REC	Loss Of Offsite Power During Mission Time and Failure of Recovery Within 1 Hour
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			SAC04/QKA40 PM4	Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance

MCS Results

EPRDC050

FLOOD

No.	Prob.	%	Event	Description
74	2.621E-11	0.04	IE FLD-EFW	Initiator - EFW Pipe Break
			LOOP24+REC	Loss Of Offsite Power During Mission Time and Failure of Recovery Within 1 Hour
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			SAC01/QKA10 PM1	Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
75	2.591E-11	0.04	IE FLD-EFW	Initiator - EFW Pipe Break
			LOOPCSD+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to a Controlled Shutdown
			XKA10____DFR_D-ALL	CCF of EDGs to Run
76	2.486E-11	0.04	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB30 SSSF	Mechanical Failure of the Stand Still Seal for RCP3
			KAA12AA005EFO_D-ALL	CCF to Open CCWS to LHSI HTX Cooling MOV
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
77	2.486E-11	0.04	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB40 SSSF	Mechanical Failure of the Stand Still Seal for RCP4
			KAA12AA005EFO_D-ALL	CCF to Open CCWS to LHSI HTX Cooling MOV
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
78	2.395E-11	0.04	IE FLD-EFW	Initiator - EFW Pipe Break
			LOOPCSD+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to a Controlled Shutdown
			XKA10____DFR_D-123	CCF of EDGs to Run
79	2.297E-11	0.04	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			CCWS/ESWS PM3	CCWS/ESWS Train 3 Pump Unavailable due to Preventive Maintenance
			JEB30AA020EFC	RCP Seal, RCP3 Seal Nitrogen Venting Isolation MOV JEB30AA020, Fails to Close on Demand
			JND10AP001EFR	MHSI, MHSI Train 1 Motor Driven Pump JND10AP001, Fails to Run
			JND20AA003MEC3	MHSI, MHSI Pump 20 Discharge MANUAL Check Valve JND20AA003, Left in Wrong Position
PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling			
80	2.297E-11	0.04	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			CCWS/ESWS PM3	CCWS/ESWS Train 3 Pump Unavailable due to Preventive Maintenance
			JEB30AA010EFC	RCP, RCP3 Leakoff Isolation MOV JEB30AA010, Fails to Close on Demand
			JND10AA003MEC3	MHSI, MHSI Pump 10 Discharge MANUAL Check Valve JND10AA003, Left in Wrong Position
			JND20AP001EFR	MHSI, MHSI Train 2 Motor Driven Pump JND20AP001, Fails to Run
PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling			
81	2.297E-11	0.04	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			CCWS/ESWS PM2	CCWS/ESWS Train 2 Pump Unavailable due to Preventive Maintenance
			JEB30AA020EFC	RCP Seal, RCP3 Seal Nitrogen Venting Isolation MOV JEB30AA020, Fails to Close on Demand
			JND10AP001EFR	MHSI, MHSI Train 1 Motor Driven Pump JND10AP001, Fails to Run
			JND30AA003MEC3	MHSI, MHSI Pump 30 Discharge MANUAL Check Valve JND30AA003, Left in Wrong Position
PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling			

MCS Results

EPRDC050

FLOOD

No.	Prob.	%	Event	Description
82	2.297E-11	0.04	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			CCWS/ESWS PM3	CCWS/ESWS Train 3 Pump Unavailable due to Preventive Maintenance
			JEB40AA020EFC	RCP Seal, RCP4 Seal Nitrogen Venting Isolation MOV JEB40AA020, Fails to Close on Demand
			JND10AP001EFR	MHSI, MHSI Train 1 Motor Driven Pump JND10AP001, Fails to Run
83	2.297E-11	0.04	JND20AA003MEC3	MHSI, MHSI Pump 20 Discharge MANUAL Check Valve JND20AA003, Left in Wrong Position
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
			IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			CCWS/ESWS PM3	CCWS/ESWS Train 3 Pump Unavailable due to Preventive Maintenance
84	2.297E-11	0.04	JEB30AA020EFC	RCP Seal, RCP3 Seal Nitrogen Venting Isolation MOV JEB30AA020, Fails to Close on Demand
			JND10AA003MEC3	MHSI, MHSI Pump 10 Discharge MANUAL Check Valve JND10AA003, Left in Wrong Position
			JND20AP001EFR	MHSI, MHSI Train 2 Motor Driven Pump JND20AP001, Fails to Run
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
85	2.297E-11	0.04	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			CCWS/ESWS PM3	CCWS/ESWS Train 3 Pump Unavailable due to Preventive Maintenance
			JEB40AA020EFC	RCP Seal, RCP4 Seal Nitrogen Venting Isolation MOV JEB40AA020, Fails to Close on Demand
			JND10AA003MEC3	MHSI, MHSI Pump 10 Discharge MANUAL Check Valve JND10AA003, Left in Wrong Position
86	2.297E-11	0.04	JND20AP001EFR	MHSI, MHSI Train 2 Motor Driven Pump JND20AP001, Fails to Run
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
			IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			CCWS/ESWS PM3	CCWS/ESWS Train 3 Pump Unavailable due to Preventive Maintenance
87	2.297E-11	0.04	JEB40AA010EFC	RCP, RCP4 Leakoff Isolation MOV JEB40AA010, Fails to Close on Demand
			JND10AA003MEC3	MHSI, MHSI Pump 10 Discharge MANUAL Check Valve JND10AA003, Left in Wrong Position
			JND20AP001EFR	MHSI, MHSI Train 2 Motor Driven Pump JND20AP001, Fails to Run
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
88	2.297E-11	0.04	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			CCWS/ESWS PM2	CCWS/ESWS Train 2 Pump Unavailable due to Preventive Maintenance
			JEB30AA010EFC	RCP, RCP3 Leakoff Isolation MOV JEB30AA010, Fails to Close on Demand
			JND10AA003MEC3	MHSI, MHSI Pump 10 Discharge MANUAL Check Valve JND10AA003, Left in Wrong Position
89	2.297E-11	0.04	JND30AP001EFR	MHSI, MHSI Train 3 Motor Driven Pump JND30AP001, Fails to Run
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling

MCS Results

EPRDC050

FLOOD

No.	Prob.	%	Event	Description
88	2.297E-11	0.04	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			CCWS/ESWS PM3 JEB30AA010EFC	CCWS/ESWS Train 3 Pump Unavailable due to Preventive Maintenance RCP, RCP3 Leakoff Isolation MOV JEB30AA010, Fails to Close on Demand
			JND10AP001EFR JND20AA003MEC3	MHSI, MHSI Train 1 Motor Driven Pump JND10AP001, Fails to Run MHSI, MHSI Pump 20 Discharge MANUAL Check Valve JND20AA003, Left in Wrong Position
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
89	2.297E-11	0.04	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			CCWS/ESWS PM2 JEB30AA020EFC	CCWS/ESWS Train 2 Pump Unavailable due to Preventive Maintenance RCP Seal, RCP3 Seal Nitrogen Venting Isolation MOV JEB30AA020, Fails to Close on Demand
			JND10AA003MEC3	MHSI, MHSI Pump 10 Discharge MANUAL Check Valve JND10AA003, Left in Wrong Position
			JND30AP001EFR PROB SEAL LOCA	MHSI, MHSI Train 3 Motor Driven Pump JND30AP001, Fails to Run Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
90	2.297E-11	0.04	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			CCWS/ESWS PM2 JEB40AA020EFC	CCWS/ESWS Train 2 Pump Unavailable due to Preventive Maintenance RCP Seal, RCP4 Seal Nitrogen Venting Isolation MOV JEB40AA020, Fails to Close on Demand
			JND10AP001EFR JND30AA003MEC3	MHSI, MHSI Train 1 Motor Driven Pump JND10AP001, Fails to Run MHSI, MHSI Pump 30 Discharge MANUAL Check Valve JND30AA003, Left in Wrong Position
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
91	2.297E-11	0.04	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			CCWS/ESWS PM2 JEB40AA010EFC	CCWS/ESWS Train 2 Pump Unavailable due to Preventive Maintenance RCP, RCP4 Leakoff Isolation MOV JEB40AA010, Fails to Close on Demand
			JND10AA003MEC3	MHSI, MHSI Pump 10 Discharge MANUAL Check Valve JND10AA003, Left in Wrong Position
			JND30AP001EFR PROB SEAL LOCA	MHSI, MHSI Train 3 Motor Driven Pump JND30AP001, Fails to Run Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
92	2.297E-11	0.04	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			CCWS/ESWS PM2 JEB40AA010EFC	CCWS/ESWS Train 2 Pump Unavailable due to Preventive Maintenance RCP, RCP4 Leakoff Isolation MOV JEB40AA010, Fails to Close on Demand
			JND10AP001EFR JND30AA003MEC3	MHSI, MHSI Train 1 Motor Driven Pump JND10AP001, Fails to Run MHSI, MHSI Pump 30 Discharge MANUAL Check Valve JND30AA003, Left in Wrong Position
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
93	2.297E-11	0.04	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			CCWS/ESWS PM2 JEB30AA010EFC	CCWS/ESWS Train 2 Pump Unavailable due to Preventive Maintenance RCP, RCP3 Leakoff Isolation MOV JEB30AA010, Fails to Close on Demand
			JND10AP001EFR JND30AA003MEC3	MHSI, MHSI Train 1 Motor Driven Pump JND10AP001, Fails to Run MHSI, MHSI Pump 30 Discharge MANUAL Check Valve JND30AA003, Left in Wrong Position
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling

MCS Results

EPRDC050

FLOOD

No.	Prob.	%	Event	Description
94	2.297E-11	0.04	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			CCWS/ESWS PM2	CCWS/ESWS Train 2 Pump Unavailable due to Preventive Maintenance
			JEB40AA020EFC	RCP Seal, RCP4 Seal Nitrogen Venting Isolation MOV JEB40AA020, Fails to Close on Demand
			JND10AA003MEC3	MHSI, MHSI Pump 10 Discharge MANUAL Check Valve JND10AA003, Left in Wrong Position
95	2.271E-11	0.04	JND30AP001EFR	MHSI, MHSI Train 3 Motor Driven Pump JND30AP001, Fails to Run
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
			IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB30AA020EFC	RCP Seal, RCP3 Seal Nitrogen Venting Isolation MOV JEB30AA020, Fails to Close on Demand
96	2.271E-11	0.04	JND10AP001EFR	MHSI, MHSI Train 1 Motor Driven Pump JND10AP001, Fails to Run
			JND30AP001EFR	MHSI, MHSI Train 3 Motor Driven Pump JND30AP001, Fails to Run
			MHSI PM2	MHSI Train 2 Unavailable due to Preventive Maintenance
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
			IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
97	2.271E-11	0.04	JEB40AA020EFC	RCP Seal, RCP4 Seal Nitrogen Venting Isolation MOV JEB40AA020, Fails to Close on Demand
			JND20AP001EFR	MHSI, MHSI Train 2 Motor Driven Pump JND20AP001, Fails to Run
			JND30AP001EFR	MHSI, MHSI Train 3 Motor Driven Pump JND30AP001, Fails to Run
			MHSI PM1	MHSI Train 1 Unavailable due to Preventive Maintenance
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
98	2.271E-11	0.04	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB30AA010EFC	RCP, RCP3 Leakoff Isolation MOV JEB30AA010, Fails to Close on Demand
			JND20AP001EFR	MHSI, MHSI Train 2 Motor Driven Pump JND20AP001, Fails to Run
			JND30AP001EFR	MHSI, MHSI Train 3 Motor Driven Pump JND30AP001, Fails to Run
			MHSI PM1	MHSI Train 1 Unavailable due to Preventive Maintenance
99	2.271E-11	0.04	PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
			IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB30AA020EFC	RCP Seal, RCP3 Seal Nitrogen Venting Isolation MOV JEB30AA020, Fails to Close on Demand
			JND10AP001EFR	MHSI, MHSI Train 1 Motor Driven Pump JND10AP001, Fails to Run
			JND20AP001EFR	MHSI, MHSI Train 2 Motor Driven Pump JND20AP001, Fails to Run
			MHSI PM3	MHSI Train 3 Unavailable due to Preventive Maintenance
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling

MCS Results

EPRDC050

FLOOD

No.	Prob.	%	Event	Description
100	2.271E-11	0.04	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB40AA020EFC	RCP Seal, RCP4 Seal Nitrogen Venting Isolation MOV JEB40AA020, Fails to Close on Demand
			JND10AP001EFR	MHSI, MHSI Train 1 Motor Driven Pump JND10AP001, Fails to Run
			JND20AP001EFR	MHSI, MHSI Train 2 Motor Driven Pump JND20AP001, Fails to Run
			MHSI PM3	MHSI Train 3 Unavailable due to Preventive Maintenance
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
101	2.271E-11	0.04	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB40AA010EFC	RCP, RCP4 Leakoff Isolation MOV JEB40AA010, Fails to Close on Demand
			JND20AP001EFR	MHSI, MHSI Train 2 Motor Driven Pump JND20AP001, Fails to Run
			JND30AP001EFR	MHSI, MHSI Train 3 Motor Driven Pump JND30AP001, Fails to Run
			MHSI PM1	MHSI Train 1 Unavailable due to Preventive Maintenance
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
102	2.271E-11	0.04	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB40AA010EFC	RCP, RCP4 Leakoff Isolation MOV JEB40AA010, Fails to Close on Demand
			JND10AP001EFR	MHSI, MHSI Train 1 Motor Driven Pump JND10AP001, Fails to Run
			JND20AP001EFR	MHSI, MHSI Train 2 Motor Driven Pump JND20AP001, Fails to Run
			MHSI PM3	MHSI Train 3 Unavailable due to Preventive Maintenance
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
103	2.271E-11	0.04	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB30AA020EFC	RCP Seal, RCP3 Seal Nitrogen Venting Isolation MOV JEB30AA020, Fails to Close on Demand
			JND20AP001EFR	MHSI, MHSI Train 2 Motor Driven Pump JND20AP001, Fails to Run
			JND30AP001EFR	MHSI, MHSI Train 3 Motor Driven Pump JND30AP001, Fails to Run
			MHSI PM1	MHSI Train 1 Unavailable due to Preventive Maintenance
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
104	2.271E-11	0.04	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB30AA010EFC	RCP, RCP3 Leakoff Isolation MOV JEB30AA010, Fails to Close on Demand
			JND10AP001EFR	MHSI, MHSI Train 1 Motor Driven Pump JND10AP001, Fails to Run
			JND20AP001EFR	MHSI, MHSI Train 2 Motor Driven Pump JND20AP001, Fails to Run
			MHSI PM3	MHSI Train 3 Unavailable due to Preventive Maintenance
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
105	2.271E-11	0.04	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB30AA010EFC	RCP, RCP3 Leakoff Isolation MOV JEB30AA010, Fails to Close on Demand
			JND10AP001EFR	MHSI, MHSI Train 1 Motor Driven Pump JND10AP001, Fails to Run
			JND30AP001EFR	MHSI, MHSI Train 3 Motor Driven Pump JND30AP001, Fails to Run
			MHSI PM2	MHSI Train 2 Unavailable due to Preventive Maintenance
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling

MCS Results

EPRDC050

FLOOD

No.	Prob.	%	Event	Description
106	2.271E-11	0.04	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB40AA020EFC	RCP Seal, RCP4 Seal Nitrogen Venting Isolation MOV JEB40AA020, Fails to Close on Demand
			JND10AP001EFR	MHSI, MHSI Train 1 Motor Driven Pump JND10AP001, Fails to Run
			JND30AP001EFR	MHSI, MHSI Train 3 Motor Driven Pump JND30AP001, Fails to Run
			MHSI PM2	MHSI Train 2 Unavailable due to Preventive Maintenance
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
107	2.254E-11	0.04	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB30AA018OFO	RCP Seal, RCP3 Nitrogen Supply Solenoid Valve JEB30AA018, Fails to Open on Demand
			JND10AP001EFR_D-123	CCF of MHSI Pumps to Run
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
108	2.254E-11	0.04	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB40AA018OFO	RCP Seal, RCP4 Nitrogen Supply Solenoid Valve JEB40AA018, Fails to Open on Demand
			JND10AP001EFR_D-123	CCF of MHSI Pumps to Run
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
109	2.202E-11	0.04	IE FLD-TB	Initiator - Flood in the Turbine Building
			OPD-SAC2H/SAC1H	Dependency (MED) Between OAs for Starting HVAC Maintenance Trains Recovering Room Cooling Locally
			OPF-SAC-1H	Operator Fails to Start Maintenance HVAC Trains After Failure of Normal SAC Safety Train
			QKA10GH001_FR_B-ALL	CCF of the Air Cooled SCWS Chiller Units to Run
110	2.184E-11	0.04	IE FLD-EFW	Initiator - EFW Pipe Break
			OPF-EFW-1H	Operator Fails to Isolate Leaking EFW Tank and Initiate DWS Make-up
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			PAS	Process Automation System (PAS) Fails (Estimate)
			SAC04/QKA40 PM4	Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance
111	2.156E-11	0.04	IE FLD-EFW	Initiator - EFW Pipe Break
			JEB40AA010EFC	RCP, RCP4 Leakoff Isolation MOV JEB40AA010, Fails to Close on Demand
			KAA12AA005EFO_D-ALL	CCF to Open CCWS to LHSI HTX Cooling MOV
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
112	2.156E-11	0.04	IE FLD-EFW	Initiator - EFW Pipe Break
			JEB40AA020EFC	RCP Seal, RCP4 Seal Nitrogen Venting Isolation MOV JEB40AA020, Fails to Close on Demand
			KAA12AA005EFO_D-ALL	CCF to Open CCWS to LHSI HTX Cooling MOV
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
113	2.156E-11	0.04	IE FLD-EFW	Initiator - EFW Pipe Break
			JEB30AA020EFC	RCP Seal, RCP3 Seal Nitrogen Venting Isolation MOV JEB30AA020, Fails to Close on Demand
			KAA12AA005EFO_D-ALL	CCF to Open CCWS to LHSI HTX Cooling MOV
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling

MCS Results

EPRDC050

FLOOD

No.	Prob.	%	Event	Description
114	2.156E-11	0.04	IE FLD-EFW	Initiator - EFW Pipe Break
			JEB30AA010EFC	RCP, RCP3 Leakoff Isolation MOV JEB30AA010, Fails to Close on Demand
			KAA12AA005EFO_D-ALL PROB SEAL LOCA	CCF to Open CCWS to LHSI HTX Cooling MOV Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
115	2.136E-11	0.03	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB30AA018OFO	RCP Seal, RCP3 Nitrogen Supply Solenoid Valve JEB30AA018, Fails to Open on Demand
			JND10AP001EFR_D-ALL PROB SEAL LOCA	CCF of MHSI Pumps to Run Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
116	2.136E-11	0.03	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB40AA018OFO	RCP Seal, RCP4 Nitrogen Supply Solenoid Valve JEB40AA018, Fails to Open on Demand
			JND10AP001EFR_D-ALL PROB SEAL LOCA	CCF of MHSI Pumps to Run Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
117	2.081E-11	0.03	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB30 SSSF	Mechanical Failure of the Stand Still Seal for RCP3
			PED10AN002EFS_D-ALL PROB SEAL LOCA	CCF to Start Standby Cooling Tower Fans Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
118	2.081E-11	0.03	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB40 SSSF	Mechanical Failure of the Stand Still Seal for RCP4
			PED10AN002EFS_D-ALL PROB SEAL LOCA	CCF to Start Standby Cooling Tower Fans Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
119	2.049E-11	0.03	IE FLD-TB	Initiator - Flood in the Turbine Building
			EFWS PM4	EFWS Train 4 Unavailable due to Preventive Maintenance
			LAS11AP001EFR_D-123 OPE-FB-90M	CCF of EFWS Pumps to Run Operator Fails to Initiate Feed & Bleed for Transient
120	2.049E-11	0.03	IE FLD-TB	Initiator - Flood in the Turbine Building
			EFWS PM1	EFWS Train 1 Unavailable due to Preventive Maintenance
			LAS11AP001EFR_D-234 OPE-FB-90M	CCF of EFWS Pumps to Run Operator Fails to Initiate Feed & Bleed for Transient
121	2.049E-11	0.03	IE FLD-TB	Initiator - Flood in the Turbine Building
			EFWS PM2	EFWS Train 2 Unavailable due to Preventive Maintenance
			LAS11AP001EFR_D-134 OPE-FB-90M	CCF of EFWS Pumps to Run Operator Fails to Initiate Feed & Bleed for Transient
122	2.049E-11	0.03	IE FLD-TB	Initiator - Flood in the Turbine Building
			EFWS PM3	EFWS Train 3 Unavailable due to Preventive Maintenance
			LAS11AP001EFR_D-124 OPE-FB-90M	CCF of EFWS Pumps to Run Operator Fails to Initiate Feed & Bleed for Transient

MCS Results

EPRDC050

FLOOD

No.	Prob.	%	Event	Description
123	2.018E-11	0.03	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			CL-PS-B-SWCCF	SW CCF of Protection System diversity group B
			JEB40AA010EFC	RCP, RCP4 Leakoff Isolation MOV JEB40AA010, Fails to Close on Demand
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
124	2.018E-11	0.03	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			CL-PS-B-SWCCF	SW CCF of Protection System diversity group B
			JEB40AA020EFC	RCP Seal, RCP4 Seal Nitrogen Venting Isolation MOV JEB40AA020, Fails to Close on Demand
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
125	2.018E-11	0.03	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			CL-PS-B-SWCCF	SW CCF of Protection System diversity group B
			JEB30AA010EFC	RCP, RCP3 Leakoff Isolation MOV JEB30AA010, Fails to Close on Demand
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
126	2.018E-11	0.03	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			CL-PS-B-SWCCF	SW CCF of Protection System diversity group B
			JEB30AA020EFC	RCP Seal, RCP3 Seal Nitrogen Venting Isolation MOV JEB30AA020, Fails to Close on Demand
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
127	1.947E-11	0.03	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB40AA010EFC	RCP, RCP4 Leakoff Isolation MOV JEB40AA010, Fails to Close on Demand
			LBA13AA001PFO_D-ALL	CCF to Open Main Steam Relief Isolation Valves
			OPE-FB-40M	Operator Fails to Initiate Feed & Bleed for SLOCA
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
128	1.947E-11	0.03	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB40AA020EFC	RCP Seal, RCP4 Seal Nitrogen Venting Isolation MOV JEB40AA020, Fails to Close on Demand
			LBA13AA001PFO_D-ALL	CCF to Open Main Steam Relief Isolation Valves
			OPE-FB-40M	Operator Fails to Initiate Feed & Bleed for SLOCA
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
129	1.947E-11	0.03	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB30AA020EFC	RCP Seal, RCP3 Seal Nitrogen Venting Isolation MOV JEB30AA020, Fails to Close on Demand
			LBA13AA001PFO_D-ALL	CCF to Open Main Steam Relief Isolation Valves
			OPE-FB-40M	Operator Fails to Initiate Feed & Bleed for SLOCA
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
130	1.947E-11	0.03	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB30AA010EFC	RCP, RCP3 Leakoff Isolation MOV JEB30AA010, Fails to Close on Demand
			LBA13AA001PFO_D-ALL	CCF to Open Main Steam Relief Isolation Valves
			OPE-FB-40M	Operator Fails to Initiate Feed & Bleed for SLOCA
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling

MCS Results

EPRDC050

FLOOD

No.	Prob.	%	Event	Description
131	1.866E-11	0.03	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB40AA020EFC	RCP Seal, RCP4 Seal Nitrogen Venting Isolation MOV JEB40AA020, Fails to Close on Demand
			JND10AP001EFS_D-ALL	CCF of MHSI Pumps to Start
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
132	1.866E-11	0.03	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB30AA020EFC	RCP Seal, RCP3 Seal Nitrogen Venting Isolation MOV JEB30AA020, Fails to Close on Demand
			JND10AP001EFS_D-ALL	CCF of MHSI Pumps to Start
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
133	1.866E-11	0.03	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB30AA010EFC	RCP, RCP3 Leakoff Isolation MOV JEB30AA010, Fails to Close on Demand
			JND10AP001EFS_D-ALL	CCF of MHSI Pumps to Start
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
134	1.866E-11	0.03	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB40AA010EFC	RCP, RCP4 Leakoff Isolation MOV JEB40AA010, Fails to Close on Demand
			JND10AP001EFS_D-ALL	CCF of MHSI Pumps to Start
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
135	1.813E-11	0.03	IE FLD-TB	Initiator - Flood in the Turbine Building
			LOOPCON+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			QKA10GH001_FS	SCWS, Train 1 Chiller Unit QKA10GH001, Fails to Start on Demand
			QKA40GH001_FS	SCWS, Train 4 Chiller Unit QKA40GH001, Fails to Start on Demand
136	1.810E-11	0.03	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JND10AA003MEC3	MHSI, MHSI Pump 10 Discharge MANUAL Check Valve JND10AA003, Left in Wrong Position
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			PAS	Process Automation System (PAS) Fails (Estimate)
			SAC02/QKA20 PM2	Normal SAC02/QKA20 Train Unavailable due to Preventive Maintenance
137	1.807E-11	0.03	IE FLD-TB	Initiator - Flood in the Turbine Building
			LOOPCON+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram
			XKA10____DFR_D-ALL	CCF of EDGs to Run
			XKA50____DFR	ELEC, SBO Diesel Generator XKA50, Fails to Run
			XKA80____DFR	ELEC, SBO Diesel Generator XKA80, Fails to Run
138	1.806E-11	0.03	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB30AA020EFC	RCP Seal, RCP3 Seal Nitrogen Venting Isolation MOV JEB30AA020, Fails to Close on Demand
			JNG13AA005CFO_D-ALL	CCF to Open LHSI/MHSI Common Injection Check Valves
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling

MCS Results

EPRDC050

FLOOD

No.	Prob.	%	Event	Description
139	1.806E-11	0.03	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB40AA010EFC	RCP, RCP4 Leakoff Isolation MOV JEB40AA010, Fails to Close on Demand
			JNG13AA005CFO_D-ALL PROB SEAL LOCA	CCF to Open LHSI/MHSI Common Injection Check Valves Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
140	1.806E-11	0.03	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB30AA010EFC	RCP, RCP3 Leakoff Isolation MOV JEB30AA010, Fails to Close on Demand
			JNG13AA005CFO_D-ALL PROB SEAL LOCA	CCF to Open LHSI/MHSI Common Injection Check Valves Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
141	1.806E-11	0.03	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB40AA020EFC	RCP Seal, RCP4 Seal Nitrogen Venting Isolation MOV JEB40AA020, Fails to Close on Demand
			JNG13AA005CFO_D-ALL PROB SEAL LOCA	CCF to Open LHSI/MHSI Common Injection Check Valves Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
142	1.805E-11	0.03	IE FLD-EFW	Initiator - EFW Pipe Break
			JEB30AA020EFC	RCP Seal, RCP3 Seal Nitrogen Venting Isolation MOV JEB30AA020, Fails to Close on Demand
			PED10AN002EFS_D-ALL PROB SEAL LOCA	CCF to Start Standby Cooling Tower Fans Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
143	1.805E-11	0.03	IE FLD-EFW	Initiator - EFW Pipe Break
			JEB40AA020EFC	RCP Seal, RCP4 Seal Nitrogen Venting Isolation MOV JEB40AA020, Fails to Close on Demand
			PED10AN002EFS_D-ALL PROB SEAL LOCA	CCF to Start Standby Cooling Tower Fans Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
144	1.805E-11	0.03	IE FLD-EFW	Initiator - EFW Pipe Break
			JEB40AA010EFC	RCP, RCP4 Leakoff Isolation MOV JEB40AA010, Fails to Close on Demand
			PED10AN002EFS_D-ALL PROB SEAL LOCA	CCF to Start Standby Cooling Tower Fans Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
145	1.805E-11	0.03	IE FLD-EFW	Initiator - EFW Pipe Break
			JEB30AA010EFC	RCP, RCP3 Leakoff Isolation MOV JEB30AA010, Fails to Close on Demand
			PED10AN002EFS_D-ALL PROB SEAL LOCA	CCF to Start Standby Cooling Tower Fans Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
146	1.790E-11	0.03	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			PAS QKA10AP107EFR	Process Automation System (PAS) Fails (Estimate) SCWS, Train 1 Motor Driven Safety Chiller Pump QKA10AP107, Fails to Run

MCS Results

EPRDC050

FLOOD

No.	Prob.	%	Event	Description
147	1.779E-11	0.03	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB30AA010EFC	RCP, RCP3 Leakoff Isolation MOV JEB30AA010, Fails to Close on Demand
			JND10AP001EFS_D-123	CCF of MHSI Pumps to Start
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
148	1.779E-11	0.03	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB40AA020EFC	RCP Seal, RCP4 Seal Nitrogen Venting Isolation MOV JEB40AA020, Fails to Close on Demand
			JND10AP001EFS_D-123	CCF of MHSI Pumps to Start
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
149	1.779E-11	0.03	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB40AA010EFC	RCP, RCP4 Leakoff Isolation MOV JEB40AA010, Fails to Close on Demand
			JND10AP001EFS_D-123	CCF of MHSI Pumps to Start
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
150	1.779E-11	0.03	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB30AA020EFC	RCP Seal, RCP3 Seal Nitrogen Venting Isolation MOV JEB30AA020, Fails to Close on Demand
			JND10AP001EFS_D-123	CCF of MHSI Pumps to Start
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
151	1.764E-11	0.03	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			OPE-FB-40M	Operator Fails to Initiate Feed & Bleed for SLOCA
			OPF-RCP-10M	Operator Fails to Trip RCPs on a Loss of Seal Injection
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			PAS	Process Automation System (PAS) Fails (Estimate)
			SAC02/QKA20 PM2	Normal SAC02/QKA20 Train Unavailable due to Preventive Maintenance
152	1.754E-11	0.03	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			LOOP24+REC	Loss Of Offsite Power During Mission Time and Failure of Recovery Within 1 Hour
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			QKA10GH001_FS	SCWS, Train 1 Chiller Unit QKA10GH001, Fails to Start on Demand
153	1.740E-11	0.03	IE FLD-TB	Initiator - Flood in the Turbine Building
			BTD01_BAT__ST_D-ALL	CCF of Safety Related Batteries on Demand
			LOOPCON+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram
154	1.717E-11	0.03	IE FLD-TB	Initiator - Flood in the Turbine Building
			LOOPCON+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			QKA10GH001_FR_B-ALL	CCF of the Air Cooled SCWS Chiller Units to Run

MCS Results

EPRDC050

FLOOD

No.	Prob.	%	Event	Description
155	1.616E-11	0.03	IE FLD-TB	Initiator - Flood in the Turbine Building
			LOOPCON+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			QKA40GH001_FR SAC01/QKA10 PM1	SCWS, Train 4 Chiller Unit QKA40GH001, Fails to Run Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
156	1.616E-11	0.03	IE FLD-TB	Initiator - Flood in the Turbine Building
			LOOPCON+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			QKA10GH001_FR SAC04/QKA40 PM4	SCWS, Train 1 Chiller Unit QKA10GH001, Fails to Run Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance
157	1.593E-11	0.03	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB30AA010EFC	RCP, RCP3 Leakoff Isolation MOV JEB30AA010, Fails to Close on Demand
			LHSI PM1	LHSI Train 1 Unavailable due to Preventive Maintenance
			PEB20AP001EFS_B-ALL PROB SEAL LOCA	CCF of ESWS Pumps 2 and 3 to Start (Standby) Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
158	1.593E-11	0.03	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB40AA010EFC	RCP, RCP4 Leakoff Isolation MOV JEB40AA010, Fails to Close on Demand
			MHSI PM1	MHSI Train 1 Unavailable due to Preventive Maintenance
			PEB20AP001EFS_B-ALL PROB SEAL LOCA	CCF of ESWS Pumps 2 and 3 to Start (Standby) Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
159	1.593E-11	0.03	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB40AA010EFC	RCP, RCP4 Leakoff Isolation MOV JEB40AA010, Fails to Close on Demand
			LHSI PM1	LHSI Train 1 Unavailable due to Preventive Maintenance
			PEB20AP001EFS_B-ALL PROB SEAL LOCA	CCF of ESWS Pumps 2 and 3 to Start (Standby) Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
160	1.593E-11	0.03	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB40AA020EFC	RCP Seal, RCP4 Seal Nitrogen Venting Isolation MOV JEB40AA020, Fails to Close on Demand
			LHSI PM1	LHSI Train 1 Unavailable due to Preventive Maintenance
			PEB20AP001EFS_B-ALL PROB SEAL LOCA	CCF of ESWS Pumps 2 and 3 to Start (Standby) Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
161	1.593E-11	0.03	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB30AA020EFC	RCP Seal, RCP3 Seal Nitrogen Venting Isolation MOV JEB30AA020, Fails to Close on Demand
			MHSI PM1	MHSI Train 1 Unavailable due to Preventive Maintenance
			PEB20AP001EFS_B-ALL PROB SEAL LOCA	CCF of ESWS Pumps 2 and 3 to Start (Standby) Probability of Seal LOCA Occurring Given a Loss of Seal Cooling

MCS Results

EPRDC050

FLOOD

No.	Prob.	%	Event	Description
162	1.593E-11	0.03	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB40AA020EFC	RCP Seal, RCP4 Seal Nitrogen Venting Isolation MOV JEB40AA020, Fails to Close on Demand
			MHSI PM1	MHSI Train 1 Unavailable due to Preventive Maintenance
			PEB20AP001EFS_B-ALL	CCF of ESWS Pumps 2 and 3 to Start (Standby)
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
163	1.593E-11	0.03	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB30AA020EFC	RCP Seal, RCP3 Seal Nitrogen Venting Isolation MOV JEB30AA020, Fails to Close on Demand
			LHSI PM1	LHSI Train 1 Unavailable due to Preventive Maintenance
			PEB20AP001EFS_B-ALL	CCF of ESWS Pumps 2 and 3 to Start (Standby)
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
164	1.593E-11	0.03	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB30AA010EFC	RCP, RCP3 Leakoff Isolation MOV JEB30AA010, Fails to Close on Demand
			MHSI PM1	MHSI Train 1 Unavailable due to Preventive Maintenance
			PEB20AP001EFS_B-ALL	CCF of ESWS Pumps 2 and 3 to Start (Standby)
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
165	1.587E-11	0.03	IE FLD-EFW	Initiator - EFW Pipe Break
			LOOPCSD+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to a Controlled Shutdown
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			QKA40GH001_FS	SCWS, Train 4 Chiller Unit QKA40GH001, Fails to Start on Demand
166	1.587E-11	0.03	IE FLD-EFW	Initiator - EFW Pipe Break
			LOOPCSD+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to a Controlled Shutdown
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			QKA10GH001_FS	SCWS, Train 1 Chiller Unit QKA10GH001, Fails to Start on Demand
167	1.550E-11	0.03	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			CCWS/ESWS PM3	CCWS/ESWS Train 3 Pump Unavailable due to Preventive Maintenance
			JEB40AA010EFC	RCP, RCP4 Leakoff Isolation MOV JEB40AA010, Fails to Close on Demand
			JND10AA003MEC3	MHSI, MHSI Pump 10 Discharge MANUAL Check Valve JND10AA003, Left in Wrong Position
			JND20AA003MEC3	MHSI, MHSI Pump 20 Discharge MANUAL Check Valve JND20AA003, Left in Wrong Position
PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling			
168	1.550E-11	0.03	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			CCWS/ESWS PM3	CCWS/ESWS Train 3 Pump Unavailable due to Preventive Maintenance
			JEB30AA020EFC	RCP Seal, RCP3 Seal Nitrogen Venting Isolation MOV JEB30AA020, Fails to Close on Demand
			JND10AA003MEC3	MHSI, MHSI Pump 10 Discharge MANUAL Check Valve JND10AA003, Left in Wrong Position
			JND20AA003MEC3	MHSI, MHSI Pump 20 Discharge MANUAL Check Valve JND20AA003, Left in Wrong Position
PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling			

MCS Results

EPRDC050

FLOOD

No.	Prob.	%	Event	Description
169	1.550E-11	0.03	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			CCWS/ESWS PM2	CCWS/ESWS Train 2 Pump Unavailable due to Preventive Maintenance
			JEB40AA010EFC	RCP, RCP4 Leakoff Isolation MOV JEB40AA010, Fails to Close on Demand
			JND10AA003MEC3	MHSI, MHSI Pump 10 Discharge MANUAL Check Valve JND10AA003, Left in Wrong Position
			JND30AA003MEC3	MHSI, MHSI Pump 30 Discharge MANUAL Check Valve JND30AA003, Left in Wrong Position
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
170	1.550E-11	0.03	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			CCWS/ESWS PM3	CCWS/ESWS Train 3 Pump Unavailable due to Preventive Maintenance
			JEB30AA010EFC	RCP, RCP3 Leakoff Isolation MOV JEB30AA010, Fails to Close on Demand
			JNG10AA006MEC3	LHSI, LHSI CL1 Discharge Manual CHECK Valve JNG10AA006, Left in Wrong Position
			JNG20AA006MEC3	LHSI, LHSI CL2 Discharge Manual CHECK Valve JNG20AA006, Left in Wrong Position
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
171	1.550E-11	0.03	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			CCWS/ESWS PM3	CCWS/ESWS Train 3 Pump Unavailable due to Preventive Maintenance
			JEB40AA020EFC	RCP Seal, RCP4 Seal Nitrogen Venting Isolation MOV JEB40AA020, Fails to Close on Demand
			JNG10AA006MEC3	LHSI, LHSI CL1 Discharge Manual CHECK Valve JNG10AA006, Left in Wrong Position
			JNG20AA006MEC3	LHSI, LHSI CL2 Discharge Manual CHECK Valve JNG20AA006, Left in Wrong Position
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
172	1.550E-11	0.03	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			CCWS/ESWS PM3	CCWS/ESWS Train 3 Pump Unavailable due to Preventive Maintenance
			JEB30AA010EFC	RCP, RCP3 Leakoff Isolation MOV JEB30AA010, Fails to Close on Demand
			JND10AA003MEC3	MHSI, MHSI Pump 10 Discharge MANUAL Check Valve JND10AA003, Left in Wrong Position
			JND20AA003MEC3	MHSI, MHSI Pump 20 Discharge MANUAL Check Valve JND20AA003, Left in Wrong Position
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
173	1.550E-11	0.03	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			CCWS/ESWS PM2	CCWS/ESWS Train 2 Pump Unavailable due to Preventive Maintenance
			JEB40AA020EFC	RCP Seal, RCP4 Seal Nitrogen Venting Isolation MOV JEB40AA020, Fails to Close on Demand
			JND10AA003MEC3	MHSI, MHSI Pump 10 Discharge MANUAL Check Valve JND10AA003, Left in Wrong Position
			JND30AA003MEC3	MHSI, MHSI Pump 30 Discharge MANUAL Check Valve JND30AA003, Left in Wrong Position
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling

MCS Results

EPRDC050

FLOOD

No.	Prob.	%	Event	Description
174	1.550E-11	0.03	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			CCWS/ESWS PM2	CCWS/ESWS Train 2 Pump Unavailable due to Preventive Maintenance
			JEB30AA010EFC	RCP, RCP3 Leakoff Isolation MOV JEB30AA010, Fails to Close on Demand
			JND10AA003MEC3	MHSI, MHSI Pump 10 Discharge MANUAL Check Valve JND10AA003, Left in Wrong Position
			JND30AA003MEC3	MHSI, MHSI Pump 30 Discharge MANUAL Check Valve JND30AA003, Left in Wrong Position
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
175	1.550E-11	0.03	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			CCWS/ESWS PM3	CCWS/ESWS Train 3 Pump Unavailable due to Preventive Maintenance
			JEB30AA020EFC	RCP Seal, RCP3 Seal Nitrogen Venting Isolation MOV JEB30AA020, Fails to Close on Demand
			JNG10AA006MEC3	LHSI, LHSI CL1 Discharge Manual CHECK Valve JNG10AA006, Left in Wrong Position
			JNG20AA006MEC3	LHSI, LHSI CL2 Discharge Manual CHECK Valve JNG20AA006, Left in Wrong Position
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
176	1.550E-11	0.03	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			CCWS/ESWS PM3	CCWS/ESWS Train 3 Pump Unavailable due to Preventive Maintenance
			JEB40AA010EFC	RCP, RCP4 Leakoff Isolation MOV JEB40AA010, Fails to Close on Demand
			JNG10AA006MEC3	LHSI, LHSI CL1 Discharge Manual CHECK Valve JNG10AA006, Left in Wrong Position
			JNG20AA006MEC3	LHSI, LHSI CL2 Discharge Manual CHECK Valve JNG20AA006, Left in Wrong Position
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
177	1.550E-11	0.03	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			CCWS/ESWS PM2	CCWS/ESWS Train 2 Pump Unavailable due to Preventive Maintenance
			JEB30AA020EFC	RCP Seal, RCP3 Seal Nitrogen Venting Isolation MOV JEB30AA020, Fails to Close on Demand
			JND10AA003MEC3	MHSI, MHSI Pump 10 Discharge MANUAL Check Valve JND10AA003, Left in Wrong Position
			JND30AA003MEC3	MHSI, MHSI Pump 30 Discharge MANUAL Check Valve JND30AA003, Left in Wrong Position
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
178	1.550E-11	0.03	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			CCWS/ESWS PM3	CCWS/ESWS Train 3 Pump Unavailable due to Preventive Maintenance
			JEB40AA020EFC	RCP Seal, RCP4 Seal Nitrogen Venting Isolation MOV JEB40AA020, Fails to Close on Demand
			JND10AA003MEC3	MHSI, MHSI Pump 10 Discharge MANUAL Check Valve JND10AA003, Left in Wrong Position
			JND20AA003MEC3	MHSI, MHSI Pump 20 Discharge MANUAL Check Valve JND20AA003, Left in Wrong Position
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling

MCS Results

EPRDC050

FLOOD

No.	Prob.	%	Event	Description
179	1.532E-11	0.02	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB40AA020EFC	RCP Seal, RCP4 Seal Nitrogen Venting Isolation MOV JEB40AA020, Fails to Close on Demand
			JND20AA003MEC3	MHSI, MHSI Pump 20 Discharge MANUAL Check Valve JND20AA003, Left in Wrong Position
			JND30AP001EFR	MHSI, MHSI Train 3 Motor Driven Pump JND30AP001, Fails to Run
			MHSI PM1	MHSI Train 1 Unavailable due to Preventive Maintenance
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
180	1.532E-11	0.02	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB30AA020EFC	RCP Seal, RCP3 Seal Nitrogen Venting Isolation MOV JEB30AA020, Fails to Close on Demand
			JND10AA003MEC3	MHSI, MHSI Pump 10 Discharge MANUAL Check Valve JND10AA003, Left in Wrong Position
			JND30AP001EFR	MHSI, MHSI Train 3 Motor Driven Pump JND30AP001, Fails to Run
			MHSI PM2	MHSI Train 2 Unavailable due to Preventive Maintenance
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
181	1.532E-11	0.02	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB40AA010EFC	RCP, RCP4 Leakoff Isolation MOV JEB40AA010, Fails to Close on Demand
			JND20AA003MEC3	MHSI, MHSI Pump 20 Discharge MANUAL Check Valve JND20AA003, Left in Wrong Position
			JND30AP001EFR	MHSI, MHSI Train 3 Motor Driven Pump JND30AP001, Fails to Run
			MHSI PM1	MHSI Train 1 Unavailable due to Preventive Maintenance
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
182	1.532E-11	0.02	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB40AA010EFC	RCP, RCP4 Leakoff Isolation MOV JEB40AA010, Fails to Close on Demand
			JND20AP001EFR	MHSI, MHSI Train 2 Motor Driven Pump JND20AP001, Fails to Run
			JND30AA003MEC3	MHSI, MHSI Pump 30 Discharge MANUAL Check Valve JND30AA003, Left in Wrong Position
			MHSI PM1	MHSI Train 1 Unavailable due to Preventive Maintenance
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
183	1.532E-11	0.02	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB30AA010EFC	RCP, RCP3 Leakoff Isolation MOV JEB30AA010, Fails to Close on Demand
			JND10AP001EFR	MHSI, MHSI Train 1 Motor Driven Pump JND10AP001, Fails to Run
			JND30AA003MEC3	MHSI, MHSI Pump 30 Discharge MANUAL Check Valve JND30AA003, Left in Wrong Position
			MHSI PM2	MHSI Train 2 Unavailable due to Preventive Maintenance
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
184	1.532E-11	0.02	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB40AA020EFC	RCP Seal, RCP4 Seal Nitrogen Venting Isolation MOV JEB40AA020, Fails to Close on Demand
			JND10AP001EFR	MHSI, MHSI Train 1 Motor Driven Pump JND10AP001, Fails to Run
			JND20AA003MEC3	MHSI, MHSI Pump 20 Discharge MANUAL Check Valve JND20AA003, Left in Wrong Position
			MHSI PM3	MHSI Train 3 Unavailable due to Preventive Maintenance
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling

MCS Results

EPRDC050

FLOOD

No.	Prob.	%	Event	Description
185	1.532E-11	0.02	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB30AA020EFC	RCP Seal, RCP3 Seal Nitrogen Venting Isolation MOV JEB30AA020, Fails to Close on Demand
			JND20AA003MEC3	MHSI, MHSI Pump 20 Discharge MANUAL Check Valve JND20AA003, Left in Wrong Position
			JND30AP001EFR	MHSI, MHSI Train 3 Motor Driven Pump JND30AP001, Fails to Run
			MHSI PM1	MHSI Train 1 Unavailable due to Preventive Maintenance
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
186	1.532E-11	0.02	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB40AA020EFC	RCP Seal, RCP4 Seal Nitrogen Venting Isolation MOV JEB40AA020, Fails to Close on Demand
			JND10AP001EFR	MHSI, MHSI Train 1 Motor Driven Pump JND10AP001, Fails to Run
			JND30AA003MEC3	MHSI, MHSI Pump 30 Discharge MANUAL Check Valve JND30AA003, Left in Wrong Position
			MHSI PM2	MHSI Train 2 Unavailable due to Preventive Maintenance
187	1.532E-11	0.02	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB30AA020EFC	RCP Seal, RCP3 Seal Nitrogen Venting Isolation MOV JEB30AA020, Fails to Close on Demand
			JND10AA003MEC3	MHSI, MHSI Pump 10 Discharge MANUAL Check Valve JND10AA003, Left in Wrong Position
			JND20AP001EFR	MHSI, MHSI Train 2 Motor Driven Pump JND20AP001, Fails to Run
			MHSI PM3	MHSI Train 3 Unavailable due to Preventive Maintenance
188	1.532E-11	0.02	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB30AA010EFC	RCP, RCP3 Leakoff Isolation MOV JEB30AA010, Fails to Close on Demand
			JND20AA003MEC3	MHSI, MHSI Pump 20 Discharge MANUAL Check Valve JND20AA003, Left in Wrong Position
			JND30AP001EFR	MHSI, MHSI Train 3 Motor Driven Pump JND30AP001, Fails to Run
			MHSI PM1	MHSI Train 1 Unavailable due to Preventive Maintenance
189	1.532E-11	0.02	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB30AA010EFC	RCP, RCP3 Leakoff Isolation MOV JEB30AA010, Fails to Close on Demand
			JND10AA003MEC3	MHSI, MHSI Pump 10 Discharge MANUAL Check Valve JND10AA003, Left in Wrong Position
			JND20AP001EFR	MHSI, MHSI Train 2 Motor Driven Pump JND20AP001, Fails to Run
			MHSI PM3	MHSI Train 3 Unavailable due to Preventive Maintenance
190	1.532E-11	0.02	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB40AA010EFC	RCP, RCP4 Leakoff Isolation MOV JEB40AA010, Fails to Close on Demand
			JND10AA003MEC3	MHSI, MHSI Pump 10 Discharge MANUAL Check Valve JND10AA003, Left in Wrong Position
			JND20AP001EFR	MHSI, MHSI Train 2 Motor Driven Pump JND20AP001, Fails to Run
			MHSI PM3	MHSI Train 3 Unavailable due to Preventive Maintenance

MCS Results

EPRDC050

FLOOD

No.	Prob.	%	Event	Description
191	1.532E-11	0.02	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB30AA010EFC	RCP, RCP3 Leakoff Isolation MOV JEB30AA010, Fails to Close on Demand
			JND20AP001EFR	MHSI, MHSI Train 2 Motor Driven Pump JND20AP001, Fails to Run
			JND30AA003MEC3	MHSI, MHSI Pump 30 Discharge MANUAL Check Valve JND30AA003, Left in Wrong Position
			MHSI PM1 PROB SEAL LOCA	MHSI Train 1 Unavailable due to Preventive Maintenance Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
192	1.532E-11	0.02	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB30AA020EFC	RCP Seal, RCP3 Seal Nitrogen Venting Isolation MOV JEB30AA020, Fails to Close on Demand
			JND20AP001EFR	MHSI, MHSI Train 2 Motor Driven Pump JND20AP001, Fails to Run
			JND30AA003MEC3	MHSI, MHSI Pump 30 Discharge MANUAL Check Valve JND30AA003, Left in Wrong Position
			MHSI PM1 PROB SEAL LOCA	MHSI Train 1 Unavailable due to Preventive Maintenance Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
193	1.532E-11	0.02	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB30AA020EFC	RCP Seal, RCP3 Seal Nitrogen Venting Isolation MOV JEB30AA020, Fails to Close on Demand
			JND10AP001EFR	MHSI, MHSI Train 1 Motor Driven Pump JND10AP001, Fails to Run
			JND30AA003MEC3	MHSI, MHSI Pump 30 Discharge MANUAL Check Valve JND30AA003, Left in Wrong Position
			MHSI PM2 PROB SEAL LOCA	MHSI Train 2 Unavailable due to Preventive Maintenance Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
194	1.532E-11	0.02	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB30AA020EFC	RCP Seal, RCP3 Seal Nitrogen Venting Isolation MOV JEB30AA020, Fails to Close on Demand
			JND10AP001EFR	MHSI, MHSI Train 1 Motor Driven Pump JND10AP001, Fails to Run
			JND20AA003MEC3	MHSI, MHSI Pump 20 Discharge MANUAL Check Valve JND20AA003, Left in Wrong Position
			MHSI PM3 PROB SEAL LOCA	MHSI Train 3 Unavailable due to Preventive Maintenance Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
195	1.532E-11	0.02	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB40AA010EFC	RCP, RCP4 Leakoff Isolation MOV JEB40AA010, Fails to Close on Demand
			JND10AA003MEC3	MHSI, MHSI Pump 10 Discharge MANUAL Check Valve JND10AA003, Left in Wrong Position
			JND30AP001EFR	MHSI, MHSI Train 3 Motor Driven Pump JND30AP001, Fails to Run
			MHSI PM2 PROB SEAL LOCA	MHSI Train 2 Unavailable due to Preventive Maintenance Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
196	1.532E-11	0.02	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB30AA010EFC	RCP, RCP3 Leakoff Isolation MOV JEB30AA010, Fails to Close on Demand
			JND10AP001EFR	MHSI, MHSI Train 1 Motor Driven Pump JND10AP001, Fails to Run
			JND20AA003MEC3	MHSI, MHSI Pump 20 Discharge MANUAL Check Valve JND20AA003, Left in Wrong Position
			MHSI PM3 PROB SEAL LOCA	MHSI Train 3 Unavailable due to Preventive Maintenance Probability of Seal LOCA Occurring Given a Loss of Seal Cooling

MCS Results

EPRDC050

FLOOD

No.	Prob.	%	Event	Description
197	1.532E-11	0.02	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB40AA020EFC	RCP Seal, RCP4 Seal Nitrogen Venting Isolation MOV JEB40AA020, Fails to Close on Demand
			JND10AA003MEC3	MHSI, MHSI Pump 10 Discharge MANUAL Check Valve JND10AA003, Left in Wrong Position
			JND20AP001EFR	MHSI, MHSI Train 2 Motor Driven Pump JND20AP001, Fails to Run
			MHSI PM3	MHSI Train 3 Unavailable due to Preventive Maintenance
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
198	1.532E-11	0.02	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB40AA010EFC	RCP, RCP4 Leakoff Isolation MOV JEB40AA010, Fails to Close on Demand
			JND10AP001EFR	MHSI, MHSI Train 1 Motor Driven Pump JND10AP001, Fails to Run
			JND20AA003MEC3	MHSI, MHSI Pump 20 Discharge MANUAL Check Valve JND20AA003, Left in Wrong Position
			MHSI PM3	MHSI Train 3 Unavailable due to Preventive Maintenance
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
199	1.532E-11	0.02	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB30AA010EFC	RCP, RCP3 Leakoff Isolation MOV JEB30AA010, Fails to Close on Demand
			JND10AA003MEC3	MHSI, MHSI Pump 10 Discharge MANUAL Check Valve JND10AA003, Left in Wrong Position
			JND30AP001EFR	MHSI, MHSI Train 3 Motor Driven Pump JND30AP001, Fails to Run
			MHSI PM2	MHSI Train 2 Unavailable due to Preventive Maintenance
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
200	1.532E-11	0.02	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			JEB40AA020EFC	RCP Seal, RCP4 Seal Nitrogen Venting Isolation MOV JEB40AA020, Fails to Close on Demand
			JND10AA003MEC3	MHSI, MHSI Pump 10 Discharge MANUAL Check Valve JND10AA003, Left in Wrong Position
			JND30AP001EFR	MHSI, MHSI Train 3 Motor Driven Pump JND30AP001, Fails to Run
			MHSI PM2	MHSI Train 2 Unavailable due to Preventive Maintenance
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling

Minimal Cutsets

Top Event frequency F = 5.770E-08

No.	Freq.	%	Event	Description
1	3.388E-09	5.87	IE SD ULD DU D KBA14AA004EFC_B CCF to Close CVCS Low Pressure Reducing Station MOVs -ALL OPE-ISOC SLPRS	Initiator - Uncontrolled Level Drop in Shutdown State Du (Demand) Operator Fails to Isolate the CVCS Low Pressure Reducing Station
2	3.388E-09	5.87	IE SD ULD CBD D KBA14AA004EFC_B CCF to Close CVCS Low Pressure Reducing Station MOVs -ALL OPE-ISOC SLPRS	Initiator - Uncontrolled Level Drop in Shutdown State CBd (Demand) Operator Fails to Isolate the CVCS Low Pressure Reducing Station
3	2.461E-09	4.26	IE SD RHR CBD SD LOOP24+REC XKA10____DFR_D CCF of EDGs to Run -ALL XKA50____DFR	Initiator - RHR in Power State CBd Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour ELEC, SBO Diesel Generator XKA50, Fails to Run
4	1.891E-09	3.28	IE SD ULD DU D KBA14AA004EFC OPE-ISOC SLPRS OPF-ULD	Initiator - Uncontrolled Level Drop in Shutdown State Du (Demand) CVCS, Low Pressure Reducing Station Isolation MOV KBA14AA004, Fails to Close on Demand Operator Fails to Isolate the CVCS Low Pressure Reducing Station Operator Fails to Stop Draindown at Mid-Loop
5	1.891E-09	3.28	IE SD ULD CBD D KBA14AA004EFC OPE-ISOC SLPRS OPF-ULD	Initiator - Uncontrolled Level Drop in Shutdown State CBd (Demand) CVCS, Low Pressure Reducing Station Isolation MOV KBA14AA004, Fails to Close on Demand Operator Fails to Isolate the CVCS Low Pressure Reducing Station Operator Fails to Stop Draindown at Mid-Loop
6	1.845E-09	3.20	IE SD RHR CBU SD LOOP24+REC XKA10____DFR_D CCF of EDGs to Run -ALL XKA50____DFR	Initiator - RHR in Power State CBU Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour ELEC, SBO Diesel Generator XKA50, Fails to Run
7	1.845E-09	3.20	IE SD RHR CAD SD LOOP24+REC XKA10____DFR_D CCF of EDGs to Run -ALL XKA50____DFR	Initiator - RHR in Power State CAD Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour ELEC, SBO Diesel Generator XKA50, Fails to Run

MCS Results

EPRDCSD1

SHUTDOWN

No.	Freq.	%	Event	Description
8	1.230E-09	2.13	IE SD RHR CAU	Initiator - RHR in Power State CAU
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR_D -ALL	CCF of EDGs to Run
			XKA50____DFR	ELEC, SBO Diesel Generator XKA50, Fails to Run
9	6.502E-10	1.13	IE SD ULD CBD D	Initiator - Uncontrolled Level Drop in Shutdown State CBd (Demand)
			KBA14AA004EFC	CVCS, Low Pressure Reducing Station Isolation MOV KBA14AA004, Fails to Close on Demand
			KBA14AA106EFC	CVCS, CVCS Low Power Reducing Station MOV KBA14AA106, Fails to Close on Demand
			OPE-ISOCSLPRS	Operator Fails to Isolate the CVCS Low Pressure Reducing Station
10	6.502E-10	1.13	IE SD ULD DU D	Initiator - Uncontrolled Level Drop in Shutdown State Du (Demand)
			KBA14AA004EFC	CVCS, Low Pressure Reducing Station Isolation MOV KBA14AA004, Fails to Close on Demand
			KBA14AA106EFC	CVCS, CVCS Low Power Reducing Station MOV KBA14AA106, Fails to Close on Demand
			OPE-ISOCSLPRS	Operator Fails to Isolate the CVCS Low Pressure Reducing Station
11	6.446E-10	1.12	IE SD LOCA CBD	Initiator - LOCA During Shutdown State CBd
			JNG10AA192SPO	LHSI, LHSI/RHR Train 10 Overpressure Protection Safety Valve JNG10AA192, Premature Opening
			JNG13AA005CFO_ D-ALL	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves)
			OPF-ISORHRFD-CB	Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB
12	6.446E-10	1.12	IE SD LOCA CBD	Initiator - LOCA During Shutdown State CBd
			JNG13AA005CFO_ D-ALL	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves)
			JNG30AA192SPO	LHSI, LHSI/RHR Train 30 Overpressure Protection Safety Valve JNG30AA192, Premature Opening
			OPF-ISORHRFD-CB	Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB
13	6.446E-10	1.12	IE SD LOCA CBD	Initiator - LOCA During Shutdown State CBd
			JNG13AA005CFO_ D-ALL	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves)
			JNG20AA192SPO	LHSI, LHSI/RHR Train 20 Overpressure Protection Safety Valve JNG20AA192, Premature Opening
			OPF-ISORHRFD-CB	Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB
14	6.446E-10	1.12	IE SD LOCA CBD	Initiator - LOCA During Shutdown State CBd
			JNA20AA191SPO	RHR, LHSI Train 2 Safety Valve JNA20AA191, Premature Opening
			JNG13AA005CFO_ D-ALL	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves)
			OPF-ISORHRFD-CB	Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB

MCS Results

EPRDCSD1

SHUTDOWN

No.	Freq.	%	Event	Description
15	6.446E-10	1.12	IE SD LOCA CBD	Initiator - LOCA During Shutdown State CBd
			JNA30AA191SPO	RHR, LHSI Train 3 Safety Valve JNA30AA191, Premature Opening
			JNG13AA005CFO_ D-ALL	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves)
			OPF-ISORHRFD-CB	Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB
16	6.446E-10	1.12	IE SD LOCA CBD	Initiator - LOCA During Shutdown State CBd
			JNA10AA191SPO	RHR, LHSI Train 1 Safety Valve JNA10AA191, Premature Opening
			JNG13AA005CFO_ D-ALL	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves)
			OPF-ISORHRFD-CB	Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB
17	5.500E-10	0.95	IE SD ULD DU D	Initiator - Uncontrolled Level Drop in Shutdown State Du (Demand)
			OPE-ISOC SLPRS	Operator Fails to Isolate the CVCS Low Pressure Reducing Station
			OPF-ULD	Operator Fails to Stop Draindown at Mid-Loop
			PAS	Process Automation System (PAS) Fails (Estimate)
18	5.500E-10	0.95	IE SD ULD CBD D	Initiator - Uncontrolled Level Drop in Shutdown State CBd (Demand)
			OPE-ISOC SLPRS	Operator Fails to Isolate the CVCS Low Pressure Reducing Station
			OPF-ULD	Operator Fails to Stop Draindown at Mid-Loop
			PAS	Process Automation System (PAS) Fails (Estimate)
19	4.835E-10	0.84	IE SD LOCA CBU	Initiator - LOCA During Shutdown State CBU
			JNG10AA192SPO	LHSI, LHSI/RHR Train 10 Overpressure Protection Safety Valve JNG10AA192, Premature Opening
			JNG13AA005CFO_ D-ALL	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves)
			OPF-ISORHRFD-CB	Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB
20	4.835E-10	0.84	IE SD LOCA CBU	Initiator - LOCA During Shutdown State CBU
			JNG13AA005CFO_ D-ALL	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves)
			JNG20AA192SPO	LHSI, LHSI/RHR Train 20 Overpressure Protection Safety Valve JNG20AA192, Premature Opening
			OPF-ISORHRFD-CB	Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB
21	4.835E-10	0.84	IE SD LOCA DU	Initiator - LOCA During Shutdown State Du
			JNG10AA192SPO	LHSI, LHSI/RHR Train 10 Overpressure Protection Safety Valve JNG10AA192, Premature Opening
			JNG13AA005CFO_ D-ALL	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves)
			OPF-ISORHRFD-D	Operator Fails to Isolate RHR Flow Diversion (LOCA) in State D
22	4.835E-10	0.84	IE SD LOCA DU	Initiator - LOCA During Shutdown State Du
			JNA10AA191SPO	RHR, LHSI Train 1 Safety Valve JNA10AA191, Premature Opening
			JNG13AA005CFO_ D-ALL	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves)
			OPF-ISORHRFD-D	Operator Fails to Isolate RHR Flow Diversion (LOCA) in State D

MCS Results

EPRDCSD1

SHUTDOWN

No.	Freq.	%	Event	Description
23	4.835E-10	0.84	IE SD LOCA DU	Initiator - LOCA During Shutdown State Du
			JNA20AA191SPO	RHR, LHSI Train 2 Safety Valve JNA20AA191, Premature Opening
			JNG13AA005CFO_D-ALL	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves)
			OPF-ISORHRFD-D	Operator Fails to Isolate RHR Flow Diversion (LOCA) in State D
24	4.835E-10	0.84	IE SD LOCA CBU	Initiator - LOCA During Shutdown State CBU
			JNA20AA191SPO	RHR, LHSI Train 2 Safety Valve JNA20AA191, Premature Opening
			JNG13AA005CFO_D-ALL	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves)
			OPF-ISORHRFD-CB	Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB
25	4.835E-10	0.84	IE SD LOCA CBU	Initiator - LOCA During Shutdown State CBU
			JNA10AA191SPO	RHR, LHSI Train 1 Safety Valve JNA10AA191, Premature Opening
			JNG13AA005CFO_D-ALL	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves)
			OPF-ISORHRFD-CB	Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB
26	4.835E-10	0.84	IE SD LOCA DU	Initiator - LOCA During Shutdown State Du
			JNG13AA005CFO_D-ALL	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves)
			JNG20AA192SPO	LHSI, LHSI/RHR Train 20 Overpressure Protection Safety Valve JNG20AA192, Premature Opening
			OPF-ISORHRFD-D	Operator Fails to Isolate RHR Flow Diversion (LOCA) in State D
27	3.432E-10	0.59	IE SD RHR ISLOCA E	RHR ISLOCA During Shutdown State E
			OPF-ISORHRBRK	Operator Fails to Isolate RHR Pipe Break
			PAS	Process Automation System (PAS) Fails (Estimate)
			RHR TR2 PIPE BRK	Pipe Break in RHR Train 2
28	3.432E-10	0.59	IE SD RHR ISLOCA E	RHR ISLOCA During Shutdown State E
			OPF-ISORHRBRK	Operator Fails to Isolate RHR Pipe Break
			PAS	Process Automation System (PAS) Fails (Estimate)
			RHR TR1 PIPE BRK	Pipe Break in RHR Train 1
29	3.285E-10	0.57	IE SD RHR CBD	Initiator - RHR in Power State CBd
			PEB10AP001EFS_D-ALL	CCF of the ESWS Pumps to Start
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA50____DFR	ELEC, SBO Diesel Generator XKA50, Fails to Run
30	2.758E-10	0.48	IE SD ULD DU D	Initiator - Uncontrolled Level Drop in Shutdown State Du (Demand)
			JNG13AA005CFO_D-ALL	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves)
			KBA14AA004EFC_B-ALL	CCF to Close CVCS Low Pressure Reducing Station MOVs

MCS Results

EPRDCSD1

SHUTDOWN

No.	Freq.	%	Event	Description
31	2.758E-10	0.48	IE SD ULD CBD D JNG13AA005CFO_D-ALL KBA14AA004EFC_B-ALL	Initiator - Uncontrolled Level Drop in Shutdown State CBd (Demand) CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves) CCF to Close CVCS Low Pressure Reducing Station MOVs
32	2.623E-10	0.45	IE SD RHR CBD OPF-XTDIVSBO-2H SA-ESWS UHS4 SBO SD LOOP24+REC XKA10____DFR_D-ALL	Initiator - RHR in Power State CBd Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During SBO Conditions Failure of SA-ESWS/UHS4 in SBO Conditions Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour CCF of EDGs to Run
33	2.464E-10	0.43	IE SD RHR CAD PEB10AP001EFS_D-ALL SD LOOP24+REC XKA50____DFR	Initiator - RHR in Power State CAD CCF of the ESWS Pumps to Start Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour ELEC, SBO Diesel Generator XKA50, Fails to Run
34	2.464E-10	0.43	IE SD RHR CBU PEB10AP001EFS_D-ALL SD LOOP24+REC XKA50____DFR	Initiator - RHR in Power State CBU CCF of the ESWS Pumps to Start Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour ELEC, SBO Diesel Generator XKA50, Fails to Run
35	2.005E-10	0.35	IE SD RHR CBD SD LOOP24+REC XKA10____DFR_D-ALL XKA50____DFS	Initiator - RHR in Power State CBd Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour CCF of EDGs to Run ELEC, SBO Diesel Generator XKA50, Fails to Start on Demand
36	1.968E-10	0.34	IE SD RHR CAD OPF-XTDIVSBO-2H SA-ESWS UHS4 SBO SD LOOP24+REC XKA10____DFR_D-ALL	Initiator - RHR in Power State CAD Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During SBO Conditions Failure of SA-ESWS/UHS4 in SBO Conditions Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour CCF of EDGs to Run
37	1.968E-10	0.34	IE SD RHR CBU OPF-XTDIVSBO-2H SA-ESWS UHS4 SBO SD LOOP24+REC	Initiator - RHR in Power State CBU Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During SBO Conditions Failure of SA-ESWS/UHS4 in SBO Conditions Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour

MCS Results

EPRDCSD1

SHUTDOWN

No.	Freq.	%	Event	Description
			XKA10____DFR_D -ALL	CCF of EDGs to Run
38	1.891E-10	0.33	IE SD ULD CBD D KBA14AA106EFC OPE-ISOC SLPRS PAS	Initiator - Uncontrolled Level Drop in Shutdown State CBd (Demand) CVCS, CVCS Low Power Reducing Station MOV KBA14AA106, Fails to Close on Demand Operator Fails to Isolate the CVCS Low Pressure Reducing Station Process Automation System (PAS) Fails (Estimate)
39	1.891E-10	0.33	IE SD ULD DU D KBA14AA106EFC OPE-ISOC SLPRS PAS	Initiator - Uncontrolled Level Drop in Shutdown State Du (Demand) CVCS, CVCS Low Power Reducing Station MOV KBA14AA106, Fails to Close on Demand Operator Fails to Isolate the CVCS Low Pressure Reducing Station Process Automation System (PAS) Fails (Estimate)
40	1.844E-10	0.32	IE SD ULD CBD D KBA14AA004PANS OPE-ISOC SLPRS OPF-ULD	Initiator - Uncontrolled Level Drop in Shutdown State CBd (Demand) CVCS, LP Reducing Iso MOV KBA14AA004, PAC A Priority Module (Type AV42) Fails (Non-Self-Monitored) Operator Fails to Isolate the CVCS Low Pressure Reducing Station Operator Fails to Stop Draindown at Mid-Loop
41	1.844E-10	0.32	IE SD ULD DU D KBA14AA004PANS OPE-ISOC SLPRS OPF-ULD	Initiator - Uncontrolled Level Drop in Shutdown State Du (Demand) CVCS, LP Reducing Iso MOV KBA14AA004, PAC A Priority Module (Type AV42) Fails (Non-Self-Monitored) Operator Fails to Isolate the CVCS Low Pressure Reducing Station Operator Fails to Stop Draindown at Mid-Loop
42	1.669E-10	0.29	IE SD RHR CBD SD LOOP24+REC XKA10____DFS_D -ALL XKA50____DFR	Initiator - RHR in Power State CBd Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour CCF of EDGs to Start ELEC, SBO Diesel Generator XKA50, Fails to Run
43	1.642E-10	0.28	IE SD RHR CAU PEB10AP001EFS_D -ALL SD LOOP24+REC XKA50____DFR	Initiator - RHR in Power State CAu CCF of the ESWS Pumps to Start Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour ELEC, SBO Diesel Generator XKA50, Fails to Run
44	1.612E-10	0.28	IE SD LOCA DD JNA10AA191SPO JNG13AA005CFO_ D-ALL OPF-ISORHRFD-D	Initiator - LOCA During Shutdown State Dd RHR, LHSI Train 1 Safety Valve JNA10AA191, Premature Opening CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves) Operator Fails to Isolate RHR Flow Diversion (LOCA) in State D
45	1.612E-10	0.28	IE SD LOCA DD JNG10AA192SPO JNG13AA005CFO_ D-ALL OPF-ISORHRFD-D	Initiator - LOCA During Shutdown State Dd LHSI, LHSI/RHR Train 10 Overpressure Protection Safety Valve JNG10AA192, Premature Opening CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves) Operator Fails to Isolate RHR Flow Diversion (LOCA) in State D

MCS Results

EPRDCSD1

SHUTDOWN

No.	Freq.	%	Event	Description
46	1.612E-10	0.28	IE SD LOCA DD JNA20AA191SPO JNG13AA005CFO_ D-ALL OPF-ISORHRFD-D	Initiator - LOCA During Shutdown State Dd RHR, LHSI Train 2 Safety Valve JNA20AA191, Premature Opening CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves) Operator Fails to Isolate RHR Flow Diversion (LOCA) in State D
47	1.612E-10	0.28	IE SD LOCA DD JNG13AA005CFO_ D-ALL JNG30AA192SPO OPF-ISORHRFD-D	Initiator - LOCA During Shutdown State Dd CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves) LHSI, LHSI/RHR Train 30 Overpressure Protection Safety Valve JNG30AA192, Premature Opening Operator Fails to Isolate RHR Flow Diversion (LOCA) in State D
48	1.612E-10	0.28	IE SD LOCA DD JNG13AA005CFO_ D-ALL JNG20AA192SPO OPF-ISORHRFD-D	Initiator - LOCA During Shutdown State Dd CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves) LHSI, LHSI/RHR Train 20 Overpressure Protection Safety Valve JNG20AA192, Premature Opening Operator Fails to Isolate RHR Flow Diversion (LOCA) in State D
49	1.539E-10	0.27	IE SD ULD DU D JNG13AA005CFO_ D-ALL KBA14AA004EFC OPF-ULD	Initiator - Uncontrolled Level Drop in Shutdown State Du (Demand) CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves) CVCS, Low Pressure Reducing Station Isolation MOV KBA14AA004, Fails to Close on Demand Operator Fails to Stop Draindown at Mid-Loop
50	1.539E-10	0.27	IE SD ULD CBD D JNG13AA005CFO_ D-ALL KBA14AA004EFC OPF-ULD	Initiator - Uncontrolled Level Drop in Shutdown State CBd (Demand) CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves) CVCS, Low Pressure Reducing Station Isolation MOV KBA14AA004, Fails to Close on Demand Operator Fails to Stop Draindown at Mid-Loop
51	1.504E-10	0.26	IE SD RHR CBU SD LOOP24+REC XKA10____DFR_D -ALL XKA50____DFS	Initiator - RHR in Power State CBU Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour CCF of EDGs to Run ELEC, SBO Diesel Generator XKA50, Fails to Start on Demand
52	1.504E-10	0.26	IE SD RHR CAD SD LOOP24+REC XKA10____DFR_D -ALL XKA50____DFS	Initiator - RHR in Power State CAD Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour CCF of EDGs to Run ELEC, SBO Diesel Generator XKA50, Fails to Start on Demand
53	1.477E-10	0.26	IE SD LOCA E JNG13AA005CFO_ D-ALL SLOCA24	Initiator - LOCA During Shutdown State E CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves) Small LOCA - 24 Hour

MCS Results

EPRDCSD1

SHUTDOWN

No.	Freq.	%	Event	Description
54	1.427E-10	0.25	IE SD RHR CBD	Initiator - RHR in Power State CBd
			OPF-XTDIVSBO-2H	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During SBO Considitions
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR_D -ALL	CCF of EDGs to Run
			XKA80____DFR	ELEC, SBO Diesel Generator XKA80, Fails to Run
55	1.312E-10	0.23	IE SD RHR CAU	Initiator - RHR in Power State CAu
			OPF-XTDIVSBO-2H	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During SBO Considitions
			SA-ESWS UHS4 SBO	Failure of SA-ESWS/UHS4 in SBO Conditions
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR_D -ALL	CCF of EDGs to Run
56	1.289E-10	0.22	IE SD RHR CBD	Initiator - RHR in Power State CBd
			BTD01_BAT__ST_D -ALL	CCF of Safety Related Batteries on Demand
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
57	1.252E-10	0.22	IE SD RHR CAD	Initiator - RHR in Power State CAd
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFS_D -ALL	CCF of EDGs to Start
58	1.252E-10	0.22	XKA50____DFR	ELEC, SBO Diesel Generator XKA50, Fails to Run
			IE SD RHR CBU	Initiator - RHR in Power State CBu
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
59	1.074E-10	0.19	XKA10____DFS_D -ALL	CCF of EDGs to Start
			XKA50____DFR	ELEC, SBO Diesel Generator XKA50, Fails to Run
			IE SD LOCA CBD	Initiator - LOCA During Shutdown State CBd
60	1.074E-10	0.19	JND20AA003CIR	MHSI, MHSI Pump 20 Discharge Manual CHECK Valve JND20AA003, Internal Rupture
			JNG13AA005CFO_ D-ALL	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves)
			OPF-ISORHRFD-CB	Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB
			IE SD LOCA CBD	Initiator - LOCA During Shutdown State CBd
			JND30AA003CIR	MHSI, MHSI Pump 30 Discharge Manual CHECK Valve JND30AA003, Internal Rupture
60	1.074E-10	0.19	JNG13AA005CFO_ D-ALL	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves)
			OPF-ISORHRFD-CB	Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB
			IE SD LOCA CBD	Initiator - LOCA During Shutdown State CBd

MCS Results

EPRDCSD1

SHUTDOWN

No.	Freq.	%	Event	Description
61	1.074E-10	0.19	IE SD LOCA CBD	Initiator - LOCA During Shutdown State CBd
			JND10AA003CIR	MHSI, MHSI Pump 10 Discharge Manual CHECK Valve JND10AA003, Internal Rupture
			JNG13AA005CFO_ D-ALL	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves)
			OPF-ISORHRFD-CB	Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB
62	1.070E-10	0.19	IE SD RHR CBU	Initiator - RHR in Power State CBU
			OPF-XTDIVSBO-2H	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During SBO Conditions
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR_D -ALL	CCF of EDGs to Run
			XKA80____DFR	ELEC, SBO Diesel Generator XKA80, Fails to Run
63	1.070E-10	0.19	IE SD RHR CAD	Initiator - RHR in Power State CAD
			OPF-XTDIVSBO-2H	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During SBO Conditions
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR_D -ALL	CCF of EDGs to Run
			XKA80____DFR	ELEC, SBO Diesel Generator XKA80, Fails to Run
64	1.013E-10	0.18	IE SD RHR CBD	Initiator - RHR in Power State CBd
			OPF-XTDIV-NSC	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions
			QKA10GH001_FS	SCWS, Train 1 Chiller Unit QKA10GH001, Fails to Start on Demand
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR_D -234	CCF of EDGs to Run
65	1.004E-10	0.17	IE SD RHR DU	Initiator - RHR in Power State Du
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR_D -ALL	CCF of EDGs to Run
			XKA50____DFR	ELEC, SBO Diesel Generator XKA50, Fails to Run
66	1.003E-10	0.17	XKA80____DFR	ELEC, SBO Diesel Generator XKA80, Fails to Run
			IE SD RHR CAU	Initiator - RHR in Power State CAU
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR_D -ALL	CCF of EDGs to Run
			XKA50____DFS	ELEC, SBO Diesel Generator XKA50, Fails to Start on Demand

MCS Results

EPRDCSD1

SHUTDOWN

No.	Freq.	%	Event	Description
67	9.665E-11	0.17	IE SD RHR CAD BTD01_BAT__ST_D SD LOOP24+REC	Initiator - RHR in Power State CAD CCF of Safety Related Batteries on Demand -ALL Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
68	9.665E-11	0.17	IE SD RHR DU BTD01_BAT__ST_D SD LOOP24+REC	Initiator - RHR in Power State Du CCF of Safety Related Batteries on Demand -ALL Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
69	9.665E-11	0.17	IE SD RHR CBU BTD01_BAT__ST_D SD LOOP24+REC	Initiator - RHR in Power State CBU CCF of Safety Related Batteries on Demand -ALL Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
70	8.346E-11	0.14	IE SD RHR CAU SD LOOP24+REC XKA10____DFS_D XKA50____DFR	Initiator - RHR in Power State CAU Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour CCF of EDGs to Start -ALL ELEC, SBO Diesel Generator XKA50, Fails to Run
71	8.137E-11	0.14	IE SD LOCA CBD JNA20AA191SPO JNK10AT001SPG_P OPF-ISORHRFD-CB	Initiator - LOCA During Shutdown State CBd RHR, LHSI Train 2 Safety Valve JNA20AA191, Premature Opening CCF of IRWST Sump Strainers - Plugged -ALL Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB
72	8.137E-11	0.14	IE SD LOCA CBD JNA30AA191SPO JNK10AT001SPG_P OPF-ISORHRFD-CB	Initiator - LOCA During Shutdown State CBd RHR, LHSI Train 3 Safety Valve JNA30AA191, Premature Opening CCF of IRWST Sump Strainers - Plugged -ALL Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB
73	8.137E-11	0.14	IE SD LOCA CBD JNG20AA192SPO JNK10AT001SPG_P OPF-ISORHRFD-CB	Initiator - LOCA During Shutdown State CBd LHSI, LHSI/RHR Train 20 Overpressure Protection Safety Valve JNG20AA192, Premature Opening CCF of IRWST Sump Strainers - Plugged -ALL Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB
74	8.137E-11	0.14	IE SD LOCA CBD JNG30AA192SPO JNK10AT001SPG_P OPF-ISORHRFD-CB	Initiator - LOCA During Shutdown State CBd LHSI, LHSI/RHR Train 30 Overpressure Protection Safety Valve JNG30AA192, Premature Opening CCF of IRWST Sump Strainers - Plugged -ALL Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB

MCS Results

EPRDCSD1

SHUTDOWN

No.	Freq.	%	Event	Description
75	8.137E-11	0.14	IE SD LOCA CBD	Initiator - LOCA During Shutdown State CBd
			JNG10AA192SPO	LHSI, LHSI/RHR Train 10 Overpressure Protection Safety Valve JNG10AA192, Premature Opening
			JNK10AT001SPG_P	CCF of IRWST Sump Strainers - Plugged -ALL
			OPF-ISORHRFD-CB	Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB
76	8.137E-11	0.14	IE SD LOCA CBD	Initiator - LOCA During Shutdown State CBd
			JNA10AA191SPO	RHR, LHSI Train 1 Safety Valve JNA10AA191, Premature Opening
			JNK10AT001SPG_P	CCF of IRWST Sump Strainers - Plugged -ALL
			OPF-ISORHRFD-CB	Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB
77	8.058E-11	0.14	IE SD LOCA DU	Initiator - LOCA During Shutdown State Du
			JND20AA003CIR	MHSI, MHSI Pump 20 Discharge Manual CHECK Valve JND20AA003, Internal Rupture
			JNG13AA005CFO_D-ALL	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves)
			OPF-ISORHRFD-D	Operator Fails to Isolate RHR Flow Diversion (LOCA) in State D
78	8.058E-11	0.14	IE SD LOCA DU	Initiator - LOCA During Shutdown State Du
			JND10AA003CIR	MHSI, MHSI Pump 10 Discharge Manual CHECK Valve JND10AA003, Internal Rupture
			JNG13AA005CFO_D-ALL	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves)
			OPF-ISORHRFD-D	Operator Fails to Isolate RHR Flow Diversion (LOCA) in State D
79	8.058E-11	0.14	IE SD LOCA CBU	Initiator - LOCA During Shutdown State CBU
			JND20AA003CIR	MHSI, MHSI Pump 20 Discharge Manual CHECK Valve JND20AA003, Internal Rupture
			JNG13AA005CFO_D-ALL	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves)
			OPF-ISORHRFD-CB	Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB
80	8.058E-11	0.14	IE SD LOCA CBU	Initiator - LOCA During Shutdown State CBU
			JND10AA003CIR	MHSI, MHSI Pump 10 Discharge Manual CHECK Valve JND10AA003, Internal Rupture
			JNG13AA005CFO_D-ALL	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves)
			OPF-ISORHRFD-CB	Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB
81	8.004E-11	0.14	IE SD RHR CBD	Initiator - RHR in Power State CBd
			OPD-SAC2H/SAC1H	Dependency (MED) Between OAs for Starting HVAC Maintenance Trains Recovering Room Cooling Locally
			OPF-SAC-1H	Operator Fails to Start Maintenance HVAC Trains After Failure of Normal SAC Safety Train
			SAC01AN001EFR_D-ALL	CCF to Run Normal Air Supply Fans

MCS Results

EPRDCSD1

SHUTDOWN

No.	Freq.	%	Event	Description
82	8.004E-11	0.14	IE SD RHR CBD	Initiator - RHR in Power State CBd
			OPD-SAC2H/SAC1H	Dependency (MED) Between OAs for Starting HVAC Maintenance Trains Recovering Room Cooling Locally
			OPF-SAC-1H	Operator Fails to Start Maintenance HVAC Trains After Failure of Normal SAC Safety Train
			SAC31AN001EFR_ D-ALL	CCF to Run Normal Air Exhaust Fans
83	7.599E-11	0.13	IE SD RHR CBU	Initiator - RHR in Power State CBU
			OPF-XTDIV-NSC	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions
			QKA10GH001_FS	SCWS, Train 1 Chiller Unit QKA10GH001, Fails to Start on Demand
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR_D -234	CCF of EDGs to Run
84	7.599E-11	0.13	IE SD RHR CAD	Initiator - RHR in Power State CAD
			OPF-XTDIV-NSC	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions
			QKA10GH001_FS	SCWS, Train 1 Chiller Unit QKA10GH001, Fails to Start on Demand
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR_D -234	CCF of EDGs to Run
85	7.521E-11	0.13	IE SD LOCA CBD	Initiator - LOCA During Shutdown State CBd
			JNG13AA005CFO_ D-ALL	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves)
			JNG20AA004EOP	LHSI, LHSI Train 2 to Tangential Miniflow Motor Operated CV JNG20AA004, Fails to Remain Closed (SO)
			OPF-ISORHRFD-CB	Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB
86	7.521E-11	0.13	IE SD LOCA CBD	Initiator - LOCA During Shutdown State CBd
			JNG13AA005CFO_ D-ALL	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves)
			JNG30AA003EOP	LHSI, LHSI Trn 3 to Radial Miniflow Motor Operated Check Vlv JNG30AA003, Fails to Remain Closed (SO)
			OPF-ISORHRFD-CB	Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB
87	7.521E-11	0.13	IE SD LOCA CBD	Initiator - LOCA During Shutdown State CBd
			JNG13AA005CFO_ D-ALL	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves)
			JNG30AA001EOP	LHSI, LHSI Pump 30 Suction from IRWST MOV JNG30AA001, Fails to Remain Closed (SO)
			OPF-ISOIRWSTFD- CB	Operator Fails to Isolate RHR Suction to IRWST (Valve JNGX0AA001) in CB

MCS Results

EPRDCSD1

SHUTDOWN

No.	Freq.	%	Event	Description
88	7.521E-11	0.13	IE SD LOCA CBD	Initiator - LOCA During Shutdown State CBd
			JNG13AA005CFO_ D-ALL	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves)
			JNG30AA004EOP	LHSI, LHSI Train 3 to Tangential Miniflow Motor Operated CV JNG30AA004, Fails to Remain Closed (SO)
			OPF-ISORHRFD-CB	Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB
89	7.521E-11	0.13	IE SD LOCA CBD	Initiator - LOCA During Shutdown State CBd
			JNG10AA003EOP	LHSI, LHSI Trn 1 to Radial Miniflow Motor Operated Check Vlv JNG10AA003, Fails to Remain Closed (SO)
			JNG13AA005CFO_ D-ALL	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves)
			OPF-ISORHRFD-CB	Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB
90	7.521E-11	0.13	IE SD LOCA CBD	Initiator - LOCA During Shutdown State CBd
			JNG13AA005CFO_ D-ALL	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves)
			JNG20AA001EOP	LHSI, LHSI Pump 20 Suction from IRWST MOV JNG20AA001, Fails to Remain Closed (SO)
			OPF-ISOIRWSTFD- CB	Operator Fails to Isolate RHR Suction to IRWST (Valve JNGX0AA001) in CB
91	7.521E-11	0.13	IE SD LOCA CBD	Initiator - LOCA During Shutdown State CBd
			JNG10AA001EOP	LHSI, LHSI Pump 10 Suction from IRWST MOV JNG10AA001, Fails to Remain Closed (SO)
			JNG13AA005CFO_ D-ALL	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves)
			OPF-ISOIRWSTFD- CB	Operator Fails to Isolate RHR Suction to IRWST (Valve JNGX0AA001) in CB
92	7.521E-11	0.13	IE SD LOCA CBD	Initiator - LOCA During Shutdown State CBd
			JNG10AA004EOP	LHSI, LHSI Trn 1 to Radial Miniflow Motor Operated Check Vlv JNG10AA004, Fails to Remain Closed (SO)
			JNG13AA005CFO_ D-ALL	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves)
			OPF-ISORHRFD-CB	Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB
93	7.521E-11	0.13	IE SD LOCA CBD	Initiator - LOCA During Shutdown State CBd
			JNG13AA005CFO_ D-ALL	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves)
			JNG20AA003EOP	LHSI, LHSI Trn 2 to Radial Miniflow Motor Operated Check Vlv JNG20AA003, Fails to Remain Closed (SO)
			OPF-ISORHRFD-CB	Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB
94	7.136E-11	0.12	IE SD RHR CAU	Initiator - RHR in Power State CAu
			OPF-XTDIVSBO-2H	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During SBO Considitions
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR_D -ALL	CCF of EDGs to Run
			XKA80____DFR	ELEC, SBO Diesel Generator XKA80, Fails to Run

MCS Results

EPRDCSD1

SHUTDOWN

No.	Freq.	%	Event	Description
95	7.114E-11	0.12	IE SD RHR CBD SD LOOP24+REC XKA10____DFR_D -ALL XKA50____DFR_B -ALL	Initiator - RHR in Power State CBd Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour CCF of EDGs to Run CCF of SBO DGs to Run
96	6.864E-11	0.12	IE SD RHR ISLOCA CBD OPF-ISORHRBRK PAS RHR TR3 PIPE BRK	RHR ISLOCA During Shutdown State CBd Operator Fails to Isolate RHR Pipe Break Process Automation System (PAS) Fails (Estimate) Pipe Break in RHR Train 3
97	6.864E-11	0.12	IE SD RHR ISLOCA CBD OPF-ISORHRBRK PAS RHR TR1 PIPE BRK	RHR ISLOCA During Shutdown State CBd Operator Fails to Isolate RHR Pipe Break Process Automation System (PAS) Fails (Estimate) Pipe Break in RHR Train 1
98	6.864E-11	0.12	IE SD RHR ISLOCA CBD OPF-ISORHRBRK PAS RHR TR2 PIPE BRK	RHR ISLOCA During Shutdown State CBd Operator Fails to Isolate RHR Pipe Break Process Automation System (PAS) Fails (Estimate) Pipe Break in RHR Train 2
99	6.444E-11	0.11	IE SD RHR CAU BTD01_BAT__ST_D -ALL SD LOOP24+REC	Initiator - RHR in Power State CAu CCF of Safety Related Batteries on Demand Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
100	6.341E-11	0.11	IE SD ULD DU D KBA14AA004EFC KBA14AA106PBNS OPE-ISOCSLPRS	Initiator - Uncontrolled Level Drop in Shutdown State Du (Demand) CVCS, Low Pressure Reducing Station Isolation MOV KBA14AA004, Fails to Close on Demand CVCS, CVCS LP Redu Stn MOV KBA14AA106, PAC B Priority Module (Type PC10) Fails (Non-Self-Monitored) Operator Fails to Isolate the CVCS Low Pressure Reducing Station
101	6.341E-11	0.11	IE SD ULD CBD D KBA14AA004EFC KBA14AA106PBNS OPE-ISOCSLPRS	Initiator - Uncontrolled Level Drop in Shutdown State CBd (Demand) CVCS, Low Pressure Reducing Station Isolation MOV KBA14AA004, Fails to Close on Demand CVCS, CVCS LP Redu Stn MOV KBA14AA106, PAC B Priority Module (Type PC10) Fails (Non-Self-Monitored) Operator Fails to Isolate the CVCS Low Pressure Reducing Station

MCS Results

EPRDCSD1

SHUTDOWN

No.	Freq.	%	Event	Description
102	6.341E-11	0.11	IE SD ULD CBD D	Initiator - Uncontrolled Level Drop in Shutdown State CBd (Demand)
			KBA14AA004PANS	CVCS, LP Reducing Iso MOV KBA14AA004, PAC A Priority Module (Type AV42) Fails (Non-Self-Monitored)
			KBA14AA106EFC	CVCS, CVCS Low Power Reducing Station MOV KBA14AA106, Fails to Close on Demand
			OPE-ISOCSLPRS	Operator Fails to Isolate the CVCS Low Pressure Reducing Station
103	6.341E-11	0.11	IE SD ULD DU D	Initiator - Uncontrolled Level Drop in Shutdown State Du (Demand)
			KBA14AA004PANS	CVCS, LP Reducing Iso MOV KBA14AA004, PAC A Priority Module (Type AV42) Fails (Non-Self-Monitored)
			KBA14AA106EFC	CVCS, CVCS Low Power Reducing Station MOV KBA14AA106, Fails to Close on Demand
			OPE-ISOCSLPRS	Operator Fails to Isolate the CVCS Low Pressure Reducing Station
104	6.265E-11	0.11	IE SD RHR CBD	Initiator - RHR in Power State CBd
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR_D -134	CCF of EDGs to Run
			XKA20____DFR	ELEC, Emergency Diesel Generator XKA20, Fails to Run
			XKA50____DFR	ELEC, SBO Diesel Generator XKA50, Fails to Run
105	6.265E-11	0.11	IE SD RHR CBD	Initiator - RHR in Power State CBd
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR_D -124	CCF of EDGs to Run
			XKA30____DFR	ELEC, Emergency Diesel Generator XKA30, Fails to Run
			XKA50____DFR	ELEC, SBO Diesel Generator XKA50, Fails to Run
106	6.265E-11	0.11	IE SD RHR CBD	Initiator - RHR in Power State CBd
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR	ELEC, Emergency Diesel Generator XKA10, Fails to Run
			XKA10____DFR_D -234	CCF of EDGs to Run
			XKA50____DFR	ELEC, SBO Diesel Generator XKA50, Fails to Run
107	6.265E-11	0.11	IE SD RHR CBD	Initiator - RHR in Power State CBd
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR_D -123	CCF of EDGs to Run
			XKA40____DFR	ELEC, Emergency Diesel Generator XKA40, Fails to Run
			XKA50____DFR	ELEC, SBO Diesel Generator XKA50, Fails to Run
108	6.103E-11	0.11	IE SD LOCA CBU	Initiator - LOCA During Shutdown State CBU
			JNG10AA192SPO	LHSI, LHSI/RHR Train 10 Overpressure Protection Safety Valve JNG10AA192, Premature Opening
			JNK10AT001SPG_P -ALL	CCF of IRWST Sump Strainers - Plugged
			OPF-ISORHRFD-CB	Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB

MCS Results

EPRDCSD1

SHUTDOWN

No.	Freq.	%	Event	Description
109	6.103E-11	0.11	IE SD LOCA CBU JNA10AA191SPO JNK10AT001SPG_P -ALL OPF-ISORHRFD-CB	Initiator - LOCA During Shutdown State CBU RHR, LHSI Train 1 Safety Valve JNA10AA191, Premature Opening CCF of IRWST Sump Strainers - Plugged Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB
110	6.103E-11	0.11	IE SD LOCA CBU JNG20AA192SPO JNK10AT001SPG_P -ALL OPF-ISORHRFD-CB	Initiator - LOCA During Shutdown State CBU LHSI, LHSI/RHR Train 20 Overpressure Protection Safety Valve JNG20AA192, Premature Opening CCF of IRWST Sump Strainers - Plugged Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB
111	6.103E-11	0.11	IE SD LOCA DU JNA10AA191SPO JNK10AT001SPG_P -ALL OPF-ISORHRFD-D	Initiator - LOCA During Shutdown State Du RHR, LHSI Train 1 Safety Valve JNA10AA191, Premature Opening CCF of IRWST Sump Strainers - Plugged Operator Fails to Isolate RHR Flow Diversion (LOCA) in State D
112	6.103E-11	0.11	IE SD LOCA DU JNA20AA191SPO JNK10AT001SPG_P -ALL OPF-ISORHRFD-D	Initiator - LOCA During Shutdown State Du RHR, LHSI Train 2 Safety Valve JNA20AA191, Premature Opening CCF of IRWST Sump Strainers - Plugged Operator Fails to Isolate RHR Flow Diversion (LOCA) in State D
113	6.103E-11	0.11	IE SD LOCA CBU JNA20AA191SPO JNK10AT001SPG_P -ALL OPF-ISORHRFD-CB	Initiator - LOCA During Shutdown State CBU RHR, LHSI Train 2 Safety Valve JNA20AA191, Premature Opening CCF of IRWST Sump Strainers - Plugged Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB
114	6.103E-11	0.11	IE SD LOCA DU JNG20AA192SPO JNK10AT001SPG_P -ALL OPF-ISORHRFD-D	Initiator - LOCA During Shutdown State Du LHSI, LHSI/RHR Train 20 Overpressure Protection Safety Valve JNG20AA192, Premature Opening CCF of IRWST Sump Strainers - Plugged Operator Fails to Isolate RHR Flow Diversion (LOCA) in State D
115	6.103E-11	0.11	IE SD LOCA DU JNG10AA192SPO JNK10AT001SPG_P -ALL OPF-ISORHRFD-D	Initiator - LOCA During Shutdown State Du LHSI, LHSI/RHR Train 10 Overpressure Protection Safety Valve JNG10AA192, Premature Opening CCF of IRWST Sump Strainers - Plugged Operator Fails to Isolate RHR Flow Diversion (LOCA) in State D

MCS Results

EPRDCSD1

SHUTDOWN

No.	Freq.	%	Event	Description
116	6.003E-11	0.10	IE SD RHR CAD	Initiator - RHR in Power State CAD
			OPD-SAC2H/SAC1H	Dependency (MED) Between OAs for Starting HVAC Maintenance Trains Recovering Room Cooling Locally
			OPF-SAC-1H	Operator Fails to Start Maintenance HVAC Trains After Failure of Normal SAC Safety Train
			SAC31AN001EFR_ D-ALL	CCF to Run Normal Air Exhaust Fans
117	6.003E-11	0.10	IE SD RHR CBU	Initiator - RHR in Power State CBU
			OPD-SAC2H/SAC1H	Dependency (MED) Between OAs for Starting HVAC Maintenance Trains Recovering Room Cooling Locally
			OPF-SAC-1H	Operator Fails to Start Maintenance HVAC Trains After Failure of Normal SAC Safety Train
			SAC01AN001EFR_ D-ALL	CCF to Run Normal Air Supply Fans
118	6.003E-11	0.10	IE SD RHR CBU	Initiator - RHR in Power State CBU
			OPD-SAC2H/SAC1H	Dependency (MED) Between OAs for Starting HVAC Maintenance Trains Recovering Room Cooling Locally
			OPF-SAC-1H	Operator Fails to Start Maintenance HVAC Trains After Failure of Normal SAC Safety Train
			SAC31AN001EFR_ D-ALL	CCF to Run Normal Air Exhaust Fans
119	6.003E-11	0.10	IE SD RHR DU	Initiator - RHR in Power State Du
			OPD-SAC2H/SAC1H	Dependency (MED) Between OAs for Starting HVAC Maintenance Trains Recovering Room Cooling Locally
			OPF-SAC-1H	Operator Fails to Start Maintenance HVAC Trains After Failure of Normal SAC Safety Train
			SAC31AN001EFR_ D-ALL	CCF to Run Normal Air Exhaust Fans
120	6.003E-11	0.10	IE SD RHR DU	Initiator - RHR in Power State Du
			OPD-SAC2H/SAC1H	Dependency (MED) Between OAs for Starting HVAC Maintenance Trains Recovering Room Cooling Locally
			OPF-SAC-1H	Operator Fails to Start Maintenance HVAC Trains After Failure of Normal SAC Safety Train
			SAC01AN001EFR_ D-ALL	CCF to Run Normal Air Supply Fans
121	6.003E-11	0.10	IE SD RHR CAD	Initiator - RHR in Power State CAD
			OPD-SAC2H/SAC1H	Dependency (MED) Between OAs for Starting HVAC Maintenance Trains Recovering Room Cooling Locally
			OPF-SAC-1H	Operator Fails to Start Maintenance HVAC Trains After Failure of Normal SAC Safety Train
			SAC01AN001EFR_ D-ALL	CCF to Run Normal Air Supply Fans
122	5.640E-11	0.10	IE SD LOCA DU	Initiator - LOCA During Shutdown State Du
			JNG10AA001EOP	LHSI, LHSI Pump 10 Suction from IRWST MOV JNG10AA001, Fails to Remain Closed (SO)
			JNG13AA005CFO_ D-ALL	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves)
			OPF-ISOIRWSTFD- D	Operator Fails to Isolate RHR Suction to IRWST (Valve JNGX0AA001) in D

MCS Results

EPRDCSD1

SHUTDOWN

No.	Freq.	%	Event	Description
123	5.640E-11	0.10	IE SD LOCA CBU	Initiator - LOCA During Shutdown State CBU
			JNG13AA005CFO_ D-ALL	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves)
			JNG20AA003EOP	LHSI, LHSI Trn 2 to Radial Miniflow Motor Operated Check Vlv JNG20AA003, Fails to Remain Closed (SO)
			OPF-ISORHRFD-CB	Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB
124	5.640E-11	0.10	IE SD LOCA CBU	Initiator - LOCA During Shutdown State CBU
			JNG10AA004EOP	LHSI, LHSI Trn 1 to Radial Miniflow Motor Operated Check Vlv JNG10AA004, Fails to Remain Closed (SO)
			JNG13AA005CFO_ D-ALL	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves)
			OPF-ISORHRFD-CB	Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB
125	5.640E-11	0.10	IE SD LOCA DU	Initiator - LOCA During Shutdown State Du
			JNG13AA005CFO_ D-ALL	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves)
			JNG20AA003EOP	LHSI, LHSI Trn 2 to Radial Miniflow Motor Operated Check Vlv JNG20AA003, Fails to Remain Closed (SO)
			OPF-ISORHRFD-D	Operator Fails to Isolate RHR Flow Diversion (LOCA) in State D
126	5.640E-11	0.10	IE SD LOCA CAD	Initiator - LOCA During Shutdown State CA
			JNG13AA005CFO_ D-ALL	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves)
			JNG20AA001EOP	LHSI, LHSI Pump 20 Suction from IRWST MOV JNG20AA001, Fails to Remain Closed (SO)
			OPF-ISOIRWSTFD-CA	Operator Fails to Isolate RHR Suction to IRWST (Valve JNGX0AA001) in CA
127	5.640E-11	0.10	IE SD LOCA DU	Initiator - LOCA During Shutdown State Du
			JNG13AA005CFO_ D-ALL	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves)
			JNG20AA001EOP	LHSI, LHSI Pump 20 Suction from IRWST MOV JNG20AA001, Fails to Remain Closed (SO)
			OPF-ISOIRWSTFD-D	Operator Fails to Isolate RHR Suction to IRWST (Valve JNGX0AA001) in D
128	5.640E-11	0.10	IE SD LOCA CBU	Initiator - LOCA During Shutdown State CBU
			JNG13AA005CFO_ D-ALL	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves)
			JNG20AA001EOP	LHSI, LHSI Pump 20 Suction from IRWST MOV JNG20AA001, Fails to Remain Closed (SO)
			OPF-ISOIRWSTFD-CB	Operator Fails to Isolate RHR Suction to IRWST (Valve JNGX0AA001) in CB
129	5.640E-11	0.10	IE SD LOCA DU	Initiator - LOCA During Shutdown State Du
			JNG10AA003EOP	LHSI, LHSI Trn 1 to Radial Miniflow Motor Operated Check Vlv JNG10AA003, Fails to Remain Closed (SO)
			JNG13AA005CFO_ D-ALL	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves)
			OPF-ISORHRFD-D	Operator Fails to Isolate RHR Flow Diversion (LOCA) in State D

MCS Results

EPRDCSD1

SHUTDOWN

No.	Freq.	%	Event	Description
130	5.640E-11	0.10	IE SD LOCA DU	Initiator - LOCA During Shutdown State Du
			JNG10AA004EOP	LHSI, LHSI Trn 1 to Radial Miniflow Motor Operated Check Vlv JNG10AA004, Fails to Remain Closed (SO)
			JNG13AA005CFO_D-ALL	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves)
			OPF-ISORHRFD-D	Operator Fails to Isolate RHR Flow Diversion (LOCA) in State D
131	5.640E-11	0.10	IE SD LOCA CAD	Initiator - LOCA During Shutdown State CA
			JNG13AA005CFO_D-ALL	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves)
			JNG30AA001EOP	LHSI, LHSI Pump 30 Suction from IRWST MOV JNG30AA001, Fails to Remain Closed (SO)
			OPF-ISOIRWSTFD-CA	Operator Fails to Isolate RHR Suction to IRWST (Valve JNGX0AA001) in CA
132	5.640E-11	0.10	IE SD LOCA CBU	Initiator - LOCA During Shutdown State CBU
			JNG10AA003EOP	LHSI, LHSI Trn 1 to Radial Miniflow Motor Operated Check Vlv JNG10AA003, Fails to Remain Closed (SO)
			JNG13AA005CFO_D-ALL	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves)
			OPF-ISORHRFD-CB	Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB
133	5.640E-11	0.10	IE SD LOCA DU	Initiator - LOCA During Shutdown State Du
			JNG13AA005CFO_D-ALL	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves)
			JNG20AA004EOP	LHSI, LHSI Train 2 to Tangential Miniflow Motor Operated CV JNG20AA004, Fails to Remain Closed (SO)
			OPF-ISORHRFD-D	Operator Fails to Isolate RHR Flow Diversion (LOCA) in State D
134	5.640E-11	0.10	IE SD LOCA CBU	Initiator - LOCA During Shutdown State CBU
			JNG13AA005CFO_D-ALL	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves)
			JNG20AA004EOP	LHSI, LHSI Train 2 to Tangential Miniflow Motor Operated CV JNG20AA004, Fails to Remain Closed (SO)
			OPF-ISORHRFD-CB	Operator Fails to Isolate RHR Flow Diversion (LOCA) in State CB
135	5.640E-11	0.10	IE SD LOCA CBU	Initiator - LOCA During Shutdown State CBU
			JNG10AA001EOP	LHSI, LHSI Pump 10 Suction from IRWST MOV JNG10AA001, Fails to Remain Closed (SO)
			JNG13AA005CFO_D-ALL	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves)
			OPF-ISOIRWSTFD-CB	Operator Fails to Isolate RHR Suction to IRWST (Valve JNGX0AA001) in CB
136	5.640E-11	0.10	IE SD LOCA CAD	Initiator - LOCA During Shutdown State CA
			JNG10AA001EOP	LHSI, LHSI Pump 10 Suction from IRWST MOV JNG10AA001, Fails to Remain Closed (SO)
			JNG13AA005CFO_D-ALL	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves)
			OPF-ISOIRWSTFD-CA	Operator Fails to Isolate RHR Suction to IRWST (Valve JNGX0AA001) in CA

MCS Results

EPRDCSD1

SHUTDOWN

No.	Freq.	%	Event	Description
137	5.372E-11	0.09	IE SD RHR CBD	Initiator - RHR in Power State CBd
			LAS11AP001EFR	EFWS, Train 1 Motor Driven Pump LAS11AP001, Fails to Run
			SA-ESWS UHS4 SBO	Failure of SA-ESWS/UHS4 in SBO Conditions
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR_D -ALL	CCF of EDGs to Run
138	5.336E-11	0.09	IE SD RHR CBU	Initiator - RHR in Power State CBU
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR_D -ALL	CCF of EDGs to Run
			XKA50____DFR_B -ALL	CCF of SBO DGs to Run
139	5.336E-11	0.09	IE SD RHR DU	Initiator - RHR in Power State Du
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR_D -ALL	CCF of EDGs to Run
			XKA50____DFR_B -ALL	CCF of SBO DGs to Run
140	5.336E-11	0.09	IE SD RHR CAD	Initiator - RHR in Power State CAAd
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR_D -ALL	CCF of EDGs to Run
			XKA50____DFR_B -ALL	CCF of SBO DGs to Run
141	5.292E-11	0.09	IE SD ULD CBD D	Initiator - Uncontrolled Level Drop in Shutdown State CBd (Demand)
			JNG13AA005CFO_ D-ALL	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves)
			KBA14AA004EFC	CVCS, Low Pressure Reducing Station Isolation MOV KBA14AA004, Fails to Close on Demand
			KBA14AA106EFC	CVCS, CVCS Low Power Reducing Station MOV KBA14AA106, Fails to Close on Demand
142	5.292E-11	0.09	IE SD ULD DU D	Initiator - Uncontrolled Level Drop in Shutdown State Du (Demand)
			JNG13AA005CFO_ D-ALL	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves)
			KBA14AA004EFC	CVCS, Low Pressure Reducing Station Isolation MOV KBA14AA004, Fails to Close on Demand
			KBA14AA106EFC	CVCS, CVCS Low Power Reducing Station MOV KBA14AA106, Fails to Close on Demand
143	5.148E-11	0.09	IE SD RHR ISLOCA CBU	RHR ISLOCA During Shutdown State CBU
			OPF-ISORHRBRK	Operator Fails to Isolate RHR Pipe Break
			PAS	Process Automation System (PAS) Fails (Estimate)
			RHR TR1 PIPE BRK	Pipe Break in RHR Train 1

MCS Results

EPRDCSD1

SHUTDOWN

No.	Freq.	%	Event	Description
144	5.148E-11	0.09	IE SD RHR ISLOCA CAD OPF-ISORHRBRK PAS RHR TR1 PIPE BRK	RHR ISLOCA During Shutdown State CA _d 2 Operator Fails to Isolate RHR Pipe Break Process Automation System (PAS) Fails (Estimate) Pipe Break in RHR Train 1
145	5.148E-11	0.09	IE SD RHR ISLOCA DU OPF-ISORHRBRK PAS RHR TR1 PIPE BRK	RHR ISLOCA During Shutdown State Du Operator Fails to Isolate RHR Pipe Break Process Automation System (PAS) Fails (Estimate) Pipe Break in RHR Train 1
146	5.148E-11	0.09	IE SD RHR ISLOCA CAD OPF-ISORHRBRK PAS RHR TR4 PIPE BRK	RHR ISLOCA During Shutdown State CA _d 2 Operator Fails to Isolate RHR Pipe Break Process Automation System (PAS) Fails (Estimate) Pipe Break in RHR Train 4
147	5.148E-11	0.09	IE SD RHR ISLOCA CAD OPF-ISORHRBRK PAS RHR TR3 PIPE BRK	RHR ISLOCA During Shutdown State CA _d 2 Operator Fails to Isolate RHR Pipe Break Process Automation System (PAS) Fails (Estimate) Pipe Break in RHR Train 3
148	5.148E-11	0.09	IE SD RHR ISLOCA DU OPF-ISORHRBRK PAS RHR TR2 PIPE BRK	RHR ISLOCA During Shutdown State Du Operator Fails to Isolate RHR Pipe Break Process Automation System (PAS) Fails (Estimate) Pipe Break in RHR Train 2
149	5.148E-11	0.09	IE SD RHR ISLOCA CAD OPF-ISORHRBRK PAS RHR TR2 PIPE BRK	RHR ISLOCA During Shutdown State CA _d 2 Operator Fails to Isolate RHR Pipe Break Process Automation System (PAS) Fails (Estimate) Pipe Break in RHR Train 2
150	5.148E-11	0.09	IE SD RHR ISLOCA CBU OPF-ISORHRBRK PAS RHR TR2 PIPE BRK	RHR ISLOCA During Shutdown State CB _u Operator Fails to Isolate RHR Pipe Break Process Automation System (PAS) Fails (Estimate) Pipe Break in RHR Train 2

MCS Results

EPRDCSD1

SHUTDOWN

No.	Freq.	%	Event	Description
151	5.066E-11	0.09	IE SD RHR CAU	Initiator - RHR in Power State CAU
			OPF-XTDIV-NSC	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions
			QKA10GH001_FS	SCWS, Train 1 Chiller Unit QKA10GH001, Fails to Start on Demand
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR_D -234	CCF of EDGs to Run
152	4.977E-11	0.09	IE SD RHR CBD	Initiator - RHR in Power State CBd
			OPD-SAC2H/SAC1H	Dependency (MED) Between OAs for Starting HVAC Maintenance Trains Recovering Room Cooling Locally
			OPF-SAC-1H	Operator Fails to Start Maintenance HVAC Trains After Failure of Normal SAC Safety Train
			SAC31AN001EFR_ D-123	CCF to Run Normal Air Exhaust Fans
153	4.977E-11	0.09	IE SD RHR CBD	Initiator - RHR in Power State CBd
			OPD-SAC2H/SAC1H	Dependency (MED) Between OAs for Starting HVAC Maintenance Trains Recovering Room Cooling Locally
			OPF-SAC-1H	Operator Fails to Start Maintenance HVAC Trains After Failure of Normal SAC Safety Train
			SAC01AN001EFR_ D-123	CCF to Run Normal Air Supply Fans
154	4.699E-11	0.08	IE SD RHR CBU	Initiator - RHR in Power State CBU
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR_D -123	CCF of EDGs to Run
			XKA40____DFR	ELEC, Emergency Diesel Generator XKA40, Fails to Run
			XKA50____DFR	ELEC, SBO Diesel Generator XKA50, Fails to Run
155	4.699E-11	0.08	IE SD RHR CAD	Initiator - RHR in Power State CAD
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR_D -123	CCF of EDGs to Run
			XKA40____DFR	ELEC, Emergency Diesel Generator XKA40, Fails to Run
			XKA50____DFR	ELEC, SBO Diesel Generator XKA50, Fails to Run
156	4.699E-11	0.08	IE SD RHR CAD	Initiator - RHR in Power State CAD
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR	ELEC, Emergency Diesel Generator XKA10, Fails to Run
			XKA10____DFR_D -234	CCF of EDGs to Run
			XKA50____DFR	ELEC, SBO Diesel Generator XKA50, Fails to Run

MCS Results

EPRDCSD1

SHUTDOWN

No.	Freq.	%	Event	Description
157	4.699E-11	0.08	IE SD RHR CBU	Initiator - RHR in Power State CBU
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR_D -134	CCF of EDGs to Run
			XKA20____DFR	ELEC, Emergency Diesel Generator XKA20, Fails to Run
			XKA50____DFR	ELEC, SBO Diesel Generator XKA50, Fails to Run
158	4.699E-11	0.08	IE SD RHR CBU	Initiator - RHR in Power State CBU
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR_D -124	CCF of EDGs to Run
			XKA30____DFR	ELEC, Emergency Diesel Generator XKA30, Fails to Run
			XKA50____DFR	ELEC, SBO Diesel Generator XKA50, Fails to Run
159	4.699E-11	0.08	IE SD RHR CBU	Initiator - RHR in Power State CBU
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR	ELEC, Emergency Diesel Generator XKA10, Fails to Run
			XKA10____DFR_D -234	CCF of EDGs to Run
			XKA50____DFR	ELEC, SBO Diesel Generator XKA50, Fails to Run
160	4.699E-11	0.08	IE SD RHR CAD	Initiator - RHR in Power State CAD
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR_D -134	CCF of EDGs to Run
			XKA20____DFR	ELEC, Emergency Diesel Generator XKA20, Fails to Run
			XKA50____DFR	ELEC, SBO Diesel Generator XKA50, Fails to Run
161	4.699E-11	0.08	IE SD RHR CAD	Initiator - RHR in Power State CAD
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR_D -124	CCF of EDGs to Run
			XKA30____DFR	ELEC, Emergency Diesel Generator XKA30, Fails to Run
			XKA50____DFR	ELEC, SBO Diesel Generator XKA50, Fails to Run
162	4.477E-11	0.08	IE SD ULD CBD D	Initiator - Uncontrolled Level Drop in Shutdown State CBd (Demand)
			JNG13AA005CFO_ D-ALL	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves)
			OPF-ULD	Operator Fails to Stop Draindown at Mid-Loop
			PAS	Process Automation System (PAS) Fails (Estimate)
163	4.477E-11	0.08	IE SD ULD DU D	Initiator - Uncontrolled Level Drop in Shutdown State Du (Demand)
			JNG13AA005CFO_ D-ALL	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves)
			OPF-ULD	Operator Fails to Stop Draindown at Mid-Loop
			PAS	Process Automation System (PAS) Fails (Estimate)

MCS Results

EPRDCSD1

SHUTDOWN

No.	Freq.	%	Event	Description
164	4.068E-11	0.07	IE SD RHR DU	Initiator - RHR in Power State Du
			JNG13AA005CFO_D-ALL	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves)
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA40_____DFR	ELEC, Emergency Diesel Generator XKA40, Fails to Run
165	4.029E-11	0.07	IE SD RHR CAD	Initiator - RHR in Power State CA d
			LAS11AP001EFR	EFWS, Train 1 Motor Driven Pump LAS11AP001, Fails to Run
			SA-ESWS UHS4 SBO	Failure of SA-ESWS/UHS4 in SBO Conditions
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10_____DFR_D-ALL	CCF of EDGs to Run
166	4.029E-11	0.07	IE SD RHR CBU	Initiator - RHR in Power State CBU
			LAS11AP001EFR	EFWS, Train 1 Motor Driven Pump LAS11AP001, Fails to Run
			SA-ESWS UHS4 SBO	Failure of SA-ESWS/UHS4 in SBO Conditions
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10_____DFR_D-ALL	CCF of EDGs to Run
167	4.002E-11	0.07	IE SD RHR CAU	Initiator - RHR in Power State CAU
			OPD-SAC2H/SAC1H	Dependency (MED) Between OAs for Starting HVAC Maintenance Trains Recovering Room Cooling Locally
			OPF-SAC-1H	Operator Fails to Start Maintenance HVAC Trains After Failure of Normal SAC Safety Train
			SAC01AN001EFR_D-ALL	CCF to Run Normal Air Supply Fans
168	4.002E-11	0.07	IE SD RHR CAU	Initiator - RHR in Power State CAU
			OPD-SAC2H/SAC1H	Dependency (MED) Between OAs for Starting HVAC Maintenance Trains Recovering Room Cooling Locally
			OPF-SAC-1H	Operator Fails to Start Maintenance HVAC Trains After Failure of Normal SAC Safety Train
			SAC31AN001EFR_D-ALL	CCF to Run Normal Air Exhaust Fans
169	3.846E-11	0.07	IE SD RHR CBD	Initiator - RHR in Power State CBd
			OPD-SAC2H/SAC1H	Dependency (MED) Between OAs for Starting HVAC Maintenance Trains Recovering Room Cooling Locally
			OPF-SAC-1H	Operator Fails to Start Maintenance HVAC Trains After Failure of Normal SAC Safety Train
			QKA10AP107EFR_D-ALL	CCF of SCWS Pumps to Run
170	3.809E-11	0.07	IE SD RHR DU	Initiator - RHR in Power State Du
			1.270E-07 KAA10AP001EFRS D-ALL	CCF of the CCWS Pumps to Run
			OPF-LHSIRHR-DU	Operator Fails to Start LHSI Pump in DU, given a loss of RHR

MCS Results

EPRDCSD1

SHUTDOWN

No.	Freq.	%	Event	Description
171	3.777E-11	0.07	IE SD RHR ISLOCA E	RHR ISLOCA During Shutdown State E
			JNA10AA001EFC	RHR, LHSI Pump 10 Hot Leg Isolation MOV JNA10AA001, Fails to Close on Demand
			JNA10AA002EFC	RHR, LHSI Pump 10 Hot Leg Isolation MOV JNA10AA002, Fails to Close on Demand
			RHR TR1 PIPE BRK	Pipe Break in RHR Train 1
172	3.777E-11	0.07	IE SD RHR ISLOCA E	RHR ISLOCA During Shutdown State E
			JNA20AA001EFC	RHR, LHSI Pump 20 Hot Leg Isolation MOV JNA20AA001, Fails to Close on Demand
			JNA20AA002EFC	RHR, LHSI Pump 20 Hot Leg Isolation MOV JNA20AA002, Fails to Close on Demand
			RHR TR2 PIPE BRK	Pipe Break in RHR Train 2
173	3.760E-11	0.07	IE SD LOCA CAU	Initiator - LOCA During Shutdown State CAU
			JNG10AA001EOP	LHSI, LHSI Pump 10 Suction from IRWST MOV JNG10AA001, Fails to Remain Closed (SO)
			JNG13AA005CFO_D-ALL	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves)
			OPF-ISOIRWSTFD-CA	Operator Fails to Isolate RHR Suction to IRWST (Valve JNGX0AA001) in CA
174	3.760E-11	0.07	IE SD LOCA CAU	Initiator - LOCA During Shutdown State CAU
			JNG13AA005CFO_D-ALL	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves)
			JNG20AA001EOP	LHSI, LHSI Pump 20 Suction from IRWST MOV JNG20AA001, Fails to Remain Closed (SO)
			OPF-ISOIRWSTFD-CA	Operator Fails to Isolate RHR Suction to IRWST (Valve JNGX0AA001) in CA
175	3.733E-11	0.06	IE SD RHR CBU	Initiator - RHR in Power State CBu
			OPD-SAC2H/SAC1H	Dependency (MED) Between OAs for Starting HVAC Maintenance Trains Recovering Room Cooling Locally
			OPF-SAC-1H	Operator Fails to Start Maintenance HVAC Trains After Failure of Normal SAC Safety Train
			SAC01AN001EFR_D-123	CCF to Run Normal Air Supply Fans
176	3.733E-11	0.06	IE SD RHR CBU	Initiator - RHR in Power State CBu
			OPD-SAC2H/SAC1H	Dependency (MED) Between OAs for Starting HVAC Maintenance Trains Recovering Room Cooling Locally
			OPF-SAC-1H	Operator Fails to Start Maintenance HVAC Trains After Failure of Normal SAC Safety Train
			SAC31AN001EFR_D-123	CCF to Run Normal Air Exhaust Fans

MCS Results

EPRDCSD1

SHUTDOWN

No.	Freq.	%	Event	Description
177	3.557E-11	0.06	IE SD RHR CAU SD LOOP24+REC XKA10____DFR_D CCF of EDGs to Run -ALL XKA50____DFR_B CCF of SBO DGs to Run -ALL	Initiator - RHR in Power State CAU Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
178	3.502E-11	0.06	IE SD RHR CBD OPF-XTDIVSBO-2H PEB10AP001EFS_D CCF of the ESWS Pumps to Start -ALL SA-ESWS UHS4 SBO SD LOOP24+REC	Initiator - RHR in Power State CBd Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During SBO Considitions CCF of the ESWS Pumps to Start Failure of SA-ESWS/UHS4 in SBO Conditions Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
179	3.484E-11	0.06	IE SD RHR CBD OPD-SAC2H/SAC1H OPF-SAC-1H QKA10AP107EFR_ D-123	Initiator - RHR in Power State CBd Dependency (MED) Between OAs for Starting HVAC Maintenance Trains Recovering Room Cooling Locally Operator Fails to Start Maintenance HVAC Trains After Failure of Normal SAC Safety Train CCF of SCWS Pumps to Run
180	3.481E-11	0.06	IE SD ULD CBD D JNK10AT001SPG_P -ALL KBA14AA004EFC_B CCF to Close CVCS Low Pressure Reducing Station MOVs -ALL	Initiator - Uncontrolled Level Drop in Shutdown State CBd (Demand) CCF of IRWST Sump Strainers - Plugged CCF to Close CVCS Low Pressure Reducing Station MOVs
181	3.481E-11	0.06	IE SD ULD DU D JNK10AT001SPG_P -ALL KBA14AA004EFC_B CCF to Close CVCS Low Pressure Reducing Station MOVs -ALL	Initiator - Uncontrolled Level Drop in Shutdown State Du (Demand) CCF of IRWST Sump Strainers - Plugged CCF to Close CVCS Low Pressure Reducing Station MOVs
182	3.432E-11	0.06	IE SD RHR ISLOCA CAU OPF-ISORHRBRK PAS RHR TR1 PIPE BRK	RHR ISLOCA During Shutdown State CAU Operator Fails to Isolate RHR Pipe Break Process Automation System (PAS) Fails (Estimate) Pipe Break in RHR Train 1
183	3.432E-11	0.06	IE SD RHR ISLOCA CAU OPF-ISORHRBRK PAS RHR TR2 PIPE BRK	RHR ISLOCA During Shutdown State CAU Operator Fails to Isolate RHR Pipe Break Process Automation System (PAS) Fails (Estimate) Pipe Break in RHR Train 2

MCS Results

EPRDCSD1

SHUTDOWN

No.	Freq.	%	Event	Description
184	3.387E-11	0.06	IE SD RHR CBD	Initiator - RHR in Power State CBd
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10_1BDABFO_D-ALL	CCF to Close EDG Supply Breakers
			XKA50____DFR	ELEC, SBO Diesel Generator XKA50, Fails to Run
185	3.387E-11	0.06	IE SD RHR CBD	Initiator - RHR in Power State CBd
			BDT01_BDA_BFO_D-ALL	CCF to Open Normal Supply 6.9kV Circuit Breakers from Aux. Xfrm to Safety Related SWGRs
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA50____DFR	ELEC, SBO Diesel Generator XKA50, Fails to Run
186	3.387E-11	0.06	IE SD RHR CBD	Initiator - RHR in Power State CBd
			BDT02_BDA_BFO_D-ALL	CCF to Open Backup Supply 6.9kV Circuit Breakers from Aux. Xfrm to Safety Related SWGRs
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA50____DFR	ELEC, SBO Diesel Generator XKA50, Fails to Run
187	3.346E-11	0.06	IE SD RHR DD	Initiator - RHR in Power State Dd
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR_D-ALL	CCF of EDGs to Run
			XKA50____DFR	ELEC, SBO Diesel Generator XKA50, Fails to Run
			XKA80____DFR	ELEC, SBO Diesel Generator XKA80, Fails to Run
188	3.222E-11	0.06	IE SD RHR DD	Initiator - RHR in Power State Dd
			BDT01_BAT__ST_D-ALL	CCF of Safety Related Batteries on Demand
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
189	3.192E-11	0.06	IE SD RHR DU	Initiator - RHR in Power State Du
			JND10AP001EFR_D-ALL	CCF of MHSI Pumps to Run
			JNG10AP001EFR_D-ALL	CCF of LHSI Pumps to Run
190	3.166E-11	0.05	IE SD RHR CBD	Initiator - RHR in Power State CBd
			OPF-XTLDSBO-2H	Operator Fails to Connect and Load SBO DGs to Div 1 and 4
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR_D-ALL	CCF of EDGs to Run

MCS Results

EPRDCSD1

SHUTDOWN

No.	Freq.	%	Event	Description
191	3.133E-11	0.05	IE SD RHR CAU	Initiator - RHR in Power State CAU
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR_D -123	CCF of EDGs to Run
			XKA40____DFR	ELEC, Emergency Diesel Generator XKA40, Fails to Run
			XKA50____DFR	ELEC, SBO Diesel Generator XKA50, Fails to Run
192	3.133E-11	0.05	IE SD RHR CAU	Initiator - RHR in Power State CAU
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR_D -134	CCF of EDGs to Run
			XKA20____DFR	ELEC, Emergency Diesel Generator XKA20, Fails to Run
			XKA50____DFR	ELEC, SBO Diesel Generator XKA50, Fails to Run
193	3.133E-11	0.05	IE SD RHR CAU	Initiator - RHR in Power State CAU
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR_D -124	CCF of EDGs to Run
			XKA30____DFR	ELEC, Emergency Diesel Generator XKA30, Fails to Run
			XKA50____DFR	ELEC, SBO Diesel Generator XKA50, Fails to Run
194	3.133E-11	0.05	IE SD RHR CAU	Initiator - RHR in Power State CAU
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR	ELEC, Emergency Diesel Generator XKA10, Fails to Run
			XKA10____DFR_D -234	CCF of EDGs to Run
			XKA50____DFR	ELEC, SBO Diesel Generator XKA50, Fails to Run
195	2.955E-11	0.05	IE SD LOCA CBD	Initiator - LOCA During Shutdown State CBd
			JNG13AA005CFO_ D-ALL	CCF to Open LHSI/MHSI Common Injection Check Valves (SIS First Isolation Valves)
			SLOCA24	Small LOCA - 24 Hour
196	2.953E-11	0.05	IE SD RHR CBD	Initiator - RHR in Power State CBd
			31BTB01_BATST	ELEC, 250V Non 1E 12-hr Battery 31BTB01, Fails on Demand
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR_D -ALL	CCF of EDGs to Run
197	2.941E-11	0.05	IE SD RHR CBD	Initiator - RHR in Power State CBd
			31BTD01_BATST	ELEC, 250V 1E 2-hr Battery 31BTD01, Fails on Demand
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10____DFR_D -ALL	CCF of EDGs to Run

MCS Results

EPRDCSD1

SHUTDOWN

No.	Freq.	%	Event	Description
198	2.922E-11	0.05	IE SD RHR CBD	Initiator - RHR in Power State CBd
			LAS11AP001EFR	EFWS, Train 1 Motor Driven Pump LAS11AP001, Fails to Run
			SD LOOP24+REC	Loss Of Offsite Power During Shutdown and Failure of Recovery Within 1 Hour
			XKA10_____DFR_D -ALL	CCF of EDGs to Run
			XKA80_____DFR	ELEC, SBO Diesel Generator XKA80, Fails to Run
199	2.885E-11	0.05	IE SD RHR CAD	Initiator - RHR in Power State CAd
			OPD-SAC2H/SAC1H	Dependency (MED) Between OAs for Starting HVAC Maintenance Trains Recovering Room Cooling Locally
			OPF-SAC-1H	Operator Fails to Start Maintenance HVAC Trains After Failure of Normal SAC Safety Train
			QKA10AP107EFR_ D-ALL	CCF of SCWS Pumps to Run
200	2.885E-11	0.05	IE SD RHR DU	Initiator - RHR in Power State Du
			OPD-SAC2H/SAC1H	Dependency (MED) Between OAs for Starting HVAC Maintenance Trains Recovering Room Cooling Locally
			OPF-SAC-1H	Operator Fails to Start Maintenance HVAC Trains After Failure of Normal SAC Safety Train
			QKA10AP107EFR_ D-ALL	CCF of SCWS Pumps to Run

Minimal Cutsets

Top Event probability Q = 5.264E-07

No.	Prob.	%	Event	Description
1	3.200E-08	6.08	IE FLD-ANN ALL PROB ANNULUS	Initiator - Flood in the RB Annulus (Contained) Probability that the Annulus connection boxes will withstand a contained Flood
2	2.626E-08	4.99	IE FIRE-MS-VR MSIV TR3 ISO-FIRE MSIV TR4 ISO-FIRE OPE-RHR-4H	Initiator - Fire in One of Two MF/MS Valve Rooms With Spurious Opening of 1 MSRIV MSIV 3 Fails to Isolate Due to Fire in MS/FW Valve Room MSIV 4 Fails to Isolate Due to Fire in MS/FW Valve Room Operator Fails to Initiate RHR Within 4 Hours
3	2.520E-08	4.79	IE FIRE-MCR OPE-MCR-RSS-90M	Initiator - Fire in the Main Control Room Operator Fails to Transfer to the RSS in 90 Mins Given A MCR Fire
4	1.220E-08	2.32	IE LOOP OPF-SAC-2H QKA10GH001_FS_ B-ALL REC OSP 2HR	Initiator - Loss Of Offsite Power Operator Fails to Recover Room Cooling Locally CCF of the Air Cooled SCWS Chiller Units to Start Failure to Recover Offsite Power Within 2 Hours
5	1.148E-08	2.18	IE LOOP OPF-SAC-2H QKA10GH001_FS REC OSP 2HR SAC04/QKA40 PM4	Initiator - Loss Of Offsite Power Operator Fails to Recover Room Cooling Locally SCWS, Train 1 Chiller Unit QKA10GH001, Fails to Start on Demand Failure to Recover Offsite Power Within 2 Hours Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance
6	1.148E-08	2.18	IE LOOP OPF-SAC-2H QKA40GH001_FS REC OSP 2HR SAC01/QKA10 PM1	Initiator - Loss Of Offsite Power Operator Fails to Recover Room Cooling Locally SCWS, Train 4 Chiller Unit QKA40GH001, Fails to Start on Demand Failure to Recover Offsite Power Within 2 Hours Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
7	7.800E-09	1.48	IE FIRE-SAB-MECH OPF-SAC-2H PAS SAC01/QKA10 PM1	Initiator - Fire in the Pump Room of Any Safeguard Building Operator Fails to Recover Room Cooling Locally Process Automation System (PAS) Fails (Estimate) Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance

MCS Results

EPRDC050

TOTAL At Power CDF

No.	Prob.	%	Event	Description
8	6.822E-09	1.30	IE SLOCA JND10AP001EFR_D CCF of MHSI Pumps to Run -ALL OPE-FCD-40M	Initiator - Small LOCA (0.6 to 3-Inch Diameter) Operator Fails to Initiate Fast Cooldown for SLOCA
9	6.659E-09	1.26	IE SLOCA LBA13AA001PFO_D CCF to Open Main Steam Relief Isolation Valves -ALL OPE-FB-40M	Initiator - Small LOCA (0.6 to 3-Inch Diameter) Operator Fails to Initiate Feed & Bleed for SLOCA
10	6.178E-09	1.17	IE SLOCA JNG13AA005CFO_ D-ALL	Initiator - Small LOCA (0.6 to 3-Inch Diameter) CCF to Open LHSI/MHSI Common Injection Check Valves
11	6.133E-09	1.17	IE FIRE-SAB14-AC 32BRA____RFR CVCS VCT PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) ELEC, 480V AC to 24V DC Rectifier for MCC 32BRA Control Power, Fails to Run CVCS Switchover to IRWST May Not Be Required Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
12	6.133E-09	1.17	IE FIRE-SAB14-AC 31BRA____RFR CVCS VCT PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) ELEC, 480V AC to 24V DC Rectifier for MCC 31BRA Control Power, Fails to Run CVCS Switchover to IRWST May Not Be Required Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
13	5.594E-09	1.06	IE LOOP BTD01_BAT__ST_D -ALL	Initiator - Loss Of Offsite Power CCF of Safety Related Batteries on Demand
14	5.000E-09	0.95	IE SLBI CL-PS-B-SWCCF	Initiator - Steam Break Inside Containment SW CCF of Protection System diversity group B
15	4.320E-09	0.82	IE FIRE-SAB14-AC CCWS/ESWS PM2 LOOPFCSD+REC OPF-XTDIV-NSC PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) CCWS/ESWS Train 2 Pump Unavailable due to Preventive Maintenance Consequential LOOP and Failure of Recovery Within 1 Hour for Fire IEs Leading to a Controlled Shutdn Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
16	3.936E-09	0.75	IE SGTR LBA40AA002PFC OPE-RHR-4H	Initiator - Steam Generator Tube Rupture MSS, Train 4 Main Steam Isolation Valve LBA40AA002, Fails to Close on Demand Operator Fails to Initiate RHR Within 4 Hours
17	3.932E-09	0.75	IE LOMFW STUCK ROD	Initiator - Total Loss of Main Feedwater Stuck Control Rods

MCS Results

EPRDC050

TOTAL At Power CDF

No.	Prob.	%	Event	Description
18	3.388E-09	0.64	IE SGTR	Initiator - Steam Generator Tube Rupture
			LBA43AA101EFC	MSS, Train 4 MSRCV LBA43AA101, Fails to Close on Demand
			OPD-RHR4H/SGTR 1H	Dependency (MED) Between Operator Actions for Stabilizing SGTR and Initiating RHR
			OPF-SGTR-1H	Operator Fails to Isolate SGTR and Initiate Cooldown
19	3.325E-09	0.63	IE LOC	Initiator - Loss of Main Condenser (Includes MSIV Closure etc.)
			STUCK ROD	Stuck Control Rods
20	2.880E-09	0.55	IE FIRE-SAB14-AC	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4)
			EDG PM2	EDG Train 2 Unavailable due to Preventive Maintenance
			LOOPFCSD+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for Fire IEs Leading to a Controlled Shutdn
			OPF-XTDIV-NSC	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
21	2.808E-09	0.53	IE FIRE-SAB-MECH	Initiator - Fire in the Pump Room of Any Safeguard Building
			LOOPFCSD+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for Fire IEs Leading to a Controlled Shutdn
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			SAC01/QKA10 PM1	Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
22	2.715E-09	0.52	IE GT	Initiator - General Transient (Includes Turbine Trip and Reactor Trip)
			LOOPCON+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			QKA10GH001_FS_B-ALL	CCF of the Air Cooled SCWS Chiller Units to Start
23	2.555E-09	0.49	IE GT	Initiator - General Transient (Includes Turbine Trip and Reactor Trip)
			LOOPCON+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			QKA10GH001_FS	SCWS, Train 1 Chiller Unit QKA10GH001, Fails to Start on Demand
			SAC04/QKA40 PM4	Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance
24	2.555E-09	0.49	IE GT	Initiator - General Transient (Includes Turbine Trip and Reactor Trip)
			LOOPCON+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			QKA40GH001_FS	SCWS, Train 4 Chiller Unit QKA40GH001, Fails to Start on Demand
			SAC01/QKA10 PM1	Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
25	2.269E-09	0.43	IE SLOCA	Initiator - Small LOCA (0.6 to 3-Inch Diameter)
			MSRIVSCPFO_P-ALL	CCF to Open Main Steam Relief Isolation Pneumatic Pilot Valves
			OPE-FB-40M	Operator Fails to Initiate Feed & Bleed for SLOCA

MCS Results

EPRDC050

TOTAL At Power CDF

No.	Prob.	%	Event	Description
26	2.262E-09	0.43	IE FLD-SAB14 FB	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			PAS	Process Automation System (PAS) Fails (Estimate)
			SAC01/QKA10 PM1	Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
27	2.083E-09	0.40	IE LBOP	Initiator - Loss of Balance of Plant - Closed Loop Cooling Water or Aux Cooling Water
			STUCK ROD	Stuck Control Rods
28	1.983E-09	0.38	IE FIRE-SAB14-AC LOOPFCSD+REC	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) Consequential LOOP and Failure of Recovery Within 1 Hour for Fire IEs Leading to a Controlled Shutdn
			OPF-XTDIV-NSC	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
			XKA20____DFR	ELEC, Emergency Diesel Generator XKA20, Fails to Run
29	1.854E-09	0.35	IE LOOP	Initiator - Loss Of Offsite Power
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			QKA10GH001_FS	SCWS, Train 1 Chiller Unit QKA10GH001, Fails to Start on Demand
			QKA40GH001_FS	SCWS, Train 4 Chiller Unit QKA40GH001, Fails to Start on Demand
			REC OSP 2HR	Failure to Recover Offsite Power Within 2 Hours
30	1.848E-09	0.35	IE LOOP	Initiator - Loss Of Offsite Power
			REC OSP 2HR	Failure to Recover Offsite Power Within 2 Hours
			XKA10____DFR_D-ALL	CCF of EDGs to Run
			XKA50____DFR	ELEC, SBO Diesel Generator XKA50, Fails to Run
			XKA80____DFR	ELEC, SBO Diesel Generator XKA80, Fails to Run
31	1.756E-09	0.33	IE LOOP	Initiator - Loss Of Offsite Power
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			QKA10GH001_FR_B-ALL	CCF of the Air Cooled SCWS Chiller Units to Run
			REC OSP 2HR	Failure to Recover Offsite Power Within 2 Hours
32	1.652E-09	0.31	IE LOOP	Initiator - Loss Of Offsite Power
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			QKA10GH001_FR	SCWS, Train 1 Chiller Unit QKA10GH001, Fails to Run
			REC OSP 2HR	Failure to Recover Offsite Power Within 2 Hours
			SAC04/QKA40 PM4	Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance
33	1.652E-09	0.31	IE LOOP	Initiator - Loss Of Offsite Power
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			QKA40GH001_FR	SCWS, Train 4 Chiller Unit QKA40GH001, Fails to Run
			REC OSP 2HR	Failure to Recover Offsite Power Within 2 Hours
			SAC01/QKA10 PM1	Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance

MCS Results

EPRDC050

TOTAL At Power CDF

No.	Prob.	%	Event	Description
34	1.540E-09	0.29	IE LOOP	Initiator - Loss Of Offsite Power
			34BTD01_BATST	ELEC, 250V 1E 2-hr Battery 34BTD01, Fails on Demand
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			REC OSP 2HR	Failure to Recover Offsite Power Within 2 Hours
			SAC01/QKA10 PM1	Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
35	1.540E-09	0.29	IE LOOP	Initiator - Loss Of Offsite Power
			31BTD01_BATST	ELEC, 250V 1E 2-hr Battery 31BTD01, Fails on Demand
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			REC OSP 2HR	Failure to Recover Offsite Power Within 2 Hours
			SAC04/QKA40 PM4	Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance
36	1.485E-09	0.28	IE FIRE-SAB14-AC	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4)
			CVCS VCT	CVCS Switchover to IRWST May Not Be Required
			LBA13AA001PFO_D CCF to Open Main Steam Relief Isolation Valves -ALL	
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
37	1.359E-09	0.26	IE LOOP	Initiator - Loss Of Offsite Power
			REC OSP 2HR	Failure to Recover Offsite Power Within 2 Hours
			SBODG8 PM4	SBO-DG Train 4 Unavailable due to Preventive Maintenance
			XKA10____DFR_D CCF of EDGs to Run -ALL	
			XKA50____DFR	ELEC, SBO Diesel Generator XKA50, Fails to Run
38	1.359E-09	0.26	IE LOOP	Initiator - Loss Of Offsite Power
			EFWS PM4	EFWS Train 4 Unavailable due to Preventive Maintenance
			REC OSP 2HR	Failure to Recover Offsite Power Within 2 Hours
			XKA10____DFR_D CCF of EDGs to Run -ALL	
			XKA50____DFR	ELEC, SBO Diesel Generator XKA50, Fails to Run
39	1.359E-09	0.26	IE LOOP	Initiator - Loss Of Offsite Power
			REC OSP 2HR	Failure to Recover Offsite Power Within 2 Hours
			SBODG5 PM1	SBO-DG Train 1 Unavailable due to Preventive Maintenance
			XKA10____DFR_D CCF of EDGs to Run -ALL	
			XKA80____DFR	ELEC, SBO Diesel Generator XKA80, Fails to Run
40	1.359E-09	0.26	IE LOOP	Initiator - Loss Of Offsite Power
			EFWS PM1	EFWS Train 1 Unavailable due to Preventive Maintenance
			REC OSP 2HR	Failure to Recover Offsite Power Within 2 Hours
			XKA10____DFR_D CCF of EDGs to Run -ALL	
			XKA80____DFR	ELEC, SBO Diesel Generator XKA80, Fails to Run

MCS Results

EPRDC050

TOTAL At Power CDF

No.	Prob.	%	Event	Description
41	1.222E-09	0.23	IE SLOCA KAA12AA005EFO_DCCF to Open CCWS to LHSI HTX Cooling MOV -ALL SAHR PM4	Initiator - Small LOCA (0.6 to 3-Inch Diameter) SAHR Train Unavailable due to Preventive Maintenance
42	1.212E-09	0.23	IE IND SGTR OPE-RHR-4H	Initiator - Induced Steam Generator Tube Rupture Operator Fails to Initiate RHR Within 4 Hours
43	1.023E-09	0.19	IE SLOCA PED10AN002EFS_DCCF to Start Standby Cooling Tower Fans -ALL SAHR PM4	Initiator - Small LOCA (0.6 to 3-Inch Diameter) SAHR Train Unavailable due to Preventive Maintenance
44	9.820E-10	0.19	IE LOOP REC OSP 2HR XKA10____DFR_D CCF of EDGs to Run -ALL XKA50____DFR_B CCF of SBO DGs to Run -ALL	Initiator - Loss Of Offsite Power Failure to Recover Offsite Power Within 2 Hours
45	9.600E-10	0.18	IE FIRE-SAB14-AC 31BDB____OFL CVCS VCT OPF-XTIE BC PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) ELEC, 6.9kV SWGR 31BDB, Fails During Operation CVCS Switchover to IRWST May Not Be Required Operator Fails to Align Backup Battery Charger to BUC Bus Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
46	9.600E-10	0.18	IE FIRE-SAB14-AC 32BDB____OFL CVCS VCT OPF-XTIE BC PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) ELEC, 6.9kV SWGR 32BDB, Fails During Operation CVCS Switchover to IRWST May Not Be Required Operator Fails to Align Backup Battery Charger to BUC Bus Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
47	9.600E-10	0.18	IE FIRE-SAB14-AC 32BMT02__TFL CVCS VCT OPF-XTIE BC PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) ELEC, 6.9kV-480V Transformer 32BMT02, Fails During Operation CVCS Switchover to IRWST May Not Be Required Operator Fails to Align Backup Battery Charger to BUC Bus Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
48	9.600E-10	0.18	IE FIRE-SAB14-AC 32BMB____OFL CVCS VCT OPF-XTIE BC PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) ELEC, 480V Load Center 32BMB, Fails During Operation CVCS Switchover to IRWST May Not Be Required Operator Fails to Align Backup Battery Charger to BUC Bus Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
49	9.600E-10	0.18	IE FIRE-SAB14-AC 31BDA____OFL OPF-XTLDSBO-NS C PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) ELEC, 6.9kV Switchgear 31BDA, Fails During Operation Operator Fails to Connect and Load SBO DGs to Div 1 or 4 During Non-SBO Conditions Probability of Seal LOCA Occurring Given a Loss of Seal Cooling

MCS Results

EPRDC050

TOTAL At Power CDF

No.	Prob.	%	Event	Description
50	9.600E-10	0.18	IE FIRE-SAB14-AC 31BMB____OFL CVCS VCT OPF-XTIE BC PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) ELEC, 480V Load Center 31BMB, Fails During Operation CVCS Switchover to IRWST May Not Be Required Operator Fails to Align Backup Battery Charger to BUC Bus Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
51	9.600E-10	0.18	IE FIRE-SAB14-AC 31BDC____OFL CVCS VCT PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) ELEC, 6.9kV SWGR 31BDC, Fails During Operation CVCS Switchover to IRWST May Not Be Required Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
52	9.600E-10	0.18	IE FIRE-SAB14-AC 32BRA____OFL CVCS VCT PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) ELEC, 480V MCC 32BRA, Fails During Operation CVCS Switchover to IRWST May Not Be Required Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
53	9.600E-10	0.18	IE FIRE-SAB14-AC 31BRA____OFL CVCS VCT PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) ELEC, 480V MCC 31BRA, Fails During Operation CVCS Switchover to IRWST May Not Be Required Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
54	9.600E-10	0.18	IE FIRE-SAB14-AC 31BMT02__TFL CVCS VCT OPF-XTIE BC PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) ELEC, 6.9kV-480V Transformer 31BMT02, Fails During Operation CVCS Switchover to IRWST May Not Be Required Operator Fails to Align Backup Battery Charger to BUC Bus Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
55	9.600E-10	0.18	IE FIRE-SAB14-AC BRW32BUW33OFL CVCS VCT PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) ELEC, 24V DC I&C Power Rack 32BRW32/32BUW33, Fails During Operation CVCS Switchover to IRWST May Not Be Required Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
56	9.600E-10	0.18	IE FIRE-SAB14-AC BRW10BUW11OFL CVCS VCT PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) ELEC, 24V DC I&C Power Rack 31BRW10/31BUW11, Fails During Operation CVCS Switchover to IRWST May Not Be Required Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
57	9.116E-10	0.17	IE LOOP OPF-SAC-2H QKA10AP107EFS REC OSP 2HR SAC04/QKA40 PM4	Initiator - Loss Of Offsite Power Operator Fails to Recover Room Cooling Locally SCWS, Train 1 Motor Driven Safety Chiller Pump QKA10AP107, Fails to Start on Demand Failure to Recover Offsite Power Within 2 Hours Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance

MCS Results

EPRDC050

TOTAL At Power CDF

No.	Prob.	%	Event	Description
58	9.116E-10	0.17	IE LOOP OPF-SAC-2H QKA40AP107EFS REC OSP 2HR SAC01/QKA10 PM1	Initiator - Loss Of Offsite Power Operator Fails to Recover Room Cooling Locally SCWS, Train 4 Motor Driven Safety Chiller Pump QKA40AP107, Fails to Start on Demand Failure to Recover Offsite Power Within 2 Hours Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
59	8.970E-10	0.17	IE SLOCA CL-PS-B-SWCCF OPE-FB-40M	Initiator - Small LOCA (0.6 to 3-Inch Diameter) SW CCF of Protection System diversity group B Operator Fails to Initiate Feed & Bleed for SLOCA
60	8.970E-10	0.17	IE SLOCA CL-PS-B-SWCCF OPE-FCD-40M	Initiator - Small LOCA (0.6 to 3-Inch Diameter) SW CCF of Protection System diversity group B Operator Fails to Initiate Fast Cooldown for SLOCA
61	8.963E-10	0.17	IE FIRE-SWGR OPF-SAC-2H QKA10GH001_FR_ B-ALL	Initiator - Fire in the Switchgear Building Operator Fails to Recover Room Cooling Locally CCF of the Air Cooled SCWS Chiller Units to Run
62	8.854E-10	0.17	IE FIRE-SAB14-AC CVCS VCT KAA12AA005EFO_DCCF -ALL PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) CVCS Switchover to IRWST May Not Be Required KAA12AA005EFO_DCCF to Open CCWS to LHSI HTX Cooling MOV Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
63	8.810E-10	0.17	IE LBOP OPF-SAC-2H SAC31AN001EFR_ D-ALL	Initiator - Loss of Balance of Plant - Closed Loop Cooling Water or Aux Cooling Water Operator Fails to Recover Room Cooling Locally CCF to Run Normal Air Exhaust Fans
64	8.810E-10	0.17	IE LBOP OPF-SAC-2H SAC01AN001EFR_ D-ALL	Initiator - Loss of Balance of Plant - Closed Loop Cooling Water or Aux Cooling Water Operator Fails to Recover Room Cooling Locally CCF to Run Normal Air Supply Fans
65	8.433E-10	0.16	IE FIRE-SWGR OPF-SAC-2H QKA10GH001_FR SAC04/QKA40 PM4	Initiator - Fire in the Switchgear Building Operator Fails to Recover Room Cooling Locally SCWS, Train 1 Chiller Unit QKA10GH001, Fails to Run Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance
66	8.433E-10	0.16	IE FIRE-SWGR OPF-SAC-2H QKA10GH001_FR SAC03/QKA30 PM3	Initiator - Fire in the Switchgear Building Operator Fails to Recover Room Cooling Locally SCWS, Train 1 Chiller Unit QKA10GH001, Fails to Run Normal SAC03/QKA30 Train Unavailable due to Preventive Maintenance

MCS Results

EPRDC050

TOTAL At Power CDF

No.	Prob.	%	Event	Description
67	8.433E-10	0.16	IE FIRE-SWGR	Initiator - Fire in the Switchgear Building
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			QKA40GH001_FR	SCWS, Train 4 Chiller Unit QKA40GH001, Fails to Run
			SAC02/QKA20 PM2	Normal SAC02/QKA20 Train Unavailable due to Preventive Maintenance
68	8.433E-10	0.16	IE FIRE-SWGR	Initiator - Fire in the Switchgear Building
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			QKA30GH001_FR	SCWS, Train 3 Chiller Unit QKA30GH001, Fails to Run
			SAC01/QKA10 PM1	Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
69	8.433E-10	0.16	IE FIRE-SWGR	Initiator - Fire in the Switchgear Building
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			QKA40GH001_FR	SCWS, Train 4 Chiller Unit QKA40GH001, Fails to Run
			SAC01/QKA10 PM1	Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
70	8.433E-10	0.16	IE FIRE-SWGR	Initiator - Fire in the Switchgear Building
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			QKA20GH001_FR	SCWS, Train 2 Chiller Unit QKA20GH001, Fails to Run
			SAC04/QKA40 PM4	Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance
71	8.294E-10	0.16	IE SLOCA	Initiator - Small LOCA (0.6 to 3-Inch Diameter)
			JND10AP001EFS_D -ALL	CCF of MHSI Pumps to Start
			OPE-FCD-40M	Operator Fails to Initiate Fast Cooldown for SLOCA
72	8.256E-10	0.16	IE LOOP	Initiator - Loss Of Offsite Power
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			REC OSP 2HR	Failure to Recover Offsite Power Within 2 Hours
			SAC01/QKA10 PM1	Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
			SAC34AN001EFR	SAC, Normal Air Exhaust Fan SAC34AN001, Fails to Run
73	8.256E-10	0.16	IE LOOP	Initiator - Loss Of Offsite Power
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			REC OSP 2HR	Failure to Recover Offsite Power Within 2 Hours
			SAC01/QKA10 PM1	Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
			SAC04AN001EFR	SAC, Normal Air Supply Fan SAC04AN001, Fails to Run
74	8.256E-10	0.16	IE LOOP	Initiator - Loss Of Offsite Power
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			REC OSP 2HR	Failure to Recover Offsite Power Within 2 Hours
			SAC04/QKA40 PM4	Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance
			SAC31AN001EFR	SAC, Normal Air Exhaust Fan SAC31AN001, Fails to Run

MCS Results

EPRDC050

TOTAL At Power CDF

No.	Prob.	%	Event	Description
75	8.256E-10	0.16	IE LOOP	Initiator - Loss Of Offsite Power
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			REC OSP 2HR	Failure to Recover Offsite Power Within 2 Hours
			SAC01AN001EFR	SAC, Normal Air Supply Fan SAC01AN001, Fails to Run
			SAC04/QKA40 PM4	Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance
76	7.943E-10	0.15	IE LOOP	Initiator - Loss Of Offsite Power
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			QKA40GH001PANS	SCWS, Train 4 Chiller Unit QKA40GH001, PAC A Priority Module (Type AV42) Fails (Non-Self-Monitored)
			REC OSP 2HR	Failure to Recover Offsite Power Within 2 Hours
			SAC01/QKA10 PM1	Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
77	7.943E-10	0.15	IE LOOP	Initiator - Loss Of Offsite Power
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			QKA10GH001PANS	SCWS, Train 1 Chiller Unit QKA10GH001, PAC A Priority Module (Type AV42) Fails (Non-Self-Monitored)
			REC OSP 2HR	Failure to Recover Offsite Power Within 2 Hours
			SAC04/QKA40 PM4	Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance
78	7.856E-10	0.15	IE SLOCA	Initiator - Small LOCA (0.6 to 3-Inch Diameter)
			CCWS/ESWS PM3	CCWS/ESWS Train 3 Pump Unavailable due to Preventive Maintenance
			LOOPCONL+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for LOCA IEs
			OPE-FB-40M	Operator Fails to Initiate Feed & Bleed for SLOCA
			OPF-XTDIV-NSC	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions
			XKA20____DFR	ELEC, Emergency Diesel Generator XKA20, Fails to Run
79	7.856E-10	0.15	IE SLOCA	Initiator - Small LOCA (0.6 to 3-Inch Diameter)
			CCWS/ESWS PM2	CCWS/ESWS Train 2 Pump Unavailable due to Preventive Maintenance
			LOOPCONL+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for LOCA IEs
			OPE-FB-40M	Operator Fails to Initiate Feed & Bleed for SLOCA
			OPF-XTDIV-NSC	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions
			XKA30____DFR	ELEC, Emergency Diesel Generator XKA30, Fails to Run
80	7.798E-10	0.15	IE SLOCA	Initiator - Small LOCA (0.6 to 3-Inch Diameter)
			JNK10AT001SPG_P	CCF of IRWST Sump Strainers - Plugged
			-ALL	

MCS Results

EPRDC050

TOTAL At Power CDF

No.	Prob.	%	Event	Description
81	7.747E-10	0.15	IE LOOP	Initiator - Loss Of Offsite Power
			LAS11AP001EFR	EFWS, Train 1 Motor Driven Pump LAS11AP001, Fails to Run
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			REC OSP 2HR	Failure to Recover Offsite Power Within 2 Hours
			SAC04/QKA40 PM4	Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance
			XKA20____DFR	ELEC, Emergency Diesel Generator XKA20, Fails to Run
82	7.747E-10	0.15	IE LOOP	Initiator - Loss Of Offsite Power
			LAS41AP001EFR	EFWS, Train 4 Motor Driven Pump LAS41AP001, Fails to Run
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			REC OSP 2HR	Failure to Recover Offsite Power Within 2 Hours
			SAC01/QKA10 PM1	Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
			XKA30____DFR	ELEC, Emergency Diesel Generator XKA30, Fails to Run
83	7.564E-10	0.14	IE SLOCA	Initiator - Small LOCA (0.6 to 3-Inch Diameter)
			MSRIVSOOFO_P-A LL	CCF to Open Main Steam Relief Isolation Solenoid Pilot Valves
			OPE-FB-40M	Operator Fails to Initiate Feed & Bleed for SLOCA
84	7.519E-10	0.14	IE SLOCA	Initiator - Small LOCA (0.6 to 3-Inch Diameter)
			LOOPCONL+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for LOCA IEs
			XKA10____DFR_D -ALL	CCF of EDGs to Run
85	7.412E-10	0.14	IE FIRE-SAB14-AC	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4)
			CVCS VCT	CVCS Switchover to IRWST May Not Be Required
			PED10AN002EFS_D -ALL	CCF to Start Standby Cooling Tower Fans
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
86	7.052E-10	0.13	IE FIRE-PZR	Initiator - Fire in the Pressurizer Compartment With Spurious Opening of 1 PSRV
			LBA13AA001PFO_D -ALL	CCF to Open Main Steam Relief Isolation Valves
87	6.948E-10	0.13	IE FIRE-SAB14-AC	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4)
			CVCS VCT	CVCS Switchover to IRWST May Not Be Required
			LBA13AA001PFO_D -124	CCF to Open Main Steam Relief Isolation Valves
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
88	6.774E-10	0.13	IE GT	Initiator - General Transient (Includes Turbine Trip and Reactor Trip)
			OPF-EBS-30M	Operator Fails to Manually Actuate EBS (SLB & ATWS)
			STUCK ROD	Stuck Control Rods

MCS Results

EPRDC050

TOTAL At Power CDF

No.	Prob.	%	Event	Description
89	6.723E-10	0.13	IE SLBI SG4 PRES CCF-ALL	Initiator - Steam Break Inside Containment CCF of SG4 pressure sensors
90	6.297E-10	0.12	IE FIRE-MS-VR LBA10AA002PFC MSIV TR3 ISO-FIRE MSIV TR4 ISO-FIRE OPF-EBS-30M	Initiator - Fire in One of Two MF/MS Valve Rooms With Spurious Opening of 1 MSRV MSS, Train 1 Main Steam Isolation Valve LBA10AA002, Fails to Close on Demand MSIV 3 Fails to Isolate Due to Fire in MS/FW Valve Room MSIV 4 Fails to Isolate Due to Fire in MS/FW Valve Room Operator Fails to Manually Actuate EBS (SLB & ATWS)
91	6.297E-10	0.12	IE FIRE-MS-VR LBA20AA002PFC MSIV TR3 ISO-FIRE MSIV TR4 ISO-FIRE OPF-EBS-30M	Initiator - Fire in One of Two MF/MS Valve Rooms With Spurious Opening of 1 MSRV MSS, Train 2 Main Steam Isolation Valve LBA20AA002, Fails to Close on Demand MSIV 3 Fails to Isolate Due to Fire in MS/FW Valve Room MSIV 4 Fails to Isolate Due to Fire in MS/FW Valve Room Operator Fails to Manually Actuate EBS (SLB & ATWS)
92	6.074E-10	0.12	IE LOOP CL-TXS-OSCCF REC OSP 2HR	Initiator - Loss Of Offsite Power SW CCF of TXS operating system or multiple diversity groups Failure to Recover Offsite Power Within 2 Hours
93	5.760E-10	0.11	IE FIRE-SAB14-AC CCWS/ESWS PM2 LOOP24+REC OPF-XTDIV-NSC PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) CCWS/ESWS Train 2 Pump Unavailable due to Preventive Maintenance Loss Of Offsite Power During Mission Time and Failure of Recovery Within 1 Hour Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
94	5.760E-10	0.11	IE FIRE-SAB14-AC EDG PM1 LOOPFCSD+REC OPF-XTLDSBO-NS C PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) EDG Train 1 Unavailable due to Preventive Maintenance Consequential LOOP and Failure of Recovery Within 1 Hour for Fire IEs Leading to a Controlled Shutdn Operator Fails to Connect and Load SBO DGs to Div 1 or 4 During Non-SBO Conditions Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
95	5.755E-10	0.11	IE FIRE-MS-VR KAA12AA005EFO_DCCF-ALL MSIV TR3 ISO-FIRE MSIV TR4 ISO-FIRE	Initiator - Fire in One of Two MF/MS Valve Rooms With Spurious Opening of 1 MSRV KAA12AA005EFO_DCCF to Open CCWS to LHSI HTX Cooling MOV MSIV 3 Fails to Isolate Due to Fire in MS/FW Valve Room MSIV 4 Fails to Isolate Due to Fire in MS/FW Valve Room

MCS Results

EPRDC050

TOTAL At Power CDF

No.	Prob.	%	Event	Description
96	5.736E-10	0.11	IE FIRE-SWGR LOOPCON+REC XKA10____DFR_D -ALL	Initiator - Fire in the Switchgear Building Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram CCF of EDGs to Run
97	5.723E-10	0.11	IE FLD-TB OPF-SAC-2H SAC01AN001EFR_ D-ALL	Initiator - Flood in the Turbine Building Operator Fails to Recover Room Cooling Locally CCF to Run Normal Air Supply Fans
98	5.723E-10	0.11	IE FLD-TB OPF-SAC-2H SAC31AN001EFR_ D-ALL	Initiator - Flood in the Turbine Building Operator Fails to Recover Room Cooling Locally CCF to Run Normal Air Exhaust Fans
99	5.622E-10	0.11	IE LOOP OPF-SAC-2H QKA10AP107EFR REC OSP 2HR SAC04/QKA40 PM4	Initiator - Loss Of Offsite Power Operator Fails to Recover Room Cooling Locally SCWS, Train 1 Motor Driven Safety Chiller Pump QKA10AP107, Fails to Run Failure to Recover Offsite Power Within 2 Hours Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance
100	5.622E-10	0.11	IE LOOP OPF-SAC-2H QKA40AP107EFR REC OSP 2HR SAC01/QKA10 PM1	Initiator - Loss Of Offsite Power Operator Fails to Recover Room Cooling Locally SCWS, Train 4 Motor Driven Safety Chiller Pump QKA40AP107, Fails to Run Failure to Recover Offsite Power Within 2 Hours Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
101	5.460E-10	0.10	IE FLD-EFW OPF-SAC-2H PAS SAC01/QKA10 PM1	Initiator - EFW Pipe Break Operator Fails to Recover Room Cooling Locally Process Automation System (PAS) Fails (Estimate) Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
102	5.358E-10	0.10	IE SLBO LBA10AA002PFC_D -ALL OPF-EBS-30M	Initiator - Steam Break Downstream of MSIV CCF to Close Main Steam Isolation Valves Operator Fails to Manually Actuate EBS (SLB & ATWS)
103	5.237E-10	0.10	IE SLOCA EDG PM2 LOOPCONL+REC OPE-FB-40M OPF-XTDIV-NSC XKA30____DFR	Initiator - Small LOCA (0.6 to 3-Inch Diameter) EDG Train 2 Unavailable due to Preventive Maintenance Consequential LOOP and Failure of Recovery Within 1 Hour for LOCA IEs Operator Fails to Initiate Feed & Bleed for SLOCA Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions ELEC, Emergency Diesel Generator XKA30, Fails to Run

MCS Results

EPRDC050

TOTAL At Power CDF

No.	Prob.	%	Event	Description
104	5.237E-10	0.10	IE SLOCA	Initiator - Small LOCA (0.6 to 3-Inch Diameter)
			EDG PM3	EDG Train 3 Unavailable due to Preventive Maintenance
			LOOPCONL+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for LOCA IEs
			OPE-FB-40M	Operator Fails to Initiate Feed & Bleed for SLOCA
			OPF-XTDIV-NSC	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions
			XKA20____DFR	ELEC, Emergency Diesel Generator XKA20, Fails to Run
105	5.059E-10	0.10	IE FIRE-SAB14-AC	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4)
			CVCS VCT	CVCS Switchover to IRWST May Not Be Required
			MSRIVSCPFO_P-A LL	CCF to Open Main Steam Relief Isolation Pneumatic Pilot Valves
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
106	5.016E-10	0.10	IE LOOP	Initiator - Loss Of Offsite Power
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			REC OSP 2HR	Failure to Recover Offsite Power Within 2 Hours
			SAC01/QKA10 PM1	Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
			SAC34AN001EFS	SAC, Normal Air Exhaust Fan SAC34AN001, Fails to Start on Demand
107	5.016E-10	0.10	IE LOOP	Initiator - Loss Of Offsite Power
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			REC OSP 2HR	Failure to Recover Offsite Power Within 2 Hours
			SAC04/QKA40 PM4	Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance
			SAC31AN001EFS	SAC, Normal Air Exhaust Fan SAC31AN001, Fails to Start on Demand
108	5.016E-10	0.10	IE LOOP	Initiator - Loss Of Offsite Power
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			REC OSP 2HR	Failure to Recover Offsite Power Within 2 Hours
			SAC01/QKA10 PM1	Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
			SAC04AN001EFS	SAC, Normal Air Supply Fan SAC04AN001, Fails to Start on Demand
109	5.016E-10	0.10	IE LOOP	Initiator - Loss Of Offsite Power
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			REC OSP 2HR	Failure to Recover Offsite Power Within 2 Hours
			SAC01AN001EFS	SAC, Normal Air Supply Fan SAC01AN001, Fails to Start on Demand
			SAC04/QKA40 PM4	Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance
110	4.979E-10	0.09	IE SLBO	Initiator - Steam Break Downstream of MSIV
			LBA10AA002PFC_D -134	CCF to Close Main Steam Isolation Valves
			OPF-EBS-30M	Operator Fails to Manually Actuate EBS (SLB & ATWS)

MCS Results

EPRDC050

TOTAL At Power CDF

No.	Prob.	%	Event	Description
111	4.979E-10	0.09	IE SLBO LBA10AA002PFC_D CCF to Close Main Steam Isolation Valves -123 OPF-EBS-30M	Initiator - Steam Break Downstream of MSIV Operator Fails to Manually Actuate EBS (SLB & ATWS)
112	4.979E-10	0.09	IE SLBO LBA10AA002PFC_D CCF to Close Main Steam Isolation Valves -234 OPF-EBS-30M	Initiator - Steam Break Downstream of MSIV Operator Fails to Manually Actuate EBS (SLB & ATWS)
113	4.979E-10	0.09	IE SLBO LBA10AA002PFC_D CCF to Close Main Steam Isolation Valves -124 OPF-EBS-30M	Initiator - Steam Break Downstream of MSIV Operator Fails to Manually Actuate EBS (SLB & ATWS)
114	4.818E-10	0.09	IE FIRE-MS-VR MSIV TR3 ISO-FIRE MSIV TR4 ISO-FIRE PED10AN002EFS_DCCF to Start Standby Cooling Tower Fans -ALL	Initiator - Fire in One of Two MF/MS Valve Rooms With Spurious Opening of 1 MSRV MSIV 3 Fails to Isolate Due to Fire in MS/FW Valve Room MSIV 4 Fails to Isolate Due to Fire in MS/FW Valve Room
115	4.800E-10	0.09	IE FIRE-SAB14-AC 32BDA____OFL CVCS VCT OPF-XTDIV-NSC PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) ELEC, 6.9kV SWGR 32BDA, Fails During Operation CVCS Switchover to IRWST May Not Be Required Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
116	4.780E-10	0.09	IE FIRE-SAB14-AC CVCS VCT JNG13AA005CFO_D-123 PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) CVCS Switchover to IRWST May Not Be Required CCF to Open LHSI/MHSI Common Injection Check Valves Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
117	4.697E-10	0.09	IE FIRE-SAB14-AC CLE24EQ001LB02N S CLE24EQ002LB02N S CVCS VCT PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) Digital output module fails (non-self-monitored) Digital output module fails (non-self-monitored) CVCS Switchover to IRWST May Not Be Required Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
118	4.697E-10	0.09	IE FIRE-SAB14-AC CLF24EQ001LB01N S CLF24EQ002LB02N S CVCS VCT PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) Digital output module fails (non-self-monitored) Digital output module fails (non-self-monitored) CVCS Switchover to IRWST May Not Be Required Probability of Seal LOCA Occurring Given a Loss of Seal Cooling

MCS Results

EPRDC050

TOTAL At Power CDF

No.	Prob.	%	Event	Description
119	4.697E-10	0.09	IE FIRE-SAB14-AC CLE24EQ001LB03N S CLE24EQ002LB01N S CVCS VCT PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) Digital output module fails (non-self-monitored) Digital output module fails (non-self-monitored) CVCS Switchover to IRWST May Not Be Required Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
120	4.697E-10	0.09	IE FIRE-SAB14-AC CLF24EQ001LB02N S CLF24EQ002LB03N S CVCS VCT PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) Digital output module fails (non-self-monitored) Digital output module fails (non-self-monitored) CVCS Switchover to IRWST May Not Be Required Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
121	4.697E-10	0.09	IE FIRE-SAB14-AC CLE24EQ001LB03N S CLE24EQ002LB03N S CVCS VCT PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) Digital output module fails (non-self-monitored) Digital output module fails (non-self-monitored) CVCS Switchover to IRWST May Not Be Required Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
122	4.697E-10	0.09	IE FIRE-SAB14-AC CLE24EQ001LB01N S CLE24EQ002LB03N S CVCS VCT PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) Digital output module fails (non-self-monitored) Digital output module fails (non-self-monitored) CVCS Switchover to IRWST May Not Be Required Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
123	4.697E-10	0.09	IE FIRE-SAB14-AC CLF24EQ001LB03N S CLF24EQ002LB01N S CVCS VCT PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) Digital output module fails (non-self-monitored) Digital output module fails (non-self-monitored) CVCS Switchover to IRWST May Not Be Required Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
124	4.697E-10	0.09	IE FIRE-SAB14-AC CLF24EQ001LB03N S CLF24EQ002LB03N S CVCS VCT PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) Digital output module fails (non-self-monitored) Digital output module fails (non-self-monitored) CVCS Switchover to IRWST May Not Be Required Probability of Seal LOCA Occurring Given a Loss of Seal Cooling

MCS Results

EPRDC050

TOTAL At Power CDF

No.	Prob.	%	Event	Description
125	4.697E-10	0.09	IE FIRE-SAB14-AC CLE24EQ001LB01N S CLE24EQ002LB02N S CVCS VCT PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) Digital output module fails (non-self-monitored) Digital output module fails (non-self-monitored) CVCS Switchover to IRWST May Not Be Required Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
126	4.697E-10	0.09	IE FIRE-SAB14-AC CLF24EQ001LB01N S CLF24EQ002LB01N S CVCS VCT PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) Digital output module fails (non-self-monitored) Digital output module fails (non-self-monitored) CVCS Switchover to IRWST May Not Be Required Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
127	4.697E-10	0.09	IE FIRE-SAB14-AC CLE24EQ001LB03N S CLE24EQ002LB02N S CVCS VCT PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) Digital output module fails (non-self-monitored) Digital output module fails (non-self-monitored) CVCS Switchover to IRWST May Not Be Required Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
128	4.697E-10	0.09	IE FIRE-SAB14-AC CLF24EQ001LB03N S CLF24EQ002LB02N S CVCS VCT PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) Digital output module fails (non-self-monitored) Digital output module fails (non-self-monitored) CVCS Switchover to IRWST May Not Be Required Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
129	4.697E-10	0.09	IE FIRE-SAB14-AC CLF24EQ001LB02N S CLF24EQ002LB02N S CVCS VCT PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) Digital output module fails (non-self-monitored) Digital output module fails (non-self-monitored) CVCS Switchover to IRWST May Not Be Required Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
130	4.697E-10	0.09	IE FIRE-SAB14-AC CLF24EQ001LB01N S CLF24EQ002LB03N S CVCS VCT PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) Digital output module fails (non-self-monitored) Digital output module fails (non-self-monitored) CVCS Switchover to IRWST May Not Be Required Probability of Seal LOCA Occurring Given a Loss of Seal Cooling

MCS Results

EPRDC050

TOTAL At Power CDF

No.	Prob.	%	Event	Description
131	4.697E-10	0.09	IE FIRE-SAB14-AC CLE24EQ001LB01N S CLE24EQ002LB01N S CVCS VCT PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) Digital output module fails (non-self-monitored) Digital output module fails (non-self-monitored) CVCS Switchover to IRWST May Not Be Required Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
132	4.697E-10	0.09	IE FIRE-SAB14-AC CLE24EQ001LB02N S CLE24EQ002LB01N S CVCS VCT PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) Digital output module fails (non-self-monitored) Digital output module fails (non-self-monitored) CVCS Switchover to IRWST May Not Be Required Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
133	4.697E-10	0.09	IE FIRE-SAB14-AC CLF24EQ001LB02N S CLF24EQ002LB01N S CVCS VCT PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) Digital output module fails (non-self-monitored) Digital output module fails (non-self-monitored) CVCS Switchover to IRWST May Not Be Required Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
134	4.697E-10	0.09	IE FIRE-SAB14-AC CLE24EQ001LB02N S CLE24EQ002LB03N S CVCS VCT PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) Digital output module fails (non-self-monitored) Digital output module fails (non-self-monitored) CVCS Switchover to IRWST May Not Be Required Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
135	4.609E-10	0.09	IE FIRE-SAB14-AC CVCS VCT PED10AN002EFS_DCCF -123 PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) CVCS Switchover to IRWST May Not Be Required DCCF to Start Standby Cooling Tower Fans Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
136	4.535E-10	0.09	IE FIRE-SAB-MECH LOOPFCSD+REC OPF-SAC-2H QKA10GH001_FS	Initiator - Fire in the Pump Room of Any Safeguard Building Consequential LOOP and Failure of Recovery Within 1 Hour for Fire IEs Leading to a Controlled Shutdn Operator Fails to Recover Room Cooling Locally SCWS, Train 1 Chiller Unit QKA10GH001, Fails to Start on Demand
137	4.321E-10	0.08	IE SLOCA CCWS/ESWS PM3 JND10AP001EFR_D -124 OPE-FCD-40M	Initiator - Small LOCA (0.6 to 3-Inch Diameter) CCWS/ESWS Train 3 Pump Unavailable due to Preventive Maintenance CCF of MHSI Pumps to Run Operator Fails to Initiate Fast Cooldown for SLOCA

MCS Results

EPRDC050

TOTAL At Power CDF

No.	Prob.	%	Event	Description
138	4.321E-10	0.08	IE SLOCA CCWS/ESWS PM2 JND10AP001EFR_D CCF of MHSI Pumps to Run -134 OPE-FCD-40M	Initiator - Small LOCA (0.6 to 3-Inch Diameter) CCWS/ESWS Train 2 Pump Unavailable due to Preventive Maintenance Operator Fails to Initiate Fast Cooldown for SLOCA
139	4.234E-10	0.08	IE LBOP OPF-SAC-2H QKA10AP107EFR_ D-ALL	Initiator - Loss of Balance of Plant - Closed Loop Cooling Water or Aux Cooling Water Operator Fails to Recover Room Cooling Locally CCF of SCWS Pumps to Run
140	4.215E-10	0.08	IE LOOP EFWS PM4 OPF-SAC-2H QKA10GH001_FS REC OSP 2HR XKA30____DFR	Initiator - Loss Of Offsite Power EFWS Train 4 Unavailable due to Preventive Maintenance Operator Fails to Recover Room Cooling Locally SCWS, Train 1 Chiller Unit QKA10GH001, Fails to Start on Demand Failure to Recover Offsite Power Within 2 Hours ELEC, Emergency Diesel Generator XKA30, Fails to Run
141	4.215E-10	0.08	IE LOOP EFWS PM1 OPF-SAC-2H QKA40GH001_FS REC OSP 2HR XKA20____DFR	Initiator - Loss Of Offsite Power EFWS Train 1 Unavailable due to Preventive Maintenance Operator Fails to Recover Room Cooling Locally SCWS, Train 4 Chiller Unit QKA40GH001, Fails to Start on Demand Failure to Recover Offsite Power Within 2 Hours ELEC, Emergency Diesel Generator XKA20, Fails to Run
142	4.214E-10	0.08	IE FIRE-SWGR OPF-SAC-2H SAC02/QKA20 PM2 SAC34AN001EFR	Initiator - Fire in the Switchgear Building Operator Fails to Recover Room Cooling Locally Normal SAC02/QKA20 Train Unavailable due to Preventive Maintenance SAC, Normal Air Exhaust Fan SAC34AN001, Fails to Run
143	4.214E-10	0.08	IE FIRE-SWGR OPF-SAC-2H SAC03/QKA30 PM3 SAC31AN001EFR	Initiator - Fire in the Switchgear Building Operator Fails to Recover Room Cooling Locally Normal SAC03/QKA30 Train Unavailable due to Preventive Maintenance SAC, Normal Air Exhaust Fan SAC31AN001, Fails to Run
144	4.214E-10	0.08	IE FIRE-SWGR OPF-SAC-2H SAC01/QKA10 PM1 SAC04AN001EFR	Initiator - Fire in the Switchgear Building Operator Fails to Recover Room Cooling Locally Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance SAC, Normal Air Supply Fan SAC04AN001, Fails to Run
145	4.214E-10	0.08	IE FIRE-SWGR OPF-SAC-2H SAC04/QKA40 PM4 SAC31AN001EFR	Initiator - Fire in the Switchgear Building Operator Fails to Recover Room Cooling Locally Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance SAC, Normal Air Exhaust Fan SAC31AN001, Fails to Run

MCS Results

EPRDC050

TOTAL At Power CDF

No.	Prob.	%	Event	Description
146	4.214E-10	0.08	IE FIRE-SWGR	Initiator - Fire in the Switchgear Building
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			SAC04/QKA40 PM4	Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance
			SAC32AN001EFR	SAC, Normal Air Exhaust Fan SAC32AN001, Fails to Run
147	4.214E-10	0.08	IE FIRE-SWGR	Initiator - Fire in the Switchgear Building
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			SAC01/QKA10 PM1	Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
			SAC03AN001EFR	SAC, Normal Air Supply Fan SAC03AN001, Fails to Run
148	4.214E-10	0.08	IE FIRE-SWGR	Initiator - Fire in the Switchgear Building
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			SAC02/QKA20 PM2	Normal SAC02/QKA20 Train Unavailable due to Preventive Maintenance
			SAC04AN001EFR	SAC, Normal Air Supply Fan SAC04AN001, Fails to Run
149	4.214E-10	0.08	IE FIRE-SWGR	Initiator - Fire in the Switchgear Building
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			SAC01/QKA10 PM1	Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
			SAC34AN001EFR	SAC, Normal Air Exhaust Fan SAC34AN001, Fails to Run
150	4.214E-10	0.08	IE FIRE-SWGR	Initiator - Fire in the Switchgear Building
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			SAC01/QKA10 PM1	Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
			SAC33AN001EFR	SAC, Normal Air Exhaust Fan SAC33AN001, Fails to Run
151	4.214E-10	0.08	IE FIRE-SWGR	Initiator - Fire in the Switchgear Building
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			SAC01AN001EFR	SAC, Normal Air Supply Fan SAC01AN001, Fails to Run
			SAC04/QKA40 PM4	Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance
152	4.214E-10	0.08	IE FIRE-SWGR	Initiator - Fire in the Switchgear Building
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			SAC02AN001EFR	SAC, Normal Air Supply Fan SAC02AN001, Fails to Run
			SAC04/QKA40 PM4	Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance
153	4.214E-10	0.08	IE FIRE-SWGR	Initiator - Fire in the Switchgear Building
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			SAC01AN001EFR	SAC, Normal Air Supply Fan SAC01AN001, Fails to Run
			SAC03/QKA30 PM3	Normal SAC03/QKA30 Train Unavailable due to Preventive Maintenance

MCS Results

EPRDC050

TOTAL At Power CDF

No.	Prob.	%	Event	Description
154	4.180E-10	0.08	IE SLBI SG4 PRES CCF-123	Initiator - Steam Break Inside Containment CCF of SG4 pressure sensors
155	4.180E-10	0.08	IE SLBI SG4 PRES CCF-124	Initiator - Steam Break Inside Containment CCF of SG4 pressure sensors
156	4.180E-10	0.08	IE SLBI SG4 PRES CCF-134	Initiator - Steam Break Inside Containment CCF of SG4 pressure sensors
157	4.180E-10	0.08	IE SLBI SG4 PRES CCF-234	Initiator - Steam Break Inside Containment CCF of SG4 pressure sensors
158	4.126E-10	0.08	IE GT LOOPCON+REC OPF-SAC-2H QKA10GH001_FS QKA40GH001_FS	Initiator - General Transient (Includes Turbine Trip and Reactor Trip) Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram Operator Fails to Recover Room Cooling Locally SCWS, Train 1 Chiller Unit QKA10GH001, Fails to Start on Demand SCWS, Train 4 Chiller Unit QKA40GH001, Fails to Start on Demand
159	4.112E-10	0.08	IE GT LOOPCON+REC XKA10____DFR_D -ALL XKA50____DFR XKA80____DFR	Initiator - General Transient (Includes Turbine Trip and Reactor Trip) Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram CCF of EDGs to Run ELEC, SBO Diesel Generator XKA50, Fails to Run ELEC, SBO Diesel Generator XKA80, Fails to Run
160	4.072E-10	0.08	IE FLD-SAB14 FB LOOPCSD+REC OPF-SAC-2H SAC01/QKA10 PM1	Initiator - Flood in Safeguard Building 1 or 4 (Pump Room) Including Fuel Building Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to a Controlled Shutdown Operator Fails to Recover Room Cooling Locally Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
161	4.034E-10	0.08	IE LOOP LAS11AP001EFR REC OSP 2HR XKA10____DFR_D -ALL XKA80____DFR	Initiator - Loss Of Offsite Power EFWS, Train 1 Motor Driven Pump LAS11AP001, Fails to Run Failure to Recover Offsite Power Within 2 Hours CCF of EDGs to Run ELEC, SBO Diesel Generator XKA80, Fails to Run
162	4.034E-10	0.08	IE LOOP LAS41AP001EFR REC OSP 2HR XKA10____DFR_D -ALL XKA50____DFR	Initiator - Loss Of Offsite Power EFWS, Train 4 Motor Driven Pump LAS41AP001, Fails to Run Failure to Recover Offsite Power Within 2 Hours CCF of EDGs to Run ELEC, SBO Diesel Generator XKA50, Fails to Run

MCS Results

EPRDC050

TOTAL At Power CDF

No.	Prob.	%	Event	Description
163	3.966E-10	0.08	IE FIRE-SAB14-AC	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4)
			LOOPFCSD+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for Fire IEs Leading to a Controlled Shutdn
			OPF-XTLDSBO-NS C	Operator Fails to Connect and Load SBO DGs to Div 1 or 4 During Non-SBO Conditions
			PROB SEAL LOCA XKA10_____DFR	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling ELEC, Emergency Diesel Generator XKA10, Fails to Run
164	3.959E-10	0.08	IE GT	Initiator - General Transient (Includes Turbine Trip and Reactor Trip)
			BTD01_BAT__ST_D -ALL	CCF of Safety Related Batteries on Demand
			LOOPCON+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram
165	3.908E-10	0.07	IE GT	Initiator - General Transient (Includes Turbine Trip and Reactor Trip)
			LOOPCON+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			QKA10GH001_FR_ B-ALL	CCF of the Air Cooled SCWS Chiller Units to Run
166	3.840E-10	0.07	IE FIRE-SAB14-AC	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4)
			EDG PM2	EDG Train 2 Unavailable due to Preventive Maintenance
			LOOP24+REC	Loss Of Offsite Power During Mission Time and Failure of Recovery Within 1 Hour
			OPF-XTDIV-NSC	Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
167	3.746E-10	0.07	IE LOOP	Initiator - Loss Of Offsite Power
			OPF-XTLDSBO-2H	Operator Fails to Connect and Load SBO DGs to Div 1 and 4
			REC OSP 2HR	Failure to Recover Offsite Power Within 2 Hours
			XKA10_____DFR_D -ALL	CCF of EDGs to Run
168	3.744E-10	0.07	IE FIRE-SAB-MECH	Initiator - Fire in the Pump Room of Any Safeguard Building
			LOOP24+REC	Loss Of Offsite Power During Mission Time and Failure of Recovery Within 1 Hour
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			SAC01/QKA10 PM1	Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
169	3.677E-10	0.07	IE GT	Initiator - General Transient (Includes Turbine Trip and Reactor Trip)
			LOOPCON+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			QKA40GH001_FR	SCWS, Train 4 Chiller Unit QKA40GH001, Fails to Run
			SAC01/QKA10 PM1	Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance

MCS Results

EPRDC050

TOTAL At Power CDF

No.	Prob.	%	Event	Description
170	3.677E-10	0.07	IE GT	Initiator - General Transient (Includes Turbine Trip and Reactor Trip)
			LOOPCON+REC	Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			QKA10GH001_FR	SCWS, Train 1 Chiller Unit QKA10GH001, Fails to Run
			SAC04/QKA40 PM4	Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance
171	3.632E-10	0.07	IE LOOP	Initiator - Loss Of Offsite Power
			31BNB01___RFR	ELEC, 480V AC to 24V DC Rectifier for MCC 31BNB01 Control Power, Fails to Run
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			REC OSP 2HR	Failure to Recover Offsite Power Within 2 Hours
			SAC04/QKA40 PM4	Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance
172	3.632E-10	0.07	IE LOOP	Initiator - Loss Of Offsite Power
			34BNB01___RFR	ELEC, 480V AC to 24V DC Rectifier for MCC 34BNB01 Control Power, Fails to Run
			OPF-SAC-2H	Operator Fails to Recover Room Cooling Locally
			REC OSP 2HR	Failure to Recover Offsite Power Within 2 Hours
			SAC01/QKA10 PM1	Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
173	3.620E-10	0.07	IE LOOP	Initiator - Loss Of Offsite Power
			JEB10AA010EFC	RCP, RCP1 Leakoff Isolation MOV JEB10AA010, Fails to Close on Demand
			OPE-FCD-40MSBO	Operator Fails to Initiate Fast Cooldown for RCP During SBO Conditions
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
			REC OSP 1HR	Failure to Recover Offsite Power Within 1 Hour
			XKA10___DFR_D -ALL	CCF of EDGs to Run
174	3.620E-10	0.07	IE LOOP	Initiator - Loss Of Offsite Power
			JEB30AA010EFC	RCP, RCP3 Leakoff Isolation MOV JEB30AA010, Fails to Close on Demand
			OPE-FCD-40MSBO	Operator Fails to Initiate Fast Cooldown for RCP During SBO Conditions
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
			REC OSP 1HR	Failure to Recover Offsite Power Within 1 Hour
			XKA10___DFR_D -ALL	CCF of EDGs to Run
175	3.620E-10	0.07	IE LOOP	Initiator - Loss Of Offsite Power
			JEB10AA020EFC	RCP Seal, RCP1 Seal Nitrogen Venting Isolation MOV JEB10AA020, Fails to Close on Demand
			OPE-FCD-40MSBO	Operator Fails to Initiate Fast Cooldown for RCP During SBO Conditions
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
			REC OSP 1HR	Failure to Recover Offsite Power Within 1 Hour
XKA10___DFR_D -ALL	CCF of EDGs to Run			

MCS Results

EPRDC050

TOTAL At Power CDF

No.	Prob.	%	Event	Description
176	3.620E-10	0.07	IE LOOP	Initiator - Loss Of Offsite Power
			JEB20AA020EFC	RCP Seal, RCP2 Seal Nitrogen Venting Isolation MOV JEB20AA020, Fails to Close on Demand
			OPE-FCD-40MSBO	Operator Fails to Initiate Fast Cooldown for RCP During SBO Conditions
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
			REC OSP 1HR	Failure to Recover Offsite Power Within 1 Hour
			XKA10____DFR_D	CCF of EDGs to Run
			-ALL	
177	3.620E-10	0.07	IE LOOP	Initiator - Loss Of Offsite Power
			JEB40AA010EFC	RCP, RCP4 Leakoff Isolation MOV JEB40AA010, Fails to Close on Demand
			OPE-FCD-40MSBO	Operator Fails to Initiate Fast Cooldown for RCP During SBO Conditions
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
			REC OSP 1HR	Failure to Recover Offsite Power Within 1 Hour
			XKA10____DFR_D	CCF of EDGs to Run
			-ALL	
178	3.620E-10	0.07	IE LOOP	Initiator - Loss Of Offsite Power
			JEB40AA020EFC	RCP Seal, RCP4 Seal Nitrogen Venting Isolation MOV JEB40AA020, Fails to Close on Demand
			OPE-FCD-40MSBO	Operator Fails to Initiate Fast Cooldown for RCP During SBO Conditions
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
			REC OSP 1HR	Failure to Recover Offsite Power Within 1 Hour
			XKA10____DFR_D	CCF of EDGs to Run
			-ALL	
179	3.620E-10	0.07	IE LOOP	Initiator - Loss Of Offsite Power
			JEB30AA020EFC	RCP Seal, RCP3 Seal Nitrogen Venting Isolation MOV JEB30AA020, Fails to Close on Demand
			OPE-FCD-40MSBO	Operator Fails to Initiate Fast Cooldown for RCP During SBO Conditions
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
			REC OSP 1HR	Failure to Recover Offsite Power Within 1 Hour
			XKA10____DFR_D	CCF of EDGs to Run
			-ALL	
180	3.620E-10	0.07	IE LOOP	Initiator - Loss Of Offsite Power
			JEB20AA010EFC	RCP, RCP2 Leakoff Isolation MOV JEB20AA010, Fails to Close on Demand
			OPE-FCD-40MSBO	Operator Fails to Initiate Fast Cooldown for RCP During SBO Conditions
			PROB SEAL LOCA	Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
			REC OSP 1HR	Failure to Recover Offsite Power Within 1 Hour
			XKA10____DFR_D	CCF of EDGs to Run
			-ALL	

MCS Results

EPRDC050

TOTAL At Power CDF

No.	Prob.	%	Event	Description
181	3.607E-10	0.07	IE FIRE-SAB14-AC CVCS VCT KAA12AA005EFO_DCCF to Open CCWS to LHSI HTX Cooling MOV -123 PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) CVCS Switchover to IRWST May Not Be Required KAA12AA005EFO_DCCF to Open CCWS to LHSI HTX Cooling MOV -123 Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
182	3.606E-10	0.07	IE SLOCA LOOPCONL+REC OPE-FB-40M OPF-XTDIV-NSC XKA20____DFR XKA30____DFR	Initiator - Small LOCA (0.6 to 3-Inch Diameter) Consequential LOOP and Failure of Recovery Within 1 Hour for LOCA IEs Operator Fails to Initiate Feed & Bleed for SLOCA Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions ELEC, Emergency Diesel Generator XKA20, Fails to Run ELEC, Emergency Diesel Generator XKA30, Fails to Run
183	3.518E-10	0.07	IE FIRE-SAB14-AC LOOPFCSD+REC OPF-XTDIV-NSC PEB20AP001EFS PROB SEAL LOCA	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) Consequential LOOP and Failure of Recovery Within 1 Hour for Fire IEs Leading to a Controlled Shutdn Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions ESWS, Train 2 Motor Driven Pump PEB20AP001, Fails to Start on Demand Probability of Seal LOCA Occurring Given a Loss of Seal Cooling
184	3.467E-10	0.07	IE LOMFW LOOPCON+REC OPF-SAC-2H QKA10GH001_FS_ B-ALL	Initiator - Total Loss of Main Feedwater Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram Operator Fails to Recover Room Cooling Locally CCF of the Air Cooled SCWS Chiller Units to Start
185	3.428E-10	0.07	IE GT 31BTD01_BATST LOOPCON+REC OPF-SAC-2H SAC04/QKA40 PM4	Initiator - General Transient (Includes Turbine Trip and Reactor Trip) ELEC, 250V 1E 2-hr Battery 31BTD01, Fails on Demand Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram Operator Fails to Recover Room Cooling Locally Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance
186	3.428E-10	0.07	IE GT 34BTD01_BATST LOOPCON+REC OPF-SAC-2H SAC01/QKA10 PM1	Initiator - General Transient (Includes Turbine Trip and Reactor Trip) ELEC, 250V 1E 2-hr Battery 34BTD01, Fails on Demand Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram Operator Fails to Recover Room Cooling Locally Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
187	3.342E-10	0.06	IE SLBI APU4 CCF NS-ALL	Initiator - Steam Break Inside Containment CCF of APU-4 Protection System Computer Processors (Non-Self-Monitored)

MCS Results

EPRDC050

TOTAL At Power CDF

No.	Prob.	%	Event	Description
188	3.342E-10	0.06	IE SLBI ALU-B CCF NS-ALL	Initiator - Steam Break Inside Containment CCF of ALU-B Protection System Computer Processors (Non-Self-Monitored)
189	3.341E-10	0.06	IE LOOP LAS11AP001EFR LAS21AP001EFR OPF-SAC-2H REC OSP 2HR SAC04/QKA40 PM4	Initiator - Loss Of Offsite Power EFWS, Train 1 Motor Driven Pump LAS11AP001, Fails to Run EFWS, Train 2 Motor Driven Pump LAS21AP001, Fails to Run Operator Fails to Recover Room Cooling Locally Failure to Recover Offsite Power Within 2 Hours Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance
190	3.341E-10	0.06	IE LOOP LAS31AP001EFR LAS41AP001EFR OPF-SAC-2H REC OSP 2HR SAC01/QKA10 PM1	Initiator - Loss Of Offsite Power EFWS, Train 3 Motor Driven Pump LAS31AP001, Fails to Run EFWS, Train 4 Motor Driven Pump LAS41AP001, Fails to Run Operator Fails to Recover Room Cooling Locally Failure to Recover Offsite Power Within 2 Hours Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance
191	3.326E-10	0.06	IE LOMFW CF LOMFW/SSS OPF-SAC-2H SAC31AN001EFR_ D-ALL	Initiator - Total Loss of Main Feedwater Common Factor LOMFW/SSS Operator Fails to Recover Room Cooling Locally CCF to Run Normal Air Exhaust Fans
192	3.326E-10	0.06	IE LOMFW CF LOMFW/SSS OPF-SAC-2H SAC01AN001EFR_ D-ALL	Initiator - Total Loss of Main Feedwater Common Factor LOMFW/SSS Operator Fails to Recover Room Cooling Locally CCF to Run Normal Air Supply Fans
193	3.262E-10	0.06	IE LOMFW LOOPCON+REC OPF-SAC-2H QKA10GH001_FS SAC04/QKA40 PM4	Initiator - Total Loss of Main Feedwater Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram Operator Fails to Recover Room Cooling Locally SCWS, Train 1 Chiller Unit QKA10GH001, Fails to Start on Demand Normal SAC04/QKA40 Train Unavailable due to Preventive Maintenance
194	3.262E-10	0.06	IE LOMFW LOOPCON+REC OPF-SAC-2H QKA40GH001_FS SAC01/QKA10 PM1	Initiator - Total Loss of Main Feedwater Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram Operator Fails to Recover Room Cooling Locally SCWS, Train 4 Chiller Unit QKA40GH001, Fails to Start on Demand Normal SAC01/QKA10 Train Unavailable due to Preventive Maintenance

MCS Results

EPRDC050

TOTAL At Power CDF

No.	Prob.	%	Event	Description
195	3.182E-10	0.06	IE FIRE-SAB14-AC LOOPFCSD+REC OPF-XTDIV-NSC PROB SEAL LOCA XKA20____DFS	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) Consequential LOOP and Failure of Recovery Within 1 Hour for Fire IEs Leading to a Controlled Shutdn Operator Fails to Xtie Division 1 to Division 2 or Division 4 to Division 3 During Non-SBO Conditions Probability of Seal LOCA Occurring Given a Loss of Seal Cooling ELEC, Emergency Diesel Generator XKA20, Fails to Start on Demand
196	3.133E-10	0.06	IE FIRE-SAB14-AC EDG PM1 LOOPFCSD+REC PROB SEAL LOCA XKA50____DFR	Initiator - Fire in Switchgear Room of Safeguard Building 1 (or 4) EDG Train 1 Unavailable due to Preventive Maintenance Consequential LOOP and Failure of Recovery Within 1 Hour for Fire IEs Leading to a Controlled Shutdn Probability of Seal LOCA Occurring Given a Loss of Seal Cooling ELEC, SBO Diesel Generator XKA50, Fails to Run
197	3.024E-10	0.06	IE GT EFWS PM4 LOOPCON+REC XKA10____DFR_D -ALL XKA50____DFR	Initiator - General Transient (Includes Turbine Trip and Reactor Trip) EFWS Train 4 Unavailable due to Preventive Maintenance Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram CCF of EDGs to Run ELEC, SBO Diesel Generator XKA50, Fails to Run
198	3.024E-10	0.06	IE GT EFWS PM1 LOOPCON+REC XKA10____DFR_D -ALL XKA80____DFR	Initiator - General Transient (Includes Turbine Trip and Reactor Trip) EFWS Train 1 Unavailable due to Preventive Maintenance Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram CCF of EDGs to Run ELEC, SBO Diesel Generator XKA80, Fails to Run
199	3.024E-10	0.06	IE GT LOOPCON+REC SBODG5 PM1 XKA10____DFR_D -ALL XKA80____DFR	Initiator - General Transient (Includes Turbine Trip and Reactor Trip) Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram SBO-DG Train 1 Unavailable due to Preventive Maintenance CCF of EDGs to Run ELEC, SBO Diesel Generator XKA80, Fails to Run
200	3.024E-10	0.06	IE GT LOOPCON+REC SBODG8 PM4 XKA10____DFR_D -ALL XKA50____DFR	Initiator - General Transient (Includes Turbine Trip and Reactor Trip) Consequential LOOP and Failure of Recovery Within 1 Hour for IEs Leading to Auto Scram SBO-DG Train 4 Unavailable due to Preventive Maintenance CCF of EDGs to Run ELEC, SBO Diesel Generator XKA50, Fails to Run

U.S. EPR Final Safety Analysis Report Markups

- Group 23 represents cutsets resulting from an SLBO, followed by a CCF to close MSIVs resulting in all four SGs uncontrolled blowdown, and with operator failure to initiate EBS and control reactivity.

19-285

- The important CDF sequences for internal events are presented in Table 19.1-127—U.S. EPR Important Sequences – Level 1 Internal Events. The “important” CDF sequences are defined as those sequences with a sequence frequency greater than one percent of total at-power CDF, as presented in Section 19.1.8.1. For each sequence, Table 19.1-127 gives corresponding event tree, sequence number, event tree sequence identifier, the sequence frequency, and a brief description. It also connects the sequence to the corresponding cutset group in Table 19.1-7, which gives a more detailed description of the sequences.

19.1.4.1.2.4 Significant SSC, Operator Actions and Common Cause Events

Table 19.1-8—U.S. EPR Risk-Significant Equipment based on FV Importance - Level 1 Internal Events through Table 19.1-11—U.S. EPR Risk-Significant Human Actions based on RAW Importance - Level 1 Internal Events shows the important contributors to the internal CDF. Importance is based on the Fussell-Vesely (FV) importance measure ($FV \geq 0.005$), or the risk achievement worth (RAW) importance measure ($RAW \geq 2$).

- Table 19.1-8 shows the risk-significant structures, systems and components (SSC) based on the FV importance measure. The components with the highest FV are the EDG trains and air chiller unit trains. The most important SSC can be explained by a high LOOP contribution to the total CDF and by an importance of the HVAC system in the SB 1 and SB 4 (the location of the running CCW pumps).
- Table 19.1-9—U.S. EPR Risk-Significant Equipment based on RAW Importance - Level 1 Internal Events shows the risk-significant SSC based on the RAW importance measure. The two most important events are the EFW storage tanks and 250V DC buses. Their high RAW rank can be explained by their high reliability and by a high consequence of their failures. A failure (a leak) of an EFW tank, if not isolated, would disable all EFW; failure of the Division 4 DC Bus would disable all Division 4 after a LOOP, and would also disable fault isolations in this division (all breaks are assumed to occur in Division 4)
- Table 19.1-10—U.S. EPR Risk-Significant Human Actions based on FV Importance - Level 1 Internal Events shows the risk-significant human actions based on FV importance. The most important operator action based on the FV is the operator failure to recover room cooling locally given the loss of ventilation. This importance illustrates the importance of the HVAC system. This action, that follows any failure of ventilation to the SBs, shows in cutsets that contribute 43 percent to the total CDF.
- Table 19.1-11—U.S. EPR Risk-Significant Human Actions based on RAW Importance - Level 1 Internal Events shows the risk-significant human actions based on RAW importance. The most important human action based on RAW is, again, the operator failure to recover room cooling locally given the loss of

specific failure pattern 1 above, a loss of Divisions 1 and 4, associated with the running CCW trains, could, if not recovered in time, lead to a loss of two additional safety divisions. All EFW and the possibility to perform feed-and-bleed will be lost, leading to core damage.

Group 5 represents a sequence with a loss of all feedwater and an operator failure to initiate feed and bleed. A flood in the TB disables the MFW and the SSS, followed by an independent CCF of the EFW pumps to start.

Groups 6, 8, 9 and 10 represent the RCP seal LOCA sequences following a flood in the SB 1 or SB 4 including the FB. As explained in flood-specific failure pattern 1 above, a flood in SB 1 or SB 4 results directly in a loss of CCW CH2 and consequently in a loss of seal cooling to two RCPs (the seal injection is disabled because of the flood propagation to the FB, which hosts the CVCS). A failure to isolate seals for one of those two RCPs leads to a seal LOCA with an assumed probability of 0.2. The mechanism by which mitigation of the seal LOCA is failed differs slightly between these groups. It involves either a failure of long-term cooling of the IRWST by the LHSI heat exchanger (the SAHRS is unavailable due to the flood), or failure of MHSI to inject. In Table 19.1-41, which accounts for the top 100 cutsets, seal LOCA sequences contribute to 6.4 percent of the flooding CDF. Overall, a consequential seal LOCA accounts for about 30 percent of the flooding CDF.

Groups 7 and 12 represent sequences when floods caused by pipe breaks in the EFWS result in a complete loss of feedwater. Since the four EFW tanks are connected and are required for a successful core cooling during a 24-hour mission time, a break in any of the trains has the potential to drain the full inventory unless the operator isolates the break and initiates makeup with the demineralized water system (DWS). The DWS is a non-safety system that relies on offsite power. Therefore, a consequential LOOP following the flooding event will fail the makeup. Since it also fails the MFW and the SSS, all feedwater is lost. Failure of feed-and-bleed, either due to an operator failure to initiate the action (Group 7) or due to a failure of required systems (Group 12, a CCF of all EDGs to run), results in core damage.

Group 11 represents a single cutset that combines a flood in SB 4, with independent failures of HVAC to Division 2, MHSI pump Division 1, and PAS (disables MFW and SSS). This leads to a failure of three divisions (2, 3 and 4), a failure of MSRTs because of electrical dependencies (see Section 19.1.4.1.1.3), and only one EFW train being available when two are needed to remove decay heat through MSSVs. Feed and bleed fails because the only available MHSI pump fails independently.

19-285

The important CDF sequences for internal floods are presented in Table 19.1-128—U.S. EPR Important Sequences – Level 1 Flooding Events. The “important” CDF sequences are defined as those sequences with a sequence frequency greater than one percent of total at-power CDF, as presented in Section 19.1.8.1. For each sequence,

**Table 19.1-127—U.S. EPR Important Sequences – Level 1 Internal Events
Sheet 1 of 3**

<u>Event Tree</u>	<u>Seq. Num</u>	<u>RS Sequence ID</u>	<u>Seq. Freq (1/yr)</u>	<u>Description</u>	<u>Corresponding Cutsets</u>	
					<u>Table Number</u>	<u>Group Number</u>
<u>LOOP</u>	<u>14</u>	<u>LOOP-REC</u> <u>LOOP-EFW-PBL</u>	<u>8.58E-08</u>	<u>A LOOP event, no recovery of OSP in 2 hours; followed by failures of EFW system and pressure relief for feed and bleed function (dominated by HVAC related failures).</u>	<u>19.1-7</u>	<u>1, 2</u>
<u>GT</u>	<u>15</u>	<u>GT-MFW-SSS-EFW-PBL</u>	<u>2.02E-08</u>	<u>A plant trip with a consequential LOOP (no recovery) and subsequent MFW and SSS failures, followed by failures of EFW system and pressure relief for feed and bleed function (dominated by HVAC related failures).</u>	<u>19.1-7</u>	<u>18, 19</u>
<u>SLOCA</u>	<u>17</u>	<u>SLOCA-SSS-EFW-OP FB</u>	<u>1.95E-08</u>	<u>An SLOCA event with failures of SSS and EFW systems (dominated by a failure of PCD function); followed by an operator failure to initiate F&B.</u>	<u>19.1-7</u>	<u>9, 10</u>
<u>SLOCA</u>	<u>34</u>	<u>SLOCA-MHSL-OP FCD</u>	<u>1.73E-08</u>	<u>An SLOCA event with a failure of all MHSL system, followed by an operator failure to initiate FCD.</u>	<u>19.1-7</u>	<u>8</u>
<u>LOOP</u>	<u>45</u>	<u>LOOP-EDG-REC</u> <u>LOOP-SBO</u>	<u>1.66E-08</u>	<u>A LOOP event, no recovery of OSP in 2 hours; with a failure of all EDGs and both SBO DGs leading to a total blackout.</u>	<u>19.1-7</u>	<u>4</u>
<u>LOOP</u>	<u>44</u>	<u>LOOP-EDG-REC</u> <u>LOOP-EFW</u>	<u>1.12E-08</u>	<u>A LOOP event, no recovery of OSP in 2 hours; with a failure of all EDGs (SBO conditions), followed by a EFW system failure (F&B is not possible in SBO conditions).</u>	<u>19.1-7</u>	<u>5, 6</u>
<u>SLBI</u>	<u>40</u>	<u>SLBI-MSIV</u> <u>ISO(3)-FW ISO</u>	<u>1.04E-08</u>	<u>An SLBI event, followed by a failure of all MS/FW isolation (dominated by common cause software failure of protection system group B).</u>	<u>19.1-7</u>	<u>15</u>



Table 19.1-127—U.S. EPR Important Sequences – Level 1 Internal Events
Sheet 2 of 3

<u>Event Tree</u>	<u>Seq. Num</u>	<u>RS Sequence ID</u>	<u>Seq. Freq (1/yr)</u>	<u>Description</u>	<u>Corresponding Cutsets</u>	
					<u>Table Number</u>	<u>Group Number</u>
<u>SGTR</u>	<u>18</u>	<u>SGTR-SG ISO-OP RHR</u>	<u>9.72E-09</u>	<u>An SGTR event with a failure to isolate the faulted SG and operator failure to depressurize RCS and initiate RHR.</u>	<u>19.1-7</u>	<u>16</u>
<u>ATWS</u>	<u>12</u>	<u>ATWS-PSR</u>	<u>9.36E-09</u>	<u>An ATWS event, pressure relief was not credited for ATWS events w/o MFW</u>	<u>19.1-7</u>	<u>17</u>
<u>LOOP</u>	<u>53</u>	<u>LOOP-EDG-RCP</u> <u>LOCA-REC</u> <u>LOOP-OP FCD</u>	<u>7.24E-09</u>	<u>A LOOP event, no recovery of OSP in 2 hours, with a failure of all EDGs (SBO conditions), followed by a seal LOCA and operator failure to initiate a FCD (MHSI not available in SBO conditions).</u>	<u>19.1-7</u>	<u>7</u>
<u>GT</u>	<u>14</u>	<u>GT-MFW-SSS- EFW-MHSI 01</u>	<u>6.78E-09</u>	<u>A plant trip with a consequential LOOP (no recovery) and subsequent MFW and SSS failures, followed by failures of EFW and MHSI system (MHSI is failing a feed and bleed function).</u>	<u>19.1-7</u>	<u>20, 21</u>
<u>SLBI</u>	<u>17</u>	<u>SLBI-FW ISO- EFW</u>	<u>6.78E-09</u>	<u>An SLBI event, followed by a failure of FW isolation and EFW (F&B not credited).</u>		
<u>SLBI</u>	<u>30</u>	<u>SLBI-MSIV ISO- FW ISO-EFW</u>	<u>6.49E-09</u>	<u>An SLBI event, followed by a failure of one MS line and FW isolation (2 SG blowing down) and EFW failure (F&B not credited).</u>		
<u>LOOP</u>	<u>11</u>	<u>LOOP-REC</u> <u>LOOP-EFW- LHSI-SAHR</u>	<u>6.39E-09</u>	<u>A LOOP event, no recovery of OSP in 2 hours, with failure of EFW, feed and bleed fails by lack of long term heat removal (no LHSI or SAHR)</u>		

↑
19-285

Table 19.1-127—U.S. EPR Important Sequences – Level 1 Internal Events
Sheet 3 of 3

<u>Event Tree</u>	<u>Seq. Num</u>	<u>RS Sequence ID</u>	<u>Seq. Freq (1/yr)</u>	<u>Description</u>	<u>Corresponding Cutsets</u>	
					<u>Table Number</u>	<u>Group Number</u>
<u>SLOCA</u>	<u>20</u>	<u>SLOCA-MHSI-ACC</u>	<u>6.24E-09</u>	<u>An SLOCA event, with a failure of MHSI system and accumulators (dominated by a failure to open MHSI/ACC/LHSI common discharge check valves).</u>	<u>19.1-7</u>	<u>11</u>
<u>LOOP</u>	<u>56</u>	<u>LOOP-EDG-I&C</u>	<u>5.63E-09</u>	<u>A LOOP event where a loss of all 1E 2hr batteries prevents starting of EDGs and results in loss of all instrumentation. Given that no instrumentation is available, OSP recoveries or SBO DGs (controlled from 12-hour batteries) are not credited.</u>	<u>19.1-7</u>	<u>3</u>
<u>LOOP</u>	<u>30</u>	<u>LOOP-RCP LOCA-REC LOOP-EFW-OP FB</u>	<u>5.48E-09</u>	<u>A LOOP event, no recovery of OSP in 2 hours, followed by an RCP LOCA, a failure of EFW and an operator failure to initiate feed and bleed.</u>		
<u>LOOP</u>	<u>29</u>	<u>LOOP-RCP LOCA-REC LOOP-EFW-PBL</u>	<u>5.38E-09</u>	<u>A LOOP event, no recovery of OSP in 2 hours, followed by an RCP LOCA, and failures of EFW system and pressure relief for feed and bleed function.</u>		
<u>LOOP</u>	<u>52</u>	<u>LOOP-EDG-RCP LOCA-REC LOOP-EFW</u>	<u>5.31E-09</u>	<u>A LOOP event, no recovery of OSP in 2 hours, with a failure of all EDGs (SBO conditions), followed by an RCP LOCA, and a failure of EFW</u>		



19-285