



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

November 2, 2009

LICENSEE: Exelon Generation Company, LLC (Exelon)
FACILITY: Three Mile Island Nuclear Station, Unit 1
SUBJECT: SUMMARY OF OCTOBER 19, 2009, MEETING WITH EXELON TO DISCUSS
GENERIC LETTER 2004-02 SUPPLEMENTAL RESPONSE REQUEST FOR
ADDITIONAL INFORMATION (TAC NO. MC4724)

On September 23, 2009, a Category 1 public meeting was held by teleconference between the U.S. Nuclear Regulatory Commission (NRC) and representatives of Exelon Generation Company, LLC (Exelon, the licensee). The purpose of the meeting was to discuss remaining issues identified during NRC staff review of the Three Mile Island, Unit 1 (TMI-1) Generic Letter (GL) 2004-02 supplemental response. A listing of the issues of concern can be found in NRC letter dated July 23, 2009, available at Agencywide Documents Access and Management System (ADAMS) Accession No. ML091890848. The meeting was a follow-up to teleconference meetings held on August 11, 2009 (meeting summary available at ADAMS Accession No. ML092250551), and September 23, 2009 (meeting summary available at ADAMS Accession No. ML092670503). The meeting was intended to give Exelon the opportunity to explain their proposed approach for responding to the NRC staff's concerns. The meeting was also intended to give the NRC staff the opportunity to provide feedback regarding the licensee's proposed approach and to provide a mechanism for the NRC and Exelon to come to a mutual agreement on the remaining steps toward resolution of the outstanding GL 2004-02 issues for TMI-1.

The licensee's approach to one of the TMI-1 specific issues, contained in the NRC request for additional information (RAI), letter dated July 23, 2009, was discussed in detail. This was the issue regarding sump de-aeration potential. During the discussion of this question, the NRC staff provided feedback to the licensee regarding the acceptability of the proposed approach for analyzing void conditions at the sump recirculation pump suction.

No proprietary information was discussed at the meeting. Two members of the public were in attendance, both of whom made comments to the NRC staff. One comment was directly answered and one was flagged for follow-up by the NRC project manager after the meeting. A list of attendees is provided in the enclosure.

Please direct any inquiries to me at 301-415-2833 or peter.bamford@nrc.gov.

A handwritten signature in black ink that reads "Peter Bamford". The signature is written in a cursive style with a large, looped initial "P".

Peter Bamford
Plant Licensing Branch I-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-289

Enclosure:
List of Attendees

cc w/encls: Distribution via ListServ

LIST OF ATTENDEES

OCTOBER 19, 2009, MEETING WITH EXELON GENERATION COMPANY, LLC

THREE MILE ISLAND, UNIT 1

GENERIC LETTER 2004-02 SUPPLEMENTAL RESPONSE

EXELON

Todd Wickel
Pat Bennett
Rich Sievers
Wendi Croft
Brian Davenport
Keith Boring
Adam Miller
Vasilios Zeppos

NRC

Stewart Bailey
Stephen Smith
John Lehning
Peter Bamford

PUBLIC

Eric Epstein, TMI Alert
Marjorie Aamodt

Enclosure

Please direct any inquiries to me at 301-415-2833 or peter.bamford@nrc.gov.

/ra/

Peter Bamford
Plant Licensing Branch I-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-289

Enclosure:
List of Attendees

cc w/encls: Distribution via ListServ

DISTRIBUTION:

PUBLIC
Branch Reading
RidsAcrsAcnw_MailCTR Resource
RidsNrrDorlLpII-2 Resource
RidsOgcRp Resource

RidsNrrPMThreeMileIsland Resource
RidsNrrLAABaxter Resource
RidsRgnlMailCenter Resource
CTucci, NRR

SSmith, NRR
SBailey, NRR
JLehning, NRR
LTrocine, EDO Region 1

ADAMS Accession Nos.: Package ML092950142; Meeting Notice ML092730623; Meeting Summary ML092950158

OFFICE	DORL/LPLI-2/PM	DORL/LPLI-2/LA	NRR/SSIB/BC	DORL/LPLI-2/BC
NAME	PBamford	ABaxter	SBailey	HChernoff
DATE	10/22/09	10/26/09	10/27/09	11/2/09