

Official Transcript of Proceedings

NUCLEAR REGULATORY COMMISSION

Title:                   Advisory Committee on Reactor Safeguards  
                              Subcommittee on EPR

Docket Number:     (n/a)

Location:             Rockville, Maryland

Date:                  Thursday, February 18, 2010

Work Order No.:     NRC-069

Pages 1-303

**NEAL R. GROSS AND CO., INC.**  
**Court Reporters and Transcribers**  
**1323 Rhode Island Avenue, N.W.**  
**Washington, D.C. 20005**  
**(202) 234-4433**

UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION

+ + + + +

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS  
(ACRS)

+ + + + +

SUBCOMMITTEE ON EPR

+ + + + +

THURSDAY

FEBRUARY 18, 2010

+ + + + +

ROCKVILLE, MARYLAND

+ + + + +

The Subcommittee met, at the Nuclear  
Regulatory Commission, Two White Flint North, Room  
T2B1, 11545 Rockville Pike, at 8:30 a.m., Dr. Dana  
Powers, Chairman, presiding.

SUBCOMMITTEE MEMBERS PRESENT:

DANA A. POWERS, Chairman

GEORGE E. APOSTOLAKIS

WILLIAM J. SHACK

JOHN W. STETKAR

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1  
2 NRC STAFF PRESENT:

3 DEREK WIDMAYER, Cognizant Staff Engineer

4 JOE COLACCINO

5 THERON BROWN

6 SURINDER ARORA

7 ED McCANN

8 PETER KANG

9 JIM STECKEL

10 GETACHEW TESFAYE

11 TARUN ROY

12 KERRI KAVANAGH

13 HANH PHAN

14 LYNN MROWCA

15 DON DUBE  
16  
17  
18  
19  
20  
21  
22  
23  
24

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

ALSO PRESENT:

GREG GIBSON

MARK FINLEY

JEAN-LUC BEGON

JAMES PEACH

ROBERT STARK

JIM REDDY

MEL HESS

SANDRA SLOAN

MICHAEL SANIUK

JOHN McENTIRE

JOSHUA REINERT

DARRELL GARDNER

VESNA DIMITRIJEVIC

TIM STACK

VINCENT CORDOLIANI

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1

2

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

## C-O-N-T-E-N-T-S

Call to Order and Opening Remarks .....	7
Chair Dana Powers	
NRC Staff Introduction of Calvert	
Cliffs RCOL Application Review .....	8
Calvert Cliffs RCOL Application	
FSAR Chapter 8, Electric Power .....	20
Calvert Cliffs R-COLA SER with Open	
Items for Chapter 8, Electric Power .....	72
NRC Staff Introduction of EPR .....	95
DC Review	
U.S. EPR DC Application FSAR	
Chapter 17, Quality Assurance .....	111
U.S. EPR DC SER with Open Items	
for Chapter 17, Quality Assurance .....	158
U.S. EPR DC Application FSAR Chapter 19,	
PRA and Severe Accident Evaluation .....	177
Adjourn	

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

P-R-O-C-E-E-D-I-N-G-S

8:29 a.m.

CHAIR POWERS: (presiding) This is a meeting of the Advisory Committee on Reactor Safeguards, U.S. EPR Subcommittee.

I am Dana Powers, Chairman of the Subcommittee.

ACRS members in attendance include Bill Shack, John Stetkar, George Apostolakis. The esteemed Harold Ray was supposed to be here, but has not been found. And Said Abdel-Khalik will not be attending.

The purpose of the meeting is to begin our review of the Safety Evaluation Report with Open Items for the Combined Operating License Application for Calvert Cliffs Unit 3, which is the Reference COLA for the EPR design. Our initial NCR chapter for review is Chapter 8, Electric Power.

The Subcommittee will also continue its review of the SER with Open Items for the Design Certification Document submitted by AREVA NP for the U.S. EPR design.

We will hear presentations and discuss Chapter 17, Quality Assurance, and do a first

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 examination of Chapter 19, PRA and Severe Accident  
2 Evaluation.

3 The Subcommittee will hear presentations  
4 by and hold discussions with representatives of  
5 UniStar, AREVA NP, the NRC staff, and other  
6 interested persons regarding these matters.

7 The Subcommittee will gather relevant  
8 information today, but will not be formulating any  
9 findings on these matters at the conclusion of  
10 today's meetings. That's a little strategy we will  
11 explain in a different environment, I guess.

12 The Subcommittee plans to take the  
13 results of the reviews of these chapters, along with  
14 other chapters reviewed by the Subcommittee in other  
15 meetings, to the full Committee probably when we meet  
16 April 8th through 10th, 2010.

17 The rules for participation in today's  
18 meeting have been announced as part of the notice of  
19 this meeting, previously published in The Federal  
20 Register. We have received no written comments or  
21 requests for time to make oral statements from  
22 members of the public regarding today's meeting.

23 However, if people want to make  
24 statements, you need just to attract my attention and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 we will put you on the schedule at an appropriate  
2 point. And in fact, I encourage for a Subcommittee  
3 meeting, anytime people have comments they want to  
4 make, just to attract our attention, and we will  
5 recognize you as appropriate.

6 A transcript of the meeting is being kept  
7 and will be made available, as stated in The Federal  
8 Register notice. Therefore, we request that the  
9 participants in the meeting use the microphones  
10 located throughout the meeting room when addressing  
11 the Subcommittee. Participants should, first,  
12 identify themselves and speak with sufficient clarity  
13 and volume so they may be readily heard.

14 Copies of the meeting agenda and handouts  
15 should be available in the back of the meeting room.

16 We do have a telephone bridge line that  
17 has been established from the meeting room today, and  
18 I understand we have participants from AREVA on the  
19 line. We request participants on the bridge line to  
20 identify themselves when they speak and keep your  
21 telephone on mute during the times when you are just  
22 listening.

23 Do members of the Subcommittee have any  
24 opening comments they would care to make?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 (No response.)

2 I think, then, we can proceed with the  
3 meeting. We will start the meeting with some opening  
4 comments from Joe Colaccino, the Chief of the U.S.  
5 EPR Branch of NRO.

6 You will provide us some introductory  
7 comments?

8 MR. COLACCINO: Yes, sir, I will. Thank  
9 you very much.

10 Good morning, everybody.

11 I just wanted to let you know what is  
12 going to happen this morning. In particular, this is  
13 the first chapter that is coming forward to you on  
14 the Calvert Cliffs Reference COLA review. I am just  
15 going to speak to that just for a brief second.

16 Then I would like to have Surinder Arora,  
17 the Lead Project Manager, just walk through a little  
18 bit of the chronology, very briefly, of where we are  
19 at, so you can understand where we are at this point  
20 of the review.

21 Then we will ask the representatives of  
22 UniStar to describe their application. Then the  
23 staff will come and describe their review.

24 Dr. Apostolakis (sic), as you said, later

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 on this afternoon we will start, or later this  
2 morning we will start with, we will shift back to the  
3 EPR design certification. And from here on out, we  
4 hope to bring you a combination of Calvert Cliffs  
5 R-COL chapters and EPR DC chapters with a natural  
6 break in between, so that we understand what part,  
7 what application that we are all looking at.

8 We encourage your feedback on how this  
9 works. We don't want to throw too much stuff at you  
10 or make it confusing, and making sure that the  
11 members understand what application review that we  
12 are in.

13 MEMBER APOSTOLAKIS: It was actually Dr.  
14 Powers who said it, not me.

15 CHAIR POWERS: That's okay.

16 MEMBER APOSTOLAKIS: He pronounced the  
17 name correctly, so that is okay.

18 (Laughter.)

19 MEMBER STETKAR: They're easy names to  
20 confuse.

21 (Laughter.)

22 MR. COLACCINO: Excuse me.

23 CHAIR POWERS: No, that's okay. That's  
24 okay. Maybe it is because your name plate is right

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 in front of me.

2 (Laughter.)

3 MR. BROWN: Excuse me, Dana.

4 CHAIR POWERS: I heard somebody speaking.

5 MR. BROWN: Excuse me, Dana.

6 CHAIR POWERS: Yes.

7 MR. BROWN: It's Theron.

8 I need a one-minute dial into this  
9 bridge, please.

10 CHAIR POWERS: Please take that minute.

11 MR. BROWN: Okay, Dana.

12 CHAIR POWERS: Okay, we can now begin.

13 Joe, I agree with you, there's some real  
14 potential for confusion, and I will ask you and,  
15 indeed, everyone else, do keep us straight on this  
16 matter because the potential for the ACRS getting  
17 confused on this I think is non-zero.

18 MR. COLACCINO: And we want to be able  
19 to, because of the time that we have in front of the  
20 Committee, we want to make the best use of it.

21 CHAIR POWERS: Yes. I mean I think we  
22 need to do these things efficiently, and this is  
23 efficient. If it works, great. If it doesn't work,  
24 then we will do something else.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. COLACCINO: We know we won't ask for  
2 feedback because we will know you will give it to us.

3 CHAIR POWERS: Yes, absolutely.

4 (Laughter.)

5 MR. COLACCINO: With that, again, I will  
6 briefly go over where we are in this application  
7 review, since this is the first time you have seen  
8 Calvert Cliffs in front of the Committee.

9 So I am going to turn it over to the Lead  
10 Project Manager, Surinder Arora.

11 CHAIR POWERS: Please.

12 Mr. Arora --

13 MR. ARORA: Good morning.

14 CHAIR POWERS: -- before you begin your  
15 planned presentation, because I think this is one of  
16 the first times you have appeared in front of us, I  
17 would appreciate it if you would give us a little bit  
18 of your background.

19 MR. ARORA: Sure.

20 CHAIR POWERS: And just who you are and  
21 what you are all about, and then go into your  
22 prepared remarks.

23 MR. ARORA: Sure, we can do that.

24 My name is Surinder Arora, and I am the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Lead Project Manager for Calvert Cliffs Unit 3  
2 Combined License Application.

3 Prior to being assigned as Lead PM for  
4 Calvert Cliffs Unit 3 Application, I was the Lead PM  
5 for Calloway Unit 2 Application, the reviews on which  
6 are suspended currently, per request from the  
7 applicant.

8 Prior to joining NRC about three-and-a-  
9 half years ago, I worked with an architect  
10 engineering firm engaged in the design and  
11 construction of nuclear and fossil power plants. I  
12 worked for about 25 years there.

13 My educational background, I have a  
14 mechanical engineering degree, and I am a District  
15 Professional Engineer with the District of Columbia.

16 CHAIR POWERS: Okay. Very good.

17 MR. ARORA: Since this is the first  
18 presentation for the Calvert Cliffs Application, I  
19 wanted to give a little overview of the chronology,  
20 the order, where we are in the application and where  
21 we stand in terms of the reviews.

22 The first slide, which is slide No. 3  
23 sequentially, is the major milestone chronology.

24 We received the application in July 2007

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 because only Part 1 of the application contained the  
2 Environmental Report and siting information. Then,  
3 Part 1 was revised at the end of the year 2007.  
4 Then, in March 2008, another revision of Part 1 and  
5 the remaining application, Part 2, which contained  
6 the Final Safety Analysis Report, was submitted to  
7 the NRC.

8 Part 2 of the application was accepted  
9 for review, and the application was docketed in June  
10 '08.

11 Following that, we received three  
12 revisions, 3, 4, and 5, between August '08 and June  
13 '09, based on which we issued a detailed review  
14 schedule the middle of July 2009.

15 In September '09, we received revision 6  
16 of the application, which is the current latest  
17 revision. That is what the SER that we will be  
18 presenting is based on.

19 Phase 1 review completion milestone  
20 currently is scheduled for April 12, 2010, this year,  
21 and we expect to finish Phase 2 on several chapters,  
22 4, 5, 8, 12, and 17, by April 2010.

23 Today is the first one, 2/18 is the first  
24 day when ACRS begins the Phase 3 review, and the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 first chapter being presented is Chapter 8.

2 Next is the review schedule for each  
3 phase. This slide also provides the definition of  
4 all the six phases and with the target completion  
5 dates in the righthand column.

6 Currently, the final SER with no open  
7 items is scheduled for July 17, 2012.

8 CHAIR POWERS: But for the purposes of  
9 the Subcommittee, it appears that by July of 2011 you  
10 want a report from us on the Phase 3 review. We will  
11 do our very best.

12 MR. ARORA: The next slide that I am  
13 presenting provides the FSAR chapters by groups. The  
14 very first chapter is Chapter 8, which we are  
15 presenting in our Subcommittee today. There are six  
16 more chapters scheduled to go before the Committee,  
17 which have already been scheduled, and the meetings  
18 are scheduled for April and May for these chapters.  
19 The remaining 12 chapters, we are still going to be  
20 finalizing those dates for ACRS presentation.

21 And that brings me to the end of my brief  
22 general presentation about the application and the  
23 review status.

24 CHAIR POWERS: Actually, this is useful

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 to know what you think we are doing.

2 (Laughter.)

3 So I appreciate that.

4 MR. ARORA: Thank you.

5 CHAIR POWERS: Do members have any  
6 questions on this?

7 (No response.)

8 Go ahead. Greg, are you ready to begin?

9 MR. GIBSON: Yes, I am. Thank you very  
10 much, Dr. Powers.

11 I would like to thank the members of the  
12 ACRS for today's presentation. As Joe mentioned,  
13 this is the first of our chapters that we will be  
14 bringing before you for our COLA.

15 I would like to introduce myself. Again,  
16 I'm Greg Gibson. I'm the Vice President of  
17 Regulatory Affairs for UniStar Nuclear Energy.

18 I have a bachelor's degree, a master's  
19 degree, and an MBA, and have over 35 years of  
20 experience in licensing and regulatory affairs.

21 I originally started out with the Nuclear  
22 Regulatory Commission. I was an inspector in Regions  
23 2 and 3. Then I went on to San Onofre and worked for  
24 20 years out at San Onofre in various capacities in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1       licensing and compliance.

2               CHAIR POWERS:   The first plant --

3               MR. GIBSON:    Pardon?

4               CHAIR    POWERS:        The    first    plant,  
5       commercial plant, I ever toured was San Onofre 2.

6               MR. GIBSON:    A fine plant it is.

7               CHAIR POWERS:   It is a fine plant.   My  
8       experience is largely DOE reactors, and that was the  
9       first commercial unit I ever toured.

10              MR. GIBSON:   I also worked on a number of  
11       NEI   committees, including the Reactor Oversight  
12       Process.    I worked with Bill Borchardt on the  
13       revision to the enforcement policy and a number of  
14       joint things with the NRC, and I have had  
15       opportunities to meet almost everyone, including  
16       Commissioner-elect Apostolakis. So it has been nice.

17              CHAIR POWERS:   Elect?

18              (Laughter.)

19              MR. GIBSON:    The appropriate term for  
20       that.

21              MEMBER STETKAR:  The appropriate thing is  
22       if he is appointed.

23              (Laughter.)

24              CHAIR POWERS:   Confirmed.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: Confirmed. I'm sorry.

2 MR. GIBSON: After San Onofre, I went to  
3 the South Texas Project, where I worked for Units 3  
4 and 4. We were the team that submitted the first  
5 docketed combined operating license. Did such a good  
6 job, UniStar made me an offer I can't refuse, and I  
7 have been there for about a year and a half now,  
8 working with not only the R-COLA, but our S-COLAs,  
9 and working with our Design Center Working Group.

10 Again, we appreciate the opportunity to  
11 come before the Committee. It is our first one.

12 So I thought the first thing that we  
13 ought to put in a slide -- and I would like to go to  
14 the next one -- is to talk about the plant itself.  
15 It is the Reference COLA for the U.S. EPR.

16 Let's go ahead to the next slide.

17 It is located in Calvert County,  
18 Maryland, and it is on the same site as the Units 1  
19 and 2. As you can see here, Units 1 and 2 are here,  
20 and this will be the location of Unit 3 with our  
21 coolant tower.

22 The next slide, please.

23 The location of the site, as you may  
24 recall, which is about, for Unit 3, it will be about

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 2,070 acres, is located right adjacent to those  
2 units. It is about 50 miles from both Washington,  
3 D.C., and Baltimore.

4 The other information that Surinder went  
5 over with regard to the dates and milestones for the  
6 current published schedule, obviously, we are hoping  
7 we can beat those milestones and schedules, and can  
8 accelerate our review because we are very anxious to  
9 start building.

10 The next slide.

11 The construction of our R-COLA has been  
12 similar to others that I believe you have been  
13 familiar with. We have used the incorporate by  
14 reference to incorporate almost all of the EPR  
15 design. We have specifically taken, and proposed for  
16 our presentation here today, to talk about  
17 supplemental information, site-specific information,  
18 and departures from the EPR design certification that  
19 we incorporated by reference.

20 Next slide.

21 For Chapter 8, we have one departure from  
22 the EPR Certified Design. We understand from the  
23 staff that there are no NRC SER open items that will  
24 be presented today. We had no contentions.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1           So, our presentation will focus primarily  
2           on the COL items, the one departure, the site-  
3           specific supplemental information, and interface  
4           items.

5           Now, in addition, we were in attendance  
6           when you reviewed Chapter 8 for the EPR on the  
7           Certified Design. There were some discussion items  
8           that you had that would be deferred until now. So,  
9           we are aware of those and we have incorporated those  
10          into our presentation to facilitate discussion.  
11          Then, we also have a summary of where we are with our  
12          SER confirmatory items.

13          Next slide, please.

14          Today's presentation is with our team.  
15          We have a very strong team. Besides UniStar, we have  
16          AREVA, which is our EPR supplier, and Bechtel, which  
17          is our architect-engineer. We are also supported in  
18          our presentation today by PowerGEM, who has helped us  
19          with our grid reliability studies.

20          I will be introducing Mark Finley, Jean-  
21          Luc Begon, Sam Peach. We have others, and these will  
22          be our presenters, and they will, at the time they  
23          make their presentation, they will give their  
24          background/biography for you.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 But we also have Dave Jenner and James  
2 Reddy, Melvin Hess, and Johnny Willis here available  
3 to answer additional questions, if necessary.

4 CHAIR POWERS: There seemed to be a lot  
5 of revisions of the R-COLA --

6 MR. GIBSON: Yes.

7 CHAIR POWERS: -- early on. Was that a  
8 lack of guidance and understanding of what was  
9 required?

10 MR. GIBSON: No. Okay, let's take  
11 Revision 6. Revision 6, which was the last revision  
12 of the COLA, was to incorporate the changes into the  
13 R-COLA from Revision 1 of the certified Design.

14 Revision 5 of the R-COLA was the revision  
15 where we went through both the R-COLA and the  
16 S-COLA -- that would be the Bell Bend COLA, the Nine  
17 Mile COLA, and the Calloway COLA -- and aligned it,  
18 so that information which was what we call outside  
19 the braces, generic information in the R-COLA that  
20 applies to all of the plants, outside of the braces  
21 material is you pass the light test. You hold it up  
22 and it is word-for-word, typo-for-typo. It is  
23 absolutely identical. And then inside the braces.  
24 So that was Rev 5, which was to align the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 standardization.

2 Rev 4 was an earlier rev to bring it up-  
3 to-speed with a number of changes that we had in the  
4 geotech area.

5 So we have had an evolution, but it  
6 wasn't for lack of guidance. It was to ensure  
7 alignment and to assist the S-COLAs in the  
8 preparation of their reviews.

9 Next slide.

10 I would like to now turn it over to Mark  
11 Finley.

12 MR. FINLEY: Thank you, Greg.

13 Good morning, my name is Mark Finley. I  
14 am UniStar Engineering Deputy. I have been with  
15 UniStar for three years, essentially, the senior  
16 manager responsible for only engineering.

17 Prior to that, with Constellation Energy,  
18 mostly at the Calvert Cliffs site in various  
19 engineering positions. I was also, just prior to  
20 UniStar, the Power Uprate Manager for the Ginna Power  
21 Plant, and I was here in 2006 before the Committee.

22 A graduate from the United States Naval  
23 Academy, and a professional engineer in the State of  
24 Maryland.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 I thought, since this is the first time  
2 with you, I would explain a little bit about UniStar.

3 It is a joint venture between Constellation and EDF.

4 We think that gives us a great opportunity to blend  
5 experience from Constellation, which is a very strong  
6 owner/operator in this country, and EDF, also a very  
7 strong owner/operator in France, and, in addition, an  
8 architect-engineer involved with new nuclear power  
9 plants in France. So we are taking full benefit of  
10 this experience in the senior engineers from both  
11 companies.

12 UniStar Engineering is responsible for  
13 the design of Calvert Cliffs 3. Essentially, we  
14 oversee the work of AREVA and Bechtel primarily. We  
15 don't originate the work ourselves. We are a  
16 relatively small staff, about 25 engineers.

17 My professional engineer license is  
18 mechanical. So I am going to turn it over rather  
19 quickly to somebody better qualified to speak about  
20 electrical matters in Jean-Luc.

21 Jean-Luc, in fact, is the Manager of I&C  
22 and Electrical for UniStar, and he is from EDF, but  
23 he has experience on the latest series of new nuclear  
24 power plants in France, the N4 series, and he will

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 speak more about that.

2 We also have Sam Peach, who is the  
3 Electrical Engineering Supervisor from Bechtel,  
4 again, working on the detailed design for the Calvert  
5 Cliffs site in the onsite systems.

6 Jean-Luc will focus on the offsite  
7 systems presentation, and Sam will discuss the onsite  
8 engineering in the electrical area.

9 Jean-Luc?

10 MR. BEGON: Yes. Thank you, Mark.

11 Good morning, everyone.

12 My name is Jean-Luc Begon. I have been  
13 working for UniStar for nearly two years now. I am  
14 working for UNE Engineering, and, as Mark said, I am  
15 in charge of I&C and Electrical.

16 I have over 25 years' experience in power  
17 reactors with EDF. I started in the Operations  
18 Division of EDF as an operator, a reactor operator.  
19 Then, I moved to the Engineering Division of EDF, and  
20 I was involved in the engineering and startup of the  
21 last series of Pressurized Water Reactor in France,  
22 which is the N4 plant, which has a fully computerized  
23 man-machine interface.

24 So, as you noticed, my English is not to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the level of expectation. So, please feel free to  
2 ask me to repeat or to clarify, if you have any  
3 difficulty understanding my presentation.

4 MEMBER APOSTOLAKIS: We are not used to  
5 accents in this.

6 (Laughter.)

7 MR. BEGON: Next slide, please.

8 So, I will be presenting the offsite  
9 power systems. I would like to say I will be  
10 presenting the COLA information item, but to say what  
11 is specific to our COLA application. And also, the  
12 different items between the site-specific items for  
13 Calvert Cliffs Unit 3 and the plant which is a U.S.  
14 EPR plant.

15 As Greg mentioned before, we attended the  
16 ACRS meeting about U.S. EPR FSAR. Therefore, we will  
17 do our best to address some of the discussion items  
18 which were raised during this previous meeting.

19 Then, for onsite power and station  
20 blackout, I will hand it over to Sam Peach.

21 Next slide, please.

22 The COLA information items are the  
23 description of the site-specific information relating  
24 to the offsite transmission system and the interface

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 with the nuclear power plant for offsite power.

2 So, what we will be presenting in the  
3 next slide is a representation of the offsite  
4 transmission systems and the connections to the  
5 switchyard and then to the plant.

6 The next slide, please.

7 And we also present in our COLA the  
8 auxiliary power and generator transformer areas.

9 So, the next slide, please.

10 So, that is a single line diagram of the  
11 Calvert Cliffs switchyard. This switchyard will be  
12 owned and operated by Baltimore Gas and Electric,  
13 once it has been commissioned.

14 As you can see, the dotted line on top  
15 shows the limit, the point of interconnection between  
16 our auxiliary transformers, which are on the top, and  
17 the main transformer, which I will describe in more  
18 detail later, and the switchyard, which, as I  
19 mentioned, will be owned and operated by Baltimore  
20 Gas and Electric.

21 MEMBER STETKAR: Jean-Luc?

22 MR. BEGON: Yes.

23 MEMBER STETKAR: Are you going to talk  
24 about the actual offsite power connections to the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 site at all in your presentation? Or is it  
2 appropriate to ask about them now?

3 MR. BEGON: Yes, I am going to address  
4 the offsite power connection, to say there are 500-kV  
5 overhead transmission lines.

6 MEMBER STETKAR: Okay.

7 MR. BEGON: Does that answer your  
8 question?

9 MEMBER STETKAR: We'll see if we get to  
10 it. Thanks.

11 MR. BEGON: Yes, I will present that.  
12 Let me know if I answer your question.

13 So, at the bottom part of this single  
14 line diagram, you can see the four overhead 500 kV-  
15 transmission lines which will connect to Calvert  
16 Cliffs' switchyards. Two of them, these two there,  
17 are tied to Calvert Cliffs Switchyards 1 and 2, which  
18 is about 1.5 miles away.

19 Then, there is one 500-kV overhead  
20 transmission line to Waugh Chapel Substation, which  
21 is about 14 miles away from the site. Then, the  
22 fourth one, which is the Chalk Point, connecting to  
23 Chalk Point Substation, which is 18 miles away from  
24 the site.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           These four lines are on separate power  
2 towers, and they have adequate clearance between them  
3 to meet independence, as required by GDC-17.

4           MEMBER STETKAR: I looked ahead a little  
5 bit. I am going to stop you here right now then.

6           MR. BEGON: Yes.

7           MEMBER STETKAR: How many total  
8 transmission lines connect to the entire Calvert  
9 Cliffs site?

10          MR. BEGON: There are three lines  
11 connecting to Calvert Cliffs site.

12          MEMBER STETKAR: And are they routed  
13 along the same route of right-of-way? I didn't see  
14 any real diagram that shows the offsite power  
15 connections to the site in your presentation. So, I  
16 would like you to expand a little bit on the actual  
17 offsite power connections to the site, so that we  
18 understand how many transmission lines, because there  
19 are not four overhead transmission lines. There are  
20 only three lines to the site. Is that correct?

21          MR. BEGON: That's correct. If we  
22 consider the site being Calvert Cliffs 1 and 2 Units  
23 and the Calvert Cliffs 3 Unit, the offsite  
24 transmission lines are three. Okay? They is, in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 fact, one transmission line coming from Waugh Chapel,  
2 which will remain connected to Calvert Cliffs 1  
3 switchyard. Then, as mentioned, there is one from  
4 Waugh Chapel connecting to Calvert Cliffs 3 and one  
5 from Chalk Point connecting to Calvert Cliffs 3.

6 Chalk Point is on different power tower  
7 than Waugh Chapel transmission lines.

8 MEMBER STETKAR: Could you back up?

9 MR. BEGON: Yes.

10 MEMBER STETKAR: In the introduction, you  
11 had a little picture of the site.

12 MR. BEGON: Yes, we can back up.

13 MEMBER STETKAR: Could you show us where  
14 those transmission lines are actually routed, just  
15 for the benefit of the Committee members?

16 MR. BEGON: Slide No. 4, please. Yes,  
17 next slide. Yes.

18 MEMBER STETKAR: There you go.

19 MR. BEGON: So, here you see Chalk Point,  
20 in fact, Substation, and you see Waugh Chapel  
21 Substation. So, there are two lines coming from  
22 Waugh Chapel and connecting to the site, Calvert  
23 Cliffs site. So, one will remain connected to  
24 Calvert Cliffs 1, and one will connect to Calvert

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Cliffs 3. Then, there is one line coming from the  
2 Chalk Point Substation, which connects to Calvert  
3 Cliffs 1.

4 So, Chalk Point line and the Waugh Chapel  
5 lines are on different power towers. Okay? And as  
6 you can see here, for some part of the routine, they  
7 are on the same -- how do you say? -- route.

8 MEMBER STETKAR: Right-of-way. They are  
9 on the same common right-of-way?

10 MR. GIBSON: Up to a point, and then that  
11 is split.

12 MEMBER STETKAR: What is the distance of  
13 that common right-of-way?

14 MR. GIBSON: Bob, do you know?

15 (No audible response.)

16 Roughly, 12 miles.

17 MEMBER STETKAR: So, you don't have any  
18 other geographically-diverse lines that connect into  
19 the site from the west or the south?

20 MR. GIBSON: No.

21 MEMBER STETKAR: Okay. Thanks.

22 Loss of those two tower lines on the same  
23 right-of-way would be loss of offsite power to all  
24 three units then?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. GIBSON: Yes.

2 MEMBER STETKAR: Okay.

3 MR. BEGON: Can we go back to slide 12?  
4 Yes.

5 The next slide, please.

6 So, now I am going to present the  
7 connection between the Calvert Cliffs 3 switchyard  
8 and the unit. So, you can see there is a main step-  
9 up transformer. So, the main step-up transformer is  
10 made of three single-phase transformers of 700 MVA  
11 each. And the synchronizing to the grid will be done  
12 by either of these two breakers, which are E4 or E5.

13 Next slide, please.

14 There are three normal auxiliary  
15 transformers which supply the non-1E loads. These  
16 NATs are designed with the fast transfer scheme, to  
17 say, in case we have a loss of one transformer, the  
18 two others will take over the load and be able to  
19 supply all the non-1E auxiliaries of the plant.

20 Next slide, please.

21 MEMBER STETKAR: Can I?

22 MR. BEGON: Yes.

23 MEMBER STETKAR: Looking through my  
24 notes, you are getting into the kind of interface

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 between the switchyard, and I want to back you back  
2 up to the offsite power.

3 MR. BEGON: Yes.

4 MEMBER STETKAR: Does any one of those  
5 500-kV circuits -- you said there are three circuits,  
6 two on one tower line and one on another. Does any  
7 one of those 500-kV circuits have sufficient capacity  
8 to supply all three units?

9 In other words, suppose I lose two of  
10 those circuits and I am down to only one. You can  
11 interconnect the switchyards quite readily between  
12 Units 1 and 2 and 3. There are cross-ties. Can you  
13 handle all three units with one 500-kV circuit?

14 MR. BEGON: It is not a contingency we  
15 have examined. So I cannot --

16 MEMBER STETKAR: Thinking about, you  
17 know, a problem on that common tower line that takes  
18 out two 500-kV circuits, because it is common, and  
19 you are down to one 500-kV circuit now supplying all  
20 three units or trying to take power away from all  
21 three units also.

22 MR. BEGON: So, on a power protection  
23 point of view, I think it would be fair to say that I  
24 am not sure that we would be able to maintain the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 three units at full load. Okay? But it won't affect  
2 the ability of one to get their power supply from the  
3 grid. But to say that we won't have a loss of  
4 offsite power.

5 MEMBER STETKAR: But you might have to  
6 ramp back load to avoid overloading that single  
7 circuit?

8 MR. BEGON: Yes, that's right.

9 MEMBER STETKAR: Okay. I have to think  
10 about that. Thanks.

11 MR. BEGON: There are two emergency  
12 auxiliary transformers which are there to supply the  
13 one unit. EAT No. 1, which is on your left side,  
14 supplies Divisions 1 and 2 of the U.S. EPR, and No.  
15 2, on the right side, supplies Divisions 3 and 4.

16 As far as EATs, there is a fast transfer  
17 scheme which is able to supply all four divisions in  
18 case one EAT fails.

19 As you can see, they are designed to  
20 minimize the likelihood of similar test failure, and  
21 they have been arranged to be on both sides of the  
22 switchyard.

23 Next slide, please.

24 There is also one site-specific

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 transformer, which supplies some site-specific load,  
2 and Sam, in his presentation, will provide you with  
3 more details of what are supplied by these site-  
4 specific transformers.

5 Next slide, please.

6 So, our COLA provides, also, information  
7 about the switchyard layout design. So it is a 500-  
8 kV air-insulated switchyard.

9 Next slide, please.

10 So, it is a breaker-and-a-half  
11 configuration. So, it is made of two buses, each of  
12 them being able to accommodate the full load going  
13 through the switchyard.

14 Next slide, please.

15 And we have a breaker-and-a-half  
16 configuration. That is to say, each bus is connected  
17 through a bay, and this bay is made of three  
18 breakers, which can accommodate connection to two  
19 lines. So, three breakers, two separate, that is why  
20 this scheme is being called a breaker and a half.

21 Next slide, please.

22 Our collaborators provide a site-specific  
23 grid stability analysis. It provides this grid  
24 stability analysis for the following contingencies.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 That is to say, Calvert Cliffs 3 turbine trip; loss  
2 of the largest unit supplying the grid; loss of the  
3 largest transmission circuit or inter-tie, and loss  
4 of the largest load on the grid.

5 MEMBER STETKAR: But you didn't look at  
6 failure of the common tower line that has the two  
7 circuits on it? Is that correct?

8 MR. BEGON: That's correct.

9 Next slide, please.

10 MEMBER APOSTOLAKIS: Do you think that  
11 they should do it, John, or what?

12 MEMBER STETKAR: Yes.

13 (Laughter.)

14 I was going to ask the staff why they  
15 didn't ask for that, but I just wanted to make sure  
16 that I didn't miss anything.

17 MR. BEGON: So, a grid stability analysis  
18 was performed by PJM, using a PJM database. We  
19 brought this analysis further to answer to the NRC  
20 staff request for additional information, and it is  
21 why we got PowerGEM involved.

22 So far, there are four contingencies  
23 which are listed in the COL items. The analysis of  
24 the voltage and the frequency curves confirmed that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 we will not degrade voltage and frequency below a  
2 value which would activate the Emergency Power Supply  
3 System for degraded grid protection, and that the  
4 transmission system will not subject the reactor  
5 coolant pumps to a frequency decay greater than 3.5  
6 hertz per second.

7 CHAIR POWERS: Would you explain to me  
8 better what these two statements mean? You  
9 absolutely will not ever degrade below a level?

10 MR. BEGON: Yes. So, in fact, we made a  
11 study to make an analysis of the voltage and the  
12 frequency transient related to the four contingencies  
13 which we have listed. The analysis of the  
14 calculation confirmed that we didn't get to a voltage  
15 or frequency which would activate the Emergency Power  
16 Supply System degrading voltage protection from the  
17 plant.

18 CHAIR POWERS: That has to have some  
19 probabilistic aspect to it. I mean there's not a  
20 physical law that says that you will never do that.

21 MR. FINLEY: The physical aspect is  
22 really the four transients that you saw in a previous  
23 slide. That is basically the input assumption.

24 CHAIR POWERS: Okay. So, given the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 specified transients, I understand that better.

2 MR. BEGON: Yes.

3 CHAIR POWERS: And, similarly, the  
4 sustained degradation of frequency is for those  
5 transients?

6 MR. BEGON: Yes. Yes.

7 Next slide, please.

8 So, the COL information items provide  
9 information related to the control of the switchout  
10 breakers and the relay device.

11 So, we have a redundant protection scheme  
12 for the 500-kV lines, buses, and equipment, primary  
13 and backup. But to say, each break area has got two  
14 tripping coils, each of them connected to a separate  
15 protection scheme, which is supplied from a separate  
16 battery bank.

17 MEMBER STETKAR: Jean-Luc, you mentioned  
18 two tripping coils.

19 MR. BEGON: Yes.

20 MEMBER STETKAR: I have to ask you this.  
21 Do they also have redundant closing coils?

22 MR. BEGON: They don't have redundant  
23 closing coils.

24 MEMBER STETKAR: They do not?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. BEGON: No.

2 MR. PEACH: No, the standard design just  
3 has redundant tripping coils and just a single  
4 closing coil.

5 MEMBER STETKAR: So, what I am thinking  
6 about is operating the circuit breakers to restore  
7 power. You know, if you open up the switchyard and  
8 you have a problem with control power, you don't have  
9 redundancy for reclosing those breakers?

10 MR. PEACH: Not within a single breaker,  
11 but the way the breaker-and-a-half switchyard is  
12 configured, and this hasn't been fully detailed in  
13 the design yet, but we believe it is possible to  
14 build that redundancy into the system by --

15 MEMBER STETKAR: Redundant closing coils  
16 on either side of the red bus or the black bus?

17 MR. PEACH: Correct. Right.

18 MEMBER STETKAR: I would be interested to  
19 see whether you actually follow through with that  
20 because that could be important for not just  
21 protection. I mean you are well-projected against  
22 faults for clearing the switchyard.

23 MR. PEACH: Right.

24 MEMBER STETKAR: I'm concerned about

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 reclosing breakers after a protracted loss of offsite  
2 power, where you might get into degraded DC supplies  
3 and things like that.

4 MR. PEACH: Yes.

5 MR. BEGON: Maybe to illustrate Sam's  
6 answer, maybe we could go back to slide 19, if you  
7 don't mind. Can we please go back to slide 19? One  
8 nine, sorry.

9 So, as I mentioned, what is important is  
10 to be able to supply especially the 1E loads. And  
11 therefore, even if each breaker has got a one closing  
12 coil, you can never supply from breaker 1 or breaker  
13 2. However, that is the advantage of the half  
14 breaker scheme.

15 And in addition to that, we have also a  
16 redundancy because there are two emergency auxiliary  
17 transformers, and therefore, you can also do the same  
18 on this side, but to say you can also get power  
19 through these two breakers.

20 So, in fact, considering the emergency  
21 loads, there are four ways of getting power supply  
22 from the grids on a functional redundancy point of  
23 view.

24 MEMBER STETKAR: Yes, functionally, at

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that level, as long as, for example, if you have two  
2 DC power supplies out there in the switchyard, if you  
3 are judicious about organizing those DC power  
4 supplies among the breaker combinations, so that you  
5 don't have --

6 MR. BEGON: Yes.

7 MEMBER STETKAR: -- vulnerabilities to  
8 loss of a single DC supply.

9 MR. BEGON: Yes, that's right. Because,  
10 as Sam mentioned, it is not something we have  
11 committed in the COLA, but it is something we will do  
12 in detailed design.

13 MEMBER STETKAR: As long as I am talking  
14 about batteries, since you don't have the final  
15 design yet, perhaps you don't know. What is the  
16 rated life of the batteries, the switchyard  
17 batteries?

18 MR. BEGON: They are rated for eight  
19 hours.

20 MEMBER STETKAR: Eight hours?

21 MR. BEGON: Yes.

22 MEMBER STETKAR: Good. Thank you.

23 MR. BEGON: In fact, we have this slide  
24 because it was a discussion topic of the ACSR meeting

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 for the FSAR.

2 MEMBER STETKAR: Okay.

3 MR. BEGON: Can we have, yes, slide 22,  
4 please?

5 And whereas the scheme is ready, in case  
6 a breaker fails to open, the adjacent breakers will  
7 open. So that is a scheme which is provided with the  
8 switchyard design.

9 Next slide, please.

10 COLA information also provides a  
11 description of inspection and testing plan, which  
12 will be applied for the Calvert Cliffs 3 Unit.

13 So, as I mentioned before, it is  
14 Baltimore Gas and Electric which will be the operator  
15 of the switchyard, and BG&E conforms to FERC and NERC  
16 requirements. For that, the guidance is PRC 17  
17 guidance.

18 In addition to that, according to  
19 Maryland requirements, BG&E files and operation and  
20 maintenance report to the Maryland Public Service  
21 Commission, which is available on their website,  
22 where they describe in great details all the  
23 inspection and testing that they performed, and  
24 especially in the switchyard.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1           So, you have there in the COLA an outline  
2 of the main testing and inspection activities, which  
3 are new maintenance of the battery system, including  
4 some quarterly visual inspection.

5           The breaker inspection is based on in-  
6 service and operating history. They also perform  
7 thermography on an annual basis, which is not a  
8 requirement from the FERC and NERC, but is a  
9 commitment from BG&E to the State of Maryland.

10          Next slide, please.

11          MEMBER STETKAR: Let me stop you right  
12 there.

13          Are you familiar with the scope of  
14 station blackout equipment, let me call it controls,  
15 that has been discussed in the United States? I am  
16 thinking, particularly, we have had these discussions  
17 in terms of plant life extension.

18          There's concerns that the licensee should  
19 be responsible for testing and maintenance of the  
20 offsite power recovery paths out to something like  
21 the first active breaker in the switchyard.

22          I was curious, when you are describing  
23 testing and maintenance agreements between Calvert  
24 Cliffs and BG&E, is BG&E solely responsible for doing

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 all of the testing and maintenance on all of the  
2 equipment in the switchyard or is there also Calvert  
3 Cliffs plant-specific testing and maintenance on some  
4 equipment? If there is, I am curious about where  
5 that interface is and how it is accomplished.

6 MR. BEGON: Yes, if you don't mind, what  
7 I would suggest is that we ask Bob Stark from Calvert  
8 Cliffs Units 1 and 2 to expand on what is the process  
9 and the relationship with BG&E for Calvert Cliffs 1  
10 and 2.

11 MR. STARK: I'm Bob Stark, a consulting  
12 engineer at Calvert Cliffs Unit 1 and 2.

13 There is an interconnect agreement, and  
14 an operating committee interfaces between BG&E and  
15 Calvert Cliffs. The way the process works is any  
16 regulatory requirements outside of the NERC/FERC  
17 requirements that BG&E operates to are incorporated  
18 in the BG&E procedures. BG&E performs all the  
19 maintenance, but if there is anything additional or  
20 different that needs to be done, per NRC regulatory  
21 requirements, we interface and it is incorporated in  
22 their maintenance procedures.

23 MEMBER STETKAR: Okay. So, they actually  
24 do it --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. STARK: Yes.

2 MEMBER STETKAR: -- but you determine the  
3 scope of their procedures?

4 MR. STARK: We oversee it. That is  
5 correct.

6 MEMBER STETKAR: Okay. Thank you.

7 MR. BEGON: Thank you, Bob.

8 So, next slide, please.

9 Yes, this relates to the interface with  
10 PJM, which will be the agreed dispatcher. So, there  
11 is a manual which specifies what will be the  
12 communication between the site and PJM.

13 In order to identify any contingency,  
14 they use an EMS model, which is a real-time model  
15 which identifies for the actual situation of the grid  
16 and the N minus 1 contingency condition, the voltage  
17 limits, voltage and frequency that could happen on  
18 the grid.

19 And also, operators receive a simulator,  
20 I guess from training, to identify this grid  
21 condition and to be in a position to select the  
22 appropriate procedures.

23 Next slide, please.

24 MEMBER APOSTOLAKIS: Can you explain N

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 minus 1 contingency conditions quickly?

2 MR. BEGON: Yes. So, N minus 1 is what,  
3 you have an agreed configuration, and you identify  
4 what is the most severe contingency that you should  
5 consider, and make an analysis of what will be the  
6 result if you have a loss of this. For example, what  
7 is the most per grid line at the time, and in case  
8 you lose this line, what will be the effect on the  
9 grid? So, that is called the N minus 1. Say you  
10 lose the most severe part of the grid at a specific  
11 time.

12 MEMBER APOSTOLAKIS: And what's "N"? Is  
13 "N" a number or --

14 MR. BEGON: Yes, I guess "N" shows the  
15 present status of the grid, but to say you are in an  
16 N configuration.

17 MEMBER APOSTOLAKIS: Oh.

18 MR. BEGON: But to say all your lines are  
19 -- for example, if --

20 MEMBER APOSTOLAKIS: It's not the number  
21 then.

22 MR. BEGON: Then N minus 1 would be --

23 MEMBER APOSTOLAKIS: Normal.

24 MR. BEGON: Yes.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER APOSTOLAKIS: I'm sorry. N minus  
2 1, that's interesting.

3 MR. BEGON: Provide site-specific  
4 information regarding indication and controls. So,  
5 the control of the switchyard breakers would be  
6 shared between Calvert Cliffs Unit 3 and the BG&E.  
7 So, they can be, every control room a different  
8 control room of the system that is special.

9 There is also an interface related to the  
10 line protection for the main step-up transformer and  
11 the direct auxiliary transformer, which was actually  
12 the default.

13 And, yes, I won't come back, but, of  
14 course, in case a breaker fails to open, there is a  
15 scheme to trip the adjacent breakers.

16 Next slide, please.

17 MEMBER STETKAR: Jean-Luc?

18 MR. BEGON: Yes.

19 MEMBER STETKAR: We are talking about  
20 interfaces now between the site and PJM and BG&E.  
21 You mentioned the protocols that they have for the  
22 outside world, let's call it informing the site in  
23 case of degraded grid conditions and contingencies,  
24 and things like that.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 Are there any particular agreements in  
2 place regarding priorities for restoration of offsite  
3 power to the site in the event that all offsite power  
4 supplies should fail? I mean that would be either a  
5 BG&E or a PJM operation protocol, if you will.

6 I was just curious whether there was  
7 anything in place that had a prioritization scheme  
8 for recovery, you know, restoration of power. I know  
9 things are in place for hospitals and schools, and  
10 things like that. I was curious whether there was  
11 something --

12 MR. BEGON: I think there is, but I am  
13 not sure because I have not read the documents.

14 So, maybe, Bob, if you could help me on  
15 that?

16 MR. STARK: Bob Stark.

17 Yes, my understanding is nuclear plants  
18 are given priority in restoration, but there is no  
19 fixed time. They can't commit to a fixed time.

20 MEMBER STETKAR: Well, certainly, they  
21 can't commit to a fixed time.

22 MR. STARK: Right.

23 MEMBER STETKAR: But I was just curious  
24 whether there is actually some type of known written

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 protocol in place, so that the folks trying to  
2 recover from one of these blackouts know that.

3 MR. STARK: The PJM procedures have  
4 written guidance to restore the nuclear plants  
5 sooner.

6 MEMBER STETKAR: Okay.

7 MR. STARK: Yes.

8 MEMBER STETKAR: Okay. Thank you.

9 MR. BEGON: Yes, so, in this slide we  
10 will do our best to address some discussion items  
11 from the ACRS meeting on Chapter 8 for the FSAR.

12 So, there was some question with the  
13 failure mode and effect analysis about the  
14 switchyards. So the answer is, yes, as part of our  
15 submission to the COLA, we have provided a switchyard  
16 failure mode and effect analysis.

17 And the result, the main result, of this  
18 switchyard failure mode and effect analysis is that  
19 any loss of the transmission circuit, loss of a bus,  
20 or even failure of a breaker to open coincident with  
21 a line fault will lead to the loss of offsite power.

22 Next slide, please.

23 And that was your previous question about  
24 the duty cycle of the batteries for the switchyard,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 which is eight hours and which is consistent with the  
2 SBO configuration for Calvert Cliffs 3.

3 And I will now hand it over to Sam Peach  
4 for the onsite power.

5 MR. PEACH: Okay, thanks, Jean-Luc.

6 My name is Sam Peach. I work for Bechtel  
7 Power Corporation. I have 25-plus years of  
8 experience in the commercial power business.

9 I have worked domestic new construction  
10 at Grand Gulf Nuclear Station, international new  
11 construction at Shinshon can-do units in China, which  
12 just completed in 2003.

13 MEMBER STETKAR: The can-do units,  
14 though, at Shinshon?

15 MR. PEACH: Yes, sir.

16 In between there, I have had some  
17 experience with a lot of other different technologies  
18 and projects, including TMI2 recovery project,  
19 Florida Power and Light nuclear units, and  
20 Commonwealth Edison nuclear units.

21 I have spent the last three years working  
22 exclusively for UniStar U.S. EPR projects, Calvert  
23 Cliffs 3 COLA and, as Mark mentioned, the Calvert  
24 Cliffs 3 detailed design.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           What I would like to concentrate on today  
2           is the onsite power systems, and specifically the  
3           site-specific portions of that.

4           We define the onsite power system  
5           starting at the high side of the auxiliary  
6           transformers and coming into the plant. So, you saw  
7           that boundary of definition on one of Jean-Luc's  
8           earlier slides.

9           We will also cover some COL information  
10          items, and we will address some of the interface  
11          points between the standard design and the site-  
12          specific design that Jean-Luc has not covered  
13          already.

14                 MR. BEGON: Yes, next slide, please.

15                 MR. PEACH: Thank you.

16                 Okay, let's go one more slide, please.

17                 Okay. As Greg mentioned earlier, we do  
18          have one departure from the U.S. EPR FSAR. Calvert  
19          Cliffs 3 has a site-specific cooling tower for the  
20          Circ Water System. There is a Circ Water System  
21          cooling tower described in the U.S. EPR FSAR standard  
22          design.

23                 However, the site-specific design for the  
24          Calvert Cliffs conditions required us to change the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 modal horsepower and configuration of the  
2 distribution buses. So, they are slightly different  
3 than what is described in the DCD. So the COLA  
4 recognizes that change and this departure recognizes  
5 that change.

6 Next slide.

7 The onsite power systems, I think you  
8 recall -- I know that you have already heard an  
9 extensive presentation from AREVA on the onsite power  
10 system about the U.S. EPR. What I want to  
11 concentrate on today are the site-specific portions  
12 of that.

13 I think you will see that the site-  
14 specific portions at Calvert Cliffs dovetail very  
15 nicely into the standard plant design that was  
16 presented to you earlier.

17 MEMBER STETKAR: Was the last slide the  
18 only place that you are going to talk about that  
19 departure from the standard design?

20 MR. PEACH: It is. If you have a  
21 question on it, I can try to address that.

22 MEMBER STETKAR: Yes. The discussion in  
23 the FSAR and the SER notes that there is no changes  
24 in the bus loading because, although you have changed

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the voltage of the fans, you have reduced the number  
2 of fans, and if I do the math, the same number of  
3 kilowatts remain connected to the buses.

4 But there seemed to be some changes in  
5 the loading because there are small things like unit  
6 heaters and sump pumps out in the cooling tower make-  
7 up water building that add additional load.

8 And the FSAR load analysis doesn't really  
9 acknowledge that. It does a load analysis assuming  
10 that the cooling loads are on, but not the heating  
11 loads. In particular, there are unit heaters and  
12 sump pumps, as I mentioned.

13 I will admit that they are small loads,  
14 but they are an increase. So, for example, in the  
15 wintertime, when it is cold, and, for example, if  
16 this area ever had a large snowstorm with melting  
17 water -- (laughter) -- sump pumps might need to work.

18 CHAIR POWERS: Let's not go up into the  
19 totally hypothetical here.

20 (Laughter.)

21 MEMBER STETKAR: Or two snowstorms within  
22 a week.

23 (Laughter.)

24 I was curious why the load analysis in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the FSAR didn't acknowledge those additional loads.  
2 I will fully admit that they are small, but they are  
3 a plus; they are not a minus.

4 MR. PEACH: Right. I think that would be  
5 better answered by AREVA. Mel Hess can probably  
6 answer that a little bit better. AREVA relooked at  
7 these sites-specific loads.

8 MR. REDDY: My name is Jim Reddy. I'm  
9 with AREVA. I've been there on the EPR project for a  
10 little over three-and-a-half years.

11 What we did is, as you noted for the EDG  
12 tables there, the cooling loads or the heating loads,  
13 if you look at that individual table, would actually  
14 reflect a greater load.

15 What we were looking at is it is either  
16 going to be one or the other. You are either going  
17 to be in winter conditions or you are going to be in  
18 summer conditions.

19 In the Calvert Cliffs 3 tables that add  
20 the additional site-specific loading, in the summer  
21 conditions it would show -- or excuse me -- in the  
22 winter conditions with the heating loads, it would  
23 show more. But, in the overall context of the EDG  
24 loading, when you factor that in with the standard

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 plant, the winter loading -- or excuse me -- the  
2 summer loading with the cooling loads provides a  
3 greater load.

4 So, the overall loading, with the overall  
5 loading, it is greater when you factor in the  
6 standard plant. So, that is why --

7 MEMBER STETKAR: I thought I did that,  
8 and the winter loads for Calvert Cliffs still came  
9 out slightly higher.

10 MR. REDDY: For Calvert Cliffs, they do.  
11 But if you add in what the standard plan is, the  
12 summer loads are greater, which is why that is  
13 reflected in the Calvert Cliffs.

14 MEMBER STETKAR: I guess I am still a  
15 little confused because perhaps I didn't add  
16 correctly, but I thought I did that, correcting for  
17 the summer loads that were in the standard plant,  
18 subtracting those out, and then adding in the Calvert  
19 Cliffs winter loads, and I still came out with  
20 slightly higher.

21 Is the rating of each diesel in the final  
22 design 9,500 kilowatts?

23 MR. REDDY: Yes, it is.

24 MEMBER STETKAR: It is? Okay. So, you

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 still have design margin then, if I added correctly.

2 Okay, let's just go on. I'm still not  
3 clear that, indeed, the FSAR cooling loads bound the  
4 site-specific heating loads, but I can be convinced  
5 otherwise.

6 MR. PEACH: Okay. Well, this departure  
7 that we are speaking of, just to be clear, is just  
8 addressing the non-safety-related distribution system  
9 at the circ water towers.

10 MEMBER STETKAR: That's true, but it is  
11 still a departure from the design --

12 MR. PEACH: Yes.

13 MEMBER STETKAR: -- that is being  
14 licensed and certified.

15 MR. PEACH: Right. Yes.

16 MEMBER STETKAR: So, it is a difference  
17 in the design.

18 MR. PEACH: Yes.

19 MEMBER STETKAR: And it, in principle, is  
20 a departure from the licensed certified design.

21 MR. PEACH: Correct.

22 MEMBER STETKAR: So, we have to be  
23 assured that, indeed, that departure doesn't affect  
24 anything that might somehow affect safety.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. PEACH: Right. Absolutely.

2 MEMBER STETKAR: I have other questions  
3 about those cooling tower loads and the  
4 configuration, but I think it is probably better if  
5 you go into more of the actual configuration of the  
6 plant-specific new distribution.

7 MR. PEACH: Okay.

8 MEMBER STETKAR: And maybe we will get to  
9 that.

10 MR. PEACH: Okay. As I noted, just to  
11 review back from the U.S. EPR FSAR, we have,  
12 basically, two systems for the onsite power system,  
13 the NPSS or the Normal Power Supply System, which  
14 supplies all, most of the non-Class 1E loads onsite.  
15 And then we have the EPSS, or the Emergency Power  
16 Supply System, which supplies the safety-related  
17 loads onsite.

18 The COL action item you see here on the  
19 screen requires the applicant to identify the safety-  
20 related loads that might impact the EDG load profile,  
21 and, also, to identify the safety-related DC loads  
22 that would impact the safety-related battery system.

23 So those were done for Calvert Cliffs  
24 Unit 3. The additional site-specific loads for the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 EDGs are 22.3 kW, and the additional DC loads are .04  
2 kW for the battery.

3 Those loads were looked at and determined  
4 to be still within the design basis of the standard  
5 equipment sizing.

6 Next slide.

7 The COL information item has to do with  
8 moisture in underground duct banks and its effect on  
9 cables, cable installation. You are aware that the  
10 industry and the NRC are still working on this issue  
11 and trying to develop some specific guidance.

12 What is committed to in the COLA is that  
13 Calvert Cliffs Unit 3 will develop a program to  
14 identify all of the cables that are within the scope  
15 of the Maintenance Rule and develop a program to  
16 identify, inspect, test, monitor the critical  
17 parameters of those cables to ensure that the  
18 installation can still meet its design function.

19 This actual program would be developed a  
20 little bit further in the design process, after we  
21 have identified the specific cable compounds that are  
22 going to be used, the specific cable construction, as  
23 well as any guidance that is developed between now  
24 and that time by the industry and by the NRC.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 Next slide.

2 Still on that same subject, what we are  
3 committed to in the COLA is a design that tries to  
4 take into account the fact that there may be water,  
5 some of these cables may be exposed to water. So, we  
6 have tried to develop a two-tiered approach to  
7 dealing with that issue.

8 The first bullet on that slide identifies  
9 some design features that are going to try to prevent  
10 water intrusion into the duct banks and into the  
11 manholes.

12 The second bullet identifies design  
13 features that can deal with the water once it gets  
14 into the duct banks or the manholes.

15 MEMBER STETKAR: In the FSAR, the third  
16 item on that second bullet say that you are going to  
17 install sump pumps. Is that the current thinking?

18 MR. PEACH: Yes.

19 MEMBER STETKAR: It seemed not completely  
20 clear whether they were going to commit to installing  
21 sump pumps.

22 MR. PEACH: No, that is committed to in  
23 an RAI response, as required, I think, but there will  
24 be sump pumps required on this site.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: Thank you.

2 MR. PEACH: Next slide.

3 This sketch presents an overview of the  
4 extent of the underground cable routing on the  
5 Calvert Cliffs Unit 3 site. All of the connecting  
6 lines between the different buildings and between the  
7 different pieces of equipment indicate underground  
8 duct banks carrying electric cables. The colored  
9 lines indicate cables that serve as the different  
10 Divisions 1 through 4.

11 MEMBER STETKAR: This is not electrical,  
12 but I just want to ask and see if anyone has thought  
13 about it. The drawing that you show there does show  
14 some rather extensive underground cable connections  
15 outside of the area of the main power block.

16 MR. PEACH: Yes.

17 MEMBER STETKAR: Do you know whether the  
18 seismic analyses have evaluated relative motions of  
19 equipment and structures -- and I'm thinking  
20 primarily structures -- between the power block and  
21 the cable canals and other structures that they  
22 connect to? You know, I am talking seismic failures,  
23 basically, of the cable canals themselves, but  
24 primarily due to relative motions among the different

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 structures from the power block out through the  
2 places they connect to.

3 MR. PEACH: That part of the design has  
4 not been done yet, but that is something that  
5 absolutely has to be considered.

6 MEMBER STETKAR: Yes. I thought, again,  
7 it is not electrical. I just wanted to bring it up  
8 to get it on the record that we are interested to see  
9 that eventually.

10 MR. PEACH: That will definitely be a  
11 consideration in the design. The cables cannot break  
12 apart when the buildings -- the buildings will move  
13 relative to the cable duct banks; that is correct.

14 MEMBER STETKAR: Okay. Thank you. I'm  
15 sorry.

16 MR. PEACH: No problem.

17 CHAIR POWERS: But it is pertinent  
18 because one of the lessons we learned from the  
19 Japanese earthquake years back was relative  
20 motions --

21 MEMBER STETKAR: Yes.

22 CHAIR POWERS: -- and the ruptures are  
23 important factors.

24 MEMBER STETKAR: Well, and because this

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 is, you know, the routing and the lengths of those  
2 duct banks are, indeed, a very site-specific feature.

3 CHAIR POWERS: Right.

4 MEMBER STETKAR: So, that it is not  
5 pertinent to talk about it in terms of the license  
6 design under the DCD.

7 MR. PEACH: But that is a good point.  
8 Thank you.

9 Next slide, please.

10 This is just a cross-section of a typical  
11 duct bank that is proposed to be installed at Calvert  
12 Cliffs. This is pretty standard with the exception  
13 of the drain that is shown in the bottom of the duct  
14 bank there. This is something that we would use to  
15 convey water from higher points to lower points in  
16 the system.

17 Next slide.

18 And this gets back to the sump pump  
19 question. Some of the manholes will have  
20 permanently-installed sump pumps. These, of course,  
21 will be installed just at low points, and they will  
22 be equipped with, at a minimum, local alarm  
23 indication that there was water in that manhole and  
24 possibly remote indication as well.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: They would be automatic  
2 sump pumps?

3 MR. PEACH: Yes.

4 MEMBER STETKAR: Yes. Okay.

5 MR. PEACH: Next slide.

6 This COL information item that is on the  
7 screen now lays out the requirements that the COLA  
8 commits to, to maintain the EDG reliability targets.

9 Basically, those points in the program  
10 that will be developed are going to consist of  
11 regular maintenance testing, performance data  
12 collection and analysis. A lot of those details will  
13 have to be developed in consultation with the EDG  
14 manufacturer's recommendations as well.

15 Next slide.

16 This is some of the site-specific  
17 supplemental information. As we touched earlier,  
18 there are site-specific loads that are added to the  
19 Emergency Power Supply System or the Class 1E system  
20 on the plant.

21 The main additions to that system are the  
22 safety-related ultimate heat sink or essential  
23 service water makeup pumps, which are located at the  
24 intake structure, which is located approximately 3500

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 feet from the essential service water pumphouse  
2 equipment.

3 The four-train design that is present  
4 everywhere in the power block for safety systems is  
5 continued out to the UHS makeup structure. Four  
6 separate divisions of power feed four independent  
7 sets of equipment.

8 Next slide.

9 This is one line of the additional loads  
10 I just described. The back circled areas indicate  
11 the site-specific additions to the EPSS system.

12 Okay, next slide, please.

13 The site-specific supplemental  
14 information also continues to the Normal Power Supply  
15 System, the non-Class 1E system. We already  
16 discussed the site-specific changes to the hybrid  
17 cooling tower.

18 We also added a site-specific transformer  
19 that Jean-Luc mentioned earlier. That was added to  
20 be the primary power supply for the site-specific  
21 desalination plant and demineralization plant, the  
22 wastewater treatment facility, and the Circ Water  
23 System cooling tower dry fans.

24 Next slide.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1           This is a slide you saw earlier. The  
2 site-specific transformer is noted there on the left.

3           Next slide.

4           MEMBER STETKAR:     If that transformer  
5 fails, do you need to shut down Unit 3?

6           MR. PEACH:     No, we don't, and I can  
7 answer that question a little bit further on the next  
8 slide.

9           MEMBER STETKAR:   Sorry.

10          MR. PEACH:     Next.

11          Okay, this is a one-line. It is a little  
12 difficult to read, I think.

13          It shows the loads that are assigned to  
14 the site-specific transformer. Our criteria for  
15 assigning loads to the site-specific transformer were  
16 that they not be involved in power production.

17          If you go from left to right, the first  
18 breaker feeds the wastewater treatment facility. The  
19 next breaker feeds the desalination plant and  
20 demineralization facility. And that facility, you  
21 will see, does have an alternate feed. Because if  
22 the site-specific transformer feed is lost, for  
23 whatever reason, for an extended period, we would  
24 need an alternate feed to maintain power production.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: Okay. Thanks for being  
2 a good straight man.

3 I am glad you have this drawing up there.

4 That alternate feed comes up to Bus  
5 36BBD, I think. Right, that is an in-plant power  
6 block NPSS bus.

7 MR. PEACH: Right.

8 MEMBER STETKAR: It seems that that feed  
9 was added fairly late during the design process. It  
10 does not show up on all of the drawings in the FSAR.

11 To kind of telegraph -- this is going to  
12 be a question for the staff. The staff did an  
13 evaluation on the design changes and concluded that  
14 there were no additional loads on any of the buses.

15 This is an additional load on that 36BBd,  
16 if you are lined up in that alternate configuration,  
17 and it could be a fairly substantial additional load.

18 MR. PEACH: Uh-hum.

19 MEMBER STETKAR: So, I am curious whether  
20 the loading analyses on the 6.9-kV buses -- I think  
21 they are 6.9 kV; I could be wrong about that --  
22 account for that additional load. I didn't see any  
23 evidence that they did. It was kind of confusing  
24 because I kind of stumbled across that feed in this

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 drawing.

2 MR. PEACH: Right. I know that AREVA has  
3 looked at that feed as one of the load cases.

4 MEMBER STETKAR: Okay. Yes.

5 MR. PEACH: And it should show on all the  
6 figures. It should be consistent across all the  
7 figures.

8 MEMBER STETKAR: Yes, it is not. I don't  
9 have the figure numbers, but go back and check them.  
10 It doesn't show up on all of them.

11 Okay, and that is the basis for saying  
12 that, if you lose the transformer out in the  
13 switchyard, you can supply the demin water plant --

14 MR. PEACH: Correct.

15 MEMBER STETKAR: -- from this alternate  
16 feed?

17 MR. PEACH: Yes.

18 MEMBER STETKAR: Okay. Okay. Thank you.

19 MR. PEACH: And just to finish with this  
20 figure, the other two buses there on the right both  
21 support the cooling tower drive fans. Those fans are  
22 just used for plume abatement. So, there's no power  
23 production requirements there.

24 Next slide.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1           There will be some site-specific heat  
2 tracing required at Calvert Cliffs. This is  
3 primarily freeze protection for smaller lines,  
4 instrumentation-type tubing.

5           Next slide.

6           There's an interface item that is  
7 addressed in the COLA dealing with the lightning  
8 protection system and the grounding system grid.  
9 What is committed to be done is that the grounding  
10 grid and the lightning protection system would be  
11 designed in accordance with the standards set forth  
12 in the DCD, and those systems will be integrated  
13 systems where the grounding grid and the lightning  
14 protection system are designed and encompass any of  
15 the site-specific grounding requirements and site-  
16 specific structures under the lightning protection  
17 system.

18          Next slide.

19          Okay, we wanted to touch a little bit on  
20 station blackout, COL information items, and then  
21 some discussion items left over from the DCD review.

22          Next slide.

23          There's three COL information items  
24 associated with station blackout that are listed

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 here. They refer to restoring offsite power,  
2 identifying local power sources, and development of  
3 related procedures for station blackout mitigation.

4 Next slide.

5 These are the main points of how those  
6 are addressed in the COLA. There are no special load  
7 sources credited for SBO at Calvert Cliffs.

8 Training and procedures will include all  
9 operator actions required to mitigate the SBO coping  
10 period.

11 As Jean-Luc mentioned earlier, the coping  
12 period is eight hours. That is the same period as is  
13 laid out in the DCD standard design.

14 Next slide.

15 This is a point that was raised during  
16 the U.S. EPR FSAR ACRS meeting. Well, the question  
17 had to do with whether a common fuel oil storage tank  
18 was planned for Calvert Cliffs Unit 3 to support the  
19 onsite diesels. And the answer to that question is,  
20 no, there will not be an onsite fuel oil storage  
21 tank. The Calvert Cliffs design for the SBO, as well  
22 as the emergency diesels, incorporates the standard  
23 design, which has a dedicated fuel oil tank for each  
24 diesel generator.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1                   MEMBER STETKAR: I asked about the loads  
2 on the SBO diesels because I noticed that you have  
3 added a new site-specific load to one of the SBO  
4 diesel buses. Is that right? 32BBH, in particular,  
5 unless I am reading the drawing wrong. Have you done  
6 that?

7                   I'm looking at a drawing from the FSAR,  
8 and it shows a new site-specific load from 32BBH to a  
9 non-Class 1E 480-volt motor control center.

10                  MR. HESS: May I see your drawing?

11                  MEMBER STETKAR: It's got a nice, little  
12 bubble around it.

13                  MR. HESS: Yes.

14                  MR. PEACH: I think he is looking at your  
15 switchyard connection here.

16                  MR. HESS: Yes.

17                  MEMBER STETKAR: Well, I know what it is.  
18 It is a feed to an MCC out at the switchyard. So,  
19 it is, obviously, a plant-specific feed, but it is a  
20 connection from the SBO diesel, which affects the  
21 loading on that bus. And I was curious --

22                  MR. HESS: Let me introduce myself, and I  
23 will help Sam here a little bit.

24                  I am Mel Hess. I'm the Electrical

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Systems Task Manager at AREVA. I've got two  
2 engineering degrees and a law degree from the  
3 University of Toledo. I have, roughly, 30 years in  
4 the industry.

5 Note that previously we talked about the  
6 battery duration for the switchyard being eight  
7 hours. So, this switchyard connection from the BBH  
8 bus is not required during the SBO coping duration  
9 period, which is also eight hours. So, it is an  
10 available connection to support the switchyard after  
11 the SBO coping duration that is defined by Reg Guide  
12 1.155 tables as passed.

13 MEMBER STETKAR: Okay. I understand  
14 that, but, indeed, it does represent a load that, in  
15 principle, could be connected to that diesel. For  
16 example, if the MCC out in the switchyard was out of  
17 service for maintenance. I don't know. I am not  
18 going to try to presuppose how it could be connected  
19 to the diesel. It is an additional load.

20 I was curious whether people have  
21 actually looked at that load and whether it could  
22 cause a problem for that SBO diesel, if it was  
23 connected during the time when the diesel needs to  
24 work.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MR. PEACH: Well, it wouldn't be  
2 automatically connected. It would have to be  
3 administratively controlled.

4 And to answer your question, we have not  
5 looked at the case -- and correct me if I am wrong,  
6 Mel -- that if it was erroneously loaded on by an  
7 operator during the SBO coping period.

8 MEMBER STETKAR: Operators sometimes, for  
9 example, like to have power, especially if they are  
10 concerned about depleting batteries and know that  
11 they have this alternate power supply. So, if they  
12 are not carefully told not to do something, they  
13 might do it.

14 MR. PEACH: I think there's more SBO  
15 loads than that that require the operator to evaluate  
16 what the loading is on the SBO diesel and make some  
17 decision points there.

18 MEMBER STETKAR: Okay, thanks. I'll ask  
19 the staff if they have thought about it.

20 MR. PEACH: Okay. That concludes the  
21 part of the presentation for the onsite power  
22 systems. I appreciate your attention.

23 To talk about the SER confirmatory items,  
24 I am going to turn it over to Greg Gibson and let him

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 finish that.

2 MR. GIBSON: Thank you.

3 Next slide, please.

4 Our last item that we want to talk about  
5 is the confirmatory items that we have.

6 Next slide.

7 On page 50, you can see that there have  
8 been six RAI sets that we have been asked by the  
9 staff. This slide provides summary information of  
10 how we have identified those and which ones are being  
11 actually incorporated into the next revision for COLA  
12 Rev 7 of the Calvert Cliffs. That is scheduled for  
13 later on in the October timeframe this year.

14 With that, as I said, we have gone  
15 through, on the next slide, the offsite power systems  
16 that Jean-Luc discussed, the onsite power systems  
17 that Sam, and the station blackout that Sam has  
18 identified. We had addressed the NRC's open items --  
19 or excuse me -- RAIs and appropriately have  
20 incorporated changes into the COL to provide  
21 additional clarification and information.

22 With that, our last slide, our  
23 conclusions are that, again, we believe that we have  
24 addressed all of the COL information items, as

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 specified in the EPR; also, the interface items. We  
2 do have one departure from the Certified Design.

3 Again, we await your discussions with the  
4 NRC staff regarding there are no current NRC SER open  
5 items. We have had no contentions on this chapter  
6 and the items that we have are clarified there.

7 So, we appreciate the opportunity, Dr.  
8 Powers and members of the ACRS, to come before you  
9 today, and thank you very much.

10 CHAIR POWERS: Do members have any  
11 additional questions they would like to pose?

12 (No response.)

13 I think the staff has been alerted to  
14 some questions that may appear.

15 MR. McCANN: This is Ed McCann. I worked  
16 with the DEE on this section, Electrical Engineering.

17 I have a September 25th, 2009, letter, in  
18 response to an RAI, related to the question you had  
19 about the backup transformer. In here, they added  
20 the additional load in. So, we have the backup power  
21 scores for the desalinization plant and the  
22 demineralization plant that are on there.

23 So, there is a figure that also shows it.  
24 The figure that you have on there is not the latest

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 one. So, if you want to see it, I could show it to  
2 you.

3 MEMBER STETKAR: That is in an RAI?

4 MR. McCANN: Yes.

5 MEMBER STETKAR: Oh, okay.

6 MR. McCANN: But it is accounted for.

7 MEMBER STETKAR: This is for the --

8 MR. McCANN: The backup transformer.

9 MEMBER STETKAR: This is at the 6.9-kV  
10 bus level, right?

11 MR. McCANN: I can't read that.

12 MEMBER STETKAR: Okay. Yes, I would be  
13 interested to see that eventually.

14 MR. McCANN: I can make a copy of it.

15 MEMBER STETKAR: Yes, let's do that.

16 MR. McCANN: Okay.

17 CHAIR POWERS: If there are no other  
18 comments to be made, then we will recess until 10:45.

19 (Whereupon, the foregoing matter went off  
20 the record at 9:58 a.m. and went back on the record  
21 at 10:44 a.m.)

22 CHAIR POWERS: Let's go back into  
23 session.

24 Greg, you have an opening statement to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 make to us?

2 MR. GIBSON: Yes, Dr. Powers. Thank you.

3 Again, Greg Gibson.

4 I wanted to take an opportunity to  
5 correct a -- well, Jean-Luc?

6 (Laughter.)

7 MR. BEGON: Yes, I misspoke during the  
8 presentation when answering the question about the  
9 power towers. In fact, there are great lengths from  
10 the Waugh Chapel Substation to the site on different  
11 power towers, and I mentioned that they were on the  
12 same power tower. So I am sorry for this confusion.

13 MEMBER STETKAR: Ah, okay.

14 MR. BEGON: There are three lines coming  
15 to the site, go through the first part of it on the  
16 same right of way, but on different power towers.

17 I am, again, sorry for the confusion.

18 CHAIR POWERS: That is quite all right.

19 MEMBER STETKAR: If I can ask, are those  
20 towers separated far enough, so that they won't  
21 interfere with them? Because everything that I have  
22 looked at seemed to treat them as not a single  
23 electrical circuit, but a single physical  
24 configuration.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. BEGON: What I can say, what we  
2 committed to, the extension for Category III, we have  
3 committed to have sufficient separation, so that if  
4 one collapsed, it won't affect the other ones. But I  
5 cannot guarantee for the right-of-way if it is the  
6 case, and that will need to be checked.

7 MEMBER STETKAR: It seems that -- and I  
8 have forgotten the names of the substations -- that  
9 the separation between Waugh Chapel and Chalk Point,  
10 there seemed to be statements that they are at least  
11 200 feet separated. But I didn't read anything about  
12 the dual-circuit line.

13 But they are on separate towers? Okay,  
14 thanks.

15 MR. KANG: They are all separate three  
16 towers, separate transmission lines. They are  
17 separated by 200 feet, and another one is 150 feet.  
18 The tower is 135 feet. So, if the tower happens to  
19 be --

20 MEMBER STETKAR: Okay. Maybe we can hear  
21 that as part of your presentation.

22 Thank you.

23 CHAIR POWERS: I think we are done.  
24 Thank you very much.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MR. ARORA: Good morning, once again.

2 My name is Surinder Arora, and I'm the  
3 Lead PM for the Calvert Cliffs Unit 3 COLA  
4 application.

5 We are to present Chapter 8 SER from the  
6 start site. For that, I am going to turn it over to  
7 the Chapter PM, Jim Steckel, who is the Chapter 8 PM  
8 both for DC and Calvert Cliffs COLA.

9 MR. STECKEL: Thank you, Surinder.

10 Yes, I am Jim Steckel. Just to give you  
11 my background, I have been with NRC for three-and-a-  
12 half years, about a year and a half now in the EPR  
13 Projects Branch. I am the Chapter PM for Chapter 8  
14 for all the design centers as well as Chapter 18. I  
15 have taken on some responsibilities for Chapter 2 in  
16 Calvert Cliffs as well.

17 My background, I have done a significant  
18 amount of environmental monitoring for pre- and post-  
19 construction sites for site characterization work for  
20 nuclear power plants, several of them. And I spent a  
21 few years down at Savannah River doing environment,  
22 safety and health, and quality assurance support  
23 services there.

24 I have a technology management degree, a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

graduate degree.

I would like to go forward here with our presentation. I would like to introduce our review team. Mr. Peter Kang, and, of course, Surinder is the Lead PM, and I am Chapter PM.

This is just a table of the number of RAI questions per section of Chapter 8. All questions were answered satisfactorily. We have no open questions.

We do have six confirmatory items, which we expect to see answered in the next revision to the FSAR.

If there no additional questions, I will turn it over to Technical Reviewer Peter Kang.

MR. KANG: Good morning.

My name is Peter Kang. I'm a Senior Electrical Engineer. I have been with the NRC since 1982, and I have been with NRR, NRO as an Electrical Engineering Branch, and License Renewal also, and Office of Research.

I worked in the DOE, as well as the Federal Energy Regulatory Commission, FERC, and also USDA.

I began my career with Pepco as a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 transmission and distribution, particularly PJM  
2 representative, in the early seventies.

3 So, today, the staff has completed U.S.  
4 EPR Design Certification on Chapter 8, Electrical  
5 Power. Since then, staff has also completed a  
6 Calvert Unit 3 COL application review.

7 COL, since this is the first one, COL  
8 application contents contain basically interface  
9 items and the COL information and also supplemental  
10 information. That was identified by the U.S. EPR.  
11 Supposedly, all COL applicants need to elaborate in  
12 their COL applications for interface items, the COL  
13 information, and the supplemental information.

14 Calvert 3, Unit 3, in the original COL  
15 application, identified no departure from U.S. EPR  
16 FSAR. This means this chapter of the U.S. EPR is IBR  
17 with only supplemental information.

18 However, staff has found one departure,  
19 and it will be discussed at Section 8.3, which is the  
20 Onsite Power System side.

21 But Joe would like to discuss these  
22 departure items.

23 MR. COLACCINO: Yes, and I just wanted to  
24 address something. It was picked up in the earlier

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 presentation. There is a slight discrepancy here of  
2 whether there was a departure or not.

3 And what actually happened was, in the  
4 staff's dryrun of their ACRS presentation, a couple  
5 of members who were participating in that dryrun  
6 questioned whether one of the items that the staff  
7 was looking at was, in fact, a departure.

8 We drilled down into the application, and  
9 we determined, in fact, it was. So that was not  
10 identified, as a matter of fact, it was not  
11 identified until yesterday.

12 So, we informed UniStar of it. UniStar  
13 this morning gave us a letter that informed us that,  
14 yes, there is now a departure in the application.  
15 They were able to update their presentation to have  
16 that departure in there.

17 So, there is a departure. We will have  
18 to go back and look, because I am not sure if the SER  
19 that we actually wrote does discuss this area, and  
20 whether it is discussed as a departure or not. It  
21 will be a slight adjustment.

22 We are going to talk about it, but we  
23 just wanted to make sure that you understood where we  
24 were. This is real-time. We would have picked this

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 up last week probably --

2 CHAIR POWERS: Due to snow.

3 MR. COLACCINO: -- but we weren't here  
4 last week.

5 (Laughter.)

6 We would normally had the dryrun. So  
7 there were some people scrambling around yesterday,  
8 we got --

9 MEMBER SHACK: Yes, because Rev 6 of the  
10 FSAR says it's not a departure.

11 MR. COLACCINO: Exactly, but the  
12 supplement that was delivered to us this morning says  
13 that it now is.

14 MEMBER STETKAR: And I believe the SER,  
15 also, I believe --

16 MR. COLACCINO: Exactly.

17 MEMBER STETKAR: -- says there are no  
18 departures.

19 MR. COLACCINO: Absolutely. So we wanted  
20 to make this very clear to you, where we came up with  
21 this. It is something we, obviously, should have  
22 picked it up, but we did pick it up, at least in time  
23 here to talk to you about it and to clear it up.

24 MEMBER STETKAR: Are you planning to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 elaborate any more on that? I recognize your  
2 presentation is probably already --

3 MR. COLACCINO: Yes, we will. We are  
4 going to elaborate on it.

5 MEMBER STETKAR: You are? Okay.

6 MR. COLACCINO: Yes.

7 MR. KANG: Yes, the 8.3 section, onsite  
8 power systems.

9 MEMBER STETKAR: Good. Yes.

10 MR. KANG: Okay. As for site-specific  
11 information, the COL applicants include the following  
12 information: electrical load changes, and, also, any  
13 changes with offsite power systems with respect to  
14 offsite lines, grid, the switchyard, and the  
15 auxiliary transformers.

16 And the onsite power system with respect  
17 to site-specific equipment that they added or  
18 modified, such as UHS system, and cooling system  
19 fans, the one we discussed this morning, and  
20 additional power supply to the desalination plant.

21 And the last item is SBO coping duration,  
22 based on offsite and onsite configurations and, also,  
23 selection of EDG target reliability values. They are  
24 going to call for it.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 And COL application review includes them  
2 confirming all COL information items identified in  
3 the U.S. EPR FSAR have been properly addressed, and  
4 determining whether the COL FSAR information provided  
5 a sufficient level of detail for interconnection with  
6 the plant, onsite power system, and the SBO coping  
7 duration.

8 So, the next slide.

9 Section 8.1 addresses the site-specific  
10 information, site-specific electrical load changes,  
11 change of counts. Basically, this has resulted from  
12 additional site-specific UHS makeup water intake  
13 structures and UHS electrical building. It results  
14 in an overall electrical increase of additional 22.3  
15 kW for each EDG load for UHS makeup water structures.

16 Yes, sir?

17 MEMBER STETKAR: Peter, let me interrupt  
18 you there.

19 MR. KANG: Yes.

20 MEMBER STETKAR: Again, that 22.3 kW is  
21 under the assumed cooling loads out in the water  
22 structure?

23 MR. KANG: Yes.

24 MEMBER STETKAR: The heating loads, if I

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 did my math right, add about 48.9. If you subtract  
2 the cooling loads and add the heating loads in, it is  
3 still within the diesel capacity, but it is not 22.3.

4 MR. KANG: Right.

5 MEMBER STETKAR: It is a little more than  
6 double that.

7 MR. KANG: Okay. Now the question is,  
8 first of all, where did you get all the electrical  
9 heating loads?

10 As far as the applicant is concerned,  
11 that is what they supplied the information to us,  
12 changes.

13 MEMBER STETKAR: I will have to look it  
14 up. Tables 8.1-1 through 8.1-4 --

15 MR. KANG: Yes, sir.

16 MEMBER STETKAR: -- in the COL FSAR, is  
17 what my notes say here.

18 MR. KANG: Okay. So, this is all --

19 MEMBER STETKAR: And I am just reading  
20 from my notes now.

21 MR. KANG: Okay.

22 MEMBER STETKAR: It says, "The unit  
23 heaters and sump pumps account for approximately 26.6  
24 kW additional load." So, if I recall those tables,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 8.1-1 through 8.1-4, are actually load lists.

2 MR. KANG: Okay. Yes.

3 MEMBER STETKAR: Now I'm not inferring  
4 that this is a particular problem --

5 MR. KANG: Okay.

6 MEMBER STETKAR: -- because as long as  
7 the diesel are rated for 9500 kW --

8 MR. KANG: Yes.

9 MEMBER STETKAR: -- your maximum  
10 connected load is still less than --

11 MR. KANG: Eight thousand, 8100 or --

12 MEMBER STETKAR: No, it's about 8300 on  
13 Division 4, but it is still less than 90 percent of  
14 the rated diesel loading.

15 MR. KANG: Yes, sir.

16 MEMBER STETKAR: So, we are not anywhere  
17 challenging the margins on the diesel. I just want  
18 to make sure that the SER and your review has thought  
19 about this, and that there isn't anything hiding  
20 anywhere.

21 MR. KANG: Okay. The staff has just  
22 looked at the basic additional load of counts, what  
23 they provided to us. So, that is what we reviewed.

24 MEMBER STETKAR: Well, it's clear, in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 their analysis, it is clear.

2 MR. KANG: Yes.

3 MEMBER STETKAR: It says they took credit  
4 for -- you know, they added the cooling loads, and  
5 the heating loads would not be on the diesel  
6 simultaneous with the cooling loads. That is clear.

7 (Laughter.)

8 I mean, you know, that is absolutely  
9 clear.

10 MR. KANG: That's right, yes.

11 MEMBER STETKAR: On the other hand, if  
12 you are looking at a margins analysis, you ought to  
13 take the largest of those loads --

14 MR. KANG: Okay.

15 MEMBER STETKAR: -- rather than the  
16 smallest.

17 MR. KANG: Okay. And, for small DC  
18 circuit breaker control power, which is a .04 kW for  
19 each emergency uninterruptible power supply system,  
20 basically, what it is is Class 1E battery.

21 And as far as the evaluation is  
22 concerned, just like what you said, this is 9500 kW,  
23 and the loads were seen in each diesel. The worse  
24 place was 8300 kW. So we have ample margins there.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 And also, DC load for that Class 1E  
2 battery is almost insignificant, yes. Okay?

3 So, the result was, and staff has no open  
4 items regarding it, and you will see all the site-  
5 specific information on some electrical load increase  
6 that resulted from additional site-specific EHS  
7 backup water structures and the building.

8 Okay. Next slide.

9 Okay. Section 8.2 is on the offsite  
10 power system. On the interface requirement,  
11 switchyard, the UniStar presentation included various  
12 one-line diagrams or the switchyard connection  
13 drawings. So, that shows switchyard layout designs,  
14 and how this is connected to the grid, to the  
15 switchyard, and the connections to the planned  
16 distribution system.

17 Generic Letter 2007-01, that calls for  
18 design provisions and the monitoring capability to  
19 detect a degradation of an inaccessible power cable  
20 installed in the duct banks and underground.

21 And also, COL information items, as we  
22 discussed this morning, offsite lines, how many  
23 offsite lines are there with respect to meeting  
24 GDC-17, and there was two 500-kV overhead extensions

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 and two new 500-kV overhead extensions from existing  
2 Calvert Units 1 and 2.

3 Also, staff was worried about Generic  
4 Letter 2006-02, which deals with establishing  
5 communication agreement with the protocol and the  
6 protocol between plant and the IS, in this case, PJM.

7 MEMBER STETKAR: Peter?

8 MR. KANG: Yes.

9 MEMBER STETKAR: I guess there's a couple  
10 of things that I am curious about regarding the body  
11 count of the offsite power connections.

12 MR. KANG: Okay.

13 MEMBER STETKAR: You heard the discussion  
14 we had earlier with the applicant.

15 The words that I read in your slide there  
16 talk about two, a total of four offsite power  
17 connections for Calvert Cliffs 3. And if I draw a  
18 dotted line around some circuit diagram and look at  
19 wires going out of that dotted line, indeed, there  
20 are four wires going out of that dotted line.

21 On the other hand, if I draw a dotted  
22 line around the whole site -- you have to be careful  
23 of the paper on the microphone.

24 MR. KANG: Oh, okay.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1                   MEMBER STETKAR:    You have to be really  
2 careful.

3                   (Laughter.)

4                   Just don't hit it.   Be careful.

5                   MR. KANG:   Yes, sir.

6                   MEMBER STETKAR:   If I draw a dotted line,  
7 rather than only around the Calvert Cliffs 3  
8 switchyard, which has innerconnections to the Calvert  
9 Cliffs 1 and 2 switchyard, if I draw a dotted line  
10 around the whole site --

11                  MR. KANG:   Yes.

12                  MEMBER STETKAR:   -- there, indeed, are  
13 only three offsite power circuits for all three units  
14 at that site.

15                  MR. KANG:   Right.

16                  MEMBER STETKAR:   So, I am not sure, from  
17 a regulatory perspective, how three offsite  
18 transmission lines gets translated into four  
19 independent offsite power supplies for Unit 3.

20                  And I think my bigger concern is, as we  
21 are adding units to this site, we are not increasing  
22 the number of offsite power connections. We are now  
23 a three-unit site with three offsite transmission  
24 lines, two of which I now know are from the same

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 source on separate tower lines, the third of which is  
2 from a second source. So we have three lines  
3 connected to two offsite power switchyards supplying  
4 power to three nuclear units.

5 Does that satisfy -- apparently, it does  
6 (laughter) -- all of the regulations? But let me  
7 take this --

8 MR. KANG: Okay, yes, take it further.

9 MEMBER STETKAR: -- just so I understand  
10 it.

11 MR. KANG: Okay.

12 MEMBER STETKAR: Suppose I added six more  
13 units at that site and didn't change the offsite  
14 power supply configuration. Would that still be  
15 adequate?

16 MR. KANG: No.

17 MEMBER STETKAR: Okay. At what point  
18 does it become not adequate?

19 MR. KANG: Okay. See, this is the way I  
20 see it. Okay? This is, originally, Calvert Cliffs  
21 Unit 1 and 2 had the three offsite lines that came  
22 in. Okay, would you say that is more than adequate?

23 (Laughter.)

24 Okay. Way back when, the staff reviewed

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 it --

2 MEMBER STETKAR: Okay. For whatever  
3 reason, that is established.

4 MR. KANG: Right. Then, now, the third  
5 unit came in. You will see this practice quite a bit  
6 in other plants, like Calloway, the ones at Calloway,  
7 and the Bell Bend.

8 And, anyway, you see you are going to  
9 have a line coming in, an existing unit, and then  
10 loop into the other unit, the added, the new  
11 construction unit, and then coming back out. This is  
12 sort of like making a big loop. But, even then, some  
13 of them have the same tower line, two lines in one  
14 tower line. You will see some of those.

15 But, on the other hand, in this case, it  
16 is a pretty clean cut. In other words, there are  
17 three separate lines, and they lead, one of them,  
18 existing Unit 1 and 2, and the two came back to  
19 offsite lines.

20 So, the staff, as well as the applicant,  
21 postulated under FMEA and the various scenarios, took  
22 single values. They find that it was --

23 MEMBER STETKAR: In fact, I agree that  
24 the design meets any deterministic single-failure

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 analysis --

2 MR. KANG: Yes.

3 MEMBER STETKAR: -- of any of those  
4 lines. I am more thinking about what happens in the  
5 real world where you have things like tornadoes and  
6 wind storms, that now leave three units vulnerable to  
7 a loss of offsite power.

8 MR. KANG: That is one of our reasons,  
9 when we evaluate the SBO, they can take any credit,  
10 loss of offsite power, they just took all of them,  
11 offsite lines, out, and they have a big four SBO  
12 diesels, took care of all of these events.

13 And also, if you lose one of those lines,  
14 probably we are assuming Unit 1 or Unit 2 would be  
15 running and be able to supply to Unit 3.

16 MEMBER STETKAR: Be really careful about  
17 that paper (referring to hitting microphone with  
18 paper).

19 (Laughter.)

20 I am trying to protect our recorder, and  
21 I am trying to protect you. He gets really upset.

22 (Laughter.)

23 He has that amplified in his ears.

24 MR. KANG: I see.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1                   So, you are really concerned about the  
2 towers?

3                   MEMBER STETKAR: I think that I don't  
4 know the level of analysis that is required to meet  
5 the letter of the law versus an analysis of what may  
6 happen in the real world.

7                   MR. KANG: The real world, okay.

8                   MEMBER STETKAR: For example, I am happy  
9 to know that the two lines from -- I always get the  
10 two places -- which is the one up north?

11                  MR. KANG: The Waugh Chapel and Chalk  
12 Point.

13                  MEMBER STETKAR: Waugh Chapel, okay. The  
14 one up north, those two lines, I am happy to know  
15 that they are not on the same tower line.

16                  MR. KANG: Yes, sir.

17                  MEMBER STETKAR: But they do connect to  
18 the same switchyard. So, if I have a problem at that  
19 Waugh Chapel switchyard, I am going to lose both of  
20 those connections.

21                  MR. KANG: Two lines, yes.

22                  MEMBER STETKAR: Which leaves me with one  
23 500-kV transmission line left --

24                  MR. KANG: Yes.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1                   MEMBER STETKAR:    If I have all three  
2 units operating --

3                   MR. KANG:    Yes.

4                   MEMBER STETKAR:   -- at Calvert Cliffs  
5 under that condition, will that condition cause an  
6 offsite instability, such that I lose all offsite  
7 power? I'm thinking primarily about over-frequency  
8 protection now because I am pumping a lot of R's out  
9 into that one line. Or I might overload it just from  
10 watts.

11                   But that is not a deterministic single-  
12 failure analysis. It is an analysis of --

13                   MR. KANG:    Loss of a switchyard.

14                   MEMBER STETKAR:   Loss of that one offsite  
15 switchyard.

16                   MR. KANG:    Switchyard, yes, right. But,  
17 in that case, it is -- I don't know about the  
18 current, but PJM studies, they have a multitude of  
19 studies where they have done loss of stations and the  
20 single failures, and the single contingencies as a  
21 first would be viewed, and the double  
22 contingencies --

23                   MEMBER STETKAR:   Do they look at failures  
24 of single substations or just generating stations and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 transmission lines? Your N minus 1 stuff typically  
2 looks at generating stations and transmission paths,  
3 I think.

4 MR. KANG: And a substation loss is one  
5 of them.

6 MEMBER STETKAR: Do they?

7 MR. KANG: Yes.

8 MEMBER STETKAR: So, there should be an  
9 analysis that says --

10 MR. KANG: Yes.

11 MEMBER STETKAR: -- if we lose --

12 MR. KANG: They performed a study to make  
13 sure they have adequate voltages and a system --

14 MEMBER STETKAR: Okay. I mean, if the  
15 results of a system stability study for loss of the  
16 Waugh Chapel Substation has been done and shows that  
17 you maintain system stability with all three units  
18 operating at power --

19 MR. KANG: Okay. You would be happy?

20 MEMBER STETKAR: I would be happier.

21 MR. KANG: Okay. Because I think,  
22 however, one requirement in our losing the largest  
23 load or the largest station, see, there were the four  
24 items, in other words, that the Calvert presentation

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 had. Itself, Unit 3, loss of Unit 3, as well as a  
2 large load, large transmission lines going forward,  
3 and it performed -- most of them have been done  
4 adequately and exhaustively. So, staff is very  
5 comfortable.

6 MEMBER STETKAR: Okay. I guess I would  
7 like to make sure that they have looked at loss of  
8 that Waugh Chapel Substation.

9 MR. KANG: Okay.

10 MEMBER STETKAR: And the problem, of  
11 course, is that, if you require all three Calvert  
12 Cliffs units to rapidly reduce power --

13 MR. KANG: Yes.

14 MEMBER STETKAR: -- plants tend not to do  
15 that very reliably. They tend to trip off. Or the  
16 grid, or the protection on the remaining line trips  
17 off that line before the plant gets a chance to run  
18 back.

19 MR. KANG: I don't know if the PJM does  
20 that nowadays. Under the NERC requirement, one of  
21 the things is maximum credible losses, contingencies,  
22 which is probably loss of Waugh Chapel.

23 MEMBER STETKAR: I don't know. Yes, I  
24 mean the word "credible" --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. KANG: Yes.

2 MEMBER STETKAR: It is not worth  
3 discussing it, I think, any further.

4 MR. KANG: Yes. Okay.

5 MEMBER STETKAR: Let me just raise that  
6 point.

7 MR. KANG: So, I will find whether they  
8 performed a single loss of a substation as one of the  
9 largest. But what we defined as one of the largest  
10 of loads, on low centers, so I am pretty sure Waugh  
11 Chapel could be qualified.

12 MEMBER STETKAR: I would hope so.

13 MR. KANG: Yes. Okay.

14 MEMBER STETKAR: Thanks.

15 MR. KANG: Under Generic Letter 2006-02,  
16 Calvert Unit 3 indicated ample coordination exists  
17 with the PJM on operations and the grid  
18 reliabilities, and the planning and the maintenance.

19 And also, the response included a performance of  
20 transmission system analysis and the equipment  
21 maintenance are performed under agreement with BG&E.

22 They already said that, then.

23 And also, it follows pretty closely to  
24 NERC reliability standards and PJM guidance and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 practice, and the guidances.

2 As for supplemental information,  
3 compliance with the monitoring requirement specified  
4 in 10 CFR 50.65, which is the Maintenance Rule for  
5 inaccessible power cables installed in duct banks or  
6 underground, some of the examples of those  
7 inaccessible power cables which fall in this  
8 Maintenance Rule is offsite power, which is non-Class  
9 1E, and the emergency diesel generators, anything,  
10 suffice it, connected to the emergency diesel  
11 generator and the essential service water systems.

12 And the result was that the staff finds  
13 that COL items for the offsite system have been  
14 adequately addressed.

15 Section 8.3 deals with the onsite power  
16 system. Under interface requirements, the applicant  
17 has addressed onsite AC power system connections  
18 between the switchyard and the plant, and also  
19 provided lightning protections and establishing a  
20 grounding system grid.

21 And COL information items, Calvert Unit 3  
22 required to monitor and maintain EDG reliability to  
23 meet reliability level target for Reg Guide 1.155,  
24 which is to do with a station blackout. Reliability,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 choice of reliability number was .95 or 9.75.

2 So, also, under the COL information item,  
3 it will establish a cable management program prior to  
4 fuel load that will describe inspection, testing, and  
5 the monitoring program to detect degradation of  
6 inaccessible or underground cables.

7 As the supplemental information for the  
8 Emergency Power Supply System, this is site-specific  
9 equipment, which is UHS makeup water system  
10 structures, and this is a seismic Category I  
11 building.

12 Now you asked earlier whether a power  
13 line connected to, underground cables connecting to  
14 electrical buildings. This is taken care of by  
15 seismic group, which is 310.

16 MEMBER STETKAR: Yes, I understand that.

17 (Laughter.)

18 I just wanted to get it on the record.  
19 It is not worth discussing any more this morning.

20 MR. KANG: Okay. And also, these four  
21 divisions of Emergency Power Supply Systems are  
22 located in UHS electrical buildings, and each  
23 division consists of an MCC and distribution  
24 transformers.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: Peter?

2 MR. KANG: Yes.

3 MEMBER STETKAR: This is relevant to  
4 electrical. So I can ask this now.

5 MR. KANG: Yes.

6 MEMBER STETKAR: You talk about the cable  
7 management monitoring program. I need some help here  
8 because I honestly don't remember.

9 Are the cables out to the UHS structure  
10 6.9-kV cables or are they 480-volt cables?

11 MR. KANG: They are 6.9 kV.

12 MEMBER STETKAR: They are 6.9 kV?

13 MR. KANG: Yes, sir.

14 MEMBER STETKAR: So, they would be under  
15 the scope of the Maintenance Rule --

16 MR. KANG: Yes.

17 MEMBER STETKAR: -- as a medium voltage  
18 cable? Okay.

19 MR. KANG: Yes.

20 MEMBER STETKAR: And they are safety-  
21 related because --

22 MR. KANG: Safety-related, yes.

23 MEMBER STETKAR: Okay. Thanks.

24 MEMBER SHACK: It is just this inspection

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 under the 50.65, the scope of 50.65 isn't necessarily  
2 the same as your reliability assurance program. So,  
3 you know, suppose you had cables that came under the  
4 RAP program that somehow weren't under the 50.65.  
5 Does this really mean O-RAP rather than 10 50.65 or  
6 both?

7 MR. KANG: Well, this is one of the COL  
8 items, which falls with 10 CFR 65 under U.S. EPR.  
9 Okay. They are identified as any offsite lines and  
10 anything connected to the emergency diesel generators  
11 and ESW. It is specified in the U.S. EPR, the COL  
12 item. So I am pretty sure, as far as a power line  
13 going only up to UHS system, I would imagine they  
14 were included in that group.

15 MEMBER SHACK: Okay. Well, I will get to  
16 ask it again this afternoon with Chapter 17.

17 MR. KANG: Okay.

18 (Laughter.)

19 Each division, there is four divisions,  
20 and each division is independent. They are  
21 physically separated, and a power system analysis was  
22 performed to ensure adequacy of voltage regulations  
23 and short circuit capabilities.

24 Okay. The next one is the Normal Power

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Supply System. This is the place where we are in a  
2 little more discussions.

3 (Laughter.)

4 First of all, the supply voltage levels  
5 for including tower wet fans has been changed.  
6 Originally, U.S. EPR had specified avoidable levels.  
7 Now it changed to 6.9-kV levels in COL FSAR.

8 The reason was, as a result of this, a  
9 number of cooling fans decreased from 56 to 48. But,  
10 on the other hand, the fan size was increased from  
11 300 horsepower at the 480-volt level to 350  
12 horsepower at the 6.9-kV level. So, horsepower is  
13 increased.

14 But, overall, total load, which is  
15 totally counted, was 16,800 horsepower for all this  
16 horsepower. Staff identified, when we were reviewing  
17 these changes, the staff identified, asked the  
18 question, whether this is a departure.

19 The applicants provided very good  
20 technical justifications with having a 480-volt  
21 system versus a 6.9-kV system. Because, first of  
22 all, this is a non-Class 1E system. Okay? And then,  
23 No. 2, it is better voltage regulation can be  
24 obtained because it is starting all this number of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 fans from 480 volts, across the line starter, may be  
2 having some tough time to start. Maybe you need to  
3 reduce the voltage to starters or it may be really  
4 difficult to start or having problems.

5 So, with this change, they said that,  
6 originally, they had six load centers originally  
7 designed for 480-volt levels, but that is reduced to  
8 four switchgear for 6.9 kV. Their argument was  
9 really, really technically pretty good. It justified  
10 it. So, staff sort of agreed that, yes, it may not  
11 be a departure.

12 Sure enough, yesterday, we have the  
13 dryruns and we find out that is not so. This is a  
14 Tier 2 departure. So, since then, a lot of things  
15 happened.

16 And also, once it is identified as a  
17 departure, I understand that there is a lot of  
18 regulatory requirements that differ. First of all,  
19 staff has to go back and fix a revised SER, to begin  
20 with, because we already accepted it as not a  
21 departure. And also, the applicant has to submit  
22 some information. So we are doing that now.

23 MEMBER STETKAR: Peter, is your  
24 concern -- you said this is very, very -- a dynamic

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 situation, let's call it that. So, you know, I  
2 certainly understand if you don't want to discuss too  
3 much of it at the moment.

4 Is the concern regarding the departure  
5 related to the fans or is it related to that backup  
6 power supply now to the demineralized water plant,  
7 the additional loads that could be added through  
8 that? Or both?

9 And I understand if you --

10 MR. KANG: No, no, this is different, a  
11 different power supply system. You are talking about  
12 this. It comes from non-Class 1E Train Nos. 5 and 6.

13 MEMBER STETKAR: Yes.

14 MR. KANG: Coming from this number of,  
15 this is wet fans. The one that you are asking about  
16 is dry fans, in other words, plume abatement fans.  
17 So, this is two separate and they feed from two  
18 separate power sources.

19 MEMBER STETKAR: Okay. Go on. I need to  
20 read more of my notes here.

21 MR. KANG: Yes. This is fans across a  
22 cooling area, and it is from Train 5 and 6, fed from  
23 non-Class 1E Trains 5 and 6. And the other one is  
24 coming from the 500-kV switchyard.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MEMBER STETKAR: No, no, no.

2 MR. KANG: Red bus is coming from that.

3 MEMBER STETKAR: Yes, but the alternate  
4 feed --

5 MR. KANG: Yes.

6 MEMBER STETKAR: -- to Bus 30BBM, which  
7 is --

8 MR. KANG: 32BBF or BB --

9 MEMBER STETKAR: 30BBM, like "Mary" --

10 MR. KANG: Yes.

11 MEMBER STETKAR: -- which supplies the  
12 demineralized water plant.

13 MR. KANG: Yes.

14 MEMBER STETKAR: The alternate feed as a  
15 backup to the power supply from that switchyard  
16 transformer.

17 MR. KANG: Yes, sir.

18 MEMBER STETKAR: That alternate feed  
19 comes from Bus 36BBD, like "dog".

20 MR. KANG: 36BBD, yes.

21 MEMBER STETKAR: Right. Which is also  
22 one of the buses that feeds the new, eventually feeds  
23 the new cooling tower, wet cooling tower fans, is  
24 that correct?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. KANG: Is it coming from 5 and 6?

2 MEMBER STETKAR: Yes. I mean it is  
3 36BBD, so it is from 6.

4 MR. KANG: Let me see, 8.32 and the 5 and  
5 6, yes, you are correct.

6 MEMBER STETKAR: So, I mean, when I was  
7 reading through the FSAR and the SER --

8 MR. KANG: Yes.

9 MEMBER STETKAR: -- I followed the  
10 argument about changing the number and power ratings  
11 of the wet cooling tower fans as at least it was  
12 presented there, as not changing the nominal loads  
13 back up at the eventual supply buses.

14 MR. KANG: Yes.

15 MEMBER STETKAR: But I didn't see any  
16 discussion about the additional loads that could be  
17 added through that backup path to the desalination --  
18 you call it the desalination plant -- the  
19 demineralized water plant.

20 MR. KANG: Yes.

21 MEMBER STETKAR: And I was curious  
22 whether that power supply was the source of your  
23 concern about the departure or whether your concern  
24 is strictly related to the loading from the wet

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 cooling tower fans.

2 MR. KANG: Well, first of all, this is  
3 normally supplied from the switchyard.

4 MEMBER STETKAR: I understand that.

5 MR. KANG: Uh-huh.

6 MEMBER STETKAR: It is normally supplied.

7 MR. KANG: This is a backup power supply.

8 Okay? And originally, staff was concerned about  
9 this electrical load in this desalination plant,  
10 maybe a little above, and that is why they may be  
11 causing some fallout or some overloading. So, that  
12 is why they provided another second line, a second  
13 backup, a standby, another standby power source, yes.

14 And that only comes from Division Train  
15 No. 6.

16 MEMBER STETKAR: Correct.

17 MR. KANG: The small one line is  
18 connected. Okay?

19 Under the latest RAI 1.1.5, they did  
20 elaborate. The one fellow came by and told -- the  
21 RAI staff asked that particular question.

22 MEMBER STETKAR: Okay. I guess we have  
23 asked for that RAI, and I guess we will get it.

24 MR. KANG: Yes.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1           MEMBER STETKAR: So perhaps we will leave  
2 that discussion. I think the important thing for us  
3 to understand is, at the moment, you do interpret  
4 this different electrical configuration as a  
5 departure. So that you are looking at it from that  
6 perspective now, is that right?

7           MR. KANG: As far as a regulatory  
8 perspective, you know, we look at a Tier 2 departure,  
9 and, undoubtedly, staff will be reviewing it and look  
10 at the whole bunch of impacts.

11           MR. COLACCINO: Peter, can I just add  
12 here?

13           MR. KANG: Yes.

14           MR. COLACCINO: This is Joe Colaccino.

15           The reason why it is a departure is  
16 because they have actually done something different  
17 than what was in the U.S. EPR FSAR. That is why it  
18 is a departure. There isn't any interpretation to it  
19 at all.

20           MEMBER STETKAR: I tend to be less  
21 concerned about the -- if they could show -- I'm an  
22 electrical engineer; I am not a lawyer. If they  
23 could show that, indeed, the loading hadn't changed  
24 at all, I wouldn't particularly care whether they

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 were supplied from 6.9-kV buses or 480-volt buses.

2 When I looked at it, I was somewhat  
3 concerned because of this alternate feed that may be  
4 energized at some time that, indeed, from just adding  
5 up kilowatts, that the loading may have changed,  
6 which to me, as an electrical engineer, seems to be a  
7 difference in the design, regardless of the physical  
8 configuration of whether it is a 6.9-kV bus.

9 Now I understand your point, that,  
10 indeed, they changed the physical configuration.

11 MR. COLACCINO: Exactly, and that is  
12 something, like I said, given the timing of this, and  
13 we appreciate it, that that is probably something  
14 that we will do after this meeting. That is a  
15 follow-up item.

16 MR. KANG: Okay. We could ask, we could  
17 audit their calculations, whether they have valid  
18 calculations which demonstrate, audit this  
19 calculation.

20 Okay. So, as far as the Section 8.3,  
21 result: the staff finds that COL items, the site-  
22 specific items on the onsite power systems for EPSS  
23 and NPSS are adequately addressed.

24 And Section 8.4 is on a station blackout.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 As for Calvert Unit 3, COL information items  
2 indicate there is no special local power source  
3 available to resupply power to the Unit 3 following  
4 loss of outside power or during SBO. So they totally  
5 rely on SBO diesels.

6 And also follows, Reg Guide 1.155  
7 guidance relating to the establishing of procedures  
8 and the training for operator actions for coping with  
9 SBO. So there is Reg Guide 1.55 guidance that  
10 requires how you determine the coping, how you  
11 evaluate the coping durations, as well as  
12 requirements for established procedures and the  
13 training for operators.

14 Yes?

15 MEMBER STETKAR: And in terms of a  
16 regulatory perspective, would you rely on that  
17 guidance to assure that the new load that they have  
18 added to the SBO bus, because there is one, a 32BBH,  
19 has now the backup power supply for the switchyard  
20 battery chargers, or whatever, at least the battery  
21 chargers, some motor control center out in the  
22 switchyard? That is a site-specific load that they  
23 have added.

24 We learned this morning that that load

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 would be added to the SBO diesel, if necessary,  
2 manually, that it is not an automatic thing. They  
3 are not normally connected.

4 MR. KANG: SBO is usually, most of all  
5 this stuff is manual controls.

6 MEMBER STETKAR: Well, I guess what I am  
7 asking is that, you rely on the quality and detail in  
8 their SBO procedures to assure that I am not overload  
9 that diesel, is that correct?

10 MR. KANG: Yes.

11 MEMBER STETKAR: Okay. Regardless of  
12 whatever additional plant-specific loads they may  
13 have added to that bus --

14 MR. KANG: Yes.

15 MEMBER STETKAR: -- because they are all  
16 manually connected?

17 MR. KANG: They are all on total manual  
18 controls, yes.

19 MEMBER STETKAR: Okay.

20 MR. KANG: And as for the supplemental  
21 information, 10 CFR 50.63 requires COL applicants  
22 perform their own site-specific SBO coping durations.

23 The applicants determine this coping duration is to  
24 be eight hours. So, staff finds the COL items for

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 SBO have been adequately addressed.

2 So, as far as a summary of the staff  
3 findings, COL FSAR for Calvert Cliffs Unit 3  
4 provided:

5 Sufficient details about the site-  
6 specific safety-related load increases to EDG and  
7 Class 1E battery that resulted from the additional  
8 UHS makeup water intake structure and USH electrical  
9 building.

10 And sufficient information about offsite  
11 power system interrelationships among the nuclear  
12 units and the switchyards, and the interconnection  
13 entities, such as PJM and NERC, to maintain grid  
14 reliability and the stability and to minimize a loss  
15 of offsite power.

16 And the sufficient supplemental  
17 information is provided to address onsite power  
18 system changes to accommodate site-specific UHS  
19 system additions to the Emergency Power Supply System  
20 and the Normal Power Supply Systems.

21 And also, finally, they performed the  
22 necessary analysis to determine the site-specific  
23 capability to withstand and recover from an SBO  
24 event.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 CHAIR POWERS: Any other questions for  
2 the speaker?

3 (No response.)

4 Surinder?

5 MR. ARORA: Thank you. That concludes  
6 our staff's presentation on Chapter 8.

7 CHAIR POWERS: And we have no other  
8 questions?

9 (No response.)

10 Gosh, we are so easy.

11 (Laughter.)

12 We will recess --

13 MR. KANG: Can I just say, just for  
14 curiosity, just for a matter of the record, they  
15 provided the information on the transmission line  
16 separations. They have about 200 feet, and the other  
17 one is 150 feet, and the transmission tower was about  
18 135. So we are pretty comfortable to see that.

19 MEMBER STETKAR: From physical failures  
20 of a single power line, I mean I think you heard the  
21 earlier discussion. My concerns tend to be, when I  
22 see several transmission lines routed through a  
23 single right-of-way, you are susceptible to  
24 environmental conditions -- for example, high winds,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 tornadoes, for example -- that can cut across that  
2 single right-of-away.

3 And in this particular instance, that  
4 common right-of-way extends for, I think this morning  
5 it was said 12 miles, but a considerable distance --

6 MR. KANG: It is.

7 MEMBER STETKAR: -- from the plant,  
8 rather than having geographically-separated  
9 transmission lines that come in from two or three  
10 different compass directions, if you will, that makes  
11 things less vulnerable to straight-line winds or  
12 tornadoes, or things like that.

13 So I am certainly glad to hear that at  
14 least they are on three separate tower lines. I  
15 missed that. Thanks. It doesn't remove the common  
16 right-of-way kind of concern or the other thing that  
17 I mentioned from grid stability from failures out  
18 there from the one that I can't ever remember, Waugh  
19 Chapel Substation.

20 CHAIR POWERS: If there are no additional  
21 questions, we will recess until on o'clock.

22 (Whereupon, the foregoing matter went off  
23 the record at 11:34 a.m. for lunch and went back on  
24 the record at 12:59 p.m.)

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

A-F-T-E-R-N-O-O-N S-E-S-S-I-O-N

12:59 p.m.

CHAIR POWERS: Now let's come into session.

We are going to proceed now with a continuation of the ongoing review of the Design Certification for the EPR.

Getachew, do you want to start us out, explain where we are, where we are going, how we are going to get there, what we are going to do once we do?

MR. TESFAYE: I'll try.

Good afternoon.

My name is Getachew Tesfaye. I am the NRC Project Manager for AREVA's U.S. EPR Design Certification Project.

This afternoon we will continue our Phase 3 SERS presentation of the staff Safety Evaluation Report with open items.

We began our Phase 3 presentation on November 3rd, 2009. As we informed you then, we have grouped the 19 U.S. EPR FSAR chapter into four groups, based on their Phase 2 review completion dates.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 We completed presentation of group one  
2 chapters in November of last year. For the record,  
3 we presented Chapter 8, Electric Power, and Chapter  
4 2, Site Characteristics, on November 3rd, and Chapter  
5 10, Steam and Power Conversion System, and Chapter  
6 12, Radiation Protection, on November 19.

7 Today, we begin presentation of group two  
8 chapters. This afternoon and tomorrow, we will  
9 present Chapters 17, Quality Assurance, and Chapter  
10 19, Probabilistic Risk Assessment and Severe Accident  
11 Evaluation.

12 On March 3rd, we will present Chapter 4,  
13 Reactor, and Chapter 5, Reactor Coolant Systems and  
14 Connected Systems.

15 We will conclude group two chapters on  
16 April 6th with a presentation of Chapter 11, Reactive  
17 Waste Management, and Chapter 16, Technical  
18 Specifications.

19 That's all I have. If there are any  
20 questions --

21 CHAIR POWERS: Any questions on the  
22 general scope and strategy?

23 (No response.)

24 Seeing none, I will ask Sandra Sloan to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 take over and lead us forward.

2 MS. SLOAN: Thank you.

3 Good afternoon.

4 My name, again, is Sandra Sloan. I am  
5 the Regulatory Affairs Manager for New Plants at  
6 AREVA NP. As Getachew said, we are here this  
7 afternoon to talk about both Chapter 17 and Chapter  
8 19, and we will begin with Chapter 17 on Quality  
9 Assurance.

10 Next slide.

11 So, on the first slide, you can see the  
12 different sections in the chapter. The way we have  
13 organized this is we have two different presenters,  
14 and my colleagues will introduce themselves as they  
15 start their portions of the presentation and will  
16 give a brief biographical background, so you know a  
17 little bit about who they are and what their past  
18 experience is.

19 To my left, Mr. Saniuk will talk about  
20 Section 17.1, 17.2, 17.3, and 17.5. And to my right,  
21 John McEntire will talk about 17.4, Reliability  
22 Assurance Program, and then I will close with just a  
23 brief discussion of Section 17.6 on the Maintenance  
24 Rule Program.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 I did want to take an opportunity again  
2 -- I know in the morning session you heard the COL  
3 applicants talking about COL items. I did just want  
4 to remind, again, that when we refer to COL items,  
5 those are items that are viewed as outside the scope  
6 for Design Certification, and when we use that term,  
7 that is sort of code for not AREVA scope, not covered  
8 in Design Certification.

9 CHAIR POWERS: That is not going to stop  
10 us from asking you, though.

11 MS. SLOAN: No, I know it doesn't. I  
12 have tried before.

13 (Laughter.)

14 So, at this point, I will turn it over to  
15 Mr. Saniuk.

16 MR. SANIUK: Thank you, Sandra.

17 And good afternoon. I appreciate the  
18 opportunity to be here this afternoon to present the  
19 QA sections of Chapter 17 of the FSAR to the ACRS,  
20 and it is my pleasure to be here.

21 My name is Michael Saniuk. I am the U.S.  
22 EPR Manager of Plant Quality Assurance. I will give  
23 you a little bit about my background and  
24 qualifications.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 I have a bachelor's and master's degree  
2 in chemistry from Boston College. I have over 29  
3 years of experience in the nuclear industry. I have  
4 held various technical specialist, engineering,  
5 supervisory, and managerial quality assurance roles  
6 for a variety of organizations, including Stone  
7 Webster Engineering Corporation, Yankee Atomic  
8 Electric Company, National Technical Systems, Duke  
9 Engineering and Services, which then became Framatome  
10 AMP, which is now part of AREVA NP Inc.

11 I am a certified lead auditor and have  
12 extensive experience in the implementation of QA  
13 program requirements. I have conducted and been  
14 involved with the oversight of internal and external  
15 audits. I have conducted supplier audits and  
16 surveillances. I have been involved in self-  
17 assessment programs and am intimately involved in  
18 AREVA's corrective action programs.

19 In addition, I have provided technical  
20 and quality training, both domestically and  
21 internationally, on quality management systems,  
22 environmental qualification in commercial grade  
23 dedication.

24 Today, my presentation will focus on

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 providing a summary of the content of FSAR Section  
2 17.1, 2, 3, and 5. I will also be providing an  
3 overview of the AREVA Quality Assurance Plan for the  
4 Design Certification, which is in the form of a U.S.  
5 EPR Topical Report, ANP-10266A.

6 17.1 of the FSAR talks about a Quality  
7 Assurance Program during design. The information in  
8 17.1, with the establishment and issuance of SRP  
9 17.5, is really obsolete in terms of that establishes  
10 QA programs for the old ANSI standards. So, 17.1,  
11 the information for a Quality Assurance Program, is  
12 actually included in Section 17.5 of the FSAR.

13 In addition, 17.3, which I will get to  
14 when we get to the 17.3 slide, is also a QA program  
15 description which was applicable to construction  
16 permit-holders, their contractors, and licensed  
17 facilities, but, again, the Section 17.1 and 17.3  
18 have basically been obsoleted and do not apply to  
19 Design Certification applicants.

20 Section 17.2 of the SRP is the quality  
21 assurance during the operational phase. AREVA's  
22 Section 17.2 states that construction and operations  
23 are not applicable to the U.S. EPR Design  
24 Certification.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1           There is a COLA item for the COLA  
2           applicant that references the U.S. EPR Design  
3           Certification, that they will provide the Quality  
4           Assurance Program associated with construction and  
5           operations.

6           Again, 17.3 in our chapter points to  
7           17.5, which is the applicable Quality Assurance  
8           Program description section for Design Certification  
9           application.

10          So, 17.5, the basis of the Quality  
11          Assurance Program description at AREVA is addressed  
12          in our U.S. EPR Topical Report 10266A. We have  
13          submitted the AREVA Topical Report to the NRC in  
14          September of 2006. We have gone through an RAI  
15          process and a resolution-of-comment process with the  
16          NRC, and we have received an SER, Safety Evaluation  
17          Report, from the NRC on April 26th, 2007, which  
18          approved our U.S. EPR Topical Report. That was also  
19          confirmed in the SER for Chapter 17, which was issued  
20          to AREVA on January 10th, 2010.

21          The basis of the U.S. EPR Topical Report,  
22          as required by SRP 17.5 of NUREG-0800, is that it is  
23          based on the 18-point criteria of the 10 CFR 50,  
24          Appendix B, as well as the basic requirements, the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 supplemental requirements, and the applicable  
2 subparts of NQA-1, dated 1994. Our program and our  
3 Topical Report was written around those two standards  
4 and is in compliance with those two standards.

5 The QAP was also prepared using the  
6 guidance of NUREG-0800, Section 17.5, which was  
7 issued in March 2007. It was in draft form when we  
8 initially submitted our Topical Report. It has since  
9 become finalized and issued in March 2007. And our  
10 revisions to our Topical Report have included all  
11 requirements for the issued March 2007 SRP.

12 And consistent with the NRC Safety  
13 Evaluation Reports and NUREG-0800 and the U.S.  
14 Topical Report, Design Certification does not include  
15 fabrication, erection, installation, or operations.  
16 And therefore, our Topical Report is specifically  
17 geared to the applicable elements of the standards as  
18 they apply to Design Certification.

19 And that ends my remarks. Are there any  
20 questions?

21 CHAIR POWERS: What I don't understand  
22 well is, what is the objective of your Quality  
23 Assurance Program?

24 MR. SANIUK: The objective of the Quality

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Assurance Program is to ensure that all activities  
2 done for Design Certification are done under the  
3 auspices and requirements of 10 CFR 50, Appendix B,  
4 which is the Code of Federal Regulations for  
5 conducting activities in relationship to a Design  
6 Certification project and to ensure that all  
7 activities are conducted under the requirements of  
8 NQA-1-1994.

9 CHAIR POWERS: So it is strictly a  
10 compliance objective?

11 MR. SANIUK: That is correct. This  
12 portion of the QA program is compliance. We have  
13 other portions of the QA program that go into lessons  
14 learned, tracking of corrective action programs,  
15 tracking and trending, instituting human performance  
16 initiatives, and other things, but this program is  
17 strictly compliance.

18 CHAIR POWERS: Any other questions for  
19 the speaker?

20 (No response.)

21 Proceed on.

22 MS. SLOAN: Okay. The next is John  
23 McEntire.

24 MR. McENTIRE: Thank you, Sandra.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           My name is John McEntire. I am the  
2 Reliability Assurance Program Coordinator for the  
3 U.S. EPR. I have nine years of operational  
4 experience in nuclear power with the United States  
5 Navy. I served on the USS Dwight D. Eisenhower,  
6 CVN-69, for four-and-a-half years, and also served as  
7 a nuclear power instructor at the moored training  
8 ship 626 in Charleston, South Carolina.

9           While serving as an instructor, I  
10 pursued a bachelor's degree from Thomas Edison State  
11 College out of Trenton, New Jersey. So, I have a  
12 bachelor's of science in nuclear engineering  
13 technology.

14           Next slide, please.

15           Implementation of the reliability  
16 assurance program enhances safety by focusing design  
17 resources on the risk-significant system structures  
18 or components, and maintaining the reliability of  
19 such SSCs during the design and operating stages of  
20 the plant.

21           AREVA is responsible for developing and  
22 implementing the design stage of the RAP, which  
23 includes the scope, design consideration, objectives,  
24 identification, and prioritization of SSCs, the RAP

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 organization, and expert panel process.

2 Next slide, please.

3 The RAP applies to the systems,  
4 structures, and components that are identified as  
5 risk-significant or significant contributors to plant  
6 safety, as determined by using the Probabilistic Risk  
7 Assessment, or PRA, which will include industry  
8 operating experience, component failure databases,  
9 and use of deterministic methods with an expert  
10 panel. The RAP is implemented in two stages, which  
11 are the design stage and the operating stage.

12 Next slide, please.

13 RAP Stage 1, or the design stage, applies  
14 to RAP activities up to the initial field load,  
15 including the Design Certification phase and the  
16 Site-Specific phase.

17 In the Design Certification phase, a list  
18 of risk-significant systems and structures was  
19 developed with the use of the PRA and deterministic  
20 insights.

21 Next slide.

22 MEMBER STETKAR: When you developed that  
23 list -- I haven't seen any of the list, so it is a  
24 little difficult to know exactly what is on the list.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1        Could you just elaborate a little bit about what  
2        criteria you used from the PRA to populate that list?

3                MR. McENTIRE: Absolutely.

4                MEMBER STETKAR: I mean, where did you  
5        draw the line in terms of saying something was risk-  
6        significant versus not risk-significant?

7                MR. McENTIRE: Absolutely. Some examples  
8        of insights, decision criteria includes impact on  
9        initiating events, component significance to low  
10       power shutdown, safety, mitigation of consequences of  
11       external events, design-basis analysis consideration,  
12       technical specifications, failure leading to degraded  
13       containment performance, and failure effect on other  
14       trains.

15               MEMBER STETKAR: Okay, those are  
16       qualitative things. I think the slide that you have  
17       up there now may be answering what I was really  
18       asking about. The numerical criteria from the PRA  
19       are those that are listed on the slide that you have  
20       up there in front of you?

21               In other words, something was considered  
22       risk-significant if the Risk Achievement Worth of a  
23       common cause group was greater than 20 or that the  
24       Fussil-Vasili importance of a particular component

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 was greater than .005. Those are the criteria you  
2 used?

3 MR. McENTIRE: Yes, for the PRA.

4 MEMBER STETKAR: Okay. Thanks. Plus,  
5 you had other qualitative-type decisions.

6 MR. McENTIRE: Yes.

7 MEMBER STETKAR: Okay. Thank you.

8 CHAIR POWERS: I guess I'm still  
9 struggling. How do you do a PRA for a plant that has  
10 never been built?

11 MR. McENTIRE: If I could, could I relay  
12 that question to my theory expert?

13 CHAIR POWERS: We can do that this  
14 afternoon later.

15 MR. McENTIRE: Mr. Josh Reinert, please.

16 MR. REINERT: I am Joshua Reinert. My  
17 qualifications are I started off in the nuclear Navy.

18 I was a RAC operator for six years. I studied at  
19 the University of Connecticut, electrical  
20 engineering, and at MIT under George Apostolakis,  
21 where I received a master's --

22 (Laughter.)

23 CHAIR POWERS: Do you have somebody else  
24 you could ask?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(Laughter.)

Go ahead, Josh. I'm just giving you a hard time.

MR. REINERT: I did a thesis with Mr. Apostolakis on including uncertainty in risk-informed decisionmaking.

I went to work at a company just down the street called Information Systems Laboratories, or ISL. And now I work at AREVA for the last three years, helping with design certification and COLA PRA.

CHAIR POWERS: So you have moved up substantially in your career, I mean from a low point at MIT --

MR. REINERT: From Apostolakis, yes.

(Laughter.)

So the question is, how do you do a PRA for a plant that hasn't been built yet?

CHAIR POWERS: Yes.

MR. REINERT: Of course, we have some preliminary, well, we have some design information. Of course, at some point, you run into an area of detail that hasn't been sited yet for a plant that is still in Design Certification. So, where we needed

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 to, we made assumptions, and those assumptions are  
2 documented in Chapter 19.

3 CHAIR POWERS: Okay. My question is, why  
4 do I believe the result? I can make assumptions,  
5 too. You wouldn't like my assumptions, but --

6 (Laughter.)

7 MR. REINERT: I think you believe the  
8 result because we do sensitivity studies to see what  
9 assumptions are important, document the important  
10 assumptions, and then we are committed to verify that  
11 those assumptions are true or update the PRA.

12 MS. SLOAN: And, Dr. Powers, I think you  
13 will have ample opportunity in the afternoon as well  
14 to talk about what we did in PRA.

15 CHAIR POWERS: Yes, I guess my reaction  
16 is, first of all, you do your thesis work for a guy  
17 who usually launches into a tirade when the word  
18 "sensitivity study" comes up, and you tell me that is  
19 the tool you used to identify important uncertainties  
20 in this, and then you go see if they are true or not.  
21 Well, it's interesting.

22 I guess I will avail myself this  
23 afternoon.

24 Go ahead, please.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. McENTIRE: The U.S. EPR PRA was used  
2 for identifying and prioritizing SSCs in the scope of  
3 the Design Certification, based on their risk  
4 significance.

5 Now what we have illustrated is a simple  
6 flow diagram which shows how a component modeled in a  
7 U.S. EPR PRA was screened into the RAP.

8 Deterministic insights were incorporated  
9 through the use of an expert panel, and that expert  
10 panel performed a qualitative review of the systems  
11 and structures to develop the final list of systems  
12 and structures in the scope of the --

13 CHAIR POWERS: How many of those system  
14 structures and components that you categorized  
15 actually show up in the PRA?

16 MR. McENTIRE: The question is, how did  
17 we categorize systems and structures that showed up  
18 in the PRA?

19 CHAIR POWERS: No, I mean, how many  
20 things actually show up that need to get categorized  
21 here?

22 MR. McENTIRE: On the component level?

23 CHAIR POWERS: Yes. On any level.

24 MR. McENTIRE: Again, if I could relay

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that question to Josh Reinert?

2 MR. REINERT: We have approximately 500  
3 basic events in the Design Certification PRA. And of  
4 the components -- 5,000, sorry, basic events, and the  
5 number of components that made it into the RAP  
6 program, based on PRA insights, was probably 5200.

7 You confirm that?

8 I have the list here. I would say 100 of  
9 the 5,000 made it. Sorry, 100 components out of  
10 5,000 basic events were screened into the RAP program  
11 based on PRA insights.

12 MEMBER STETKAR: Josh, unfortunately, you  
13 have lists and we don't, because they are not in the  
14 FSAR. It would have been a lot better to actually  
15 see those lists, so we are a little bit informed.

16 You carefully characterized components  
17 and basic events. Let me try to get a feel, because  
18 you are doing body-count-type things. When you say a  
19 component was categorized into the RAP, the plant has  
20 four diesel generators. Now, those four diesel  
21 generators, each diesel might have, you know, six  
22 basic events assigned to it.

23 So, saying 5,000 basic events and number  
24 of components sometimes doesn't exactly scale. But,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 when you say approximately 100 components were  
2 included in the RAP, is each diesel one of those  
3 components? So, for example, I have now added --  
4 four out of those 100 are the four diesels? Or is  
5 any one of the four diesels one of your 100?

6 MR. REINERT: The way I was thinking of  
7 it when I said 100, all four diesel generators would  
8 have counted as one component.

9 MEMBER STETKAR: So, a generic diesel  
10 generator is one of your 100?

11 MR. REINERT: That's true, yes.

12 MEMBER STETKAR: So, you could have as  
13 many as 400 individual pumps and valves and things  
14 like that?

15 MR. REINERT: Yes.

16 MEMBER STETKAR: Okay. Thanks. That  
17 helps a little bit in terms of getting a handle on  
18 this number counts.

19 MR. McENTIRE: Sir, the list of systems  
20 and structures that we were referring to, we  
21 currently have that in Revision 2 of our Final Safety  
22 Analysis Report.

23 MEMBER STETKAR: We don't have Revision 2  
24 in terms of the ACRS. So that doesn't help an awful

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 lot.

2 MR. McENTIRE: Yes, I do have a sample  
3 list of systems and structures later in the slide  
4 presentation.

5 MR. COLACCINO: This is Joe Colaccino.

6 Just for the ACRS benefit, the staff  
7 doesn't have Revision 2, either.

8 MEMBER STETKAR: I understand that they  
9 came in through a bunch of RAIs.

10 MR. COLACCINO: That's correct.

11 MEMBER STETKAR: But we also don't have  
12 the RAIs.

13 MR. COLACCINO: Correction. Interim Rev  
14 2.

15 MEMBER STETKAR: Interim Rev?

16 MS. SLOAN: You are correct, it came in  
17 with an RAI response.

18 CHAIR POWERS: But it will be added to  
19 the FSAR, yes.

20 MS. SLOAN: Correct.

21 MR. McENTIRE: Okay. Next slide.

22 And as you see here, this is just a  
23 sample list of systems and structures that we have  
24 included into the RAP for the Design Certification.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 And you can see the complete list of  
2 Design Certification scope systems and structures  
3 included within the RAP can be found in U.S. EPR FSAR  
4 Section 17.4, which will be Revision 2.

5 MEMBER STETKAR: Can it eventually be  
6 found somewhere?

7 (Laughter.)

8 CHAIR POWERS: Yes, let me try to get  
9 here -- you have, as an example, boron concentration  
10 measurement system. That did not come into that list  
11 because of your PRA.

12 MR. McENTIRE: That is true.

13 CHAIR POWERS: But an expert panel added  
14 it?

15 MR. McENTIRE: That is true.

16 CHAIR POWERS: Why did they add this  
17 system and not other systems?

18 MR. McENTIRE: Well, based on the --

19 CHAIR POWERS: Who is the expert panel,  
20 by the way?

21 MR. McENTIRE: Yes, based on the safety  
22 function of the boron concentration measurement  
23 system, which is that it provides boron concentration  
24 measurements for the protection system, the expert

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 panel felt that it was a risk-significant system.  
2 And therefore, it was included.

3 CHAIR POWERS: Well, who is the expert  
4 panel? I mean, do they know anything about risk?

5 MR. McENTIRE: Absolutely.

6 CHAIR POWERS: I swear I don't anymore.

7 (Laughter.)

8 MR. McENTIRE: The expert panel that you  
9 ask about, the panel consists of members that were  
10 chosen based on their ability to assess PRA elements,  
11 have a collective knowledge of plant NSSS design,  
12 containment design, and plant operation.

13 Qualifications of an expert panel consist  
14 of "individuals who possess extensive knowledge in  
15 the areas of PRA, risk and reliability, plant  
16 operations, systems engineering, and maintenance."

17 CHAIR POWERS: So, somebody just dreamed  
18 up a list of his buddies, right? There's no  
19 measurable criterion that I can use there, right?

20 MR. McENTIRE: The only measurable  
21 criteria you have is our decision criteria, the  
22 qualitative analysis.

23 CHAIR POWERS: Yes. There's no way for  
24 me to decide whether -- I can't take a guy out of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 this room and decide whether to put him on the panel  
2 or not, right?

3 MR. McENTIRE: In one of the RAI  
4 responses that we submitted to the NRC, we did list  
5 the credentials of the expert panel. I am sorry, I  
6 don't have that information with me.

7 MS. SLOAN: But we can identify the RAI  
8 number. If you are interested, we did submit more  
9 details of each expert panel member's credentials, if  
10 you would like that.

11 MEMBER STETKAR: Without going into the  
12 individuals, did you have anyone on the expert panel  
13 outside of the AREVA or R-COLA organization? In  
14 other words, an independent outsider?

15 MR. McENTIRE: Not for the Design  
16 Certification.

17 MEMBER STETKAR: Thank you.

18 CHAIR POWERS: If I look at your list up  
19 there, which is the same as the list I have down  
20 there, I mean one thing that surprises me is that  
21 emergency power generating buildings are not there,  
22 did not come out of your PRA as an important system.

23 I would have assumed that that would show up as  
24 important at least in the seismic part of the PRA.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MR. McENTIRE: Again, if I could relay  
2 that question to my PRA expert?

3 CHAIR POWERS: Are you going to get  
4 harassed again, Joshua?

5 (Laughter.)

6 What did you do to John to get him upset  
7 at you?

8 (Laughter.)

9 MR. REINERT: I was thinking about how to  
10 answer this question earlier. I think the answer is  
11 there is a little bit of overlap between what would  
12 come out of the PRA and what came out of the expert  
13 panel. And also, there is overlap because the PRA  
14 member sits on the expert panel, so he can provide  
15 input other than these quantitative Fussil-Vasili and  
16 RAW numbers.

17 So, I think you're right, the emergency  
18 power generator buildings, it does show up as  
19 important from a seismic PRA perspective, but it  
20 doesn't come out of this generation of basic events  
21 with Fussil-Vasili's and RAWs.

22 When it says here "PRA input to the RAP",  
23 it is just talking about those quantitative  
24 importance measures.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR POWERS: It would be interesting to  
2 see a list of systems, components and structures that  
3 did not get on this list. That would be interesting.  
4 It would be lengthy.

5 (Laughter.)

6 MR. McENTIRE: Okay, next slide, please.

7 MEMBER STETKAR: I would have been happy  
8 just to see the list that was on there, and by  
9 implication, everything else is not.

10 (Laughter.)

11 MR. McENTIRE: Okay. The Site-Specific  
12 phase, this is for the combined license applicant,  
13 and it is not for the Design Certification phase. It  
14 is outside the scope.

15 MEMBER STETKAR: Now let me ask you, we  
16 are not going to let you off the hook this quickly.  
17 I have to admit ignorance here, and a bit of  
18 frustration is that we don't have direct access to  
19 all of the RAIs and the responses, nor do I think --  
20 I am not implying that we want them.

21 (Laughter.)

22 It is a huge volume of things. Please  
23 don't send them.

24 But you have to recognize what

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 information we have available at our fingertips. We  
2 have the FSAR. We have the SER and references to  
3 RAIs.

4 One of the RAIs and the responses  
5 apparently dealt with the issue of populating the RAP  
6 list with passive components. And in particular, I  
7 am going to use the words "check valves".

8 And I am a bit confused about whether the  
9 Design Reliability Assurance Program lists include,  
10 for example, potentially risk-important check valves.

11 Because, as I read through the information we have  
12 available, which is just the summary and the SER, it  
13 seemed to say that it was the COL applicant's  
14 responsibility for populating that portion of the  
15 Design Reliability Assurance Program list. And yet,  
16 in other places, the requirement seems to be for the  
17 COL applicant to only examine site-specific issues.  
18 Of course, a check valve in the Certified Design is  
19 not a site-specific issue.

20 So, could you tell me a little bit about,  
21 first of all, whether the Design Reliability  
22 Assurance Program list includes any so-called passive  
23 components, in particular, check valves? If not,  
24 what process is going to be used to examine those and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 determine whether or not they are included in the  
2 list?

3 MR. McENTIRE: For specifically a  
4 component such as a check valve, if the component did  
5 not already screen into the PRA as being risk-  
6 significant, then that determination would have to be  
7 made by an expert panel in our detailed design  
8 process.

9 Currently, right now, for the Design  
10 Certification, it is only focusing on systems and  
11 structures.

12 MEMBER STETKAR: I'm not sure I  
13 understood you.

14 CHAIR POWERS: I'm certain that I didn't  
15 understand him.

16 (Laughter.)

17 MEMBER STETKAR: Try to explain --  
18 honestly, I am not trying to be coy. I really don't  
19 understand what you are trying to tell me.

20 MR. McENTIRE: For the Design  
21 Certification phase --

22 MEMBER STETKAR: Yes.

23 MR. McENTIRE: -- AREVA's goal is to  
24 identify risk-significant systems and structures.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: And components, though.  
2 You have things like diesels on your list, I assume.

3 MR. McENTIRE: They were screened by the  
4 U.S. EPR PRA, that is true. If a component was  
5 screened into the PRA as being important --

6 MEMBER STETKAR: I got you. Okay. So,  
7 you are saying a component is on the list only if the  
8 PRA identified it as important, according to those  
9 RAW or Fussil-Vasili importance, that there are no  
10 components on the list that came out of the expert  
11 panel process? Is that --

12 MR. McENTIRE: That is true.

13 MEMBER STETKAR: Okay.

14 MR. McENTIRE: Well, what I think I am  
15 trying to explain here is, if a component was  
16 screened into the PRA for the Design Certification  
17 phase, we only identified that system -- we  
18 identified the component as being important, but we  
19 also identified that component within a system. So,  
20 we identified that system as a whole in the PRA --  
21 excuse me -- in the RAP, as of right now.

22 But, as we go through the detailed design  
23 phase, we will be making adjustments and we will  
24 identify --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           MEMBER STETKAR: I guess at one level I  
2 am asking about the completeness of the list, which I  
3 admit, since I don't have the list, I can't really  
4 make any comments about that.

5           On the second level, though, I am trying  
6 to understand where the responsibility lies for  
7 identifying potentially-important passive components  
8 that are part of the Certified Design. Because  
9 reading through the brief summary information that we  
10 had, it seemed to say that it was the COL applicant's  
11 responsibility to do that assessment of passive  
12 components now, for example, check valves.

13           And I want to understand whether that is  
14 actually true in your opinion or whether that is a  
15 responsibility of AREVA in terms of populating the  
16 final RAP list that will be part of the  
17 certification. You know, who owns the decisionmaking  
18 regarding those passive components?

19           In principle, it spins out to structures,  
20 but I will keep focusing back on check valves, just  
21 because they are one of those kind of gray area  
22 things between what is called an active versus a  
23 passive component, and they happen to be mentioned in  
24 this general area of discussion in the SER.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MR. McENTIRE: Yes. AREVA will own that  
2 responsibility to identify risk-significant  
3 components.

4 MEMBER STETKAR: Okay. Okay. Thanks.  
5 That is what I was hoping I would hear. So,  
6 eventually, that will be closed. Thank you.

7 MR. GARDNER: Excuse me. Let me  
8 interject here.

9 I'm Darrell Gardner. I'm with AREVA,  
10 Director of Licensing Projects.

11 I just want to correct that. We have  
12 identified systems and components based on the PRA.  
13 The expert panel made that review at a system level  
14 only. So, if the system was screened in, it was  
15 screened in through the system.

16 MEMBER STETKAR: For an entire system?

17 MR. GARDNER: Right. So, during detailed  
18 design, there will be further drilldowns to decide  
19 whether -- the system was screened in for a very  
20 specific reason, a narrow reason. Then, obviously,  
21 you will narrow it down to the component level.

22 MEMBER STETKAR: Okay. Let me ask you  
23 that. Again, I really have to apologize because we  
24 don't have the list.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1           The lists that we don't have, then, are  
2           only at the system level, not the component level? I  
3           mean the list that will appear in whatever --

4           MR. GARDNER: FSAR.

5           MEMBER STETKAR: -- the FSAR. Is that  
6           only at the system level, not at the component?

7           MR. GARDNER: There are two lists that  
8           were added in RAI 2.26 Supplement 1.

9           MEMBER STETKAR: Uh-hum.

10          MR. GARDNER: One list is based on the  
11          PRA and is a component-based list. Another table  
12          that was added was the results of the expert panel,  
13          which is a system-based list.

14          MEMBER SHACK: But the sample list we  
15          have seems to have systems added from the PRA and  
16          systems from the expert panel.

17          MEMBER STETKAR: Yes, but this is only a  
18          sample summary.

19          MEMBER SHACK: Yes, but you made it sound  
20          as though the PRA was at the component level, but it  
21          appears to be at the system level also, at least in  
22          some cases.

23          MR. GARDNER: Depending on how it was  
24          modeled, correct.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MEMBER SHACK: Okay. So, depending on  
2 how it was modeled?

3 CHAIR POWERS: But you would think that  
4 the expert panel would be there to refine the list  
5 down. If it was at a relatively high level, the  
6 expert panel would be in a position to say, well, in  
7 addition to this system, you need to focus on these  
8 components, wouldn't it?

9 MEMBER SHACK: I normally think of expert  
10 panels as bringing in things that aren't identified  
11 --

12 CHAIR POWERS: That's right.

13 MEMBER SHACK: -- in the PRA.

14 MEMBER STETKAR: My concern is a  
15 potential gap, that if the expert panel is thinking  
16 only at a relatively high level, I mean that is good,  
17 they need to think about that. But, obviously, they  
18 thought about the diesel generator building. And if  
19 they are relying only on the PRA to populate the  
20 details, by whatever scope of the PRA plus whatever  
21 rules are applied to that scope, is there a potential  
22 gap because the PRA scope may not include all passive  
23 things, and the expert panel may not have been told  
24 that they need to think about them?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 I don't know. I mean I don't know. And  
2 I don't have any good examples. I don't have any  
3 good possible counter-examples without a list. I  
4 mean the benefit of a list is that you can look at it  
5 and say, "Hey, wait a minute, why isn't this on that  
6 list? Can you explain why it isn't?" But we don't  
7 have the list.

8 And I am not hearing a lot of real firm  
9 confidence-building that, for example, if there were  
10 some check valves in a system that, for whatever  
11 reason, didn't show up above the numerical criteria  
12 from the PRA, either they weren't modeled or, for  
13 whatever reason, like the diesel buildings, they just  
14 don't show up, what in terms of this process kind of  
15 challenges the expert panel to say, "Hey, those  
16 pieces of equipment might be important."?

17 I will give you a typical example, and I  
18 don't know whether they are on there. Accumulator  
19 discharge check valves, typically, are not very  
20 important from a PRA perspective because they only  
21 help you for large LOCAs, which are usually not very  
22 important risk contributors.

23 On the other hand, if I was looking at  
24 accumulator discharge check valves as an expert

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 panel, I might say maybe they are more important than  
2 even boron monitoring, which can only have an  
3 implication for shutdown dilution events.

4 So, what challenges that expert panel to  
5 say, "Hey, those check valves might be on this  
6 list."?

7 MS. SLOAN: Vesna, did you want to  
8 respond? Do you want to introduce yourself, Vesna?

9 MS. DIMITRIJEVIC: Yes.

10 MS. SLOAN: You need to use a microphone.

11 MS. DIMITRIJEVIC: I went into this  
12 myself much more a little when we started the  
13 Chapter 19 because I presented.

14 My name is Vesna Dimitrijevic. I was  
15 technically doing the Level 1 PRA, and I have  
16 degrees, all my degrees are in PRA. I have about 55  
17 areas in this area.

18 I just want to help John to understand  
19 some. The systems are not ranked in the PRA. There  
20 is no ranks for the systems. The ranks are on the  
21 basis of the component level where the basic events  
22 are combined to produce component rankings.

23 If any component shows as important, that  
24 system will be identified. If any component from

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 that system shows as important in the PRA, that  
2 system will be identified as important from the PRA  
3 perspective.

4 MEMBER STETKAR: Any component in the  
5 system?

6 MS. DIMITRIJEVIC: Yes. Yes. That  
7 system, so far, there was one expert panel meeting  
8 that was on the system level, on the general level of  
9 the plant. Every system will have a separate expert  
10 panel which will identify as important.

11 Some of those check valves will show as  
12 important. For example, say 15 traction track valves  
13 are one of the most important --

14 MEMBER STETKAR: From the PRA, those show  
15 up as important?

16 MS. DIMITRIJEVIC: Yes, right.

17 MEMBER STETKAR: Sure.

18 MS. DIMITRIJEVIC: You had a very good  
19 example with accumulators. Because of the low  
20 failure rate of both tanks and check valves to stay  
21 in an open position, they are likely not to show as  
22 important in the original RAP and the system.

23 However, given the PRA rankers will be  
24 presented with the safety injection system, important

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 is elevated. And it will be because a lot of those  
2 components are showing as important.

3 It is likely that the PRA presenter can  
4 contribute and can bring this back to us to ask. I  
5 have a feeling, but, actually, this is my feeling,  
6 and I have elevated that as part of some previous  
7 risk-informed application for the FEMA plan.  
8 Accumulators may not show as important in this plan.

9 So, the thing to bring, if those are  
10 valves are going to bring in, it will have to be on  
11 the different level. Accumulators are not treated as  
12 a separate system, but they are part of the safety  
13 protection, so they will be discussed.

14 MEMBER STETKAR: Yes, but, I mean, that  
15 is a little bit of where you draw the dotted lines --

16 MS. DIMITRIJEVIC: Right, right.

17 MEMBER STETKAR: -- in calling a system a  
18 system.

19 MS. DIMITRIJEVIC: Definitely, you are  
20 right, they will not show up as really important,  
21 yes.

22 MEMBER STETKAR: But, I mean, some of the  
23 concerns, if you look at historical -- accumulators  
24 are always a good example. I like to hear the fact

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that any component in a system will raise the system  
2 to a level because that means, for example, reverse  
3 leakage through emergency feedwater injection check  
4 valves --

5 MS. DIMITRIJEVIC: Yes.

6 MEMBER STETKAR: -- which never shows up  
7 important in the PRA, but the emergency feedwater  
8 system does.

9 MS. DIMITRIJEVIC: That's true.

10 MEMBER STETKAR: So, by implication,  
11 those check valves at least are part of that list --

12 MS. DIMITRIJEVIC: That's true.

13 MEMBER STETKAR: -- if I understand the  
14 process.

15 MS. DIMITRIJEVIC: Yes. And actually,  
16 this is modeled, you know, as far as shortening  
17 the --

18 MEMBER STETKAR: Yes, but that is  
19 probably not important, though.

20 MS. DIMITRIJEVIC: Right. Well, the  
21 thing is, like this is true. I mean several  
22 components, because of their low failure rates, are  
23 not going to show as important in the PRA, but the  
24 system, though, some of the active components in that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 train, the accumulators are very good examples  
2 because they don't have active components.

3 So, some other active component will show  
4 up, and then everything which comes, like, for  
5 example, you cannot rank these generators as  
6 important and say the building is not, you know,  
7 because it disables important systems.

8 So, hopefully, the expert panel will  
9 cover this all. I mean there is absolutely probably  
10 no guarantee they will, but they are supposed to.

11 MEMBER STETKAR: But, I mean, eventually,  
12 the list will be generated --

13 MS. DIMITRIJEVIC: Yes.

14 MEMBER STETKAR: -- and both the staff  
15 and we will have an opportunity to question details  
16 of the list as a kind of a second or third check.

17 I think my basic, one of my basic  
18 concerns was that I am still hearing that it is  
19 AREVA's responsibility to populate those lists from  
20 everything that is within the Design Certification  
21 scope, that the responsibility of the COL applicant  
22 is strictly limited to anything additional from site-  
23 specific concerns.

24 Does everybody agree?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. GARDNER: I want to apologize if I  
2 didn't finish correcting, that that particular  
3 activity would occur as part of the design phase  
4 performed by the COL applicant.

5 So, I think your question was, when will  
6 very specific components be identified?

7 MEMBER STETKAR: Keep talking. Yes,  
8 that's a question. Yes, when will very specific  
9 components be identified?

10 MR. GARDNER: The final list of the RAP  
11 will be done when the detailed design is finished and  
12 all components have been identified and screened.

13 MEMBER STETKAR: Is that part of the  
14 Design Certification or is that part of the COL?

15 MR. GARDNER: It is part of the COL phase  
16 detailed design.

17 I gave you the list that was provided in  
18 RAI-226.

19 MEMBER STETKAR: Yes, we can get -- I  
20 have to be careful about cites. I can't see that,  
21 basically. I can, but we need to get it through --

22 MR. WIDMAYER: You have to give it to  
23 everybody.

24 MEMBER SHACK: Okay, but let me go

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 through the process again.

2 We just heard that we started with the  
3 PRA. We put components in. We elevated that up to  
4 systems. Now you are saying, in the final design  
5 level, we are going to go back again and deconstruct  
6 back to components when we have more design  
7 information available?

8 Okay, so we started with components. We  
9 go to systems. Eventually, the COL guy will go back  
10 to a list of components.

11 MEMBER STETKAR: Except for the fact that  
12 I read quotes that say -- this is from the SER --  
13 "FSAR Tier 2, Section 17.4(3) describes that the  
14 Design Certification applicant is responsible for  
15 formulating and implementing" -- now it says, "phase  
16 1 of the RAP, including RAP scope, objectives, design  
17 considerations, identification and prioritization of  
18 SSCs" -- SSCs is structures, systems, and components;  
19 that's the "C" -- "RAP organization and expert  
20 panel."

21 So that seems to say that it is a DCD  
22 function to populate the design RAP list down to the  
23 level of components, doesn't it?

24 MR. GARDNER: I think it was on an

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 earlier slide, but the distinction to make is that  
2 that design phase extends not only through Design  
3 Certification, but through design, up through  
4 completion of the design. So, there is an overlap  
5 between what is happening in the design phase and  
6 what is being implemented by the COL.

7 MS. SLOAN: And, Darrell, I would just  
8 clarify. Design Certification is design to a certain  
9 level. Then, I think what we are saying is, beyond  
10 that, we use the term "detailed design". So, what we  
11 are saying is there's the Design Cert part of design  
12 phase, but the other piece, part, is detailed design.

13 MEMBER STETKAR: I understand that. On  
14 the other hand, at the Design Certification stage,  
15 you know that a particular system is going to have a  
16 normally-closed motor-operated valve that must open  
17 with some accident conditions. You might not know  
18 the precise manufacturer of the motor. You might not  
19 know the precise torque and limit switch settings,  
20 but it's got a valve in it that's got to open.

21 You can put that valve in a risk  
22 assessment and determine that that valve, not the  
23 system, the valve, has a certain Risk Achievement  
24 Worth and a certain Fussil-Vasili importance, and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 therefore, on a Design Reliability Assurance Program,  
2 you might identify that valve now as a component;  
3 whereas, perhaps another valve in the system, a  
4 manual isolation valve on a pump might not be so  
5 important. So, for example, you might not  
6 necessarily need to assure yourself that that manual  
7 isolation valve is going to work.

8 So I am still concerned about where this  
9 break is between populating the D-RAP and continuing  
10 that process between the Design Certification and the  
11 COL pump phase, and whether or not the reference --  
12 what I am hearing is that the reference COL  
13 applicant's responsibilities here in this particular  
14 area might extend certainly further than what I  
15 originally understood they were. And are they aware  
16 that they need to do that?

17 Because everything else that I have read  
18 simply seems to say that it is the COL applicant's  
19 responsibility to identify any site-specific  
20 additions to that list. You know, that is certainly,  
21 absolutely, that is a requirement. But how far their  
22 responsibility extends back into the design list is  
23 not clear to me yet.

24 I guess we have probably discussed this

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 enough. Maybe we can ask the staff, when they come  
2 up, in terms of what their interpretation of this is,  
3 as a forewarning.

4 CHAIR POWERS: Maybe they can help us  
5 understand this a little better.

6 Please continue.

7 MR. McENTIRE: Thank you.

8 For the detailed design phase, the RAP is  
9 an integral part of the design process and is  
10 implemented during the detailed design phase, so that  
11 the important U.S. EPR reliability assumptions of the  
12 PRA are considered in the areas of design,  
13 procurement, fabrication, construction, and pre-  
14 operational testing activities and programs.

15 Next slide.

16 For RAP stage 2, which is called the  
17 operating stage, this is outside the scope of the  
18 Design Certification. This will be handled by the  
19 COL applicant.

20 MEMBER STETKAR: But, again, in this  
21 context, this is what people generally call the O-RAP  
22 process.

23 MR. McENTIRE: Correct.

24 MEMBER STETKAR: This is the actual

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 implementation of the programs that will provide  
2 assurance of the reliability of whatever is on that  
3 list, right? It is not populating the list  
4 necessarily.

5 MR. McENTIRE: Right.

6 CHAIR POWERS: I am still struggling a  
7 little bit, I'm afraid, on a lot of this.

8 (Laughter.)

9 But I'm struggling with the RAP is an  
10 integral part of the design process. What does that  
11 mean?

12 MR. McENTIRE: It means that the  
13 important assumptions of the PRA will be carried  
14 through the design process for when we go to procure  
15 and build a plant.

16 CHAIR POWERS: Okay. So, he says I need  
17 a valve for the reliability of 10 to the minus 5; the  
18 valve has to have a reliability of 10 to minus 5? Is  
19 that what that means?

20 MR. McENTIRE: I don't have an answer for  
21 that question. If I can take an action?

22 CHAIR POWERS: Yes, you can.

23 MEMBER STETKAR: I think that is a good  
24 example, but let's extend it to something that I have

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 seen. I haven't seen reliability for valves, but I  
2 have seen reliability goals for diesel generators.

3 CHAIR POWERS: Well, you haven't seen 10  
4 to the minus 5 as a reliability.

5 MEMBER STETKAR: No, no, no.

6 (Laughter.)

7 I won't continue the sentence. But I  
8 have seen reliability goals at the design stage for  
9 things like emergency diesel generators.

10 CHAIR POWERS: Uh-hum.

11 MEMBER STETKAR: So, in principle, that  
12 process, although, as I understand it, the  
13 reliability assurance program, that list doesn't  
14 necessarily specify any particular reliability  
15 targets other than the numbers that are used in the  
16 PRA, but they are not necessarily specified as a  
17 particular target. Is that correct?

18 MR. REINERT: That is true. I mean, the  
19 PRA input was just Fussil-Vasili or a list of  
20 components --

21 MEMBER STETKAR: Right.

22 MR. REINERT: -- but not their  
23 reliability.

24 MEMBER STETKAR: I mean, as I understand

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 it, the purpose of that list is to identify  
2 equipment, structures for which the plant needs to  
3 ensure that, through the plant operating history at  
4 least, that the equipment maintains certain  
5 reliability targets, whether that is through the  
6 Maintenance Rule, or whatever.

7 How that is used or whether it is used in  
8 the design procurement stage, that is another area  
9 where I am not quite sure. In other words, if the  
10 PRA assumes that the diesel generator reliability is  
11 .999, you know, and even with that reliability, it  
12 shows up important, does that imply that the supplier  
13 of that diesel has to demonstrate a 99.9 percent  
14 reliability? I don't know. I mean I am a little bit  
15 vague about how those numbers --

16 MR. REINERT: Yes, I am not sure about  
17 it. From my perspective, I think we are still  
18 wondering how that is going to play out.

19 MEMBER STETKAR: And that gets a bit to  
20 Dana's question about, you know, when I have the  
21 list, what do I do with it? I'm just trying to  
22 figure out how you get the list first.

23 CHAIR POWERS: Yes, I don't understand  
24 that, but I've decided that is hopeless. So, now, I

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 am trying to figure out what to do with it.

2 (Laughter.)

3 I'm not getting too much promising there,  
4 either. But, I mean, it does say it is an integral  
5 part of the design process, and I am trying to  
6 understand what that means exactly from an  
7 operational point of view.

8 And you have said you will explain that  
9 to me, and that is good. I am willing to wait.

10 MS. SLOAN: I would just add,  
11 qualitatively, and I have to leave it to the PRA  
12 experts to talk about quantitatively what it means,  
13 but, qualitatively, part of what it means in the  
14 design process is, as we evolve the design, that the  
15 PRA folks are involved and are evaluating the design  
16 and evolutions of the design.

17 You know, there's a certain level of  
18 design detail we talked about in Design Cert. As you  
19 get into more design detail and add detail or modify  
20 detail, the PRA folks are involved. An integral part  
21 of the review process is to ensure that they review  
22 all of those design evolutions, and particularly  
23 focusing on the systems that are in the RAP list.

24 I think one of them one of them would

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 have to talk quantitatively about what that means in  
2 their evaluation, but that is --

3 CHAIR POWERS: But you would think that  
4 it would, then, say that the RAP is part of the  
5 design review process, not the design process itself.

6 I mean it is very explicit. It says it is an  
7 integral part of the design process. I am just  
8 trying to understand how.

9 And I am a little confused because it  
10 seems like the only thing that we have here is a list  
11 of assumptions in the PRA, which, after that, I don't  
12 know. Do those assumptions have to be -- are they  
13 part of the design specification?

14 MR. REINERT: We do have a COL item that  
15 tells us that we need to verify that those  
16 assumptions are true. I don't know if that counts as  
17 a design --

18 MS. SLOAN: You mean the PRA assumptions?

19 MR. REINERT: The PRA assumptions.

20 MS. SLOAN: In Chapter 19?

21 MR. REINERT: In Chapter 19, yes.

22 MR. GARDNER: And I think it is  
23 important, again, to restate that this design process  
24 extends from Design Certification through this

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 detailed design. So, in terms of the Design  
2 Certification, the objective is the identification.  
3 The implementation of those into the design is done  
4 during that detailed design phase performed by a COL  
5 applicant, in terms of when they begin procurements,  
6 fabrication, construction.

7 MEMBER STETKAR: I just don't -- we have  
8 belabored this, but the good thing is Dana runs a  
9 good meeting, so we are a little bit ahead of  
10 schedule.

11 CHAIR POWERS: And we are about to run  
12 out of time.

13 MEMBER STETKAR: That's okay. I'm aware  
14 of that.

15 It is just that I understand that it may  
16 be that the detailed design phase, for example -- I  
17 will come back to the diesel because it is a better  
18 example than my check valve concern.

19 It may be the detailed design phase and  
20 procurement process that says, okay, we need a diesel  
21 generator that has a demonstrated reliability of 95  
22 percent. You know, you are a potential manufacturer.

23 You have to supply a diesel that meets all of the  
24 design specs and this reliability target. That is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 one way that this process could be implemented from  
2 the Design Certification through what you are  
3 calling, as I understand it, the detailed design in  
4 the COL phase.

5 On the other hand, I am more concerned  
6 about making sure that the list of things that the  
7 COL applicant needs to be aware of, and specify  
8 perhaps reliability targets, is effectively populated  
9 and who has the responsibility for doing that  
10 population. And I am still not clear on that.

11 So I am going to pull back to, who  
12 develops the initial list? And if it is the COL  
13 applicant who has the responsibility of developing  
14 that list, including things that are not only the  
15 site-specific items, but extending back into the  
16 basic elements of the Certified Design, I guess, in  
17 principle, I can handle that, but I want to make sure  
18 that we understand that that's the way the process  
19 works.

20 Because we are getting into reviewing COL  
21 applications. Quite frankly, we are a little bit  
22 further ahead on another one of the designs, and I  
23 haven't seen any of that. So, if it is an  
24 understanding of who does the population of that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 list, again, it is a little bit of a question to the  
2 staff. But, as long as there is consistency from  
3 design to design center, and that the COL applicants  
4 and the Design Certification folks are both on the  
5 same page in terms of who does what when --

6 MS. SLOAN: And what I heard you say is  
7 making sure there are no gaps.

8 MEMBER STETKAR: That is exactly right.

9 MS. SLOAN: To me, that is the critical  
10 part.

11 MEMBER STETKAR: That is exactly right.

12 MS. SLOAN: Is there a piece of it that  
13 is uncovered? I think we will need to take an action  
14 to come back and give you a more detailed explanation  
15 of how all the phases are covered.

16 Vesna Dimitrijevic was saying she would  
17 like to make a comment.

18 Vesna, did you want to comment here?

19 MS. DIMITRIJEVIC: Yes. I just would  
20 like to make a simple comment. It is, obviously, I  
21 hope nobody -- I mean I know, John, you are not  
22 expecting that somebody is going to buy this  
23 generator with 2.5 E minus 2 failure to start. That  
24 is absurd.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 (Laughter.)

2 So, nobody is expecting this, the PRA is  
3 going to give such level of detail. If the PRA  
4 identified this component as important, that is what  
5 is just called up, is the reliability issue, and  
6 probably it means the plan has to have in place a  
7 problem, which just makes sure that this component is  
8 not neglected somewhere in the corner; nobody is  
9 testing, inspecting, keeping it active. That's all.

10 All of these assumptions which we made, I  
11 also want to say, are just general PRA assumptions.  
12 They don't have to be important. They are not there  
13 to design the plant. They are there to make sure the  
14 PRA reflects the plan, and if something happens, we  
15 can just change assumptions or we can elevate the  
16 importance of it.

17 That was all I was going to say.

18 MR. McENTIRE: That is all I have.

19 CHAIR POWERS: Thank you, John.

20 MS. SLOAN: So, last, just a brief  
21 description of the implementation of the Maintenance  
22 Rule Program. This is very quick, and that is fine.

23 As you know, the Maintenance Rule is an  
24 operational program required by 10 CFR 50.65, and in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 our application there is a COL item there saying that  
2 the COL applicant will describe the program for  
3 Maintenance Rule implementation.

4 So that is all we have on Chapter 17.

5 CHAIR POWERS: Any other questions?

6 (No response.)

7 We will turn to the staff and see if they  
8 can help us here.

9 Very good.

10 MR. TESFAYE: Thank you, Mr. Chairman.  
11 Staff is ready to make its presentation.

12 I would like to introduce the Chapter PM  
13 who is going to be leading this presentation, Mr.  
14 Tarun Roy.

15 MR. ROY: My name is Tarun Roy. I am the  
16 NRO Project Manager responsible for coordinating  
17 staff review of U.S. EPR FSAR Chapter 17, Design  
18 Certification application.

19 I have been with the NRC for the last  
20 four years in different capacities, as an operation  
21 engineer, structural engineer, and product manager.  
22 I have a degree in civil structural engineering.

23 I have several years of experience, about  
24 30 years, dealing with several nuclear power plants

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 during construction to completion phases. I worked  
2 in construction, design engineering, and quality  
3 assurance programs at nuclear sites as well as in  
4 engineering offices.

5 I worked for Bechtel Corporation in San  
6 Francisco, DuPont Engineering, Charlotte, North  
7 Carolina, and the TVA jobsite in Alabama and  
8 Tennessee.

9 The NRC technical staff involved with the  
10 safety review of the U.S. EPR FSAR 17 are Kerri  
11 Kavanagh, Quality Assurance and Vendor Branch; Hanh  
12 Phan, PRA Branch.

13 During this meeting, the staff plans to  
14 make a presentation of the Chapter 17 Reliability  
15 Assurance and Safety Evaluation Report of SER with  
16 the open items.

17 Staff issued a total of 26 questions to  
18 the applicant requesting additional information. Out  
19 of the 26 questions, there are two open items  
20 identified in the SER with the open items. The staff  
21 will discuss these open items in detail.

22 U.S. EPR FSAR Chapter 17 SER with open  
23 items was issued as a publicly-available document on  
24 January 26th, 2010.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 With that, I now turn the presentation  
2 over to Technical Reviewer Kerri Kavanagh for the  
3 Section 17.1, 17.2, 17.3, 17.4 -- 17.5 -- of the  
4 Quality and Vendor Branch.

5 MS. KAVANAGH: Yes, don't ask me any  
6 questions about 17.4. I'll deny all of it,  
7 especially after the grilling you gave them.

8 (Laughter.)

9 Good afternoon.

10 I'm Kerri Kavanagh, Senior Reactor  
11 Engineer, the Office of NRO Quality and Vendor  
12 Branch.

13 I have been with the agency almost 18  
14 years. Not all of it has been with the Quality and  
15 Vendor Branch, but most of it has been in reactor  
16 systems and tech specs.

17 I have a degree, a bachelor's degree, in  
18 nuclear engineering and a master's degree in  
19 environmental engineering.

20 Before I joined the NRC, I worked part-  
21 time for Jonah Public Service as a junior engineer  
22 doing fuel cycle analysis.

23 With that, I would like to go over the  
24 two RAIs that are still open within the SER.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           The first RAI is 227 with regard to the  
2       staff's inspection that we currently plan to do in  
3       April. As part of our review of 17.5, our program  
4       requires us to go out and make sure that the  
5       applicant is implementing their QA program. That  
6       inspection is currently scheduled for April. That is  
7       about all I have to say about that one.

8           CHAIR POWERS: Do you have an inspection  
9       plan?

10          MS. KAVANAGH: The inspection plan, I do  
11       not know if that has been issued, but we normally  
12       issue a non-public inspection plan that would be  
13       available in ADAMS. Generally, our inspections are  
14       limited in scope. They will cover the areas of  
15       particular interest. We will be looking at probably  
16       design control, corrective action, non-conformances,  
17       training, Part 21, and I would say procurement  
18       document control, are generally the areas that  
19       inspections will look at.

20          CHAIR POWERS: You're not responsible for  
21       making up that plan?

22          MS. KAVANAGH: I am not leading that  
23       inspection, no, sir.

24          The other open item is with regard to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 17.4, and this is all I am ever going to say about  
2 17.4. It is in reference to the RAP ITAAC wording  
3 in the FSAR Tier 1, table 3.2.1, that needs to be  
4 revised to conform to the wording in the Interim  
5 Staff Guidance 018, Reliability/Quality Assurance.

6 MEMBER STETKAR: Should we ask you about  
7 that?

8 MS. KAVANAGH: No, sir.

9 MEMBER STETKAR: No?

10 (Laughter.)

11 We shouldn't have even said that, then,  
12 should we?

13 MS. KAVANAGH: But, once we turn it over  
14 to Hanh, I would be more than happy to let him answer  
15 that for you.

16 (Laughter.)

17 Next slide.

18 17.5, as described by our counterparts at  
19 AREVA, AREVA submitted their QA Topical Report prior  
20 to their Design Certification. So, we were able to  
21 review and approve their Topical Report for the  
22 Design Certification. We did that in April 2007.  
23 That Topical Report is based on the ASME NQA-1-1994  
24 standard.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 And that is all I have to present. Any  
2 questions?

3 CHAIR POWERS: Well, we are certainly not  
4 going to ask you about --

5 (Laughter.)

6 MS. KAVANAGH: Thank you.

7 CHAIR POWERS: Because you won't answer.  
8 It just doesn't do any good to ask that question.

9 Are there any questions on the area that  
10 Kerri will talk about?

11 Kerri, could you give us a list of the  
12 topics you are willing to talk about?

13 (Laughter.)

14 A unique strategy for a speaker, "I'm not  
15 going to answer any."

16 (Laughter.)

17 Are there any more questions?

18 (No response.)

19 Charge ahead.

20 MR. PHAN: Thank you.

21 Good afternoon.

22 I would like to start my presentation  
23 with a brief introduction of myself. My name is Hanh  
24 Phan. I joined the NRC in 2006.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Prior to that, I worked at the Idaho  
2 National Lab in Idaho Falls and Pacific Northwest  
3 National Lab in Richland, Washington. I also worked  
4 at the Nuclear Power Plant Columbia Generating  
5 Station in Washington State as well.

6 I have served as multiple positions,  
7 including principal investigator, project manager,  
8 lead technical, and currently I am the Senior PRA  
9 Analyst in the PRA Branch.

10 I have over 20 years working with the  
11 industry, specializing in reliability and PRA.

12 The U.S. EPR RAP is divided into two  
13 stages, design and operating. The DC applicant is  
14 responsible for the design-specific information, and  
15 the COL applicant is responsible for the site-  
16 specific information.

17 The RAP design information, specific  
18 information, is provided in the Chapter 17.4. As a  
19 result of the staff review, the applicant agreed to  
20 include two tables in Chapter 17.4.

21 Table 17.1-1 provides the risk-  
22 significant SSCs identified from the PRA perspective.

23 Table 17.4-2 provides the risk-significant systems  
24 and structures, including those identified by the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 expert panels. Those tables include those risk-  
2 significant SSCs identified by the staff.

3 MEMBER STETKAR: Hanh?

4 MR. PHAN: Yes, sir.

5 MEMBER STETKAR: Now you get to answer  
6 all the questions.

7 MR. PHAN: Yes, sir.

8 MEMBER STETKAR: Can you expand a little  
9 bit about your understanding of the process that we  
10 heard about in the previous discussion in terms of  
11 who is responsible to populate the list, the D-RAP  
12 list at the level of components? Is that part of the  
13 scope of the Design Certification applicant or is  
14 that the scope of the COL applicant?

15 MR. PHAN: From the staff's perspective,  
16 we are working on the Interim Staff Guidance 018,  
17 which provides more details on the responsibility of  
18 the DC applicants and COL applicant. But, for now, I  
19 would like to briefly, please, answer your question  
20 that the responsibility of the final list of the  
21 risk-significant SSCs, that is the responsibility of  
22 both.

23 The staff expected that at the  
24 certification the DC applicant is going to identify

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 all risk-significants identified in the design stage  
2 and the specific information belongs to the COL-  
3 holders.

4 MEMBER STETKAR: Okay. Let me make sure  
5 I understand what you just said, then. When you say,  
6 "any design-specific", do you mean any changes from  
7 the Certified Design and site-specific issues? Or do  
8 you mean specific elements of the Certified Design?

9 And let me use the accumulator check  
10 valves. That is an element of the Certified Design.  
11 The accumulators have check valves.

12 Is the responsibility for identifying  
13 those check valves as being on the D-RAP list, does  
14 that lie within the Design Certification scope or  
15 does it lie within the COL applicant scope of  
16 populating that list?

17 MR. PHAN: Yes, sir. As you have seen,  
18 one of the questions issued by the staff regarding  
19 the class of components, we specifically spell out  
20 check valves. In the response, they say that, the  
21 applicants say that the COL-holder is responsible for  
22 all the passive components, including check valves.

23 However, the staff looked at the list of  
24 the risk-significant SSCs identified by the PRA;

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 check valve is included in there. The staff does not  
2 review to the level of component levels because there  
3 are open items in Chapter 19 asking applicants to  
4 revise and update their PRA to include all of the  
5 findings from the reviews. The applicant needs to  
6 update their insights, including their risk-  
7 significant SSCs.

8 But, then, the staff would check to  
9 ensure that all the risk-significant SSCs from the  
10 component levels would be included, those that are  
11 identified in the Design Certification.

12 I guess I have just been told that maybe  
13 we will revisit this topic tomorrow, which I think --  
14 let me just make a short statement.

15 CHAIR POWERS: Well, I can guarantee we  
16 are going to revisit this topic, but whether it is  
17 tomorrow or not, I don't know.

18 (Laughter.)

19 MEMBER STETKAR: Oh.

20 MR. WIDMAYER: AREVA wants to bring some  
21 figures and stuff and present them to try to clarify  
22 the situation.

23 MEMBER STETKAR: Okay. I think the  
24 reason that I am feeling uneasy about this is that,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 from what I hear you saying and from what I heard  
2 AREVA saying, it seems to impose a fairly substantial  
3 requirement on the COL applicant to, if not update  
4 the scope of the PRA, at least do a substantial  
5 amount of evaluation, both quantitative and  
6 qualitative, of the PRA results, and perhaps the  
7 findings of the Design Certification expert panel, to  
8 ensure that the D-RAP -- and remember D-RAP, not  
9 O-RAP -- D-RAP list is appropriately populated.

10 Now, if it is the D-RAP list, it is still  
11 not clear to me how that goes over into the COL  
12 stage. And quite honestly, from at least what we  
13 have seen so far, COL applicants seem to be simply  
14 taking by reference the PRA results and findings and  
15 the lists. They don't seem to be doing anything with  
16 them.

17 So, I think it is important for us to  
18 understand, and a potential COL applicant, where  
19 those responsibilities lie, because I see the  
20 potential for some big gaps.

21 MR. PHAN: Yes, sir.

22 MEMBER STETKAR: The Design Certification  
23 people saying, "Well, it's their responsibility"; the  
24 COL applicant saying, "Well, we just take over

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 something by reference that has already been  
2 certified as part of the design."

3 MR. PHAN: Yes, sir.

4 MEMBER STETKAR: So, I guess we will  
5 revisit this tomorrow, then, unless Dr. Powers wants  
6 to revisit it immediately.

7 (Laughter.)

8 CHAIR POWERS: No, we've got time, based  
9 on the schedule.

10 MEMBER STETKAR: You think you have time  
11 tomorrow.

12 (Laughter.)

13 CHAIR POWERS: I am quite certain  
14 tomorrow is not going to resolve this issue.

15 MEMBER STETKAR: Okay.

16 CHAIR POWERS: Between now and the time  
17 that we have to write something, we have got time to  
18 understand this issue.

19 MEMBER STETKAR: Okay.

20 CHAIR POWERS: And I suspect that we will  
21 take every minute of it, if I am the one to declare  
22 that I understand.

23 Okay, please continue.

24 MR. PHAN: Thank you.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           From the PRA's perspective, the DC  
2           applicant used the importance measured criterias of  
3           Fussil-Vasili and Risk Achievement Worth. The staff  
4           found that these criterias conformed to the NEI 00-04  
5           and Title 10 CFR 50.69 SSC, Categorization  
6           Guidelines, as endorsed by Reg Guide 1.201. So,  
7           these criterias are acceptable.

8           Next, please.

9           The staff identified two COL information  
10          items. 17.4-1 states that COL applicants that  
11          referenced the U.S. EPR Design Certification will  
12          identify the site-specific SSC within the scope of  
13          the RAP. And COL information item 17.4-2 states that  
14          COL applicants will provide the information requested  
15          in the Reg Guide 1.206, Section C.I.17.4.4.

16          At the end of the phase two, the staff,  
17          out of 22 questions, the staff identified one open  
18          item regarding the RAP ITAAC wording provided in the  
19          FSAR Tier 1 document, Section 3.2, table 3.2.1.

20          Next slide, please.

21          For comparison purposes, this slide shows  
22          you the wording provided in Revision 1 of the FSAR  
23          and, also, shows you the wording provided in the  
24          Draft Interim Staff Guidance 0018.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1           The staff identified that the RAP ITAAC  
2 provided in the FSAR Tier 1, Section 3.2, table  
3 3.2.1, does not clearly specify the ITAAC commitment  
4 wording and the associated acceptance criterias.

5           First, in RAI 355, Question 17.4-23, the  
6 staff requested that the applicant reconsiders this  
7 wording to conform with the wording provided in the  
8 Interim Staff Guidance 0018. This question is being  
9 tracked as an open item.

10           MEMBER STETKAR: Hanh?

11           MR. PHAN: Yes, sir.

12           MEMBER STETKAR: I certainly agree that  
13 what was in there didn't say anything. Could you  
14 explain what the ITAAC from the COL ISG-018 means?  
15 Because when I read those words, there are more words  
16 there, but I don't understand what they mean.

17           MR. PHAN: Yes, sir.

18           Would you please take a look at the last  
19 column of the two tables there? The first table in  
20 the last two lines is talking about overall plans,  
21 reliabilities.

22           In the second table, we are talking about  
23 the applicable reliability assurance activities for  
24 the D-RAP. The lessons learned and the insights

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 gained from the reviews indicate that the applicants  
2 commonly interpreted the acceptance criterias at the  
3 numerical analysis that would require the estimated  
4 reliability of each RAP SSC to be at least equal to  
5 the reliability assumed in the PRA.

6           However, these RAPs should not be based  
7 solely on the numerical values. These RAPs should  
8 also address the key assumptions and insights.

9           The staff concluded that implementation  
10 of these RAPs should be in the practice of having a  
11 process that would control reliability and  
12 availability of the RAP SSCs.

13           CHAIR POWERS: I am not helped.

14           MEMBER STETKAR: No, I think what I am  
15 struggling with is I think I hear what you are  
16 saying, but I am looking at the words up there that  
17 say, you know, the inspections, tests, and analyses.

18           "An analysis will confirm that applicable  
19 reliability assurance activities for the D-RAP have  
20 been used in the design of all RAP SSCs." And this  
21 is a COL, whatever it is called. It is an ITAAC  
22 item. And the acceptance criteria is that analyses  
23 verify that that has been achieved.

24           What are the applicable reliability

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 assurance activities for the D-RAP if we don't have  
2 (a) a complete D-RAP list from the DCD and the  
3 requirement is only to provide a list? I mean I  
4 guess, what reliability assurance activities are you  
5 talking about in the design?

6 I understand about post-design, the  
7 eventual licensee is responsible for making sure  
8 that, indeed, the equipment remains reliable and  
9 available, and if they have reliability targets, how  
10 those are -- that is fine. I understand the  
11 operational phase of this program.

12 I am struggling with what, I am trying to  
13 think of what type of measures do I use in practice  
14 to audit this ITAAC and say, yes, indeed, people have  
15 confirmed that applicable reliability assurance  
16 activities have been used during the design. What  
17 does that mean?

18 MR. PHAN: May I read to you the wording  
19 in the Draft Interim Staff Guidance 0018?

20 MEMBER STETKAR: Please, yes.

21 MR. PHAN: "The objective of the D-RAP  
22 can be achieved through the following: apply the  
23 essential elements of this RAP, including  
24 organization, design control, procedures and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 instructions, corrective action, and audit plans."

2 Okay, that is the design and construction

3 --

4 MEMBER STETKAR: That is all standard  
5 design-type quality assurance and procurement.

6 MR. PHAN: Yes, sir.

7 MEMBER STETKAR: So, there is nothing  
8 about what I consider reliability there.

9 Continue.

10 MR. PHAN: Yes. And the second bullet  
11 says that, "Implements the appropriate quality  
12 assurance programs related to the design and  
13 construction, including design, construction,  
14 inspection, and testing activities to provide control  
15 over activities affecting the quality of the RAP's  
16 SSCs."

17 MEMBER STETKAR: Okay. That's it? Those  
18 are all standard design-type quality assurance  
19 issues.

20 MR. PHAN: Yes, sir.

21 MEMBER STETKAR: Those don't say anything  
22 about assuring the reliability of potentially risk-  
23 important structures, systems, or components.

24 MR. PHAN: Not as mentioned in this

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

Interim Staff Guidance.

MS. MROWCA: Excuse me.

Hi, John.

MEMBER STETKAR: Hi.

MS. MROWCA: This is Lynn Mrowca. I am the PRA Branch Chief in the Office of New Reactors, PRA and Severe Accidents.

I would like to add, we know that you are struggling with the wording on this D-RAP ITAAC. I would highlight the word "draft". We are also struggling, as staff, on this. Currently, it is not issued.

Part of our issue has been with the acceptance criteria and understanding and making sure that is clear. So, all I can say right now is we are still working on it.

MEMBER STETKAR: Yes, thanks, Lynn.

MS. MROWCA: So we understand your struggling with words.

MEMBER STETKAR: That helps a lot. I mean, you know, one thing that I flagged, reading through here, is exactly what you did, is that the previously-proposed wording didn't say anything. These words say more, but it is not clear, when I

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 think about the actual ITAAC closeout process, what  
2 are the inspectors going to be looking for and what  
3 is expected of the COL applicant to actually satisfy  
4 what we want?

5 So, I am glad to hear that it is a staff  
6 draft, and it is an open item in the SER. So, we  
7 will have a chance to revisit it.

8 MR. PHAN: Yes, sir.

9 MEMBER STETKAR: So, I guess that is as  
10 far as we can get, Hanh.

11 MS. MROWCA: In our conversation about  
12 the detailed design, that is really why we have this  
13 ITAAC, to ensure that, in quotes, "the conceptual  
14 design", once we get to the detailed design part,  
15 that we have not changed our key risk assumptions and  
16 insights.

17 MEMBER SHACK: Now this is very similar  
18 to the problem one runs into in 50.69, and I can't  
19 remember the guidance that was developed to help  
20 there. Is it as vague as this?

21 MS. MROWCA: I don't know. I would have  
22 to look at that again to see.

23 MEMBER SHACK: I mean, that would  
24 certainly be the first place I would go look, since

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 people wrestled with that for years, and it is a  
2 similar problem. That would be the first place I  
3 would look for some guidance. I am little surprised  
4 to see you haven't looked at it at all, but that  
5 would seem like the first place to look.

6 CHAIR POWERS: Any more questions for  
7 this speaker?

8 MEMBER SHACK: Just there's a listing in  
9 the SER of the criteria that the expert panel used  
10 and why you blessed the numerical criteria for the  
11 PRA. You didn't say anything about whether you  
12 thought the criteria they used for the expert panel  
13 were suitable.

14 Are those also consistent with the 50.69  
15 categorization guidance?

16 MR. PHAN: I have questions regarding the  
17 expert panel. The applicant states that they are  
18 using the same process described in the PRA standard,  
19 ASME standard of 2005, to select the expert panels  
20 and look at the systems and components, according to  
21 the guidance provided in the NEIs. So, I assumed  
22 they are using the same process for the Maintenance  
23 Rule to identify the risk-significant SSCs.

24 CHAIR POWERS: Are you satisfied with

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that?

2 MEMBER SHACK: No, but I am going to  
3 quit.

4 (Laughter.)

5 CHAIR POWERS: Oh, okay.

6 But could you tell me, just for my own  
7 information, the applicant and everybody else in the  
8 world seems to use RAW thresholds of 2 and Fussil-  
9 Vasili of 5 times 10 to the minus 3rd. Can you tell  
10 me why we use those?

11 MR. PHAN: I apologize that I don't have  
12 the answer. But based on my experience at the  
13 nuclear power plants, that is these criterias that  
14 people use for the Maintenance Rule.

15 CHAIR POWERS: Yes, I know that.

16 MR. PHAN: Yes.

17 CHAIR POWERS: I mean everybody seems to  
18 use them.

19 MR. PHAN: Yes.

20 CHAIR POWERS: It just struck me that I  
21 don't know why we use them.

22 MR. TESFAYE: Maybe we can get back to  
23 you with that.

24 CHAIR POWERS: Yes, if you can. It is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 just an item of curiosity to me right now.

2 Any other questions for these speakers?

3 (No response.)

4 Okay, I am going to conclude this, and I  
5 am going to go off the record because I want to chat  
6 with the Committee just a little bit about where we  
7 stand here, if we can.

8 We will resume at 3:15.

9 (Whereupon, the foregoing matter went off  
10 the record at 2:30 p.m. and went back on the record  
11 at 3:14 p.m.)

12 CHAIR POWERS: We are going to launch  
13 into the first part of our discussion of PRA and  
14 Chapter 19, Severe Accident Analysis. And what's  
15 more, we are going to conclude tomorrow at sometime  
16 between 4:00 and 4:30, contrary to what the agenda  
17 says. So, that means we are going to be action-  
18 packed tomorrow.

19 Okay, Getachew?

20 MR. TESFAYE: We have a lot of materials  
21 to present today.

22 CHAIR POWERS: Apparently so.

23 MR. TESFAYE: We will go as long as you  
24 let us stay here.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(Laughter.)

Our goal is to finish up everything by tomorrow.

And also, we are handling this chapter differently because AREVA is going to present certain portions first, and then the staff will present theirs.

CHAIR POWERS: So you are going to do a tag team?

MR. TESFAYE: We are going to do that, yes, a tag team. So, we have broken it up into, I think, three different presentations.

CHAIR POWERS: And you're not going to confuse me on any of them?

MEMBER STETKAR: This is only AREVA's first presentation?

(Laughter.)

MR. WIDMAYER: Oh, you want me to get the others?

(Laughter.)

MS. DIMITRIJEVIC: It depends on how many slides he has.

MEMBER STETKAR: There's 97 slides here. Let me count them.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MS. DIMITRIJEVIC: No, no, no, this is  
2 all of them.

3 MEMBER STETKAR: Okay.

4 MS. DIMITRIJEVIC: No, no.

5 MEMBER STETKAR: And this is the staff's  
6 entire presentation, 97? Okay, good.

7 CHAIR POWERS: Okay. Well, regardless of  
8 what --

9 MR. TESFAYE: We are going to go fast, so  
10 --

11 CHAIR POWERS: Yes, well, that probably  
12 won't happen. My intention is to conclude the  
13 discussions for the day at five o'clock, in which  
14 case I will talk to my Committee for a half-an-hour  
15 or less, because I don't think this issue is going to  
16 get resolved today.

17 Okay. So you are done?

18 MR. TESFAYE: I'm done. Thank you.

19 CHAIR POWERS: And now we will turn to  
20 Sandra, who is promising me that she is not going to  
21 confuse me.

22 MEMBER STETKAR: Boredom.

23 MS. SLOAN: No confusion, no boredom.

24 CHAIR POWERS: Neither confusion nor

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 boredom? Okay.

2 MS. SLOAN: So, we would like to start  
3 the Chapter 19 presentation talking about the Level 1  
4 PRA. As you noted, we have an extensive AREVA staff  
5 here. Part of that is because PRA is broad and  
6 focuses in a lot of different areas. So, while we  
7 have expert PRA practitioners here supporting us,  
8 there are also some staff supporting us with systems-  
9 related questions.

10 Part of that is related to our perception  
11 from previous meetings that there's a lot of interest  
12 in this area and questions that have carried over  
13 from previous discussions. So, with that in mind, we  
14 wanted to be sure we had the right staff here to take  
15 care of those questions. So, that is why you see --

16 CHAIR POWERS: You tell me that this is  
17 broad, but you have left out seismic?

18 MS. SLOAN: We will get to that. We will  
19 get to that.

20 So, like we have done in the past, we  
21 will ask the presenters at the beginning of their  
22 presentation to give some brief biographical  
23 information, and then, as AREVA staff is called on to  
24 answer questions, if you have not already done so for

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the ACRS staff, if you will give your biographical  
2 information.

3 And we will be describing the results of  
4 the PRA and the Severe Accident Evaluation, as  
5 presented in the FSAR.

6 I did want to call your attention to the  
7 fact that, at least for me, when I look at PRA space,  
8 sometimes it is like alphabet soup. So, there is a  
9 list of abbreviations and acronyms at the back of  
10 your package. I find, particularly in the I&C area,  
11 and maybe I am just challenged in that particular  
12 area, but when we start talking about our I&C  
13 systems, I get confused. So, you might want to pull  
14 off the last two pages. Anyway, I just want to make  
15 you aware those are there. If you get confused, stop  
16 us and ask us, but that is at the end.

17 So, with that, I will go ahead and  
18 introduce our first speaker, Dr. Vesna Dimitrijevic.

19 MS. DIMITRIJEVIC: Thank you.

20 Well, I was going to open with thank you  
21 for the opportunity, but I am going to save this for  
22 the end.

23 (Laughter.)

24 I am going to say thank you when I am

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 finished.

2 CHAIR POWERS: Usually people thank me  
3 because we brought it to an end, not because we  
4 started.

5 (Laughter.)

6 MS. DIMITRIJEVIC: I was the Technical  
7 Lead on Level 1 in the area of PRA for the EPR Design  
8 Certification.

9 I have 35 years of experience in the PRA  
10 area. I started right out at WASH-1400, was sent to  
11 old Europe in universities. So, there is 35 years  
12 since WASH-1400 came out.

13 I have done my master's degree in the PRA  
14 area at the University of Belgrade, and I did my PhD  
15 at MIT. I had a chance to work with Professor Rasmus  
16 and Professor Vasili on my thesis.

17 Since then, I worked in the Yankee  
18 Atomic, which was bought by Duke Engineering, which  
19 was bought by Framatome, which became AREVA.

20 (Laughter.)

21 Basically, I work in the same office with  
22 a similar group of people.

23 Through this history, I have had a chance  
24 to be part of a lot of historic moments. Actually, I

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 see this as an historic moment because we are doing  
2 something new, actually. We are using PRA Design  
3 Certification. So, that explains why we may have a  
4 little more questions than answers.

5 In Yankee Atomic, I actually was a part  
6 of the team which did the first IPE and IEEE  
7 application ever submitted to the regulator. In Duke  
8 Engineering, I was the PRA lead on the risk-informed  
9 development of the EPRI risk-informed ISI  
10 application, which became the most successful risk-  
11 informed application in the U.S. history. It is now  
12 used almost in every plant.

13 And here, in AREVA, this is one of my  
14 most exciting jobs. I work on a wonderful PRA team.

15 I am AREVA's senior expert, and I am Technical  
16 Consultant, which is the highest technical title.

17 But, actually, you would think by now I  
18 know everything about PRA, but the PRA is such a  
19 complex area that, actually, there is no single  
20 person who can know this area so well, and there are  
21 some things which I am definitely not a specialist.  
22 Like, for example, I refuse to look in Level 2,  
23 because for me this is like forensic science, which  
24 is the melted. After we melt it, I don't really

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 care what happens.

2 (Laughter.)

3 CHAIR POWERS: I assume that you are good  
4 friends with your Emergency Planning people, huh?

5 (Laughter.)

6 MS. DIMITRIJEVIC: I decided maybe I  
7 should look a little more.

8 I definitely am not a seismic specialist.

9 I am not a digital I&C specialist. We have members  
10 of my team which will support me in these areas.

11 So, let me just start on a very high  
12 level. There is Commission Safety Goals, which we  
13 are all familiar with. U.S. EPR also has their own  
14 probabilistic goals, which are very similar, except  
15 the probabilistic goal for core damage frequency was  
16 less than 10 to the minus 5 per year. There was no  
17 goal on the condition of containment ability, but a  
18 scope is defined that should include internal and  
19 external events.

20 CHAIR POWERS: None of those are  
21 Commission Safety Goals.

22 MS. DIMITRIJEVIC: Excuse me?

23 CHAIR POWERS: None of them are  
24 Commission Safety Goals.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER APOSTOLAKIS: They are not  
2 Commission on this. This is just staff.

3 MS. DIMITRIJEVIC: Staff? All right.  
4 Okay. I am not really finetuned to those  
5 differences, but I will learn.

6 CHAIR POWERS: Now let's go back. Hold  
7 it. We're not done yet.

8 MS. DIMITRIJEVIC: All right.

9 CHAIR POWERS: Why are we excluding  
10 seismic?

11 MS. DIMITRIJEVIC: Why did we exclude  
12 seismic? Because that is how the U.S. EPR  
13 probabilistic goal was defined in that we did not  
14 expect the seismic PRA would part of the requirements  
15 in the Design Certification scope.

16 MEMBER APOSTOLAKIS: Really? There is  
17 always a summary of seismic evaluation.

18 MS. DIMITRIJEVIC: Well, yes, evaluation,  
19 but not the PRA.

20 CHAIR POWERS: The seismic margins.

21 MS. DIMITRIJEVIC: Not in America.

22 MEMBER APOSTOLAKIS: Oh, okay.

23 MS. DIMITRIJEVIC: Within America.

24 MEMBER APOSTOLAKIS: Okay. Okay.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MS. DIMITRIJEVIC: Yes, we did the PRA  
2 seismic margin, not part of the numerical values, is  
3 what I am saying.

4 CHAIR POWERS: Did we include fire?

5 MS. DIMITRIJEVIC: We include fire. We  
6 include the floods, include all modes of operation.  
7 Include the level of --

8 MEMBER APOSTOLAKIS: That is an  
9 interesting point, though. You include fire, but you  
10 have a statement somewhere there that you don't know  
11 the routing of the cables.

12 (Laughter.)

13 MS. DIMITRIJEVIC: That's true.

14 MEMBER APOSTOLAKIS: How can you do a  
15 fire -- I mean, is it the bounding analysis again?

16 MS. DIMITRIJEVIC: It is a bounding  
17 analysis.

18 MEMBER APOSTOLAKIS: If everything goes?

19 MS. DIMITRIJEVIC: If everything goes.  
20 You will see, as we promised through this --

21 MEMBER STETKAR: How can you do a  
22 bounding --

23 MEMBER APOSTOLAKIS: I mean, if you don't  
24 know where the cables are --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MEMBER SHACK: Let's get to the fire, so  
2 we can ask specifically. If we get to the fire, we  
3 can ask specific questions.

4 MS. DIMITRIJEVIC: We will be responding  
5 very soon, in the next couple of slides.

6 Somebody asked here, how can you do at  
7 all like a PRA in this area? I just want to say what  
8 we have is the PRA which corresponds to the design  
9 that is going to be certified. When you have a PRA  
10 which corresponds to design, you have a very good  
11 skeleton of the PRA. Everything else comes later,  
12 procedures, you know, maintenance, and everything.  
13 This is just like adding meat on the skeleton.

14 MEMBER APOSTOLAKIS: Is this why you have  
15 this very interesting table? I would expect most  
16 applicants to actually show the CDF that you have --

17 MS. DIMITRIJEVIC: And we will do it.

18 MEMBER APOSTOLAKIS: -- but all you are  
19 saying is that it is less than 10 to the minus 4?

20 MS. DIMITRIJEVIC: No, no, no. Don't  
21 worry.

22 MEMBER APOSTOLAKIS: I've got to worry.  
23 I do worry.

24 MS. DIMITRIJEVIC: You are going to see

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 much details. As you can see, this is Chapter 19.  
2 Believe me, this is how to start.

3 MEMBER APOSTOLAKIS: I know, but --

4 MS. DIMITRIJEVIC: But there is going to  
5 be less numbers and we will present every single risk  
6 measure which we calculated.

7 MEMBER APOSTOLAKIS: Can somebody remind  
8 when we decided -- I know we had a discussion like  
9 this before. When did the LRF become part of this  
10 approach and we extend to the minus 6? Is that  
11 official?

12 MEMBER SHACK: Yes. Yes. It is  
13 Commission policy, in the nineties, '93, something  
14 like that.

15 MEMBER APOSTOLAKIS: But we were working  
16 with LERF of 10 to the minus 5 for a long time.

17 MEMBER SHACK: As a surrogate.

18 MEMBER APOSTOLAKIS: So we came to back  
19 the real thing?

20 MEMBER SHACK: Well, now you are back to  
21 -- this is an advanced reactor.

22 MEMBER APOSTOLAKIS: Yes, okay.

23 MEMBER STETKAR: Vesna, before we leave  
24 the seismic thing, because my sense is we probably

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 won't have a chance to talk about it after this  
2 point.

3 (Laughter.)

4 MS. DIMITRIJEVIC: No, no, no. there  
5 will be slides on seismic. Don't worry. I mean I am  
6 really surprised that we are stopped on this slide.  
7 It is very introductory.

8 MEMBER STETKAR: Okay. All right. So,  
9 should we leave the discussion --

10 MS. DIMITRIJEVIC: Yes, please.

11 MEMBER STETKAR: -- of seismic risk until  
12 we get to the seismic topic then?

13 MS. DIMITRIJEVIC: Very true. And, you  
14 know, I actually missed to show you some simple table  
15 of contents, but I will go to internal events, to the  
16 fire, floods, seismic, shutdown. I will show that  
17 all these measures we will discuss, the main system.  
18 So, everything will be here. It is on a high level,  
19 but we will have a chance to stop on each of them.  
20 Then, we will be Level 2 tomorrow.

21 So, the objective of the Design  
22 Certification PRA was to demonstrate that this design  
23 is robust and that the probabilistic goals are met.  
24 This is very high level.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           The result specificity of this U.S. EPR  
2 Design Certification PRA which, actually, made me  
3 enjoy this project very much, and, actually,  
4 basically makes PRA to be everything but boring.

5           I have to say that this was the first  
6 Design Certification PRA where we have provided all  
7 PRA results. Everything which you will see today was  
8 included in Chapter 19. So, very detailed results,  
9 importance measures, importance sequences, all the  
10 risk of measures are part of the FSAR Chapter 19.  
11 You can see that this chapter has 600 pages. It is a  
12 very detailed description of the PRA.

13           Also, this PRA started, we didn't start  
14 it from zero because the design already existed in  
15 Europe. But, basically, U.S. EPR started in 2005  
16 when their ASME standards in Reg Guide 1.200 were  
17 issued. So, we basically had a chance to start this  
18 PRA by knowing the PRA standards and taking them in  
19 account while we were developing the PRA.

20           And the third thing is not really  
21 specific, but it is specific for every Design  
22 Certification PRA. That is that you have to use  
23 bounding/realistic-type assumption when detailed  
24 design information was not available.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MEMBER APOSTOLAKIS: Now these PRAs for  
2 Design Certification are not peer-reviewed, right?

3 MS. DIMITRIJEVIC: No, they are no.

4 MEMBER APOSTOLAKIS: Just internally?

5 MS. DIMITRIJEVIC: Well, we did review,  
6 which you will see on the next one, actually. No,  
7 first is the scope, but we actually did go through  
8 peer review, and I will show you that.

9 MEMBER APOSTOLAKIS: Really?

10 MS. DIMITRIJEVIC: Yes.

11 MEMBER APOSTOLAKIS: With outside peers?  
12 Outside your organization?

13 MS. DIMITRIJEVIC: Yes, absolutely.

14 MEMBER APOSTOLAKIS: Oh.

15 MS. DIMITRIJEVIC: This is why it is very  
16 exciting and, you know, satisfying to be part of it.

17 MEMBER STETKAR: Somebody is rubbing  
18 paper.

19 CHAIR POWERS: Don't rub paper.

20 MR. REINERT: It was me. Sorry.

21 MS. DIMITRIJEVIC: Wow, that is very  
22 loud.

23 So, this is just showing scope, the core  
24 damage, large release frequency. Level 3 wasn't part

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 of Design Certification, but it was performed in  
2 order to support an Environmental Report and SAMDA.

3 Scope of initiating events includes  
4 internal events, at-power and at low-power/shutdown;  
5 internal hazards or internal area hazards. They  
6 changed the name of this. Those are flood and fire  
7 events, and external events are just covered in the  
8 high-level, qualitative evaluation, and the PRA-based  
9 seismic margin assessment was performed.

10 CHAIR POWERS: What does it mean to say  
11 that you have a limited scope for shutdown, which is  
12 how I interpreted that language?

13 MS. DIMITRIJEVIC: You can interpret this  
14 that they are not specifically analyzed, but they  
15 compare it to the risk at power.

16 CHAIR POWERS: So, do we do fires at  
17 shutdown?

18 MS. DIMITRIJEVIC: We didn't do  
19 specifically fires at shutdown, but we have --

20 CHAIR POWERS: But showers are most  
21 common in shutdown. Fire frequency is much higher  
22 during shutdown operations than any other time during  
23 the plant's operational history.

24 MS. DIMITRIJEVIC: That is very true, but

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the risks are different, too. Most of those fires  
2 occur while the men are present. And there is a  
3 different -- we have actually elevated, we have  
4 actually an RAI, also, in this which I can check for  
5 you.

6 We have elevated fire risk in shutdown  
7 versus the fire risk at power, and conclude the fire  
8 risk at power is bounding, and it was analyzed for  
9 all year.

10 MEMBER STETKAR: You can't make the  
11 argument that it has been analyzed for the whole year  
12 in terms of a denominator and a frequency when the  
13 functional impacts from the fires during shutdown are  
14 vastly different than the functional impacts from the  
15 fires during power.

16 MS. DIMITRIJEVIC: That is true.

17 MEMBER STETKAR: So, a fire that burns up  
18 a diesel during power operation has a much different  
19 impact and risk compared to a fire that burns up a  
20 diesel during shutdown.

21 MS. DIMITRIJEVIC: That's true.

22 MEMBER STETKAR: So, just by saying that,  
23 well, we used 365 days in our denominator is not --

24 MS. DIMITRIJEVIC: We used exactly 365

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 days for all at power, actually, because we didn't  
2 really differentiate between -- we don't have the  
3 shutdown schedules firm.

4 What we said, we have concluded that  
5 analyzing specifically fire in shutdown would not  
6 make a difference in conclusions to meet safety  
7 goals. That is a very high-level conclusion.

8 Analyzing fire in shutdown, it is a very  
9 new area. I mean I have to say that, no, actually, I  
10 am not aware of anybody who actually performed fire  
11 analysis --

12 CHAIR POWERS: Do you know that a  
13 detailed analysis of shutdown risk would not change  
14 your Risk Achievement Worth and risk reduction worth  
15 of systems, components, and structures?

16 MS. DIMITRIJEVIC: No, I don't, but I  
17 know that I have a Design Certification PRA, and it  
18 is not the same as the PRA which is going to be  
19 available as to be the operated plant. So, I know it  
20 is not going to change the ranking on the Design  
21 Certification PRA, which is based on Certified  
22 Design.

23 By the time this plant is ready for  
24 operation, there is going to be multiple additions.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 There will be procedures returned. There will be  
2 cables set down. There will be pipe routed through.

3 And this PRA is going to have a different importance  
4 measures than this one, too. I assumed everybody is  
5 aware of that. We are just talking about Design  
6 Certification application today.

7 So, in order to assure the technical  
8 adequacy of this PRA, we have performed self-  
9 assessment on the ASME standards. We have also  
10 performed formal peer review. It was done by the  
11 members outside of AREVA from ABC.

12 MEMBER APOSTOLAKIS: S, ABS.

13 MS. DIMITRIJEVIC: ABS. That was  
14 performed in 2008. It was just a classical peer  
15 review. And if you are interested in the results,  
16 then --

17 MEMBER APOSTOLAKIS: Not the NEI peer  
18 review or the process.

19 MS. DIMITRIJEVIC: Yes.

20 MEMBER APOSTOLAKIS: The NEI process?

21 MS. DIMITRIJEVIC: Yes, yes.

22 The thing is it was a lot, not a lot, but  
23 a little more than 10 percent of those requirements  
24 cannot be met in Design Certification, and there is a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 special category which was assigned for that, not  
2 met, as not achievable.

3 MEMBER STETKAR: I'll let you finish.

4 One thing that is going to help me over  
5 the next day is that there's a table in the FSAR --  
6 it is table 19.1-1 -- that characterizes the EPR PRA  
7 relative to the ASME PRA standards. I noticed that  
8 that table claims that this PRA meets Category III  
9 standards, III -- you will look surprised; let me  
10 finish this -- for initiating events, accident  
11 sequence analyses, and success criteria, and it meets  
12 Category II standards for everything else except  
13 human reliability. Human reliability is left a  
14 little bit vague.

15 That is a very, very high bar, given the  
16 fact that most PRAs in the world today cannot claim  
17 that they meet Category III criteria. Do you  
18 actually endorse this table and claim that the PRA  
19 meets Category III criteria in those three areas and  
20 Category II criteria in the remaining areas?

21 MS. DIMITRIJEVIC: This peer review was  
22 performed after the FSAR was --

23 MEMBER STETKAR: Well, I noticed in the  
24 peer review, the peer review, at least the summary --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 I haven't seen the peer review, but there's a summary  
2 of the results in the SER. That summary of results  
3 seems to say that the peer review and these findings  
4 that you mentioned was performed to determine whether  
5 or not the PRA met Capability Category I.

6 Now those are very, very different, and I  
7 need to understand whether the peer review looked at  
8 Capability Category I, and you're claiming that this  
9 is a Capability Category III PRA. I really need to  
10 understand that.

11 MS. DIMITRIJEVIC: Okay. That is fine.  
12 You know that, actually, the Design Certification PRA  
13 is expected to meet the Category I. That is a  
14 requirement which exists somewhere. But I cannot  
15 really, if I think -- where is Hanh? Maybe he can  
16 help me with that.

17 The thing is this table was met -- as I  
18 said, we performed this PRA -- yes, Don, you can  
19 help?

20 MR. DUBE: Don Dube, NRC staff.

21 The staff put out, I think it is now two  
22 years, an Interim Staff Guidance on Design  
23 Certification and COL applications and what the  
24 expectation is for that phase of the PRA. We said,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 generally speaking, typically, Category I would be  
2 sufficient at that stage.

3 MS. DIMITRIJEVIC: Thank you.

4 MEMBER STETKAR: I understand that, and I  
5 will still ask. There is a real reason why I'm  
6 asking this question, technical and certification,  
7 and I will get to it.

8 I need to know whether the peer review  
9 that was performed reviewed the PRA relative to  
10 Capability Category I requirements or Capability  
11 Category III.

12 So, for example, there are some examples  
13 where the peer review identified deficiencies in the  
14 PRA. I need to understand is that a deficiency  
15 relative to Category I or Category II or III.

16 MS. DIMITRIJEVIC: Well, John, the peer  
17 review classified, however you did that, that  
18 category. Most of the categories, and we can --  
19 first, let me just deal with your first question.

20 Table 9.1-1 was done before the peer  
21 review because we had a chance to do this PRA  
22 following the standards. That is our expectations  
23 based on what information which we had, which  
24 Category III can strive to meet. We have not really

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 met all of these categories.

2           Actually, we met about 70 percent of the  
3 supporting requirements. Around 10 percent of those  
4 were not applicable, a little less than 10 percent,  
5 because this is now two units. About a little more  
6 than 10 percent, we couldn't meet in the Design  
7 Certification, and around 10 percent we didn't meet  
8 on the technical merits.

9           MEMBER STETKAR: So, for example, if I  
10 understand you -- I just want to understand this --  
11 are you saying that the peer review essentially  
12 confirmed that, with the caveats that you put in  
13 there, that you meet Capability Category III in the  
14 area of initiating events analysis?

15           MS. DIMITRIJEVIC: Well, internal  
16 initiating events have multiple, I mean supporting  
17 requirements, many of them. I can tell you, if I  
18 look in the summary of the results, I can tell you  
19 what of them meet Category III, which ones meet  
20 Category II, which meet Category I.

21           MEMBER STETKAR: Okay.

22           MS. DIMITRIJEVIC: And I know how many we  
23 didn't meet. So, some percentage of those numbers,  
24 some percentage is met in different categories.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           MEMBER STETKAR: My concern, and this is  
2 really a question more for the staff, is that the  
3 staff's SER has concurred that, indeed, the PRA meets  
4 these capability categories; that, indeed, the  
5 summary of the adequacy of the PRA, as it is listed  
6 in this table, has been accepted by the staff.

7           Now that has implications for the  
8 potential further use of the PRA. Because if the  
9 staff, during the Design Certification, says that,  
10 indeed, we accept the fact that this PRA meets  
11 Capability Category III, I am a little bit concerned  
12 that people using the PRA will, then, come back and  
13 say, "Aha, the staff issued an SER that, indeed,  
14 accepted the fact that this PRA at this stage meets  
15 Capability Category III."

16           MEMBER APOSTOLAKIS: But this PRA, John,  
17 though, is for Design Certification, and a lot of  
18 actual information from the plant is missing.

19           MEMBER STETKAR: It is.

20           MEMBER APOSTOLAKIS: That cannot really  
21 be used for anything very practical, other than the  
22 certification. Isn't that true?

23           MS. DIMITRIJEVIC: Right. That's very  
24 true.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: But, for example, if it  
2 meets Capability Category III in the area of  
3 selection of initiating events, that means that a  
4 potential --

5 MEMBER APOSTOLAKIS: Eventual for the  
6 complete plant.

7 MEMBER STETKAR: For the complete plant.  
8 Fine, you don't know how you do your testing and  
9 maintenance and things like that.

10 It is a very high bar, and I am concerned  
11 about --

12 MEMBER APOSTOLAKIS: It is a high bar.  
13 No question.

14 MS. DIMITRIJEVIC: I don't believe that  
15 everybody will ever say that this PRA meets Category  
16 III, and I don't believe --

17 MEMBER STETKAR: Well, this table says it  
18 does.

19 MS. DIMITRIJEVIC: No, no, this table  
20 says it tries to meet. You have to -- very  
21 specifically, we can meet and, basically, in the  
22 initial event, we meet 70 percent of the SERs which  
23 are spread through all three categories. Nobody ever  
24 talks about some of the --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MEMBER STETKAR: Vesna, let me, for the  
2 record, let me just get something on here.

3 MS. DIMITRIJEVIC: Sure.

4 MEMBER STETKAR: The table says,  
5 "Characterization of U.S. EPR PRA Relative to  
6 Supporting Requirements in ASME PRA Standard". That  
7 is the title of it.

8 If I look at the technical area,  
9 "Initiating Events Analysis", it says,  
10 "Comprehensive, systematic search made for initiating  
11 events. Most aspects of the IE analysis satisfy  
12 Capability Category III. Elements of the PRA that  
13 cannot generally meet at least Capability Category II  
14 until later stages of design, construction, and  
15 operation include the following: plant-specific  
16 operating experience is not available for review.  
17 Operators are not yet available to be interviewed.  
18 Initiating event frequencies reflect generic data.  
19 The ability to capture plant-specific information in  
20 the assessment of recovery actions is limited."

21 I am led to believe that it is not  
22 attempting to meet Category III, but that it does  
23 meet Category III except for those four bullets. Is  
24 that a correct interpretation of this table?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MS. DIMITRIJEVIC: Yes.

2 MEMBER STETKAR: Okay.

3 MS. DIMITRIJEVIC: It was intended to  
4 mean, because we performed the PRA, why would we  
5 strive for anything less than III when we can reach  
6 it?

7 MEMBER STETKAR: Okay. Thanks.

8 MS. DIMITRIJEVIC: That's it. It doesn't  
9 mean it meets Category III.

10 MEMBER STETKAR: No, this says, no, this  
11 does, to any reasonable person, say that it meets  
12 Category III. You are representing this PRA as  
13 meeting Category III except for those four bullets.

14 MS. DIMITRIJEVIC: John, this table was  
15 done before peer review as self-assessment of that.

16 MEMBER APOSTOLAKIS: So, it should be  
17 revised then, soften the language?

18 MS. DIMITRIJEVIC: Well, how I read it  
19 and how he reads it is different. In my opinion,  
20 what was attempted to say, since we have a standard  
21 when we try PRA, we will try to do our best, which we  
22 know the standard. We are not going to try to do a  
23 less-perfect job because we don't have to. We are  
24 going to try to do the best job that we can, and,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 hopefully, we will meet. However, we do meet in 70  
2 percent of things happening in --

3 MEMBER STETKAR: This, again, just to get  
4 it on the record, and this will come back to the  
5 staff, let me read you a quote from the SER.

6 "The staff reviewed FSAR Tier 2 table  
7 19.1-1, Characterization of U.S. EPR Design-Specific  
8 PRA Relative to Supporting Requirements in ASME PRA  
9 Standard and finds that the applicant properly  
10 characterized its findings relative to the capability  
11 categories addressed in the ASME PRA standard, and  
12 reasonably described the quality state of the U.S.  
13 EPR Design-Specific PRA."

14 That sounds like a finding. Indeed, the  
15 staff concurs that the PRA meets these capability  
16 categories.

17 Now, if AREVA's intent is to not say that  
18 it meets these capability categories, but that you  
19 would like to meet these capability categories --

20 MS. DIMITRIJEVIC: No, because --

21 MEMBER STETKAR: -- that's okay.

22 MS. DIMITRIJEVIC: No. I would like to  
23 just put this. Since we have performed peer review  
24 and since we met with such there, we can add the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 actual peer review results to that. In 70 percent of  
2 the initiating events, we meet the Category III  
3 because most of those were I, II, and III.

4 So, therefore, we can add, if this will  
5 make -- if it doesn't make sense, if we are requested  
6 to add the actual results, we can or we can remove  
7 those sentences.

8 MEMBER APOSTOLAKIS: What would be the  
9 implication of --

10 MEMBER STETKAR: I don't know, George.  
11 The thing that I'm worried about is what happens down  
12 the road.

13 MEMBER APOSTOLAKIS: I know.

14 MEMBER STETKAR: Because I don't know -  
15 - you know, what typically happens is the COL  
16 applicant will just take the PRA by reference. Now,  
17 certainly, if any eventual licensee is going to use  
18 the PRA for a particular application, they are going  
19 to need to justify the fact that the PRA is of  
20 adequate quality for that justification.

21 On the other hand, if the interpretation  
22 is that the staff has reviewed the PRA in the design  
23 phase and accepted the fact that it meets Capability  
24 Category III, except for these itemized bullets, that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 level of review of the adequacy of the PRA for a  
2 particular application later on may never be done.

3 MEMBER APOSTOLAKIS: I understand that.

4 MEMBER STETKAR: That is the concern.

5 MEMBER APOSTOLAKIS: But in terms of a  
6 specific item here of initiating events, what -- I  
7 mean let's say somebody builds a plant and they come  
8 back here and they want to use their PRA to request,  
9 to do a risk-informed ISI or something. The fact  
10 that the staff has declared it as meeting Category  
11 III requirements, in practical matters, what does it  
12 mean? That nobody can challenge the initiating  
13 events? Nobody can add to the list of the initiating  
14 events because it is now sacred? What exactly does  
15 that mean?

16 Because if it doesn't mean these things,  
17 then the debate is perhaps one of semantics. But if  
18 it means that nobody should touch that area, then I  
19 think John's concern is very valid.

20 So maybe somebody from the staff can --

21 MEMBER STETKAR: I think we can ask the  
22 staff, when they come up, but I wanted to understand  
23 from AREVA what the implications of this table are.

24 MEMBER APOSTOLAKIS: Well, obviously,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 there is a different view, the way --

2 MS. DIMITRIJEVIC: I mean I assumed  
3 certification just say the PRA -- it doesn't say --  
4 we didn't even have to do this peer review.

5 MEMBER APOSTOLAKIS: Can the staff tell  
6 us what that means? If it is Category III, what does  
7 it mean? Is Dube here? Oh, he's hiding. Very wise.

8 (Laughter.)

9 What would it mean, Don? Would it mean  
10 that you guys cannot touch it again? Or would it  
11 mean that -- I mean, for just a list of events, I  
12 mean I understand Category III means specific  
13 sequences --

14 MEMBER STETKAR: Well, the completeness  
15 and level of detail are basically the elements as you  
16 go from I to III and uncertainties.

17 MR. DUBE: But the PRA is done in phases.  
18 The Design Certification phase meets a lower  
19 standard, using the word "standard" loosely, than the  
20 ultimate, what we are calling, the Fuel Load PRA,  
21 which, by regulation, before the plant initially even  
22 loads fuel, the PRA has to meet the standards that  
23 were in place one year prior to fuel load and that  
24 have been endorsed by the staff.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1           That is going to be a pretty high  
2           standard. It will be Capability Category II for the  
3           most part.

4           MEMBER STETKAR: But, if during the  
5           design stage, Don, if the SER has said, well, we  
6           agree, with the exception, let's say, of these four  
7           bullets here, that deal with more operational-  
8           oriented things, that we agree that the scope of the  
9           initiating events meets Capability Category III, does  
10          that mean that during the COL review of the PRA the  
11          staff would simply say, "Well, okay, we just passed  
12          that through," and only look at how they addressed  
13          these operational-oriented?

14          MR. DUBE: No, because, then, we have to  
15          say, okay, now you have the standard design and you  
16          have a plant-specific design, a site-specific design  
17          that may have a different balance of plan and  
18          ultimate heat sink and offsite power configuration,  
19          it may have different external events, and you have  
20          to look at how is this site-specific design  
21          different.

22          Now, for many of these internal events,  
23          initiators, balance-of-plan initiators probably for  
24          the most part are going to be the same. So we will

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 have a high degree of confidence.

2 MEMBER APOSTOLAKIS: He is saying it  
3 doesn't matter. That is what he is saying.

4 MEMBER STETKAR: No, I heard something  
5 different, George. He said things that related to  
6 site-specific stuff.

7 Well, I'll give you a good example, and  
8 we will eventually get to initiating events. This  
9 PRA does not quantify loss of DC power as an  
10 initiating event, period. That is not a site-  
11 specific issue. It is not an operational procedure  
12 issue. It is not an operator experience issue.

13 MEMBER APOSTOLAKIS: But he said that the  
14 PRA during COLA has to meet the staff's requirements  
15 one year before, and I'm sure they will raise the  
16 issue there.

17 MR. DUBE: The Fuel Load PRA, right, not  
18 just the COL.

19 MEMBER APOSTOLAKIS: The fuel load.

20 MEMBER STETKAR: But what I am asking is,  
21 if the staff says, well, it's okay, that it meets  
22 Capability Category III for initiating events at this  
23 stage, and that it doesn't include loss of DC, does  
24 the staff, when they come to the Fuel Load PRA only,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 then, focus on site-specific and more refined  
2 operational things that evolve --

3 MR. DUBE: Our emphasis will be on the  
4 delta.

5 MR. PHAN: Hello.

6 MR. DUBE: But I'm not familiar with why  
7 loss of DC is not included. I imagine it is not  
8 going to lead to reactor trip. So, it doesn't pass  
9 the screening.

10 MEMBER STETKAR: Yes, we will get to it  
11 when we talk about initiating events. I am just  
12 trying to, before I waste everybody's time for the  
13 next day and a half, I really want to understand.

14 MR. PHAN: Hello again.

15 My name is Hahn Phan, and I am the Lead  
16 Reviewer for Chapter 19.

17 The staff never characterized the EPR PRA  
18 as Capability III. The staff only looked at the PRA  
19 at the level of the Capability I.

20 In our presentation later, the staff will  
21 tell you that the U.S. EPR PRA is not currently used  
22 for any formal risk-informed application.

23 Secondly, in our conclusion, the staff  
24 says that, due to the open items and the appearance

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 of the confirmatory items, the staff is currently  
2 unable to come to an overall conclusion on the  
3 Section 19.1, including that PRA quality.

4 MEMBER STETKAR: Ah, okay.

5 MEMBER APOSTOLAKIS: That takes care of  
6 it.

7 MEMBER STETKAR: That takes care of it.  
8 Thank you.

9 (Laughter.)

10 MS. DIMITRIJEVIC: Okay. So, in addition  
11 to this, I mean there is the normal documentation.  
12 There will be a requirement that all documents and  
13 revisions are controlled by procedures requiring  
14 independent review and checking.

15 AREVA has a corrective action process in  
16 place if previously used information is changed or is  
17 in error.

18 And the EPR also has the advantage that  
19 the PRA team participates in technical meeting and  
20 exchange with all European counterparts working with  
21 a similar design. That was an interesting experience  
22 because we compared our insights and results with  
23 similar teams working on the similar design for  
24 Finland, the UK, and China.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1                   MEMBER APOSTOLAKIS:    So, there is a PRA  
2                   for the old kilowatt plant?

3                   MS. DIMITRIJEVIC:    Yes.

4                   I just want to refresh your memory about  
5                   these design features which contribute to low risk.  
6                   The PRA has four independent safety trains in  
7                   separate buildings.    These buildings provide the  
8                   physical separation against internal and external  
9                   hazards, which makes it a little easier to perform  
10                  the special analysis because we can actually limit  
11                  damage, the advanced safeguard building.

12                  Some of those buildings, including the  
13                  reactor building, are protected against airplane  
14                  crash, the reactor building and two safeguard  
15                  buildings and the fuel building.

16                  CHAIR POWERS:    Why does extended airplane  
17                  crash protection help in this particular PRA?

18                  MS. DIMITRIJEVIC:    In this particular  
19                  PRA, it didn't, but in some of the COLA aspects of  
20                  the PRA, it did.    So, this PRA was extended to the  
21                  external ones, including airplane crash for the COLA  
22                  applicants, and that is where this protection was  
23                  factored.

24                  This design also has an in-containment

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 refueling water storage tank, which is also an  
2 advantage from the PRA perspective because there is  
3 no need to fast switch over any circulation.

4 This plant has four emergency diesel  
5 generators, one for each safety division.

6 CHAIR POWERS: Come back to the in-  
7 containment refueling water storage tank. Explain to  
8 me again why that is helpful.

9 MS. DIMITRIJEVIC: That is helpful  
10 because one of the most dominant errors in the  
11 coolant PRA in the plan is the error to switch to  
12 recirc in the case of the LOCA, especially not a  
13 large LOCA only, but medium LOCAs. Where the  
14 operators on the lower level have to switch to  
15 recirc, in this case you don't have to do that  
16 because your IRWST is your sump. So, there is no  
17 need to switch sump recirc when the IRWST level is  
18 low.

19 So, in addition to the four emergency  
20 diesel generators, we have two-station blackout  
21 diesel generators which support Division 1 and 4.  
22 So, basically, this plan has six diesel generators.

23 Two of the station blackout diesel  
24 generators, one of the PRA insights was also that it

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 is very important that they are independent, so they  
2 didn't belong to the same common-cause group. Their  
3 independence and diversity was achieved by they were  
4 different/diverse models, different control power,  
5 different HVAC, different engine cooling, different  
6 fuel supply, and the different location.

7 This is billed as a generator system. In  
8 addition, they also can feed, actually, two low-head  
9 safety injection pumps. So you can basically  
10 mitigate LOCA in station blackout conditions.

11 Another design feature is this reactor  
12 coolant pump stand-still seal system, which minimizes  
13 the probability of the reactor coolant pump seal  
14 LOCAs, which is a pneumatic, metal-to-metal seal that  
15 provides back-up seal capability independent of  
16 normal seals and minimizes RCP shaft leakage.

17 MEMBER STETKAR: Vesna?

18 MS. DIMITRIJEVIC: Yes?

19 MEMBER STETKAR: I haven't seen details  
20 of that design. I have only read about it in the  
21 Chapter 19 report. It sounds a little bit different  
22 from seal designs that I am familiar with, even for  
23 European plants. I am not familiar with reactor  
24 coolant pumps in the French plants.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           Has this particular design been used in  
2           any operating plants to date?

3           MS. DIMITRIJEVIC: That I cannot really  
4           respond. This is based, the EPR original, from the  
5           N4 design, the German plans. But, to be honest with  
6           you, I don't really know. There is no data available  
7           on this system that I know.

8           MEMBER STETKAR: Okay.

9           MS. SLOAN: Tim, did you want to add  
10          something?

11          MR. STACK: Well, introduction for  
12          myself: my name is Tim Stack from AREVA.  
13          Background: I previously spoke to you on Chapter 10.

14          Educationally, I have a bachelor's  
15          degree, a master's degree from Penn State in  
16          mechanical engineering.

17          I started work for Babcock and Wilcox in  
18          the early eighties. My experience covers NSSS  
19          design, front-line safety system design, VOP. I have  
20          worked on power uprates, steam generator  
21          replacements, and plant programs that have covered  
22          largely most areas of the plant from the system  
23          design to the programmatic aspect. And I have worked  
24          on the EPR since 2003. I am really responsible for

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 the technology and the design.

2 Coming back to your question at hand, the  
3 general answer, to give you the best place for it, is  
4 we will be covering that in our Chapter 5 ACRS  
5 meeting. I don't have the answer right off the top  
6 of my head to tell you where exactly we have used it.

7 We will cover that in our ACRS for Chapter 5, which  
8 is coming in early March, I believe.

9 MS. SLOAN: March 3rd.

10 MR. STACK: March 3rd?

11 MS. SLOAN: March 3rd.

12 MR. STACK: And we will provide you the  
13 answer to that question on March 3rd.

14 MEMBER STETKAR: Okay. Thanks.

15 MR. STACK: Okay?

16 MEMBER STETKAR: Put it on your list.

17 Let me ask you at least this then:  
18 functionally, since it is called a stand-still seal  
19 system, as I said, I am not familiar with this  
20 particular design, but, honestly, I haven't read the  
21 Chapter 5 stuff yet.

22 In other pump designs that employ a  
23 mechanical face-rubbing seal to stop leakage, I am  
24 aware of test data that show that the pump must,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 indeed, be stationary for that seal to seal; that  
2 that seal provides essentially no protection if the  
3 pump is still operating and you lose all seal  
4 coolant.

5 Is that also true for this seal design?  
6 In other words, the pump must be actively tripped?

7 MS. DIMITRIJEVIC: I can tell you what  
8 are the PRA assumptions. The system questions you  
9 will have to ask with the Chapter 5.

10 But we assumed the pump has to trip, you  
11 know, to that system to engage.

12 MEMBER STETKAR: But the pumps themselves  
13 must trip?

14 MS. DIMITRIJEVIC: Yes.

15 MR. STACK: The pumps must be,  
16 essentially, stationary.

17 MEMBER STETKAR: So, the PRA includes the  
18 requirement to trip --

19 MS. DIMITRIJEVIC: Yes.

20 MEMBER STETKAR: -- the reactor coolant  
21 pump?

22 MS. DIMITRIJEVIC: Yes. That is,  
23 actually, a trip from the pump is explicitly modeled.

24 MEMBER STETKAR: Circuit breakers for the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 pumps?

2 MS. DIMITRIJEVIC: Yes, yes.

3 MEMBER STETKAR: Okay. You will find me  
4 asking questions about the models because we don't  
5 have pictures of the models.

6 MS. DIMITRIJEVIC: This is, actually, the  
7 seal that came with these systems are an important  
8 concept, if anything is important --

9 MEMBER STETKAR: I noticed it modeled a  
10 lot for losses of offsite power --

11 MS. DIMITRIJEVIC: Yes, yes.

12 MEMBER STETKAR: -- which are easy for me  
13 to think about because I know the pumps aren't going  
14 to be running there.

15 MS. DIMITRIJEVIC: That's true.

16 MEMBER STETKAR: I am more concerned  
17 about losses --

18 MS. DIMITRIJEVIC: They model, also, for  
19 the loss of component cooling water as another  
20 initiator. And this is modeling a lot of the ties,  
21 every single trip valve which have to open. It is  
22 modeling a lot, the automatic plant trip, the manual  
23 plant trip.

24 MEMBER STETKAR: And these things do

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1       require -- I mean it is not only a mechanical, but it  
2       is a pneumatic backup --

3               MS. DIMITRIJEVIC:  Yes, yes.

4               MEMBER STETKAR:  -- as I understand it.  
5       So, you do need to have active nitrogen valves --

6               MS. DIMITRIJEVIC:  Valves, yes.

7               MEMBER STETKAR:  -- to open to force  
8       something to go there?

9               MS. DIMITRIJEVIC:  Yes.

10              MEMBER STETKAR:  Oh, okay.

11              MS. DIMITRIJEVIC:  That is what we have  
12       been engaging, and one of our RAIs was what did we  
13       assume on the fail operabilities.  We actually proved  
14       the assumption of fail operability of this system is  
15       not so important because all of these other things  
16       have to happen.  Those valves have to close up and  
17       pumps trip, and things like that.

18              Data which we used is the mix of the  
19       American and European data.  We have used some EG&G  
20       data.  We used, for the component failure rates, we  
21       used ZEDB, which is Centralized Reliability and  
22       Events Database, mostly based on the German nuclear  
23       plant experience with one Dutch and one Swiss unit.  
24       And we used the European Industry Reliability Data

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Bank. That is just for the component failure rates.

2 For initiating event and component  
3 common-cause parameters, initiating event  
4 frequencies, LOOP frequencies and recovery, we use  
5 the NUREGs which are --

6 CHAIR POWERS: When you say, "We used  
7 these data", presumably, none of the components in  
8 any of these plans that make up the database are, in  
9 fact, the components you will use. So, do you adjust  
10 the reliabilities in any way or do you just accept  
11 these relatively geriatric components?

12 MS. DIMITRIJEVIC: We have done a  
13 comparison, you know, with the EPRI Advanced Light  
14 Water Reactor component. There is no really  
15 component database for advanced reactors yet. It is  
16 going to take some years of operation, and how we are  
17 going, probably we are not going to have it in  
18 another 50 years.

19 The thing is the one moment that we will  
20 assume -- these components are not procured yet. So,  
21 this data, our philosophy was we are going to use  
22 these data in this phase. Until we have some plant-  
23 specific operational data, there is no need really to  
24 change it, until we really know more.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 I mean, in the worst case, I mean this  
2 will be conservative data. We think that these  
3 components are going to show much better performance  
4 than the current industry.

5 CHAIR POWERS: So, I think what you told  
6 me is that you didn't adjust anything here? You  
7 just, if it said a pump was this reliable, you took  
8 that pump as that reliable?

9 MS. DIMITRIJEVIC: Yes, but how would we  
10 adjust it? Based on what? There is no data on  
11 advanced plants available in industry. So, it will  
12 be very difficult to adjust it. The components are  
13 not bought yet, procured, and there is no  
14 manufacturing data. We have nothing to adjust.

15 We have done intensive comparison on the  
16 data in order to think what should we really use. We  
17 have found relatively good agreement even with this  
18 EPRI Advanced Light Water Reactor.

19 So, I think in this moment this is --

20 MS. SLOAN: Vesna, I guess I would offer  
21 a broader-brush approach, that for the purpose of  
22 what we are trying to demonstrate for Design  
23 Certification, the data is representative. But,  
24 clearly, we don't have procurement data. But,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 remember, we are not applying the PRA at this phase  
2 for Design Certification for risk-informed  
3 applications.

4 So, if you kind of step back and view it  
5 as a demonstration, you get a different perspective.

6 MEMBER STETKAR: I tend to think of this  
7 as the areas where it raises questions are where the  
8 particular component design for EPR is substantially,  
9 or may be substantially, different from equipment  
10 that is in currently-operating plants, including  
11 European plants.

12 Similarly, when I think of pumps and  
13 pipes and valves, motor-driven centrifugal pumps are  
14 probably not going to be that much different. Motor-  
15 operated valves, pneumatic valves, and so forth, you  
16 know, are they going to be better or are they going  
17 to be worse? It is difficult to say.

18 One of the reasons I asked the question  
19 about the reactor coolant pump seals is this seems to  
20 be a seal design for which I am not personally aware  
21 of any operating experience or any actual test  
22 experience. So, in particular, that was one area  
23 that I flagged, whether you want to call it data or  
24 success criteria, whatever, within the PRA context,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 of what available evidence do we have to support the  
2 reliability of those seals? Even if all of the PRA  
3 things function correctly, the valves open and the  
4 nitrogen, or whatever it is, comes in -- so, that is  
5 one area where it is not at all clear that we have  
6 data.

7 The other things, you know, it is  
8 difficult to find things in this plant that are  
9 dramatically different from equipment that are in  
10 currently-operating plants.

11 MS. DIMITRIJEVIC: That is very true. It  
12 is a very active, actually, in LOOP plants.

13 MEMBER STETKAR: That being said, some of  
14 these databases used are pretty old. I mean anything  
15 published before 1990 is using data that was derived  
16 in the early eighties and is probably not all that  
17 relevant to the way that the world really works. So  
18 I would be a bit cautious about relying too much on  
19 data that are characterized before 1990.

20 MS. DIMITRIJEVIC: This ZEDB is pretty  
21 current, but EGG and this European are relatively  
22 older.

23 MEMBER STETKAR: How much did you rely on  
24 the ZEDB?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MS. DIMITRIJEVIC: Oh, I would say  
2 probably more than 50 percent.

3 MEMBER STETKAR: Okay.

4 MS. DIMITRIJEVIC: That is my guess, but  
5 we have, for every component, as much as I saw in  
6 this model.

7 Then, for human reliability analysis, we  
8 used ASEP for the pre-initiator human reliability,  
9 and we used SPAR-H for post-initiator, and we used  
10 HRA Calculator for implementing those two methods.

11 MEMBER STETKAR: I was hoping you  
12 wouldn't list these things. So, since you did, I  
13 have to ask you.

14 Why did you use SPAR-H for the post-  
15 initiator rather than something like the ASEP Time-  
16 Reliability Correlation? There must have been an  
17 active decision to do that.

18 MS. DIMITRIJEVIC: Yes, there was  
19 probably, and it is an active decision. We,  
20 actually, somehow thought that this sort of relative  
21 comparison was well-suited for the Design  
22 Certification phase of the performance-shaping  
23 departures.

24 MEMBER STETKAR: Okay.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MS. DIMITRIJEVIC: That is what we  
2 thought. It was maybe a little more general. It is  
3 a matter of, I mean, also, the HRA Calculator  
4 supported it, which we decided to use as a  
5 documenting and performing --

6 MEMBER STETKAR: That is the EPRI HRA  
7 Calculator?

8 MS. DIMITRIJEVIC: The EPRI HRA  
9 Calculator.

10 Thermal hydraulic does, which we use for  
11 success criteria, include MAAP. We actually used  
12 MAAP4 for most of our success criteria cases, and we  
13 benchmarked for selected cases against S-RELAP5, so  
14 that we can prove applicability of these things,  
15 these calculations.

16 Model quantification, we used Risk  
17 Spectrum code. That code is widely used in Europe.  
18 I think the Palo Verde plant used it in the United  
19 States.

20 We used a cutoff point of 10 to the minus  
21 20 per year and 10 to the minus 6 relative cutoff  
22 points. That allows for reasonable for to ask  
23 questions for the Level 1, and not so reasonable for  
24 to ask questions for the Level 2s.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: Let's don't switch yet.

2 MS. DIMITRIJEVIC: Okay.

3 MEMBER STETKAR: Because I was going to  
4 bring this up later, but I might as well hit it now.

5 MS. DIMITRIJEVIC: Sure.

6 MEMBER STETKAR: You say that you use 10  
7 to the minus 20 per year absolute --

8 MS. DIMITRIJEVIC: Yes.

9 MEMBER STETKAR: -- and a 10 to the minus  
10 6 relative cutoff. I haven't used Risk Spectrum in  
11 the last couple of years, and they claim they keep  
12 changing things. But the last times that I have kind  
13 of run into it, Risk Spectrum has an internal  
14 algorithm that resets the cutoff, the truncation  
15 value, automatically based on populating a cutset  
16 database.

17 So, that you could put in 10 to the minus  
18 -- I have seen places where people have put in 10 to  
19 the minus 20th, 10 to the minus 25th, 10 to the minus  
20 30th. It quantifies it 10 to the minus 8 because  
21 that is the only cutoff that it can take to populate  
22 the cutset database.

23 So, my question is, what real -- two  
24 questions, this is a two-part question, since you are

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 going to get into the results soon.

2 One question is, what was the real cutoff  
3 that was finally used in the model? And Risk  
4 Spectrum will tell you what that value was.

5 And as part of that, what was the -- I  
6 think Risk Spectrum calls it the maximum cutoff  
7 error, which is the maximum frequency, an estimate of  
8 the maximum frequency of the truncated cutsets. I  
9 would be really curious to know what those values are  
10 because --

11 MS. DIMITRIJEVIC: If you have the total  
12 CDF results --

13 MEMBER STETKAR: Total CDF isn't what I  
14 am worried about.

15 MS. DIMITRIJEVIC: No, no, no. I know.

16 MEMBER STETKAR: I am worried about what  
17 is the Risk Spectrum output that is --

18 MS. DIMITRIJEVIC: They know what I'm  
19 asking. Do we have the Risk Spectrum input first  
20 page for the total CDF?

21 MR. CORDOLIANI: Hello. My name is  
22 Vincent Cordoliani.

23 A little biography I am going to give.  
24 I graduated from UC Berkeley with a master's in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 nuclear engineering in 2006. Since early 2007, I  
2 have been with AREVA on PRA, and mostly doing, I have  
3 been really involved with the internal hazards, bio  
4 and flood, but also wider areas of quantification.

5 So, to answer your question, actually,  
6 like I have an example here where I have this case  
7 where the final CDF is 1.70 minus 7, and the cutoff  
8 used, the final cutoff that Risk Spectrum used for  
9 demographization of the cutsets was 1.70 minus 13.  
10 So, really, the CDF times the relative cutoff.

11 MS. DIMITRIJEVIC: Relative cutoff.

12 MR. CORDOLIANI: So, really it would  
13 detect a firm generated cutset based on the absolute  
14 curve, but as soon as like the total CDF increases,  
15 then the cutset it will use is the cutset that is  
16 determined by the relative cutoff.

17 By using an absolute cutoff very low,  
18 like 1 to the minus 20, we make sure that whatever  
19 the total rate is going to be, we are going to have a  
20 definition good enough. At the end of the day, what  
21 it generally uses is the CDF times the relative  
22 cutoff.

23 MEMBER STETKAR: As I said, this is for  
24 my own -- it will help in later questions.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           The current version of Risk Spectrum  
2 holds to that relative cutoff? In other words, I  
3 have seen an earlier version where it also adjusts  
4 the relative cutoff. So, that, for example, you  
5 could put 10 to the minus 20 and 10 to the minus 6,  
6 and it would just readjust to populate a maximum  
7 number of cutsets that it can handle in its database.

8           So, that, for example, your 10 to the  
9 minus 7 and 10 to the minus 13 example, the actual  
10 cutoff value that it applies could be 10 to the minus  
11 -- pick a number -- 11, let's say, because it doesn't  
12 really hold to that 10 to the minus 6 either.

13           MS. DIMITRIJEVIC: We did not experience  
14 that.

15           MEMBER STETKAR: You didn't?

16           MS. DIMITRIJEVIC: We didn't. We did  
17 not.

18           MEMBER STETKAR: I mean it depends very  
19 much on your model, on the size of the model, and a  
20 lot of things.

21           MS. DIMITRIJEVIC: But I want to check  
22 with Vincent. I don't think the limit of the cutset  
23 which Risk Spectrum can handle -- and I know that we  
24 had a slide of that. Actually, whatever that limit

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 was, it was not --

2 MEMBER STETKAR: You didn't run into  
3 that?

4 MS. DIMITRIJEVIC: No.

5 MR. CORDOLIANI: No.

6 MEMBER STETKAR: Okay. Good. Good.  
7 Thanks. I mean that helps.

8 It is certainly possible. It depends on  
9 the size of the model and a lot of very subtle  
10 things.

11 MS. DIMITRIJEVIC: We have an RAI from  
12 NRC based on this, especially concerned about this  
13 relative cutoff, which is similar to what you say  
14 because it was --

15 MEMBER STETKAR: But I read the response  
16 to that RAI.

17 MS. DIMITRIJEVIC: Yes.

18 MEMBER STETKAR: And it said, well, we  
19 changed things and the results didn't change. But I  
20 have seen that an awful lot in earlier, at least  
21 earlier versions or other models, where, well, yes,  
22 the results don't change because you could put in 10  
23 to the minus 100 for each of those, and if the  
24 software is resetting the cutoff by itself, the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 results won't change because you are still working  
2 with the same population of retained cutsets.

3 MS. DIMITRIJEVIC: Well, the thing is,  
4 which I just found, the thing which we got from the  
5 Risk Spectrum capabilities says that there is no  
6 absolute limit on the cutset gates and the basic  
7 amounts it can handle. So, that could be --

8 MEMBER STETKAR: There's no limit on what  
9 you put in, but there is a limit on how much it will  
10 retain.

11 MS. DIMITRIJEVIC: Of the --

12 MEMBER STETKAR: On the saved number of  
13 cutsets.

14 MS. DIMITRIJEVIC: We didn't experience  
15 that. However, we did really experience what you  
16 just said; when we looked at the cutoff at all of  
17 them, we did not really like what we saw.

18 So, since it will take forever to run  
19 such -- this is a very complex model, as you can  
20 imagine, with a thousand fault trees and gates. The  
21 thing is what we did, we chose one event. For  
22 example, loss of offsite power, which was one of the  
23 main, and then for this specific event, we changed  
24 the absolute cutoff and relative cutoff to see how

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 much the result would change. And while the cutoff  
2 error dramatically went down, it didn't result in a  
3 change at all. So it is sort of an artificial value  
4 which wasn't telling us too much.

5 MEMBER STETKAR: That's true. Anybody  
6 who has run those calculations knows that --

7 MS. DIMITRIJEVIC: Right.

8 MEMBER STETKAR: -- whatever that number  
9 is isn't necessarily real.

10 MS. DIMITRIJEVIC: Right.

11 MEMBER STETKAR: But it is a confidence-  
12 builder anyway.

13 MS. DIMITRIJEVIC: Yes. Yes. That's  
14 right.

15 MEMBER STETKAR: Okay. Continue. Go  
16 ahead.

17 MS. DIMITRIJEVIC: We played with this.  
18 We played with this, and we were going to even  
19 publish an article about this stabilization based on  
20 those two. But, unfortunately, we are always working  
21 and with really busy schedules, so really didn't have  
22 the time to.

23 All right. So, this is initiating events  
24 which we choose for the analysis. There is no

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 surprise on them. However, I will take this  
2 opportunity to discuss why we didn't have a loss of  
3 the DC bus.

4 We do have a loss of the one division, as  
5 you can in transients. We have general transient,  
6 loss of condenser, loss of main feedwater, loss of  
7 balance of plan, and the loss of one division, 31BDA.

8 That is the bus which supplied the Division 1.

9 This is also not an initiating event.  
10 Neither the loss of one division or the loss of the  
11 DC bus will trip this plant.

12 We only analyzed this for the  
13 illustration purposes, actually, because there are  
14 some things which have to occur. For example, when  
15 this is operating, the division of component cooling  
16 water, it has to switch to the other standby division  
17 automatically. But, actually, definitely, we  
18 analyzed that as a sort of plant perturbation.

19 But, as the initiating event, also, one  
20 division, either AC or DC, would not trip this plant.

21 And when it comes to the DC, loss of one division of  
22 DC, we couldn't even think of a perturbation in the  
23 plant operation. So, that is why it was on the  
24 part -- we couldn't really think of anything which

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 will actually require some ultimate deduction.

2 MEMBER STETKAR: Let me ask you, is this  
3 our only chance to ask about initiating events?

4 MS. DIMITRIJEVIC: That's the best  
5 chance.

6 MEMBER STETKAR: Oh, okidoke.

7 (Laughter.)

8 It is very likely true that loss of a  
9 single DC division will not cause a trip on this  
10 plant, at least safety-related DC division. I am not  
11 at all clear about non-safety DC divisions or how  
12 important they may be.

13 Will loss of two DC divisions cause a  
14 plant trip?

15 MS. DIMITRIJEVIC: To be honest with you,  
16 I don't think so. I cannot think what would cause  
17 the plant on the loss of the two DC divisions, other  
18 than something through I&C.

19 MEMBER STETKAR: Well, that is the way it  
20 would come in.

21 MS. DIMITRIJEVIC: Yes.

22 MEMBER STETKAR: Nod your head, yes, it  
23 probably will.

24 What about a situation where you have one

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 DC bus out for maintenance and you have a fault on  
2 another DC bus, or some person makes a maintenance  
3 error and trips two DC buses during some sort of  
4 testing or maintenance? Is the frequency of that  
5 zero?

6 MS. DIMITRIJEVIC: I mean, well, we can  
7 always build a scenario where -- I mean frequency,  
8 what is zero?

9 MEMBER STETKAR: Do you have a concept of  
10 what the conditional risk -- and I'm talking about  
11 Level 2 risk now -- would be from loss of two DC  
12 divisions?

13 MS. DIMITRIJEVIC: Well, how would they  
14 lose the two DC divisions?

15 MEMBER STETKAR: I already gave you. One  
16 DC bus out for maintenance --

17 MS. DIMITRIJEVIC: No, we didn't really  
18 model the maintenance on the DC buses.

19 MEMBER STETKAR: Oh, okay.

20 MS. DIMITRIJEVIC: So the battery needs  
21 to be modeled, but --

22 MEMBER STETKAR: Well, that is just the  
23 battery, DC bus.

24 MS. DIMITRIJEVIC: I know.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: It is allowed to be out  
2 for maintenance for some period of time.

3 MS. DIMITRIJEVIC: Well, we didn't really  
4 think that planning maintenance on the DC buses  
5 that --

6 MEMBER STETKAR: You didn't think? I'm  
7 trying to ask how -- the completeness of the list of  
8 initiating events. Because, for example, I am aware  
9 of PRAs of other similar four train designs in Europe  
10 that have identified losses of two DC buses as  
11 measurable. I don't want to say dominant because  
12 nothing is dominant, but measurable contributors, not  
13 so much to Level 1 core damage frequency, but to  
14 Level 2 risk because of implications on containment,  
15 isolation, and signals to initiate some of the  
16 containment cooling systems.

17 MS. DIMITRIJEVIC: Well, we have a review  
18 of this European experience for the initiators which  
19 we did not account for, and I don't really remember  
20 that we saw this case. We saw very interesting cases  
21 on the batteries, but not on the DC buses.

22 MEMBER STETKAR: Let me leave that one.

23 MR. STACK: Excuse me. Before we go on,  
24 could I have Jim Reddy, who is really covering the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1       electrical side, really speak to the batteries and --

2               MEMBER STETKAR:       That would be good  
3       because I have more questions on electrical stuff.  
4       So, if you have somebody who is better on electrical  
5       things, it would be great.

6               MR. REDDY:   Again, my name is Jim Reddy.

7               With the DC buses, a couple of things  
8       with that. First, keep in mind that the DC bus being  
9       out of service, that puts you into the two-hour  
10      required action statement. So, I would not foresee  
11      an intentional taking a bus out of service for  
12      maintenance.

13              One of the other aspects would be DC  
14      systems specific to the I&C is that there are two  
15      parallel 24-volt supplies to it. So, if you were to  
16      lose just the DC bus itself, the inverter is going to  
17      swap over with the static bypass switch and continue  
18      to provide power to the 480-volt MCC, which goes to a  
19      converter, which maintains a 24-volt power that is  
20      auctioneered at the high I&C input. So, that is  
21      where, unless you lose both of those sources, you are  
22      going to maintain power to your I&C system.

23              MEMBER STETKAR:   Again, the problem with  
24      reviewing the PRA at this stage of the DCD process is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that some of us sitting on this side of the table  
2 have not seen the complete plant design. It is  
3 usually easier to review the PRA, from my  
4 perspective, when I know more about the design.

5 Is the I&C design here, is it all AC  
6 stuff or is it DC?

7 MR. REDDY: As far as the power supplies  
8 going into the I&C system, it is a 24-volt DC.

9 MEMBER STETKAR: Okay.

10 MR. REDDY: And it's auctioneered such  
11 that you have a 250-volt to 24-volt converter and a  
12 480-volt AC to 24-volt converter. They are in the  
13 same division.

14 MEMBER STETKAR: And it is done at the  
15 division level rather than at --

16 MR. REDDY: Yes.

17 MEMBER STETKAR: Okay.

18 MR. REDDY: Well, it is done at the I&C  
19 cabinet.

20 MEMBER STETKAR: Okay.

21 MR. REDDY: So, you have each one of  
22 those two feeds into the I&C cabinet.

23 MEMBER STETKAR: Different from the  
24 design I'm familiar with. Thanks. That helps. I'm

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 still not convinced that a double DC bus, a 250-volt  
2 DC bus failure is not an initiating event, though.

3 MR. REDDY: I'm not saying it's not, but  
4 I did want to --

5 MEMBER STETKAR: Yes, that helps, by the  
6 way.

7 MR. REDDY: -- to make sure that a lot of  
8 times with the four divisions that we do keep in  
9 mind, as far as the tech spec action statements, that  
10 is the same with the two-hour required action.

11 MEMBER STETKAR: But the problem, of  
12 course, in risk assessment is that a low-frequency,  
13 high-consequence initiator, when I look through Level  
14 2, is something that we don't necessarily want to  
15 screen out simply because we can't think of a high-  
16 initiating event frequency, or that somebody hasn't  
17 thought about it, because there may be something  
18 unique about the design or the tech specs, or  
19 whatever, that makes that particular initiator more  
20 or less important.

21 And it sounds a little bit that DC may be  
22 somewhat less important than some of the designs I'm  
23 more familiar with that are strict DC feed all the  
24 way through.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. REDDY: Right.

2 MEMBER STETKAR: Let me ask you, as long  
3 as you are sitting there and have volunteered so  
4 graciously to talk about electrical stuff --  
5 (laughter) -- when I looked at the electric power  
6 supplies, you mentioned that -- I have to be careful  
7 here; I'll use the word -- artificially evaluated an  
8 initiating event from loss of a single safety-related  
9 AC bus, your 31BDA event, that you are not convinced  
10 will give you a trip, but it is probably the path of  
11 least resistance.

12 When I looked at the electric power  
13 supply, will loss of power from either of the  
14 emergency auxiliary transformers give you a unit  
15 trip?

16 MR. REDDY: No.

17 MEMBER STETKAR: No? How about one of  
18 the normal auxiliary transformers?

19 MR. REDDY: Remember, with the normal  
20 auxiliary transformers, you still have the fast  
21 transfer there as well.

22 MEMBER STETKAR: Okay. Will failure of a  
23 normal auxiliary transformer and failure of a fast  
24 transfer give you a plant trip?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. REDDY: With that, if you lose power  
2 to two of your reactor coolant pumps, then --

3 MEMBER STETKAR: Okay. So, those are  
4 possible initiating events. I don't know what the  
5 implication of those things are.

6 Maybe I will just stop there. I didn't  
7 see evidence of a systematic evaluation of single and  
8 multiple electric power failures, looking for  
9 initiating events. Now, again, I know that there  
10 have been questions raised in the RAI process, and we  
11 don't have all of the RAIs. So perhaps some of these  
12 things have been answered through the RAI process,  
13 but I'm not sure.

14 MS. DIMITRIJEVIC: No, we did the FEMA, I  
15 mean, which supported initiating events. The results  
16 of that are not in the FSAR, and I don't think we  
17 have actually provided that.

18 MEMBER STETKAR: Yes.

19 MS. DIMITRIJEVIC: The NRC has to look  
20 now at the commentation on that.

21 MEMBER STETKAR: Let me, because I know  
22 we want to keep moving here, sir, let me just ask  
23 about a few more initiating events. These are not  
24 electrical, so you are off the hook.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           The FSAR shows a number of ventilation  
2           system dependencies. And in fact, the PRA results  
3           show that certain ventilation failures can be rather  
4           important contributors to risk. The PRA includes no  
5           initiating events from failures of ventilation. Why  
6           is that?

7           MS. DIMITRIJEVIC: Well, you know, the  
8           ventilation, originally, they say with just one  
9           train. So, this actually 31BDA covers the  
10          ventilation. I mean since all divisions are in  
11          separate buildings, the loss of one ventilation will  
12          disable one safety train. So, the consequences of  
13          the loss of ventilation are covered through the loss  
14          of one train.

15          MEMBER STETKAR: Is the frequency covered  
16          by the loss of one train?

17          MS. DIMITRIJEVIC: Yes, we think it is.

18          MEMBER STETKAR: Have you --

19          MS. DIMITRIJEVIC: And we have actually  
20          answered this thing in the RAI.

21          MEMBER STETKAR: Oh, okay. Okay.

22          MS. DIMITRIJEVIC: I cannot exactly --

23          MEMBER STETKAR: That's another RAI?

24          MS. DIMITRIJEVIC: -- tell you. I cannot

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 exactly tell you. I have to look in the cutsets of  
2 initiating events to see does it.

3 However, what is not covered is the  
4 common-cause things of the ventilation. So,  
5 therefore, we have been considering, since we are  
6 doing the PRA update, considering these common-cause  
7 to see will it change our frequency calculations.

8 MEMBER STETKAR: And as a final question  
9 on the completeness of the initiating events, when I  
10 think of ventilation, ventilation is both air-  
11 handling equipment and chilled-water equipment. And  
12 the chilled water is also train-specific, but I  
13 didn't see any mention of failures of chilled water.

14 You have very detailed analyses for  
15 losses of component cooling water. I was fairly  
16 impressed with the number of different combinations  
17 of things that you looked at for component cooling  
18 water because everybody knows that component cooling  
19 water is important to reactor coolant pump seal load,  
20 and everybody knows that reactor coolant pump seal  
21 load, because they are the most important contributor  
22 to risk. So, obviously, you have to be pretty  
23 careful there.

24 It struck me that a chilled water system

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that has some operating and some standby equipment  
2 sounds to me an awful lot like a component cooling  
3 water system that has some operating and standby  
4 equipment, and, yet, there is no initiating events  
5 that look at chilled water. And yet, the overall  
6 results seem to be quite sensitive to failures of  
7 ventilation.

8 MS. DIMITRIJEVIC: That's true, and  
9 ventilation was looking at details as mitigating,  
10 say, in chilled water. And it is a true statement;  
11 it wasn't looking at an initiating event other than  
12 through supporting the --

13 MEMBER STETKAR: Did your peer review  
14 identify that as a deficiency?

15 MS. DIMITRIJEVIC: No.

16 MEMBER STETKAR: Ah, that's interesting.

17 MS. DIMITRIJEVIC: No, but they have  
18 access to the different documentation which is not  
19 accessible here. I mean, when we talk about the  
20 safety of the chilled water and the HVAC, this is the  
21 same question you brought up, too. I mean it is the  
22 same initiator, basically.

23 MEMBER STETKAR: It might be the same,  
24 but it is curious about what frequencies are used for

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 things, because you have lumped, for example, failure  
2 of ESW and failure of CCW together --

3 MS. DIMITRIJEVIC: Right, right.

4 MEMBER STETKAR: -- arguing that they  
5 have the same impact.

6 MS. DIMITRIJEVIC: Right, right.

7 MEMBER STETKAR: but I didn't read  
8 anything about chilled water. And I don't even know  
9 how the frequency of CCW was calculated.

10 What I am looking for is, again, it comes  
11 back to my original question about completeness.  
12 What we have seen is that completeness in the area,  
13 especially of support system initiating events, is a  
14 very important area --

15 MS. DIMITRIJEVIC: And believe me, we are  
16 completely aware of that.

17 MEMBER STETKAR: -- of risk assessment.

18 MS. DIMITRIJEVIC: Yes. Yes.

19 MEMBER STETKAR: And the problem is that  
20 we don't have all of that other communications that  
21 has gone on between you and the staff in terms of  
22 answering RAIs and things. So, that is a part of my  
23 reason. Perhaps some of these things, indeed, have  
24 been asked and resolved appropriately.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MS. DIMITRIJEVIC: Well, I mean I will  
2 argue with you that this is considered -- the loss of  
3 ventilation is limited to the one building and to the  
4 one division, and that was involved in the loss of  
5 one division. However, common-cause parts of HVAC,  
6 it was not specifically --

7 MEMBER STETKAR: Yes, I mean I just look  
8 at, for example, honestly, I think you did a really  
9 good job at looking at different combinations of  
10 component cooling water in terms of standby and  
11 operating, and all that kind of stuff.

12 MS. DIMITRIJEVIC: That's right.

13 MEMBER STETKAR: I thought that was much  
14 more than I have seen in many studies. That was  
15 really good.

16 And I was a little disappointed that I  
17 didn't see the same type of thought process done for  
18 things like ventilation and chilled water which  
19 involve --

20 MS. DIMITRIJEVIC: Okay, but don't forget  
21 that, actually, this component cooling water and  
22 emergency service water are also supplying chiller  
23 units water. So, they, basically, through the loss  
24 of this common header of component cooling, we

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 analysis loss of chilled water through the plant.  
2 However, not specifically on the chillers and not  
3 specifically --

4 MEMBER STETKAR: You come back to the  
5 frequency, you know, the contributors to the  
6 frequency, because the frequency was derived from a  
7 design-specific fault tree model.

8 MS. DIMITRIJEVIC: That's what I -- yes,  
9 and this loss of the common headers involve all of  
10 the other ways to lose cooling to the chillers, which  
11 is promulgated through the plant. I have no problem  
12 with your comment.

13 MEMBER STETKAR: Okay. I will let you go  
14 on.

15 MS. DIMITRIJEVIC: Yes.

16 MEMBER STETKAR: Thanks.

17 MS. DIMITRIJEVIC: So, the systems which  
18 we analyze are also the no surprises typical for the  
19 PWRs. Just, you know, reactivity control, heat  
20 removal, systems important for RCS integrity,  
21 inventory control, long-term cooling, which is the  
22 heat removal system. That may be one which you would  
23 not recognize. And the support systems model in a  
24 lot of -- as mitigators, maybe with some omission for

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 the initiators, HVAC, electrical, I&C, and all  
2 cooling trains.

3 MEMBER STETKAR: Vesna, the emergency  
4 boration system --

5 MS. DIMITRIJEVIC: Yes.

6 MEMBER STETKAR: -- I am trying to read  
7 ahead. So, stop me if you are actually going to talk  
8 about some of the models, but I don't see that.

9 MS. DIMITRIJEVIC: No, we will not have  
10 the time.

11 MEMBER STETKAR: The emergency boration,  
12 the ATWS models include credit for emergency boration  
13 to shut down the reactor. That is a manually-  
14 initiated system.

15 MS. DIMITRIJEVIC: Yes.

16 MEMBER STETKAR: Let me see if I can be  
17 careful here. What is the available time window for  
18 the operators to initiate emergency boration in  
19 enough time to successfully shut down the reactor to  
20 avoid the most limiting transient. Think of loss of  
21 main feedwater initiating event, which is typically  
22 the most limiting transient for ATWS. How much time  
23 is available for the operators to initiate that?

24 MS. DIMITRIJEVIC: Well, loss of main

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 feedwater within the credited, I guess. We just led  
2 that, if the reactor protection system fails, we led  
3 that to the core damage.

4           However, I remember I knew that you were  
5 ask about those times for EBS, and I don't think that  
6 this is in the -- can you check?

7           MR. CORDOLIANI: If I may add something,  
8 actually, we did encourage EBS to like prevent the  
9 first pressure peak. If we mitigate, successfully  
10 mitigate, the first ATWS pressure peak, then we model  
11 EBS for long-term reactivity going forward.

12           So, that gives us a set period of time.  
13 I think 30 minutes is one action we credit. I'm not  
14 sure if we have another one, but --

15           MS. DIMITRIJEVIC: I think there was two.  
16 This is what you are going to remember about  
17 timing --

18           MR. CORDOLIANI: Yes.

19           MS. DIMITRIJEVIC: -- and I just don't  
20 even know where to actually look for that level of  
21 details.

22           MR. CORDOLIANI: It's 30 minutes. It's  
23 30 minutes, actually, for both cases, both ESFAS and  
24 steamline break. But, again, that is not 30 minutes

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 to like use the manual back-up requirements to look  
2 --

3 MS. DIMITRIJEVIC: Long-term reactivity  
4 control.

5 MR. CORDOLIANI: Right.

6 MS. DIMITRIJEVIC: We didn't credit the  
7 EBS to treat the reactor and escape the original  
8 pressure peak. That is why the loss of main  
9 feedwater and the reactor trip fail we led directly  
10 to the damage.

11 MEMBER STETKAR: Let me see if I can  
12 understand the models a little bit better, then.

13 I looked at your ATWS event tree, and  
14 there are some initiating events that include reactor  
15 trip failure as a top event in the event tree. For  
16 example, loss of offsite power does. General  
17 transient does. And I have a list here, if I could  
18 find them.

19 Loss of balance of plant's closed cooling  
20 water, loss of main feedwater. Include reactor trip.

21 So, I know the initiating event frequency times some  
22 model for reactor trip failure goes to an ATWS  
23 condition.

24 From what I am hearing, was the ATWS

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 model actually linked to those event-specific models  
2 as a consequence event tree? Anybody?

3 MS. DIMITRIJEVIC: Yes, from the event,  
4 yes, from the events which we transfer, yes, it was  
5 linked.

6 MEMBER STETKAR: Okay. Okay. So, in  
7 principle, you have different success criteria in the  
8 ATWS model, depending on where you came from?

9 MS. DIMITRIJEVIC: Yes, but we didn't  
10 connect it from every tree.

11 MEMBER STETKAR: That was the second part  
12 of the question. I was trying to understand if there  
13 was a generic ATWS model with a generic manual  
14 response time for EBS, how that applied across the  
15 whole spectrum. Because, as you mentioned, there are  
16 no transfer to the ATWS model from any of the small-  
17 to-medium LOCA-initiating events. There are a couple  
18 of transient initiating events, like loss of  
19 component cooling water that does not transfer to  
20 ATWS, but none of the small-LOCA to medium-LOCA-type  
21 initiating events can result in an ATWS condition.

22 So, I was a little bit curious about why  
23 that is, especially if you are linking ATWS models  
24 specifically to other initiators.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MS. DIMITRIJEVIC: Well, that sounds  
2 specifically -- I mean general transient, basically,  
3 has a much higher frequency than any LOCA, right. Is  
4 that something in the LOCA which we think is going to  
5 influence ATWS protection differently than --

6 MEMBER STETKAR: Operator confusion and  
7 operator response. For example, if I'm trying to  
8 cope with a LOCA at the same time that I am trying to  
9 cope with a reactor trip failure, it might be a low  
10 frequency, but --

11 MS. DIMITRIJEVIC: Yes, that would be,  
12 also, I mean the LOCA would be just a small LOCA,  
13 right? I'm not sure those will shut the plant long-  
14 term down.

15 MEMBER STETKAR: Yes, anything that would  
16 go up, some sort of up into the -- I don't know on  
17 this plant whether a medium LOCA will shut you down,  
18 but, certainly, any of the small LOCA-type  
19 initiators. A steam generator tube rupture, for  
20 example, is a small LOCA that gets operators diverted  
21 away to doing other things. So, that if the ATWS  
22 model is including credit for operator action to  
23 mitigate the ATWS condition, at the same time the  
24 other models are including credit for operator action

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 to mitigate those things, it can become more  
2 complicated.

3 Now I'm not trying to imply that this is  
4 a large contributor to either core damage frequency  
5 -- it could be a relatively larger contributor to  
6 risk, but not a major contributor. I am trying to  
7 understand the completeness of these models in terms  
8 of assessing the risk from the design.

9 MS. DIMITRIJEVIC: All right. I mean I  
10 just want to say --

11 MEMBER STETKAR: I was curious, I wasn't  
12 sure how you treated ATWS. So, I am glad to hear  
13 that you actually linked it to some of the models.

14 MS. DIMITRIJEVIC: Yes.

15 MEMBER STETKAR: But, given that, why  
16 didn't you link it to any of the --

17 MS. DIMITRIJEVIC: We didn't link it to  
18 others because we didn't think it makes a difference  
19 in mitigating a thing. And you're right, there is  
20 this one human action, so on the EBS it may be linked  
21 to the other human performance. But we neglected  
22 dependency; we don't think it will have any impact,  
23 seriously.

24 I mean because we are looking between 5 E

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 to the minus 4 and 1 per year challenging frequency.

2 So, we already tend to 10,000 times lower  
3 frequencies challenging the reactor protection  
4 systems. So, this human action is not really an  
5 important contributor. It has to be some significant  
6 change in the response to make this more significant.

7 And we have looked at this in determining all the  
8 initiating events.

9 I mean we are talking a thousand times  
10 smaller --

11 MEMBER STETKAR: Not necessarily, if you  
12 add up the --

13 MS. DIMITRIJEVIC: I don't think this  
14 action is probably -- I don't even know what the  
15 human error probability on these actions.

16 MEMBER STETKAR: And it is not  
17 necessarily a thousand times smaller. If I add up  
18 all of the small LOCA contributors, small LOCA  
19 frequency, the sum of them is probably closer to --

20 MS. DIMITRIJEVIC: Do we have an AGP for  
21 this EBS actuation factor? What was the AGP  
22 probability?

23 MEMBER STETKAR: The actual numbers, I  
24 honestly don't care about the numbers at this stage

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 of the game. I really don't. The numbers are really  
2 artificial anyway. I care more about the scope of  
3 what is called the assessment of the risk from this  
4 design.

5 MS. DIMITRIJEVIC: Well, John, we did  
6 that detailed FEMA in identifying initiators, and if  
7 you are challenging me something which important,  
8 that is different. We can go back and look at that,  
9 but I have a -- I mean, in this particular case, I  
10 mean I will completely argue with you on the chilled  
11 water and the ventilation. The issue may be choose  
12 to look at more details, but here I don't really  
13 think it will make a difference, but we can go back  
14 to our FEMA and see what these are.

15 MEMBER STETKAR: You know, Vesna, I have  
16 to be careful that I am not trying to imply that I  
17 believe that -- I'm not sure about the chilled water,  
18 how important that is. That could be --

19 MS. DIMITRIJEVIC: Yes.

20 MEMBER STETKAR: That could be important  
21 in my opinion.

22 MS. DIMITRIJEVIC: Yes.

23 MEMBER STETKAR: Things like linking the  
24 ATWS model to some of these other initiating events,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 I honestly don't believe is going to be a large  
2 contributor to risk. I don't know that. That's kind  
3 of my personal belief.

4 On the other hand, you very, very  
5 carefully analyze many, many other things that may be  
6 much smaller contributors, all of those less than  
7 4/100ths of 1 percent contributors that are included.

8 Now I don't know that these things that  
9 are omitted are less than that. I just don't know.

10 MS. DIMITRIJEVIC: Well, if you are  
11 asking, did we have a systematic process of  
12 identifying initiating events, yes, we had the FEMA;  
13 we had a systematic process in identifying. So, we  
14 made these -- I looked at the selection of initiating  
15 events which we decided to model. Some of those  
16 which you brought up are not part, but they  
17 definitely went through this process, and we go back  
18 and see the rationale why they were excluded.

19 You understand that actually linking ATWS  
20 to every trigger significantly complicates and  
21 extends the time of calculations.

22 MEMBER STETKAR: You know, I don't  
23 care --

24 MS. DIMITRIJEVIC: Right.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: -- at this stage. This  
2 is a design risk assessment.

3 MS. DIMITRIJEVIC: Absolutely.

4 MEMBER STETKAR: I don't care if it takes  
5 six weeks to run the model. The last I heard, we are  
6 not under that type of pressure. So, you know, if  
7 the quantification time is six weeks, who cares?

8 MS. DIMITRIJEVIC: That's very true, but,  
9 actually --

10 MEMBER STETKAR: We are not using this as  
11 an online risk monitor, are we?

12 MS. DIMITRIJEVIC: No, no. No, I just  
13 want to say --

14 MEMBER STETKAR: The computer is cheap.  
15 But having run computer models for six weeks, the  
16 electricity is cheap, unless you have a poor power  
17 supply.

18 (Laughter.)

19 MS. DIMITRIJEVIC: One of my favorite PRA  
20 sayings actually came from Stan Kaplan, who said  
21 that, fortunately, there is such a limit to how  
22 simple you can make things and, unfortunately, there  
23 is no limit to how complicated we make things.

24 I mean I am always proud, as simple as we

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 can keep the model, I am always proud instead of  
2 adding. And we may be able to do some sensitivity  
3 study and show that this not important, but we tried  
4 to keep this model that was already very complex to  
5 the limited complexity. And maybe we missed something  
6 in this process.

7 MEMBER STETKAR: Yes, as a general  
8 comment, the thing that bothers me a bit is that you  
9 do sensitivity studies and you say, okay, this is  
10 small; this is less than a 3 percent contributor,  
11 even if we model it, and this is less than a 5  
12 percent contributor, and this is less than a 2  
13 percent contributor.

14 And I have forgotten the Senator's name,  
15 but he says, "A billion here, a billion there. After  
16 a while, you know, you are starting to talk about  
17 real money."

18 CHAIR POWERS: It was Everett Dirksen.

19 MEMBER STETKAR: Thank you.

20 Twenty-five percent contributors doubles  
21 your core damage frequency. Individually, each one  
22 is only 5 percent. If you are missing 20 of them,  
23 you are off by a factor of two. Is a factor of two  
24 important relative to 10 to the minus 4 CDF? No, it

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 is not. No, it's not. Is it important to having an  
2 understanding of the risk and the real contributors,  
3 and perhaps risk importance measures from specific  
4 equipment failures? It might be.

5 MS. DIMITRIJEVIC: Well, everything is  
6 important from the risk importance standpoint.

7 MEMBER STETKAR: That is the problem on  
8 this plant.

9 MS. DIMITRIJEVIC: Yes, yes.

10 MEMBER STETKAR: Because everything is  
11 equally unimportant --

12 MS. DIMITRIJEVIC: Yes.

13 MEMBER STETKAR: -- that means anything  
14 that is potentially omitted is also equally  
15 unimportant. If you had something that had a core  
16 damage frequency of 5 E to the 5 minus with one 90  
17 percent contributor, you wouldn't worry.

18 MS. DIMITRIJEVIC: Right, but now I only  
19 move to the 12th slide out of 56, and it is 4:45.

20 MEMBER APOSTOLAKIS: I don't understand  
21 the line of questioning. Are you trying to  
22 understand a specific sequence and how it was done or  
23 are you trying to ascertain the level of overall  
24 quality?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: The second.

2 MEMBER APOSTOLAKIS: The second?

3 MEMBER STETKAR: Absolutely the second.

4 MEMBER APOSTOLAKIS: And you are using  
5 these --

6 MEMBER STETKAR: I'm using these as  
7 specific examples in terms of completeness of the  
8 initiating event list, the modeling, completeness of  
9 the modeling --

10 MEMBER APOSTOLAKIS: Sure.

11 MEMBER STETKAR: -- of certain phenomena,  
12 that kind of thing. So, it is certainly the second.  
13 It is not the first at all.

14 CHAIR POWERS: Okay.

15 MS. DIMITRIJEVIC: All right. Gee, I  
16 mean we didn't even start I&C. Now it is not moving  
17 really.

18 Although this system, we choose the  
19 digital I&C to talk a little more about, its platform  
20 is Teleperm XS, safety I&C platform.

21 MEMBER APOSTOLAKIS: So, how did you  
22 handle the I&C in the PRA?

23 MS. DIMITRIJEVIC: Well, we have the time  
24 model of some of this. The protection system and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 ESFAS are modeled in details.

2 MEMBER APOSTOLAKIS: But, even there, I  
3 mean you have to say something about the digital  
4 part.

5 MS. DIMITRIJEVIC: Yes.

6 MEMBER APOSTOLAKIS: Did you assume that  
7 it always does its job or --

8 MS. DIMITRIJEVIC: Well --

9 MEMBER APOSTOLAKIS: This is going way  
10 beyond the state-of-the-art. Let me start with that.

11 MS. DIMITRIJEVIC: Okay.

12 MEMBER APOSTOLAKIS: But I am just  
13 curious how you handled it. I mean, you can tell us  
14 how you --

15 MS. DIMITRIJEVIC: This is just to  
16 define, this slide is just to define the scope of the  
17 ESFAS, and I will come back. Because what you want  
18 to talk is the softer failures.

19 MEMBER APOSTOLAKIS: Yes, yes.

20 MS. DIMITRIJEVIC: So, we will come back  
21 to this.

22 So, if I can just go move, then, faster,  
23 we have four-division redundancy. We have two  
24 independent subsystems per division, which provide A

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 and B functional diversity.

2 Not all I&C systems are modeling details  
3 in this phase; safety process or automation systems  
4 model simplified with undeveloped events.

5 A diverse actuation system, which is,  
6 therefore, diversity and defense in depth was only  
7 modeled as a back-up reactor trip, but not through  
8 ESFAS in this model.

9 This Teleperm, there is 10 years of  
10 experience in the system worldwide, 39 plants at 24  
11 sites, 11 countries, 10 different reactor designs.  
12 About 2,000 computer processor modules are in  
13 service, with over 92 million hours of operating  
14 experience.

15 So there is experience. There is some  
16 proven multi-pronged defense against Software common-  
17 cause failures, which is in the next slide.

18 We actually included two aspects of  
19 potential software failure. One was operating system  
20 common-cause failures, and one was application  
21 software common-cause failures. They are explicitly  
22 modeled.

23 We have been asked to perform numerous  
24 sensitivity studies, and the results show, which is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 not really a surprise to anybody, that those results  
2 are sensitive to the software common-cause failures.

3 The model is designed and optimized to  
4 let us analyze this.

5 MEMBER APOSTOLAKIS: On the common-cause  
6 failures you considered simply disabled some  
7 function?

8 MS. DIMITRIJEVIC: Yes.

9 MEMBER APOSTOLAKIS: You did not consider  
10 possible failures that --

11 MS. DIMITRIJEVIC: Disabled the system,  
12 yes, we did.

13 MEMBER APOSTOLAKIS: Not only, but  
14 actually did something, like the errors of commission  
15 in human error, you know. You are really focusing on  
16 the equivalent of omission.

17 MS. DIMITRIJEVIC: Yes, failures to  
18 perform and required, not to do something strange,  
19 no.

20 MEMBER APOSTOLAKIS: Okay.

21 MS. DIMITRIJEVIC: This was the results.

22 Okay, great. So, let me just move and  
23 show you the results.

24 MEMBER STETKAR: Vesna?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MS. DIMITRIJEVIC: Yes? We all have a  
2 lot of important questions.

3 MEMBER STETKAR: Don't laugh at me. I  
4 didn't say anything about digital I&C, did I?

5 (Laughter.)

6 Are we going to have an opportunity at  
7 all to ask about certain parts of the models,  
8 technical issues? I have already slowed you down and  
9 destroyed every --

10 MS. DIMITRIJEVIC: Give me an example.

11 MEMBER STETKAR: For example, I had a  
12 question about the loss of offsite power model. I  
13 had a question about the modeling of that famous EFWS  
14 suction cross-tie.

15 MS. DIMITRIJEVIC: Okay.

16 MEMBER STETKAR: Where in the next, you  
17 know, "N" number of hours would it be appropriate to  
18 ask about those questions?

19 MS. DIMITRIJEVIC: That I'm not in charge  
20 of. You definitely can ask me for both of those  
21 questions. I just don't know how this --

22 MS. SLOAN: Vesna, is there an  
23 appropriate -- I mean maybe --

24 MS. DIMITRIJEVIC: I don't know. Right

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 now, I'm going to start presenting the results.

2 MEMBER STETKAR: Okay, but at some level  
3 we can all read results. You know, there are tables  
4 of numbers. Fine.

5 MS. DIMITRIJEVIC: Okay.

6 MEMBER STETKAR: A couple of times 10 to  
7 the minus 7, a couple times 10 to the minus 8.

8 MS. DIMITRIJEVIC: All right.

9 MEMBER STETKAR: Those results are only  
10 as credible as the supporting models.

11 MS. DIMITRIJEVIC: There's very true, but  
12 they will show you importance on the system  
13 structure, and it could be connected to this  
14 discussion.

15 But if you want to discuss both of those,  
16 please --

17 MEMBER STETKAR: Oh, you know, I was  
18 looking through your presentations here, and I was  
19 curious about when the appropriate time to ask about  
20 those might be.

21 MS. SLOAN: Well, maybe can I offer a  
22 suggestion?

23 MEMBER STETKAR: Yes.

24 MS. SLOAN: And maybe this is for you and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the Chairman. You have seen what we have. And I  
2 tend to agree with you; you can go through and read  
3 tables. But, given the constraints that we are  
4 under, if there are particular areas in the slides  
5 you want us to focus on, or even things not in the  
6 slides, maybe we should regroup and try to focus it  
7 that way, and skip things that you can just read that  
8 are not so controversial.

9 MS. DIMITRIJEVIC: That's fine.

10 CHAIR POWERS: The objective, of course,  
11 is for us to gather the information we want. The  
12 presenters do their best to try to anticipate the  
13 information we want and, in general, do a fairly good  
14 job. On that, maybe not in the reliability assurance  
15 program, but in many areas.

16 My view on Chapter 19 is this is our  
17 introduction to this subject that is going to take  
18 place, and we can refine as we see fit or any  
19 additional information we want.

20 My suggestion to you is do your best to  
21 acquaint the applicant here with the information you  
22 would like to see, and I am sure that they will  
23 accommodate us in one way or another.

24 MEMBER STETKAR: Okay.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR POWERS: My examination of what is  
2 assembled here is that I don't think that I want to  
3 have you regrouping here in the next day or two, but  
4 I do want you to come away with understanding where  
5 we want to go into some depth, additional depth.

6 So, if that provides you any guidance, I  
7 want your --

8 MEMBER STETKAR: Yes, it does. Thanks.

9 CHAIR POWERS: I want you to have the  
10 information you think is going to be necessary. But  
11 I don't know that it is necessary to get it in the  
12 next day or today and tomorrow.

13 MEMBER STETKAR: Right. Right. So, I  
14 think perhaps the best idea is to let them continue  
15 with their presentation at least to a certain point,  
16 but to see if we can have a little bit of time to at  
17 least raise two or three technical points. And  
18 perhaps they can be resolved very quickly is the  
19 problem; perhaps they can't, but to kind of give you  
20 an idea of --

21 CHAIR POWERS: My experience is nothing  
22 gets resolved quickly.

23 (Laughter.)

24 MEMBER STETKAR: Well, occasionally, they

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 do.

2 CHAIR POWERS: My intention is to allow  
3 this presentation to go on through slide 38.

4 MEMBER STETKAR: Okay.

5 CHAIR POWERS: And then I am going to  
6 stop for the day. Then, we will let the staff  
7 provide their rebuttal or endorsement, or whatever it  
8 is that you are going to provide, first thing in the  
9 morning.

10 Then, we will launch again, and we will  
11 go as far as we can. Recognize I am going to stop us  
12 sometime between 4:00 and 4:30. Okay?

13 In that time, I see at least two  
14 opportunities where we can have a little bit of  
15 discussion, and we will do so, even at the expense of  
16 presentations, because the presentations are  
17 prepared. We can always come back to them as we see  
18 fit. Okay?

19 With that, I encourage the speaker to  
20 continue, understanding that I am going to stop when  
21 you get to slide 38.

22 MS. DIMITRIJEVIC: Okay.

23 CHAIR POWERS: So, if you popped 38 all  
24 of a sudden, I would probably say, oh, well, we're

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 done.

2 (Laughter.)

3 MS. DIMITRIJEVIC: Right.

4 MEMBER STETKAR: Is that a hint?

5 MS. DIMITRIJEVIC: I'm from southern  
6 Europe. I can speak very fast.

7 CHAIR POWERS: That does never help.

8 MS. DIMITRIJEVIC: This shows you all the  
9 numbers and what our CDF and LRF. That is a slide.  
10 It shows you total at-power, shutdown, and the  
11 events, and the corresponding CCFP.

12 So, since you had a chance to read that,  
13 there is not too much to say about this. So, I will  
14 jump to the uncertainty curve.

15 The Risk Spectrum allowed us to run the  
16 full Monte Carlo estimate and --

17 MEMBER APOSTOLAKIS: Vesna, when there is  
18 a PRA for a plant that is about to go critical, what  
19 do you think will happen to this total at power  
20 number?

21 MS. DIMITRIJEVIC: Well, I --

22 MEMBER APOSTOLAKIS: Your just  
23 professional opinion.

24 MS. DIMITRIJEVIC: Well, I think it will

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 go down.

2 MEMBER APOSTOLAKIS: Down from 510 to the  
3 minus 7?

4 MS. DIMITRIJEVIC: Yes. Yes. I think it  
5 will go down because it is based on a lot of bounding  
6 analyses on the floods and fires without knowing the  
7 special review killing all buildings.

8 I honestly believe that this is a  
9 conservative envelope, and as much as we know, we  
10 will be able to credit the more details.

11 MEMBER SHACK: Except for seismic?

12 MS. DIMITRIJEVIC: Except for seismic,  
13 yes. That is an exactly very good point. We don't  
14 know what is going to happen with the seismic.

15 MEMBER APOSTOLAKIS: And, then, 10, 20  
16 years later, the number will stay the same, after we  
17 have, say, 10 of those operating? The operating  
18 experience will say, yes, it is 10 to the minus 8 or  
19 7?

20 MS. DIMITRIJEVIC: I was going to say  
21 something really wise because I notice the CDF  
22 numbers are changing based on how the PRA progresses,  
23 not how the operations progress.

24 (Laughter.)

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1                   MEMBER APOSTOLAKIS: I don't know about  
2                   that. I mean a lot of the things, a lot of the  
3                   numbers that were presented in the seventies and  
4                   early eighties have been changed drastically moving  
5                   up for the current generation of reactors.

6                   MS. DIMITRIJEVIC: Well, we have seen the  
7                   fire now dominant strongly. That is because our  
8                   knowledge about is still, we cannot really model this  
9                   level of detail. So, we tend to make the bounding  
10                  analysis, and you can see the fire so strongly  
11                  dominant this, which I assume is going to be done  
12                  with the seismic, until we don't learn how to do it.

13                  The only period which we know exactly how  
14                  to do today is the Level 1 PRA. As soon as we learn  
15                  more, we will be able to produce the more realistic  
16                  results.

17                  So, I cannot really say how they will go.

18                  I certainly how that with ITAAC this information,  
19                  the input of the PRA and the RAP, these plants will  
20                  operate better than the current generation. And  
21                  therefore, I don't have a doubt that these results  
22                  will improve.

23                  MEMBER APOSTOLAKIS: Well, the number can  
24                  go up and still be better than the current

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 generation. I mean there is no question about it.

2 MEMBER STETKAR: Vesna, unfortunately,  
3 you shows this curve. Why didn't you use the mean  
4 frequency of every initiating event in your  
5 quantification?

6 MS. DIMITRIJEVIC: Why we didn't we what?

7 MEMBER STETKAR: Why didn't you use the  
8 mean value of each initiating event frequency in your  
9 quantification?

10 MS. DIMITRIJEVIC: We did.

11 MEMBER STETKAR: No, you didn't.

12 MS. DIMITRIJEVIC: We didn't?

13 MEMBER STETKAR: You used a point  
14 estimate frequency. Some of those are mean values.  
15 Some of them are up to a factor of 16 lower than the  
16 mean value.

17 So, I am curious why -- I mean the  
18 explanation -- yes?

19 MR. CORDOLIANI: If I may say something,  
20 actually, for the initiating events the frequency of  
21 which were determined using fault trees, for  
22 instance, also balance of plant or the values of  
23 component coolant water. We did use the mean values  
24 of the initiating event to create the mean value

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 which is on this curve. But the difference in point  
2 estimate without using the mean value, instead of the  
3 point estimate, for those initiators was very small,  
4 maybe 1 percent. I don't have the number offhand.

5 MEMBER STETKAR: I am just curious you  
6 didn't use the mean value to consistently quantify  
7 the model that gave you the cutsets, that you, then,  
8 did the uncertainty analysis on.

9 Remember, the uncertainty analysis in  
10 this is only the result of the retained cutsets.

11 MS. DIMITRIJEVIC: Now I understand your  
12 question. We used the mean values to calculate  
13 uncertainty curves.

14 MEMBER STETKAR: You used the uncertainty  
15 distributions --

16 MS. DIMITRIJEVIC: Yes, yes.

17 MEMBER STETKAR: -- to calculate that  
18 curve

19 MS. DIMITRIJEVIC: That's true.

20 MEMBER STETKAR: -- which has a mean  
21 value?

22 MS. DIMITRIJEVIC: That's true.

23 MEMBER STETKAR: You did not use the mean  
24 values consistently of each uncertainty distribution

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 to populate the database of the cutsets that you,  
2 then, later did the uncertainty analysis on?

3 MEMBER APOSTOLAKIS: Screening, in other  
4 words.

5 MS. DIMITRIJEVIC: Yes, but --

6 MEMBER STETKAR: Remember, Risk Spectrum  
7 only does the uncertainty analysis on the retained  
8 cutsets.

9 MS. DIMITRIJEVIC: Cutsets. That's very  
10 true. That is very true, but that is 80,000 cutsets.

11 So, I mean, it is not really the -- the most  
12 important thing was, for all of the initiating events  
13 which are taken from generic data, input is the main  
14 one.

15 For the initiating event, which we  
16 calculated by fault trees, which is just loss of  
17 component cooling water, the event risk, the  
18 difference between mean value and point estimate was  
19 not --

20 MEMBER STETKAR: The largest one I found  
21 was a factor of 16.5 difference --

22 MS. DIMITRIJEVIC: Right.

23 MEMBER STETKAR: -- because the error  
24 factor for the uncertainty distribution is assigned

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 as 300-and --

2 MS. DIMITRIJEVIC: That was the total  
3 ISLOCA.

4 MEMBER STETKAR: Oh, ISLOCA. I wonder  
5 how important that might be to Level 2 results, for  
6 example, since it is an interfacing system LOCA?

7 MS. DIMITRIJEVIC: We responded on those  
8 things. We can get back to you on this tomorrow.

9 MEMBER STETKAR: It might be. I don't  
10 know. It is a small number, but being a factor of 16  
11 low to start out with the populate the cutsets is  
12 troubling.

13 MS. DIMITRIJEVIC: We will get back to  
14 you on this tomorrow. I mean there is certain  
15 technical problems of merging the initiating events  
16 with the mitigating system. We will get back to you  
17 on this one.

18 This is a general distribution between  
19 internal events, fire and floods, and to show you the  
20 internal events that dominate. The LOOP LOCA and  
21 fire in safeguard buildings 1 and 4, and flood is  
22 dominated by flood in annulus, the activating  
23 annulus. This shows you some representative cutsets,  
24 shows you what is present.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 I said that we don't rank, previously, in  
2 the RAP, that we don't rank systems. That is true.  
3 There is no risk measures for the system, but this  
4 will be something that we run into Fussil-Vasili.

5 You can see this is an active plant; an  
6 electrical system dominates. After that reactor  
7 coolant system, which includes the reactor coolant,  
8 pump seals and safety chilled water systems are the  
9 most important.

10 No surprise, of those four systems.

11 That shows the component ranked by  
12 Fussil-Vasili. We rank the components based both on  
13 Risk Achievement Worth and Fussil-Vasili.

14 MEMBER APOSTOLAKIS: Now, in the previous  
15 slide --

16 MS. DIMITRIJEVIC: Yes?

17 MEMBER APOSTOLAKIS: -- how was this  
18 importance determined?

19 MS. DIMITRIJEVIC: It will be equivalent  
20 to the Fussil-Vasili of the system for all cutsets  
21 where that system plays down.

22 MEMBER APOSTOLAKIS: I see.

23 MS. DIMITRIJEVIC: We have, actually,  
24 manipulated them in the database.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1           This is important components based on the  
2           Fussil-Vasili, some of the different failure modes  
3           for the specific components. So, they are actual  
4           component-ranked.

5           Those are operator actions ranked on the  
6           Risk Achievement Worth, which we also provided in  
7           FSAR. We provided the Risk Achievement Worth rank on  
8           the common-cause initiators. You can see the sum of  
9           the common-cause initiators.

10          MEMBER APOSTOLAKIS: On slide 21, here is  
11          a stupid question.

12          MS. DIMITRIJEVIC: Sure.

13          MEMBER APOSTOLAKIS: The main steam  
14          relief isolation valve train has a RAW of 1.

15          MS. DIMITRIJEVIC: Yes.

16          MEMBER APOSTOLAKIS: So, why do you need  
17          it?

18          MS. DIMITRIJEVIC: Main steam relief?

19          MEMBER APOSTOLAKIS: Well, No. 9. No. 9.

20          MS. DIMITRIJEVIC: No. 9. "Main Steam  
21          Relief Isolation Valve Train" and has a RAW of 1.  
22          Why do we need it?

23          MEMBER APOSTOLAKIS: Which means, even if  
24          I eliminate it, the core damage frequency remains the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 same.

2 MS. DIMITRIJEVIC: This is just for  
3 single train. We have four.

4 MEMBER APOSTOLAKIS: You have what?

5 MS. DIMITRIJEVIC: Four.

6 MEMBER APOSTOLAKIS: It is because you  
7 have four?

8 MS. DIMITRIJEVIC: Yes. We have four.  
9 So, if you want to look in the real importance, it  
10 has to be looked to common-cause events. I don't  
11 know that we have this specific one there for common-  
12 cause. We might.

13 MEMBER APOSTOLAKIS: This would suggest  
14 to me that this is just a waste of money.

15 (Laughter.)

16 MS. DIMITRIJEVIC: Well, maybe on the  
17 single train --

18 MEMBER APOSTOLAKIS: Well, single train,  
19 yes.

20 MS. DIMITRIJEVIC: On the single --

21 MEMBER APOSTOLAKIS: So, then, why do I  
22 need this RAW? I mean, if there is always this  
23 caveat that you cannot look at the single train, what  
24 does it tell me? But they are all one. It says, you

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 know, I really don't need that.

2 MS. DIMITRIJEVIC: Well, this is based on  
3 the single component, and we also ran common-cause.  
4 So common-cause of those will also show, and that is  
5 going to show important.

6 MEMBER APOSTOLAKIS: The common-cause  
7 will appear in the system?

8 MS. DIMITRIJEVIC: No, it will appear --  
9 we have actually ranks for the common-cause, but I  
10 don't think that this is a common-cause. I don't  
11 think this one set on this selection.

12 Do you have all the Risk Achievement  
13 Worth on the Level 1, just internal ones? Check on  
14 the main steam relief trains, what's the role on --

15 MEMBER APOSTOLAKIS: I don't know. I  
16 mean --

17 MS. DIMITRIJEVIC: I only presented one  
18 slide. I can present 20 in the FSAR. Just to  
19 shorten the presentation, I just showed you the top  
20 of common-cause. I am sure that this row is bigger  
21 than 20.

22 MEMBER APOSTOLAKIS: It seems to me these  
23 importance measures should mean something. We don't  
24 do it just to show them. So, if I get 1, it is a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 very good candidate for elimination?

2 (Laughter.)

3 MS. DIMITRIJEVIC: From one train.

4 MEMBER APOSTOLAKIS: I mean, if I don't  
5 have it at all, CDF is insensitive --

6 MEMBER SHACK: That is just missing it  
7 from one train, she is saying.

8 MEMBER STETKAR: Take away one of the  
9 four.

10 MEMBER SHACK: This doesn't make any  
11 difference.

12 MS. DIMITRIJEVIC: Yes, yes.

13 MEMBER SHACK: You've got three others.  
14 If you take away all of them, that's a big deal.

15 MEMBER APOSTOLAKIS: Then say all of  
16 them, because for all of them is different.

17 MS. DIMITRIJEVIC: You know, what is RAW  
18 for all of them, 600.

19 MEMBER APOSTOLAKIS: I understand that.  
20 But maybe this suggests that, instead of four, you  
21 could have three. See, that's what I'm saying. That  
22 is the whole point of RAW.

23 MS. DIMITRIJEVIC: Well --

24 MEMBER APOSTOLAKIS: And especially if

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 you want to use PRA in design, that is a very good  
2 indicator. But that's the way it is. I mean,  
3 otherwise, I don't know what this --

4 MEMBER SHACK: You want an asymmetric  
5 reaction?

6 (Laughter.)

7 CHAIR POWERS: Well, I thought it was an  
8 asymmetric core. I don't see why not.

9 (Laughter.)

10 MEMBER APOSTOLAKIS: Now we're talking  
11 about the asymmetric stuff.

12 MS. DIMITRIJEVIC: Do we have a RAW on  
13 the double? Let's see.

14 MEMBER APOSTOLAKIS: Now they are all the  
15 system; I agree with you, that probably is high.

16 MS. DIMITRIJEVIC: No, not all of those  
17 valves.

18 MEMBER APOSTOLAKIS: Sure.

19 MS. DIMITRIJEVIC: There are four of  
20 them, right. But, don't forget, we have the safety  
21 valves also relieves on the --

22 MEMBER APOSTOLAKIS: But that would be a  
23 good indicator to me to at least look -- to at least  
24 look. If I went down to a three-train redundant

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 system, what would I get? Right?

2 MS. DIMITRIJEVIC: I mean I am sure the  
3 EPR with the three trains would satisfy every safety  
4 goal. It is just, I mean --

5 MEMBER APOSTOLAKIS: Because if you say,  
6 you know --

7 MS. DIMITRIJEVIC: The selection of the  
8 design --

9 MEMBER APOSTOLAKIS: -- don't pay any  
10 attention to it, then, the question is, why do you  
11 have the thing?

12 (Laughter.)

13 CHAIR POWERS: Let her continue.

14 MEMBER APOSTOLAKIS: Oh, absolutely.

15 MS. DIMITRIJEVIC: Okay. This is a  
16 summary of the flood, and I am trying to move as fast  
17 as I can.

18 Basically, we have selected --  
19 everything that is going to be flooded in that  
20 building, we assume it was flooded. Then, we  
21 calculated the frequency of that because we don't  
22 know exact locations of the components.

23 You can see the flood, actually, was  
24 dominated of a flood in annulus, from the fire model

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 distribution system.

2 Fire -- did I jump over two?

3 MEMBER STETKAR: I am going to ask about  
4 that flood.

5 MS. DIMITRIJEVIC: Yes.

6 MEMBER STETKAR: That annulus flood  
7 sounded like it was modeled pretty conservatively in  
8 the Level 1 PRA. You said that, if the flood level  
9 got up to the electrical penetrations --

10 MS. DIMITRIJEVIC: Right.

11 MEMBER STETKAR: -- you assumed core  
12 damage. And yet, I was a bit surprised, and I guess  
13 we will talk about Level 2 tomorrow, but I was a bit  
14 surprised that it didn't really show up as a  
15 contributor to the Level 2 results.

16 So, how is that flood modeled through  
17 Level 2? Because if it fails all of the signals in  
18 the Level 1 model, I was curious about containment  
19 isolation, containment heat removal, and things like  
20 that, in the Level 2 model.

21 Is that more appropriate to ask tomorrow?

22 MS. DIMITRIJEVIC: Tomorrow, yes.

23 MEMBER STETKAR: Okay.

24 MR. CORDOLIANI: I mean I can give some

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 elements, events of that, actually. In Level 2, we  
2 did fail, in that scenario, we did fail all the  
3 containment isolation valves in-board, like the  
4 inside containment, because consistently with the  
5 assumption that the communication to the control room  
6 would be lost.

7 It did show up, I mean lots of Level 2  
8 cutset have this event. It may not be a major  
9 contributor because we also have other Level 2-  
10 specific events, and those will be discussed  
11 tomorrow, I think.

12 But we did take into account impact --

13 MEMBER STETKAR: Think about it. Go  
14 look, homework, think about where the signals for the  
15 containment isolation come from, and if they come  
16 from inside the containment out to the other plant  
17 and back to the valves.

18 MR. CORDOLIANI: We also create a menu of  
19 backup, a different configuration.

20 MEMBER STETKAR: Okay.

21 MS. DIMITRIJEVIC: You can see this is 3  
22 minus 8. So, I mean, we are crediting back up to  
23 the --

24 MEMBER STETKAR: I am not concerned about

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 core damage frequency.

2 MS. DIMITRIJEVIC: No, no, no. I know.  
3 I know. Even LERF, you shouldn't be concerned so  
4 much. We have a backup of the .1 we do in the LERF  
5 range.

6 Okay. A similar analysis was done with  
7 the fire. And it was also assumed that, for every  
8 fire location, that we postulated the worst scenario  
9 and applied the total are fire frequency, and we did  
10 a very limited credit to fire suppression. Actually,  
11 manual suppression was only credited in the control  
12 room, which is --

13 MEMBER STETKAR: Quick on the fire.

14 MS. DIMITRIJEVIC: Sure.

15 MEMBER STETKAR: Initiating event  
16 frequencies, as best as I could tell, they were  
17 derived from NUREG/CR-6850. Is that correct?

18 MS. DIMITRIJEVIC: That is not true. It  
19 was only we used RES because we prefer to use a  
20 generic location. The NRC has questions about that,  
21 and we had to do and compare those to the NUREG.  
22 Because we don't really know -- we used the NUREG  
23 frequencies when we didn't have a generic location.

24 MEMBER STETKAR: Okay. Let me cut to the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 quick here.

2 MS. DIMITRIJEVIC: All right.

3 MEMBER STETKAR: Two things. You said  
4 you did not model transient or maintenance-induced  
5 fires. That is a statement that was made. So that  
6 is one omission.

7 The second omission is the observation is  
8 in NUREG/CR-6850 they develop various fire  
9 categories, and I have, essentially, a plant-level  
10 fire frequency, if I add up -- that is based on  
11 operating experience. And that plant-level fire  
12 frequency is on the order of about .25 per year  
13 during power operation, if you add up everything.

14 Your plant level fire frequency is .07  
15 per year, less than 30 percent of the NUREG/CR-6850  
16 total frequency. So, I am curious why the total fire  
17 frequency for the EPR --

18 MS. DIMITRIJEVIC: Well, did you sum the  
19 same locations?

20 MEMBER STETKAR: Hum?

21 MS. DIMITRIJEVIC: You summed the same  
22 location? Because this is not --

23 MEMBER STETKAR: I added up all the  
24 locations that are tabulated.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MS. DIMITRIJEVIC: I mean this is only  
2 buildings which we evaluate. That doesn't involve  
3 the total plant.

4 MEMBER STETKAR: Define total plant.

5 MS. DIMITRIJEVIC: Well, other buildings  
6 like, you know, radwaste area --

7 MEMBER STETKAR: Those aren't included in  
8 the NUREG/CR-6850 categories.

9 MS. DIMITRIJEVIC: They're not?

10 MEMBER STETKAR: Turbine building,  
11 auxiliary building, control building, and --

12 MS. DIMITRIJEVIC: Well, I think they are  
13 included in auxiliary building, to be honest with  
14 you, the auxiliary building, the -- what is it  
15 called? The pool of the data.

16 When you summed all the frequencies --

17 MEMBER STETKAR: I summed all the  
18 frequencies that are tabulated in your table of  
19 initiating event frequencies.

20 MS. DIMITRIJEVIC: Okay.

21 MEMBER STETKAR: They came out to be .072  
22 --

23 MS. DIMITRIJEVIC: Okay.

24 MEMBER STETKAR: -- fires per year.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MS. DIMITRIJEVIC: Okay.

2 MEMBER STETKAR: If you sum all of the  
3 frequencies at the plant level from NUREG/CR-6850,  
4 which screen out things like radwaste and, you know,  
5 storage buildings, and stuff like that, it comes out  
6 to be .25 per year. More than half of that, by the  
7 way, is due to transient combustibles and maintenance  
8 activities that you don't model.

9 MS. DIMITRIJEVIC: No, we want the  
10 transient combustibles. We just treat them equally  
11 through the areas. I mean when we did the  
12 sensitivity, we actually used areas, total area  
13 frequencies. NRC has a problem with that, says they  
14 may not be applicable to the Design Certification  
15 phase. We have to go and try to compare them with  
16 how with they come up if we can assume location of  
17 all components.

18 So, based on the current information, we  
19 could have a component, assuming a certain location  
20 of the components -- we have done and we did the  
21 compare our frequencies to how would they come to the  
22 NUREG/CR, and it came out very comparable.

23 However, we did not do this general check  
24 on there. I have really to go and check the --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1                   MEMBER STETKAR:    Check it because the  
2 whole philosophy of NUREG/CR-6850 is that I have a  
3 plant-level fire frequency subdivided among different  
4 components, let's call it exposure fires, maintenance  
5 and transient combustibles, and that, for a given  
6 plant, I allocate that frequency among locations in  
7 the plant based on the inventory of equipment for  
8 equipment fires and the types of activities that I  
9 would expect in that location.

10                   I mean one could argue that perhaps the  
11 frequency from NUREG/CR-6850, which is derived from  
12 U.S. plants, might even be low for this plant because  
13 you have about twice as much equipment. And if you  
14 do online maintenance, you are going to be doing more  
15 maintenance at power than typical U.S. plants.

16                   So, having a total plant-level fire  
17 frequency that's --

18                   MS. DIMITRIJEVIC: But there is a lot of  
19 things which are also improvements, you know, like,  
20 for example, the fiber cables, which are not --

21                   MEMBER STETKAR: That's good. That's --

22                   MS. DIMITRIJEVIC: There is extremely  
23 well-designed the reactor coolant pump's oil  
24 collection systems, advanced designs.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 I mean I have to think, actually, about  
2 your question --

3 MEMBER STETKAR: Think about it.

4 MS. DIMITRIJEVIC: -- and look in the  
5 details for that.

6 Actually, do we have -- we have a NUREG  
7 on the electronics, right? Yes. Okay.

8 This is the fire major contributions. We  
9 also did the low-power and shutdown, based on the  
10 preliminary assumptions of the ability because we  
11 don't really have shutdown schedules.

12 And we divided in the plant operating --  
13 basically, we selected representative sets of plant  
14 operating states and the representative sets of  
15 initiating events, and some fault trees were  
16 modified. Operator actions were maybe new.

17 Equipment from the shutdown was also  
18 considered in seismic margin agreement, and fire and  
19 flood, the only qualitative level that we didn't see  
20 any outliers that would be different. That was  
21 address in an RAI. We will check that because there  
22 was a question about the frequency, because we did  
23 look in this.

24 There are the power operating states

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 which were analyzed and how they related to the  
2 modes. And this is their safety contribution, the  
3 state CB, which is actually draining down mid-loop  
4 with the heat on shows as the most important.

5 The seismic was done, the PRA-based  
6 seismic margin assessment methodology, which was  
7 evaluation of the sequences for the fragilities were  
8 not going to be misidentified.

9 The detailed seismic analysis is not  
10 completed, and it will be completed when we have all  
11 the information on the design.

12 Also, for the other external events, like  
13 high winds and tornadoes, external floods, external  
14 fires, and aircraft crash, we have done a high-level  
15 qualitative review. All of those are analyzed as a  
16 part of the COLA, part of the applicant's Chapter 19.

17 And this is our general division. As you  
18 can see, actually, the coolant plants are mostly  
19 dominated by the fires. Here this is not the case  
20 because of the good spatial separation.

21 This is a division between power and  
22 shutdown CDF. And we have performed some sensitivity  
23 studies as a part of the Chapter 19. We have  
24 performed much more in the process of RAIs.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           This is some results here on the sum of  
2           the assumptions or the insights.

3           MEMBER STETKAR:    Vesna, when you say  
4           without preventive maintenance, what do you mean by  
5           that?

6           MS. DIMITRIJEVIC:   Well, we have made an  
7           assumption on the preventing maintenance on the train  
8           basis, and we just wanted to see how much of the  
9           maintenance, of the abilities, contributed to the  
10          total results.

11          MEMBER STETKAR:    Do the models -- again,  
12          I am kind of at a loss because I don't have the fault  
13          trees.    Did you quantify the effects of planned  
14          preventive maintenance during power operation?

15                 And in particular, what I am concerned  
16          about is the tech specs for essentially all of the  
17          safety systems, with the exception of electric power,  
18          allow one train of equipment to be out of service for  
19          120 days, I believe it is, and two trains to be out  
20          for 72 hours, and in some cases three trains to be  
21          out of service, although that's rare.

22                 Does the PRA model those types of  
23          maintenance configurations with extended duration  
24          outages for preventive maintenance?   And not only

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 extended duration, but correlated? So, for example,  
2 all equipment in train one is out of service together  
3 for some period of time, and multiple outages across  
4 trains, because during a preventive maintenance  
5 configuration, you could have forced maintenance on  
6 something. So, have you considered all of that?

7 MS. DIMITRIJEVIC: Well, in the PRA, the  
8 answer to that is no. We have addressed the  
9 preventive maintenance assuming certain corrective  
10 maintenance on a building site.

11 However, this was done before tech specs  
12 were finalized, and we made our own assumptions of  
13 what the AOTs would be. We were close to the  
14 current.

15 However, we did a sensitivity study when  
16 this proposal was given to do exactly what you  
17 describe. We did the sensitivity studies to see,  
18 would these tech specs meet the requirements of the  
19 risk-informed tech specs and would they satisfy it?

20 And when you model -- let's say the  
21 component has an AOT of 120 days. That doesn't mean  
22 that this component is going to be 120 days out per  
23 year. In general, the experience in the industry, it  
24 usually it means it is 1/10th of that; maybe once in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 10 years it would happen to be out for this.

2 MEMBER STETKAR: No, actually, the  
3 experience in Europe is every year they take out a  
4 train for something on the order of, oh, a week to 10  
5 days. That is actual operating experience.

6 MS. DIMITRIJEVIC: What we assume in the  
7 PRA is that will be out for the one week for  
8 preventive maintenance and 1/10th of AOT for  
9 corrective maintenance. That is a reasonable  
10 assumption.

11 However, in the sensitivity study which  
12 we did, we actually put one train out for that. You  
13 know, PRA is a sophisticated method, but it is not  
14 magic. It cannot give an answer to everything. You  
15 have to make a lot of assumptions to model AOT.

16 One of the assumptions -- we have  
17 analyzed six different assumptions when we analyzed  
18 this AOT. One is that one train is going to be all  
19 year out 120 days.

20 MEMBER STETKAR: Vesna, because of the  
21 time, I don't care about sensitivity analyses. There  
22 are many, many plants operating in Europe today --

23 MS. DIMITRIJEVIC: But we are talking  
24 about the U.S. EPR.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: There are many plants  
2 operating in Europe today that have four-train  
3 designs, and the way they organize their operations  
4 is to do online coordinated maintenance.

5 MS. DIMITRIJEVIC: That's true.

6 MEMBER STETKAR: Okay. That is human  
7 beings and nuclear power plant operators. It is not  
8 U.S. design versus European design.

9 MS. DIMITRIJEVIC: That's true.

10 MEMBER STETKAR: It is a design that  
11 allows you to do that.

12 The tech specs allow you to do that, as  
13 proposed for the U.S. EPR. The question is, does the  
14 PRA reflect that known and expected operating  
15 experience --

16 MS. DIMITRIJEVIC: In the way --

17 MEMBER STETKAR: -- and does it account  
18 for the actual history of operating experience in  
19 Europe? Because Europeans don't want to melt their  
20 plants. Europeans want to have very, very reliable  
21 systems. Europeans want to perform online  
22 maintenance. Therefore, there are years of actual  
23 experience to tell you how long, with some  
24 variability, these things are actually removed from

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 service.

2 So, you don't need to make sensitivity  
3 studies on suppose this is out for this, and suppose  
4 it is this train, and suppose it is that train.  
5 There's actual real operating experience in the  
6 world. That is one of the benefits of this design.

7 MS. DIMITRIJEVIC: Well, I don't really  
8 know. This database which we have available doesn't  
9 track on-schedule maintenance or scheduled  
10 maintenance. I don't even know where would I look  
11 for this data. Theoretically, what you said is true.

12 MS. SLOAN: I think what I would suggest,  
13 Vesna, as we follow up, and when we do have the  
14 benefit of having a partner who has extensive  
15 European operating experience -- this is through  
16 UniStar -- and we can certainly talk to our  
17 colleagues who work through EDF and talk about their  
18 OE with four-train plants.

19 MS. DIMITRIJEVIC: Well, we made  
20 assumptions based on the U.S. experience. This is  
21 different?

22 MEMBER STETKAR: The U.S. experience, the  
23 U.S. operating experience, by and large, except for  
24 south Texas, is irrelevant for this issue.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 On the other hand, the European operating  
2 experience from probably at least 20 years of  
3 operating experience, both in Germany and I assume in  
4 France, would be directly relevant to this issue.

5 MS. DIMITRIJEVIC: Well, the question is  
6 the preventive maintenance, we assume there is no  
7 question about preventive maintenance. How long it  
8 takes to do the regular preventive maintenance and  
9 the components can be reasonably assumed.

10 We are fashioning here corrective  
11 maintenance.

12 MEMBER STETKAR: No. We are talking  
13 about preventive maintenance, and we are talking  
14 about scheduled, coordinated preventive maintenance.

15 I don't know how you have modeled it. Have you  
16 modeled it at the entire safety train level, so that  
17 you take out an ESW pump and an EFW pump and an MHSI  
18 pump and an LHSI pump, all at the same time in one  
19 train for a fixed period of time, not independently?

20 MS. DIMITRIJEVIC: Not in the PRA.

21 MEMBER STETKAR: Okay.

22 MS. DIMITRIJEVIC: But in the sensitivity  
23 study, we did, for the tech specs, we did. We took  
24 the entire train and we didn't allow the double mix

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 of corrective and preventive. We did a much more  
2 detailed study for when they proposed their 120 tech  
3 specs, and we have that study.

4 In the PRA, we assume preventive  
5 maintenance on each system.

6 MEMBER STETKAR: Individually?

7 MS. DIMITRIJEVIC: Individually.

8 MEMBER STETKAR: Component-based  
9 individually?

10 MS. DIMITRIJEVIC: Right, component-based  
11 in corrective maintenance. But we classified that as  
12 a one or two, dependent on what train was being  
13 performed.

14 MEMBER STETKAR: Thanks. I wouldn't have  
15 asked, except you said without preventive  
16 maintenance. So it gave me an opportunity.

17 MS. DIMITRIJEVIC: Right. And we just  
18 analyzed, if we didn't really make an assumption of  
19 preventive maintenance in this stage, what would be.

20 This is some -- I mean I am not sure.  
21 Now, really, we are pushing really late.

22 This is some of the examples of how the  
23 PRA was used in design, not necessarily here in the  
24 United States, but in some of those supplied. Like

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the last one is our experience, based on this annulus  
2 flooding that we are now considering in closing those  
3 feedwater, the fire water distribution system valves.

4 The rest of the examples come from our  
5 European counterparts.

6 MEMBER APOSTOLAKIS: But you didn't use  
7 the PRA to simplify the design.

8 MS. DIMITRIJEVIC: No.

9 MEMBER APOSTOLAKIS: All these are  
10 always, you know, to eliminate this, eliminate that.

11 And it seems to me that the Risk Achievement Worth  
12 values you found should have alerted you to the fact  
13 that maybe certain things could be eliminated, not  
14 that you have to do it. It is your business, but it  
15 seems to me that the PRA for design, when I get a  
16 RAW 1, it tells me something.

17 MEMBER STETKAR: The only problem,  
18 George, is the symmetry and the desire to do this  
19 online preventive maintenance stuff is real problems  
20 if you have four trains and only three valves.

21 MEMBER APOSTOLAKIS: So, why, then, show  
22 the table?

23 MS. DIMITRIJEVIC: Well, this table  
24 wasn't to show you the Risk Achievement Worth. It

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 was to show you Fussil-Vasili, actually. And somehow  
2 the Risk Achievement sneaked in.

3 (Laughter.)

4 MEMBER APOSTOLAKIS: I still think --

5 MS. DIMITRIJEVIC: It would not be an  
6 important Risk Achievement Worth.

7 MEMBER APOSTOLAKIS: I still think that a  
8 lot of the RAW values you have there -- it doesn't  
9 have to be 1. If it is 1.2, come on. It is almost  
10 irrelevant.

11 So, I am not complaining about anything.

12 I am just saying that using PRA to design to make it  
13 safer is good and fine, and so on, but there is this  
14 other side, too.

15 It is none of our business here to do  
16 that. We are not trying to optimize anything. We  
17 are just looking at the safety aspects.

18 MS. DIMITRIJEVIC: That is very true. I  
19 just want to say this is why we are using two  
20 importance measures, because one shows us what will  
21 happen if this component is completely neglected.  
22 That shows us how much really achievement action, and  
23 so this is right.

24 And for example, this component has an

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 important Fussil-Vasili.

2 MEMBER APOSTOLAKIS: All the RAW would do  
3 would be an indication that you have to look into it.

4 MS. DIMITRIJEVIC: Yes.

5 MEMBER APOSTOLAKIS: And you do all that  
6 stuff. Because, otherwise, I can go to 10 redundant  
7 trains and still say, well, I get RAWs of 1, but it  
8 really doesn't matter because Fussil-Vasili -- now  
9 come on, it does matter.

10 Anyway, I just wanted it for the record.

11 MS. DIMITRIJEVIC: Believe me, I will be  
12 the first one to support such a --

13 MEMBER APOSTOLAKIS: But this is not the  
14 only use of the PRA.

15 MS. DIMITRIJEVIC: -- especially the  
16 design engineers.

17 MEMBER APOSTOLAKIS: Especially in the  
18 design phase.

19 MEMBER STETKAR: I ask something to  
20 follow up on that. You don't mention it here, but I  
21 was curious because I didn't read the whole story. I  
22 mean I don't think the whole story was in what I  
23 read.

24 Apparently, the original design had the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 cross-tie valves in the EFWS section header normally  
2 open. Is that right?

3 MS. DIMITRIJEVIC: Yes.

4 MEMBER STETKAR: And that you did a risk  
5 assessment with that configuration, is that right?

6 MS. DIMITRIJEVIC: That's true.

7 MEMBER STETKAR: And somehow -- and we  
8 can get into that perhaps tomorrow -- but somehow the  
9 design evolved into keeping the section cross-tie  
10 valves --

11 MS. DIMITRIJEVIC: True.

12 MEMBER STETKAR: -- normally closed,  
13 which now requires an operator action to manually  
14 open valves under certain situations.

15 MS. DIMITRIJEVIC: That's right.

16 MEMBER STETKAR: Is it correct that the  
17 current configuration has a higher risk than the  
18 former configuration?

19 MS. DIMITRIJEVIC: Yes, but very  
20 slightly. And actually, PRA supported closing those  
21 valves. We had a couple of reasons for that.

22 MEMBER STETKAR: You believe --

23 MS. DIMITRIJEVIC: We believe that,  
24 actually, by keeping those valves -- there is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 operator action, but he has six hours to perform it,  
2 plenty of time, indications, directions.

3 We were really more into preserving  
4 independence between the --

5 MEMBER STETKAR: I understand that, but I  
6 am thinking about, how does one use the risk  
7 assessment in the design process? I thought that I  
8 read somewhere that, with the valves closed, the core  
9 damage frequency increased by something like 6  
10 percent, which, to me, it is not a huge percent, but  
11 it is a measurable increase.

12 MS. DIMITRIJEVIC: But you will also find  
13 the flooding scenario, the EFW pipe fails. See, this  
14 is true. We may -- yes.

15 MEMBER STETKAR: You might help me. What  
16 I read, and what I made note of, was that the core  
17 damage frequency increased by 6 percent, but is that  
18 total core damage frequency from all contributors?

19 MS. DIMITRIJEVIC: We will check this for  
20 you because I am not sure the percentage of 6, but I  
21 will check. We analyzed both. We looked in the  
22 flood and the emergency --

23 MEMBER STETKAR: What I am worried is,  
24 you know, you talk about where we improved risk --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MS. DIMITRIJEVIC: Yes, yes.

2 MEMBER STETKAR: -- from the risk  
3 assessment, and I am worried about implementation of  
4 configurations that satisfy deterministic design  
5 rules that, indeed, might have a negative impact on  
6 risk.

7 In other words, is this an example of a  
8 place where, if, indeed, this configuration can be  
9 shown to increase the risk, where we may want to  
10 think more carefully about whether or not you want to  
11 keep those valves closed.

12 MS. DIMITRIJEVIC: I don't know, is it 6  
13 percent, and I will get back to you.

14 MEMBER STETKAR: I think it was. I can't  
15 --

16 MS. DIMITRIJEVIC: I will analyze it.

17 MEMBER STETKAR: Let me be careful about  
18 the number because I just pulled it off the top of my  
19 head, and I can't --

20 MS. SLOAN: Tim, did you want to say  
21 something?

22 MR. STACK: John, going through this,  
23 when we looked at the design originally, the  
24 advantage of them open is that you have four suction,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 four tanks all interconnected. Life is good. You  
2 don't have to take any action.

3 The problem is that, if you do look at it  
4 deterministically, and you are able to defeat it,  
5 break one of the lines, now I am draining all four  
6 tanks, and now I am challenging security questions  
7 on, well, if somebody was to breach the tank, how  
8 long before I can get to them before they deplete all  
9 the inventory from all four tanks?

10 So, you are balancing a deterministic  
11 consideration with a risk consideration.

12 MEMBER STETKAR: That's true, but if we  
13 actually believe that the risk assessment process can  
14 help us to improve the safety, overall safety, of the  
15 design --

16 MR. STACK: I think part of the issue,  
17 though, is the other deterministic consideration  
18 isn't modeled in the PRA, is what it comes down to.  
19 It never shows up.

20 MR. CORDOLIANI: Actually, if I can, I  
21 may have two comments to make on this point.

22 The first point is just for the number.  
23 I believe in the latest RAI we submitted on that  
24 sensitivity case we had a risk increase on total CDF

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 of 5 percent.

2 MEMBER STETKAR: Five percent? I just  
3 found my notes here. It is. Thanks.

4 MR. CORDOLIANI: That actually supports  
5 what Tim just discussed. If we look at the risk not  
6 only in Design Certification, which I know is the  
7 topic today, but also including the COLs and the  
8 aircraft crash scenarios, which we do in the COLs,  
9 that actually, having the valves open, was a very  
10 high contributor to like the aircraft crash risk.  
11 And having them closed resulted in a very high, a  
12 very significant decrease in risk.

13 So, if we look at that from a global  
14 perspective, not only the small increase in Design  
15 Certification, but, also, in the COLA, in our  
16 screening scenarios, it is even for sensitivity, the  
17 PRA pushes above that eventually.

18 MEMBER STETKAR: Okay. That helps me a  
19 lot because what I am hearing is AREVA saying that  
20 this is a good thing to keep the valves closed.

21 MS. DIMITRIJEVIC: Yes, yes. Actually,  
22 the PRA --

23 MEMBER STETKAR: From your total  
24 understanding of all types of risk contributors.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           When I read what I read, it sounded like  
2       this was perhaps an externally-imposed situation  
3       because somebody wanted to preserve some type of  
4       deterministic separation, where the risk assessment  
5       shows that that might not necessarily be a good thing  
6       to do.

7           But, as long as AREVA is supporting that,  
8       I feel much better.

9           MS. DIMITRIJEVIC:       Yes.       We are  
10      supporting it because it preserves spatial  
11      independence between the trains better, even if the  
12      numbers don't show up. Sometimes numbers don't show  
13      up which we believe is true.

14          And this is it, I think. Basically, we  
15      met the design safety goals, and we have shown all  
16      these outliers, and confirmed robustness of the PRA  
17      designs.

18          5:30.

19          CHAIR POWERS: We are on page 38.

20          (Laughter.)

21          MS. DIMITRIJEVIC: This is page 36.

22          MS. SLOAN: No, 38.

23          CHAIR POWERS:     Thirty-eight.     You're  
24      done.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MS. DIMITRIJEVIC: Ah, 38. That's what I  
2 meant, the last one.

3 (Laughter.)

4 The last page. Now I hope to say thank  
5 you.

6 (Laughter.)

7 Everybody but John.

8 (Laughter.)

9 MEMBER STETKAR: Just be careful. You're  
10 on the record. Don't say what you really want to  
11 say.

12 (Laughter.)

13 MS. DIMITRIJEVIC: Thank you.

14 MEMBER STETKAR: Okay.

15 CHAIR POWERS: We will recess now.

16 Tomorrow, the staff will respond to this  
17 portion, and then we will launch forward on the  
18 remainder of 60-some, actually, only 59 more slides.  
19 Episodically, staff will offer us their  
20 interpretation on all this.

21 MR. TESFAYE: That is true.

22 MR. WIDMAYER: Dr. Powers, are we going  
23 to address Chapter 17 again or are we going to just  
24 skip that, take back from AREVA, bring back from

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 AREVA?

2 CHAIR POWERS: Oh, well, to the extent  
3 that AREVA wants to provide additional information on  
4 Chapter 17, it will be useful to do that.

5 MS. SLOAN: At your discretion, and time  
6 permitting, we would like to provide some  
7 clarification.

8 CHAIR POWERS: This is not the last word  
9 on Chapter 19, I can assure you.

10 MS. SLOAN: Okay.

11 CHAIR POWERS: So, I am willing to  
12 sacrifice parts of Chapter 19, in recognition that we  
13 are going to get another shot at all this, I can  
14 assure you.

15 MEMBER APOSTOLAKIS: Or we can send  
16 Stetkar for a cup of coffee for 10 minutes.

17 (Laughter.)

18 CHAIR POWERS: John is doing exactly what  
19 I hope and pray he will do. I hope he will continue  
20 this. It has resulted in me having pages and pages  
21 of notes of things I need to understand better.

22 MEMBER STETKAR: You can just bang the  
23 gavel.

24 (Laughter.)

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 CHAIR POWERS: I encourage him to do more  
2 of this, and he is doing exactly what he is supposed  
3 to do.

4 With that, I am going to recess until  
5 8:30 tomorrow morning.

6 You might ask, why 8:30? That is our  
7 tradition.

8 (Laughter.)

9 (Whereupon, at 5:37 p.m., the proceedings  
10 in the above-entitled matter were adjourned for the  
11 day, to reconvene the following day, Friday, February  
12 19, at 8:30 a.m.)  
13  
14  
15  
16  
17  
18  
19  
20

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

A large, decorative graphic on the right side of the slide. It consists of two thick, blue, curved swooshes that originate from the left and curve towards the right. At the end of the swooshes is a large, solid blue five-pointed star. The entire graphic has a subtle drop shadow.

# UNISTAR NUCLEAR ENERGY


**Presentation to ACRS  
U.S. EPR™ Subcommittee  
Calvert Cliffs Nuclear Power Plant Unit 3  
FSAR Chapter 8  
February 18, 2010**



# Introduction

- Calvert Cliffs Unit 3 is the Reference COLA (RCOLA) for the U.S. EPR
  - Located in Calvert County, Maryland
  - Site of Operating PWR Units 1 and 2
- RCOLA submitted to NRC Docket in July 2007
- Current COLA Revision 6 submitted September 2009
- AREVA EPR Design Certification ACRS Meeting for Chapter 8 – Electric Power occurred on November 3, 2009







# Introduction

- RCOLA authored using 'Incorporate by Reference' (IBR) methodology
- To simplify document presentation and review, only supplemental information, or site-specific information, or departures from the U.S. EPR Design Certification are contained in the COLA

# Introduction



- One Departure from EPR FSAR for Calvert Cliffs Unit 3, Chapter 8
- No Open NRC SER items
- No Contentions
- COL Information Items
- Site-specific supplemental information
- Interface Items
- U.S. EPR FSAR ACRS Discussion Items
- NRC SER Confirmatory Items



# Introduction

- Today's Presentation was prepared by UniStar and is supported by AREVA (U.S. EPR Supplier), Bechtel (Architect Engineer) and PowerGEM (Grid Studies)
  - Mark Finley (UniStar)
  - Jean-Luc Begon (UniStar)
  - Sam Peach (Bechtel)
  - Dave Jenner (Bechtel)
  - James Reddy (AREVA)
  - Melvin Hess (AREVA)
  - Johnny Willis (PowerGEM)

# Introduction



- UniStar Nuclear Energy (UNE) is a joint venture between Constellation and EDF
- UNE draws on experienced staff from both parent companies to staff its organization
- UNE Engineering is responsible for the design of CC3 and develops the design primarily through contracts with Bechtel and AREVA
- UNE Engineering oversees the work of Bechtel and AREVA who have joined in a Consortium to develop the detailed design of the US EPR
- The Manager of the I&C and Electrical Group within UNE Engineering (Jean-Luc Begon) is from EDF and has experience on new construction for the last series of plants put in service in France (N4 series)
- Today Jean-Luc Begon will present the Offsite Systems and Sam Peach, the project Electrical Engineering Supervisor from Bechtel, will continue the presentation with Onsite Systems and Station Blackout Systems
- The focus of today's presentation will be on site-specific information that supplements the US EPR Design Certification



## Chapter 8, Electric Power Agenda

- Offsite Power Systems
  - COL Information Items/Interface Items
  - U.S. EPR FSAR ACRS Discussion Items
- Onsite Power Systems
  - Departure from the U.S. EPR FSAR
  - COL Information Items
  - Site-specific Supplemental Information
  - Interface Items
- Station Blackout
  - COL Information Items
  - U.S. EPR FSAR ACRS Discussion Items
- NRC SER Confirmatory items
- Conclusions



# Offsite Power Systems

## COL Information Items/Interface Items

- Item# 8.1-1  
Provide site-specific information describing the interface between the offsite transmission system, and the nuclear unit, including switchyard interconnections.
- Item# 8.2-1  
Provide site-specific information regarding the offsite transmission system and their connections to the station switchyard.
- Item# 8-1 (Interface)  
Off-site AC power transmission system connections to the switchyard and the connection to the plant power distribution system.
- Item# 8-2 (Interface)  
On-site AC power transmission system connections to the switchyard and the connection to the plant power distribution system.



# Offsite Power Systems

## COL Information Items/Interface Items

Items# 8.1-1, 8.2-1, 8-1 (Interface), 8-2 (Interface) & 8-3 (Interface) – continued

- Item# 8-3 (Interface)

Auxiliary power and generator transformer areas


The COL and interface Items are addressed as follows:

- Four 500kV overhead lines from the transmission system
- Six overhead lines to the main generator & auxiliary transformers

# Offsite Power Systems

## COL Information Items/Interface Items


Items# 8.1-1, 8.2-1 , 8-1 (Interface), 8-2 (Interface) & 8-3 (Interface) - continued



# Offsite Power Systems

## COL Information Items/Interface Items

Generator Items# 8.1-1, 8.2-1, 8-1 (Interface), 8-2 (Interface) & 8-3 (Interface)  
 Main Step-Up Transformer continued  
 Transformer




UNIT 3 SWITCHYARD

# Offsite Power Systems

## COL Information Items/Interface Items

Three Items# 8.1-1, 8.2-1, 8-1 (Interface), 8-2 (Interface) & 8-3 (Interface) -  
 Normal  
 Auxiliary  
 Transformers



UNIT 3 SWITCHYARD


# Offsite Power Systems

## COL Information Items/Interface Items

Items# 8.1-1, 8.2-1, 8-1 (Interface), 8-2 (Interface) & 8-3 (Interface) -

continued

One  
Emergency  
Auxiliary  
Transformer



One  
Emergency  
Auxiliary  
Transformer


UNIT 3 SWITCHYARD

# Offsite Power Systems

## COL Information Items/Interface Items

Items# 8.1-1, 8.2-1, 8-1 (Interface), 8-2 (Interface) & 8-3 (Interface) - continued

One Site  
Specific  
Transformer





# Offsite Power Systems

## COL Information Items

- Item# 8.2-2  
Provide site-specific information for the switchyard layout design.


The COL Item is addressed as follows:

- 500kV Air Insulated Switchyard,
- A breaker and a half configuration,
- 500 kV breakers equipped with two trip coils each connected to separate battery banks each supplied from a different battery charger,
- Any breaker can be isolated for maintenance or inspection without interruption of any line or bus.

# Offsite Power Systems

## COL Information Items

Item# 8.2-2 - continued




# Offsite Power Systems COL Information Items

## Item# 8.2-2 - continued

### Breaker and a half

- Three breakers
- Two circuits



UNIT 3 SWITCHYARD

# Offsite Power Systems

## COL Information Items



- Item# 8.2-4

Provide a site-specific grid stability analysis. The result of the analysis demonstrates that:

The Preferred Power Supply will not degrade below a level that will activate the Emergency Power Supply System degraded grid protection after any of the following contingencies:

- Calvert Cliffs Unit 3 turbine-generator trip
- Loss of the largest unit supplying the grid
- Loss of the largest transmission circuit or inter-tie
- Loss of the largest load on the grid

The transmission system will not subject the reactor coolant pumps to a sustained frequency decay of greater than 3.5 Hz/sec as bounded by the decrease in reactor coolant system flow rate transient and accident analysis described in Section 15.3.2.

# Offsite Power Systems

## COL Information Items

- Item# 8.2-4 - continued

The COL Item is addressed as follows:

- UniStar Nuclear Energy performed a Grid Stability Analysis using PJM database and provided the voltage and frequency response,
- For the four contingencies listed in the COL item, the analysis of the voltage and frequency curves confirmed that:
  - The Preferred Power Supply will not degrade below a level that will activate the Emergency Power Supply System degraded grid protection,
  - The transmission system will not subject the reactor coolant pumps to a sustained frequency decay of greater than 3.5 Hz/sec.



# Offsite Power Systems COL Information Items

- Item# 8.2-5  
Provide site-specific information for the protective devices that control the switchyard breakers and other switchyard relay devices.

The COL Item is addressed as follows:

- Redundant protection schemes for 500 kV lines, buses and equipment: primary and backup
- 500 kV breakers equipped with two trip coils each connected to separate battery banks
- Breakers are provided with a breaker failure scheme that isolates a breaker that fails to trip due to a malfunction



# Offsite Power Systems COL Information Items

- Item# 8.2-6  
Provide site-specific information for the station switchyard equipment inspection and testing plan.

The COL Item is addressed as follows:

- BGE observes Federal Energy Regulatory Commission requirements.
- Annual maintenance of battery system is performed, including quarterly visual inspections, verification of battery voltage, and verification of electrolyte level,
- The frequency of circuit breaker inspection is based on time in service and operating history,
- Thermography is used annually to identify potential thermal heating issues on buses, conductors, connectors and switches.



# Offsite Power Systems COL Information Items

- Item# 8.2-7
  - Provide site-specific information regarding the communication agreements and protocols between the station and the transmission system operator, independent system operator, or reliability coordinator/authority.
  - Provide a description of the analysis tool used by the transmission system operator to determine, in real time, the impact that the loss or unavailability of various transmission system elements will have on the condition of the transmission system to provide post-trip voltages at the switchyard. The information provided will be consistent with information requested in NRC Generic Letter 2006-02.



# Offsite Power Systems COL Information Items

- Item# 8.2-7 - Continued

The COL Item is addressed as follows:

- PJM Manual 03 ensures that nuclear plant operators are notified whenever post-contingency voltages are determined to be at or below acceptable limits,
- The PJM Energy Management System (EMS) models and operates the most restrictive substation limits for both actual and N-1 contingency conditions, PJM will notify Calvert Cliffs Unit 3 if the EMS results indicate nuclear substation voltage limits are or could be exceeded,
- Operators will receive classroom and simulator training for recognition of grid conditions, selecting the appropriate procedure for response.



# Offsite Power Systems COL Information Items

- Item# 8.2-8  
Provide site-specific information regarding indication and control of switchyard components.

The COL Item is addressed as follows:

- Administrative control of the switchyard breaker is shared between Calvert Cliffs Unit 3 and BGE. The circuit breakers are controlled remotely from the plant control room or by the system load dispatcher,
- The line protection for the Main Step-Up (MSU) Transformer and auxiliary transformers use the primary and back-up scheme to trip the switchyard breaker and isolate the fault.
- A circuit breaker failure scheme is provided. If a breaker fails to open coincident with a fault, tripping of all breakers adjacent to the failed one will occur.



# **Offsite Power Systems**

## **U.S. EPR FSAR ACRS Discussion Item**

- Is a Calvert Cliffs Unit 3 switchyard Failure Mode and Effects Analysis performed and what are the results?

The Discussion Item is addressed as follows:

- The switchyard Failure Mode and Effects Analysis is presented in the Calvert Cliffs Unit 3 FSAR Chapter 8.
- This analysis demonstrates that the following failures do not lead to a loss of offsite power supply:
  - Loss of a transmission circuit,
  - Loss of a bus,
  - Breaker failure to open coincident with a line fault.



# **Offsite Power Systems**

## **U.S. EPR FSAR ACRS Discussion Item**

- What is the Calvert Cliffs Unit 3 switchyard battery duty cycle and design basis?

The Discussion Item is addressed as follows:

- The battery load duty cycle is 8 hours, this is based on the SBO coping duration for Calvert Cliffs Unit 3.



## Chapter 8, Electric Power Agenda

- Offsite Power Systems
  - COL Information Items/Interface Items
  - U.S. EPR FSAR ACRS Discussion Items
- Onsite Power Systems
  - Departure from the U.S. EPR FSAR
  - COL Information Items
  - Site-specific Supplemental Information
  - Interface Items
- Station Blackout
  - COL Information Items
  - U.S. EPR FSAR ACRS Discussion Items
- NRC SER Confirmatory items
- Conclusions



# Onsite Power Systems

## Departure From U.S. EPR FSAR

### Normal Power Supply System

- The design of the site-specific Circulating Water System (CWS) cooling tower electrical distribution system for Calvert Cliffs Unit 3 results in increasing the size of the CWS cooling tower wet fans from 300 hp (each) to 350 hp (each). The total number of fans was also reduced from 56 to 48 fans, which resulted in no increase in total load (16,800 hp). These changes also resulted in four additional 6.9 kV switchgear, which replaced six 480 V load centers shown in the EPR design.



# Onsite Power Systems COL Information Item

- Item# 8.1-2  
Identify site-specific loading differences that raise EDG or Class 1E battery loading, and demonstrate the electrical distribution system is adequately sized for the additional load.

The COL Item is addressed as follows:

- Additional site-specific loads powered from the station EDGs are 22.3 kW per EDG.
- Additional site-specific loads powered from the Class 1E battery source are circuit breakers that require steady state control power of 0.04 kW.



# Onsite Power Systems COL Information Item

- Item# 8.3-2

Describe inspection, testing and monitoring programs to detect the degradation of inaccessible or underground power cables that support EDGs, offsite power, ESW and other systems that are within the scope of 10 CFR 50.65.

The COL Item is addressed as follows:

- Calvert Cliffs Unit 3 will develop and implement a program that will
  - Identify the inaccessible or underground cables that are within the scope of 10 CFR 50.65.
  - Inspect, test and monitor critical parameters to detect degradation of these cables. This program will comply with industry accepted standards.



# Onsite Power Systems COL Information Item


## Item# 8.3-2 continued

The detailed design consists of the following:

- The design features of manholes and ductbanks minimizes water intrusion:
  - Manhole tops above grade
  - Waterproofing on manhole assembly points
  - Waterproofing on duct bank system
- Design features to remove water:
  - Integral drains installed with duct bank runs
  - Sloped duct banks to lower elevation manholes
  - Permanent sump pumps in pre-determined manholes to remove water
- Cables will be underground with access only at manholes, above ground continuation of routes and termination points.




Item# 8.3-2 continued



# Onsite Power Systems

## COL Information Item

Item# 8.3-2 continued



Typical  
Ductbank  
Cross-section


**NOTE:** #4/0 AWG BARE COPPER GROUND CABLE (STRANDED) TO BE RUN ALONG WITH DUCT BANK AND CONNECTED TO THE GROUNDING SYSTEM AT EACH MANHOLE, ABOVE GROUND CONDUIT OR CABLE TRAY.

# Onsite Power Systems COL Information Item

Item# 8.3-2 continued



Manholes with  
Sump Pumps -  
Typical  
Arrangement



# Onsite Power Systems

## COL Information Item



- Item# 8.3-1

Monitor and maintain EDG reliability during plant operations to verify the selected reliability level target is being achieved as intended by RG 1.155.

- Calvert Cliffs Unit 3 will monitor and maintain EDG reliability to verify the selected reliability level goal of 0.95 is being achieved as intended by Regulatory Guide 1.155.
- Calvert Cliffs Unit 3 will have test and maintenance procedures and will have scheduled regular diesel generator maintenance.
- Surveillance testing and reliability monitoring programs designed to track EDG performance and to support maintenance activities.
- A maintenance rule program to ensure the target EDG reliability is being achieved and provides a capability for failure analysis and root-cause investigations.
- An information and data collection system that services the elements of the reliability program and that monitors achieved EDG reliability levels against target values.

# Onsite Power Systems

## Site-Specific Supplemental Information




### 1. Emergency Power Supply System (EPSS)

- Four divisions of EPSS distribution equipment for the UHS Makeup Water System are located in the Seismic Category I UHS Electrical Building. Each division is functionally independent and physically separated from the other divisions.
- The EPSS distribution equipment for the UHS Makeup Water System is located in the applicable division of the Seismic Category I UHS Electrical Building. Redundant equipment independence, including cabling independence and separation, described in the U.S. EPR is incorporated by reference (FSAR, Section 8.3.1.1.9).
- The EPSS 480 VAC MCC and distribution transformers for the UHS Makeup Water System are located in the applicable division of the UHS Electrical Building.

# Onsite Power Systems

## Site-Specific Supplemental Information

### Emergency Power Supply System continued





# **Onsite Power Systems**

## **Site-Specific Supplemental Information**

### 2. Normal Power Supply System


- The site-specific transformer was added to supply power to the Calvert Cliffs Unit 3 site-specific desalinization plant, wastewater treatment facility and CWS cooling tower dry fans.

# Onsite Power Systems

## Site-Specific Supplemental Information

### Normal Power Supply System continued

Site Specific  
Transformer




UNIT 3 SWITCHYARD

# Onsite Power Systems

## Site-Specific Supplemental Information

### Normal Power Supply System continued

Site Specific  
Transformer



# Onsite Power Systems

## Site-Specific Supplemental Information



### 3. Electrical Heat Tracing

- Freeze protection is incorporated at the individual system level using insulation for external tanks, tubing, instruments, and piping that may freeze during winter weather.
- Electrical heat tracing systems are installed to provide freeze protection for service components and process fluids, as required. Power for heat tracing is supplied from the onsite distribution system buses.



# Onsite Power Systems Interface Item

- Item# 8-4

Lightning protection and grounding system grid

This interface item is addressed as follows:

- The switchyard grounding grid is interconnected with the Nuclear Island and power block ground grid.
- The switchyard ground grid, including conductor sizing, matrix pattern spacing, and connection with the power block ground grid are determined using the regulatory guidance and industry standards described in U.S. EPR FSAR Section 8.3.1.3.8.
- The site-specific UHS Intake Structure and Electrical Building is designed with lightning protection and grounding consistent with U.S. EPR FSAR Tier 2, Section 8.3.1.3.5 and 8.3.1.3.8.



## Chapter 8, Electric Power Agenda

- Offsite Power Systems
  - COL Information Items/Interface Items
  - U.S. EPR FSAR ACRS Discussion Items
- Onsite Power Systems
  - Departure from the U.S. EPR FSAR
  - COL Information Items
  - Site-specific Supplemental Information
  - Interface Items
- Station Blackout
  - COL Information Items
  - U.S. EPR FSAR ACRS Discussion Items
- NRC SER Confirmatory items
- Conclusions



# Station Blackout COL Information Item

- Item# 8.2-3  
Provide site-specific information that identifies actions necessary to restore offsite power and use available nearby power sources when offsite power is unavailable.
- Item# 8.4-1  
Provide site-specific information that identifies any additional local power sources and transmission paths that could be made available to resupply the power plant following a loss of offsite power (LOOP).
- Item# 8.4-2  
Address the RG 1.155 guidance related to procedures and training to cope with SBO.

# Station Blackout COL Information Item



- Item# 8.2-3, 8.4-1 & 8.4-2 - Continued

The COL items are addressed as follows:

- Calvert Cliffs Unit 3 includes two redundant SBO diesel generators designed in accordance with 10 CFR 50.63 and Regulatory Guide 1.155. As such, reliance on additional offsite power sources as an alternate AC source is not required.
- There are no special local power sources that can be made available to re-supply the plant following a loss of the offsite power grid or an SBO.
- Procedures and training shall include the operator actions necessary to cope with a station blackout for at least the duration determined according to Regulatory Guide 1.155.
- Procedures and training shall include the operator actions necessary to restore normal decay heat removal once AC power is restored.
- Procedures and training shall also include actions to restore emergency AC power when the emergency AC power system is unavailable and actions that are necessary to restore offsite power.



# **Station Blackout**

## **U.S. EPR FSAR ACRS Discussion Item**

- Is there a Calvert Cliffs Unit 3 site-specific common large fuel oil tank that supplies the individual tanks dedicated to each EDG/SBODG?

The Discussion item is addressed as follows:

- The RCOLA incorporates by reference the EPR FSAR individual dedicated fuel oil tank design for each EDG/SBODG and does not have a common large bulk fuel oil tank. Therefore, there is no sharing of fuel oil systems for the EDGs or SBODGs.



## Chapter 8, Electric Power Agenda

- Offsite Power Systems
  - COL Information Items/Interface Items
  - U.S. EPR FSAR ACRS Discussion Items
- Onsite Power Systems
  - Departure from the U.S. EPR FSAR
  - COL Information Items
  - Site-specific Supplemental Information
  - Interface Items
- Station Blackout
  - COL Information Items
  - U.S. EPR FSAR ACRS Discussion Items
- **NRC SER Confirmatory items**
- Conclusions

# NRC SER Confirmatory Items

- NRC SER Confirmatory Items

1. Incorporate response to RAI 110, Question 08.02-3 (Grid Analysis) into COL FSAR Section 8.2.2.4.
  2. Incorporate response to RAI 170, Question 08.02-10 (Ductbank Water Level) into COL FSAR Section 3.8.4.1.8.
  3. Incorporate response to RAI 115, Questions 08.03.01-5 (Electrical Equipment Layout) into COL FSAR Sections 8.3.1.1.2, 8.3.1.1.7, Tables 8.3-1 & 8.3-3 and Figures 8.2-2, 8.3-2 & 8.3-3.
  4. Incorporate response to RAI 169, Question 08.03.01-15 (Lightning Protection and Grounding) into COL FSAR Section 8.3.1.3 and COL Part 10, Table 2.4-29.
  5. Incorporate response to RAI 184, Question 08.03.01-14 (Lightning Protection and Grounding) into COL FSAR Table 14.3-3.
  6. Incorporate response to RAI 163, Question 08.04-2 (SBO Coping Duration) into COL FSAR Sections 8.4.2.6.1 and 8.4.3.
- UniStar Nuclear Energy will incorporate the Chapter 8 NRC SER Confirmatory Items in revision 7 of the COLA.



## Chapter 8, Electric Power Agenda

- Offsite Power Systems
  - COL Information Items/Interface Items
  - U.S. EPR FSAR ACRS Discussion Items
- Onsite Power Systems
  - Departure from the U.S. EPR FSAR
  - COL Information Items
  - Site-specific Supplemental Information
  - Interface Items
- Station Blackout
  - COL Information Items
  - U.S. EPR FSAR ACRS Discussion Items
- NRC SER Confirmatory items
- **Conclusions**

# Conclusions



- COL Information Items, as specified by EPR FSAR, are addressed in Calvert Cliffs Unit 3 FSAR Chapter 8
- EPR Interface Items, as specified by EPR FSAR, are contained in the Calvert Cliffs Unit 3 FSAR Chapter 8
- One departure from EPR FSAR for Chapter 8 of the Calvert Cliffs Unit 3 COL
- No Open NRC SER items
- No Contentions
- Six NRC Confirmatory Items (Incorporation of RAI response into next COLA revision)



# Presentation to the ACRS Subcommittee

**UniStar Calvert Cliffs Nuclear Power Plant (CCNPP) Unit 3  
COL Application Review**

**Safety Evaluation Report**

**CHAPTER 8: ELECTRIC POWER**

February 18, 2010

# Order of Presentation

- **Joseph Colaccino** – EPR Projects Branch Chief
- **Surinder Arora** – Calvert Cliffs RCOLA Lead PM
- **UniStar** – RCOL Applicant
- **James Steckel** – Chapter 8 PM
- **Peter Kang** – Chapter 8 Technical Reviewer

# Major Milestones Chronology

07/13/2007	Part 1 of the COL Application (Partial) submitted
12/14/2007	Part 1, Rev. 1, submitted
03/14/2008	Part 1, Rev. 2, & Part 2 of the Application submitted
06/03/2008	Part 2 of the Application accepted for review (Docketed)
08/01/2008	Revision 3 submitted
08/14/2008	Review schedule presented in a public meeting
03/09/2009	Revision 4 submitted
06/30/2009	Revision 5 submitted
07/14/2009	Review schedule published
09/30/2009	Revision 6 submitted
04/12/2010	Phase 1 review completion milestone
April, 2010	Phase 2 reviews will be complete for Chapters 4,5,8,12, and 17
02/18/2010	ACRS begins Phase 3 review

# Review Schedule (Public Milestones)

Phase - Activity	Target Date
<b>Phase 1</b> - Preliminary Safety Evaluation Report (SER) and Request for Additional Information (RAI)	April 12, 2010
<b>Phase 2</b> - SER with Open Items	April 27, 2011
<b>Phase 3</b> – Advisory Committee on Reactor Safeguards (ACRS) Review of SER with Open Items	July 27, 2011
<b>Phase 4</b> - Advanced SER with No Open Items	January 31, 2012
<b>Phase 5</b> - ACRS Review of Advanced SER with No Open Items	May 17, 2012
<b>Phase 6</b> – Final SER with No Open Items	July 17, 2012

# ACRS Phase 3 Review Plan

## FSAR CHAPTERS GROUPED BY COMPLETION DATES

Group	Chapter(s)	Issue Date	ACRS Meeting
3A-1	8	1/6/2010	2/18/2010
3A-2	4 5 12 17	3/20/2010 3/22/2010 3/12/2010 3/19/2010	4/20/2010 & 4/21/2010
3B-1A	10 19	4/20/2010 4/19/2010	5/21/2010
3B1-B, 3B2, 3B3, 3B4	Remaining 12 Chapters		Meeting Dates not yet finalized

# Staff Review Team

- **Technical Staff**
  - ♦ **Peter Kang**  
Electrical Engineering Branch
  
- **Project Managers**
  - ♦ **Surinder Arora**
  - ♦ **James Steckel**

# Overview of Staff's Review

<b>SRP Section/Application Section</b>		<b>Number of RAI Questions</b>	<b>Number of SE Open Questions</b>
8.1	Introduction	1	0
8.2	Offsite Power System	10	0
8.3.1	Alternating Current (ac) Power Systems (Onsite)	14	0
8.3.2	Direct Current (dc) Power Systems (Onsite)	0	0
8.4	Station Blackout	2	0
Totals		27	0

# COL Review Topics of Interest

## Chapter 8.0 - Electric Power

### **CCNPP Unit 3 COL Application Review**

- COL application contains:
  - ♦ Interface Items
  - ♦ COL Information Items
  - ♦ Supplemental Information
- COL application identified no departures from the U.S. EPR FSAR
- COL application includes site-specific information on the following:
  - ♦ Electrical load increases
  - ♦ Offsite power system – offsite lines, grid, switchyard, auxiliary transformers
  - ♦ Onsite power system - UHS, cooling system, and additional power supply
  - ♦ SBO coping duration - offsite and onsite configurations, and EDG target reliability
- COL application review included:
  - ♦ Confirming all COL information items identified in U.S. EPR FSAR are addressed
  - ♦ Determining whether the COL FSAR information provided a sufficient level of detail for interconnection with the plant, onsite power system, and SBO coping duration

# COL Review Topics of Interest

## Section 8.1 - Site-Specific Information

### **Site-Specific Electrical Loads**

- Addition of site-specific UHS makeup water intake structure and UHS Electrical Building
  - ♦ Additional 22.3 kW for each EDG load for UHS makeup water structure
  - ♦ Additional .04 kW for each EUPS for circuit breaker control power
- Evaluation
  - ♦ No change to EDG size (9500 kW) from U.S. EPR FSAR, as the increased loads are still within the design margin of the EDGs (10% margin)
  - ♦ No change to EUPS size, as the dc control power requirement demand is within the design margin of the EUPS battery
- Result
  - ♦ Staff has no open items regarding COL site-specific information on electrical load increases that result from addition of UHS makeup water structure and UHS Electrical Building

# COL Review Topics of Interest

## Section 8.2 - Offsite Power System

- **Interface Requirements**
  - ♦ Switchyard layout design - grid connection to switchyard and connection to plant power distribution system
  - ♦ GL 2007-01 for inaccessible power cables installed in duct banks or underground
- **COL Information Items**
  - ♦ Offsite lines: Two 500 kV overhead extensions and two new 500 kV overhead extensions from existing CCNPP Units 1 and 2
  - ♦ GL 2006-02: Coordinates with PJM on operation, grid reliability, planning, and maintenance based on established communication and protocol. Performs transmission system analyses and equipment maintenance under agreement with BG&E. Follows NERC reliability standards and PJM practices
- **Supplemental Information**
  - ♦ Compliance with monitoring requirements in 10 CFR 50.65(a)(4) for inaccessible power cables installed in duct banks or underground
- **Result**
  - ♦ Staff finds that COL items for the offsite power system have been adequately addressed

# COL Review Topics of Interest

## Section 8.3 - Onsite Power System

- **Interface Requirements**
  - ♦ Onsite ac power connections between the switchyard and the plant
  - ♦ Lightning protection and grounding system grid
- **COL Information Items**
  - ♦ Monitor and maintain EDG reliability to meet reliability level target per RG 1.155
  - ♦ Cable management program prior to fuel load that will describe inspection, testing, and monitoring programs to detect degradation of inaccessible or underground power cables within scope of 10 CFR 50.65
- **Supplemental Information**
  - ♦ EPSS - added site-specific UHS makeup water system structure and Seismic Category 1 UHS Electrical Building
  - ♦ Four divisions of EPSS are located in an UHS Electrical Building and each division consists of an MCC and a distribution transformer
  - ♦ Each division is independent and physically separated, and the power system analysis verified the adequacy of voltage regulation and short circuit capability

# COL Review Topics of Interest

## Section 8.3 - Onsite Power System (cont.)

- Supplemental information - continued
  - ♦ NPSS - Supply voltage level for the cooling tower wet fans changed from 480 V specified in the U.S. EPR FSAR to 6.9 kV specified in the COL FSAR
    - The number of cooling tower wet fans decreased from 56 to 48
    - Each fan size increased to 350 hp at 6.9 kV, from 300 hp at 480 V
    - No change to total load of 16,800 hp
  - ♦ NPSS provides a backup power supply to desalination plant
  - ♦ Provided electric heat tracing for freeze protection and cathodic protection for buried carbon steel pipes for corrosion prevention
  - ♦ Establishes a cable management program prior to fuel load that will identify inaccessible or underground power cables and describe inspection, testing, and monitoring programs that will be implemented to detect cable degradation
- Result
  - ♦ Staff finds that COL items for the onsite power (EPSS and NPSS) system are adequately addressed

# COL Review Topics of Interest

## Section 8.4 - Station Blackout (SBO)

- COL information items
  - ♦ Indicate that there is no special local power source available to resupply power to the CCNPP Unit 3 following loss of the grid or during an SBO
  - ♦ Follow the RG 1.155 guidance related to procedures and training for operator actions in coping with SBO
- Supplemental Information
  - ♦ The COL applicant conducted the same SBO coping duration evaluation prescribed by U.S. EPR FSAR, and determined the coping duration to be eight hours
- Result

Staff finds that COL items for station blackout are adequately addressed

## **The COL FSAR for Calvert Cliffs Unit 3 Provides:**


- Sufficient details about site-specific safety-related load increases to EDG and EUPS that result from addition of the UHS makeup water intake structure and UHS Electrical Building
- Sufficient information about offsite power system interrelationships among the nuclear units, switchyards, and interconnection entities (PJM and NERC) to maintain grid reliability and stability and minimize a loss of offsite power
- Sufficient supplemental information to address onsite power system changes to accommodate the site-specific UHS system additions to EPSS, and the site-specific cooling tower wet fans and addition of a backup power supply in NPSS
- Necessary analysis to determine site-specific capability to withstand and recover from an SBO event of specified 8 hour duration

# Acronyms


- ac – alternating current
- BG&E – Baltimore Gas and Electric
- COL – combined license
- dc – direct current
- EDG – emergency diesel generators
- EPSS – Emergency Power Supply System
- EUPS – Emergency uninterruptable power supply
- FSAR – Final Safety Analysis Report
- GL – Generic Letter
- hp – Horsepower
- MCC – Motor Control Center
- NERC – North American Electric Reliability Corporation
- NPSS – Normal Power Supply System
- PJM – Pennsylvania, New Jersey, and Maryland Interconnection
- RAI – request for additional information
- RG – Regulatory Guide
- SBO – station blackout
- UHS – Ultimate Heat Sink

# **AREVA NP Inc.**

Presentation to ACRS  
U.S. EPR Subcommittee  
Design Certification Application  
FSAR Tier 2 Chapter 17



# Chapter 17, Quality Assurance and Reliability Assurance: Chapter Topics



- ▶ **17.1 Quality Assurance During Design**
- ▶ **17.2 Quality Assurance During the Operations Phase**
- ▶ **17.3 Quality Assurance Program Description**
- ▶ **17.4 Reliability Assurance Program**
- ▶ **17.5 Quality Assurance Program Description**
- ▶ **17.6 Description of Applicant's Program for Implementation of 10 CFR 50.65, the Maintenance Rule**



# **AREVA NP Inc.**


Presentation to ACRS U.S. EPR  
Subcommittee

Design Certification Application  
U.S EPR FSAR Tier 2 Sections  
17.1, 17.2, 17.3, and 17.5

**Michael P. Saniuk**  
**Manager, Project Quality U.S. EPR**




# Agenda



- ▶ **Summary of FSAR Tier 2, Sections 17.1, 17.2, 17.3, and 17.5**
- ▶ **Overview of AREVA NP Inc. Quality Assurance Plan (QAP) for Design Certification of the U.S. EPR Topical Report (ANP-10266A)**

# Chapter 17 Quality Assurance


## 17.1 – Quality Assurance During Design



- ▶ This information is provided in FSAR Tier 2, Section 17.5, Quality Assurance Program Description

# **Chapter 17 Quality Assurance**


## **17.2 – Quality Assurance During the Operations Phase**



- ▶ **FSAR Tier 2, Section 17.2 states that construction and operations phases are not applicable for the U.S. EPR design certification**
- ▶ **A COL applicant that references the U.S. EPR design certification will provide the Quality Assurance Programs associated with the construction and operations phases**

# Chapter 17 Quality Assurance


## 17.3 – Quality Assurance Program Description



- ▶ This information is provided in FSAR Tier 2, Section 17.5, Quality Assurance Program Description

# **Chapter 17 Quality Assurance**


## **17.5 – Quality Assurance Program Description**



- ▶ **The basis of the AREVA Quality Assurance Program Description is addressed in the “AREVA NP Inc. Quality Assurance Plan (QAP) for Design Certification of the U.S. EPR Topical Report”, ANP-10266**
- ▶ **AREVA Topical Report has been approved by the NRC in the SER dated April 26, 2007 and confirmed in the SER dated January 10, 2010**


# **Chapter 17 Quality Assurance**

## **17.5 – Quality Assurance Program Description**



- ▶ **The QAP is based on the eighteen-point criteria of 10 CFR 50, Appendix B, “Quality Assurance Criteria for Nuclear Power Plants and Fuel Reprocessing Plants,” and ANSI/ASME NQA-1-1994, “Quality Assurance Requirements for Nuclear Facility Applications”**
- ▶ **The QAP was prepared using the guidance provided in NUREG-0800, SRP, Section 17.5, “Quality Assurance Program Description – Design Certification, Early Site Permit and New License Applicants,” dated March, 2007.**
- ▶ **Consistent with the NRC Safety Evaluation Reports, NUREG-0800, SRP Section 17.5 and the U.S. EPR Topical Report, design certification does not include fabrication, erection, installation, or operations**

# **AREVA NP**




Presentation to ACRS  
U.S. EPR Subcommittee  
Design Certification Application  
FSAR Tier 2 Section 17.4 Reliability  
Assurance Program

John McEntire,  
U.S. EPR Reliability Assurance Program Lead



# **Chapter 17 Quality Assurance**


## **17.4 – Reliability Assurance Program**



- ▶ **Implementation enhances safety by focusing design resources on risk-significant SSCs and maintaining the reliability of such SSCs during the design and operating stages of the plant**
- ▶ **AREVA NP is responsible for developing and implementing the design stage of the RAP which includes:**
  - ◆ **Scope**
  - ◆ **Design consideration**
  - ◆ **Objectives**
  - ◆ **Identification and prioritization of SSCs**
  - ◆ **RAP organization**
  - ◆ **Expert panel process**

# Chapter 17 Quality Assurance


## 17.4 – Reliability Assurance Program



- ▶ **Applies to the systems, structures, and components (SSCs) that are identified as risk-significant (or significant contributors to plant safety) as determined by using:**
  - ◆ **Probabilistic Risk Assessment (PRA)**
    - Industry Operating Experience
    - Component Failure Databases
  - ◆ **Deterministic Methods**
    - Expert Panel
- ▶ **The RAP is implemented in two stages:**
  - ◆ **Design stage**
  - ◆ **Operating stage**

## **Chapter 17 Quality Assurance**


### **17.4 – Reliability Assurance Program**




- ▶ **RAP Stage 1 (Design Stage): Applies to RAP activities up to the initial fuel load, including the Design Certification (DC) phase and the Site-Specific phase**
- ▶ **In the DC phase a list of risk-significant systems and structures was developed with the use of the PRA and deterministic insights**

# Chapter 17 Quality Assurance

## 17.4 – Reliability Assurance Program




- ▶ The U.S. EPR PRA was used for identifying and prioritizing SSCs in the scope of the Design Certification based on risk-significance



- ▶ Deterministic insights were incorporated through the use of an Expert Panel
  - ◆ The Expert Panel performed a qualitative review of the systems and structures to develop the final list of systems and structures in the scope of the Design Certification included in the RAP

# Chapter 17 Quality Assurance

## 17.4 – Reliability Assurance Program




### ► Sample results of systems and structures

Chemical & Volume Control System; incl. RCP Seal Injection	PRA important to the RAP
Extra Borating System	Added by the Expert Panel
Safety Injection / Residual Heat Removal System	PRA important to the RAP
Emergency Power Generating Buildings	Added by the Expert Panel
Component Cooling Water System	PRA important to the RAP
Safety Chilled Water System	PRA important to the RAP
Main Steam System	PRA important to the RAP
Containment Building Ventilation System	Added by the Expert Panel
Emergency Diesel Generator Set	PRA important to the RAP
Class 1E Uninterruptible Power Supply System	PRA important to the RAP
Boron Concentration Measurement System	Added by the Expert Panel
Protection System	PRA important to the RAP
Reactor Control, Surveillance & Limitation System	Added by the Expert Panel

- ◆ A complete list of Design Certification scope systems and structures included within the RAP can be found in the U.S. EPR FSAR Section 17.4

# Chapter 17 Quality Assurance

## 17.4 – Reliability Assurance Program



### ► Site-Specific Phase


- ◆ In the Site-Specific phase the Combined License (COL) applicant will introduce the plant site-specific design information to the RAP process
  - A COL applicant that references the U.S. EPR Design Certification will identify the site-specific SSCs within the scope of the RAP

### ► Detailed Design

- ◆ The RAP is an integral part of the design process and is implemented during the detailed design phase so that the important U.S. EPR reliability assumptions of the PRA are considered in the areas of:
  - Design
  - Procurement
  - Fabrication
  - Construction
  - Preoperational testing activities and programs

# Chapter 17 Quality Assurance

## 17.4 – Reliability Assurance Program



### ► RAP Stage 2 (Operating Stage):

#### ◆ The Operating Stage is outside the scope of the Design Certification

- A COL applicant that references the U.S. EPR Design Certification will provide the information requested in Regulatory Guide 1.206, Section C.I.17.4.4 (RAP information needed in a COL application)

# AREVA NP


Presentation to ACRS  
U.S. EPR Subcommittee  
Design Certification Application  
FSAR Tier 2 Section 17.6 Description of  
Applicant's Program for Implementation of  
10 CFR 50.65, the Maintenance Rule

Sandra Sloan, Manager, New Plants Regulatory Affairs



## **Chapter 17 Quality Assurance**

### **17.6 – Description of Applicant’s Program for Implementation of 10 CFR 50.65, the Maintenance Rule**



- ▶ **The Maintenance Rule is an operational program required under 10 CFR 50.65 “Requirements for Monitoring the Effectiveness of Maintenance at Nuclear Power Plants”**
  - ◆ **A COL applicant that references the U.S. EPR design certification will describe the program for Maintenance Rule implementation**



# Presentation to the ACRS Subcommittee

**AREVA U.S. EPR Design Certification Application Review**

**Safety Evaluation Report with Open Items**

**Chapter 17: Quality Assurance**

February 18, 2010

# Staff Review Team

- **Technical Staff**

- ♦ Kerri Kavanagh, Senior Reactor Engineer  
Quality and Vendor Branch 1
- ♦ Hanh Phan, Senior Reliability & Risk Engineer  
PRA and Severe Accidents Branch

- **Project Managers**

- ♦ Getachew Tesfaye
- ♦ Tarun Roy

# Overview of Design Certification Application

SRP Section/Application Section		Number of RAI Questions	Number of SE Open Items
17.0	Quality Assurance and Reliability Assurance	0	0
17.1	Quality Assurance During Design	0	0
17.2	Quality Assurance During the Operations Phases	0	0
17.3	Quality Assurance Program Description	0	0
17.4	Reliability Assurance Program	22	1
17.5	Quality Assurance Program Description	2	1
17.6	Description of Applicant's Program for Implementation of 10 CFR 50.65, the Maintenance Rule	2	0
<b>Totals</b>		<b>26</b>	<b>2</b>

# Description of SE Open Items

- **RAI 227, Question 17.5-2:** NRC staff inspection of the applicant's implementation of the QAPD as it relates to the U.S. EPR project. The NRC inspection is currently planned for the week of April 12, 2010
- **RAI 355, Question 17.04-23:** RAP ITAAC wording in U.S. EPR FSAR Tier 1, Table 3.2.1 needs to be revised to conform to the wording in ISG-018 "Reliability Assurance Program"

# Technical Topics of Interest

## **Section 17.5 – Quality Assurance Program Description**

- AREVA Topical Report ANP 10266A, Revision 2
- Approved by NRC staff (April 26, 2007)
- TR ANP 10266A, Revision 2, is based on American Society of Mechanical Engineers (ASME) NQA-1-1994

# Technical Topics of Interest

## Section 17.4 – Reliability Assurance Program

- Risk-significant SSCs
  - ♦ PRA
    - $FV \geq 0.005$
    - $RAW \geq 2$
    - $RAW$  (common cause events)  $\geq 20$
  - ♦ Expert Panel
- Combined License Information Items
  - ♦ 17.4-1 – “[a] COL applicant that references the U.S. EPR design certification will identify the site-specific SSCs within the scope of the RAP”
  - ♦ 17.4-2 – “[a] COL applicant that references the U.S. EPR design certification will provide the information requested in Regulatory Guide 1.206, Section C.I.17.4.4”
- SE Open Item
  - ♦ RAP ITAAC wording

# Technical Topics of Interest – Open Item

## U.S. EPR FSAR, Tier 1, Table 3.2-1— Reliability Assurance Program ITAAC

Commitment Wording	Inspections, Tests, Analyses	Acceptance Criteria
A Reliability Assurance Program exists and provides reasonable assurance that the overall plant reliability is maintained.	Inspection will be performed for the existence of a Reliability Assurance Program.	A Reliability Assurance Program provides reasonable assurance that the overall plant reliability is maintained.

## Draft DC/COL-ISG-018 - Inspections, Tests, Analyses and Acceptance Criteria

Design Commitment	Inspections, Tests, Analyses	Acceptance Criteria
Ensure that the design of systems, structures, and components within the scope of the reliability assurance program (RAP SSCs) is consistent with the risk insights and key assumptions (e.g., SSC design, reliability, and availability).	An analysis will confirm that applicable reliability assurance activities for the D-RAP have been used in the design of all RAP SSCs.	Analysis verifies that all RAP SSCs have been designed in accordance with the applicable reliability assurance activities for the D-RAP.

# ACRONYMS

- **ASME** - American Society of Mechanical Engineers
- **CFR** - Code of Federal Regulations
- **COL** - combined license
- **FSAR** - final safety analysis report
- **FV** - Fussell-Vesely
- **ISG** - interim staff guidance
- **ITAAC** - inspections, tests, analyses, and acceptance criteria
- **MR** - maintenance rule
- **NEI** - Nuclear Energy Institute
- **PRA** - probabilistic risk assessment
- **QAPD** - quality assurance program description
- **RAI** - request for additional information
- **RAP** - reliability assurance program
- **RAW** - risk achievement worth
- **SE** - safety evaluation
- **SRP** - Standard Review Plan
- **SSCs** - structures, systems, and components
- **TR** - topical report

# Questions?



# **AREVA NP Inc.**

Presentation to ACRS U.S. EPR  
Subcommittee  
Design Certification Application  
FSAR Tier 2 Chapter 19:  
Probabilistic Risk Assessment and  
Severe Accident Evaluation

# 19.1 – Probabilistic Risk Assessment Level 1

Dr. Vesna Dimitrijevic  
U.S. EPR PRA Group

# Chapter 19 PRA and Severe Accidents

## U.S. EPR PRA Risk Measure Goals



<b>Risk Measures</b>	<b>Commission's Safety Goals</b>	<b>U.S. EPR Probabilistic Goals</b>
<b>Core Damage Frequency</b>	<b>CDF &lt; 1E-4 per year</b>	<b>CDF &lt; 1E-5 per year</b>
<b>Large Release Frequency</b>	<b>LRF &lt; 1E-6 per year</b>	<b>LRF &lt; 1E-6 per year</b>
<b>Conditional Containment Failure Probability</b>	<b>CCFP <math>\leq</math> 0.1</b>	
<b>Scope</b>		<b>Internal and external events for all operating modes (excluding seismic and sabotage)</b>

# Chapter 19 PRA and Severe Accidents

## Design Certification PRA

- ▶ **Objective is to demonstrate robustness of U.S. EPR design and that probabilistic goals are met**
- ▶ **Specificity of the U.S. EPR DC PRA:**
  - ◆ **Detailed PRA description and results are provided in U.S. EPR FSAR Section 19.1**
  - ◆ **Analysis is performed considering Reg. Guide 1.200/ASME PRA Standard**
  - ◆ **Bounding/realistic-type assumptions are used where detailed design information is not available**


# Chapter 19 PRA and Severe Accidents

## PRA Scope

- ▶ **Level 1 – Core Damage Frequency**
- ▶ **Level 2 – Large Release Frequency**
- ▶ **Level 3 – Offsite Dose Consequence (supports Environmental Report and SAMDA)**
- ▶ **Scope of initiating events for design certification**
  - ◆ **Internal events (at-power and low power/shutdown)**
  - ◆ **Internal hazards (Internal flood and internal fire events, at-power and limited scope at shutdown)**
  - ◆ **External events**
    - PRA-based seismic margin assessment
    - Other external events – high level, qualitative evaluation

# Chapter 19 PRA and Severe Accidents

## PRA Technical Adequacy




- ▶ **Self assessment and formal peer review are performed against ASME Standard / RG 1.200, as applicable to DC**
- ▶ **Documentation development and revisions are controlled by procedures requiring independent review/checking**
- ▶ **Corrective action process is in place if previously used information is changed or in error**
- ▶ **PRA team is participating in technical meetings and exchange with European counterparts working with similar designs**

# Chapter 19 PRA and Severe Accidents Design Features Contributing to Low Risk

- ▶ **Four independent safety trains in separate buildings, which provide physical separation against internal & external hazards**
- ▶ **Extended airplane crash protection provided to reactor building, two safeguard buildings and fuel building**
- ▶ **In-containment refueling water storage tank**



# Chapter 19 PRA and Severe Accidents Design Features Contributing to Low Risk



- ▶ **Four Emergency Diesel Generators (one EDG for each safety division)**
- ▶ **Two Station Blackout Diesel Generators**
  - ◆ Divisions 1 and 4 each contain one SBO diesel
  - ◆ 2 LHSI pumps can be powered from SBO diesels
  - ◆ SBO diesels independence/diversity from EDGs to be achieved by different/diverse models, control power, HVAC, engine cooling, fuel system, and location
- ▶ **RCP Stand-Still Seal System: a pneumatic, “metal-to-metal” seal that provides back-up seal capability independent of the normal seal and can prevent RCP shaft leakage**

# Chapter 19 PRA and Severe Accidents

## Data Sources

- ▶ **Applicability of European data is justified via comparison with US data/experience**
- ▶ **Data sources used (component failure rates)**
  - ◆ **EGG-SSRE-8875 – Generic Component Failure Database for Light Water and Liquid Sodium Reactors, EG&G Idaho, 1990**
  - ◆ **ZEDB - Centralized Reliability and Events Database of Reliability Data for Nuclear Power Plant Components, that includes all German nuclear plants, one Dutch and one Swiss unit**
  - ◆ **EIREDA95 – European Industry Reliability Data Bank, EIReDA, Volume 2, 1977/1993**
- ▶ **Other data sources used**
  - ◆ **CCF Parameters: NUREG/CR-6819 2003 Update**
  - ◆ **Initiating Event Frequencies: NUREG/CR-6928 and CR-5750**
  - ◆ **LOOP Frequency and Recovery: NUREG/CR-6890**

# Chapter 19 PRA and Severe Accidents Methods and Codes

## ► Human Reliability Analysis

- ◆ ASEP (NUREG/CR-4772) for pre-initiator HRA
- ◆ SPAR-H (NUREG/CR-6883) for post-initiator HRA
- ◆ HRA Calculator for implementation

## ► Thermal hydraulic codes supporting Success Criteria

- ◆ MAAP4 used for most success criteria cases
- ◆ S-RELAP5 used for benchmarking of selected cases

## ► Model quantification

- ◆ Risk Spectrum® PSA Professional
- ◆ Cutoff: 1E-20/yr absolute, 1E-6 relative

# Chapter 19 PRA and Severe Accidents

## Scope of Initiating Events

- ▶ **Transients** GT, LOC, LOMFW, LBOP, 31BDA
- ▶ **LOCAs** LLOCA, MLOCA, SLOCA, ISLOCAs
- ▶ **Loss of Support** LOOP, CCW, ESW
- ▶ **SGTR** SGTR, IND SGTR
- ▶ **SLB** SLBI, SLBO, MSSV
- ▶ **ATWS**
- ▶ **FLOOD** SBs, TB, FB, RB Annulus, ESWS Pump Building
- ▶ **FIRE** SBs, MCR, Cable Spreading Room, TB, FB, Switchgear Building, MS/MF Valve Room, Transformer Yard, ESWS Pump Building, Pressurizer Compartment

# Chapter 19 PRA and Severe Accidents

## Examples of Systems Modeled

- ▶ **Reactivity Control** EBS
- ▶ **Heat Removal** MFWS, SSS, EFWS
- ▶ **RCS Integrity** RCP Seals, Pressurizer Relief System
- ▶ **Inventory Control** IRWST, LHSI, MHSI, ACC
- ▶ **Long Term Cooling** SAHRS
- ▶ **Support Systems**
  - ◆ **Cooling Chain** ESWS, UHS, CCWS, CLCWS
  - ◆ **HVAC** SCWS, OCWS, HVAC
  - ◆ **Electrical** ac, dc Power Supply System, EDG, SBO DG
  - ◆ **I&C** RPS, ESFAS

# Chapter 19 PRA and Severe Accidents

## Digital I&C Modeling Approach

- ▶ **Safety I&C platform is AREVA Teleperm XS (TXS)**
- ▶ **Detailed model of Protection System (RPS and ESFAS)**
  - ◆ 4 division redundancy
  - ◆ 2 independent subsystems per division provide “A/B” functional diversity
- ▶ **Simplified models of other I&C systems**
  - ◆ Safety and process automation systems (SAS, PAS)
- ▶ **Diverse actuation system (DAS) for diversity and defense in depth (D3)**
  - ◆ Reactor trip backup modeled
  - ◆ ESFAS backup not modeled



# Chapter 19 PRA and Severe Accidents I&C Operating Experience Data

- ▶ **TXS has been operating for over 10 years in safety I&C systems world-wide**
  - ◆ 39 plants at 24 sites
  - ◆ 11 countries
  - ◆ 10 different Rx designs
- ▶ **About 2000 computer processor modules in service with over 92 million hours of operating experience (thru 2008)**
- ▶ **Proven multi-pronged defense against Software CCF**
  - ◆ **High-quality software development life-cycle**
    - Minimize software defects
  - ◆ **Operating system defensive features**
    - Minimize failure triggers
    - Limit failure consequence (failure propagation)
  - ◆ **Functional diversity**

# Chapter 19 PRA and Severe Accidents

## Software Common Cause Failures

- ▶ **Model includes two aspects of potential software failure:**
  - ◆ Operating system CCF to capture global failure of common platform software
  - ◆ Application software CCF to capture errors in functional specifications or analytical knowledge
- ▶ **Results are sensitive to assumptions for SWCCF**
  - ◆ Not unexpected – precise SW CCF estimates are not possible
  - ◆ Model provides good basis for sensitivity analysis
  - ◆ Shows relative importance of software
- ▶ **Diversity and defense in depth (D3) functions in DAS will reduce uncertainty**


# Chapter 19 PRA and Severe Accidents

## U.S. EPR PRA – Summary of Results


Initiator Group	Plant Operating State	CDF [1/yr]	LRF [1/yr]	CCFP
Internal Events	At power	2.9E-07	2.2E-08	0.08
Internal Floods	At power	6.1E-08	1.1E-09	0.02
Internal Fires	At power	1.8E-07	3.6E-09	0.02
Total at-power	At power	5.3E-07	2.6E-08	0.05
Internal Events	Shutdown	5.8E-08	5.7E-09	<0.1

# Chapter 19 PRA and Severe Accidents Total at Power CDF Uncertainty Results

Cumulative Distribution for all Internal, Fire and Flood Events CDF



# Chapter 19 PRA and Severe Accidents Initiating Events Contribution to Total at- Power CDF



**Total At Power CDF =  $5.3E-07/\text{yr}$**

# Chapter 19 PRA and Severe Accidents


## Selected Core Damage Cutsets/Sequences



Cutset Group	Contribution of Cutset Group to Internal Event CDF (%)	Representative Sequence of Cutset Group
#1 and #18	22.5%	Initiator - LOOP
		Failure to recover offsite power within 2 hours
		CCF of the air cooled SCWS chiller units to start
		Operator fails to recover room cooling locally
#9	3.8%	Initiator - Small LOCA (0.6 to 3-inch diameter)
		CCF of MSRIV to open
		Operator fails to initiate feed and bleed for Small LOCA
#17	3.5%	Initiator - Total Loss of Main Feedwater
		Stuck control rods
#8	3.3%	Initiator - Small LOCA (0.6 to 3-inch diameter)
		CCF of MHSI pumps to run
		Operator fails to initiate fast cooldown for Small LOCA
#16	3.0%	Initiator - Steam Generator Tube Rupture
		MSIV fails to close on the faulted steam generator side
		Operators fails to initiate cooldown and align RHR


# Chapter 19 PRA and Severe Accidents Systems Importance

System Contribution to at Power CDF



# Chapter 19 PRA and Severe Accidents

## Component Ranked By FV, Internal Events CDF



Rank	System	Description	FV	RAW
1	ELEC	ELEC, Emergency Diesel Generator Train	<b>0.187</b>	2.5
2	SCWS	SCWS, Chiller Unit Trains 1 and 4	<b>0.168</b>	18.7
3	ELEC	ELEC, SBO Diesel Generator Train	<b>0.058</b>	1.8
4	ELEC	ELEC, 250V 1E 2-hr Battery Train	<b>0.050</b>	23
5	SIS/RHRS	MHSI, Motor Driven Pump Train	<b>0.044</b>	1.4
6	EFWS	EFWS, Motor Driven Pump Trains 1 and 4	<b>0.042</b>	3.3
7	MSS	MSS, Main Steam Isolation Valve Train 4	<b>0.034</b>	14.8
8	SIS/RHRS	LHSI, CL First SIS Isolation Check Valve	<b>0.028</b>	1.1
9	MSS	MSS, Main Steam Relief Isolation Valve Train	<b>0.026</b>	1.0
10	SCWS/HVAC	SCWS, Motor Driven Safety Chiller Pump Trains 1 and 4	<b>0.020</b>	17.8


# Chapter 19 PRA and Severe Accidents

## HEPs Ranked by RAW, Internal Events CDF

Rank	Basic Event	Description	Nominal Value	RAW	FV
1	OPF-SAC1	Operator Fails to Recover Room Cooling Locally	1.3E-02	<b>33.6</b>	0.430
2	OPE-RHR	Operator Fails to Perform Cooldown and Initiate RHR for ISLOCA, SLB and SGTR	1.0E-03	<b>27.2</b>	0.027
3	OPE-FB	Operator Fails to Initiate Feed & Bleed for Transient	5.0E-04	<b>16.4</b>	0.008
4	OPF-SGTR	Operator Fails to Isolate SGTR and Initiate Cooldown	2.0E-03	<b>7.1</b>	0.012
5	OPF-XTLDSBO	Operator Fails to Connect and Load SBODGs to Div 1 and 4	6.0E-04	<b>5.5</b>	0.003
6	OPF-SAC2	Operator Fails to Start Maintenance HVAC Trains After Failure of Normal SAC Safety Train	2.0E-04	<b>3.4</b>	0

# Chapter 19 PRA and Severe Accidents

## CCFs Ranked by RAW – Internal Event CDF



Rank	System	Description	RAW
1	ELEC	CCF of Safety-related Batteries on Demand	72,580
2	I&C	SW CCF of TXS operating system or multiple diversity groups	35,340
3	IRWST	CCF of IRWST Sump Strainers - Plugged	5,341
4	SIS/RHRS	CCF to Open LHSI/MHSI Common Injection Check Valves	5,140
5	I&C	SW CCF of Protection System diversity group B	5,128
6	I&C	CCF of ALU-B Protection System Computer Processors (Non-Self-Monitored)	4,998
7	I&C	CCF of ALU-B Protection System Computer Processors (Self-Monitored)	4,971
8	HVAC	CCF to Run Normal Air Exhaust/ Supply Fans	4,967
9	SCWS	CCF of SCWS Pumps to Run	4,911
10	I&C	CCF of APU-4 Protection System Computer Processors (Non-Self-Monitored)	3,756


# Chapter 19 PRA and Severe Accidents

## Internal Flood Analysis

- ▶ In the absence of detailed spatial information (equipment, pipe routing, etc.) conservative flood analyses are performed. In general flood scenarios are modeled to disable a whole building
- ▶ Frequencies are calculated based on the estimated number of segments (EPRI TR-102266 method) from system P&IDs.
- ▶ The following buildings are evaluated:
  - ◆ Safeguard Buildings (SB - Mechanical area), Fuel Building (FB), Turbine Building (TB), ESW Pumphouses, RB Annulus

# Chapter 19 PRA and Severe Accidents

## Flooding PRA Results Summary




*Flood CDF:  $6.1E-08/\text{yr}$*

# Chapter 19 PRA and Severe Accidents Internal Fire Events Analysis

- ▶ **In the absence of detailed spatial information (equipment, combustible loads, cable routing, etc.) conservative fire analyses are performed:**
  - ◆ The worst scenario is postulated for each location and total area fire frequency is applied. A fire ignition is considered to grow to a fully developed fire (no severity factors).
  - ◆ Very limited credit is given to fire suppression: manual fire suppression credited in main control room only
- ▶ **Main source of fire ignition frequencies: NRC Research paper RES/OERAB S02-01 (based on generic locations). Use of NUREG/CR-6850 (component-based) frequencies would require multiple assumptions on component locations. Comparison shows good agreement.**
- ▶ **Fire areas evaluated: SB (Electrical/Mechanical areas), MCR, CSR, FB, TB, Switchgear building, MS valve room, Pressurizer compartment, ESWS pumphouses, Transformer yard**

# Chapter 19 PRA and Severe Accidents

## Fire PRA Results Summary




# Chapter 19 PRA and Severe Accidents

## LPSD Analysis Scope

- ▶ **Representative set of Plant Operating States (POS) conservatively chosen and modeled (defined on next slide)**
- ▶ **Representative set of initiating events chosen and modeled (includes specific IE such as drain down during midloop)**
- ▶ **Some new & modified fault trees (e.g., RHR protective trip, SIS signal)**
- ▶ **Operator actions: new and modified (e.g., RHR start, feed & bleed)**
- ▶ **Equipment from LPSD model included in seismic margins equipment list for fragility analysis to ensure no vulnerabilities**
- ▶ **Fire and Flood are qualitatively evaluated**

# Chapter 19 PRA and Severe Accidents

## LPSD Plant Operating States (POS)



POS	Description	Equivalent TS Mode
A	Full Power to Hot Shutdown (T > 550 F)	1 & 2 (Power and Startup)
B	Steam Generator Heat Removal (T > 248 F)	3 & 4 (Hot Standby & Hot Shutdown)
CA	RHR Heat Removal with Level in Pressurizer (T ~ 248 to 131 F)	4 & 5 (Hot Shutdown and Cold Shutdown)
CB	RHR Heat Removal at Mid-loop with RPV Head On (T ~ 131 F)	5 (Cold Shutdown)
D	RHR Heat Removal at Mid-loop with RPV Head Off (T ~ 131 F)	6 (Refueling)
E	Reactor Cavity Flooded (T ~ 131 F)	6 (Refueling)
F	Core off loaded to spent fuel pool (not in the scope)	6 (Refueling – Core offload)


► **POS A and B included in Power Operation PRA**

► **Remaining POS included in LPSD PRA**

# Chapter 19 PRA and Severe Accidents

## LPSD PRA Results Summary

Initiator Contributions to Shutdown CDF



Shutdown CDF:  $5.8E-08/\text{yr}$

# Chapter 19 PRA and Severe Accidents

## U.S. EPR – PRA-Based Seismic Margin Assessment Methodology



- ▶ **PRA-Based Margins Assessment is performed using internal events PRA model**
- ▶ **Hazard Input: U.S. EPR™ Certified Seismic Design Response Spectra (CSDRS) is based on EUR Ground Motion Spectral Shape Anchored at 0.3g pga**
- ▶ **Goal - Show margin in design (HCLPF) of at least 1.67 \* CSDRS, 0.5g pga**
- ▶ **No vulnerabilities identified, fragility results and assumptions to be used during design development**

# Chapter 19 PRA and Severe Accidents

## PRA-Based Seismic Fragility Assessment

- ▶ **Median Ground Motion Capacity (pga) of Component and its Uncertainties (randomness & uncertainty parameters) are estimated.**
- ▶ **Detailed Seismic Analysis and Equipment Qualification is not completed; fragilities are based mostly on design and qualification criteria (reasonably achievable), assumptions documented to support design development.**
- ▶ **COL Item 19.1-9 ensures that assumed HCLPF values are met by as-built plant**


# Chapter 19 PRA and Severe Accidents Other External Events

- ▶ **For DC – Assessment of other external events limited to high-level qualitative review based on EPR external design and siting requirements:**
  - ◆ **High Winds and Tornadoes**
  - ◆ **External Flood**
  - ◆ **External Fires**
  - ◆ **Aircraft Crash**

# Chapter 19 PRA and Severe Accidents

## Cumulative Initiator Contribution


Initiator Cumulative Contribution to Total CDF at Power



*At Power Total CDF = 5.3 E-07/yr*

# Chapter 19 PRA and Severe Accidents

## POS Contributions to CDF



**Total CDF =  $5.8 \text{ E-07/yr}$**

# Chapter 19 PRA and Severe Accidents Sensitivity Studies – Total at power CDF

Sensitivity Case Description	SC CDF [1/yr]	Delta CDF [%]
Base Case	5.3E-07	0%
W/O Preventive Maintenance	3.1E-07	-42%
W/O Common Cause Groups	3.7E-07	-30%
All HEPs Set to 5% Value	2.2E-07	-58%
All HEPs Set to 95% Value	1.6E-06	202%
EDGs & SBO DGs in the same CC Group	1.4E-06	164%
No Credit for LOOP Recovery	1.1E-06	108%

# Chapter 19 PRA and Severe Accidents

## PRA Influence on Design - Examples

- ▶ **Addition of SBO DGs in divisions 1 and 4 to improve plant response to LOOP events**
  - ◆ Diversity from EDGs based on different model, control power, HVAC, engine cooling, fuel system and location
- ▶ **Permanent alignment of Safety Chilled Water to LHSI pump motors and mechanical seals in Division 1 and 4**
- ▶ **Diversification of the cooling system for SAHRS by providing a CCW/ESW division dedicated to the SAHRS division**
- ▶ **Isolation of FWDS to the RB Annulus (in progress) to reduce annulus flooding risk.**

# Chapter 19 PRA and Severe Accidents Conclusions

- ▶ PRA results show that the design and safety goals are met
- ▶ PRA shows no risk outliers and confirms robustness of the design

# **19.1 – Probabilistic Risk Assessment Level 2 At Power PRA**

David Gerlits  
U.S. EPR PRA Group

# Chapter 19 PRA and Severe Accidents

## Level 2 Overall Scope

- ▶ **Full scope Level 2, with Containment Event Tree including phenomena, systems and human actions**
- ▶ **All plant operating states**
- ▶ **Results: Release Category frequencies and source terms covering all release sizes and timing**

# Chapter 19 PRA and Severe Accidents

## Level 2 Phenomenological Analysis

### ▶ Induced RCS Rupture

- ◆ Steam generator tube, hot leg/surge line, and Reactor vessel creep rupture

### ▶ Fuel Coolant Interactions

- ◆ In-vessel and ex-vessel steam explosions

### ▶ Phenomena at Vessel Failure

- ◆ Reactor pit overpressure failure, vessel rocketing, direct containment heating

### ▶ Hydrogen

- ◆ Deflagration, flame acceleration, and deflagration to detonation transition (DDT)

### ▶ Long term containment challenges

- ◆ Containment overpressurization
- ◆ Incomplete melt transfer from pit to core spreading area
- ◆ Extended molten core concrete interaction with basemat penetration

### ▶ In-vessel core retention

# Chapter 19 PRA and Severe Accidents

## Level 2 Systems Analysis

### ► Systems credited in Level 2 analysis:

- ◆ Dedicated primary system depressurization valves
- ◆ Core Melt Stabilization System /Severe Accident Heat Removal System in the following cooling modes:
  - IRWST Cooling (as in Level 1)
  - Spray mode for containment pressure control and atmospheric scrubbing
  - Gravity fed flooding and forced core spreading area cooling
- ◆ Low Head Safety Injection for in-vessel core retention and core spreading area cooling
- ◆ Primary Containment Isolation System
- ◆ Operation of the hydrogen recombiners is credited in Hydrogen Phenomenological Evaluation

# Chapter 19 PRA and Severe Accidents

## Level 2 Human Reliability Analysis

- ▶ **Based on state of the art severe accident guidance**
- ▶ **Intermediate and long term actions include consideration of Control Room, Technical Support Center, and Emergency Director in the evaluation and decision making process**
- ▶ **The analysis models the dependencies between Level 2 actions and between Level 1 and Level 2 actions**
- ▶ **Important Level 2 Human actions**
  - ◆ **Operator fails to perform backup actions for containment isolation**
  - ◆ **Operator fails to enter the Accident Management Guidelines and manually depressurize the RCS.**

# Chapter 19 PRA and Severe Accidents

## Containment Fragility Evaluation

- ▶ **Developed a composite fragility curve for the U.S. EPR containment**
- ▶ **Ratio of median failure pressure to design pressure is 2.9**
- ▶ **Probability of containment failure for each event**
  - ◆ **Calculated using the composite containment capacity distribution and a load distribution for each event**
  - ◆ **Monte-Carlo sampling used for the convolution of the load and capacity distributions**
- ▶ **Uncertainty in the containment failure probability is accounted for in the load and capacity distributions**

# Chapter 19 PRA and Severe Accidents

## Level 1 to Level 2 Integration

### ► Core Damage End States (CDES)

- ◆ Are a set of attributes that uniquely defines and groups a set of Level 1 core damage sequences
- ◆ Transfer groups of sequences to the appropriate Level 2 CET for quantification
- ◆ Allow system failures in Level 1 to propagate through the CET to the release category frequencies

### ► The Level 2 CETs have two interfaces with the Level 1 model

- ◆ The output of the Level 1 event trees is linked directly to the input for the Level 2 event trees via the Core Damage End States
- ◆ The Level 2 event tree top events are linked to the system top events in the Level 1 event trees

# Chapter 19 PRA and Severe Accidents Source Term Analysis Methodology

- ▶ **Twenty four release categories are defined**
  - ◆ The attributes for these include containment bypass, time frame for containment failure, type of containment failure, use of containment spray, status of core melt cooling
- ▶ **Source term analysis performed using MAAP4.0.7**
- ▶ **MAAP results include**
  - ◆ Release fractions for twelve (12) fission product groups
  - ◆ Release height and timing
  - ◆ Plume energy


# Chapter 19 PRA and Severe Accidents

## Large Release Definition and Frequency

- ▶ Any release category with a release fraction for Iodine, Cesium, or Tellurium above the range of 2 to 3% is classified as a large release
- ▶ Conservative with respect to the early fatality Quantitative Health Objective defined in the NRC Safety Goal Policy
- ▶ The Large Release Frequency for the U.S. EPR is  $2.8\text{E-}8/\text{yr}$

# Chapter 19 PRA and Severe Accidents

## Level 2 Release Category Contribution to Total At-Power LRF



# Chapter 19 PRA and Severe Accidents

## Top LRF Sequences and Phenomena

### ► Top LRF Sequences

- ◆ Internal Events – Containment Overpressure failure due to unmitigated Steamline Break inside containment and Steam Generator Tube Rupture initiating events leading to core damage
- ◆ Fire and Flooding – Early containment failure due to hydrogen flame acceleration loads and high pressure core damage sequences with thermally induced steam generator tube rupture

### ► Top LRF Phenomena

- ◆ Thermally induced steam generator tube rupture occurring for small/seal LOCAs
- ◆ Containment failure occurring due to loads from an accelerated hydrogen flame originating in the lower or middle equipment rooms

# Chapter 19 PRA and Severe Accidents

## At-Power Level 2 PRA Conclusions

- ▶ The phenomena of containment failure have been examined on a plant specific basis using state of the art techniques
- ▶ Large Release Frequency is 5% of CDF for all initiators
- ▶ The at-power conditional containment failure probability is 0.05
- ▶ This meets the Commission goals of a conditional containment failure probability of less than 0.1

# Shutdown PRA Level 2

Nissia Sabri-Gratier  
U.S. EPR PRA Group



# Chapter 19 PRA and Severe Accidents

## General Approach




- ▶ **Analysis structured similarly to the Level 2 at-power analysis: Elements of the at-power Level 2 analysis are assessed for their applicability in shutdown**
- ▶ **Differences with the Level 2 at-power analysis are summarized below:**
  - ◆ **Lower decay heat levels and pressures (Preclusion of the IHLR and modification of the ISGTR)**
  - ◆ **Limitations in modeling 'open' RCS states with MAAP (POS D & E)**
  - ◆ **Additional system and operator actions analyzed (containment hatch and hatch closure)**
  - ◆ **High likelihood that containment or containment penetrations are open**
  - ◆ **Re-evaluation of the containment failure due to hydrogen combustion loads**

# Chapter 19 PRA and Severe Accidents

## Release Categories and Source Term (1/2)

- ▶ **RC defined using the same criteria as at-power**
- ▶ **Source Term assessment driven by the pressurization level and status of the primary system**
  - ◆ **POS C: Initially pressurized and closed RCS**
  - ◆ **POS D&E: Initially depressurized and open RCS**
- ▶ **Specific shutdown conditions impacting the source term evaluation**
  - ◆ **Low decay heat levels**
  - ◆ **Low RCS coolant inventories in a number of POS**
  - ◆ **Potential for air ingress -with RCS open- potentially leading to higher Ruthenium releases (no impact on LRF)**
  - ◆ **'Open' RCS leading to higher source term (The source term is evaluated considering that all fission products are released into containment with zero retention in the RCS)**

# Chapter 19 PRA and Severe Accidents Release Categories and Source Term (2/2)



- ▶ **Simplified methodology for source term in shutdown:**
  - ◆ Use of MAAP runs for POS CA and CB
  - ◆ Use of insights from available at-power analyses to evaluate source term for POS D and E
- ▶ **Preclusion of some phenomena at-shutdown (absent or unimportant with open RCS)**
  - ◆ Induced hot leg rupture
  - ◆ High pressure melt ejection challenges
  - ◆ Direct containment heating
- ▶ **Certain RC defined at-power conditions are unpopulated in one or more shutdown POS**

# Chapter 19 PRA and Severe Accidents

## Air Ingression



- ▶ **Timing: Of concern after vessel failure with head removed**
  - ◆ Possibility of high convective air flow through the core remaining in the vessel
  - ◆ Low decay heat potentially resulting in a greater mass of residual fuel in RPV at the time of breach
  
- ▶ **Mechanism: Degraded core is exposed to gas flow (oxygen, nitrogen and hydrogen) leading to**
  - ◆ Alteration of the Zircaloy oxidation kinetics due to oxidation of Zr in air rather than in steam
  - ◆ Formation of oxidic forms of certain fission products such as Ruthenium oxides ('RuOx')
  
- ▶ **Consequence and Mitigation:**
  - ◆ No impact on LRF but potential for higher Ru releases
  - ◆ PAR reduction of Oxygen concentration lowers the potential for enhanced Zr oxidation

# Chapter 19 PRA and Severe Accidents

## LRF Results- Significant Sequences/Cutsets



- **Cutsets contributions to the shutdown LRF (6 cutset groups contribute more than 1%)**

### Main Cutsets

### Total RC contribution to LRF


- |   |                 |
|---|-----------------|
| ◆ RHR LOCA Outside Containment (containment bypass)   | RC 802 (27.3%)  |
| ◆ LOCA in POS CB with failure to close the hatch,<br>LOCA in POS E with containment open in POS E   | RC 204 ( 17.3%) |
| ◆ Loss of RHR due to LOOP in POS CA and CB with very<br>early containment failure due to hydrogen flame acceleration,<br>LOCA in POS CB with very early containment failure due to<br>hydrogen flame acceleration | RC 303 ( 15.8%) |
| ◆ LOCA in POS CB with failure to close the hatch  | RC 205 ( 8.1%)  |

# Chapter 19 PRA and Severe Accidents LRF Results

## ► Main RC contributors to shutdown LRF

- ◆ Containment Isolation (mainly RC 201) [52%]
- ◆ ISLOCA (RC 802) [27%]
- ◆ Containment rupture due to early hydrogen FA (RC 303) (only CA and CB) [20%]

POS contributions to SD LRF ( $5.7\text{E-}9/\text{yr}$ )




# Chapter 19 PRA and Severe Accidents

## LRF Results



Initiator contributions to LRF




# Chapter 19 PRA and Severe Accidents


## Release Categories contribution to at-power and shutdown LRF




**Total at-power LRF**



**Shutdown LRF**



# Chapter 19 PRA and Severe Accidents Importance Rankings



- ▶ **Phenomena (Table 19.1-122 and Table 19.1-123)**
  - ◆ Very early containment failure due to H<sub>2</sub> flame acceleration (FV =20%)
  - ◆ Containment failure due to in-vessel steam explosion (RAW=9)
- ▶ **Systems (Table 19.1-125)**
  - ◆ SAHR
  - ◆ RHR flow diversion isolation
- ▶ **Operator actions (Table 19.1-124)**
  - ◆ Hatch closure with and without power

# Chapter 19 PRA and Severe Accidents Conclusions

- ▶ The shutdown Large Release Frequency for the U.S. EPR is 10% of CDF and satisfies the Commission's safety goal
- ▶ Shutdown CDF:  $5.8\text{E-}08/\text{yr}$
- ▶ Shutdown LRF:  $5.7\text{E-}09/\text{yr}$
- ▶ This analysis provides unique insights on accident sequences during shutdown

	Shutdown	Total (At-power and Shutdown)
CDF(yr)	$5.8\text{E-}8$	$5.8\text{E-}7$
LRF(yr)	$5.7\text{E-}09$	$3.1\text{E-}8$
CCFP	0.1	0.05

