

Official Transcript of Proceedings

NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards
 571st Meeting: OPEN SESSION

Docket Number: (n/a)

Location: Rockville, Maryland

Date: Thursday, April 8, 2010

Work Order No.: NRC-170

Pages 1-113

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1323 Rhode Island Avenue, N.W.
Washington, D.C. 20005
(202) 234-4433

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY
COMMISSION'S ADVISORY COMMITTEE ON REACTOR
SAFEGUARDS

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, as reported herein, is a record of the discussions recorded at the meeting.

This transcript has not been reviewed, corrected, and edited, and it may contain inaccuracies.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

+ + + + +

571ST MEETING

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

(ACRS)

+ + + + +

OPEN SESSION

+ + + + +

THURSDAY

APRIL 8, 2010

+ + + + +

ROCKVILLE, MARYLAND

+ + + + +

The Advisory Committee met at the Nuclear
Regulatory Commission, Two White Flint North, Room
T2B3, 11545 Rockville Pike, at 8:30 a.m., Dr. Said
Abdel-Khalik, Chairman, presiding.

COMMITTEE MEMBERS PRESENT:

SAID ABDEL-KHALIK, Chairman

J. SAM ARMIJO, Vice Chairman

JOHN W. STETKAR, Member-at-Large

SANJOY BANERJEE

DENNIS C. BLEY

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

MARIO V. BONACA

COMMITTEE MEMBERS PRESENT: (cont.)

CHARLES H. BROWN

MICHAEL CORRADINI

DANA A. POWERS

HAROLD B. RAY

MICHAEL T. RYAN

WILLIAM J. SHACK

JOHN D. SIEBER

CONSULTANTS TO THE ACRS PRESENT:

THOMAS DOWNER

GRAHAM WALLIS

NRC STAFF PRESENT:

MAITRI BANERJEE

EARL LIBBY

GETACHEW TESFAYE

JASON CARNEAL

STEPHEN PHILPOTT

PETER YARSKY

ALSO PRESENT:

BRIAN MCINTYRE

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

TIMOTHY STACK

JIM HARRISON

TABLE OF CONTENTS

PAGE

Opening Remarks by ACRS Chairman:

Opening Statement 4

Items of Current Interest 6

Draft Final ISG DC/COL-ISG-016:

Remarks by Subcommittee Chairman 8

Selected Chapters of the SER with Open Items

Associated with Review of the USEPR

Design Certification Application:

Remarks by Subcommittee Chairman 11

Discussion with NRC Staff and AREVA 12

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

P R O C E E D I N G S

(8:28 a.m.)

CHAIRMAN ABDEL-KHALIK: The meeting will now come to order.

This is the first day of the 571st meeting of the Advisory Committee on Reactor Safeguards. During today's meeting the Committee will consider the following:

One, draft final interim staff guidance DC/COL-ISG-016, "Compliance with 10 CFR 50.54(hh)(2) and 10 CFR 52.80(d);

Two, selected chapters of the Safety Evaluation Report with open items associated with the review of the U.S. Evolutionary Power Reactor Design Certification Application;

Three, Supplement 3 to General Electric Topical Report NEDC-33173PA, "Applicability of GE Methods to Expanded Operating Domains; and

Four, preparation of ACRS reports.

A portion of the session on draft final

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 interim staff guidance DC/COL-ISG-016, "Compliance
2 with 10 CFR 50.54(hh)(2) and 10 CFR 52.80(d)," may be
3 closed to protect unclassified safeguards information
4 applicable to this matter.

5 Also, a portion of the session on
6 selected chapters of the SER with open items
7 associated with the review of the Evolutionary Power
8 Reactor Design Certification Application and the
9 session on Supplement 3 to GE Topical Report NEDC-
10 33173PA, "Applicability of GE Methods to Expanded
11 Operating Domains," may be closed to protect
12 proprietary information applicable to these matters.

13 This meeting is being conducted in
14 accordance with the provisions of the Federal
15 Advisory Committee Act. Ms. Maitri Banerjee is the
16 Designated Federal Official for the initial portion
17 of the meeting.

18 We have received no written comments or
19 requests for time to make oral statements from
20 members of the public regarding today's sessions.

21 There will be a phone bridge line at
22 today's meeting. To preclude interruption of the
23 meeting, the phone will be placed in a listen in mode
24 during the presentations and Committee discussions.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 A transcript of portions of the meeting
2 is being kept, and it is requested that the speakers
3 use one of the microphones, identify themselves, and
4 speak with sufficient clarity and volume so that they
5 can be readily heard.

6 I will begin with items of current
7 interest. It is with great joy and pride that I
8 announce that Professor George Apostolakis, a member
9 of ACRS since June 1995, will be sworn in as an NRC
10 Commissioner on Friday, April 23rd. For the past 15
11 years, Professor Apostolakis has made numerous
12 significant and lasting contributions to the safety
13 and regulation of nuclear power plants in the United
14 States, particularly in the areas of probabilistic
15 assessment, cyber security, digital instrumentation
16 and control, and fire protection.

17 He was instrumental in the advancement of
18 risk-informed regulations, including the application
19 of defense in depth in a risk-informed context; the
20 development of the risk-informed decision making
21 process; and preparation of the landmark Regulatory
22 Guide 1.174.

23 Dr. Apostolakis served as ACRS Chairman
24 in 2001 and 2002.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 His professionalism, dedication, sense of
2 humor, attention to details, trenchant comments,
3 ability and willingness to handle highly complex
4 technical issues and regulatory matters, and
5 enthusiastic and energetic participation in the
6 Committee's discussions will be greatly missed. We
7 all wish him well in his new assignment and are
8 confident that he will discharge his duties with
9 honor and distinction.

10 George is not here, but I'm sure he
11 wouldn't mind if applaud him in absentia.

12 (Applause.)

13 CHAIRMAN ABDEL-KHALIK: Ms. Jenny Gallo,
14 ACRS Director for Program Management, Policy
15 Development and Analysis, PMDA, has been selected to
16 receive the NRC Meritorious Service Award for 2010.
17 This award is presented to individuals who have
18 distinguished themselves in service to the federal
19 government throughout their careers.

20 Ms. Gallo began her career with the NRC
21 nine and a half years ago and has been working for
22 the federal government since 1989. Throughout her
23 service to the NRC and the American public, Ms. Gallo
24 has always demonstrated remarkable leadership skills,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 team management and motivation, and goal oriented
2 performance management.

3 During her tenure at the ACRS, she has
4 consistently exercised prime skills in development of
5 progressive strategies that have improved the
6 efficiency and effectiveness of office processes.
7 Under Ms. Gallo's leadership, PMDA is performing in
8 an outstanding manner in a demanding and rapidly
9 evolving environment.

10 Please join me in congratulating Jenny
11 Gallo on this significant career recognition.

12 (Applause.)

13 CHAIRMAN ABDEL-KHALIK: At this time, we
14 will begin with the first item on the agenda, dealing
15 with DC/COL-ISG-016 and our colleague, Dr. Mario
16 Bonaca, will lead us through that discussion.

17 MEMBER BONACA: Thank you.

18 I'm Mario Bonaca, the Chairman of the
19 ACRS Subcommittee on Safeguards and Security. Ms.
20 Banerjee is the Designated Federal Official for this
21 part of the meeting.

22 This is an open and closed meeting under
23 the provisions of the Sunshine Act to allow
24 discussion of sensitive and classified and safeguards

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 material. We will go into the closed session after
2 my opening remarks. Participation in the closed
3 portion of the meeting is restricted based on a list
4 prepared by the DFO. Any personnel not on the list
5 and who do not have the proper level of clearance and
6 the need to know would have to leave the room once
7 the closed portion of the meeting starts.

8 I ask the staff to verify. Also, please
9 make sure that any electronic devices, like the cell
10 phones which could be used for recording and
11 transmission, are left outside this conference room.

12 The purpose of today's meeting is to hear
13 presentation from the staff regarding draft final
14 Interim Staff Guidance DC/COL-ISG-016, "Compliance
15 with 10 CFR 50.54(hh)(2) and 10 CFR 52.80(d), loss of
16 large areas of the plant due to explosions or fires
17 from beyond design basis event. This ISG was
18 prepared to provide implementation guidance for the
19 new rule for the applicants for new nuclear power
20 reactors beyond that provided in NEI Guidance
21 Document NEI06-12, which the ISG endorses with some
22 exceptions and clarifications.

23 The ISG was issued with public comment
24 with the comment period expiring on November 19th,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 2009. The Committee had been intimately involved in
2 and made valuable contributions to the development of
3 the requirements now defined in 50.54(hh), which were
4 imposed on the operating power reactor licensees by
5 NSC orders.

6 The Commission in an SRM, dated December
7 17th, 2008, stated that the staff should have the
8 ACRS review the implementation guidance for the
9 portions of the security rulemaking within the
10 Committee's scope. Following this directive, we were
11 provided a copy of the draft final ISG on March 8th.

12 At that time the ISG was going through
13 the NRC monitoring concurrence review. Hence, I
14 asked the staff to confirm that no substantive
15 changes were made to the ISG after it was provided to
16 the ACRS.

17 MR. LIBBY: That is correct. No
18 substantive changes have been made to ISG-016 since
19 they were submitted to ACRS in March.

20 MEMBER BONACA: Excellent. Thank you.

21 As this meeting is being transcribed, I
22 request that participants in this meeting use the
23 microphones located throughout the meeting room when
24 addressing the Subcommittee. Participants should

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 first identify themselves and speak with sufficient
2 clarity and volume so that they can be readily heard.

3 I'm asking now Mr. Earl Libby of NRO to
4 begin the staff presentation.

5 MS. BANERJEE: Excuse me, Mr. Chairman.

6 This is Maitri Banerjee.

7 Excuse me. Can I just go out and check
8 with the security guard to see if anybody came in who
9 are not on the list? Because I asked for them to
10 take down the names.

11 MEMBER BONACA: Yes, please.

12 MS. BANERJEE: And I ask the presenters
13 to put their name tents up.

14 Thank you.

15 CHAIRMAN ABDEL-KHALIK: Thank you.

16 MS. BANERJEE: We are okay to proceed,
17 Mr. Chairman.

18 MEMBER BONACA: Okay. We can proceed.

19 (Whereupon, at 8:39 a.m., the meeting
20 adjourned to closed session, and at 10:28 a.m.
21 reconvened in open session.)

22 CHAIRMAN ABDEL-KHALIK: We're back in
23 session.

24 At this time we will consider Item 3 on

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the agenda, selected chapters of the Safety
2 Evaluation Report with open items associates with the
3 review of the U.S. Evolutionary Power Reactor design
4 certification application.

5 And Dr. Powers will lead us through that
6 discussion.

7 Dr. Powers.

8 MEMBER POWERS: Thank you.

9 Many of you have noticed certification of
10 new reactor designs occupies an increasing fraction
11 of our subcommittee meeting time, and many of those
12 are of the passive persuasion, but now they have a
13 plant that they were going to look at that is active
14 and, more importantly, that are actually being built
15 around the world. So they're really interesting
16 plans. We're going to discuss a little bit about the
17 EPR.

18 To start our discussion, I'm going to ask
19 Getachew Tesfaye to give us some introductory
20 comment, and then we'll move to presentations by both
21 the applicant and the staff.

22 MR. TESFAYE: Good morning, everyone. My
23 name is Getachew Tesfaye. I'm the lead project
24 manager for the EPR Design Certification Project.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 In a six phase review, we are currently
2 more than halfway through Phase 3. We also at the
3 same time are completing Phase 2 for some of the
4 chapters, but today we will give you a high level
5 summary of the presentation we've made to the
6 Subcommittee prior to this week. There will be seven
7 chapters that we will be going over, and I have with
8 me all of the chapter PMs to support any discussion
9 you may have.

10 With that, Mr. Chairman.

11 MEMBER POWERS: Thank you.

12 As Getachew indicated, we are going
13 through this in a phased approach and we have looked
14 at a variety of chapters. What I have asked people
15 to do in their presentations is to give you a fairly
16 high level view of the chapters we're going through
17 and our strategy for going through the remainder, and
18 we have before us a veteran of appearances in front
19 of this Committee, and he's not going to talk about
20 AP-1000 or 600 or any other number of AP, right?

21 MR. MCINTYRE: Right.

22 MEMBER POWERS: In fact, he has vowed
23 that he has thoroughly enjoyed not speaking in front
24 of the Subcommittee. So this is kind of his maiden

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 voyage here on this particular reactor.

2 Brian, I turn the floor to you.

3 MR. MCINTYRE: Thank you, Dr. Powers.

4 AREVA is very happy to be here, and as
5 Dr. Powers said, I'm very surprised to be here again.

6 (Laughter.)

7 MR. MCINTYRE: It's not a bad thing. I
8 dearly kind of miss you guys. That was --

9 (Laughter.)

10 MR. MCINTYRE: That was ten years and 44
11 meetings. We did get to know each other reasonably
12 well. And I would say in the ten years since I have
13 not been here that the review process has really
14 matured, and I think for the better, and I think a
15 lot of that is on the part of the staff. They've
16 come up with a six-phase review, and a lot of that
17 is, I think, just defensive to get things more
18 planned and make sure that it moves along, that
19 things get done so that the applicant knows what to
20 expect.

21 We are exactly halfway through the Phase
22 3 subcommittee meetings of the 19 chapters. So we're
23 nine and a half chapters in, and we didn't complete
24 Chapter 19. We just did the PRA part. The PRA

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 severe accident is scheduled for the 21st of April.
2 We have a one-day session, and the chapters we're
3 doing are two, four, five, eight, ten, 12, and 17.

4 Those weren't selected in random order
5 even though it did sort of look like when we were
6 going through it that they were in random order, but
7 that was, I think, part of the improvement of the
8 process is when the chapter is done, it is put on the
9 shelf. We don't continue to talk about it and review
10 it.

11 And I think that is absolutely super
12 because I'm the project manager now, and I worry
13 about how much I'm spending on this. So it
14 eliminates the money I'm spending not only on my end,
15 but I'm paying the staff and the ACRS to review it.
16 So my focus is on --

17 MEMBER POWERS: We were going to ask for
18 a raise, too.

19 MR. McINTYRE: I know how much I pay.
20 I'm sure it doesn't all translate.

21 (Laughter.)

22 MR. McINTYRE: So it doesn't on my end
23 either. So that covers our introduction. Tim Stack
24 is going to provide just a general overview of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 plant. We were here in 2008, and it's time to get
2 refreshed on that just to talk about the EPR in
3 general, and then I'm going to do a real high level
4 summary of the application at the very end and talk
5 about the seven chapters that have been completed.

6 We're not going to talk about the two
7 chapters that were done on Tuesday. So we're just
8 going to do the seven that we're basically through,
9 and we're not going to do the half of 19 until 19 is
10 all done.

11 And with that, Tim.

12 MR. STACK: Thank you, Brian.

13 And as Brian said, I'm Tim Stack from
14 Areva. I'm the manager of technical integration in
15 the EPR. I've been working on the EPR since 2005,
16 and I'm responsible for EPR technology at a high
17 level of technology.

18 As Brian indicated, again, we'll give an
19 overview on the overall design. When we go through
20 the individual chapters we'll try to highlight some
21 of the key differences in those individual chapters
22 versus typical PWRs. So we'll try to build it on a
23 differential basis.

24 When we got started in the EPR

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 development, which began in the early '90s, we really
2 wanted to build an evolutionary design. We didn't
3 want to go after a passive plant design. We wanted
4 to build on years of experience of what we've
5 learned, and basically you have a design that builds
6 on what did we learn plus what should we be doing
7 differently to raise the standards of the plant to
8 move to the future.

9 And the major objectives were really
10 looking at improving economics for our customers, as
11 well as improving safety for our customers, the staff
12 and the public as far as the design is concerned.

13 With regards to the safety aspects, I'm
14 not going to cover all of the points. Some of the
15 key points though, we wanted to increase design
16 margins in the design itself. We have increased
17 redundancy and physical separation of our safety
18 trains versus the operating plants, and I'll go into
19 that in more detail as we move on.

20 We wanted a reduction in core damage
21 frequency versus what the previous operating plants
22 had achieved, and we wanted to have features to
23 accommodate severe accidents from the design stage
24 moving forward, as well as accommodating external

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 hazards from the original design phase, predominantly
2 aircraft hazards and explosion pressure waves.

3 So that's what we set out to do with the
4 overall EPR design. This slide really covers the
5 major design features, and we'll go into a number of
6 these in more detail as we move on. And, again, this
7 one is broken into what do we have in the nuclear
8 island. What have we done from an electrical design
9 and what have we done from a site characteristics
10 perspective?

11 And the best way to really look at this
12 is kind of a comparison. Where are we similar to a
13 typical PWR, and this isn't necessarily all, but this
14 is really where are we similar and, more importantly,
15 where are we different with regards to the EPR?

16 So this is mainly a contrasting way of
17 looking at the plant, and when we look at the nuclear
18 island again, we have a proven four-loop design.
19 Again, that's proven through the U.S., France and
20 Germany of large, four-loop PWRs. So we're very
21 similar in that regard.

22 Then when we move on we have four trains
23 of safety systems for our major front line safety
24 systems. Most plants typically have two. We have a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 double containment. Most plants typically have a
2 single containment.

3 We have an in containment borated water
4 storage tank. Most plants have an outside
5 containment BWST or RWST. That allows us to get rid
6 of one of the major operator actions to swap over to
7 the sump for LOCA mitigation, which is one of the
8 dominant sequences in the PRAs of the existing plants
9 as being problematic.

10 We have severe accident design features
11 built into the design from the ground up versus the
12 operating plants having them backfit. We have
13 separate safety buildings for each of our safeguards
14 buildings versus having them consolidated into a
15 nuclear auxiliary building where you have all of your
16 safeguards divisions in one building.

17 We have an advanced control room design
18 that's digital versus analogue design. Within the
19 context of the electrical world, we --

20 MEMBER BLEY: Tim, on your four train
21 safety systems, are they 100 percent; each train is
22 100 percent for all of your accidents?

23 MR. STACK: When we sit back and we look
24 at our four train systems, we really look at them

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 more from the standpoint of what's an N plus two
2 design. Some of the functionality is not purely 100
3 percent, and I'll cover that in a little more detail.

4 MEMBER BLEY: Okay.

5 MR. STACK: If that's okay.

6 MEMBER BLEY: That's fine.

7 MR. STACK: Thank you.

8 In the electrical design we have the
9 ability to accommodate a load rejection from 100
10 percent power back to house load versus the operating
11 plants, which would typically trip. There would be a
12 reactor trip from 100 percent load rejection.

13 We've got four trains of emergency diesel
14 generators versus typically two trains, and then we
15 have smaller, diverse SBO diesel generators to
16 support station blackout as well as other severe
17 accident scenarios.

18 Finally, on the site characteristics, we
19 are designed for airplane crashes, both military and
20 commercial, and we're designed to accommodate
21 explosion pressure waves. In general, we see a
22 number of major upgrades that look at where has the
23 U.S. regulatory arena gone, as well as where has
24 Europe predominantly gone moving forward.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 When we look at the -- moving on to major
2 design features, again, phenomenally, how do we
3 change the NSSS? What you see is, again, a really
4 conventional four-loop PWR design. We have a single
5 reactor vessel. We have four steam generators.
6 We've got four reactor coolant pumps, a pressurizer,
7 interconnecting hot and cold legs and a surge line.
8 So from the standpoint of four-loop PWR, it looks
9 very similar to what we've generally seen in the
10 past.

11 We also increased the component volumes
12 both on the primary and the secondary. That was
13 really aimed at slowing down the response and
14 increasing the operator response times.

15 As far as the operators are concerned,
16 for design basis accident mitigation we have a 30
17 minute no operator action time for design basis
18 accident mitigation from within the control room, 60
19 minutes for outside of the control room for design
20 basis accident mitigation. So we're really trying to
21 keep our timing up so that the operators do not have
22 to intercede early into events.

23 MEMBER POWERS: Tim, I have to ask. In
24 the DBR-1000, which has large horizontal steam

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 generators, thinking about your design, I mean, did
2 you think about going to that kind of design with the
3 large secondary volumes?

4 MR. STACK: Originally, early on in the
5 original design, they really looked at what was done
6 in France and Germany primarily. so they were
7 looking at the N4 plants in France and the convoy
8 plants in Germany. Typically what we have generally
9 seen, the horizontal generators have really not been
10 used in the commercial applications, and really this
11 was building from what do we want from a commercial
12 application.

13 Part of it, as well, is really
14 configuration of the containment and the size of the
15 containment. We didn't want the overall footprint of
16 the containment to be too large. Typically when you
17 go to the horizontal generators, you're into a larger
18 footprint. So it wasn't --

19 MEMBER POWERS: I admit I don't know
20 exactly what the footprint on the 1000 is, but it's
21 not huge, and at least the IAEA seems to be very
22 enthused about these horizontal steam generators. So
23 I was just -- I mean, what you're saying is that
24 didn't figure into the panoply of what we've learned

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 when you set this design up.

2 MR. STACK: And, again, even in terms of
3 part of that experience, part of it was also the
4 corporate experience of AREVA looking at what we drew
5 our experience from, and some of the problems you
6 have. Just changing orientation may not seem like
7 it's --

8 MEMBER POWERS: Oh, I imagine.

9 MR. MCINTYRE: -- a huge change, but
10 again, we really wanted to build from the experiences
11 we had though.

12 MEMBER POWERS: Yeah, I'm sure there are
13 downsides to horizontal steam generators that I'm
14 certainly not aware of, and I don't know how
15 publicized they are, but they certainly have a
16 certain je ne sais qua, shall we say?

17 CHAIRMAN ABDEL-KHALIK: But the volume of
18 the various components has been increased, and
19 presumably that's to increase the time available for
20 no operator action.

21 MR. STACK: Yes.

22 CHAIRMAN ABDEL-KHALIK: But what is the
23 ratio between the volume and the thermal power vis-a-
24 vis that of a four-loop plant?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. STACK: Unfortunately, I have a back-
2 up slide where I can go and show you or we can
3 provide you a back-up slide where we look at
4 increases in volume versus megawatt thermal and the
5 improvements that we have in those.

6 Perhaps one of the best ways to look at
7 some of the operator action times, my experience --
8 and I grew up through the B&W plants -- and you look
9 at time to boil the secondary inventory dry --

10 CHAIRMAN ABDEL-KHALIK: Which is not a
11 good example.

12 (Laughter.)

13 MR. STACK: Just bear with me.

14 So when you look at a once through
15 generator, you're looking at a few minutes. When
16 you're looking at a typical plant with recirc
17 generators, you're looking on the order of 30
18 minutes, 30 to 40 minutes perhaps. Here we're
19 looking at over an hour to boil the generators dry
20 such that we have a significant improvement in the
21 time to boil dry, even compared to plants with recirc
22 generators.

23 MEMBER BANERJEE: Have the volumes of the
24 piping also been increased like the hot legs, the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 cold legs, the loop seals?

2 MR. STACK: Generally not. You're
3 typically looking at sizing on velocities, and those
4 lines would be pretty similar to what you've seen in
5 the past.

6 MEMBER BANERJEE: So the diameter of the
7 pipe has been increased to accommodate the increased
8 power?

9 MR. STACK: The diameter of the pipes are
10 really being set based on the reactor coolant flow
11 rate and the velocities that you want to have in the
12 reactor coolant lines.

13 MEMBER BANERJEE: So let me just ask the
14 question. So let's say this is a four-loop plant,
15 right? And the diameter of the hot leg in comparison
16 to the power produced, is that the same ratio as,
17 say, in other forms of plants or is it different?

18 MEMBER SIEBER: It's close.

19 MR. STACK: It's going to be close
20 because what you're setting the hot leg diameters are
21 really being set to set the velocity that you want in
22 it. So you're looking at the total reactor coolant
23 flow rate that you have in the loops and looking at
24 what velocity do you want.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 The total reactor coolant flow rate is
2 really going pretty much proportionally with power.

3 MEMBER BANERJEE: So what is the diameter
4 of the hot leg?

5 MR. STACK: Off the top of my head --
6 Brian? -- I'm going for -- I can come back and get
7 you that. I have that also in one of my back-up
8 slides.

9 MEMBER BANERJEE: Because this is a
10 crucial question because you depend on secondary side
11 pulling the pressure down to get, you know, the
12 pressure down. You don't have a hot leg system or
13 high pressure injection system.

14 MR. STACK: Typically though when you
15 look at the sizing of the hot legs and cold legs,
16 again, in the operating plants they're generally set
17 by what velocity can you support.

18 MEMBER BANERJEE: Right, and my concern
19 is more reflux condensation. It's a different
20 problem.

21 MR. McINTYRE: And we're setting up a
22 special meeting to chat about that.

23 MEMBER BANERJEE: I just wanted to
24 understand.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. STACK: Any further questions on
2 this?

3 CHAIRMAN ABDEL-KHALIK: I guess I'm just
4 wondering based on the response to the previous two
5 or three questions are you prepared to give any
6 specific numerical answers to any of the questions
7 that will come up or is this sort of a general sort
8 of descriptive --

9 MEMBER POWERS: Yeah, I specifically
10 asked them to stay in a fairly general level.

11 CHAIRMAN ABDEL-KHALIK: Right.

12 MEMBER POWERS: They're doing what I told
13 them to do, fairly high level, because we do have
14 meetings scheduled to go into the gory details.

15 CHAIRMAN ABDEL-KHALIK: Do you have
16 anybody here who would be able to answer specific
17 questions that may come up?

18 MR. STACK: Right at this point in time
19 we have Brian and myself. In some of these, in some
20 of our backup slides what I can do is get you some of
21 your answers specifically. Beyond that, we can take
22 additional questions and get back to you.

23 CHAIRMAN ABDEL-KHALIK: Okay.

24 MR. STACK: Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER BANERJEE: Also we'd be interested
2 in what's happening in the lower plenum and, you
3 know, the distribution system, all the gory details.

4 MEMBER POWERS: And in all fairness, I
5 did not ask them to do it. I specifically directed
6 them not to go into the gory details because (a)
7 there isn't time and (b) you're going to get to see
8 this several more times.

9 MEMBER BANERJEE: All right, Dana.
10 That's a promise.

11 MR. MCINTYRE: And I think a lot of the
12 stuff that you're interested in when we get to
13 Chapter 15, we'll be front and center for that part
14 of the discussion. The chapters that we've been
15 through that we came to talk about, I don't want to
16 say they're irrelevant, but not as important.

17 MEMBER BANERJEE: Sure.

18 MR. TESFAYE: In addition, we also plan
19 to come in front of the Subcommittee to discuss the
20 reflux condensation you just mentioned. We plan to
21 come and present to you before Chapter 15.

22 MEMBER BANERJEE: Oh, you are?

23 MR. TESFAYE: Yes.

24 MEMBER BANERJEE: I didn't know that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 When did that get slipped into the agenda?

2 MR. TESFAYE: It's not in the agenda yet,
3 but we're planning to put it on the agenda.

4 MEMBER BANERJEE: Oh, all right.

5 MEMBER CORRADINI: That will teach you.

6 CHAIRMAN ABDEL-KHALIK: Please proceed.

7 VICE CHAIRMAN ARMIJO: As you go through
8 this, I'd appreciate it if you'd just point out if
9 there are any significant differences between the
10 design we're talking about here and the plant that's
11 being constructed in Finland.

12 MR. STACK: Okay.

13 VICE CHAIRMAN ARMIJO: As you go along,
14 if there are big differences or significant
15 differences, just kind of point that out.

16 MR. STACK: Okay. Just in general, when
17 you look at the major design features level, they
18 actually have additional diesel generators because of
19 some of their design requirements, well, additional
20 diesel generators as well as combustion turbines
21 because, yes, Dana, because of some of the design
22 provisions that they have.

23 Absent that, the major design features
24 are really the same as OL3.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER POWERS: That's what you guys need
2 is more diesel generators.

3 MR. STACK: That's what we were thinking.

4 VICE CHAIRMAN ARMIJO: The Finns wanted
5 additional?

6 MR. STACK: They had an additional diesel
7 generator to support investment protection on the
8 turbine island. They also had an additional
9 combustion turbine generator.

10 MEMBER POWERS: I'm pretty sure that's
11 just exactly a refinement your plant needed. All
12 right. Please go ahead.

13 MR. STACK: Okay. We talk --

14 MEMBER SIEBER: Let me ask a question
15 about component sizes. I'm not asking for specific
16 numbers. To me one of the important ones is the
17 accumulator size and each plant reactor power output.
18 Could you in general describe the differences
19 between the accumulators in this?

20 I notice all of the times are longer. So
21 they must be bigger. Do you know on roughly a
22 percentage basis how much bigger they are? And do
23 they have any special features that control the flow?

24 MR. STACK: Okay. I'll have a slide

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 covering the accumulators. Off the top of my head, I
2 do not have a proportion on the size of the
3 accumulators. However, when you look at most of the
4 pumped ECCS systems, they tend to be smaller than
5 what you would see on many of the operating plants.
6 That's more of an evolution in the designs,
7 understanding what do you really need to do to
8 accommodate your LOCAs.

9 So, for example, when you look at low
10 head safety injection, it's smaller than you would
11 typically see on many of the operating plants, but
12 again, that's more of an evolution of understanding
13 how the designs progress and really matching the ECCS
14 requirements to the accident mitigation.

15 MEMBER SIEBER: Do you have an off the
16 top of your head number for peak clad temperature for
17 a full LOCA?

18 MR. STACK: Brian, do you know what that
19 one is off the top of your head?

20 MR. McINTYRE: I think it's in the 15s.

21 MEMBER SIEBER: Okay. Thank you.

22 MR. STACK: Okay? Four-train concept,
23 yes, we'll move on. Generally what you have in here,
24 and let me get you oriented; here we're going to show

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 and I'll explain the four-train concept for you.
2 What you see in this, we have the reactor building
3 here; the fuel building is down here. Then we have
4 Safeguards 1, 2, 3 and 4. The turbine building is up
5 here for orientation for you. What you see is we
6 have physically separate safeguards buildings. So
7 basically that really improves your mitigation of any
8 internal hazards like fires, HELBs, flooding, where
9 it confines it to a single safeguards building versus
10 the operating plants where you're into multiple
11 divisions in the aux building.

12 When we look at the N plus two concept,
13 what we have is basically you can take a single
14 failure in this train; you can have this train down
15 for preventive maintenance; in the third train you
16 can have the train, you can have the train impaired
17 by the initiating event.

18 So, for example, if you have an ECCS line
19 break, it's going to impair the ECCS function of that
20 train. However, that's the only function of that
21 train that it will impair. Other aspects of it that
22 are unaffected by the initiating event are credited.

23 So, for example, removing heat from the sump fluid
24 by that train is still active and credited.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 And then finally, you would have your
2 fourth train providing the accident mitigating
3 function. In general, when you look at this, we have
4 two trains that are going to be energized and
5 ultimately supporting the accident mitigation, and
6 that's really the overall architecture of how the N
7 plus two design works.

8 In the purest sense we don't necessarily
9 like to look at it as four by 50 or four by 100 per
10 se.

11 MEMBER BLEY: But for some accidents
12 you're probably 100 percent from one of them and for
13 certain things you need the extra help from a second
14 one.

15 MR. STACK: Yes.

16 MEMBER CORRADINI: That's what I was
17 trying to understand in answering his question. So
18 for some accidents you need only one. For some
19 accidents you need as many as two, but you never need
20 three.

21 MR. STACK: That's correct.

22 MEMBER BLEY: And you might not need the
23 whole two.

24 MR. STACK: Right.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER BLEY: Part of it is impaired.

2 MEMBER CORRADINI: Sorry?

3 MEMBER BLEY: Part of it could be
4 impaired by the initiating event.

5 MEMBER CORRADINI: Right, but I guess
6 what I'm trying to say is if the purple one is out, I
7 could get along with yellow and green.

8 MR. STACK: Yes.

9 MEMBER CORRADINI: And if the red one is
10 out, but I still have a spare is, I guess, what I'm
11 trying to understand.

12 MR. STACK: Well, part of what happens in
13 it though is we are crediting -- let's take the
14 example of the ECCS line break. In order to insure
15 that you're fulfilling your accident mitigating
16 function, they're not cross-connected. Okay? So in
17 order to make sure that you fulfilled your accident
18 mitigating function, you basically have to energize
19 two divisions, one that feeds the break and the other
20 that's providing the accident mitigating function.

21 MEMBER BLEY: Let me try just a little
22 differently. I'm assuming that in your Chapter 15
23 analysis. One's working and one might be degraded.
24 In your PRA you might have done additional analysis

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 and gone down to one train in some cases?

2 MR. STACK: In the PRA, they would look
3 at the type of event and what is really required to
4 mitigate it more from a realistic perspective versus
5 a Chapter 15 design basis accident perspective.

6 MEMBER BLEY: But the Chapter 15 is
7 always kind of one-plus.

8 MEMBER CORRADINI: Right.

9 MR. McINTYRE: One is deterministic and
10 the PRA is looking at what's the success. How many
11 can you get by with?

12 MEMBER BLEY: But every analysis in
13 Chapter 15 is this one-plus analysis.

14 MR. STACK: As it's appropriate for the
15 design of the systems, yes.

16 MEMBER BLEY: Okay, okay.

17 MEMBER CORRADINI: I think, to say it
18 differently, just to make sure I'm on board with
19 Dennis' clarification, it is as he said. One is
20 feeding the break and one is essentially mitigating
21 the accident under the DBA because of the way you
22 have two connected to any one input line.

23 MR. STACK: Yes, and what I'd like to do
24 is I'll clarify it a little further when we have --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER CORRADINI: That's fine.

2 MR. STACK: -- more of a --

3 MEMBER CORRADINI: You can do that, but I
4 just wanted to clarify here. That's fine. I'm
5 happy.

6 MEMBER BROWN: I'm presuming absent all
7 the failures, are they all initiated on any
8 particular ECCS demand? Would they all come on, all
9 four trains?

10 MR. STACK: They're all demanded on, yes.

11 MEMBER BROWN: Okay. So there's no
12 prioritization.

13 MR. STACK: There's no prioritization.
14 They're all demanded just like in the operating
15 plants.

16 MEMBER BROWN: Okay. Thank you.

17 MR. STACK: Oh, one of my favorite
18 slides, the safety systems. What we have, and here
19 we're really looking at the main safety systems
20 really covering the primary slide. The next slide
21 will show really what we have on the secondary side,
22 and what you see is really we have four trains of
23 safety systems with needing that safety injection in
24 a combined low head safety injection and RHR. We

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 have -- and I'll go through this in some more detail
2 -- we have an in containment refueling order storage
3 tank, which you can see down here, and again, that's
4 really providing benefits from the standpoint of not
5 having to swap over to the sump if the RWST was
6 outside containment just like on the operating
7 plants.

8 We have two trains of extra borating
9 system that are not shown in this figure that are
10 powered from two of the divisions.

11 MEMBER BLEY: So your IRWST is actually
12 the sump?

13 MR. STACK: Yes.

14 MEMBER BLEY: Okay.

15 MR. STACK: Okay? What I'll do is I'll
16 go through the line-ups and just show you how this is
17 going to be lined up on this side, and first we'll
18 cover the safety systems, and what we see, first
19 we'll look at MHSI, and one of the things that's
20 first notable about MHSI is that it takes suction
21 directly from the IRWST.

22 One of the improvements versus the
23 operating plants, typically when you look at the
24 medium head safety injection or the high high-head

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 safety injection on the operating plants, it can't
2 take suction directly from the sump. They have to be
3 piggybacked through the low-head safety injection.
4 That has been eliminated in this such that they can
5 take suction directly from the sump, which is an
6 improvement, and let's you look on the MHSI and
7 they'll take suction from the sump. They'll inject
8 to a cold leg. There will be an accumulator on each
9 of the cold legs.

10 If this was the broken cold leg what you
11 would find is, again, the flow from this would be
12 diverted back to the sump, and that would be lost for
13 injection capability, and that's basically the
14 alignment on MHSI.

15 When you look at the LHSI, again, we take
16 suction from the IRWSD --

17 CHAIRMAN ABDEL-KHALIK: How low is the
18 shutoff head for the medium-head safety injection
19 compared to the saturation pressure at the hot leg
20 temperature?

21 MR. STACK: The MHSI pumps are in the
22 1,400 pound range, shutoff head. So they're pretty
23 typical of what you -- give or take, they're pretty
24 typical of what you see on the operating plants that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 have medium-head safety injection.

2 MEMBER CORRADINI: So what you don't have
3 here is the charging pumps essentially providing high
4 head flow.

5 MR. STACK: We have charging pumps, but
6 they're not safety related. They perform no safety
7 related functions.

8 MEMBER BLEY: Are they similar to the
9 charging pumps in existing plants?

10 MR. STACK: yes.

11 MEMBER BLEY: They're centrifugal pumps?

12 MR. STACK: Yes.

13 MEMBER BLEY: About the same head?

14 MR. STACK: They're, again, very similar
15 to what you would see in the operating --

16 MEMBER BLEY: But they don't get a start
17 signal?

18 MR. STACK: But they don't get a start
19 signal, and that's not uncommon for many of the
20 plants that are out there with this type of ECCS
21 design.

22 CHAIRMAN ABDEL-KHALIK: The charging
23 pumps are centrifugal pumps rather than positive
24 displacement pumps?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. STACK: Yes, and that's pretty
2 typical of many of the operating plants. The extra
3 borating system pumps are just small positive
4 displacement pumps.

5 MEMBER BLEY: Are the accumulators in the
6 European plants?

7 MR. McINTYRE: Yes.

8 MR. STACK: When you look at the
9 alignment on the LHSI, what you have is basically
10 suction, again, off the sump through the pump, and
11 then it's going to go through an RHR cooler. This is
12 going to reject heat to the component cooling water
13 system, then out to the essential service water
14 system, then out to our cooling towers to get it all
15 the way out to the ultimate heat sink.

16 What's happening in here on this, it's
17 also removing any heat from the fluid that's taken
18 from the sump. So, for example, when we look at the
19 N plus two, that function is still going to be
20 fulfilled if that's an energized division. Okay?
21 The function of removing heat from the sump from that
22 train is not impaired if I break this cold leg here.
23 So we will take credit for that in our analysis
24 because it's functional.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER CORRADINI: I'm sorry. I
2 listened. I tried to listen carefully, but can you
3 just repeat that again? I'm sorry.

4 MR. STACK: Okay. Let's say that this
5 was the broken -- let's say I had a break in this
6 cold leg.

7 MEMBER CORRADINI: Got it.

8 MR. STACK: Okay? If I have a break in
9 this cold leg, basically it means that I'm going to
10 lose the injection flow from the accumulator. I'm
11 going to lose the injection flow from this MHSI pump,
12 and I'm going to lose the injection flow from this
13 LHSI pump.

14 However, just because this is a broken
15 cold leg, I can still take suction from here, pump it
16 through this LHSI pump and this RHR cooler and remove
17 heat from the fluid in the sump.

18 MEMBER CORRADINI: Oh, okay, okay. Thank
19 you.

20 MR. STACK: So we're taking credit for
21 what is really available versus just arbitrarily
22 saying, well, the whole division has failed, and
23 we're not going to credit it at all. Okay?

24 MEMBER CORRADINI: Okay. Thank you.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. STACK: You're welcome.

2 MEMBER SIEBER: Why wouldn't you put the
3 heat exchanger upstream of the pump?

4 MR. STACK: On most of these, typically
5 what happens on anything that's sitting on the
6 suction to the IRWST, you're always going to have
7 MPSH challenges on the pump, and the last thing you
8 want to do is add resistance on the suction side of
9 the pumps.

10 MEMBER CORRADINI: But that's because of
11 your design philosophy. You're not feeding from low
12 head to higher head, right?

13 MR. STACK: Right.

14 MEMBER CORRADINI: I mean, you said that
15 as an advantage, but to take advantage of that, you
16 have to put the heat exchanger downstream of the
17 pump.

18 MR. STACK: Typically, I'm not sure if
19 I've seen any of the operating plants where they ever
20 put the heat exchangers on the suction of the pumps.

21 MEMBER CORRADINI: Well, that's true.
22 Okay.

23 MEMBER POWERS: I don't know why you
24 would do that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. STACK: It's extremely difficult to
2 add resistance on the suction of the pumps.

3 MEMBER CORRADINI: I'm just trying to
4 think of a lineup for an older plant where the low-
5 head pump feeds the higher head pump, and I'm trying
6 to think if there was a heat exchanger. I thought
7 there was, but you're probably right.

8 MEMBER BLEY: Well, maybe between them.

9 MR. STACK: There is typically.

10 MEMBER BLEY: I don't remember where the
11 top off is to the higher pump. It's before the heat
12 exchanger?

13 MR. STACK: Typically what you would find
14 if it was one of the operating plants, you would see
15 -- what you would see is you'd take suction off the
16 sump. You'd go through the LHSI pump, the RHR heat
17 exchanger, and then it would tie back right here to
18 the suction of the MHSI pump.

19 MEMBER CORRADINI: Right. That's right.

20 MR. STACK: And that would be the typical
21 piggyback line-up that you would normally see.

22 MEMBER CORRADINI: Thank you.

23 MR. STACK: That arrangement, again, is
24 pretty typical on the heat exchanger side.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER CORRADINI: Thank you.

2 MR. STACK: So on the LHSI side though
3 what we will have in here is, again, it will come out
4 of the RHR cooler, and then we will go and pump
5 through the cold leg. An alternate alignment is to
6 go and align it through the hot leg for hot leg
7 injection, and that's basically covering what you
8 generally see on the LHSI and RHR from a safety
9 perspective.

10 In addition, in one train we have a non-
11 safety containment spray for severe accident heat
12 removal. It's basically cooling the corium in the
13 inside containment. It's also spraying down the
14 containment for depressurization.

15 MEMBER POWERS: Do the Finns require that
16 to be safety grade?

17 MR. STACK: Their classifications don't
18 exactly match up, but yes.

19 MR. MCINTYRE: And they have two trains.

20 MEMBER POWERS: And how is it being
21 treated in France?

22 MR. STACK: Their classification systems
23 are different yet again. I'll be honest with you,
24 Dana. Off the top of my head, I forget how they're

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 doing it in France.

2 MEMBER POWERS: Sounds like we probably
3 ought to go visit and find out.

4 MR. STACK: I think a visit is well in
5 order.

6 MEMBER POWERS: We'd better.

7 MR. STACK: I think one phone call will
8 solve it, but --

9 PARTICIPANT: One pump.

10 MR. STACK: Clearly for severe accident
11 mitigation, beyond design basis.

12 PARTICIPANT: The blue.

13 MR. STACK: The blue.

14 MEMBER CORRADINI: But I guess my memory
15 is that in France it's similar to the Finns, although
16 a different classification. I thought it was
17 considered safety grade to have that for the severe
18 accident.

19 MR. STACK: I believe that is also true,
20 but here it's the difference between what's at beyond
21 design basis action here is different than how they
22 evaluate them in Europe.

23 MEMBER BLEY: Is there a limit on outage
24 time for that non-safety spray pump?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. STACK: Basically the unavailability
2 of all the equipment in the end would be managed
3 through the maintenance rule for all of the
4 equipment.

5 MEMBER POWERS: Of course.

6 MEMBER BLEY: There would still be tech
7 specked under your safety grade equipment.

8 MR. STACK: Yes.

9 MEMBER BLEY: But not this.

10 MEMBER POWERS: WE'll see.

11 (Laughter.)

12 VICE CHAIRMAN ARMIJO: The figure shows
13 some dashed red lines to the hot legs.

14 MR. STACK: Yes.

15 VICE CHAIRMAN ARMIJO: What are they?
16 What are those? Are those lines or --

17 MR. STACK: The dashed, what you see in
18 here from the LHSI, they're really showing two
19 things. Sorry for the busy figure. The dashed line
20 is really showing an alternate alignment for hot leg
21 injection. The green line is really showing the
22 normal RHR line-up where you take it from the hot leg
23 back into the pump and back to the cold leg..

24 VICE CHAIRMAN ARMIJO: Okay, but you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 could actually go the other way. What is the red?

2 MR. STACK: What's happening is the
3 initial line-up of the system -- a pointer here
4 sooner or later -- the initial line-up is on cold leg
5 injection. At nominally an hour interview, that will
6 swap over to hot leg injection up through this path.

7 VICE CHAIRMAN ARMIJO: Okay.

8 MR. STACK: Okay?

9 VICE CHAIRMAN ARMIJO: I have one other
10 question with that. When you say extra borating
11 system, that implies to me that there's some non-
12 extra, that is, regular borating system.

13 MR. STACK: What's happening is that the
14 IRWST is borated. The extra borating system is
15 looking at concentrated boric acid, nominally 7,000
16 ppm versus 1,700 or 1,800, and it's providing high
17 concentration really that's looking at shutdown
18 boration as well as ATWS mitigation.

19 VICE CHAIRMAN ARMIJO: Okay. Thank you.

20 MR. STACK: John, you look like you want
21 to dive in.

22 (Laughter.)

23 CHAIRMAN ABDEL-KHALIK: Is the switch to
24 hot leg injection automatic?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. STACK: No. It's manual operator
2 action.

3 CHAIRMAN ABDEL-KHALIK: And because you
4 said it's done an hour after event initiation. Is
5 that sort of procedural guidance?

6 MR. STACK: That will be in procedural
7 guidance.

8 We'll move over to the secondary side
9 now, and on the secondary side, we're really just
10 showing an architecture where there are four loops
11 where we have nominally four trains of heat removal
12 for each of the generators, and I'll run through this
13 in some detail for you, perhaps a little more detail
14 than I had planned, but please feel free to ask any
15 questions you have.

16 What you see is, first --

17 MEMBER POWERS: Don't ever say that to
18 them.

19 (Laughter.)

20 MR. STACK: I'm sorry, Brian. You'll
21 survive, Brian.

22 MR. MCINTYRE: Ask him to answer the
23 question now that you've offered.

24 MR. STACK: There you go.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 All right. On the secondary side, the
2 first thing we have is a safety related main steam
3 relief train, and what that means basically, and I'll
4 just use this train up here, first we'll cover the
5 steam side and then we'll cover the liquid side.
6 What you see is in each of the steam lines you'll
7 have the main steam isolation valve and, of course,
8 there will be bypass valves around that you
9 concentrate on this. Downstream of this you'd have
10 normal turbine bypass in the connection down to the
11 turbine.

12 Upstream of the MSIV you have a tap-off
13 that has two 25 percent spring loaded safeties, which
14 is a reduction from the number we typically would see
15 on the operating plants, and you would have a 50
16 percent main steam relief train. In the main steam
17 relief train, that's comprised of a media actuated,
18 normally closed isolation valve and a motor operated
19 normally open control valve, and that provides 50
20 percent relief capacity.

21 When you look at the functionality of the
22 main steam relief train, what it is really doing is
23 several things.

24 First, it's providing a portion of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 over pressure protection on the team line. So the
2 MSRTs plus the safeties are really providing the
3 overall over pressure protection.

4 The second thing that the MSRTs do is
5 they are providing safety grade depressurization.
6 That's used really in three ways. It's supporting
7 LOCA mitigation by initiating a partial cool-down to
8 allow you to lower the secondary pressure and as a
9 result lower the primary pressure.

10 The second thing it's doing is it allows
11 you to bias the set point up on the MSRT, which
12 allows you to isolate a steam generator if you have a
13 tube rupture, and the third thing it does is it
14 allows you to do safety grade cool-down for Branch
15 Technical Position 5-04, so really accomplishing
16 several things with that safety grade
17 depressurization path. Compared to the operating
18 plants it's basically replacing what you see in
19 atmospheric dump valves.

20 MEMBER BLEY: So you have no atmospheric
21 dump.

22 MEMBER RAY: Could you touch on the
23 second point of those three points again?

24 MR. STACK: Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER RAY: I understand two breaks and
2 atmospheric dumps, but what is it that you're saying
3 that it does?

4 MR. STACK: What we are doing with this,
5 and this deals with how it interacts with the medium-
6 head safety injection, and I am sure we will again
7 cover this more when we discuss Chapter 17 --

8 MEMBER BLEY: The other side of your --

9 MR. STACK: Well, what's happening is
10 what we're trying to do is lower -- we're trying to -
11 - initially we're depressurizing the secondary to
12 facilitate the medium-head safety injection. If you
13 have the tube rupture, what we want to do is we want
14 to raise the set point in the valve such that the set
15 point in the valve is higher than the shut-off head
16 of the medium-head safety injection pump such that
17 we're not pumping liquid through the MSRT.

18 So when you look at it after a tube
19 rupture, that set point is set below the safety, the
20 first safety on that line as well. The net effect of
21 all of it is it allows up to bottle up the generator
22 for a tube rupture.

23 MEMBER RAY: Yeah, but after you've
24 depressurized, right?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. STACK: After the initial portion of
2 the depressurization when we've sensed that we have a
3 rupture in that one, we will raise the set point.

4 MEMBER RAY: Well, okay. The point is
5 you have a steam generator tube rupture and you're
6 going to dump to atmosphere to depressurize, and the
7 point I guess you were making with your Item 2 was
8 you can then stop the depressurization.

9 MR. STACK: Right.

10 MEMBER RAY: But you have depressurized
11 following the tube rupture by definition. Okay. I
12 understand your point now anyway.

13 MR. STACK: Okay?

14 MEMBER RAY: Yeah. It made it sound like
15 you were only discovering you had a tube rupture
16 after you depressurized.

17 MR. STACK: No, no, no, no. It's just a
18 portion of the mitigation.

19 CHAIRMAN ABDEL-KHALIK: I guess I don't
20 understand. I have the same concern you have.

21 MEMBER RAY: Yeah. I mean, the plant I
22 ran with atmospheric steam dumps, you wouldn't dump
23 to atmosphere if you had a tube rupture, but we had a
24 high pressure safety injection pump.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. STACK: Right, and that's the
2 difference in this.

3 MEMBER RAY: That's the difference.

4 MR. STACK: Is that you don't have a high
5 high-head safety injection pump. You have a medium-
6 head safety injection pump, and again, what's
7 happening here is you're setting the set point. It's
8 over 1,400 pounds. You're setting the set point of
9 the MSRT at a value that's in excess of the shutoff
10 head of the MHSI pump such that you can't pump
11 through the leak and out through the MSRT.

12 MEMBER RAY: But you've gotten the
13 pressure down far enough that you're getting
14 delivery, I guess. I have got to look at the time
15 history. I realize we're not doing that here.

16 MEMBER STETKAR: Tim, I've forgotten, and
17 it may help. I get confused between the different
18 designs. Does that reset come off an N-16 signal on
19 the main steam line or is it -- in other words, do
20 you reset that one selectively on an N-16?

21 MR. STACK: This is really for design
22 basis accident mitigation, for the tube ruptures.
23 The events are so slow in progression that they're
24 all operator action, but there's an N-16 indication

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 as well as level in the generator to indicate it.

2 MEMBER STETKAR: The operator resets the
3 set point?

4 MR. STACK: Yes.

5 MEMBER STETKAR: Back-up? Oh, okay.
6 Like I said I got -- thanks -- I got confused between
7 designs.

8 CHAIRMAN ABDEL-KHALIK: From the oil
9 generators or after identifying the affecteds being
10 generated?

11 MR. STACK: They'll only reset the set
12 point on the affected generator.

13 MEMBER RAY: But this obviously has
14 triggered a lot of interest from us here. Sorry for
15 all of the back-and-forth, but you know, I mean,
16 that's your barrier to containment bypass on a tube
17 leak, is that reset isolation valve we're talking
18 about.

19 MR. STACK: Yes.

20 MEMBER RAY: Okay. I just have to think
21 about it is all.

22 CHAIRMAN ABDEL-KHALIK: But there is a
23 time period from the time you initiate atmospheric
24 dump and the time you get the pressure down where the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 pump is, where the pressure is below the shutoff head
2 of the pump where you're actually dumping to the
3 atmosphere from the affected steam generator.

4 MR. STACK: And what has happened in the
5 analysis, any leakage you have up till the time that
6 you take your mitigating action is analyzed in the
7 Chapter 15 accident. Beyond that point you're going
8 to isolate it though. So, again, the operator action
9 time is that 30 minutes.

10 CHAIRMAN ABDEL-KHALIK: Okay.

11 MR. STACK: Okay?

12 MEMBER RAY: One last question. I'm
13 sorry. At the moment. Be patient. You would think
14 that you would not use the affected steam generator
15 for your depressurization, I guess.

16 MR. STACK: That's true.

17 MEMBER RAY: Is that part of the
18 procedures?

19 MR. STACK: That's going to happen with
20 those generators, in the end what we will do is
21 transfer inventory from that generator to one or the
22 other intact generators to get the plant all the way
23 down and cooled down. At the end of the day we need
24 to ultimately reduce inventory in all four generators

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 and get the plant down on the RHR.

2 MEMBER RAY: Yeah.

3 MEMBER BLEY: What the questions are
4 really aimed at is during that initial time when you
5 are dumping, but you're not dumping to atmosphere
6 anymore. This doesn't dump to atmosphere, right?

7 MEMBER RAY: Sure, it does.

8 MEMBER BLEY: Oh, it does?

9 MEMBER RAY: It is at atmosphere.

10 MEMBER BLEY: It's a containment bypass,
11 right? So you've got to bottle it up at the right
12 point.

13 MEMBER RAY: For the initial use of the
14 atmospheric relief you are dumping and you're
15 accounting for that.

16 MR. STACK: Yes, for 30 minutes you take
17 time for the operator action. Yes, we are taking
18 accounting for that in the doses that we calculated.

19 MEMBER BLEY: And that's assuming
20 probably one, two.

21 MEMBER STETKAR: Tim, do you know, does
22 the finnish design have the features that the KONVOY
23 plants have where the N-16 signal on that steam line
24 resets a bunch of stuff automatically? Do you know

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that? I don't know.

2 MR. STACK: I'm not sure of that detail,
3 John.

4 CHAIRMAN ABDEL-KHALIK: Now, what do
5 these dump valves automatically -- what signal
6 automatically actuates those dump valves?

7 MR. STACK: When we look at these, the
8 dump valve on the main steam relief train, really
9 what they're triggering on is an SI actuation. So
10 really their real purpose in life as far as the
11 initial accident mitigation is really supporting
12 safety injection. So they're starting on an SI
13 signal, which is basically starting on low RCS
14 pressure.

15 MEMBER BROWN: Do you initiate all four?

16 MR. STACK: All four are initiated, yes.

17 MEMBER BROWN: And excuse my next
18 question. This might be ignorance speaking. I'm a
19 Naval nuclear background, and are you dumping? When
20 you talk about an atmospheric dump, is that outside
21 the containment?

22 MR. STACK: It is.

23 (Simultaneous conversation.)

24 MR. STACK: It's outside containment,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 yes.

2 MEMBER BROWN: For 30 minutes from the
3 affected steam generator?

4 MR. STACK: Yes, yes.

5 MEMBER STETKAR: There will be a release
6 to the atmosphere during a tube rupture event.

7 MEMBER RAY: It's either that or put in
8 high-head safety injection pumps. That's your
9 choice.

10 MEMBER SIEBER: wear your mask and use
11 your earplugs.

12 MEMBER BROWN: Now, you made it sound
13 like you've got similar type stuff on the operating
14 plant today. Is that true?

15 MEMBER RAY: I can't speak for everything
16 in the world, but this is new to my experience, but I
17 understand it nevertheless.

18 MEMBER STETKAR: Remember though the
19 emergency operating procedures for operating plants
20 allow you to blow from the ruptured steam generator
21 as long as the releases are analyzed.

22 MEMBER RAY: Well, that's why I said,
23 John, we just need to --

24 MEMBER STETKAR: They allow you to. It

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 isn't automatic.

2 MEMBER RAY: We need to think about this
3 more. It's not intuitive. This isn't the place to
4 try to run it to ground.

5 MEMBER SIEBER: This ends up with a
6 smaller release.

7 MR. STACK: That's correct.

8 MEMBER RAY: Well, it depends what you
9 mean by a conventional plant. Not all plants, from
10 the affected steam generator, but let's leave it that
11 way now, right?

12 MEMBER SIEBER: Okay.

13 MEMBER BROWN: Okay. Let me further
14 examine my level of ignorance here. Based on what
15 Bill just told me, as long as you meet all of your
16 dose limits, then it's just perfectly okay to blow
17 all of the stuff out into the atmosphere --

18 MEMBER RAY: Yes, yes.

19 MEMBER BROWN: -- and have it spread
20 around with the population.

21 MEMBER RAY: "Perfectly okay" isn't the
22 word I would use.

23 (Laughter.)

24 MEMBER BROWN: Well, I mean, that's what

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 it sounds like. I mean we don't do this today.

2 MEMBER SIEBER: It's permissible.

3 MEMBER RAY: It's permitted.

4 MEMBER BROWN: I just need to discuss it
5 later is all. This isn't --

6 MEMBER RAY: I will discuss it later.
7 This sounds like a terrible idea.

8 MEMBER POWERS: You get a release on a
9 steam generator tube rupture almost invariably.

10 MEMBER BROWN: Not if you don't blow it
11 outside the containment. It's not as bad.

12 MEMBER POWERS: Pretty much ipso facto a
13 steam generator tube rupture is going to give you a
14 blowout.

15 MEMBER BROWN: As much as this?

16 MEMBER SIEBER: Yes.

17 MEMBER POWERS: And more.

18 MEMBER BROWN: In today's operating
19 plants.

20 MEMBER POWERS: Today's plants.

21 MEMBER BROWN: I think that sounds like
22 blowing smoke, but you're doing a good job, Dana.
23 Thank you.

24 CHAIRMAN ABDEL-KHALIK: I guess we'll get

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 to see more of this when we talk about Chapter 15?

2 MR. STACK: Chapter 15.

3 CHAIRMAN ABDEL-KHALIK: So let's proceed.

4 MEMBER BROWN: We're taking notes.

5 CHAIRMAN ABDEL-KHALIK: Thank you.

6 MEMBER STETKAR: The interesting thing
7 about this design though that is a bit different from
8 the ones I've seen is that this design keeps the
9 isolation valve closed and the control valve normally
10 open. So when you control the cool-down, you pop the
11 isolation valve open and you have to basically
12 control the cool-down by throttling down on the
13 control valve. It's a little bit different than
14 having the isolation valve open and the control valve
15 coming open.

16 Just think about Dr. Banerjee and his
17 things about overcooling transients and stuff like
18 that.

19 MR. STACK: Very good. Next I'll move on
20 to the liquid side, and we look at our emergency
21 feedwater trains. We have four separate trains, and
22 when you look at a train of these, I'll just start at
23 this one here. We have suction from an emergency
24 feedwater tank, and this equipment is housed within

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 the safeguards building. There's suction from here.

2 It's going to go directly to the suction of the
3 pump. The pumps are nominally 400 gpm of ejection
4 flow.

5 They'll then go through, if I can get my
6 pointer to work, they'll then go through a flow
7 control valve, a level control valve and an isolation
8 valve in their path to the steam generators.

9 What I have on the last point here, you
10 will also see cross-connects, which are normally
11 closed on the suction side of the pump and on the
12 discharge side of the pump, which allows you to have
13 all your water sources available to you and allows
14 you to connect an individual EFW pump to an intact
15 steam generator, and that's providing more
16 flexibility in the design that way.

17 And on these, these are motor driven
18 pumps, all four of them.

19 VICE CHAIRMAN ARMIJO: What pressure?
20 Are these medium pressure, high, low pressure?

21 MR. STACK: They're medium pressure.
22 Nominally they're going up to -- oh, they're going up
23 to 15 or 1,600 pounds, just somewhat higher than what
24 you would see in the operating plants, which tend to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 be in the 12 to 1,300 pound range for their shutoff
2 head.

3 As far as power sources on these, you'll
4 have, for each of these, you'll have a normal power
5 source from an off-site source, and you'll have an
6 emergency diesel generator backing them. In
7 addition, two of the four have station blackout
8 diesel generators backing them such that you have a
9 number of sources of power to the emergency feedwater
10 pumps.

11 We'll move on to protection from the
12 external hazards. In our protection from the
13 external hazards, what we have is in this building
14 we're showing a portion of the containment building.

15 There is an inner wall of the containment that's
16 post tensioned concrete with a quarter inch carbon
17 steel liner.

18 We also have an outer wall of reinforced
19 concrete that's nominally, depending on location,
20 give or take between four and six feet thick.

21 The outer shield structure is really
22 providing protection against external pressure waves
23 as well as airplane crashes. On our next slide, I'll
24 show you which portions actually have this physical

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 protection.

2 And in between the outer containment or
3 outer shield structure and the containment, there is
4 an annulus where we have two-by-100 percent capacity
5 filtration for dose control.

6 With regards to the protection from the
7 external hazards, we've not protected all portions of
8 the plant with a shield structure. There's a
9 combination in protection that includes shield
10 structure, which are shown in blue; protection by
11 physical separation, in gray; and then no protection
12 at all that's shown in white. And I'll go through
13 these in a little bit more detail.

14 In terms of the physical protection where
15 we have a shield structure, it includes the
16 containment building, which was again showing
17 diagrammatically on the previous slide; the fuel
18 building; Safeguards 2 and 3. And in Safeguards 2
19 and 3, they house the main control room and the
20 remote shutdown station. So all of those structures
21 have a shield structure to them.

22 Relative to the ones that are not
23 contained in the shield structure, we have Safeguards
24 1 and 4. We have the Diesels 1 and 2 on this side,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 the Diesels 3 and 4 on this side, and we have the
2 cooling towers, ultimate heat sink cooling Towers 1
3 and 2 down here and 3 and 4 up here.

4 The ones that are shown in gray are
5 protected by physical separation such that we will
6 never lose more than two trains from any airplane
7 crash, whether it's into the shield structure or
8 whether it's into an unprotected area.

9 MEMBER CORRADINI: I'm sorry. Maybe you
10 said it and I just wasn't catching it. So none of
11 the diesels are protected in the blue?

12 MR. STACK: None of the diesels are.
13 Here are one and two; and here are three and four.
14 they are not physically protected with a supplemental
15 shield structure.

16 MEMBER CORRADINI: They are protected by
17 physical --

18 MR. STACK: From airplane crash they're
19 protected by physical separation. Obviously they'll
20 have protection against tornado and missiles and
21 things like that.

22 MEMBER CORRADINI: That's what I thought
23 you meant. I didn't --

24 MR. STACK: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 VICE CHAIRMAN ARMIJO: Why aren't Trains
2 1 and 4 protected by the shield building? Is the
3 structure less rugged than the ones protecting two
4 and three?

5 MR. STACK: When you sit back and look at
6 the designs of these, this is shown in containment
7 where you have an inner containment and an external
8 shield building.

9 VICE CHAIRMAN ARMIJO: Yes.

10 MR. STACK: When you move down to the
11 safeguards building and fuel building, they're
12 similar to that. They have a supplemental shield
13 structure which is physically separate from the
14 normal structure of the building.

15 VICE CHAIRMAN ARMIJO: But you did not
16 put that separate structure --

17 MR. STACK: We did not put that separate
18 structure on one and four.

19 VICE CHAIRMAN ARMIJO: -- on one and
20 four?

21 MR. STACK: Again, we need two trains to
22 remain free of damage, and in these cases, you know,
23 if we had an airplane crash that affected Safeguard
24 4, we would still have two and three protected.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER SHACK: You can see it in blue on
2 Slide 6.

3 VICE CHAIRMAN ARMIJO: Yeah, I understand
4 what they're doing now. Thank you.

5 MR. STACK: Severe accident mitigation.
6 Really for the severe accident mitigation features,
7 I'll just high level overview. This is really
8 covering the phenomena from severe accident covered
9 in SECY 90-016 and SECY 93-087. Just at a very,
10 very high level, and we will be having a presentation
11 on severe accident features coming in April, April
12 21st, to cover those features in more detail.

13 Just at a very high level, for the EPR
14 what you have is there's a high pressure core melt,
15 high pressure core melt depressurization system that
16 had two trains where we're trying to get the target
17 pressure below 200 pounds and prevent direct
18 containment heating.

19 We have a passive ex-vessel melt
20 stabilization conditioning and cooling system. When
21 we look in this area here we will actually, hold up
22 outside of the vessel, we will hold up the core melt
23 for a period of time before it's directed into a
24 cooling channel and down into a cooling pool, if you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 wish.

2 Beyond that, we will have long-term core
3 melt cooling where we have active cooling with the
4 severe heat removal spray that we showed.

5 MEMBER CORRADINI: That's the blue line.
6 The blue line showed --

7 MR. STACK: The blue line, yes. This
8 is --

9 MEMBER CORRADINI: -- on the previous
10 one. Yeah, that's fine. You don't have to again.

11 MR. STACK: That is this one right here.

12 MEMBER CORRADINI: Okay.

13 MR. STACK: So basically that blue line
14 will provide direct cooling of the corium in this
15 area as well as spraying it out into the containment
16 for depressurization and will also have passive
17 autocatalytic recombiners to handle the hydrogen.

18 MEMBER CORRADINI: In your first bullet,
19 is that depressurization system different than what
20 maybe I mis-remember what I might call the crash
21 cooling system that you have in the plant, or are
22 they one and the same?

23 MR. STACK: When you sit back and you
24 look at these -- do you want to answer, John?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER STETKAR: He was asking about MSR
2 main steam relief trains versus --

3 MR. STACK: Oh, okay. This is on the
4 primary. Yeah, this is all in the primary. This is
5 sitting on the pressurizer.

6 MEMBER CORRADINI: Ah, so this is on the
7 pressurizer versus simply just cooling down the
8 secondary to get the pressure down.

9 MR. STACK: Yes, this is all in the
10 primary.

11 MEMBER CORRADINI: thank you. Thank you
12 very much.

13 CHAIRMAN ABDEL-KHALIK: Now, I'd like to
14 point out that you are at the end of your allotted
15 time. However, given the level of questions that
16 have been raised so far, I would like to give you
17 some extra time. How much time do you think you'll
18 need?

19 MR. STACK: As far as the overview is
20 concerned, which was supposed to have been done 30
21 minutes ago, I'm done. We're ready to turn this over
22 to Mr. McIntyre.

23 MR. MCINTYRE: I'm just going to go very,
24 very quickly through the chapters.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 CHAIRMAN ABDEL-KHALIK: All right.
2 Please go ahead.

3 MR. MCINTYRE: Okay. With that, thank
4 you, Tim.

5 Tim has just talked about it at a pretty
6 high level, the design features. It's an
7 evolutionary plant. It's an active plant. It's
8 really, you know, fundamentally not significantly
9 different.

10 If you look at the number of exemptions
11 and exceptions that we have in the applicant, we had
12 1.2 exemptions. One is for M5 fuel, which is an
13 AREVA specific fuel cladding, and it's not in the
14 rules. So we have to ask for an exemption even in
15 operating plants whenever we use it, and we have had
16 an exemption for the dedicated containment vent for
17 severe accidents. That came through in an RAI and as
18 a result of the RAI, we're taking credit for a 36
19 inch vent that's there. So we've taken that
20 exemption away.

21 Now, this is not a passive plant. So
22 there's no RTNSS. There's no focused PRA. There's
23 none of that stuff that you've been talking about on
24 some of the previous applications or in my previous

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 life.

2 MEMBER STETKAR: There is a DRAP list
3 though.

4 MR. MCINTYRE: Yes. We'll get to that.

5 And because it is not significantly
6 different, there's no unusual design features that
7 forced us into special analysis methods or testing
8 requirements. I think there has been a question over
9 there. Do we have something on the accumulators that
10 juggles the -- that juggles? -- that moderates the
11 flow, and the answer is, no, we don't have fluid
12 diodes.

13 What we did in preparation, we started in
14 2005 and 2006 of trying to get a leg up with the
15 staff, of getting them a fundamental understanding of
16 the plant. We put together a report that wasn't for
17 review. It was just sort of a primer, if you will,
18 on the unique design features of the plant. We had
19 meetings with the technical staff. We submitted 15
20 topical reports for this that covered I&C, QA, the
21 set point methods, the fuel, human factors, piping
22 analysis methods. Some of those have since turned
23 into technical reports rather than topical reports.
24 If it's a topic report, the staff has got to write a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 safety evaluation report, which is good if you're
2 going to reference it on another application. This
3 is just for the EPR. So really the SER may not be
4 that valuable.

5 And we also set up a local office which
6 we hadn't had here before so that we could have
7 technical information here for the staff to go over
8 and audit or conduct, you know, brief, quick meetings
9 with the technical proprietary information.

10 The format of the FSAR, when you're
11 reading it, it follows pretty much Reg. Guide 1.206.

12 Sort of the challenge there is that's for a combined
13 license applications and we're a design certification
14 application, and what we've tried to do is to cover
15 the information that you'd expect to see in the
16 design certification, that the COL applicant would do
17 what they call incorporate by reference.

18 So if you're looking at Reg. Guide 1.206,
19 you'll see things that we don't have because we're
20 not there yet. Like we don't have the material certs
21 for the turbine. You wouldn't expect us to.

22 And for the standard review plan, we did
23 provide the staff a technical report that was
24 basically a summary of do we meet the standard review

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 plan or not, and we want to be up front about that.
2 We don't want them to be sitting there figuring,
3 well, do they meet it or not, but here's what we
4 think. If we don't meet it, here's why it's okay to
5 not meet it or, if we meet it, here's why we meet it
6 and how we meet it, and that's really kind of a good
7 road map for the staff when they're going through
8 their review.

9 CHAIRMAN ABDEL-KHALIK: Now, I notice
10 that all numbers given in the FSAR are given in both
11 SI and British units, and the question is will COL
12 applicants be required to declare a set of units to
13 use?

14 MR. McINTYRE: I don't think they all
15 are. That's another application.

16 CHAIRMAN ABDEL-KHALIK: They aren't?

17 MR. McINTYRE: No, ours --

18 CHAIRMAN ABDEL-KHALIK: The ones I saw
19 are mixed.

20 MEMBER POWERS: Can you tell me why is
21 that even vaguely important?

22 CHAIRMAN ABDEL-KHALIK: That is very
23 important.

24 MEMBER POWERS: It cannot possibly be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 important.

2 CHAIRMAN ABDEL-KHALIK: Because --

3 MEMBER POWERS: I'm sure there's some
4 arcane reason.

5 CHAIRMAN ABDEL-KHALIK: No, it's not
6 arcane. It's practical reasons. If people are using
7 mixed units, there is room for misinterpretation and
8 with misinterpretation of the units of specific
9 quantities in tech specs --

10 MEMBER POWERS: I'm going to take over
11 the timing on this meeting and say let's settle that
12 elsewhere.

13 CHAIRMAN ABDEL-KHALIK: Well, I think
14 this is a very important issue, and I think the staff
15 ought to be aware of it.

16 MEMBER POWERS: Staff, please take note.
17 Let's move on.

18 MR. McINTYRE: Chapter 2. The topics
19 listed are, in each of the following sites, are what
20 the SRP requires. You've got to cover these things,
21 these areas.

22 The design parameters that you'll find in
23 the FSAR, they're pretty close to what were in the
24 utility requirements document that EPRI put together

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 years ago, and we've gone through and we tweaked them
2 where we needed to to make sure that they covered the
3 plants that had the sites that were going to have an
4 EPR built if there was any changes that needed to be
5 made to it.

6 And essentially Chapter 2 is a large,
7 combined license information item that here are the
8 parameters. You need to make sure that your site
9 fits within that list of parameters.

10 Chapter 4. The topics are from the SRP,
11 as Tim has talked about the design features. He
12 talked about and mentioned earlier having submitted a
13 number of topical reports. One, oh, two, six, three
14 PA is code for the code applicability report that we
15 turned into the staff, and we did get an SER on that.

16 And our purpose of turning that in was if
17 we're going to do a lot of safety analyses, and from
18 my standpoint spend tens of millions of dollars, we
19 want to make sure that the staff is in fairly
20 fundamental agreement on the codes and methods that
21 we're using, and so that was one of the proactive
22 things that we did.

23 The differences in Chapter 4 and the 14
24 foot fuel, that's really not unique for the EPR.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Other plants have 14 foot fuel. N4 has 14 foot fuel.

2 The thing that we had to do was to go around the
3 critical heat flux testing and develop our own CHF
4 model because that wasn't --

5 MEMBER CORRADINI: That's the main point
6 you're -- that's the main reason you're identifying
7 this here, right?

8 MR. MCINTYRE: Yes.

9 MEMBER CORRADINI: Okay. I'm just trying
10 to remember if anything in the country, in the U.S.,
11 is 14 foot.

12 MR. MCINTYRE: South Texas.

13 MEMBER CORRADINI: South Texas is?

14 MR. MCINTYRE: Yes.

15 MEMBER CORRADINI: Okay. I thought none
16 were. Sorry. Thanks. Fine.

17 MR. MCINTYRE: That's it. We have a lot
18 more experience with, "we," big AREVA, with 14 foot
19 cores because we've got the N4 units.

20 MEMBER CORRADINI: Right, right. Okay.
21 So it's mainly CHF.

22 MR. MCINTYRE: Un-huh.

23 MEMBER CORRADINI: Okay. Thank you.

24 MR. MCINTYRE: We have a heavy reflector

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 which is really new to plants, but if you're a new
2 plant designed, people that are coming through that's
3 not so new anymore reduces vessel fluence and affects
4 the fuel cycle.

5 We have Aeroball Measurement System, and
6 again, that's while it's new here. The Siemens units
7 have been using it since 1974. So there's a fair bit
8 of experience with that, but that will be the first
9 of a kind in this country.

10 And something that's a little different
11 is that the DNB and the linear heat generation rates
12 are through a continuous power mapping. So it's
13 through a calculation, and if you look at the tech
14 specs, you'll see some things that are a little
15 different in the tech specs because we don't have
16 specific DNBR numbers. It goes into a computer and
17 it does a calculation of DNBR. It's sort of an on-
18 line process. So that is something that is going to
19 be different that we'll talk about when we get to
20 those chapters.

21 Chapter 5, as Tim showed you, it's a
22 standard four-loop PWR, U-tube steam generators, four
23 reactor coolant pumps, and again, it's a difference -
24 - there's no penetrations in the bottom of the head.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 It's a maintenance issue. It's a radiation exposure
2 issue. So we have a different approach for that.

3 Tim talked about the pressurizer safety
4 relief valves, and Alloy 690 -- no, 600 in the plant.

5 It's just pretty much, again, a standard plant.

6 Chapter 8, electrical. The good news
7 about Chapter 8 is there were no open items in the
8 safety evaluation report. So that was really good
9 news for us.

10 If there are no open items, Getachew, is
11 that through Phase 4?

12 MR. TESFAYE: That's true.

13 MR. MCINTYRE: Yes. So that's really a
14 super thing.

15 Tim talked about the four emergency
16 diesels, talked about the alternate feeds, island
17 mode operation. This unit has 100 percent load
18 rejection and can be kept running if the grid goes
19 down so it can be used to start the grid back up and
20 have a power source. That's going to be really
21 different.

22 Chapter 10, steam and power conversion.
23 Again, Tim has talked about the first two sets of
24 bullets. He talked about a difference is we do not

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 have a mechanical over-speed trip. It's redundant in
2 diverse electrical trips for the turbine. He talked
3 about the main steam generator or main steam relief
4 train.

5 I don't know if he mentioned this, but we
6 do not start up with aux feed. We have a separate
7 start-up feed system, non-safety related, and he did
8 mention that we have the feedwater pumps. There's no
9 turbine driven pumps. They are all about motor
10 driven pumps, and that really improves the
11 reliability of the plant.

12 Chapter 12, it's really kind of neat, I
13 think, to see this because in Chapter 12, and if you
14 start thinking about radiation doses and exposures
15 when you're building the plant, you can really make
16 some huge differences in the design of the plant and
17 keep the dose down.

18 So things are significantly more
19 compartmentalized. This plant has a lot of rooms.
20 If you start looking at the diagrams, you can see
21 that this plant really has a lot of rooms because
22 things are built to keep high radiation areas away
23 from other areas and they are trying to keep them
24 also as small as possible.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 And they also have dedicated ventilation
2 systems to try to reduce the chance of cross-
3 contamination between clean areas and dirty areas.
4 We've tried to reduce cobalt. Permanent shielding is
5 in place. If you go in, it's not stuff that when
6 you're doing maintenance on the plants you've got to
7 go in and move stuff in to do maintenance.

8 And basically what we did was that it was
9 applying ALARA as you went through the design process
10 of how could you do this and make the plant easier to
11 maintain and, quite honestly, keep the dose down.

12 The 50 person rem is a three-year average
13 and includes an outage.

14 Chapter 17, one of the topical reports we
15 had was the QA plan. It was important to get that in
16 again because we're going to work to this plan
17 because we're going to be doing all of this work. We
18 got this back in 19 -- excuse me -- in 2006 before we
19 turned the application in.

20 Reliability Assurance Program that John
21 mentioned, we had much discussion of that during the
22 subcommittee, and the questions were the DRAP, design
23 reliability assurance program, and as the design
24 certification guys, it's our view that the DRAP and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 it's really kind of a short-sighted view, I guess I'd
2 go so far as to say; the DRAP ends with design
3 certification, and even though the design process
4 goes on for years, after the COLA is issued the D
5 part of the DRAP is ongoing.

6 And at design certification time we are
7 able to tell you what the important structures and
8 systems are, but we can't talk about components
9 because we haven't got it down to that level yet, and
10 we don't have the PRA. We haven't done the expert
11 panel. We haven't done all of the things that you
12 need to do in the DRAP.

13 Lynn Mrowca has put together a -- and I
14 don't have it -- she's put together a better slide
15 that explains it, showing that the DRAP goes out over
16 a period of time because John's concern was how do
17 you do the hand-off to the people that are going to
18 be doing the component evaluations, and I think we've
19 got a better story on that.

20 We understand now why we were struggling
21 answering your question because we're not going to
22 get to that in design certification time, but it does
23 get done.

24 MEMBER STETKAR: It will essentially be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 handed over to the COLA.

2 MR. MCINTYRE: Right, and we've had a
3 better idea of how that handoff works and they have a
4 better idea of what's going to be coming their way
5 and the staff has a better idea of exactly how this
6 process should work because this is something that
7 hasn't been -- the DRAP is a new thing. Actually I
8 was kind of surprised that we were struggling in
9 this, being the fifth or sixth design certification,
10 that we were having some pretty fundamental questions
11 of how this thing worked.

12 MEMBER STETKAR: You're doing it in real
13 time. The other folks didn't have to do it in real
14 time. That's the problem.

15 MR. MCINTYRE: That's true. That's
16 right. It was easier the first time I did it. I was
17 "no, never mind," and we do have --

18 MEMBER STETKAR: It was later.

19 MR. MCINTYRE: yes. We do have the DRAP
20 list in the application, and the maintenance rule is
21 basically a combined license applicant activity
22 because you don't have the maintenance rule during
23 design certification until after the plant is
24 operating.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 And that concludes our prepared
2 presentation.

3 MEMBER POWERS: Any questions that you --
4 any more questions that you have? They won't ask him
5 questions, Tim. Only you.

6 MR. STACK: I noticed that, Dana. I made
7 great efforts to not learn the details of this plan.

8 (Laughter.)

9 MR. STACK: I know what happened last
10 time.

11 MEMBER POWERS: All right. At this point
12 we would turn it over to staff. We'll run through a
13 fairly summary description of where they stand on the
14 chapters we've looked at. There are, with the
15 exception of one chapter, there are open items in
16 each one of the chapters, but the staff will assure
17 us that none of the open items appear to us at this
18 stage to represent major hurdles. In many cases they
19 are formal opens.

20 Getachew.

21 And thank you very much. I really
22 enjoyed your presentation.

23 MR. MCINTYRE: It's good to be back. I
24 appreciate all of the questions on the tube rupture.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER POWERS: Now you know that that
2 will get some discussion.

3 MR. MCINTYRE: I'll put that on --

4 MEMBER POWERS: We'll get to it.

5 MR. TESFAYE: Good morning again. I'm
6 Getachew Tesfaye. I'm the Project Manager for EPR
7 design certification review, and Jason Carneal here
8 is my right hand. He has three difficult chapters.
9 So he's going to help me with the slides.

10 None of my presentation involves
11 technical issues. I'm just going to give you an
12 overall overview of the project process, some of the
13 strategies we employed in our review, and some of
14 them will be repetitive because Brian has mentioned
15 some of our strategies. But I will go ahead and
16 mention them from our perspective.

17 Next slide, please.

18 This slide shows a major milestone
19 chronology for this project. As Brian mentioned,
20 this project started back in 2004, December of 2004,
21 with pre-application activities. There was two phase
22 pre-application activity, and the first phase lasted
23 about a year. The AREVA personnel introduced their
24 plant, the unit design features through various

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 presentations.

2 And then the second phase they submitted,
3 as Brian mentioned, about 15 topical reports and four
4 technical reports for the staff's review. So that
5 was a very productive pre-application activity.

6 Of course, the major milestone here, the
7 design certification was submitted in December,
8 December 11th, 2007. That's a little bit over 2
9 years old now, the design certification review.

10 Now, we completed Phase 1 review exactly
11 a year later on time, and AREVA submitted Revision 1
12 of the FSAR in May 2009. This was essentially to
13 incorporate some of their commitments that they made
14 when they responded to some RAI questions.

15 And beginning last summer through March,
16 we completed Phase 2 review of ten chapters, Chapters
17 2, 4, 5, 8, 10, 11, 12, 16, 17 and 19.

18 MEMBER CORRADINI: Just for my memory,
19 the difference between two and three is three has an
20 SER with open items. Two is just back and forth with
21 the applicant?

22 MR. TESFAYE: No. You mean the phase?

23 MEMBER CORRADINI: Yeah. I just can't
24 remember. I'm sorry.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. TESFAYE: I'll go over that. There a
2 next slide. Okay>

3 MEMBER CORRADINI: Sorry.

4 MR. TESFAYE: Phase 3 is actually the
5 subcommittee presentation, is Phase 3. I'll show you
6 in the next slides.

7 Next slide, please.

8 MEMBER CORRADINI: Thank you.

9 MR. TESFAYE: This is the current review
10 process. It has got the various phases, six phases.

11 We just issued this on February 16. The main reason
12 for revising the schedule was because of what we call
13 phase discipline. We would like to get the main
14 technical issues resolved in Phase 2 before we move
15 to Phase 3. As a result of that, the Phase 2 review
16 was delayed by six months, from June through December
17 of this year. That translated into, I believe, a
18 four-month delay in the overall six-phase review.

19 Next slide, please.

20 Now, here I'd like to go over some of the
21 strategies we employed in this review. As I
22 mentioned, our application activities was very
23 instrumental in getting the staff to know what the
24 plant is like. We also employ a lot of interaction

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 with the applicants, frequent teleconferences,
2 audits, and as Brian mentioned, AREVA has a local
3 office where they make some technical documents that
4 are not normally docketed in their offices. So the
5 staff has very easy access to all their back-up
6 calculations, and so that was very instrumental.

7 And of course, we hold several public
8 meetings where the staff has to give feedback to the
9 applicant.

10 And use of electronic RAI has been very
11 instrumental. We issue RAIs using e-mails, and AREVA
12 provides using e-mails. So that has made it easier
13 for the staff to ask for the questions they want to.

14 (Laughter.)

15 MR. TESFAYE: Now, this is the last one.

16 The last item here, phased discipline, is something
17 that I'd like to raise here because this is very
18 important. This is what Dr. Powers indicated why we
19 leave RAIs as an open item.

20 First, discipline is the act of orderly
21 completion of all activities within a phase prior to
22 transitioning to the subsequent phase. Open items
23 are to be limited to those issues that have a well
24 defined scope and are likely to be resolved with one

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 applicant's response to the open items. That's not
2 usually the case, but at least we try to get one
3 response to reserve open items.

4 In phase 1, discipline requires all RAIs
5 on the original submission be written and issued to
6 the applicant and that preliminary safety analysis
7 report developed for internal use. The completion of
8 both activities allows the task to transition to
9 Phase 2. In other words, the staff will have to ask
10 all the questions for the first time in Phase 1, and
11 in Phase 2 we started receiving the responses. If we
12 like the responses, we close them and move on. If we
13 don't like the responses and we find the issues
14 significant, then we extend Phase 2. We don't get
15 out of Phase 2.

16 And in Phase 2, the phase discipline
17 requires two specific activities to be completed
18 prior to transition of the task to the next phase.
19 The first is the closing of RAIs with the applicant's
20 responses and identification of the open items. In
21 the event that some responses are incomplete and
22 require supplemental RAIs or considerable new design
23 information is submitted in response to the RAIs.
24 The activity should be retained in Phase 2 and Phase

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 2 will be extended, and that's precisely what
2 happened when we changed the schedule recently,
3 because some of the RAIs that were not answered
4 properly or took longer to respond to we could not
5 get out of Phase 2 with those RAI questions being an
6 open item.

7 So this is really the crux of our review,
8 as discipline is very, very important.

9 MEMBER POWERS: And what I can say from a
10 Subcommittee point of view, by the time they come to
11 bring something to us, that when there are open
12 items, they can fairly clearly articulate what the
13 open item is and what they foresee is the path to
14 resolution. So we're not getting hung up on a lot of
15 things just misunderstanding what each other is
16 talking about. It has really made things much
17 easier.

18 MR. TESFAYE: Now, from this point on
19 what I'll give you is the high level summary of the
20 seven chapters that were completed prior to this
21 week. I don't want to go through any details, but in
22 Chapter 2, start generated 45 RAI questions and 13 of
23 them are left open, and we're closing some of them as
24 we speak.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Next slide, please.

2 Chapter 4 has one. Staff requested 104
3 questions, and 14 of them are left open. One of the
4 items that's left open is the topic of the report as
5 we discussed that involves the mechanical fuel
6 design, and again, discusses a clear path forward.
7 That's why we left that open.

8 Next slide, please.

9 Chapter 5, we generated 127 RAI questions
10 and we have only 25 left.

11 CHAIRMAN ABDEL-KHALIK: I guess I'm
12 wondering what is it that you're trying to convey to
13 us by giving us the number of RAIs that you have
14 asked and the number of RAIs that remain open. What
15 sort of detailed technical information are you
16 conveying to us by giving that kind of table?

17 MR. TESFAYE: Zero.

18 CHAIRMAN ABDEL-KHALIK: So why?

19 MR. TESFAYE: This is just an overview
20 from the project's perspective. It will give you an
21 idea of the extent of the review that has taken place
22 by the number of questions that we've asked and by
23 the number of items that are left open. So this is
24 just to give you an idea of the high level summary of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 this task finding. It doesn't have, like I said --
2 this is from the project's perspective, and we don't
3 have any technical people to support us to discuss
4 the open items if that's what you're looking for.

5 But those open items are discussed in
6 detail and discussed at the Subcommittee level.

7 CHAIRMAN ABDEL-KHALIK: So if that is the
8 case do you expect the Committee's review and/or the
9 Committee's letter to be void of technical
10 commentary?

11 MR. TESFAYE: No, no, no, no. Like I
12 said, this presentation gives you the summary of the
13 open items, the number of open items, the number of
14 questions. It doesn't give you the nature of the
15 technical nature of the open items. That was
16 discussed in the Subcommittee, and the Subcommittee
17 report, of course, will have those technical
18 discussions.

19 MEMBER POWERS: I think that's a fair
20 statement. The chapters where the Subcommittee has
21 had significant comment, we have not brought those
22 forward to you here. They're still going through
23 regurgitation. Here I think the substance of the
24 thrust is the Subcommittee generally agrees that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 those things they've listed as open items are open
2 and there is a clear to resolution on them.

3 I don't know that we've taken a vote on
4 every single one of them, but we certainly haven't
5 flagged them as anything that is in your list is
6 where we disagree with your assessment on the
7 situation. I think that's a fair statement.

8 VICE CHAIRMAN ARMIJO: Well, clearly, in
9 all of these open items there must be a few that are
10 significant, not just procedural or administrative.
11 The answer is no? There's no big deal? There's no
12 problem?

13 MR. TESFAYE: Most of them are
14 clarifications.

15 MEMBER POWERS: Yes.

16 MR. TESFAYE: Most of them are
17 clarifications. Nothing significant in the chapters
18 that were presented so far, and again, it's very
19 important to emphasize if the staff doesn't see any
20 clear path forward, we don't leave them open. We
21 extend the review process, the review schedule.

22 MEMBER POWERS: There's one on the
23 previous section where you have to do an SER on a
24 topical report, and the only reason that it is open

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 is that the SER isn't done yet.

2 MR. TESFAYE: That's right.

3 MEMBER POWERS: And as soon as it's done,
4 then they come off.

5 VICE CHAIRMAN ARMIJO: That's an SER on
6 the fuel mechanical design topical report?

7 MR. TESFAYE: Mechanical design, yes.

8 VICE CHAIRMAN ARMIJO: Will we see that?
9 Will the Subcommittee see it?

10 MEMBER POWERS: To the extent that we
11 wanted to go through it, which means to the extent
12 that you want to go through it as a matter of fact.

13 VICE CHAIRMAN ARMIJO: Could I get a hold
14 of it just to take a look at that topical report? I
15 don't have it.

16 MEMBER POWERS: Oh, okay.

17 VICE CHAIRMAN ARMIJO: If I could get it,
18 I'd like to take a look at it.

19 MEMBER POWERS: Sure.

20 VICE CHAIRMAN ARMIJO: Because this is,
21 you know, a pretty evolutionary approach, and I
22 expect the fuel design is going to be pretty
23 evolutionary, too, or not much change, but I'd like
24 to see it.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER POWERS: Some differences, yeah.

2 MEMBER STETKAR: I think it's also
3 important to note the chapters. You know, this
4 doesn't cover Chapter 6, the safety systems. It
5 doesn't cover Chapter 7, the digital I&C. It doesn't
6 over Chapter 15, the safety analysis. So, you know,
7 a lot of the potentially really difficult technical
8 issues haven't come before us yet anyway.

9 MR. TESFAYE: That's correct. That's why
10 we completed these chapters early, on time.

11 MEMBER BANERJEE: Which chapter are the
12 sump screen issues in?

13 MR. TESFAYE: Chapter 6 and a little bit
14 of 15.

15 MR. CORNEAL: Six and a little bit of 15.

16 VICE CHAIRMAN ARMIJO: So we haven't
17 gotten that yet.

18 MR. CORNEAL: Downstream effects are in
19 Chapter 15.

20 MEMBER BANERJEE: This is a low fiber
21 plant?

22 MR. CORNEAL: Yes. That's what the
23 applicant is claiming.

24 (Laughter.)

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. CORNEAL: There's some trouble with
2 the definition of what is a low fiber plant.

3 MEMBER BANERJEE: Well, there's enough
4 latent debris to cause trouble, anyway.

5 MR. CORNEAL: Yes, and that's one of our
6 very active review areas at this point based on
7 performance.

8 CHAIRMAN ABDEL-KHALIK: I guess this is
9 an internal discussion that the Committee will have
10 to have to decide the level of technical rigor and
11 content that is presented to the full Committee vis-
12 a-vis the Subcommittee. So given that you've had
13 directions from the Subcommittee as to how to make
14 this presentation, I urge you to proceed.

15 MR. TESFAYE: Thank you.

16 Next chapter, Chapter 8 is one of the
17 cleanest chapters. This is essentially done. We are
18 in Phase 5 for this you can say because there are no
19 open items to close in Phase 4. There was no open
20 item. The staff asked 49 RAI questions and all of
21 them were closed.

22 Chapter 10, 75 RAI questions and 12 of
23 them are still open, and again, most of these open
24 items are clarification, nothing technically

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 significant.

2 MEMBER BROWN: I just have one question
3 on Chapter 8.

4 MR. TESFAYE: Yes, sir.

5 MEMBER BROWN: When I looked at it, and
6 this is only from a difference from what was observed
7 in two of the other designs. There's something
8 called a NAT, normal auxiliary transformer, set-up
9 and then a UAT or EAT. I don't know, some other
10 transformer set-up.

11 In other words, power for the plant
12 support services do not come from the main generator.
13 They come off the main grid out of the switchyard,
14 which is obviously the generator supplied in there.
15 That seemed to be a major difference between at least
16 the other couple of designs.

17 I don't know that that's consistent with
18 any other commercial plants today. It is, John? I
19 mean, I had not seen any in the design cert, and
20 plants I'm familiar with we obviously supplied our
21 own power in the Navy ships.

22 (Laughter.)

23 MEMBER BROWN: No long cables coming out
24 to us. So we had no choice. Does that --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER SIEBER: They have investment
2 protection diesel.

3 MEMBER BROWN: Yeah, well, I guess that's
4 -- I mean, if you have a station blackout or where
5 everything goes out, you've still got the UPSIS
6 (phonetic) before you --

7 MEMBER SIEBER: What do you need, turbine
8 oil?

9 MEMBER BROWN: I had no idea what was in
10 the other conventional plants today. So I thought
11 I'd ask the question just to learn something new in
12 the process. I think my compatriots and colleagues
13 have answered my question.

14 MR. TESFAYE: Thank you.

15 We'll move to Chapter 12 please.

16 Chapter 12, 26 RAI questions and then of
17 them are still open.

18 Chapter 17, 26 RAI questions. Only two
19 of them, actually one of them is just to track an
20 inspection that the staff is planning to do under QA
21 activities. Again, Chapter 17 heavily relies on the
22 topical report that was previously approved. So not
23 a whole lot of questions were asked. And Brian has
24 discussed the main topic of discussion during the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Subcommittee presentation.

2 And the last slide kind of gives you an
3 overview of where we're at in terms of Subcommittee
4 presentation. The left column has Groups 1 and 2
5 which we completed, with the exception of 19 that we
6 completed this week. We presented 11 and 16 on
7 Tuesday.

8 And Group 3 and Group 4 are where we
9 expect the very detailed and very contentious
10 discussions in the Subcommittee. No? Okay.

11 MEMBER POWERS: Piece of cake.

12 MR. TESFAYE: Piece of cake.

13 MEMBER CORRADINI: So just to get back to
14 the Group 1, just to understand the way you're
15 thinking about this, this is, at least as I look at
16 it from my perspective, from another certification,
17 I'm pleased to see the organization. So there's
18 nothing in -- I think Dana characterized it as
19 there's formal open items, but you guys have a path
20 to the end game.

21 MR. TESFAYE: Yes.

22 MEMBER CORRADINI: So nothing looks as
23 anything of great concern at this point with the
24 chapters you've briefly gone over today.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. TESFAYE: None, none whatsoever.
2 Like I said, that's why I read how we defined phase
3 discipline. It's very important.

4 MEMBER CORRADINI: That's why I wanted to
5 make sure I understood.

6 MR. TESFAYE: Yes.

7 MEMBER CORRADINI: But that's fine.
8 Thank you.

9 MR. TESFAYE: That's all I have, Mr.
10 Chairman.

11 MEMBER POWERS: I think it's fair to say
12 that in the reviews of the chapters, that those
13 chapters have been presented here today. Any
14 questions the Subcommittee had were primarily ones
15 that we felt were the Subcommittee just needed
16 additional clarification; that when the Committee has
17 had significant questions that required more than
18 just clarification, we've held those back so far. I
19 mean, that's primarily 19 right now, which I think is
20 going to be completed, and that will be another
21 round. I'm not sure that I'm that optimistic on 19.

22 But my characterization of the Committee
23 and, I think, Subcommittee itself is that, yeah,
24 there's a little more information we need, but we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 don't see anything that is a major stumbling block
2 here.

3 Is that your assessment of it as well?

4 MR. TESFAYE: That's a very true
5 assessment.

6 MEMBER POWERS: Yeah. And as I said,
7 they've been very careful about bringing things to us
8 where they're really not asking the Subcommittee to
9 intrude in the resolution process. They have a
10 strategy that they're pursuing, and to the extent
11 that we have gone into those strategies, it does not
12 look like there's any formidable barriers.

13 So in truth, it has been altogether a
14 fairly pleasant exercise in going through these
15 chapters up till now. A fair characterization?

16 MR. TESFAYE: That's right, and we'll
17 keep it that way.

18 MEMBER POWERS: Or wait till we get to
19 seven.

20 If there are no other questions for the
21 speakers, that's where we stand with respect to the
22 EPR certification, and I guess we're kind of on
23 schedule. We'll turn it back to you.

24 CHAIRMAN ABDEL-KHALIK: Thank you.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(Whereupon, at 12:01 p.m., the meeting was recessed for lunch, to reconvene at 1:00 p.m., the same day.)

(12:58 p.m.)

At this time, we will discuss Item 4 on the agenda, Supplement 3 to General Electric Topical Report NEDC-33173PA, "Applicability of GE Methods to Expanded Operating Domains." And Dr. Banerjee will lead us through this discussion.

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BANERJEE: Thank you, Mr.
2 Chairman.

3 I am Sanjoy Banerjee, the Chairman of the
4 Power Uprates Subcommittee, which considered this
5 matter. And we have with us, in addition of course
6 to the ACRS full Committee members, our consultants,
7 Professor Graham Wallis, who was former chairman of
8 the ACRS, and Professor Tom Towner, and Zeyna
9 Abdullahi, who acted as our DFO, Designated Federal
10 Officer, with regard to the Subcommittee meeting, the
11 Power Uprates Subcommittee meeting.

12 Now, let me give you a little background.

13 Some of you perhaps were not here, but many of you
14 were. In around the middle of 2007, we held a number
15 of meetings related to operation in what is called
16 the expanded operating domain related to MELLLA+, and
17 considered two GEH topical reports.

18 The first was NEDC-33173P, which had to
19 do with the applicability of GE methods to expanded
20 operating domains. It was a methods topical report.

21 And NEDC-33006PA, Revision 3, which had to do with
22 the General Electric -- really with the application
23 and procedures followed in applying the methods to
24 the MELLLA+ extended operating domain.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 We wrote a letter report on June 22,
2 2007, where we recommended acceptance of both of
3 these topical reports, subject to the limitations
4 that were imposed on them by the staff, with which we
5 agreed.

6 Now, one of the limitations was that if
7 we move to different fuel designs that we would take
8 another look at the applicability of these methods.
9 I'm not going to say very much about the fuel designs
10 right now, because we are in open session. But what
11 we have now is a different fuel design, in fact
12 different part-length rods and different other
13 characteristics, which I won't go into right now.

14 In any case, this meant that we need to
15 take another look to see if the methods that were
16 developed and which we accepted back in 2007 were
17 still applicable to these -- to this new fuel design.

18 So that's what we are going to talk about.

19 We had a Subcommittee meeting on
20 March 3rd, and we looked at the Supplement 3, which
21 had to do with this GNF2 fuel design, and we are
22 going to consider now whether we are going to accept
23 it or not. That's going to be the crux of it, any
24 other recommendations that you want to make.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Out of the Subcommittee meeting came
2 several comments, which we conveyed to the staff and
3 the staff responded, and together with GE, GEH. And
4 we got very complete responses to many of the things
5 we asked. So that's the situation right now.

6 It is -- I am going to now hand this over
7 to I think Steve Philpott to take it on. And when we
8 close the meeting, please, GEH, ensure that only the
9 people who should be here should be here. This is
10 not closed yet. We are still open. We will close it
11 after you.

12 MR. PHILPOTT: Okay. Thank you. My name
13 is Steve Philpott. I'm a Project Manager in NRR in
14 the Licensing Processes Branch in the Division of
15 Policy and Rulemaking, and I have been working with
16 the technical staff here at NRC for the -- to
17 coordinate the review of this evaluation.

18 As. Dr. Banerjee has already summarized
19 for you, we are addressing in particular Supplement 3
20 for the methods topical report.

21 Just a quick summary of what we are going
22 to do. You should have four presentations in front
23 of you, or copies of four presentations. We are
24 going to start with staff from GE Hitachi, some open

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 session opening remarks, followed by a closed
2 session, more technical review of the qualification
3 of GNF2 from GEH staff. We will come back, and then
4 there's two presentations from NRC staff. Dr. Peter
5 Yarsky is going to address the scope of the review in
6 an open session, and then we will go back again to
7 closed session for a more detailed review.

8 As Dr. Banerjee mentioned, there are
9 several limitations and conditions in the methods
10 topics report, and Supplement 3 addresses
11 specifically this one that the applicability was
12 limited to, earlier fuel designs up to GE14. This
13 supplement would extend it to GNF2, of course, with
14 no other changes to limitations and conditions in the
15 topical report.

16 So the -- well, there is a series of
17 supplements that GE has agreed to submit to address
18 several of these limitations. This is -- we are
19 focusing on Supplement 3, and this review addresses
20 that one particular one. We do have a total of four
21 supplements in-house now that address some of the
22 other limitations or penalties for the topical
23 report.

24 But I am not going to stay up here much

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 longer. I am going to hand it over to Jim Harrison.

2 We will start off with the folks from GE, and let
3 them start with the presentation.

4 MEMBER BANERJEE: Thanks.

5 MR. HARRISON: I am Jim Harrison with GE
6 Hitachi. I handle the fuels licensing with GE and
7 GNF.

8 I am going to kind of go over a little
9 background material and a little bit of some of the
10 same things Steve mentioned with respect to the
11 supplements and the approach for updating and
12 addressing some of the limitations that were in the
13 SE for 33173.

14 Basically, there were 24 limitations and
15 conditions in the safety evaluation. Many of those
16 had to do with reporting and documenting and
17 analysis, and they didn't have a direct impact on
18 plants' operability or applicability.

19 There are four supplements that are in
20 process now. The one that we are talking about
21 today, Supplement 3 --

22 CHAIRMAN ABDEL-KHALIK: I think we are
23 going to need to wire you up.

24 MR. HARRISON: Or I can sit down.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN ABDEL-KHALIK: That's good, too.

2 MR. HARRISON: I can stand or sit.

3 CHAIRMAN ABDEL-KHALIK: As long as the
4 mics pick you up. That's the important thing.

5 MR. HARRISON: The four limitations that
6 we are addressing now have to do with the
7 applicability to GNF2, because the initial SE was
8 limited to GE14 fuel products.

9 MEMBER BANERJEE: Hold on. Let's get the
10 mics organized. Can you hear him?

11 CHAIRMAN ABDEL-KHALIK: All right. Go
12 ahead.

13 MR. HARRISON: There was an additional
14 margin on the safety limit, and an additional margin
15 that was placed on the operating limit. Those are
16 the subject of two supplements. There was a penalty
17 that was applied to the GESTR-M thermomechanical
18 models, and then there was a requirement, which is
19 now in the process of being implemented, that when
20 PRIME was approved that it would be implemented in
21 place of GESTR-M for plants referencing NEDC-33173.

22 Now, in terms of acronyms, GESTR-M is the
23 older thermomechanical analysis program at GNF, and
24 PRIME is the new one recently approved.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Supplement 3 is seeking to remove the
2 limitation on the GE14 fuel, extending that to GNF2,
3 the most recent GNF fuel product. It doesn't seek to
4 change any of the other limitations. It doesn't seek
5 to remove any of the penalties. Essentially, it only
6 looks to extend the applicability of the document.

7 Supplement 3 utilizes the same structure
8 as the initial 33173 LTR, so that each of the
9 subjects that were addressed initially are addressed
10 again for Supplement 3.

11 I mentioned that there were four
12 supplements that were in play right now, and numbered
13 1, 2, 3, and 4. And as fate would have it, they got
14 submitted in 4, 3, 2, 1. So they were planned 1, 2,
15 3, 4, but it didn't happen that way.

16 So taking it left to right, starting
17 with 1, which was just recently submitted this week,
18 the operating limit penalty was established based on
19 the staff's view that there wasn't sufficient void
20 fraction information to support the use of the
21 Findlay-Dix model and expanded operating domains.

22 The report supporting that was just
23 recently submitted. So the safety limit penalty was
24 associated with the staff's view that there weren't

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 sufficient gamma scans for 10x10 fuel. We have
2 gathered those gamma scans, analyzed them, and
3 submitted that in August of last year.

4 The staff has provided RAIs, and the
5 review time is estimated to be 18 months on that one.

6 Supplement 3 is our subject at hand today
7 having to do with the GNF2 applicability. That
8 report was submitted July 31st of last year. It is
9 obviously complete, as you are hearing today.

10 PRIME kind of comes in from the side on
11 this, PRIME having its own review, and being
12 completed January 22nd of 2010.

13 Supplement 4 has to do with the
14 implementation plan of PRIME through all of the
15 downstream codes. So, you know, PRIME being the
16 design and analysis code for the fuel, the parameters
17 from that code get used in transient analysis and
18 LOCA codes and stability codes, which we call the
19 downstream codes.

20 So from each of these supplements the
21 anticipation is that we will have a supplemental SE,
22 which will address the limitation associated with
23 that item.

24 VICE CHAIRMAN ARMIJO: I just want to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 make sure I understand. When PRIME gets approved,
2 and these other things, assuming they get approved --
3 the OLMCPR, SLMCPR -- will all of those be
4 transferable to GNF2? Or do we go through another
5 cycle of getting those approvals accepted for GNF2
6 fuel?

7 MR. HARRISON: No, they're structured to
8 cover GNF2.

9 VICE CHAIRMAN ARMIJO: So they are
10 covered.

11 MR. HARRISON: Right.

12 VICE CHAIRMAN ARMIJO: Okay.

13 MEMBER SHACK: PRIME will just remove the
14 burnup limit, is that --

15 MR. HARRISON: Well, yes.

16 VICE CHAIRMAN ARMIJO: That's one thing
17 it will do.

18 MR. HARRISON: It does, and then -- but
19 what we're talking about here is implementation into
20 the downstream codes -- you know, the transient
21 analysis codes, the stability codes, and the CODES.
22 But PRIME is the vehicle for removing the burnup
23 limit. That's true.

24 Okay. I'm going to turn it over to Brian

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 to --

2 CHAIRMAN ABDEL-KHALIK: I mean, just to
3 follow up on Sam's question --

4 MR. HARRISON: Sure.

5 CHAIRMAN ABDEL-KHALIK: -- we are looking
6 at Supplement 3, and Supplement 3 states that we are
7 only looking at extending the type of fuel that these
8 methods are going to be applied to.

9 MR. HARRISON: Right.

10 CHAIRMAN ABDEL-KHALIK: Without any
11 change in the current constraints --

12 MR. HARRISON: Correct.

13 CHAIRMAN ABDEL-KHALIK: -- which are
14 addressed in Supplements 1 and 2.

15 MR. HARRISON: Right.

16 CHAIRMAN ABDEL-KHALIK: I guess perhaps
17 my question will come up when we address Supplements
18 1 and 2.

19 MR. HARRISON: So the task, then, if I'm
20 anticipating your question, is that when -- when the
21 staff is reviewing 1 and 2, and when you are looking
22 at 1 and 2, you will have to consider that it
23 addresses GNF2.

24 CHAIRMAN ABDEL-KHALIK: Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 VICE CHAIRMAN ARMIJO: And the staff will
2 address that in their --

3 MR. HARRISON: Yes.

4 VICE CHAIRMAN ARMIJO: -- review.

5 MR. HARRISON: Yes.

6 VICE CHAIRMAN ARMIJO: Okay.

7 CHAIRMAN ABDEL-KHALIK: Thank you.

8 MR. HARRISON: Okay.

9 MEMBER BANERJEE: So do you want to close
10 the session now?

11 MR. HARRISON: Yes. That was the plan --
12 to close the session now.

13 MEMBER BANERJEE: Okay. So please check.
14 So we will go into closed session now.

15 (Whereupon, the proceedings went into
16 Closed Session until 1:59 p.m.)

17 MEMBER BANERJEE: We are now in open
18 session for the next 20 minutes.

19 DR. YARSKY: What I was going to offer
20 before beginning my formal presentation is to briefly
21 show a picture of the MELLLA+ operating domain. This
22 picture is taken from the topical report NEDC-
23 33006P-A. You may bring that up.

24 I generated this a second ago, so I hope

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 it's not too --

2 (Laughter.)

3 There is a blue line, but you can't see
4 it on this figure. The MELLLA+ operating domain is
5 represented by this blue upper boundary -- can you
6 follow the mouse on the screen? -- from point B to D
7 to E.

8 The purpose for expanding this operating
9 domain here is to allow this flow control window
10 between D and B, and to pictorially show what that
11 allows is for two ways of controlling reactivity
12 during exposure, one of which is control blade
13 motion, and the other which is to actually control
14 reactivity through flow rate.

15 So this is showing how, through exposure,
16 reactivity changes can be compensated by rod movement
17 and also changes in the flow. That's what the
18 MELLLA+ operating domain would allow at EPU power
19 levels.

20 Part of the reason for the staff's review
21 of the methods is that at point D you are operating
22 at EPU power levels generally 20 percent higher than
23 originally licensed thermal power, but at a reduced
24 flow rate, in the neighborhood of 80 percent of rated

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 core flow. So you have higher power level and a
2 lower flow rate leads to potentially higher void
3 fraction.

4 CONSULTANT DOWNER: Peter, can I ask a
5 question real quick? For point E, the only way to
6 get back to then the dark -- the black line, then, is
7 by rods?

8 DR. YARSKY: Okay. You are referring to
9 point E?

10 CONSULTANT DOWNER: E, right. To
11 vertically go down.

12 DR. YARSKY: To vertically go down from
13 this point, there are -- well, there is -- you could
14 allow the power to decrease due to burnup effects and
15 reactivity decrease due to burnup, or you could
16 insert a control rod valve.

17 CONSULTANT DOWNER: All right. Okay.

18 MEMBER CORRADINI: But I view -- maybe
19 since we're just educating ourselves -- I view the
20 blue and the black as boundaries that one should not
21 cross unless something bites you. But what bites you
22 down at the knee down here and up there could be
23 different. Down here I seem to remember when you
24 guys first gave the presentation to Sanjoy about

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MELLLA for the current fuel its potential
2 instabilities up by D is more approaching CPR limits
3 potentially.

4 MEMBER BANERJEE: Well, D is --

5 DR. YARSKY: Critical heat flux limits.

6 MEMBER BANERJEE: Yes. Yes, sure.

7 MEMBER CORRADINI: So the mechanism in
8 which you don't -- the reason you don't want to cross
9 differs as you move through that boundary.

10 DR. YARSKY: Yes.

11 MEMBER CORRADINI: Okay.

12 MEMBER BANERJEE: No doubt. All right.
13 Thank you, Peter. Let's move on.

14 DR. YARSKY: No problem. Give me one
15 second to locate the slides. No? No, that's --
16 concluding remarks is not it. That's my proprietary
17 presentation.

18 Okay. Give me a second while I bring up
19 my slides from my thumb drive. I apologize. Give me
20 a moment.

21 MEMBER BANERJEE: So while he is doing
22 that, who is going into MELLLA+ with the EPU first?

23 DR. YARSKY: Monticello submitted their
24 MELLLA+ license amendment request in January of this

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 year.

2 Okay. Now, to begin the open portion of
3 my presentation, I want to discuss the scope of the
4 NRC staff review of Supplement 3. Of course, as we
5 talked about in this morning's session, there is a
6 specific limitation in the staff's SE for the IMLTR,
7 specifically Limitation 22, which says that the
8 interim methods review is applicable to all GE
9 lattices up to GE14.

10 Supplement 3 was provided for staff
11 review to extend the applicability of the IMLTR to
12 GNF2. In our review of the Supplement, Limitation 22
13 of course says GE14 and earlier. Supplement 3 is
14 intended to extend that to GNF2. And as part of this
15 supplement, there is no request for removal or
16 modification of any of the IMLTR limitations beyond
17 extension to a fuel design that is beyond GE14.

18 We talked briefly this morning also about
19 some of the specific GNF2 features and how it is
20 different from GE14. I have listed some of these
21 features here, which is that GNF2 is a high power
22 density fuel design with two part-length rod
23 configurations, a new spacer design, an increased
24 uranium content fuel pin design, different cladding

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 thickness, and a new Defender debris filter.

2 In our review, our review was guided by
3 the review that was previously done for the IMLTR.
4 So GEH spoke this morning as to how they developed
5 the content of the supplement by addressing all of
6 the same topics in their original IMLTR submittal.
7 The staff review covered all of the same topics laid
8 out in the staff's SE for the original IMLTR, and in
9 this way we make sure that the scope of the staff's
10 review for Supplement 3 is fully consistent with the
11 staff review of the initial IMLTR.

12 These are the primary topics that the
13 review covered, which is the extrapolation of the
14 methods to high void fractions, the 40 percent
15 depletion assumption, bypass and water rod voiding,
16 stability, and also the applicability of the thermal
17 hydraulic model.

18 I believe that's all I have in way of
19 talking about the scope of the staff's review.

20 MEMBER BANERJEE: I think what we'll do
21 now, Peter, is rather than go into closed session
22 we'll take a break, and then we'll go into closed
23 session. So let's take a 10-minute break. Okay. So
24 we'll come back let's say shortly after 2:15, and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 then we'll start.

2 MEMBER CORRADINI: 2:20?

3 MEMBER BANERJEE: 2:20. Let's make it
4 2:20.

5 MEMBER CORRADINI: Thank you.

6 MEMBER BANERJEE: I want to stay on time.

7 I'm emulating Dana, trying to keep things on time.

8 (Whereupon, at 2:06 p.m., the proceedings in the
9 foregoing matter went off the record for
10 a break until 2:17, but resumed in Open
11 Session at 3:12 p.m.)

12 CHAIRMAN ABDEL-KHALIK: We are back in
13 session.

14 This is -- we are now in open session,
15 and I hand it over -- back to you, Dr. Banerjee.

16 MEMBER BANERJEE: Okay. I am sorry that
17 I dismissed this so cursorily, so I give it back to
18 you, Peter.

19 DR. YARSKY: I just have a few slides and
20 concluding remarks to make in the open session.

21 IMLTR Supplement 3 seeks, of course, to
22 extend NRC approval to cover the GNF2 fuel design.
23 We have looked at the several evolutionary design
24 features that were incorporated into the GNF2 to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 improve the fuel performance.

2 In the course of our review, we have
3 addressed all of the topics that were addressed in
4 the application of interim methods to GNF2,
5 consistent with our initial approval of the IMLTR.
6 We found that the bases were consistent, but there
7 were no inherent features in the GNF2 fuel design
8 that posed a challenge to the capability of the
9 methods to analyze it.

10 The qualification basis of the methods
11 for GNF2 is the same as was previously reviewed, and
12 the performance of the methods is essentially the
13 same.

14 And so the staff's SE would extend
15 applicability of the IMLTR, including the current
16 limitations and conditions to GNF2, and Limitation 22
17 specifically will be revised accordingly to document
18 the staff approval up to designs including GNF2.

19 That's all I have.

20 MEMBER BANERJEE: Thank you very much.
21 Are there any other questions?

22 (No response.)

23 Good. Excellent, Peter. Thank you, as
24 well as the staff and GE, for very illuminating

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 presentations.

2 And I will hand it back to you now.

3 CHAIRMAN ABDEL-KHALIK: All right. So
4 our discussion of Item 4 on the agenda has now
5 concluded, and we will proceed to Item 5 on the
6 agenda.

7 We are now off the record.

8 (Whereupon, at 3:32 p.m., the proceedings in the
9 foregoing matter went off the record.)

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

AREVA NP Inc.

**Presentation to ACRS
U.S. EPR Design
Certification Application**

Brian A. McIntyre
Design Certification Project Manager

Timothy G. Stack
Technical Integration Manager

April 8, 2010



Outline



- ▶ **Introduction**
- ▶ **Overview of the U.S. EPR Design**
 - ◆ **EPR Development Objectives**
 - ◆ **Major Design Features**
 - ◆ **Main Safety Systems**
 - ◆ **Protection From External Hazards**
 - ◆ **Severe Accident Mitigation**
- ▶ **Overview of U.S. EPR Design Certification Application**

EPR Development Objectives



- ▶ **Evolutionary design based on existing PWR construction experience, R&D, and operating experience**
- ▶ **Improved economics**
 - ◆ Reduce generation cost by at least 10%
 - ◆ Simplify operations and maintenance
 - ◆ 60-year design life
- ▶ **Improved safety**
 - ◆ Reduce occupational exposure and LLW
 - ◆ Increase design margins
 - ◆ Increased redundancy & physical separation of safety trains
 - ◆ Reduce core damage frequency (CDF)
 - ◆ Accommodate severe accidents and external hazards with no long-term local population effect



Major Design Features - Overview



► Nuclear Island

- ◆ Proven Four-Loop RCS Design
- ◆ Four-Train Safety Systems
- ◆ Double Containment
- ◆ In-Containment Borated Water Storage
- ◆ Severe Accident Mitigation
- ◆ Separate Safety Buildings
- ◆ Advanced 'Cockpit' Control Room

► Electrical


- ◆ Shed Power to House Load
- ◆ Four Emergency DGs
- ◆ Two Smaller, Diverse SBO DGs

► Site Characteristics

- ◆ Airplane Crash Protection (military and commercial)
- ◆ Explosion Pressure Wave

Reflects full benefit of operating experience and 21st century requirements.

Major Design Features



- ▶ Conventional 4-loop PWR design, proven by decades of design, licensing and operating experience.
- ▶ NSSS component volumes increased compared to existing PWRs, increasing operator grace period for many transients and accidents

A solid foundation of operating experience.

The Four Train (N+2) Concept



Each safety train is independent and located within a physically separate building.


Main Safety Systems

► Four train Safety Injection System (SIS)


- ◆ Medium head SI pumps
- ◆ Combined Residual Heat Removal System / Low Head Safety Injection

► In-Containment Refueling Water Storage Tank

► Extra Borating System (two trains not shown)



Main Safety Systems Secondary Side



- ▶ Safety-related main steam relief train
- ▶ Four separate Emergency Feed Water Systems (EFWS)
- ▶ Separate power supply for each
- ▶ 2/4 EFWS also powered by Station Black Out (SBO) diesels
- ▶ Interconnecting headers at EFWS pump suction & discharge


Protection From External Hazards Shielded Containment



- ▶ Inner wall post-tensioned concrete with steel liner
- ▶ Outer wall reinforced concrete
- ▶ Protection against airplane crash
- ▶ Protection against external explosions
- ▶ Annulus filtered to reduce radioisotope release





Protection From External Hazards



Severe Accident Mitigation

- ▶ Prevention of high-pressure melt-through using Primary Depressurization System
- ▶ Passive ex-vessel melt stabilization, conditioning and cooling
- ▶ Long-term melt cooling and containment protection using active cooling system
- ▶ Control of H₂ concentration using passive autocatalytic recombiners



U.S. EPR Design Certification Application



- ▶ **U.S. EPR design reflects an evolutionary, active plant design**
 - ◆ Exemptions and exceptions minimized
 - ◆ No RTNSS
- ▶ **Applies proven analytical methodologies**
- ▶ **Preapplication activities**
 - ◆ Unique Design Features technical report developed
 - ◆ Meetings with technical staff
 - ◆ Topical reports submitted in selected areas
 - ◆ Established local AREVA NP office
- ▶ **FSAR format and content is consistent with key NRC guidance documents**
 - ◆ Regulatory Guide 1.206, “Combined License Applications for Nuclear Power Plants (LWR Edition)”
 - ◆ NUREG-0800, "Standard Review Plan for the Review of Safety Analysis Reports for Nuclear Power Plants"
 - Technical Report Summary provided


Chapter 2: Site Characteristics



► Topics

- ◆ Site characteristics
 - ◆ Geography and demography
 - ◆ Nearby industrial, transportation, and military facilities
 - ◆ Meteorology
 - ◆ Hydrologic engineering
 - ◆ Geology, seismology, and geotechnical engineering
- U.S. EPR design is based on a set of conservatively established design parameters
- Chapter 2 provides list of assumed design parameters for comparison with site-specific data and characteristics by a COL applicant


Chapter 4: Reactor



► Topics

- ◆ Fuel System Design
 - ◆ Nuclear Design
 - ◆ Thermal-Hydraulic Design
 - ◆ Reactor Materials
 - ◆ Functional Design of Reactivity Control Systems
- **U.S. EPR design features are fundamentally the same as previous PWR designs**
- **Design methods and codes for mechanical, nuclear, and thermal hydraulic designs approved for use in ANP-10263PA**
- **Key differences from previous PWR designs include:**
- ◆ 14-foot active fuel length
 - ◆ Stainless steel “heavy” reflector
 - ◆ Aeroball Measurement System used for calibration of core monitoring neutronics computer codes and fixed incore Co-59 self-powered neutron detectors (SPND)
 - ◆ Online monitoring of DNB and LHGR accomplished through power distribution reconstruction from SPNDs

Chapter 5: Reactor Coolant System and Connected Systems



► Topics

- ◆ Integrity of the reactor coolant pressure boundary
- ◆ Reactor vessel
- ◆ Component and subsystem design

► U.S. EPR design is typical of four-loop PWR designs

- ◆ Four U-tube steam generators
- ◆ Four reactor coolant pumps

► Key differences

- ◆ No reactor pressure vessel lower head penetrations
- ◆ Reactor coolant pump shaft seal isolation for station blackout
- ◆ Pressurizer safety relief valves provide overpressure protection at power and at low temperature
- ◆ Alloy 690

Chapter 8: Electric Power



► Topics

- ◆ Offsite power system
- ◆ Onsite power system
- ◆ Station blackout


► U.S. EPR design features fundamentally same as previous reactor designs

- ◆ Two independent offsite feeds
- ◆ Degraded voltage protection for emergency buses

► Key differences

- ◆ Four Emergency Diesel Generators (Class 1E) and four 2-hour Uninterruptible Power Supplies (Class 1E)
- ◆ Alternate electrical feed configuration to facilitate on-line maintenance
- ◆ No intervening non-safety buses in Class 1E distribution system
- ◆ Two SBO diesel generators as Alternate AC source
- ◆ No fast transfer of plant loads during startup, shutdown, or plant trip
- ◆ Island mode operation

Chapter 10: Steam and Power Conversion System



► Topics

- ◆ Turbine generator
- ◆ Main steam supply system
- ◆ Other features of steam and power conversion system
- ◆ Emergency feedwater system

► U.S. EPR design features fundamentally the same as previous designs

- ◆ Seven stages of regenerative feedwater heating
- ◆ Two stages of reheat
- ◆ Multi-pressure condenser

► Key differences

- ◆ Single Flow High Pressure (HP) Turbine and Single Flow Intermediate Pressure (IP) Turbine in a common casing
- ◆ Two redundant and diverse electrical overspeed trip systems for the Turbine Generator
- ◆ Safety-grade Main Steam Relief Train (MSRT) for overpressure protection and safety-grade secondary depressurization
- ◆ Stand alone Startup/Shutdown Feedwater System
- ◆ Four motor-driven Emergency Feedwater pumps


Chapter 12: Radiation Protection



► Topics

- ◆ Ensuring that occupational radiation exposures are as low as reasonably achievable
 - ◆ Radiation sources
 - ◆ Radiation protection design features
 - ◆ Dose assessment
 - ◆ Operational radiation protection program (COL applicant responsibility)
- **U.S. EPR design reflects operating experience and implements As Low as Reasonably Achievable (ALARA) principles in the design process**
- ◆ Physical plant layout that includes compartmentalization and dedicated ventilation
 - ◆ Material selection reduces activation/corrosion products
 - ◆ Permanent shielding
 - ◆ Minimization of contamination following industry lessons learned
 - ◆ ALARA applied in the design process
- **The occupational dose of 50 person-rem demonstrates that ALARA has been an integral part of the U.S. EPR design process**

Chapter 17: Quality Assurance



► Three main topics

◆ Quality Assurance Program Description

- Addressed in “AREVA NP Inc. Quality Assurance Plan (QAP) for Design Certification of the U.S. EPR Topical Report,” ANP-10266A
- Based on 18-point criteria of 10 CFR 50 Appendix B and ANSI/ASME NQA-1-1994
- Prepared using guidance provided in NUREG-0800, Standard Review Plan, Section 17.5

◆ Reliability Assurance Program

- Purpose is to maintain reliability of risk-significant SSCs
- Prepared using the guidance provided in NUREG-0800, Standard Review Plan, Section 17.4

◆ Maintenance Rule Program

- Purpose is to monitor effectiveness of plant maintenance activities
- COL applicant will describe program for Maintenance Rule implementation

List of Acronyms



- ▶ **AC – Alternating Current**
- ▶ **ACCU – Accumulator**
- ▶ **ALARA – As Low As Reasonably Achievable**
- ▶ **CDF – Core Damage Frequency**
- ▶ **CL – Cold Leg**
- ▶ **COL – Combined Operating License**
- ▶ **DG – Diesel Generator**
- ▶ **DNB – Departure from Nucleate Boiling**
- ▶ **EFWS – Emergency Feedwater System**
- ▶ **ESF – Engineered Safety Features**
- ▶ **HL – Hot Leg**
- ▶ **HP – High Pressure**
- ▶ **IP – Intermediate Pressure**
- ▶ **IRWST – In-containment Refueling Water Storage Tank**
- ▶ **LHGR – Linear Heat Generation Rate**
- ▶ **LHSI – Low Head Safety Injection System**
- ▶ **LLW – Low Level Waste**
- ▶ **MHSI – Medium Head Safety Injection System**
- ▶ **MSRT – Main Steam Relief Train**
- ▶ **MSIV – Main Steam Isolation Valve**
- ▶ **PWR – Pressurized Water Reactor**
- ▶ **RCS – Reactor Coolant System**
- ▶ **RHR – Residual Heat Removal**
- ▶ **RTNSS - Regulatory Treatment of Non-Safety Systems**
- ▶ **SAHRS – Severe Accident Heat Removal System**
- ▶ **SBO – Station Blackout**
- ▶ **SIS – Safety Injection System**
- ▶ **SG – Steam Generator**
- ▶ **SPND - Self-powered Neutron Detectors**
- ▶ **SSC - Structures, Systems and Components**





Presentation to the ACRS Full Committee - 571st Meeting

**Briefing on EPR Design Certification Application Safety Evaluation
Report with Open Item for Chapters 2, 4, 5, 8, 10, 12, and 17**

**Getachew Tesfaye
Project Manager**

April 8, 2010

Major Milestones Chronology



12/02/2004	Pre-application activities began
12/11/2007	Design Certification Application submitted
02/25/2008	Application accepted for review (docketed)
03/26/2008	Review scheduled published
01/29/2009	Phase 1 review completed
03/19/2009	Revised schedule published
05/29/2009	U.S. EPR FSAR, Revision 1 submitted
06/25/2009	Revised schedule published
Aug 09 to Mar,10	Phase 2 review completed for Chapters 2,4, 5, 8,10, 11, 12, 16, 17 and 19. Phase 3 is completed for Chapters 2, 4, 5, 8, 10, 12, and 17
02/16/2010	Revised schedule published

Review Schedule



Task	Target Date
Phase 1 - Preliminary Safety Evaluation Report (SER) and Request for Additional Information (RAI)	Completed
Phase 2 - SER with Open Items	December 21, 2010
Phase 3 – Advisory Committee on Reactor Safeguards (ACRS) Review of SER with Open Items	February 25, 2011
Phase 4 - Advanced SER with No Open Items	July 2011
Phase 5 - ACRS Review of Advanced SER with No Open Items	October 2011
Phase 6 – Final SER with No Open Items	December 2011
Rulemaking	June 2012

Review Strategy

- Pre-application activities
- Frequent interaction with the applicant
 - ♦ Teleconferences
 - ♦ Audits
 - ♦ Public meetings
- Use of Electronic RAI System (eRAI)
- Phase discipline

Summary of SER with OI: Chapter 2 Site Characteristics



SRP Section/Application Section		Number of RAI Questions	Number of SER Open Items
2.0	Site Characteristics	2	2
2.1	Geography and Demography	0	0
2.2	Nearby Industrial, Transportation, and Military Facilities	0	0
2.3	Meteorology	31	10
2.4	Hydrologic Engineering	4	0
2.5	Geology, Seismology, and Geotechnical Engineering	8	1
2.6	COL Information Items	0	0
Totals		45	13

Summary of SER with OI: Chapter 4 Reactor



SRP Section/Application Section		Number of RAI Questions	Number of SER Open Items
4.2	Section Title Fuel System Design	15	2
4.3	Section Title Nuclear Design	24	2
4.4	Section Title Thermal-Hydraulic Design	37	3
4.5.1	Section Title Control Rod Drive System Structural Materials	7	2
4.5.2	Section Title Reactor Internals and Core Support Materials	11	3
4.6	Section Title Functional Design of Reactivity Control Systems	10	2
Totals		104	14

Summary of SER with OI: Chapter 5 Reactor Coolant System and Connected Systems



SRP Section/Application Section		Number of RAI Questions	Number of SER Open Items
5.2	Section Title Integrity of the Reactor Coolant Pressure Boundary	51	12
5.3	Section Title Reactor Vessel	27	8
5.4	Section Title Component and Subsystem Design	49	5
Totals		127	25

Summary of SER with OI: Chapter 8 Electric Power

SRP Section/Application Section		Number of RAI Questions	Number of SER Open Items
8.1	Introduction	4	0
8.2	Offsite Power System	7	0
8.3.1	Alternating Current (AC) Power Systems (Onsite)	24	0
8.3.2	Direct Current (DC) Power Systems (Onsite)	5	0
8.4	Station Blackout	9	0
Totals		49	0

Summary of SER with OI: Chapter 10 Steam and Power Conversion Systems



SRP Section/Application Section		Number of RAI Questions	Number of SER Open Items
10.2	Turbine-Generator	7	1
10.2.3	Turbine Rotor Integrity	23	7
10.3	Main Steam Supply System	2	0
10.3.6	Steam and Feedwater System Materials	12	2
10.4.1 10.4.2 10.4.3 10.4.4 10.4.5	Main Condensers, Main Condenser Evacuation System, Turbine Gland Sealing System, Turbine Bypass System, Circulating Water System	5	0
10.4.6	Condensate Polishing System	6	0
10.4.7	Condensate and Feedwater System	3	0
10.4.8	Steam Generator Blowdown System	4	0
10.4.9	Emergency Feedwater System	13	2
Totals		75	12

Summary of SER with OI: Chapter 12 Radiation Protection



SRP Section/Application Section		Number of RAI Questions	Number of SER Open Items
12.1	Ensuring that Occupational Radiation Exposures are ALARA	0	0
12.2	Radiation Sources	6	2
12.3-12.4	Radiation Protection Design Features	18	7
12.5	Operational Radiation Protection Program	3	1
Totals		26	10

Summary of SER with OI: Chapter 17 Quality Assurance



SRP Section/Application Section		Number of RAI Questions	Number of SE Open Items
17.0	Quality Assurance and Reliability Assurance	0	0
17.1	Quality Assurance During Design	0	0
17.2	Quality Assurance During the Operations Phases	0	0
17.3	Quality Assurance Program Description	0	0
17.4	Reliability Assurance Program	22	1
17.5	Quality Assurance Program Description	2	1
17.6	Description of Applicant's Program for Implementation of 10 CFR 50.65, the Maintenance Rule	2	0
Totals		26	2

ACRS Phase 3 Review Plan

FSAR Chapters Grouped by Phase 2 Completion Date							
Group	Chapters	Chapter Issuance (Phase 2)	ACRS Meeting (Phase 3)	Group	Chapters	Chapter Issuance (Phase 2)	ACRS Meeting (Phase 3)
1A	2	09/21/2009	11/03/2009, Done	3A	13	06/01/2010	TBD
	8	07/10/2009			15	05/11/2010	
1B	10	09/04/2009	11/19/2009, Done	3B	7	08/02/2010	TBD
	12	10/09/2009			18	08/02/2010	
2A	17	01/12/2010	02/18/2010 02/19/2010 17 Done 19 will be completed on 04/21/2010	4A	6	09/15/2010	TBD
	19	01/15/2010			9	09/09/2010	
2B	4	02/03/2010	03/03/2010, Done	4B	1	10/29/2010	TBD
	5	02/03/2010			3	10/29/2010	
2C	11	03/01/2010	04/06/2010 Done		14	10/29/2010	
	16	03/01/2010					
Closing: ▪General Plant Description (final) and summation of open items ▪Cross-cutting issues and re-visit earlier chapters as needed							TBD



**NRC Staff Review of
NEDC-33173P, Supplement 3
“Supplement for GNF2 Fuel”**

Concluding Remarks

Dr. Peter Yarsky

NRR/DSS/SNPB



Concluding Remarks

- IMLTR Supplement 3 seeks to extend NRC approval to cover the GNF2 fuel design
- Several evolutionary design features were incorporated in GNF2 to improve fuel performance



Scope of Staff Review

- The staff review addressed the applicability of interim methods to calculations with GNF2 fuel
- Addressed all topical areas addressed in the staff review of the IMLTR



Review Determination

- GNF2 design features do not pose an inherent challenge to the capability of the analysis methods
- Qualification basis of the methods for GNF2 is the same as previously reviewed
- Performance of the methods is essentially the same




Review Outcome

- The staff's SE extends applicability of the IMLTR and the associated SE (including limitations and conditions) to GNF2
- Limitation 22 will be revised accordingly to document staff approval up to designs including GNF2

**April 8, 2010
ACRS Full Committee Meeting**

**NEDC-33173P - Supplement 3
Applicability of GE Methods to
Expanded Operating Domains -
Supplement for GNF2 Fuel**

Jim Harrison, GE Hitachi



As Approved – NEDC-33173P

Applicability of GE Methods to Expanded Operating Domains (IMLTR)

24 Limitations in NRC Safety Evaluation

- **Limited to the GE14 Fuel and Older Products**
- **Penalties:**
 - SLMCPR Adder: 0.02 for EPU and 0.03 for M+**
 - OLMCPR Adder: 0.01 for EPU/M+**
 - GESTR-M: 350 psi Pcrit Reduction**
- **Use PRIME when approved**

Supplement 3 - GNF2 Supplement

- ✓ Limitation 22 restricts the applicability to GE14 & earlier fuel designs
- ✓ Supplement 3 extends applicability to GNF2
- ✓ No changes to any other limitations

IMLTR Supplement Flow

