

May 18, 2010

MEMORANDUM TO: Robert M. Taylor, Chief  
Steam Generator Tube Integrity and  
Chemical Engineering Branch  
Division of Component Integrity  
Office of Nuclear Reactor Regulation

FROM: Thomas P. Morgan, General Engineer */RA/*  
Steam Generator Tube Integrity and  
Chemical Engineering Branch  
Division of Component Integrity  
Office of Nuclear Reactor Regulation

SUBJECT: SUMMARY OF THE MAY 6, 2010, CATEGORY 2 PUBLIC MEETING  
WITH INDUSTRY TO DISCUSS NEUTRON ABSORBER MATERIALS  
DEGRADATION ISSUES

Industry representatives and members of the public met with U.S. Nuclear Regulatory Commission (NRC) staff on May 6, 2010, at the Baltimore Marriott Inner Harbor at Camden Yards in Baltimore, Maryland. The purpose of the meeting was to discuss neutron absorber materials degradation issues. The topics discussed are summarized in the staff's and industry's slides, which are available in the Agencywide Documents Access and Management System (ADAMS) under Accession Numbers ML101310015 and ML101310017. The enclosure provides a list of those in attendance. This meeting was noticed as a public meeting and the meeting agenda is available in ADAMS under Accession Number ML101110002.

During the meeting there was discussion on many neutron absorber materials degradation issues. These discussions are summarized below:

- The BORAL material porosity issues that were discussed included historical porosity issues and manufacturing improvements in the more recent vintages of BORAL. The industry indicated that 5-7% porosity was optimal in BORAL to prevent blistering.
- Hydrogen production and entrainment during the blistering process in BORAL was discussed, and whether all possible chemical reactions have been considered for all spent fuel pool environments and conditions.
- Neutron absorber material degradation as a function of spent fuel pool conditions was discussed. Conditions such as neutron flux, impurities, and chemistry (products and reactants) were discussed. In 2010, these parameters will be evaluated parametrically to discover their effects on BORAL degradation.

CONTACT: Thomas P. Morgan  
301-415-2678

- The issue of helium production within neutron absorbing materials during extended plant operation was raised. The industry stated that helium production and the subsequent B<sub>4</sub>C swelling is not an issue in spent fuel pool environments.
- The industry stated that guidelines for a Boraflex surveillance program were issued subsequent to the first Boraflex Users Group meeting. These guidelines ("Guidelines for a Standard Boraflex Coupon Surveillance Program") were published as Appendix C in EPRI Report NP-6159 in December 1988. Additionally, this guidance informed ASTM standard C 1187-07, "Establishing Surveillance Test Program for Boron-Based Neutron Absorbing Material Systems for Use in Nuclear Spent Fuel Storage Racks."
- The industry mentioned that pitting corrosion has been seen on Metamic samples. The cause was thought to be due to cleanliness during production.
- The industry indicated that coupon surveillance samples that are removed from the spent fuel pool for testing are generally disposed of since subsequent surveillance tests would be invalidated once the samples are removed from the spent fuel pool environment and prepared for testing.

Enclosure:  
Attendance List

- The issue of helium production within neutron absorbing materials during extended plant operation was raised. The industry stated that helium production and the subsequent B<sub>4</sub>C swelling is not an issue in spent fuel pool environments.
- The industry stated that guidelines for a Boraflex surveillance program were issued subsequent to the first Boraflex Users Group meeting. These guidelines (“Guidelines for a Standard Boraflex Coupon Surveillance Program”) were published as Appendix C in EPRI Report NP-6159 in December 1988. Additionally, this guidance informed ASTM standard C 1187-07, “Establishing Surveillance Test Program for Boron-Based Neutron Absorbing Material Systems for Use in Nuclear Spent Fuel Storage Racks.”
- The industry mentioned that pitting corrosion has been seen on Metamic samples. The cause was thought to be due to cleanliness during production.
- The industry indicated that coupon surveillance samples that are removed from the spent fuel pool for testing are generally disposed of since subsequent surveillance tests would be invalidated once the samples are removed from the spent fuel pool environment and prepared for testing.

Enclosure:  
Attendance List

DISTRIBUTION:

DCI R/F	PUBLIC	CHarris	DAlgama	CRegan
RidsOgcMailCenter	MGordon	APulvirenti	CHunt	MGavrilas
RidsEdoMailCenter	MYoder	MDiaz	KWood	CBrown
RidsNrrAdes	AObodoako	TMorgan	TNakanishi	PPatnaik
RidsNrrOd	EWong	ESastre	AHiser	

**ADAMS Accession Number:**

<b>OFFICE</b>	NRR/DCI/CSGB	NRR/DCI/CSGB
<b>NAME</b>	TMorgan	RTaylor
<b>DATE</b>	05/18/2010	05/18/2010

**OFFICIAL RECORD COPY**

Attendance List  
May 6, 2010 Public Meeting

Industry

Albert Machiels, EPRI  
John Kessler, EPRI  
Andrew Sowder, EPRI  
Everett Redmond, NEI  
Steven Edwards, Progress Energy  
John Ponder, Southern Nuclear  
William Slagle, Westinghouse  
Bill Lang, Constellation  
Brendan Brown, Constellation  
John Massari, Constellation  
Ken Lindquist, NETCO  
Matt Eyre, NETCO  
Kevin Morris, TransNuclear  
Kevin Koski, First Energy  
Peter Sharp, FPL  
Dennis Buschbaum, Luminant Power  
Brett Carlsen, INL  
Zita Martin, TVA  
Suzanne Leblang, Entergy  
Phil Blue, Nanotec  
Luis Hinojasa, Holtec  
Jayant Bondre, Transnuclear  
Brian Gustems, PSEG Nuclear  
Sandra Birk, INL  
Joy Russell, Holtec  
Brian Gutherman, ACI  
Michael Lampe, TransWare Enterprises  
Robert Sanchez, US GAO

Phone Participants

Ray Lambert, EPRI  
William Murphy, Duke Energy  
Joseph Coletta, Duke Energy  
Philip Tufts, Duke Energy  
Robert St. Clair, Duke Energy  
Curt Bock, FPL-Duane Arnold  
William Long, Engineered Materials Insights  
Deann Raleigh, Scientech-Curtiss Wright  
Elaine Hiruo, Platts  
John Weiss, Entergy

Phone Participants, Continued

Robin Jones, Southern Nuclear  
Ron Cocherell, Southern Nuclear  
Susan Hoxie-Key, Southern Nuclear  
Adel Alapour, Southern Nuclear  
Rick Fennell, Southern Nuclear  
John Hannah, GE Hitachi Nuclear Energy  
Bob Ashe-Everest, SONGS  
Janice Bostelman, Alion  
Joseph Willett, Fort Calhoun Station  
Richard Roenigk, Fort Calhoun Station  
Matthew Kirkland, Fermi Unit 2  
Jeffrey Dunlap, Exelon  
Charles Rombough, CTR Technical Services  
Robert Quinn, Westinghouse  
Adam Levin, Exelon  
Thomas Loomis, Exelon  
James Rajenski, PVNGS  
Nancy Chapman, Bechtel Power  
Dale Lancaster, Nuclear Consultants  
Don Algama, NRC  
Tony Nakanishi, NRC  
Matt Gordon, NRC

NRC

Robert Taylor  
Emma Wong  
April Pulvirenti  
Marilyn Diaz  
Eduardo Sastre  
Aloysius Obodoako  
Charles Harris  
Thomas Morgan

ENCLOSURE