

Official Transcript of Proceedings
NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards
 License Renewal Subcommittee

Docket Number: (n/a)

Location: Rockville, Maryland

Date: Tuesday, June 8, 2010

Work Order No.: NRC-288

Pages 1-134

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1323 Rhode Island Avenue, N.W.
Washington, D.C. 20005
(202) 234-4433

1
2
3 DISCLAIMER
4
5

6 UNITED STATES NUCLEAR REGULATORY COMMISSION'S
7 ADVISORY COMMITTEE ON REACTOR SAFEGUARDS
8
9

10 The contents of this transcript of the
11 proceeding of the United States Nuclear Regulatory
12 Commission Advisory Committee on Reactor Safeguards,
13 as reported herein, is a record of the discussions
14 recorded at the meeting.
15

16 This transcript has not been reviewed,
17 corrected, and edited, and it may contain
18 inaccuracies.
19
20
21
22
23

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 UNITED STATES OF AMERICA

2 NUCLEAR REGULATORY COMMISSION

3 + + + + +

4 ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

5 (ACRS)

6 + + + + +

7 LICENSE RENEWAL SUBCOMMITTEE

8 + + + + +

9 TUESDAY,

10 JUNE 8, 2010

11 + + + + +

12 ROCKVILLE, MARYLAND

13 + + + + +

14 The Subcommittee convened at the Nuclear
15 Regulatory Commission, Two White Flint North, Room
16 T2B1, 11545 Rockville Pike, Rockville, Maryland at
17 8:30 a.m., Dr. Dennis Bley, Chairman, presiding.

18 SUBCOMMITTEE MEMBERS PRESENT:

19 DENNIS C. BLEY, Chair

20 J. SAM ARMIJO

21 MARIO V. BONACA

22 HAROLD B. RAY

23 WILLIAM J. SHACK

24 JOHN D. SIEBER

25 JOHN W. STETKAR

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26

CONSULTANTS TO THE SUBCOMMITTEE PRESENT:

JOHN J. BARTON

NRC STAFF PRESENT:

KATHY D. WEAVER, Designated Federal Official

BRIAN HOLIAN

BRIAN HARRIS

BENNY JOSE

CLIFF DOUTT

ABDUL SHEIKH

ALSO PRESENT:

CHRIS COSTANZO

KEN PUTNAM

MIKE FAIRCHILD

CURT BOCK

CLARA RUSHWORTH

ERIC SORENSON

AL THOMAS

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24

T-A-B-L-E O-F C-O-N-T-E-N-T-S

WELCOME/OPENING REMARKS:

Dennis Bley, Chair 4

STAFF INTRODUCTION/REMARKS:

Brian Holian, NRR 5

DUANE ARNOLD ENERGY CENTER PRESENTATION:

Chris Costanzo, DAEC 8

Ken Kleinheinz, DAEC 16

Ken Putnam, DAEC 32/44

Mike Fairchild, DAEC 39

NRC STAFF PRESENTATION, SER OVERVIEW:

Brian Holian, NRR 99

Brian Harris, Region III 99

Benny Jose, Region III 102

SUBCOMMITTEE COMMENTS/DISCUSSION: 130

ADJOURN:

Dennis Bley 134

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

P-R-O-C-E-E-D-I-N-G-S

8:27 a.m.

CHAIR BLEY: Good morning. The meeting will now come to order. This is a meeting of the Plant License Renewal Subcommittee. I'm Dennis Bley, Chairman of this Subcommittee meeting.

ACRS Members in attendance are: John Stetkar, William Shack, Harold Ray, Mario Bonaca, Jack Sieber, Sam Armijo.

I said Harold, right? Harold Ray.

MEMBER SHACK: You said William.

CHAIR BLEY: I did. I read it. John Barton our consultant is also present.

Cathy Weaver of the ACRS staff is the Designated Federal Official for this meeting.

The Subcommittee will review the license renewal application for the Duane Arnold Energy Center and the Associated Draft Safety Evaluation Report with Open Items.

We will hear presentations from NRC staff and FPL energy, Duane Arnold, LLC representative and other interested persons regarding this matter.

We have received no written comments or requests for time to make oral statements from members of the public regarding today's meeting.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 This meeting will be open to public
2 attendants.

3 The Subcommittee will gather information,
4 analyze relevant issues and facts and formulate
5 proposed positions and actions as appropriate for
6 deliberation by the full Committee.

7 The rules for participation in today's
8 meeting have been announced as part of the notice of
9 this meeting, previously published in the Federal
10 Register.

11 A transcript of the meeting is being kept
12 and will be made available as stated in the Federal
13 Register notice. Therefore, we request the
14 participants in this meeting to use the microphones
15 located throughout the meeting room when addressing
16 the Subcommittee.

17 The participants should first identify
18 themselves and speak with sufficient clarity and
19 volume so that they may be readily heard.

20 We will now proceed with the meeting. I
21 call upon Brian Holian of the NRC staff to begin.
22 Brian?

23 MR. HOLIAN: Good morning and thank you
24 Chairman. My name is Brian Holian. I'm the Director
25 of the Division of License Renewal. The agenda for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 today's meeting is just brief introductions by myself
2 of the NRC staff and then I'll turn it over to Duane
3 Arnold's staff for their morning presentation which
4 will be followed by the staff's presentation.

5 To my immediate left is Bo Pham, the
6 Branch Chief that is responsible for Duane Arnold. To
7 my immediate right we have Benny Jose, Senior Reactor
8 Inspector from Region III and the Project Manager from
9 the Division of License Renewal, Brian Harris. You
10 will be hearing from both of them at the NRC
11 presentation.

12 In the audience I have Dr. Allen Hiser,
13 Senior Level Advisor, several DLR Branch Chiefs,
14 technical staff on both license renewal and some of
15 the technical divisions at NRR and they will be
16 available for questions during the staff presentation.

17 I did want to just take a short minute,
18 half a minute here to recognize to my immediate right
19 Dr. Sam Lee. Sam, if you would stand up? Sam is
20 moving on from license renewal. He has been a long
21 time license renewal reviewer, branch chief and deputy
22 division director. He has been my deputy for the last
23 two years and of P.T. Kuo before that.

24 Sam is swapping over. He is still staying
25 at NRR, but just broadening himself over to the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Division of Risk Assessment and he will be swapping
2 with Melanie Galloway. You will meet her at next
3 month's session.

4 And yesterday was Sam's last day in
5 license renewal and I just wanted to highlight his,
6 you know, participation in license renewal. He
7 clearly is probably the single person with the most
8 longevity in license renewal. He dates himself back
9 to Calvert Cliffs and the rule before that, he has
10 been, I didn't count up all the ACRS Subcommittee and
11 Committee meetings that he has attended, but, to quite
12 a few.

13 He has been involved in almost all of the
14 59 plants that have been renewed. He did take a stint
15 in there when he went through his SES CDP and had a
16 rotation away from license renewal for a couple of
17 years, but then came back.

18 To cite his technical accomplishments, you
19 know, Dr. Lee from MIT, he has been involved in all
20 our technical reviewers issues. You can ask the
21 branch chiefs the level of detail he gets into.
22 Besides that, which I know these are recognized, Sam
23 has also been a key hirer, not only for license
24 renewal, but for NRR.

25 And just within the last six months, he

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 has received a couple of awards from the Federal
2 Advisory Committee for his hiring efforts. In the
3 last 15 months, he has hired over 25 people at NRR.

4 And part of that aspect is really
5 increasing the diversity of NRR. He has done just a
6 super job. You know, he is already starting to talk
7 risk assessment talk. He has repeated 10-7 if only a
8 couple of times yesterday. And he is asking me to put
9 a little more risk into license renewal, so we'll get
10 that view from him and you will be seeing him from
11 that side of the house.

12 But I did want to recognize him today in
13 this setting. He, like all of us, think very highly
14 of the ACRS. He uses these sessions to scare our
15 staff to death at presentations and prepare them well.

16 So he has always used that. But I wanted to
17 highlight him today in this setting and thank him.

18 (Applause)

19 MR. HOLIAN: With that, I'll turn it over
20 to Duane Arnold and Chris Costanzo, the site Vice
21 President.

22 MR. COSTANZO: Thank you, Brian. And
23 congratulations, Dr. Lee, and I wish you the best in
24 your new endeavor.

25 Good morning and welcome, Mr. Chairman and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the Committee, and welcome everybody in the back. I
2 think I can see everybody in the back.

3 I certainly appreciate the opportunity to
4 discuss our safety evaluation report with this
5 Committee and as well as the process reviews and
6 license renewal, our future plans at Duane Arnold and
7 the current plat status as well.

8 I have brought with me a great team. To
9 my left is Ken Putnam from the License Renewal
10 Project. He is the Project Manager. I have Ken
11 Kleinheinz, who is the Director of Engineering at
12 Duane Arnold. And Mike Fairchild who is the License
13 Renewal Electrical Lead.

14 And in the back row, if you guys wouldn't
15 mind, just raise your hand when I call you, Curt Bock.

16 Curt Bock is our License Renewal Mechanical Lead.
17 Ken Chew, which is our License Renewal Civil Lead,
18 Clara Rushworth, which is our License Renewal
19 Licensing Lead, Herb Giorgio, Environmental Lead, Eric
20 Sorenson, our Program Engineer, and Al Thomas, who as
21 well is a Program Engineer.

22 Today's agenda, we will be talking about a
23 background of the site. We will be talking about an
24 operation history and I'm going to have Ken Kleinheinz
25 do that, our Engineering Director. And Ken Putnam

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 will do our License Renewal Project overview. He will
2 include scoping discussions, our time-limiting aging
3 analysis. He will go through the generic aging
4 lessons learned and our commitment process.

5 As well, Ken will touch on our technical
6 items of interest. In particular, we will be talking
7 about the torus coatings, our buried piping system and
8 our small bore piping system, which are open items.

9 The next slide that may seem odd that we
10 are showing a picture, but I think it's a very good
11 picture to depict where Duane Arnold is. And what
12 this represents is what we call our excellence model,
13 as Duane Arnold knows well, at our fleet.

14 And this shows, and it's no optical
15 illusion, that both the prevention and the detection
16 parts of the circles are slightly bigger than the
17 correction model, because that depicts exactly how
18 Duane Arnold operates. We tried to attempt to stay
19 more in our prevention mode as well as our detection
20 mode to be better prepared to not react to things and
21 spend less time in correction.

22 And the reason I thought this is just one
23 of those values that we use in our excellence plan.
24 And this has been a journey that we have been on since
25 2008 and there is a series of values. But we picked

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 this slide in prevention correction detection, because
2 I think it most accurately represents what we do in
3 this license renewal process.

4 And when you look at our aging mechanisms
5 and establishing goals and trying to get a head of the
6 different aging issues that come up at Duane Arnold,
7 it depicts exactly where we are at.

8 We set those goals. We establish a
9 process to make those commitments and we go ahead and
10 effect those changes before they become a correction
11 mode.

12 And the next slide. Just a little bit of
13 background from the site. We are, approximately, six
14 miles northwest of Cedar Rapids in Iowa. We are a
15 general electric plant. Bechtel was our constructor.

16 We are a BWR. We are a Mark I containment. We have
17 just upgraded to 1912 megawatts thermal power and,
18 approximately, 630 megawatts electric.

19 The Cedar River is an ultimate heat sink
20 and a water makeup source with forced draft cooling
21 towers for condenser cooling. And our staff right now
22 consists of, approximately, 650 people.

23 MEMBER SIEBER: What was your original
24 licensed electrical output?

25 MR. PUTNAM: It's about 515.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER SIEBER: 515, okay.

2 CONSULTANT BARTON: Why did you have a
3 restriction on your original license? Your original
4 license, you didn't have -- you weren't licensed for
5 your full power.

6 MR. PUTNAM: Yes, you license it to 1658
7 was the license and then the tech specs are restricted
8 to 1593.

9 CONSULTANT BARTON: What was the
10 restriction all about?

11 MR. PUTNAM: You know, I think that was
12 for testing and power density. Duane Arnold has a
13 small core, so there is a -- they wanted some
14 operating time there on that before they allowed us to
15 go up.

16 CONSULTANT BARTON: Okay.

17 MR. PUTNAM: And we did that in 1985.

18 CONSULTANT BARTON: Thank you.

19 MR. COSTANZO: Earlier in the slide that I
20 used with prevention, detection and correction, I
21 spoke of a fleet. And so just as a little bit of
22 background, as we are a plant of five in our fleet, we
23 do have Point Beach in Wisconsin, Seabrook in New
24 Hampshire and we have the two southern plants, both
25 St. Lucie and as well Turkey Point down in Miami.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 And since 1974, and the reason I mention
2 that is, when we were first connected to the grid,
3 Duane Arnold has become a member of, you know, the
4 third largest fleet for very small plant in Palo, Iowa
5 just outside of Cedar Rapids. And with the inception
6 of that fleet and the strength of that fleet comes a
7 tremendous amount of governance and oversight.

8 So I just kind of wanted to mention that
9 with regards to we are not that small plant in Palo,
10 Iowa. We are actually a member of a much larger fleet
11 with a good bit of governance and oversight.

12 MEMBER SIEBER: Is this a merchant plant?

13 MR. COSTANZO: Yes, it is. There is a
14 portion. We do work with a PPA, which is a Power
15 Purchase Agreement, with the State of Iowa, but yes,
16 there is a portion of it that is a merchant.

17 MEMBER SIEBER: Okay. Thank you.

18 MR. COSTANZO: A little background on
19 plant status. We did start-up from the refueling
20 outage 21 and that was in March of 2009. The current
21 plant status is it's operating very well. We are at
22 100 percent power. And I just will mention, I'm
23 certain that the Committee is familiar with the
24 Institute for Nuclear Power Operations, we were just
25 rated as an excellence rating back in December, and we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 are operating the licensee response column with the
2 NRC.

3 We did have a mid-cycle outage that we
4 concluded in May. We did have an issue with a drywell
5 cooler leak. It was one of the last remaining copper-
6 tubed coolers, which did have a very small leak. We
7 did also identify that we did have -- actually, there
8 was a small plug in one of our circuit-setter valves,
9 which is the throttle valve on the outlet of the those
10 coolers that did have some erosion that also caused
11 that leak and it got up to almost 3.5 to 4 gallons a
12 minute. And we did take the unit off and made those
13 repairs.

14 And as well, there were several other, not
15 several, but there were some other issues that we did
16 take care of during that mid-cycle outage to get us
17 ready for our outage this year.

18 MEMBER SIEBER: I take it you didn't
19 replace the heat exchanger?

20 MR. COSTANZO: Actually, we did. I'm
21 sorry.

22 MEMBER SIEBER: Okay.

23 MR. COSTANZO: Yes, we did. It was
24 actually a job that was going to be done in this
25 upcoming refueling outage, however, we did take the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 opportunity to put a stainless steel cooler in, which
2 is a much nicer design and much more reliable.

3 MEMBER SIEBER: So is that the end of the
4 copper in that kind of application?

5 MR. COSTANZO: There is actually one set
6 of coolers that still remain copper, but they are much
7 different design. They are not like a U-tube type
8 heat exchanger. They are a full flow with a tube
9 sheet that haven't experienced that same type of
10 corrosion on those coolers that we have had excellent
11 reliability on. So with those two, there is no more
12 remaining copper-tubed coolers in containment.

13 MEMBER SIEBER: Okay.

14 MR. COSTANZO: Our next refueling outage
15 is in October of 2010.

16 CONSULTANT BARTON: You have what kind of
17 cycle refueling cycle?

18 MR. PUTNAM: Variable.

19 CONSULTANT BARTON: Variable?

20 MR. PUTNAM: Yes, it's two years is the
21 nominal, you know, like the tech spec surveillance
22 frequency, but fuel loading decides exactly what it
23 is, so we are a little under probably this year.

24 MR. KLEINHEINZ: We are averaging about 21
25 month cycles.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CONSULTANT BARTON: Okay. Okay.

2 MR. COSTANZO: And I'll turn it over to
3 Ken to talk a little bit about the operating history.

4 MR. KLEINHEINZ: All right. Good morning.
5 Again, my name is Ken Kleinheinz. I'm the
6 Engineering Director at the plant. I'll be presenting
7 slides 7 through 9. We'll go to slide 7 there.

8 On 7, we show a brief time line of the
9 operating history of the plant with regard to its
10 license. That history starts in 1970 when the Atomic
11 Energy Commission granted a construction permit to
12 Iowa Electric Light & Power and its two minority
13 owners. And then four years later they issued License
14 DPR-49, the operating license. And then just about
15 one year after that, the plant went fully commercial
16 in 1975.

17 In 1985, back to the question that Mr.
18 Burton asked, we were approved for an uprate of,
19 approximately, 5 percent in our tech spec to get us
20 from that 1593 up to 1658.

21 And then in November of 2001, we were the
22 first plant approved for extended power uprate. And
23 that was to go to a full 120 percent of original rated
24 thermal power.

25 The plant used a very deliberate phased

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 approach to implementing the extended power uprate.
2 We implemented mods to equipment over several cycles.

3 I'm going to describe some of those uprates in the
4 next two slides, so I'll hold off on that now.

5 But as Chris mentioned, the final phase
6 was completed at our last outage in the spring of 2009
7 and we did reach full extended power in March of 2009.

8 Let's see, in 2006, the plant was
9 purchased by FPL Group, NextEra Energy and the license
10 was transferred at that time. And then September
11 2008, we submitted our application for license renewal
12 and that's what will extend our current license, which
13 expires, as it states, in February of 2014.

14 Are there any questions on Slide 7 before
15 I move on?

16 CONSULTANT BARTON: What kind of equipment
17 did you have to change out for that large increase?

18 MR. KLEINHEINZ: I'm going to cover that--

19 CONSULTANT BARTON: Okay.

20 MR. KLEINHEINZ: -- on the next two
21 slides.

22 CONSULTANT BARTON: Gotcha. All right.

23 MR. KLEINHEINZ: And if there is any
24 questions after that, I'll --

25 CONSULTANT BARTON: All right. Thank you.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. KLEINHEINZ: Okay. On Slide 8, I
2 mentioned a moment ago that the plant has implemented
3 several upgrades to achieve power uprate. We have
4 also made several upgrades in recent years to support
5 long-term asset health of the plant and also to
6 address several reliability and performance issues,
7 such as the coolers we just mentioned.

8 I used the word deliberate earlier also in
9 describing our approach to power uprate. I think that
10 best characterizes how the plant operates in
11 developing long-term life cycle management plans for
12 the equipment and taken a very conservative approach
13 implementing equipment upgrades and in achieving
14 initiatives like the license renewal, which is one of
15 extended power uprate.

16 Okay. So on Slide 8, the first two
17 bullets list improvements the plant made to ensure the
18 long-term health of the recirculation system piping,
19 stainless steel piping. In 1987, the plant was the
20 pilot for boiling water reactor, hydrogen water
21 chemistry.

22 And since 1987, we have been injecting 6
23 standard cubic feet per minute of hydrogen
24 continuously into our feedwater system to protect that
25 piping.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 In order to stay in the detection phase
2 and monitor the effectiveness of that hydrogen water
3 chemistry, we also installed, at that time, a rather
4 unique system called a crack arrest verification
5 system, so I can point on my slide and you can read
6 through yourself.

7 But basically, that's a continuous monitor
8 using precracked, stressed metal specimens typical
9 alloys like Alloy 600, 304 stainless steel and A182
10 filler material, so we can measure the effectiveness
11 and verify that our cracks are not growing.

12 Also at that time, we installed another
13 system, an electrochemical potential monitor
14 monitoring system. And basically, that's also a
15 continuous system monitoring reactor coolant to make
16 sure the electrochemical potential stays below the
17 value that assures that cracks won't grow. So that
18 has been in place since that time also.

19 MEMBER SHACK: What percent of the time is
20 that operable?

21 MR. KLEINHEINZ: Well, it's got to be --

22 MEMBER SIEBER: Good question.

23 MR. KLEINHEINZ: It is operable more than
24 98 percent of the time.

25 MEMBER SHACK: Oh, that's good.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. KLEINHEINZ: It is very rare for that
2 system to come out of service.

3 MEMBER SHACK: This is the electrochemical
4 potential monitor?

5 MR. KLEINHEINZ: Oh, I'm sorry.

6 MEMBER SHACK: Not the hydrogen water
7 chemistry.

8 MR. KLEINHEINZ: Oh, I'm sorry. I don't
9 have -- I can't say I have a percentage of time.

10 MEMBER SHACK: Is it something that is
11 reliable or as I suspect it takes a lot of coaxing and
12 care?

13 MR. KLEINHEINZ: Not a lot of coaxing and
14 care when the electrodes wear out, we do have to go in
15 and replace, which is no small evolution because of
16 dose concerns mostly.

17 What we have shown is there are other
18 monitoring systems like dissolve hydrogen and oxygen,
19 which are kind of backups to that, so that's not the
20 only system that kind of tells us, you know, based on
21 our start-up test and we know as long as we have a
22 certain result, load of dissolved oxygen, dissolved
23 hydrogen, these --

24 MEMBER SHACK: The hydrogen water
25 chemistry is 98 percent?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. KLEINHEINZ: That system is in service
2 greater than 98 percent of the time.

3 MEMBER SHACK: Okay.

4 MR. KLEINHEINZ: That was one of the
5 conditions for our risk-informed ISI Program.

6 MR. COSTANZO: Actually, we were one of
7 the first plants to put hydrogen water chemistry in
8 their very reduced power and actually, we are looking
9 to do that even further down in the reduction of power
10 as you start to come up to increase the effectiveness
11 of the hydrogen water chemistry. It was recognized by
12 INPO as one of our strengths.

13 MEMBER ARMIJO: Do you still have the
14 original stainless steel piping in your recirc system
15 in coarse braids or have you changed that out?

16 MR. KLEINHEINZ: No, we have the original.

17 MEMBER ARMIJO: You are protecting that
18 with the water chemistry?

19 MR. KLEINHEINZ: That's correct.

20 MEMBER ARMIJO: Okay.

21 MR. KLEINHEINZ: And that's a good
22 question. The purpose of hydrogen water chemistry is
23 to mitigate intergranular stress corrosion cracking of
24 the piping.

25 Now, in 1996, we implemented another

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 process, noble metals application.

2 MEMBER SIEBER: Right.

3 MR. KLEINHEINZ: Because hydrogen water
4 chemistry only provides mitigation for the piping
5 itself. No metals is applied to the piping and to the
6 reactor internals. So that extends the coverage of
7 IGSCC protection into the vessel internals. So we
8 first injected platinum and rhodium in 1996 during
9 that outage and our last application was in the 2005
10 refueling outage.

11 Starting next year, 2011, we will be doing
12 on-line noble metals application, which is now the
13 industry standard. It reduces outage time. It can be
14 performed with the plant at full power. So we look
15 forward to that next year.

16 MEMBER SHACK: Did you do some residual
17 stress improvements? Since you have risk-informed
18 inspections, you somehow got out of the 03-13 enhanced
19 inspections, but you needed two methods.

20 MR. PUTNAM: We did induction heat
21 stressing improvement.

22 MEMBER SHACK: Okay.

23 MR. PUTNAM: And --

24 MR. KLEINHEINZ: Certain welds.

25 MR. PUTNAM: -- in '86 or so. I don't

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 recall.

2 MR. KLEINHEINZ: Roughly, yes. In the
3 mid-'80s, yes.

4 MEMBER SHACK: So it is two methods. SO
5 you have some welds that you did the heating.

6 MR. KLEINHEINZ: There are some welds we
7 did the heating, not all.

8 MEMBER SHACK: Yes.

9 MEMBER ARMIJO: And your shroud, did you
10 have any cracking of your shrouds and did you have to,
11 you know, clamp them, since some plants did?

12 MR. KLEINHEINZ: No. We have had no
13 incidents of cracking in our core shroud to date.

14 MEMBER ARMIJO: Okay.

15 MR. KLEINHEINZ: We will be doing another
16 inspection in our next outage.

17 MEMBER ARMIJO: Good.

18 MR. KLEINHEINZ: Back to the noble metals
19 application. Are there any questions on that, I mean,
20 any further questions?

21 Okay. Just again, back to the monitoring
22 phase. Along with the noble metal application, we did
23 install a coupon system also in that crack arrest
24 verification, the sampling system, we installed
25 coupons that are treated with noble metals, so we can

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 track the wear rates. Make sure the metals are still
2 present protecting our vessel.

3 So we have a routine sampling program
4 where we remove those coupons. And every time we
5 apply, we install new coupons.

6 Okay. Moving on to 19 --

7 MEMBER SHACK: Did you sign up for
8 continuous injection?

9 MR. KLEINHEINZ: Of noble metals?

10 MEMBER SHACK: Yes.

11 MR. KLEINHEINZ: That's platinum and
12 rhodium are not inexpensive, but no, I know of no
13 continuous injections.

14 MEMBER ARMIJO: It lasts a long time
15 though.

16 MR. KLEINHEINZ: They do last a long time,
17 that's right.

18 MEMBER ARMIJO: Yes.

19 MEMBER SIEBER: Need a stimulus program.

20 MR. KLEINHEINZ: In 1998, the plant did
21 install larger emergency core cooling system suction
22 strainers on our low pressure ECCS system that is
23 inside of our torus. We did that to increase our
24 margin in the case there is a pipe break inside our
25 containment that blows debris into the containment and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that gets washed to our torus. So that increased the
2 surface area of those strainers significantly. That
3 was a preemptive measure.

4 In 2001, we implemented the first
5 component upgrades.

6 MEMBER SHACK: When you did that, did you
7 replace --

8 MR. KLEINHEINZ: Okay.

9 MEMBER SHACK: How much fiber insulation
10 is left?

11 MR. KLEINHEINZ: We did not replace the
12 fiber insulation in our drywell, at least not at this
13 point. Now, the BWR Owner's Group is taking a
14 significant look at that and we are a part of that
15 group. As a matter of fact, we'll be doing some
16 significant walk-downs of our containment next outage
17 to, basically, get a feel for how much fibrous
18 insulation is in our containment.

19 MEMBER SHACK: Okay. On the piping you
20 have got reflective metal?

21 MR. KLEINHEINZ: Jacketing on some of it.
22 I don't know if anyone wants to add to that over
23 there, but it is fibrous insulation.

24 MEMBER SHACK: Oh, okay. So it's the
25 packaged kind of fibrous insulation that you can take

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 off to inspect?

2 MR. KLEINHEINZ: Right.

3 MEMBER SHACK: Right.

4 MR. COSTANZO: But as Ken mentioned, we
5 are on the BWR Owner's Group Committee. We are going
6 to stay ahead of that in prevention, so that we don't
7 have to react to that. And as the other Ken had
8 mentioned, we are doing some walk-downs to this outage
9 to be able to better understand that, so that when we
10 do have to take some actions, that we would be better
11 poised to do that.

12 MEMBER SHACK: Okay.

13 MR. KLEINHEINZ: In 2001, we implemented
14 the first round of upgrades to support our Phase I of
15 power uprate and that included new high pressure
16 turbine internals, new moisture separator heater
17 internals and then two new circulating water pumps.

18 In 2003, we mentioned, we replaced 10 out
19 of 12 of our copper drywell coolers, those were the
20 original coolers.

21 CONSULTANT BARTON: So one of the two that
22 are remaining leaked?

23 MR. KLEINHEINZ: Yes. We had replaced
24 those in 2001, like-for-like, they were the first ones
25 that caused us an issue and, at that time, we were

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 replacing like-for-like. So we had planned for a
2 later replacement of them, an upgrade, and --

3 CONSULTANT BARTON: It gotcha though.

4 MR. KLEINHEINZ: -- it got me. It got us,
5 yes, sir.

6 MR. COSTANZO: Really, the leaks were very
7 minimal --

8 MR. KLEINHEINZ: As it turned out.

9 MR. COSTANZO: -- on those coolers
10 themselves. We had anticipated that it was going to
11 come from those, because of the history of those
12 coolers. But as I had mentioned, it was actually in
13 the downstream circuit setter valves that had a
14 quarter inch plug that actually caused some turbulent
15 erosion on that plug and it was a hollow plug that
16 actually caused the leak.

17 MR. KLEINHEINZ: So it was the same
18 system, different component that actually affected --

19 MR. COSTANZO: And we did do an extensive
20 condition and root cause analysis and did some
21 mitigating, put some solid plugs in and we will take a
22 look at any other extent of condition we have to do
23 this outage.

24 MEMBER SHACK: Okay.

25 MEMBER ARMIJO: Do you still have the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 original condenser? Did you have stainless steel
2 condensers or did you have --

3 MR. KLEINHEINZ: Yes, we have stainless
4 steel condensers.

5 MEMBER ARMIJO: So you never had the
6 copper Admiralty-brass problem?

7 MR. KLEINHEINZ: No, that's right. We had
8 stainless steel, three or four stainless steel since
9 we began.

10 MEMBER BONACA: In your extended power
11 uprate, did you need credit for accident pressure?

12 MR. KLEINHEINZ: Yes.

13 MEMBER BONACA: Okay.

14 MR. KLEINHEINZ: I don't recall the
15 number.

16 MR. PUTNAM: But as a matter of fact, you
17 know, we credited over pressure in the original
18 license for the plant, you know, in power uprate the
19 number changed a pound or two, and we continued to
20 credit over -- containment over-pressure.

21 MEMBER BONACA: All right.

22 MR. KLEINHEINZ: Okay. I'll move on to
23 Slide 9. 2005 included equipment upgrades to support
24 the second phase of power uprate. 6 of 12 of our
25 feedwater heaters replaced in that outage. We

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 replaced both of our condensate pumps with new pumps
2 and motors. And then we installed condenser isolation
3 valves on our circulating water system and that allows
4 us to isolate individual trains of these circ water
5 going into our condensers and do repairs or cleaning
6 of the tubes on-line, if necessary, at lower power.

7 Previously, we had had to shut down any
8 time we had an issue with condenser leaks or fouling.

9 In 2007, we replaced a significant number
10 of the instrumentation and power cables inside our
11 heater bay. We hadn't encountered any failures of
12 these non-safety cables, but it's a higher
13 temperature, ambient temperature in that area and had
14 noted some cracking and brittleness of those cables.

15 So in the prevention mode, we went in and
16 replaced about a third of all the cables in that area
17 to ensure continued reliability.

18 CONSULTANT BARTON: With different cable
19 insulation?

20 MR. KLEINHEINZ: Well, I'll ask Mike. I
21 don't believe there is anything significantly
22 different than what we had.

23 MR. FAIRCHILD: This is Mike Fairchild.
24 No, it was basically the same type of cable, XLPE
25 installation.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. KLEINHEINZ: Okay. In our 2009
2 outage, our last refueling outage in the spring of
3 '09, we implemented several upgrades to our emergency
4 diesel generators, replaced the governor on the Bravo
5 Generator. We will replace the Alpha Governor in this
6 coming fall outage. Then we also replaced both
7 regulating systems on those engines for reliability
8 purposes.

9 MEMBER SIEBER: What kind of governors
10 were originally on and what did you replace them with?

11 MR. KLEINHEINZ: Woodward.

12 MEMBER SIEBER: Okay.

13 MR. KLEINHEINZ: Both.

14 MEMBER SIEBER: So it's --

15 MR. KLEINHEINZ: An upgrade.

16 MEMBER SIEBER: -- the new one is an
17 upgrade or just a replacement?

18 MR. KLEINHEINZ: No, it is an upgrade. It
19 makes the engines a little more responsive.

20 MEMBER SIEBER: Okay.

21 MR. KLEINHEINZ: Then we installed the
22 last large upgrade to achieve full power uprate and
23 that was a replacement of our main transformers.

24 And then just a couple more enhancements
25 we did during that outage. We put new more reliable

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Jordan positioners on our recirc pump MG Set Scoop
2 Tube Positioners. And then lastly, replaced our
3 ultrasonic feedwater flow measuring system during that
4 outage to get us a little more accurate calorimetric
5 for measuring reactor power.

6 CONSULTANT BARTON: Transformer upgrade
7 was just because of power uprate? It wasn't because
8 of transformer failures?

9 MR. KLEINHEINZ: The transformers are not
10 failed. We had basically four individual phases. One
11 was a spare and any time could be swapped out.

12 CONSULTANT BARTON: Okay.

13 MR. KLEINHEINZ: So they were all operable
14 at the time of the change out.

15 CONSULTANT BARTON: All right.

16 MR. KLEINHEINZ: The one showed some signs
17 of gasing, I think, so early signs of degradation.

18 MR. COSTANZO: Now, Mr. Barton, one of
19 your questions was, you know, we talked a little bit
20 about the power upgrade and what were those
21 modifications we did. The list is not, obviously, all
22 due to those modifications required for power uprate,
23 but they do represent a lot of our life cycle
24 management, our system health reporting systems for
25 obsolescence and some, unfortunately, for instance the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 tube position upgrade we did in correction, because we
2 did have some issues and some problems with the
3 previous ones with regard to reactivity control.

4 But it does represent a little bit about
5 the slide that I was trying to show you earlier, our
6 value with regard to prevention and protection.

7 CONSULTANT BARTON: Thank you.

8 MR. KLEINHEINZ: Any other questions on
9 Slides 7 through 9? Okay. Hearing none, then I'm
10 going to turn the presentation over to our License
11 Renewal Project Manager, Ken Putnam who will cover the
12 remaining slides.

13 MR. PUTNAM: All right. Thanks. I'll
14 give a brief overview of our License Renewal Project
15 for Duane Arnold and then cover the three technical
16 items of interest, including two open items we have
17 with the staff.

18 Shortly after FPL purchased Duane Arnold,
19 we kicked off the project to renew the operating
20 license. The decision was made then that we wanted
21 the bulk of the work done on-site at Duane Arnold,
22 that would allow us to have good site ownership and
23 oversight to support both the quality of the project
24 as well as ensure we had site ownership of the
25 programs as we went forward in implementing license

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 renewal.

2 We staffed the project with a very
3 experienced team. It included people who had been
4 long-term employees at Duane Arnold. We also had
5 several people who had been involved from corporate at
6 St. Lucie and Turkey Points License Renewal, so we had
7 their experience and then we augmented that with
8 contract staff, who had been at an awful lot of the
9 plants that have renewed their license in the past.

10 To ensure we tapped into the most current
11 experience with respect to renewing the license for a
12 BWR, we sent our team up to Monticello who was just
13 wrapping up their License Renewal Project, at that
14 time, to do benchmarking for a week there, that was a
15 great leaning experience for us. We picked up a lot
16 of things from them.

17 And we have continued to be engaged with
18 the industry throughout the project, sending team
19 members to observe audits at other sites during -- who
20 were slightly in front of us. And we have also
21 participated in industry working groups throughout the
22 period.

23 We did have peer reviews of both the
24 technical products being produced by our individual
25 disciplines. And we also had a peer review of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 integrated application at the end. We did also use
2 our QA folks to perform independent audits midstream
3 as we were developing our analysis to check us to make
4 sure we were following our own processes.

5 Next slide. The scoping process is pretty
6 standard. We followed NEI 95-10. We categorized the
7 entire plant in terms of major system structures and
8 components and we tried to stay as close as practical
9 to the existing plant system nomenclature.

10 We went through each of the systems and
11 cataloged the system level functions then evaluated
12 these functions against the scope and criteria
13 specified in 10 CFR 54.4(a)(1) for safety-related
14 (a)(2) for non-safety-related equipment that could
15 affect safety-related and (a)(3) for the regulated
16 events of EQ fire protection at loss, ATWs and station
17 blackout.

18 Then we went down to the component level
19 and identified those components supporting an intended
20 function under the license renewal.

21 Next slide.

22 MEMBER STETKAR: Ken, on that, I don't
23 think you are going to cover it later, so stop me if
24 you are. But I noticed there was some discussion
25 about the intake trash racks and the rakes on the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 trash racks. And they are currently not in scope.

2 They do provide protection for safety-
3 related service water intake traveling screens. The
4 discussion seemed to focus on the fact that failures
5 of the trash racks themselves would not block the
6 intake, because the trash racks would collapse down
7 into the intake. Well, I can buy that, they are steel
8 or whatever they are made out of.

9 On the other hand, what they do is they
10 keep large debris from coming in and jamming up the
11 traveling screens which then causes smaller debris to
12 collect on the screens, which then plugs the intake.

13 So I was curious why the maintenance of
14 the function of those trash racks is excluded from the
15 scoping.

16 And also the second question is it
17 probably gets pretty cold in Palo in the wintertime.
18 Do they block ice from coming in from the river?

19 MR. PUTNAM: I'll let Curt Bock, our
20 mechanical lead, maybe answer that.

21 MR. BOCK: Yes. This is Curt Bock for the
22 applicant. Our main reasoning there was that the flow
23 that is the inner velocity through those racks is so
24 small that we felt that the racks would fall directly
25 down and would not impact our safety-related equipment

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that is in our intake structure.

2 MEMBER STETKAR: I understand that. As I
3 said, they are steel. They will go down.

4 MR. BOCK: Right.

5 MEMBER STETKAR: The stuff that is
6 floating in the river will not go down. So I'm
7 curious about if the trash racks disappear, what
8 protection does your safety-related intake have from
9 debris in the river? Large debris.

10 MR. BOCK: Well, if we no longer have the
11 trash racks, then larger debris would be able to --
12 you are assuming a failure of the trash racks?

13 MEMBER STETKAR: Yes.

14 MR. BOCK: Which would then -- the
15 material could then enter that area in the intake
16 structure.

17 MR. PUTNAM: That configuration though at
18 the intake rake, Curt, the screen flow pulls the stuff
19 away. You know, it is kind of angled toward the
20 downstream, so that debris tends to not sweep into
21 that intake. And then, you know, our operating
22 experience certainly is we don't get trash on those
23 trash racks oddly enough. We have a trash grate there
24 that is intended to like remove that. It was never
25 getting used. We had to put a PM in place to cycle

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the motors, because it was never used.

2 MEMBER STETKAR: That's good experience.
3 I mean, that's odd, but that's good experience.

4 MEMBER SIEBER: Well, usually the screen
5 house is built with the outer shell submerged, so the
6 trash actually stays out in the river.

7 MR. PUTNAM: Right.

8 MEMBER SIEBER: While the water flows in,
9 that's why it doesn't freeze in there provided you
10 heat the building, which is the other question, I
11 think, you asked.

12 MEMBER STETKAR: Yes.

13 MEMBER SIEBER: On the other hand, that
14 doesn't happen all the time.

15 MR. PUTNAM: Yes, we do have deicing out
16 there as well where we circulate circ water, I guess--

17 MR. BOCK: Yes.

18 MR. PUTNAM: -- back to the -- to spray on
19 those in that area.

20 MEMBER SIEBER: Screen wash pumps, right.

21 MR. PUTNAM: To keep things in place.

22 MEMBER STETKAR: But basically your
23 operating experience is that you don't have periods of
24 large --

25 MR. PUTNAM: That's correct.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: -- things coming in, tree
2 limbs.

3 MR. PUTNAM: No.

4 MEMBER SHACK: Even when you had Cedar
5 Rapid flooding?

6 MR. PUTNAM: We inspect them.

7 MEMBER STETKAR: I mean, you know,
8 riverine locations in northern climates tend to get
9 affected, you know, in the autumn we have severe
10 storms in the autumn and brings down tree limbs and
11 lots of debris in winter.

12 MR. PUTNAM: And as Curt said, the
13 approach velocity is really slow there. The river
14 speed is actually, I think, faster than the approach
15 velocity of the pumps pulling it in, so it's --

16 MEMBER STETKAR: Okay.

17 MR. PUTNAM: -- not competing with the
18 river in terms of flow over there.

19 MEMBER STETKAR: Thank you.

20 CONSULTANT BARTON: In the recent floods,
21 did any of that equipment at the intake get flooded?

22 MR. PUTNAM: You know, we had some backup
23 discussion of the flooding, if you would be interested
24 in jumping clear to that now?

25 CONSULTANT BARTON: Oh, if you are going

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 to cover it, that's fine.

2 MR. PUTNAM: Well, we intended. Mike, why
3 don't you pull that up and let's just jump to that
4 now.

5 MR. FAIRCHILD: Okay.

6 MR. PUTNAM: Go ahead, Mike.

7 MR. FAIRCHILD: This is Mike Fairchild for
8 Duane Arnold. This is a picture of the plant before
9 the flood. This is during the flood and this is
10 actually from the opposite direction. This is the
11 intake structure.

12 CHAIR BLEY: Could you go back to when the
13 orientation changed in it?

14 MR. FAIRCHILD: Yes, the orientation
15 changed.

16 MEMBER SIEBER: Oh, okay.

17 MR. FAIRCHILD: You can see the intake
18 structure is over here.

19 MEMBER SIEBER: So that was that little
20 island over there, right?

21 MR. FAIRCHILD: Yes.

22 MEMBER SIEBER: Okay. Got it.

23 MR. FAIRCHILD: None of the safety-related
24 components in the intake structure got water in it.
25 The level was above it and the next slide has the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 actual levels, one of the next slides.

2 MEMBER SIEBER: I take it that was
3 inaccessible, your intake structure, during the whole
4 period of the flood. So if you got debris, you
5 couldn't do anything about it anyway, right?

6 MR. FAIRCHILD: Right. There was --

7 MR. COSTANZO: Well, you would have had to
8 send some boats out there and mitigate by boat.

9 MEMBER SIEBER: Maybe you can go.

10 CONSULTANT BARTON: Yes, but could you
11 take big equipment to get the chicken coops and stuff
12 off the trash racks?

13 MR. FAIRCHILD: The river was actually
14 relatively debris free.

15 CONSULTANT BARTON: Was it?

16 MR. PUTNAM: At Duane Arnold.

17 MR. FAIRCHILD: Yes, at Duane Arnold.

18 MR. PUTNAM: Down the street at Cedar
19 Rapids --

20 MEMBER STETKAR: Before you flip to the
21 next one, is that your switchyard in the lower left
22 hand?

23 MR. FAIRCHILD: No, the switchyard is
24 actually right over here.

25 MEMBER STETKAR: Oh, back there? Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. FAIRCHILD: This is a parking lot.

2 MEMBER STETKAR: Oh, that's a parking lot.

3 Okay. I couldn't see.

4 MR. FAIRCHILD: Okay.

5 MEMBER STETKAR: Thank you.

6 MEMBER SIEBER: The insurance company
7 solves --

8 MR. FAIRCHILD: This is the flood levels
9 for Cedar Rapids. You can see the 2008 flood was
10 significantly higher than the previous records, over
11 11 feet.

12 MEMBER SIEBER: Yes.

13 MR. FAIRCHILD: So that was quite an
14 experience for us. The maximum probable flood is
15 764.1 and the intake structure floor level where the
16 safety-related equipment is is actually 767.

17 MEMBER STETKAR: Okay.

18 MR. FAIRCHILD: And that's what the plant
19 is designed to withstand. The main plant area
20 actually has stop logs and things to block entrances
21 up to that level.

22 CHAIR BLEY: What was the level in this
23 last part?

24 MEMBER SIEBER: 730 he said.

25 MR. FAIRCHILD: 751.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER SIEBER: 751.

2 CHAIR BLEY: 751.

3 MEMBER STETKAR: It's right here.

4 CHAIR BLEY: The flood zone.

5 MR. FAIRCHILD: That was the highest flood
6 level.

7 CONSULTANT BARTON: So your flood design
8 is higher than what you experienced in this flood?

9 MR. FAIRCHILD: That is correct.

10 CONSULTANT BARTON: All right.

11 MR. FAIRCHILD: And then this is 15 plus
12 years of records, river level rev and you can see that
13 the 2008 was significantly higher than anything we had
14 had previously. The closest was like 2003. And our
15 records, computer records didn't go back that far.
16 This is just a trace of how it went up and the length
17 of time of the flood.

18 The purple line below is the average river
19 level and the green line on top is the plant floor
20 level.

21 CONSULTANT BARTON: Okay.

22 MR. FAIRCHILD: To show how much spare we
23 had, margin.

24 MEMBER SIEBER: 17 feet.

25 MR. COSTANZO: We had some renewed

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 advocacy by the entire Cedar Rapids area, because we
2 were one of the only stations that stayed on producing
3 electricity.

4 CONSULTANT BARTON: That's good for you.

5 MR. FAIRCHILD: We operated at 100 percent
6 power. If we had to back down it was because of lack
7 of load, not lack of any problems in the plant. And
8 only a couple of out buildings got water in them.
9 Just a little bit on the floor. Any further questions
10 on the flood?

11 CONSULTANT BARTON: Thank you.

12 MEMBER SIEBER: I think they have already
13 had their 100 year flood.

14 CONSULTANT BARTON: I think so.

15 MEMBER SIEBER: So they don't need it
16 inspected.

17 MR. PUTNAM: Yes, it was beyond the 100
18 year flood levels in Cedar Rapids. You know, it
19 certainly was a traumatic event for our community, I
20 think, more than for our plant.

21 MEMBER SIEBER: Yes.

22 MR. PUTNAM: A lot of people affected by
23 it.

24 MEMBER SIEBER: Right.

25 MR. PUTNAM: All right. Sorry, where was

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 I? On scoping, right? Let me think where I cut off
2 here.

3 MR. COSTANZO: At the fourth bullet down.

4 MR. PUTNAM: All right. Yes. We mapped
5 this stuff down to the individual component level.
6 Let's go to the next slide, Mike.

7 MEMBER STETKAR: I'm not going to let you
8 off the hook --

9 MR. PUTNAM: Okay.

10 MEMBER STETKAR: -- quite -- well, yes, I
11 am. Get to the next slide.

12 MR. PUTNAM: I've got one more slide of
13 scoping.

14 MEMBER STETKAR: Okay. I'll let you get
15 to the middle bullet on this one.

16 MR. PUTNAM: We use site component
17 databases and controlled drawings and all controlled
18 documents for performing the scoping reviews. For
19 safety-related and the regulated events, those
20 databases they were easy, you know, it was one-to-one,
21 straightforward match-up on the definition of safety-
22 related. That was pretty straightforward stuff.

23 They weren't really constructed to
24 evaluate non-safety affecting safety that is kind of a
25 different concept from our current licensing basis.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 So to compensate for that, we took a conservative
2 spaces approach. Like I said, we had good databases
3 on where our safety-related equipment is, so we took a
4 spaces approach where anything that had -- any area
5 that had safety-related equipment in it, we assumed
6 that the non-safety-related equipment located in that
7 same area could affect that safety-related equipment
8 and evaluated it for scope.

9 To confirm that there wasn't anything
10 unique about the physical location that doesn't show
11 up in the database or on a drawing, we did send our --
12 we have a couple of former shift managers on the team.

13 We sent them out to walk-down those areas we excluded
14 to make sure there wasn't something going on in the
15 plant where there was more interaction than we
16 realized from the drawings. And so that gave us a
17 good comfort that we had the right scope there on non-
18 safety affecting safety.

19 For things like electrical really aren't--
20 isn't information so much down to the component and
21 tag number, level, so those we treated as commodity
22 groups in performing the evaluation at the commodity
23 group level, that's how we performed our scoping. I
24 assume you've got a question for me now?

25 MEMBER STETKAR: Yes, I do. And this is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the appropriate place to ask this one, I guess. There
2 was a question, I think, about scoping of the main
3 generator hydrogen coolers. And I'm assuming it was
4 under (a)(2). I didn't go back and check my notes
5 this morning.

6 MR. PUTNAM: Yes.

7 MEMBER STETKAR: But the response to the
8 staff's question said that the floor generator
9 hydrogen coolers are tube heat exchangers that are
10 entirely contained within the main generator shell.

11 MEMBER SIEBER: Right.

12 MEMBER STETKAR: Your hydrogen coolers are
13 inside the main generators?

14 MR. PUTNAM: Yes.

15 MEMBER STETKAR: Inside the main
16 generator?

17 MR. PUTNAM: Yes.

18 MEMBER STETKAR: That's -- okay.

19 MEMBER SIEBER: It is water in.

20 MEMBER STETKAR: A lot of plants don't do
21 that though. They don't like service water --

22 MR. PUTNAM: Yes, you don't want them to
23 leak.

24 MEMBER STETKAR: You don't want them to
25 leak. Okay. But yours are inside. Okay. Thanks.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CONSULTANT BARTON: It's a typical GE
2 design, if I remember correctly.

3 MEMBER STETKAR: Is it?

4 CONSULTANT BARTON: Yes.

5 MEMBER STETKAR: Okay.

6 CONSULTANT BARTON: I have seen GE plants
7 that have the hydrogen coolers down below.

8 MEMBER STETKAR: Okay.

9 CONSULTANT BARTON: Thanks.

10 MEMBER STETKAR: Is it these older GE
11 plans?

12 CONSULTANT BARTON: That could be, yes.

13 MEMBER STETKAR: Okay.

14 CONSULTANT BARTON: The ones I have seen
15 are newer ones.

16 MEMBER SIEBER: One thing, Westinghouse
17 had that, too, in some plants.

18 MEMBER STETKAR: Okay. Thanks. I just
19 hadn't seen one. Thank you.

20 CONSULTANT BARTON: Okay.

21 MEMBER STETKAR: Another question. This
22 is kind of scoping or -- I guess it is. You have
23 excluded monitoring of hot insulated piping that is
24 located indoors, because the argument that hot piping
25 will not have corrosion, because there is no way that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 moisture can collect on that hot piping.

2 Although I noticed your operating
3 experience said you had had some corrosion on the
4 external surfaces of the turbine stop-valve piping,
5 which is usually pretty hot.

6 So I was curious what the basis for
7 excluding hot piping --

8 MR. PUTNAM: No, we didn't exclude it from
9 scope. It is in scope.

10 MEMBER STETKAR: It is in scope, it's just
11 not part of the -- but I looked at forwarding your --

12 MR. PUTNAM: For one of the aging effects
13 there.

14 MEMBER STETKAR: Right.

15 MR. PUTNAM: Corrosion on the exterior
16 surface and I forget the details. If you remember
17 more, Curt, feel free to correct me. You know, so
18 that is really about evaluating one aging effect
19 there.

20 MEMBER STETKAR: Okay. I was looking
21 ahead and there wasn't a convenient place to ask you
22 about it in the next couple of slides.

23 MR. PUTNAM: I don't recall that operating
24 experience you are talking about off-hand, so I really
25 -- we can check into that, but I don't --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: I was just -- the main
2 question that I had, of course, is that if the piping
3 is always hot, above 212 degrees, 365 days a year,
4 there's no much chance to get water between the
5 insulation and the pipe.

6 On the other hand, if the pipe is cooled
7 down for extended periods of time, like during
8 outages, you might have some type of corrosive
9 effects. So I was curious. I was sort of interested
10 to know what systems or what piping sections are
11 excluded from that aging management program due to
12 that consideration?

13 MR. PUTNAM: Well, you know --

14 MEMBER STETKAR: It's probably something
15 you have to go back and take a look at.

16 MR. PUTNAM: Yes, we would have to look
17 that up.

18 MEMBER STETKAR: That's fine.

19 MR. PUTNAM: I'm sure it would be quite a
20 number of them.

21 MEMBER STETKAR: Yes, that's what I was --

22 MR. PUTNAM: That was in our methodology
23 as you work through evaluating each of the aging
24 effects, if it was above 212, and I don't remember if
25 there was a material restriction on that evaluation or

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 not, but if it was, if it fits the box that we defined
2 in our methodology using the EPRI tools, that's how we
3 treated it.

4 MEMBER SIEBER: But that's just the
5 external surface?

6 MR. PUTNAM: Correct.

7 MEMBER SIEBER: You still have the
8 corrosion taking place inside the piping.

9 MR. PUTNAM: That's correct.

10 MEMBER SIEBER: Which I'm sure you do
11 examine UT or whatever method you use. That is where
12 I would expect the most significant wall thinning from
13 the inside.

14 MR. PUTNAM: And that would depend on the
15 system again.

16 MEMBER SIEBER: Yes.

17 MR. PUTNAM: What we were doing on the
18 inside.

19 MEMBER SIEBER: Yes.

20 MR. PUTNAM: Next slide.

21 CONSULTANT BARTON: Let me ask you a
22 question on scoping. Can you explain to me what your
23 safety-related air system is? I was confused in your
24 application. The instrument air is not included. Do
25 you have a safety-related air system?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. PUTNAM: Yes.

2 CONSULTANT BARTON: What is it and what
3 are the components of it?

4 MR. PUTNAM: Curt, do you want to answer
5 that?

6 MR. BOCK: Yes. This is Curt Bock for the
7 applicant. Our safety-related air system, it's a
8 system designed to provide a reliable source of
9 compressed air to operate components in the standby
10 gas treatment system, control building standby filter
11 unit and the control building ventilation system and
12 other containment isolation valves.

13 We have two independent redundant motor-
14 driven air compressors that are powered by the vital
15 buses. Dryers, receivers, instrumentation and the
16 distribution piping. The air receivers are normally
17 supplied by the plant instrument air system. And then
18 if, you know, air pressure falls below the set point,
19 they will kick on.

20 They are normally cooled by well water
21 with emergency service water backup. And the
22 compressors and dryers and receivers are located in a
23 portion of a standby gas treatment system room in our
24 reactor building on the second level.

25 CONSULTANT BARTON: Are some of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 components in the instrument air system also part of
2 the safety-related system or is the safety-related air
3 system entirely separate?

4 MR. PUTNAM: You know, typically, you
5 know, most of the safety-related components that are
6 supplied by air are fail-safe.

7 CONSULTANT BARTON: I understand that.

8 MR. PUTNAM: If there is a loss of air, it
9 will fail to -- like an isolation valve, it will fail
10 to close. For a handful of equipment, that's not
11 true. You need active air to make it work right. And
12 that's the component that is supplied by that safety-
13 related air.

14 CONSULTANT BARTON: But what is the air
15 source for that? Is it instrument air or is it
16 nitrogen bottles? You know, what is the source?

17 MR. PUTNAM: No, it's instrument air.
18 It's compressing atmospheric air and drying it. And
19 there is a, you know, redundant path with check valves
20 that your normal instrument air system is supplying it
21 99.9 percent of the time. If for some reason that
22 non-safety-related air went away, a check valve would
23 close and these compressors would start up and provide
24 air to that limited number of components.

25 CHAIR BLEY: So the safety-related air

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 system is a standby system that only supplies some of
2 the components supplied by instrument air?

3 MR. PUTNAM: Correct.

4 MR. BOCK: Correct.

5 CHAIR BLEY: Okay.

6 MR. PUTNAM: A very small subset.

7 CHAIR BLEY: Thanks.

8 CONSULTANT BARTON: Now I understand it.

9 All right.

10 MEMBER STETKAR: Does the safety-related
11 air system come into the instrument air head or
12 downstream from the outlet of the air receivers or
13 does the -- do the safety-related air compressors
14 charge the air receiver, the main air receiver from
15 the plant air system?

16 MR. PUTNAM: Downstream.

17 MEMBER STETKAR: They are downstream.
18 Okay. Okay. Now, you had problems with corrosion in
19 your instrument air system. Corrosion inside the air
20 receiver.

21 MR. PUTNAM: Yes.

22 MEMBER STETKAR: And apparently, corrosion
23 in the piping from the air compressor building --

24 MR. PUTNAM: Yes.

25 MEMBER STETKAR: -- wherever it is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 located, because you replaced that.

2 MR. PUTNAM: Yes.

3 MEMBER STETKAR: When did that happen?
4 When was that all of that? When was the piping
5 replaced? And when did you -- you repaired the
6 corrosion on the inside of the air receivers with weld
7 grounded down and put weld overlays or something like
8 that. When did that happen?

9 MR. PUTNAM: I don't have that
10 information.

11 MR. BOCK: Approximately, 2007.

12 MEMBER STETKAR: 2007. So about three
13 years ago. Okay. I don't need a precise date. I was
14 looking for, you know, 1980 versus 2010. So a couple
15 of years ago.

16 MR. BOCK: Correct.

17 MR. PUTNAM: And that stuff, obviously, is
18 upstream of the dryers.

19 MEMBER STETKAR: That's right. But on the
20 other hand, you now, corrosion products and moisture
21 from those events can be carried through the system
22 and eventually deposit down in little solenoid
23 operated valves. And having worked at a plant that
24 had a problem that way, your fail-safe valves don't
25 fail-safe if the solenoids don't move when they are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 de-energized.

2 So I was curious whether you have had any
3 problems in the intervening three years with operation
4 of any of the air operated equipment or whether you
5 actually checked the eventual consumer lines, you
6 know, blew down the lines at the final endpoint to see
7 whether you had corrosion products and moisture out in
8 there?

9 MR. PUTNAM: We do routine periodic blow
10 downs.

11 MEMBER STETKAR: You do.

12 MR. PUTNAM: With the system in place and
13 check for exactly that.

14 MEMBER STETKAR: Good.

15 MR. PUTNAM: And we didn't -- we haven't
16 had any problem with the dryers.

17 MEMBER STETKAR: If you are doing the blow
18 downs --

19 MR. PUTNAM: Currently, you know, in the
20 way-back times we have had problems back in the early
21 '80s there with, I think it was, desiccant carrying
22 over and getting in there and causing problems. So
23 that, you know, we definitely know exactly what you
24 are talking about in terms of causing problems
25 downstream. And we do have -- we upgraded our dryers

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 to get rid of the desiccant moving downstream. And we
2 do do periodic blow downs --

3 MEMBER STETKAR: You do periodic blow
4 downs out at the end --

5 MR. PUTNAM: -- to check the quality of
6 that area.

7 MEMBER STETKAR: -- of consumers.

8 MR. COSTANZO: And part of the prevention
9 system is an operator can't go stroke a valve for an
10 IST. If it was an IST stroke, if he doesn't know the
11 history back two to three years and therefore can
12 monitor that, and if there is any change in that
13 prevention protection model, that gets incorporated
14 into the risk model and then you plan the work orders.
15 You get yourself prepared. And that feeds back to
16 the monitoring program. So we would have early
17 indication to be able to stand prevention in that.

18 MEMBER STETKAR: Okay. Thank you.
19 Thanks.

20 MR. PUTNAM: Does that hit on where we are
21 at on scoping? Any other questions on that? All
22 right.

23 Time-limited aging analysis. We do have
24 to take a look at time-limited aging analysis under
25 the regulations in place that our analysis relies on

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 on a component of time to determine its adequacy. We
2 have a very good electronic file system of our
3 licensing basis for the facility. Every piece of
4 communication we ever had with the NRC is in a nicely
5 searchable format. We are able to do keyword searches
6 on that and definitely find anything in that realm
7 that mattered for licensing that depended on time.

8 We also went through all our calculations
9 and looked for anything there that was depending on
10 time and we also interviewed our engineers for
11 anything we might miss and compared ourselves against
12 similar plants to see what was in their time-limited
13 aging analysis.

14 So we think we have a good list of those
15 things where time matters in terms of 40 years of time
16 to take a look at.

17 Some of the things we did need to relook
18 at definitely neutron fluence, obviously, changes as
19 you go to 60 years, so we did reperform our analysis
20 for that. We went to the RAMA methodology. We hadn't
21 previously had that. That was a good improvement for
22 us, because it allowed us to do a lot better modeling
23 of our internals. We had good modeling, I think, of
24 the shell, not so good of the reactor vessel
25 internals. So by going to the RAMA methodology, I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 think we improved quite a bit there.

2 We selected 54 effective full power years
3 as the endpoint for the analysis. That will take us
4 out several years past the 60 year life. We can't
5 quite get to 54 effective full power years yet. So we
6 picked a conservative value there.

7 And then using that neutron fluence value,
8 we did recalculate pressure-temperature curves for the
9 vessel and confirmed that we could get acceptable
10 results for those.

11 MEMBER SHACK: You mentioned that you
12 didn't have any cracking on your core shroud yet.
13 What's your fluence at those high fluence welds?

14 MR. PUTNAM: Clara, do you actually have
15 numbers for that? They are high.

16 MEMBER ARMIJO: I was going to add to
17 something, Bill. They did have, they mentioned, a
18 fluence of 5 times $10^{20\text{th}}$ for the top guide.

19 MEMBER SHACK: Well, that's their trigger
20 for inspection.

21 MEMBER ARMIJO: That's their threshold for
22 IASCC.

23 MR. PUTNAM: That's written down.

24 MEMBER ARMIJO: But I believe that's a
25 threshold for conventional water chemistry, not a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 threshold when you are doing hydrogen water chemistry.

2 Really, in a sense, that's my question. You are
3 going to have to do some additional inspection of that
4 top guide, because you are already there as far as
5 that threshold.

6 MEMBER SHACK: Right.

7 MEMBER ARMIJO: And then at 50 years or 54
8 years, you will be two orders of magnitude higher in
9 fluence. So my question is do you believe that the
10 threshold that you are using is valid for hydrogen
11 water chemistry plant?

12 MR. PUTNAM: Conservative.

13 MEMBER ARMIJO: Should you be doing
14 something else?

15 MR. PUTNAM: That is a question I don't
16 recall looking at. Clara, do you?

17 MS. RUSHWORTH: This is Clara Rushworth
18 for Duane Arnold. And no, I'll need to specifically
19 go back and see if I can get some more information for
20 you on the top guide. But as far as the core shroud,
21 I have the fluence numbers here. Is that what you
22 were asking?

23 MEMBER SHACK: Yes, that was. I was
24 curious.

25 MS. RUSHWORTH: Here we go. For 54

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 effective full power years, for example, for the H4
2 welds, there is a value of around 4 times $10^{21\text{st}}$
3 neutrons per centimeter squared. And did you want
4 more specific numbers?

5 MEMBER SHACK: No, that's fine.

6 MS. RUSHWORTH: Okay.

7 MEMBER SHACK: You know, so you, you know,
8 clearly have the fluence, so we can attribute some
9 benefit perhaps to the hydrogen water chemistry.

10 MEMBER ARMIJO: Well, that was the
11 original intent for that whole water chemistry change
12 is to protect the internals without having to replace
13 them. And I just wondered if the Owners Group or
14 someone else has come up with an IASCC threshold that
15 is appropriate for hydrogen water chemistry and noble
16 metals or whether you are just going to stick with the
17 conventional threshold, which I think is the 5 times
18 $10^{20\text{th}}$?

19 MR. PUTNAM: The way we did the method,
20 that's what we compared it to.

21 MEMBER ARMIJO: Okay. So you will be
22 doing augmented inspections to look for any evidence
23 of cracking?

24 MR. PUTNAM: That's correct.

25 MEMBER ARMIJO: Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER SHACK: So since Sam brought this
2 up, I had a question on your Commitment No. 46.

3 MR. PUTNAM: Okay.

4 MEMBER SHACK: And since that's not in
5 your document, the only verbiage I have on it is in
6 the staff's SER. And the staff's text makes sense to
7 me, because it talks about BWR VIP-100 and fracture
8 toughness and reevaluating that fracture toughness for
9 higher fluences.

10 The actual commitment as it reads says
11 "Plant-specific inspection and rules we develop for
12 Duane Arnold core shroud welds that are exposed to a
13 neutron fluence equal or greater than a 1 times 10^{21}
14 as needed."

15 So my question is are you still using the
16 5 times 10^{20} fluence threshold for inspection, and
17 this really only applies to the fracture toughness
18 evaluation, or have you changed the fluence threshold
19 for inspection?

20 MR. PUTNAM: I'm going to have to defer
21 over there to the --

22 MS. RUSHWORTH: This is Clara Rushworth
23 for Duane Arnold again. And in our administrative
24 document for the vessel internals and as we mentioned
25 before, we will be doing the core shroud UT

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 inspections this coming outage. And as you said, the
2 1E to the 21st, that's for the VIP-100, and the flaw
3 evaluation, should they occur, and for the
4 reinspection role that is given in the VIP, that value
5 is still 5 times 10^{20th} neutrons per centimeter
6 squared.

7 MEMBER SHACK: Okay.

8 MS. RUSHWORTH: Does that answer your
9 question?

10 MEMBER SHACK: That answers my question.

11 MR. PUTNAM: All right. Thermal cycle
12 projections. If we are done with fluence here.
13 Thermal cycle projections, we did update those for a
14 60 year life. We used where we were at at the time we
15 performed our analysis in terms of actual events we
16 had experienced to that point.

17 Then we projected forward to 60 years
18 using the current rate that we are accumulating
19 thermal cycles. For those events that are very
20 infrequent where we would have been projecting zero,
21 of course, we didn't project zero, we continued to
22 project that those will occur and kept the same number
23 for analysis purpose for those infrequent events.

24 And also for scrams, we had pretty good
25 performance in the period we used for projection. And

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 we were worried that that might be too optimistic, so
2 we added some cushion on there of about a little over
3 30 scrams to make sure that we didn't flirt with
4 problems there at some point downstream.

5 And regardless of the number selected for
6 projection, we will monitor those on an ongoing basis.

7 And if we approach one of those assumptions, in terms
8 of thermal cycles, we will take action before getting
9 there, not after getting there.

10 MEMBER STETKAR: Ken, on the thermal cycle
11 projections, I noticed that you have been monitoring
12 actual plant transients since 1998.

13 MR. PUTNAM: Yes.

14 MEMBER STETKAR: So you have, let's say,
15 real-time data since 1998.

16 MR. PUTNAM: Right.

17 MEMBER STETKAR: You went back and
18 reconstructed the operating history prior to 1998.
19 And I know that there was some discussions about
20 cycles that were used in the power uprate analyses
21 and, apparently, those have been reconciled for the
22 license renewal process.

23 Do you have any -- I know the staff asked
24 for it and I was curious whether you had any more
25 detailed information that shows how your trip history

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 or your transient history has changed over time?

2 I mean, typically, you will see a
3 reduction from early years and improved performance in
4 later years. I'm curious where -- you typically find
5 a knee in that performance. So I'm curious about
6 where that knee is relative to the experience that you
7 use to project out into the future.

8 MR. PUTNAM: We didn't bring along a
9 histogram of scrams. You're really asking scrams --

10 MEMBER STETKAR: Yes, that's --

11 MR. PUTNAM: I think we do have one in the
12 background of shutdowns there. Our data gets a little
13 bit skewed because we had an extended outage in '78
14 and '79, so we got like a one year period there with
15 extraordinarily good performance and we were never
16 operating.

17 MEMBER STETKAR: Not many scrams, yes.

18 MR. PUTNAM: I don't think they thought it
19 was good at the time. You know, so it gets a little
20 bit flatter at the beginning of life than maybe --

21 MEMBER STETKAR: Than you would --

22 MR. PUTNAM: -- you would guess. But yes,
23 I think in the first --

24 MEMBER STETKAR: I would be curious.

25 MR. PUTNAM: -- 10 years, we had a high --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: Oh, yes, I mean, that's
2 typical performance.

3 MR. PUTNAM: Clearly, we had a high number
4 of scrams. We had extremely good performance in the
5 mid '80s out there.

6 MEMBER STETKAR: What particular period of
7 time for your operating history did you use as the
8 basis for your projection?

9 MR. PUTNAM: Yes.

10 MEMBER STETKAR: In other words, you know,
11 the years that you used to calculate your average
12 number of transients per year going forward.

13 MR. PUTNAM: I think that we used like '98
14 to 2005, something like that, you know, it was roughly
15 seven or eight years --

16 MEMBER STETKAR: About seven years.

17 MR. PUTNAM: -- there in the --

18 MEMBER STETKAR: Perhaps, you know, you
19 could put together or maybe the staff may have the
20 histogram and I can get it from them. We typically
21 don't get all of the RAIs.

22 MR. PUTNAM: If you want to pull up that
23 histogram on shutdown, I don't think we put a
24 histogram of scrams in there.

25 MEMBER SIEBER: Well, the interesting

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 thing about the curves of transients over the years is
2 that there is a knee in the beginning. There is also
3 a knee at the end, that's why they call it --

4 MEMBER STETKAR: Not in this one. There
5 is not a knee here.

6 CHAIR BLEY: Bending over gradually.

7 MEMBER STETKAR: I'm used to seeing kind
8 of an inverse of this, but --

9 MR. PUTNAM: Well, you know, in terms of
10 scrams, you know, that's the one thing -- that's the
11 main reason we added that.

12 MEMBER STETKAR: Your recent performance
13 really --

14 MR. PUTNAM: We had a bad year in 2003.

15 MEMBER STETKAR: Yes, I see a bad year in
16 2003. But, you know, on kind of a straight-line
17 averaging here, your recent performance is not
18 tremendously better.

19 MR. PUTNAM: Well, you know --

20 MEMBER STETKAR: In terms of accumulated
21 numbers.

22 MR. PUTNAM: -- I think you probably had
23 twice as many in the first -- or we had 47 in the
24 first 10 years and you have had roughly 60 since -- in
25 the preceding 25 years. So I think there is --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: There is improvement. I
2 mean, it's --

3 MR. PUTNAM: -- clearly improvement. And
4 I'll tell you, I think was it '84 to '88, some time in
5 there we had a string of 40 months without a scam.
6 Which at those days was --

7 MEMBER STETKAR: That's unusual.

8 MR. PUTNAM: -- pretty remarkable.

9 MEMBER STETKAR: That's unusual.

10 MEMBER SIEBER: That's remarkable.

11 MR. PUTNAM: That's freakishly low. We
12 had people coming up saying what are you doing out
13 there?

14 MEMBER STETKAR: I was mostly --

15 MR. PUTNAM: Then we immediately in '88
16 had a spike again of scrams and that's where I learned
17 the lesson that scrams aren't actually that
18 predictable. You need to leave some cushion in there
19 for the scam rates.

20 MEMBER STETKAR: Yes. And that's exactly
21 why I asked the question to see whether there was a
22 dramatic change in the operating history and this says
23 not as dramatic as some plants have recognized. And
24 to see the year-to-year variability in that transient
25 experience. And there is some, but not a huge amount.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 You said you used 1998 through 2005.

2 MR. PUTNAM: 2005, yes.

3 MEMBER STETKAR: So you saw a couple of
4 spikes in there. Okay.

5 MR. PUTNAM: Yes.

6 MEMBER STETKAR: The other question I had
7 in terms of projecting events, and this is in the
8 experience-base there were a couple of events in, I
9 think, 2006 where -- and I don't know the dynamics of
10 the process. I'm only reading from the experience
11 that apparently events occurred where you had an
12 unusual cool-down in the bottom head and experienced
13 an unusual cooling of the reactor coolant water, you
14 know, bottom head draining line. I'm assuming that is
15 what it was.

16 It is kind of interesting that you
17 experienced two of those kind of events in six years,
18 given your operating experience. You then go on to
19 say that that particular piping, although it is, you
20 know, an external piping from the vessel, has been
21 qualified for more severe transients and many more
22 cycles.

23 When you went back and reconstituted the
24 operating experience from day one up through 1998, did
25 you make any attempt at all to capture those types of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 events that might have caused similar types of over-
2 cooling down in the bottom head area?

3 MR. PUTNAM: Well, we definitely were
4 looking for that sort of thing. We didn't find a
5 whole lot of information there. And I guess, you
6 know, I think we put in the application as we came
7 across.

8 MEMBER ARMIJO: In your application you do
9 point out that the vessel shell and lower head will
10 have a cumulative usage factor, including
11 environmental effects, of .996 at the end of year,
12 which one comment is that's remarkably precise, .996.

13 MR. PUTNAM: Yes.

14 MEMBER ARMIJO: Which it's slightly lower
15 than one. But so I'm not sure you believe that number
16 to that --

17 MR. PUTNAM: Accuracy?

18 MEMBER ARMIJO: -- accuracy. But the
19 question is were those unusual cooling events the main
20 reason for that usage factor being so high? It's
21 surprisingly high.

22 MR. PUTNAM: They have a big environmental
23 penalty there. Those were actually ones with
24 relatively low cumulative usage factors before you
25 applied the environmental penalty, you know, so those,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 I think, are unrefined calculations, because they had
2 such a low number initially and then they had a high
3 environmental penalty you put on there and that's how
4 we got up there as high as we were.

5 MEMBER ARMIJO: Aren't these clad,
6 stainless steel-clad on the vessel at the bottom head?
7 And that's part of --

8 MR. PUTNAM: Clara is bending her head
9 there. I don't think that will make it into the
10 transcript, Clara.

11 MS. RUSHWORTH: Yes.

12 MEMBER ARMIJO: You have seen unusually
13 high, because there were a couple of other locations,
14 outlet nozzles and safe-ends for the same period of
15 time, including environmental effects, the usage
16 factors are like .19 or .2, but just the lower head
17 seems like unusually high. I still don't understand
18 what is going on there.

19 MR. PUTNAM: Well, Clara?

20 MS. RUSHWORTH: This is Clara Rushworth
21 for Duane Arnold again. As Ken said, the lower head,
22 those calculations were not refined. And the
23 calculations you are looking at, I believe, are for
24 the recirc outlet nozzle, feedwater nozzle and the
25 coarse spray nozzle. We had those calculations

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 refined ASME Code, the six stressors calculations
2 redone, finite element analysis by structural
3 integrity and environmental factors applied and with
4 those refinements, it shows much lower numbers.

5 MEMBER ARMIJO: So are you telling me that
6 the .996 is just very, very conservative?

7 MS. RUSHWORTH: That's correct.

8 MEMBER ARMIJO: And if you had applied
9 similar refinements, it would be less? You don't know
10 how much, but it should be less.

11 MR. PUTNAM: Correct.

12 MS. RUSHWORTH: That would be correct.
13 And we have not done, so, of course, we can't say for
14 sure, but that's based on the 40 year usage factor,
15 which was based on a lot of conservatisms and then
16 that adjusted for the cycles for 60 years and then the
17 environmental factors placed on.

18 So that was not using a finite element
19 analysis.

20 MEMBER ARMIJO: Okay. Thank you.

21 MR. PUTNAM: Mike, can you get us back to
22 the presentations here?

23 CHAIR BLEY: I'm going to interrupt you
24 for just a minute. We are running a bit behind. You
25 have a lot of slides left and we want to make sure we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 get to your open item discussion at the end, so I'm
2 going to ask you to go ahead. Staff doesn't need
3 quite as much time as they have budgeted, so you can
4 go over, but let's aim for a quarter after or 20
5 after, something like that. See if we can get there.

6 MR. PUTNAM: Okay. We have already talked
7 about environmental fatigue adjustments. We made
8 those adjustments and we were asked by the staff about
9 new data on Alloy 600. We didn't reperform the
10 calculations using that new rate for new plants, but
11 we did check to see if the data in there, if we just
12 plugged that in in a conservative way, would it move
13 us above CUF < 1.0. And the conclusion was no, it
14 wouldn't alter the conclusions if we used that.

15 Environmental qualification calculations
16 are all updated to 60 year life without any real
17 problems here.

18 Next slide, Mike. Ultimately, our whole
19 point here, of course, is to get aging management
20 programs that make sure we manage aging in the plant
21 in the renewed term.

22 We tried to stay as close to the goal as
23 practical. We ended up with 43 aging management
24 programs. 19 of those are existing ones that just
25 will keep doing. They don't need enhancements.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 10 of the programs are existing, but they
2 do need enhancements. Typically, those are places
3 where we had to add more restrictive acceptance
4 criteria or we need to apply the program to more
5 pieces of equipment than we currently are.

6 And then we had 14 new programs, some of
7 which aren't entire new. We may be doing individual
8 maintenance tasks out in the field that are remarkably
9 similar, but they weren't organized in a programmatic
10 way, so we called those out as new programs.

11 In terms of GALL consistency, we ended up
12 with 28 programs consistent. 11 that were consistent
13 with exceptions and four that were plant-specific. A
14 couple of those are ones that could become issues with
15 ISGs that were consistent with and a couple are unique
16 to us.

17 Next slide. We did a number of industry
18 issues during our project. Station blackout boundary,
19 for some plants that's kind of a hard one if their
20 switchyards are a long way away from the plant. For
21 us, it's easy. During that flood part of the show
22 there, the switchyard is right next to our power
23 plant, so that wasn't a problem for us to go out to
24 the breakers in the switchyard.

25 Clara mentioned that we did any

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 refinements to calculations. We didn't use
2 simplifying assumptions. We did full bore ASME
3 calculations for those.

4 Generic Letter 2007-01 came along during
5 our project where we were a lot more focused on the
6 status of power cables underground. We thought we
7 were in pretty good shape there, but we did find we
8 needed to do some improvements to our sump pumps to
9 make sure those were as reliable as we thought they
10 should be and we also had to add some inspections for
11 manholes without sump pumps to make sure even though
12 they are at higher elevations and shouldn't be as
13 likely to get water in them, we do need to inspect to
14 make sure we keep those in good shape.

15 CONSULTANT BARTON: Do you have any
16 experience of any cables that have failed as a result
17 of being submerged or wetted?

18 MR. PUTNAM: No power cables. Mike, do
19 you want to?

20 MR. FAIRCHILD: No, we have had some
21 inaccessible cables, 125-volt dc control cables.

22 CONSULTANT BARTON: Okay.

23 MR. FAIRCHILD: That have failed, but we
24 haven't pulled any of them out to do any recross
25 testing on them other than one that we could see and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that was an installation error.

2 CONSULTANT BARTON: Okay.

3 MR. FAIRCHILD: The bend radius was too
4 tight.

5 CONSULTANT BARTON: Okay.

6 MR. FAIRCHILD: But none of them have
7 failed coincident with water.

8 CONSULTANT BARTON: Okay. Thank you.

9 MR. PUTNAM: Then Information Notice 2009-
10 26 on degradation of neutron absorbers came out during
11 our review and we had to adjust our program there to
12 add a Boral Surveillance Program. We ended up with 50
13 commitments for license renewal, even though we are
14 numbered up to 51, I notice you counted our number
15 there. We have one of the commitments we ended up not
16 using as it changed during the course of the review.

17 The commitments are entered into our site
18 commitment tracking system, just like any other
19 commitment. We are relatively close to the end of our
20 period of extended -- or to our period of our license,
21 so we are moving straight into implementation
22 activities. We are not waiting on any of those. So
23 our goal is to be ready well in advance of the period
24 of extended operation.

25 We will retain a portion of our project

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 core team to support the implementation activities
2 with the program owners on the site. And for some of
3 the bigger commitments, we have set up specific
4 projects for running those and making that step change
5 for us to make sure those get the right oversight and
6 management attention for those hard ones to get
7 accomplished.

8 Any questions on that?

9 MEMBER STETKAR: Just one, sorry. Your
10 operating experience says you have had a leak in your
11 spent fuel pool since 1994. And you are confident
12 that you are currently collecting all of that leakage.

13 What are you doing to stop the leak? Do you know
14 where it is coming from?

15 MR. PUTNAM: No.

16 MEMBER STETKAR: And what's the leakage
17 rate?

18 MR. PUTNAM: The leakage rate is about 280
19 milliliters a day. And so about a little over a cup.

20 We have looked for it. We have not found a source
21 for that very, very small leakage.

22 CONSULTANT BARTON: Is it affecting any
23 equipment in the sortability?

24 MR. PUTNAM: No, no. It goes into a case
25 and then it goes to a series of drains that our

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 operators check every day. I think it's every day or
2 is it every week? Frequently.

3 CONSULTANT BARTON: Are you trending it?

4 MEMBER STETKAR: Is there any indication
5 that it is increasing?

6 MR. PUTNAM: No. It has been pretty
7 stable for years and years.

8 CONSULTANT BARTON: Okay.

9 MR. PUTNAM: Unchanged.

10 MEMBER STETKAR: Okay. Thank you.

11 MR. PUTNAM: There are two open items.
12 Buried piping and small bore piping. We will talk
13 about those later. And there were no confirmatory
14 items in the safety evaluation. Okay.

15 The first item here and it's not an open
16 item, but it is an item that has been of some interest
17 I know and a lot of interest to us, our torus
18 coatings. Our IWE Program has identified numerous
19 areas of zinc depletion on our torus coatings and
20 minor pitting.

21 I think the staff's main concern with it
22 is there is not really anything defined in the ASME
23 Code for when do you got to go replace those coatings
24 or restore those coatings. And so they were
25 interested in how we were going to manage that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Our torus was last coated in 1985. It is
2 a zinc oxide coating with a belly band of phenolic at
3 the water line. We do perform routine inspections,
4 obviously, under the IWE Program and we touch up any
5 areas of problems during the outage.

6 CONSULTANT BARTON: The original coating
7 only lasts about 10 years?

8 MR. PUTNAM: Correct.

9 CONSULTANT BARTON: Wow.

10 MEMBER ARMIJO: And it was replaced with
11 the same coating?

12 MR. PUTNAM: Yes.

13 MEMBER ARMIJO: Now, in the previous
14 review, somebody stated this was a zinc metal coating
15 in the phenolic. Is it zinc oxide or is it zinc
16 metal?

17 MR. PUTNAM: Eric, do you want to answer?

18 MR. SORENSON: The actual coating is a --
19 this is Eric Sorenson for Duane Arnold. The actual
20 coating is a carbo-zinc 11. It's a zinc oxide
21 coating.

22 MEMBER ARMIJO: Zinc oxide. In a
23 phenolic --

24 MR. PUTNAM: The phenolic is only at the
25 belly band, right?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. SORENSON: Yes, but there is a 2 foot
2 belly band that has a phenole-lined 386 WG. It's a
3 phenolic coating.

4 MEMBER ARMIJO: So that's plus or minus a
5 couple of feet?

6 MR. SORENSON: Right. That's plus or
7 minus a foot.

8 MEMBER ARMIJO: Okay.

9 MEMBER SIEBER: And you have only found
10 one pitting defect below mid-wall?

11 MR. PUTNAM: It was beyond 10 percent. It
12 wasn't below mid-wall.

13 MEMBER SIEBER: Okay.

14 MEMBER SHACK: The SER --

15 MEMBER SIEBER: Just one out of a
16 potential of thousands, right?

17 MR. PUTNAM: Yes, yes.

18 MEMBER SIEBER: Okay.

19 MEMBER SHACK: The SER says you are going
20 to replace the coating according to ANSI N101.2, which
21 is a 1972 standard that has been withdrawn so long ago
22 I can't find a copy of it in any of the databases.
23 I'm just wondering, I mean, I can understand why you
24 don't want to redesign your piping, but, you know, why
25 wouldn't you use a more modern standard for your

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 coating?

2 MEMBER SIEBER: You might have trouble
3 finding the coating.

4 MR. PUTNAM: Eric?

5 MEMBER SHACK: Is that the staff putting
6 words in your mouth here?

7 MR. SORENSON: This is Eric Sorenson
8 again. No. We are not committed to Reg Guide 1.154
9 Rev 0. And when we responded to Generic Letter 98.04
10 regarding our debris accumulation and how we were
11 treating our coatings, that was the standard that we
12 were using at the time and we still use. That's what
13 we were originally committed to.

14 MEMBER SHACK: Yes, I realize that it's
15 your original commitment.

16 MR. SORENSON: However, I will acknowledge
17 that we have -- our program does recognize the more
18 current standards for the ASTM, so our program is
19 built around more current ASTM Standards as sub-
20 documents to 101.4.

21 MEMBER SHACK: Okay.

22 CONSULTANT BARTON: Do you do outage
23 sludge removal every outage? Get much man-rem out of
24 that?

25 MR. PUTNAM: Man-rem?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CONSULTANT BARTON: Yes. If you are
2 pumping your EMRVs in there occasionally and going and
3 cooling down those engine causants, you know.

4 MR. PUTNAM: Is this radioactive? I don't
5 recall that being a real --

6 CONSULTANT BARTON: Okay.

7 MR. PUTNAM: -- big dose.

8 MR. SORENSON: I don't believe. We don't
9 desludge necessarily for the man-, this is Eric
10 Sorenson again, rem exposure. We desludge to remove
11 the potential for the pit growth underneath the
12 sludge. We do the sludge removal every other outage
13 with divers with mechanical pumps underneath and with
14 brushes that they can remove it with. Otherwise the
15 other outage we use people from the catwalk with
16 extended vacuums doing it. So it's a much less
17 efficient desludge, but we do do a full desludge and
18 wall scrub basically every other outage.

19 And since we have this past outage when we
20 went in and we observed a significant change in the
21 amount of degradation we have seen in the torus due to
22 zinc, pure zinc depletion. So we have now changed our
23 program to an every other outage with divers going
24 into our torus, during every outage with divers, and
25 doing repairs to the torus that we find until we get

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 to a point where we do the full recoat.

2 CONSULTANT BARTON: So this is --

3 MEMBER ARMIJO: It seems to me for all the
4 money that is spent on divers, you could recoat the
5 torus.

6 MR. PUTNAM: I don't believe that math
7 works. I'm sure it's an extraordinarily large project
8 to recoat the torus. That is a major, major
9 commitment.

10 CONSULTANT BARTON: There was a plant that
11 did it.

12 MR. SORENSON: I would say we did. At
13 Duane Arnold we did recoat the torus in 1985 and our
14 cost back then was, approximately, \$6 million. And we
15 expect that it is significantly, at least twice that
16 much --

17 MR. PUTNAM: Yes, double.

18 MR. SORENSON: -- or more to do it at this
19 point.

20 CONSULTANT BARTON: Okay.

21 MR. PUTNAM: And we are scheduling to do
22 that in the 2012 outage currently.

23 Recent industry events on buried piping,
24 unless there were other questions on torus?

25 Buried piping, the issue is that recent

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 industry events involving leakage from buried and
2 underground piping may warrant changes to the buried
3 piping tanks inspection program.

4 CONSULTANT BARTON: Do you have any
5 tritium issues at the site?

6 MEMBER SIEBER: If you're doing that kind
7 of work.

8 MR. PUTNAM: Certainly we produce tritium.

9 CONSULTANT BARTON: Do yo have any --

10 MR. PUTNAM: We have a tad tritium --

11 CONSULTANT BARTON: Have you found any?

12 MR. PUTNAM: We haven't had tritium above
13 the threshold reporting. We haven't had any
14 indication of tritium for pipe leaks at this point.

15 CONSULTANT BARTON: Okay.

16 CHAIR BLEY: How much buried pipe do you
17 have?

18 MR. PUTNAM: Oh, a lot. Al?

19 MR. THOMAS: How much buried pipe do we
20 have? This is Al Thomas for Duane Arnold. I don't
21 know the exact number off the top of my head. The
22 vast -- a good piece of it is from the intake
23 structure to the pumphouse.

24 CONSULTANT BARTON: Sure.

25 MR. THOMAS: Which there is three 24 inch

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 diameter line and they are about 1,800 feet long.

2 MEMBER STETKAR: What kind of pipe is
3 that? Is it carbon steel? Normal steel, normal
4 carbon steel?

5 MR. THOMAS: It's A16, Grade B, 24 inch
6 diameter stain or scheduled 312.

7 MEMBER STETKAR: Coated and lined?

8 MR. THOMAS: It's externally coated. It's
9 not lined on the inside.

10 CHAIR BLEY: Go ahead.

11 MR. PUTNAM: All right. I guess before I
12 move on too far here, we talked about underground
13 piping and buried piping and I want to make sure there
14 is no miscommunication on that.

15 Underground piping is piping that is
16 exposed to air that happens to be below-grade
17 typically involves chases of some sort.

18 Buried piping is in contact with soil. We
19 do have a limited amount of underground piping at
20 Duane Arnold. Not very much. And all of that is
21 accessible. There is not stuff that is difficult to
22 get at and look at, so where appropriate in license
23 renewal process, that that piping would be typically
24 managed by external surface monitoring, not the buried
25 piping program.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 But I'll focus most of my discussion here
2 on the buried piping program. The industry certainly
3 recognizes that this is an important issue. So far, I
4 don't think there has really been so much safety
5 significance to the events, but certainly things that
6 matter to our stakeholders.

7 In response to that, there is an NEI
8 Initiative where they issued guidelines in January of
9 this year and we do support that and have actively
10 participated with them.

11 In addition, EPRI has issued out
12 guidelines, kind of more technical guidelines on how
13 to control degradation of buried piping in the yard
14 following that.

15 CONSULTANT BARTON: So it is direct
16 buried, it's not in vaults, right?

17 MR. PUTNAM: That's correct.

18 CONSULTANT BARTON: Okay.

19 MR. PUTNAM: Yes, anything that is
20 underground for us, not in contact with soil is a
21 couple of vaults for cross-connecting pipes and some
22 manholes for the sump pump discharge piping and some
23 diesel fuel oil lines happen to run through an access
24 manway, where you can climb down to the top of the
25 tank. So it's very limited underground. Most of it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 is buried.

2 Our fleet-issued guidance is -- our fleet
3 is participating actively with the industry in this.
4 And mid-course, our fleet elected to issue guidance
5 documents, upgrade our program with respect to buried
6 piping and then DAEC, out of that fleet guideline,
7 developed implementing procedures on-site where we are
8 really going above and beyond the minimum requirements
9 that are in the GALL or that had historically been out
10 there for how you manage buried piping. It mentions
11 underground is accessible.

12 Next slide.

13 CHAIR BLEY: Before you leave that one,
14 oh, no, you still have more buried pipe. Go ahead.

15 MR. PUTNAM: Got more buried piping, yes.

16 CHAIR BLEY: Okay.

17 MR. PUTNAM: We haven't had a history of
18 any leaks on our in-scope buried piping. We have had
19 leaks on our well water piping that is not in scope.
20 Those seem to be kind of unique to their material and
21 the physical location of those well water pipes, but,
22 you know, definitely one lesson that we can take from
23 that well water piping issue is that we are not immune
24 to problems on buried piping. It can happen to us and
25 it's something we do need to manage.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 We have had a fair bit of maintenance work
2 on fire protection piping in the last couple of years.

3 We took the opportunity to examine that piping when
4 it was excavated. We are happy to have found that
5 piping in very good condition, so that was a good
6 indicator.

7 We performed torsional guided wave exams
8 on our HR service water piping, emergency service
9 water piping and river water supply piping. Last year
10 on roughly 20 locations that identified -- and by the
11 way, I might comment here, that's really a screening
12 tool. It's not an absolute answer, but it gives you--
13 helps you pick what place do you want to go look
14 harder at.

15 And so out of that, we identified four
16 areas we wanted to go look at harder. We will be
17 excavating those this year or doing some sort of
18 examination, detailed examination of that piping this
19 year.

20 MR. COSTANZO: Yes, we have considerable
21 understanding of what this issue is, both at the fleet
22 level and at the site level. And actually, you know,
23 both the detection, the mitigation and the long-term
24 strategy has been budgeted, you know, at least through
25 2015, which we have just approved just recently. We

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 will commit those resources. We will commit the time
2 and effort to make sure that we stay ahead of this one
3 in prevention.

4 MEMBER SHACK: How long a run can you do
5 with the torsional guided wave?

6 MR. PUTNAM: It depends, I think. Al,
7 maybe you want to answer that?

8 MR. THOMAS: This is Al Thomas. Would you
9 repeat the question again, please?

10 MEMBER SHACK: How long a run can you do
11 with the guided wave? How far will it penetrate?

12 MR. THOMAS: Basically, with the guided
13 wave, it will basically go through two elbows. Okay.
14 It will go a long ways in straight pipe.

15 MEMBER SHACK: Pipe.

16 MR. THOMAS: But basically the second
17 elbow is about the end of your exam.

18 MEMBER SHACK: Okay.

19 MEMBER SIEBER: If you have a leak, a
20 small leak, in your buried piping, would you really
21 know it?

22 MR. PUTNAM: I don't know. It depends, I
23 think, is the answer. I think if you had a few drops
24 a minute coming out of an ESW pipe, you would never
25 know.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER SIEBER: Would never know.

2 MR. PUTNAM: You would never know.

3 CHAIR BLEY: Use the mike.

4 MR. PUTNAM: Whoops, I'm sorry. Yes, I
5 don't think you would see a tiny leak like a few drops
6 a minute. I'm sure you would see a few gallons a
7 minute, because you would be coming up to the surface
8 floor area.

9 MEMBER SIEBER: Yes. On the other hand,
10 you really can't say for sure you have no leakage,
11 right?

12 MR. PUTNAM: That's correct.

13 MEMBER SIEBER: You really can't tell.

14 MR. PUTNAM: Yes. Well, what we have done
15 with the operating experience is looked back in time
16 of anything that we have seen in our Corrective Action
17 Program.

18 MEMBER SIEBER: Okay. Have you seen any
19 buildup of material inside of, for example, cooling
20 water piping? That refers to a lot of plants where
21 organisms from the river or where they are getting it
22 from gets inside lines that are ordinarily very low
23 flow, which during emergency testing provide much more
24 flow and tend to clog those lines? Have you seen any
25 evidence of that? That you know of.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. PUTNAM: In these buried pipes? You
2 know, those pipes -- now, the river water supply,
3 those are normally operating. They are running at a
4 flow rate comparable to emergency conditions normally.

5 ESW and HR service water, those we do full flow tests
6 on routinely on a quarterly basis, so we would, you
7 know, see it. If there was a flow blockage, we would
8 definitely see that.

9 MEMBER SIEBER: But your detection of
10 blockage is by periodically measuring flow and the
11 flow is at full force as opposed to any kind of
12 inspection or other means to decide what is actually
13 inside the piping? Is that correct?

14 MR. PUTNAM: I believe that is correct,
15 unless somebody -- you know, there is a lot of
16 preventive maintenance out there on some of those
17 downstream components. But I think in terms of those
18 buried pipes we're talking about, definitely I would
19 say it's by flow.

20 MEMBER SIEBER: Some plants have found
21 that to be a problem. Some plants that I have worked
22 at have found it to be a problem. Thank you.

23 MR. PUTNAM: Okay.

24 MEMBER STETKAR: Ken, you mentioned
25 earlier we discussed the instrument or the compressed

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 air systems. You replaced the piping from the air
2 compressor building wherever the air receivers are.
3 Was there evidence of corrosion in that piping?

4 MR. PUTNAM: No, not really. I would say
5 that piping was in pretty good condition.

6 MEMBER STETKAR: Okay.

7 MR. PUTNAM: It was a little different.
8 You know, it wasn't in-scope piping.

9 MEMBER STETKAR: No, that's --

10 MR. PUTNAM: It's a little different
11 coating, so I didn't include it on this slide.

12 MEMBER STETKAR: Yes, yes.

13 MR. PUTNAM: So it's --

14 MEMBER STETKAR: That's why I asked you
15 about it.

16 MR. PUTNAM: But it was in good condition.

17 MEMBER STETKAR: Okay. Thanks.

18 MR. PUTNAM: All right. And we have
19 checked the diesel fuel oil tank using UT and found
20 that in good condition, so that's another positive
21 indicator for us. And we will do another check of
22 that, I think, in 2012 as scheduled.

23 MEMBER SIEBER: Did you find a lot of
24 water or sludge in the bottom of the tank?

25 MR. PUTNAM: No. No, we check for water,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 you know, routinely under that fuel oil. The program,
2 the whole objective is to keep that out of there. You
3 know, the withdraws they are a little bit above the
4 bottom. It's the only place you would be really very
5 worried about.

6 MEMBER SIEBER: Yes.

7 MR. PUTNAM: We are doing additional
8 torsional guided wave exams and we started those, I
9 guess, at the end of May there. We started doing some
10 additional pipes there next to the condensate storage
11 tank. And as I said, the ones we identified in 2009
12 for follow-up will be inspected yet this year.

13 You know, in terms of resolving the open
14 item, we did submit a response to the NRC's questions
15 on May 28th and we will work with the staff on
16 anything more that needs to be done there.

17 But fundamentally, you know, re recognize
18 that buried piping is something we need to continue to
19 move forward with the industry in doing the best job
20 we can with that component.

21 Next topic. Socket welds. The issue
22 really is --

23 CHAIR BLEY: Oh, on the buried pipe --

24 MR. PUTNAM: Yes.

25 CHAIR BLEY: -- have you now responded to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the RFI on that?

2 MR. PUTNAM: We did.

3 CHAIR BLEY: You think it should close?
4 You don't know, but you have submitted?

5 MR. PUTNAM: We have submitted it. You
6 know, clearly, it's our objective to do that. I don't
7 know whether some of the details will mean more. The
8 staff hasn't finished their review on it.

9 CHAIR BLEY: Okay. So we will hear from
10 them in a minute. But on your part, you have done
11 what you think you need to do?

12 MR. PUTNAM: We answered their question.

13 CHAIR BLEY: Okay. Go ahead.

14 MR. PUTNAM: Yes, socket welds. This is a
15 little more straightforward topic. NUREG-1801
16 recommends a volumetric exam of small bore Class 1
17 piping using qualified techniques. And right now,
18 there is no qualified volumetric exam to technique for
19 socket welds.

20 Surface exams, obviously, don't detect
21 flaws coming from the inside out. And the staff is
22 interested in -- regardless of the qualification of
23 the examination, they feel that there are exams that
24 can be done that would provide meaningful information,
25 even if those socket weld configurations preclude a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 perfectly qualified exam.

2 Since we have submitted our application,
3 there have been ongoing industry efforts to improve
4 those examination technologies and those seem to be
5 actually making a fair bit of progress there.

6 CHAIR BLEY: Let me ask you a question.
7 As I read the things going back and forth on this, it
8 wasn't completely clear to me. Is your position on
9 this one about the no industry-accepted qualified exam
10 a, it's the wrong word, but, legal objection or is it
11 a technical one? Do you think there is no good
12 volumetric exam you can use that will give you good
13 information?

14 MR. PUTNAM: I think when we submitted, I
15 would say I would have been biased towards -- I don't
16 think there are good exams. If you looked at the
17 published data back in that time frame --

18 CHAIR BLEY: Yes.

19 MR. PUTNAM: -- they were very
20 questionable, in my opinion. As a matter of fact in
21 one study, I saw they had about -- and I'll mess up
22 the numbers here, but, when they looked at socket
23 welds with known flaws, they had about a third of the
24 flaws they found correctly.

25 CHAIR BLEY: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. PUTNAM: About a third of the flaws
2 they didn't find. And a third of the flaws that they
3 couldn't distinguish them from other things going on
4 there, which for me I was kind of worried that might
5 be -- you might get false positives out of that.

6 CHAIR BLEY: Sure.

7 MR. PUTNAM: So I would say in 2008, I
8 wouldn't have been -- I would have been uncomfortable
9 sending people into the field to perform it or we
10 would have had to restrict what they looked at very
11 harshly.

12 CHAIR BLEY: Okay.

13 MR. PUTNAM: I think since then, and I'm
14 not a UT guy at all, but our NDE Level 3 tells me he
15 is pretty optimistic about some of the things that
16 they are doing lately and so he is real interested in
17 it and he thinks he can do good exams at some point
18 here in the future with the right planning and the
19 right equipment for it. So that's kind of where he is
20 at. You know, he hasn't done it yet.

21 CHAIR BLEY: Yes.

22 MR. PUTNAM: So --

23 CHAIR BLEY: I understand. Okay. Thanks.
24 Go ahead.

25 MR. PUTNAM: All right. Next slide, Mike.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 In terms of operating experience, we did have one pin
2 hole leak in 1989 on a Class 1 pipe. The apparent
3 cause for that was fatigue cracking due to vibration
4 and some apparent problems with initial fit-up. That
5 pipe was, of course, replaced, refabricated and
6 replaced slightly differently and we verified that the
7 vibration problems weren't present after that and we
8 haven't experienced any further problems in Class 1
9 small bore piping since, in terms of socket welds,
10 then.

11 So at any rate, with the operating
12 experience, I'm directing we have to have a plant-
13 specific program. We do have that.

14 Next slide, Mike. We did submit a
15 response to the NRC's open item. We are proposing
16 that we will do a volumetric exam of 10 percent of the
17 Class 1 socket welds. If a qualified technique is
18 available, we will use that, of course.

19 If one is not available, we will develop a
20 plant-specific procedure for performing it and we
21 will, you know, restrict the procedure to match the
22 technology that is available to us under that. So
23 that's socket welds. Unless there is more questions
24 on that?

25 Okay. Are there any questions?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CONSULTANT BARTON: I got a question. You
2 could tailor that, the story of years ago. And I know
3 it's for -- beyond design basis accidents. So it's
4 not included in your Aging Management Program.

5 The question I have is do you at least
6 have a preventive maintenance procedure? Can you at
7 least do something with that system on some periodic
8 basis?

9 MR. PUTNAM: Yes, some of the components
10 are actually in-scope. They happen to fall into, you
11 know, some of the other containment systems and so
12 those components out to the ruptured disk are in-
13 scope. You know, how that sits once you have the
14 isolation valve and a ruptured disk that go at a
15 certain -- at a pressure above P_a but below the dent
16 you are intending to mitigate, below the design
17 pressure of the containment.

18 And there are PMs on those ruptured disks.

19 CONSULTANT BARTON: Okay.

20 MEMBER RAY: You have a turbine-driven
21 RCIC pump?

22 MR. PUTNAM: Yes.

23 MEMBER RAY: Does anybody know how often
24 it is surveilled?

25 MR. PUTNAM: Quarterly full blown test.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER RAY: What's your experience with
2 that?

3 MR. PUTNAM: Recent experience has been
4 very good. You know, if you went back to the '80s not
5 so good.

6 MEMBER RAY: That's all I have.

7 MR. PUTNAM: No, I think recently it has
8 been very reliable. I think that system is agreeing.

9 CHAIR BLEY: Anything more from the
10 Committee? John, do you want to follow-up with
11 something?

12 CONSULTANT BARTON: You had this dollar
13 weld indication. I think it's on your vessel head
14 failed ASME acceptance standard, but you think it's
15 okay? What do you know about that? What can you tell
16 me about that?

17 MR. PUTNAM: Well, I'm going to pull up
18 another person from the background here.

19 MS. RUSHWORTH: This is Clara Rushworth
20 for Duane Arnold again. And we had identified on
21 indication in the dollar weld some years ago. We did
22 a flaw evaluation on it, submitted it to the staff for
23 approval and I believe we have an SE for that. And I
24 could look that information up if you would like.

25 CONSULTANT BARTON: Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR BLEY: Anything more? I think, at
2 this time, we will recess for 15 minutes until 10:30
3 and come back and then we will hear from the staff.
4 Thank you.

5 (Whereupon, at 10:12 a.m. a recess until
6 10:29 a.m.)

7 CHAIR BLEY: Okay. The meeting will come
8 back in session, please. And we will proceed with the
9 staff. I don't know who is starting this. Brian?

10 MR. HOLIAN: This is Brian Holian.
11 Introductions again, we have besides Benny Jose from
12 Region III, I just wanted to highlight he has had
13 seven years as an inspector in Region III, has
14 industry time at a couple of plants in Region III and
15 also some time in Sargent 1 before coming to the NRC.

16 Brian Harris has been the lead Project
17 Manager. His first project coming through license
18 renewal, so we're glad to have him present.

19 And also up there helping him just mainly
20 with the slides is John Daly. John has been with the
21 Kewanee Plant, which will come next month to ACRS.
22 And with that, Brian Harris.

23 MR. HARRIS: Okay. Good morning. Go
24 ahead, John.

25 CHAIR BLEY: Morning.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. HARRIS: My name is Brian Harris. I'm
2 the Senior Project Manager for the Duane Arnold Energy
3 Center License Renewal Application.

4 So you have heard from Brian Holian, our
5 Director of the Division of License Renewal. Also we
6 have joining me today Bo Pham, Branch Chief of the
7 Reactor Project Branch 1, and Benny Jose, Region III
8 Inspection Team Leader.

9 Also seated in the audience are members of
10 the Technical Staff who participated in the review of
11 the license renewal application or in audits that were
12 conducted at the applicant's facility.

13 So I'll begin by providing an overview of
14 the LRA and the staff's review. Then we will discuss
15 Section 2 of the SER. And Mr. Benny Jose will discuss
16 the license renewal inspections and findings. And
17 then I'll discuss the staff's review of the Section 3
18 and 4 of the safety evaluation report.

19 CHAIR BLEY: Okay.

20 MR. HARRIS: The LRA was submitted by
21 letter dated September 30, 2008 and supplemented by
22 letter dated January 23, 2009. The unit is a GE
23 Boiling Water Reactor with a Mark 1 containment.

24 An extended power uprate was granted in
25 November of 2001. And the operating license

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 expiration is in year 2014.

2 The plant is located near Cedar Rapids,
3 Iowa.

4 For the staff issues, the SER open items,
5 on May 7, 2010, there are two open items: The first
6 is Open Item 3.0.3.3.3 that's related to socket welds
7 in the small bore piping program and Open Item
8 3.0.3.1.7 is related to buried piping and Tanks
9 Inspection Program, which we will discuss later in
10 this presentation.

11 There are no confirmatory items.

12 So the NRC Review Team has conducted two
13 audits and one inspection at the Duane Arnold Energy
14 Center cited during the periods listed on the slide.
15 The staff started the on-site review with the aging
16 management audit in mid-August followed by a scoping
17 and screening methodology towards the end of August.

18 The Region III conducted its inspections
19 in November to review the applicant's scoping and
20 screening and aging management programs.

21 I'll now move on to Section 2 of the SER.

22 Section 2 discusses structures and components subject
23 to aging management review.

24 Within Section 2 we have scoping and
25 screening methodology; plant-level scoping results;

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 scoping and screening, excuse me, mechanical system;
2 structures; and electrical and instrumentation and
3 controls.

4 Based on review of the LRA and additional
5 information submitted as a result of requests for
6 additional information, the staff concluded that the
7 applicant's methodology is consistent with the
8 requirements of 10 CFR.54.4(a) and 54.21(a)(1).

9 Benny Jose, the Region III Inspection Team
10 leader will now discuss the results of his inspection.

11 MR. JOSE: Good morning again. I'm Benny
12 Jose. I'm the team lead for the regional inspection
13 of the 71002 inspection.

14 As Brian mentioned in the previous couple
15 of slides that we completed our inspection during
16 November of 2009 and the first part of the inspection
17 we concentrated on scoping and screening.

18 And we focused on the systems that -- non-
19 safety-related systems that affected the safety
20 systems and also the four regulated events which are
21 fire protection, station blackout, ATWS and SBO.

22 During our review, we focused on, you
23 know, the system or the scoping boundary line, scoping
24 and screening reports. We did walk-downs of the
25 systems. And just to observe the general condition

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 for us to verify the scoping of all the components.

2 And during our review, we did identify a
3 few items that were not actually scoped in. Some of
4 it due to drying errors and some of it due to simple
5 mistakes by omitting.

6 One of the examples were the river screen
7 house, we did find two of the recent dampers which
8 were not scoped-in and due to our questioning, they
9 were scoped-in.

10 And as part of our inspection, the
11 licensee did send a letter subsequent to our
12 inspection, which is NG-09-0823 and Enclosure 2 to
13 that letter actually lists all our findings in that.
14 And in general scoping and screening was found to be
15 acceptable.

16 And after the scoping and screening we
17 moved down to the Aging Management Program. They had
18 about a total of 43 Aging Management Programs and we
19 reviewed about 30 of them, which is roughly 70
20 percent, which is normally our norm. We couldn't
21 possibly look at all of them.

22 We chose those 30 Aging Management
23 Programs based on their safety significance. They
24 also had a 70/30 percent difference in new programs
25 versus existing programs. About 70 percent of them

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 were existing programs. And we chose the majority of
2 our 30 systems did include a good percentage of
3 existing systems and a small representation of the new
4 programs, because we found that looking at new
5 programs, we can't really add much value, because they
6 are all promises to be in accordance with GALL just
7 before the end of the -- just before the period of
8 operation.

9 CONSULTANT BARTON: Well, on the Aging
10 Management Program inspection, the Inaccessible Medium
11 Voltage Cable Program --

12 MR. JOSE: Yes, sir?

13 CONSULTANT BARTON: -- the applicant
14 stated that it is a new program using existing
15 inspection monitoring activities, consistent with
16 GALL. And they have done all the testing. Why is it
17 that this is an existing program versus a new program,
18 if they have already been -- they say they have been
19 doing this testing.

20 MR. JOSE: Well, they categorized that as
21 a new program which uses existing monitoring
22 techniques or which uses existing monitoring in terms
23 of testing that is just MEGGER. I believe the type of
24 cables that they have are without -- what do you call
25 that, those cannot be. The only available test right

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 now is MEGGER test.

2 CONSULTANT BARTON: Right.

3 MR. JOSE: You know. They don't have that
4 shield. You require a uniform shield for our unit
5 from ground for doing standout and other things.

6 CONSULTANT BARTON: Right.

7 MR. JOSE: So they were doing some kind of
8 monitoring, but they took it as if it's a new program.

9 And hoping that will be a state of the art test just
10 before the --

11 CONSULTANT BARTON: Before the license
12 expires?

13 MR. JOSE: -- license expires. Plus, they
14 will have a one time test before the license expires
15 and 10 years thereafter.

16 CONSULTANT BARTON: Okay.

17 MR. JOSE: Yes, Cliff?

18 MR. DOUTT: Cliff Doutt. I have a
19 question as well.

20 CHAIR BLEY: Please, speak into the mike.

21 MR. DOUTT: Oh.

22 CHAIR BLEY: Just point it right at you.

23 MR. DOUTT: Is that better?

24 CHAIR BLEY: And give your name.

25 MR. DOUTT: Sorry. Cliff Doutt, License

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Renewal. We asked the same question in an RAI. Our
2 concern was taking credit for a program that didn't
3 implement the AMP already.

4 CONSULTANT BARTON: Yes, that was my
5 problem.

6 MR. DOUTT: And so what they did is they
7 corrected the basis documents to remove that
8 statement. And they are not doing that. But in
9 reality, part of the issue was they wanted a credit
10 for current testing. And since we don't know what we
11 are going to do just yet, we've got four years to go,
12 then it's prior to, and we ask that question and it's
13 discussed in the SER as well. I think it is Section
14 3.0.3.1.1.9. There is a small paragraph on that.

15 There was another LRA revision, but the
16 basis documents are correct. So that's more
17 background.

18 CONSULTANT BARTON: Thank you.

19 MR. DOUTT: Sure.

20 MR. JOSE: Again, for Aging Management
21 Program reviews, we did the program documentation. we
22 also performed walk-downs of the underground cable
23 vaults and switchyard and we also did -- interviewed
24 plant personnel.

25 Operating experience was another piece of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 our review also just to make sure that they do account
2 for internalized industry operating experience. For
3 that, we did look at their Corrective Action Programs
4 and their reports on their Corrective Action Program,
5 as well as system health reports and the program
6 results.

7 Again, the Aging Management Program
8 inspection results. The licensee also did a specific
9 letter after our inspection called NG 10-009, which is
10 dated January 14, 2010. And Enclosure 1 to that
11 letter details all our findings.

12 And I did list a few here just for the
13 highlights here. Like the BWR vessel ID attachment
14 and BWR internal program, the licensee agreed to do
15 some clarification of the water chemistry. We did
16 have questions as to how increased sampling is going
17 to help or is used to verify effectiveness, things of
18 those nature and licensee has clarified they did take
19 corrective action to correct those.

20 And external surfaces monitoring, again
21 procedure enhancements that will include surface
22 conditions and document retention requirements, except
23 for those things that were not spelled out in their
24 program.

25 Structural monitoring was a bigger piece

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 here. And the bolting integrity took credit -- was
2 credited by several programs which also included
3 structural monitoring and this was not explicitly
4 stated in their program or their program procedures.
5 So licensee did agree to revise their plan procedures
6 to include inspection of bolting integrity.

7 And water chemistry program, we had a
8 question about how, because GALL has specific steps
9 and therefore monitoring hydrogen peroxide which was
10 not very explicit and the licensee did agree to
11 clarify to include this electrochemical potential
12 method that they are using.

13 Those were the highlights. Yes?

14 MEMBER ARMIJO: The hydrogen peroxide
15 monitoring, I'm not really familiar with that. Could
16 you explain what is going on there? Is this a
17 chemical additive that is in their system or is --

18 MR. JOSE: You know, I believe the water
19 chemistry, hydrogen peroxide comes in as a byproduct.

20 And again, this electrochemical potential is used to
21 measure the oxidizing power of oxygen and hydrogen
22 peroxide.

23 MEMBER SHACK: It's a radiolysis product,
24 Sam.

25 MR. JOSE: Right.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER SHACK: It's just that oxygen isn't
2 the only thing that raises the electrochemical
3 potential. Hydrogen peroxide does, too.

4 MEMBER ARMIJO: But that is produced in
5 the core?

6 MEMBER SHACK: In the core.

7 MEMBER ARMIJO: Yes.

8 MEMBER SHACK: Okay. Okay.

9 MEMBER ARMIJO: And so they monitor or
10 track peroxide as well as --

11 MEMBER SHACK: Well, since they are
12 monitoring electrochemical potential, you know,
13 whether the potential is coming from oxygen or from
14 hydrogen peroxide, it doesn't --

15 MEMBER ARMIJO: They don't care?

16 MEMBER SHACK: They don't care.

17 MEMBER ARMIJO: Right.

18 MEMBER SHACK: What they really worry
19 about is the potential. And, you know, if they were
20 just monitoring the oxygen, you would worry.

21 MEMBER ARMIJO: Yes.

22 MEMBER SHACK: Because they might be
23 getting a potential increase from the peroxide. But
24 since they are monitoring the potential, they got the
25 right thing.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER ARMIJO: Okay. Thank you.

2 MR. JOSE: And with that, we concluded
3 that the scoping and screening as related to the Aging
4 Management Programs were appropriate. And
5 documentation, you know, was supporting. The
6 application was auditable and retrievable and we found
7 the documentation to be to an acceptable level.

8 And our report was documented in 2009-10,
9 that was the report number. Any more questions for
10 me?

11 CHAIR BLEY: Okay. You can go ahead.

12 CONSULTANT BARTON: Oh, I'm sorry.

13 CHAIR BLEY: Go ahead. No, go ahead,
14 John, do you have one?

15 CONSULTANT BARTON: In your report you
16 noted material condition items during walk-down of the
17 plant and, apparently, you guys submitted or made sure
18 work orders were written as a result of some of your
19 observations on material conditions.

20 MR. JOSE: Yes.

21 CONSULTANT BARTON: Did the team get a
22 chance to go and look at the plants' list of the open
23 work items and look for material condition issues and
24 how long they may be open?

25 MR. JOSE: Yes. When we do the work, I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 mean, we did the walk-downs. We identified like
2 corrosion, for example, some oil leaks here and there.

3 And the first reflection from the plant personnel to
4 us was to write a corrective work order.

5 CONSULTANT BARTON: Yes.

6 MR. JOSE: Okay. And we questioned that,
7 the threshold of writing CRs or IRs, corrective action
8 documents instead of work orders. And things that
9 they could repair with their team or whatnot, you
10 know, they would generally write a work order.

11 CONSULTANT BARTON: Right.

12 MR. JOSE: But during that process, we did
13 look at their work history.

14 CONSULTANT BARTON: Okay.

15 MR. JOSE: And their, I think, SAP-based
16 program and corrective action documents again, you
17 know, for system-based. And system health reports was
18 another avenue for looking at, you know, what their
19 standard problems were.

20 CONSULTANT BARTON: Okay.

21 MR. JOSE: And the focus was to get them
22 to start thinking in terms of license renewal,
23 basically. You know, something like corrosion or
24 pitting, it's not just to correct it immediately, but
25 you should be looking for long-term.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR BLEY: Thank you.

2 MR. HARRIS: Okay. Moving on to Section 3
3 of the SER. Section 3 of the SER consists of the
4 following subsections: Aging Management Programs;
5 reactor vessel and internals; engineered safety
6 features; auxiliary systems; steam and power
7 conversion systems; containment, structures and
8 component supports; and electrical and instrumentation
9 and controls.

10 So I won't cover each section, subsection,
11 but will touch on those which either have an open item
12 or items of interest.

13 Section 3.0.3 contains the staff's review
14 of the applicant's Aging Management Program or AMPs.
15 43 AMPs were reviewed by the staff. 14 are new
16 programs. 29 are existing programs. 20 were
17 identified as consistent with the GALL Report. 8 were
18 consistent with enhancements. 9 consistent with
19 exceptions. 2 consistent with both enhancements and
20 exceptions. 4 were identified as plant-specific.

21 So during the staff's review, an open item
22 was identified related to the management of small bore
23 piping socket welds. During the review, the staff
24 indicated to the applicant our concern that a visual
25 inspection would be inadequate, as it would not detect

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 flaws initiating from the inside diameter.

2 So this concern stemmed from the staff's
3 review of industry operating experience for failures
4 in small weld piping socket welds and resulted in
5 unplanned shutdowns.

6 So we understand the applicant's initial
7 concerns regarding the lack of industry-endorsed
8 methodology for volumetric inspections. However, we
9 have also pointed to them several instances where
10 other applicants have been able to demonstrate flaw
11 detection using different plant specific techniques.

12 So the staff's position remains that
13 periodic volumetric examination is needed for small
14 bore socket welds in order to be consistent with the
15 recommendations of the GALL.

16 So as covered earlier, the applicant has
17 provided an RAI response subsequent for resolution.
18 And the staff has performed a preliminary review of
19 the response related to socket welds and will confirm
20 this item for the final SER.

21 Okay. Moving on to the next open item
22 here related to buried piping and the Tanks Inspection
23 Program. There has been a number of recent entry
24 events involving leakage from buried and underground
25 piping where the causes have included coating damaged

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 during backfill of piping; failure of fiberglass
2 piping; failure of buried piping in and around the
3 piping penetrations and failures of piping in
4 trenches.

5 The applicant's program is a new program,
6 which is aimed at managing the aging effect of piping
7 in the right contact with the soil. The program
8 credits incorporation of industry experience later
9 during the period of extended operation.

10 So the staff needed further information to
11 evaluate the impact that these recent industry events
12 might have on the buried piping program.

13 The staff issued an RAI in May to complete
14 its review. And the applicant has recently provided
15 an RAI response, supplement for this resolution. So
16 we are performing a preliminary review of this
17 information related to buried piping and will confirm
18 this item for the final SER review.

19 So I'm including the next set of slides,
20 because they are items of interest that have come up
21 in other reviews and I think that we are highlighting
22 here in our presentation today.

23 So the torus coating is an issue that was
24 also recently covered in the Cooper License renewal
25 review last month. Like Cooper, Duane Arnold has a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Mark 1 containment. And the staff reviewed the
2 applicant's operating experience and identified
3 concerns with more than the 15,000 coating repairs in
4 the torus, suppression pool documented since 1995.

5 One pit measured .25 inches in diameter
6 and .056 inches in depth or 10.5 percent of the
7 nominal thickness there. All other applications --
8 excuse me, all other locations of pit depths were less
9 than 10 percent of the nominal thickness.

10 MEMBER ARMIJO: What is the corrosion
11 allowance for that material?

12 MR. HARRIS: Corrosion allowance? I'll
13 have Abdul from the staff talk in more detail.

14 MR. SHEIKH: This is Abdul Sheikh, NRC
15 staff. As far as I know, there is no corrosion
16 allowance in this torus. But the way the applicant is
17 managing this torus is they are following the ASME
18 procedures and they are managing the program as in
19 regard with the ASME, the IWE Guidelines and GALL.

20 MEMBER ARMIJO: Well, that's kind of
21 strange. Maybe the applicant wants to clarify
22 something for me. If there is no corrosion allowance,
23 then there is some margin in the design, in the
24 structural design of the torus that is effectively a
25 corrosion allowance.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 You know, clearly, there has got to be
2 some margin against predictable things like corrosion.

3 So I wonder if the applicant can clarify that?

4 UNIDENTIFIED SPEAKER: Very little.

5 MR. SORENSON: Eric Sorenson for Duane
6 Arnold again. With regard to pitting, we do have
7 evaluations performed that are structural in nature
8 that since pit is a discrete defect, we can evaluate
9 the wall thickness with that discrete defect and
10 consider it acceptable. So we are talking about small
11 pits in a very -- you know, a single pit in a large
12 area not affecting the structural integrity of the
13 torus.

14 MEMBER ARMIJO: But that addresses other
15 questions, because it's a coated structure, you don't
16 really have a general corrosion allowance, do you?

17 MR. SORENSON: We do not have a general
18 corrosion allowance.

19 MEMBER SIEBER: All right.

20 MEMBER ARMIJO: The presumption is that
21 the coating protects you. Okay. I understand it now.
22 Thank you.

23 MEMBER BONACA: You refer to 15,000
24 coating repairs.

25 MEMBER ARMIJO: A lot of pits.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER BONACA: What is this? This simply
2 recoating?

3 MR. SORENSON: Yes, those 15,000 -- this
4 is Eric Sorenson again. Those 15,000 coating repairs
5 range from mechanical corrections to areas where we
6 just observe zinc depletion to areas that have had
7 actual pitting observed in there. And this is over
8 five exam periods. So we average -- I think it's
9 probably more exam periods in that. I have to look
10 exactly, but that's over a long period of time, 10 to
11 15, 15 or so years of inspection where we have
12 observed that many repairs.

13 MEMBER BONACA: Okay.

14 CONSULTANT BARTON: Does that mean there
15 is 15,000 pits or just 15,000 failures of the coating?

16 MR. SORENSON: 15,000 --

17 CONSULTANT BARTON: Some are repairs.

18 MR. SORENSON: Yes. There are not 15,000
19 pits.

20 CONSULTANT BARTON: That's a good thing.

21 UNIDENTIFIED SPEAKER: There's only 5,000
22 pits.

23 CHAIR BLEY: Go ahead. Let me ask one.
24 You said some of those weren't just touching up the
25 coating, you actually did mechanical repairs?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. SORENSON: No, no. This is Eric
2 Sorenson again. Some of those repairs that we had to
3 correct were mechanical things where somebody -- were
4 mechanical damage and we had to correct.

5 CHAIR BLEY: Oh, okay. I understand.
6 Okay.

7 MEMBER ARMIJO: But just to make sure I
8 understand, you never actually ground out the pit or
9 anything like that?

10 MR. SORENSON: No.

11 MEMBER ARMIJO: You just --

12 MEMBER SIEBER: Painted over it.

13 MEMBER ARMIJO: -- cleaned it up and
14 painted over it?

15 MR. SORENSON: That is -- this is Eric
16 Sorenson again. That is correct. The pit was not
17 deeper than the qualified coating thickness of the
18 coating that we were going to apply, so we could just
19 coat over the pit.

20 MEMBER ARMIJO: Okay.

21 CHAIR BLEY: Okay. Brian, go ahead.

22 MR. HARRIS: Okay. Yes. So basically,
23 from a cumulative effect, with respect to staff
24 concerns, the pitting corrosion rates are typically
25 much higher and less predictable than the general

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 corrosion rate.

2 So in resolution of this item of interest,
3 the IWE inspection procedure was revised to inspect
4 the torus coating during every outage until it is
5 recoated.

6 And a commitment was written to recoat the
7 torus underwater surface prior to start-up of the
8 first refueling outage during PEO.

9 An item of interest within Section 3.5 is
10 groundwater sampling. The applicant's groundwater is
11 non-aggressive as shown on the slide. All the
12 sampling markers meet acceptable limits. The staff
13 was concerned about the ten-year frequency of
14 groundwater sampling. And the applicant enhanced the
15 structures monitoring program to include groundwater--
16 sampling of groundwater on the five-year frequency
17 instead of the original ten-year frequency.

18 Moving on to Section 4 of the SER.
19 Section 4 contains the staff's review of the time-
20 limited aging analysis or TLAA. TLAA's are certain
21 plant-specific safety analysis that involve time-
22 limited assumptions defined by the current operating
23 term. It must be listed by section 54.21(c)(1). And
24 any plant-specific TLAA based assumptions per
25 54.21(c)(2).

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 The staff reviewed information in the LRA
2 to determine whether the applicant has provided
3 sufficient information pursuant to 54.21(c)(1) and
4 (c)(2).

5 In Section 4.2, the SER covers the reactor
6 vessel neutron embrittlement analysis. There were
7 three reviews performed to evaluate neutron
8 embrittlement as documented in the SER. Those three
9 were neutron fluence and adjusted reference
10 temperature review, upper shelf energy review and
11 pressure-temperature limits review.

12 The staff concluded that the reactor
13 neutron embrittlement analysis meet the review
14 criteria in the Standard Review Plan in accordance
15 with the rules.

16 In Section 4.3 of the SER, the staff
17 documents its review of the metal fatigue and piping
18 and the components TLAA. The 60-year environmentally
19 assisted fatigue analyses were performed for plant-
20 specific locations identified in NUREG/CR-6260 for an
21 older vintage BWR plant. The resulting
22 environmentally assisted fatigue cups were all less
23 than 1.0 for these locations.

24 The applicant manages fatigue of all
25 NUREG-6260 locations using the metal fatigue or

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 reactor coolant pressure boundary program in
2 accordance with 10 CFR 5421(c)(1)(iii).

3 So in conclusion, on the basis of its
4 review, the staff determines that pending resolution
5 of the open items discussed, the requirements of 10
6 CFR 5429(a) have been met for the license renewal of
7 the Duane Arnold Energy Center.

8 Staff conclusions regarding the LRA for
9 Duane Arnold will be provided in the final SER
10 scheduled to be issued on October 2010.

11 CHAIR BLEY: Okay. Thank you. Any
12 questions from the Committee?

13 MEMBER RAY: Can we go back to 16, please?

14 I did listen to the whole discussion. I got stuck
15 here and the discussion moved on. So there is an
16 average of 1,000 -- clearly, I'm getting confused
17 between coating problems and the pressure boundary
18 effects.

19 I take it that a pit or pitting corrosion
20 rates is something that affects the pressure boundary?

21 Is that right?

22 MR. HARRIS: Abdul?

23 MR. SHEIKH: This is Abdul Sheikh, NRC
24 staff. Let me just explain the issues. There are
25 15,000 total repairs. There is only one pit which is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 bigger than 10 percent and that's just slightly bigger
2 than that.

3 MEMBER RAY: 10 percent of what?

4 MR. SHEIKH: 10 percent of about .553 of
5 an inch.

6 MEMBER RAY: Okay. Let's try it this way.

7 Is it 10 percent of the pressure boundary or 10
8 percent of the coating?

9 MR. SHEIKH: 10 percent of the pressure
10 boundary.

11 MEMBER RAY: Okay. Thank you. All right.

12 So but we repair the coating, we don't repair the
13 pressure boundary. Is that correct?

14 MR. SHEIKH: That is -- about this 15,000,
15 most of them are touch-ups of the coating. There are
16 -- I don't have the exact number where there has been
17 some loss of material. There is only one pit where
18 there is a loss of material that's more than 10
19 percent. And that was evaluated and found that the
20 structural integrity of the torus is maintained.

21 MEMBER RAY: Okay. Well, that's
22 information that isn't here, at least explicitly.
23 Maybe it is implicitly here. But the information on
24 this slide it's hard to puzzle out exactly what we are
25 talking about. But it sounds like most of the time

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 you are talking about repairs to the coatings, that's
2 what it says, coating repairs.

3 MR. SHEIKH: Right.

4 MEMBER RAY: And very occasionally, I
5 guess, you find there has been degradation of the
6 pressure boundary, but not enough to require repair of
7 the pressure boundary.

8 MR. SHEIKH: That is correct.

9 MEMBER RAY: Okay. Well, that's not
10 easily discerned from this slide, to be honest with
11 you.

12 MR. SHEIKH: Okay.

13 UNIDENTIFIED SPEAKER: It's not my slide.

14 MR. SHEIKH: We can -- I mean, at this
15 time, we can't correct it, but I --

16 MEMBER RAY: That's fine. But I'm just
17 telling you I can't -- it's hard to figure out what
18 you are talking about here.

19 MR. HOLIAN: This is Brian Holian. We
20 will take that comment. We are kind of following up
21 on last month's Cooper that had similar types of
22 coating repairs and probably more severe pitting in
23 that area. And Duane Arnold had had it coated once,
24 Cooper had not. So really, we were just shining a
25 little bit of a spotlight on their operating

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 experience.

2 It hasn't been a significant issue for the
3 regions. The regions have been following it pretty
4 well. You know, we have even gone back to some plans
5 at Nine Mile Point that is already in license renewal
6 that had coated, but now, as a matter of fact, I think
7 they are coating this outage. So just following up on
8 operating experience and making sure they were long-
9 range plan is really the message.

10 MEMBER RAY: Well, that's fine, Brian. I
11 appreciate the clarification. I just think
12 distinguishing between fixing the coating and fixing
13 the pressure boundary is what I'm trying to get
14 straight here. And this has generic applicability as
15 you say. So I'm trying to figure out what information
16 are we being given. Thank you.

17 MR. HOLIAN: Okay.

18 MEMBER ARMIJO: Yes, well, I don't
19 disagree with the staff conclusion about the
20 consequences of pits on the structural integrity. I
21 just was looking to how much margin that the torus
22 really had. And just assume that you had lots of
23 pits, even though that's not the case, and if they
24 were 10 percent of the wall, would that be a
25 significant problem?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 And normally, in components like this,
2 there is often a corrosion allowance and so that's
3 throw away material. I just wondered if effectively
4 you have a corrosion allowance through some other
5 margin in the design? And my guess is you do, but I
6 don't know what it is. Maybe somebody can tell me.

7 MEMBER RAY: Well, I just accepted the
8 statement that it didn't affect structural integrity
9 and is consistent with what you are saying.

10 MEMBER ARMIJO: Yes, I'm sure that is the
11 way it will turn out. I'm just trying to get a number
12 of seeing how much could we have lost and still have
13 plenty of margin.

14 MR. SHEIKH: The staff hasn't calculated
15 that, but what we have looked, we have taken is that
16 they have only one small pit --

17 MEMBER ARMIJO: No, I understand one small
18 pit won't cause a problem.

19 MR. SHEIKH: Right, right.

20 MEMBER ARMIJO: Or even a lot of small
21 pits if they are spread out. But I'm just trying to
22 see how much margin that torus had in the original
23 design.

24 MR. SHEIKH: As far as I think, there is
25 plenty of margin in the torus, because the normal

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 corrosion, general corrosion rate in industry is about
2 2 to 4 millimeter, 2 to 4 mils per year. I'm sorry.
3 2 to 4 mils per year.

4 MEMBER ARMIJO: Okay.

5 MR. SHEIKH: So we have, you know, plenty
6 of margin there.

7 MEMBER BONACA: Just a question I had was
8 are the defects uniformly distributed on the torus or
9 are they look at it in certain specific areas?

10 MR. SHEIKH: I didn't get the question.

11 MEMBER BONACA: My question is if this
12 15,000 repairs are for defects that are uniformly
13 distributed over the torus area?

14 MR. SHEIKH: They are all in the area
15 underwater.

16 MEMBER BONACA: Yes, I understand that.

17 MR. SHEIKH: All of them. That's why they
18 are coating the bottom half of the torus.

19 MEMBER BONACA: But what are they? Are
20 they uniformly spaced?

21 MR. SHEIKH: Probably the applicant can
22 tell.

23 MR. SORENSON: This is Eric Sorenson
24 again. The pits and the defects, defined defects are
25 at every bay in our torus all the way underneath the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 water line where we had -- those are areas we
2 typically would find general zinc depletion.

3 MEMBER BONACA: Okay.

4 MR. SORENSON: We do find heavier pittings
5 and damage in the bottom, in the actual bottom 12
6 inches of the ark of the torus where we would have the
7 heaviest sludge accumulation, so that would create
8 that pocket that we would have higher corrosion rates
9 in there.

10 MEMBER BONACA: Okay.

11 MR. SORENSON: But we do see it completely
12 around the torus, up on the walls.

13 MEMBER BONACA: Yes.

14 MR. SORENSON: Is where we would see all
15 the damage.

16 MEMBER BONACA: All right.

17 MEMBER RAY: But I'm sorry, I'm going to
18 pick at words again. You're talking about corrosion.
19 I don't know if that's the right word to apply to the
20 coating damage that you are seeing.

21 MEMBER SIEBER: Deterioration.

22 MEMBER RAY: Is that the correct term?

23 MR. SORENSON: This is Eric Sorenson
24 again. Corrosion is probably not the correct term in
25 here, because this is a sacrificial zinc coating that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 is supposed to sacrifice. And when it does, you will
2 see surface rust and then immediately when we see, we
3 would go in and correct it.

4 There is a lot of cases where there is no
5 depth to that. It's just we have seen the coating
6 deplete.

7 MEMBER RAY: Okay.

8 CHAIR BLEY: Anything more? It looks like
9 you will be coming back to the Full Committee some
10 time around October?

11 MR. HARRIS: Yes, that's correct.

12 CHAIR BLEY: Okay.

13 MEMBER ARMIJO: How many open items do you
14 still have?

15 MR. SORENSON: We have two open items.

16 MEMBER ARMIJO: Two. Okay.

17 MR. HOLIAN: This is Brian Holian. Just a
18 comment on those open items. I could have stated that
19 earlier, but those are 12 or 13 applications that we
20 have in-house now. Both of those are current issues
21 that we are kind of upgrading to the new GALL, both of
22 them.

23 We just had a public meeting on the GALL
24 last week, the revised GALL coming out. Buried piping
25 is obviously one that we are increasing the amount of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 sampling. A little push-back from the staff, you
2 know. Not the staff, I'm sorry, the industry on that.

3 The industry is worried a little bit about, you know,
4 the increased sampling that we might require and the
5 GALL will also then possibly cause opportunistic, you
6 know, degradations or backhoe damage to the piping.

7 But we are working towards a resolution as
8 is stated here. They stated they know they need to
9 increase their looks at what is unseen down there. So
10 not only are we picking those two up on these plans,
11 those two open items, but on all plants in- house kind
12 of finalizing and improving those commitments in the
13 commitment table.

14 MEMBER ARMIJO: Thanks.

15 CHAIR BLEY: Anything more? Well, I'm
16 going to go around the table, but I think before I get
17 the Committee Members, I'm going to ask our
18 consultant, John Barton, to give us your comments,
19 please. John?

20 CONSULTANT BARTON: Well, I believe the
21 staff did a good job in their inspection report,
22 pretty thorough. The only issues I see is the
23 resolution to two open items. I'm sure that they can
24 give these out fairly easily. And the fact that they
25 have committed to finally recoat the torus, that's the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 last issue I had. So I don't have any other issues
2 that would preclude license renewal in my opinion.

3 CHAIR BLEY: Okay. Great. Thank you.
4 And as we go around for the Committee, if you would
5 also mention anything, if there is anything here you
6 want to make sure we bring to the Full Committee,
7 please, do so.

8 Jack, why don't we go this way. Jack?

9 MEMBER SIEBER: Yes, I think that the
10 application was appropriate. And the staff's review
11 and their RAIs and resolutions are appropriate. But
12 we still have two open items, which I think should be
13 or must be resolved. And it is up to the staff to
14 resolve those in the appropriate fashion which we will
15 then review.

16 I think this plant compared to others of
17 this age is in pretty good condition. And so I really
18 don't have any issues that jump out at me that would
19 cause us to raise new issues with respect to this
20 application.

21 CHAIR BLEY: Thanks, Jack. Sam?

22 MEMBER ARMIJO: Yes, I share Jack's view.
23 I think the applicant was very good. I think the
24 staff has done a really good review. I think that the
25 plant has benefitted from a very technically

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 aggressive program to deal with IASCC and IGSCC. I
2 think the plant has done a very good job being the
3 lead plant in the industry to apply hydrogen water
4 chemistry and noble metals.

5 I think that's one of the reasons why they
6 have such good experience with their core internals
7 and their piping. That being said, you still have to
8 monitor and you still have to inspect.

9 But overall, I think the plant's
10 presentation is very good. I would try in the
11 Committee, Full Committee, meeting try and just make
12 it easy for the Members who aren't here to understand
13 that this pitting corrosion of the torus is really a
14 very minor problem. And you don't get that from word
15 charts.

16 CHAIR BLEY: Thanks. Harold?

17 MEMBER RAY: I would just echo what Sam
18 said and add nothing more.

19 CHAIR BLEY: Thank you. John?

20 MEMBER STETKAR: I don't have anything
21 more, other than to thank the staff for aggressive
22 reviews of operating experience and gaining a lot of
23 insight from that.

24 I think that that helped an awful lot in
25 their inspections and identifying potential issues.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 So I'm glad to see the staff is continuing to do that.

2 CHAIR BLEY: All right. Bill?

3 MEMBER SHACK: I am just glad to see the
4 torus is going to get recoated with a good modern
5 coating. The one thing that is new to me, and maybe
6 it has been here before, was the use of the torsional
7 guided waves to look at some very frightening -- I
8 mean, we have been sort of relying totally on
9 opportunistic inspections up until now, you know, and
10 if it isn't a perfect tool, at least any tool that
11 would help you to get some insight into degradation of
12 buried piping seems like a helpful kind of
13 development.

14 And I hope other people will apply it and
15 sort of get along.

16 CHAIR BLEY: All right.

17 MR. HOLIAN: This is Brian Holian again.
18 Just a comment on that. I don't know if Bill Holston
19 was here. He is a Senior Engineer and spent 20 years
20 at Calvert. I know he is in the back, but I'll just
21 state it for him.

22 Several plants are, you know, using that
23 now and I guess we haven't highlighted as much, but
24 even the staff is going down to Charlotte in a couple
25 of weeks here to look at the latest techniques in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that.

2 And I know some Region I staff has already
3 gone there to look at what aspects, you know, we heard
4 that it can get out to the second bend or second
5 elbow. There is other indications sometimes that
6 external supports have also caused false issues, but
7 it is an area not only we are looking at license
8 renewal, but obviously the Division of Component
9 Integrity is looking at NEI's submittal on buried
10 piping and how far we can credit that.

11 MEMBER STETKAR: Brian, you said other
12 plants are actually implementing or have committed to
13 implement this?

14 MR. HOLIAN: Yes. I don't know if they
15 have committed in their applications yet.

16 MEMBER STETKAR: Because I was going to
17 say, I haven't seen it.

18 MR. HOLIAN: Yes.

19 MEMBER STETKAR: I think Bill is right,
20 this is the first one.

21 MR. HOLIAN: Yes, the committed -- the
22 word I might have used is verbally to us at times, but
23 we are looking at trying to get it in writing where
24 they are using it for their process.

25 MEMBER STETKAR: Good.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR BLEY: Excellent. Mario?

2 MEMBER BONACA: No further comments.

3 CHAIR BLEY: Okay. And I would like to
4 thank staff and the applicant very much for very good
5 presentations and discussions.

6 And we will look forward to seeing you in
7 October.

8 At this point, the Subcommittee meeting is
9 -- well, I guess I should ask, are there any public
10 comments before we close the meeting?

11 Then we will close the Subcommittee
12 meeting. The Subcommittee is adjourned.

13 (Whereupon, the meeting was concluded at
14 11:12 a.m.)

15

16

17

18

19

20

21

22

23

24

25

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701



Duane Arnold Energy Center



ACRS License Renewal Subcommittee Presentation

June 8, 2010

Personnel in Attendance


Christopher Costanzo	Site Vice President
Ken Kleinheinz	Engineering Director
Ken Putnam	License Renewal Project Manager
Curt Bock	License Renewal Mechanical Lead
Ken Chew	License Renewal Civil Lead
Mike Fairchild	License Renewal Electrical Lead
Clara Rushworth	License Renewal Licensing Lead
Herb Giorgio	Environmental Lead
Eric Sorenson	Program Engineering
Al Thomas	Program Engineering

Agenda

- **Background**
- **Operating History**
- **License Renewal Project Overview**
 - Scoping Discussion
 - Time Limited Aging Analysis
 - Application of GALL
 - Commitment Process
- **Technical Items of Interest**
 - Torus Coatings
 - Buried Piping
 - Small Bore Piping



PDC



Value

Maximize the time spent on
Prevention and Detection
to minimize / eliminate Correction activities

Background – Site

- **Approximately 6 miles NW of Cedar Rapids, Iowa**
- **General Electric (NSSS & Turbine Generator)**
- **Bechtel (AE and Constructor)**
- **BWR- Mark I Containment**
- **1912 MWt Thermal Power; ~ 630 MWe**
- **Cedar River is ultimate heat sink and water makeup source. Forced draft cooling towers for condenser cooling**
- **Staff Complement: approximately 650**

Background – Plant Status

- **Startup from Refuel Outage 21 – March 2009**
- **Current Plant Status**
- **Next Refuel Outage – October 2010**

Operating History – Licensing

Construction Permit	June 17, 1970
Operating License	February 22, 1974
Commercial Operation	February 1, 1975
Upated Power License (5%)	March 27, 1985
Extended Power Uprate License (15%)	November 6, 2001
Operating License Transfer to FPL (NextEra)	January 27, 2006
LR Application Submitted	September 30, 2008
Operating License Expires	February 21, 2014

Major Improvements

1987 Hydrogen Water Chemistry and Crack Arrest Verification System

Electrochemical Potential Monitor

1996 Noble Metals Applied

1998 ECCS Suction Strainers Replaced

2001 High Pressure Turbine Upgrade

Moisture Separator Reheaters Upgrade

Replaced 2 Circulating Water Pumps

2003 Replaced Drywell Coolers

Major Improvements (continued)

- 2005** Replaced Feedwater Heaters
Replaced Condensate Pumps
Installed Condenser Isolation Valves
- 2007** Heater Bay Cable Replacement
- 2009** “B” Diesel Generator Governor Upgrade
“A” & “B” Diesel Generator Voltage Regulator Upgrade
Main Transformer Replacement
Recirculation MG Set Scoop Tube Positioner Upgrade
Feedwater Flow Correction System Replacement

License Renewal Project Overview

- **Site Ownership and Oversight**
- **Experienced Team (DAEC, Corporate, Contract)**
- **Benchmarking**
- **QA Audits**
- **Participation in industry working groups**
- **Industry Peer Review**

Project Overview – Scoping

- **Scoping process consistent with requirements of 10CFR 54 and the guidance of NEI 95-10**
- **Categorized entire plant in terms of major SSCs**
- **Identified system level functions**
- **Evaluated all SSCs against Scoping Criteria 10CFR54.4 (a)(1), (a)(2) and (a)(3)**
- **Identified SSCs that perform or support an intended function**

Project Overview – Scoping

- **Utilized site component database, controlled drawings, design and licensing documents**
- **Non-Safety Affecting Safety (a)(2)**
 - Reviewed safety related equipment locations
 - Conservative “spaces” approach
 - Performed walk-downs for verification
- **Use of commodity groups used when evaluations were best performed by component type rather than SSC**

Project Overview – TLAA

- **Design and Licensing Basis reviewed for potential Time Limited Aging Analysis**
- **Neutron fluence was determined for DAEC operation out to 54 EFPY using RAMA methodology.**
 - Extended operation to 60 years will be bounded by 54 EFPY.
 - Fluence determined for vessel and internals.
 - Pressure/Temperature Curves created for 54 EFPY.
- **Thermal Cycle projections updated for 60 year life**
 - Used to evaluate fatigue for 60 year life.

Project Overview – TLAA

- **Environmental Fatigue evaluated for locations identified in NUREG/CR-6260 using NUREG/CR-6583 and 5704**
 - All locations confirmed CUF < 1.0
 - NUREG/CR-6909 for new plants has updated data for Nickel Alloys
 - NUREG/CR-6909 can result in higher environmental fatigue factor but it would not alter the conclusion that CUF < 1.0
- **Environmental Qualification calculations updated to 60 year life**

Project Overview – Application of GALL Programs

- **43 Aging Management Programs**
 - 19 Programs in place with out Enhancements
 - 10 Programs will be Enhanced
 - 14 New Programs
- **GALL Consistency**
 - 28 Consistent
 - 11 Consistent with Exceptions
 - 4 Plant Specific
 - Electrical Connections Program
 - Electrical Penetration Assembly Program
 - ASME Code Class 1 Small-bore Piping Inspection Program
 - Boral Surveillance Program

Project Overview – Industry Issues

- **Industry Issues During DAEC Project**

- Station Black Out boundary – DAEC has included switchyard breakers, control circuits and associated structures within scope
- Methods for fatigue evaluation – DAEC eliminated use of simplifying methods (Green's Function) in fatigue calculations
- NRC GL 2007-01 – Inaccessible or Underground Power Cables
 - Sump pumps upgraded in three manholes
 - New inspections for man-holes without sump pumps
- IN 2009-26 Degradation of Neutron Absorbing Materials in Spent Fuel Pool – DAEC Added Boral Surveillance Program

Project Overview – Commitment Process

- **50 Regulatory Commitments for License Renewal**
- **Commitments entered into site commitment tracking system**
- **Implementation activities underway to ensure completion well in advance of PEO**
- **Retain portion of project core team to support implementation activities with program owners**
- **Specific projects for larger items**

Project Overview – Open Items

Draft SER Summary

- **Open Items – 2**
 - Buried Piping
 - Small Bore Piping
- **Confirmatory Items – None**

Technical Items – Torus Coatings

- **Issue**

- IWE Program has identified numerous areas of zinc depletion on torus coatings and minor pitting
- ASME Code does not specify when coatings must be replaced

- **DAEC Operating Experience**

- Torus was last recoated in 1985
- Zinc Oxide Coating with Phenolic Coating band at the waterline
- Routine Inspections with touch up coating repairs
- Sludge deposits minimized during feed and bleed of torus using torus cooling and by outage sludge removal

- **Resolution**

- Recoat of underwater surfaces planned for 2012 Refuel Outage

Technical Items – Buried Piping

- **Issue**

- Recent industry events involving leakage from buried and underground piping may warrant changes to the Buried Piping and Tanks Inspection Program

- **Background**

- In response to industry events, the Nuclear Energy Institute issued an initiative on buried piping titled “Guideline for the Management of Buried Piping Integrity, NEI 09-14, in January, 2010.
- The Electric Power Research Institute issued buried component guidelines per EPRI 1016456, “Recommendations for an Effective Program to Control the Degradation of Buried Piping” in December, 2008.

Technical Items – Buried Piping

- **DAEC Status**

- NextEra Energy issued fleet guidance documents related to buried piping
- DAEC developed the DAEC implementing procedures in accordance with fleet guidance document. This document lists all buried piping at DAEC and performs a risk ranking to prioritize piping sections for inspection based on likelihood and consequence of failure.
- Underground piping is accessible and where applicable is managed by External Surfaces Monitoring Program

Technical Items – Buried Piping

- **DAEC Operating Experience**

- No history of leaks on in-scope piping.
- Buried piping leaks have occurred in well water piping sections constructed of gray cast iron.
- Opportunistic examinations of fire protection piping found the piping in good condition.
- Torsional Guided Wave exams have been performed on portions of the RHR Service Water, Emergency Service Water, and River Water Supply systems.
- UT examination of buried Diesel Fuel Oil Storage tank in 2001 found tank in good condition

Technical Items – Buried Piping

- **2010 Planned Examinations**

- Torsional Guided Wave examinations of HPCI CST suction piping, Core Spray CST suction piping, Condensate system makeup and reject, and Demineralized Water pump suction and transfer piping are scheduled for 2010.
- Excavations to allow UT examinations of RHR Service Water and River Water Supply piping are also scheduled for 2010.

- **Proposed Resolution**

- DAEC Buried Piping and Tanks Inspection Program has been updated to reflect recent industry operating experience.

Technical Items – Socket Welds

- **Issue**

- NUREG-1801 Recommends a volumetric examination of Small Bore Class 1 Piping using qualified techniques
- No industry accepted qualified volumetric exam technique for socket welds exists
- Surface examinations do not detect flaws originating on the interior surface until component fails
- NRC staff indicates volumetric examinations can provide meaningful information about many flaws even if the configuration precludes full qualification
- On going industry efforts appear to be improving potential examination technology

Technical Items – Socket Welds

- **DAEC Operating Experience**

- Pin Hole Leak in Recirculation Pump Drain Line Socket Weld in 1989 (Small Bore Class 1)
- Apparent Cause – Fatigue Cracking due to vibration and initial fit up
- NUREG-1801 Requires a plant specific program for Class 1 Small Bore Piping if plant has experienced cracking
- No additional Class 1 socket weld issues since 1989


Technical Items – Socket Welds

- **Proposed Resolution**

- Perform periodic volumetric exams of 10 percent of Class 1 socket welds using industry qualified exam technique if it is available at time of exam
- If no industry qualified examination technique is available at time of inspections a plant procedure for volumetric examination will be used

Questions?

Histogram for Cumulative Plant Startups





U.S. NRC

UNITED STATES NUCLEAR REGULATORY COMMISSION

Protecting People and the Environment

Advisory Committee on Reactor Safeguards License Renewal Subcommittee

Duane Arnold Energy Center Safety Evaluation Report with Open Items

June 8, 2010

Brian K. Harris, Project Manager
Office of Nuclear Reactor Regulation

- Overview
- Section 2: Scoping and Screening Review
- License Renewal Inspections
- Section 3: Aging Management Program and Review Results
- Section 4: Time-Limited Aging Analyses (TLAAs)

- LRA Submitted by letter dated Sept 30, 2008
- GE Boiling Water Reactor (BWR), Mark I containment
- Nov. 6, 2001 - Extended Power Uprate (EPU) was granted to DAEC to operate at 1912 MWth, 629 MWe
- Operating license for NPR-49 expires February 21, 2014
- Located approximately 8 miles NW of Cedar Rapids, IA

- Safety Evaluation Report with Open Items was issued May 2010
- 2 Open Items
 - OI-3.0.3.3.3 Socket Welds
 - OI-3.0.3.1.7 Buried Piping

- **Aging Management Programs (AMP) Audit**
 - August 10 - 14, 2009
- **Scoping and Screening Methodology Audit**
 - August 24 - 28, 2009
- **Regional License Renewal Inspections**
 - November 2 – 6, 2009
 - November 16 – 20, 2009



Section 2: Structures and Components Subject to Aging Management Review

Section 2.1 - Scoping and Screening Methodology

Section 2.2 - Plant-Level Scoping Results

Section 2.3 - Scoping and Screening Results: Mechanical System

Section 2.4 - Scoping and Screening Results: Structures

Section 2.5 - Scoping and Screening Results: EI&C System

- Staff concludes that the applicant has appropriately identified the systems, structures, and components in accordance with 10 CFR 54.4(a), and those subject to an AMR in accordance with 10 CFR.54.21(a)(1)



U.S.NRC

UNITED STATES NUCLEAR REGULATORY COMMISSION

Protecting People and the Environment

License Renewal Inspections

Benny Jose

Region III Inspection Team Leader

71002 Inspection Scope

- 54.4(a)(2) Scoping & Screening Non-Safety SSCs
 - Non-Safety Affecting Safety was Acceptable
- Reviewed 30 of 43 AMPs
 - Program Documents & Procedures
 - Walkdowns of Plant Areas including Cable Vaults and Switchyard.
 - Interviewed Plant Personnel
- Operating Experience Review
 - System Health Reports and Program Results
 - Corrective Action Reports for Prior SSC Problems, associated with the 30 AMPs reviewed

71002 Inspection Results

- **Aging Management Program (AMP) Changes**
 - Buried Piping and Tanks Inspection Program (procedure revisions for opportunistic inspection of excavated pipes)
 - BWR Vessel ID Attachment Welds Program (Water Chemistry clarifications)
 - BWR Vessel Internals Program (Water Chemistry clarifications)
 - External Surfaces Monitoring (procedure enhancements include surface conditions, document retention etc.)

Aging Management Program (AMP) Changes contd.

- Structural Monitoring Program (procedure revisions to include acceptance criteria, inspection of bolting materials and fasteners)
- Water Chemistry Program (LRA revision to clarify monitoring of H₂O₂)

Inspection Summary

- Inspection results support a conclusion there is reasonable assurance that the effects of aging will be adequately managed
- Scoping of non-safety systems was acceptable
- Documentation supporting the application was auditable & retrievable
- Report 05000331/2009010

Section 3: Aging Management Review Results

- Section 3.0 – Aging Management Programs
- Section 3.1 – Reactor Vessel & Internals
- Section 3.2 – Engineered Safety Features
- Section 3.3 – Auxiliary Systems
- Section 3.4 – Steam and Power Conversion System
- Section 3.5 – Containments, Structures and Component Supports
- Section 3.6 – Electrical and Instrumentation and Controls System

Section 3: Aging Management Review Results

- Section 3.0.3 - 43 AMPs evaluated in the SER, consistent with GALL Report

	Plant Specific	Consistent with GALL	With Exception	With Enhancement	With exception & enhancement
Existing 29	0	14	5	8	2
New 14	4	6	4	0	0

Section 3.0.3.3.3 Small Bore Piping

OI-3.0.3.3.3

- DAEC proposed to use visual (VT-2) examination for socket welds
- GALL AMP XI.M.35 recommends volumetric examination
- Given previous operating experience of socket weld failures, GALL recommends that periodic volumetric examination is necessary for managing cracking in socket welds
- In recently docketed responses, DAEC committed to perform periodic volumetric inspections

Section 3.0.3.1.7 Buried Piping and Tanks Inspection Program

OI-3.0.3.1.7:

- Given recent industry OE related to leaks from buried and underground piping, staff is interested in efforts to incorporate OE into AMPs at DAEC
- Staff issued an RAI on May 2, 2010, regarding buried and underground piping at DAEC
- Recently docketed responses will be evaluated for acceptability in final SER

Torus Coating

- Staff Concern
 - Over 15000 coating repairs (5% of the underwater torus area) performed since 1995
 - One pit 0.25 inch diameter and 0.056 inch depth (10.5% of nominal thickness). All others less than 10%.
 - Pitting corrosion rates are typically much higher and less predictable than general corrosion rate
- Resolution
 - IWE inspection procedure revised to inspect the torus coating during every outage until it is recoated
 - Commitment to recoat the torus underwater surface prior to startup of first refueling outage during PEO

Item of Interest: Section 3.5

- Groundwater sampling for pH, chloride, and sulfate concentrations will be performed on a 5-year periodicity.
- DAEC Groundwater is non-aggressive

Groundwater Monitoring Results from September 2007							
Sample Description	Acceptance Criteria	Shallow Wells					
		D111	D112	D113	D114	D115	D116
pH	>5.5	6.60	6.87	7.06	6.87	7.20	6.79
Chloride (ppm)	<500 ppm	77	62	124	48	14	110
Sulfate (ppm)	<1500 ppm	349	470	112	270	14	92

Section 4: Time-Limited Aging Analysis


- 4.1 Introduction
- 4.2 Reactor Vessel Neutron Embrittlement of the Reactor Pressure Vessel and Internals
- 4.3 Metal Fatigue
- 4.4 Environmental Qualification of Electrical Equipment
- 4.5 Concrete Containment Prestress
- 4.6 Fatigue of Primary Containment, Piping, and Components
- 4.7 Other Plant-Specific TLAA

- Section 4.2 - Reactor Vessel Neutron Embrittlement Analysis**

Reactor Vessel Limiting Material	Fluence at 54 EFPY	Predicted USE Decrease (RG 1.99, Rev.2)	EOL USE Acceptance Criteria—Maximum Drop in USE value allowed per the BWRVIP-74-A
Vessel Shell Ring #2, 1-20 Heat # B0436-2	5.74×10^{18} n/cm ² E > 1 MeV	21%	23.5% Equivalent Margin Analysis (EMA) Performed per BWRVIP-74-A

- **Section 4.3 – Metal Fatigue of Piping and Components**
 - NUREG-6260 locations
 - Eight plant-specific locations for DAEC
 - Environmentally adjusted CUF < 1.0 for all locations
 - Dispositioned in accordance with 10 CFR 54.21(c)(1)(iii)
 - Continued monitoring with “The Metal Fatigue of Reactor Coolant Pressure Boundary Program” for all NUREG-6260 locations during the period of extended operation

- On the basis of its review, the staff determines that, pending resolution of the open items, the requirements of 10 CFR 54.29(a) have been met for the license renewal of Duane Arnold Energy Center
- The staff's conclusion regarding the LRA for DAEC will be provided in the Final SER scheduled to be issued in October, 2010



U.S. NRC

United States Nuclear Regulatory Commission

Protecting People and the Environment