

Official Transcript of Proceedings

NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards
US-APWR Subcommittee

Docket Number: (n/a)

Location: Rockville, Maryland

Date: Monday, June 7, 2010

Work Order No.: NRC-286 Pages 1-204

**NEAL R. GROSS AND CO., INC. Court Reporters and Transcribers 1323 Rhode Island
Avenue, N.W. Washington, D.C. 20005 (202) 234-4433**

1
2 DISCLAIMER

3
4
5 UNITED STATES NUCLEAR REGULATORY COMMISSION'S
6 ADVISORY COMMITTEE ON REACTOR SAFEGUARDS
7

8
9 The contents of this transcript of the
10 proceeding of the United States Nuclear Regulatory
11 Commission Advisory Committee on Reactor Safeguards,
12 as reported herein, is a record of the discussions
13 recorded at the meeting.
14

15 This transcript has not been reviewed,
16 corrected, and edited, and it may contain
17 inaccuracies.
18
19
20
21
22
23

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION
+ + + + +
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS
(ACRS)
+ + + + +
US-APWR SUBCOMMITTEE
+ + + + +
MONDAY
JUNE 7, 2010
+ + + + +
ROCKVILLE, MARYLAND
+ + + + +

The Subcommittee convened at the Nuclear Regulatory Commission, Two White Flint North, Room T2B1, 11545 Rockville Pike, at 8:30 a.m., Dr. John Stetkar, Chairman, presiding.

SUBCOMMITTEE MEMBERS PRESENT:

JOHN W. STETKAR, Chair
DENNIS C. BLEY
MARIO V. BONACA
WILLIAM J. SHACK

1 NRC STAFF PRESENT:

2 NEIL COLEMAN, Designated Federal Official

3 HOSSEIN HAMZEHEE

4 BRAD HARVEY

5 JEFF CIOCCO

6 SESHAGIRI TAMMARA

7 NEBIYU TIRUNEH

8 YONG LI

9 SARAH TABATABAI

10 BOB TJADER

11 JOE DeMARSHALL

12 HIEN LE

13 ALSO PRESENT:

14 ATSUSHI KUMAKI

15 RYAN SPRENGEL

16 KAZUKI OKABAYSHI

17 FUTOSHI TANAKA

18 KEN SCAROLA

19 ETSURO SAJI

20 MAKOTO TAKASHIMA

21 HIROSHI HAMAMOTO

22

23

24

25

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

T-A-B-L-E O-F C-O-N-T-E-N-T-S

Opening Remarks.....4

NRC Staff Introduction.....6

US-APWR Design Certification Application, Tier 2, Ch.
2, Site Characteristics, MHI.....7

SER with Open Items, US-APWR, NRC staff.....37

US-APWR Design Certification Application, Tier 2, Ch.
16 Site Characteristics, MHI.....88

SER with Open Items, NRC Staff.....159

Subcommittee Discussion.....202

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

P-R-O-C-E-E-D-I-N-G-S

8:30 a.m.

CHAIRMAN STETKAR: The meeting will now come to order.

This is a meeting of the ACRS US-APWR Subcommittee. I'm John Stetkar, Chairman of the Subcommittee. Other ACRS members in attendance are William Shack, Dennis Bley and Mario Bonaca.

Neil Coleman of the ACRS staff is the Designated Federal Official for this meeting.

The purpose of our meeting is for the Subcommittee to review Chapters 2 and 16 of the NRC Safety Evaluation with open items for the US-APWR designed rollout. Chapter 2 is site characteristics and Chapter 16 is technical specifications.

Chapter 2 of the Design Control document focuses on the geography and demography, nearby facilities and postulated site parameters for the design, including meteorology and climatology geology, seismology and geotechnical parameters.

Chapter 16 includes required technical specifications that set forth the safety limits, limiting safety system settings, limiting conditions for operation and other limitation on facility operation deemed necessary to protect the public's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 health and safety.

2 The Subcommittee will gather information,
3 analyze relevant issues and facts and will formulate
4 proposed positions and actions as appropriate for the
5 full the Committee to deliberate.

6 The rules for participation in today's
7 meeting have been announced in the notice of this
8 meeting previously published in the *Federal Register*.

9 Later today there will be an opportunity for
10 stakeholder comments. We've received no additional
11 written comments or requests for time to make oral
12 statements from members of the public regarding
13 today's meeting. We have received no requests for
14 people to participate via a bridge phone line
15 regarding today's meeting.

16 A transcript of the meeting is being kept
17 and will be made available as stated in the *Federal*
18 *Register* notice. Therefore, we request that
19 participants in this meeting use the microphones
20 located throughout the meeting room when addressing
21 the Subcommittee.

22 Participants should first identify
23 themselves and speak with sufficient clarity and
24 volume so they may be readily heard.

25 We will now proceed with the meeting and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the presentations by the NRC staff and Mitsubishi
2 Heavy Industries.

3 And I'll turn it over to Mr. Hossein
4 Hamzehee from the staff. Hossein?

5 MR. HAMZEHEE: Yes, thank you. Good
6 morning. I am Hossein Hamzehee, the Branch Chief for
7 the US-APWR Projects.

8 As you mentioned, we're today to present
9 to you the results of the staff's review of Phase 2
10 Safety Evaluations with open items.

11 And as you mentioned earlier, we are
12 going to present the results of Chapter 2 Site
13 Characteristics and Chapter 16 Technical
14 Specification.

15 Chapter 2 will be presented this morning
16 and Chapter 16 will be covered in the afternoon. The
17 presentation will be made by our key members from
18 technical branches and projects. And we also have the
19 key members from Mitsubishi Heavy Industries that are
20 going to make their presentation for us. And, as you
21 know, usually they're going to be first made by MHI
22 and then followed by the staff's presentation.

23 And I would also like to thank you, the
24 Members, for your time today.

25 And with that, I would like to turn it to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Neil and maybe MHI.

2 Anything else, Neil, you would like to
3 add?

4 DESIGNATED FEDERAL OFFICIAL COLEMAN:
5 Nothing for me.

6 MR. HAMZEHEE: All right. So if you don't
7 have any questions for me, I'm going to turn it to
8 MHI.

9 CHAIRMAN STETKAR: Great. Thank you.
10 Make sure you have your name tag.

11 MR. KUMAKI: Okay. Shall I start.

12 MR. HAMZEHEE: Yes, please.

13 MR. KUMAKI: Good morning. My name is
14 Atsushi Kumaki from Mitsubishi Heavy Industries.

15 And I would like to present about the
16 Chapter 2 US-APWR CD.

17 Today's contents of my presentation
18 includes overview of the chapter and I will introduce
19 our site's characteristics for US-APWR, the design.

20 And number 3 is the major RAIs which we
21 exchanged with NRC and MHI for a long time.

22 And lastly, I will summarize my
23 presentation.

24 The first item is overview of chapter.
25 Title of the chapter is Site Characteristics. And we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 had some discussion with NRC using the term of
2 "characteristics" or "parameters." Site
3 characteristics means the actual features of US-APWR
4 design and the site parameter means postulated
5 features for the design. And we referred to 10 CFR
6 Part 52 description and we understand the difference
7 as to the term. So we collected some parts of using
8 this term "characteristics" or "parameters." And we
9 agreed with NRC, and then final our DCD Revision 2 is
10 agreed by both of us.

11 And the scope of chapter. This chapter
12 includes geological, seismological, hydrological and
13 the meteorological characteristics. And these
14 parameters, you know these characteristics is applied
15 for the standard design only. But most COL applicant
16 will confirm our site characteristics defined in DCD.

17 And if it's not bounded compared with on-site
18 conditions, COL applicant will provide their site-
19 specific qualification or evaluation.

20 And I'd like to explain about the key
21 site parameters. When we developed our DCD of the
22 US-APWR we leave out the UTT requirement documents
23 which is provided by Electric Power Research
24 Institute. We have no experience in the U.S. power
25 plant. We only have our Japanese plant only. So we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 researched and we researched what kind of condition
2 is good for the U.S. people or U.S. utilities. So we
3 leave out the EPRI document.

4 And our parameters bounds estimated is 75
5 percent to 80 percent of U.S. landmass.

6 And our site is defined as contiguous
7 real estate with legal right to control access by
8 individuals and to restrict land use.

9 Table 2.0-1 on our DCD Chapter 2 is a
10 summary identifying specific site parameters for the
11 US-APWR.

12 From this slide I would like to explain
13 our site characteristics, just to outline of
14 subsections.

15 And on the presentation of major RAIs, at
16 that time I will explain more detail. Right now I
17 would like to introduce each items only.

18 On Section 2.1 geography and demography
19 and 2.2 is nearby industrial, transportation and
20 military facilities. Those items is the exact site
21 specific characteristics, so we didn't define
22 anything under DCD standard design. That will come
23 to COL applicant.

24 And Section 2.3 meteorology we set some
25 conditions as: Winter precipitation and tornado wind

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 speed right from that.

2 Next slide is continuing of Section 2.3
3 meteorology, we set some values for the tornado like
4 radius of maximum rotational speed or rate of
5 pressure drop, maximum tornado pressure drop, like
6 from that. And those we reset atmospheric distortion
7 factors.

8 And also we set the extreme wind speed
9 for US-APWR on the standard design.

10 Next section is 2.4, describe above the
11 hydrologic engineering. We set groundwater elevation
12 level for flood or tsunami, and also we set the
13 rainfall rate.

14 Under Section 2.5 --

15 CHAIRMAN STETKAR: Can I stop you on --

16 MR. KUMAKI: Yes.

17 CHAIRMAN STETKAR: -- you on hydrologic
18 engineering.

19 MR. KUMAKI: Yes.

20 CHAIRMAN STETKAR: Groundwater elevation
21 1 foot below plant grade is a relatively high
22 groundwater level.

23 MR. KUMAKI: Yes.

24 CHAIRMAN STETKAR: Do any of the
25 buildings in the US-APWR design have safety related

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 equipment located more than 1 foot below grade level?

2 MR. KUMAKI: Actually, we facing that COL
3 application for Comanche Peak. And at that site the
4 groundwater level -- I'm sorry. I don't remember in
5 detail. But our design of building is applicable to
6 the ground.

7 CHAIRMAN STETKAR: But at this stage
8 we're talking about the design certification. And
9 the design certification specifies groundwater
10 elevation minimum of one foot below plant grade. So
11 my question is does the certified design contain any
12 safety related equipment that's located more than 1
13 foot below grade? For the certified side of it.
14 We'll discuss Comanche Peak when we get to the COL
15 for their site specific characteristics.

16 So I'm curious for the certified design
17 do you have any safety related equipment located more
18 than 1 foot below grade level?

19 MR. KUMAKI: No.

20 CHAIRMAN STETKAR: Nothing? Everything-
21 -

22 MR. KUMAKI: Over.

23 CHAIRMAN STETKAR: --is above ground?

24 MR. KUMAKI: Yes.

25 CHAIRMAN STETKAR: Are there any cables

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 routed through underground cable ducts.

2 MR. KUMAKI: It's all -- it's also no.

3 CHAIRMAN STETKAR: No underground cable
4 ducts?

5 MR. KUMAKI: Let me --

6 CHAIRMAN STETKAR: Below ground level.

7 MR. KUMAKI: Below 1 foot?

8 CHAIRMAN STETKAR: If it was a cable
9 duct, it would be more than 1 foot below ground.

10 MR. KUMAKI: I'm sorry. I don't know any
11 details.

12 CHAIRMAN STETKAR: Okay. Well, I'd like
13 to know that.

14 MR. KUMAKI: Okay.

15 CHAIRMAN STETKAR: Because there are many
16 sites in the United States that have groundwater
17 levels that are relatively high and you're allowing a
18 groundwater level to be only 1 foot below surface.

19 MR. KUMAKI: Yes.

20 CHAIRMAN STETKAR: Which is rather high.

21 And in those types of designs it's been necessary to
22 install continuous dewatering facilities to keep the
23 groundwater from coming in through building walls and
24 such. That's the concern about locations of safety
25 related equipment inside the buildings and if you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 have any underground cable ducts that have safety
2 related or cables that are important to safety. I'd
3 be interested to know about that.

4 DESIGNATED FEDERAL OFFICIAL COLEMAN: May
5 I suggest we get clarification on what plant grade
6 means?

7 MR. KUMAKI: Yes, sir.

8 DESIGNATED FEDERAL OFFICIAL COLEMAN:
9 Whether that's surface or, say, base of containment.

10 CHAIRMAN STETKAR: That's a good
11 question, Neil. Thanks for bringing that up.

12 I thought that I read somewhere in the
13 DCD that plant grade, indeed, was surface elevation.
14 But we should get that clarified because there may be
15 a misunderstanding whether it's basemat level or
16 actual ground surface.

17 MR. KUMAKI: Yes. My understanding that
18 plant grade means the level of a basemat.

19 CHAIRMAN STETKAR: Okay. Well, okay. I
20 hope that's clarified. Because I tried to read
21 through the DCD and I thought I found someplace where
22 plant grade was defined as surface level, in other
23 words ground surface.

24 MR. KUMAKI: And also, we are not
25 considering about the dewatering system for our

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 design.

2 CHAIRMAN STETKAR: Well, that was going
3 to be my second question, but I first wanted to
4 understand where the equipment and cables were
5 located.

6 Okay. Maybe we can get some
7 clarification on that.

8 MR. KUMAKI: Right. Understand.

9 CHAIRMAN STETKAR: Thank you.

10 MR. KUMAKI: You're welcome.

11 And so next Section 2.5, it's geology,
12 seismology, and geotechnical engineering. We set SSE
13 peak ground acceleration is 0.3g. This value is
14 taken from the Utility Requirement Document of EPRI.

15 And also we set certified seismic design
16 response spectra, it according to the Regulatory
17 Guide 1.60.

18 And the slope of stratum or surface
19 tectonic deformation.

20 MEMBER SHACK: Did you give any
21 consideration to using Regulatory Guide 1.208 to
22 define the spectra?

23 MR. KUMAKI: Pardon?

24 MEMBER SHACK: The performance-based
25 approach rather than the 1.60, the uniform hazard

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 approach?

2 MR. KUMAKI: I'm sorry.

3 Yes, we know the Regulatory Guide 1.208
4 and also we compare -- we refer both Regulatory
5 Guide. And we took the --

6 MEMBER SHACK: The 1.60?

7 MR. KUMAKI: Yes.

8 Okay. Next is a continuing of 2.5. We
9 said the subsurface stability, like, bearing capacity
10 and shear wave velocity. And we don't consider about
11 the liquefaction on our standard design.

12 And also next be the 2.5. We set the
13 settlement of the foundation and also tilt of the
14 foundation for the seismic Category 1 structures.

15 From this slide I will explain about the
16 major RAIs exchanging with NRC and MHI.

17 And these values and description of site
18 parameters are revised and added based on those RAIs.

19 The first point is Section 2.3
20 meteorology. We discussed about winter
21 precipitation, its normal and for extreme. And under
22 our DCD less than zero there are some confusing
23 description. So we examine our DCD on Chapter 2 and
24 finally we set the normal precipitation roof load is
25 50 pounds per square feet. And the extreme winter

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 precipitation roof load is 75 pounds per square feet.

2 This raises some confusing information, but finally
3 we set a normal 50 psf for normal and the 75 psf for
4 extreme.

5 And number 3 item. Forty-eight hour
6 probable maximum winter precipitation, we didn't set
7 any information on our Chapter 2 DCD Legend zero.
8 But we already considered for the design of this 36
9 inches. And so we discussed with NRC, and NRC
10 request us to clarify this design. And so we put
11 this 36 inches on this too.

12 And the fourth line is maximum tornado
13 line speed. Maximum rotational is 184 miles per hour
14 and the maximum translational 46 miles per hour. We
15 also didn't set those values on our DCD legend zero
16 on Chapter two. But we put those values on Chapter 3
17 of the DCD. And so NRC request us to put those
18 values taking from Chapter 3 and also put the Chapter
19 2.

20 Next 5 and 6 radius of maximum --

21 CHAIRMAN STETKAR: Just be careful when
22 you turn the paper with the microphone there. It
23 makes noises for our reporter.

24 MR. KUMAKI: I'm sorry.

25 This continuous 5 radius of maximum

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 rotational speed, and 6 is rate of pressure drop. We
2 also didn't set those values 150 feet and 0.5 psi/s
3 on our DCD Chapter 2. But those values are under
4 Chapter 3. So those values taken from Chapter 3 and
5 Chapter 2.

6 And number 7 is extreme wind speed. Our
7 characteristics is 155 mile per hour for 3 second
8 gusts at 33 feet above ground level. And NRC
9 recommend us to clarify our scope of these values and
10 parameters. Then we added the supplemental
11 information as we added those terms were based on 100
12 hour year return period was importance factor 1.15
13 for seismic Category I/II.

14 CHAIRMAN STETKAR: I'm going to ask the
15 staff about this also. I looked up hurricane ratings
16 and a Category IV hurricane has a sustained wind
17 speed between 131 miles per hour and 155 miles per
18 hour, a sustained wind speed. And I suspect that
19 gusts within a Category IV hurricane would probably
20 exceed 155 miles an hour. It's not clear. I'm not a
21 meteorologist. I don't know whether gusts within a
22 Category III hurricane would exceed 155 mils per
23 hour.

24 I'm curious how you arrived at a 155 mile
25 per hour 3 second gust as having a 100 year return

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 period. It seems that the return period for several
2 locations, especially in the south and southeast and
3 eastern coastal portions of the United States might
4 be considerably less than 100 years for that type of
5 gust.

6 What's your basis for that 100 year
7 return period for that magnitude of a wind gust?

8 MR. KUMAKI: We refer the several
9 information of the United States Meteorology
10 database. And, I'm sorry, I don't know in detail.
11 But we have some base data source for this
12 identification.

13 CHAIRMAN STETKAR: Okay. I guess if you
14 can find that data source, I'd appreciate it.

15 MR. KUMAKI: Yes.

16 CHAIRMAN STETKAR: Thanks.

17 MR. KUMAKI: I will provide later.

18 MR. HARVEY: This is Brad Harvey from the
19 staff.

20 Is this an appropriate time to answer
21 your question now?

22 CHAIRMAN STETKAR: Why don't we wait
23 until you guys come up.

24 MR. HARVEY: Understood.

25 CHAIRMAN STETKAR: We'll run through the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 issues then.

2 MR. KUMAKI: Okay. This slide is
3 describing about the chi/Q for main control room and
4 the technical support center.

5 We provided our presentation slide later
6 regarding this chi/Q discussion. So I'd like to skip
7 this slide now.

8 CHAIRMAN STETKAR: Okay.

9 MR. KUMAKI: Next section is 2.4
10 hydrologic engineering. We said the maximum
11 rainfall rate is 19.4 inches per hour and also 6.3
12 inches for five minutes for short-term.

13 We discussed about those values with NRC,
14 and we set some erroneous information on our DCD
15 legend zero like 19.4 inch per hour with importance
16 factor of 1.2 and also for the short-term we said the
17 same words, was importance factor of 1.2. And then
18 NRC recommended us what's the information or what's
19 the meaning of this importance factor of 1.2. So we
20 reconsider and re-examine our description or our
21 design. And so finally we removed those importance
22 factor of 1.2 from the DCD. So actually we set the
23 19.4 inch per hour for rainfall rate and also the 6.3
24 for short-term.

25 And then next these are Section 2.5

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 regarding subsurface stability. We set bearing
2 capacity for static dynamic, and also we set the
3 shear wave velocity. The discussion in RAIs for
4 those parameters is using the average or minimum, or
5 an average or a mean, or those using term.

6 For the static bearing capacity and the
7 dynamic bearing capacity we said the word "average"
8 on the DCD legend zero. But NRC request us or
9 comment us, we have to limit or qualify the limiting
10 condition. So we changed our words from "average" to
11 "minimum" for both static bearing capacity and
12 dynamic bearing capacity.

13 And also, we changed the number of
14 dynamic bearing capacity from 95,000 to 60,000. And
15 95,000 includes some conservatisms. And also we
16 analyzed our seismic design and finally we set the
17 60,000 for the minimum allowable bearing capacity.

18 And Item C is shear wave velocity. We
19 pull on the word of "mean," and also the mark of mean
20 before the 1,000 foot per second the mark. Okay. We
21 said that those are minimum shear wave velocity.

22 MEMBER BLEY: There is a little thing
23 bothering me and it goes from the slide before and
24 this one. When you get asked a question, you come
25 back and change language. Were these language

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 problems or -- you know, I'm a little concerned --

2 MR. KUMAKI: Yes.

3 MEMBER BLEY: -- that you're saying "Oh,
4 okay, whatever you want, we'll tell you."

5 Isn't the thing on the left the thing had
6 originally, or did you make a mistake, or was it a
7 matter of English language interpretation?

8 Can you, for this whole group, explain a
9 little of that?

10 MR. KUMAKI: The first one for static is
11 just a using of word.

12 MEMBER BLEY: Okay.

13 MR. KUMAKI: English program for our
14 Japanese.

15 And also we didn't limit any values. At
16 that time our design is -- I'm sorry. I say again.

17 For the dynamic bearing capacity, that
18 includes the program for using English and also the
19 values, analyzing the values.

20 And items C and A, the program of using
21 word.

22 MEMBER BLEY: And on the previous page
23 you have the importance factor. Did you have an
24 importance factor of 1.2, or didn't you? You know, I
25 mean suddenly this disappears and the numbers stay

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the same. So I'm a little confused.

2 MR. KUMAKI: This is just a mistake of
3 us.

4 MEMBER BLEY: Okay.

5 MR. KUMAKI: We didn't consider about the
6 importance factor.

7 MEMBER BLEY: Okay. But out of habit or
8 something you wrote it down that way?

9 MR. KUMAKI: Yes.

10 MEMBER BLEY: Go ahead.

11 MR. KUMAKI: Thank you.

12 So next the continuance of Section 2.5.

13 It's also talking about the shear wave velocity.

14 Yes, it is -- the program for the using of word,
15 English word and mean and also those marks. And so we
16 removed the word "mean" based on the RAI.

17 And the bottom one, too, is a discussion
18 about the settlement or differential settlement.
19 Those two values 6 inches and also 2 inches we
20 considered under our Chapter 3 DCD, but we didn't set
21 any information under Chapter 2. So we set those
22 values on the Chapter 2, the same as Chapter 3.

23 This a continuing of 2.5. These value
24 the 0.5 inches and also 1/2000 we set those values
25 under Chapter 3, but we didn't on Chapter 2. So we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 put those on Chapter 2.

2 MEMBER BLEY: My colleague and I just had
3 a little discussion.

4 It's surprising to me that one can claim
5 over the life of the plant you're going to have less
6 settlement differential than half an inch; that
7 that's not much. That just doesn't seem achievable
8 to me, but I'm not a civil engineer. It sounds
9 remarkable.

10 MR. KUMAKI: You're talking about 2?

11 MEMBER BLEY: J. J. Maximum
12 differential of settlement between buildings. And so
13 over time the buildings settle some and that you can
14 guarantee it's never going to be more than a half
15 inch, that much differential between two is
16 surprising to me. So, can you tell me a little about
17 the basis for that?

18 MEMBER BONACA: How did you get up to
19 that number?

20 MEMBER BLEY: When you claim that, then
21 you can have fairly rigid pipe connections between
22 buildings and assume there'll never be a problem
23 there.

24 MR. KUMAKI: Yes.

25 CHAIRMAN STETKAR: But the question is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 can anyone actually ever build a facility at an
2 actual site that will meet that specification?

3 MR. KUMAKI: Okay. I'm sorry. Let me ask
4 our engineer.

5 MEMBER BLEY: Yes. Yes. Okay. It's just
6 what do you do with it? If you can do that, you
7 design the connections one way. If you can't, you
8 design them with a little more flexibility.

9 MR. KUMAKI: Yes. Yes.

10 MEMBER BLEY: And it's troublesome to me.

11 MR. KUMAKI: Okay. I will go on.

12 MEMBER BLEY: Thanks.

13 MR. KUMAKI: You're welcome.

14 MR. SPRENGEL: I will point out that it
15 is the differential settlement, too. So, it's not
16 allowing any settlement, but it's --

17 MEMBER BLEY: Right.

18 MR. SPRENGEL: -- the two buildings
19 settle differently.

20 MEMBER BLEY: That's right. I think the
21 specification settlement of the site, which is fine,
22 as long as everything settles equally. But our
23 problem is none of the four of us who are in
24 attendance today are civil structural engineers. So
25 it just seems like a rather small value.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. KUMAKI: I understand. Okay.

2 And from this slide we are discussing
3 about chi/Q so I'd like to turn the mic to Mr.
4 Okabayshi.

5 MR. OKABAYSHI: My name is Okabayshi.

6 I'm going to talk about the atmosphere
7 dispersion factor chi/Q. We talked three main major
8 items during the discussions between the MHI and NRC.

9 So three major change from the original DCD as based
10 on the following RAIs.

11 First change is regarding the change of
12 chi/Q for 4-to-30 days. The second one, with having
13 change of source locations.

14 And third, description of additional
15 information.

16 So I will explain the detail for each
17 items.

18 This items is first item, change of chi/Q
19 for 4-to-30 days based on this RAI number.

20 This question is for staff finds that 4-
21 to-30 days chi/Q value for the MCR and the TSC were
22 not bounding for three out of the four sites; North
23 Anna, Clinton, Grand Gulf and Vogtle. And they are
24 not representation of the U.S. The staff suggested
25 that 4-to-30 days chi/Q value increase to ensure they

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 bound a reasonable number of sites.

2 Well, we agreed with that. So χ/Q for
3 4-to-30 days is be raised up to 1.5 times of the
4 prevent value of the DCD. So this graph shows the
5 relation between χ/Q over the distance between
6 source and receptor. So these symbols indicated
7 χ/Q at Grand Gulf and Clinton and North Anna and
8 Vogtle. So dense line is indicated present value of
9 DCD.

10 So we can suggest present value of DCD
11 doesn't bound χ/Q over the full sites. So we have
12 to increase the χ/Q to the 1.5 times over the
13 present value. This line is this.

14 So we can see new value bounded χ/Q of
15 the four sites.

16 Number 2 items is change of source
17 locations. Open item 02.03.04-1.

18 This question is posed some pathways
19 where the source location is inside the building,
20 imply indoor transport and dispersion. The ARCON96
21 are not appropriate for modeling indoor transport and
22 dispersion. If the reactivity in the spilled reactor
23 coolant is assumed to be discharged to the atmosphere
24 from the plant vent stack for the purposes of
25 modeling the MCR dose, then the plant vent should be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 identified as the release pathway. That's right. We
2 agreed.

3 So, we change the source locations,
4 number one.

5 Number two, to change to the plant vents.

6 So two accidents assumed here occurred
7 inside a building at location 1 and 2. But the
8 radioactive materials goes through inside building to
9 the plant vent and then it's discharged to the
10 atmosphere from the plant vent. So source location
11 should be plant vent. This is the realistic
12 situation.

13 CHAIRMAN STETKAR: Sir, before you change
14 that slide, where is the technical support center
15 located in these buildings?

16 MR. KUMAKI: About here, auxiliary
17 building.

18 CHAIRMAN STETKAR: It's inside the
19 auxiliary building?

20 MR. KUMAKI: Yes.

21 CHAIRMAN STETKAR: Oh, I didn't even know
22 that.

23 I went through the RAI and your
24 responses. And I think one of the concerns was
25 regarding a pipe break in the auxiliary building that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 caused a release inside the auxiliary building that
2 could transfer to the technical support center. And
3 the original analysis, I believe, spoke about a
4 single door that separated the auxiliary building
5 from the technical support center. The revised
6 analysis says that all of those releases will be
7 selectively drawn out the plant stack. And the only
8 way that they can enter the technical support center
9 is through the technical support center ventilation
10 intake. IS that correct?

11 MR. KUMAKI: I am sorry. I have to
12 change.

13 Technical support center is this
14 building.

15 CHAIRMAN STETKAR: So I understood it was
16 in the control building?

17 MR. KUMAKI: Access corridor.

18 CHAIRMAN STETKAR: Access hall. Is there
19 a single door that separates the auxiliary building
20 from --

21 MR. KUMAKI: Single door.

22 CHAIRMAN STETKAR: Single door?

23 MR. KUMAKI: Yes.

24 CHAIRMAN STETKAR: What is the basis for
25 saying that all of the releases will be removed

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 through the auxiliary building ventilation system and
2 that no releases can go through that door?

3 MR. KUMAKI: The accidental rupture in
4 the auxiliary building.

5 CHAIRMAN STETKAR: Because as I
6 understand it, the first analysis said there's a
7 potential propagation pathway from the auxiliary
8 building to the technical support center through a
9 door. And an analysis was done to evaluate the
10 potential dose via that pathway.

11 The revised analysis seems to say that
12 all of the releases in the auxiliary building will be
13 removed through the auxiliary building ventilation
14 system, distributed out through the plant stack and
15 the only pathway is then from the plant stack,
16 diluted in the atmosphere into the ventilation intake
17 for the technical support center. So I was curious
18 why that potential pathway through that door has been
19 eliminated in the revised analysis, if there is only
20 one door.

21 MR. KUMAKI: Yes. I will confirm the
22 design of our ventilation system of our technical
23 support centers.

24 CHAIRMAN STETKAR: Thank you.

25 MR. OKABAYSHI: I'm going to the next.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 The last change is this additional
2 information based on open item 02.03.04-6.

3 This question is DCD Tier 1 Table 2.1-1
4 and DCD Tier 2 Table 2.0-1 identify inleakage
5 locations for some, but not all, of the postulated
6 accidents and anticipated operational occurrences.
7 COL applicant should be directed to evaluate chi/Q
8 value for each inleakage location for each accident
9 release point and compare the resulting bounding
10 chi/Q value with the corresponding key site parameter
11 values.

12 That means that MHI is requested to
13 provide the information or all combinations of the
14 sources and receptors. So we agreed with that. So
15 the following information is described to DCD for COL
16 applicant. It's all combination of the source and
17 receptors for MCR or TSC as well as the shortest
18 distance combination used in the dose calculation.

19 We described in the DCD only the short
20 distance combination of chi/Q. And so we changed, we
21 changed all combinations of source and receptors.

22 So, to explain the detail of this. So
23 source location for each accident and location of
24 source and receptor showing in Table 1 and Figure 1
25 respectively.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 The next slide is Figure 1. This is
2 layout of all locations of source and receptors. So
3 symbol of the circles indicated the source location.

4 And the triangle symbol indicated the receptor
5 locations.

6 So if we take according to the triangle
7 symbol is missing to in here. So mistakes. So
8 better where we can know which receptor is
9 essentially intake or inleak from this table.

10 So MCR intake is the location of A, this
11 one and the MCR inleak location is B, C and D.

12 And TSC intakes C and inleak same point
13 of C.

14 So the nearest receptor to each source is
15 chosen for each of the MCR intake and MRC inleak and
16 TSC intake and inleak.

17 So the χ/Q of the nearest receptor to
18 each location is set to the old receptor in the same
19 group receptor. So we can determine χ/Q of all
20 combination of source and receptor.

21 Now next slide shows a source location of
22 accident releases. This shows a source and source
23 location for each accident.

24 So this number is source location in
25 Figure 1 of previous slide. And same table. This is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 also for other accident.

2 So this Table and Figure 1 of previous
3 slide provides the necessary information of all
4 combination of source and receptor. So from this
5 information DCD was revised as Revision 2.

6 Lastly, this slide is a summary of
7 Chapter 2. Three point summarize it here.

8 Chapter 2 defines site parameters of the
9 US-APWR standard plant and also identified important
10 site parameters.

11 COL applicant is to confirm that DCD site
12 parameters envelope site-specific parameters.

13 Table 2.0-1 is a summary identifying
14 specific site parameters for the US-APWR.

15 Thank you for your attention.

16 CHAIRMAN STETKAR: Thank you.

17 Do members have anymore comments or
18 questions for MHI?

19 MR. SPRENGEL: Let me run through real
20 quick what we're going to get for you.

21 CHAIRMAN STETKAR: Good deal.

22 MR. SPRENGEL: Clarification on plant
23 grade.

24 CHAIRMAN STETKAR: And clarification on
25 what is plant grade and whatever that is.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. SPRENGEL: Agreed. Agreed.

2 CHAIRMAN STETKAR: Include cable ducts.
3 Don't forget the cables.

4 MR. SPRENGEL: And safety-related
5 equipment.

6 CHAIRMAN STETKAR: Safety-related
7 equipment.

8 MR. SPRENGEL: If we can get any more
9 detail for you on using Regulatory Guide 1.6, see
10 what we can find.

11 John, again, on the 100 year?

12 CHAIRMAN STETKAR: 100 year 155 mile per
13 hour three second gusts exceedance frequency.

14 MR. SPRENGEL: Dennis, if we can find
15 anymore detail on communication, just what were
16 language issues and what were the reasons for those
17 changes.

18 And then I think we had lots of questions
19 on the 2.5 settlement differential.

20 CHAIRMAN STETKAR: Yes.

21 MR. SPRENGEL: And then the single door
22 for the technical support center.

23 CHAIRMAN STETKAR: Yes, the basis for
24 what that potential internal pathway might be.

25 MEMBER BONACA: I would have liked to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 hear some more explanation regarding why these values
2 chosen are bounding in your judgment. I wasn't clear
3 that I got a message clearly.

4 One observation this Committee has made
5 in the past is that in many respects these kind of
6 parameters come from past experience, limiting past
7 experience and the question is if in fact we're going
8 to have global warming and changes in the future, to
9 what extent will these parameters be, in fact,
10 acceptable or be a problem? I mean is there any
11 attempt on the part of Mitsubishi to build in a
12 little bit of margin or something that will call for
13 this database to be in fact bounding in the future?

14 MR. SPRENGEL: I understand.

15 CHAIRMAN STETKAR: Are you speaking,
16 Mario, primarily are you concerned about
17 meteorological parameters?

18 MEMBER BONACA: Yes.

19 CHAIRMAN STETKAR: Rainfalls, wind
20 speeds, things like that.

21 MEMBER BONACA: Yes. Those parameters
22 which are affected very much by --

23 CHAIRMAN STETKAR: Yes. Again,
24 basically, is there any consideration of changing
25 climatological effects been considered.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Anything else?

2 Well, good. Thank you very, very much.

3 We are ahead of schedule.

4 Is the staff prepared? We'll just charge
5 through --

6 MR. HAMZEHEE: Yes.

7 CHAIRMAN STETKAR: -- doing this Chapter
8 2.

9 MR. HAMZEHEE: Okay.

10 CHAIRMAN STETKAR: We are constrained, I
11 believe, this is a *Federal Register* meeting that we
12 cannot begin Chapter 16 until after lunch. So we may
13 finish early this morning, but let's proceed with
14 Chapter 2 and see how far we get.

15 MEMBER BLEY: Is that true for a
16 Subcommittee meeting.

17 MR. HAMZEHEE: For a Subcommittee we can
18 keep going if everyone is available.

19 CHAIRMAN STETKAR: If everyone is -- yes.
20 And I guess because we haven't received any requests
21 for -- there's no one on the line. So maybe we can -
22 -

23 MR. CIOCCO: But if that's the case, we
24 need to know so that we can inform --

25 CHAIRMAN STETKAR: Yes. Let's see where

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 we are. I suspect that we probably will get to at
2 least MHI's presentation on 16 before lunch.

3 MR. HAMZEHEE: Okay. We'll notify the
4 staff to come down as well.

5 CHAIRMAN STETKAR: Yes, you may want to
6 listen in. I doubt that we'll get to the staff's
7 presentation on 16 before lunch.

8 MR. SPRENGEL: And we're not prepared to
9 facilitate that. I think we can maybe start the
10 afternoon session earlier.

11 CHAIRMAN STETKAR: We have a problem
12 because I have a meeting over the lunch hour, so I
13 can't really reorganize the lunch.

14 MR. SPRENGEL: Okay. But I'll follow-up
15 on when they will --

16 CHAIRMAN STETKAR: Okay. Okay.

17 MR. SPRENGEL: When they will be here.

18 CHAIRMAN STETKAR: That's fine.

19 MR. CIOCCO: Okay. Are we ready? Okay.

20 Good morning. My name is Jeff Ciocco.
21 I'm the Lead Project Manager for the US-APWR Design
22 Certification. I'm clueing in today as well for the
23 Chapter 2 Lead Project Manager for Chapter 2 and for
24 Chapter 16.

25 We're going to present to you our Safety

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Evaluation Report with open items for Chapter 2 this
2 morning.

3 Okay. What we're going to talk about is
4 I'll go through, as you can see our staff review
5 team.

6 I have a brief overview of the design
7 certification application, which is really just
8 Chapter 2, not the entire application.

9 A brief discussion of the open items that
10 we found in our review.

11 And then we're going to go through each
12 of the specific sections, each of the five sections
13 and we're going to specifically cover the open items.

14 We have a list of the acronyms for you there.

15 Let me introduce to you our staff review
16 team.

17 For Sections 2.1 and 2.2 is Seshagiri.

18 Brad Harvey is going to cover Section 2.3
19 meteorology.

20 Nebiyu is going to cover hydrology.

21 And Yong Li is going to cover the geology
22 and seismology in 2.5

23 I'm the lead Project Manager, and Mike
24 Magee is on leave. He's our Chapter 2 Lead for the
25 design certification as well as the Reference COLA

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 application.

2 This is just the overview of what the
3 staff found in our review of Chapter 2. And they're
4 going to cover these specifically, but these are the
5 sections in Chapter 2.

6 What we have in this column is a total of
7 the number of questions, we call them the RAIs,
8 request for additional information, that we asked.
9 And we have a total of 52. And you'll see the unique
10 numbers, and you saw it during Mitsubishi's
11 presentation. There was very unique numbers that
12 they used. So those totaled 52, with the majority
13 being in the meteorology area. And of those what the
14 Safety Evaluation Report that we provided to you, we
15 have five open items which we're close. Actually,
16 MHI has responded to these and we're going to be
17 evaluating those responses after this meeting in
18 Phase 4. And then we'll come back to you in what we
19 call our Phase 5 with a complete SE and no open
20 items.

21 This is a summary. I don't want to go
22 into detail because each of our reviewers is going to
23 cover them. But you can see, these are the four open
24 items that came out of meteorology as far as the
25 containment release, the inleakage receptors, chi/Q

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 and then one on the bearing capacity values in
2 Section 2.5

3 And so of the reviewers, we're going to
4 cover each of these areas.

5 We're going to cover each of these areas.
6 MHI has covered these already, how they responded to
7 them. And we're going to let our technical staff
8 cover those as well.

9 So I'm going to turn for Section 2.1 and
10 Section 2.2

11 MR. TAMMARA: My name is Seshagiri
12 Tammara. I am with the Office of New Reactors with
13 the Division of Environmental and Accidents Group.

14 I reviewed the Section 2.1 and 2.2.

15 2.1 covers the geography and demography.

16 Usually these are the site-specific information
17 where after the selection of the design they will
18 furnish all the information with respect to where the
19 site is located. They give you the description of
20 the area and also they will contain what is the
21 restricted area, allows for the exclusion area and
22 with authorities they have and what they want, and
23 what mineral rights they have.

24 And in relation to that one they will
25 provide the population distribution within 50 miles

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 of the site taking the latest population available
2 and projecting to the life of the plant. And they
3 will address mainly the density and where the solid
4 site is permissible for the application.

5 And leaving out the design-specific,
6 therefore the COL applicant will provide all the
7 information in the COL application.

8 In Chapter 2 all the nearby industrial,
9 transportation and military facilities are addressed
10 with respect to potential leaks or accidents that may
11 potentially affect the operation of the plant. And
12 those are mainly addressed to what are primary
13 radius, all the roadways, airways and also waterways
14 that they have and what they carry potential
15 hazardous materials and what are the potential
16 accidents, and what will be the impact on the
17 operation of the plant.

18 In addition to that one, they will
19 evaluate the aircraft accidents also, I mean the
20 airports. But it will be provided in 3.6.

21 So these are also very site-specific
22 information and not the design information, therefore
23 the COL applicant will address the site-specific
24 information in their COL application. So these are
25 not dependent on the design of DCD.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER BLEY: Let me ask just one
2 question about this.

3 MR. TAMMARA: Yes.

4 MEMBER BLEY: Because it doesn't make
5 sense.

6 When you review at this stage, do you
7 look for some basic hardening of areas of the site
8 that would cover most of these local things that
9 might happen, or is that just -- you don't think
10 about it at all until you see it all.

11 MR. TAMMARA: No. Because we do not know
12 what the site is.

13 MEMBER BLEY: Okay.

14 MR. TAMMARA: And the description will be
15 valued. But we are know that the applicant's
16 statement and the designer's statement, these all
17 will be addressed by COL applicant because we have to
18 say, yes, okay we agree to that.

19 So that is my presentation.

20 MR. HARVEY: Good morning. My name is
21 Brad Harvey. I am a meteorologist in the Siting and
22 Accident Consequence Branch with the Division of Site
23 and Environmental Reviews. And now we're discussing
24 SER Section 2.3 meteorology.

25 Section 2.3 typically involves site-

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 specific information such as regional climatology,
2 local meteorology, on site meteorological
3 measurements program, short-term atmospheric
4 dispersion estimates for design-basis accident
5 releases and long-term atmospheric dispersion
6 estimates for routine releases.

7 The US-APWR DCD states the COL applicant
8 is to provide this information as part of the COL
9 application. The staff finds this to be acceptable.

10 Meteorological site parameters. Tier 1
11 Table 2.1-1 and Tier 2 Table 2.0-1 of the US-APWR DCD
12 identifies climatic and atmospheric dispersion site
13 parameters. These site parameters are the postulated
14 meteorological features assumed for the site which
15 the applicant used to design its facility.

16 The climatic site parameters were
17 selected to ensure the facility is being designed
18 such that potential threats from the physical
19 characteristics of a potential site, such as a
20 regional climatic extremes and severe weather will
21 not pose an undue risk to the facility in accordance
22 with GDC-2.

23 The accident atmospheric dispersion site
24 parameters were selected to help demonstrate that the
25 radiological consequences of design-basis accident

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 off-site and in the control room and technical
2 support center meet radiation dose criteria specified
3 in 10 CFR 52.47 and CDC-19. The continual release
4 atmospheric dispersion site parameters were selected
5 to help demonstrate that calculated off-site
6 concentrations and dose consequences of routine
7 airborne radioactive releases meet criteria specified
8 in 10 CFR Part 20 and Appendix R to 10 CFR Part 50
9 respectively.

10 CHAIRMAN STETKAR: Brad, can I interrupt
11 you for just a second. And I have to apologize. I'm
12 reading through notes here that are not organized
13 very well.

14 Actually, I had a question for Seshagiri.
15 Is he still here? It derived out of Section 2.2 of
16 the SER, but it's actually a more generic question.

17 In Section 2.2.3 of the DCD there's a
18 statement that says "The determination of design-
19 basis events followed the probabilistic and
20 predictable approach to identify ten to the minus
21 seven per year or greater occurrence rate with
22 potential consequences serious enough to affect the
23 safety of the plant. Where data may not be available
24 to permit accurate calculations, a ten to the minus
25 six per year occurrence rate can be utilized when

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 combined with reasonable qualitative arguments."

2 That's a basis for screening out
3 potential near-site events. And it will apply to all
4 of the sections, but it actually appears in Section
5 2.2. That's why I wanted to ask the question in that
6 context.

7 Does the staff accept those screening
8 criteria? Because they're not consistent with
9 guidance in Regulatory Guide 1.200 which states that
10 it's recognized for those new reactor designs with
11 substantially lower risk profiles, for example
12 internal events, core damage frequency below ten to
13 the minus six per year the quantitative screening
14 value should be adjusted according to the relative
15 baseline risk value. In other words, if your total
16 core damage is on the order of ten to the minus six
17 per year, it makes absolutely no sense whatsoever to
18 screen out events whose frequency could be comparable
19 to the total core damage frequency.

20 So I was curious why the staff has not
21 commented on those screening criteria in Section 2.2.
22 of the DCD. In fact, the staff has disallowed the
23 use of those screening criteria for at least one
24 other new plant design that we've reviewed, or that
25 we're in the process of reviewing.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. TAMMARA: This is Seshagiri Tammara
2 for Chapter 2 review.

3 Whenever we evaluate the site hazards
4 within five miles, we look at what are the potential
5 accidents for that one. And if data shows that the
6 frequency of transportation of hazardous material on
7 the roadways, if they are provided, is lower than ten
8 to the four minus seven. That is acceptable.

9 CHAIRMAN STETKAR: Why is that
10 acceptable? I don't know --

11 MR. TAMMARA: I mean, that is the --

12 CHAIRMAN STETKAR: That's the traditional
13 -- let me interrupt here.

14 MR. TAMMARA: Yes.

15 CHAIRMAN STETKAR: That is the
16 traditional value for operating plants in the United
17 States that generally have core damage frequencies in
18 the order of ten to the minus five per year. That
19 would be less than one percent of the approximate
20 total core damage frequency.

21 If the total core damage frequency for a
22 new plant design is on the order of ten to the minus
23 seven, and I don't know what the projected core
24 damage frequency for the US-APWR, but we have indeed
25 seen several new plants come in with projected core

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 damage frequencies considerably lower than ten to the
2 minus seven.

3 If the total core damage frequency is on
4 the order of ten to the minus seven, does it make
5 sense to screen out something that could be as large
6 as everything else -- everything else in total?
7 LOCAs, transients, internal fires; everything else,
8 does it make sense to screen that out?

9 MR. TAMMARA: That will be summarized in
10 Chapter 19. But whenever the individual facilities
11 are concerned in Chapter 2, we are looking at that
12 particular external hazard and if that frequency is
13 greater than ten to the power minus six, then that
14 evaluation goes into the core damage frequency, that
15 accident will be covered in evaluating the total
16 frequency.

17 So -- but if the individual hazard is
18 less than ten to the four minus seven, it is not -- I
19 mean I'm not saying required, but it is acceptable
20 not to consider for the total probability.

21 CHAIRMAN STETKAR: I'm asking the staff
22 now why is that acceptable, especially in light of
23 the fact that the staff already for another new plant
24 design center is on record saying that that is not
25 acceptable? The staff is on record saying that that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 screening is not acceptable in the licensing process
2 for at least one other new design center. And I'm
3 not going to name that design center because it's not
4 relevant to this particular proceeding. You can find
5 it out, or I'll tell you which one off-line.

6 MEMBER BONACA: The elimination of that
7 contributor, really, changes the whole risk profile
8 of the plant.

9 CHAIRMAN STETKAR: That's right. And the
10 staff, indeed, in the screening analysis that are in
11 progress for at least one other new design center,
12 has explicitly said that those numerical values that
13 are cited in this DCD are not acceptable. That the
14 screening values should, indeed, account for the
15 published core damage frequency and there be some
16 confidence that the screening has been performed as a
17 small fraction of that published core damage
18 frequency.

19 So there seems to be an internal
20 discrepancy here within the staff as far as what
21 acceptable screening will be applied from design
22 center to design center.

23 Maybe we should just leave it at that
24 unless Hossein or Jeff has something to add.

25 MR. HAMZEHEE: John, this is Hossein

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Hamzehee from the staff.

2 I think this is not the right audience
3 for the discussion that you have. Because you're
4 right, you have some valid concern.

5 CHAIRMAN STETKAR: Okay.

6 MR. HAMZEHEE: It depends on the risk
7 profile of a given design. You got to be careful
8 what the other contributors are. But what we need to
9 do is to go back and when we are looking at Chapter
10 19, the PRA and risk assessment to see how they have
11 incorporated this portion of the risk. And then try
12 to follow-up on that.

13 CHAIRMAN STETKAR: Well, except you can't
14 necessarily divorce the two that easily, Hossein.
15 Because what we're doing now is we're running a
16 Safety Evaluation on Chapter 2 of this design control
17 document. And Chapter 2 explicitly has those numbers
18 in there as basically acceptance criteria. So it's
19 difficult to say well we'll accept those numbers in
20 Chapter 2 and somehow later work it out in the
21 context of Chapter 19. Because Chapter 19 is really
22 an evaluation of all the potential contributors.
23 Chapter 2 is setting the grounds by which you could
24 potentially screen out some of those contributors.

25 MR. HAMZEHEE: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: And if I were an
2 applicant and I screened out something as less than
3 ten to the minus seven and then in Chapter 19 you
4 come back and say well why didn't you evaluate this?
5 You said well I was allowed to screen it out
6 according to the accepted criteria in Chapter 2.

7 So, I think we do need to address it in
8 the context of Chapter 2.

9 MR. HAMZEHEE: Yes. And let us get back
10 to you.

11 CHAIRMAN STETKAR: Okay.

12 MR. HAMZEHEE: But again, sometimes from
13 the design prospective something could be acceptable,
14 but then when you do the risk assessment, that could
15 become a risk contributor or it could be one of your
16 risk significant contributor.

17 CHAIRMAN STETKAR: That's what we're
18 saying.

19 MR. HAMZEHEE: Yes.

20 CHAIRMAN STETKAR: The only thing that
21 I'm bringing to the forefront is that there are two
22 specific numbers --

23 MR. HAMZEHEE: Yes.

24 CHAIRMAN STETKAR: -- cited in Section
25 2.2.3 of the DCD. And if the staff accepts Chapter 2

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 of the DCD, those are staff approved accepted
2 numbers. And if we, the agency, do not agree that
3 those numbers should apply, we should indeed do
4 something about it within the context of Chapter 2.

5 MR. HAMZEHEE: Yes.

6 CHAIRMAN STETKAR: Because otherwise they
7 will be accepted.

8 MR. HARVEY: Mr. Chairman, in defense of
9 the applicant, I'd like to point out that those
10 numbers are in the staff's Standard Review Plan for
11 Section 2.2.3.

12 CHAIRMAN STETKAR: Yes. Good thanks.
13 It's good to have on the record.

14 MR. HARVEY: All right. So essentially
15 we've already accepted that because it's in our
16 Standard Review Plan. And maybe it's the Standard
17 Review Plan that needs to --

18 CHAIRMAN STETKAR: That's probably true,
19 Brad, although I'll tell you from our experience with
20 at least one of the other new design centers the
21 staff indeed has taken the position that those
22 numbers should be changed in the Standard Review Plan
23 for consistency with the guidance in the current
24 revision of Regulatory Guide 1.200, which is more of
25 a relative risk rather than an absolute numerical

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 value type guidance. And indeed, the staff has
2 already taken that position and is applying it to
3 their review of one of the other new design centers.

4 So --

5 MEMBER SHACK: Now, in all fairness,
6 since they don't have risk metrics yet for the new
7 reactors, it's a little difficult to come up with
8 those answers. But I think John's point is you could
9 at least take the numbers out of here and then we'll
10 settle it at the COL basis --

11 CHAIRMAN STETKAR: Right. Settle at the
12 COL basis consistently across all of the design
13 centers.

14 MEMBER SHACK: Right.

15 CHAIRMAN STETKAR: One of the things I'm
16 looking for, obviously is I'm not trying to penalize
17 US-APWR because they have these particular numbers at
18 the moment in their design control document. I know
19 where they came from. I want to make sure that we as
20 an agency are applying consistent review and
21 acceptance criteria across the whole fleet of new
22 reactors. That just because one design center has
23 applied one set of acceptance criteria, I don't want
24 to see another design center use a different set of
25 acceptance criteria. That isn't quite fair.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Okay? Thanks. As I said, I brought it
2 up in the context of Section 2.2 but applies equally
3 well to screening of meteorological events or any
4 other type of hazards.

5 Sorry to interrupt you, Brad. Go on.
6 Continue.

7 MR. HARVEY: Okay. A COL applicant needs
8 to demonstrate that its meteorological site
9 characteristics fall within the US-APWR meteorology
10 site parameters pursuant to 10 CFR 52.79(d)(1).
11 Should the meteorological site characteristics not
12 fall with the US-APWR meteorological site parameters
13 the COL applicant must provide supporting
14 justification that the proposed facility is still
15 acceptable at the proposed site.

16 The staff evaluated the US-APWR
17 meteorological site parameters in accordance with the
18 Standard Review Plan to ensure they're representative
19 of a reasonable number of sites that have been or may
20 be considered within a COL applications. Details
21 regarding this evaluation will be presented during
22 the next several slides.

23 Climatic Site Parameters. The US-APWR
24 DCD presents climatic site parameters related to
25 winter precipitation for roof load design, tornados,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 extreme wind speed other than in tornado, and ambient
2 design air temperature.

3 The applicant's winter precipitation site
4 parameters are used to determine a winter
5 precipitation live loads on the roofs of seismic
6 Category I structures as discussed in the DCD Chapter
7 3. The staff compared the applicant's winter
8 precipitation site parameter values against snowfall
9 data recorded at weather stations located throughout
10 the contiguous United States and found that the
11 applicant's site parameters bounded most weather
12 stations. The staff therefore concluded that their
13 is reasonable assurance that the applicant's winter
14 precipitation site parameters values can be expected
15 to be representative of a reasonable number of
16 potential COL sites. The staff finds this
17 acceptable.

18 The staff reviewed the applicant's
19 tornado site parameter values by comparing them to
20 design-basis tornado characteristics specified in
21 Revision to Regulatory Guide 1.76. The staff found
22 that the tornado site parameter values chosen by the
23 applicant are the same as the tornado intensity
24 Region I design-basis tornado characteristics
25 specified in Regulatory Guide 1.76 where Region I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 represents the central portion of the United States
2 where the most severe tornados typically occur. The
3 staff finds this acceptable.

4 CHAIRMAN STETKAR: Brad?

5 MR. HARVEY: Yes?

6 CHAIRMAN STETKAR: Move Seshagiri's thing
7 over there. I mean when you hit it hits the
8 microphone.

9 MR. HARVEY: Okay. The staff reviewed
10 the applicant's extreme wind speed site parameter
11 value by comparing to wind loading design criteria
12 presented in ASCE 07-05, which is the American
13 Society of Civil Engineers Standard for the minimum
14 design load for buildings and other structures. The
15 staff found that US-APWR extreme wind speed site
16 parameter value bounds the ASCE 07-05 wind loading
17 design criteria for the continental United States.

18 CHAIRMAN STETKAR: Now is the time to
19 talk about that 155 mile gust.

20 MR. HARVEY: Yes. Yes. That comes from
21 this ASCE 07-05 standard, which is a contour of wind
22 speed plots against the continental United States.
23 And what they've chosen was a 100 year return period.
24 And hurricanes are included in the drawing of those
25 wind plots.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: And those plots
2 actually do -- I guess if you take the entire
3 contiguous continental United States and say that if
4 you're extruding for something like 80 percent of the
5 land mass, that's probably true. It just might be
6 that you can't build one of these plants anywhere
7 near the southeast coast of the United States.

8 MR. HARVEY: Well, I do think the 155
9 miles an hour that they've chosen, I think pretty
10 much does envelop the entire --

11 CHAIRMAN STETKAR: Southeast coast also?

12 MR. HARVEY: Including the southeast,
13 yes.

14 CHAIRMAN STETKAR: How many year return
15 period --

16 MR. HARVEY: A 100 year.

17 CHAIRMAN STETKAR: -- on Category IV --
18 Category III to Category IV hurricanes?

19 MR. HARVEY: It depends where you're
20 located, but yes.

21 CHAIRMAN STETKAR: Okay. And what was
22 that reference?

23 MR. HARVEY: ASCE 07-05.

24 CHAIRMAN STETKAR: 07-05. Thank you.

25 MEMBER BLEY: There's the piece of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 way we handle extreme events, not just these but
2 others, where we tend to rely on 100 year return
3 periods which doesn't seem consistent with the way we
4 deal with other low probability events. And that's
5 the chance of ten to the minus two per year. And we
6 don't say what happens if you go beyond that where
7 most other things, and you heard the discussion
8 before we're talking events of ten to the minus six,
9 ten to minus seven per year are less. How do we
10 reconcile that?

11 MR. HARVEY: If you look at the tornado.

12 The tornado design- basis is ten to the minus seven
13 year event. Okay. So the tornado will envelope the
14 extreme wind speed.

15 Now, the extreme wind speed there's
16 different subsequent -- what's the right word? Other
17 loads combine differently for the 100 year return
18 wind speed as opposed to the tornado, and it's
19 different load factors.

20 MEMBER BLEY: Yes.

21 MR. HARVEY: But the wind is basically a
22 plant design for a ten minus 7, or intended to be.

23 MEMBER BLEY: So in a sense to you that
24 is a sound --

25 MR. HARVEY: Yes. The winter

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 precipitation we talked about the normal and the
2 extreme.

3 MEMBER BLEY: Yes.

4 MR. HARVEY: The normal is, again, a 100
5 year return. The extreme is not to calculated to be
6 ten to the minus seven, but it's some additional
7 margin above the 100 year return period for that.
8 But the ambient design temperature, those are based
9 on 100 year return period.

10 MEMBER BLEY: Thanks.

11 CHAIRMAN STETKAR: Go ahead.

12 MR. HARVEY: Consequently, staff
13 concluded that the applicant's maximum wind spend
14 site parameter values represented a reasonable number
15 of sites that may be considered with COL
16 applications. Staff finds this acceptable.

17 CHAIRMAN STETKAR: Brad?

18 MR. HARVEY: Yes?

19 CHAIRMAN STETKAR: Did you get air
20 temperature?

21 MR. HARVEY: I'm doing this next.

22 CHAIRMAN STETKAR: Okay. Sorry. I was
23 mumbling.

24 MR. HARVEY: Okay. The applicant
25 provided zero percent exceedance or 100 percent

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 exceedance air temperature site parameters values for
2 use in the design and sizing of plant cooling
3 equipment and for evaluating plant structures under
4 severe environmental conditions. The zero percent
5 exceedance values are historic high and low values,
6 whereas the one percent exceedance value are values
7 that are expected to be exceeded on average 88 hour
8 per hour since there are 8,768 hours in a typical
9 non-leap year.

10 The staff reviewed the applicant's zero
11 percent and one percent exceedance air temperature
12 site parameter values by comparing them against
13 temperature data compiled by the American Society of
14 Heating Refrigeration and Air Conditioning Engineers
15 or ASHRAE, for over 600 weather stations scattered
16 throughout the continental United States. The staff
17 found that the applicant's zero percent and one
18 percent exceedance air temperature site parameter
19 values found in most of the weather stations listed
20 in the ASHRAE database. The staff, therefore,
21 concluded that there is reasonable assurance that the
22 applicant's ambient design air temperature site
23 parameter values can be expected to be representative
24 of a reasonable number of potential COL sites. The
25 staff finds this acceptable.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: Brad, let me ask you,
2 I read through this section and I got confused, I
3 think.

4 When you discuss in Section 2.3.4 the
5 zero percent exceedance non-coincident wetbulb
6 temperature, you report the results from your
7 independent survey from all of the weather stations.

8 MR. HARVEY: Yes.

9 CHAIRMAN STETKAR: And in the SER it
10 says: "The staff found the applicant's proposed zero
11 percent exceedance non-coincident wetbulb temperature
12 site parameter value of 30 degrees C, 86 degrees
13 Fahrenheit was exceeded at approximately 21 percent
14 of the weather stations, primarily in the southeast."

15 MR. HARVEY: Yes.

16 CHAIRMAN STETKAR: "Nonetheless, because
17 the applicant's zero percent has not been exceeded at
18 79 percent of the stations throughout the contiguous
19 U.S., the staff accepts the applicant's" value,
20 basically.

21 It's surprising to me that 21 percent of
22 the weather stations in the United States report a
23 wetbulb temperature of 86 degrees are higher. That's
24 pretty humid. And the reason I got confused is that
25 later it says the one percent exceedance non-

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 coincidence maximum wetbulb temperature of 27.2
2 degrees C, 81 degrees Fahrenheit was exceeded at only
3 one percent of the weather stations throughout the
4 contiguous U.S.

5 Well, if the zero percent exceedance of
6 86 degrees was exceeded at 21 percent of the weather
7 stations, it would seem that a much higher percentage
8 would have exceeded 81 degrees less humid conditions.

9 MR. HARVEY: Well, the 81 degrees will
10 occur up to 88 hours per year. That's the definition
11 of the one percent.

12 The zero percent is supposed to be
13 historic maximums.

14 CHAIRMAN STETKAR: Yes. But you would
15 expect a larger number of weather stations to exceed
16 the less humid conditions compared to the more humid
17 conditions, wouldn't you?

18 MR. HARVEY: No. You're comparing
19 historic versus occurs 88 hours in a given year. So
20 it's hard to --

21 CHAIRMAN STETKAR: I guess maybe I don't
22 understand how those calculations are done.

23 MR. HARVEY: The 88 is basically the
24 highest number that's been recorded in this database
25 over the last 25 years.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: Okay.

2 MR. HARVEY: And that's been exceeded at
3 21 percent. But the 81 that can be recorded up to
4 70/80 hours in a given year, year after year after
5 year and still meet that criteria.

6 CHAIRMAN STETKAR: So it actually means
7 kind of different things. Okay.

8 MR. HARVEY: Yes, they are very
9 different.

10 CHAIRMAN STETKAR: Okay. Okay.

11 MR. HARVEY: And it's very easily
12 confused.

13 CHAIRMAN STETKAR: Okay. Thanks. That
14 helps me because I apparently was confused about what
15 they meant.

16 Can you explain in the DCD for the zero
17 percent exceedance, the 86 degrees there's a
18 qualifier in there. It says: "86 degree non-
19 coincidence wetbulb historical limit excluding peaks
20 less than two hours." What does that mean? If it's
21 never been --

22 MR. HARVEY: Now, meaning that they could
23 withstand a short duration exceedance of that 88.

24 CHAIRMAN STETKAR: What's the basis for
25 that? And I was going to ask Mitsubishi, but I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 thought I'd ask you first because I knew I probably
2 wasn't understanding the criteria?

3 MR. HARVEY: Yes. In fact, that's another
4 reason why the 21, because we only looked at the
5 highest --

6 CHAIRMAN STETKAR: Yes.

7 MR. HARVEY: -- as opposed to the two
8 hour values. If you assume that's a two hour
9 average, it needs to exceed the 88, then you're going
10 to get --

11 CHAIRMAN STETKAR: That's right. Well
12 what I hung up on was that I thought I understood the
13 86, and apparently I understood that one correctly.
14 But my curiosity is what the criteria -- why is this
15 2 hour exceedance of even --

16 MR. HARVEY: That came out of the EPRI
17 URD has that criteria in it.

18 CHAIRMAN STETKAR: It's funny, I haven't
19 seen it in any of the other --

20 MR. HARVEY: It is in some of the others.

21 CHAIRMAN STETKAR: Some of the others?
22 Okay. I checked two of them and I couldn't find it
23 there.

24 MR. HARVEY: Yes, it is in some of the
25 others. Honestly, I'm trying to give a good answers.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

CHAIRMAN STETKAR: Yes.

MR. HARVEY: The engineers are the ones who choose the statistics they want to design to. And I just -- my job is to make sure that they're reasonably bound.

CHAIRMAN STETKAR: No, I understand that.

MR. HARVEY: So I don't have a good answer for you.

CHAIRMAN STETKAR: I have a question for Mitsubishi then. This implies that the plant can withstand a wetbulb temperature of greater than 86 degree Fahrenheit for two hours without any detrimental effects from ventilation. Well, that sounds to me like a design criterion for the ventilation systems or environmental qualifications of equipment. It's probably not appropriate to discuss that in regards to Chapter 2, but it certainly seems to apply to the review of Chapter 9 where we do talk about the ventilation systems and the environmental control systems.

So if you could, just put it in your notes that when we get to Chapter 9 I'm going to be curious about what that two hours really means

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 because it does sound like it's, as Brad mentioned,
2 related to design criteria for the ventilation
3 systems.

4 Thanks, Brad.

5 MR. HARVEY: Thank you.

6 Next slide, please.

7 Short-term dispersion site parameters for
8 design-basis accident releases. Exclusion area
9 boundary or EAB and the outer boundary or low
10 population zone, or LPZ, atmospheric dispersion for
11 chi/Q site parameters are used in DCD Chapter 15 to
12 help demonstrate that the off-site radiological
13 consequences of accidents meets specified radiation
14 dose guidelines as specified in 10 CFR 52.47.

15 The staff reviewed the applicant's EAB
16 and LPZ chi/Q site parameter values by comparing them
17 with corresponding site characteristic values
18 identified in the four approved early site permit
19 applications which are Clinton, Grand Gulf, North
20 Anna and Vogtle. The staff found that the
21 applicant's EAB and LPZ chi/Q site parameter values
22 bound the corresponding site characteristics for
23 three of the four ESP sites. Consequently, the staff
24 finds that the applicant's EAB and LPZ chi/Q site
25 parameter values should bound a reasonable number of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 sites that may be considered within a COL
2 application. Staff finds this acceptable.

3 CHAIRMAN STETKAR: I know you looked at
4 the four sites that submitted early site permit
5 applications. Did you look at all at the reference
6 COLA site, the Comanche Peak site for which you
7 should have that information from the operating unit
8 there.

9 MR. HARVEY: I probably did at one time.
10 I can't give you definitive answer on that one.

11 CHAIRMAN STETKAR: Okay. It popped --
12 that comparison between the four early site permit
13 sites --

14 MR. HARVEY: Yes.

15 CHAIRMAN STETKAR: -- popped up, but
16 they're really not relevant --

17 MR. HARVEY: The reason why they were --
18 you know, that's a good very point. The reason why I
19 picked the four early site permits because those are
20 fully vetted values.

21 CHAIRMAN STETKAR: Yes.

22 MR. HARVEY: And in some of the COLAs,
23 including in our COLAs that I'm reviewing we're still
24 negotiating --

25 CHAIRMAN STETKAR: Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. HARVEY: -- what some of those values
2 are between defining where the EAB and LPZ is and
3 making sure that we're happy with the quality
4 meteorological database they use, so forth and so on.

5 CHAIRMAN STETKAR: I'm just curious. I
6 mean, you discovered the fact that they were in some
7 sense originally nonconservative relative to three
8 out of four of those sites. Well, it would be
9 probably disappointing to the Comanche Peak folks--

10 MR. HARVEY: Yes. There's a different
11 staff reviewer who is doing it now, actually. And it
12 would have to be a deviation or a departure, if that
13 was the case.

14 CHAIRMAN STETKAR: Yes. Yes.

15 MR. HARVEY: Which I don't recall it
16 being the case, but I can't say that definitively.

17 CHAIRMAN STETKAR: Okay. I was just
18 curious whether you just in passing had taken a look
19 at that.

20 MR. HARVEY: I can't answer that.

21 CHAIRMAN STETKAR: Thanks.

22 MR. HARVEY: The control room and
23 technical report center chi/Q value, site parameter
24 values are used in DCD Chapter 15 to help demonstrate
25 that the radiological consequences of design-basis

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 accidents in the control room and technical support
2 center meet radiation dose guidelines specified in
3 GDC-19.

4 In order to confirm that the US-APWR
5 control room and technical support center chi/Q
6 values listed as these site parameters are
7 representative of a reasonable number of sites that
8 have been or may be considered for a COL application,
9 the staff generated a set of site-specific control
10 room and technical support center chi/Q values using
11 hourly meteorological data provided in support of the
12 four approved ESP applications. Again, North Anna,
13 Clinton, Grand Gulf and Vogtle. The staff executed
14 the ARCON96 atmospheric dispersion code assuming the
15 US-APWR plant aligned to true north at each site. The
16 staff found that the US-APWR is zero-to-eight hour,
17 eight- to-24 hour, and one-to-four day chi/Q values
18 were bounding in all cases, but the US-APWR four-to-
19 30 day chi/Q value were not bounding for three out of
20 four ESP sites. The staff consequentially issued
21 open item 02.03.04-11 asking the applicant to
22 consider increasing the 4-to-30 day control room and
23 technical support center chi/Q values so they bound a
24 reasonable number of sites that have been or may be
25 considered for a COL application. And the applicant

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 already discussed that they've did that.

2 MEMBER BLEY: They did. And I didn't
3 them this question, but since you're the
4 meteorologist let me ask you.

5 When they showed the new curve with the
6 new chi/Q values, some of the plants come very, very
7 close to that curve. What kind of uncertainty is
8 there in those chi/Q values?

9 MR. HARVEY: Probably some. But there's
10 a lot of other uncertainty in the entire calculation
11 that we're doing. And I would say the uncertainty in
12 atmospheric dispersion is no less or no more than
13 some of the other uncertainties.

14 MEMBER BLEY: Are these kind of maximum
15 values or just kind of middle --

16 MR. HARVEY: They tend to be values that
17 are exceeded no more than 95 percent of the time.

18 MEMBER BLEY: Okay. So there is a bit of
19 a bound to them?

20 MR. HARVEY: There is intended to be
21 conservative.

22 MEMBER BLEY: Okay. Because some are
23 real close to that line.

24 MR. HARVEY: Yes.

25 MEMBER BLEY: I was wondering why you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 wouldn't want to see the line a little further away
2 if there's uncertainty to that?

3 MR. HARVEY: Well, we got this regulatory
4 criterion. As long as they meet it.

5 MEMBER BLEY: Okay.

6 MR. HARVEY: That's the name of the game.

7 MEMBER BLEY: Okay. Go ahead.

8 MR. HARVEY: The staff identified three
9 other open items in the SER when it reviewed the
10 applicant's control room and technical support center
11 chi/Q site parameters. First is the list of chi/Q
12 site parameter values includes containment release to
13 the Class IE electrical room HVAC intake for control
14 room inleakage. The staff has asked the applicant to
15 explain why there are no chi/Q site parameter values
16 provided for containment releases to the control room
17 and leakage locations, such as the reactor building
18 door and auxiliary building intake.

19 In the SER this is identified as open
20 item 02.03.04-8.

21 Secondly, the plant configuration
22 information needed by COL applicants to calculate
23 site-specific control room and technical support
24 center chi/Q values is presented in both DCD Chapter
25 2 and Chapter 15. The staff asked the applicant to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 move all this information into Chapter 2 of the DCD
2 of the SER. This is identified as open item
3 02.03.04-9.

4 And third, Table 2.3-3 in Chapter 2 of
5 the DCD presents above ground heights for control
6 room and technical support center intake and
7 inleakage locations. This information is presented
8 for use for COL applicants in calculating site-
9 specific control room and technical support center
10 chi/Q values. The staff has asked the applicant to
11 correct apparently conflicting information in this
12 table.

13 In the SER this is identified as open
14 item 02.03.04-10.

15 Because of the open items that remain,
16 the staff could not in the SER finalize its
17 conclusions regarding the acceptability of the
18 control room and technical support center chi/Q
19 values.

20 Next slide.

21 Long-term dispersion site parameters for
22 routine releases. The US-APWR DCD utilizes routine
23 release for annual average atmospheric dispersion
24 chi/Q in deposition or D/Q factors in DCD Chapter 11
25 to calculate off-site concentrations dose

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 consequences from normal operations to demonstrate
2 compliance with the off-site radionuclide
3 concentration criteria in 10 CFR Part 20 and the dose
4 criteria in Appendix I of 10 CFR Part 50.

5 The staff reviewed the applicant's
6 routine release chi/Q and D/Q values by comparing
7 them to the corresponding site characteristic values
8 identified in the Clinton, Grand Gulf, North Anna and
9 Vogtle early site permits. The staff found that the
10 applicant's routine release chi/Q and D/Q values
11 bound the corresponding site characteristics for the
12 four ESP sites. Consequently, the staff finds that
13 the applicant's routine release chi/Q and D/Q values
14 should bound a reasonable number of sites and may be
15 considered with a COL application. The staff finds
16 this acceptable.

17 Meteorology COL information items.

18 The US-APWR DCD contains three
19 meteorology-related COL information items which read
20 as follows:

21 COL Information Item 2.3(1). A COL
22 applicant is to provide site-specific pre-operational
23 and operational programs for meteorological
24 measurements. It is to verify the site-specific
25 regional climatology and local meteorology are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 bounded by the site parameters for the standard US-
2 APWR design or demonstrate by some other means that
3 the proposed facility and associated site-specific
4 characteristics are acceptable at the proposed site.

5 COL information item 2.3(2). The COL
6 applicant is to provide conservative factors as
7 described in Section 2.3.4 of NUREG-0800 that a
8 selected site will cause excess to the bounding chi/Q
9 values then the COL applicant is to demonstrate how
10 the dose referenced values in 10 CFR 52.79 and the
11 control dose limits in 10 CFR Part 50 are met using
12 the site-specific chi/Q values.

13 And the third information item 2.3(3) the
14 COL applicant is to characterize the atmospheric
15 transport and diffusion conditions necessary for
16 estimating radioactive consequence of the routine
17 release of radioactive materials to the atmosphere
18 and provide realistic estimates of annual chi/Q and
19 D/Q values as described in Section 2.3.5 of NUREG-
20 0800.

21 The staff finds the scope of the
22 applicant's COL information items to be appropriate.

23 Conclusion. Pending the resolution of
24 meteorologically-related open items, the staff hopes
25 to be able to eventually conclude that the applicant

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 has identified an appropriate list of site parameters
2 and the values assigned to each of the site
3 parameters are expected to be representative of a
4 reasonable number of sites that may be considered for
5 a COL application.

6 And that concludes my presentation.

7 CHAIRMAN STETKAR: Thank you.

8 I think with that what we'll do is take a
9 break before we come to the hydrology and seismology
10 discussions. We're well ahead of schedule. I'm sure
11 everybody would appreciate a break.

12 Let's break until 10:35. I'm generous
13 with the breaks.

14 (Whereupon, at 10:30 a.m. off the record
15 until 10:34 a.m)

16 CHAIRMAN STETKAR: Okay. We'll come
17 back into session and pick up with hydrologic
18 engineering.

19 MR. TIRUNEH: Okay. My name is Nebiyu
20 Tiruneh and I'm the Technical Reviewer for Section
21 2.4

22 CHAIRMAN STETKAR: Just speak up a little
23 bit. Make sure the mic catches you. It helps our
24 reporter.

25 MR. TIRUNEH: Good morning. My name is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Nebiyu Tiruneh and I'm the Technical Reviewer for
2 Section 2.4.

3 The review of US-APWR Design
4 Certification SER Section 2.4 was performed in
5 accordance with the Standard Review Plan. And the
6 following areas were reviewed.

7 DCD Section 2.4.1 strives to set specific
8 hydrologic information that a COL applicant must
9 consider for safe operation of the plant and the
10 plant-specific enveloping hydrologic design
11 parameters of maximum flood level, hourly maximum
12 rainfall rate, short-term maximum rainfall rate and
13 maximum groundstream level are provided in Table 2.0-
14 1 of DCD Tier 1 and Table 2.1-1 of DCD Tier 2.

15 In Section 2.4.2 the applicant had
16 described the flooding information to be collected
17 and analyzed by a COL applicant at the proposed site
18 on the region of the site.

19 In Section 2.4.3 the applicant had to
20 describe the set specific flooding analysis that
21 needs to be performed to determine PMF level on
22 streams and rivers.

23 And in Section 2.4.4 the applicant had to
24 describe what a COL applicant must provide from first
25 potential hazards to plant safety and separate

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 facilities as a result of plausible of plausible
2 failures of on-site upstream and downstream water
3 control structures.

4 In Section 2.4.5 the DCD applicant has to
5 design the hydrological meteorological design basis
6 to developed by a COL applicant to ensure that
7 potential hazard to the safety-related facilities due
8 to the effects of probable maximum surge and seiche
9 are considered.

10 In Section 2.4.6 the applicant again has
11 identified the geohydrologic design basis to be
12 developed by a COL applicant to ensure that any
13 potential hazard to the structures, systems and
14 components important to safety due to the effects of
15 probable maximum tsunami are considered.

16 In Section 2.4.7 The DCD applicant has
17 identified the hydrologic design basis to be
18 developed by a COL applicant to ensure that safety-
19 related facilities and water supplies are not
20 effected by ice induced hazards.

21 In Section 2.4.8 the applicant again has
22 identified the hydrologic design basis to be
23 developed by a COL applicant for such specific
24 channels and reservoirs used to transport and impound
25 water supply to SSEs important to safety.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 In 2.4.9, again, the applicant has
2 described the set specific evaluation that needs to
3 be done with respect to seismic topographical
4 geologic and thermal evidence in the region and
5 related to the potential for upstream diversion or
6 rerouting source of cooling water.

7 In 2.4.10 the applicant has designed site
8 specific locations and evaluations of safety-related
9 facilities and also of structures and components
10 required for protection of those safety-related
11 facilities. And the information is then to be
12 compared to design basis flood conditions to
13 determine of flood effects need to be considered in
14 the emergency procedures analysis.

15 In 2.4.11 the applicant, the COL
16 applicant is to ensure that an adequate water supply
17 will still exist to shutdown the plant under SSE
18 conditions.

19 In 2.4.12 the COL applicant will have to
20 describe and analyze hydrogeological characteristics
21 of the site to determine the effects of groundwater
22 on plant foundations and also describe the
23 reliability of safety-related water supplies and the
24 dewatering systems and critical downwater pathways.

25 In 2.4.13 the COL applicant will describe

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the hydrogeological characteristics of the site to
2 determine if there's accidental releases of
3 radioactive liquid effluents in ground and surface
4 waters when using existing uses and known likely
5 future uses.

6 In 2.4.14, again the COL applicant is
7 required to describe the basis for technical
8 specifications and emergency procedures that are
9 required to implement protection against floods for
10 safety-related plant facilities.

11 And then 2.4.15, of course, the combined
12 license information item is provided which basically
13 directs the COL applicant to provide the technical
14 information.

15 And next slide, please.

16 And the applicant has provided the Tier 2
17 plant-specific design parameters and clearly
18 identified the information to be provided by the
19 perspective COL applicant.

20 And the hydrologic parameters provided by
21 the applicant are:

22 Maximum groundwater level of 1 foot below
23 finished grade;

24 Maximum flood of 1 foot below the
25 finished grade level, and then;

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Maximum hourly rainfall rate of 19.4
2 inches per hour, and;

3 Short-term rainfall rate of 6.3 inches
4 per five minutes.

5 Staff performed a review to determine
6 whether the values are appropriate and to compare the
7 parameter values with that of applicable technical
8 documents and other previously reviewed DCDs. The
9 general hydrogeologic description required stated in
10 Section 2.4.1 of the DCD are also in agreement with
11 EPRI Advance Light Water Reactor Utility Requirement
12 Document and HMR 52.

13 And also staff compared the previously
14 submitted and reviewed DCDs. And these values are
15 found to be consistent.

16 Next slide, please.

17 The applicant therefore has correctly
18 identified one COL information item which states the
19 COL applicant is to provide sufficient information to
20 verify that hydrologic-related events will not affect
21 the safety-basis for the US-APWR.

22 And next slide, please.

23 As part of the review process, staff
24 issues 13 RAIs which were eventually resolved by the
25 applicant's response. And as a result, there are no

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 open items at this stage. And staff acknowledged
2 that the plant-specific hydrological site parameters
3 are acceptable and that the applicant has properly
4 identified the site specific information to be
5 provided as part of the COL application.

6 And this concludes my presentation.

7 Questions?

8 MR. CIOCCO: Any questions, anything on
9 2.4?

10 CHAIRMAN STETKAR: I guess not. Let's
11 continue. Thank you.

12 MR. CIOCCO: Thank you.

13 And I will turn it over to Yong Li and
14 Sarah Tabatabai.

15 MR. LI: Hi. My name is Yong Li. And my
16 partner Sarah Tabatabai and I will present Section
17 2.5, which is the geology, seismology and
18 geotechnical section.

19 And Sarah is going to focus in on Section
20 2.5.2, which is the vibratory ground motion. I will
21 cover the rest.

22 So this review involves the following
23 subjects:

24 First, is the basic geology and the
25 seismic information which provide the background for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the seismicity and the faults.

2 And then there's another section talking
3 about the vibratory ground motion, which is a seismic
4 section provide the GMRS, ground motion response
5 spectra.

6 And the third section is surface
7 faulting, which is focuses on the fault or site.

8 And the fourth section is stability of
9 subsurface materials and the foundations.

10 And the fifth section is stability of
11 slopes.

12 And the last section talks about the
13 combined license information.

14 And the COL applicant is to provide this
15 information as part of the COL application to
16 complete their whole FSAR.

17 Next please.

18 So Section 2.5.4 focus on the site, so
19 there are a lot of primary relate to this particular
20 section. So this slide addressing the basic
21 geotechnical parameters for a candidate site, such as
22 minimum bearing capacity, minimum shear wave
23 velocity, total settlement and the differential
24 settlement. And the maximum tilt of a reactor
25 building complex foundation during the plant's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 operational life. And the maximum slip for the
2 foundation bearing stratum. Basically the subsurface
3 layers cannot be titled more than 20 degrees at the
4 site.

5 So those parameters are expected to be
6 representative for a responsible number of COL or ESP
7 sites in the U.S.

8 Next please.

9 MEMBER SHACK: So you don't have any
10 problems with the half-inch differential settlement
11 that seems kind of small to some of the members?

12 MR. LI: Good question. I think about
13 this question when you asked the applicant.
14 Generally, we like the smallest of parameter there
15 for the staff, because it's more conservative. But
16 if you look carefully at the applicant's
17 presentation. I mean, their parameter table, there's
18 a footnote there indicates if the differential
19 settlement is less than this one, you don't need to
20 do additional work.

21 MEMBER SHACK: Right.

22 MR. LI: So that means if you exceed the
23 .5 inches, it doesn't mean the site is not qualified
24 at all. You still can do additional work to verify
25 that, to prove that site is still okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: The site is okay or
2 you need to additional work on things like piping
3 connections between buildings? That's different.

4 MR. LI: Yes. At least from the
5 settlement side, you need to do additional work to
6 verify all the SSE can be functional without any
7 problem, basically. Yes.

8 MEMBER BLEY: I am just curious because I
9 haven't thought about this before. Suppose there's
10 good basis for it, you accept it, they go to plant.
11 And how --is this monitored over time, the
12 differently settlement and if it gets more than that,
13 I know that's not your part of this process, but has
14 that ever happened and what do we do with it if they
15 start getting more settlement than they sought in the
16 submittal and designed to?

17 MR. LI: Yes. A long-term observation
18 for settlement does exist for some of the power
19 plants. They do keep observing the long-term
20 settlement. But most settlement will be finished
21 after the structure is there. So the bigger portion
22 of the settlement is done when you put the load
23 there.

24 MEMBER BLEY: Sure.

25 MR. LI: Yes. So that's the kind of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 situation. Yes.

2 MEMBER BLEY: So basically we'd find out
3 sometime later if we start having problems?

4 Okay. Go ahead.

5 MR. LI: Yes. Different question.

6 MEMBER BLEY: Have to think about that a
7 bit.

8 MR. LI: This one talks about the other
9 site parameters for potential site.

10 First is a no liquefaction potential for
11 seismic Category I structures and also no surface
12 tectonic deformation, basically a capable fault
13 within the exclusion area boundary.

14 And also those parameters are expected to
15 be representative at quite a number of the potential
16 COL and ESP sites.

17 Next please. Sarah?

18 MS. TABATABAI: The US-APWR DCD
19 establishes certified design response spectra for a
20 candidate site.

21 The CSDRS are based on Reg. Guide 1.60,
22 and they're also anchored at a peak ground
23 acceleration of .30g and enhanced in the high
24 frequency range.

25 And the CSDRS also are considered to be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 representative of general power plant conditions in
2 the United States.

3 And the next slide, please.

4 This figure just shows the US-APWR
5 horizontal CSDRS. COL applicants need to make sure
6 that their site-specific ground motion response
7 spectra at the foundation level are enveloped by the
8 CSDRS.

9 Next slide. It's back to Yong.

10 MR. LI: Yes. Through the interactions
11 of applicant a lot of RAIs are resolved, but we still
12 have one open item, which is 2.05.04-1. We asked the
13 applicant to explain on the different between the
14 original proposed bearing capacity values and the
15 revised minimum allowable bearing capacity value.
16 Yes. That's the one pending to be finished in the
17 future. To be addressed by the applicant in the
18 future.

19 And we have COL information item for this
20 particular section, which requires the future COL
21 applicant provide sufficient information regarding
22 the site-specific geology, seismology and
23 geotechnical engineering characteristics surrounding
24 the site.

25 And except for those pending open items,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 we conclude the following basically:

2 The applicant has appropriate list of
3 geologic, seismological and geotechnical engineering
4 site parameters;

5 And applicant also identified the site-
6 specific information to be provided as part of the
7 COL applicant, and also the last one is;

8 That those values assigned to each of the
9 site parameters are expected to be representative for
10 a reasonable number of prospective COL and also ESP
11 sites.

12 And that concludes our presentation for
13 Section 2.5

14 MR. CIOCCO: And I think that's our
15 conclusion for all of the Chapter 2 of the open
16 items.

17 CHAIRMAN STETKAR: Any Members have
18 additional questions, comments on Chapter 2?

19 Okay. That finishes up Chapter 2.

20 MHI, where are you terms of presentation
21 for Chapter 16.

22 MR. SPRENGEL: We're not ready to start.

23 CHAIRMAN STETKAR: You're not ready?

24 MR. SPRENGEL: Yes, we could do earlier,
25 but because of the --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 COURT REPORTER: Please use the mic.

2 MR. SPRENGEL: Sorry. We could earlier,
3 but --

4 CHAIRMAN STETKAR: Yes, I have a conflict
5 over the noontime hour for another meeting. And I
6 can't move that around.

7 I'd really like to hear from Mitsubishi,
8 I think, before we hear from the staff. That's
9 usually much more effective.

10 So, I guess given our stellar performance
11 this morning, our only practical option is to adjourn
12 and come back at 1:00.

13 I'm sorry. Recess. I would love to
14 adjourn, but apparently we can't.

15 Recess until 1:00 and we'll come back and
16 start Chapter 16 then.

17 (Whereupon, at 10:41 a.m. the meeting was
18 recessed, to convene at 1:02 p.m.)

19
20
21
22
23
24

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MS. TORENE: A-F-T-E-R-N-O-O-N S-E-S-S-I-
2 O-N

3 1:02 p.m.

4 CHAIRMAN STETKAR: Let's reconvene, then,
5 and this afternoon's topic is Chapter 16 for the
6 technical specifications. And I guess we'll hear
7 from Mitsubishi first. I don't know who is going to
8 introduce it. Ken or Tanaka.

9 MR. TANAKA: Yes. I'm Futoshi Tanaka.
10 I'd like to start the presentation from MHI. Okay.

11 Here we have the content of this
12 presentation.

13 First number 1 is overview of the
14 chapter. We will describe the title and the scope of
15 this chapter, Chapter 16.

16 And number 2 we will discuss the features
17 of the technical specifications.

18 And the third, the major RAIs.

19 And finally, the summary.

20 And number 1, overview of the Chapter.

21 The title of the chapter is Chapter 16 is
22 Technical Specifications. This chapter includes the
23 information as required by 10 CFR 50.36 and 10 CFR
24 50.36(a).

25 Next slide.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 This slides shows the features of the
2 technical specifications of a US-APWR DCD. That's
3 the features of the US-APWR.

4 The plant concept and the basic
5 configuration of the main components is the same as
6 the current PWRs in the United States and also the
7 same with the PWRs in Japan. There are some
8 differences such as the four-train safety systems and
9 the digital platform.

10 The US-APWR consists of four-train safety
11 systems, a combination of active and passive systems
12 are used for the accident mitigations.

13 Next, the features of the US-APWR
14 technical specifications.

15 First of all, the tech specs for the US-
16 APWR it basically follows the standard technical
17 specifications for Westinghouse PWRs.

18 The US-APWR has four-train safety
19 systems. The high redundancy is used to maximize the
20 benefits of the on-line maintenance. And the US-APWR
21 tech specs adopted risk-management technical
22 specifications and a surveillance frequency control
23 program.

24 Next, the utilization of the standard
25 tech specs.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 The basic design concept of the US-APWR
2 design is similar with the current PWRs. This makes
3 possible the tech specs differ from the standard tech
4 spec with modifications. Therefore, the US-APWR
5 technical specifications are almost the same as the
6 standard technical specifications NUREG-1431, which
7 we're already familiar with. The major portions that
8 is new to the US-APWR technical specifications are
9 the treatment of the four-train safety systems,
10 application of risk-informed initiatives and the
11 digital platform. So today at this presentation we
12 focuses mainly on the differences: The safety
13 systems and risk-informed initiatives and a digital
14 platform.

15 Justification of a deviation between the
16 standard technical specifications and the US-APWR
17 technical specifications has been submitted to the
18 NRC staff as a technical report.

19 This slide here shows the safety benefits
20 of a four-train system. The US-APWR has four-train
21 safety systems. And due to this redundancy the
22 capability is beyond a single failure criteria. The
23 high redundancy design can maximize the benefits of
24 on-line maintenance. And the technical specifications
25 limited condition for operation only require three

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 operable trains. However, none of the trains are
2 allowed to be out of maintenance for more than 90
3 days in accordance with the 10 CFR 50.59 and the NEI
4 Guideline.

5 CHAIRMAN STETKAR: I guess I didn't read
6 90 day limit in the technical specifications. Where?

7 MR. TANAKA: It's not TS. Written in
8 the--

9 CHAIRMAN STETKAR: It's not --

10 MR. TANAKA: We haven't added it.

11 CHAIRMAN STETKAR: Why is it not
12 specified in the technical specifications then? If I
13 read the technical specifications the interpretation
14 is that I can leave one train out indefinitely.

15 MR. TANAKA: Yes. Our understanding is
16 that -- our point is that that 90 days is not
17 controlled the technical specifications. It is
18 controlled it --

19 CHAIRMAN STETKAR: I guess --

20 MEMBER BLEY: How is it controlled?

21 CHAIRMAN STETKAR: How is it controlled.

22 MR. TANAKA: Okay.

23 CHAIRMAN STETKAR: That's an NEI document
24 which, by the way, has no legal bearing in terms of
25 licensing.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. TANAKA: Yes, we know.

2 MR. TJADER: This is Bob Tjader,
3 Technical Specifications Branch.

4 It's a guideline is what it is. And the
5 90 days is not a guideline for equipment being out of
6 service. The guidelines, it's based upon the 90 days
7 as a guidelines for the amount of time that you can
8 have a temporary alteration or a temporary change to
9 a plant. The idea being that if you keep a train out
10 or equipment out for more than 90 days, i.e, more it
11 is a non-temporary change to the plant. And
12 therefore, you shouldn't do it. But it's a guideline
13 within the --

14 CHAIRMAN STETKAR: It's a guideline,
15 though?

16 MR. TJADER: Yes.

17 CHAIRMAN STETKAR: It's not part of the
18 licensing basis of the plant?

19 MR. TJADER: No. That's right.

20 CHAIRMAN STETKAR: So my question is on
21 this slide it says "One train out of service is not
22 allowed for more than 90 days in accordance with 10
23 CFR 50.59 and its guideline." Well, 10 CFR 50.59
24 doesn't really specify a 90 day limit for anything.

25 And I'm really curious if you're saying

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that one train cannot be out of service for more than
2 90 days, why that 90 days it not actually specified
3 in the technical specifications, which indeed governs
4 the operation and licensing basis for the plant?

5 MR. TANAKA: Yes.

6 CHAIRMAN STETKAR: Well, let me put it
7 another way: If your intention is that no train of
8 safety systems shall be removed for longer than 90
9 days, why would you not specify that in the technical
10 specifications, that limit?

11 MEMBER BONACA: Why does that maximizes
12 the benefit of on-line maintenance?

13 MR. TANAKA: Why this 90 days? We have
14 one train that can be out of maintenance for 90 days.
15 We also have another train that can be out of
16 maintenance as restricted by the technical
17 specifications LCO.

18 MEMBER BONACA: Okay.

19 MR. TANAKA: So it maximize of the four-
20 train safety system.

21 Yes, I understand the question of why
22 it's not --

23 CHAIRMAN STETKAR: It's a fundamental
24 question because as the technical specifications are
25 currently written and if I'm operating the nuclear

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 power plant, I operate the nuclear power plant
2 according to the technical specifications I am
3 allowed according to the technical specifications the
4 way they're written to have a train of safety
5 equipment unavailable, inoperable without any time
6 limit whatsoever.

7 MEMBER BLEY: You could use it for spare
8 parts?

9 CHAIRMAN STETKAR: I could use it for
10 spare parts.

11 The reason I bring this up is I operated
12 at a plant a long time ago that had technical
13 specifications that allowed because of the particular
14 plant's configuration one train of equipment to be
15 inoperable without a time limit. And indeed, one of
16 our trains of equipment was inoperable for on the
17 order of 15 months, a year and a quarter, because
18 there was no priority to get spare parts for a failed
19 piece of equipment. And, indeed, I was operating
20 fully within the law. I wasn't operating prudently,
21 but I was operating fully within the law.

22 This having no specified backstop on that
23 single train unavailability in the technical
24 specifications is effectively legal carte blanche to
25 as Dr. Bley said, have something that I can use for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 spare parts.

2 Now in your presentation this afternoon
3 you've indicated that, indeed 90 days might be a
4 operable limit, and people can argue why should it be
5 90 days versus 60 days, versus 120 days, versus some
6 other perhaps risk optimized number, but at least
7 it's a number. It's not an infinite time limit.

8 And so this question is really geared not
9 so much to 90 days, it's a specified limit versus no
10 specified limit.

11 MR. SCAROLA: It's my understanding that
12 in all aspects of the design we meet the single
13 failure criteria with one division out of service.
14 It's also my understanding that the PRA reflects one
15 division out of service continuously.

16 So I'm really not exactly sure of where
17 this 90 day came about, but I think we need to take
18 an action and make sure we have consistency there.

19 CHAIRMAN STETKAR: We haven't seen the
20 PRA. I mean, that's one of the questions that I
21 would certainly have in the PRA is --

22 MR. SCAROLA: What is the basis of out of
23 service?

24 CHAIRMAN STETKAR: Right. Right. But
25 that's a different topic for a different day. And

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 right now we're focusing more on more traditional
2 licensing basis --

3 MR. SCAROLA: Yes.

4 CHAIRMAN STETKAR: -- for technical
5 specification limits.

6 MR. TJADER: Yes. I'd just like to say
7 that I was going to say exactly the point that Ken
8 was going to make there. That basically you meet
9 single failure with three trains, and therefore you
10 don't need the fourth train. And theoretically you
11 could have the fourth train out indefinitely.

12 However, the maintenance rule as its availability
13 goes and things like that would be a deterrent for
14 doing that.

15 There are other designs that have four-
16 trains in a similar situation and they spec the four-
17 trains and then you run into that argument: Well,
18 what should the completion time be? 120 days?
19 Should it be a year? What could it be?

20 And in the reality, the PRA the risk-
21 assessment would support it being out indefinitely,
22 operable you know for an indefinite period of time.

23 So the goal is not to have it out
24 indefinitely. The goal is that surveillances are
25 performed on it, it would be operable and available

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 so that maintenance can be performed on the other
2 systems.

3 MEMBER BLEY: Just for my enlightenment,
4 as I'm not fully conversant with the maintenance rule
5 as I should be, what part of the maintenance rule
6 puts pressure on your in this regard?

7 MR. TJADER: Well, I'm not an expert in
8 the maintenance rule either. But the maintenance
9 rule requires that you set goals, operating and
10 reliability goals for systems. And if they're not
11 met, then you have to change your maintenance regime,
12 the frequency of maintenance and that sort of thing.

13 MEMBER BLEY: Okay.

14 MR. TJADER: And it's part of, I believe,
15 that part of the elements of which a train is
16 evaluated and whether they meet their minimum.

17 MEMBER BLEY: Okay.

18 MEMBER BONACA: Since you are going to
19 look at it, another thing also why it is not credible
20 with 10 CFR 50.59?

21 MR. SPRENGEL: Where the connection is?

22 MEMBER BONACA: Yes. I just don't
23 understand.

24 MEMBER BLEY: Yes, I don't see it.

25 CHAIRMAN STETKAR: I think the actual

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 connection is that there might be guidance in NEI 96-
2 07 to utilities for implementing 50.59 type analyses.
3 But, again, that's NEI guidance, it's not a direct
4 regulatory basis.

5 MEMBER BONACA: They would not refer to
6 90 days.

7 CHAIRMAN STETKAR: They would never refer
8 to 90 days.

9 MEMBER BLEY: But I suppose before we got
10 to this line which says it's not allowed, which is
11 probably not true, your other statement is probably
12 what drives this is that if you keep all four running
13 you've got a lot of flexibility in how you do
14 maintenance.

15 CHAIRMAN STETKAR: Well, but the question
16 is that the risk you go is you don't want to specify
17 a 72 hour allowed outage train for a single train
18 because that does not give you flexibility from
19 maintenance. You have to specify a long enough
20 allowed outage time such that you can perform on-line
21 preventive corrective maintenance at a reasonable
22 schedule. So specifying the longer time allows you
23 to do that. Specifying infinite time allows you a
24 lot of flexibility for on-line maintenance.

25 MR. TANAKA: That's right.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: Okay. I think we've
2 probably discussed that point. I'm still a bit
3 disturbed by the fact, and I think we'll discuss this
4 with the staff when they come up also, but this
5 limitless specification for a single train
6 unavailability.

7 MR. SAJI: Excuse me. Let me say one
8 thing.

9 CHAIRMAN STETKAR: Identify yourself
10 also, just give your name.

11 MR. SAJI: I'm Etsuro Saji from MHI.
12 Okay.

13 CHAIRMAN STETKAR: Well, it' just for our
14 record so we'll know who we are.

15 MR. SAJI: All right. Let me say one
16 thing. On the 90 days is not regulatory limitation,
17 that's what I understand. But actually I have keep
18 the 90 day backstop as the actual limitation.

19 CHAIRMAN STETKAR: And my point is that
20 if you as the applicant agree that that was your
21 actual backstop limitation, why is here a reluctance
22 to put that into the technical specifications? Why
23 won't you specify that to actually just codify it and
24 make it a formal limitation?

25 MR. SAJI: Because if the guideline would

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 change, we'd have to change the technical
2 specification itself.

3 CHAIRMAN STETKAR: The guideline is a
4 guideline.

5 MR. SAJI: Yes.

6 CHAIRMAN STETKAR: The guideline is not
7 the law.

8 MR. SAJI: So we don't want the 90 days
9 in the technical specification because if in the
10 future the guideline change, the 90 days maybe
11 change. So if we put the 90 days in the technical
12 specification, we'll have to change the technical
13 specification also.

14 MR. SPRENGEL: So I think we're saying we
15 commit to following the guideline of NEI 96-07, so in
16 that respect we have committed to the 90 days.

17 MEMBER BLEY: Well, you can't. It's
18 going to be the licensee who has to commit to that,
19 and there's in the technical specification or
20 anywhere else I've seen that assures you that this is
21 the way the plant will be operated. You have no
22 control over that once you build the plant.

23 CHAIRMAN STETKAR: If you have the
24 certified design technical specification saying no
25 limit on the operation and the licensee, the eventual

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 COL applicant simply adopts those technical
2 specifications or at least in that area of the
3 technical specifications from the certified design,
4 the 90 days is meaningless.

5 MR. HAMZEHEE: Excuse me, John, this is
6 Hossein Hamzehee.

7 We'll follow-up on this issue, but I
8 believe that what they're trying to accomplish here
9 is what is within the technical specifications and
10 what is outside the technical specifications. So the
11 90 days is administrative control that they're
12 proposing, but that's not something that has to be
13 complied with under technical specification. They
14 have three trains and they believe that's more than
15 adequate to put it in the technical specifications
16 and maintain the LCO and all the other operating
17 requirements.

18 So, this is an administrative control
19 that is somehow consistent with NEI guideline that
20 would like to ensure as part of the maintenance rule
21 that the safety related systems or those systems that
22 are risk-significant have met the targeted liability.

23 As part of that, then they say regardless of what
24 your technical specifications say based on some other
25 things such as PRA, we look at your risk and your

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 risk profile and then maintain your targeted
2 liability.

3 So I'm assuming that they're just
4 maintaining as an administrative control the fourth
5 train as a 90 day backstop so that it doesn't get
6 into some kind of what you just mentioned, that it
7 becomes unavailable for too long.

8 MEMBER BONACA: I thought you mentioned
9 another train before on 90 percent --

10 MR. HAMZEHEE: I beg your pardon?

11 MEMBER BONACA: I thought that another
12 train that is controlled. So I agree with
13 interpretation they're making that probably this is a
14 self-imposed limit --

15 MR. HAMZEHEE: Correct.

16 MEMBER BONACA: -- to be consistent with
17 the NEI approach.

18 MR. HAMZEHEE: Correct.

19 CHAIRMAN STETKAR: Let me follow-up on
20 that line of reasoning. If that's true, where in the
21 DCD is this 90 day administrative limit, if we want
22 to cast it that way, specified?

23 MR. HAMZEHEE: We have to go back and
24 follow-up on that item to see if it has been clearly
25 identified. And if not, it's something that should be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 added. I'm not sure if they articulated this
2 clearly.

3 MEMBER BLEY: Yes, because these slides
4 don't have any meaning.

5 MR. HAMZEHEE: Correct. You're
6 absolutely right. And maybe the word that they have
7 used there is not the right word of saying it's not
8 allowed. Because if you say it's not allowed, then
9 it should be part of the technical specification.

10 CHAIRMAN STETKAR: Yes. I mean, the
11 slide says it's not allowed for more than 90 days in
12 accordance with 10 CFR 50.59, which is not a correct
13 statement.

14 MR. HAMZEHEE: We will look at that.

15 CHAIRMAN STETKAR: It might be consistent
16 with some guidance in NEI 96-07.

17 MR. HAMZEHEE: Correct.

18 CHAIRMAN STETKAR: But the statement as
19 its written here is not a correct statement.

20 Okay.

21 MR. TANAKA: Can I move forward?

22 CHAIRMAN STETKAR: Yes. Sure. Please.

23 MR. TANAKA: The next slide. The main
24 deviations between the standard technical
25 specifications and the US-APWR technical

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 specifications.

2 Here is the typical deviations between
3 the standard technical specifications is described.

4 First is a four train safety systems,
5 which we have just discussed in the previous slide.

6 And the gas turbine generators, which is
7 quite unique, is unique to the US-APWR design.

8 And also the digital platform.

9 And also the surveillance interval. We
10 have 24 months which is accordance with the refueling
11 cycle.

12 And these are deviations between the
13 standard technical specifications and the US-APWR
14 technical specifications.

15 Another feature of the US-APWR technical
16 specifications is the adoption of the risk-informed
17 technical specifications initiatives.

18 US-APWR technical specifications adopts
19 Initiative 4b: A risk-managed technical
20 specifications, which is called RMTS. This program
21 allows completion times to be flexibly determined on
22 site by a licensee using PRA results based on the
23 real time plant configuration. And its program will
24 be developed in accordance with NEI 06-09.

25 Another one, Initiative 5b: Surveillance

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 frequency control program, SFCP. This program
2 relocates surveillance frequencies to licensee
3 controls using the PRA and operating experiences.
4 This program will be developed in accordance with NEI
5 04-10.

6 CHAIRMAN STETKAR: I didn't look ahead.
7 Is this your only slide on the risk-informed --

8 MR. TANAKA: No, there's a next one.

9 CHAIRMAN STETKAR: Okay. Why don't you
10 finish that one then.

11 MR. TANAKA: Okay. And the technical
12 specification provides only the framework o the risk-
13 informed technical specifications initiatives 4b and
14 5b and adoption of each program is specified as a COL
15 item. In other words, the COL applicant can choose
16 whether or not to adopt these programs which include
17 the PRA model qualified for these programs as well as
18 the station procedures will be established by the COL
19 applicant who intends to implement these programs.

20 And since this technical specifications
21 only provides the framework of these risk-informed
22 applications, the implementation of the program
23 itself COL item.

24 The US-APWR DCD technical specification
25 is therefore not effected by the ongoing issue

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 regarding a risk metrics for new reactors.

2 So the key point is that in the DCD
3 technical specification we only provide the
4 framework, not the detailed program or the PRA.

5 CHAIRMAN STETKAR: Okay. Let me ask you
6 a couple of things about that. I understand that the
7 material, I understand those statements regarding the
8 surveillance frequencies, the framework that's been
9 established is there are nominal surveillance
10 frequencies specified in the DCD technical
11 specifications and then there's consistently that
12 second level that could be modified by the COL
13 applicant to apply a risk-informed surveillance
14 frequency program.

15 There is not a comparable framework, if
16 you want to call it that, for the completion times,
17 the allowed outage times. The allowed outage times
18 are simply simplified, I believe -- no, I'm sorry. In
19 some places they're specified. In other places you
20 do have the framework.

21 But the question I was asking is have any
22 of the allowed outage times, being the DCD technical
23 specifications, been derived from a risk-informed
24 basis or are they strictly developed from the
25 technical specifications except for the single train

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that we talked about earlier?

2 MR. TANAKA: Basically is developed from
3 the standard technical specifications.

4 CHAIRMAN STETKAR: Okay. Okay. Okay.
5 So essentially the values that are currently in the
6 DCD technical specifications do not take benefit from
7 any risk-informed analyses, is that correct?

8 MR. TANAKA: Yes, correct.

9 MR. SCAROLA: But I think it's important
10 there to point out that the outage times are the time
11 that we do consider in the PRA. So the PRA enforces
12 that these are acceptable outage times. We meet the
13 core damage frequency, we meet the other--

14 CHAIRMAN STETKAR: Understand. But those
15 outage times, with the exception of the fourth train
16 that we talked about earlier, the 72 hours, 24 hours,
17 8 hours, 2 hours; whatever they are are all derived
18 from the standard technical specifications and not
19 derived from a PRA analysis that has developed those.

20 I understand the PRA uses those values, but the PRA
21 does not generate those values, in a sense?

22 MR. SCAROLA: Right.

23 CHAIRMAN STETKAR: Okay.

24 MR. SCAROLA: There are a number of
25 cases, at least in the I&C area, where the starting

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 point was the standard technical specification. But
2 then we do justify an extension of those times based
3 on features in the I&C system. For example, in some
4 cases we have more levels of redundancy, or we have
5 automated testing for the things that are remaining
6 in operation. Therefore, we make arguments,
7 deterministic arguments of why we can extend the
8 outage times.

9 CHAIRMAN STETKAR: That's the key. But
10 those arguments are deterministic --

11 MR. SCAROLA: Those arguments are
12 deterministic arguments, they're not PRA-based.

13 CHAIRMAN STETKAR: Okay. Thank you.
14 That helps.

15 MR. TANAKA: Okay. From here, this is
16 the major RAIs. Mr. Ken Scarola will make the
17 presentation.

18 MR. SCAROLA: Thank you very much.

19 As Mr. Tanaka said, most of the technical
20 specifications are based on the standard technical
21 specifications for Westinghouse and CE PWRs. Of
22 course, as in many areas and our digital I&C is an
23 exception to that and there are some deviations.

24 And although we do have a number of RAIs
25 that remain in a confirmatory state or in an open

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 state, there are really only three major issues in
2 the I&C area, but these are replicated over and over
3 again since there are so many measurement channels
4 and so many chains and so many functions.

5 The first issue is identified on slide 9
6 of your handout, and it relates to the method that we
7 use to calculate allowable values.

8 The second issue is on slide 11 -- and
9 I'm going to go back to these. I just want to give
10 you an overview.

11 The second issue is how we apply these
12 AVs, allowable values.

13 And the third issue is the functional
14 verification method, and that's on slide 16.

15 So we'll be going through these three
16 issues now and, hopefully, we'll see that they're not
17 actually very significant.

18 The first one is on the method of
19 allowable value calculation. And here, first of all,
20 the allowable value is the value that you use to
21 determine the acceptance criteria for what is
22 operable or not operable during surveillance tests.
23 So, for example, when you have a setpoint, your
24 setpoint is never going to be right at that value,
25 there's always going to be some leeway. And the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 allowable value determines the acceptable leeway in
2 that setpoint.

3 We submitted to the staff a setpoint
4 methodology document. The staff pointed out to us
5 that our seventh grade math was not quite accurate.
6 That the root of all of the sum of the squares is not
7 equal to the square root of the parts of the sum of
8 squares. And this is actually better shown on slide
9 10 where if you see what we first did, if you see
10 that there's a safety limit on this chart at the very
11 and then the analytical limit which is used in
12 Chapter 15. Then from the analytical limit we
13 subtract all of the uncertainties using the sum root
14 of the sum of the squares method to get to the
15 setpoint. Okay. That's the trip setpoint that you
16 see at the bottom.

17 In Rev. 0 of our methodology we then
18 added to that the measurable uncertainties and said
19 that's the allowable value. Well, the staff
20 correctly pointed out that if you do that method, you
21 don't leave enough for the unmeasurable
22 uncertainties. There's not enough margin left
23 because the sum of the parts is not equal to the
24 square root of all the uncertainties.

25 Rev. 0 we are starting with the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 analytical limit, subtracting from the analytical
2 limit the unmeasurable uncertainties, and that's now
3 the allowable value for surveillance testing.

4 So as you can see, we have pushed the
5 allowable value closer to the setpoint leaving more
6 margin for the unmeasurable uncertainties.

7 The staff is now reviewing this document.
8 We think we got it right this time. We think the
9 staff will find this acceptable. But this is a
10 Chapter 7 review issue. It's related to the technical
11 specifications but it's reliant on the acceptance by
12 the Chapter 7 review team.

13 So that's the first issue. Before I move
14 on, any questions on that one?

15 The second issue relates to how we apply
16 the allowable value. The AV is traditionally applied
17 to the COT, Channel operability test, which is really
18 where you establish the leeway in the setpoint.

19 In MHI's design we intend to apply the
20 allowable value during channel calibration for
21 digital functions. The intent is to reduce what is a
22 two step method of surveillance for analog plants to
23 a one step method of surveillance for digital
24 functions. I'll go through the reason for that is so
25 we can have less manual intervention to avoid human

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 error, and also to reduce O&M labor. And I'll explain
2 what that all means in these subsequent slides.

3 The first couple of slides simply to give
4 the background, explain how we check the allowable
5 value for analog functions or how plants do this
6 conventionally for analog systems.

7 The first step is any surveillance is to
8 calibrate the measurement channel. We typically do
9 this by pumping up a transmitter with a mechanical
10 pumping mechanism. We valve out the transmitter,
11 hook in a valving manifold, pump up that transmitter
12 and we check the accuracy of that transmitter
13 typically at five points over its entire span:
14 Zero, 100 and then three points in between, 25, 50
15 and 75.

16 And at each one of these points you
17 verify that you have an accurate output from that
18 transmitter, what we call the performance test
19 acceptance criteria. Now are we within the
20 acceptable tolerance of that transmitter. This is
21 what we call the as-found value on channel
22 calibration. So this is step one that we calibrate
23 the transmitter in an analog plant.

24 Step two, if we go to slide 13, is where
25 we actually check the setpoint. Now after we have a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 calibrated transmitter, now we disconnect that
2 transmitter from the I&C rack and we inject a
3 calibrated voltage source into the I&C rack. And we
4 ramp that voltage source up to the setpoint and we
5 verify that we actually get a trip from that
6 setpoint.

7 And at the setpoint we again have a PTAC
8 value, what is the acceptance criteria. Above that
9 PTAC there is some margin, but ultimately we will get
10 to the allowable value, whereas if that setpoint
11 trips above the allowing value, we now have an
12 inoperable channel. And this is an example of a
13 rising setpoint. We do the opposite on a decreasing
14 setpoint.

15 So for analog functions we'd do a two
16 step calibration. We would like to, if we go to the
17 next slide, make this a one step calibration function
18 for digital channels. And this slide, let me just
19 give you an orientation. It looks a little
20 complicated but I can, hopefully, verbally simplify
21 it.

22 On this slide you see we have a
23 measurement device. This would be something like a
24 pressure transmitter. That feeds into the plant
25 safety monitoring system, through a distribution

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 module which is just a passive filtering device, and
2 then it goes into the digital controller, what we
3 call the MELTAC controller. Inside that controller
4 is where we do calculation. So trip setpoints, logic
5 functions, whatever it might be.

6 We ultimately, though, send an output
7 from the module into what we call the power interface
8 module, PIF module, and that's the thing that finally
9 actuates valves and pumps, et cetera.

10 We would like to determine that we have
11 operable channel by stimulating that measurement
12 device, the same as we would do with an analog
13 function, let that signal propagate through these
14 heavy lines that you see here and read the output on
15 an video display unit that you see on the left hand
16 side of the drawing. So as we pump up that
17 transmitter, we'll read the five calibration points
18 not at the transmitter as we do in an analog plant,
19 but at the video display unit. So we take that
20 signal, e sent it all the way through the digital
21 system through the A to D conversion, through the
22 controller that's going to do the setpoint calcs,
23 send it out through the data communication and we
24 read it on the VDU. This is one step calibration.

25 If we got to the next slide what it shows

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 now is in order to accomplish this one step
2 calibration, now instead of applying the allowable
3 value to the setpoint as we did for an analog plant
4 in step two, step two is gone now. So now we're
5 applying the allowable value to the five calibration
6 settings; to zero, 5, 25, 50, 75 and 100. So we now
7 have the allowable value verifying the entire loop
8 accuracy from the measurement all the way to the VDU,
9 but we completely eliminate the second step because
10 we verify everything during that channel calibration.
11 We don't apply the allowable value during channel
12 operability tests.

13 So this is certainly new to the Technical
14 Specification Branch. They are working with the I&C
15 Chapter 7 seven guys to try and see, okay, does this
16 all make sense? Is there some gap that we may be
17 missing in this test? We certainly think there are
18 no gaps. We think it's a viable method. And we
19 certainly think one step is better than two steps,
20 primarily because we know the human interaction is
21 the highest source, history shows, for common cause
22 failure. So the less human interaction we can get
23 with these systems, we feel we're minimizing CCF
24 potential.

25 CHAIRMAN STETKAR: Not being an expert on

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 instrument calibrations, certainly, the challenge is
2 to make sure then that the allowable value setpoint
3 criteria at the transmitter now appropriately account
4 for the summed uncertainties through the digital and
5 analog devices. And that you've done your seventh
6 grade math correctly through that serial --

7 MR. SCAROLA: Right.

8 CHAIRMAN STETKAR: -- string, right?

9 MR. SCAROLA: So our setpoint
10 methodology, which also explains the allowable value
11 methodology, is detailing that to the staff.

12 CHAIRMAN STETKAR: Okay.

13 MR. SCAROLA: We're pretty confident we
14 got it right this time.

15 CHAIRMAN STETKAR: And we'll see that in
16 Chapter 7?

17 MR. SCAROLA: We'll see that, yes. I
18 believe the actual calculation methodology is going
19 to be addressed in the Chapter 7 SER.

20 CHAIRMAN STETKAR: So is there a separate
21 topical report on it, Ken?

22 MR. SCAROLA: There's a separate
23 technical report.

24 CHAIRMAN STETKAR: Separate a technical
25 report.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER BLEY: And NRC has that now and
2 they're reviewing it?

3 MR. SCAROLA: The NRC has read one of
4 that. Rev 0 we got RAIs, they now have Rev. 1.

5 MEMBER BLEY: We might have it. I'm not
6 sure.

7 MR. HAMZEHEE: You should have it. If
8 not, let me know.

9 MR. SCAROLA: Now we actually think this
10 is a more thorough way of actually confirming the
11 allowable value because it takes into account all of
12 the measurable uncertainties. Of course, we still
13 have to reserve margin for the unmeasurable
14 uncertainties, but it takes into account--

15 MEMBER BLEY: It sounds right.

16 MR. HAMZEHEE: I think you have a copy.
17 If you don't, let us know, we'll send you one.

18 MEMBER BLEY: Okay.

19 CHAIRMAN STETKAR: You know, we're sort
20 of starting up the US-APWR from our Subcommittee
21 schedule after quite a delay. We received several
22 topical reports and technical reports, but probably
23 more than a year ago in many cases.

24 MEMBER BLEY: Rev 1 is pretty recent or
25 is it --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. SCAROLA: December.

2 MEMBER BLEY: December. Okay.

3 MR. SPRENGEL: No, no, no. It was more
4 recent in the last month.

5 MR. SCAROLA: April 30th. Excuse me.
6 April 30th.

7 MEMBER BLEY: Rev 1 of the technical
8 report.

9 MR. SCAROLA: OF the setpoint methodology
10 technical report was April 30th, I believe.

11 CHAIRMAN STETKAR: We certainly have not
12 received it that recently. Anything that we have on
13 technical reports or topical reports is probably--

14 MR. SCAROLA: This methodology of
15 applying the allowable value to channel calibration
16 versus channel operability was in Rev. 0. So nothing
17 in this area has changed.

18 What has changed between Rev. 0 and Rev.
19 1 was the method of doing the calculation. That sum
20 of the squares problem that we talked about. But the
21 actual methodology of applying it is the same.

22 MEMBER BLEY: I didn't read it there.

23 MR. SCAROLA: Okay. Now let me go on to
24 the third item, and this what we call functional
25 verification methods.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Setpoints and logic functions are
2 traditionally set by direct manual verification.
3 What that means is if you have an and gate in your
4 logic, you'll actually inject two signals and make
5 sure the and gate has an and function. If you have
6 an or gate, you'll inject whatever number of signals
7 are in the or gate and you'll verify the or gate has
8 an or function. The same thing with the latches,
9 flip-flops, whatever it might be.

10 It requires a lot of manual labor,
11 multiple signal injections. Similarly for setpoints.

12 If you're going to verify that a setpoint is exactly
13 2251, then you have to ramp up your signal right
14 before that, make sure you don't get a trip, and then
15 slightly above it and make sure you do get a trip.
16 These are all very time consuming functional
17 verifications.

18 The US-APWR verification method is a
19 combination of self tests and manual tests. We do
20 rely extensively on self-testing. We confirm the
21 self-testing is functioning through manual tests.
22 Our intention is to eliminate all manual functional
23 verification tests: That's our intent. And, again,
24 the same reason: Less manual intervention results in
25 a lower potential for human error and also reduced

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 operations and maintenance.

2 So the staff has requested more
3 information on how we are ensuring that the system is
4 actually operable through this combination of tests.

5 So what I have here is a series of slides
6 that will walk us through what we are taking credit
7 for. These are simplified slides. I know they look
8 complicated, but they're actually simplified
9 drawings. And, hopefully, this will give you a feel
10 for the methodology we are proposing.

11 The first test that we are crediting is
12 what we call continuous self-testing. All of the
13 dark lines that you see on this drawing, this is the
14 same drawing that we saw before, represent the
15 portions of the system that are continuously self-
16 tested.

17 So, for example, if we look at the MELTAC
18 controller, this is the device that's doing the
19 algorithms, the setpoint calculations, the actuations
20 of the pumps and the valves, the self-testing is
21 continuously verifying that the CPU is running, that
22 the CPU is reading and writing to memory locations.
23 It's also checking all the memory to make sure that
24 there has been no alteration in either the basic
25 software, or what you might think of as the operating

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 system, and the application software. So all of
2 these tests are running continuously.

3 In addition, there are tests that are
4 verifying all of the data communications that that
5 controller can talk to all of the other controllers
6 in the system, it can talk to the VDUs, it can send
7 data to the plant computer. These are all self-tests
8 that are running continuously.

9 Another very important self-test is the
10 automated cross channel checks. Normally inside
11 control rooms the operators run cross channel checks.
12 The operators will look at the A channel, the B, the
13 C and D and they will do comparisons. They will do
14 visual comparisons. In this plant that's automated,
15 it runs continuously, and it runs in this separate
16 computer which is part of the plant control and
17 monitoring system.

18 So what you see here that we show is the
19 A train sending data to the plant computer, similarly
20 the B train, C train and D train. So inside the
21 plant computer we're doing a comparison.

22 So if there is any failure in the MELTEC
23 controller or in any part of this MELTAC system, it
24 should be picked up by MELTAC's self-testing. On the
25 other hand, if for some reason it's not and MELTAC

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 does a wrong calculation and it sends bad data,
2 there's a second computer here on the side that's
3 looking at all these analog values -- excuse me.
4 Looking at the digitized version of he analog values
5 and saying are they right? Is the A channel, B
6 channel, C and D channel all falling within an
7 acceptable tolerance?

8 So these tests are running continuously
9 one internal to the safety system and one external to
10 the safety system. First step.

11 Any questions on this one? There's many
12 steps to this, so I just want to make sure we're
13 getting as we go through? Okay.

14 Now let's look at the first manual test,
15 which is the one we talked about before, Channel
16 calibration. Channel calibration is where we pump
17 that measurement device and we read the value on the
18 video display unit. The important point here is when
19 we do that, we are completely overlapping with those
20 self-tests that I spoke about before. So there
21 should be no surprises here.

22 When we do this measurement channel
23 calibration if for some reason we see that this thing
24 is out of calibration and the problem is not in the
25 transmitter, the problem is inside the system, it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 means that the self-testing missed something. So
2 this is essentially a test of the self-tests. It also
3 tests the system, but it's a test again of that self-
4 test because it overlaps with all the self-testing
5 functions. So this is the first manual test that
6 actually overlaps with the automatic tests.

7 MEMBER BLEY: Is there a way to briefly
8 describe what the self-tests actually do? What are
9 they testing and what aren't they testing?

10 MR. SCAROLA: There are many, many self-
11 tests. For example, one self test is a watchdog
12 timer. The start of every software cycle it sets a
13 timer. At the end of the software cycle, it reads
14 that value. And if that timer times out, it's a
15 hardware timer, it sounds an alarm, stops the system
16 and generates a trip. That's a self-test.

17 There's a self-test that divides all the
18 memory inside the memory into blocks. Every block
19 calculates a CRC check or the checksum. I forget.
20 Oh, a checksum. Excuse me. Checksum. So inside the
21 system there's a known checksum value.

22 MEMBER BLEY: And these two things are
23 within MELTAC?

24 MR. SCAROLA: These things are all in
25 MELTAC. These things are all in MELTAC.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 There's data communications where all the
2 system will continuously send data through the data
3 links. It will send data through the data networks
4 and it looks for things like parity checks, CRC
5 checks. It's constantly running those data
6 communications.

7 I/O modules, the system will continuously
8 send data to an output module. Receive feedback back
9 from the output module that it received the data.

10 There's many, many more.

11 MEMBER BLEY: Are they described in that
12 technical report?

13 MR. SCAROLA: They're in the MELTAC
14 topical report.

15 MEMBER BLEY: MELTAC topical.

16 MR. SCAROLA: All the self-testing for
17 MELTAC is in the MELTAC topical report.

18 The cross channel checks that I spoke
19 about, which are inside this PCMS computer, that's a
20 very, very simple cross channel calibration --

21 MEMBER BLEY: Thanks.

22 MR. SCAROLA: -- or cross channel
23 verification. Similar to what the operators would do
24 manually.

25 Okay. So this channel calibration is an

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 input test. Now we move to TADOT, or trip actuation
2 device operability test, which is an output test.
3 This is a test conducted by the operators. They will
4 call up a video display that shows the pumps and
5 valves in a piping mimic diagram. They will select a
6 single pump or a single valve or even groups of pumps
7 and valves, and they will manually start, stop,
8 open/close those components.

9 The signal path is from the left side of
10 the figure where you see operator control demand from
11 the VDU through the data communications, through the
12 same controller that we talked about before, again
13 fully overlapping with all those self-tests, through
14 the power interface module and out to the pump and
15 valve. So this is where we actually run the pumps,
16 cycle the valves. Again, we're not only testing the
17 system to verify operability, but again we are
18 looking to see if there's any problems that the self-
19 testing may have not picked up. Because there should
20 be no surprises here. If the self-testing says the
21 system is working, when the operators run this test
22 the system should work the exception of possibly
23 things that are outside the self-testing. For
24 example, maybe the pump motor center is not working
25 right, or you'll find that here. But you shouldn't

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 find any problems in MELTAC, or any data
2 communications because this fully overlaps with all
3 this.

4 MEMBER BLEY: We're calling this an
5 operability test, but this is actually an operation,
6 pushing the button or clicking on some level and
7 seeing that the thing works the way it should.

8 MR. SCAROLA: Right. Correct.

9 Is that wrong to call this TADOT?

10 MEMBER BLEY: Oh, it's fine. I have no
11 idea. I just wanted to make sure I understood it.
12 He's doing what he would normally do to start that
13 pump or operate the valve.

14 MR. SCAROLA: Yes. Exactly.

15 MEMBER BLEY: Okay.

16 MR. SCAROLA: And his manual actions
17 completely overlap with signals for example that
18 would be generated as an ESFAS function which for
19 example you might let a low pressurizer pressure that
20 starts an SI pump while he's starting the SI pump
21 here. But it overlaps completely with that same
22 function.

23 CHAIRMAN STETKAR: The difference being
24 that the low pressurizer pressure comes in from four
25 analog measurement devices through four channels are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 then compared in a voting logic, which is not quite
2 the same as touching a touch screen.

3 MR. SCAROLA: But it's the same CPU. The
4 same CPU has got to respond to either one. And the
5 logic here is that --

6 CHAIRMAN STETKAR: Occasionally when I
7 put a number in with my key pad here, it's a
8 different number than what gets calculated to an
9 algorithm that's got some errors it.

10 MR. SCAROLA: Okay. But if there's an
11 error there it's likely because you have a memory
12 problem. Something happened in your memory. So we
13 are separately testing this memory that's also a
14 test.

15 Okay. So so far we have talked about
16 continuous self-testing, manual input testing which
17 is channel calibration, that's every 24 months and
18 manual output actuation, again that's 24 months.

19 There is in addition a separate test for
20 the safety VDUs. And the reason we do this as a
21 separate test is because the non-safety VDUs are what
22 the operator is going to use day in and day out, but
23 they're not Class 1E, so they're not fully credited.
24 So we do need to test the safety VDUs as well because
25 they are the accident credited interface for the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 operators, even though in this design they're
2 anticipated as being the backups. Those of you who
3 have been to our simulator know that you run
4 everything from non-safety VDUs, but the safety VDUs
5 they are the Class 1E backups. So this is a separate
6 test. So this verifies that the safety VDU can talk
7 to the controller and the controller can talk back to
8 the safety VDU, separate test.

9 Finally we have on slide 21 a diverse
10 software memory integrity test. Now as I said
11 before, the original continuous tests that we're
12 doing continuously verifying all the memory
13 locations. However, that test cannot detect if there
14 may have been an erroneous alteration to the
15 software. You know, maybe a technician put the wrong
16 software in at some point in time.

17 This is a diverse bit-by-bit memory
18 comparison that's done through this engineering tool
19 where the engineering tool has a copy of the software
20 that should be in every controller and the
21 technicians manually initiate this test, but the
22 engineering tool actually conducts it. It does a
23 bit-by-bit comparison to make sure that there has
24 been no unexpected alteration to the software for any
25 reason.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 So again, this is overlapping with the
2 continuing self-tests so it's verifying that the
3 self-test picked up everything that it should have,
4 but its also going beyond that and saying okay, was
5 there some sort of technician error or possibly if
6 you get into the cyber security world, was there some
7 sort of cyber problem, security problem.

8 MEMBER BLEY: And all of this, this is a
9 manual test?

10 MR. SCAROLA: This is a manually
11 initiated test, but of course --

12 MEMBER BLEY: Computer driven?

13 MR. SCAROLA: Yes.

14 MEMBER BLEY: But all of these manual
15 tests it looks like you do every two years?

16 MR. SCAROLA: All of the manual tests are
17 done at refueling intervals.

18 MEMBER BLEY: Okay.

19 MR. SCAROLA: But not necessarily at
20 refueling. They are done every two years. All of
21 these can be on-line tests. That's one of the
22 advantages of requiring only three trains and having
23 the fourth train available for testing, you can do
24 them anytime.

25 MEMBER BLEY: Okay. What's the basis for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 only doing the manual tests, especially the operable
2 tests, only once every two years?

3 MR. SCAROLA: That is justified in the
4 PRA. Normally these manual surveillance tests --

5 MEMBER BLEY: But we'll find that out in
6 Chapter 19?

7 MR. SCAROLA: Well, Chapter 19 uses that
8 24 months surveillance interval as the basis for CDF
9 and LRF calculations.

10 MEMBER BLEY: Okay. Let me ask you
11 another question then. Many of these pumps and
12 valves may have monthly or quarterly surveillance of
13 its own, wouldn't that be done the same way as this
14 operability test?

15 MR. SCAROLA: And that would force that
16 operability test to be done more frequently.
17 Absolutely.

18 MEMBER BLEY: Okay.

19 MR. SCAROLA: So there are two components
20 of frequency that goes into this TADOT. There is an
21 I&C technical specification requirement and there is
22 a mechanical. Whichever one is more limiting is
23 going to dictate the frequency.

24 For an I&C perspective, it's only
25 required every 24 months. But as you say, the pump

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 may require a monthly test.

2 MEMBER BLEY: This isn't really a safety
3 issue? Well, in a way it is, in kind of a bad-ended
4 way.

5 Are you folks, because you're doing the
6 technical specifications too, are you providing the
7 operators with a way to effectively minimize the
8 amount of surveillance testing they're doing on
9 equipment by making sure that one may operate it if
10 you need to test a valve for one purpose, that those
11 all get counted and they aren't multiple testing the
12 same equipment just for fun? To keep track of
13 separate requirements?

14 MR. SCAROLA: I would certainly expect
15 that we would do that. And we have a detailed--

16 MEMBER BLEY: And it would have a
17 equipment out of service list often then?

18 MR. SCAROLA: Right. So what you're
19 saying is anytime you cycle valve, take credit for
20 that as part of your surveillance tech. It is done
21 in operating plants today, I would certainly --

22 MEMBER BLEY: It's done as an add-on
23 because people found it was a lot of -- they were
24 multiply testing things quite a bit, not on purpose,
25 but testing other things. You need the valves to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 test the pump.

2 MR. SCAROLA: Exactly.

3 CHAIRMAN STETKAR: Ken, before you get--
4 I didn't want to interrupt you because you were on a
5 good roll. But it's time to interrupt you, because
6 you only have one more slide.

7 This has been real helpful, by the way.
8 Trying to divine what indeed was done just reading
9 through the technical specifications themselves was
10 rather difficult.

11 The technical specifications do call out
12 something specified as an actuation logic test, that
13 phrase is used in the technical specifications. The
14 description of that test in the technical
15 specification bases document seems to be consistent
16 with what you have up on this slide here, is that
17 correct?

18 MR. SCAROLA: Yes. I probably should have
19 added that annotation on that slide to make it clear.

20 CHAIRMAN STETKAR: Okay. So this is one
21 in the same. Okay. I at least understand what the
22 term means now.

23 MR. SCAROLA: This fulfills the ALT
24 requirement, the actuation logic test. There's also
25 a COT, channel operability test, which is the same

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 sort of test but on different controllers. Some
2 controllers we define it as a COT, some controllers
3 we define it as an ALT. In an attempt to follow the
4 standard technical specifications as much as could,
5 the distinction being in Westinghouse plants you have
6 the COT applied to 7300 racks if you're familiar with
7 Westinghouse. The analog processing racks.

8 CHAIRMAN STETKAR: Okay.

9 MR. SCAROLA: And the ALT is applied to
10 the SSPS, which is the solid-state protection system.

11 So we have controllers that mimic the
12 function of the analog processing racks. So we call
13 that software memory integrity test the COT. And we
14 have other controllers that mimic the function of the
15 solid-state protection system racks, so we call that
16 software memory integrity test an ALT.

17 In doing this, we may have caused more
18 confusion than we helped. But we were trying to line
19 up with the standard technical specifications as best
20 we could.

21 MEMBER BLEY: I think it probably helped.

22 I have a question. Back when you began
23 all this talk about the self-tests, the manual tests,
24 I thought I heard you say something about you were
25 trying to eliminate manual tests but the four manual

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 tests we just went through are intended, they're
2 going to be there? You're trying to minimize manual
3 calibrations and that kind of thing.

4 MR. SCAROLA: Yes. I think there are
5 actually three manual tests. There's only three. We
6 are trying to minimize --

7 MEMBER BLEY: I'm calling the last one
8 manual too, because that's manually started.

9 MR. SCAROLA: Yes, you're right.

10 MEMBER BLEY: Okay.

11 MR. SCAROLA: There are four manual
12 tests. You are correct. Because the safety VDU is a
13 manual test also. Yes.

14 I probably should have said we are trying
15 to minimize manual testing, not completely eliminate
16 it. We don't think we can --

17 MEMBER BLEY: That's fine. I just wanted
18 to make sure I didn't misunderstand.

19 CHAIRMAN STETKAR: Ken, tell me what
20 tests or combinations of these tests essentially does
21 the confirmation that you described in your
22 introduction, your initial introduction, the test
23 that confirms, indeed, when I have that two-out-of-
24 four low pressurizer pressure of signal coincidence
25 that I have an out put signal to your PIF module?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. SCAROLA: Okay. The two-out-of-four
2 logic is logic that's in the memory. So if we go to
3 continuing self-testing, we say inside the MELTAC
4 controller we are continuously verifying all the
5 application software. Well, the application software
6 includes two-out-of-four logic. That is part of the
7 application software. So that's the first place
8 where we verify that the two-out-of-four is in fact
9 still two-out-of-four. Then we do that diversely on
10 the last page, which is the diverse software memory
11 integrity tests where again, we look a that
12 application software using a different method of
13 memory checking to verify that it is still two-out-
14 of-four.

15 The actual generation of the output is
16 done through the TADOT.

17 CHAIRMAN STETKAR: Okay.

18 MEMBER BLEY: But the continuous self-
19 tests, you said also part of what they do is send
20 signals all the way through the system I think
21 somewhere in there you talked about that.

22 MR. SCAROLA: Yes. The measurement
23 channel signals are sent all the way through the
24 system.

25 MEMBER BLEY: Okay. As they're currently

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 being measured? You don't generate signals?

2 MR. SCAROLA: No. Go to the channel
3 calibration slide and you'll see it.

4 MEMBER BLEY: Yes, I have it there. On
5 the channel calibration slide?

6 MR. SCAROLA: Yes. Channel calibration
7 what it shows is that we are continuous -- excuse me.
8 Thirteen.

9 MEMBER BLEY: That's where I was, yes.
10 Okay.

11 MR. SCAROLA: Well, actually, it's a
12 continuous self-test. I probably could have done a
13 better job on the continuous self-test slide.

14 MEMBER BLEY: Yes.

15 MR. SCAROLA: Because this slide we're
16 actually reading the measurement device continuously.
17 That's part of the normal processing.

18 MEMBER BLEY: Yes.

19 MR. SCAROLA: So I should have actually
20 bolded that measurement device, bolded that
21 distribution module and bolded the signal path into
22 the MELTAC controller.

23 MEMBER BLEY: That's fine.

24 MR. SCAROLA: That really should have
25 been bolded.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER BLEY: Okay.

2 MR. SCAROLA: Because what we're sending
3 into that computer are the continuous --

4 MEMBER BLEY: The actual signal?

5 MR. SCAROLA: -- digitized measurement
6 values. So that's part of that continuous test.

7 MEMBER BLEY: Okay. In this system I
8 guess we have software in several places. There's
9 probably more than one place in MELTAC that there is
10 software running. There's software running over in
11 the PCMS.

12 MR. SCAROLA: And there's several MELTAC
13 controllers.

14 MEMBER BLEY: And there's several --

15 MR. SCAROLA: This is a greatly
16 simplified diagram.

17 MEMBER BLEY: Yes. And I assume as you
18 have improvements in the software or mods, they're
19 all changed at the same time? One gets changed when
20 there's a mod needed for it?

21 So what I'm kind of wondering about is
22 this isn't the place -- I mean, you're telling us one
23 thing here, but I'm kind of branching off into
24 Chapter 7, I guess. What I'll be interested in there
25 is on this a the possibility of one piece of software

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 being updated and somehow getting matched up with
2 something that's incompatible from a previous version
3 and one of the modules somewhere around this system.

4 How do we --

5 MR. SCAROLA: Well, configuration control
6 is a major Chapter 7 issue.

7 MEMBER BLEY: Okay. We'll wait for that.

8 MR. SCAROLA: And we have addressed it in
9 our software program manual, which is part of the
10 software life cycle.

11 MEMBER BLEY: Okay.

12 MR. SCAROLA: So, yes. I think it's a
13 very valid concern. What we can find in the system
14 is that the application software -- remember there
15 are two kinds of software inside a controller like
16 there are two kinds in your PC. You have the Windows
17 Operating System and then you have all the
18 indications --

19 MEMBER BLEY: Not on my PC?

20 MR. SCAROLA: Or in Apple. You have the
21 Apple and then you have all the application programs.
22 It is on our intent that the application programs
23 could be modified individually.

24 MEMBER BLEY: Yes.

25 MR. SCAROLA: But we expect all the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 operating systems in all the controllers to be
2 managed the same.

3 MEMBER BLEY: Exactly the same? Okay.

4 MR. SCAROLA: If there's an upgrade to
5 the operating system, it would be done across the
6 board.

7 MEMBER BLEY: It's the same across all of
8 them?

9 MR. SCAROLA: Yes. And the other thing
10 about the operating system, is that an only be done
11 by physically replacing the programmable read-only
12 memory. That can't be done by engineering. You have
13 to actually physically replace the integrated
14 circuits.

15 MEMBER BLEY: Okay. Thank you.

16 MR. SCAROLA: Entirely different process.

17 MEMBER BLEY: Well, we'll wait until
18 Chapter 7 and ask about that.

19 MR. SCAROLA: So in summary, we go to the
20 last slide. The US-APWR technical specifications are
21 essentially the same as the standard technical
22 specifications in most areas. I&C, as we saw, is one
23 area where we have differences.

24 The LCOs are actually the basic part of
25 the technical specifications require three operable

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 trains for four train systems. Now realize, not all
2 systems are four train systems. There are some two
3 train systems, for example containment isolation is
4 only a two train system. Main steam isolation. Most
5 of the isolation functions are two trains. But where
6 there are four trains, we require only three.

7 Where there are four channels in most cases we
8 require only three. There are some cases where we do
9 require four, so there are some variations in the
10 tech specs.

11 This all provides the framework for risk-
12 managed technical specifications and for the
13 surveillance frequency variations.

14 The method that we use for allowable
15 values for period surveillance ensures there's
16 sufficient margin preserved for unmeasurable
17 uncertainties. This was a major RAI from the staff.

18 We think we have now resolved this RAI. Of course,
19 the Chapter 7 guys are still reviewing that.

20 The one step surveillance method for
21 digital channels ensures total channel operability
22 equivalent to the two step methods of analog
23 channels. I would actually suggest that it's a better
24 method. It's not just equivalent; it's better because
25 its a total channel test.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 The digital portion of the system is
2 continuously self-tested including all setpoints and
3 logic. Now this is probably the biggest issue that
4 the Chapter 7 guys are wrestling with right now.
5 Because we test all the memory, have we convinced
6 them that we have gotten all the functions verified?

7 And of course, there's a combination of memory
8 integrity plus these actual manual tests and we
9 believe this is a sufficient combination to claim
10 that everything has been tested.

11 MEMBER BLEY: This, again, is not
12 particularly relevant to the technical specifications
13 in terms of periodic surveillance. It's more
14 relevant to -- I don't remember what it is. Chapter
15 13, I guess, where you talk about startup testing
16 programs and things like that. I think that's 13.

17 What type of at least functional tests
18 will be performed, and this again is probably just a
19 takeaway for Chapter 13, to at least verify those
20 functions in terms of what I call an end-to-end test,
21 at least before plant startup? And again, that's
22 probably Chapter 13. It's beyond necessarily what we
23 want to talk about today.

24 MR. SCAROLA: Certainly there will be
25 end-to-end factory acceptance tests. There will be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 end-to-end systems startup tests for each of these
2 I&C systems.

3 I can't speak to Chapter 13. I'm not
4 familiar with it.

5 MEMBER BLEY: Yes. We'll address that,
6 similar to some of the Chapter 7 stuff that we're
7 talking about.

8 MR. TAKASHIMA: This is Makoto Takashima.
9 Completely integrated tests.

10 CHAIRMAN STETKAR: Okay.

11 MR. TAKASHIMA: And we integrated all our
12 machine. And we have tested all functions in the
13 factory. But it's exactly that, other under Chapter
14 13 this is a factory accepted test.

15 CHAIRMAN STETKAR: Well, I understand the
16 factory accepted tests. I'm worried about after you
17 install it in the facility, connect the input sensors
18 to the plug-in units --

19 MR. TAKASHIMA: Oh, yes, yes.

20 CHAIRMAN STETKAR: -- and connect the
21 output devices into the output plug-in units and
22 making sure that indeed if I verify the input sensors
23 over the full range, not just about the trip
24 setpoint, but drive them to saturation at high and
25 low ends, that indeed the software will not respond

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 unexpectedly to those conditions.

2 MEMBER BLEY: You just hit on the way
3 I've seen in other applications where an out an area
4 that doesn't normally get tested --

5 CHAIRMAN STETKAR: Minimum maximum range.

6 MEMBER BLEY: -- because you don't expect
7 the plant to work there. But somehow a signal is
8 generated there and registers overflow and all of a
9 sudden things go squirrely.

10 CHAIRMAN STETKAR: Yes.

11 MEMBER BLEY: So that driving to
12 saturation idea kind of covers it.

13 CHAIRMAN STETKAR: Yes.

14 MEMBER BLEY: So that would be Chapter 7,
15 right?

16 CHAIRMAN STETKAR: 13 is where they
17 specify what's done in terms of startup testing.

18 MEMBER BLEY: Okay.

19 MR. TAKASHIMA: All testing, internal
20 will check in other chapter.

21 MEMBER BLEY: Yes, I understand. But
22 that's the box.

23 MR. TAKASHIMA: Of course we will check
24 with the transmitters and actual devices. And that
25 testing are discussed in Chapter 13.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: Okay. We'll get to
2 that when to get to 13 then.

3 MR. SCAROLA: And I think it's also
4 important to understand that when we talk about
5 technical specifications we're talking about formal
6 in writing part of your licenses basis test as
7 opposed to all the other things that in practice has
8 shown technicians do.

9 When they do this channel calibration,
10 we're not doing it just at the setpoint. We're
11 forcing them to send the signal from zero all the way
12 up to 10 percent and calibrate at zero, calibrate at
13 100. So during these calibration points, I don't
14 think they will ignore signals that say hey, the
15 system has gone wild and done something that's
16 unacceptable, even though the thing may calibrate
17 properly. So, you know, again, it's a difference
18 between what they do in actual practice versus what
19 are we going to document as licensing basis. The
20 licensing basis is the allowable value.

21 CHAIRMAN STETKAR: The other things is,
22 Ken, they don't do it, for example you can't
23 simultaneously calibrate live two or three of those
24 channels to saturation simultaneously and see how the
25 system responds to that, which is where other systems

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 at times have gotten into trouble.

2 MR. SCAROLA: But those are the things
3 that we would do during validation testing.

4 CHAIRMAN STETKAR: Yes.

5 MR. SCAROLA: Those are all part of our
6 V&V program. To put the system to put extraordinary
7 abnormal conditions.

8 I don't think it's practical to duplicate
9 that kind of testing --

10 CHAIRMAN STETKAR: Not necessarily on a
11 periodic surveillance, but in terms of confidence in
12 the fact that you've at least baselined or
13 benchmarked whatever you want to call it, the
14 installed system in the plant to confirm that it does
15 not respond in an unexpected way is I think an
16 important thing to do.

17 And then other surveillance and
18 administrative controls you have in place throughout
19 operations to give you confidence that that
20 benchmarked or baselined performances valid is more
21 the periodic surveillance that you're talking.

22 MR. SCAROLA: The only thing to keep in
23 mind is that the reason we develop software in phases
24 and we test it in phases is the smaller the module
25 that you're testing, the more different combinations

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 of inputs you can stimulate that module with.

2 As you get bigger and bigger and
3 ultimately finally get to the plant, it becomes more
4 and more difficult to establish so many different
5 combinations of test conditions. So we have to be
6 cautious of that.

7 Okay. Finally the last point of the
8 slide, is that the periodic surveillance tests
9 confirm not only system operability, but self-test
10 operability. And this is probably one of the things
11 that I&C Branch are wrestling with. To say, okay,
12 yes, do we have adequate manual tests so that we can
13 take credit for those automated tests. Kind of like,
14 okay, we got an automated test running but how do we
15 know it's really running? What tests the tester. And
16 this is the test of the tester.

17 MEMBER BLEY: Yes. This is kind of new
18 for us. I'm just kind of wondering if you get to a
19 manual test and you fail, that kind of means you got
20 to do some real digging to figure out what's going on
21 with your self-checking.

22 MR. SCAROLA: Well, realize there are
23 certain things that are not self-tested. So if the
24 failure is in a part that's not self-tested, that
25 would be expected. Okay, I found that. But if it's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 a failure of a part that self-tested and the self-
2 test missed it, I agree. Now we have a real issue.

3 MEMBER BLEY: And if you start getting
4 more of the first kind, you might need to figure out
5 ways to self-test but do more manual tests?

6 MR. SCAROLA: Absolutely. Absolutely.

7 MEMBER BLEY: Interesting.

8 MR. SCAROLA: Okay.

9 CHAIRMAN STETKAR: This was a great
10 presentation, by the way, on the calibration and I&C
11 stuff. Thanks.

12 I do have a couple of questions playing
13 way back from this. And that is as I read through
14 the technical specifications I start to think about
15 the systems that are actually in the plant. And I
16 haven't had the benefit of that of actually reviewing
17 the plant design, that'll come later, so
18 understanding the systems that are in there and some
19 of the subtle and nuance is not really feasible at
20 this point. But a couple of things that I noticed is
21 that, for example, the US-APWR design contains a four
22 train essential chilled water system, safety-related
23 system, and nothing with technical specifications on
24 that system. Why?

25 MR. HAMAMOTO: This is Hiroshi Hamamoto.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 This is separate cooling water for the
2 safety HVAC system.

3 CHAIRMAN STETKAR: Yes.

4 MR. HAMAMOTO: So the HVAC system, it
5 safety is a system.

6 CHAIRMAN STETKAR: Well, there's no
7 technical specifications on the HVAC systems either.
8 That was the next question.

9 I thought I'd start with chilled water
10 because it was more obvious. There is no technical
11 specifications on the HVAC systems. And there are no
12 technical specifications on the chilled water system.

13 MR. HAMAMOTO: I need to confirm. My
14 understanding is chilled water system including --

15 CHAIRMAN STETKAR: I couldn't find it.
16 If it's hidden in there, it's called something else.
17 I couldn't find it.

18 So the reason I'm curious about this is
19 that there's apparently been some discussion between
20 the staff. And I'm going to ask the staff about this
21 to telegraph things. About the process that was used
22 to identify which particular systems in the plant are
23 indeed covered by the technical specifications.
24 There seems to be some documentation through the RAI
25 process that a screening process qualitative or

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 perhaps quantitative was performed to identify risk-
2 important SSCs that are included in the technical
3 specifications and by implication things that are not
4 risk-important are not included in the technical
5 specifications.

6 So I was curious, for example, because I
7 couldn't find either chilled water or HVAC in the
8 technical specifications whether they were actively
9 screened out because they're not considered risk-
10 important, or were they screened out for some other
11 criteria, or are they simply not included?

12 I'm talking here about the process, you
13 know the scoping process for the technical
14 specifications themselves.

15 MR. SCAROLA: I guess we'll have to take
16 an action. I don't have an answer.

17 CHAIRMAN STETKAR: I'd be curious. I
18 mean, chilled water seemed pretty obvious to me. The
19 ventilation stuff I actually did some homework on and
20 there is some rationale about why some parts of the
21 ventilation systems might be included by being
22 subsumed within the technical specifications for the
23 equipment that's cooled. For example, ventilation for
24 a pump room is subsumed in the technical
25 specification requirements for that pump because it's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 a support system for that pump. And I can understand
2 that.

3 But looking into the designs of some of
4 the ventilation systems that are indeed shared
5 between multiple divisions there's not a one-to-one
6 divisional allocation in those ventilation systems
7 just because of the way that they're configured and
8 designed.

9 And of course, because the chilled water
10 system then cools those ventilation system, it's just
11 not clear how they're treated.

12 MR. SCAROLA: There are certainly
13 technical specifications related to the I&C portions.

14 Some of those systems. For example, the main
15 control room habitability and all the HVAC ducts that
16 have to close and revent, you know that's all in the
17 I&C technical specifications. So I can't--

18 CHAIRMAN STETKAR: Because the note here
19 says "Except for main control room." The main
20 control room ventilation seems to be covered pretty
21 well.

22 MR. SCAROLA: Right.

23 MR. HAMAMOTO: But basically support the
24 system for ECCS, it is basically forthright system.
25 And also the system is forthright.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: But there are some
2 areas. For example, Class 1E electrical switch gear
3 rooms where the way the system is designed instead of
4 having train A HVAC -- I don't remember whether you
5 call them 1, 2, 3, 4 or A, B, C, D. I'll call them
6 A, B, C, D.

7 Train A HVAC cooling the train A switch
8 gear room, and B cooling B, C and D. Trains A and B
9 are designed such that each train can cool both A and
10 B and has sufficient capacity to do that. So, for
11 example, you have now effectively a two functional
12 train ventilation system cooling four switch gear
13 rooms.

14 MR. SCAROLA: Correct.

15 CHAIRMAN STETKAR: So you can't say, for
16 example, if you remove train A ventilation from
17 service, it's the same as removing train A switch
18 gear. It just doesn't work that way.

19 And I don't know if there are other
20 samples. All I needed to do was find one example
21 where there are that type of different divisional
22 dependencies as opposed to a strict one-to-one
23 cooling for a particular pump room, for example.

24 So I think we'll leave it.

25 I'm curious about the chilled water and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 ventilation, but I'm more generally curious about the
2 process that was used to identify which particular
3 system structures and components are in the technical
4 specifications and which are not. Because if there
5 was some basis for screening out, for example, the
6 chilled water system, I'd really like to understand
7 what that basis is.

8 MR. SCAROLA: So we'll take that action.

9 MR. TJADER: This is Bob Tjader, Tech
10 Specs Branch.

11 Basically what in general we applied the
12 50.36 criteria for criteria for whether or not a
13 system should be included in the specs. And then,
14 you know, whether or not it is a system to mitigate
15 an accident or prevent a fission product barrier,
16 which would be under Criteria 1, mitigate an accident
17 Criteria 2; that type of thing. Apply those to the
18 systems.

19 Now Criteria 4 is whether or not the
20 system is risk-significant. I think the systems that
21 you referred to are support systems that support
22 other systems that are in technical specifications.

23 There are confirmed cooling water,
24 essential service water. There are, as you pointed
25 out, the control room habitability systems; those are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 in technical specifications.

2 Now we do have an RAI, and it's listed in
3 our set of RAIs, technical RAIs that are still open.

4 That is that we requested the analysis or the
5 application of Criteria 4 to their systems to confirm
6 that some of these systems that weren't incorporated
7 with the application of the standard technical
8 specifications, whether or not they should have been
9 incorporated or not. So we're awaiting that analysis
10 of the plant systems with respect to Criteria 4: The
11 risk incorporate through risk-significance.

12 CHAIRMAN STETKAR: Yes. Thanks. We'll
13 talk a little bit more about that I think when you
14 folks get up.

15 I think I only had -- I'm trying to read
16 through several notes here that again are not
17 organized very well.

18 Another question I think before MHI steps
19 down, and that is the -- let me read my notes here
20 for a second.

21 Silence is wonderful, isn't it?

22 Okay. The question I have is relates to
23 the gas turbines. And it doesn't really relate to the
24 gas turbines. It has nothing to do with the fact that
25 they're gas turbines. They could be anything. It

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 relates to the technical specifications for the day
2 tank, the gas turbine day tanks. There's a technical
3 specifications, and this is more of a curiosity that
4 I believe the technical specification says that the
5 day tank has to contain more than 600 gallons of
6 fuel. And I did a little bit of homework and as best
7 as I can tell, that 600 gallons of fuel will support
8 gas turbine operation for about 66 minutes at full
9 load capacity. It's a little more than an hour's
10 worth of fuel. That's fine. I mean, that might be
11 the design.

12 Does that mean that in practice you have
13 fuel oil transfer pumps that transfer fuel. This is
14 partly a technical specification question, but it's
15 more of a design-related question that's sort of
16 derived from this technical specification value.

17 You have fuel oil transfer pumps that
18 supply fuel from the storage tank to the day tank,
19 refill the day tank. If the day tank contains enough
20 fuel for about an hour's worth of operation, does
21 that mean the fuel oil transfer pumps cycle on and
22 off if the gas turbine needs to operate for a nominal
23 24 hour mission time, let's say. Does that mean that
24 those fuel oil transfer pumps cycle on and off,
25 something, 22, 23 times during that 24 hours?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. TAKASHIMA: This Makoto Takashima.
2 That's covered by the level of the day
3 tank.

4 CHAIRMAN STETKAR: So when the level goes
5 down, the transfer pumps comes on.

6 MR. TAKASHIMA: Yes. Yes.

7 CHAIRMAN STETKAR: High level of transfer
8 pump cycles off?

9 MR. TAKASHIMA: Yes. And that function
10 is a new function and I will check on this.

11 CHAIRMAN STETKAR: I was more curious
12 about just the design actually if I'm going to run
13 those turbines for 24 hours, do I have these pumps
14 coming on and off roughly once an hour or so?

15 MR. TAKASHIMA: Yes.

16 CHAIRMAN STETKAR: Okay. Check that.
17 Again, that's more probably when we get into Chapter
18 9 usually has the fuel oil transfer systems. But I
19 wanted to make sure that I had didn't think about
20 something that was incorrect here.

21 All right. I don't have any more
22 questions.

23 Any other members have any questions for
24 MHI?

25 ell, thank you very much. That was a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 really good presentation, especially the I&C stuff.

2 MR. SPRENGEL: Let me clarify what we are
3 going to get back.

4 CHAIRMAN STETKAR: Good.

5 MR. SPRENGEL: We had a long discussion
6 on the 90 day limitation. So we'll look into that and
7 get some clarification. Tied into that 10 CFR 50.59,
8 our statement of how that's tied in.

9 I'm not sure if we need to go any further
10 with taking credit for surveillance when we're
11 looking at --

12 CHAIRMAN STETKAR: That, I think we'll
13 probably get into that in Chapter 7.

14 MR. SPRENGEL: Yes.

15 CHAIRMAN STETKAR: You know, the basic
16 surveillance scheme and the philosophy.

17 MR. SPRENGEL: That discussion there.
18 And along with that, we'll be sure to touch on it in
19 Chapter 10 with the software update. And that will
20 come again later. But I think we covered it pretty
21 well here.

22 CHAIRMAN STETKAR: Yes.

23 MR. SPRENGEL: Chapter 13 we'll touch on
24 factor testing.

25 CHAIRMAN STETKAR: That again, will be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Chapter 13. But make sure you have it.

2 MR. SPRENGEL: Yes. And then we do need
3 to look into the --

4 CHAIRMAN STETKAR: I mean, that's an
5 example, but I'm more interested in what the process
6 is to identify the scope of systems that are in.

7 MR. SPRENGEL: And then need to do fuel
8 oil.

9 CHAIRMAN STETKAR: And that again, it's
10 more of a Chapter 9 type of --

11 MR. SPRENGEL: Yes. So a couple of these
12 to cover now, a couple of them we'll make sure to
13 incorporate in future presentations.

14 CHAIRMAN STETKAR: Yes. Yes. Yes. Good.
15 Thank you very much.

16 We have a break scheduled at 3:00. And
17 to avoid getting the staff up and then just
18 interrupting them as they're coming up to speed, I
19 think what we'll do is take a break a little bit
20 early now. And then continue with the staff after
21 the break.

22 So let's break until -- I'm still going
23 to be generous. Until 3:00.

24 (Whereupon, at 2:38 p.m. off the record
25 until 2:58 p.m.)

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: Okay. We're back in
2 session.

3 Hear from the staff's presentation on
4 Chapter 16.

5 And I just realized that do we have a
6 copy of the Staff's -

7 MR. CIOCCO: Yes, we do. My apologies.
8 I thought they were distributed.

9 MEMBER SHACK: There they are.

10 MR. CIOCCO: These are identical to the
11 ones that were sent.

12 MEMBER SHACK: SO they are the same as
13 the electric version?

14 MR. CIOCCO: Yes, they are.

15 Does everybody have one? For the rest of
16 you, they're in the back of the room.

17 Okay. John, are you ready?

18 CHAIRMAN STETKAR: I'm good.

19 MR. CIOCCO: Okay. My name is Jeff
20 Ciocco with the NRC staff. I'm the Lead Project
21 Manager.

22 Just briefly introduce you to our Chapter
23 16 Technical Specification, our staff experts. Then
24 we'll get into our specification.

25 On the staff review team, there's about

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 six individuals. two of them are going to present
2 today. Bob Tjader is the Team Leader. He's going to
3 cover the technical specifications risk-managed
4 technical specifications. And Joe DeMarshall is
5 going to present the instrumentation.

6 These other reviewers, they are here. If
7 you have any questions, we'll be happy to answer
8 them. But the way we've set up this presentation
9 today when we look at our next slide, we've issued
10 about 300 RAI questions, 290 on Chapter 16. A lot of
11 those have been resolved. Of the 54 open items,
12 that's where we focused our presentation today, the
13 majority being in the implementation area. Joe
14 DeMarshall and Bob Tjader is going to cover the rest.

15 And then there's 20 confirmatory items
16 where we have acceptable answers, we just need to see
17 them in the next update of the DCD, which would be
18 Revision 3.

19 So with that, I'm going to turn it over
20 to Bob Tjader. He's going to explain the areas where
21 we have our technical topics and the open items and
22 then get into our specific presentations.

23 MR. TJADER: Of the 54 open items the
24 technical topic that are yet to be resolved, that is
25 that we come to an understanding with MHI as to what

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the resolution is are in the list here. The others
2 we've come to some sort of conclusion, we just
3 haven't seen an input to. Some of the them are
4 redundant in nature, but this is basically the list
5 of technical topic open items. The ones that are
6 asterisked are the significant ones, the ones that
7 may have some impact on schedule, perhaps, that we
8 certainly don't see the end result immediately in
9 sight.

10 Okay. The next slide here.

11 The significant open items. They cover
12 the risk-informed technical specifications metrics
13 and instrumentation: The TADOT surveillance
14 requirements, the credit for continuous self-test and
15 self-test diagnostics and post accident monitoring
16 instrumentation.

17 The next slide.

18 Covering the risk-informed initiatives
19 proposed by US-APWR, they've proposed some of the
20 risk-informed initiatives including the two
21 significant initiatives of the risk-informed
22 completion times, otherwise known as Initiative 4b,
23 which is specified in technical specification 5.5.18,
24 the admin control section 5.5.18. The risk-informed
25 completion time is a real time calculation of a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 completion time based upon a quantified risk
2 assessment of the configuration of the plant at the
3 time and it is based upon a risk-management document
4 which we referenced in the admin control section of
5 the technical specifications, section 5.5.18, that is
6 the NEI 06-09 which contain the requirements for
7 risk-informed completion times.

8 And also the surveillance frequency
9 control program, otherwise known as Initiative 5b,
10 and that is it contains the requirements to perform
11 surveillances -- requirements to perform
12 surveillances remain in the technical specifications.

13 The frequencies, however, can be adjusted in
14 accordance with the control program. The program
15 uses both a quantitative and a qualitative criteria
16 to assess off-line the surveillances and to make a
17 determination in accordance with the NEI document 04-
18 10, which is also the guidance document. NEI 04-10 is
19 also referenced in the admin control section 5.5.19.

20 So in essence, it becomes a technical specification
21 requirements documents.

22 Now NEI 06-09 and 04-10 metrics the
23 guidance or requirements that we utilize to make
24 determinations for risk-informed completion times and
25 surveillance frequencies are based upon Regulatory

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Guide 1.174 and 1.177, 1.174 be the overriding
2 document. The metrics in these documents are
3 basically derived for existing plant today. There
4 has been a Commission policy back in the '90s that
5 says that in light of the fact that the new
6 generation of reactors will be safer, that safety
7 shall maintained.

8 And so the question comes and to whether
9 or not metrics for new reactors need to be revised or
10 that they need to be more stringent for the new
11 reactors. And if that is the case, then that may
12 necessitate a revision to the regulatory guidance
13 documents and including revisions to the NEI
14 guidance/requirements documents.

15 The next slide, please.

16 MEMBER SHACK: You don't buy their
17 argument that they're only setting up a framework and
18 therefore this all can be pushed off to the COL sage?

19 MR. TJADER: Yes. Yes, I do buy that to a
20 degree. And we're going to slightly get into that
21 there.

22 Basically what they have proposed, as an
23 aside, for these two initiatives 4b and 5b, they put
24 in brackets as an option for which the COL applicant
25 can adopt if they so desire, you know. And so if we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 do not have these resolutions at this point in time,
2 the COL applicant will just not, in essence, adopt
3 them at this time.

4 So the framework is there for the
5 applicant adopt. There is just one minor little area
6 where maybe there needs to be a revision in the DCD,
7 and that is when they reference those documents they
8 need to come up with appropriate revisions within the
9 admin control section of the technical
10 specifications. And I mention that later.

11 So, this is where I mentioned it. Impact
12 of quantified risk metrics if they're to revised for
13 new reactors. Last year we sent -- about a year or
14 so ago, we sent a information letter to the
15 Commission informing them of this issue and that we
16 would follow it up with either an information
17 document or an options document. But at any rate,
18 this very issue, in fact, will go before I believe
19 ACRS in a month or so and later in the year a paper
20 itself will go to the Commission. And depending upon
21 what is determined by that, will determine whether or
22 not we need to revise these documents and the degree
23 to which we need to revise these documents.

24 If we have to revise these documents in
25 accordance with what Mitsubishi says, they implied

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 there would be no change to the DCD, I say it's very
2 minimal and that is, i.e., the references to the NEI
3 06-09 and 04-10 will need to be themselves bracketed
4 so that the appropriate revision number of those
5 documents is included in the DCD. It would have to
6 be, but then it would be more complex and a departure
7 would be entailed.

8 Then with regard to the COL applicants
9 themselves it is a significant implication if the
10 metrics are not determined in an appropriate time.
11 And that is that if it's not in the DCD, the
12 applicants will not be able to adopt these two
13 initiatives, risk-information completion
14 time/surveillance frequency control program. At
15 least they will not be able to adopt them in
16 accordance with the DCD. They could go through a
17 much more convoluted process of departure or
18 something like that and conceivably they could have
19 themselves provide addendum to the requirements
20 documents and we could do it on an ad hoc basis like
21 that. But I don't see that as being feasible, in a
22 way, but I'm not going to rule it out. The
23 applicants are certainly free to propose what they
24 wish to propose.

25 But at any rate if the COL applicant does

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 not adopt these at the time that the COL is issues
2 but they desire to do that, the other path to
3 adoption of these initiatives is that once they get
4 their license, they would do it through the normal
5 license amendment process.

6 That is that big open issue with regard
7 to risk metrics at the moment.

8 Yes, go ahead, I'm sorry.

9 CHAIRMAN STETKAR: But again, Bob, in
10 terms of the staff's safety evaluation at least the
11 DCD stage today with the exception of references in
12 the DCD to specific versions or bracketed references
13 to regulatory guidance and NEI documents. There's no
14 staff review of any type of risk information for the
15 completion times or the surveillance. Is that at the
16 DCD stages?

17 MR. TJADER: At the DCD stage what would
18 be reviewed is where they incorporated into the
19 specs, and they've incorporated into a set of
20 specifications, and that set I think we find
21 appropriate at this point in time.

22 As far as the process of implementing
23 risk-informed completion completion times, that is
24 fully defined in NEI 06-09. There has been a safety
25 evaluation written on 06-09. 06-09 was treated, and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 04-10 were treated as topical reports. So there's
2 safety evaluations in those. That process and those
3 metrics that are incorporated in them for current
4 operating reactors have been fully vetted and
5 acceptable. If the Commission finds that for
6 operating purposes we don't need to revise metrics,
7 we could go forward with this immediately.

8 As far as the risk that is assessed at
9 this stage, the PRA Branch is assessing the DCD PRA
10 to the extent that they can. Obviously, the PRAs are
11 very much a plant-specific beast and I would say the
12 majority of that burden or the majority of that
13 effort would be when the COL comes in. Now it does
14 raise other issues as to whether or not the PRA, when
15 would that be acceptable for adopting the specs.

16 CHAIRMAN STETKAR: That's exactly my
17 whole point.

18 MR. TJADER: Right.

19 CHAIRMAN STETKAR: Is that the quality
20 and level of detail in the PRA must be sufficient to
21 support a risk-informed technical specifications
22 initiative, if you want to call it that.

23 MR. TJADER: Right. Yes. And that puts
24 a pretty big burden, actually, on the staff.

25 Go ahead, I'm sorry.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: Yes. But it's my
2 understanding that that -- and I recognize that it is
3 a large burden. That burden right at the moment
4 though will certainly not be incurred at least until
5 the COL stage.

6 MR. TJADER: That's right.

7 CHAIRMAN STETKAR: Okay.

8 MR. TJADER: But the burden is more than
9 just assuring that the PRA is adequate, which it
10 absolutely must be determined for this. The problem
11 is, is that for instance in the instrumentation area
12 all the pieces may not be together to fully complete
13 the PRA until just prior to fuel load or something
14 after the COL and we come up with a problem of we
15 have to, in accordance with the ISG-08 that was put
16 out a year and a half or two years ago, the technical
17 specifications have to complete at the time of
18 issuance. We have to in essence come up with a
19 program, a process that we're going to follow to
20 ensure that the PRA is adequate. Now that includes
21 both the Regulatory Guide 1.200 effort and also
22 another ISG, in fact, that we're in conjunction with
23 the PRA Branch developing at this time to ensure that
24 when the COL is issued we will have confidence that
25 we can determine that the PRA will be sufficient to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 support 06-09 and 04-10.

2 CHAIRMAN STETKAR: Thanks. That helps.

3 MR. TJADER: And then at this point I'd
4 like to turn it over to Joe DeMarshall, who is our
5 reviewer in the instrumentation area and he will
6 cover the open items in that area.

7 MR. DeMARSHALL: Okay. Trip actuating
8 device operational tests or TADOT surveillance
9 requirement.

10 The TADOT, as originally defined in the
11 standard technical specifications in NUREG-1431 was
12 revised under the GTS to accommodate aspects of the
13 fully digital MELTAC I&C platform design.

14 TADOT, as defined in Revision 2 of the
15 GTS, which is the current revision, states that there
16 are two types of binary devices: Those that have no
17 drift potential an those that do have drift
18 potential.

19 Next slide.

20 Details regarding this distinction are
21 included in the GTS definition which goes on to
22 state:

23 That the operability of binary devices
24 that have drift potentials be confirmed through
25 channel calibration and/or response time testing.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 While the channel calibration confirms the accuracy
2 of the device's binary state change with regard to a
3 strip setpoint requirement and the response time
4 testing confirms the accuracy of the device's state
5 time with regard to a trip timing requirement.

6 The GTS definition also states that the
7 operability of devices that have no drift potential
8 is confirmed through TADOT, and that the TADOT
9 confirms only the state change operability, i.e.,
10 there is no setpoint or timing accuracy conformation
11 needed.

12 In other words, the TADOT provides
13 confirmation of state change operability only and not
14 a confirmation of the accuracy of a binary device's
15 state change with regard to either trip setpoint or
16 trip timing requirement.

17 The last statement cited from the GTS
18 definition reads as follows: The TADOT shall include
19 adjustment, as necessary, of the trip actuating
20 device so that it actuates at the required setpoint
21 within the necessary accuracy. This statement appears
22 to be contradict the first three statements on the
23 slide with respect to what the TADOT surveillance is
24 actually confirming the operability of.

25 Next slide.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Okay. The staff is presently unable to
2 make a conclusive determination regarding the
3 capability of the TADOT to adequately verify trip
4 actuating device operability for designated functions
5 in LCOs 3.3.1, 3.3.2 and 3.3.5 on the basis of
6 ambiguities associated with TADOT performance
7 specifics that exist relative to information provided
8 in the definition for TADOT in Revision 2 of the GTS.

9 Specifically, is the TADOT a confirmation of states
10 inoperability or does it involve an adjustment of the
11 trip actuating device?

12 Next slide.

13 I probably have some overlap with Ken's
14 presentation with regard to this next topic, which I
15 also see as the biggest issue out there as far as
16 instrumentation.

17 Credit for continuous self-test and self-
18 diagnostics features.

19 Okay. The first bullet makes reference
20 to the protection and safety monitoring system, or
21 the PSMS. I'd like to at this time provide some
22 upfront information that will actually serve as a
23 good lead into the first bullet.

24 That with few exceptions the PSMS
25 encompasses all safety-related I&C systems in the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 plant including but primarily, the microprocessor-
2 based digital RPS and ESFAS systems. RPS and ESFAS
3 functional logic and algorithms are performed by PSMS
4 software, except for ones which are stored as digital
5 values that have no potential for variation. For the
6 digital PSMS the only factors that can result in
7 variations in the trip function are uncertainties
8 that are associated with the analog portion of the
9 system, such as the sensor, analog, following
10 circuitry and A to D, or analog to digital conversion
11 circuitry.

12 Okay. So the first bullet reads: The
13 US-APWR safety-related protection and safety
14 monitoring system includes continuous automatic self-
15 testing and on-line self-diagnostic monitoring to
16 verify the proper functioning of digital systems and
17 to ensure the integrity of the installed application
18 and system software.

19 The DCD credits these features as a means
20 of:

21 Eliminating manual surveillance tests of
22 functional logic and algorithms, setpoints, and
23 constants, specifically elimination of the
24 conventional channel operational test and
25 conventional actuation logic test for digital

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 equipment. The premise being that manual testing and
2 manual calibration are only provided for functions
3 with no self-diagnostics.

4 At this point, I'd like to briefly touch
5 on one significant aspect of the self-diagnostics.
6 PSMS self-diagnostic features continuously check the
7 software memory of the PSMS controller to verify that
8 the stored data has not been corrupted. And this is
9 accomplished via what is commonly referred to as a
10 memory checksum which Ken alluded to earlier.

11 And basically a checksum is a means of
12 checking the validity of a set of data by assuming
13 all the bytes of data and comparing that summation to
14 internally stores checks and values. And these
15 internally stored values are what are calculated
16 during PSMS controller initialization.

17 This continuous automatic assessment of
18 the software serves as the basis for elimination of
19 the conventional channel operational tests and
20 conventional actuation logic test surveillance
21 requirements for the digital PSMS.

22 Now at the risk of sounding redundant, I
23 want to reemphasize that last point. What we're
24 talking about here is elimination of the conventional
25 channel operational tests and the conventional

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 actuation logic tests surveillance requirements for
2 the digital PSMS, the digital equipment. It's
3 important to point out that the GTS in addition to
4 retaining the STS definitions for COT and ALT for
5 functions implemented via conventional analog by
6 stables has adapted the definition of these
7 surveillance requirements to accommodate the digital
8 PSMS and that's what Ken talked about previously with
9 the software memory integrity test. I'm just going to
10 briefly talk about that a little bit. So the COT and
11 the ALT for the digital equipment, PSMS, are what are
12 referred as software as software memory integrity
13 tests. These are manually initiated functions which
14 automatically compare the software memory of the PSMS
15 controller bit by bit with a calculator software
16 stored off- line. These functions are used during
17 periodic surveillance tests 24 months on a fuel cycle
18 basis to confirm that the software and the controller
19 is the same as the off-line version, and therefore
20 has not changed.

21 So what we're talking about is a 100
22 percent bit-by-bit check, it's a manual surveillance.

23 The way I would describe the self-testing the
24 continuous self-testing is more of an in between type
25 test. It's not a 100 percent test, not a 100 percent

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 bit-by-bit by test, it's not a representative sample
2 type test, it's an in between test, or basically it's
3 a checksum.

4 Checksum is a good check, however it's
5 not an infallible test. I could have a satisfactory
6 checksum value, but I could have two characters
7 transposed; I will still see the same checksum
8 value. That's where the software and memory
9 integrity check on the 24 month basis comes into play
10 and verifies that actual integrity.

11 Yet the COT and ALT surveillance
12 requirements for the PSMS provide a diverse check of
13 the software memory, including the memory that
14 controls all self-testing, the memory that controls
15 the automated trip functions and the memory that
16 contains all setpoints and constants.

17 Regarding the last two items, the DCD
18 also credits these features as a means of justifying
19 in part the completion times and surveillance testing
20 bypass times specified for certain LCO conditions,
21 and it also justifies in part, the frequencies
22 specified for certain surveillance requirements.

23 And the only thing I'd like to say about
24 those two items is that these features are just one
25 component of the justification.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Next slide.

2 Okay. So the PSMS continuous automatic
3 self-testing and on-line self-diagnostic monitoring
4 capabilities are being evaluated in Chapter 7 of the
5 SER to determine the extent to which these features
6 may be credited towards established requirements for
7 periodic surveillance testing of reactor protection
8 systems, and the justifications for several
9 completion times, surveillance testing bypass times
10 and surveillance frequencies in LCOs 3.3.1, 3.3.2 and
11 3.3.5.

12 Next slide.

13 Okay. Post-accident monitoring
14 instrumentation.

15 MEMBER BLEY: But we'll continue to have
16 an open item on the self-checking until Chapter 7 is
17 complete at a minimum.

18 MR. DeMARSHALL: Yes, that is correct.

19 Okay. Post-accident monitoring
20 instrumentation or PAM instrumentation.

21 COL applicant that reference the US-APWR
22 design certification must address Revision 4 of
23 Regulatory Guide 1.97 "Criteria for Accident
24 Monitoring Instrument for Nuclear Power Plants."

25 Revision 4 must be referenced because

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Revision 3 does not provide the criteria for advance
2 instrumentation system designs based on modern
3 digital technology.

4 PAM variable section criteria in
5 Regulatory Guide 1.97, Revision 4, depend on the
6 prior development of plant-specific emergency
7 operating procedures, EOPs, and abnormal operating
8 procedures, AOPs, which are post-COL activities.

9 Next slide.

10 COL applicants must complete site-
11 specific technical specification information in the
12 plant-specific technical specifications in accordance
13 with interim staff guides DC/COL-ISG-8 "Necessary
14 Content of Plant-Specific Technical Specifications
15 When A Combined License is Issued." This must be
16 done prior to COL issuance using one of three
17 options:

18 Option 1 provides site-specific technical
19 specification information or PAM function list
20 derived from Regulatory Guide 1.97 guidance which
21 cannot be done prior to COL issuance;

22 Option 2 provides useable bounding
23 information, ie., the development of a bounding list
24 of PAM functions, and;

25 Option 3 relocates the site-specific

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 information to a licensee-controlled document and
2 establishes an administrative control technical
3 specification that requires determining the
4 information using an NRC approved methodology and
5 that controls changes to the information, PAM
6 function list derived from Regulatory Guide 1.97
7 guidance.

8 Next slide.

9 MHI has proposed a useable bounding list
10 of PAM functions, which is Option 2. COL applicant
11 could incorporate the bounding list by reference.

12 And the staff is evaluating the proposed
13 PAM function list to determine if the list is truly
14 bounding. That is also a Chapter 7 review item.

15 Okay. The last slide. The staff
16 conducted a review and evaluation of the US-APWR DCD
17 which generated 290 questions with 54 remaining as
18 open items. Through the use of public meetings and
19 conference calls, the open items have been defined.

20 The staff and MHI have arrived at a
21 common understanding of the requirements that must be
22 satisfied. Presently, the staff concludes that
23 resolution of the 54 open items is manageable within
24 the planned schedule.

25 Upon resolving the open items, the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Chapter 16 US-APWR DCD will provide sufficient
2 information to assist a COL applicant in constructing
3 a US-APWR plant that satisfies the requirement of 10
4 CFR Part 52.

5 And that concludes my presentation.

6 MR. CIOCCO: And that's the end of the
7 Chapter 16 presentation.

8 MEMBER BLEY: Could you put a little
9 structure, a little more than we had that in that
10 first slide, into the 54 open items? Which are the
11 ones that could be troublesome and maybe fairly
12 difficult to get through? I assume those are the ones
13 that are going to be resolved in Chapter 7?

14 MR. DeMARSHALL: Yes. That's a good
15 question. Let me elaborate on that a little bit
16 here.

17 Forty-two of those 54 open items, they're
18 my issues. For example, 20 of them are the same or
19 similar issues between the trip system LCO ESFAS LCO
20 and the ESFAS LCO. So the way I wrote them up was I
21 wrote them up to make sure I was tracking them as
22 best we could. So that's actually ten issues. Twenty
23 RAIs, but ten issues.

24 The other thing, eighteen of those I put
25 together in a category that deals with completion

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 times, surveillance testing bypass times and
2 surveillance frequencies. And those, the reason I
3 did that was because there -- I grouped them that way
4 because there are a number of issues or a number of
5 reasons why associated with justification for those
6 times or surveillance frequencies. It could be a
7 combination of the continuous self-testing. It could
8 be automatic channel checks, continuous automatic
9 channel checks depending on which ones we're talking
10 about. It could be improved redundancy, and also
11 single failure criteria issues as well. So once
12 again, depending on which one we're talking about,
13 there are similar issues with those 17 RAIs.

14 MEMBER BLEY: Okay. Are you actually
15 doing the Chapter 7 reviews that are associated with
16 these issues?

17 MR. DeMARSHALL: I am on the Chapter 16
18 I&C technical specification reviewer, but I have been
19 working very closely with Chapter 7 on these issues.

20 MEMBER BLEY: Okay. You went through the
21 TADOT issue and I couldn't complete follow it. It
22 seemed to me as much definitional as technical. And
23 what are the key technical things you're hanging on
24 with respect to TADOT?

25 MR. DeMARSHALL: Well, the TADOT, it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 seems to be that the existing definition has
2 information that contradicts.

3 MEMBER BLEY: Yes.

4 MR. DeMARSHALL: In one case, where like
5 in the bottom bullet there it says "That the TADOT
6 shall include adjustment as necessary of the trip
7 actuating device at the requirement setpoint to
8 ensure the necessary accuracy." However, if you look
9 at the first bullet it states that with regard to the
10 trip setpoint that the channel calibration is what is
11 actually taking care of that requirement. And with
12 respect to the trip timing requirement, the timing
13 response test, a separate test is taking care of that
14 requirement.

15 If you look at the second and third
16 bullets it specifically states, and these are right
17 out of the definition, that the operability of the
18 devices that have no drift potential is confirmed
19 through TADOT. That its only confirming state change
20 operability.

21 The point I was trying to make was that
22 in one case we're saying it's an adjustment
23 associated with the trip actuating device, in another
24 -- and I have contradicting information that says
25 that it's not. That that information is actually --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER BLEY: But if I'm reading this
2 right, if they clarify these things, that's the
3 problem. It's not a technical issue, or is there a
4 technical issue buried in this that's troubling you?

5 MR. DeMARSHALL: Well, I'm not sure. And
6 the reason is, is because in the STS definition for
7 TADOT originally the adjustment of the trip actuating
8 device was part of that. And now once again, this is
9 Revision 2 of the GTS.

10 In Revision 1 that was taken out. That
11 was not incorporated into the Revision 1 definition.

12 The Revision 1 definition specifically stated that
13 the TADOT was associated with binary devices that had
14 no drift associated with them.

15 So now in Revision 2 I've got -- it's
16 telling me I'm doing both. I don't know. And am I
17 doing with a channel calibration with response time
18 testing or am I checking my setpoint requirements
19 with respect to accuracy with a TADOT.

20 MEMBER BLEY: Does staff have a position
21 on what it ought to be or where these things ought to
22 be cleared up, or are you just waiting for them to
23 clarify it so you see that everything's covered?

24 MR. DeMARSHALL: Well, I'm looking for
25 clarification. I personally -- it's a little muddy

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 to me is why I'm asking you about this.

2 MR. DeMARSHALL: But do you understand
3 the distinction I'm trying to make, though?

4 MEMBER BLEY: I think I do, but they seem
5 to me things that could be easily resolved rather
6 than real technical issues that you might not be able
7 to actually accomplish a test or the test won't be
8 able to give us the confidence that: (1) The
9 equipment's working right, or; (2) that the self-
10 test is working right.

11 MR. DeMARSHALL: Well, the thing that I'm
12 struggling with is that when I looked at Revision 1
13 and I wrote my RAIs, I identified the difference
14 between the standard technical specifications and
15 Revision 1 with respect to calibration or adjustment
16 of the trip actuating device and setpoint
17 requirements.

18 Now in Revision 2 that information was
19 retained as far as TADOT is supposedly only
20 associated with binary devices that have no drift
21 potential, but it also reintroduced the STS component
22 of the definition. It talks about I'm making
23 adjustments now with TADOT. I don't know what the
24 intent is, and maybe it is something as simple as a
25 wording thing or just massaging the definition. But

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 I'm confused as to what MHI is trying to do with the
2 TADOT with respect to the trip setpoint requirement.

3 I mean, it makes sense to me that that
4 could be done with a channel calibration. It makes
5 sense, but why that was re-introduced -- well not re-
6 introduced, but incorporated in the Revision 2 I
7 don't know.

8 MEMBER BLEY: Okay.

9 CHAIRMAN STETKAR: I have two or three
10 questions that, again, aren't related to I&C, kind of
11 out of left field and probably more in the expertise
12 of some of the other review areas.

13 I noticed that there was -- and the staff
14 actually had some questions about this. That there
15 was no requirement for instrumentation to initiate
16 containment purge isolation. And apparently the
17 justification for that was that in modes 5 and 6 the
18 only possible cause for release of radioactivity
19 would be a fuel handling accident and that the
20 Chapter 15 safety analysis for fuel handling accident
21 assumed that the containment was not isolated. And
22 that under that assumption the off-site doses from
23 those fuel handling accidents were acceptable.

24 MR. DeMARSHALL: Yes.

25 CHAIRMAN STETKAR: My question is why by

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 definition is a fuel handling accident the only way
2 that we can get a release of radioactivity during
3 modes 5 and 6?

4 MR. DeMARSHALL: Well, I think with
5 regards to your specific question, I was addressing
6 the footnote in the table. There was a Table 3.3.2-
7 1. The whole issue started with a footnote that
8 states "During movement of irradiated fuel assemblies
9 within containment." So that was a special condition
10 other than modes 1 through 4 per se.

11 Now that in the standard technical
12 specifications, that footnote, was an actual mode.
13 Whereas in the GTS it was removed, and it was removed
14 with the justification which you just stated, that
15 fuel handling accident was evaluated with containment
16 unisolated. But it is all associated with that
17 footnote.

18 CHAIRMAN STETKAR: And that's Table
19 3.3.2-1?

20 MR. DeMARSHALL: Yes.

21 CHAIRMAN STETKAR: I can't find that real
22 quickly.

23 I guess I still have a question. I know
24 why I can't find it, because I'm looking in the wrong
25 section.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 If I step back from all of that, I don't
2 particularly care about the Westinghouse technical
3 specifications at the moment. I care more about what
4 can happen. And as I understand the basis for this
5 is that is Mitsubishi has performed an analysis for
6 the fuel handling accident and said that if I have
7 the nominal fuel handling accident when I'm moving
8 fuel, because that's when you have it, and the
9 containment is not isolated, my off-site doses are
10 still acceptable. Therefore, I don't need a
11 requirement to have containment isolation capability
12 during those modes.

13 MR. DeMARSHALL: Right.

14 CHAIRMAN STETKAR: My question is why by
15 definition is the only source of a potential release
16 of radiation into the containment during mode 5 or 6
17 a fuel handling accident? Can I not have, for
18 example, a loss of coolant accident during mode 5 or
19 mode 6, or a loss of decay heat removal cooling
20 during mode 5 or mode 6 that could cause a much
21 larger release of radioactivity into the containment
22 then a fuel handling accident? That's why we do
23 shutdown modes, PRA example. Shutdown modes, PRA not
24 being an insignificant contributor to estimated risk.

25 So my question is why is simply the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 release of activity from damage to a single fuel
2 assembly the thing that determines the fact that I
3 don't need to have containment isolation capability
4 or radiation monitoring that would initiate
5 containment isolation during modes 5 and 6?

6 MR. DeMARSHALL: Yes. I understand --

7 CHAIRMAN STETKAR: And I don't know,
8 maybe the people who wrote the standard technical
9 specifications wrote the standard technical
10 specifications without considering shutdown modes
11 very carefully. You know, that's why I don't
12 particularly care about the standard technical
13 specifications, I'm looking at going forward.

14 MR. TJADER: You are right. I think the
15 original standard technical specifications did not
16 consider shutdown to the degree that they should
17 have.

18 CHAIRMAN STETKAR: That's right.

19 MR. TJADER: But that doesn't mean that
20 the only thing we're considering is the fuel handling
21 accident. I know that the PRA Branch has come up
22 with mid-loop operation as being a significant
23 activity and there's been an RAI addressed about
24 that, and MHI has agreed to enhance their RHR specs
25 in light of mid-loop operation. So it's not the only

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 one, and it's not the only one we're addressing.

2 CHAIRMAN STETKAR: It's just in this
3 particular case the rationale says that I don't need
4 to have operable I think it's radiation monitors that
5 would initiate containment isolation during those
6 modes because by definition the only accident that
7 could cause a release of radiation during those
8 modes, at least in terms of the supporting analyses,
9 is indeed a fuel handling accident. And I don't know
10 what the justification for that rationale is.

11 Because if you had a much larger release of radiation
12 into the containment and it was not isolated, it's
13 not clear that you would meet the dose acceptance
14 criteria that you do with a fuel handling accident.

15 Yes.

16 MR. LE: This is Hien Le from Technical
17 Specifications Branch.

18 For that particular issue, if you look at
19 the containment closure requirement was that
20 basically in mode 6 the containment closure
21 requirement there is two particular requirement that
22 you technically can when you consider these other
23 term for the accident dealing in that mode.

24 One requirement was a layer of a water to
25 be 23 feet above the flange. And the other one is a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 decay time.

2 In the STS in the current fleet the
3 technical specification have a decay time, but during
4 the various evolution of changing the technical
5 specification for current fleet, we've removed the
6 decay time requirement of the technical specification
7 and then drawn into the STS. So to capture the
8 containment closure requirement, the decay time to
9 add to water level is embedded into the containment
10 closure technical specification. For these new
11 design we ask the applicant to put in the decay time.

12 And then an order to a technical specification on
13 the water level. During that mode those two element
14 will fulfil the requirement in the Regulatory Guide
15 1.183.

16 So, if the applicant re-evaluate the fuel
17 handling accident to that Regulatory Guide, the staff
18 feel that they fulfilled the need for containment
19 closure. And the closure and the accident has been
20 analyzed under open containment, that means there is
21 no isolation requirement for high radiation.

22 CHAIRMAN STETKAR: Okay. Thank you.

23 I can see I'm not going to get very far
24 here. So let's make sure that Mitsubishi when they
25 explain their PRA for shutdown modes, when we get to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Chapter 19, convinces me that any accidents that they
2 evaluate during modes 5 and 6 have been evaluated
3 with the containment not isolated and see what,
4 indeed, the off-site releases are from those
5 accidents. So I'd be really interested to have
6 supporting analyses that, indeed, confirm that some
7 type of isolation capability is not required during
8 those modes.

9 I might be able to be convinced, but I'd
10 really like to see the supporting analyses to show
11 that. Because a fuel handling accident alone is not
12 adequate to do that.

13 A couple of other questions I had. And
14 the standard technical specifications do include a
15 limiting condition for protection against boron-
16 dilution events. And that LCO has been removed from
17 the US-APWR technical specifications. And apparently
18 the justification for that is that there's no
19 automatic features to protect against boron-dilution
20 in this particular design. And significant time
21 exists for manual actions to stop a dilution event.

22 And so I went over into Chapter 15 of the
23 DCD and looked at -- but careful with those. Our
24 reporter is loading up for you.

25 In Chapter 15 of the DCD when I looked at

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the supporting analyses for dilution events, I found
2 that the most limiting time for that operator action
3 was dilution that occurred during either shutdown or
4 hot standby conditions when, according to I guess
5 design-specific analyses, the time window, the
6 available time was 16 minutes. So, I was curious why
7 the staff would approve something based on the fact
8 that the operators have 16 minutes available to take
9 manual action to stop a dilution event?

10 The analyses during power operation,
11 depending on whether the rods are in auto or rods are
12 in automatic show time windows on the order of 61
13 minutes, if you want to be really precise if the rods
14 are in manual, or 73 minutes if the rods are in auto.
15 which sound like reasonable times. But 16 minutes
16 when you're shutdown and there are a lot of things
17 going on in the plant isn't an awful lot of time. So
18 I was so sort of curious about why that's adequate
19 justification.

20 And another related issue is that there's
21 no -- I don't think there is, a requirement for
22 closing -- let's see, a limiting condition that
23 addresses closing the block valve for a main steam
24 depressurization valve, main steam atmospheric relief
25 valve, whatever you want to call it. And there, too,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the justification for that is that operations actions
2 are required to open the main steam depressurization
3 valves and isolate the main steam depressurization
4 valve under the most limiting event, which is a steam
5 generator tube rupture. So that steam generator tube
6 rupture is identified as the most limiting accident
7 that affects operator actions to either open the
8 depressurization valves to depressurize the intact
9 steam generators and isolate the affected steam
10 generator.

11 So I went over to the safety analyses in
12 Section 15 of the DCD. And those safety analyses are
13 based on -- and this is a quote if you want to look
14 it up from Section 15.6.3.4.2 subpart C. It says:
15 "The actions to isolate the ruptured steam generator
16 are assumed to be completed within five minutes after
17 the reactor trip," and that's isolation. And that's
18 okay; if the block valve is closed, it's isolated.

19 Then 15,6.3.4.2 subsection D, dog says:
20 "Operators are assumed to start to reduce the RCS
21 temperature by opening the main steam
22 depressurization valves on the intact steam
23 generators five minutes after isolation of the
24 ruptured steam generator, or accumulative total time
25 of ten minutes." It assumed that those valves are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 opened in ten minutes after the initial indication.

2 So this is another case where now,
3 depending on whether you count five minutes plus five
4 minutes or just five minutes, is used as
5 justification for no limiting condition on those
6 block valves being closed.

7 MR. DeMARSHALL: So with respect to
8 instrumentation, you're thinking that possibly --

9 CHAIRMAN STETKAR: Well, this isn't an
10 instrumentation really. It's not a technical
11 specification saying that a block valve for a main
12 steam depressurization valve has a limiting time for
13 it. So, it's not instrumentation.

14 The first one was an instrumentation
15 because it's instrumentation --

16 MR. DeMARSHALL: Right.

17 CHAIRMAN STETKAR: -- to initiate the
18 containment isolation function for whatever those
19 accidents are in modes 5 and 6. This is not an
20 instrumentation. It's strictly an LCO allowed outage
21 time, let's say, for a time limit for the amount of
22 time that one block valve, two block valves, however
23 many block valves can be closed during power
24 operation. And there's no limit on that right now.
25 There is the standard technical specifications, but

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 this says well because it's the limiting accident
2 requires manual operator action anyway and sufficient
3 time is available, it doesn't make any difference
4 whether the operators have to open the block valves
5 and the depressurization valves or only the
6 depressurization valves.

7 Having been an operator if you don't
8 expect the block valves to be closed, and you go open
9 the depressurization valves and then get involved in
10 doing everything else you need to do in a steam
11 generator tube rupture, it might take a while for you
12 to figure out that nothing's depressurizing and what
13 that might be occurring.

14 So, it's another question. There was two
15 areas where I found that time windows assessed for
16 manual actions were used as justification for not
17 imposing any LCOs --

18 MR. DeMARSHALL: Right.

19 CHAIRMAN STETKAR: -- on instrumentation
20 in the first case and just allowed outage times in
21 the second case.

22 MR. DeMARSHALL: Right. On the boron-
23 dilution, I'll have to touch base with Chapter 15
24 people and --

25 CHAIRMAN STETKAR: And Chapter 15, you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 know, is used as -- I cited the sections for the
2 block valve stuff. It's just curious. Again, if the
3 time windows were half an hour to open up the
4 depressurization valves, I'd say well okay, fine. I'm
5 not going to worry about one valve versus two valves.

6 Or in the dilution event, as I said, for the time
7 windows during power, an hour or so --

8 MR. DeMARSHALL: I understand.

9 CHAIRMAN STETKAR: -- is a reasonable
10 amount of time.

11 MR. DeMARSHALL: Did you specify the
12 section for the blind --

13 CHAIRMAN STETKAR: Well, I can if I can--
14 -

15 MR. DeMARSHALL: I think it's somewhere
16 about 15.4.6.

17 CHAIRMAN STETKAR: It actually is.
18 You're really, really good. 15.4.6.3.3.2 is actually
19 where I found those time windows. Those are derived
20 time windows. They start out by saying, well, the
21 minimum time window must be greater than 15 minutes
22 to satisfy some type of analysis criteria. And, you
23 know, 16 minutes is more than 15 minutes, so they
24 won.

25 MR. DeMARSHALL: Understand.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: That's all I had.

2 Any other members have questions for
3 Chapter 16.

4 Thank you. Thanks again for the
5 presentation. It helped a lot, too, on the I&C stuff.

6 The blue screen of death here, which is pretty --
7 with that, I think that we finished the presentations
8 for today.

9 MR. SCAROLA: Mr. Chairman, Mitsubishi
10 would like to address the TADOT issue.

11 CHAIRMAN STETKAR: That would be
12 wonderful. We have time.

13 MR. SCAROLA: If you have the time for
14 it.

15 CHAIRMAN STETKAR: We have the time if
16 you have the ability. That's great.

17 MR. SCAROLA: I'm not sure that I have
18 the ability, but I've been asked to do it.

19 Ken Scarola.

20 I'd like to address this issue on TADOT.

21 And I have to agree with Joe, we have confusing
22 words in the technical specifications. We need to
23 clarify them. What I would like to attempt to do is
24 explain our intent, and then we're going to go fix
25 those words.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 There are two types of binary devices.
2 There are the types that need no adjustments. For
3 example, the manual initiation switches for ECCS,
4 containment isolation, these need to be periodically
5 checked. You need to hit the button, you need to
6 verify that the system gets the signal. That's a non-
7 adjustable binary device. It has no drift. It has no
8 mechanical adjustments. You simply are verifying that
9 there's a state change and we receive the signal
10 inside the digital system.

11 The other type of binary devices are
12 things like the under voltage relays that are sensing
13 loss of off-site power. Under voltage relays, they
14 have the potential for drift. They have to be
15 periodically adjusted.

16 There are two tests for the under voltage
17 relays. One is the TADOT, which is done about every
18 quarter, maybe every 92 days or something like that.

19 And we say that's not going to verify the setpoint.

20 That's simply a drop out test. Does the under
21 voltage sense that there's no voltage, does its state
22 change.

23 Then there's the 24 month channel
24 calibration where we actually verify that the under
25 voltage drops out at 89.5 percent, or whatever the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 setpoint is.

2 So what we tried to explain is there are
3 two tests. Since the total channel uncertainty, the
4 setpoint that we established for the under voltage
5 relay, considers that 24 month surveillance and the
6 amount of drift we can have over that period, there's
7 no reason to test the setpoint any more frequently.
8 We do, however, need to test the operability that it
9 in fact does drop and mechanical change state. So
10 there are two different tests there.

11 I don't think that the technical
12 specifications clarify why we have two specs. The
13 wording's not good. We definitely have to fix it.

14 The other case of an adjustable binary
15 device are the reactor trip breakers. Now the
16 reactor trip breakers get a TADOT, which is a state
17 change test, and they get a response time test. The
18 TADOT, again, is roughly a recorder, something like
19 that. The response time is every two years.

20 Now here's where this confusion comes in
21 about the adjustment during TADOT. The reactor trip
22 circuit breaker manufacturer is going to tell you to
23 test this thing every quarter, lubricate it and maybe
24 check some mechanical clearances with feeler gauges
25 and things like that. So you stick a feeler gauge

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 in, do I have the right clearance? No. So I make an
2 adjustment. That's different than a response time
3 verification.

4 So we were trying to say during the TADOT
5 we're going to make adjustments as recommended by the
6 manufacturer's tech manual. But we're not going to do
7 a response time test every quarter.

8 MR. DeMARSHALL: Ken, I know that --

9 MR. SCAROLA: We're going to do the
10 response time test every two years.

11 MR. DeMARSHALL: I know exactly what
12 you're referring to, and I'm sure you're aware of it.

13 In the first part of that definition it also talks
14 about adjustment to assure that the device for the
15 trip setpoint requirement.

16 MR. SCAROLA: Yes.

17 MR. DeMARSHALL: And that's what's --

18 MR. SCAROLA: And that's what is wrong.
19 We got to take those words "adjustment for the trip
20 setpoint" out of there and simply say "adjustment
21 according to manufacturer's recommendations," or
22 something like that.

23 MR. DeMARSHALL: So just so I'm clear for
24 the record. So with regard to trip setpoint
25 adjustment for setpoint requirements and accuracy

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 requirements, that's being done with channel
2 calibration every 24 months and response time tests
3 associated with that device being done every --

4 MR. SCAROLA: Every 24 months.

5 MR. DeMARSHALL: -- 24 months. And the
6 TADOT is strictly a confirmation of state change
7 operability?

8 MR. SCAROLA: With adjustment as
9 necessary according to manufacturer's
10 recommendations.

11 MR. DeMARSHALL: Right. But those
12 adjustments have nothing to do with the trip
13 setpoint?

14 MR. SCAROLA: Correct.

15 MR. DeMARSHALL: Okay.

16 MR. SCAROLA: So I fully understand why
17 the technical specification guys are having
18 difficulties with the words that we wrote because the
19 words don't accurately state what we're trying to
20 accomplish. We have to work on the words. But I
21 don't think we have a technical disagreement on what
22 we're trying to accomplish, and that's really what
23 your question is.

24 MEMBER BLEY: That's what I was after.
25 So thank you. This helps.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. SCAROLA: It is confusing.

2 MR. DeMARSHALL: The thing that where I
3 struggled with that, Ken, was once again in Revision
4 1 you know that initial component of the STS
5 definition was not part of the Revision 1 definition
6 and it specifically stated that it was only a state
7 change operability issue. And then when we went to
8 Revision 2, we retained that premise but then we
9 threw back in word-for-word right out of what was in
10 the STS with regard to adjustments for the trip
11 setpoint. And at that point, and when you add in the
12 part that you talked about with the adjustments that
13 you make regarding manufacturer's recommendations,
14 which is also in the definition, I didn't know what
15 was going on.

16 MR. SCAROLA: I have to apologize.
17 There's a root cause analysis right there as to how
18 we got it so confused, but I don't think we have a
19 technical issue.

20 CHAIRMAN STETKAR: But this helps a lot.
21 I mean, it sounds like there's a path to resolution
22 i this and that it's just a matter of making sure
23 that the technical specifications clearly define the
24 boundaries about what you're talking about.

25 MR. SCAROLA: Thank you.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: Anything from the
2 staff or Mitsubishi? Any members? Okay.

3 What I'd like to do now is go around the
4 table among the members and see if any of the members
5 have either any final comments or questions first.
6 And I'll start with Mario just because he's been so
7 quiet.

8 MEMBER BONACA: I thought it was
9 excellent presentations that we got today. And I
10 think the issues are pretty clear.

11 CHAIRMAN STETKAR: Okay. Bill?

12 MEMBER SHACK: No comments.

13 CHAIRMAN STETKAR: Dennis?

14 MEMBER BLEY: It's more on me than
15 anybody else. I thought they were great
16 presentations.

17 I need to spend a little time rummaging
18 through the revised setpoint technical report to see
19 if I understand the things that were talked about
20 today. I do that before we get to the chapters.

21 CHAIRMAN STETKAR: Well, good. I'll rely
22 on you then to do that, sir. You're on the hook. On
23 the record, too. Make sure he gets the transcript.

24 And I don't have any.

25 Again, I'd like to thank everybody.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 One other thing that I would like to ask
2 the members, and this will help our planning with the
3 staff and with Mitsubishi, and I think we can
4 probably go off the record for this. Because it's
5 more planning. So what I will do is I will close the
6 meeting.

7 DESIGNATED FEDERAL OFFICIAL COLEMAN: Oh,
8 wait, wait. Any public comments would need to be on
9 the record, if there are any?

10 CHAIRMAN STETKAR: I'm sorry.

11 DESIGNATED FEDERAL OFFICIAL COLEMAN: In
12 case someone here choose --

13 CHAIRMAN STETKAR: Is there anyone from
14 the public who have any other comments?

15 Thanks for reminding me. Hearing
16 nothing, then I can close the meeting.

17 (Whereupon, at 3:58 p.m. the meeting was
18 adjourned.)

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701



US-APWR

Design Certification Application

Tier 2: Chapter 2

June 7, 2010

Mitsubishi Heavy Industries, Ltd.

Contents



- 1. Overview of Chapter**
 - **Title of Chapter**
 - **Scope of Chapter**
- 2. Site Characteristics**
 - **Key Site Parameters**
 - **Outline of Subsections**
- 3. Major RAIs**
- 4. Summary**

1. Overview of Chapter

- Title of Chapter

Chapter 2: SITE CHARACTERISTICS

- Scope of Chapter

This Chapter includes geological, seismological, hydrological and meteorological characteristics.

COLA confirms site characteristics are bounded, or provides site-specific qualification.

2. Site Characteristics



➤ Key Site Parameters

Bounds estimated **75% to 80%** of US landmass.

Site is defined as contiguous real estate with legal right to control access by individuals, and to restrict land use.

Table 2.0-1 is a summary identifying specific site parameters for the US-APWR.

2. Site Characteristics (cont'd)



➤ Outline of Subsections

Section	Title	Description
2.1	Geography and Demography	Site Specific Characteristics
2.2	Nearby Industrial, Transportation, and Military Facilities	Site Specific Characteristics
2.3	Meteorology	<ol style="list-style-type: none">1. Normal winter precipitation roof load of 50 psf2. Extreme winter precipitation roof load of 75 psf3. 48-hr probable maximum winter precipitation of 36 in4. Maximum tornado wind speed of 230 mph<ul style="list-style-type: none">- Maximum rotational of 184 mph- Maximum translational of 46 mph

2. Site Characteristics (cont'd)



➤ Outline of Subsections (cont'd)

Section	Title	Description
2.3 (cont'd)	Meteorology	<ol style="list-style-type: none">5. Radius of maximum rotational speed of 150 ft6. Rate of pressure drop of 0.5 psi/s7. Maximum tornado pressure drop of 1.2 psi8. Tornado-generated missile characteristics in accordance with RG 1.76 Rev. 19. Bounding limits of atmospheric dispersion factors and deposition factors presented in Table 2.0-110. 155 mph extreme wind speed is for 3-second gusts at 33 ft above ground level based on 100-year return period, with importance factor of 1.15 for seismic category I/II structures

2. Site Characteristics (cont'd)



➤ Outline of Subsections (cont'd)

Section	Title	Description
2.4	Hydrologic Engineering	<ol style="list-style-type: none">1. Groundwater elevation minimum of 1 ft below plant grade2. Maximum level for flood or tsunami of 1 ft below plant grade3. Maximum rainfall rate, hourly of 19.4 in/hr and short-term of 6.3 in/5min
2.5	Geology, Seismology, and Geotechnical Engineering	<ol style="list-style-type: none">1. SSE peak ground acceleration = 0.3g2. SSE is based on Certified Seismic Design Response Spectra, enhanced spectra in high frequency range of RG 1.60 (further detail in Subsection 3.7.1.1)3. Maximum slope for foundation-bearing stratum of 20°4. Potential for surface tectonic deformation at site; None within the exclusion area boundary

2. Site Characteristics (cont'd)



➤ Outline of Subsections (cont'd)

Section	Title	Description
2.5 (cont'd)	Geology, Seismology, and Geotechnical Engineering	5. Subsurface stability <ul style="list-style-type: none">a. Minimum allowable static bearing capacity of 15,000 lb/ft²b. Minimum allowable dynamic bearing capacity, normal conditions plus SSE of 60,000 lb/ft²c. Minimum shear wave velocity at SSE input at ground surface of 1,000 ft/sd. Shear wave velocity of defining firm rock of 3,500 ft/se. Shear wave velocity of defining firm to hard rock of 6,500 ft/sf. Shear wave velocity of defining hard rock of 8,000 ft/sg. Liquefaction potential; None (for Seismic Category I structures)

2. Site Characteristics (cont'd)



➤ Outline of Subsections (cont'd)

Section	Title	Description
2.5 (cont'd)	Geology, Seismology, and Geotechnical Engineering	5. Subsurface stability (cont'd) h. Total settlement of R/B complex foundation of 6 in i. Differential settlement across R/B complex foundation of 2.0 in j. Maximum differential settlement between buildings of 0.5 in k. Maximum tilt of R/B complex foundation generated during operational life of the plant of 1/2000

3. Major RAIs



➤ Values and descriptions of some site parameters are revised and added based on RAIs as follows

Section	Parameter	DCD Rev.0	DCD Rev.2	Note
2.3 Meteorology	1. Normal winter precipitation roof load	100-year snowpack maximum snow weight	Normal winter precipitation roof load	Clarify scope of parameter [RAI 59-1086] (Value unchanged)
	2. Extreme winter precipitation roof load	50 psf	75 psf	Clarify design roof snow load [RAI 23]
	3. 48-hr probable maximum winter precipitation	-	36 in	Clarify design roof snow load [RAI 59-1086]
	4. Maximum tornado wind speed			
	- Maximum rotational	-	184 mph	Added tornado components [RAI 154-1643]
- Maximum translational	-	46 mph		

3. Major RAIs (cont'd)



Section	Parameter	DCD Rev.0	DCD Rev.2	Note
2.3 Meteorology (cont'd)	5. Radius of maximum rotational speed of 150 ft	-	150 ft	Added tornado components [RAI 154-1643]
	6. Rate of pressure drop	-	0.5 psi/s	(As above)
	7. Extreme wind speed	155 mph for 3-second gusts at 33 ft above ground level	155 mph for 3-second gusts at 33 ft above ground level based on 100-year return period, with importance factor of 1.15 for seismic category I/II structures	Clarify scope of parameter [RAI 23]

3. Major RAIs (cont'd)



Section	Parameter	DCD Rev.0	DCD Rev.2	Note
2.3 Meteorology (cont'd)	8. X/Q for MCR and TSC			
	a. X/Q for 4-30 days	-	-	Will modify to bound a reasonable number of sites [RAI 562-4427] See pages 19,20
	b. Source location	-	Change indoor source to a vent stack	Clarify realistic pathway [OPEN ITEMS RSAC 2.3.4] See pages 21,22
	c. Description of Source-receptor combinations	Combinations only of the shortest distance	All combinations	Add tables of combination for COL applicants [OPEN ITEMS RSAC 2.3.4] See pages 23 to 27

3. Major RAIs (cont'd)



Section	Parameter	DCD Rev.0	DCD Rev.2	Note
2.4 Hydrologic Engineering	3. Maximum rainfall rate - hourly	19.4 in/hr with importance factor of 1.2 for category I/II structures	19.4 in/hr for seismic category I/II structures	Remove erroneous reference to importance factor and clarify type of category [RAI 13]
	- short-term	6.3 in/5min with importance factor of 1.2 for category I/II structures	6.3 in/5min for seismic category I/II structures	(As above)

3. Major RAIs (cont'd)



Section	Parameter	DCD Rev.0	DCD Rev.2	Note
<p>2.5 Geology, Seismology, and Geotechnical Engineering</p>	<p>5. Subsurface stability</p> <p>a. Minimum allowable static bearing capacity</p> <p>b. Minimum allowable dynamic bearing capacity, normal conditions plus SSE</p> <p>c. Minimum shear wave velocity at SSE input at ground surface</p>	<p>Average static bearing capacity</p> <p>Average dynamic bearing capacity, normal conditions plus SSE of 95,000 lb/ft²</p> <p>Mean minimum shear wave velocity at SSE input at ground surface of “~1,000 ft/s”</p>	<p>Minimum allowable static bearing capacity</p> <p>Minimum allowable dynamic bearing capacity, normal conditions plus SSE of 60,000 lb/ft²</p> <p>Minimum shear wave velocity at SSE input at ground surface of 1000 ft/s</p>	<p>Clarify scope of parameter [DCD_OI_2.5.4] (Value unchanged)</p> <p>Clarify scope of parameter and value [DCD_OI_2.5.4]</p> <p>Clarify scope of parameter and value (MHI’s independent correction)</p>

3. Major RAIs (cont'd)



Section	Parameter	DCD Rev.0	DCD Rev.2	Note
2.5 Geology, Seismology, and Geotechnical Engineering (cont'd)	d. Shear wave velocity of defining firm rock	Mean minimum shear wave velocity for defining firm rock of "≥3,500 ft/s"	Shear wave velocity of defining firm rock of 3,500 ft/s	Clarify scope of parameter and value (MHI's independent correction)
	e. Shear wave velocity of defining firm to hard rock	Mean shear wave velocity for defining firm to hard rock of "~ 6,500 ft/s"	Shear wave velocity of defining firm to hard rock of 6,500 ft/s	(As above)
	f. Shear wave velocity of defining hard rock of 8,000 ft/s	Mean shear wave velocity for defining hard rock of "≥ 8,000 ft/s"	Shear wave velocity of defining hard rock of 8,000 ft/s	(As above)
	h. Total settlement of R/B complex foundation	-	6 in	Added settlement parameter [DCD_OI_2.5.4]
	i. Differential settlement across R/B complex foundation	-	2.0 in	(As above)

3. Major RAIs (cont'd)



Section	Parameter	DCD Rev.0	DCD Rev.2	Note
2.5 Geology, Seismology, and Geotechnical Engineering (cont'd)	j. Maximum differential settlement between buildings	-	0.5 in	Added settlement parameter [DCD_OI_2.5.4]
	k. Maximum tilt of R/B complex foundation generated during operational life of the plant	-	1/2000	(As above)

3. Major RAIs (cont'd)



Three major changes from the original DCD are based on the following RAIs:

- **Change of χ/Q for 4-30 days**
 - RAI NO.562-4427 REVISION 2, 4/23/2010
 - QUESTION NO. 02.03.04-9 a

- **Change of source locations**
 - OPEN ITEMS RSAC 2.3.4, 2/13/2009
 - Open Item 02.03.04-1

- **Description of additional information**
 - OPEN ITEMS RSAC 2.3.4, 2/13/2009
 - Open Item 02.03.04-6

3. Major RAIs (cont'd)



- 1) Change of χ/Q for 4-30 days
- RAI NO.562-4427 REVISION 2, 4/23/2010
 - QUESTION NO. 02.03.04-9 a.
 - The staff found that the 4-30 days χ/Q values for MCR and TSC were not bounding for 3 out of the 4 sites (North Anna, Clinton, Grand Gulf and Vogtle), and they were not representative of a reasonable number of US sites. The staff suggested that the 4-30 days χ/Q values increase to ensure they bound a reasonable number of sites.


3. Major RAIs (cont'd)



➤ 1) Change of χ/Q for 4-30 days

➤ ANSWER

- χ/Q for 4-30 days is raised up to 1.5 times of the present value, because the original value wasn't representative of a reasonable number of existing sites



3. Major RAIs (cont'd)



- **2) Change of source locations**
- **OPEN ITEMS RSAC 2.3.4, 2/13/2009**
 - Open Item 02.03.04-1
 - Some pathways, where the source location is inside the building, imply indoor transport and dispersion. The ARCON96 are not appropriate for modeling “indoor” transport and dispersion. If the reactivity in the spilled reactor coolant is assumed to be discharged to the atmosphere from the plant vent stack for the purposes of modeling MCR doses, then the plant vent should be identified as the release pathway.

3. Major RAIs (cont'd)




- 2) Change of source locations
- ANSWER

- Some source locations of the following accidents are changed to a plant vent from an inside-building.

- ① Failure of small carrying primary coolant outside containment
- ② Fuel handling accident in the fuel handling area

Although the above accidents occur inside a building, radioactive materials is discharged from a plant vent into the atmosphere. Therefore, the realistic pathway from a plant vent to a receptor should be taken.



Layout of US-APWR

3. Major RAIs (cont'd)



➤ 3) Description of additional information

➤ OPEN ITEMS RSAC 2.3.4, 2/13/2009

- Open Item 02.03.04-6
- DCD Tier 1 Table 2.1-1 and DCD Tier 2 Table 2.0-1 identify inleakage locations for some (but not all) of the postulated accidents and anticipated operational occurrences. COL applicants should be directed to evaluate χ/Q values for each inleakage location (i.e. class 1E electrical room HVAC intake, auxiliary building HVAC intake, and reactor building door) for each accident release point and compare the resulting bounding χ/Q values with the corresponding key site parameter values listed in DCD Tier 1 Table 2.1-1 and DCD Tier 2 Table 2.0-1.

3. Major RAIs (cont'd)



- **3) Description of additional information**
- **ANSWER**
- **The following information is described for COL applicants:**
 - All combinations of the sources and receptors for MCR and TSC, as well as the shortest distance combination used in the dose calculation
 - Source locations for each accident in Table 1
 - Locations of source and receptor is shown in Figure 1

3. Major RAIs (cont'd)



➤ 3) Description of source-receptor combination

➤ Figure 1 Layout

○ :Sources 1 to 9

△ :Receptors a to d for

- ▲ MCR intake
- ▲ MCR inleak
- ▲ MCR inleak and TSC intake/inleak

Location of Receptor

	Intake	Inleak
For MCR	a	b, c, d
For TSC	c	c

△ RECEPTORS

- a. Main Control Room HVAC Intake
- b. Reactor Building Door
- c. Auxiliary Building HVAC Intake and Technical Support Center HVAC Intake
- d. Class 1E electrical room HVAC intake




Figure 15A-1 Site Plan with and Intake Locations

3. Major RAIs (cont'd)



- 3) Description of source-receptor combination
- Table 1 Source Location of Accident Releases

Sheet 1/2

Accident	Source	Indication of location in Figure 1
Steam system piping failure	Main steam line	5
	Main steam relief valve and safety valve	6 and 7
RCP rotor seizure accident	Main steam relief valve and safety valve	6 and 7
Rod ejection accident	Plant vent	9
	Main steam relief valve and safety valve	6 and 7
	Ground level containment	1, 2, 3 or 4
Failure of small lines carrying primary coolant outside containment	Plant vent	9

3. Major RAIs (cont'd)



- 3) Description of source-receptor combination
- Table 1 Source Location of Accident Releases (cont'd)

Sheet 2/2

Accident	Source	Indication of location in Figure 1
Steam generator tube rupture	Main steam relief valve and safety valve	6 and 7
LOCA	Plant vent	9
	Ground level containment	1, 2, 3 or 4
Fuel handling accident in the containment	Plant vent	9
Fuel handling accident in the fuel handling area	Fuel handling area	8

4. Summary



- Chapter 2 defines site parameters of the US-APWR standard plant and also identifies important site parameters.
- COLA is to confirm that DCD site parameters envelope site-specific parameters.
- Table 2.0-1 is a summary identifying specific site parameters for the US-APWR.



Presentation to the ACRS Subcommittee

**Mitsubishi Heavy Industries, INC (MHI)
US-APWR Design Certification Application Review**

Safety Evaluation Report with Open Items

Chapter 2: SITE CHARACTERISTICS

June 7, 2010

Presentation Contents

- Staff Review Team
- Overview of Design Certification Application
- Discussion of Open Items
- Technical Areas of Interest
 - ◆ 2.1 Geography and Demography
 - ◆ 2.2 Nearby Industrial, Transportation, and Military Facilities
 - ◆ 2.3 Meteorology
 - ◆ 2.4 Hydrological Engineering
 - ◆ 2.5 Geology, Seismology, and Geotechnical Engineering

ACRONYMS

- COL – Combined License
- CSDRS – Certified Seismic Design Response Spectra
- D/Q – Deposition Factor ($1/m^2$)
- EAB – Exclusion Area Boundary
- LPZ - Low Population Zone
- MCR – Main Control Room
- OI – Open Item
- RAI – Request for Additional Information
- SE – Safety Evaluation
- SRP – Standard Review Plan
- TSC – Technical Support Center
- US-APWR – United States – Advanced Pressurized Water Reactor
- χ/Q – Atmospheric Dispersion Factor (sec/m^3)

Staff Review Team

- **Technical Staff**
 - ♦ **Seshagiri Tammara**
Siting & Accident Consequences Branch
 - ♦ **Brad Harvey**
Siting & Accident Consequences Branch
 - ♦ **Nebiyu Tiruneh**
Hydrologic Engineering Branch
 - ♦ **Weijun Wang (Presentation by Yong Li and Sarah Tabatabai)**
Geoscience and Geotechnical Engineering Branch 2
- **Project Managers**
 - ♦ **Jeff Ciocco – Lead PM**
 - ♦ **Mike Magee – Chapter PM**

Overview of Design Certification Application



SRP Section/Application Section		Number of RAI Questions	Number of SE Open Items
2.0	Site Characteristics	1	0
2.1	Geography and Demography	0	0
2.2	Nearby Industrial, Transportation, and Military Facilities	0	0
2.3	Meteorology	33	4
2.4	Hydrologic Engineering	13	0
2.5	Geology, Seismology, and Geotechnical Engineering	5	1
Totals		52	5

Description of Open Items

- **Open Item 02.03.04-8:** Provide χ/Q site parameter values for containment releases to all MCR inleakage locations
- **Open Item 02.03.04-9:** Consolidate containment release source/receptor information
- **Open Item 02.03.04-10:** Correct DCD Tier 2 Table 2.3-3 listing of CR intake and inleakage receptor heights
- **Open Item 02.03.04-11:** Increase 4-30 day MCR and TSC site parameter χ/Q values
- **Open Item 02.05.04-1:** Explain the difference between the original proposed and the revised minimum allowable bearing capacity values

Technical Topics of Interest

Section 2.1 - Geography and Demography



Section 2.1 - Geography and Demography

- The review involves the following sections of the US-APWR DCD:
 - ♦ 2.1.1 - Site Location and Description
 - ♦ 2.1.2 - Exclusion Area Authority and Control
 - ♦ 2.1.3 - Population Distribution
 - ♦ 2.1.4 – Combined License Information

The COL applicant is to provide this information as part of the COL application.

Technical Topics of Interest

Section 2.2 - Nearby Industrial, Transportation, and Military Facilities



Section 2.2 - Nearby Industrial, Transportation, and Military Facilities

- The review involves the following sections of the US-APWR DCD:
 - ♦ 2.2.1 - Locations and Routes
 - ♦ 2.2.2 - Descriptions
 - ♦ 2.2.3 - Evaluation of Potential Accidents
 - ♦ 2.2.4 – Combined License Information

The COL applicant is to provide this information as part of the COL application.

Technical Topics of Interest

Section 2.3 - Meteorology



Section 2.3 - Meteorology

- The review involves the following sections of the US-APWR DCD:
 - ♦ 2.3.1 – Regional Climatology
 - ♦ 2.3.2 – Local Meteorology
 - ♦ 2.3.3 – Onsite Meteorological Measurements Program
 - ♦ 2.3.4 – Short-term Atmospheric Dispersion Estimates for Design- Basis Accidental Releases
 - ♦ 2.3.5 – Long-term Atmospheric Dispersion Estimates for Routine Releases
 - ♦ 2.3.6 – Combined License Information
- The COL applicant is to provide this information as part of the COL application

Technical Topics of Interest

Section 2.3 - Meteorology



Meteorological Site Parameters

- The applicant identified meteorological site parameters related to:
 - ♦ Climate Extremes and Severe Weather
 - ♦ Atmospheric Dispersion (Accident & Routine Releases)
- A COL applicant needs to demonstrate that its site characteristics fall within the US-APWR site parameters
- The staff evaluated the US-APWR meteorological site parameter values to ensure they are representative of a reasonable number of sites that have been or may be considered for a COL application

Technical Topics of Interest

Section 2.3 - Meteorology



Climatic Site Parameters

- Winter Precipitation (for Roof Load Design)
 - ♦ Expected to be representative of a reasonable number of potential COL sites
- Tornado
 - ♦ Consistent with RG 1.76 Revision 1
- Extreme Wind Speed (other than in Tornado)
 - ♦ Expected to be representative of a reasonable number of potential COL sites
- Ambient Design Air Temperature
 - ♦ Expected to be representative of a reasonable number of potential COL sites

Technical Topics of Interest

Section 2.3 - Meteorology



Short-Term Dispersion Site Parameters for Design-Basis Accident Releases

- EAB and LPZ χ/Q Site Parameter Values
 - ◆ Expected to be representative of a reasonable number of potential COL sites
- CR and TSC χ/Q Site Parameter Values
 - ◆ **Open Item 02.03.04-11:** Increase 4-30 day MCR and TSC site parameter χ/Q values
 - ◆ **Open Item 02.03.04-8:** Provide X/Q site parameter values for containment releases to all CR inleakage locations
 - ◆ **Open Item 02.03.04-9:** Consolidate MCR source/receptor information
 - ◆ **Open Item 02.03.04-10:** Correct DCD Tier 2 Table 2.3-3 listing of CR intake and inleakage receptor heights

Technical Topics of Interest

Section 2.3 - Meteorology



Long-Term Dispersion Site Parameters for Routine Releases

- Site Boundary and Food Production Area χ/Q and D/Q Values
 - ♦ Expected to be representative of a reasonable number of potential COL sites

Technical Topics of Interest

Section 2.3 - Meteorology



COL Information Items

- COL Information Item 2.3(1)
 - ♦ Provide pre-operational and operational meteorological monitoring programs
 - ♦ Verify site-specific regional climatology and local meteorology are bounded by the US-APWR site parameters
- COL Information Item 2.3(2)
 - ♦ Provide design-basis accident χ/Q values per SRP Section 2.3.4
- COL Information Item 2.3(3)
 - ♦ Provide annual average χ/Q and D/Q values per SRP Section 2.3.5

Conclusion

Section 2.3 - Meteorology



- Except for the SE Open Items:
 - ♦ Applicant has identified an appropriate list of site parameters
 - ♦ The values assigned to each of the site parameters are expected to be representative of a reasonable number of sites that may be considered for a COL application

Technical Topics of Interest

Section 2.4 -Hydrologic Engineering



Section 2.4 – Hydrologic Engineering

- The review involves the following sections of the US-APWR DCD:
 - 2.4.1 Hydrological description
 - 2.4.2 Floods
 - 2.4.3 Probable Maximum Flood on Streams and Rivers
 - 2.4.4 Potential Dam Failures
 - 2.4.5 Probable Maximum Surge and Seiche Flooding
 - 2.4.6 Probable Maximum Tsunami Flooding
 - 2.4.7 Ice Effects
 - 2.4.8 Cooling Water Channels and Reservoirs
 - 2.4.9 Channel diversion
 - 2.4.10 Flooding Protection Requirements
 - 2.4.11 Low Water Considerations
 - 2.4.12 Groundwater
 - 2.4.13 Accidental Release of Liquid Effluents in Ground and Surface Water
 - 2.4.14 Technical Specifications and Emergency Operations Requirements
 - 2.4.15 Combined License Information

Technical Topics of Interest

Section 2.4 -Hydrologic Engineering



- Information in all the sections is site specific and will be provided by the COL applicant.
- Hydrologic Parameters
 - ♦ The applicant identified the following hydrologic parameters:
 - Maximum groundwater level (1 ft below finished grade)
 - Maximum flood (tsunami) level (1 ft below finished grade)
 - Maximum hourly rainfall rate (19.4 in/hr.)
 - Maximum short-term rainfall rate (6.3 in/5 min.)
- A COL applicant needs to demonstrate that its site characteristics fall within the US-APWR DCD site parameters
- Staff evaluated these parameters to determine the acceptability of the parameter values

Technical Topics of Interest

Section 2.4 -Hydrologic Engineering



- COL Information Item 2.4(1)
 - ♦ The COL applicant is to provide sufficient information to verify that hydrologic-related events will not affect the safety-basis for the US-APWR

Conclusion

Section 2.4 – Hydrologic Engineering



- The Applicant has provided plant specific hydrological site parameters and the Staff finds those acceptable.
- The Applicant has properly identified the site specific information to be provided as part of the COL application.
- The Applicant has satisfactorily answered all the RAI's and there are no open items.

Technical Topics of Interest

Section 2.5 – Geology, Seismology, and Geotechnical Engineering



Section 2.5 – Geology, Seismology, and Geotechnical Engineering

- The review involves the following sections of the US-APWR DCD:
 - 2.5.1 Basic Geologic and Seismic Information
 - 2.5.2 Vibratory Ground Motion
 - 2.5.3 Surface Faulting
 - 2.5.4 Stability of Subsurface Materials and Foundations
 - 2.5.5 Stability of Slopes
 - 2.5.6 Combined License Information
- The COL applicant is to provide this information as part of the COL application

Technical Topics of Interest

Section 2.5 – Geology, Seismology, and Geotechnical Engineering



- Establishes geotechnical site parameters for a candidate site
 - ♦ Minimum bearing capacity
 - ♦ Minimum shear wave velocity
 - ♦ Maximum settlement, etc.
 - ♦ Total settlement and differential settlement
 - ♦ Maximum tilt of R/B complex foundation during the plant's operational life
 - ♦ Maximum slope for foundation bearing stratum
- ♦ These parameters are expected to be representative of a reasonable number of COL and ESP sites

Technical Topics of Interest

Section 2.5 – Geology, Seismology, and Geotechnical Engineering



- Establishes other site parameters for a candidate site
 - ♦ No liquefaction potential for seismic category I structures
 - ♦ No surface tectonic deformation potential within the exclusion area boundary
 - ♦ These parameters are expected to be representative of a reasonable number of COL and ESP sites

Technical Topics of Interest


Section 2.5 – Geology, Seismology, and Geotechnical Engineering



- Establishes certified seismic design response spectra (CSDRS) for a candidate site (figure on next slide)
- Based on RG 1.60, anchored at a peak ground acceleration of 0.30 g, and enhanced in the high frequency range
- The US-APWR CSDRS is considered to be representative of general plant conditions in the US

Technical Topics of Interest

Section 2.5 – Geology, Seismology, and Geotechnical Engineering



Note: spectra for damping 0.5, 2, 5, 7, 10%.

Technical Topics of Interest

Section 2.5 – Geology, Seismology, and Geotechnical Engineering



- Open Item # 02.05.04-1:
 - ♦ Provide an explanation on the difference between the original proposed and the revised minimum allowable bearing capacity values

Technical Topics of Interest

Section 2.5 – Geology, Seismology, and Geotechnical Engineering



- COL information Item, 2.5 (1)
 - ♦ The COL applicant is to provide sufficient information regarding the seismic and geologic characteristics of the site and the region surrounding the site

CONCLUSION

Section 2.5 – Geology, Seismology, and Geotechnical Engineering

- Except for the SE Open Item:
 - ♦ Applicant has identified an appropriate list of geologic, seismologic and geotechnical site parameters
 - ♦ Applicant has properly identified the site specific information to be provided as part of the COL application
 - ♦ The values assigned to each of the site parameters are expected to be representative of a reasonable number of prospective COLA sites

Questions?



US-APWR

Design Certification Application

Tier 2: Chapter 16

June 7, 2010

Mitsubishi Heavy Industries, Ltd.

Contents



1. Overview of Chapter

- Title of Chapter
- Scope of Chapter

2. Features of Technical Specifications (TS)

3. Major RAIs

4. Summary

1. Overview of Chapter

- Title of Chapter

Chapter 16: Technical Specifications

- Scope of Chapter

This chapter includes the following categories of information as required by 10 CFR 50.36 and 10 CFR 50.36a.

Safety limits, limiting safety system settings, LCOs, surveillance requirements, design features and administrative controls.

2. Features of TS

➤ Features of US-APWR safety system design

- Design concept is based on current PWRs in the USA
- Four-train safety systems are one of the characteristic design features

➤ Features of US-APWR Technical Specifications

- Basically follow the Standard TS* (STS)
- Maximize the benefits of on-line maintenance (OLM)
- Provide the framework of Risk-Managed Technical Specifications (RMTS) and Surveillance Frequency Control Program (SFCP)

* NUREG-1431, Rev.03, "Standard Technical Specifications Westinghouse Plants"

2. Features of TS (cont'd)

➤ 2.1 Utilization of STS

- US-APWR Technical Specifications are almost the same as the STS of NUREG-1431
- US-APWR Technical Specifications differ from STS to reflect technical differences between conventional PWR designs and the US-APWR design
- Technical report* describes the justification for deviations between the STS and US-APWR TS

* Justification for deviations between NUREG-1431 and US-APWR Technical Specifications (Nov 2009)

2. Features of TS (cont'd)

➤ 2.2 Safety Benefits of Four-train systems

- Enhanced redundancy (50% x 4)
 - Capability beyond single failure criterion
- Maximize the benefits of on-line maintenance
 - TS LCO only require three operable trains
 - One train out of service is not allowed for more than 90 days in accordance with 10CFR50.59 and its guideline NEI 96-07*

* NEI-96-07, Revision 1, "Guidelines for 10CFR50.59 Implementation"

2. Features of TS (cont'd)

- **2.3 Main deviations between STS and US-APWR TS**
 - Characteristic design features
 - Four train safety systems (e.g. LCO is three of four SIS trains shall be OPERABLE)
 - Gas turbine generators (e.g. Fuel oil testing program)
 - Digital Platform (e.g. Actuation logic test interval increased)
 - Surveillance Interval
 - 24 month refueling cycle

2. Features of TS (cont'd)

- **2.4 Adoption of Risk Informed Technical Specifications Initiatives**
 - Initiative 4b: Risk-Managed Technical Specifications (RMTS)
 - ✓ This program allows Completion Time (CT) to be flexibly determined on site by a licensee using PRA result based on the real time plant configuration.
 - ✓ Developed in accordance with NEI 06-09
 - Initiative 5b: Surveillance Frequency Control Program (SFCP)
 - ✓ This program relocates Surveillance Frequencies (SF) to licensee control using PRA and operating experiences.
 - ✓ Developed in accordance with NEI 04-10

2. Features of TS (cont'd)

- DCD TS provide the framework of RMTS and SFCP and adoption of each program is specified as COL item.
- Actual Programs which include the PRA model qualified for these program as well as the station procedures will be established by the COL applicant who intends to implement them.
- The issue of risk metrics for new LWRs does not affect DCD TS.

3. Major RAIs

➤ 1) Setpoints – Allowable Value Calculation


- Allowable Value (AV) is the acceptance criteria for channel measurements during periodic surveillance
- NRC staff correctly commented that MHI's method of calculating AV does not provide sufficient allowance for those uncertainties not measured during the test.

$$\text{Total Channel Uncertainty} = \sqrt{\frac{\text{Unmeasurable Uncertainties}}{A^2 + B^2 + C^2 + \dots} + \frac{\text{Measurable Uncertainties}}{T^2 + U^2 + V^2 + \dots}}$$

$$\leq \sqrt{\frac{\text{Unmeasurable Uncertainties}}{A^2 + B^2 + C^2 + \dots}} + \sqrt{\frac{\text{Measurable Uncertainties}}{T^2 + U^2 + V^2 + \dots}}$$

3. Major RAIs (cont'd)

- MHI addressed this issue by revising the AV calculation method.




3. Major RAIs (cont'd)

➤ 2) Setpoints – Allowable Value Application

- AV is traditionally applied to setpoints during CHANNEL OPERABILITY TEST (COT)
- NRC requested more detail on MHI's application of AV to CHANNEL CALIBRATION for digital functions
- MHI's intent is to reduce the 2 Step surveillance traditionally applied to analog channels to 1 Step for digital channels
 - Less manual intervention to avoid human error
 - Reduced O&M labor

3. Major RAIs (cont'd)


Periodic Surveillance Analog Processing Functions – TWO STEPS



- Step 1 checks measurement device accuracy (eg. transmitter)

3. Major RAIs (cont'd)


Periodic Surveillance Analog Processing Functions – TWO STEPS



- Step 2 checks setpoint accuracy within I&C equipment rack
- Two steps are needed for analog channels due to separate analog drift contribution of measurement devices and I&C equipment racks


3. Major RAIs (cont'd)

Periodic Surveillance Digital Processing Functions – ONE STEP



3. Major RAIs (cont'd)

Periodic Surveillance Digital Processing Functions – ONE STEP



- ONE STEP checks total channel accuracy from measurement device to visual display unit, including all analog to digital processing
- ONE STEP is sufficient since digital setpoint drift contribution is negligible; digital setpoint has no adjustments

3. Major RAIs (cont'd)




➤ 3) Functional Verification Method

- Setpoints and logic functions are traditionally checked by direct manual verification
 - » Multiple signal injection – system response check
- NRC requested more detail on US-APWR verification method
 - a combination of self-testing and manual tests
- MHI's intent is to eliminate all manual functional verification tests
 - Less manual intervention to avoid human error
 - Reduced O&M labor


3. Major RAIs (cont'd)

Continuous Self-Tests




3. Major RAIs (cont'd)

CHANNEL CALIBRATION*



3. Major RAIs (cont'd)


Trip Actuation Device Operability Test (TADOT)*



*24 month

3. Major RAIs (cont'd)

Safety VDU Test*




*24 month

3. Major RAIs (cont'd)

Diverse Software Memory Integrity Test*

Compare controller Basic and Application software, including setpoints, constants, logic, self-test, to software copy in Engineering Tool; diverse comparison method from continuous self-test



Overlaps with continuous self-test; confirms system and self-test operability

***24 month**

4. Summary

- **US-APWR Technical Specifications are the same as the STS of NUREG-1431 in most areas.**
- **LCOs only require three operable trains for four train systems.**
- **Provide the framework of RMTS and SFCP.**
- **Allowable Values for periodic surveillance ensure sufficient margin is preserved for unmeasurable uncertainties.**
- **ONE STEP surveillance method for digital channels ensures total channel operability, equivalent to the two step method for analog channels.**
- **Digital portions of the system are continuously self-tested, including all setpoints and logic.**
- **Periodic surveillance tests confirm system operability and self-test operability through diverse methods.**



Presentation to the ACRS Subcommittee

**Mitsubishi Heavy Industries (MHI)
US-APWR Design Certification Application Review
SER-OI Chapter 16
Technical Specifications
June 7, 2010**

Staff Review Team

Technical Staff

- **Bob Tjader**, Lead Reviewer, Technical Specifications Branch (CTSB)/ Division of Construction, Inspection & Operational Programs (DCIP)
- **Hien Le / Travis Chapman**, Use and Application, LCO and SR Applicability, RCS System, ECCS Systems, Containment Systems, Plant Systems, Refueling Operations, Design Features & Admin Controls, CTSB/DCIP
- **Dayna Dority**, Electrical Power Systems, CTSB/DCIP
- **Rick Scully**, Safety Limits, Reactivity Control Systems & Power Distribution Limits, CTSB/DCIP
- **Joe DeMarshall**, Instrumentation, CTSB/DCIP

Project Management Staff

- **Jeff Ciocco**, Lead US-APWR Project Manager
- **Mike Takacs**, Chapter 16 Project Manager

RAI Status Summary

- Original Number of RAIs 290
- Number of RAIs Resolved 216
- Number of Open Items 54
- Number of Confirmatory Items 20

Technical Topics

Open Items

- TS Section 3.3 (Instrumentation) Issues
 - TADOT Surveillance Requirements (SR)*
 - Credit for Continuous Self-Test and Self-Diagnostics Features*
 - Post Accident Monitoring (PAM) Instrumentation*
- TS 3.4.9, Pressurizer Water Level LCO Value
- TS 3.4.12, LTOP Relief Valve single failure criteria met
- TS 3.5.2, ECCS Valve Operability Issues
- SR 3.8.1.8, power factor (pf) of .85 vs .9
- TS 3.9.4, Equipment Hatch Design Information
- TS 5.5.18 & 5.5.19, Risk-Informed Technical Specifications Metrics*
- T.S 5.5.21, Use of a Setpoint Control Program (SCP)
- Use of 10 CFR 50.36(c)(2)(ii) Criteria 4 on SSCs for Inclusion in TS

*To Be Discussed

Significant Open Items

TS 5.5.18 and 5.5.19

- Risk-Informed Technical Specifications Metrics

TS 3.3 Instrumentation

- TADOT Surveillance Requirement (SR)
- Credit for Continuous Self-Test and Self-Diagnostics Features
- Post Accident Monitoring (PAM)
Instrumentation

Risk-Informed Initiatives for US-APWR Technical Specifications Requiring Quantified Risk Metrics

- **Risk-informed completion times (Initiative 4b) ,TS 5.5.18**
 - “Real-Time” calculation of completion time (CT) based upon plant configuration and associated quantified risk assessment
 - Risk Management Guidance Document (NEI 06-09)
- **Surveillance frequency control program (Initiative 5b), TS 5.5.19**
 - Requirement to perform surveillance remains in TS, frequency adjusted outside TS in TS program using both quantitative & qualitative criteria
 - Risk-Informed Method for Control of Surveillance Frequencies (NEI-04-10)
- **NEI 06-09 & NEI 04-10 metrics are based on RG-1.174, “An Approach for Using Probabilistic Risk Assessment in Risk-Informed Decisions on Plant-Specific Changes to the Licensing Basis”**
- **Metrics for New Reactors may need to be revised, which would necessitate revisions to RG 1.174, NEI 06-09 & NEI 04-10 ?**
 - NEI 06-09 & NEI 04-10 are referenced in Admin Control Tech Specs

Impact if Quantified Risk Metrics are to be revised for New Reactors

- Paper has been sent to Commission presenting the Risk-Metrics issue.
- If Risk-Metrics are to be revised for New reactors, the impact on TS will be:
 - Minimal to DCD Generic TS, in that the references to NEI 06-09 and NEI 04-10 will need to be bracketed to allow applicants to reference the appropriate revision.
 - Significant to COL TS, in that applicants will not be able to adopt Risk-Informed Completion Times and Surveillance Frequency Control Program initiatives until revisions to RG 1.174, NEI 06-09 and NEI 04-10 are completed, IAW ISG-08; TS must be complete when COL is issued. Applicants would have to adopt later by license amendment.

TADOT Surveillance Requirement

- The TADOT, as originally defined in the STS (NUREG-1431), was revised under the GTS to accommodate aspects of the fully digital MELTAC I&C platform design.
- TADOT, as defined in Revision 2 of the GTS, states that there are two types of binary devices – those that have no drift potential and those that do have drift potential.

TADOT Surveillance Requirement (cont'd)

- The GTS definition also states the following:
 - The operability of binary devices that have drift potential is confirmed through CHANNEL CALIBRATION and/or RESPONSE TIME testing.
 - The operability of devices that have no drift potential is confirmed through TADOT.
 - The TADOT confirms only the state change operability (i.e., there is no setpoint or timing accuracy confirmation needed).
 - The TADOT shall include adjustment, as necessary, of the trip actuating device so that it actuates at the required setpoint within the necessary accuracy.

TADOT Surveillance Requirement (cont'd)

- The staff is presently unable to make a conclusive determination regarding the capability of the TADOT to adequately verify trip actuating device OPERABILITY for designated functions in LCOs 3.3.1, 3.3.2, and 3.3.5.
 - Ambiguities associated with TADOT performance specifics (i.e., adjustment versus confirmation) exist relative to information provided in the definition for TADOT in Revision 2 of the GTS.

Credit for Continuous Self-Test and Self-Diagnostics Features

- The US-APWR safety-related Protection and Safety Monitoring System (PSMS) includes continuous self-testing and self-diagnostics to verify the proper functioning of digital systems and to ensure the integrity of the installed application and system software.
- DCD credits these features as a means of:
 - eliminating manual surveillance tests of functional logic and algorithms, setpoints, and constants (e.g., Conventional Channel Operational Test, Conventional Actuation Logic Test) for digital equipment, and
 - justifying in part, the Completion Times and Surveillance Testing Bypass Times specified for certain LCO Conditions, and
 - justifying in part, the Frequencies specified for certain SR's.

Credit for Continuous Self-Test and Self-Diagnostics Features (cont'd)

- PSMS continuous self-testing and self-diagnostic monitoring capabilities are being evaluated in Chapter 7 of the SER to determine the extent to which these features may be credited towards established requirements for periodic surveillance testing of reactor protection systems, and the justifications for several Completion Times, Surveillance Testing Bypass Times, and Surveillance Frequencies in LCOs 3.3.1, 3.3.2, and 3.3.5.

Post Accident Monitoring (PAM) Instrumentation

- COL applicants that reference the U.S. APWR design certification must address Revision 4 of RG 1.97, “Criteria for Accident Monitoring Instrumentation for Nuclear Power Plants”.
- PAM variable selection criteria in RG 1.97, Revision 4, depend on the prior development of plant-specific Emergency Operating Procedures (EOPs) and Abnormal Operating Procedures (AOPs), which are post-COL activities.

PAM Instrumentation (cont'd)

- COL applicants must complete site-specific TS information in the plant-specific TS in accordance with DC/COL-ISG-8, “Necessary Content of Plant-Specific Technical Specifications When a Combined License Is Issued,” prior to COL issuance using one of three options:
 - Option 1 provides site-specific TS information (PAM function list derived from RG 1.97 guidance – cannot do before COL issuance).
 - Option 2 provides useable bounding information (i.e., development of a bounding list of PAM functions).
 - Option 3 relocates site-specific information to licensee-controlled document and establishes an administrative control TS that requires determining the information using an NRC-approved methodology and that controls changes to the information (PAM function list derived from RG 1.97 guidance).

PAM Instrumentation (cont'd)

- MHI has proposed a useable bounding list of PAM functions (Option 2). COL applicants could incorporate the bounding list by reference.
- The staff is evaluating the proposed PAM function list to determine if the list is truly bounding.

Staff Finding

- Common understanding between MHI and the staff of the requirements that must be satisfied and how to do so.
- Manageable within the planned schedule.
- TS are sufficient for COL applicants to satisfy the requirements of 10 CFR Part 52.

Discussion/Committee Questions