Official Transcript of Proceedings

NUCLEAR REGULATORY COMMISSION

Title: Advisor Committee on Reactor Safeguards Subcommittee on ESBWR

Docket Number: (n/a)

Location: Rockville, Maryland

Date:

Friday, September 24, 2010

Work Order No.: NRC-445

Pages 1-184

NEAL R. GROSS AND CO., INC. Court Reporters and Transcribers 1323 Rhode Island Avenue, N.W. Washington, D.C. 20005 (202) 234-4433

	1
1	
2	DISCLAIMER
3	
4	
5	UNITED STATES NUCLEAR REGULATORY COMMISSION'S
6	ADVISORY COMMITTEE ON REACTOR SAFEGUARDS
7	
8	
9	The contents of this transcript of the
10	proceeding of the United States Nuclear Regulatory
11	Commission Advisory Committee on Reactor Safeguards,
12	as reported herein, is a record of the discussions
13	recorded at the meeting.
14	
15	This transcript has not been reviewed,
16	corrected, and edited, and it may contain
17	inaccuracies.
18	
19	
0.0	
20	
21	
22	
	NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS
	(202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealroross.com
	(202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com

	2
1	UNITED STATES OF AMERICA
2	NUCLEAR REGULATORY COMMISSION
3	+ + + +
4	ADVISORY COMMITTEE ON REACTOR SAFEGUARDS
5	(ACRS)
6	+ + + +
7	SUBCOMMITTEE ON ESBWR
8	+ + + +
9	FRIDAY
10	SEPTEMBER 24, 2010
11	+ + + +
12	ROCKVILLE, MARYLAND
13	+ + + +
14	The Advisory Committee met at the Nuclear
15	Regulatory Commission, Two White Flint North, Room
16	T2B1, 11545 Rockville Pike, at 8:30 a.m., Michael L.
17	Corradini, Chairman, presiding.
18	SUBCOMMITTEE MEMBERS:
19	MICHAEL L. CORRADINI, Chairman
20	SAID ABDEL-KHALIK, Member
21	J. SAM ARMIJO, Member
22	CHARLES H. BROWN, Member
23	JOHN W. STETKAR, Member
24	
25	
	NEAL R. GROSS
	COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W.
	(202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com

1	CONSULTANTS:	
2	THOMAS S. KRESS	
3	GRAHAM B. WALLIS	
4		
5	DESIGNATED FEDERAL OFFICIAL:	
6	CHRISTOPHER L. BROWN	
7		
8	NRC STAFF:	
9	JOE ASHCRAFT	
10	AMY CUBBAGE	
11	THOMAS FREDDIE	
12	DENNIS GALVIN	
13	IAN JUNG	
14	HULBERT LI	
15	KHOI NGUYEN	
16	DINESH TANEJA	
17	DEANNA ZHANG	
18	JACK ZHAO	
19		
20		
21		
22		
23		
24		
25		
	NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. (202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgm	oss.com

			4
1	GENERAL ELECT	TRIC HITACHI:	
2	GARY AN	NTHONY (via telephone)	
3	J. ALAN	N BEARD	
4	SKIP BU	JTLER	
5	PATRICI	IA CAMPBELL	
6	ROMEO F	EL DACCACHE	
7	BRAD JO	DHNSON	
8	RICK KI	INGSTON	
9	WAYNE N	MARQUINO	
10	IRA POP	PPEL	
11	PETER Y	YANDOW	
12			
13	ALSO PRESENT:	:	
14	WILLIAM	M BIRD, LOCKHEED MARTIN	
15	KIMBERI	LY KEITHLINE, NEI	
16	JOHN SM	AITH, WSC	
17			
18			
19			
20			
21			
22			
23			
24			
25			
		NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS	
	(202) 234-4433	1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701	www.nealrgross.com

	5
1	AGENDA
2	OPENING REMARKS AND OBJECTIVES6
3	Chairman Corradini, ACRS
4	STAFF OPENING REMARKS11
5	Amy Cubbage, NRO
6	CHAPTER 7: INSTRUMENTATION AND CONTROL SYSTEMS11
7	GEH - Skip Butler, Peter Yandow,
8	Ira Poppel
9	CHAPTER 7: INSTRUMENTATION AND CONTROL SYSTEMS95
10	GEH - Skip Butler, Peter Yandow,
11	Ira Poppel
12	CHAPTER 7: INSTRUMENTATION AND
13	CONTROL SYSTEMS160
14	NRO – Dennis Galvin, Hubert Li,
15	Joe Ashcraft, Dinesh Taneja, Ian Jung
16	
17	
18	
19	
20	
21	
22	
23	
24	
25	
	NEAL R. GROSS
	(202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com

	б
1	PROCEEDINGS
2	(8:30 a.m.)
3	CHAIRMAN CORRADINI: Okay, so we'll come to
4	order. This is the second day of the ACRS
5	Subcommittee meeting on the ESBWR application. My
6	name is Mike Corradini, Chair of the Committee. We
7	have with us today our consultants, Dr. Tom Kress, and
8	Graham Wallis. Member Sam Armijo soon to be, John
9	Stetkar, myself, Dr. Said Abdel-Khalik, and Charlie
10	Brown. Our Designated Federal Official is Christopher
11	Brown.
12	I'll skip through all the preliminaries,
13	and simply remind everybody that a transcript of the
14	meeting is being kept. It will be made available on
15	the Federal Register. It's requested that speakers
16	first identify themselves, and speak with sufficient
17	clarity and volume so they can be heard.
18	Everybody please check your cell phones,
19	pagers, appliances, silence them. All right? We've
20	not received any request from members of the public to
21	make oral statements. Do we have GEH folks on the
22	phone line as we did yesterday?
23	PARTICIPANT: We do.
24	CHAIRMAN CORRADINI: Okay. All right. And
25	then we are under the impression, and I'm going to
	NEAL R. GROSS
	COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE N.W.
	(202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com

7 make this clear to the GE presenters, that we're not 1 2 presenting proprietary information relative to Chapter If we delve into proprietary matters, 3 7 I&C issues. 4 and we need to close the session, you need to let us 5 know. We can maybe postpone those questions until after break and pick them back up. All right? 6 7 Other than that, I am told that the GEH 8 folks have some clarification, or information from 9 what had open questions, just we as or open informational items from yesterday. 10 So, Wayne, are 11 you going to lead us in that? MR. MARQUINO: Alan Beard is. 12 CHAIRMAN CORRADINI: Oh, Alan is. 13 Okay, 14 I'm sorry. 15 MR. BEARD: That's all right. Alan Beard 16 with GE Hitachi. Two issues to follow up from 17 yesterday. The first dealt with the potential for valve misalignment to draining of the suppression 18 pool, or the GDCS pools, the mechanism up through the 19 surge tanks. 20 21 CHAIRMAN CORRADINI: Okay. MR. BEARD: Some information we delve out 22 23 The lines that connect both the suppression on that. pool and the GDCS are 10 inches in diameter. 24 The 25 suppression pool has safety-related isolation valves **NEAL R. GROSS** COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

on that system; however, they are manually actuated. 1 2 There is no automatic actuation on those. CHAIRMAN CORRADINI: Say that again. 3 I'm 4 sorry. 5 MR. BEARD: The suppression pool suction lines, there are safety-related containment isolation 6 7 values on them, that they are motor operated, and they 8 require manual or a signal form the -- via manual 9 operation in the control room. Signals that would be 10 available to the operator to detect that he was having 11 some sort of situation like that would be a decreasing level within the suppression pool, or a rising level 12 within the surge tank of the spent fuel pool, so that 13 14 there should be plenty of time to do that. With a 10-15 inch line and approximately 5-1/2 meters of head, we could estimate that the flow would be not tremendous. 16 17 It would certainly be a significant amount, but not a huge volumetric rate. 18 As far as the connection to the gravity-19 driven cooling system pools --20 21 CHAIRMAN CORRADINI: Could I just stop you just for clarification? 22 23 MR. BEARD: Yes, you may. 24 CHAIRMAN CORRADINI: So, the time window 25 for them to see this is based on an annunciator that **NEAL R. GROSS** COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. (202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com

	9
1	would show a low level, and they'd have to take
2	action?
3	MR. BEARD: That would be correct.
4	CHAIRMAN CORRADINI: Okay. Thank you.
5	MR. BEARD: Normal operating level in the
6	suppression pool is 5.45 meters, high level if 5.5
7	meters, low level is 5.4, so you would drain if you
8	were operating at the high end of the band,
9	potentially a tenth of a meter from the suppression
10	pool before you would get the alarm that the level was
11	dropping.
12	CHAIRMAN CORRADINI: Okay.
13	MR. BEARD: I would expect that if you're
14	doing that, the first alarm that you would get would
15	be the surge tank level going high.
16	CHAIRMAN CORRADINI: Okay. Thank you. I'm
17	sorry. And then you wanted to go forward with GDCS.
18	MR. BEARD: Yes. As far as the GDCS pool
19	suction, this was alluded to yesterday by John Gels on
20	the phone from Wilmington. There are a scupper type
21	of arrangement, and you can actually see this
22	pictorially in Figure 9.1-1. The water that has been
23	cooled, and is being returned to the GDCS pools is
24	actually introduced into the center pool, which is
25	labeled B on that drawing, and then it overflows
	NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

ļĮ

10 1 through connections into the A&C pools. And then 2 there are scupper suctions within the A&C pools to 3 take that water, route it to the point. We're not 4 exactly sure what the level of those are, but the 5 scuppers are towards the top of the pool, so that the amount of water that could be lost in there would be 6 7 fairly minimal. 8 The other question I was going to respond 9 to was Mr. Stetkar's concern about load handling, and 10 a statement about any radiological release --11 CHAIRMAN CORRADINI: Why don't we -- can we hold that until we have him? 12 13 MR. BEARD: Yes. 14 CHAIRMAN CORRADINI: Okay. And we'll find 15 him, and have him later. We'll catch up to you. Is 16 that all right? 17 MR. BEARD: Yes. 18 CHAIRMAN CORRADINI: Okay. MR. BEARD: And then the final thing, to go 19 20 back, I did make a statement in error yesterday. Ι 21 said that the rooms that house the FACPS pumps have 22 watertight doors on them. Apparently, at some point I 23 missed a design change. Those rooms actually do not 24 have watertight doors on them, so I need to correct 25 that for the record. **NEAL R. GROSS** COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

	11
1	CHAIRMAN CORRADINI: Okay. And we'll wait
2	on the heavy load handling, and the other question,
3	Alan, until all the members are here.
4	So, Amy, did you want to say anything to
5	lead us off here?
6	MS. CUBBAGE: No, we're just pleased to be
7	here to continue with the meeting, and get to some
8	challenging issues here on I&C. The Staff and GE have
9	done a lot of work to prepare for this meeting. We're
10	very hopeful that it'll address the Committee's
11	concerns that have been expressed in the past, and
12	look forward to your questions. And, hopefully, we
13	can get them all answered today.
14	CHAIRMAN CORRADINI: Okay. And of the trio
15	that's up there, who's going to lead us off, is it
16	Skip, or you?
17	MR. BUTLER: I'll kick it off.
18	CHAIRMAN CORRADINI: Okay.
19	MR. BUTLER: And then when we get into
20	portions of the technical material, Ira Poppel, who's
21	the Principle Engineer and Lead Designer for the I&C
22	DCIS will lead those discussions.
23	CHAIRMAN CORRADINI: Go ahead.
24	MR. BUTLER: Okay. So, next chart, please.
25	Okay. So, just a brief overview of the agenda. We
	NEAL R. GROSS
	COURT REPORTERS AND TRANSCRIBERS
	1323 RHODE ISLAND AVE., N.W. (202) 234,4433 WASHINGTON D.C. 20005 3701 WWW poekaress com

1 will highlight changes from Rev. 6 through 7 and 8, 2 briefly. We'll talk about the ACRS letter on DAC on August 9^{th} , 2010. And then we decided in GEH to 3 4 proactively address some of those concerns after doing 5 an internal assessment, and perhaps not having the content in tier two that was appropriate, so we'll 6 7 discuss that. We'll present some of the key themes 8 from the letter in our design, and then we'll present 9 a key topic to some of the ACRS Members on logic diagrams. And then, if necessary, we have a number of 10 11 backup slides that we might ask to go to if there's some additional discussions. Okay, next slide. 12 So, from Rev. 6 to Rev. 8, when we were 13 here last on the 22nd of October, there's been a number of RAIs, three specifically for Chapter 7. One of them had to do with set point methodology, which is not germane to this particular discussion today, I

14 15 16 17 18 think. There was one in November on digital devices, and we clarified some ambiguity in our licensing 19 topical reports, that yes, all digital devices that 20 21 involve software or firmware are covered by our LTRs. 22 And then there was a clarification on GDCS equalizing 23 valves, and some information regarding when they 24 actuate with regards to sustained levels.

25

MS. CUBBAGE: Skip, if I may just for the

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

	13
1	Members' benefit, when he refers to DCD Rev.8, DCD
2	Rev. 8 has not been formally docketed as a whole DCD
3	yet, but GE has docketed recently some change pages to
4	Rev. 8, and they're going to be speaking to those
5	today. The Committee has not received those. They
6	just came in, I believe, yesterday, but we'll be happy
7	to get those to you.
8	CHAIRMAN CORRADINI: So, just to clarify
9	for the Committee, so Rev. 8 is be the one that is
10	going to be docketed with all the necessary
11	information that allows Staff that, essentially,
12	answers the RAIs, and, therefore, closes all the open
13	items.
14	MR. BEARD: That's right, in addition to
15	these changes that GE has recently made in preparation
16	for this meeting.
17	CHAIRMAN CORRADINI: Okay. Thank you. Go
18	ahead.
19	MR. BUTLER: So, as I noted, we were also
20	able to read the letter issued on the 9^{th} of August,
21	which gave us an opportunity to critique Tier 2, and
22	most of this presentation is centered around sort of
23	enhancing the design detail information in Tier 2 to
24	sort of address that letter.
25	And then we have ECAs and CARs, and there
	NEAL R. GROSS
	COURT REPORTERS AND TRANSCRIBERS
	1323 RHODE ISLAND AVE., N.W. (202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com

(202) 234-4433

14

was one change to Chapter 7 I&C related to an ECA. And, actually, that ECA is related to the RAI 62-202. And really all that happened there was we added a forth independent control function and a DPS function for the ICS DPV isolation, so that was a minor change on the I&C side to support that change, engineering change authorization.

8 And then, as I mentioned, we had some 9 CARs, Corrective Action Requests. The most germane one is the one that we self-identified to add content 10 11 to Tier 2 that we submitted to the Staff. Okay, 12 next chart.

Really, the key theme of this 13 Okav. 14 paragraph from the letter is really highlighting these 15 principles redundancy, key of independence, 16 determinant data processing, and communication, as 17 as defense-in-depth and diversity, well and the 18 subjective attribute simplicity, and the statement 19 that systems, digital I&C systems can be functionally specified and shown to meet the essential criteria, 20 21 regardless of what technologies you choose to do your 22 elaboration and implementation. So, we would concur 23 with that. And our goal with the CAR 52743 that we 24 issued to add changes was to really bring together in 25 one portion of Chapter 7.1, and one smaller portion in

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

3

4

5

6

7

15 7.8 for diversity, 7.1 being "Introductory Material," 1 2 bring together the design features that do exist to better address the ACRS' concerns. 3 4 And I'd like to make a note that we did 5 all that with just a Corrective Action Request. There was no engineering change. There was no fundamental 6 7 change to our design. We just added further detail. 8 Okay. So, the next chart. 9 is Okay. Here the theme of the 10 presentation. Independence and determinism were the 11 two themes that we felt most in need of additional 12 material and explanation, so not only did we focus a bit more on these two themes out of the four plus one, 13 14 but most of this presentation is really going to be 15 about a deep dive into independence and determinism, 16 particularly in one aspect of the safety system, which 17 is SSLC/ESF. 18 MEMBER BROWN: You're going to talk about it relative to ARC, to the reactor trip system, as 19 well, RTIF? 20 21 MR. BUTLER: Yes, RTIF, Reactor Trip and Isolation Function. We have a little bit of material 22 23 in there on RTIF, yes. 24 MEMBER BROWN: Okay. Because that was one 25 of my points of interest. They look different, and **NEAL R. GROSS** COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

16 1 I'm going to ask you to explain a little bit of the 2 difference to me, just make sure I understand it --3 MR. BUTLER: Sure. Right. 4 MEMBER BROWN: -- once you get into it. 5 Okay? MR. BUTLER: Yes, we'll get into it. 6 7 MEMBER BROWN: Thank you. 8 MR. BUTLER: Okay. So, in order to add the 9 additional material in Tier 2, we just wanted to 10 explain briefly how we did that. There are the four 11 key design principles, and we have three diverse platforms on the safety side, so there's RTIF, NMS, 12 there's SSLC/ESF, and there's the independent control 13 14 platform. So, what we did is for each one of the 15 explained how four platforms, we these design principles are met. 16 Simplicity being more of а 17 subjective attribute, we added a discussion section on 18 that, and then DPS being a RTNSS system, we had a 19 discussion standalone on that. So, that's, essentially, the outline format for how we changed the 20 21 DCD. And if you go to the next slide. This in very high-level summary explains 22 23 the additional sections that were added, and the page count for Tier 2 that they're related to. 24 25 MEMBER BROWN: This is in Rev. 8 now. **NEAL R. GROSS** COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. (202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com

	17
1	MR. BUTLER: This is the Rev. 8 in progress
2	that I introduced with, yes. And it was submitted
3	yesterday to the Staff on the letter. So, in overall,
4	there were
5	MS. CUBBAGE: I'll send it right now.
6	MEMBER BROWN: Gimmie a break, why don't
7	you?
8	(Laughter.)
9	MEMBER BROWN: I was just wondering how
10	long you all wanted to hold it before you go it out to
11	
12	MS. CUBBAGE: Oh, I'll send it right now.
13	I'm just
14	MEMBER BROWN: Okay. All right. Thank
15	you.
16	CHAIRMAN CORRADINI: Amy, I'm sorry.
17	You're going to send what? I'm sorry.
18	MS. CUBBAGE: The markup pages that GE
19	submitted on the docket yesterday
20	CHAIRMAN CORRADINI: Okay, fine. Got it.
21	MS. CUBBAGE: about the Rev. 8 content.
22	CHAIRMAN CORRADINI: Thank you.
23	MR. BUTLER: If you would like, there's a
24	binder. Do you want to have this binder for the
25	meeting? It might help.
	NEAL R. GROSS
	COURT REPORTERS AND TRANSCRIBERS
	1323 RHODE ISLAND AVE., N.W. (202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com

	18
1	MEMBER BROWN: You expect me to read all
2	this?
3	MR. BUTLER: Well, you can thumb through
4	it, as might be appropriate. Some of us might have
5	begun to commit it to memory, so I don't know.
6	MEMBER BROWN: I can pass lunch, and just
7	do it during lunch. Right?
8	MR. BUTLER: We're just trying to make sure
9	you don't miss anything.
10	MEMBER BROWN: No, I appreciate that.
11	Thank you.
12	MR. BUTLER: Okay. So, next page. Okay.
13	For Tier 1, it was also mentioned in the ACRS' letter
14	that applicant should do a better job identifying
15	design descriptions and features that should be
16	testable, inspectable, so we went ahead and looked
17	through the material that's now, hopefully, better
18	presented in Tier 2, and realized that on some of the
19	key areas that maybe the ACRS is struggling to better
20	understand our design independence and determinism, we
21	would go and add additional ITAACs, both DAC and
22	construction ITAACs, and specifically apply
23	independence and determinism to these three platforms.
24	And, as a result of that, we added a number of
25	additional ITAACS. And that's really the theme here.
	NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	19
1	Okay?
2	MEMBER BROWN: Those aren't reflected on
3	this sheet here. So, you're saying in addition to
4	Chapter 7 changes, there are some Tier 1 changes, as
5	well, that go along with these?
6	MR. BUTLER: Yes. And maybe you'd like to
7	be able to have a copy of that. So
8	CHAIRMAN CORRADINI: John, do you want to
9	sit over there?
10	MEMBER STETKAR: No, that's all right.
11	MEMBER BROWN: This is too far to the right
12	for him.
13	CHAIRMAN CORRADINI: Go ahead.
14	MEMBER STETKAR: It's the evil empire over
15	there.
16	MR. BUTLER: So, the theme really is
17	independence and determinism. And, as you notice on
18	the upper right, this is Tier 1, so we sort of focus
19	on the key points that were now better presented in
20	Tier 2. For independence and determinism, in our Tier
21	2, Item 11, in our Tier 1, excuse me, Item 11 is a
22	family of ITAACs that talk about 603 criteria, 5.6 and
23	6.3, so we added a number of ITAACs there.
24	Determinism is addressed in Item 8, which is new, and
25	Item 17, which we modified by adding content too. And
	NEAL R. GROSS
	COURT REPORTERS AND TRANSCRIBERS
	(202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com

it's these -- this is the outline of the changes that we made in Tier 1. Okay? Next slide.

And here's the count of what was added, 3 4 and what was the purpose, so we ended up adding 32 5 DACs and 32 construction ITAACs, for a total of 64. And pretty much, again, they follow this theme of 6 7 independence and determinism, and the platforms. Now, 8 some of these ITAACs are specific to a platform and a 9 topic, and others for a particular design principle 10 are generic, and apply across all of Table 7, all of 15-1, which 11 Table is where our platforms are 12 presented. All right? So, that's how you combine the two primary tables, Tier 1, 2.2.15-1, and 2.2.15-2 and 13 14 generate the specific unique ITAACs. That's the 15 count. MEMBER BROWN: Table 15, you mean Chapter 16 17 15? 18 BUTLER: No, it's Tier 1, and the MR. 19 section is 2.2.15-1 is the table. MEMBER BROWN: Oh, 2.2.15. Okay. 20 21 MR. BUTLER: Yes, sorry. 22 MEMBER BROWN: No, I've got --23 BUTLER: So, 2.2.15-1 is the table MR. 24 which presents the platforms and the specific 25 functional systems that are related to the safety **NEAL R. GROSS** COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

www.nealrgross.com

	21
1	case. That's in the horizontal row. And then in the
2	vertical are all the 603 criteria from Tier 2.
3	MEMBER BROWN: Okay.
4	MR. BUTLER: And then the Table 2.2.15-2 is
5	the specific ITAACs, but they're then applied as
6	matrix algebra to the one above, and that's how you
7	generate the unique list of
8	MEMBER BROWN: What do you mean by a
9	platform multiplier in that column?
10	MR. BUTLER: The platform multiplier is how
11	many times this specific ITAAC is applied to RTIF-NMS,
12	or is it applied to SOC, or is it applied to one of
13	the ICPs? So, in that Table 2.2.15-1, the 603 Table,
14	the horizontal rows have letter Rs in them. The R
15	means reference requiring a report, a closure report.
16	So, each one of the ITAACs that are in the 15-2,
17	where there's an R, these tables get applied.
18	MR. BUTLER: So, there are seven Rs in one
19	line.
20	MR. BUTLER: There are seven Rs in one
21	line.
22	MEMBER BROWN: I got it.
23	MR. BUTLER: So, up until we added the
24	items for 11, those rows were applicable to all
25	platforms. But with independence, we've now presented
	NEAL R. GROSS
	COURT REPORTERS AND TRANSCRIBERS
	1323 RHODE ISLAND AVE., N.W.
	2027 234-4433 WASHINGTON, D.C. 20005-3701 WWW.nealrgross.com

design features for communication, particularly, which are specific to that implementation, and so to write a good ITAAC, we had to become platform-specific. So, that's why there's a little bit of a jitter, if you will. Okay, next chart, Romeo.

Here's an example for what we added in 6 7 Okay? So, this is the Item 11A, B, which is Tier 1. 8 the DAC, followed by the construction ITAAC. And this 9 one here is for independence and interactions. And 10 what we're trying to present here in a series of four 11 of these, so there's one of four, two of four, three 12 of four, four of four, is a specific example from the prior table where we've highlighted what is the type 13 14 of additional material added. Hence, it's blue 15 underlined, So as not to confuse, blue underline means we've added it for Rev. 8 in progress. 16 This is what 17 we submitted yesterday.

DR. WALLIS: That's a very readable slide. MEMBER BROWN: Well, Mike just pointed out that this is not the Tier 1 thing, this is Tier 2.

21MR. BUTLER: These are the change pages.22Sorry. I apologize.

23 MEMBER BROWN: That's fine. Just a real 24 rapid look at this, when I look at one of these design 25 commitments, it talks about intra-divisional

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

3

4

5

23 1 input/output, which is within a division. So, from a 2 -- the major independence issue is from division to 3 division, so intra-division, I mean, you've got to be 4 careful that you don't do certain things, also. But 5 the division to division, is there an equivalent? MR. BUTLER: Yes. So, Romeo, if you --6 7 thank you for being the questioner. This one is on 8 intra-divisional for the VDUs. And if you go to the 9 next one, inter-divisional, so the three of four is the inter-divisional for the SSLC/ESF platform. 10 This 11 is the one where we use a particular implementation of ethernet, so we'll have more discussion that IRA will 12 lead, which will talk --13 14 MEMBER BROWN: Is this the next page? Oh, 15 you went two pages. MR. BUTLER: Yes, three of four. 16 17 MEMBER BROWN: There it is. 18 MR. BUTLER: So, this is the one that talks about the inter-divisional data communication within 19 safety-related --20 21 MEMBER BROWN: All right. So, you address 22 both areas. 23 MR. BUTLER: SSLC/ESF Yes. is an 24 interesting one, an interesting platform to discuss 25 with Staff, because in this case of data the **NEAL R. GROSS** COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

24 1 communication, there were four themes. There's the 2 intra-divisional for sensors, intra-divisional for the 3 VDUs going to the main control room, or the remote 4 shutdown system, they're intra-divisional. There's 5 inter-divisional, and then there's safety to nonsafety. So, the next one, four of four, are a set of 6 7 very specific criteria related to the safety to non-8 safety one-way. 9 MEMBER BROWN: Okay. Now, is there a set 10 of things like this for, I don't mean slides, but 11 ITAACs, and whatever we want to call them, for the 12 RTIF, as well? 13 MR. BUTLER: Yes. 14 MEMBER BROWN: Okay. 15 MR. BUTLER: And that's presented in the 16 table, the Introductory Summary Table, where it's 32 17 and 32, for a total of 64. 18 MEMBER BROWN: Okay. 19 MR. BUTLER: So, these are the new ones added for each platform. 20 21 DR. WALLIS: Could you explain what a hash function is? 22 23 MR. BUTLER: Ira, you want to jump on that? MR. POPPEL: A hash function is like a one-24 25 way algorithm that, basically, it's like a -- the best **NEAL R. GROSS** COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

25 way to describe it would be a signature. So, that if 1 the sender writes it, it's a complicated algorithm 2 3 that the receiver can determine that only the sender -4 5 DR. WALLIS: This is the right person sending it. 6 7 MR. POPPEL: Yes. 8 DR. WALLIS: The right thing is sending it. 9 Okay. Came from the right place. 10 MR. POPPEL: It's not a corruption thing, 11 it's a signature thing. 12 DR. WALLIS: Okay. It's a strange name for a signature, though. Some people's signatures look 13 14 like hash, but --15 CHAIRMAN CORRADINI: Well, that would be 16 your doctor. 17 DR. WALLIS: Okay. Thank you. 18 POPPEL: Actually, hash function is MR. widely -- I don't want you to think we're designing 19 from Wikipedia, but, for example, you'll certainly 20 21 find a description of it there. It's a very common name for it. 22 23 DR. WALLIS: Thank you very much. 24 CHAIRMAN CORRADINI: Keep going. 25 MR. BUTLER: So, the next one is an example **NEAL R. GROSS** COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. (202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com

1 of determinism for the new ITAACs. There's two 2 examples here. This one has to do with -- we did note that perhaps we weren't as clear as we should have 3 4 been in Tier 2 about clearly presenting the fact that 5 for every plant process, there is -- safety-related there is a timing budget that's 6 plant process, 7 determined by the Systems Engineer in Chapter 15, 8 which Wayne leads. And from that plant process timing 9 budget, then any controls on that plant process must 10 complete their complete loop of action, which is 11 sense, command, and execute, or sense, command, and 12 actuate within something less than that plant process control timing budget. 13 So, we explicitly added 14 material in Tier 2 related to the 603 Criteria 4.10 15 that talks about that, and then we added an ITAAC, 16 ITAAC for all platforms, which is an and all 17 functional systems that says there will be a timing 18 budget, and it will be part of the design basis. And 19 the control it will insure that function and protective action completes in the specified allowable 20 21 time less than required by the plant process. So, 22 that's what this one is. 23 It was inferred in Rev. 7 and prior, but 24 it wasn't explicitly stated, so we made it explicit in 25 Chapter 7, Tier 2, and we added this ITAAC into it.

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

	27
1	MEMBER BROWN: Okay. Now, in one place,
2	going back to the number where you talk and maybe
3	it was the Staff's writeup in the SER, you talked
4	about the determination determinism of the
5	processes. While we're operating, you said it was
6	near, because you had to depend on loading of the bus,
7	so you said you had near determinism, which might have
8	been applied to RMUs. I'm not exactly sure where it
9	was. It's just some that's muddled around. Are you
10	going to address program cycle architecture, and its -
11	- forget the RMUs right now, but the stuff that goes
12	directly
13	MR. BUTLER: Yes, there's a chart on that.
14	MEMBER BROWN: Okay.
15	MR. BUTLER: So, the next one is 17A.2 and
16	17B.2, the As being the DACs, and the Bs being the
17	construction ITAACs related to inspection, test, and
18	analysis. So, here we address BTP HICB-21, and make
19	specific note that in the safety-related control
20	processors, and application programs, we do not use
21	the methods which are identified, which could be a
22	negative impact to a deterministic behavior. So, the
23	processors that are used in all three platforms, ICP
24	not really have an explicit processor, because it's
25	gate logic, they do not use these specific features,
	NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

which are not advantageous to insuring deterministic behaviors. So, we made that commitment. Earlier it wasn't clear, so we highlighted it with some change pages in Tier 2, and we've made this new ITAAC, so that it can be assured through design and inspection that we don't do that.

MEMBER BROWN: Okay.

8 MR. BUTLER: So, there's been, obviously, 9 throughout the process a few changes. This slide is 10 simply a statement of where we are today. The numbers 11 might change a little bit, as all of the resolutions 12 come forward with Rev. 8. And, also, we have ongoing conversations with the construction inspection at 13 14 Branch, with Patricia Campbell, to make sure that we 15 are all agreeing on which ones are ITAACs and DACs. 16 And this is just something we need to make sure we 17 clarify before everything is finalized, so that we all 18 have the same set of ITAACs. And they have a common unique numbering scheme. 19

20 MEMBER BROWN: Based on looking at this 21 one, I'm anticipating with great thrill running up my 22 leg, to coin a phrase, you talk about the features are 23 not used as part of your ITAAC determination. There 24 was no political intent meant by that, just it was a 25 good phrase, that's all. Not used, interrupts in

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

3

4

5

6

7

1 multi-tasking, so I take it that the DCD revision 2 which you make will note or discuss the fact that your 3 program cycles and stuff like that are not interrupt-4 driven, or if they are, where they are, and why 5 they're not -- and why they don't matter. I'm not saying interrupts aren't useful. In some places they 6 7 This is probably no absolutely interrupt-free are. prevalent cycle architecture. It's just you don't 8 9 want them in the main processing. 10 MR. BUTLER: Right. 11 MEMBER BROWN: So, I'm anticipating since 12 there's an ITAAC on this, or DAC ITAAC, that's a DAC in that case, that --13 14 MR. BUTLER: Well, A is the DAC, and B is -15 MEMBER BROWN: I got -- I even made a note 16 17 of that, so I won't forget it. 18 MR. BUTLER: There's a picture coding --MEMBER BROWN: Okay. 19 So, that — I should expect to see some discussion of that aspect of the --20 21 MR. BUTLER: Yes. 22 MEMBER BROWN: Okay. MR. BUTLER: Next one. Okay, so this is 23 24 sort of a transition to the specific technical 25 material and associated deep dives. And just to **NEAL R. GROSS** COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. (202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com

1 orient everybody on the ESBWR architecture, and I won't belabor this, other than to say that it's a very 2 3 modular and layered level to insure that we meet the 4 604 Criteria. And when you're at the functional 5 system, and platform level, we've made every effort to make in that area of design and implementation things 6 7 as simple as they can be, when you're actually 8 implementing at the end of the day an overall digital 9 scheme for a nuclear power plant. But what we've 10 tried to achieve is something that, at the functional 11 level, and the subsystem and system level, that's in a singular type of technology platform, that that work 12 scope is understandable for the engineer, for the 13 14 implementer, and for the auditor, and, obviously, for 15 the QUIN operator. So, next slide. 16 So, the first one is on independence, and 17 Ira is going to present the topic on independence, so 18 go to the next one. MR. POPPEL: Can you go back to the overall 19 20 one? Okay. 21 MEMBER BROWN: Let me backtrack for just a 22 second, if I can. I'm trying to -- I want to make 23 you've got the right understanding. For each of the 24 divisions, they have their own dedicated --I'm 25 talking RTIF right now. They have their own dedicated **NEAL R. GROSS** COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

31 1 sensors for each division. You don't share them 2 division to division, but they all feed into а 3 multiplexing system to be fed into their own division 4 processing. Is that correct? For instance, pressure, 5 temperatures, flows, et cetera. MR. POPPEL: Yes. The multiplexor for Div. 6 7 1 handles the Div. 1 sensors, and it only goes to the 8 Div. 1 --9 MEMBER BROWN: Right. Okay. My question 10 relative to that is, I almost forgot my point now. Is 11 that addressed relative to the multiplexing function, 12 the timing of that -- in a predictable approach, so that all the data actually gets fed within a certain 13 14 prescribed time? And if it doesn't, then there's some 15 -- something gets flag to the processor, say I'm not 16 getting the right data, and I don't know what message 17 you use, but is that there to insure that they get everything in every cycle? 18 19 MR. BUTLER: Yes. MEMBER BROWN: And is that discussed any 20 21 place in --22 MR. BUTLER: Yes. In Tier 2, what --23 MEMBER BROWN: I don't remember reading it 24 in Rev. 7. 25 MR. BUTLER: Correct. It was not adequately **NEAL R. GROSS** COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

discussed in Rev. 7 of Tier 2.

1

2

16

MEMBER BROWN: Okay.

BUTLER: So, in looking at Tier 2, 3 MR. Chapter 7 after the letter on August 9th, we realized 4 5 that we had not done an adequate job presenting that topic, so we wrote a CAR, and we added a significant 6 7 amount of material to explain through sense, command, 8 and execute through the layers that you go through, 9 including the multiplexor, that there is divisional independence, that there is a timing budget, and that 10 11 that timing budget will execute in the allowable time, 12 which, obviously, has to be less than what's required for the plant to be safe. So, we took great pains to 13 14 do that in these 23 pages. 15

MEMBER BROWN: Okay.

MR. BUTLER: That was the objective.

17 MEMBER BROWN: Yes. My -- what I'm trying 18 to make sure I understand with all of this is that 19 from sensor input to actuation output, the trip in the predetermined, predictable, 20 that there's a _ _ 21 repeatable path that is verifiable. And that's what 22 I'm looking -- it looks like you all are going after the attack to show that that is --23

24 MR. BUTLER: Added the description that 25 says that will exist. It will be part of the design

> **NEAL R. GROSS** COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

33 bases, and the relevant engineering documents. 1 We 2 will inspect for it as DAC, and we will test to it. 3 MEMBER BROWN: Okay. Thank you. Sorry to 4 interrupt. 5 MR. BUTLER: And we did that with no 6 engineering design change. It was just we hadn't 7 adequately described it. 8 MEMBER BROWN: Well, that's good. 9 MR. BUTLER: Okay. 10 POPPEL: This is a good diagram to MR. 11 occasionally refer back to, because you can get lost 12 in exactly where we are in these systems. But overall, on the left side, you can see the four 13 14 divisions. You can, if you have your glasses on, can 15 three platforms in the divisions, see the the 16 platforms being roughly what you guys would call the 17 reactor trip system, and another one what you would 18 call roughly the ECCS, which is SOC ESF, and the third 19 one is the independent control platforms. And, in general, the whole plant is radial. In other words, 20 21 the signals that things need, safety and non-safety, 22 come to the processor directly. They do not come 23 through a network. So, we do not use in the safety or 24 non-safety side the network, which I'll put in quotes, 25 to do data transfer. Essentially, our networks are **NEAL R. GROSS**

> COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1 used for monitoring, alarming, et cetera, but if you 2 the radial thing is the sensors are on the -- so, 3 bottom lower left for the safety. They come up 4 through remote multiplexing units. They turn to 5 fiber. They go to the four divisional DCIS rooms in the control building, where roughly the controllers 6 7 are, and then they go through one-way gateways to the 8 non-safety side. And then those five gray different 9 sized boxes that says GENE network, PIP network, et 10 Our network is really five individual cetera. 11 networks, all of which can run by themselves. So, in 12 other words, first of all, you don't need any of those networks to do anything for safety, and none of those 13 14 networks can control anything safety. But you can 15 lose any one of them, like our RTNSS network, RTNSS-A 16 and RTNSS-B will continue running. So, it degrades 17 very gracefully, and pretty much everything you see 18 there is redundant in terms of communication paths. There's a few that aren't, and I'll tell you. 19 On the right side is the non-safety, and I 20

20 On the right side is the hon-safety, and i 21 could say pretty much the same thing about it. The 22 RTNSS stuff is separate from what you would call the 23 power generation stuff, and the plant computer stuff. 24 And then, essentially, the main control room, various 25 displays, monitors, recording devices in the upper

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

left plug into those networks. Okay?

1

2 So, one of the other things about the 3 design is, if you lost the main control room, the 4 plant controllers continue to operate autonomously. 5 The only thing you need the main control room for is monitoring, and to send operator commands down to 6 7 them, but if, for example, you stop sending commands for reactor water level, the reactor level controller 8 9 will control water level at the last known command, et 10 So, that's pretty much the overview of our cetera. 11 And most of this discussion is going to system. concentrate on the lower left, and most of that will 12 concentrate on SSLC/ESF, because that's probably the 13 14 networks that you will find most interesting. 15 MEMBER BROWN: Question. You said the sensors enter from the bottom. Right? 16 17 MR. POPPEL: Yes. 18 MEMBER BROWN: On this diagram. 19 MR. POPPEL: Yes. MEMBER BROWN: I can't read it, so -- and 20 21 then I see these things -- those three little units 22 right above in the pink area, those three right there. 23 What are those? 24 MR. POPPEL: Those are the remote 25 multiplexing units. **NEAL R. GROSS** COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com
	36
1	MEMBER BROWN: They are the multiplexing
2	units. Okay. And then the processing units are up
3	here in the gray area, the blue, light gray?
4	MR. POPPEL: Yes.
5	MEMBER BROWN: And then I see this thing
6	off multiplexing, called low drivers. What do those
7	feed?
8	MR. POPPEL: For the RPS system, the load
9	drivers are the things that actually interrupt current
10	to the scram solenoids. They are
11	MEMBER BROWN: Say that again.
12	MR. POPPEL: The low drivers are the things
13	that interrupt currents to the scram solenoids. And
14	they are intelligent, which I can describe a little
15	bit about.
16	MEMBER BROWN: Well, before you get to the
17	intelligent part, they look like they come right off
18	the RMUs, and they don't care about the RTIF, so
19	before the RMUs feed data up to the RTIF, where,
20	presumably, the processing is done.
21	MR. POPPEL: Well, the load okay.
22	MEMBER BROWN: I'm trying to figure how
23	MR. POPPEL: Well, what we should have made
24	clear is an RMU
25	MEMBER BROWN: two of the four
	NEAL & GROSS
	COURT REPORTERS AND TRANSCRIBERS
	1323 RHODE ISLAND AVE., N.W.
	(202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com

channels.

1

2 MR. POPPEL: An RMU is a two-way device. There's outputs, and those inputs. Okay? So, when a 3 controller makes a decision -- one other thing. Our 4 5 control processors for almost everything are located in the control building. Almost all the signals of 6 7 safety interest are located in the reactor building. 8 There's a few in the control building. So, hence, the 9 remote multiplexors. So, basically, outputs occur in the reactor building, and inputs occur from the 10 11 reactor building. And the generic term for the boxes 12 in the reactor building is remote multiplexor units, 13 whether they house inputs measure to pressure, 14 temperature, or whether they house outputs to drive 15 loads. 16 MEMBER BROWN: You have separate RMUs for 17 output, or are you using the same RMU to process plant 18 data, that then goes to the RTIF, then it goes back

19 down to the RMU and gets fed out to the scram breaker?

20 MR. POPPEL: In the case of RTIF, it 21 happens that the boxes are separate, but for the 22 SSLC/ESF, they are mixed. They do inputs and outputs. 23 MEMBER BROWN: How come there are no load

24 sensors devices in Divisions 3 and 4?

MR. POPPEL: Okay. This has been a subject

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

25

1 of a lot of interest in the electrical area, but --2 we're sort of out of -- okay. A load driver in the 3 reactor building, if you look at it in a broad block 4 diagram level, you'll see four fibers going into it 5 coming from the four divisions. And the load driver is an intelligent device that when it gets a signal 6 7 from two out of those four fibers, it will interrupt 8 The current being interrupted is in the current. 9 Division 1, or the Division 1 solenoids on the 10 hydraulic control units.

11 There's another cabinet, similar 12 except there the current arrangement, being interrupted is in Division 2. And then just like all 13 14 BWRs, you have to drop out both the Division 1 and the 15 Division 2 scram solenoids to get a scram. So, 16 electricity is in two divisions, logically it's four 17 divisions.

18 MEMBER BROWN: Okay. That's fine, but why 19 aren't there little wires going over here to the load 20 drivers from Divisions 3 and 4 then?

21 MR. POPPEL: There are -- well, the right 22 answer to that is it's a simple broad block diagram. 23 MEMBER BROWN: That's the point.

MR. POPPEL: Okay.

MEMBER BROWN: That's the difficulty of

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

24

25

www.nealrgross.com

	39
1	understanding.
2	MR. POPPEL: Yes.
3	MEMBER BROWN: That gave me some difficulty
4	the first time I went through this trying to figure
5	out how anything from 3 and 4 got over to 1. That's
6	why I asked, since you, obviously, knew what you were
7	talking about.
8	MR. POPPEL: Okay. The
9	MR. BUTLER: Was that enough to answer the
10	question?
11	MEMBER BROWN: I'm not sure.
12	MEMBER STETKAR: Let me ask. You mentioned
13	something very quickly that it's given you interest
14	among your electrical folks. This means that not all
15	electrical divisions in this design are created equal,
16	because Division 1 if I fail power, Divisions 1 and
17	2, I get a different type of plant response than
18	Division 1 and Division 3, or Division 2 and Division
19	3. I know this is beyond single failure design space,
20	but I just want to make sure that I understand that
21	it's not a fully symmetric plant.
22	MR. POPPEL: Yes.
23	MEMBER STETKAR: There are some other
24	subtleties because of what powers, like the remote
25	shutdown panels, things like that.
	NEAL R. GROSS
	COURT REPORTERS AND TRANSCRIBERS
	(202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com

	40
1	MR. POPPEL: Well, this came about in the
2	electrical area because of the batteries.
3	MEMBER STETKAR: Yes.
4	MR. POPPEL: Everybody thought that look,
5	Division 1 and 2 are different, and, therefore
6	however, if you think about it, the scram solenoids
7	are energized normally, so the division, if you will,
8	is powering the solenoids. Almost every scenario you
9	can think about results in a reactor scram, which
10	means the power goes away.
11	MEMBER STETKAR: Going to unload this.
12	MR. POPPEL: So, now all four divisions are
13	pretty much the same, because they dropped off 4,500
14	watts of scram solenoids.
15	MEMBER STETKAR: The remote shutdown panels
16	are also just Division 1 and 2. Right?
17	MR. POPPEL: Yes. But the loads we're
18	talking about there are
19	MEMBER STETKAR: Yes. Get back to the
20	other stuff that you were going to do. I just wanted
21	to make sure I understood sort of that level. Thanks.
22	MR. POPPEL: Okay. And, incidentally, when
23	you say it's beyond design basis, it's beyond design
24	basis squared, because it should never be forgotten
25	that each of our divisions is redundantly powered.
	NEAL R. GROSS
	COURT REPORTERS AND TRANSCRIBERS
	1323 RHODE ISLAND AVE., N.W. (202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com

41 1 So, in other words, it's possible in tech spec land to 2 talk about losing power for -- losing a division. 3 Okay? It takes a lot more to lose a division in this 4 plant than it does in any other plant. 5 MEMBER STETKAR: On the other hand, in tech spec land you can have one division out of service 6 7 indefinitely. 8 MR. POPPEL: Yes. But we didn't go into 9 the -- one power, half a division's power out, that 10 would drive everybody crazy. You know, you can three 11 and a half divisions running, that would -- that 12 doesn't work. Anyway --MEMBER STETKAR: Back to I&C. 13 14 MR. POPPEL: Back to I&C. 15 MEMBER STETKAR: I just wanted -- you just 16 happened to give me the lead by saying there's concern 17 for your electrical folks, and I want to make sure 18 that --MR. POPPEL: Okay. Next one, Romeo. 19 DR. WALLIS: This is off their subject all 20 21 together. You show this wide display panel. 22 MR. POPPEL: Yes. DR. WALLIS: Is that really a huge screen 23 24 up there that dwarfs everything else? 25 MR. POPPEL: The technology for that is **NEAL R. GROSS** COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. (202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com

	42
1	evolving incredibly fast, but, essentially, it could
2	be done with composite amount of LED displays. And
3	nowadays, there are people who are making them almost
4	with the right resolution for LED
5	MEMBER STETKAR: I think he's answered a
6	much higher question. The answer is yes, it's like
7	the size of that wall behind you.
8	MR. POPPEL: Yes.
9	DR. WALLIS: This is the thing that sort of
10	displays the state of the plant.
11	MR. POPPEL: Yes. It's a main
12	DR. WALLIS: It dwarfs everything else. If
13	you want to see any details, then you've got to look
14	at these little screens down below. Is that
15	CHAIRMAN CORRADINI: Or you could focus in.
16	This is I mean, the fact that I know this scares
17	me. If you go to a combined cycle natural gas plant
18	now, that's how the CCGTs run. So, it's the same
19	thing.
20	DR. WALLIS: But it just seems so enormous
21	compared with the other
22	MR. POPPEL: Well, it's always
23	DR. WALLIS: So, that's the thing they look
24	at really.
25	MEMBER STETKAR: It's what the operators
	NEAL R. GROSS
	COURT REPORTERS AND TRANSCRIBERS
	(202) 234-4433 WASHINGTON D.C. 20005 3701
I.	

	43
1	normally use
2	(Simultaneous speech.)
3	MR. POPPEL: In ABWR, and our intention is
4	to put everything up there that would be a control
5	parameter for the operator to handle emergencies, and
6	to gain a very quick understanding of the plant
7	status.
8	DR. WALLIS: That's right. There's an
9	awful lot of information, according the picture
10	shows an awful lot of stuff up there.
11	MR. POPPEL: Yes.
12	MR. BUTLER: Well, there's a section of the
13	wide display panel which is, essentially, a strip at
14	the very top which is meant to be upon final HFE
15	design and analysis, is meant to be a means by which
16	alarms by system, which the plant engineers and
17	operators are very aligned with, if there's any
18	condition that needs to be interrogated, there will be
19	an annunciator that comes up as a light, and then
20	they'll be able to go into the appropriate monitors in
21	the main console to look at it. So, you won't the
22	objective is not to get lost in all the information,
23	but to have one place, which is the top strip, that if
24	there is really something that needs to be
25	interrogated, it'll be annunciated.
	NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

44 DR. WALLIS: And it's all there. All the 1 2 focus is on that one thing most of the time. POPPEL: Yes. They don't want the 3 MR. 4 operators to develop tunnel vision looking at two 5 displays. They want them to have a broad overview of the plant status. 6 7 DR. WALLIS: I just wonder if they ever 8 look at the other displays. 9 MR. POPPEL: Although, of course, our plant would never had an alarm. If it did, then they would 10 11 look down at the other displays. WALLIS: Look down 12 DR. at the other 13 displays. Okay. 14 MR. POPPEL: And, of course, you would also 15 operate the systems. That mimic is not an operations 16 thing, so you would call up the display to operate the 17 feedwater system. 18 DR. WALLIS: You would. 19 MR. POPPEL: Yes. DR. WALLIS: Thank you. 20 21 MR. POPPEL: Slide 2. Okay. So, now a 22 different view of the same thing. We're talking about 23 independence now, so we're concentrating -- I mean, 24 this slide isn't very profound, except to say our four 25 divisions are electrically separate. There are no **NEAL R. GROSS** COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. (202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com

1 conductive paths between divisions. Our four 2 divisions are physically separate, both in the control 3 building, and in the reactor building where it's set 4 up by quadrants. So, in other words, the Division 1 5 RMU and the Division 1 instrument rack is in whatever quadrant it's in, and then it goes back via its own 6 7 fiber separate path than the other divisions to the 8 the control building room in that houses the 9 controllers. So, physically and electrically we have 10 the independence that everybody wants. And those 11 boxes that say gateways, not only do we have no conductive paths between divisions, we don't have any 12 conductive paths between divisions and non-divisions. 13 14 So, we hope to blow off the electrical and the 15 physical, and just get and discuss mostly data 16 isolation. Okay? Which is most people's concern. We 17 did want to get across that we did the other things, 18 too. Oh, and the other thing I should say is, 19 every one of those divisions is separately and 20 21 redundantly powered, so no safety powers non-safety,

redundantly powered, so no safety powers non-safety,
no safety Div. 1 powers anything in Div. 2, et cetera,
et cetera, et cetera.

24 MEMBER BROWN: When you say redundant, you 25 mean if you lose one of the two, then the other one

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

	46
1	can fully support the operation of that one division?
2	MR. POPPEL: Yes.
3	MEMBER BROWN: So, there's no load sharing.
4	I mean, they may share a load when they're in
5	parallel, but effectively drop one, the other one can
6	supply
7	MR. POPPEL: Yes. The only difference is -
8	- MEMBER BROWN: You don't have to elaborate,
9	if you don't want to.
10	MR. POPPEL: Yes, is the answer.
11	MEMBER BROWN: Yes.
12	MR. POPPEL: Okay. So, it sounded like you
13	wanted to talk more about RPS, so maybe I should just
14	say one thing about RPS does not have any inter-
15	divisional networks. RPS all of the divisional
16	platforms have several communication paths. One
17	communication path is
18	MR. BUTLER: There's a chart on that we can
19	talk to.
20	MR. POPPEL: Okay.
21	MR. BUTLER: So, I suggest that we just try
22	to get through all the material, just go through the
23	charts. And I assure you that there is one that we
24	can talk to on RTIF. Is that okay?
25	MR. POPPEL: Okay. All right. So, the
	NEAL R. GROSS
	COURT REPORTERS AND TRANSCRIBERS
	1323 RHODE ISLAND AVE., N.W. (202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com
	5

controllers in question are, if you will, not shown here, but they're underneath the bottom row. And the -- what you're looking at for SSLC/ESF is the four divisions. And each of the divisions has four CIMs or communication cards. Okay? And, basically, the communication cards are ports to the various networks.

7 One of the networks is two out of four, 8 one of the networks is the display units, one of the 9 networks is to non-safety. Those are different networks, different cards, and all redundant. 10 Okay? 11 So, the network operate in -- not only can they take a single failure proof within the network because of the 12 redundancy, for example, you can lose their links to 13 14 the non-safety, and it has nothing to do with the two 15 out of four, et cetera. So, it's not like there's one 16 which communicates everything, box separate, 17 individual things. And you can see the communication 18 cards talk to, they're called CIMs there, but they are mildly smart switches, ethernet switches, and you can 19 see that they're arranged one, two, three, four in one 20 21 path, and one, three, two, four in the other path. 22 I'll explain to you why, but --

23 MEMBER BROWN: I totally lost what you were24 saying. I apologize.

MR. POPPEL: Okay.

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

25

1

2

3

4

5

6

www.nealrgross.com

	48
1	MEMBER BROWN: I mean, I'm
2	MR. BUTLER: Why don't we just get to the
3	next slide.
4	MR. POPPEL: Okay.
5	MR. BUTLER: We have a series of slides
6	that sort of break it down.
7	MR. POPPEL: Okay.
8	MEMBER BROWN: It gets worse. I already
9	looked at those quickly to see if it clarifies. I'm
10	just trying to look at the simple picture here for a
11	minute.
12	MR. POPPEL: Okay.
13	MEMBER BROWN: The four lower you've got
14	four divisions of four boxes each down at the bottom.
15	MR. POPPEL: Yes.
16	MEMBER BROWN: And where are those getting
17	this is in the SSLC?
18	MR. POPPEL: Yes. They're getting their
19	information from the controllers that are not shown
20	there. This just the communication network.
21	MEMBER BROWN: This is not gateways and
22	stuff going out to the plant.
23	MR. POPPEL: No.
24	MEMBER BROWN: This is within
25	MR. POPPEL: This is just one network for
	NEAL R. GROSS
	COURT REPORTERS AND TRANSCRIBERS
	(202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com

1 SSLC four inter-divisional communication that's 2 dedicated. 3 MEMBER BROWN: Okay. MR. POPPEL: That's the only thing this 4 5 network does. MEMBER BROWN: Okay. So, these -- the 6 7 bottom four are just feeding data into the two 8 networks that are above it. 9 MR. POPPEL: Yes. And taking data from it. MEMBER BROWN: Yes. Well, there's no --10 11 okay. I see the bidirectional arrows. The lower 12 network shows a path except it doesn't always go -- I guess it's always bidirectional. Is this a dual fiber 13 14 _ _ 15 MR. POPPEL: I will show you in the next 16 slide, but yes. 17 MEMBER BROWN: Okay. The upper network 18 doesn't look like it operates the same way. It's one 19 and three, and two and four are connected. 20 MR. POPPEL: Yes. And we will explain 21 that, also. 22 MEMBER BROWN: All right. MR. POPPEL: Okay. Maybe the next slide 23 will make it clearer. 24 25 MEMBER BROWN: Simplicity was the thought **NEAL R. GROSS** COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. (202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com

process.

1

2

3

4

MR. BUTLER: It is when you get to the layer that works.

MEMBER BROWN: Okay.

5 First of all, if Romeo flips MR. POPPEL: 6 between this slide and the next one just back and 7 forth, you can see the two networks, and you can see 8 the two different communication cards. Okay? That's 9 just meant to show that there are two cards, two 10 networks, two sets of switches. They're completely 11 redundant to one another, and they're completely 12 independent of one another, so that, in other words, we can take N minus 2 failures in the system and still 13 14 get the information we need to get a two out of four 15 decision for ECCS initiation, and isolation decisions.

16 The way those switches work is, assume 17 like Division 1 says I have some information. I have 18 to write a message to Division 2 to say my trip And the reason it's sending 19 status. I am in trip. that to Division 2, as well as all the other divisions 20 are sending the Division 2, is so that Division 2 can 21 22 make a decision two out of four to do a trip. So, the 23 networks are common, so these messages are floating 24 around on the network together. Okay? So, 25 periodically, there's a Division 1 message to Division

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 2, periodically, to Division 3, to Division 4, and 2 same thing is happening with Division 2, Division 3, 3 and Division 4. So, the data path is the 4 communication card takes the information, puts it onto 5 the network which is the switch, and the switch's 6 rules are let's send the data around through the other 7 switches, and you can see it's a loop, and it comes 8 back to the original switch. So, if it comes back, 9 that means the network is in tact. So, the response 10 of the switch is to say all is well, and take the 11 message off the network. That always happens.

12 If, in fact, the message doesn't come 13 back, all is not well. Something has happened to 14 interfere with the message. So, the switch's response 15 to that is to send the data around in the other 16 So, for example, if you break the direction. Okay? 17 top network between red and green, so red tries to 18 send -- Div. 1 tries to send to Div. 2, and the link is broken, so it sends the message around the other 19 way to Div. 2. So, this is to demonstrate that if you 20 actually have a fiber break, the data still gets to 21 all three divisions, all three other divisions. 22 And 23 this is one of the redundant networks, so the other 24 division is in tact, and still working, but the intent 25 is to show that it's self-healing. Okay? If it goes

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

communication failure. Okay? So, that's how the fiber breaks are handled.

The next thing is, those switches, and 6 7 those communication cards, and the division, in 8 general, are actively powered. So, if you want to 9 send a message from Div. 1 to Div. 3, it goes through 10 the Div. 2 switch. Okay? So, what happens if the 11 Div. 2 has gone bye-bye? It's broken, or has no 12 power.

Well, first of all, the same rules hold, 13 14 it goes around in the other direction. Okay? So, for 15 individual divisional failures, we are completely N 16 Okay? But we have told you we're an N minus one. 17 minus two plant. So, for example, if I take out on 18 this drawing Division 4, and Division 2, then you could properly tell me that the data never gets to 19 Division 3. And, therefore, I will not be able to 20 make a two out of four decision. 21

Now, you go to the next network, and you
can see if I had taken out -- I forgot which ones -MR. BUTLER: Two and four.

MR. POPPEL: Two and four, that now I can

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

25

1

2

3

4

5

53 1 get data to the division that previous was isolated. 2 So, in other words, I can handle two fiber breaks, two 3 divisional failures, and still get the data. Okay? 4 So, we believe this is properly under the independence 5 section, so that somebody would say are you -- is data getting around dependent on other divisions? And the 6 7 answer is, we are N minus two proof against that. 8 Okay? So, there's that. Next slide. 9 MEMBER BROWN: So, effectively, all you do 10 is reverse the positions to Division 3 --11 POPPEL: Yes, that's why they went MR. 12 through different paths. MEMBER BROWN: -- and 4, and their location 13 14 15 MR. BUTLER: Yes, the topology on the ring for the nodes is different, so that you can be assured 16 17 that the message will always go through. 18 MEMBER BROWN: Okay. MR. POPPEL: Okay. This is what's actually 19 going on in the individual divisional processors and 20 21 communication cards. Okay? So, first of all, what 22 you guys would call a controller, main application 23 modular processor, is the top box. Okay? And the 24 architecture is such that we have an application 25 controller on far left. the The application **NEAL R. GROSS** COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

	54
1	controller is that controller that's actually running
2	the logic for
3	MEMBER BROWN: Before you go to that, if
4	I'm looking at your big diagram, this is the three
5	lines, RTIF-NMS, and SSLC, it's the box that's labeled
6	SSLC/ESF.
7	MR. POPPEL: Yes. Correct.
8	MEMBER BROWN: Okay.
9	CHAIRMAN CORRADINI: So, you had your
10	correct. So, the Committee was all given,
11	essentially, the response that now updates the
12	information they had just told us about at the
13	beginning of the presentation. So, we have what
14	they've given to Staff. Thank you. Go ahead.
15	MR. POPPEL: So, the application processor
16	is the one Mr. Brown is so interested in, in terms of
17	its determinancy, and all the good design rules, et
18	cetera. That application processor is programmed, and
19	then the programming is not changeable unless you have
20	access to a bunch of equipment, and key locks, and
21	door locks, and access that is not available to the
22	average person. That application runs continuously,
23	and uninterruptedly, and it has that application
24	processor has its very own communication processor.
25	And you can see the shared memory between them. So,
	NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

1 in other words, that's the way we say hey, when we 2 have data for you, we are not going to interrupt you. 3 We are just going to put communications data into the 4 shared memory, and then the application process will 5 access it, so it has no -- memory location 3 is reactor trip -- level trip status from Div. 2. 6 No 7 idea how it got there, but it just accesses it at the 8 cycle rate of the processor to use in its 9 calculations. So, the shared memory and separate 10 communication processor concept is one of the things 11 that supports the lack of interrupts on the main 12 application processor.

Now, you've also heard us say that each of 13 14 our divisions for SSLC/ESF is triply redundant within 15 the division. Okay? So, there are three of these 16 purple boxes per division. Okay? And the reason for 17 this is because our SSLC depressurizes the reactor, we don't want to do that inadvertently. That's why we 18 have the triple redundancy to avoid that. Okay? 19

So, in the background of all of this, there's a lot of two out of three voting going on, which we're not going to describe, but each of the processors gets the data in the way that I'm about to describe to you.

So, the blue line --

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

25

	56
1	MEMBER BROWN: You said purple. Am I color
2	blind, or is that which I may be.
3	MR. POPPEL: That is red.
4	MEMBER BROWN: Slightly red, more like
5	MEMBER STETKAR: It's the upper rectangle.
6	CHAIRMAN CORRADINI: It's rose.
7	MEMBER STETKAR: The top one.
8	MEMBER BROWN: Rose, that's fine.
9	DR. WALLIS: It's a different color on the
10	handout, too.
11	MEMBER BROWN: I just wanted to make sure -
12	- I didn't think I was missing anything here, or that
13	I'm going color blind. I need to see the doctor
14	again.
15	MR. POPPEL: The blue
16	MEMBER BROWN: Let me
17	MR. POPPEL: Oh, I'm sorry.
18	MEMBER BROWN: I want to clarify something.
19	I understand your box. I understand what you're
20	talking about here. I'm going to look at the little
21	controller application processor A. And you've got
22	all of your application code is in there.
23	MR. POPPEL: Yes.
24	MEMBER BROWN: I presume it's in PROM?
25	MR. POPPEL: No, this is programmable.
	NFAL R. GROSS
	COURT REPORTERS AND TRANSCRIBERS
	1323 RHODE ISLAND AVE., N.W. (202) 234-4433 WASHINGTON D.C. 20005-3701 www.neakaross.com
I.	

	57
1	MEMBER BROWN: That's what I said.
2	MR. POPPEL: Yes.
3	MEMBER BROWN: It's programmable read on
4	the memory, probably e-squared PROM, I guess, or
5	something, whatever, so you can change it outside
6	within the controls that you have.
7	MR. POPPEL: Yes.
8	MEMBER BROWN: I understand that part. So,
9	that if you had, I'll just pick a number, okay, ten
10	applications, functions that you needed to process,
11	ten little subroutines that it cycles through, starts
12	Subroutine A, finishes Subroutine A with whatever data
13	has come via the shared memory, goes to B, C, D, E,
14	right on up until it's through number ten. When it
15	finishes, it comes back, starts over at A, and it
16	doesn't stop anywhere in-between. It doesn't stop A,
17	to start B, stop A to start
18	MR. POPPEL: No.
19	MEMBER BROWN: Based on some priority
20	assignment or anything like that. It's a straight
21	main what I kind of call a main operating loop
22	MR. POPPEL: Yes.
23	MEMBER BROWN: run, where you take
24	I'm just saying in my words, you take data that's in a
25	data bus or data buffers, you read it, you use it as
	NEAL R. GROSS
	COURT REPORTERS AND TRANSCRIBERS
	1323 RHODE ISLAND AVE., N.W. (202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com

	58
1	you go through, and that's it.
2	MR. POPPEL: Yes.
3	MEMBER BROWN: Okay.
4	MR. POPPEL: The only thing I would add to
5	that is, it starts to loop again after checking in
6	with the watchdog timer.
7	MEMBER BROWN: Yes. And it tells the
8	watchdog timer after all of them are done, it says
9	don't tell the system that I'm broke.
10	MR. POPPEL: Yes.
11	MEMBER BROWN: Okay.
12	MR. POPPEL: This portion was already in
13	Rev. 7.
14	MEMBER BROWN: Not clear, but that's okay.
15	It's tough for me, okay? Give me a break.
16	MR. POPPEL: So, the blue/middle, the T-
17	shaped box is an internal triply redundant
18	communication bus to support the triply redundant
19	control application processors. And that bus goes to
20	the two communication cards that you'd seen on the
21	previous slide. Okay? So, the orange and the
22	yellowish
23	CHAIRMAN CORRADINI: Just watch the
24	pointer.
25	MR. POPPEL: Yes.
	NEAL R. GROSS
	COURT REPORTERS AND TRANSCRIBERS
	1323 RHODE ISLAND AVE., N.W. (202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com

MR. POPPEL: Yes.

1

2

3

MEMBER BROWN: I have no idea, that's --

4 MR. POPPEL: Those represent -- they're the 5 same physical type cards, but they're two physically separate cards. Okay? So, you can see that there is 6 7 a shared memory in the communication processors of the 8 main processor, and a shared memory read and write in 9 the communication card. Okay? So, for example, as 10 you'll see later, if you disable read and write, you 11 can control information flow, but the intention is that the communication card has its own processor, and 12 what that processor does for a living is mainly 13 14 authentication, which we'll describe. So, as you go 15 horizontally, and then down to the white boxes, you 16 can see the connections to the two networks. Excuse 17 me. The left one is one network, the other one is the other network. The cards have two ports on them, so 18 one is the VDU network, and one is the two out of four 19 They're kept completely independently. 20 network. 21 Okay? And the reason we show that is because they're 22 safety, they have no connection to non-safety.

23 So, essentially, data comes -- the buffer 24 is where ethernet data are stored both when you write 25 to the network, and when you read from the network.

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1 So, if we investigate data coming in, so data comes in from the network. It's completely asynchronous to the 2 3 main processor, and it's completely asynchronous to the communication card, because other divisions are 4 5 it, and other divisions sending are not time synchronized in any way with this division, except 6 7 that they're all running at approximately say 10 times 8 a second. Okay? 9 The communication So, data comes in. processor looks at it. We'll describe some of the 10 authentication, and decides whether or not it's good 11 And then puts it onto the shared memory. 12 data. Ιf the -- well, that's enough to say for this one. Let's 13 14 go to the next slide. 15 MEMBER BROWN: Before you do that, this is 16 -- I'm trying to -- this is the TRICON stuff. one 17 Right? And that's the triply redundant, so this in 18 each division, if I understand what I read before, there are three of these pink modules, CPU processing 19 units per division. 20 21 MR. POPPEL: Yes. 22 MEMBER BROWN: Now, each division, 23 obviously, has to get some voting information from the other divisions in order to make a two out of four 24 25 determination. They each also have three, let me call **NEAL R. GROSS** COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. (202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com

them A, B, and C. In terms of the intra-divisional --I may be ahead, but let me ask the question, then you can tell me you're going to elaborate later, but I've got to get it in my head. In order to do the voting in each of the processors in one division, does Division 2's A feed Division 1's A, and only A, or does it also feed A, B, and C?

8 MR. POPPEL: What happens is the 9 communication card is just like an IO device. So, the 10 communication -- it's a bus, so each communication 11 card has access to all three of the processors. So, 12 the three processors saying here's my trip decision, so each communication card does its own internal two 13 14 out of three. And it says this is the information I'm 15 going to put on the bus. And, of course, if the three 16 don't agree, you get an alarm, but the communication 17 card does that. Each communication card makes that two out of three decision from the three processors. 18

19 So, in other words, there's а Communication Card A, Div. 1 trip status put out, and 20 21 there's a Communication Card B, Div. 1 trip status put 22 out, but you don't put out Div. 1 main processor A, 23 Div. 1 main processor B, Div. 1 main processor C trip 24 status.

MEMBER BROWN: Go to your pink thing, go to

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

25

1

2

3

4

5

6

7

www.nealrgross.com

	62
1	the next slide, that one. It says "Main application
2	module A, B and C not shown." So, I presume those are
3	the other two processors.
4	MR. POPPEL: Yes.
5	MEMBER BROWN: And it says, "Communication
6	Bus A, B, and C not shown." Where do they vote
7	between those three? You're telling me there's
8	another okay, no. Let me phrase that differently.
9	Each of these three units comes up and say gets a
10	trip. They each communicate that trip to their to
11	safety communications cards.
12	MR. POPPEL: Yes.
13	MEMBER BROWN: All of them go to the
14	buffer.
15	MR. POPPEL: No.
16	MEMBER BROWN: Well, within their own
17	communication card they have a buffer.
18	MR. POPPEL: Yes, but what happens is, you
19	can see what's shown there is the connection to the
20	communication bus of main processor A. You can also
21	see four other empty boxes not showing the
22	communication bus
23	MEMBER BROWN: Okay. So, this is where
24	is the voting done in this brown box?
25	MR. POPPEL: Done in the communication
	NEAL R. GROSS
	COURT REPORTERS AND TRANSCRIBERS
	1323 RHODE ISLAND AVE., N.W. (202) 234-4433 WASHINGTON. D.C. 20005-3701 www.peakaross.com
1	, , , , , , , , , , , , , , , , , , ,

63 processor. 1 2 MEMBER BROWN: Okay. So, you do get the stuff from B and C via these other shared memory 3 4 units. 5 MR. POPPEL: Yes. MEMBER BROWN: And the voting is done down 6 7 here, so that'll pick up a two out of three in this 8 division. 9 MR. POPPEL: Yes. MEMBER BROWN: And then that division trip 10 11 is sent to the other voting logic. MR. POPPEL: In the other divisions, yes. 12 MEMBER BROWN: Okay. 13 How does -- that's 14 not shown on here. Right? 15 MR. POPPEL: Not yet, but the connection is 16 having --17 MEMBER BROWN: Put it on the ethernet switch. It goes to the ethernet switch. 18 19 POPPEL: Yes. It goes from MR. the communication card to that switch. 20 21 MEMBER BROWN: Okay. So, that puts one 22 trip signal on that switch for that channel, that division. 23 24 MR. POPPEL: Yes. 25 MEMBER BROWN: So, now where does it go **NEAL R. GROSS** COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. (202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com

after that? It goes back to the -- it comes back -it goes to Division B or 2. Right?

3 MR. POPPEL: So, if you remember the loop, 4 every division has two communication cards, and one of 5 the communication cards is for Network One, one is for Two out of four Network One, two out of 6 Network Two. 7 four Network Two. So, that Div. Okay? 1 trip 8 decision is set out to Network One through its 9 communication card and its switch, and Div. 1 trip 10 status is set out to Network Two through a separate 11 communication card and separate switch. So, it's now circulating on the network following the switch rules 12 which say send it around, and if I don't get it back, 13 14 that's all that business of reversing direction, 15 picking up alarms, et cetera. But what's happening 16 is, so a Div. 1 message to Div. 3, for example, will 17 pass through the Div. 2 switch. The Div. 2 switch 18 isn't that smart, it'll send it to - every division 19 sees all the messages. This is where the authentication comes in. Okay? 20 21 So, the switches don't have any

22 intelligence, other than what I described to you about 23 reverse --

MEMBER BROWN: Not voting.

MR. POPPEL: No. They're not voting at

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

24

25

1

2

	65
1	all.
2	MEMBER BROWN: Where is the voting done?
3	MR. POPPEL: Okay.
4	MR. BUTLER: That's why I said keep going.
5	Ira, just
6	MR. POPPEL: Okay, but let's go back to the
7	okay. We describe how it got out, now let's
8	describe how it gets in. Okay? So, the Div. 1 if
9	this is Div. 1, Div. 2, 3 and 4 messages are
10	circulating around on the two networks. Okay? So,
11	the communication card sees it, it gets pulls into the
12	buffer, and it goes to the communication processor.
13	So, the communication processor is now making a
14	decision, is this a good message? One of the things
15	about that is, is it addressed to me, as opposed to
16	one of the other divisions. Okay? But I'll describe
17	authentication in a second. But, basically, it goes
18	into the communication processor in two cards, two
19	networks, so each communication processor says is this
20	a good message? And I'm going to put it in the shared
21	memory so that it can go on the communication bus to
22	the communication processor on the main processor
23	card, control application processors, where it gets
24	taken in and used for the logic.
25	MEMBER BROWN: Where is the logic? That's
	NEAL R. GROSS
	1323 RHODE ISLAND AVE., N.W.
	(202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com

still ·	-
---------	---

2

3

MR. POPPEL: The logic is in the --MEMBER BROWN: Processor A.

4 MR. POPPEL: Yes. It's in the left box. 5 All the logic for the division is in the three controller application processors associated with that 6 7 So, all of this scheme that you see here division. 8 is, basically, a way of getting that data into the 9 control application processor. So, in the end, the 10 control application processor, this is what you'll see in the next slide, but in the end, the control 11 12 application processor has trip statuses from four divisions, its own internal, and then the other three, 13 14 and it has that times two, because it gets it from 15 each communication card. So, in other words, I have a 16 Network One trip status from Div. 2, I have a Network 17 Two trip status from Div. 2. And now let's go to the 18 next slide.

MEMBER BROWN: No, not yet.

20

19

MR. POPPEL: Oh, I'm sorry.

21 MEMBER BROWN: So, if I get a -- you said 22 these are not smart switches, and you haven't talked 23 about authentication yet, which is of interest to talk 24 about, because, effectively, you're saying to me that 25 a piece -- let's assume a piece of corrupt data got

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

	67
1	through whatever it is, kind of like when you're
2	playing with your PC or your laptop, or your desktop
3	at home, and all of a sudden your mouse pointer
4	doesn't move, so everything stops and your only choice
5	is to reboot. So, something stopped the
6	microprocessor from operating. And so I'm taking any
7	one division's trip unit, trip signals being
8	circulated, and they're being fed to everybody. And
9	if there's a piece and every one sees every piece
10	of data.
11	MR. POPPEL: Yes.
12	MEMBER BROWN: So, that means if the
13	corrupt piece of information got to the processor and
14	would lock up wanted to lock all of them
15	MR. POPPEL: Assume that
16	MEMBER BROWN: Even if they're operating
17	asynchronously, I'm making that assumption, it's like
18	assuming
19	MR. POPPEL: Assuming that a corrupt data
20	could interrupt the processor, and assuming it go to
21	authentication, you're correct.
22	MEMBER BROWN: I understand that. So, it
23	would lock up every one of them.
24	MR. POPPEL: Yes.
25	MEMBER BROWN: And that, in my own mind, is
	NEAL R. GROSS
	COURT REPORTERS AND TRANSCRIBERS
	1323 RHODE ISLAND AVE., N.W. (202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com

	68
1	a point of weakness, if you're depending on
2	authentication modes for insuring that all that data
3	is always correct, and will always be detected. I
4	mean, fundamentally, you've got a niche. There's a
5	little no, a chink, excuse me, in the armor, in
6	that you have to do you're potentially sharing
7	corrupt data from division voting logic, to division
8	voting logic, to division voting logic, and you can
9	lock them you could lock them up. And you're
10	depending upon authentication to insure that that
11	doesn't happen in some way, shape, or form.
12	MR. POPPEL: Even though this is a network,
13	what you said is, essentially, no different for the
14	point-to-point communication for the reactor trip
15	system.
16	MEMBER BROWN: Well, that's another
17	problem.
18	MR. POPPEL: Yes. But, I mean, the
19	authentication is easier, because it's point-to-point,
20	so you assume that if it was set up right, that it
21	would
22	MEMBER BROWN: I haven't gotten to ask you
23	about the trip logic unit switch. What you're telling
24	me is I'm going to see the same thing
25	MR. BUTLER: But there's always a chink in
	NEAL R. GROSS
	COURT REPORTERS AND TRANSCRIBERS
	1323 RHODE ISLAND AVE., N.W. (202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com

69 1 the armor, because they'll all use some form of 2 authentication. 3 MEMBER BROWN: If you design the system 4 such that you don't have a processor doing your 5 voting, and you send nothing but analog data, you can isolate it, and you don't have to worry about one 6 7 piece of trip logic unit corrupting, or stopping a 8 three, two of four analog voting unit. 9 CHAIRMAN CORRADINI: So, couldn't a relay 10 stick analog? 11 MEMBER BROWN: It's okay if a relay sticks. 12 You get one set of contacts, but it doesn't corrupt the other three relays. 13 It can't. That's why they 14 have electrical isolation and contact isolation. So, 15 I'm not -- all I'm pointing out is that any time you 16 use microprocessors as voting units, and you have them 17 all doing -- you have them all getting all the data, 18 that's why I asked the question about do you just go to A to A, B to B, C to C, and each of those is kept 19 separate, and they voted separately, then you could 20 21 argue that hey, I'm not mixing things; therefore, I 22 have one corrupt data from one can't processor 23 contaminating all the voting logic in all the 24 processors, and not have to depend on authentication. 25 Authentication doesn't always work theoretically.

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

70 MR. POPPEL: You're right; however, it 1 2 works _ _ 3 MEMBER BROWN: Most of the time. 4 MR. POPPEL: Yes. 5 MEMBER BROWN: Well, most of the time is very long. 6 7 MR. POPPEL: I agree. 8 MEMBER BROWN: I'm just saying it's most of 9 the time. 10 MR. POPPEL: Okay. 11 MEMBER BROWN: So, architecturally, you've 12 made -- a good discussion. I appreciate this. You've 13 made clear, but, Ι it very, very mean, 14 architecturally, the system is not -- I call it not 15 architecturally independent. You have to depend on 16 something else, another belt of armor, in order to --17 it's software-related, authentication and an 18 methodology that will always insure that you don't have a corrupt set of data that can lock everything 19 20 up. MR. POPPEL: There's a difference between 21 22 corruption and locking everything up. Okay? The 23 application processor is instructed to look by its own 24 program, which isn't changeable in normal operation, 25 look to this memory location. Okay? That's the only **NEAL R. GROSS** COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	71
1	place it looks. Okay? And there's no question that
2	the data, however unlikely, in that memory location
3	could be corrupt. But it's hard to understand how
4	that will stop the processor from continuing its
5	program work.
6	CHAIRMAN CORRADINI: Can I ask a question,
7	since I don't understand half of what you've been
8	asking, are you trying to say that there's something
9	goofy, there's a goofy piece of information in the
10	central box, and that goofy piece of information is
11	taken in the voting, and that stops the voting? And
12	everything comes to a grinding halt?
13	MEMBER BROWN: Yes.
14	CHAIRMAN CORRADINI: Okay.
15	MEMBER BROWN: Bad information, corrupt
16	information can lock up microprocessors. Does it all
17	the time. That's what happens when your that's why
18	you go to that's why you turn it off, and turn it
19	back on.
20	CHAIRMAN CORRADINI: That's a PC, it never
21	happens to me.
22	MEMBER BROWN: Well, that's because you're
23	an Apple, right?
24	CHAIRMAN CORRADINI: You betcha.
25	MEMBER BROWN: With a stem. And I'm not
	NEAL R. GROSS
	COURT REPORTERS AND TRANSCRIBERS
	1323 RHODE ISLAND AVE., N.W.
	(202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com
72 1 saying -- there may be other pieces of armor, 2 architecturally, that provide a backstop to this, and maybe the watchdog timer is depending on how they 3 4 operate, may be a way of overcoming this particular 5 chink. And I understand your point, but to say it can't happen, while you can really say is, it's 6 7 unlikely that it will happen. 8 MR. POPPEL: We will try to be cautious in 9 that direction in the future, for unlikely. 10 MEMBER BROWN: But you've got what you've 11 got right now. MR. POPPEL: However, unlike other plants, 12 for example -- let's do two things. Let's assume what 13 14 you say just happened, okay? Unlike other plants, we 15 have DPS, didn't happen there. 16 MEMBER BROWN: You're depending on the 17 diverse protection system. 18 MR. POPPEL: We're depending on the diverse protection system after a chain of events that is 19 borderline incredible. 20 21 MEMBER BROWN: One event. 22 MR. POPPEL: No, not one event. 23 MEMBER BROWN: Oh, yes, a corrupt set of 24 data that stops them all. It's a single failure. 25 MR. POPPEL: Okay. I have -- yes. The **NEAL R. GROSS** COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	73
1	other thing is, having "stopped that," is the vast
2	majority the ECCS isn't controlling anything in
3	terms of reactor operation. So, for example, what
4	you've heard us mention the tech spec monitor. We're
5	not going to go into in great detail
6	MEMBER BROWN: But what you said, it
7	applies to the RTIF, as well.
8	MR. POPPEL: Yes. But
9	MR. BUTLER: Your point is a generic point.
10	MR. POPPEL: Yes, it's a generic point.
11	MR. BUTLER: Yes, so that's why we can move
12	on, Ira.
13	MR. POPPEL: But I just want to say one
14	other thing. That whatever else is true, it can't
15	happen silently, because one of the things that's
16	going on, for example, is the ECCS processors through
17	the N-DCIS data link, are sending out, for example, a
18	square away to the tech spec monitor. So, your
19	failure would have to be it locks up the processors,
20	stops them from operating, and yet continues to send
21	the square away. I will now say that that's
22	incredible squared. So, in other words, there is no
23	question that the operator will know that these
24	processors have locked up in the unlikely event
25	MEMBER BROWN: But you have to assume the
	NEAL R. GROSS
	COURT REPORTERS AND TRANSCRIBERS
	(202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com

	74
1	failure occurs when I'm having some other casualty,
2	and it doesn't matter whether he knows, or not.
3	MR. POPPEL: The idea
4	MEMBER BROWN: The whole intent of the
5	single failure approach to doing business is you can
6	have a single failure, and not stop the system from
7	operating. I'm not saying there's not something else
8	in here that's okay. I'm just saying this depending
9	upon an authentication like that, which can mess up,
10	they are not impervious.
11	CHAIRMAN CORRADINI: So, can I say in
12	simpler lingo for me. What you're saying, it's not
13	100 percent there's not a zero chance of failure.
14	MEMBER BROWN: There's not single this,
15	architecturally, it is not single failure proof,
16	architecturally.
17	MEMBER STETKAR: For certain types of
18	failure.
19	MEMBER BROWN: For certain
20	MEMBER STETKAR: For certain failure modes.
21	MEMBER BROWN: For certain failure modes.
22	And all I did was all I'm trying to
23	MEMBER STETKAR: I think it's important to
24	
25	MEMBER BROWN: Yes. No, it's very
	NEAL R. GROSS
	COURT REPORTERS AND TRANSCRIBERS
	1323 RHODE ISLAND AVE., N.W.
1	(202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com

important. There's a lot of other failure modes, is totally satisfactory. It's just the particular circumstance of trading data, trip data and voting in microprocessors results in fundamental -- unless you do the architecture properly, results in it. I don't want to say this is not -- I'm just saying do it in a certain way, you run into this potential problem of having something lock up those voting logic units, all of them.

10 CHAIRMAN CORRADINI: So, just for my 11 understanding, again. His response to you for reactor 12 trip would make it even smaller there, but this whole 13 method of control is everywhere, so if I go away --

MEMBER BROWN: This is very generic.

15 CHAIRMAN CORRADINI: I understand, but just 16 let me ask you before you answer. So, before I go --17 if I go away from reactor trip, I don't have the 18 backup system. I have the system as described here for other things, depressurization, I don't know, but 19 that's a good one. They want to depressurize the 20 21 plant. It would go through the same sort of voting 22 logic, et cetera. 23 MR. POPPEL: Yes. 24 CHAIRMAN CORRADINI: Okay. Fine. All

25 right. Thanks.

1

2

3

4

5

6

7

8

9

14

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

MR. POPPEL: Okay. The next sheet 1 is, 2 we're going to touch on the authentication process. But what you're looking at is a truth table 3 Okay? 4 that's being run by the control application processor. 5 And the truth table has to deal with I'm getting an authentic message from Network One, or not. And I am 6 7 getting a trip message from Network One, or not. And 8 same thing in Network Two. And this is for a single 9 divisional message coming in, so there'll be three truth tables like this for each of the divisional 10 11 messages coming in. So, basically, what happens, 12 since this is not a failsafe system, if the message isn't authenticated, it doesn't trip. If one of the 13 14 divisions is authenticated, then it accepts the data 15 as valid, trip or not trip. 16 MEMBER ARMIJO: Ira, your note says it does 17 some sort of a corruption check. 18 MR. POPPEL: Yes. MEMBER ARMIJO: Now, Charlie made the point 19 20 that corrupt data can get through it. 21 MEMBER BROWN: Well, this is CRC check. 22 That's --MEMBER ARMIJO: I just don't know what --23 24 you know, I imagine there's all kinds of corruption, 25 and the question is, is there -- this is a very narrow **NEAL R. GROSS** COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. (202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com

corruption check, so why --

1

2 MEMBER BROWN: It's a data transmission All it does is say if I've got corrupt data 3 check. 4 in, and I calculate the CRC based on that corrupt 5 data, and it receives that corrupt data on the other end, it looks at the CRC at the other end, computes it 6 7 separate. They got a match, if they don't, it rejects 8 the data. All that does is say the bad data started 9 out bad, and it ends up, and I'll pass it on, it 10 checks out fine, it goes on to the thing. That's CRC, 11 it's very effective to make sure data doesn't get 12 corrupted in transmission. MEMBER ARMIJO: But if it started out --13

MEMBER BROWN: If it started out bad, and you assigned a CRC based on the bad data, then it's going to get to the other and say okay, that data is just fine, and go on in. So, that's the difficulty. It doesn't mean it's not useful, but --

19CHAIRMAN CORRADINI: Ira, did you want to20say something?

21 MR. POPPEL: Yes. Authentication is not 22 just corruption, so imagine you have a message that 23 says -- my message is one or zero --

24 MR. BUTLER: Ira, just a second. If you 25 look at the bottom of the chart, we'll try and explain

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

78 1 some of the techniques to mitigate Charlie Brown's 2 concern. Okay? MEMBER ARMIJO: Yes. That was the root of 3 my question. 4 5 (Simultaneous speech.) MR. BUTLER: It's more than just corruption 6 7 preventer. 8 MEMBER ARMIJO: That's what I was --9 MR. BUTLER: Yes, so what we're trying to 10 explain here to the best of our ability is that it's 11 not just one thing that would allow the corruption 12 Charlie's concerned about to get through the triply redundant processors per division. Rather, there is a 13 14 defense-in-depth layered approach here that we're 15 trying to explain in the bottom of this chart. Ιt 16 doesn't eliminate it 100 percent, but what it does is 17 it dramatically mitigates it to a nearly highly 18 unlikely situation. MR. POPPEL: The authentication process is 19 probably two orders of magnitude larger than the data 20 21 being sent. The data is one or zero, trip, no trip. 22 So, the first thing that happens in the communication card is it says I'm going to put my sending address on 23 it, so it has the address of Div. 1, won't be saying 24 25 Div. 1, it'll be a numerical address and saying I have **NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

a message for Div. 2. So, it has a sending address and a receiving address. Okay? That's how the cards know who the data is for.

1

2

3

16

(202) 234-4433

4 In addition, it has a sequence number. 5 So, the sequence number is Div. 1 sends a message to Div. 2. Okay? Let's say the sequence number is one. 6 7 Okay? Div. 2 gets it, and Div. 2 acknowledges back. 8 If Div. 1 gets an acknowledgment back, it Okay? 9 changes the sequence number to two, and the receiving division changes its number to two. So, in other 10 11 words, the next message that's sent better have a 12 sequence number of two, or it won't be authentic from that division. 13

DR. WALLIS: Much more complicated thanhaving a wire that connects A to B.

MR. POPPEL: Yes.

DR. WALLIS: Just go directly. You don't have to ask where it came from, or where it's going, or who sent it.

20 MR. POPPEL: Yes. So, the -- and, 21 incidentally, these messages are going on at the 22 cyclic rate of the processors, which is ten times a 23 So, the idea of somebody pulling the fiber second. 24 and reconnecting it fast enough, and spoofing the 25 sequence number is unlikely. Okay? So, next comes

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

www.nealrgross.com

80 the hash function, which is a -- you know how like 1 2 with your computer you have pretty good privacy. 3 MR. BUTLER: It's a signature. 4 MR. POPPEL: It's а signature. Ιt 5 basically says I'm adding my Div. 1 hash function on to this message so that something downstream can 6 7 determine that. It's not just Div. 1 because of the 8 sending address, it's Div. 1 because the hash function 9 can be decoded by Div. 2, and knows it's from Div. 1. And then the cyclic redundancy check, which is, 10 11 basically, let's add up all of these bits, ones and 12 zeroes that we just laid on top of the message. Okay? Divide them in this case by 64, get a remainder, and 13 14 put the remainder into the message. So, the message 15 gets received, and the remainder is there, the 16 receiving processor calculates what -- its own cyclic 17 redundancy. 18 DR. WALLIS: You think of discussions between people were like this. 19 20 MR. POPPEL: So, basically, it's not 21 impossible, but it's highly unlikely, but the net 22 result of all of this is the communication card says 23 it's a good message, and I'm going to put that one or

24 zero trip into the shared memory of the communication 25 card, which then goes to the communication processor

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

MEMBER ARMIJO: But it doesn't check for the type of corruption that Charlie is talking about.

7 MR. POPPEL: No, if the sending division --8 but remember, what we're sending is a one or a zero, 9 so, in other words, we're not expecting some huge 10 complicated message. What we're sending is, we want 11 to see a one or a zero in this shared memory location 12 of the application processor. That's the only place 13 it's told to look.

DR. WALLIS: I want to tell you, all your message here are not authentic, because there's no page number on the slide. So, I cannot make notes on different slide numbers in my notes.

MR. POPPEL: Okay.

19DR. WALLIS: I was disappointed. You have20to number your slides. It really helps us very much.

21 MR. BUTLER: Okay, point taken. We'll take 22 this as an opportunity to ask for permission to 23 resubmit with various things that we capture, page 24 numbering might be one of them.

MEMBER ARMIJO: I really want to get to

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

3

4

5

6

18

25

www.nealrgross.com

82 1 this thing. If it is just simply a zero or one, why 2 is Charlie concerned that this --MEMBER BROWN: Because it doesn't eliminate 3 4 _ _ 5 MEMBER ARMIJO: How can a zero or a one --You have to postulate MEMBER BROWN: 6 7 because you're sending digital data from Point A to 8 Point B, that you could be in a situation, regardless 9 of how you get there, that the data is not going to be 10 what you want. So, it's a -- and if you ask anybody 11 that goes and does it, they'll tell you no, we can't 12 guarantee, but we're pretty sure it's going to be 13 okay. That's all. 14 MR. BUTLER: So, you're right. You're 15 right, and the techniques that we're trying to present 16 here are those techniques which dramatically mitigate 17 your concern, so that there's a very, very high 18 probability that the message that gets through for 19 trip status, bypass status is authentic, and is 20 actionable for the safety of the plant. That's the 21 technique, and we're doing it digitally, and that's 22 the way it is. 23 MEMBER BROWN: I got it. 24 CHAIRMAN CORRADINI: I'm doing а time 25 check. Are we like on track here? **NEAL R. GROSS** COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. (202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com

	83
1	MR. BUTLER: Sure. We can forward at a
2	higher rate, hopefully.
3	CHAIRMAN CORRADINI: So
4	MS. CUBBAGE: But I will say it's very
5	important that we bring these issues to resolution
6	today, so take whatever time is necessary for that to
7	happen.
8	MEMBER BROWN: We will proceed on. I mean,
9	this is fine.
10	CHAIRMAN CORRADINI: Okay. Let's go.
11	MR. POPPEL: So, now you've gone through
12	that truth table authentication for three divisions in
13	the receiving processor, and, of course, it knows its
14	own internal status for trip. And now you see the
15	messages combined in the two out of four logic with
16	the bypass status. So, each of the three control
17	processors is doing what you see in the yellow upper
18	box, which is fairly straightforward two out of four
19	stuff you've seen all over the place.
20	In addition, the bottom box shows that if
21	the data are different on Networks One and Two, and
22	authentic, you get a data alarm. If you have an
23	authentication problem, it shows up as a communication
24	alarm. Okay? And remember these are all the
25	control application processor is different from its
	NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

own communication processor, which is different from the communication processor in the card. Okay? So, that -- and all of these cards are expecting to talk to one another. So, for example -- again, I'll go back to, it's very hard to have this problem happen silently. You'll get alarms all over the place.

7 The reason we discussed this under Okay. 8 independence is because we have several networks, but 9 the two out of four network is one of the -- because it's between four divisions challenges independence, 10 11 and there's another network which is to say 12 communicating to non-safety, which also challenges There's networks inside the 13 independence. Okay? 14 division, but they just show up as single divisional 15 failure-type things. These that are the ones 16 challenge independence.

17 So, now if you look at this slide, and the 18 one next to it, go to the I Chart flipping back and 19 forth, you can we have redundant separate see 20 networks. So, in other words, we're now on а 21 different communication card, and on a different 22 network than is doing the two out of four. So, none 23 of this data that we're seeing here shows up on the two out of four network. 24

MEMBER BROWN: Where is this on your big

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

25

1

2

3

4

5

6

www.nealrgross.com

	85
1	diagram?
2	MR. POPPEL: Okay.
3	MEMBER BROWN: Which network is this?
4	MR. POPPEL: That's the one that goes to
5	the gateway, the vertical line up to the gateway from
6	yes. From the SSLC/ESF. So, basically, what we're
7	doing is we're the goal of this is to try and make
8	this network one-way, and because we want to insure
9	the statement that no non-safety can control safety.
10	And, in fact, we want to make it such that the
11	existence, or anything on this network will have
12	nothing whatever to do with the safety function of
13	SSLC/ESF. So, this is a convenience network for
14	alarming, showing things on the non-safety displays,
15	et cetera, et cetera, but not to control. Okay?
16	MEMBER BROWN: So, if it's one-way, why did
17	you make the statement at the beginning that it
18	challenges the independence of the SSLC/ESF? Is that
19	because it's not one-way?
20	MR. POPPEL: Yes. Because you've taught me
21	never to say never. But let me explain it, and see if
22	I can get the point across. Okay? You'll see in a
23	second. But the important thing is that I just
24	want to get across it's a separate network, it's
25	redundant, and it does this function, and doesn't do
	NEAL R. GROSS
	COURT REPORTERS AND TRANSCRIBERS
	(202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com

the other functions. Okay?

1

2 have the familiar main So, now we 3 processor card times three in the upper box. We have 4 the familiar communication network, and now we're 5 talking to two different communication cards, different ones than the ones that were on the two out 6 7 But you can see they look exactly the same. of four. 8 So, this is what happens in the card, the Okay? 9 communication card is disableable by which we're 10 saying that you can see there's an X through the right 11 shared memory. So, in other words, what we're saying is for data on this network, the communication card is 12 capable of writing back to the application 13 not 14 processor. That's program in. Okay? I want to talk a 15 little bit more about that in a second. MEMBER BROWN: Yes, that's -- my question 16 17 is, you say it's programmed in. So, in other words, 18 you've sent a bit in to say disable that line. 19 MR. POPPEL: Yes. MEMBER BROWN: Or do you hard bus that line 20 21 so that it cannot be programmed digitally? 22 MR. POPPEL: No. MEMBER BROWN: So, in fact, you still have 23 24 a path of failure then. 25 MR. POPPEL: Yes, but as --**NEAL R. GROSS** COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

87 MEMBER BROWN: If that digital signal 1 2 somehow gets flips --MR. POPPEL: Silently, of course. 3 4 MEMBER BROWN: It probably is silent. 5 Okay? MR. POPPEL: It probably isn't. 6 7 MEMBER BROWN: Okay. Now, you have the 8 capability of having information transmitted back the 9 other way through that particular port. 10 MR. POPPEL: Yes. But there's more to say 11 about that. MEMBER BROWN: Yes, but why didn't you just 12 That's what I used to do? We used to lock it down? 13 14 tie them to ground so they couldn't do that. 15 MR. POPPEL: It's the technology we have. 16 MR. BUTLER: That's a technique, but we're 17 using a different technique. 18 MEMBER BROWN: I know you are. MR. BUTLER: Okay. There's two different 19 techniques. This technique, which we'll elaborate a 20 21 little bit more on, will achieve the objective. DR. WALLIS: I think you ought to tell us 22 23 the modes of failure instead of having Charlie have to 24 tell us. 25 MR. POPPEL: Okay. NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. (202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com

	88
1	MR. BUTLER: We're trying.
2	MEMBER BROWN: I'm getting ahead of the
3	game probably.
4	MR. POPPEL: Okay. But the point is, in
5	normal operation, the communication card won't write
6	to the main controllers.
7	DR. WALLIS: But if something bad gets in
8	there and turns all those things so they can write,
9	then
10	MR. POPPEL: That's a programmable thing
11	which, incidentally, is not programmable by a little
12	switch in front of the card. You have to turn a key,
13	make the division in op, and et cetera, et cetera, et
14	cetera to change the program.
15	MR. BUTLER: You have to have special
16	equipment to come in and change the program. That
17	can't happen during normal operations.
18	MR. POPPEL: Unless, as you say, it flips.
19	But, of course, it would have to flip in two
20	processors, because the minute you get two processors
21	sending different information, you'll get an alarm,
22	two communication cards.
23	DR. WALLIS: Couldn't you get a lightning
24	strike or something that although you filtered
25	everything out, it sends some piece of information in
	NEAL R. GROSS
	COURT REPORTERS AND TRANSCRIBERS
	(202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com

89 1 through this thing that reverses all those no write 2 instructions? 3 MR. POPPEL: We have learned a bunch of 4 lessons about lightning and voltage surges from recent 5 operating experience, and although I could tell you I'm not sure we want to go 6 about it, in that 7 direction. 8 MR. BUTLER: No, we're not going to go into 9 We're not going to do that in a public session. that. MR. POPPEL: Yes, it's not going to happen 10 11 on the fiber optics. It would have to happen in the 12 division. Okay? But let's continue on with the path a little bit. 13 14 So, all -- the application program in the 15 processor on the left side that we write, this is what 16 we want the SSLC/ESF to do for a living. Okay? One 17 of the things you have to do is say I need data from 18 the outside world, or I have to write data to the You have to declare that as 19 outside world. а 20 read/write or both variable in your program, which is, 21 therefore, then after under change control. So, what 22 that's really saying is, I ain't even going to read 23 the shared memory unless it's written -- the variable 24 is written as a write variable. So, in other words, 25 all the MDCIS data coming in, even if it got through **NEAL R. GROSS**

> COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W.

> > WASHINGTON, D.C. 20005-3701

(202) 234-4433

	90
1	the X of the closed right port, and somehow got to the
2	main processor, and somehow got put in the shared
3	memory, it still would not be used under the control
4	of the application that we wrote.
5	DR. WALLIS: If the write function is
6	disabled, why is it even there?
7	MR. POPPEL: Because it wasn't disabled on
8	the other in other words, we want
9	MR. BUTLER: So, the reason why it's still
10	there is because we try to design these things from an
11	industrially practical perspective, so that there's
12	available technology and products on the market that
13	don't require everything to be fully custom designed
14	from scratch. So, these are implementation techniques
15	with technology and products that are available on the
16	market today that can be applied with appropriate
17	techniques and Appendix B controls to present a
18	layered defense approach to whether or not that kind
19	of failure could occur. And in this case, you have to
20	go through several processor failures, or application
21	programming failures, through several shared memory
22	buffers in order to be able to present the wrong data
23	there. And these are industrial techniques for secure
24	communication in industrial controllers. They are
25	well known in the industrial field.

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

91 MEMBER STETKAR: What kind of industries? 1 2 MR. BUTLER: Process industries, oil and marine industries. 3 4 MEMBER STETKAR: Ware industries, yet? 5 MR. BUTLER: There is a particular platform that has an LTR in which these techniques 6 are 7 presented. 8 MEMBER BROWN: LTR? 9 BUTLER: Licensing Topical Report, MR. which is an approved LTR. 10 11 MEMBER BROWN: Okay. 12 MR. BUTLER: And these techniques are on that LTR. 13 14 MEMBER BROWN: This is -- they might be 15 approved, but I'm still going to ask the question. MR. BUTLER: No, that's fine. I'm just 16 17 saying that --18 MEMBER BROWN: I understand what you're 19 talking about. 20 MR. BUTLER: Okay. 21 MEMBER BROWN: I just wanted to make sure. 22 I just -- you're going through the stork dance on the 23 things --MR. BUTLER: But it's important --24 25 MEMBER BROWN: In fact, you don't have to **NEAL R. GROSS** COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. (202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com

1 have lightning or surges. I mean, we -- in my past, 2 we actually found that bits got flipped by simple 3 gamma radiation. We lost -- the program changed in 4 certain places just due to gamma radiation that was 5 around, which was not a very happy circumstance. So, what did we do? We now have protected data such that 6 7 we can -- we refresh the PROMs that we use just to 8 make sure we maintain the program authentically for 9 And that's outside the -- it doesn't what it does. 10 happen -- it's very infrequent. Let me use Ira's 11 words, it's very infrequent, but it's happened. 12 MR. BUTLER: But just to emphasize again, that not only is this presented in a layered approach 13 14 through the communication card into the communication 15 processors environment into the shared memory, but 16 this pink bar at the top is triply redundant, so even 17 if you had this gamma radiation that affected one 18 thing, there would still be a TMR two out of three 19 vote. So, now you're talking about the same kind of 20 gamma --MEMBER BROWN: No, no, no, no. 21 I'm not 22 trying to go there. 23 MR. BUTLER: Okay. 24 MEMBER BROWN: I'm just telling you that --25 MR. BUTLER: Because that would be highly -**NEAL R. GROSS** COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. (202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com

	93
1	_
2	MEMBER BROWN: That's just a fact, that's
3	all I'm saying. That's all I'm saying. And I
4	understand the need to use common hardware to minimize
5	cost using conventional techniques. I'm not arguing
6	about that.
7	MR. BUTLER: Okay.
8	MEMBER BROWN: I'm just pointing out that
9	there's better ways with the common card to make sure
10	that doesn't happen by grounding the port.
11	CHAIRMAN CORRADINI: Are you guys done with
12	independence, because I'm going to vote for a break.
13	MR. BUTLER: We're done with dependence,
14	independence. We're going to go
15	CHAIRMAN CORRADINI: So, I just wanted to
16	know, if we're done with independence if you're
17	going to start a new topic, determinism, could we like
18	take 10 minutes for those that are
19	MR. BUTLER: Sure.
20	MEMBER BROWN: Biologically impaired.
21	CHAIRMAN CORRADINI: Okay. We'll take a
22	break for 10 minutes. We'll be back at 10:25.
23	(Whereupon, the proceedings went off the
24	record at 10:15:10 a.m., and went back on the record
25	at 10:27:11 a.m.)
	NEAL R. GROSS
	COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W
	(202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com

CHAIRMAN CORRADINI: Okay, let's come back into session.

We're going to have -- we wanted to have another piece of information from yesterday brought to the Committee's attention. Alan, go ahead. I'm sorry.

7 MR. BEARD: Again, Alan Beard with GE 8 Hitachi, and Gary Anthony should be in the room in 9 Wilmington, and he'll be able to correct me if I state 10 anything wrong, or enhance anything that -- the 11 statements I'm going to make now.

In regards to the loading handling issue 12 that came up yesterday, Mr. Stetkar was referring to 13 Section 9.1.5.6 of the DCD that referred to the 14 15 potential for a drop of the heavy load, and we had a 16 statement that it created no radiological hazards. He 17 was worried about load handling events in the turbine 18 building. We'd like to point out that all Section 19 9.1.5 is confined to discussions of heavy load handling from the reactor building, and the fuel 20 21 building, and, thus, that any radiological statement is confined to load handling accidents that occur in 22 23 that building.

Now, in regards to control of the heavy loads within the turbine building, couple of issues

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

3

4

5

6

that we would like to point out. Number one, the operating deck of the turbine building is a very robust structure. Any heavy loads that we're handling in that building we're keeping as low to the floor as we can, such that if you were to drop it, we would certainly expect that the floor would prevent propagation of that load to lower elevations.

8 During operation, access to what we would 9 call the south end of the building, which is the end where the high-pressure turbine is, and the moisture 10 11 separator reheaters is restricted because of the 12 shielding that's in place to prevent that. Gary Anthony, I'm going to ask you to verify this, but the 13 14 moisture separator reheaters are actually located 15 below the operating deck. Is that correct?

MR. ANTHONY: No, they are on the operating deck, but they're fully shielded in cubicles, including shine shields over the turbines so you couldn't drop anything on them.

20 MEMBER STETKAR: Gary, this is John 21 Stetkar. The shielding -- just to make sure I'm clear 22 on this, the shielding extends up above the tops of 23 the main turbine enclosures?

24 MR. ANTHONY: The main turbine is under a 25 set of shine shields.

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

3

4

5

6

7

www.nealrgross.com

	96
1	MEMBER STETKAR: Okay.
2	MR. ANTHONY: And the MSRs are completely
3	in like bunker-type cubicles that are completely
4	enclosed.
5	MEMBER STETKAR: Okay. So, if you were to
6	move something on the turbine building crane over
7	those enclosures, the shield walls and the enclosures
8	would provide protection for both the steam lines and
9	the MSRs?
10	MR. ANTHONY: Yes. Actually, the main
11	steam lines do not appear on the operating deck. They
12	are on the lower deck below, underneath.
13	MEMBER STETKAR: I tend to generically
14	assign the HP to LP and MSR crossover lines are up
15	above. Right?
16	MR. ANTHONY: They're completely shielded,
17	also.
18	MEMBER STETKAR: Okay. Great. Thank you.
19	MR. BEARD: Okay. And then continuing to
20	build on that, any heavy load handling that might be -
21	- pre-staging of heavy components for an upcoming
22	outage would largely be limited to the north end of
23	the building where we don't have any of the steam
24	piping that you're worried about.
25	MEMBER STETKAR: Great.
	NEAL R. GROSS
	COURT REPORTERS AND TRANSCRIBERS
	(202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com

	97
1	MR. BEARD: Okay?
2	MEMBER STETKAR: Yes. And that information
3	pretty well satisfies my concerns. Thank you.
4	MR. BEARD: Okay.
5	CHAIRMAN CORRADINI: Thank you. Go ahead.
6	MR. BUTLER: Okay. So, just a few
7	introductory remarks. We're back to talk about
8	determinism as part of the four plus one. And this
9	section so this section will focus mainly on the
10	processors related to RTIF-NMS, and SSLC/ESF, because,
11	in fact, in the ICP there isn't formally a processor.
12	It's a series of hard logic gates. So, this
13	discussion will primarily focus on RTIF and NMS. Ira.
14	MR. POPPEL: Okay. Basically, this is one
15	of the new sections that's been added to Rev. 8, was
16	on the list way back at the beginning of this talk.
17	So, the three platforms, in our case the two
18	platforms, we'll discuss the four principles. And
19	this is the determinant principle, so here's where
20	you'll find it in the new DCD. And, basically, what
21	we're saying is that we recognize that as a design
22	basis for these platforms, that you must have a time
23	budget. It must be traceable to some requirements,
24	which will be mainly Wayne's, that these events happen
25	at these times in the accident sequences. And that we
	NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

11

1 must then take that that time budget and insure that 2 the systems meet it consistently, and in that time or 3 less, so both. And we must, further, take the time 4 budget for the system, and if we have individual 5 components in the system, like sensors, RMUs, et cetera, et cetera, et cetera, whole bunch of out of 6 7 service for the system that we must assign, breakdown 8 the time budget further, and assign it to those 9 individual communication links, and to the individual 10 processing that's going on all through the system, so 11 that in the end in a demonstrable way traceable back 12 to a specific requirement we can show that the systems are deterministic and will work. 13 14 DR. WALLIS: Is determinism just timing, or 15 is it -- it completes an operation in an adequate time 16 with no errors, because if it gets near the end of not 17 being able to quite meet the time, does it introduce 18 errors? Isn't errors introduced into this somehow, or 19 is it only time you worry about? MR. POPPEL: So far, we're only worried 20 21 about time, because if, in fact, there were errors 22 introduced, we would interpret that as а single divisional failure. 23 24 DR. WALLIS: Well, a person, they were 25 trying to conduct something, complete an operation in **NEAL R. GROSS** COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. (202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com

99 1 a given time, is more likely to screw up if it's 2 almost hasn't got quite enough time. So, you don't 3 worry about that at all? 4 MR. POPPEL: We worry about it, but what 5 you said is, especially, a human -- anything an operator does is so long in time frame compared to the 6 7 process that we're talking about. 8 WALLIS: It's all relative. DR. So, 9 determinism is only a matter of time in your view. 10 MR. POPPEL: Yes. 11 DR. WALLIS: Okay. That's all I'm getting 12 at. 13 MR. POPPEL: But --14 MEMBER BROWN: Repeatable and predictable. 15 DR. WALLIS: That's also part of it, isn't 16 it? Predictable is key. It's not just time. So, his 17 like my view, so it's repeatable view is and predictable. But your's is just time? 18 19 MR. BUTLER: It's repeatable and predictable within the specific time allowed. 20 21 DR. WALLIS: Yes, but the other two are 22 important criteria. 23 MR. BUTLER: Yes. 24 DR. WALLIS: Thank you. It's not just time 25 you're worried about. **NEAL R. GROSS** COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. (202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com

	100
1	MR. BUTLER: Yes.
2	DR. WALLIS: Otherwise, I can just put in
3	for my ACRS hours and not care about what I did.
4	CHAIRMAN CORRADINI: We won't go there.
5	MR. BUTLER: Next chart.
6	CHAIRMAN CORRADINI: Yes, let's avoid that.
7	MR. POPPEL: Okay. So, this gets down to
8	okay, having decided we needed a time budget, and
9	having decided we need to design using it, then how do
10	we design the various systems, what techniques do we
11	use for the design to insure that we can get the
12	repeatable deterministic, predictable response. And
13	it's silly just to read it, but, basically, we have to
14	consider well known programming techniques that are
15	used to do this.
16	So, for example, we are clock-driven. So,
17	in other words, we're going to look at reactor water
18	level every 20 milliseconds no matter what. We don't
19	care about a reactor water level event. We're just
20	going to keep on looking at that rate no matter what,
21	so that we are totally independent of the events.
22	Okay. So, we're not going to use those techniques.
23	And, as Skip said earlier, you'll find a listing of
24	the techniques that we're not using in the ITAACs.
25	That was one of the changes in Tier 1, so it can be
	NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

H

verified that we're not using these techniques. Next slide.

We skipped to this one earlier, 3 Okay. 4 but, basically, the idea is that we're just going to 5 have a large programming loop that's going to do everything that that chassis or that system uses, and 6 7 it steps through the various functions continuously 8 all the time, and nobody says stop what you're doing, 9 and listen to me. It just keeps on going, and then 10 So, we have to design the IO systems, loops around. 11 the measurements that the process needs, and the 12 communications that the process needs so that it 13 doesn't interrupt that main loop. And, in fact, we do 14 those programming techniques so that we don't 15 interrupt the main loop.

The advantage of having the main loop run all the time is so that in a predictable way, so you can have a watchdog timer to say it didn't run, and you can tell when it stopped built into the actual application. Next.

Okay. So, this is RTIF, and this is --MEMBER BROWN: Let me backtrack to that for just a second. I presume this timing cycle also includes all -- since you've got the voting logic in the processor, this includes all those functions.

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

www.nealrgross.com

	102
1	They're not done as a separate
2	MR. POPPEL: Correct.
3	MEMBER BROWN: So, this is straight
4	through. You do it all, so regardless of what happens
5	with all these other microprocessors, data coming in
6	and out, you're just receiving data from other
7	divisions, from parameters, whatever, telling you, and
8	you just look at that, and you determine whether
9	you've got two out of four trips, et cetera.
10	MR. POPPEL: Yes.
11	MEMBER BROWN: Or two out of three,
12	whatever they are. Okay.
13	MR. POPPEL: Emphasizing the parameters,
14	again, are just trip and bypass.
15	MEMBER BROWN: I understand that.
16	MR. POPPEL: So, there's lots of pieces in
17	say the RPS system that have to be deterministic.
18	We're going to look at one piece, and we're going to
19	look at the piece that says let's talk about the two
20	out of four logic used to support the reactor scrams.
21	Okay? And Skip filled in the dotted blue line, which
22	wasn't on the main thing, but that's the line by which
23	the RTIF processors have to talk to one another. Now,
24	let's go to the next slide.
25	In reality, that isn't a network. It
	NEAL R. GROSS
	COURT REPORTERS AND TRANSCRIBERS
	(202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com

1 isn't a bus, it's point-to-point. So, here is a box 2 in Div. 1, and it has three ports on it. One port goes to Div. 2, one goes to Div. 3, and one goes to 3 4 Div. 4. Okay? And, again, the only information on 5 those links is authentication, and trip and bypass And I should also say per parameter, so it's 6 status. 7 like a pressure trip, a level trip, et cetera, because 8 the ultimate two out of four logic is any two like 9 parameters that aren't bypassed exceeding their values 10 So, as it happens, this is will cause the scram. 11 described in the DCD, and we don't have to do it here, because it's a communication thing, we actually have 12 two two out of four votes in the RPS system. 13 One is 14 at the sensor level, so it's basically saying if I --15 I can bypass one of these divisions, so it says, 16 basically, don't consider the Div. 1 pressure sensor 17 in your two out of four calculation. And there is a 18 joystick-type switch to make sure you can only do that 19 one division at a time. Okay? And the switch is enforced by logic that says despite that, if more than 20 21 two divisions are in bypass, then no divisions are in 22 bypass. Okay? 23 Another thing associated with -- and then 24 following that, we have a logic trip, so we've made a 25 trip, Div. 1 that says there's a two out of four trip,

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

	104
1	and communicates that to all four divisions. And then
2	we have another vote, again, to see whether the four
3	divisions, there's two out of four divisions that
4	agree, and that causes the ultimate reactor scram.
5	That causes a logic trip. Too much detail for here,
6	but
7	MEMBER BROWN: Just a minute. Back that up
8	a minute. I want to ask two questions. One on the
9	bypass thing. You're talking about an operator thing
10	bypass.
11	MR. POPPEL: Yes.
12	MEMBER BROWN: Okay. So, that's I just
13	wanted to make sure I understood that point. The
14	each division has its own two out of four voting
15	function.
16	MR. POPPEL: Yes.
17	MEMBER BROWN: And then you made the next
18	statement, said there's another, if I understood you
19	correctly, another two out of four. In other words,
20	you've got to have two out of four divisions all
21	coming to that two out of four decision.
22	MR. POPPEL: Yes.
23	MEMBER BROWN: Now, where is that voting
24	done, in the same processors?
25	MR. POPPEL: You can see on this thing
	1323 RHODE ISLAND AVE., N.W.
	(202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com

here, the flow across the yellow boxes is the remote multiplexing unit in the field talking to, we'll talk about that later, to the DTM, which is the box that says the parameter has exceeded its value. And then you can see the two out of four links going to the other divisions, so that each division communicates a per parameter trip decision. And then the DTM reports and says that Div. 1 has determined that there is a two out four pressure trip. Okay?

10 It gets transmitted to the box called TLU, 11 Trip Logic Unit, which, basically, has another two out 12 of four vote at the, for want of a better term, load driver level. So, when I told you that here's a load 13 14 driver that has four fibers connected to it, and when 15 two out of the four fibers say you should interrupt 16 the current to this thing, if I bypass it, it says to 17 the load drivers don't pay attention to that division in your decision. Okay? And just like the first 18 bypass switch, there is a joystick and logic to insure 19 that only one division at a time can be bypassed. 20

21 MEMBER BROWN: So, the second voting logic 22 is not done in the processors, it's done at the load 23 driver --

24 MR. POPPEL: It's done at what's called the 25 output logic unit. Okay? But it is done in a

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

3

4

5

6

7

8

9

106 1 processor. I shouldn't mislead you. It is absolutely 2 done in a processor. The processor is in a different 3 chassis than the first processor. The first processor 4 being the VTM one, and the second being the TLU one. 5 MEMBER STETKAR: Ira, quick while he's looking for a reference. Is it physically possible, 6 7 or legally allowed to place, for example, is Division 8 1 sensor has been bypassed, and Division 2 logic, if I 9 can call it --10 MR. POPPEL: Yes. 11 MEMBER STETKAR: in bypass _ _ 12 simultaneously. 13 MR. POPPEL: Yes. 14 MEMBER STETKAR: Both physically possible, and there's two separate joysticks, one of sensors, 15 and one for whatever it's called, logic. 16 17 Maybe the most MR. POPPEL: assuring statement to say is, no matter what the operator does 18 with those joystick switches in the main control room 19 20 _ _ MEMBER STETKAR: You still have two left. 21 22 MR. POPPEL: -- will not degrade you to 23 below two like parameters exceeding their parameters, 24 not bypassed will cause a trip. 25 MEMBER STETKAR: But you can, actually --**NEAL R. GROSS** COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. (202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com

	107
1	MR. POPPEL: Yes.
2	MEMBER STETKAR: Yes, do that. Okay.
3	MR. POPPEL: And what it, basically, boils
4	down to is what boxes you want to do maintenance on.
5	MEMBER STETKAR: Yes.
6	MR. POPPEL: Okay. The reason you have to
7	do well, you don't have to, because it's two out of
8	four. You can always work on one while it's quote.
9	But if you disable anything in the system, if the
10	boxes don't talk to one another, et cetera, being a
11	fail-safe design, it just goes to trip. So, for
12	example, those two out of four links, one of the
13	reasons they're not redundant is says I'm telling
14	you about the trip status of all my measurements, and
15	if you don't get it, you just assume that I'm all
16	tripped, unless I have a signal that says that
17	division is in bypass.
18	MEMBER STETKAR: In bypass.
19	MR. POPPEL: I should also say that the
20	I'm sorry, Charlie.
21	MEMBER STETKAR: I'm assuming he's ready.
22	MEMBER BROWN: Yes. I'm waiting for him.
23	MEMBER STETKAR: No, I'm done. I've got
24	enough.
25	MEMBER BROWN: Okay.
	NEAL R. GROSS
	(202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com
	108
----	---
1	MEMBER STETKAR: Thanks.
2	MEMBER BROWN: Don't ever assume I'm ready
3	for anything, John.
4	MEMBER STETKAR: You look prepared.
5	MEMBER BROWN: I'm looking at your figure
6	here, which I saw in the Rev. 7 stuff, also. And I
7	see the TLU. Then when I go look at Figure 7.2-1 in
8	the DCD, it shows the output of the TLU going to an
9	RPS output logic unit, which is not shown on here that
10	I can see.
11	MR. POPPEL: Right. There's another figure
12	in the
13	MR. BUTLER: I think those figures are all
14	in backup.
15	MEMBER BROWN: Well, I don't know. I
16	haven't gone through your entire presentation. But, I
17	mean, it's Figure 7.2-1, shows that, and it goes
18	so, is the output logic unit why does it have to be
19	a microprocessor? All it's doing is getting a
20	division output unit singing a one or a zero off to
21	or something, whatever you're sending. It's kind of
22	maybe a load but it goes off to a load driver down
23	where you have all the scram solenoids.
24	MR. POPPEL: Just in case I misunderstood
25	you, the DTM and the TLU are processor-driven devices.
	NEAL R. GROSS
	COURT REPORTERS AND TRANSCRIBERS
	1323 RHODE ISLAND AVE., N.W. (202) 234-4433 WASHINGTON. D.C. 20005-3701 www.nealroross.com
	· · · · · · · · · · · · · · · · · · ·

1	109
1	MEMBER BROWN: Yes.
2	MR. POPPEL: You asked that's what I
3	thought you were asking.
4	MEMBER BROWN: No, I said each division
5	MR. POPPEL: The OLU, not only does it not
6	have to be, it is
7	MEMBER BROWN: Yes. Okay. That's what I
8	thought. The DTM, though, I mean just the processing,
9	the TLU is a separate processor, that's where the
10	voting is done.
11	MR. POPPEL: Yes.
12	MEMBER BROWN: Okay. You confused me for a
13	minute. You have to be careful with old guys.
14	MR. POPPEL: The only reason we concentrate
15	on the first slide is because that's where the two out
16	of four point-to-point lines are shown.
17	MEMBER BROWN: Yes, from all the DTMs and
18	all the other type stuff.
19	MR. POPPEL: Right.
20	MR. BUTLER: That's where the inter-
21	divisional communication
22	MEMBER BROWN: I got that. But for the two
23	out of four division level trip, the actual trip that
24	gets sent out, I mean, does something, actuates the
25	final control device, is a matter of how the load
	NEAL R. GROSS
	COURT REPORTERS AND TRANSCRIBERS
	(202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com
I.	(202) 257 4455 WASHINGTON, D.C. 2000-5701 WWW.itealigioss.com

ĺ	110
1	devices are arranged. Is that correct?
2	MR. POPPEL: Yes.
3	MEMBER BROWN: So, they get a division trip
4	signal, and then they're the final two out of four,
5	any two out of four the division trips will trigger
6	the load device, will trigger the scram breakers.
7	MR. POPPEL: Yes. We discussed that, that
8	they only existed physically in Div. 1 and Div. 2
9	because that's the power they were switching. So,
10	where it says LD, that means Load Driver.
11	MEMBER BROWN: Okay.
12	MR. BUTLER: That's in backup. It's Figure
13	7.2-11b from the DCD Rev. 6, and 7, and 8.
14	MEMBER BROWN: I have that one, also, which
15	is readable. Okay. All right. This is just an
16	expansion of this in here. Okay.
17	MR. POPPEL: Now, if you go back to
18	MR. BUTLER: Okay, you're fine. Let's stay
19	on track. So, let's keep going.
20	MR. POPPEL: Before we leave this one, just
21	to say that the two out of four is point-to-point,
22	it's fiber, of course, and its coding is such that in
23	a simpleminded way it can tell that there is no
24	communication, and it can also determine something
25	about each division's clock, technical Manchester
	NEAL R. GROSS
	COURT REPORTERS AND TRANSCRIBERS
	1323 RHODE ISLAND AVE., N.W. (202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com

	111
1	coding. But the bottom line is, it's set up so that
2	to support the failsafe nature of the communication
3	and the isolated nature of the communication.
4	When the communication occurs, it gets
5	dumped into a shared memory. Okay? And then it's
6	pretty much like we had our discussion before. So,
7	the application program, which in this case is a burnt
8	in, accesses the shared memory to see what was brought
9	in by that point-to-point link.
10	MR. BUTLER: Okay. Let's go to SSLC.
11	MR. POPPEL: Okay. SSLC has the same line,
12	but in this case, it's the bus that you saw before.
13	So, the SSLC is, in fact, the network. So, unlike the
14	point-to-point communication, which is 100 megabits a
15	second at 30 feet of fiber, which is, essentially,
16	instantaneous in terms of our time budgets, anything
17	that's ethernet is not instantaneous, and on the face
18	of it may not appear deterministic because of the way
19	ethernet works. Okay? So, we had to think about that
20	carefully.
21	So, we have the buses that you saw before.
22	So, this is a little example of our communications
23	that are going on. So, in other words, this is a
24	calculation to say well, how loaded is that bus? So,
25	in other words, if I'm sending a Div. 1 message that's
	NEAL R. GROSS
	(202) 234-4433 WASHINGTON D.C. 20005-3701 Www.nealroross.com

1,024 bytes long, which is -- and I don't know whether there's 1,024 bytes to send one or a zero with all that authentication stuff on it, so I have Div. 1 doing that roughly 10 times a second, and acknowledging to the four divisions, so Div. 1 is doing that times four, times two because of the acknowledgment, and so is Div. 2, and Div. 3, and Div. 4 all on the same network.

9 DR. WALLIS: This is all to send a one or a 10 zero.

11 MR. POPPEL: Yes, all to send a one or a So, in other words, if you say okay, it's 1,024 12 zero. bytes and it's 100 megabyte a second link, exactly how 13 14 much do we fill out that link, just assuming it's just 15 random, and we'll talk about the randomness stuff. 16 And the bottom line is, we're filling up the link 17 about zero percent, .6 percent. Okay? So, it's a 18 very, very lightly loaded network. Okay?

Now, the other thing we did is said, okay, well that's how long the message is in time, but how about the transport of the message? Okay. The next calculation is the bottom one, said well, okay, speed of light in the fiber, the distance of the DCIS rooms, et cetera, et cetera, so the bottom line is, our message is about 82 microseconds in length, and the

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

3

4

5

6

7

8

www.nealrgross.com

transmission time is about .15 microseconds. Okay? That's a fairly straightforward calculation, so what we have to do about determinism is say what does that mean given the way that ethernet works? But the takeaway is, transport time is almost negligible. The network is extremely lightly loaded, and the messages are not long in time. So, this is what happens with ethernet to make it, perhaps, non-deterministic, and we say functionally deterministic.

10 So, I draw your attention to the yellow 11 box, and that box across the top is 100 milliseconds. 12 So, in other words, it may or may not have been obvious by now but the ESBWR is a very slow beast in 13 14 terms of ECCS. Not much has to happen fast, there's a 15 long time to do stuff. We don't have to get diesels started in 10 seconds, et cetera, et cetera. 16 So, 17 nominally, we don't know yet, but we're saying we'll 18 probably be running the SSLC/ESF, that cyclic program that we talked about at maybe two to four times a 19 second, but we wrote down 10 times a second. 20 So, in 21 other words, the top yellow bar is 100 milliseconds in 22 time, and we say that's how often the loop is going to 23 repeat. Okay? So, we want to make sure that our two 24 out of four messages get to the microprocessors in a 25 timely way to support their two out of four decisions.

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

3

4

5

6

7

8

9

So, we set a criterion of one millisecond. That's that little red sliver that Romeo is pointing to there. That's what we're saying is success. If we can get our message in a reliable way in one millisecond, we'll be fine.

And then we expanded that one millisecond 6 7 and said by the way, the green that you're seeing 8 there is the length of the message. That's the 82 microseconds we talked about before. So, somehow we 9 have to make sure that all four divisions using the 10 11 same network doing this stuff can get the information in a timely way. So, here's the way that ethernet 12 works. And this isn't unique to GE, this is just the 13 14 way ethernet works.

15 So, the first thing that happens is that all the divisions typical of ethernet, but all four 16 17 divisions are looking at the network. Is there 18 anything on it? Okay. Well, in general, 99.4 percent 19 of the time there's nothing on it. Okay? There's random, but in general, 99.4 percent of the time 20 21 there's nothing on it, so it sends a message. It's an 22 80 microsecond message, it takes .15 microsecond, all 23 is well. Okay?

24 So, the next thing that happens is well, 25 wait a minute, suppose I go look at the network, more

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

3

4

5

or less the remaining .6 percent of the time, and 1 2 there's something on it? Okay. Because everything is 3 common, they're not synchronized in any way, so it 4 says there's something on it. Okay? So, I'm not 5 going to try to transmit. I'm going to wait. How long do you have to wait? You have to wait 82 6 7 microseconds for the message to clear, plus another 8 .15 microseconds for the message to get through the 9 That's how long you've got to wait, and then fibers. 10 the division that's sitting there waiting says my 11 turn, so then it sends its message. So, now what 12 you've done is you've sent the message, if you will, 82 microseconds late, which more than meets our one 13 14 milliseconds criteria for getting the message there in 15 a timely way.

16 So, that's the situation that's going to 17 happen essentially all the time, but there is a 18 possibility of data collisions. Okay? The way this comes about is, Div. 1 is using the network. 19 Okav? And as it happens, just randomly, Div. 2 and Div. 3 20 21 have a message to go. Okay? So, Div. 2 and Div. 3 22 are looking, they wait for the Div. 1 to clear, and then Div. 2 and Div. 3 simultaneously, because they 23 24 don't talk to one another, they say my turn, and they 25 both put data on the ring. Collision. Okay? So,

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 what ethernet does about that is they say everybody 2 backs off, and we're going to -- this is heavy inside 3 baseball, we're going to wait some random slot time, 4 which is like 5 microseconds for 100 megabyte ring, 5 we're going to wait like -- each division makes a random calculation. I'm going to wait an X multiple 6 7 of 5 microseconds, and then I'm going to try again. 8 And they do that independently. Okay? So, in 9 general, one division goes and gets it, and then the 10 third division waits. And now, if you will, you lost 11 80 microseconds, 80 microseconds, and the third one 12 goes 164 microseconds late, which is still okay for our one millisecond. 13

14 But suppose just at random both divisions 15 said I'm going to wait the same random amount of time 16 So, they have another collision. and try again? 17 Okay? Then ethernet says okay, I'm going to back off a different random time that has bigger numbers, so 18 before I could have just had a random two slot times 19 to four slot times, the second time it'll be like four 20 21 slot times to a slot time. But the bottom line is, 22 they keep trying. Okay? And each time they're trying 23 there's a longer delay, but each time they're trying 24 the chances of this event happening are becoming less, 25 and less, and less, because, in general, there's

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

nothing on the network.

1

2

3

4

5

6

7

8

So, you can actually take a calculation that says here's the ethernet rules. Okay? So, what are the chances of getting a message through in -next slide. Yes. What are the chances of getting a message through in our -- so, here's our criteria. We said we want to get the message through in 100-year period in one millisecond with a certain probability.

9 DR. WALLIS: These are probabilities per 10 100 years. They're not probabilities per message.

11 MR. POPPEL: No, it's actually probability 12 of it happening in 100 years per message. So, this is happening at 10 times a second per division, but each 13 14 one is an individual chance. So, in other words, what 15 chance do I have of getting my message through on this 16 So, you can see, I mean, we included a "network?" 17 lot of stuff there, but our thing which says 1,024 and 18 100 megabit a second network, and dead time of one millisecond, et cetera, et cetera, and you can see the 19 probability calculated, and we're like seven nines. 20

DR. WALLIS: And your X axis on the right there is a zero percent that should be message rate. The X axis is message rate, it's not network load.

24 CHAIRMAN CORRADINI: What are you looking25 at, Graham? I didn't understand.

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	118
1	DR. WALLIS: The X axis in the probability
2	of success, the upper graph there shouldn't be zero
3	percent for every spot, it should be it's per
4	message rate, if you look at the table.
5	MR. POPPEL: Oh, no. The reason for that
6	is, you can see that all of those varying loadings
7	that we calculated, the network is all, essentially,
8	zero percent
9	DR. WALLIS: The variable is message rate.
10	The independent variable is message rate, zero, five,
11	ten, fifteen, twenty, twenty-five.
12	MR. POPPEL: Okay. I see what you're
13	seeing. Yes.
14	CHAIRMAN CORRADINI: Plotted the wrong X
15	variable with Excel.
16	MEMBER ARMIJO: That's right.
17	MR. POPPEL: So, all I'm trying to say out
18	of this is that it's unlikely that the message won't
19	get through, and the probability is enormous. And
20	it's like and, remember, the success criteria is
21	getting it through in one millisecond.
22	DR. WALLIS: Well, the probability of
23	something else going wrong must be bigger.
24	MR. POPPEL: Yes.
25	MR. BUTLER: That's it, that's the point.
	NEAL R. GROSS
	COURT REPORTERS AND TRANSCRIBERS
	(202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com

	119
1	Let's go.
2	MEMBER BROWN: What did he say? I didn't -
3	-
4	MR. BUTLER: He said the probability of
5	something else going wrong is bigger.
6	MEMBER BROWN: Yes.
7	MR. BUTLER: Yes. Okay. So, let's go on
8	to the next chart.
9	MR. POPPEL: Universal agreement having
10	been obtained.
11	MR. BUTLER: All right. We won't spend too
12	much time on redundancy, simply because I don't think
13	there's too many concerns about that. So, what we did
14	here was just present the highlights, no different
15	than from the 22 nd of October, no different than
16	what's been in the DCD since Rev. 6, or earlier.
17	Okay?
18	We wanted to make a specific point, again.
19	We are trying to highlight an area of concern around
20	ethernet networks within SSLC/ESF, so here is the
21	explanation, again, very briefly, Ira, which we kind
22	of discussed before, what happens with a fiber break
23	in the dual rotating rings. So, I don't think there's
24	any okay, next chart. All right. Diversity.
25	We're highly diverse. Okay? Any questions about
	NEAL R. GROSS
	COURT REPORTERS AND TRANSCRIBERS
	(202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com

	120
1	this?
2	MR. POPPEL: By definition, the three
3	platforms are highly diverse.
4	MR. BUTLER: Okay. So, the next one. All
5	right. So, this is just another graphic to show how
6	it lays out in an architectural format, so go the next
7	one.
8	MEMBER ARMIJO: Going back to that
9	diversity chart.
10	MR. BUTLER: Yes.
11	MEMBER ARMIJO: You point out that you use
12	this approach or design from the ABWR Lungmen Project,
13	and was it also part of the design, or the same thing
14	in the Japanese ABWR?
15	MR. POPPEL: No, the Japanese ABWR was
16	different. What happened at Lungmen is, we separated
17	out ECCS and reactor trip, two different platforms,
18	and we maintain that with ESBWR, and added the diverse
19	protection system.
20	MEMBER ARMIJO: Okay. But that plant has
21	yet to operate. Right? It's almost ready, it's
22	almost built.
23	MR. BUTLER: Architecturally, with the
24	exception of DPS, the approach to having different
25	platforms for RTIF-NMS and SSLC/ESF was what we
	NEAL R. GROSS
	COURT REPORTERS AND TRANSCRIBERS
	(202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com

learned from that project to address concerns in digital systems. Let's go to the next one. Simplicity.

4 MR. POPPEL: We're, basically, as simple as 5 possible given the complexity of the design. But, I mean, there were some active decisions that we took 6 7 about how to configure all of this DCIS. Okay? And 8 one of the things we did is, we split it up into lots 9 of different functions, so that -- in other words, a 10 Mark VI controller, or a DTM processor is capable of 11 doing lots and lots of things, far more than we're asking it to do, but we didn't put those things in it. 12 So, we made it so this controller controls reactor 13 14 pressure, it doesn't control reactor level. So, the 15 bottom line is, removes the concerns about the failure 16 of the platform. It also means that when it comes time 17 to specify design and test the software, it's a lot 18 simpler when it only has one or a few functions to do, permutation combinations, and all of that. 19

Another one that we did is no closed loop control over a shared network. So, basically, here's the reactor pressure system controller. Okay? Obviously, it has to measure reactor pressure, and it measures its own reactor pressure, and it measures its own reactor pressure with its own sensors that it

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

3

controls, and it poles, and doesn't depend on anybody else's reactor pressure sensors to do it.

3 So, similarly, all our controllers that 4 have functions to do are not using that big network to 5 pass data back and forth because it's convenient. Ιf they need it, they measure it themselves. Okay? 6 And 7 that allows us to make the statement that -- the 8 reason for the control room is monitoring, alarming, 9 and all the rest of it. If you lost all of those 10 controllers continue links, the on autonomously 11 controlling their processes, both safety and non-12 safety can say that.

13MEMBER BROWN: In each division, let me14just pick the RTIF, again, doesn't matter which,15pressure, each division has its own pressure sensor.

MR. POPPEL: Yes.

17 MEMBER BROWN: Other than trip functions, 18 or like functions, which that data, once it gets tripped, sent from division to division, do you do any 19 data evaluation? For example, do you take your say 20 21 Division 1 pressure and then somehow Division 2, 3, 22 and 4 get over there, and you say oh, look at all of 23 these, and I'm going to reject this, because it 24 differs from an average of the other three, or the 25 four, blah, blah. Do you do any --

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

16

	123
1	MR. POPPEL: I did that, Charlie. You
2	shish kabobbed me.
3	MR. BUTLER: So, we have a chart on that.
4	MEMBER BROWN: That's why I asked the
5	question.
6	MR. BUTLER: We say absolutely not, and the
7	chart is in there.
8	MEMBER BROWN: Okay. That's fine.
9	MR. BUTLER: Yes. So, that's it, we don't.
10	MEMBER BROWN: Yes, we don't have to go
11	we can go on.
12	MR. BUTLER: We don't have to go any
13	further, yes.
14	MR. POPPEL: I, also, just wanted to say
15	that the pressure sensor in SSLC/ESF is different than
16	the pressure sensor in RTIF. They're not the same
17	even within the division.
18	MR. BUTLER: And they're different for DPS.
19	MEMBER BROWN: Yes. I mean, you've got
20	independent sensors for each function.
21	MR. BUTLER: Do have independence.
22	MEMBER BROWN: Yes. Thank you.
23	MR. POPPEL: The other thing is a big issue
24	nowadays with DCIS is cyber security. We have it's
25	hard to say about that. Basically, we said we're
	NEAL R. GROSS
	COURT REPORTERS AND TRANSCRIBERS
	1323 RHODE ISLAND AVE., N.W.
I	(202) 234-4433 WASHINGTON, D.C. 20005-3701 WWW.nealrgross.com

1 going to choose communication protocols that make it 2 highly resistant to spoofing, et cetera, and we're 3 going to use all kinds of smart switches to prevent 4 all kinds of bad things from happening. And even our 5 non-safety controllers can't be programmed externally. So, for example, if they need data, I 6 7 mean, the application in the non-safety program 8 basically says I'm going to listen to this. I have to 9 be programmed for it. I'm going to send this out, but nobody can say to me stop and do it. 10 11 MEMBER BROWN: Okay. So, go backwards to 12 the shared memory, the communication via -- with the writes being X'd. The only way that can be done is at 13 14 the cabinet? 15 MR. BUTLER: Yes. 16 MEMBER BROWN: You have to come down, open 17 the cabinet --18 MR. BUTLER: With a special device. 19 MEMBER BROWN: Yes, whatever, lap -whatever the thing is you use, but it cannot be done -20 21 22 MR. BUTLER: You cannot do that through the 23 network. MEMBER BROWN: -- from the main control 24 25 room. **NEAL R. GROSS** COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. (202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com

	125
1	MR. BUTLER: It cannot be done. Only with
2	a separate piece of equipment
3	MEMBER BROWN: At the
4	MR. BUTLER: at the actual chassis.
5	MEMBER BROWN: Okay. All right. I just
6	want to clarify.
7	MR. BUTLER: Okay.
8	MR. POPPEL: Main control room can't
9	program anything.
10	MR. BUTLER: Anything. And nothing can be
11	programmed from outside of the cabinets, themselves,
12	in the Q-DCIS room. And, in fact, all of the
13	information that we shared with you about the design,
14	to get to data isolation and data independence, are
15	the similar techniques that one uses to create a cyber
16	secured digital environment. So, that's why if you
17	embrace 603, and do it is in this modular, segmented,
18	and layered way making the functional level simple,
19	and building up from there, that creates a cyber
20	secure design from a data perspective. That's why
21	they're synergistic.
22	MR. POPPEL: Just a few more simplicity
23	things. Our remote shutdown panel is basically an
24	auxiliary control room with less screens. So, it's
25	not a limited function, you can only do this, that, or
	NEAL R. GROSS
	COURT REPORTERS AND TRANSCRIBERS
	(202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com

126 1 the other thing. It's, basically, the operator 2 controls the plant in the same way with the same 3 screen formats that you will control from the main 4 control room, and only loses functionality depending 5 on power and all the rest of the stuff. But he doesn't have -- there's no new human factors, or 6 different human factors associated with that. So, you 7 8 can pretty much operate the plant completely from the 9 remote shutdown panels. This is sort of a duh. I mean, we use --10 11 even where we don't have to, we use optical fiber. 12 MEMBER BROWN: Let me go back to the other 13 question, again. Is that captured in the DCD? That's 14 a configuration management issue. Is that -- your 15 remote programming. 16 MR. BUTLER: We have made it very clear 17 with the Rev. 8 that we've submitted, yes. 18 MEMBER BROWN: Okay. Yes, I didn't see any 19 MR. BUTLER: It was implicit before in some 20 21 of the way we stated things, we made it very clear. 22 MEMBER BROWN: Okay. All right. Thank 23 you. 24 MR. POPPEL: Okay. Next. 25 MR. BUTLER: Next. **NEAL R. GROSS** COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. (202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com

	127
1	MR. POPPEL: This is sort of like a major
2	simplicity. Absolutely, we do not have non-safety
3	talking to safety, or controlling it, or any
4	possibility of it. I shouldn't say any, very low
5	possibility of it, and we do not have any very low
6	possibility of any division controlling any other
7	division. To control a division, you have to go to
8	the VDU associated with that division. That is the
9	only way operator commands can get to the things in
10	that division. Absolutely, so we never have any box
11	saying who should I listen to?
12	MR. BUTLER: There's a question.
13	MEMBER STETKAR: Ira, what do you do in
14	some some systems have both non-safety and safety
15	functions. Pick fuel auxiliary pool cooling system,
16	for example, it's a normally operating non-safety
17	system, provides cooling, some pools can be aligned to
18	the suppression pool. It has a safety function in a
19	sense that it has containment isolation valves that
20	need to close from a safety signal. How do you
21	interface the non-safety signals? For example, if I,
22	as the operator, through the non-safety system want to
23	during normal operation align the fuel and auxiliary
24	pool's cooling system for cooling the suppression
25	pool, I need to open those isolation valves. And,

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

128 1 yet, if an accident happens, the leak detection and 2 isolation system has to come in and tell those valves 3 to close, even thought they might have an open demand 4 signal from my non-safety controls. 5 MR. POPPEL: You said it correctly. The operator has to do that. What the operator has to do 6 7 is, he has to step over to the safety VDU. 8 MEMBER STETKAR: Okay. So, those valves 9 are only controlled through safety. 10 MR. POPPEL: Yes. 11 MEMBER STETKAR: Okay. Thanks. MR. POPPEL: It makes it simpler to do the 12 design that way. 13 14 MEMBER STETKAR: The thing with RWCU and, yes, all that kind of --15 16 MR. BUTLER: They're all done that way. 17 MEMBER STETKAR: Okay. Good. That wasn't completely clear. 18 MR. POPPEL: Even with the plant automation 19 system, can't control anything except safety. Okay. 20 21 Oh, logic. I'm sorry. Let's go to the next one. 22 MEMBER BROWN: You really want to say that? MR. POPPEL: Which? 23 24 MEMBER BROWN: Not required. 25 CHAIRMAN CORRADINI: Well, they're just **NEAL R. GROSS** COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. (202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com

	129
1	stating facts.
2	MEMBER BROWN: I know. I know. I'm just
3	MR. POPPEL: It's a factual statement.
4	MEMBER BROWN: You've got to have
5	MR. BUTLER: So, yes, we want to say that.
6	They're not required by regulation. Second bullet,
7	Ira.
8	MR. POPPEL: You mean notwithstanding.
9	MEMBER STETKAR: The correct term is that
10	the regulations do not require that you submit that.
11	It's not that the regulations preclude you from
12	submitting them. Is that correct?
13	MR. BUTLER: Yes.
14	MEMBER STETKAR: Okay.
15	MEMBER BROWN: Thank you, John. I like
16	that.
17	MR. BUTLER: You want us to change the
18	statement on the chart?
19	MEMBER STETKAR: No, it's fine.
20	MR. BUTLER: Okay. But your clarification
21	is correct. Bullet two.
22	MR. POPPEL: Okay. The original logic
23	diagrams that had been submitted were called
24	simplified logic diagrams, and they were, basically,
25	to demonstrate statements in the DCD. They were in no
	NEAL R. GROSS
	COURT REPORTERS AND TRANSCRIBERS
	(202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com

1 shape, or form a description of the entire way, system, or all the things that were in them. 2 Okay? Okay? 3 So, it's sort of a dead-end path. But, as 4 you've seen with our software management LTRs, we have 5 very detailed development process to making а software, and putting into those controllers. 6 And 7 part of that is to make logic diagrams, in this case 8 functional logic block diagrams, as an input to the 9 software design process, to say this is some of the 10 stuff we want you to incorporate in the software 11 requirement specification.

12 So, we just wanted to leave, I guess, with the warm fuzzy that there will be logic diagrams. They 13 14 will be viewable. And in the ITAAC process, coupled 15 with the software LTRs, you may remember there was 16 something called a Baseline Review Process, we have 17 phases of the software design, and at the end of the 18 phase, we say have this Baseline Review Process, in part to look at all the documentation associated with 19 that phase, to give approval before you can go on to 20 21 the next phase. And part of that will be the review 22 of the logic diagrams that were created to support 23 So, they will exist, they will be that phase. 24 viewable.

MR. BUTLER: Available for audit.

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	131
1	MR. POPPEL: Available for audit, is the
2	MEMBER ARMIJO: Who does the baseline
3	review, is that a GE function?
4	MR. BUTLER: So, the baseline review is
5	convened by the design organization. It's chaired by
6	an independent group. And for those things identified
7	as software critical, there's an independent a
8	group that does not report to Design Engineering, that
9	does the assessment and the approval of those
10	artifacts, which include the logic diagrams.
11	MEMBER ARMIJO: Well, it's equivalent to an
12	independent design review
13	MR. BUTLER: It's equivalent to an
14	independent design review, yes.
15	MEMBER ARMIJO: Within GEH?
16	MR. BUTLER: Yes. It is within for the
17	LTRs, it is within GEH, but it is — ultimate approval
18	to go forward is by an independent body. And that's
19	the role of SQA, and that's why there's a whole
20	separate SQA LTR. There are three LTRs. There's one
21	that describes the overall systems engineering
22	process. There's the one for SQA, which is the
23	independent auditor, not in Design Engineering, and
24	then there's one for cyber security. And they all
25	integrate together, and they all have a role in these
	NEAL R. GROSS
	COURT REPORTERS AND TRANSCRIBERS
	(202) 234-4433 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701 www.nealrgross.com

six phases. Just a typical example of a block diagram from Rev. 5. There's many of them. Go to the next. Okay. I'll do this one.

4 What this shows from Rev. 8 that was 5 submitted yesterday is the RTIF software plan example, and what you see here is, for each phase -- let me 6 7 draw it. So, for each phase, here's the planning 8 phase. The logic diagrams are explicitly identified in 9 the LTRs as being input and output requirements for 10 every design phase. There is an ITAAC for each one of 11 the platform to go through and say it exists, and it's 12 adequate. It's done again in the requirements phase, the design phase. Implementation is where the initial 13 14 coding is done, test phase, installation phase. All 15 of these have an independent assessment, and they all 16 have the requirement that the logic diagram, or any of 17 input/output the other requirements have been independently assessed, fit for use, and meet their 18 intended safety function purpose. Go to the next. 19

20 MEMBER BROWN: Go back up to that for a 21 second. I guess you're still there.

MR. BUTLER: Yes.

23 MEMBER BROWN: I read through a whole bunch 24 of these, 2As through whatever. They were in Rev. 7. 25 And, I guess, I have to admit, I walked away a little

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

22

1

2

3

www.nealrgross.com

	133
1	bit I mean, they are very, very, very, very
2	general. I mean, it effectively says our design phase
3	says we'll design it, and the acceptance criteria is
4	that there is a report that says we designed it in
5	accordance with our requirements, which
6	MR. BUTLER: I guess, what I'd like to ask
7	you to consider, Charlie, is that the three LTRs are
8	Tier 2*, and in the three LTRs, they do explain not
9	only the process, but how the voracity of the
10	input/output documents are assessed. So, you can't
11	just read the ITAACs outside of those three LTRs.
12	MEMBER BROWN: They are Tier 2*.
13	MR. BUTLER: They are Tier 2*.
14	MEMBER BROWN: I guess, my point being, I'm
15	just going back to the, I guess, logic diagrams.
16	These are the logic diagrams that are, in my mind,
17	it's not what I've been talking about in terms of
18	architecture and stuff. This is the functional system
19	logic diagrams that says I'm going to take a pressure,
20	and a flow, and a level, and I've got water in the
21	reactor compartment, excuse me, in the reactor
22	building, then certain things happen, and pumps start.
23	That's a logic diagram that describes a safety
24	function, and that's what you're talking about. And
25	some of those, I don't know whether they're simplified
	NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

	134
1	or not, but I guess they are, show up. You've given
2	us some of those in the DCD, I think in Tier 2. Yes,
3	Tier 2, Chapter 7, didn't you? I thought I saw some.
4	CHAIRMAN CORRADINI: The logic diagrams?
5	MEMBER BROWN: Yes.
6	CHAIRMAN CORRADINI: I think Ira
7	MEMBER BROWN: John, you pointed that out
8	last time, didn't you?
9	CHAIRMAN CORRADINI: Well, I think just to
10	state it as I remember it, we asked for them, they
11	gave us samples. Ira's point was the samples, you
12	used the word "dead-end," I'd say incomplete. That
13	is, the examples we got were not complete. John found
14	some things when he was looking for completeness, but
15	I think the characterization was we got examples of
16	them, and that was kind of
17	MR. BUTLER: Yes, design basis of the
18	plant. Yes.
19	MEMBER STETKAR: Except even within Rev. 5,
20	there were incomplete is one, errors is another. So,
21	it's not clear what they what purpose they were
22	meant to serve, because they were not an accurate
23	logical replication of the plant design. So, it's not
24	clear what they were. I could give you specific
25	examples, but going into specifics is not worth the
	NEAL R. GROSS
	COURT REPORTERS AND TRANSCRIBERS
	1323 RHODE ISLAND AVE., N.W. (202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com

	135
1	effort. If you want, go look at GDCS actuation.
2	MR. BUTLER: Okay.
3	MEMBER STETKAR: It's wrong.
4	CHAIRMAN CORRADINI: In the example that
5	was given to us.
6	MEMBER STETKAR: Yes.
7	MR. BUTLER: Okay.
8	MEMBER BROWN: One of my concerns was that,
9	and this is just at this level right now. Okay? Is
10	that I've sat in these meetings where we've taken the
11	various systems, the GDCS, the other whatever all
12	the various systems that go into the safety, the ESF-
13	type functions, what have you, and we get excruciating
14	detail of pipe lengths, and runs, so that water flows
15	down through the pipes at the right velocity, and the
16	amount of debris that gets caught in the screens, and
17	all this, so it's just I mean, it's down to the
18	stainless steel bolts.
19	CHAIRMAN CORRADINI: That's because that's
20	the important stuff.
21	MEMBER BROWN: That's the important stuff,
22	right. But, yet, the logic diagram for saying when we
23	actuate these systems is not there. And that's what
24	got me, is that the logic diagram for telling all this
25	stuff to start, and what is the coincidence, what are
	NEAL R. GROSS
	1323 RHODE ISLAND AVE., N.W.
	(202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealraross.com

	136
1	the things that do this, what are the things you
2	didn't follow Mike's request.
3	(Off the record comment.)
4	MEMBER BROWN: And we sit here, and we
5	don't have those, and those will be developed later,
6	but the NRC has had no look at whether those cover all
7	the parameters, and are they configured or timed in a
8	safe viewpoint. So, I mean, I think that's what
9	one of the that was my concern, and it's done
10	later, and that the oversight is not there. But it is
11	for the diameter of the pipe, and all the other type
12	of stuff.
13	MEMBER STETKAR: I'm going to I've been
14	pretty silent so far this morning, by design, because
15	I think the discussion we've had for the last three
16	hours has been exceedingly useful, really, really,
17	really productive, and I don't want to try to
18	interrupt this. And, Charlie, if you're kind of to
19	the end of
20	MEMBER BROWN: Yes, I'm kind of to the end.
21	MEMBER STETKAR: Now, I'm going to pick up
22	the logic diagrams. As they're presented here, the
23	logic diagrams seem to be focused as part of a
24	software development tool, which they are. They
25	should be. They're kind of the architecture of the
	NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

11

way that you want that logic to work.

1

2 I look at them as something different from an overall plant integrated safety review perspective, 3 4 in the same way that we have piping and 5 instrumentation drawings that show that water goes from Tank A through Pump B, through Valve C, out into 6 7 Pipe Connection D, into the reactor vessel, that 8 picture gives me a good way of understanding in a 9 nice, comprehensive format the way that that system 10 Now, I might have questions about the pump works. 11 flow rate, about the opening times on the valves.

12 had example yesterday where We an Ι thought about gee, there's a way of getting water from 13 14 Point A to Point X, where I don't want water in Point 15 X, and I don't see a check valve in this nice little 16 piping diagram to prevent that from happening. So, as 17 a reviewer, as someone who might be concerned about 18 not putting water from Point A to Point X, that little drawing is really, really helpful for me, because I 19 can ask gee, can you get water from those two points, 20 and should there be a check valve in that line. 21 That 22 might be a safety concern.

I don't have similar diagrams right now in the DCD to allow me to look at the integrated reactor protection, safeguards actuation, and control

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

functions that, basically, orchestrate how everything in the plant works. So, as a reviewer, I have a difficult time standing back and getting that integrated perspective. That's just a statement.

5 Because of that, I believe that the Staff, 6 and the Staff has done a tremendous amount of work, as 7 you're well aware, the Staff has been relegated to 8 spending, essentially, all of their time trying to 9 insure that every single possible design requirement, 10 standard, and technical position and shall be 11 satisfied in words, such that later there is some assurance that the design can be audited, inspected, 12 reviewed, and I'm not going to use any one of those 13 14 three words in preference to the other, to gain some 15 confidence that, indeed, the design is going to do 16 what we want it to do; in other words, keep the plant 17 safe.

My impression is they've spent a lot more time doing that sort of stuff, than they've spent looking at the real design, because there are only 24hours in a day, and so many human beings in the world, and they've had to spend their time looking at things that look like the slide in front of us, which are tiers of numbers of requirements of things.

Now, that's just a monologue. Let me ask

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

25

1

2

3

4

some questions. I wanted to ask a kind of example question, kind of bring this point across. And I, honestly, don't know the answer. I really tried to figure out the answer, and I don't know. And I hope we've got the talent from GEH here that I need to get the answer to this question.

7 Suppose the plant is operating at 100 8 percent power. I normally have three feedwater pumps 9 running, and one feedwater pump in standby. Suppose 10 that feedwater pump that was in standby is out of 11 service for maintenance. It's allowed, it can be. 12 And now suppose that one of my three running feedwater pumps trips, so that now my feedwater flow reduces. 13 14 What happens to the plant?

15 CHAIRMAN CORRADINI: Somebody has a hand up16 out there.

MEMBER STETKAR: Anyone.

MR. MARQUINO: Wayne, here.

MR. POPPEL: I know, but, I mean, the -well, I'll let -- the proper answer is it has to be in the system design spec for the feedwater system, but the answer to your question is, I think, first we have an auto start of the feed pump, which would be disabled, and then we would have a select rod insert to reduce power.

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

3

4

5

6

17

140 MEMBER STETKAR: And, theoretically, the 1 2 plant should stabilize at a reduced power with -- the 3 pumps are nominally 33 percent pumps, so let's give 4 them 40 percent. 5 MR. POPPEL: Twenty-five percent. MEMBER STETKAR: Okay. So, the plant is 6 7 going to stabilize at maybe 80 percent power, 90 8 percent power, somewhere in there. But the key is 9 that the plant automation system will initiate select 10 rod insert? 11 MR. POPPEL: Yes. 12 MEMBER STETKAR: Okay. Is that true? MR. POPPEL: Well, the --13 14 MEMBER STETKAR: Everybody is shaking their 15 heads. 16 (Simultaneous speech.) 17 MEMBER STETKAR: This is a key point here, so I want to make sure that GEH agrees to this, 18 because I couldn't find that anywhere in the design 19 certification documents, so this is, honestly, a 20 question. And I want to make sure that that's what 21 22 will happen. MR. 23 MARQUINO: This is Yes. Wayne 24 Marquino. I believe you brought this question up at a 25 previous meeting we had --**NEAL R. GROSS** COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	141
1	MEMBER STETKAR: I don't remember, Wayne.
2	I actually don't.
3	MR. MARQUINO: All right.
4	CHAIRMAN CORRADINI: I think you did.
5	MR. MARQUINO: But we should be clear on
6	what functions are documented in the DCD versus what
7	GE internally expects to put in the design,
8	eventually, because I believe you're right in stating
9	that there's no description of an SRI function, or
10	SCRRI SRI function.
11	MEMBER STETKAR: SCRRI and SRI is all on
12	MR. MARQUINO: That triggers on
13	MEMBER STETKAR: It's all on ATWS in
14	feedwater temperature in the DCD.
15	MR. MARQUINO: Right.
16	MEMBER STETKAR: I'm trying to understand
17	the real plant in the real world, though.
18	MR. MARQUINO: Right. Now, going forward
19	in the detailed design, Ira and I have had discussions
20	about what we expect to put in the design as
21	requirements as we get into detailed design, and
22	that's what Ira is telling you.
23	MEMBER STETKAR: So, right now, best
24	available information would be, if I'm in this
25	configuration, if I have one feedwater pump out of
	NEAL R. GROSS
	COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W
	(202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com

	142
1	service, and I trip one of the three running feedwater
2	pumps, I would expect what I generically call a plant
3	run-back, SCRRI, ER, whatever that is. And I'd
4	stabilize at some reduced power level. Is that a
5	reasonable presumption?
6	MR. MARQUINO: That's a reasonable
7	presumption.
8	MEMBER STETKAR: Okay.
9	MR. MARQUINO: In terms of the actual
10	survival of the plant, if you you said I tripped
11	the feedwater pump, and the standby pump, which is
12	intended to mitigate that event is out of service, so
13	maybe the plant will scram, maybe it won't.
14	MEMBER STETKAR: I'm just thinking
15	MR. MARQUINO: Because it's a challenge. I
16	mean, it's a challenge to start with, and then you
17	said I'm disabling this
18	MEMBER STETKAR: I'm trying to understand
19	the plant design and operation. I'm not trying to
20	second guess stuff. Don't try to secondguess me yet,
21	you'll get a chance to answer specific questions in a
22	moment. I just wanted to make sure that I I didn't
23	know how the plant automation system, because there's
24	very little information, would work. And I just
25	wanted to make sure that I wasn't presuming something
	NEAL R. GROSS
	COURT REPORTERS AND TRANSCRIBERS
	(202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com

different before I walk into this.

1

2

3

4

5

6

Now, in the reactor protection logic, there is a reactor trip from loss of voltage at two power generation buses, and that's called an anticipatory loss of feedwater trip. Why do I have that trip?

7 MR. POPPEL: If -- okay. The original 8 concern was loss of all feedwater flow. We, actually, 9 lost all feedwater flow, and we did not want that 10 transient to get down to Level One, and turn on the 11 safety systems. Okay? If we had done nothing about 12 it, we're getting very close to that with the traditional Level Three scram. So, the talk turned to 13 14 can we do something anticipatorily. Okay?

15 So, how would you measure loss of all 16 feedwater flow? And we don't have any safety-related 17 instrumentation on the feedwater nozzles, but for 18 various other reasons on the independent -- anyway, we can monitor bus voltages pretty well. So if, in fact, 19 we lose the 13.8 KV buses, we will certainly lose all 20 21 feedwater flow. Okay? Absolutely. The reason it was 22 -- that was chosen was because it's anticipatory, but 23 if even just one feed pump remains on line, that's why it has to be all feedwater flow, one feed pump with 45 24 25 percent capacity will avoid the Level One concern.

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433
	144
1	Okay? So, that was the reasoning behind it.
2	MEMBER STETKAR: Ira, is the logic loss of
3	four power generation buses, or is it loss of any two
4	power generation buses?
5	MR. POPPEL: As of now, it's any two.
6	MEMBER STETKAR: Ahh, that's, basically,
7	what I read in the words. I couldn't confirm that in
8	the nice logic diagrams, except it looked from the
9	logic diagrams, so the logic diagrams were sort of
10	nice, because they were kind of consistent with the
11	words. But that doesn't seem to be consistent with
12	the plant design, because if I trip two feedwater
13	pumps, I don't get this nice anticipatory loss of
14	feedwater thing, but if I trip two electrical buses, I
15	do?
16	MR. POPPEL: If you trip two feedwater
17	pumps, by definition, you have at least one remaining.
18	MEMBER STETKAR: I had two in my example. I
19	had two feedwater pumps remaining. I tripped one, and
20	one was out of service.
21	MR. POPPEL: Okay.
22	MEMBER STETKAR: I reduced feedwater flow
23	to 70 percent, you said 90 percent of what it was
24	before this feedwater pump tripped. If I trip the
25	electrical bus for the feedwater pump that was out of
	NEAL R. GROSS
	COURT REPORTERS AND TRANSCRIBERS
	(202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com

service, and any one of the three remaining electrical buses, the plant doesn't know the difference in terms of feedwater flow. It doesn't know the difference.

Why in one case do I scram the reactor as an anticipatory loss of feedwater flow from loss of power to two, and only two feedwater pumps, and in the other case, the plant actually just remains operating at power per the plant design. Why does that happen? It seems inconsistent to me.

10 If I were a reviewer, I would be asking 11 questions about, is the plant protection design 12 consistent with the integrated plant control system, consistent with the design criteria for what you're 13 14 trying to protect against, which you mentioned is a 15 loss of all feedwater flow, not just a 10 or 15 percent reduction in feedwater flow. I don't see any 16 17 review questions being asked right now at that level. 18 You get those review questions when you have that integrated logic in front of you, and you can start 19 coincidences between 20 thinking about protection 21 controls, and safequards actuation.

So, if you have a good explanation of why losing the electric power to the same two feedwater pumps I decided to trip because of a mechanical problem in maintenance, why those give you wildly

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

3

4

5

6

7

8

9

146 1 different plant responses, I'm interested in learning 2 about. 3 MR. MARQUINO: I can answer the first part 4 of your question. The reason the safety logic has 5 this feature is to allow us to credit a scram in the design basis accident scenario where we're required to 6 7 assume that we lose offsite power, and we lose 8 feedwater. 9 MEMBER STETKAR: Okay. 10 MR. MARQUINO: So, then we looked at -- we 11 want to be able to credit a scram in that event, but we don't want to scram if we lose a feedwater pump in 12 operation. So, that's the 13 normal reason the 14 statements in the DCD are what they are. 15 MEMBER STETKAR: So, it's in the -- I'm 16 going to be silent. 17 CHAIRMAN CORRADINI: I guess I heard your answer. Can you say it again, because I don't think I 18 19 appreciated the answer. John may have got it, but can you try it again one more time. 20 21 MR. MARQUINO: So, the feature that's in 22 the safety system to initiate a scram, if you have a 23 loss of two out of four bus power to the feedwater 24 system is to allow us to credit that in the design 25 basis logo. In that event, you would get the scram, **NEAL R. GROSS** COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	147
1	and the reason it's two out of four is to prevent the
2	scram from occurring if we have an operational event,
3	which we can survive.
4	CHAIRMAN CORRADINI: Okay. Thank you.
5	MEMBER STETKAR: But you can survive the
6	operational event with loss of only two buses. Unless
7	there was something originally I you can't, with
8	the current logic, you can't
9	MR. MARQUINO: Okay. What you're saying
10	is, if we have 90 percent feedwater capacity, and I
11	think Ira will back me up on this math, and then we
12	have a SCRRI that reduces, a SCRRI SRI that reduces
13	power to around 50 or 60 percent, at least, we could
14	probably survive we could survive this event you're
15	postulating, which is when one pump is out of service,
16	and
17	MEMBER STETKAR: Reduction of feedwater
18	flow to two pumps, basically, however you get there.
19	However you get there.
20	MR. MARQUINO: So, yes, maybe we
21	MEMBER STETKAR: Part of this is simply, I
22	don't have a particular concern about this one. In
23	fact, it was just something that I thought about that
24	would integrate the normal plant control system,
25	whatever you call it, the plant automation system, and
	NEAL R. GROSS
	COURT REPORTERS AND TRANSCRIBERS
	1323 RHODE ISLAND AVE., N.W. (202) 234-4433 WASHINGTON D.C. 20005-3701 WANN DESIGNESS COM
1	

the protection and safeguards system where everybody thinks about that in the context of design basis licensing accidents. Your answer was you needed to take credit for that scram, because you have to assume a loss of power for your design basis accident analysis.

7 Putting scram signals into a plant that 8 might not actually protect you against the things you 9 want to protect against, or that might introduce inadvertent scrams for conditions that you don't need 10 11 to scram, simply because they're a convenient way of 12 meeting design basis licensing analysis requirements might be questioned in a review. 13 For example, you 14 mentioned well, you could monitor bus voltage easily, 15 you didn't want to put safety-related flow sensors in 16 the feedwater lines. Safety-related flow sensors in 17 the feedwater lines would give me an unambiguous 18 indication of the fact I don't have enough feedwater I'd better 19 flow that's survivable, SO scram the reactor in anticipation of not reaching Level One, or 20 21 something like that. But you didn't want to put the 22 levels in, the flow sensors in. From a review, you 23 ask is that alternative a better might want to 24 protection?

I had difficulty even dreaming up this

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

25

1

2

3

4

5

```
www.nealrgross.com
```

	149
1	little exercise. The logic diagrams that we haven't
2	officially seen help me, but I didn't even have the
3	logic diagrams to show me the plant automation system,
4	or even the general architecture, what it might do, so
5	that's why I had to ask the question first about the
6	run-back stuff.
7	MR. MARQUINO: So, your point
8	MEMBER STETKAR: I'm not my point being
9	
10	CHAIRMAN CORRADINI: I think I get your
11	point. Let me say it a different way. Your point is
12	that you think the logic diagrams give you an insight
13	into how control, safety, and safeguard interact, even
14	though they might be meeting the criteria, if I had
15	that there I might ask penetrating questions about how
16	I'm meeting the criteria, and how I might be
17	generating, let's say in this case, unnecessary
18	scrams.
19	MEMBER STETKAR: This seems to generate an
20	unnecessary scram.
21	CHAIRMAN CORRADINI: That's what I wanted
22	to make sure.
23	MEMBER STETKAR: And it doesn't,
24	necessarily, always protect you against the loss of
25	feedwater flow. Eventually, the Level Three scram
	NEAL R. GROSS
	COURT REPORTERS AND TRANSCRIBERS
	1323 RHODE ISLAND AVE., N.W. (202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com

will get you, if you don't have enough feedwater flow. But it's not clear what the loss of two, and only two buses, loss of three buses, loss of four buses might satisfy everything.

1

2

3

4

5

19

(202) 234-4433

CHAIRMAN CORRADINI: Okay.

MEMBER STETKAR: You follow me? 6 It was 7 simply an example to show -- I've been a strong 8 you all know, of getting the advocate, as logic 9 diagrams into the DCD, and that -- the purpose of that is allow reviewers to have that information available 10 11 at that level, at the same level as a PNID, a piping 12 diagram that shows check valves and normally open motor-operated valves, and so forth, so that you can 13 14 look at that in an integrated perspective, and at 15 least think about it, rather than down to minutia of 16 compliance with specific elements of а design 17 standard, like this thing. That's all I'm going to 18 say.

CHAIRMAN CORRADINI: Okay. Charles?

20 MEMBER BROWN: I have one other question 21 that I forgot to ask, if that's okay. It's not a long 22 question. The watchdog timers that you showed in your 23 cycle, program cycle architecture layout, there's a -24 - for the reactor trip and nuclear monitoring system, 25 you point out that those watchdog timers, if they time

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

www.nealrgross.com

151 1 out, process a channel trip, and an alarm while the 2 processor or logic function is resetting. So, I presume what they're doing is they're sending a boot-3 4 up again signal to the processor at the same time it's 5 initiating a single trip out of four. And that that information would be sent to all the other three 6 7 divisions, like any other trip signal. Is that 8 correct? What is the time associate with a restart, a 9 reboot, reset, whatever you want to call it on one of 10 the processors? 11 MR. POPPEL: We'll have to take the 12 question. 13 MR. BUTLER: We can get an answer for that. 14 We don't have that --15 CHAIRMAN CORRADINI: Say it again, so I 16 capture it. I'm sorry. 17 MEMBER BROWN: Okay. Well, the watchdog 18 timers that you saw in that program cycle architecture -- oh, they got it back. If you exceed the time and 19 the timer trips for the RTIF and NMS, the Nuclear 20 21 Monitoring System, those timers go back and they reset that 22 logic processor. In other words, it sends a 23 pulse, whatever you want to call it, says start --24 it's like rebooting your computer. And, at the same 25 time, it issues a channel trip, and an alarm. Correct **NEAL R. GROSS** COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

	152
1	me if I say something wrong, because I'm now, I
2	guess my question was, how long does it take to bring
3	a processor back?
4	CHAIRMAN CORRADINI: They'll come back and
5	give us an answer.
6	MEMBER BROWN: And they'll get back to
7	that. And the reason for my question is, if you want
8	to know why am I asking this nitwit question, is I
9	mean, everybody is familiar with when you hit a reboot
10	on your computer, it takes five minutes before you can
11	do anything. I picked a number, three minutes.
12	DR. WALLIS: It depends on the computer.
13	MEMBER BROWN: Exactly, it depends.
14	(Off the record comment.)
15	MEMBER BROWN: And one of the points a long
16	time ago when we first doing this stuff in our
17	program, 22 years ago, as a matter no, 32 years
18	ago, excuse me, was what do you do if you have a
19	processor all of a sudden blurp, and it needs to
20	restart, how long before operators see anything? And
21	when you started watching screens come up, and it took
22	three or four minutes, you decided very rapidly that
23	wasn't very good for operators. This was on display-
24	type stuff. The point being is, it ought to be quick,
25	and that's just what I'm there's a second part to
	NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	153
1	this.
2	CHAIRMAN CORRADINI: Okay.
3	MEMBER BROWN: The second part to this is
4	in the very unlikely based on our earlier conversation
5	of corrupting all the
6	MR. BUTLER: Those layers.
7	MEMBER BROWN: All those voting functions
8	at the same time, now I have 16 processors all going
9	into the reset mode. What is and I'm now getting
10	all my things there's no trip logic, because it's
11	not functional because the processors aren't
12	processing, so the plant just sits there during this
13	period, I would presume. You get the alarms, but
14	that's it. So, would the reactor actually scram in
15	that period of time while they're that's the other
16	point is how long they take to reboot. Would it
17	actually scram in that period of time, or would it
18	not?
19	MR. POPPEL: Yes. It's like because you
20	use the statement all of the processors and stuff like
21	that if you do it the way for example, if a two
22	out of four processor in DTM broke, and all the DTM
23	broke, there's no particular reason that would affect
24	anything downstream.
25	MEMBER BROWN: Well, the TLU is in there,
	NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS
	1323 RHODE ISLAND AVE., N.W. (202) 234-4433 WASHINGTON, D.C. 20005-3701

	154
1	also. Right? Okay.
2	MR. POPPEL: But it's a different set of
3	two out of four stuff.
4	MEMBER BROWN: Yes.
5	MR. POPPEL: But my point was and it's a
6	different watchdog timer. So, the first thing that'll
7	happen is for any of these events that any of these
8	incredible events that might be credible is, it will
9	scram. Okay? Because if you have four DTMs out, or
10	four TLUs out, and anything downstream was still
11	functioning, it'll scram.
12	The second thing is we're the reset of
13	those processors per 603 is not allowed to reset the
14	scram. The scram is there. The operator has to
15	MEMBER BROWN: No, that's the operable.
16	MR. POPPEL: The operator has to reset the
17	scram.
18	MEMBER BROWN: That's fine. This just says
19	it issues a channel trip. A channel trip can reset,
20	but a scram if they all there is no vote in this
21	case, so my point being is if you issued the it
22	issues a channel trip, but what does it issue it to?
23	I mean, is that a I guess I lost the bubble when we
24	were looking at one of the previous diagrams. The DTM
25	is a processor, and the TLU is a separate processor in
	NEAL R. GROSS
	COURT REPORTERS AND TRANSCRIBERS
	1323 RHODE ISLAND AVE., N.W. (202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com

	155
1	that
2	MR. POPPEL: Yes, and a separate chassis.
3	MEMBER BROWN: Okay. I was going back to
4	the even higher level one, where you there was a
5	higher level picture, but that's fine. So, they are
6	separate. Okay. So, the TLUs — the DTMs would
7	actually be the relevant it would issue a trip to
8	the TLUs. Is that correct?
9	MR. POPPEL: Yes.
10	MEMBER BROWN: And I'm not talking about
11	corrupting all the DTMs, because I'm not communicating
12	with those.
13	MR. POPPEL: They wouldn't issue a trip.
14	The lack of communication would be received as a trip
15	by the receiving thing. So, in other words, we're not
16	saying hey, broken thing, send a trip. The receiving
17	thing is saying I'm not hearing from you. I,
18	therefore, assume you tripped.
19	MEMBER BROWN: Okay. Now, the DTMs are not
20	exchanging trip data with all the other divisions.
21	It's just the TLUs that's doing that.
22	MR. POPPEL: No, it's doing it twice.
23	MEMBER BROWN: Both of those
24	MR. POPPEL: That's why we have the TLU
25	level, and it's happening at the DTM level. So, there
	NEAL R. GROSS
	COURT REPORTERS AND TRANSCRIBERS
	(202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com

	156
1	two two out of four votes going on.
2	MEMBER BROWN: I'm just looking at Figure
3	7.2-1, and it does not show any other DTM-to-DTM
4	communication. It only shows DTM-to-TLU
5	communication. Okay? So, that's why
6	CHAIRMAN CORRADINI: Is your question
7	answered?
8	MEMBER BROWN: Well, it's the voting unit
9	issue I'm talking about. Okay? If it got there, and
10	all the voting units went out, there would be no trip
11	issue. If they couldn't process
12	MR. POPPEL: Well, when you say all
13	okay.
14	MEMBER BROWN: If they got corrupted, they
15	couldn't process, because that's where the logic
16	function is.
17	MR. POPPEL: So, when you say that so,
18	they got corrupted, but they're still sending no trip.
19	MEMBER BROWN: I don't know they're sending
20	anything at all.
21	MR. POPPEL: Then they'll trip, because the
22	next thing downstream
23	MEMBER BROWN: So, the watchdog timer would
24	not get struck, and it would do its thing. But where
25	does it send its trip, to the load drivers, to the
	NEAL R. GROSS
	COURT REPORTERS AND TRANSCRIBERS
	1323 RHODE ISLAND AVE., N.W. (202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com

output logic unit?

1

MR. POPPEL: The actual -- yes, it's a 2 chain, just like you just said. 3 So, for example, if 4 we go to the -- if you go to the load driver -- well, 5 the backup sheet. Okay. The load driver is a smart switch. Okay? It's receiving four fibers. 6 Okay? 7 And it's expecting to hear that two out of four fibers 8 said Okay? have trip. That's an active 9 communication, it's not a one or a zero. So, the load 10 drivers will say hey, two divisions aren't talking to 11 me, trip. It's failsafe. So, what you have to 12 postulate is this corruption is somehow letting the things go normally, and not tripping when they should 13 14 trip, as opposed to -- but if they just shut down, 15 you'll scram. MEMBER BROWN: So, they --16 17 POPPEL: Everything downstream is -MR. 18 upstream of the thing that stopped sending, everything downstream will --19 20 MEMBER BROWN: If the RPS load drivers are 21 not being told to constantly stay on, absence of 22 signal telling them to stay on, they will trip. 23 MR. POPPEL: Yes. 24 MEMBER BROWN: Okay. So, that's а 25 reasonable answer that says -- my concern was, even **NEAL R. GROSS** COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. (202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com

though you're trying to convince me that this whole other scenario is unlikely, that if the TLUs all locked up, which was the basis for my discussion earlier --

MR. BUTLER: The postulated scenario.

MEMBER BROWN: Postulated scenario, 6 the watchdog timer for the TLU would, based on this 7 8 comment would say channel trip. Okay? And send an 9 alarm, and it would try to reset. Now, you can't 10 reset a scram, but if the TLU is not functioning, what 11 does the watchdog timer tell to trip? Right now, I'm trying to figure out what the -- and it has to go --12 somehow it's communicating with the load drivers, I 13 14 guess.

15 MR. POPPEL: The load drivers trip and no 16 trip are both actively transported data. So, in other 17 words, you have to keep saying don't trip, and you 18 send also trip. It's not like a relay where the absence of electricity, both ones and zeroes 19 are actively transported so that no information can be 20 21 determined, and, therefore, set a trip by whatever the 22 downstream component is, wherever it's located in the 23 If the RMU loses power, then the DTM says chain. 24 every RMU signal is in trip. If the --

MEMBER BROWN: I don't want to work on the

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

25

1

2

3

4

5

	159
1	RMU right now.
2	MR. POPPEL: Okay.
3	MEMBER BROWN: I'm trying to understand
4	the watchdog timer can
5	MR. BUTLER: If it infinitely fails to
6	reset itself in the processing loop, what happens?
7	MEMBER BROWN: You've got a DTM, which is
8	processor, it's got a watchdog timer on it with its
9	program cycle. You've got a TLU with a watchdog
10	timer, it's processor, and it's got its operating
11	cycle. Obviously, they stack together for your
12	overall timing budget, whatever it is. Okay? They're
13	determinant, I'm going to take your word based on your
14	operating loops, the main all that kind of stuff.
15	Now, with the DTM, if it fails to process data, it
16	sends out a trip. That trip would go to the TLU, I
17	would presume. And, therefore, it's one out of the
18	four it doesn't get anything from the other
19	divisions, but the DTM can be reset, so it's trying to
20	reset. You haven't scrammed, but you've got a
21	momentary trip signal to a TLU in one division. Well,
22	excuse me, the other three divisions, as well, so I'm
23	one out of four in all three divisions. Now, the DTM
24	resets. That will go away. You don't maintain that
25	single trip in that one well, I presume it goes
	NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	160
1	away. Is that correct?
2	MEMBER STETKAR: Manually reset?
3	MEMBER BROWN: No, it's not manual. I
4	don't know, that's you have to reset everything to
5	recover from a scram where all the rods go up, or
6	down, or whichever way they go. So, that part I could
7	envision what was going on. Maybe I'm wrong.
8	MR. POPPEL: If any one of those chassis
9	restarts, it comes up as a trip, and the operator at
10	the chassis level even if you just turn the power
11	off, both powers off
12	MEMBER BROWN: I don't want to
13	MR. POPPEL: then turn it back on
14	MEMBER BROWN: That's too hard.
15	MR. POPPEL: So, it was a trip, but the
16	so, it comes up as a trip, and because it's like the
17	operator has to go to the chassis if it's happened at
18	the chassis
19	MEMBER BROWN: He's got to go to the
20	cabinet.
21	MR. POPPEL: Yes.
22	MEMBER BROWN: So, if a DTM exceeded its
23	program cycle, didn't strobe the watchdog timer in
24	time, the watchdog timer issues a trip. That's what
25	this says, it trips issues a channel trip.
	NEAL R. GROSS
	1323 RHODE ISLAND AVE., N.W.
	(202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com

	161
1	MR. POPPEL: Yes.
2	MEMBER BROWN: I'm working only on the DTM
3	right now. Now, if it resets and it comes back up,
4	that trip will stay there, and it will stay in all
5	four divisions.
6	MR. POPPEL: Until the operator does
7	something to
8	MEMBER BROWN: Resets each division, resets
9	that trip to that one to each TLU.
10	MR. POPPEL: I don't believe has to do it
11	in the other divisions. He has to do it in the
12	originating division.
13	CHAIRMAN CORRADINI: Charlie, are we do
14	you have enough that we can move on?
15	MEMBER BROWN: No. That's why, if I can
16	finish this. The DTM the TLU, if that watchdog
17	timer goes, what does it does it function the same
18	way? But what does it where does it issue a trip,
19	to whom?
20	MR. POPPEL: The OLUs.
21	MEMBER BROWN: To the OLUs from the TLUs.
22	MR. POPPEL: Yes.
23	MEMBER BROWN: Okay. Now, the OLUs only
24	get data only get information from its own
25	channel, according to your other diagrams.
	NEAL R. GROSS
	COURT REPORTERS AND TRANSCRIBERS
	1323 RHODE ISLAND AVE., N.W. (202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com

	162
1	MR. POPPEL: Okay. Maybe there's too many
2	diagrams, or maybe they're too simplified. This is an
3	accurate representation, and you can see that an OLU
4	gets data from
5	MEMBER BROWN: Okay. To pick up with my
6	well, I guess, what I'd like to see is an under I'd
7	like to understand the operation and execution of
8	watchdog timer timeouts, what they do, how they get
9	reset, whatever, if we could get that.
10	MR. BUTLER: Okay.
11	MEMBER BROWN: Is that okay, Mike?
12	CHAIRMAN CORRADINI: Sure. I want to move
13	on to the Staff before lunch.
14	MEMBER BROWN: That's fine.
15	CHAIRMAN CORRADINI: Thank you.
16	MR. BUTLER: Thank you.
17	CHAIRMAN CORRADINI: I want to hear the
18	Staff.
19	MEMBER BROWN: Now, we'll be done when the
20	Staff finishes. Right? Is that correct?
21	CHAIRMAN CORRADINI: Yes.
22	MEMBER BROWN: Okay.
23	(Off the record comment.)
24	CHAIRMAN CORRADINI: Go.
25	MR. GALVIN: It's still good morning.
	NEAL R. GROSS
	COURT REPORTERS AND TRANSCRIBERS
	1323 RHODE ISLAND AVE., N.W.
	202) 234-4433 WASHING I UN, D.C. 20005-3701 www.nealrgross.com

163 MEMBER STETKAR: Α accurate 1 more 2 description is just morning. It's not how good it is. 3 4 MR. GALVIN: Mike, we ready to go? Okay. 5 The Staff is here to present their review of Chapter 7, Instrumentation Controls, and we're going to talk 6 7 about the same topics. Ian, go ahead. 8 A little introduction MR. JUNG: Okay. 9 I appreciate the Committee for giving us the remark. 10 opportunity today. Staff hopes to fully support the My Staff's presentation is 11 needs of the Committee. intended to address the issues of the Committee's 12 interest expressed during earlier interactions, which 13 14 we'll focus on four plus one issues. 15 I'd like to take this opportunity for a 16 couple of minutes to provide the Committee an overview 17 of what Staff efforts was about for Chapter 7. Staff's Chapter 7 SER is a result of the following big 18 picture items, so the Committee understands what it 19 took for the Staff to reach at this point. 20 21 It's been almost five years since original Revision 0 has been submitted. I had the -- close to 22 10 Staff members worked on this project, some of them 23 on and off, some of them close to a full-time, for on 24 25 and off in some period, but 2006, 7, 8 it was almost **NEAL R. GROSS**

> COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W.

> > WASHINGTON, D.C. 20005-3701

(202) 234-4433

full-time for some people.

1

2 Looking back, we spent more than 15,000 3 hours for Chapter 7. It involved the multiple disk DCD revisions from Revision 0 to Revision 7, now we 4 5 are looking at Revision 8 to make sure it does not impact the SAP finding. Not only that, in between 6 7 certain revisions, Chapter 7 had the draft revisions 8 in between. Chapter 5, for example -- Revision 5, for 9 example, we have three revisions in draft to make sure the final Revision 6 coming in addressed the Staff 10 11 concerns.

We issued about 300 RAIs on this project, 12 not including many subsequent supplemental RAIs. 13 We 14 had a number of interactions with GEH through public 15 meetings, closed meetings, and conference calls, 16 significant engagement with other Chapter areas. You 17 realize that we cannot work in silo, we have to work with the Chapter 15 Accident Analysis, and the Chapter 18 3 EQ, Chapter 6 on ECCS systems, and Chapter 11, 10, 19 Chapter 6 in tech specs, Chapter 18, RTNSS and PRAs 20 21 insights. We all recognize this area is complex, 22 resource-intensive, and challenging technical 23 discipline from a digital perspective, but also from a traditional reactor review perspective. 24

25

Staff's goal is to reach the conclusion

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

that the design is safe from sensors to actuators for various safety and other important safety systems for the whole facility, and complies with the applicable regulatory requirements, and continues to promote standardization that Part 52 intended. At the licensing basis FSAR level of detail, we concluded

8 My Staff and I will try to address your 9 questions today to the best we can. If we don't, 10 we'll work with you and respond to you as fast as we 11 can.

that we have reached the goal.

With that, I'd like to turn it over to my two senior staff members, Hulbert Li on my far right, and Dinesh Taneja, my senior staff. Okay, Hulbert.

15 MR. LI: Good morning. My name is Hulbert 16 I'm one of the reviewers for ESBWR I&C design. Li. 17 The staff evaluated safety of the I&C design according 18 to the Commission's regulations by following the standard review plan. And we used the design control 19 document, DCD Tier 1 and Tier 2 information to make 20 21 our safety determination. And we document our review 22 in SER.

In Chapter 7.1, we addressed some critical issues for the overall safety of the I&C system, that including the conformance to the regulations, the

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

3

4

5

6

7

software development activities, the diversity and defense-in-depth, the set for methodology, and data communication, and secure development, and operational environments. And those are the critical issues we addressed and document in 7.1. Next page, please.

6 Next, 7.2 through 7.8, basically, we 7 follow standard review plan, and addressed every 8 concern, and list in the standard review plan. So, 9 the -- for the time concern, we elect next introduce 10 Dinesh to discuss the evaluation of the I&C design 11 principles. That's the meat of today's discussion.

MR. TANEJA: Thanks, Hulbert. Good morning. My name is Dinesh Taneja, and I'm going to be presenting our evaluation of some of the key technical areas that relate to the I&C system design in the ESBWR.

17 In general, Staff finds the ESBWR I&C 18 design to be safe. That was our determination. And we found that the I&C design employs the four safe 19 design principles that GE has discussed earlier this 20 21 morning; namely, the independence, determinism, 22 redundancy, and risk beyond defense-in-depth. And the 23 safety-related I&C systems are designed with the 24 concept of simplicity in many aspects. In the next few 25 slides, I'll go over the basis for our findings in

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

3

4

5

these technical areas.

1

2

3

4

The Staff also found ESBWR I&C design to be in conformance with all applicable regulations. Next slide, please.

5 One of the key technical areas of digital 6 I&C deals with the maintaining the data communication 7 familiar independence. And we are very with 8 independence, with the non-traditional, and the 9 traditional I&C systems. The challenge that we face 10 digital is maintaining in the I&C area the 11 independence and data communication area.

The Staff found that the I&C system design 12 provided sufficient independence and compliance with 13 14 the regulations, specifically, IEEE-603 and GDC-21. 15 The safety-related platforms are organized into four 16 physically separated electrically isolated and 17 divisions. And the communication independence is 18 achieved by multiple different ways. And simple 19 things that we saw that were useful for our decision making process was that the inter-divisional data 20 21 communication and safety-related system is limited, 22 and it's only limited to the voting logic, bypass and data authentication. And, also, the inter-divisional 23 data communication in the RTIF and NMS platform is 24 25 point-to-point, unidirectional, and wire optical

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

fibers.

1

2 And the point that we were discussing 3 earlier, the faulty or loss of data in communication 4 interpret it as a trip signal, and it carries all the 5 That's what we understood it to be. way through. It's a failsafe design. The inter-divisional data 6 7 communication in the SSLC and the ESF platform uses redundant ethernet network with two out of four voting 8 9 logic, networks are doubly buffered to prevent data 10 corruption to adversely impact both networks at the 11 same time. Next slide, please.

The ICP platforms, they do not use any 12 multiplexing or data communication. All the Ios are 13 14 hard wired, so there was really no concern there for 15 the issues of data communication. And, also, the data 16 communication from the safety to non-safety systems is 17 all unidirectional. So, any failure in a division 18 does not prevent the other redundant safety divisions 19 intended from performing their functions, such supporting that in a concept of taking a single 20 21 failure and continuing to perform its safety function. 22 Diverse and independent, diverse 23 protection system is provided as a defense-in-depth 24 feature to cope with the unlikely scenario of а 25 primary system malfunction. Example would be common

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

cause failures of software which are beyond design basis, or multiple independent failures. Next slide, please.

The determinism is the other issue with 4 5 the digital I&C areas, how deterministic, are we getting our things done? And we reviewed this thing 6 this 7 definition in with mind. Basically, our 8 understanding is, determinism means that a required 9 safety function is always accomplished within the 10 required time period specified by Chapter 15, DB 11 Analysis. That is how we viewed the determinism.

So, based on the following, the Staff 12 found that the real high performance of the safety-13 14 related I&C systems deterministic, and its conformance 15 with BTP-21 and IEEE-603. The two DCIS data The RTIF-16 communication protocols are deterministic. 17 NMS platform performed a cyclic realtime execution. 18 The operating system is clock-driven and not eventdriven, and it does not incorporate any interrupts. 19

Similarly, the SSLC/ESF platform also runs cyclical programs that include both the application and diagnostics, and do not incorporate interrupts. The ICP platforms always -- they do not have any operating system, so that was not the concern there. So, all platforms always react in the same way

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

3

according to the order of events occurring at the point and time of the plant conditions.

In the areas of redundancies, it's very well understood, I think we saw what GE presented this morning, we have four divisions of RTIF, you have four division SSLCs, we have four divisions ICP. They're physically separated, they're totally redundant, different areas. And even the DPS utilizes two out of four voting logic.

And the other thing that we also found in our review was that each division has its own set of sensors, and no sharing of sensors between safety division is allowed. Next slide, please.

14 The RTIF-NMS platforms use dual redundant 15 communication, inter-divisional data communication. 16 SSLC/ESF platforms use doubly buffered And the 17 redundant networks for two out of four voting logic. 18 Now, within each SSLC/ESF division, there are DMR controllers used for high reliability. And even the 19 non-safety NDCS platforms use double or triple 20 21 redundant controllers for hiqh reliability, and 22 availability. So, therefore, less challenges to the 23 safety systems. Next slide, please.

The diversity and defense-in-depth, this review really focused on the basic regulatory

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

3

4

5

6

7

8

9

requirement of ATWS. The ATWS system, essentially, is diverse from the primary system. The ICS is there, used for the SSLC, standby liquid control, SLC. There are too many acronyms here. The standby liquid -- the boron injection is done by the independent platform. Okay? And then the alternate rod injection is done by the DPS system.

8 The I&C systems also provide diverse 9 backup for RTIF-NMS, and SSLC/ESF to address software 10 common cause failure concerns. And this is in 11 accordance with the SRM to SECY 93-87.

The LTR on diversity and defense-in-depth 12 that was provided, that whole analysis was done 13 Staff 14 following the guidance of BTP-19, which 15 concurred with. And the diverse protection system is 16 designed based on different technology, different 17 equipment, design personnel, different signal sets, 18 and functional diversities. The diversity is also provided within O-DCIS. There are three different 19 platforms within Q-DCIS, and externally with non-20 21 safety-related DPS system.

The DSP system is classified as RTNSS, and is developed by a rigorous, highly structured process similar to the ones used for safety systems.

In the area of simplicity, I think the key

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

25

1

2

3

4

5

6

7

thing that we saw was the ESBWR design was very simple for us to review, because it did not really do a lot of mingling of data communication between this and that. Q-DCIS division is independently monitored and controlled. Each division from its dedicated redundant set of VDUs. We really didn't have the concern about any communication occurring from one to the other.

8 We found the safety-related components 9 cannot be controlled for any non-safety-related media 10 use. The data communication from safety to non-safety 11 I&C system was unidirectional, and the I&C system 12 design meets independent isolation and separation 13 requirement.

14 The inter and intra-divisional 15 communication is very limited. We talked about the 16 amount of data that gets transmitted there. And the 17 passive nature of the ESBWR plant has very limited 18 safety-related ESF functions, as compared to the 19 active plants. And the other thing is, the maintenance tool is not continuously connected. 20 You 21 have to open the cabinets, and go and hook up the 22 tools to do any work. They're not left there, so that 23 keeps a simple design very simple.

In the area of the logic diagram, I think this concern, we took back and we looked the DCD, and

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

3

4

5

6

7

www.nealrgross.com

1 we found that the DCD contains adequate control logic 2 design information for the Staff to make a reasonable 3 safety assurance finding. Information that's 4 described in the DCD will be used to develop the logic 5 diagrams, SO that becomes the design basis for developing the detailed logic diagrams. And the logic 6 7 diagrams are produced used during the I&C development 8 life cycle process. And we anticipate that they will 9 get finalized as the life cycle process progresses 10 through its various life cycle stages.

11 So, in conclusion, I quess Staff has 12 really concluded safety of the I&C system design and 13 finds the design to be safe. That's what our 14 evaluation has concluded. And the I&C systems are in 15 conformance applicable with the regulatory 16 requirements, and the I&C implementation DAC and ITAAC 17 that are provided in TRM are acceptable.

We have also looked at the, I guess not in depth, but we have looked at the Rev. 8 material, and so far what we see, it just provides clarity of the I&C design information, has no impact on the I&C design, itself, and has no impact on our safety findings.

24 MEMBER ADBEL-KHALIK: Were these slides 25 prepared prior to receipt of this new information from

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

the applicant? 1 2 MR. TANEJA: These slides were prepared --3 the new information that we received was just a couple 4 of days ago. 5 MEMBER ADBEL-KHALIK: Okay. MR. TANEJA: So, we had the chance to just 6 7 browse through it. And our initial review, basically, 8 when we went through the whole thing, it was the 9 information that we already knew. We found within the 10 DCD discussing various different areas, so we 11 concluded that information was better presented in a 12 more concise manner. The ITAACs that they've added, those ITAACs were implied in the DACs and ITAACs that 13 14 were already there. So, they, essentially, took the 15 ACRS comments, and they tried to enhance that, their 16 DCD material. 17 MEMBER ADBEL-KHALIK: I'm just trying to 18 get to the bottom of this third bullet in view of the changes that were proposed by the applicant. So, you 19 don't think - the changes provided by the applicant 20 21 do not add value. 22 MR. JUNG: Ι think we've engaged, 23 obviously, this is the ACRS letter and interactions, 24 and the previous transcripts have been communicated to 25 GEH, so we've been engaged the last several weeks with **NEAL R. GROSS** COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 GEH. But the bottom line is that the information they 2 have provided adds additional clarification; yet, is 3 helpful. It's helpful from the sense of those who are 4 now familiar with -- who are not involved in detailed 5 design review, they could interpret that more clearly. For example, inspectors in the future looking at the 6 7 ITAAC DAC, when they start inspecting against the DCD, 8 they'll be able to better see oh, this is what it was, 9 compared to Revision 7. It's clearly a plus, we felt this as a clarification, additional clarity. 10 However, 11 it did not pose a new safety question that we need to address in our overall safety finding. 12 MEMBER ADBEL-KHALIK: Thank you. 13 14 MEMBER BROWN: I guess I would -- I'm going 15 to springboard off of Said's comment. I mean, I went 16 back, and I did look at the Rev. 7 Tier 1 document, 17 which was more extensive than what was in Rev. 5, 18 which was what I had previously, or even in Rev. -- I won't speak to Rev. 6. I think it was more than in 19 20 Rev. 6, as well. And just a very quick look at the examples they gave from the design commitment through 21 22 the description, and into the acceptance criteria, and 23 I haven't looked at them all yet, which I will go do, since I have Rev. 8 markup stuff here for that. And I 24 25 presume it includes the Tier 1 information, as well,

> COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

NEAL R. GROSS

(202) 234-4433

www.nealrgross.com

on the CD. Provides a much more clear -- you say it was implicit in the other ones. You would have had to have been a monk looking at this stuff for 1,000 years to figure out that this stuff was implicit. Okay? I'm saying that with a little bit of tongue in cheek, but we have to be lighthearted at some times.

CHAIRMAN CORRADINI: I enjoyed your stork 8 dance before, too.

9 MEMBER BROWN: Oh, you did? Well, it's 10 like sucking blood out of rocks sometimes, Mike, to 11 get information, but the information provided here provides a much clearer view of how somebody intends 12 to do something, as opposed to saying a report will be 13 14 issued that complies with our SQAP, or our blah, blah, 15 blah, whatever other of the Alphabet soup that you 16 throw in there for -- it was all process. Everything 17 was going to be okay because of process, there was no 18 technical information identifying what the were technical design attributes that you were trying to 19 meet that are critical to what I call the four 20 21 fundamentals of making this stuff is sure 22 satisfactory. So, I would disagree with you, if you 23 said the stuff in Rev. 7 or Rev. 6 was acceptable. I would have answered that no. I haven't looked at all 24 25 this yet, but it, obviously, provides a lot more

> **NEAL R. GROSS** COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

3

4

5

6

technical meat, or at least the examples they pulled 1 2 out, the example had technical meat in them, and 3 provides a much better feeling that yes, there's 4 something cast in concrete which somebody has to meet, 5 which now gives somebody something to review against, and gives somebody like us, who are looking at it at a 6 7 certain level, some comfort that there's some real 8 technical design issues that people are going to --9 which address things you don't want to do in these 10 systems. 11 MR. TANEJA: Mr. Brown, I agree with you. 12 I agree with your assessment that it does --13 MEMBER BROWN: That's not what was on your 14 slide. 15 MR. TANEJA: -- present this information in a much clearer fashion. I think what's on my slide 16 17 is saying that -- see --18 MS. CUBBAGE: Well, maybe I could say, I think the slide is reflecting what you said. 19 It's that it does provide clarity. We welcome the change, 20 21 but it doesn't impact our safety finding. MEMBER BROWN: No, I don't disagree with 22 that. 23 24 MS. CUBBAGE: It didn't introduce any new -25 - okay. **NEAL R. GROSS** COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. (202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com

	178
1	MEMBER BROWN: I understand your comment on
2	that. It's just that the DAC, which is where a good
3	bit of our concern has been focused, whatever the
4	design is, there was nothing implicit that I could
5	find. I mean, I could drag my way through key word
6	after key word search and couldn't even find a mention
7	of any of these in any of the DAC. It's because they
8	weren't. It was all referencing process documents.
9	We're going to do it in accordance with our process
10	documents, and, therefore, it'll be okay. And that's
11	unsettling in some circumstances, in other words.
12	It's fine.
13	MR. TANEJA: Regarding
14	MEMBER BROWN: I'll stop.
15	MR. TANEJA: I just want to
16	CHAIRMAN CORRADINI: Before we start
17	commenting on each other, I want to make sure I get
18	the Committee to ask others that have questions.
19	John.
20	MEMBER STETKAR: I would have said
21	something, if I was going to.
22	CHAIRMAN CORRADINI: All right. I'm sorry,
23	Charlie. I didn't mean to did you have a there
24	was you guys are commenting on your comments, but I
25	want to make sure
	NEAL R. GROSS
	1323 RHODE ISLAND AVE., N.W.
	(202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com

	179
1	MEMBER BROWN: No, I just wanted to
2	springboard off of Said's comment. I thought that
3	that was a good lead-in, because this was prepared
4	before they got the Rev. 8 stuff.
5	MS. CUBBAGE: Actually, these slides were
6	prepared last night.
7	MEMBER BROWN: Oh, they were?
8	MS. CUBBAGE: Yes. The Staff has been
9	looking at the information in great detail that was
10	provided.
11	MEMBER BROWN: Okay. It said that based on
12	the Rev. 8 stuff, now we find the Tier 1 stuff
13	acceptable, instead of saying it's implicit. It was
14	all there before when
15	CHAIRMAN CORRADINI: Well, I think Amy's
16	MS. CUBBAGE: At the end of the day, Rev. 8
17	is what will be certified, and we are pleased with it.
18	MEMBER BROWN: Okay.
19	MR. GALVIN: We've had extensive
20	discussions with GE about how they're going to
21	implement the August 9^{th} letter. I mean, this is
22	we weren't surprised what came in Rev. 8. What came
23	in is what we expected to come in, because we've been
24	talking about it for the last month.
25	MEMBER BROWN: Okay. All right. Thank you.
	NEAL R. GROSS
	COURT REPORTERS AND TRANSCRIBERS
	(202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com
	180
----	---
1	MR. GALVIN: That's sort of what we meant
2	to say.
3	CHAIRMAN CORRADINI: So, other questions
4	for this group? Don't go anywhere, but any questions
5	for this group in front of us? I want to turn back.
6	Did you guys get some clarification that we can answer
7	Charlie's question, or are you still in the
8	clarification mode?
9	MR. BUTLER: If it's okay, this is Skip
10	Butler, if it's okay, we'll get back on Monday, if
11	that's acceptable.
12	CHAIRMAN CORRADINI: That's fine.
13	MEMBER BROWN: Monday, Tuesday, Wednesday?
14	I mean, I just as long as
15	CHAIRMAN CORRADINI: Okay. But I just want
16	to make sure
17	MEMBER BROWN: I just wanted a more
18	detailed discussion of what watchdog timers do, and
19	how do they execute the functions they're supposed to
20	be doing.
21	CHAIRMAN CORRADINI: And the timing part of
22	it, too. You had
23	MEMBER BROWN: And the timing part of the
24	execution of the watchdog timers, yes.
25	CHAIRMAN CORRADINI: Okay.
	NEAL R. GROSS
	(202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com

	181
1	MR. BUTLER: Right.
2	CHAIRMAN CORRADINI: Okay. Good. I don't
3	think there's any other more open items that we
4	haven't answered. We've gotten all that, so I will
5	just go through everybody today relative to Chapter 7.
6	Dr. Kress, you enjoyed it immensely, I could tell,
7	but I
8	DR. KRESS: I enjoyed it immensely. It's
9	not my area. I have no comments.
10	CHAIRMAN CORRADINI: Okay.
11	DR. WALLIS: Yes, I felt I learned a lot,
12	but, again, I defer to the experts like Charlie to ask
13	the real questions.
14	MEMBER STETKAR: I think that the
15	discussion was very, very useful. Thanks a lot to GEH
16	for the effort you put into the responditory part. I
17	remain personally concerned about a different level of
18	the review. In some sense, it has nothing to do with
19	the fact that this is digital, it could be analog, it
20	could be knife switches, for all I'm concerned. It's
21	more of the level of depth of the review of the
22	functional logic, and how that's integrated into the
23	rest of the plant control system. The example that I
24	mentioned before.
25	CHAIRMAN CORRADINI: I understand. You're
	NEAL R. GROSS
	COURT REPORTERS AND TRANSCRIBERS
	(202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com

182 1 welcome to help me try to capture that, but I think I 2 can capture that. 3 MEMBER STETKAR: Okay. 4 MEMBER ADBEL-KHALIK: Again, I'd like to 5 thank GE for really a very informative presentation. I have no additional comments. 6 Thank you. 7 MEMBER BROWN: Yes, I just wanted to say 8 the same thing. I thought they did a very good job of 9 -- much more thorough than we had seen before in any 10 circumstance. And it answered many, many, many, many 11 questions, and was much appreciated with the level of detail, and your tenacity with putting up with my 12 repeated request for clarifying slightly more. 13 So, 14 thank you. 15 MR. BUTLER: Well, this is Skip speaking. like to thank the Staff and the ACRS, and 16 We'd 17 particularly Charlie for being tenacious. 18 CHAIRMAN CORRADINI: Okay. Now, that we're 19 thanking everybody. So, let me --20 MEMBER BROWN: It sounds like а 21 Congressional committee. 22 CHAIRMAN CORRADINI: Let me just remind you 23 of the path forward. Yes, we're getting that way. 24 Wait until we get video on site, and then you can be 25 even more eloquacious. **NEAL R. GROSS** COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

All right. So, I want to thank GE and 1 Staff for doing this. We're kind of at the end. 2 This is our second to last Subcommittee meeting. 3 The last Subcommittee meeting will be on October 6th, where we 4 5 will be discussing aircraft impact, and the final and enjoyable parts of the PCCS relative to hydrogen 6 7 control. Okay? Which you all now have a CD, so you can't claim you don't have it. You also all have a CD 8 9 which is the Tier 1/Tier 2 -- it's in two parts. 10 There's actually two files that you have on that CD 11 that are both Tier 1 and Tier 2. And, unfortunately, Tier 2 is first, and enclosure 2 is Tier 1, but it's 12 there on your CD. So, that's going to be the last 13 14 Subcommittee meeting. 15 Let me remind everybody that for that Subcommittee meeting, all members and consultants, if 16

they want to look at the details of the Aircraft 17 18 Impact Assessment, that will be the day before open by 19 procedures that Kathy and Chris will tell you about, but the day before will be available here, which is 20 August 5th, as we all will be here anyway, because --21 MEMBER BROWN: October what? 22 CHAIRMAN CORRADINI: October 5th. What did 23 I say? I'm sorry, excuse me, October 5^{th} , as we will 24 25 all be here anyway for AP1000, and the joys of GSI-**NEAL R. GROSS**

> COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

183

184 1 191. Okay? So, I think that's the schedule going in, 2 and we're looking forward to trying to produce a --DR. WALLIS: Is this stuff available? 3 4 MEMBER STETKAR: It's available, but only -5 CHAIRMAN CORRADINI: Only that day --6 7 MEMBER STETKAR: You have to be physically 8 here. 9 CHAIRMAN CORRADINI: Physically here. You 10 can talk to Kathy and Chris, and they'll give you the details, the protocol. Thank you. 11 12 MEMBER BROWN: Okay. CHAIRMAN CORRADINI: Other than that, I'll 13 14 thank everybody again. I truly do think GEH, I think, 15 it was very informative. I think it took me only four 16 think I got it relative to years, but I the 17 differences in, shall we say, views on things, but I think it was very informative relative to the digital 18 I&C. 19 With that, I think we're adjourned. 20 21 (Whereupon, the proceedings went off the 22 record at 12:26 p.m.) 23 24 **NEAL R. GROSS** COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. (202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com

GEH Nuclear Energy

ESBWR Design Certification Chapter 7 I&C

Advisory Committee on Reactor Safeguards

Skip Butler Ira Poppel Romeo El Daccache





HITACHI



Topics

- Changes from Rev 6 to Rev 8
- ACRS Letter on DAC dated August 9th, 2010
- GEH Response to ACRS's Letter
 - Tier 2 Additional Design Descriptions
 - Tier 1 Additional ITAACs
- "4+1" Design Principles
 - Independence with Deep Dive into SSLC/ESF
 - Determinism with Deep Dive into SSLC/ESF
 - Redundancy
 - Diversity (D3)
 - Simplicity
- Logic Diagrams Implementation Design Artifacts
- Backup Slides



Changes from Rev 6 to Rev 8

	Source	Rev 7	Rev 8	Total	Comment .
	RAIs	7	1	8	Included in Rev. 7 and Rev. 8
)riven	Chapter 7	3	0	3	Setpoint Methodology (7.1-141), Digital Devices in LTRs (7.1-142), and GDCS eq. valves open at RPV Level 0.5 after sustained Level 1 (7.3-18)
C L	Other Chapters	4	1	5	RAI 6.2-202 S01
NR	Unresolved	0	1	1	
		ACR "Closure	S's letter t e of Design	o the NR Accepto	C dated 9 August 2010 on ance Criteria for New Reactors"
u	ECAs	10	6	16	
rive	I&C driven	0	0	0	
H D	I&C impacted	1	3	4	Added 4 th ICP function and 1 DPS function for ICS DPV Isolation
GEł	I&C not impacted	9	3	12	
	CARs	1	2	3	Self-Identification; 2 for Consistency, 1 for ACRS Letter

Added one ICP (the 4th)... ICS DPV Isolation Function (IDIF) No change to overall ESBWR I&C and DCIS architecture and design



ACRS's Letter to NRC dated 9 August 2010... Closure of Design Acceptance Criteria for New Reactors

"The fundamental reliability of DI&C systems is based on four essential objective design principles – **redundancy, independence, determinant data processing communications**, and **defense-indepth and diversity** – and one subjective attribute, **simplicity**. The logic and hierarchy of DI&C designs are well established, as are the individuals digital component technologies for implementing these functional system designs. Thus, the design of **DI&C systems can be functionally specified and shown to meet the essential criteria** regardless of the parts technology (digital and analog electronic components) used in developing the designs of the hardware assemblies and sub-assemblies."

ACRS's 4 Design Principles + 1 Attribute of Simplicity ("4+1") represent... Clear commitment to IEEE Std. 603... "Robust" Engineering philosophy



GEH Responds to ACRS's Letter



Based on IEEE Std 603

Criteria for Safety Systems for Nuclear Power Generating Stations



GEH's Additional Design Descriptions...

Align Existing Information plus Additional Features :

- For each of 4 ACRS Design Principles
 - Independence
 - Determinancy
 - Redundancy
 - Diversity
- Provide features by Q-DCIS Platform
 - RTIF-NMS
 - SSLC/ESF
 - ICP
- Simplicity (as consolidated discussion)
- DPS (as standalone discussion)

Addressed ACRS "4+1" Design Principles with No Design Changes... ESBWR DI&C is Modular, Robust and Compliant with IEEE Std. 603



GEH's Additional Design Description Specifics... Tier 2

7.1.2.1.1 Independence Design Principle 7.1.2.1.1.1 RTIF-NMS Independence Design Principle 7.1.2.1.1.2 SSLC/ESF Independence Design Principle 7.1.2.1.1.3 ICP Independence Design Principle	(~7 Pages added)
7.1.2.1.2 "Determinism" Design Principle 7.1.2.1.2.1 RTIF-NMS Determinism Design Principle 7.1.2.1.2.2 SSLC/ESF Determinism Design Principle 7.1.2.1.2.3 ICP Determinism Design Principle	(~6 Pages added)
7.1.2.1.3 Redundancy Design Principle 7.1.2.1.3.1 RTIF-NMS Redundancy Design Principle 7.1.2.1.3.2 SSCL/ESF Redundancy Design Principle 7.1.2.1.3.3 ICP Redundancy Design Principle	(~3 Pages added)
7.1.2.1.4 Defense in Depth and Diversity (D3) Design Principle 7.1.2.1.4.1 RTIF-NMS D3 Design Principle 7.1.2.1.4.2 SSLC/ESF D3 Design Principle 7.1.2.1.4.3 ICP D3 Design Principle	(~2 Pages added)
7.1.2.1.5 Simplicity Design Principle and Subjective Attribute	(~2 Pages added)
7.8.1 DPS System Description	(~3 Pages added)
~23 Pages Added – Combination of	

Repackaging Existing plus New Details of Features to support ITAACs HITACHI

GEH's Additional ITAACs...

3 Enhancements to Sec. and Tables 2.2.15 I&C Compliance with IEEE Std. 603 :

INDEPENDENCE (1):

• Item 11 (Modified) : Criteria 5.6, Independence and Criteria 6.3, Interactions Between Sense Command Features and Other Systems

Note (7): Data communications between the diverse Q-DCIS platforms is itself diverse. To provide adequate granularity and specificity to the ITAAC descriptions there are ITAACs that are not common across the software projects. ITAACs 11a4, 11a5, 11a6, 11b4, 11b5, and 11b6 are specific to the RTIF-NMS platform. ITAACs 11a7, 11a8, 11a9, 11b7, 11b8, and 11b9 are specific to the SSLC-ESF platform. ITAACs 11a10, 11a1, 11b10, and 11b11 are specific to the ICP platform.

DETERMINISM (2):

• Item 8 (New) : Criteria 4.10, The critical points in time or plant conditions... (e.g., overall plant process control timing budget)

Remark : New 12th Para. in Design Description, "... included as ITAAC even though it is not included in NUREG 0800, Section 14.3.5, and RG 1.206, Section C.II.1. ..."

• Item 17 (Modified) : Criteria 6.1 and 7.1, Automatic Control

(e.g., sense – command – execute incl. digital processing times) Note (6): Includes BTP HICB-21 on Design Commitments related to avoiding the use of design practices that lead to non-deterministic timing behaviors.

Focused ITAACs around :

- Top 2 of "4+1" Design Principles
 - Independence
 - Determinism
- Applied to 3 Q-DCIS Platforms
 - RTIF-NMS
 - SSLC/ESF



• ICP

Summary of Additional ITAACs...

Tier 1

ltem Code	Item Type Description Code ITAAC Purpose		Q-DCIS Platform Applicability	T2.2.15-1 Platform Multiplier	DAC ITAAC	Construct ITAAC
8a1	DAC	Determinism	All	7	7	
8b1	Construct	Determinism	All	7		7
11a4	DAC	Independence	RTIF-NMS - Intra I/O	2	2	
11a5	DAC	Independence	RTIF-NMS - Inter VLU	2	2	
11a6	DAC	Independence	RTIF-NMS - SR-to-NSR	2	2	
11a7	DAC	Independence	SSLC/ESF - Intra I/O	1	1	
11a8	DAC	Independence	SSLC/ESF - Intra VDU	1	1	
11a9	DAC	Independence	SSLC/ESF - Inter VLU	1	1	
11a10	DAC	Independence	SSLC/ESF - SR-to-NSR	1	1	
11a11	DAC	Independence	ICP - Intra I/O	4	4	
11a12	DAC	Independence	ICP - Inter VLU	4	4	
11b4	Construct	Independence	RTIF-NMS - Intra I/O	2		2
11b5	Construct	Independence	RTIF-NMS - Inter VLU	2		2
11b6	Construct	Independence	RTIF-NMS - SR-to-NSR	2		2
11b7	Construct	Independence	SSLC/ESF - Intra I/O	1		1
11b8	Construct	Independence	SSLC/ESF - Intra VDU	1		1
11b9	Construct	Independence	SSLC/ESF - Inter VLU	1		1
11b10	Construct	Independence	SSLC/ESF - SR-to-NSR	1		1
11b11	Construct	Independence	ICP - Intra I/O	4		4
11b12	Construct	Independence	ICP - Inter VLU	4		4
17a2	DAC	Determinism	All	7	7	
17a3	Construct	Determinism	All	7		7
Sub-Total					32	32
TOTAL					6	4

Target key areas of ACRS concern... Independence and Determinism



Independence ITAACs...SSLC/ESF Networks (1 of 4)Item 11 a/b 7 : IEEE Std. Criteria 5.6, Independence and 6.3, Interactions...

Table 2.2.15-2

ITAAC For IEEE Std. 603 Compliance Confirmation

Design Commitment	Inspections, Tes	its, Analyses Acceptance Crit		teria		
11a7. Criteria 5.6. Independence and 6.3. Interactions Between the Sense and Command Features and Other Systems: The SSLC/ESF software project's design base for intra- divisional input/output data communications have the following features:	Inspection of the softw design phase summary performed to verify that intra-divisional input/o communications have to features; e sensor inputs a measured with	are project's <u>BRR will be</u> t the design for utput data he following	The software project 'sdesi summary BRR show that the bases for intra-divisional in data communications have features:	gn phase ne design uput/output the following Tai For IEEE Std.	ble 2.2.15-2 603 Compliance Confirm:	tion
 sensor inputs at the RMUs are measured with triple redundancy; 	 sensor inputs a and from the P 	Design	a Commitment	Inspecti	ons, Tests, Analyses	Acceptance Criteria
 sensor inputs and outputs sent to and from the RMUs are on a dedicated triply redundant communication backplane bus to triply redundant controller application processors; data links for sensor inputs from the RMUs are sent via triply redundant optical fibers actuator outputs from the RMUs are determined using commands from the triply redundant controller application processors; and data links for actuator commands are sent via triply redundant optical fibers. 	and from the k dedicated triply communication triply redundar application prc data links for s the RMUs are redundant opti actuator output are determined from the triply controller appl and data links for a are sent via trip optical fibers. {{Design Acceptance }}	11b7. Criteria 5.6, 6.3, Interacti and Commai Systems: TI software proinput/output the following sensor input measured w sensor input from the RI triply redurn backplane I controller a data links fi RMUs are so optical fibe	Independence and ions Between the Sense nd Features and Other ne as-built SSLC/ESF ject's intra-divisional data communications have g features: ts at the RMUs are with triple redundancy; ts and outputs sent to and MUs are on a dedicated idant communication bus to triply redundant pplication processors; for sensor inputs from the sent via triply redundant rs	Inspection of th will verify that input/output da have the follow • sensor i and from dedicate commu triply re applicat • data lim the RM redunda • actuaton are dete	ne as-built software project the intra-divisional ta communications design ving features; nputs at the RMUs are ed with triple redundancy; inputs and outputs sent to m the RMUs are on a ed triply redundant nication backplane bus to edundant controller tion processors; ks for sensor inputs from Us are sent via triply ant optical fibers r outputs from the RMUs remined using commands	The intra-divisional input/output data communications have the following features: • sensor inputs at the RMUs are measured with triple redundancy: • sensor inputs and outputs sent to and from the RMUs are on a dedicated triply redundant communication backplane bus to triply redundant controller application processors: • data links for sensor inputs from the RMUs are sent via triply redundant optical fibers • actuator outputs from the RMUs from the triply redundant optical fibers
		actuator ou <u>determined</u> triply redur processors; data links fe sent via trip	tputs from the RMUs are using commands from the idant controller application and or actuator commands are oly redundant optical	from th controll and data lin are sent optical	e triply redundant ler application processors: ks for actuator commands via triply redundant fibers.	 <u>controller application processors:</u> and <u>data links for actuator commands</u> are sent via triply redundant optical fibers.

Intra- Divisional Input/Output Data Communications Features

fibers.



Independence ITAACs... SSLC/ESF Networks (2 of 4) Item 11 a/b 8 : IEEE Std. Criteria 5.6, Independence and 6.3, Interactions...

Table 2.2.15-2

ITAAC For IEEE Std. 603 Compliance Confirmation

Design Commitment	Inspections, T	Tests, Analyses Acceptance Cr		riteria		
11a8. Criteria 5.6, Independence and 6.3, Interactions Between the Sense and Command Features and Other Systems: The SSLC/ESF software project's design bases for intra- divisional VDU data communications have the following features:	Inspection of the soft design phase summar performed to verify the for intra-divisional V communications have features:	ware project's y BRR will be nat the design bases DU data the following	The software project's de summary BRR show that bases for intra-divisional communications have the features:	sign phase the design VDU data following Tab	le 2.2.15-2 503 Compliance Confirma	ition
the SSLC/ESF platform;	data inputs ai	Design	Commitment	Inspection	ns, Tests, Analyses	Acceptance Criteria
data inputs are only from RTIF-NMS platform;	<u>platform;</u> <u>data inputs/or</u>	<u>11b8. Criteria 5.6, In</u> 6.3. Interactio	ndependence and	Inspection of the will verify that f	as-built software project	The intra-divisional VDU data
 data inputs/outputs to and from the safety-related VDUs are via dual, 	<u>the safety-rel</u> <u>dual, redunda</u>	and Command Systems: The	d Features and Other as-built SSLC/ESF	data communica following featur	tions design have the es;	features:
redundant networks;	 data links hav communicati 	software proje VDU data con	ect's intra-divisional mmunications have the	data inpu from the		from the SSLC/ESF platform;
<u>communication interface modules;</u>	<u>modules;</u>	following feat	tures;	data inpu	its are from RTIF-NMS	 data inputs are from RTIF-NMS platform;
 data links use optical fibers: message authentication resides in the 	message auth	the SSLC/ES	SF platform;	• data inpu	<u>.</u> 	 data inputs/outputs to and from the safety-related VDUs are via
receiving division only; and	 the receiving message auth 	 data inputs a platform; 	re only from RTIF-NMS	<u>the safety</u> dual, red	y-related VDUs are via undant networks;	dual, redundant networks; data links have dedicated
 Inessage authentication includes transmitter and receiver identification, sequence number, hash functions, and 	transmitter an identification	 data inputs/o safety-related 	utputs to and from the d VDUs are via dual,	 data links commun 	<u>s have dedicated</u> ication interface	<u>communication interface</u> modules:
cyclic redundancy checks.	<u>hash functior</u> redundancy c	e data links ha	e tworks; ve dedicated	modules:	a use entied fileers	data links use optical fibers:
	{{Design Acceptant	<u>communicati</u>	ion interface modules;	 data Imk message 	authentication resides in	 message authentication resides in the receiving division only; and
		data links use message auth	e optical fibers; hentication resides in the	the receive message	ving division only; and authentication includes	message authentication includes transmitter and receiver
		receiving div	vision only; and	transmitt identifier	er and receiver	identification, sequence number,
		message auth transmitter as	nd receiver identification,	hash fun redundar	ctions, and cyclic	redundancy checks.

Intra- Divisional <u>VDU</u> Data Communications Features

sequence number, hash functions, and

cyclic redundancy checks.



Independence ITAACs...SSLC/ESF Networks (3 of 4)Item 11 a/b 9 : IEEE Std. Criteria 5.6, Independence and 6.3, Interactions...

Table 2.2.15-2

ITAAC For IEEE Std. 603 Compliance Confirmation

Design Commitment	Inspections, Te	Tests, Analyses Acceptance		iteria		
11a9. Criteria 5.6, Independence and 6.3, Interactions Between the Sense and Command Features and Other Systems: The SSLC/ESF software project's design bases for inter- divisional data communications within safety-related systems have the following features; edata links supporting two-out-of-four voting logic are via dual, redundant networks;	Inspection of the softy design phase summary performed to verify the for inter-divisional date within safety-related soft following features; data links supp four voting log redundant netw data links hav communication	vare project's y BRR will be at the design bases ta communications systems have the porting two-out-of- gic are via dual, vorks;	The software project's des summary BRR show that bases for inter-divisional of communications within sa systems have the followin <u>6 data links supportin</u> <u>four voting logic an</u> <u>redundant network</u> <u>6 data links have ded</u>	sign phase the design data ifety-related g features: ing two-out-of- e via dual, s: icated Tab	le 2.2.15-2	ntion
 data links have dedicated communication interface modules; 	data links use	Design	Commitment	Inspectio	ns, Tests, Analyses	Acceptance Criteria
 data links use optical fibers; message authentication resides in the receiving division only; and message authentication includes transmitter and receiver identification, sequence number, hash functions, and cyclic redundancy checks. 	message auth the receiving message auth transmitter an identification hash function redundancy cl {{Design Acceptanc } }	11b9. Criteria 5.6, 1 6.3, Interactive and Comman Systems: Th software proj communicati systems have data links su	Independence and ons Between the Sense id Features and Other e as-built SSLC/ESF eet's inter-divisional data ons within safety-related e the following features: upporting two-out-of-four	Inspection of th will verify that communication related systems features; data link four vot: redunda	e as-built software project the inter-divisional data s design within safety- have the following as supporting two-out-of- ing logic are via dual, nt networks;	The inter-divisional data communications within safety-related systems have the following features; data links supporting two-out-of-four voting logic are via dual, redundant networks; • data links have dedicated communication interface modules;
		voting logic networks: data links ha communicat data links us data links us message aut receiving di message aut transmitter a sequence nu cyclic redur	are via dual, redundant ave dedicated tion interface modules; se optical fibers; thentication resides in the vision only; and thentication includes and receiver identification, umber, hash functions, and idaney checks.	data link <u>commur</u> <u>modules</u> data link <u>message</u> <u>the received</u> <u>message</u> <u>transmit</u> <u>identific</u> <u>hash fum</u> <u>redundat</u>	ts have dedicated itication interface ts use optical fibers; authentication resides in ving division only; and authentication includes ter and receiver ation, sequence number, ictions, and cyclic ney checks.	 data links use optical fibers; message authentication resides in the receiving division only; and message authentication includes transmitter and receiver identification, sequence number, hash functions, and cyclic redundancy checks.

Inter- Divisional Voting Logic Data Communications Features



Independence ITAACs... SSLC/ESF Networks (4 of 4) Item 11 a/b 10 : IEEE Std. Criteria 5.6, Independence and 6.3, Interactions...

Table 2.2.15-2

ITAAC For IEEE Std. 603 Compliance Confirmation

Design Commitment	Inspections, Te	sts, Analyses	Analyses Acceptance Criv			
11a10. Criteria 5.6, Independence and 6.3, Interactions Between the Sense and Command Features and Other Systems: The SSLC/ESF software project's design bases for N-DCIS data communications between safety- related and nonsafety-related systems have the following features;	Inspection of the softw design phase summary performed to verify the for N-DCIS data comr between safety-related related systems have the features: <u>communications</u> to nonsafety-r	Vare project's BRR will be at the design bases nunications and nonsafety- he following	The software project's des summary BRR show that t bases for N-DCIS data con between safety-related and related systems have the for features:	ign phase he design nmunications l nonsafety- ollowing Tal For IEEE Std.	ole 2.2.15-2 603 Compliance Confirm:	tion
to nonsafety-related components;	• data links are	Design	Commitment	Inspectio	ons, Tests, Analyses	Acceptance Criteria
 data links are via a separate, dedicated, dual, redundant networks; data links have dedicated communication interface modules data links use optical fibers; SSLC/ESF message authentication (for absolute time) resides in the receiving division only; and message authentication includes transmitter and receiver identification, sequence number, hash functions, and cyclic redundancy checks. 	 data links due dedicated, dua networks; data links have communicatio data links use SSLC/ESF me authentication resides in the poly only; and message authe transmitter an identification, hash functions redundancy el 	11b10. Criteria 5.6 6.3, Interacti and Comman Systems: The software pro- communicati related and n have the folle data commutor to nonsafety data links and dedicated, of edata links and	, Independence and ons Between the Sense ad Features and Other te as-built SSLC/ESF ject's N-DCIS data ions between safety- ionsafety-related systems owing features; inications are one way out y-related components; re via a separate, lual, redundant networks; ave dedicated tion interview of the second	Inspection of th will verify that communication related and non have the follow • data cor out to no compon • data linl dedicate network • data linl communication	e as-built software project the N-DCIS data s design between safety- safety-related systems ing features: nmunications are one way onsafety-related ents: cs are via a separate, ed, dual, redundant (S) cs have dedicated nication interface modules	The N-DCIS data communications design between safety-related and nonsafety- related systems have the following features: • data communications are one way out to nonsafety-related components: • data links are via a separate, dedicated, dual, redundant networks; • data links have dedicated communication interface modules
	<u>{{Design Acceptane</u>	data links u data links u SSLC/ESF (for absolut receiving di message au transmitter : sequence m evalia eacher	se optical fibers: message authentication e time) resides in the ivision only; and thentication includes and receiver identification, umber, hash functions, and videncer absolve	SSLC/E authenti resides i only: an message transmit identific hash fu	State optical noers, SF message cation (for absolute time) in the receiving division d authentication includes ter and receiver action, sequence number, actions, and cyclic	<u>SSLC/ESF message</u> <u>authentication (for absolute time)</u> resides in the receiving division only: and <u>message authentication includes</u> <u>transmitter and receiver</u> <u>identification, sequence number,</u> <u>hash functions, and cyclic</u> redundancy checks.

<u>Safety -to- NonSafety</u> N-DCIS Data Communications Features

redundancy checks

cyclic redundancy checks.



Determinism ITAACs... Item 8 a/b 1 : IEEE Std. 603 Criteria 4.10

All Platforms (1 of 2)

Table 2.2.15-2

ITAAC For IEEE Std. 603 Compliance Confirmation

Design Commitment	Inspections, Tests, Analyses	Acceptance Criteria
 <u>8a1.</u> Criterion 4.10, The critical points in time or the plant conditions, after the onset of a design basis event: The software project's design bases ensures that; <u>a plant process control timing budget (end-to-end sense, command, and execute loop including the associated DCIS components' response times) exists; and</u> <u>the plant process control timing budget completes its protective action in less than the specified maximum time allowable.</u> 	Inspection of the software project's design phase summary BRR will be performed to verify that: a plant process control timing budget (end-to-end sense, command, and execute loop including the associated DCIS components' response times) exists; and the plant process control timing budget completes its protective action in less than the specified maximum time allowable. {{Design Acceptance Criteria}} 	The software project's design phase summary BRR identifies that; • a plant process control timing budget (end-to-end sense, command, and execute loop including the associated DCIS components' response times) exists; and • the plant process control timing budget completes its protective action in less than the specified maximum time allowable. {{Design Acceptance Criteria}}
 <u>8b1.</u> Criterion 4.10, The critical points in time or the plant conditions, after the onset of a design basis event: The asbuilt software project ensures that; <u>built software project ensures that</u>; <u>the plant process control timing</u> <u>budget completes its protective action</u> <u>in less than the specified maximum</u> <u>time allowable.</u> 	Tests will be performed to show that the as-built software project complies with: • the plant process control timing budget completes its protective action in less than the specified maximum time allowable.	 <u>the plant process control timing</u> <u>budget completes its protective</u> <u>action in less than the specified</u> <u>maximum time allowable.</u>

Plant Process Control Timing Budget EXISTs Protective Action Complete in Less that Max. Allowable Time



All Platforms (2 of 2)

Determinism ITAACs... Item 17 a/b 2 : BTP HICB-21 Perspective

Table 2.2.15-2

ITAAC For IEEE Std. 603 Compliance Confirmation

Design Commitment	Inspections, Tests, Analyses	Acceptance Criteria
 <u>17a2. Criteria 6.1 and 7.1, Automatic</u> <u>Control: The software project's design</u> <u>bases show that in normal operation of</u> <u>the end-to-end sense, command, and</u> <u>execute plant process control loops</u> <u>(including the associated DCIS</u> <u>components involved with determinant</u> <u>data processing and communications)</u> <u>the following features are not used;</u> <u>non-deterministic data</u> <u>communications;</u> <u>non-deterministic computation;</u> <u>interrupts;</u> <u>multi-tasking;</u> <u>dynamic scheduling; and</u> <u>event-driven actions.</u> 	Inspection of the software project's design phase summary BRR will be performed to verify that the design bases show that in normal operation of the end- to-end sense, command, and execute plant process control loops (including the associated DCIS components involved with determinant data processing and communications) the following features are not used;	The software project's design phase summary BRR shows that the design bases show that in normal operation of the end-to-end sense, command, and execute plant process control loops (including the associated DCIS components involved with determinant data processing and communications) the following features are not used; • non-deterministic data communications; • non-deterministic computation; • interrupts; • multi-tasking; • dynamic scheduling; and • event-driven actions. {{Design Acceptance Criteria}}
 17b2. Criteria 6.1 and 7.1, Automatic Control: The as-built software project's normal operation end-to-end sense, command, and execute plant process control loops (including the associated DCIS components involved with determinant data processing and communications) do not use the following features; non-deterministic data communications; non-deterministic computation; interrupts; multi-tasking; dynamic scheduling; and event-driven actions. 	Inspection of the as-built software project will verify that in normal plant process control loops (including the associated DCIS components involved with determinant data processing and communications) the following features are not used: non-deterministic data communications; non-deterministic computation; interrupts; multi-tasking; dynamic scheduling; and event-driven actions. 	The as-built software project, in normal plant process control loops (including the associated DCIS components involved with determinant data processing and communications), does not use the following features; non-deterministic data communications; non-deterministic computation; interrupts; multi-tasking; dynamic scheduling; and event-driven actions.



Avoid using Non-Deterministic Design Practices ESBWR Does Not Uses these Features

DCD Rev. 8 In-Prog. ITAAC Count...

<u>Tier 1</u>	<u>I&C</u>	<u>Other</u>	<u>Total</u>	<u>% Tot</u>
DAC-ITAAC :	378	24	402	94%
Construct-ITAAC :	428	701	1129	38%
TOTAL ITAAC :	806	725	1531	53%

Counting Methodology :

- Straight Count
- Matrix Count
 - IEEE Std. 603 Criterion System Applicability Matrix
 - Every criterion (DAC-ITAAC or Construct-ITAAC) in Table 2.2.15-2 was multiplied by the numbers of 'R' in the corresponding criterion Row of Table 2.2.15-1.
 - Environmental Qualification (Table 3.8-1)
 - Every item (DAC or C-ITAAC) in Table 3.8-2 was applied to the corresponding qualification program (e.g. Harsh Mechanical (MH), Harsh Electrical (EH)).

NOTE:

• DCD Rev. 6 DAC,- Construct-, and Total ITAAC count presented at ACRS Meeting on 22 October 2009 was higher (688, 1387, 2075) mainly driven by a reduction in Chapter 7 I&C from (663, 801, 1464) due to correcting an error in the counting methodology applicability rules applied to Table 2.2.15-1 when matrix'ed with Table 2.2.15-2.

Adequate coverage of Digital I&C Design and Process Commitments



ESBWR DCIS Overview...

Simplified Block Diagram



DCD Rev. 8 – Figure 7.1-1

ESBWR Instrumentation and Control DCIS Simplified Network and Functional Block Diagram



"4+1" Design Principles...

Independence



Based on IEEE Std 603

Criteria for Safety Systems for Nuclear Power Generating Stations



ESBWR DCIS Overall Architecture



Derived from DCD Rev. 6 Figure 7.1-1 ESBWR Instrumentation and Control DCIS Simplified Network and Functional Block Diagram

Platform, Divisional, Network, and Channel INDEPENDENCE HITACHI

HITACHI

SSLC/ESF Inter-Divisional Networks

100 Mbits/Sec Ethernet



- 2 Networks are DUAL
- Each Network is REDUNDANT
- Each Network is DEDICATED
- Messages are "AUTHENTICATED"

Independence... SSLC/ESF Network 1 SSLC/ESF "two-out-of-four" Trip Voting Logic Ethernet Network 1 (Inter-Divisional Data Communication)



SSLC/ESF Network 1 is INDEPENDENT... Dedicated, Redundant, and Message **HITACHI** Authentication.... Messages travel in either direction

Independence... SSLC/ESF "two-out-of-four" Trip Voting Logic Ethernet Network 2 (Inter-Divisional Data Communication)



SSLC/ESF Network 2 is INDEPENDENT... Dedicated, Redundant, and Message **HITACHI** Authentication.... Messages travel in either direction

SSLC/ESF DIV x Main Chassis (Inter-Divisional Data Communication)



Main Chassis Backplane Bus supports INDEPENDENCE... Dedicated, Shared Memory, HITACHI Triply Redundant Channels, and Message Authentication

SSLC/ESF Divisional Truth Table for Trip and Bypass Status



Achieving Data Independence... Managing Divisional Trip, Bypass, and HITACHI Message Authentication Status

Independence... SSLC/ESF "2 out of 4" Trip Voting Logic





Achieving Data Independence and highly Reliable Initiate/Operate Decision

SSLC/ESF Data Communication (A) to N-DCIS



SSLC/ESF Network 3 is INDEPENDENT and SEPARATE from Divisional Trip Voting Logic Network

SSLC/ESF Data Communication (B) to N-DCIS



SSLC/ESF Network 4 is INDEPENDENT and SEPARATE from Divisional Trip Voting Logic Network

SSLC/ESF DIV x Main Chassis (Data Communication to N-DCIS)



X indicates that the communication card is set "read only"

Main Chassis Backplane Bus supports INDEPENDENCE... Dedicated, Shared HITACHI Memory, Triply Redundant Channels

"4+1" Design Principles...

Determinism



Based on IEEE Std 603

Criteria for Safety Systems for Nuclear Power Generating Stations



Determinism...

Timing Budgets

7.1.2.1.2 Determinant Data Processing and Communication (Determinism) Design Principle

Reliability, redundancy and independence in ESBWR DCIS can be achieved separately from timing considerations but **there must be timing criteria that ensure that the DCIS operates fast enough to satisfy the automatic and manual operability goals**. Transients, design basis and beyond design basis events are analyzed in Chapter 15 of the DCD and assume time criteria that the DCIS must meet to make the analyses accurate. The ESBWR DCIS **design bases will use these requirements to determine the speed required of the Q-DCIS (and N-DCIS) controller application programs and required data communication management programs.** Per BTP HICB-21, Q-DCIS computer **timing will be shown to be consistent with the limiting response times** and the characteristics of the computer hardware, software, and data communications systems and ESBWR DCIS design basis documents will describe system timing goals.

Establish timing budget for each plant process to be controlled and Function must always perform in less than allowable time... DETERMINISTIC



Determinism...

Processors and Logic Gates

What <u>IS</u> Done...

RTIF-NMS and SSLC/ESF processors, in normal operation, designed using:

- Cyclic real-time executive or operating system with system clock
- Program loop is internally monitored by watch dog timers
- Application processors are buffered from any data communications
- Includes monitoring and diagnostic programs
- Application code implemented differently by Platform:
 - **RTIF-NMS** code is "burnt in" and unchangeable after implementation
 - SSLC/ESF code is "blockware" via secure configurator toolkit

ICP is designed using Custom Programmable Logic Devices (CPLDs) that:

- Implement gate logic only for control functions
- Do not use cyclic real-time executive, clock, or run application code for control
- Logic is "burnt in" and unchangeable after implementation

What is <u>NOT</u> Done...

Per BTP HICB-21 Guidance on Digital Computer Real-Time Performance

ESBWR Q-DCIS and DPS (specific N-DCIS hardware/software controllers) platforms do not use, in normal operation, the following:

- non-deterministic data communications
- non-deterministic computation
- interrupts
- multi-tasking
- dynamic scheduling
- event-driven methods



Processors and Hard Logic Gates are Functionally DETERMINISTIC HITACHI
Determinism...

Controller Processors





Determinism... RTIF Inter-Div. Data Link Example



ESBWR Instrumentation and Control DCIS Simplified Network and Functional Block Diagram



Determinism...

RTIF Inter-Div.Voting Data Link



Inter-Div. Pt-to-Pt and Intra-Div. "scramnet" cycle times are... <u>10's micro</u>-sec. RPS scram response time is... <u>10's milli</u>-sec. Communications are DETERMINISTIC within plant process time budget

Determinism... SSLC/ESF Inter-Div. Network Example



_SSLC/ESF "2-out-of-4" Votng Inter-Divisional DEDICATED Ethernet (100 Mbits/Sec) Network

Figure 7.1-1

ESBWR Instrumentation and Control DCIS Simplified Network and Functional Block Diagram

🛞 HITACHI

Determinism...

SSLC/ESF Inter-Divisional Networks

100 Mbits/Sec Ethernet



- 2 Networks are DUAL
- Each Network is REDUNDANT
- Each Network is DEDICATED
- Messages are "AUTHENTICATED"



Determinism... SSLC/ESF "2-out-of-4"Network Loading Example - Assumptions

	rates and capacities
assumption	
each interdivisional transmittal message on each 2 out of 4 network is:	
One bit per Trip status per parameter	
One bit for Divisional sensors bypass status	
Message authentication	= 1024 bytes (1024 x 8 = 8192 bits)
assumption	
each division sends message at 10 X per second (conservative for expected 2 to 4 X per second)	= 1024 X 8 X 10 = 81920 bits/sec
each message is acknowledged (assumed same size)	= 81920 X 2 = 163840 bits/sec
there are four divisions (nodes or communication cards) on the network	= 163840 X 4 = 655360 bits/sec on network
network capacity = 100 Mbits/sec	= 655360/10000000 = 0.0066 = .6%
therefore network loading	(avg no data on network 99.4% of the time)
time "size" of single message on 100 Mbits/sec network	= 1024 X 8 = 8192 bits =
	= 8192 bits / 10000000 bits/sec
	= 81.92 microseconds
assumption	
max distance between divisions for 2 out of 4 communication path	= 30 m
fiber index of refraction	= 1.48
speed of light in fiber	= 300 million m/sec / 1.48
	~ 200 million m/sec
time for message to travel 30 meters	= 30 m / 20000000 m/sec
-	= 0.15 microseconds
	0.15 << 81.92 (travel time negligible)

Supporting Assumptions and Math are Industry Practice HITACHI



Determinism... SSLC/ESF "2-out-of-4" Network Loading Ethernet Collision Protocol

nodes monitor the network for ongoing messages

most of the time (99.4% in this example) the network is free and the nodes transmit without delay

if a second node wants the network while data is being transmitted it simply waits for its turn to send – the delay time is the first node's transmission time (81.92 microseconds in this example)

if two nodes try to access the network simultaneously (usually occurs when two nodes are waiting for another node's transmission to clear) they will notice the resulting collision, both nodes will it back off and wait up to two time slots (5.12 microseconds for a 100 Mbits/sec network) before retrying. If the retry fails, the maximum wait time is doubled, and the node waits a random period again. The algorithm continues until the network is acquired – typically 10 attempts (1024 slot delays) and declares an error after 16 attempts. The resulting randomness causes the "deterministic" concern but the probability of not getting a message through or waiting the maximum number of attempts becomes very small as the network speed increases and the message size and number of nodes decrease. For ESBWR the "criteria" for the two-out-of-four messages is (in this example) 10 X second (100 milliseconds) and a one millisecond (i.e. 1000 microseconds) delay is (for this example) is considered acceptable. A probabilistic analysis indicates that the chance of getting a message through in one millisecond on a bus loaded per our example in 100 years of operation is greater than 0.9999999







SSLC/ESF Dedicated and Lightly Loaded Ethernet is DETERMINISTIC

Determinism... Functionally Possible with Ethernet

Developed by Real-Time Innovations, Inc (www.rti.com)

Real-time applications fail when data isn't available on time. This spreadsheet lets you determine the probability you'll never get a program failure (that is, a delay longer than the required deadline) using Ethernet for real-time data delivery of high frequency, periodic data. To calculate the probability for your target environment, enter the network bandwidth, the size of the packets, the rate at which packets are sent (packets per second), and the application life cycle (in years). The results are shown under Network Loading (which tells you how much of the available bandwidth that particular combination is using) and Probability of Success. The tables and graphs that follow illustrate the impact on probability by varying just the message rate and the deadline.

Network	Packet					
Bandwidth	Size	Msg	Deadline	Time	Network	Probability
(Mbits/Sec)	(bytes)	Rate	(max ms)	(Years)	Loading	of Success
100	1024	0	1	100	0%	1
100	1024	5	1	100	0%	1
100	1024	10	1	100	0%	1
100	1024	15	1	100	0%	0.99999998
100	1024	20	1	100	0%	0.99999993
100	1024	25	1	100	0%	0.99999982
100	1024	30	1	100	0%	0.99999963
100	1024	35	1	100	0%	0.99999932
100	1024	40	1	100	0%	0.99999884
100	1024	45	1	100	0%	0.99999814
100	1024	50	1	100	0%	0.99999716
100	1024	55	1	100	0%	0.99999585

Network	Packet					
Bandwidth	Size	Msg	Deadline	Time	Network	Probability
(Mbits/Sec)	(bytes)	Rate	(max ms)	(Years)	Loading	of Success
100	1024	10	0.1	100	0%	0.38190672
100	1024	10	0.2	100	0%	0.99874252
100	1024	10	0.3	100	0%	0.99996187
100	1024	10	0.4	100	0%	0.99996187
100	1024	10	0.5	100	0%	0.99999941
100	1024	10	0.6	100	0%	0.99999941
100	1024	10	0.7	100	0%	0.99999941
100	1024	10	0.8	100	0%	1
100	1024	10	0.9	100	0%	1
100	1024	10	1	100	0%	1
100	1024	10	1.1	100	0%	1
100	1024	10	1.2	100	0%	1





Network Loading (%)



Deadline (max milli-Sec)

Properly designed and loaded – Probability of message delivery is ~100% Ethernet is Functionally DETERMINISTIC



"4+1" Design Principles...

Redundancy



Based on IEEE Std 603

Criteria for Safety Systems for Nuclear Power Generating Stations



Redundancy...

Highlights

All Safety DCIS (as required by IEEE Std 603) is REDUNDANT for:

• Sensors, Controllers and Actuators

SSLC/ESF DCIS:

• Controllers and Actuator outputs are triply redundant (TMR) within Division to avoid inadvertent actuation

All Safety DCIS design is Single Failure Proof for:

- Safety transient analysis events including inadvertent actuation
- Non Safety normal operations
- DCIS is not a credible transient "initiator"

All DCIS is REDUNDANTLY powered (primary and cabinet)

• Safety DCIS is REDUNDANT with its Division

Non Safety DCIS may use REDUNDANT:

• Sensors, Controllers and Actuators

As required for plant availability including single failure proofing

All DCIS Networks (except Point-to-Point) are REDUNDANT



ESBWR DCIS meets or exceeds requirements for REDUNDANCY HITACHI

Redundancy...

SSLC/ESF Ethernet Networks



Configuration of 2 Networks is N-2... 3 Failures to Cease Functioning HITACHI

"4+1" Design Principles...

Diversity



Based on IEEE Std 603

Criteria for Safety Systems for Nuclear Power Generating Stations



Diversity...

DCIS Platform Design

Safety Category Platform/Network Segment		Safety-Related	1	Nonsafety-Related								
		Q-DCIS		N-DCIS								
Platform/Network Segment	RTIF NMS	SSLC/ESF	Independent Control Platform	GE	NE	PIP A/B	BC	P	PC	CF		
Architecture	Divisional	Divisional	Divisional	Triple Redundant (DPS)	Dual Redundant	Dual Redundant	Triple Redundant	Dual Redundant	Workstations	PLC (Deluge)		



NOTE: Crosshatching denotes different platforms or networks.

DCD Rev 6 Figure 7.1-4 and D3 LTR Figure 1.1 ESBWR Hardware/Software (Architecture) Diversity Diagram

Essentially Unchanged Throughout ~5 Year Design Certification Process ESBWR inheritance from ABWR (Lungmen Project)



Diversity...

4 Major DCIS Platforms



Derived from DCD Rev. 6 Figure 7.1-1 ESBWR Instrumentation and Control DCIS Simplified Network and Functional Block Diagram

3 Safety-Related and 1 DPS (RTNSS) in 4 DIVERSE Platforms HITACHI

"4+1" Design Principles...

Simplicity



Based on IEEE Std 603

Criteria for Safety Systems for Nuclear Power Generating Stations



Simplicity...

ESBWR's DCIS Approach

- DCIS functions are modularized and segmented to simplify requirements management, specification, design and testing
- Few plant process control functions per controller application to simplify requirements management, specification, design and testing
- No closed loop control over a shared network
- Design Certification cyber security is "designed in" to most systems and components rather than added on
- Remote Shutdown System (RSS) is designed as an auxiliary control room
- Use of optical fiber and remote multiplexing maximized to simplify fire protection analysis and design of cable trays, conduit, and raceways

Given nuclear regulations and cyber security requirements... ESBWR's DCIS architecture and design is as "SIMPLE" as possible HITACHI



Simplicity... ESBWR Does NOT Use Prioritization Module



ISG-04 acknowledges possible use of "Prioritization Module" but... Introduces COMPLEXITY and IEEE Std 603 Compliance challenges and... May require challenging combinatorial tests to demonstrate conformance HITACHI

Implementation Design Artifacts...

Logic Diagrams



Based on IEEE Std 603

Criteria for Safety Systems for Nuclear Power Generating Stations



Implementation Design Artifacts... Logic Diagrams

- Logic Diagrams NOT required to be submitted by regulation for **Design Certification**
- GEH provided "typical" Logic Diagrams based on DCD Rev. 5
 - Purpose was to substantiate high level design approaches
- Logic Diagrams are part of the Detailed Design Process... governed by Software Development Life Cycle (SDLC) per 3 Tier 2* LTRs (i.e., SMPM, SQAPM, CySPP)
 - Created as Functional Logic Block Diagrams (FLBDs) during **Planning Phase**
 - Iterates under configuration management into Detailed Logic Diagrams (DLDs) as overall plant design matures
 - Iterations controlled via plant system (MPL) Design Reviews and **Controls specific Baseline Review Records (BRRs)**
 - Configuration management thru 6 Phases... Planning, Rqmts, Design, Implementation, Test, and Installation
 - BRRs are foundation for ITAAC Closure Reports

Logic Diagrams do and will exist... Key deliverables of Detailed Design



Logic Diagrams... RPS Monitored Parameters Example



Typical or "simplified" Logic Diagrams provided for DCD Rev. 5



Logic Diagrams in ITAACs... Sec. 3.2 Software Development, Table 3.2-1 2 a/b 1

RTIF Example

2al.	The pla detaile	nning phase a d in the RTIF	activities software pla	ns a	The plann and analy	ning phase out zed for the R	tputs are inspec TIF software	ted]	Planning l conclude t	hase Summ hat the RTH	ary BRR(s) ex software proj	tist and jects						
	2b1.	The requirem detailed in th	ents phase a e RTIF softw	ctivitie vare pl	es Th lans in	he requiremen spected and a	nts phase output nalyzed for the	ts are RTIF	Re	quirements ist and concl	Phase Summa ude that the R	ry BRR(s) TIF softw) /are					
		2c2. The in the	design phase e NMS softw	activi are pl	ties detail ans and C	led The des CySP analyze	sign phase outp ed for the NMS	uts are softwa	inspected re project	and Design conclu	Phase Summ de that the NM	ary BRR(IS softwa	(s) exist a ire projec	nd ts				
		2d)	l. The impl detailed i	lement in the l	tation pha RTIF soft	ase activities tware plans	The implement inspected and	ntation analyz	phase out ed for the	outs are RTIF	Implementa exist and co	tion Phase nelude the	e Summa at the RT	ry BRR(s) IF software				
			2e1. 1	The te: the RT	st phase a TF softwa	activities detai are plans and (iled in The t CySP analy	est phas zed for	se outputs the RTIF	are inspecte software pro	d and Tes ojects. con	t Phase St clude that	ummary l : the RTII	BRR(s) exist : F software pro	and ojects			
		L		3al.	The inst detailed and CyS RTIF so	tallation phase in the RTIF s SP are comple oftware projec	e activities software plans sted for the ts.	The : softv RTII and a	installatio vare proje ? Cyber S analyzed .	n phase outp ets, includin ecurity FAT,	uts for the RT g RTIF FAT a , are inspected	IF Instal and and e project perfort softw SMPI	llation Ph onclude (cts install rmed in c vare plans M, SQAF	that the RTIF lation phase a compliance with and CySP as PM, and CySP	• BRR(s) exis software ctivities were ith the RTIF derived from PP.	£		
		3a2.				 The RTIF software projects performs as designed. 			FAT is performed on the RTIF software projects.			RTIF : that th compl derive CySPI	RTIF FAT report(s) exist and concludes that the RTIF software projects is in compliance with the RTIF software plans as derived from the SMPM, SQAPM, and CySPP.			as		
				3a3.	The RTIF software projects is cyber secure.			r A cyber see for the RTI		ty FAT will oftware proj	be performed ects.	RTIF cyber se and conclude	' cyber se onelude (cts is in c	curity FAT re that the RTIF compliance wi	port(s) exist software ith the RTIF			
				3j1. 7 a	The RTIF software projects pe as designed.			performs A RTIF software proje performed.		ojects SAT is R an pu C Si		RTIF c and com project CySP a SQAPI	F cyber security SAT report(s) ex conclude that tIne RTIF softwar ects is in compliance with the RT P as derived from the SMPM, APM, and CySPP.) exist vare RTIF			
						3j2. 1	The RTIF soft secure.	tware projects i	s cyber	A RTI SAT is	software pr performed.	ojects cyber s	ecurity	RTIF e	yber security nelude that th	SAT report(s e-RTIF softwa) exist are	
						3i. The co instru with s of ope	omplete ESBW mentation and o ensors and actu grating as design	R control : ators is ned.	systems capable	An overlap, performed network seg	ping and encor on the as-built gments.	mpassing platforms	SAT is s and	The Installat the complete control syste that t <u>T</u> he con instrumentat sensors and a	tion Phase Sur ESBWR ins SAT existem Margan SAT existem Margan SAT exist Margan SAT Saturation Margan Margan Mar	mmary BI trumentati and cone R ol system upable of	ie le	
gio	Di	agra	ms Co	on	figu	ratio	n Man	ag	ed 1	์ Throu	ighou	I t		operating as with the soft as derived fr CySPP.	designed and ware projects om the SMPI	is in com plans and A, SQAPI	pi I (M	

Questions?



Based on IEEE Std 603

Criteria for Safety Systems for Nuclear Power Generating Stations







What is the Independent Control Platform (ICP)?

The ICP platform is fundamentally and technologically diverse from the other two safety-related Q-DCIS hardware/software technology platforms; RTIF-NMS and SSLC/ESF. The ICP digital hardware platform is implemented in a system composed of custom programmable logic devices (CPLDs). The ICP safety-related function is not changeable after initial configuration and setup. The ICP implementation that performs its safety-related control function does not execute, run, or use a cyclic real-time executive or operating system or any associated controller application program to perform its safety function. The ICP implementation that performs its safety-related control function does not include a system clock as there is no cyclic real-time executive. The overall ICP platform does include monitoring and diagnostics programs but these programs are independent from the implementation that performs the safety-related control function. The ICP implementation. The ICP implementation that performs the safety-related control functions are independent from the implementation that performs the safety-related control functions are implemented in CPLDs and are relatively simple functions. The ICP functions are only required after the complete failure of RTIF-NMS or SSLC/ESF functions.

The design objective with ICP implementation is to configure them to be nearly 100% testable. The currently available CPLD logic and associated digital circuit engineering design and configuration tools are software based. There is a possibility that system level or functional logic and control requirement errors exist or that the engineering design and configuration tools used to implement the CPLDs contain a latent defect. Identifying, dispositioning, and remediating both of these types of errors are addressed by the rigorous and structured system and software development lifecycle (SDLC) as described in Section 7B. SOFTWARE DEVELOPMENT. The ICP platform does not execute, run, or use any active software to perform its safety-related control function, the functions implemented are simple, and it is designed to be nearly 100% testable. Therefore, the ICP digital hardware platform is highly immune to common-cause failure (CCF) with respect to its own software based engineering design and configuration tool, itself, as well as the other two Q-DCIS hardware/software technology platforms as well as the systems and functions implemented on them.

ICP is highly IMMUNE to CCFs and is DIVERSE from RTIF-NMS and SSLC/ESF

DCD Tier 2 Ch 7 I&C – Uses of... "deterministic"

7.1 Introduction

7.1.3.2.7 Data Communication Systems

The DCIS data communication functions are embedded within the Q-DCIS and the N-DCIS architectures. Safety-related Q-DCIS internal and external communication protocols are deterministic.

7.1.6.4 Regulatory Guides

A discussion of the general conformance of the I&C equipment to RGs is provided below. The following sections are noted in IEEE Std. 7-4.3.2 as specifically addressed by the NRC in RG 1.152:

• Annex F, "Computer reliability." The NRC states that quantitative reliability goals are not the only means, and does not endorse this method as the sole means of meeting the regulations for reliability of digital computers. The NRC acceptance is based on deterministic criteria.

7.1.6.6.1.17 Automatic Control (IEEE Std. 603, Sections 6.1 and 7.1)

The RTIF-NMS, and ATWS/SLC logic automatically initiates reactor trip and the RTIF for LD&IS (non-MSIV), SSLC/ESF and VBIF logic automatically actuates the ESF that mitigate the consequences of DBEs. These automatic protection actions are implemented through two-out-of-four voting logic whenever one or more process variables reach their actuation setpoint. Variables are monitored and measured by each of the RTIF - NMS, ATWS/SLC, SSLC/ESF, and VBIF divisions.

Plant-specific setpoint analyses determine the protection systems' instrument setpoints using the methodology described in Reference 7.1-9. The GEH setpoint methodology uses plant-specific setpoint analyses to ensure that the combination of characteristics of the instruments such as range, accuracy and resolution provide the required high probability that the analytical limits in Chapter 15 analyses are not exceeded for the safety-related control system components and systems of the safety-related I&C. The response times of the I&C systems are assumed in the safety-related analyses and verified by plant specific surveillance testing or system analyses. The Q-DCIS application software, hardware processing rates, and internal and external communication system design ensures that the real-time performance of the safety-related control systems is deterministic.

7.2 Reactor Trip System

7.2.1.3.5 Branch Technical Positions

BTP HICB-21, Guidance on Digital Computer Real-Time Performance:

• Conformance: The real-time performance of RPS in meeting the requirements for safety-related system trip and initiation response conforms to BTP HICB-21. The real-time performance of the safety-related control system is **deterministic** based on the Q-DCIS internal and external communication system design and the RPS logic design. Timing signals are neither exchanged between divisions of independent equipment nor between logics within a division.

7.3 Engineered Safety Features Systems

7.3.5.3.5 Branch Technical Positions

BTP HICB-21, Guidance on Digital Computer Real-Time Performance:

• Conformance: The real-time performance of SSLC/ESF in meeting the requirements for safety-related system trip and initiation response conforms to BTP HICB-21. Each SSLC/ESF controller operates independently and asynchronously with respect to other controllers. The real-time performance of the safety-related control system is **deterministic** based on the Q-DCIS internal and external communication system design and the SSLC/ESF controller between divisions of independent equipment, nor between controllers within a division.

Logic, Controllers, and Communications are by design DETERMINISTIC HITACHI

DCD Tier 2 Ch 7 I&C – Uses of... "error"

7.1.3.4 Q-DCIS Testing and Inspection Requirements

2nd Para.:

The Q-DCIS uses three diverse safety-related platforms: RTIF-NMS (RPS, NMS, and the MSIV isolation function) and SSLC/ESF, and ICP. The RTIF-NMS and SSLC/ESF platforms are accessible for testing purposes. Their continuous automatic on-line diagnostics detect data transmission errors and hardware failures at the replaceable card or module level. On-line diagnostics for RTIF-NMS and SSLC/ESF are qualified as safety-related in conjunction with functional software qualification, and also meet the self-diagnostic characteristics for digital computer based protection systems recommended by IEEE Std. 7-4.3.2.

7th Para.:

The ICP is similar to the RTIF-NMS and SSLC/ESF platforms in that it contains self-diagnostic capabilities to ensure that the platform is functioning properly. The ICP self-diagnostics possess the capability to:

- Detect data transmission errors,
- Detect hardware failures, and
- Check platform operability.

7.1.6.6.1.8 Capability for Testing and Calibration (IEEE Std. 603, Section 5.7)

1st Para., 5th Sentence:

The I&C equipment has built-in self-diagnostic functions to identify critical failures such as loss of power and data errors. The Q-DCIS meets the requirements outlined in this section. Refer to Subsections 7.1.3.3.6, 7.1.3.3.7, 7.1.3.4 and 7.1.3.5.

7.3.5.4 Testing and Inspection Requirements

2nd Para.:

The self-testing includes continuous error checking of transmitted and received data on the serial data links of each SSLC/ESF controller; for example, error checking by parity check, checksum, or Cyclic Redundancy Checking (CRC) techniques. Self-test failures are indicated to the operator at the MCR console and recorded in a log maintained by the PCF of the N-DCIS.

7.8.2.1 Design Techniques for Optimizing Safety-Related Hardware and Software

1st Para., 8th Bullet, 3rd sub-bullet:

Code is segmented by system and function:

• Fixed message formats are used for plant sensor data, equipment activation data, and diagnostic data. Thus, corrupted messages are detected by error-detecting software in each digital instrument;

7.8.2.2.1 System Level Defenses

1st Para., 2nd Bullet:

Operational defenses include:

• Automatic error checking on all multiplexed transmission paths. Only the last valid data is used for logic processing. If a permanent fault is detected, the channel alarms and a trip is initiated for the RPS and MSIV isolation functions;

2nd Para.:

Functional defenses include:

• Automatic error detection. This permits early safe shutdown or bypass before common mode effects occur. Instantaneous, simultaneous, and undetected failure on a common mode error is unlikely; and

"Errors" are detected and mitigated...

Control and Communications are DETERMINISTIC



DCD Tier 2 Ch 7 I&C – Uses of... "checksum"

7.1.3.4 Q-DCIS Testing and Inspection Requirements

6th Para.:

Both RTIF-NMS and SSLC/ESF are cyclically tested from the sensor input point to logic contact output. The self-diagnostic capabilities include power supply checks, microprocessor checks, system initialization, watchdog timers, memory integrity checks, I/O data integrity checks, communication bus interfaces checks, and checks on the application program (checksum). Cyclically monitored items include:

- inputs to the I/O for unacceptably high/low levels;
- Proper execution of application code/checksum verification of code integrity;
- Internal clocks;
- Functionality of input cards/modules, and their main processor communication;
- Main processor communication with the output contact (SSLC/ESF platform);
- Inter-divisional communication between RPS and NMS logic processors or logic functions (RTIF-NMS platform);
- Functionality of the output contact by momentarily reversing its state and confirming readiness to change state on demand (SSLC/ESF platform); and
- Power supplies.

7th Para.:

Subsequent to verification and validation (V&V) of software during factory and preoperational testing in accordance with approved test procedures. there is no mechanism for the RTIF-NMS or SSLC/ESF code, response time, or coded trip setpoints to inadvertently change. For user adjustable parameters a new checksum is calculated at the time acceptable changes are implemented. The new checksum is used from that point forward to validate the application software.

7.3.5.4 Testing and Inspection Requirements

3rd Para.:

The self-testing includes continuous error checking of transmitted and received data on the serial data links of each SSLC/ESF controller; for example, error checking by parity check, checksum, or Cyclic Redundancy Checking (CRC) techniques. Self-test failures are indicated to the operator at the MCR console and recorded in a log maintained by the PCF of the N-DCIS.



"Checksums" used to identify and mitigate them... **Control and Communications are DETERMINISTIC**

DCD Tier Ch 7 I&C – Uses of... "interrupt" & "query"

7.1.3.3.2 Communication Pathways (CIMs, Fiber-Optic Cable, Datalinks, and Nonsafety-Related Gateways)

4th Para.:

Safety-related software is as simple as possible so that Q-DCIS components have neither interrupts from nonsafety-related devices nor do they respond to nonsafety-related component gueries for information. The O-DCIS components simply put information on the safety-related (O-DCIS) networks in a known format so that other safety-related devices can retrieve what is needed for their function. Self-diagnostics information is also put on the DCIS networks.

7.1.3.3.3 Nonsafety-Related Gateways

1st Para.:

The nonsafety-related gateways translate the information sent between the O-DCIS (through the required isolation, via datalinks and fiber-optic cable) and the N-DCIS into a format that the other portion of the DCIS (either N-DCIS or O-DCIS) can apply. The N-DCIS agteways package the safety-related information into the necessary message packets to support specific N-DCIS components for monitoring and alarm management purposes. The N-DCIS aateways also respond to interrupts and queries. Safety-related to nonsafety-related communication pathways that do not involve nonsafety-related aateways use safety-related fiber-optic CIMs (which provide the safety-related isolation), datalinks, and fiber-optic cable.

7.1.4.5 N-DCIS Testing and Inspection Requirements Summary

2nd Para.:

The N-DCIS controllers, displays, monitoring and input and output communication interfaces function continuously during normal power operation. Abnormal operation of these components can be detected during plant operation. In addition, the controllers are equipped with on-line diagnostic capabilities to identify and isolate failure of I/O signals, buses, power supplies, processors, and inter-processor communications. These on-line diagnostics can be performed without interrupting the normal operation of the N-DCIS.

"Interrupts" and "Queries" are not used in or recognized by safety systems... **Control and Communications are DETERMINISTIC** HITACHI



DCD Tier 2 Ch 7 I&C – Uses of... "watchdog timer"

7.1.2.5 Q-DCIS Testing and Inspection Requirements Summary

1sh Para.:

The Q-DCIS integrated hardware and software functions, including the network parameters and data status, are checked and tested together. The Analog-to-Digital (A/D) converters in the RMUs are the only components requiring periodic calibration checks. Key diagnostics include:

- The central processing unit (CPU) status check,
- Parity checks, watchdog timer status,
- Voltage level in controllers,
- Data path integrity and data validation checks,
- Data cycling time, and
- Processor clock time.

7.1.3.4 Q-DCIS Testing and Inspection Requirements

4th Para.:

The RTIF-NMS hardware has watchdog timers for various logic processors and logic functions that monitor the execution of the software. If the software stops executing (suspending the self-diagnostics), its watchdog timer resets the affected logic processor or logic function. This results in a channel trip and alarm while the logic processor or logic function is resetting.

5th Para.:

The SSLC/ESF platform is a Triple Modular Redundant (TMR) system, with three main processors. The main processors are monitored by **individual watchdog timers** that reset or fail a main processor depending on the severity of the problem. A single or double main processor failure causes alarms, but the division continues to function to provide the required automatic protective actions.

6th Para.:

Both RTIF-NMS and SSLC/ESF are cyclically tested from the sensor input point to logic contact output. The self-diagnostic capabilities include power supply checks, microprocessor checks, system initialization, watchdog timers, memory integrity checks, I/O data integrity checks, communication bus interfaces checks, and checks on the application program (checksum). Cyclically monitored items include:

6th Para., 4th Heading – Response Time Test:

The response time test is performed by a series of sequential, overlapping, or total steps to measure the entire response time. The logic processor or logic function self-diagnostics and the TSM support the performance of the response time test for the safety-related platforms. Watchdog timers monitor logic processor or logic function internal clocks and alarms for out-of-limit conditions and the completion of application code per logic processor or logic function cycle. Since the clocks set the response time, there is no mechanism for the response time to change without alarm or trip. All time delays incorporated into system logics are performed by software and the values are set during factory and preoperational testing in accordance with approved test procedures. Subsequent to final V&V of the code, there is no mechanism for the time delay values to inadvertently change. The response time tests for the remaining portions (i.e. sensors [except neutron radiation detectors] and final control elements/actuators) are performed separately from self-diagnostics and the TSM.

7.8.2.1 Design Techniques for Optimizing Safety-Related Hardware and Software

1st Para., 9th Bullet:

In addition to the DPS, other techniques ensure safety-related system reliability by minimizing both random and common mode failure probabilities.

• Software design uses recognized defensive programming techniques, backed up by self-diagnostic software and hardware watchdog timers;.

"Watchdog Timers" monitor software – Enable completion of protective action...



HITACHI Control and Communications are DETERMINISTIC

Simplicity...

A Typical Example - RPS



Derived from DCD Rev. 6 Figure 7.2-1 RPS Simplified Functional Block Diagram

Decompose COMPLEX into SIMPLE elements... Systems Engineering Each Control Function partitioned into Sense – Command - Execute HITACHI

Logic Diagrams...

RPS Monitored Parameters Example

Software Management Program Manual (SMPM) NEDE-33226 (Tier 2*)

Software Quality Assurance Program Manual (SQAPM) NEDE-33245 (Tier 2*)



Remark::

Generally, design process begins with a Functional Logic Block Diagram (FLBD) or equivalent and matures into a final Detailed Logic Diagram (DLD). Simplified Logic Diagrams (SLDs) are developed from the "As Built" DLDs and are a customer deliverable.

Cyber Security Program Plan (CySPP) NEDE-33295 (Tier 2*)

Logic concepts proposed early in overall System SDLC as FLBDs... Matures under configuration management into DLDs Iterations controlled via design reviews (DRs) or baseline reviews (BRs) Design basis records (BRR) foundation of all ITAAC closure reports HITACHI



Regulatory Compliance Approach...

Governing LTRs



Based on IEEE Std 603

Criteria for Safety Systems for Nuclear Power Generating Stations



Regulatory Compliance...

The Approach

Tier 1



~2,280 Regulatory **Conformance Statements**

~806 ITAACs (including ~378 DACs) **Commitments**

Regulation... Foundation for Quality, Safety and Reliable I&C System DESIGN and Software PROCESS



System and Software Design Process...

LTR Triad



Cyber-Security Program Plan NEDE-33295 (Tier 2*)

> LTRs are detailed, comprehensive and integrated... Provide structure for System and Software DESIGN PROCESS Foundation of DAC and ITAAC Closure



Recommendation – Provide Add'l DCIS Design Detail Example... RAI 7.1-139 – Question 3

NRC Request:

DCD Tier 2 Figure 7.1-1 shows the elements of the Q-DCIS and the N-DCIS with a very high-level functional representation. During the ACRS meeting, GEH presented additional architectural information, including a simplified diagram with a "safety ring." This level of architectural detail needs to be included in the DCD for the safety systems. Add figures with this level of detail to the DCD with corresponding discussion in the text as applicable.

GEH Response:

17 New or Revised Figures provided w/ descriptive text...

<u>New [Qty 8] – (See Backup for copies):</u>

- Figure 7.2-11a, RTIF Functional Block Diagram
- Figure 7.2-11b, RTIF Functional Block Diagram OLU Detail
- Figure 7.2-12, NMS Functional Block Diagram
- Figure 7.3-6, SSLC/ESF Division 1 Layout
- Figure 7.3-7, SSLC/ESF Functional Block Diagram
- Figure 7.3-8, SSLC/ESF Interdivisional Communication Detail
- Figure 7.3-9, SSLC/ESF Safety-Related VDU Communication Detail
- Figure 7.3-10, SSLC/ESF Nonsafety-Related Communication Detail

Revised [Oty 9]:

- Figure 7.1-1, Simplified Network/Functional Diagram of DCIS
- Figure 7.2-2, RPS Interfaces and Boundaries Diagram.
- Figure 7.3-1a, SRV Initiation Logics
- Figure 7.3-1b, GDCS and DPV Initiation Logics
- Figure 7.3-2, GDCS Equalizing Valve Initiation Logics
- Figure 7.3-3, LD&IS System Design Configuration
- Figure 7.3-4, SSLC/ESF Functional Block Diagram
- Figure 7.3-5, SSLC/ESF System Interface Diagram
- Figure 7.4-3, Isolation Condenser System Initiation and Actuation

Chapter 7 Rev 6 contains 485 Pages plus Change List with 111 Pages Significant ADDITIONAL DESIGN DETAIL with block diagrams provided HITACHI



Add'l Design Detail – New Fig. (1/8)... Figure 7.2-11a From: RAI 7.1-139 – Question 3



Figure 7.2-11a

Reactor Trip and Isolation Function (RTIF) Simplified Functional Block Diagram


Add'l Design Detail – New Fig. (2/8)... Figure 7.2-11b From: RAI 7.1-139 – Question 3

(Four Divisions Shown)



Figure 7.2-11b

Reactor Trip and Isolation Function (RTIF) Simplified Functional Block Diagram – Output Logic Unit Detail



Add'l Design Detail – New Fig. (3/8)... Figure 7.2-12 From: RAI 7.1-139 – Question 3



Neutron Monitoring System (NMS) Simplified Functional Block Diagram



Add'l Design Detail – New Fig. (4/8)... Figure 7.3-6 From: RAI 7.1-139 – Question 3



Figure 7.3-6 SSLC/ESF Division 1 Layout



Add'l Design Detail – New Fig. (5/8)... Figure 7.3-7 From: RAI 7.1-139 – Question 3



Figure 7.3-7 SSLC/ESF Simplified Functional Block Diagram



RXM = Remote Expansion Chassis

Add'l Design Detail – New Fig. (6/8)... Figure 7.3-8 From: RAI 7.1-139 – Question 3



Figure 7.3-8 SSLC/ESF Inter-Divisional Communication Detail



Add'l Design Detail – New Fig. (7/8)... Figure 7.3-9 From: RAI 7.1-139 – Question 3





Figure 7.3-9 SSLC/ESF Safety-Related VDU Communication Detail



Add'l Design Detail – New Fig. (8/8)... Figure 7.3-10 From: RAI 7.1-139 – Question 3



Figure 7.3-10 SSLC/ESF Nonsafety-Related VDU Communication Detail







GE Hitachi Nuclear Energy

ESBWR DCD Section 6.4 Control Room Habitability System

- Advisory Committee on Reactor Safeguards
- **Mike Arcaro**
- Wayne Marquino
- September 24, 2010





<u>Agenda</u>

- Control Room Habitability Area (CRHA) Technical Specification (TS) for Heat Sink Temperatures (TS 3.7.2)
- ESBWR Control Building (CB) Passive Heat Sink Validation
- Bounding ESBWR Standard Plant Site Parameters
- Reactor Building Temperature Monitoring Requirements



- CRHA heat sink temperatures are maintained below the initial analysis values by maintaining the average of the air temperatures in the areas in TS Table B3.7.2-1 below the specified limit
 - Permanently installed temperature sensors will be provided in various locations and elevations inside CB with sensors feeding the plant computer for averaging and continuous monitoring of the CRHA heat sink areas
- When the average temperature of one or more rooms is greater than the limit specified in SR 3.7.2.1 (Applicable in Mode 1, 2, 3 & 4), Action A.1 requires that the average air temperature of each CRHA heat sink be restored within 8 hours
 - Prior to the CR reaching 85 F (above the 74 F LCO), Redundant CRHA
 / CB HVAC started and CRHA non-essential N-DCIS loads secured in CRHA
 - CRHA non-essential N-DCIS loads tripped at 85 F CR temperature



- Action A.2 requires that the average temperature of each CRHA heat sink be restored to within limits within 24 hours
 - If the average of the CRHA air sink temperatures exceed the specified limit, restoration of the CRHA heat sinks is verified by <u>administrative</u> <u>evaluation considering</u> the length of <u>time and extent</u> of the CRHA heat sink average air temperature excursion outside of limits, <u>or by</u> <u>direct measurement of the CRHA heat sink area structural materials</u> <u>temperatures</u>
 - An evaluation can be used to provide temperature profiles based on initial conditions (initial ambient temperatures, initial CRHA air temps, CRHA heat loads) to assess heat sink performance in lieu of actual heat sink (concrete) temperature measurement
 - CRHA heat sink temperature monitoring could be used to assess and ensure CRHA heat sink performance under TS 3.7.2 by measuring CRHA concrete surface temperature and predicting heat sink average temperature



- If A.1 or A.2 are not met, must be in MODE 3 in 12 hours and Mode 5 in 36 hours
- COL Item 6.4-1-A, CRHA Procedures and Training, will develop procedures and training for control room habitability including administrative evaluation of CRHA heat sink



ESBWR Passive Heat Sink Validation

Summary from ACRS question:

Discuss why an Analysis was chosen as the ITAAC method for the CB heat sink; Would it be beneficial to add an operational test of these passive heat sinks?

Response:

ITAAC T 2.16.2-4 (CB), A Control Building and Reactor Building Environmental Temperature <u>Analysis</u> for ESBWR, <u>will be performed</u> using the as-built heat sink dimensions, the as-built heat sink thermal properties, the as built heat sink exposed surface area, the as-built thermal properties of materials covering parts of the heat sink, and the asbuilt heat loads. An operational test that would simulate limiting design conditions would be extremely difficult to perform. The analysis method is Tier 2*



ESBWR Control Building Passive Heat Sink Validation

- CB Passive Heat Sink performance is assured by analysis rather than testing because critical as-built parameters can be readily verified
- The heat capacity of the control room concrete mass and name plate heat loads will be validated in an ITAAC.
 - No tests of the structural components of the concrete are required. It's inconsistent with other passive functions (e.g. building structure response) to test the heat capacity of the concrete or physical cooling processes.
- Limiting design parameters associated with the passive heat sink can not be readily reproduced during performance testing (i.e. 117 F ambient temp, ground temp 86 F, Temp Range 27 F, high humidity conditions 92 F db / 88 F wb)
- A performance test would require verification of CRHA heatup with minimum safety-related loads <u>for a period of 72 hours</u>



ESBWR Control Building Passive Heat Sink Validation

- Test would require tripping the non-safety DCIS equipment, which terminates control of the equipment. There is no equivalent challenge to the non-safety DCIS planned
- The startup test would require 72 hour to perform after all MCR equipment and DCIS room equipment is installed and then deliberately turned off (Critical Path Startup Test)
- The test would impose a significant schedule challenge, to sequence when the loads are available to be powered, but where interruption of the NDCIS would not disrupt the plant pre-operational or startup tests

Conclusion:

Sufficient information is provided to ensure CB passive heat sink will function as designed



Summary from RAI question:

RAI 6.4-24S02 requested clarification for site characteristic values related to daily temperature range and high humidity diurnal swing associated with ESBWR Standard Plant Site Parameters 0% exceedance

<u>Response:</u> Response to RAI 6.4-24 S02 has been provided to NRC Staff

<u>Conclusion:</u> DCD S 3H3.2 has been revised under revision 8 to incorporate NRC comments



3H.3.2.1.1 Maximum Temperature Analysis Conditions

For the summer conditions the 0% exceedance maximum dry bulb and coincident wet bulb ambient outside air temperature [47.2°C (117°F) DBt and 26.7°C (80°F) WBt] was considered. The Daily Temperature Range applied for this analysis is Δ 15°C (27°F).

The Daily Temperature Range for summer conditions is defined as the dry bulb temperature difference between the 0% exceedance maximum dry bulb temperature and the dry bulb temperature that corresponds to the higher of the two lows occurring within 24 hours before and after that maximum.

The Maximum Average Dry Bulb Temperature for the 0% Exceedance Maximum Temperature Day is defined as the average of the 0% exceedance maximum dry bulb temperature of 47.2°C (117°F) and the dry bulb temperature resulting from a daily temperature range of 15°C (27°F), which is 39.7°C (103.5°F).

3H.3.2.1.2 Minimum Temperature Analysis Conditions

For the winter conditions the Cont rol Room Habitability Area Minim um Temperature Analysis considers the 0% exceedance minimum dry bulb am bient outside air temperature (-40°C/°F). The Daily Temperature Range applied for this analysis is Δ 15°C (27°F).

The Daily Temperature Range for winter conditions is defined as the dry bulb temperature difference between the 0% exceedance minimum dry bulb temperature and the dry bulb temperature that corresponds to the lower of the two highs occurring within 24 hours before and after that minimum.

The Minimum Average Dry Bulb Temperature for 0% Exceedance Minimum Temperature Day is the average of the 0% exceedance minimum dry bulb temperature of -40° C (-40° F) and the dry bulb temperature resulting from a daily temperature range of 15°C (27°F), which is -32.5°C (-26.5° F).



3H.3.2.1.3 High Humidity Analysis Conditions

For high humidity conditions the 0% exceedance non-coincident maximum wet bulb temperature [31.1°C (88°F) WBt] and High Humidity Diurnal Swing [Δ 4.4°C (8°F) DBt] are applied to the methodology for the analysis presented in Reference 3H.4-8.

The High Humidity Diurnal Swing is defined as the dry bulb temperature range determined by the maximum and the minimum wet bulb temperatures for the worst three-day period over which the 0% exceedance wet bulb temperature occurs. The maximum wet bulb temperature (31.1°C/88°F) has a coincident dry bulb temperature of (33.3°C/92°F). These temperatures define the maximum dry bulb and wet bulb temperatures for three days in the analysis. The minimum dry bulb temperature is defined as the coincident dry bulb temperature (28.9°C/84°F) for the highest of six low wet bulb temperatures (27.2°C/81°F) occurring in each of the three 24-hour periods before and after the 0% coincident maximum wet bulb temperature. The High Humidity Diurnal Swing is the difference between the coincident maximum dry bulb temperature (33.3°C/92°F) and the highest daily low dry bulb temperature (28.9°C/84°F).

The overnight low wet bulb temperature in the high humidity CONTAIN analysis is 28.9°C (84°F), which is conservative relative to the 27.2°C (81°F) wet bulb temperature in the High Humidity Diurnal Swing.

The WBGT index value is determined by the dry bulb temperature multiplied by 0.3 plus the wet bulb temperature multiplied by 0.7.

The Maximum High Humidity Average Wet Bulb Globe Temperature Index for 0% Exceedance Maximum Wet Bulb Temperature Day is defined as the average of the WBGT index values for the temperatures used to determine the High Humidity Diurnal Swing. The WBGT index value for the maximum dry bulb 33.3°C (92°F) and wet bulb 31.1°C (88°F) temperatures is 31.8°C (89.2°F). The WBGT index value for the minimum dry bulb 28.9°C (84°F) and wet bulb 28.9°C (84°F) temperatures is 28.9°C (84°F). The average of the WBGT index values is then 30.3°C (86.6°F).



Reactor Building Temperature Monitoring Requirements

<u>Summary from ACRS question:</u>

How are assumptions of the Reactor Building passive heatup calculation assured ?

Response:

DCD provides assurance that monitoring is performed to maintain RB temperatures below limits

<u>Conclusion:</u> Sufficient information is provided to ensure RB temperatures will be maintained below EQ limits



Reactor Building Temperature Monitoring Requirements

- ESBWR GTS do not include an LCO for monitoring EQ related temperatures in RB rooms containing safety-related (SR) equipment because it does not meet the criteria of 10 CFR 50.36. This is consistent with the current STS (NUREGs 1433 & 1434), which evolved as follows:
 - The old STS (i.e., NUREG-0123) included an LCO titled "Area Temperature Monitoring," which ensured that SR equipment in various areas was not subjected to temperatures beyond the defined EQ envelope.
 - During development of the current STS, the NRC Staff agreed that the Area Temperature Monitoring LCO did not meet the criteria for including in TS and, therefore, the requirements of the LCO could be controlled outside of TS.
 - Compensating provisions considered to support the change to the STS include the existence of monitoring instrumentation and control room annunciators for high area temp which will alert the operator to take corrective action. These compensating provisions also exist for the ESBWR design.



HITACHI

Reactor Building Temperature Monitoring Requirements

- Indicators including flow rates, control damper position, filter pressure drop, building pressure with respect to atmospheric, <u>temperatures</u>, battery room hydrogen concentration [ref. DCD S9.4.6.5]
- Alarms for high or low conditions including airflow rates, <u>temperatures</u>, filter pressure drop, building differential pressure, smoke detection, and high battery room hydrogen concentration and <u>temperature</u> [ref. DCD S9.4.6.5]
- DCD Table 9.4-8 Design Parameters for RBVS provides normal & design temperatures for RB safety related components
- Table 3H-3 Thermodynamic Environment Conditions Inside RB for Normal Operating Conditions
- Table 3H-9 Thermodynamic Environment Conditions Inside RB for Accident Conditions
- Table 18.1-1a Minimum Inventory of MCR Alarms, Displays, and Controls Description Alarm Display Control- RB Area Temperature High



<u>Summary</u>

- CRHA design meets GDC 19 habitability requirements
- CRHA Design Validation / Surveillance Procedures assure functions will be met
- Bounding ESBWR Standard Plant Site Parameters can be interpreted and implemented by COL Applicants
- Reactor Building Temperature Monitoring Requirements ensure EQ life of equipment



Follow up to ACRS Subcommittee comment on Ch 16



Passive Safety System – Inspection Frequencies

Summary of Concern from August 2010 ACRS Meeting

Staggering of the surveillances for inspection of the passive safety systems should be considered

Response

The following changes have been made, and will be included in Revision 8 of the DCD. <u>LCOs 3.5.2 and 3.5.3 – GDCS</u>:

- Verify the flow path for each GDCS injection branch line is not obstructed every 24 months on a staggered test basis for each pair of GDCS injection branch lines (was once/10 years)
- Verify the flow path for each GDCS equalizing line is not obstructed every 24 months on a staggered test basis for each equalizing line (was once/10 years)

LCO 3.7.1 – IC/PCCS Pools:

- Verify each IC/PCCS pool subcompartment has an unobstructed path through moisture separator to the atmosphere – every 48 months on a staggered test basis for the flow path associated with each moisture separator (was once/10 years)
 <u>ACLCO 3.5.1 – GDCS Deluge Function:</u>
- Verify the flow path for each GDCS deluge line is not obstructed every 24 months on a staggered test basis for each deluge line (was once/10 years)







ESBWR CRHA Passive Heat Sink Issues Table B3.7.2-1

Heat Sink Group	Established Design Temperature
CRHA Heat Sink Group 1	
Control Room Habitability Area: Main control room panel Rooms: No 3270, 3272, 3271, 3201, 3202, 3273, 3206, 3205, 3204, 3275, 3207, 3208	23.3°C (74°F)
Corridors: ¹ Rooms 3100, 3101 and Rooms 3200,3203, 3277, 3274	25.6°C (78°F)
HVAC chases: ¹ Rooms 3251, 3260	25.6°C (78°F)
CRHA Heat Sink Group 2	
Q-DCIS equipment rooms: Rooms No 3110, 3120, 3130 and 3140	25.6°C (78°F)
N-DCIS equipment rooms: Rooms 3301, 3302, 3303, 3300	25.6°C (78°F)
Electrical chases: ¹ Rooms 3250, 3261	25.6°C (78°F)
CRHA Heat Sink Group 3	
HVAC equipment rooms: Rooms 3401, 3402, 3403, 3404	40°C (104°F)
Safety Portions of CRHAVS: Rooms 3406, 3407	40 °C (104°F)

1. Access corridors, electrical chases, and HVAC chases, although part of the CRHA heat sink, are not monitored because these areas do not contain heat sources and their temperatures are assumed to match the average of the associated group.



Parameter	Value (ºF)	Discussion
CRHA Normal Operating Limit (at 0% summer exceedance)	70* to 74*	Comfort level. URD specifies 73°F to 78°F. Value allows margin to N- DCIS trip setpoint and provides initial condition for CRHA heat sink structural material temperature while considering ventilation system operating costs and margin for long term structural degradation.
Alarm/ Tech Spec Action	74*	CRHA heat-up analysis assumes CRHA heat sink structural material (e.g., concrete) is 74°F or less
Tech Spec Surveillance Limit – Heat Sink Temp.	74* (for CRHA)	If the heat sink air is above analyzed temperature (e.g., 74°F for CRHA*), after air temperature has been brought back down (8 hour limit to accomplish this), the complete heat sink must be assured of having returned to (or never exceeded) the assumed limit(s). Restoring the CRHA heat sink average air temperatures to within limits within 8 hours limits the temperature excursion of the CRHA heat sink structure; i.e., restoring CRHA heat sink average air temperature begins the process of cooling the CRHA heat sink structure.
Select N-DCIS Trip Setpoint – CRHA Air Temp.	85	Setpoint will provide reasonable amount of time to restore CRHA ventilation or reduce CRHA heat loads prior to trip of certain loads, including some N-DCIS loads.



ESBWR CRHA Passive Heat Sink Issues-Conditions for Simulation

- Step 1- Room air temperatures under normal operation with these temperatures artificially maintained in CB rooms
 - All room air temperatures are kept steady until all temperatures across the structures reach a steady state simulating full operation of the CB HVAC system
- Step 2- The structure temperature profile in structures calculated previously is considered as initial temperatures, and the model is run for 8h
 - All room air temperatures are kept the same as in step 1 during 8h with the exception of the CRHA air temperature, which is maintained at 29.4°C (85°F)
 - The concrete temperatures on the surface and inside the CRHA structures increase slightly because they are in contact with air at a higher temperature
- Step 3- The event of an SBO is considered where this transient calculates the room air heatup curve inside the CRHA and rooms housing safetyrelated equipment in an SBO during 72h









Ambient	0% Exceedance Values
Design	- Maximum: 47.2°C (117°F) dry bulb
Temperature:	26.7°C (80°F) wet bulb (mean coincident)
(6)	31.1°C (88°F) wet bulb (non-coincident)
	- Minimum: -40°C (-40°F)
	Maximum Average Dry Bulb Temperature for 0% Exceedance Maximum Temperature Day ⁽¹⁷⁾
	39.7°C (103.5°F)
	<i>Minimum Average Dry Bulb Temperature for 0% Exceedance</i> <i>Minimum Temperature Day</i> ⁽¹⁸⁾
	-32.5°C (–26.5°F)
	Maximum High Humidity Average Wet Bulb Globe Temperature Index for 0% Exceedance Maximum Wet Bulb
	<i>Temperature Day</i> ⁽¹⁹⁾
	30.3°C (86.6°F)
6 HITACHI	





Presentation to the ACRS Subcommittee

ESBWR Design Certification Review Chapter 7, "Instrumentation and Controls"

September 24, 2010



Chapter 7 Review Team

- Technical Review Staff
 - Ian Jung, Branch Chief, ICE2
 - Hulbert Li
 - Joseph Ashcraft
 - Dinesh Taneja
 - Deanna Zhang
 - Eugene Eagle
 - Sang Rhow
 - Kimberley Corp
- Project Manager
 - Dennis Galvin

Chapter 7 Overview

The staff is required to evaluate safety of the I&C system design in accordance with the Commission's regulations by following SRP guidance

The staff's safety evaluation is based on the design information provided in the design control document (DCD) and the referenced technical reports. The staff's evaluation is documented in the SER as follows:

- 7.1 Overview of I&C systems, including:
 - Conformance to regulations GDCs, IEEE-603, TMI Action Items
 - Software development activities LTRs NEDE-33226P and NEDE-33245P
 - Diversity and defense-in-depth LTR NEDO-33251
 - Setpoint methodology LTR NEDE-33304P
 - Data communication
 - Secure development and operational environment (SDOE) LTR NEDE-33295P

Chapter 7 Overview (cont.)

- 7.2 Reactor Trip System
- 7.3 Engineered Safety Features Systems
- 7.4 Safe Shutdown Systems
- 7.5 Information System Important to Safety
- 7.6 Interlock Logic
- 7.7 Control Systems
- 7.8 Diverse Instrumentation and Control Systems
General Finding

- The staff has evaluated safety of the I&C system design and finds the design to be safe and in compliance with applicable regulations
- I&C design follows safe design principles:
 - Independence
 - Determinism
 - Redundancy
 - Diversity and Defense-in-Depth
- Safety-related I&C design employs **Simplicity** in many aspects
- I&C systems are designed to conform with the following applicable regulatory requirements:
 - 10 CFR Part 52
 - 10 CFR Part 50, including 50.55a(h) (IEEE Std. 603)
 - 10 CFR Part 50 Appendix A (GDC)
 - 10 CFR Part 50 Appendix B (QA)
 - 10 CFR Part 50.34 (TMI items)

Independence

- The staff found that the I&C system design provides sufficient independence in compliance with IEEE-603 (10 CFR 50.55a(h)) and GDC 21
 - Safety-related platforms are organized into four physically separated and electrically isolated divisions
 - Communication independence is achieved using following design features:
 - Inter-divisional data communication in safety-related systems is limited to:
 - Voting logic
 - Bypass
 - Data authentication
 - Inter-divisional data communication in RTIF/NMS platform is point-topoint unidirectional via optical fibers. Faulty or loss of data communication is interpreted as a trip signal (fail safe)
 - Inter-divisional data communication in SSLC/ESF platform uses redundant Ethernet networks for 2/4 voting logic. Networks are doubly buffered to prevent data corruption to adversely impact both networks

Independence (cont.)

- ICP platforms do not use multiplexing for data communication, I/O is hard wired
- Data communication from safety to non-safety related I&C systems is unidirectional
- Any failure in a division does not prevent other redundant safety divisions from performing their intended safety function
- Diverse and independent diverse protection system (DPS) is provided as a defense-in-depth feature to cope with an unlikely scenario of a primary system malfunction (CCF or multiple independent failures)

Determinism

- Determinism means that a required safety function is always accomplished within the required time period specified by Chapter 15 DBA analyses
- Based on the following, the staff found that the real time performance of the safety-related I&C systems is deterministic and conforms to IEEE-603 (10 CFR 50.55a(h)) and BTP HICB-21:
 - Q-DCIS data communication protocols are deterministic
 - RTIF/NMS platform performs a cyclic real-time execution. The operating system is clock-driven and not event-driven, and it does not incorporate "interrupts"
 - SSLC/ESF platform runs cyclic programs that include both the application and diagnostics and do not incorporate "interrupts"
 - ICP platforms do not have an operating system
 - All platforms always react in the same way according to the order of events occurring at the point in time of plant conditions

Redundancy

- The staff found that the I&C system design provides sufficient redundancy in compliance with IEEE-603 (10 CFR 50.55a(h)) and GDC 21
 - All safety-related platforms are organized into four redundant divisions
 - 4 redundant divisions of RTIF/NMS platforms
 - 4 redundant divisions of SSLC/ESF platforms
 - 4 redundant divisions of ICP platforms
 - Each division has its own set of sensors, and no sharing of sensors between safety divisions is allowed
 - DPS utilizes 2/4 voting logic

Redundancy (cont.)

- RTIF/NMS platform uses dual redundant communication rings for intra-divisional data communication
- SSLC/ESF platform uses doubly buffered redundant networks for 2/4 voting logic
- Within each SSLC/ESF division, triply modular redundant (TMR) controllers are used for high reliability
- N-DCIS platforms use double or triple redundant controllers for high reliability and availability

Diversity and Defense-in-Depth

- The staff found that the I&C system design provides sufficient diversity in compliance with 10 CFR 50.62 for ATWS mitigation
- The I&C system design also provides diverse backup for RTIF/NMS and SSLC/ESF to address software CCF concern in accordance with the SRM to SECY-93-87, item II.Q
- LTR NEDO-33251, "ESBWR I&C Diversity and Defense-in-Depth," provides I&C system architecture and the analysis in conformance with BTP HICB-19 guidance
- DPS design is based on different technology, equipment, design personnel, signals, and functionality
- Diversity is provided both within Q-DCIS (three platforms RTIF/NMS, SSLC/ESF, and ICP are diverse from each other) and externally by a non-safety DPS
- DPS is classified as RTNSS and is developed via a rigorous, highly structured process similar to ones used for safety systems

Simplicity

- The staff found that the I&C system design employs simplicity in many aspects, which contribute to the staff's safety finding:
 - Each Q-DCIS division is independently monitored and controlled from its dedicated redundant set of safety related VDUs
 - Safety related components cannot be controlled from the nonsafety related VDUs
 - Data communication from safety to non-safety related I&C systems is unidirectional
 - I&C system design meets "Independence Isolation Separation" requirements
 - Inter and intra-divisional communication is limited
 - ESBWR is a passive plant and the safety-related ESF functions are limited
 - Maintenance tool is not continuously connected

Logic Diagrams

- DCD contains adequate control logic design information for the staff to make a reasonable safety assurance finding
- Information described in the DCD will be used to develop logic diagrams
- Logic diagrams are produced and used during the I&C development life-cycle process
- Logic diagrams are finalized during the hardware/software design specification phase of the I&C system development lifecycle

Conclusion

- The staff has evaluated safety of the I&C system design and finds the design to be safe
- I&C systems are in conformance with the applicable regulatory requirements:
 - 10 CFR Part 52
 - 10 CFR Part 50, including 50.55a(h) (IEEE Std. 603 requirements)
 - 10 CFR Part 50 Appendix A (GDC)
 - 10 CFR Part 50 Appendix B (QA)
 - 10 CFR Part 50.34 (TMI items)
- I&C implementation DAC/ITTAC provided in Tier 1 are acceptable
- DCD Revision 8:
 - Provides clarity of I&C design information
 - No impact on I&C design
 - No impact on safety finding

Chapter 7 ACRONYMS

- ATWS Anticipated Transient Without Scram
- CCF Common Cause Failure
- DBA Design Basis Accident
- DCD Design Control Document
- DPS Diverse Protection System
- ESF Engineered Safety Feature
- GDC General Design Criteria
- ICP Independent Control Platform
- I&C Instrumentation and Control
- I/O Input and Output
- IEEE Institute of Electrical and Electronics Engineers
- LTR Licensing Technical Report
- N-DCIS Non Safety-related Distributed Control and Information System
- NMS Neutron Monitoring System
- QA Quality Assurance
- Q-DCIS Safety-related Distributed Control and Information System

Chapter 7 ACRONYMS (cont.)

- RG Regulatory Guide
- RTIF Reactor Trip and Isolation Function
- RTNSS Regulatory Treatment of Non-Safety System
- SER Safety Evaluation Report
- SSLC Safety System Logic and Control
- TMR Triply Modular Redundant
- VDU Video Display Unit



Presentation to the ACRS Subcommittee

ESBWR Design Certification Review

Section 9.4, "Heating, Ventilation, and Air Conditioning," and Section 6.4, "Control Room Habitability System"

September 24, 2010

Purpose

- Brief the Subcommittee on the staff's review of the ESBWR design certification application, Chapter 9.4, "Heating, Ventilation, and Air Conditioning," and Section 6.4, "Control Room Habitability System"; ventilation issues
 - Address follow up items from the previous briefing on this issue held on May 19, 2010.
 - Address related follow up items from briefings held on August 17, 2010
- Answer the Subcommittee's questions

Project and Technical Review Team

Project Managers

- Dennis Galvin, Project Manager (9.4)
- Bruce Bavol, Project Manager (6.4)

Technical Reviewers

- Jim O'Driscoll (6.4, 9.4.1 9.4.8) Lead
- Ed Forrest
- Syed Haider
- Shie-Jeng Peng
- Brad Harvey (2.3)
- Craig Harbuck (16)

Staff Follow-Up Items

- Provide and discuss heat up profiles for three models; CONTAIN 2.0, GOTHIC, and NRC First Principles Model (FPM)
- Discuss details of the Tech Spec Surveillance on Control Room Habitability Area (CRHA)heat sink temperatures
- Discuss details of verification of related site characteristics
- Discuss how assumptions used in the Reactor Building heat up calculation are assured

Confirmatory Analyses

- Staff review focus:
 - Suitability of applicant's approach using CONTAIN
 - Understanding of sensitivities
 - Heat sink properties
 - Heat sink initial temperature
 - Outside environmental conditions
- Summary of work performed:
 - Review of Applicants CONTAIN analysis
 - 1 Run using updated GOTHIC model.
 - Review of GEH FPM / Development of Staff FPM
 - Over 24 sensitivity runs performed using CONTAIN and NRC FPM of GEH ESBWR CRHA.

Confirmatory Analyses

- Summary of findings:
 - Heat up rates of all models agree.
 - CONTAIN and FPM behave similarly in sensitivity studies.
 - FPM sensitivity result are 2 to 4 °F higher than CONTAIN due to:
 - More heat is assumed to enter CRHA from adjacent rooms in FPM
 - Steel structures not modeled in FPM
 - Higher initial temperature of FPM heat sinks
 - ¹/₂ Mass of concrete touching soil modeled in FPM
 - Staff conclusion is that there is no benefit to reconcile models further. Studies support use of CONTAIN.
 Applicants initial conditions are appropriately conservative. Difference in models results are small.



 $\overline{=}$

Details of CRHA Heat sink TS Surveillance

- LCO 3.7.2 requires maintaining heat sink temperature "within established design limit" (SR 3.7.2.1) (CRHA thermal analysis)
 - \leq 74 °F for CRHA
 - ≤ 78 °F for Q-DCIS & N-DCIS equipment rooms
 - ≤ 104 °F for HVAC equipment rooms and safety portions of Control Room Habitability Area Ventilation System (CRAVS)
- CRHA boundary passive heat sinks limit the CRHA temperature to the acceptance criterion of 33.9°C (93°F) for 72 hours post-DBA with no internal forced air recirculation or cooling.

Technical Specification 3.7.2 "CRHAVS"

LCO 3.7.2 ensures that CRHA

- <u>Average</u> air temperatures will be maintained within acceptable limits for 72 hours following an event that includes loss of CRHAVS cooling, and
- Heat sink bulk <u>average</u> temperatures are within design-basis analysis assumptions.
- LCO 3.7.2 bases state that the CRHA heat sinks are operable when the air and heat sinks in the CRHA and adjacent spaces are maintained within the <u>average</u> temperature limits of SR 3.7.2.1.
- LCO 3.7.2 Required Action A.2 requires restoring the bulk <u>average</u> temperature of <u>each</u> CRHA heat sink to within limits within 24 hours.
 - The 24-hour Completion Time is based on engineering judgment. Staff considers that 24 hours is reasonable and consistent with staff analysis.
 - Restoration of CRHA heat sink bulk <u>average</u> temperatures to within limits may be verified by
 - administrative evaluation considering the duration and extent of the CRHA average air temperature excursion outside limits, and/or
 - direct temperature measurement of CRHA heat sink structural materials.
 - Determination of CRHA heat sink bulk <u>average</u> temperatures is the subject of licensee procedures.

Ambient Design Temperature Site Parameters

		DB	96 °F
Exceedance	Max	MCWB	79 °F
		WB	81 °F
	Min	DB	-10 °F
1% Annual		DB	100 °F
Exceedance	Max	MCWB	79 °F
		WB	82 °F
	Min	DB	-10 °F
0%		DB	117 °F
Exceedance	Max	MCWB	80 °F
		WB	88 °F
	Min	DB	-40 °F
Max Avg DB for 0% Exceedance Max Temp Day			103.5 °F
Min Avg DB for 0% Exceedance Min Temp Day			-26.5 °F
Max HH Avg WBGT Index for 0% Exceedance Max WB Day			86.6 °F

Maximum Average Dry Bulb Temperature for 0% Exceedance Maximum Temperature Day

Site Parameter Value: 103.5 °F

- Defined as the average of:
 - 0% exceedance maximum dry bulb site parameter value of 117 °F
 - Dry bulb temperature resulting from a daily temperature range of 27 °F

Determining the Corresponding Site Characteristic Value:

- Defined as the average of:
 - Site-specific 0% exceedance maximum dry bulb
 - Dry bulb temperature that corresponds to the higher of the <u>two</u> lows <u>occurring within 24 hours</u> before and after the 0% exceedance maximum dry bulb

Verification of Related Site Characteristics Example Calculation #1

 Maximum Average Dry Bulb Temperature for 0% Exceedance Maximum Temperature Day: <u>93.5 °F</u>



Minimum Average Dry Bulb Temperature for 0% Exceedance Minimum Temperature Day

Site Parameter Value: <u>-26.5 °F</u>

- Defined as the average of:
 - 0% exceedance minimum dry bulb site parameter value of -40 °F
 - Dry bulb temperature resulting from a daily temperature range of 27 °F

Determining the Corresponding Site Characteristic Value:

- Defined as the average of:
 - Site-specific 0% exceedance minimum dry bulb
 - Dry bulb temperature that corresponds to the lower of the <u>two</u> highs <u>occurring within 24 hours</u> before and after the 0% exceedance minimum dry bulb

Verification of Related Site Characteristics Example Calculation #2

 Minimum Average Dry Bulb Temperature for 0% Exceedance Minimum Temperature Day: <u>-8.5 °F</u>



Maximum High Humidity Average Wet Bulb Globe Temperature Index for 0% Exceedance Maximum Wet Bulb Temperature Day

WBGT Index = 0.7×WB + 0.3×DB

Site Parameter Value: 86.6 °F

- Defined as the average of:
 - WBGT index for the 0% exceedance wet bulb site parameter value of 88 °F (and a concurrent dry bulb value of 92 °F)
 - WBGT index resulting from a high humidity diurnal dry bulb temperature swing of 8 °F (dry bulb temperature of 84 °F and concurrent wet bulb temperature of 84 °F)

Determining the Corresponding Site Characteristic Value:

- Defined as the average of:
 - WBGT index for the site-specific 0% exceedance wet bulb
 - WBGT index resulting from wet bulb temperature that corresponds to the highest of the six low wet bulb temperatures <u>occurring in each of the three 24-hour periods</u> before and after the 0% exceedance wet bulb

Verification of Related Site Characteristics Example Calculation #3 (sheet 1 of 3)

 Maximum High Humidity Average WBGT Index for 0% Exceedance Maximum Wet Bulb Temperature Day: <u>71.4 °F</u>



Verification of Related Site Characteristics Example Calculation #3 (sheet 2 of 3)

 Maximum High Humidity Average WBGT Index for 0% Exceedance Maximum Wet Bulb Temperature Day: <u>71.4 °F</u>



Verification of Related Site Characteristics Example Calculation #3 (sheet 3 of 3)

 Maximum High Humidity Average WBGT Index for 0% Exceedance Maximum Wet Bulb Temperature Day: <u>71.4 °F</u>



Verification of Related Site Characteristics Example Calculation #4 (Sheet 1 of 3)

 Maximum High Humidity Average WBGT Index for 0% Exceedance Maximum Wet Bulb Temperature Day: <u>82.2 °F</u>



Verification of Related Site Characteristics Example Calculation #4 (sheet 2 of 3)

 Maximum High Humidity Average WBGT Index for 0% Exceedance Maximum Wet Bulb Temperature Day: <u>82.2 °F</u>



Verification of Related Site Characteristics Example Calculation #4 (sheet 3 of 3)

 Maximum High Humidity Average WBGT Index for 0% Exceedance Maximum Wet Bulb Temperature Day: <u>82.2 °F</u>



Assurance of RB Heat Up Analysis Assumptions

- Staff reviewed the need for a reactor building heat sink temperature LCO similar to control building heat sink temperature LCO 3.7.2, "CRHAVS"
 - CRHAVS meets LCO criterion 3; its passive cooling function depends on heat sink initial temperatures and is part of primary success path for DBA mitigation by supporting CR habitability required by GDC 19
- 1988 letter from NRR to Owners Groups (OGs) ("Split Report") Staff's review of the BWROG's LTR regarding the application of the LCO criteria of the 1987 Commission Interim Policy Statement on TS improvements to the

BWR4 custom TS (Hatch 1) and standard TS (Hatch 2), and

BWR6 standard TS (Grand Gulf 1)

Staff agreed with relocation of LCOs for

- > ECCS and RCIC pump room air coolers from pilot plant custom TS (Hatch 1)
- > Area temperature monitors from pilot plant standard TS (Grand Gulf 1).

• Purpose of these LCOs was to maintain equipment qualification (§50.49)

- LCOs should not duplicate regulations;
- Improved STS do not include LCOs on monitoring instrumentation except for post-accident monitoring; area temperature monitors are not in primary success path for accident mitigation and are not used to detect degradation of reactor coolant pressure boundary; equipment room temperatures are not initial conditions for any DBA

OPERABILITY definition → necessary support system functions

- RIS 2005-20, Rev. 1; operability assessment of degraded or nonconforming equipment
- EQ is one factor in determining equipment operability

• Conclusion: §50.36 requires no LCO for reactor building heat sink temperatures