

Official Transcript of Proceedings
NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards
Westinghouse AP1000 DCD: Open Session

Docket Number: (n/a)

Location: Rockville, Maryland

Date: Wednesday, December 1, 2010

Work Order No.: NRC-576

Pages 1-115

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1323 Rhode Island Avenue, N.W.
Washington, D.C. 20005
(202) 234-4433

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, as reported herein, is a record of the discussions recorded at the meeting.

This transcript has not been reviewed, corrected, and edited, and it may contain inaccuracies.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 UNITED STATES OF AMERICA

2 NUCLEAR REGULATORY COMMISSION

3 + + + + +

4 ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

5 (ACRS)

6 + + + + +

7 SUBCOMMITTEE ON THE WESTINGHOUSE AP1000 DCD

8 + + + + +

9 WEDNESDAY

10 DECEMBER 1, 2010

11 + + + + +

12 ROCKVILLE, MARYLAND

13 + + + + +

14 The Subcommittee met at the Nuclear
15 Regulatory Commission, Two White Flint North, Room
16 T2B1, 11545 Rockville Pike, at 8:30 a.m., Harold B.
17 Ray, Subcommittee Chairman, presiding.

18 COMMITTEE MEMBERS:

19 HAROLD B. RAY, Subcommittee Chairman

20 SAID ABDEL-KHALIK, ACRS Chairman

21 J. SAM ARMIJO, ACRS Vice Chairman

22 SANJOY BANERJEE, Member

23 MARIO V. BONACA, Member

24 DENNIS C. BLEY, Member

25 CHARLES H. BROWN, JR., Member

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 COMMITTEE MEMBERS (continued):

2 MICHAEL CORRADINI, Member

3 DANA A. POWERS, Member

4 HAROLD B. RAY, Member

5 JOY REMPE, Member

6 MICHAEL T. RYAN, Member

7 WILLIAM J. SHACK, Member

8 JOHN D. SIEBER, Member

9 THOMAS S. KRESS, Consultant

10 GRAHAM B. WALLIS, Consultant

11
12 ACRS STAFF PRESENT:

13 WEIDONG WANG

14 PETER C. WEN
15
16
17
18
19
20
21
22
23
24
25**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

C O N T E N T S

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

ITEM	PAGE
Opening Remarks and Objectives	
Chairman Ray.....	4
NRC Feedback on Tier*	
for chapter 3 and item 72.....	8
Eileen McKenna	
Other Action items (4, 10, 55, 73,	
status re 65 and 71 documents)	
Rob Sisk.....	19
Closing Remarks.....	113

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

P R O C E E D I N G S

[8:31 a.m.]

CHAIRMAN RAY: The meeting will now come to order. This is a well-attended meeting of the AP1000 Reactor Subcommittee, a standing subcommittee to the Advisory Committee on Reactor Safeguards. I'm Harold Ray, chairman of the subcommittee.

ACRS members in attendance are Jack Sieber, Sanjoy Banerjee, Sam Armijo, Dana Powers, Said Abdel-Khalik, Michael Ryan, Bill Shack, Charles Brown, Joy Rempe, and Mario Bonaca. We've got a chair here for Member Corradini, but we just received word, he's "snowed in" in Detroit. So we will see if he joins us, or not.

MEMBER POWERS: Or so he says.

CHAIRMAN RAY: This meeting is a part of the--well, excuse me. Tom Kress and Graham Wallis are also present, consultants to the committee, and Weidong Wang is the designated federal official for this meeting.

This meeting is a part of the ongoing review of the proposed amendment to AP1000 Pressurized Water Reactor Design Control Document, and it is also going to review matters associated with long-term tooling, or GSI-191. We have two

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 items, really, running in parallel here, with the
2 goal, and it remains just a goal at this point, that
3 we would be able to complete subcommittee review on
4 both matters, GSI-191 and the amendment, in advance
5 of the discussion of the Full Committee later this
6 week.

7 We previously had 11 meetings totaling 21
8 meeting days, and I won't recite when they all
9 occurred. They're a matter of the record.

10 This AP1000 subcommittee meeting will
11 continue to review the safety evaluation reports on
12 Revision 17 of the AP1000 DCD, and we'll discuss, as
13 I said, also GSI-191 and follow-up items that the
14 subcommittee has been tracking.

15 We will hear presentations from the DCD
16 Applicant, Westinghouse, and the NRC staff. We have
17 received no written comments, or requests for time to
18 make oral statements from members of the public
19 regarding today's meeting.

20 As shown on the agenda--and let me hasten
21 to say don't get optimistic about the timeline shown
22 on the agenda. The reality is that we will spend all
23 the time that is available to discuss any matters
24 that members wish to discuss, until it gets too late
25 to continue, if that should be required. So the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 agenda is simply an order of presentation and not a
2 timeline that we necessarily need to adhere to.

3 Some presentations will be closed in
4 order to discuss information that is proprietary to
5 the Applicant and its contractors, pursuant to 5 U.S.
6 Code 552BC3 and 4. Attendance at this portion of the
7 meeting dealing with such information will be limited
8 to Westinghouse representatives, the NRC staff, and
9 its consultants, and those individuals and
10 organizations that have entered into appropriate
11 confidentiality agreements with them.

12 Consequently, we need to confirm that we
13 have only eligible observers and participants in the
14 room for the closed portion, or portions.

15 The subcommittee will gather information,
16 analyze relevant issues and facts, and formulate
17 proposed positions, and actions, as appropriate, for
18 deliberation by the Full Committee. The rules for
19 participation in today's meeting have been announced
20 as part of the notice previously published in the
21 Federal Register. A transcript of the meeting is
22 being kept. It will be made available as stated in
23 the Federal Register notice. Therefore, we request
24 that participant sin the meeting use the microphones
25 located throughout the meeting room when addressing

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the subcommittee.

2 The participants should first identify
3 themselves, and speak with sufficient clarity and
4 volume, so that they may be readily heard.

5 We will now proceed with the meeting, and
6 somewhat unusually, I guess Eileen, you're going to
7 start.

8 MS. MCKENNA: Yes. Actually, I do have
9 one slight adjustment to the agenda. We have a topic
10 on the action item, I believe it's 72, which has to
11 do with some of the I&C issues. We'd like to do
12 that, kind of as the last agenda topic rather than
13 the first agenda topic.

14 CHAIRMAN RAY: Okay.

15 MS. MCKENNA: If that's acceptable. And
16 yes, at this point we would start with the other part
17 of that box, which was some feedback on the Tier 2*
18 information with respect to the seismic structural
19 material. We had some discussion about this at one
20 of our last meetings, and we think we may have left a
21 false impression about where we were with this
22 review, and, you know, our understanding of how the
23 information is going to be captured in the Design
24 Control Document, to move forward as the licensing
25 basis for the COL.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 So I did want to spend a few moments to
2 speak to that topic.

3 CHAIRMAN RAY: Indeed. And I would just
4 say, and urge everybody to take the time required to
5 ensure we've got all the information that should be
6 exchanged, and that there's nothing left open that we
7 could address, if we were to give the time to it. So
8 go ahead.

9 MS. MCKENNA: Okay. I just have a couple
10 of slides, just to kind a walk us through--

11 CHAIRMAN RAY: You're going to speak from
12 over there, Eileen?

13 MS. MCKENNA: I can, or if you want up
14 front--whichever you prefer.

15 CHAIRMAN RAY: Well, I think it'd be more
16 convenient for the members if you--

17 MS. MCKENNA: Okay. I will come up
18 front. And I may have neglected to send slides to
19 the computer, so--

20 CHAIRMAN RAY: We'll follow along. Just
21 tell us what page you're on.

22 MS. MCKENNA: I apologize for that. So
23 what I wanted to do was, is that we talked at the
24 last meeting, we were talking the shield building,
25 and there was some question about how is all this

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 wonderful information on the shield building going to
2 be included in the Design Control Document, and what
3 assurance do we have that the design that has been
4 proposed is the design that's actually built.

5 So I thought it would be worth spending a
6 few minutes to talk about how some of the
7 information, structural matters, as captured in the
8 Design Control Document. And in order to do that, I
9 want to take you back, first, to Rev 15, which had a
10 lot of information about seismic and structural
11 analysis, and it was embodied in the DCD, in various
12 parts of the document, including--there is a section
13 in Tier 1 that's called Buildings, and it's--Tier 1
14 is part of the rule itself, and can only be changed
15 as a rule or an exemption.

16 So in that particular part of the DCD,
17 has information about buildings, and I listed some of
18 the types of information that appear in Section 33.

19 CHAIRMAN RAY: Are you on page three?

20 MS. MCKENNA: I'm on page three of the
21 slides. Yes; sorry. That's the design basis loads,
22 the key dimensions, identification of the particular
23 critical sections, like a dozen particular locations
24 in shield building and aux building that are
25 considered to be the most important with respect to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the design, and have some of the more challenging
2 structural components to them, and some of the
3 figures about what these sections look like.

4 And then, in addition to that, there is
5 Tier 2 designation on Other Material, and as you
6 recall, the Tier 2* designation means that prior NRC
7 approval is needed for any change to that
8 information. And there was information in Section
9 37, which is on seismic design, 38 which is the--of
10 the analysis, appendix 3H, with regard to Critical
11 Sections are included, and it has this designation on
12 some of the descriptions of what those buildings, and
13 walls, and features look like.

14 The criteria of No. 4 says "plate
15 thicknesses and stress results," and that was all
16 part of Rev 15. And then in the rule, Appendix D,
17 those are then captured through these, what are
18 listed on page four. These are specific line items
19 in the rule, that are designated as Tier 2*, and see,
20 I've listed these right out of the rule, or in the
21 seismic arena.

22 So that brings us, then, to the next
23 slide, to, okay, where are we now, that we're in to
24 17, and soon eighteen? I'm aware of the reanalysis
25 done for the change, to broaden the range of soil

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 conditions, and, you know, so there's a lot of new
2 analysis, and there were design changes, and most
3 visibly, obviously, the new shield building.

4 And so therefore, the details, the Tier 2
5 information, and the Tier 1, that was in the DCD
6 originally, needs to be brought up to date to reflect
7 that.

8 What happened as we were going through
9 the review was, there were periods of time where
10 Westinghouse proposed to remove certain Tier 2*
11 information and the staff questioned why were they
12 proposing to do that.

13 And what it came down to was that there
14 were things like stress results, that had been marked
15 as Tier 2*, and kind of a realization that well, did
16 we really want to see every change to some stress
17 result for one particular piece of the building, that
18 seemed, maybe, overly restrictive level of control,
19 when you don't have the final design drawings to go
20 right into construction.

21 So we kind a took another look at what
22 was Tier 2* and what wasn't, and we did agree that we
23 still wanted things like the loads, acceptance
24 criteria, plate thicknesses, that kind of information
25 to remain as Tier 2*, but that other material perhaps

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 could be left at Tier 2, or not even necessarily be
2 displayed in the DCD at all, if it's too fine a level
3 of detail.

4 So in the course of our interactions, and
5 submittal of the Shield Building Report, we did get
6 proposed markups to the DCD from Westinghouse, to
7 reflect the changes that they had made, and what
8 information would be Tier 2*, moving forward.

9 So that brings me, then, to my slide six,
10 which--this is where I think our discussion may have
11 got us a little off-track--is as you're aware,
12 initially, we're looking at material that's presented
13 in technical reports, that it would provide a lot of
14 background and discussion, and rationale, and
15 analysis, and different things to support DCD
16 markups. And staff was really focusing on that body
17 of information, and we really hadn't "zoned in" on
18 exactly what were the DCD markups that would go along
19 with that, until fairly late in the game, and I think
20 we are in general agreement about what type of
21 information needs to be Tier 2*, critical sections,
22 things like reinforcement thicknesses, but not to
23 have to capture the stress results.

24 So we have Westinghouse's proposals. I
25 think I would say we're doing a fine-tuning look, to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 make sure that we agree that what they--everything
2 they've marked as Tier 2* is right, and that they
3 haven't left something out, or that there's not
4 something that--some wording about something, even as
5 Tier 2, that we think could be improved, and we are
6 going to be doing that in the near future.

7 In fact, we have plans to go, next week,
8 look in detail at drawings and other information, to
9 make sure that we're satisfied that everything that
10 needs to be in the DCD is in there, and in
11 appropriate fashion.

12 And if there are any changes that are
13 necessary, or as a result of that final look, it
14 would be reflected in a future revision. We don't
15 think this is---it's a big possible delta, but, you
16 know, we are open to the possibility that if that's
17 necessary, we will do that.

18 The last slide I just had was, I think
19 was--we talked about this last time, a little bit,
20 about, well, okay, it's good to get all that stuff in
21 the DCD, but then what happens, moving forward.

22 And so I just highlighted, you know,
23 NRC's oversight doesn't stop with getting information
24 into the DCD. The COLs have processes that they have
25 to follow, if they make changes, moving forward

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 during the construction process, that includes
2 departure reports. They are required to submit
3 reports to the NRC every six months, of any
4 departures they make to the DCD.

5 There are certain departures where they
6 would still need to get approval, if it was, for
7 example, Tier 2*. So there is that kind of oversight
8 that would occur. And then on the inspection side of
9 the house, there's a range of inspection activities
10 that would be overseeing the construction and any
11 changes that occur.

12 One thing that's kind of a near-term
13 thing, I think, is this engineering design
14 verification inspection. There have been some
15 discussions about performing one of those--I don't
16 know the exact time, but relatively soon. What this
17 does is it takes, looks at--I think they call it the
18 Design Authority--in this case, presumably
19 Westinghouse or some of their supporting partners--to
20 see how this DCD FSAR-like information has been moved
21 forward into the detailed engineering drawings and
22 construction material, procurement documents, so that
23 you do get the design being implemented, that you
24 think is the design that you have approved, and
25 obviously, there's the other two major parts of that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 oversight during construction, being the construction
2 inspection and the ITAAC inspections.

3 So I hope I've clarified a little bit
4 where we are with the DCD review, the Tier 2*
5 information, and why we believe that the appropriate
6 information is going to be in the licensing documents
7 and control implementation in the future.

8 CHAIRMAN RAY: That is responsive, I
9 think, at least to my perception of what we were
10 talking about, Eileen. It is difficult, when
11 questions that the committee feels are important, get
12 satisfactory and responsive answers. But then you
13 wonder, as you said at the beginning, how do we know
14 this is the way it's going to actually turn out,
15 since they aren't telling us what is actually, at the
16 moment, incorporated in the application that we're
17 reviewing? That's still, as you said, a work in
18 progress.

19 And you've given us, I think, a
20 responsive answer to that question. I guess I would
21 only say that it is important to make sure that when
22 we rely on something as the basis of reaching a
23 judgment, that there be some way to ensure that
24 that's what actually is done.

25 MS. MCKENNA: Yes. Two things. One is,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 as I said, these markups were submitted with the--
2 either an RAI response or an open item response. So
3 we have a specific document from Westinghouse saying
4 this is what we're going to put in Rev 18 on these
5 sections. And we will be receiving Rev 18, I believe
6 today, thereabouts, and then we can go check for
7 ourselves, that it's all in there, just the way they
8 proposed to include it, and that we are satisfied
9 with what it looks like.

10 CHAIRMAN RAY: Yes. And we are in a
11 position of relying on you to that, because of course
12 we don't have the visibility to these "moving parts"
13 as they--

14 MS. MCKENNA: Yes. I mean, it's
15 challenging, I think, for anyone to take, you know,
16 three or four different RAI responses, and look
17 through all the different pages, and make sure that
18 everything's in there. And that's what we are doing,
19 and we hope, and we think that we are very close on
20 agreement.

21 ACRS VICE CHAIRMAN ARMIJO: Eileen, along
22 those lines, the materials construction of the plant,
23 those are Tier 2 in the tables that I've seen.

24 MS. MCKENNA: Generally, that's correct;
25 yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 ACRS VICE CHAIRMAN ARMIJO: Yes. And
2 this is, in some cases there's some changes from Rev
3 15 to the current rev, in, let's say the piping
4 material--

5 MS. MCKENNA: Correct. Right.

6 ACRS VICE CHAIRMAN ARMIJO: --going from
7 a low carbon nuke grade, nuclear grade, to
8 conventional type 304, type 316, and maybe to some
9 it's not a problem; but it is to me.

10 But let's say everybody was happen with
11 the choice. It could be changed at Westinghouse's
12 discretion, and they do a 5059 type thing and let you
13 know that they've done it; but they don't need your
14 approval. Is that correct?

15 MS. MCKENNA: Well, the one who'd be
16 doing that 5059 review would be the COL. Now it may
17 be that Westinghouse--

18 ACRS VICE CHAIRMAN ARMIJO: Well, whoever
19 does it; right.

20 MS. MCKENNA: --is proposing it on their
21 behalf, but it would be the COL who would undertake
22 that process, and they still have to satisfy
23 themselves that they meet applicable requirements,
24 whether it's codes that might be in play, acceptance
25 criteria, information that's in the DCD, and then if

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 they decide that yea, verily, they think that it is a
2 satisfactory material, they would then do the 5059
3 review, and either determine that it could be made
4 without a prior approval, or not.

5 But even if they made it without the
6 prior approval, they do have the reporting
7 requirement in the departures report. So there is a
8 means for the NRC to be aware of it, albeit after the
9 fact, but it's still--and there are records that have
10 to be kept.

11 So in that sense, it's no different than
12 an operating plant that--

13 ACRS VICE CHAIRMAN ARMIJO: No, I
14 understand that, and the practice of having material
15 specifications as Tier 2, it's been throughout the
16 process, so--

17 MS. MCKENNA: Right. Exactly. Yes.
18 Right.

19 ACRS VICE CHAIRMAN ARMIJO: --I don't
20 want to say, well, we shouldn't do it that way. But
21 I'm just--it makes me worry about material changes,
22 particularly where they're sensitive to some
23 environmental effects, could be changed with--well,
24 certainly, without your approval.

25 MS. MCKENNA: It could be done. Again,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 it depends on what the change is.

2 ACRS VICE CHAIRMAN ARMIJO: And we've got
3 to just realize that.

4 MS. MCKENNA: You're correct.

5 ACRS VICE CHAIRMAN ARMIJO: Okay.

6 CHAIRMAN RAY: Any other comments or
7 questions for Eileen?

8 [No response]

9 CHAIRMAN RAY: Thank you.

10 MS. MCKENNA: Okay. I think next, we
11 have some Westinghouse presentations on--

12 CHAIRMAN RAY: Yes.

13 MS. MCKENNA: --various open items. Or
14 action items.

15 CHAIRMAN RAY: Yes. We do. We have a
16 collection of action items that we'll try and resolve
17 on. I don't believe there's any particular pattern,
18 except that these still have some outstanding aspect
19 to them. So Rob.

20 MR. SISK: Thank you, Mr. Chairman.

21 I beg the committee's indulgence. We're
22 going to have a parade of different people coming up
23 on different topics. The first topic we're going to
24 talk about is flywheel material, and I'm going to ask
25 our subject matter experts to come to the front of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the room here.

2 CHAIRMAN RAY: Yes. We talked before, at
3 length. Okay. Who will introduce the topic?

4 MR. MELTON: Yes, sir. I will do it.
5 Mike Melton, Westinghouse licensee. I'd like to
6 introduce Dr. Gutti Rao, one of our senior colleagues
7 in metallurgy, and you've seen Dale Wiseman before,
8 for the *... and pump discussions.

9 Essentially what we're going to do this
10 morning is go through the action items, to the point
11 where we can get to agreement on closure. We're
12 going to cover actions 4, 10, 55, and 73. I think
13 the only one that is probably closed, in this
14 particular success, is ten. So we'd like to take the
15 action 10 and move that to the last of the actions we
16 talk about.

17 On the action number 4, on the flywheel,
18 I think we have scoured, looking for more
19 information, we've done a little bit of work, but
20 essentially we're at the point where--

21 CHAIRMAN RAY: Excuse me, Mike. Do we
22 have handout copies of what you'll be presenting?

23 MR. MELTON: Yes; yes. We're making
24 copies. We have just one talking point slide and
25 this is it.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN RAY: All right. But for our
2 sanity, you'll give us a hard copy? Okay.

3 MR. MELTON: Yes, sir. Essentially, I
4 think as we left the last actions, it was to--sam, I
5 thought was going to look at some of the previous
6 Westinghouse presentations.

7 I wanted to get Dr. Rao here to make a
8 few points about the material. Essentially the 18
9 manganese, 18 chromium steel, is essentially a
10 secondary side material. However, we did do some
11 more research on the grain structures and materials,
12 and I thought we could speak to that, just a little
13 bit.

14 DR. RAO: Yes. I know some of this has
15 been discussed before, but I want to bring in, very
16 briefly, just a concern that the likely, unlikely
17 event of catastrophic failure of the *8:54 [Believe
18 he is talking about *"welds" or *"valves???" also, at
19 times?] repainted ring material, which is *..., and
20 in item 32, that the breaching of the 625 material,
21 and then susceptibility of the 18, 18 material. So I
22 would want to briefly touch upon the potential for
23 breaching of the 625 base material and weld, as well
24 as the susceptibility of 18, 18.

25 And then we can discuss more on 18, 18,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 why, whether we need original boric acid corrosion
2 expo--test corrosion data to establish its *8:55...
3 for failure.

4 Now 625 is a material, it's been
5 developed, many of you know, a alternate to 690 from
6 600, and probably 625, as far as the base material is
7 concerned, it is a process of corrosion *8:55... and
8 it has molybdenum in it, there's a lot of test data
9 and so there's experience with that. And the
10 bridging of the 625, the concern expressed about
11 *valves, is more likely locations.

12 The valves themselves are 625, which are
13 much more experienced than 690 valves, even, 52-150.

14 Sixty--625 is--*durability is good, it has a high
15 resistance to *NIL... ductility cracking. So the
16 8:56*... reasonably good confidence and experience
17 with the 625 valves.

18 As far as the base material, it is
19 designed for a process of corrosion resistance. It
20 has molybdenum in it, and its pitting resistance is
21 pretty high, much significantly higher than 316.
22 There's a lot of data in there.

23 So in the unlikely event of any breaching
24 in 625, now we've got to the point of 18, 18
25 material, which is basically cobalt to higher

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 strength level--but the important thing here is 18,
2 18 is 18 manganese, primarily is a gamma stabilizer.

3 It's a austenitic phase stabilizer, and basically we
4 have like 316 or 304, as far as corrosion of boric
5 acid exposure.

6 ACRS VICE CHAIRMAN ARMIJO: Mike, I'm not
7 talking about boric acid. I'm talking about PWR
8 water chemistry.

9 MR. MELTON: Yes.

10 DR. RAO: PWR chemistry. Our experience-
11 -we have been using austenitic materials as a
12 protective layer for carbon seal corrosion. All the
13 austenitic materials, as cladding or *8:57 roll
14 bonding, whatever, and we have extensive experience
15 to show that austenitic materials are a good
16 protector, are highly resistant for boric acid
17 corrosion.

18 So we expect 18, 18, since it is a gamma
19 stabilizer, is an austenitic material basically,
20 similarly to 316 or 304, with the exception that it
21 has much higher *8:57:45 corrosion resistance for
22 *products and nitrites. So it is superior for such
23 corrosion cracking resistance, and it at least has
24 same corrosion, boric acid corrosion resistant
25 property. When I said boric acid, I mean primary

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 water.

2 And in the unlikely--the only corrosion,
3 really, concern for 18, 18, a lot of data developed
4 is in the areas of contaminants beyond the spec
5 limits. So we have test data to show hundreds of
6 ppms of chlorides and nitrites, exposed to the 18, 18
7 material, and that show that it is immune for such
8 corrosion cracking.

9 ACRS VICE CHAIRMAN ARMIJO: That's my
10 fundamental problem, is all of this data is at
11 boiling water temperature or less. We found no data--
12 they put it in. You know, all the qualification
13 testing has been done on retainer rings on
14 generators, and the generator environment is
15 extremely mild compared to the PWR coolant
16 environment.

17 MEMBER SHACK: Lower temperature.

18 ACRS VICE CHAIRMAN ARMIJO: It's much
19 lower temperature, okay, and it's just moisture,
20 Bill. It's not primary water--

21 MEMBER SHACK: But it's oxygenated.

22 ACRS VICE CHAIRMAN ARMIJO: Yes. Well,
23 it is--you've just--I'll give you an example, and
24 this is from personal experience. When the boiling
25 water reactor stainless steel pipe cracking phenomena

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 started, and I was part of the team that had to sort
2 that out, we had been testing, for many years, of BWR
3 welded piping type 304, in big loops. High
4 temperature, high purity water. Unfortunately,
5 nothing cracked in the test tubes, even though we
6 thought it was prototypic, until it started cracking
7 in the field, and then we realized that there's more
8 to the water that comes--that makes it oxide, comes
9 from the core. So just tiny amounts of oxygen and
10 oxidizing species turned a benign environment into a
11 very severe environment.

12 So unless you test in prototypic
13 environments, you don't have a clue, that this
14 material is going to be resistant, and if you don't
15 test, if you can't inspect it, I don't see how you
16 can--you know, if you can't inspect to assure that
17 your 625 can is hermetic, then you must assume that
18 in a 60-year-life, or well before you have to look at
19 this vessel, you must ensure that if it fails,
20 something--that the 18, 18 is going to be resistant,
21 and you have the test methods available.

22 Westinghouse has crack growth test
23 facilities, crack initiation test.

24 These are very standard. You don't have
25 to invent a test.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 DR. RAO: Right.

2 ACRS VICE CHAIRMAN ARMIJO: So I'm
3 puzzled why you keep referring to this set of data in
4 other, in my opinion, irrelevant environments. Sure,
5 it says, hey, it might work. And it might. I'm not
6 saying it won't work. But you can't be sure unless
7 you test it, and that's where I have a big hang-up--

8 DR. RAO: I understand that. I
9 appreciate your point. I mean, if you look at the
10 BWR experience at 9:01:16 *.. dation and the residual
11 *.., it's only related to the weld. If you don't
12 have sensitization, you don't have problem. But all
13 the problems are because after the situation, we well
14 understand what's happening there.

15 In this case, it is an austenitic
16 material, and--

17 ACRS VICE CHAIRMAN ARMIJO: But--

18 DR. RAO: It is nothing, but it's
19 austenitic material--

20 ACRS VICE CHAIRMAN ARMIJO: Oh, we failed
21 so many austenitic materials, both in BWRs and PWRs.

22 So austenitic material doesn't mean anything, unless
23 it's a specific one, or if you have good experience.

24 I don't think you have any experience of 18 chrome,
25 18 manganese steel, in any application in a BWR, or a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 PWR, particularly in a high-stress component like
2 this.

3 MR. ZIESING: Mr. Armijo, this is Rolf
4 Ziesing, director of licensing, Westinghouse. We
5 believe that we've evaluated these materials, and
6 based on the evaluation, there's a low risk of SEC,
7 based on our engineering judgment. But you do raise
8 a valid and reasonable question, and Westinghouse is
9 committed to addressing this question.

10 We are developing a test perspective and
11 we will do some validation testing to evaluate the
12 SEC resistance to this material. We just--obviously,
13 it takes time to do that, so we don't have the
14 results available; but we will commit to do that.

15 ACRS VICE CHAIRMAN ARMIJO: Well you
16 know, that's great, you know, that's--I appreciate
17 that, because I know you know how to do it. And we
18 do it all the time. You know, if this thing was
19 inspectable, and I agree that it's very impractical
20 to try and inspect that outer cannon, and that's the
21 only thing that would have to be inspected for
22 hermeticity. You wouldn't have to take apart the
23 rotor. You just have to be able to make sure that
24 those welds aren't leaking.

25 If you could do that, routine--you know,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 periodically, then you're assured that the rotor will
2 never see the environment, not--and it's just a
3 straight mechanical design.

4 DR. RAO: Right.

5 ACRS VICE CHAIRMAN ARMIJO: But unless
6 you can inspect it, you have to be sure that if it
7 leaks you don't have a violent failure of your
8 flywheel in triggering all the lock rotor issues that
9 you analyze in chapter 15, and I think putting
10 enormous stress on that heat exchanger that's hanging
11 on the outside of that pump.

12 Those are the issues that I think are
13 safety issues, as well as investment protection
14 issues, and I appreciate that Westinghouse is going
15 to do some testing on this material.

16 DR. RAO: Yes. We have established a
17 preliminary test matrix, and we were just--want to
18 review, briefly, the likelihood of such a thing
19 happening. We believe it is very--highly low
20 probability, but--

21 ACRS VICE CHAIRMAN ARMIJO: And it should
22 be. You know. And I would expect you have done
23 everything to say what's the best choice of
24 materials. Because you've been changing materials
25 over the past several years. Stainless steel to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 *MAR-aging steels for that application.

2 But the ultimate test is how it performs
3 in the environment, and if you perform those tests,
4 my mind is really put at ease.

5 CHAIRMAN RAY: I think that the first
6 three bullets up there are ones that, absent what has
7 just been said, we would have to delve into and
8 discuss further.

9 But I understand Sam's response to be,
10 and certainly it would be my less expert opinion,
11 that if the failure probability could be shown, to
12 distress corrosion cracking, to be sufficiently low,
13 then I doubt we need to debate the safety issues of
14 flywheel failure, or am I wrong?

15 ACRS VICE CHAIRMAN ARMIJO: I'm
16 convinced, if Westinghouse does tests, and they know
17 how to perform these tests, and they do it in a
18 prototypical environment, and either crack growth
19 threat tests, or crack initiation tests--and you
20 should do both--and you conclude that, hey, this
21 stuff is really as good as we thought, I'm happy.

22 But if you find out it isn't so good,
23 you're going to have to do some sort of design
24 change.

25 DR. RAO: We agree. I mean--

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 ACRS VICE CHAIRMAN ARMIJO: You know, at
2 this point, it would be--you know, you know what to
3 do. But just not testing is what drove me--

4 CHAIRMAN RAY: Well, I think--I'm just
5 focused back on these first three bullets. I think
6 they accurately state what the state of the
7 application is. It's just that if we couldn't get
8 that kind of assurance, they're going to get a lot
9 more discussion, because there are differing views on
10 that, and--

11 ACRS VICE CHAIRMAN ARMIJO: For example,
12 in chapter 15, the lock rotor analysis is really the
13 worst case situation. That's the only event
14 associated with a pump, that can give you an off-site
15 dose. And granted, it's identified as sort of a
16 nonmechanistic failure. I think, like the flywheel
17 coming apart and acting like a giant break, could get
18 you into a lot lock rotor event. I can't prove it;
19 but it'd be hard to disprove it. So--

20 CONSULTANT KRESS: I don't see how you do
21 a risk acceptance without initiating again frequency.

22 ACRS VICE CHAIRMAN ARMIJO: Yes, and that
23 means something's got to break.

24 CONSULTANT KRESS: Yes.

25 CHAIRMAN RAY: So we need to get

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 assurance that the flywheel's not going to fail if
2 it's subjected to *rapid cooling.

3 ACRS VICE CHAIRMAN ARMIJO: That's it.

4 CHAIRMAN RAY: And that seems like
5 something that would pretty well be in everyone's
6 interest to do, and it's very helpful to understand
7 that it's your intent to do it.

8 Do you folks have other things that you'd
9 like to say? We'll be glad to hear them.

10 MEMBER SHACK: Are you testing alternate
11 materials, just in case this doesn't work?

12 MR. CUMMINS: This is Ed Cummins. That's
13 not part of our current plan.

14 ACRS VICE CHAIRMAN ARMIJO: It's always
15 good to have a backup.

16 MEMBER SHACK: That's an engineering
17 issue.

18 CHAIRMAN RAY: At this point it would--
19 I'd just expect to see that we would rely upon
20 satisfactory test results in reaching our conclusion.

21 DR. RAO: 9:07:47* didn't speak to that.

22 A better material, the 18, 4, which has been used in
23 retainer rings, that work has been done, to compare
24 and include the susceptibility, resistance for
25 cracking. The 18, 18, apparently the best sort of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 material for--

2 ACRS VICE CHAIRMAN ARMIJO: Yes. You
3 know, I think the retainer ring issue I think makes a
4 good point. The retainer rings in the generators,
5 using the high manganese steel, the original 18
6 manganese 5 chrome,--

7 DR. RAO: 5 chrome.

8 ACRS VICE CHAIRMAN ARMIJO: --failed
9 miserably by intergranular stress corrosion cracking,
10 because they didn't do much of a test program on it.

11 After those failures, they did an extensive testing
12 to qualify the 18 chrome, 18 manganese, and they
13 tested not only in their prototypic environment but
14 also more aggressive. They added nitrites,
15 chromates--you name it.

16 And that material has worked beautifully,
17 because it's been tested and qualified. And that's
18 really my point. A similar approach should be taken
19 for your retainer ring.

20 DR. RAO: Yes. Only my point is the only
21 reason we don't have the primary water testing of
22 this material is because of the experience we have
23 with 304 and 316 in primary environment, and this is
24 supposed to be held similar, because an austenitic
25 *9:09:08 stabilized stainless steel, it's superior

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 stress corrosion than 316 and 304.

2 I just want to make that point. We
3 understand, we don't have data and we do have every
4 reason to expect we have better on 316 and 304, but
5 if we should have data in the back pocket to support
6 that, we do need to do some tests.

7 CHAIRMAN RAY: We appreciate your
8 response to this concern.

9 Are we done with item four, then?
10 Anything else?

11 MR. MELTON: Yes. We're done with item
12 four.

13 CHAIRMAN RAY: You're done. I'm asking
14 if we're done.

15 [Laughter]

16 CHAIRMAN RAY: Okay. Thank you, and
17 we'll move on, and like I say, we'll make a comment
18 that we're relying on these test results being
19 satisfactory in reaching our conclusion. Thank you.

20 MR. MELTON: Okay. Our next subject is
21 action number 55, post-seismic testing, squib valves.

22 CHAIRMAN RAY: Okay. Is Mr. Brown in the
23 room here?

24 MEMBER BROWN: Oh, yes. Well, I wasn't
25 going to be--

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 [Laughter]

2 MEMBER BROWN: If I get up and leave,
3 you'll have to stop. Or you don't have to stop.

4 MEMBER SHACK: But you're going to get up
5 and leave?

6 MEMBER BROWN: Yes. I will get up and
7 leave; yes.

8 [Laughter]

9 MEMBER SHACK: Just coming back for a
10 second, Harold--

11 CHAIRMAN RAY: Yes, sir.

12 MEMBER SHACK: --on how we verify, in
13 fact, this is satisfactory. Do we expect the staff
14 to add an ITAAC, that this has to be satisfactory?
15 Or do we just sort of--you know, we have an ACRS
16 ITAAC that isn't really part of the staff ITAAC?

17 CHAIRMAN RAY: I'm not sure, Bill.
18 That's a fair question. I'm inclined, in the first
19 instance, to say what I indicated--recommend we say
20 what I indicated in the letter, which is we're
21 relying on that satisfactory test results, and then
22 to explore with staff what the answer to your
23 question is. I don't have an answer, right off the
24 top of my head .

25 MEMBER SHACK: Well, I sort of expected

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Eileen to say something.

2 MS. MCKENNA: Well, yes, I'm not sure an
3 ITAAC is necessarily the right way to include this.
4 I think we can--

5 ACRS VICE CHAIRMAN ARMIJO: What are the
6 alternatives?

7 MS. MCKENNA: --think about other ways
8 that--

9 ACRS VICE CHAIRMAN ARMIJO: Eileen.

10 MS. MCKENNA: Sorry?

11 ACRS VICE CHAIRMAN ARMIJO: What are the
12 options?

13 MS. MCKENNA: Well, it could be that we
14 ask that it be provided as a reference with--
15 obviously not Rev 18, because it's still on the table
16 now--but we are reasonably thinking that there's a
17 good likelihood would be the 19, for whatever reasons
18 that were out there, and it could be the document
19 that would be referenced--

20 ACRS VICE CHAIRMAN ARMIJO: Isn't there
21 some sort of an ITAAC on the pump itself, acceptance
22 testing, and all--

23 MS. MCKENNA: There certainly would be--

24 ACRS VICE CHAIRMAN ARMIJO: Could be sort
25 of a subpar--sentence within such an ITAAC that's--

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN RAY: Charlie--*audio static.

2 [Laughter]

3 ACRS VICE CHAIRMAN ARMIJO: I'm not
4 telling you how to do it, but, you know, we'd really
5 want assurance that it'd been done and it was done--

6 MS. MCKENNA: I understand that, and I
7 just would need to figure out the best way to get
8 that captured, given we don't have a test document,
9 or a plan, in hand, today. You know, we have a
10 commitment, but we need to capture that in some
11 appropriate fashion.

12 CHAIRMAN RAY: I have confidence, in the
13 first place, if it's committed, it'll be--

14 MR. CUMMINS: Well, I was going to say
15 that this will be a one-time thing, rather than for
16 each plant, and therefore it's more like a DAC than
17 an ITAAC. But DAC have also issues. And the other
18 way we make commitments, typically, is with COL open
19 items, and I think maybe the staff and the COL
20 applicants, and Westinghouse, need to get together
21 and discuss what the options are to have a
22 commitment.

23 CHAIRMAN RAY: Yes. This is a matter of
24 dotting i's and crossing the t's, but I have no doubt
25 that work will be done as they indicate. So we just

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 need to make sure we--

2 MS. MCKENNA: Yes. Where--I'm sorry to
3 interrupt.

4 CHAIRMAN RAY: No; that's all right.

5 MS. MCKENNA: You know, we need to talk
6 among ourselves and come up with an approach that we
7 think would meet the committee's needs, and that
8 would meet everybody else's needs. We understand the
9 issue, and we just need to figure out the best way to
10 implement it.

11 CHAIRMAN RAY: All right. Why don't you
12 proceed, slowly. Charlie will be back in a moment.

13 MR. MELTON: We're going to talk about
14 the materials. In our pre-job brief, I told everyone
15 that don't worry, if metallurgists are talking--you
16 know, we go right hand, left hand, a lot, and it
17 looks like we're arguing but we're really enjoying
18 ourselves, so--

19 [Laughter]

20 MR. MELTON: Talking about materials. We
21 have a good time, so don't get nervous about that.
22 Okay. This, as we wait for Charlie to get back, is
23 action item 55, a follow-up for the AP1000 squib
24 valve, and Ron is here, Wessel is here to help lead
25 our discussion on that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN RAY: You can begin. Charlie
2 will read fast.

3 MR. WESSEL: Good morning. We were here
4 two weeks ago, and Jerry Riegel, the valve design
5 engineer, presented a lot of information on the squib
6 valve, and to address the first two items that are on
7 this slide. Based on that presentation, that we
8 received a secondary inquiry from Charlie, that is
9 shown on the third bullet of the slide.

10 So that's what I'm here, really, to
11 discuss, is this third question here. I am capable
12 of going back and discussing some of the other
13 issues, if you so desire. But mainly, I'm here to
14 discuss the seismic testing that we're going to do on
15 the squib valve.

16 MEMBER BLEY: Okay. While we wait for
17 Charlie, I might just mention that I think his
18 concern isn't just with the squib itself, but it's
19 with the actual valve mechanism, knowing that nothing
20 has bound up inside it.

21 MR. WESSEL: Yes.

22 MEMBER BLEY: Not to speak for him.

23 [Laughter]

24 MR. WESSEL: I expect that same question
25 from Charlie, so it is really not in the slide. I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 want to discuss the testing that we are doing, and
2 why we're doing that testing. But I can also answer
3 further questions about the whole valve assembly
4 also. The seismic testing. In our opinion, there's
5 two critical areas for the squib valve to do a safety
6 relay in function. One is the actuator works upon
7 demand, and two, that the tension bolt that holds the
8 piston up--if you remember from the presentation two
9 weeks ago, there's a tension bolt that holds the
10 piston in the proper position, so the proper amount a
11 gas is built up prior to it breaking and sending the
12 piston down to shear of the cap of the valve.

13 So those are, really, the two critical
14 things. The tension bolt is critical, because if it
15 would break during a seismic event, the piston would
16 come down. There's not enough force on, with the
17 piston coming down to actuate the valve, but that
18 would make the valve inoperable. They would not be
19 able to build up the pressure, or required sheer, if
20 the valve was--if the piston was in the lower
21 position.

22 So we have developed testing for both of
23 those types of--

24 MEMBER BROWN: What was the first one?

25 MR. WESSEL: The first one is the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 actuator itself, the--

2 MEMBER BROWN: The charge?

3 MR. WESSEL: The propellants and the
4 charges, and everything. And the second point is to
5 make sure that tension bolt remains integrity--

6 MEMBER BROWN: I got that.

7 MR. WESSEL: --until it's needed to
8 break. So that is the critical parts of the squib
9 valve operation. The squib valve is very, really a
10 simple design. It has a piston, it has a tension
11 bolt, and that we had discussed two weeks ago, and it
12 comes down and shears off the cap. So it's a pretty
13 simple design.

14 But these are two of the critical things.
15 In the testing that we're going to do, to show those
16 work, is, first of all, is the actuator. We're going
17 to test the actuator portion of the squib valve.
18 We're going to do a full IEEE 323 harsh environmental
19 qualification program, based on Regulation Guide 189
20 and Regulation 10 CFR 5049, all the good testing
21 that's required to show that the actuator will
22 properly fire, on demand, to do its safety-related
23 function.

24 ACRS VICE CHAIRMAN ARMIJO: Could you
25 remind me of what you mean by actuator starting the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 charge, the tension bolt, the sliding thing, and the
2 cap comes--

3 MR. WESSEL: The actuator--what we call
4 the actuator in the squib valve program is the
5 initiator, which has the electrical wire bridge that
6 would shoot off, and inside the initiator also is a
7 small amount of pyrotechnical material. That the
8 initiator, the bridge wire will heat up, set off
9 that, which then will fire off the main propellant
10 that's contained in the cartridge.

11 ACRS VICE CHAIRMAN ARMIJO: Okay. Then
12 the tension bolt and the--

13 MR. WESSEL: The tension bolt is--

14 ACRS VICE CHAIRMAN ARMIJO: Part of the
15 actuator system?

16 MR. WESSEL: No. The tension bolt is
17 part of the valve system, and we maybe want to bring
18 that drawing up--

19 ACRS VICE CHAIRMAN ARMIJO: That's what I
20 didn't understand.

21 MR. WESSEL: --that's on the--it's on
22 here.

23 MEMBER BANERJEE: But when you do the
24 test, you set off the explosive, don't you?

25 MR. WESSEL: Yes; yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER BANERJEE: Because you don't break
2 the tension bolt, but you take it out, and--

3 MR. WESSEL: Right. The first, I'd like
4 to discuss, is the actuator portion, and I want to
5 get the picture up. It's not in that. Go in this
6 folder here. That's Jerry's old folder. I just
7 grabbed all his stuff, and if you get his
8 presentation that he had had.

9 This is from the presentation that Mr.
10 Riegel had before you.

11 So this is basically a 14-inch valve.
12 This is the tension bolt, here. The cartridge isn't
13 shown here, but it screws into this portion here, and
14 that would contain the cartridge, there's a steel
15 cartridge, and it's *9:21:26..., and then the
16 initiator screws into the top of the cartridge, and
17 then there's electrical connections that are made to
18 the top of that.

19 So when it fires as--how did Jerry get to
20 do this thing?

21 [Laughter]

22 MEMBER SHACK: It was pretty slick.

23 MR. WESSEL: Sorry.

24 MEMBER SHACK: You may have to--

25 MEMBER BANERJEE: You definitely should

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 show that to the Full Committee, the animation.

2 MR. WESSEL: I actually have a video, if
3 you'd like to see what are the prototype tests of
4 this valve going off.

5 MEMBER SHACK: That goes pretty fast.

6 MR. WESSEL: Yes; it does go very fast.

7 Mr. Scarbrough's been there to see some
8 of them go off.

9 MEMBER BANERJEE: It's already moved.

10 MR. WESSEL: Yes; yes.

11 MEMBER BLEY: Shears it.

12 MEMBER BROWN: Do it again.

13 MR. WESSEL: Okay. Here we go. Ready.
14 Go. Okay. So there it goes.

15 [Laughter]

16 MR. WESSEL: The fire--the pressure
17 builds up in this portion right here, the piston
18 moves down and it hits the shear cap, and the shear
19 cap breaks, and then the 14 inch, it has, it's on a
20 hinge, and it falls down, out of the way, to allow
21 full flow.

22 MEMBER BANERJEE: Now Charlie asked at
23 one point--I don't want to paraphrase--but the way I
24 understood it, that, you know, post-seismic, if
25 something goes a little bit out of kilter, you know,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 so it's not all perfectly lined up, then, you know,
2 how do you know that?

3 MR. WESSEL: Yes. We'll get into that.
4 That's really the third part, that I haven't slides,
5 but we can discuss that portion. We'll continue with
6 what testing we're going to do and then I'll talk
7 about how we assure the clearances are there for the
8 piston to come down to do--

9 ACRS VICE CHAIRMAN ARMIJO: I just wanted
10 to understand that an actuator test is more than an
11 initiator test. It's a combination of the initiator
12 and the piston, and the tension bolt, and all of that
13 stuff? Or not?

14 MR. WESSEL: No. The actuator is the
15 initiator, the initiator, the propellant that's in
16 the initiator, the propellant that actually sets off
17 the big part of it, and the cartridge that it's
18 contained in. In addition to it, the top of that is
19 built to simulate the actual mounting in to the
20 valve. So it's in a safety container, with a top
21 part that fits down into this body.

22 This whole top part is simulated in our
23 test fixture with the initiator--or the cartridge
24 screwed into it. And then there's a can on it, that
25 contains a pressure vessel, that we measure the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 amount of pressure that is built up, and that's how
2 we determine if it was successful or not, by
3 measuring that pressure when we set them off.

4 MEMBER BROWN: And Sam, the point is they
5 do not--that's only the actuator, the igniter, the
6 propellant, and it pressurizes whatever that little
7 container is. It does not test the valve that it
8 comes down and shears the cap, post-seismic. That's
9 not part of the post-seismic testing.

10 MEMBER BANERJEE: And does not break the
11 extension bolt or--

12 MEMBER BROWN: It doesn't break the
13 tension bolt. It doesn't do any of that--

14 MR. WESSEL: Not in the actuator test;
15 okay?

16 ACRS VICE CHAIRMAN ARMIJO: I understand
17 what an actuator--

18 MEMBER BROWN: That's all they do, post-
19 seismic, and that's fundamentally my issue. They
20 don't test the valve.

21 MR. WESSEL: So just to give you a better
22 idea of what we do here, we have 22 of these
23 cartridges that we start out the program with. They
24 go through thermal aging, they go through radiation
25 aging, they go through vibration aging, they go

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 through both single-axis testing for pipe-mounted
2 equipment, and we also do random multi-frequency
3 tests on the actuator.

4 So that's all the seismic tests that are
5 done, and then the remaining ones that are left are
6 put in a pressure vessel, and actually run through
7 the design base accident condition, and they are
8 fired during that.

9 So cartridges that have gone through that
10 whole sequence are fired during the design base
11 accident simulation. But after the seismic tests, we
12 take two of those out, and we fire them and measure
13 the pressure.

14 MEMBER BROWN: The actuator.

15 MR. WESSEL: Yes. After each step, after
16 thermal aging we fire off a set. After radiation
17 aging, we fire off a set. After vibration, we fire
18 off a set. After seismic, we fire a set, and then we
19 fire the set that are in the vessel during the
20 accident simulation.

21 CONSULTANT KRESS: You do those aging
22 processes as if they were independent of each other?

23 MR. WESSEL: That's correct. First, you
24 do the thermal, then you do the radiation, and then
25 you do the vibration, and it's all based on the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 sequences in the IEEE specifications that are
2 endorsed by Reg Guide 189.

3 So that's the testing that's done for the
4 actuator; okay?

5 So the next slide, please, Mike.

6 MEMBER POWERS: Dr. Kress, you raised the
7 issue of sequential testing with thermal or
8 radiation. I wonder--do you have ideas that perhaps
9 there's synergism between thermal and radiolytic
10 aging?

11 CONSULTANT KRESS: I don't have any
12 direct data. It just appears to me that's possible
13 to have synergistic effects.

14 MEMBER POWERS: From the developing of
15 databases for cable aging, that work by Clough showed
16 there to be synergistic effects between radiolytic
17 and thermal aging.

18 CONSULTANT KRESS: Yes. That particular
19 kind of material; yes.

20 MEMBER POWERS: That was for, primarily
21 for the aging of insulation on cables.

22 CONSULTANT KRESS: Yes.

23 MEMBER POWERS: Which of course are not
24 the same as either explosives or other materials.
25 But they're not a "wild departure" from--

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BANERJEE: They're polymeric
2 materials.

3 MEMBER POWERS: They are polymeric
4 materials.

5 MEMBER BANERJEE: But in certain senses,
6 explosives are too.

7 MEMBER POWERS: That's right. So one
8 wonders.

9 ACRS VICE CHAIRMAN ARMIJO: The IEEE
10 guidance does not require concurrent aging at
11 temperature in a radiation environment?

12 MR. WESSEL: No; it does not.

13 ACRS VICE CHAIRMAN ARMIJO: But that's
14 what you would consider--

15 MR. WESSEL: And all qualifications for
16 harsh environment program, that is very--very--not
17 much done, it's not easy to do both temperature and
18 radiation at the same time because of the facilities
19 that are available. There has been some work done,
20 over in Japan, of trying to do that. But in this
21 country, the current practices here, it's done
22 separately.

23 Now of course you always evaluate. We
24 are propellant manufacturers, which is the important
25 part here. They have much military experience, that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 they've used it in military applications, and
2 aircraft applications, and that they have looked at
3 that, and they can't see if any synergy effects that
4 would be--that you would need to do these at the same
5 time.

6 You've got to remember, you know, we're
7 trying to put this thing at its end of life. That's
8 our process here. We put it to its end of life
9 before we do the design basis accident.

10 So that's the purpose of the thermal
11 radiation and vibration aging.

12 MEMBER BANERJEE: You replace this
13 cartridge every eight years or something?

14 MR. WESSEL: Yes. Every outage, 20
15 percent of the cartridges are replaced. So over an
16 eight year period, all 12 valves will have changed
17 out their cartridges.

18 MEMBER BANERJEE: And when you replace
19 them, do you test the old cartridge?

20 MR. WESSEL: Yes; that's the purpose.
21 That's part of the IST testing for the squib valve,
22 is you take the cartridge out, and you fire the 20
23 percent, and to show that they were still viable.

24 ACRS VICE CHAIRMAN ARMIJO: So that got
25 the concurrent, everything.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BANERJEE: In whatever--

2 MR. WESSEL: Yes.

3 MEMBER BROWN: You made the comment, in
4 the previous brief, relative to Sanjoy's question,
5 that the propellant manufacturer guaranteed
6 performance for what? ten, twelve years or some--that
7 was a statement that was made during the discussion--
8 and that you then pulled them out, 20 percent every
9 two years, which means the oldest one would be
10 roughly eight years old, if you--

11 MR. WESSEL: Right. That's correct.

12 MEMBER BROWN: That was part of the
13 dialogue in the last meeting, relative to the
14 actuators themselves.

15 MR. WESSEL: Right. And so in our
16 qualification program of the actuator, we will
17 accelerate, age the actuator, including the
18 propellants, for an eight year qualified life to
19 match that out. We're also doing additional aging
20 for shelf life to demonstrate shelf life for
21 approximately 15 years. So that's all part of the
22 qualification program.

23 MEMBER BANERJEE: So will you have--you
24 know, one of the problems you run into with things
25 like explosives, and so on, some of the manufacturers

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 go out of business, or whatever. It's very hard to
2 get the same stuff. So you're going to buy enough of
3 this to start with or--

4 MR. WESSEL: The manufacturer, Goodrich,
5 is out in California. They've been in business for
6 many many years, and mostly in the military and space
7 program that--

8 MEMBER BANERJEE: So hopefully, this
9 manufacturer will not, but--

10 MR. WESSEL: But what we do have in that
11 case, we do have all the formulations, and all that,
12 so, you know, if they would happen to go out of
13 business, Westinghouse does own all the recipes and
14 all the processes that go to make up these. They're
15 all written and can't be changed, because we can't
16 change something in the middle of the process, that
17 had gone through to qualification program. So that
18 is all very well documented, and it's called a
19 baseline program, so they can't deviate.

20 We own all that. So if they would go out
21 of business, then we'd take all these papers and find
22 a new guy, say, "Here--make this."

23 MEMBER BANERJEE: So you actually have
24 that, because in some cases, you're pointing out in
25 the past what has happened, is the ownership, of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 where that is not so clear, and when the manufacturer
2 went out of business nobody could reproduce the--

3 MR. WESSEL: Westinghouse owns all this,
4 so it is all well-documented, and so if that
5 manufacturer would go out of business, we would have
6 to find a new propellant manufacturer.

7 MEMBER BANERJEE: Okay. So your testing
8 would be--

9 MR. WESSEL: Yes, and during each batch--
10 each time they make a batch, they have--and Jerry
11 just talked about some of this last time we were
12 here--there's lot acceptance testing that they go
13 through, various testings and firing of the
14 propellants in test cases, to make sure that it's the
15 same as what we're testing here.

16 So every time they mix up a new batch of
17 propellant, it goes through rigorous testing, to show
18 that it's the same as what we had before.

19 CONSULTANT KRESS: Is your tension bolt
20 removable in place?

21 MR. WESSEL: You remove the--picture--do
22 you still have that up there, Mike?

23 CONSULTANT KRESS: It's a screw-in
24 device, and you could remove the top. I'm trying to
25 get at the question of inspecting the valves in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 place, and if I knew that tension bolt was still in
2 good shape, that would go, that would do a lot of
3 weight--

4 MR. WESSEL: You would have to remove the
5 top enough--the design is changed a little bit since
6 this picture. You would have to remove the top of
7 the bonnet or top of the valve to inspect the tension
8 bolt.

9 CONSULTANT KRESS: Is that difficult?

10 MR. WESSEL: No. Just take sponge bolts
11 off the top.

12 CHAIRMAN RAY: It is bolted on?

13 MR. WESSEL: Yes. The top of the bonnet
14 here is bolted on to the top of the valve--

15 CONSULTANT KRESS: And you could look at
16 the tension bolt--

17 MR. WESSEL: Yes, you could pull out that
18 thing--

19 CONSULTANT KRESS: Pull it down.

20 MR. WESSEL: --and the tension bolt
21 would be there. You can inspect the tension bolt.
22 You can look at the top of the piston and see if--

23 CONSULTANT KRESS: Are there any plans--
24 are there plans to do that sort of inspection?

25 MR. WESSEL: Every ten years I believe

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 they have to have--and correct me--but they have to
2 do some kind of inspection or--

3 CHAIRMAN RAY: It was not listed in your
4 list.

5 MR. CUMMINS: Ed Cummins. I don't know.
6 I think we really on ASME code requirements. I
7 don't believe that that's in there; but I'm not sure.

8 MR. WESSEL: I believe like after ten
9 years, you have to do some kind a inspection, you
10 know, to make sure there isn't corrosion and all that
11 other. But that isn't--that's not in my EQ realm, so
12 that's all I can recall from hearing that.

13 MEMBER BLEY: Have you done some of this
14 seismic qualification testing yet?

15 MR. WESSEL: No. This testing is
16 scheduled to start in March of this coming year.

17 MEMBER BLEY: So we don't know what those
18 natural frequencies are now?

19 MR. WESSEL: Well, have the design
20 analysis of the valve from the ASME code analysis,
21 and the lowest one is 123 hertz, so--

22 MEMBER BLEY: 123?

23 MR. WESSEL: Yes. This is a big--this
24 valve's 9,000 pound. It's a big hunk a metal, you
25 know, so, really--

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER BLEY: But for the tension bolt
2 and the--

3 MR. WESSEL: Yes, the--

4 MEMBER BLEY: --grooving, or whatever you
5 have in there to--

6 MR. WESSEL: Yes, the body of that. You
7 know, it's just a big hunk a metal, really.

8 MEMBER BLEY: But just on this--the squib
9 valve assembly itself is 690. That's what you said
10 last time.

11 MR. WESSEL: I believe that's true. I'm
12 the EQ guy, and, you know, I'm not real "up" on all
13 the different materials and that, but we could get
14 that info--it might be in Jerry's presentation. But
15 I'm sorry, I'm the guy that just tests it, so--

16 MEMBER BANERJEE: And you're exposed to
17 the atmosphere on the other side; right? Whatever
18 the--

19 MR. WESSEL: On the 14 inch. On eight
20 inch, it's actually in--

21 MEMBER BANERJEE: Yes; yes. I
22 understand. The other side is the containment
23 atmosphere.

24 MR. WESSEL: Yes. This side, here, is
25 the containment atmosphere.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER BANERJEE: And that's the only
2 atmosphere that has access, if at all, to the piston
3 and things like that?

4 MR. WESSEL: No, the shear cap, this
5 shear cap here--

6 MEMBER BANERJEE: Yeah.

7 MR. WESSEL: --is there, and that's the
8 only thing exposed to the atmosphere until it's
9 actuated.

10 MEMBER BANERJEE: That's what I mean;
11 yeah. It's not exposed, in any way, to the coolant,
12 at all.

13 MR. WESSEL: No. The coolant--on this
14 side there's a cold trap. On that. So the testing
15 is scheduled to start in March, of both the actuator
16 and the tension bolt testing.

17 In February of this year, we're going to
18 have sort of what we call a design review. We're
19 going to have, at Wylie Laboratories, where we're
20 going to do this testing, we're going to invite both
21 our customers and the NRC staff to join us, and we're
22 going to go through all the procedures and review
23 them, and get any observations anyone may have into
24 our program, so that everybody's aware of what we're
25 doing, and everybody's on board, and satisfied with

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 what we're doing, so--

2 CONSULTANT WALLIS: You're talking about
3 clearances and seals and things, and during *9:37:43,
4 there is some pressurization of the containment
5 before this thing goes off.

6 MR. WESSEL: Yes.

7 CONSULTANT WALLIS: So there's gas, which
8 is trying to get into this thing, underneath the
9 piston. You've got seals and things that are there--

10 MR. WESSEL: Yes, that's--

11 CONSULTANT WALLIS: It's not clear.
12 There's no detail in these things, so--

13 MR. WESSEL: Yeah, there are seals that--
14 this isn't actually a pressure boundary. Up through
15 here is all pressure boundary, so--

16 CONSULTANT WALLIS: So the seals at every
17 place where things can get in from contain--

18 MR. WESSEL: It's ASME code pressure
19 boundary on everything this side of the shear caps,
20 and above.

21 MR. CUMMINS: This is Ed Cummins. Just
22 the regulatory basis of all this. There's a ITAAC
23 for all of the safety-related valves, including the
24 squib valves, that says provide seismic
25 qualification, and then another ITAAC that says

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 provide environmental qualification, and then there's
2 tables that list all the valve numbers that you have
3 to demonstrate to the staff that you've done those
4 before.

5 And so this is viewed as a post-
6 certification process.

7 MEMBER BANERJEE: And the seismic testing
8 is for what? a design basis earthquake of some sort?

9 MR. WESSEL: Both the aging portion of
10 it, to give it the fatigue, we don't call it--
11 nowadays, we don't call it OBEs. We call it half
12 SSEs. But it's the same thing if you go to IEEE 344,
13 it's what's considered and OBE. They are aged with
14 the OBE runs, and they're run through the--through
15 the single axis testing, it's actually, in each
16 direction, it's ran about sixteen times, from one to
17 64 hertz at 1/8th off all the way up through, so that
18 we hit it there, and then we have the multi-frequency
19 test that we do after that. So it gets shook a lot.

20 That sixty, taken on that single axis, is
21 a very severe test.

22 MEMBER BANERJEE: Horizontal and vertical
23 acceleration?

24 MR. WESSEL: Yes. And each with the
25 three directions. And then the random or multi-

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 frequency is the tri-axial test.

2 CONSULTANT WALLIS: So how is it mounted?

3 It's actually mounted in that way, or is it turned
4 around and mounted vertically?

5 MR. WESSEL: It's mounted this way.

6 CONSULTANT WALLIS: It's mounted that
7 way?

8 MR. WESSEL: Yes. Now we didn't talk a
9 whole lot--we got off from the tension bolt. The
10 tension bolt test, we're mocking up, we're hanging in
11 a cylinder, we're hanging one of the pistons actually
12 on the tension bolt with a cap and we're going to run
13 those same seismic tests that we do on the actuator
14 on the tension bolt, and of course the purpose of
15 that test is to make sure it does not break.

16 CONSULTANT WALLIS: And what's upstream
17 is water? Or is it gas?

18 MR. WESSEL: RCS is--

19 CONSULTANT WALLIS: So a vent or
20 something to let gas out of there?

21 MR. WESSEL: I'm sorry?

22 CONSULTANT WALLIS: Is there a vent to
23 let gas out of there?

24 MR. WESSEL: No; no.

25 CONSULTANT WALLIS: So you don't quite

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 know what's upstream at this time? It's a high
2 point, isn't it, in the *circa 9:40:47?

3 MR. WESSEL: Well, there's a cold trap
4 from it, from the RCS system, and I'm not a system
5 guy either, so maybe--I'm not--

6 MEMBER BANERJEE: So the ADS 4 valves are
7 up, and then horizontally placed like that?

8 MR. WESSEL: Yes; just like that.

9 MEMBER BANERJEE: So there's sort of a
10 standpipe, right, that goes off the--

11 MR. WESSEL: Well, it comes down off, and
12 then there's a cold trap, and it comes down at an
13 angle in a cold trap, and then it comes up, like
14 this, from what I understand. But just like that.

15 MR. CUMMINS: So Ed Cummins. The
16 physical arrangements is the 18-inch line on the top
17 of the hotleg that comes up, and it splits into two
18 14-inch line that run horizontally. So there's a
19 vertical 18 inch and then a spilt into two 14-inches
20 that are horizontal, and then two 14-inch lines that
21 have a cold trap, which is like a little U, and then
22 comes the valve.

23 MR. WESSEL: Yeah. There's a block valve
24 in front of the cold trap for servicing purposes.

25 CONSULTANT WALLIS: So there's a vent.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. CUMMINS: There's not a vent in this
2 line.

3 CONSULTANT WALLIS: So you could get gas
4 up in that line, presumably?

5 MR. CUMMINS: You could, though it's not--
6 --it's not--it is a high point in that little part of
7 the line. It's not in the whole system. But yes.

8 MR. WESSEL: During the QME testing,
9 which I really didn't bring any slides on here, we
10 will do full functional tests of the whole valve
11 under full design steam flow, that actually has the
12 cold trap built into the system, that'll show the
13 actuation and the flow requirements are met. That's
14 all part of our qualification program for a squib
15 valve.

16 ACRS VICE CHAIRMAN ARMIJO: And that
17 would be one valve of each size, or--

18 MR. WESSEL: One of each. We're doing
19 all the--

20 ACRS VICE CHAIRMAN ARMIJO: That's a
21 "full up" functional test?

22 MR. WESSEL: Yes, under design basis
23 conditions.

24 MEMBER BROWN: That's not a seismic
25 circumstance. That's not post-seismic?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. WESSEL: No; no.

2 MEMBER BROWN: This is just--it's just
3 showing the actual system operation, or confirming
4 it.

5 ACRS CHAIRMAN ABDEL-KHALIK: Everything
6 on the left of the cap is part of the pressure
7 boundary.

8 MR. WESSEL: That's correct.

9 ACRS CHAIRMAN ABDEL-KHALIK: How about
10 that junction between the cap and the sleeve?

11 MR. WESSEL: This part here?

12 ACRS CHAIRMAN ABDEL-KHALIK: No; no. The
13 interface between the cap and the sleeve.

14 MR. WESSEL: I'm sorry.

15 ACRS CHAIRMAN ABDEL-KHALIK: The vertical
16 ring that is sheared off, is that also a part of the
17 pressure boundary?

18 MR. WESSEL: Yes. It's all part of this
19 piece here. See, this is--

20 MR. CUMMINS: It's machined.

21 ACRS CHAIRMAN ABDEL-KHALIK: It's
22 machined. I understand.

23 MR. WESSEL: This is all--

24 [Simultaneous conversation]

25 MR. WESSEL: --and it is actually

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 replaceable. These valves are serviceable. If it
2 goes off, they can, within 72 hours they can
3 reservice them and have them back in service.

4 MEMBER BANERJEE: That white piece, you
5 can replace it.

6 MR. WESSEL: This portion here, the shear
7 cap portion, you take the flange off and you put a
8 new one in.

9 MEMBER BLEY: Without an isometric to
10 see, it's hard for me to see, even on initial fill,
11 you don't get air trapped in this thing. So there
12 must be some other high point that--but if you got
13 the cold trap, I don't know why it wouldn't be full
14 of air after initial--

15 MEMBER SIEBER: Well, other than the
16 corrosive effect, it shouldn't make any difference
17 for the operation--

18 MR. WESSEL: It doesn't affect the
19 operation of the valve, at all.

20 MEMBER BLEY: I wouldn't think so, but
21 it's not what--

22 MR. WESSEL: But that will be tested in
23 the QME test, because we have the cold trap built
24 into the test for--

25 MEMBER SIEBER: It will be absorbed in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 water, eventually, I think.

2 MR. WESSEL: We have no--in fact, in the
3 test that Jerry was talking about, when he was here
4 before, they've already done the test on the
5 prototype valve. One like that.

6 MEMBER SIEBER: I would think the more
7 severe test would be one where there is no pressure
8 on the upstream side.

9 MR. WESSEL: Well, we're going to use the
10 lowest pressure that's available, because we don't
11 want help pushing it open.

12 MEMBER SIEBER: That's right.

13 MR. WESSEL: That's part of the QME test.
14 We're going to go with the low pressure point, so--

15 MEMBER SIEBER: That becomes--

16 [Simultaneous conversation]

17 MR. WESSEL: --we know the pressure, high
18 pressure will help us, so we're going to use the low
19 pressure in the depths.

20 MEMBER BROWN: Now we've diverted from
21 the initial issue--

22 [Simultaneous conversation]

23 MEMBER BROWN: The actuators are tested--
24 my conclusion, they were tested satisfactorily. My
25 conclusion on--

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 [Simultaneous conversation]

2 MR. WESSEL: I guess we need our backup
3 on here, Mike.

4 MEMBER BROWN: --on the tension bolts,
5 that was satisfactory, so their environmental runs
6 through, even though I'm not a propellant or
7 explosives guy, I listen to enough of you guys talk.
8 I was happy with that. Fundamentally, though, the
9 one thing you do not do is test that the valve
10 operates after the seismic excursions that you test.
11 It is--

12 MR. WESSEL: Well, we saw the actuator
13 will produce the necessary--

14 MEMBER BROWN: I'm not arguing--I got
15 that. The actuator works. I'm not worried about
16 that. It's the valve, the valve cap, the flopping
17 open, it's the travel of the piston after a seismic
18 event. None of that's tested, and I would echo my
19 peer's comment earlier. If you don't test it after
20 you shock it, like if you don't test for stress crows
21 and cracking, how do you know it's going to be okay?
22 And multiple things can happen.

23 You could have a L6COA, or some type of
24 leak that occurs during a seismic event, although
25 it's not supposed to. You could demand these work,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 and they don't, because they have been deformed
2 slightly. The cap is deformed slightly.

3 MR. WESSEL: That can't happen.

4 MEMBER BROWN: Why?

5 MR. WESSEL: It can't happen.

6 MEMBER BROWN: Explain.

7 MR. WESSEL: This is why it can't happen.

8 MEMBER BROWN: Why? You don't test it
9 after seismic. How do you know--

10 MR. WESSEL: I do a class one ASME code
11 analysis on all the body and all the internal metal
12 parts.

13 MEMBER BROWN: Analysis doesn't always
14 work.

15 MR. WESSEL: You have a big hunk a steel
16 here, Charlie.

17 MEMBER BROWN: I've got a piston that's
18 going to drive down and break a seal, and it's--

19 [Simultaneous conversation]

20 MR. WESSEL: Yes. And you know what the
21 analysis shows on that piston? The clearance
22 required is point zero one for the valve to operate.
23 The calculated deflection is point zero zero six in
24 a 335 percent margin on that. So I am very
25 confident, and code analysis will tell me that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 there's plenty of clearance in the piston, that it
2 will operate as long as the actuator produces the
3 required pressure.

4 MEMBER BANERJEE: But you do seismic
5 qualification, which means you actually test--

6 MR. WESSEL: We test the actuator.

7 [Simultaneous conversation]

8 MEMBER BANERJEE: You never test the
9 whole valve?

10 MR. WESSEL: We test a whole valve
11 assembly in the QME testing but it has not gone
12 through seismic qualification.

13 MEMBER BANERJEE: Okay. I didn't
14 realize--

15 MR. WESSEL: We take credit for the ASME
16 code--this is just like a motor-operated valve.

17 MEMBER BROWN: This is the first--this
18 is--

19 [Simultaneous conversation]

20 MEMBER BROWN: We've been having motor-
21 operated valve for 50 years. Okay?

22 MR. WESSEL: Let me talk to you about
23 this; okay? We got a--

24 CHAIRMAN RAY: Wait a minute. Keep the
25 emotion down.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER BROWN: I never get emotional,
2 Harold.

3 CHAIRMAN RAY: I wasn't directing it at
4 you.

5 [Laughter]

6 MEMBER BROWN: My point being is that
7 we've got a lot of experience with motor-operated
8 valves, and regardless of that, we don't have any
9 experience with these. It's a first-time
10 application, and you're asking us to accept, on the
11 first-time application that in fact the analysis
12 will--

13 MR. CUMMINS: This is Ed Cummins. That's
14 not exactly true. I mean, there are safety-related
15 squib valves and BWRs that are about three inch size.
16 We definitely are not in the three inch size but--

17 MEMBER BROWN: I would agree with that.

18 MR. CUMMINS: But there is some past
19 nuclear experience with safety-related squib valves.

20 MEMBER BROWN: But his mechanical valve
21 operation ought to give you confidence that he can
22 compute these clearances, which is what he needs to
23 do.

24 [Simultaneous conversation]

25 MEMBER SIEBER: Well, it's a different--

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. CUMMINS: I mean he's still
2 calculating clearances--

3 MEMBER SHACK: Yes, but with a motor-
4 operated valve, I've got a giant motor that's driving
5 the valve in one direction. I've got constant--I've
6 got torques applied and forces applied that don't--
7 this is a pulse operation. Bang--it's got to go.
8 Explosive expand, go down and do it.

9 MR. WESSEL: Let me ask you this,
10 Charlie. On a motor-operated valve, you don't
11 seismically test the whole thing. But you do an ASME
12 code analysis that shows that the disk will go down
13 and close satisfactorily, and everything else. So
14 this is no different than what we do for any safety-
15 related valve.

16 MEMBER BROWN: I'm not arguing with you
17 on that. If I go back in the programs that I've
18 operated in, after we seismically tested these--or
19 shock-tested them, we operated them, to make sure
20 they would operate. All the motor-operated valves
21 that were critical to safety got operated, post-shock
22 and vibration testing.

23 And I understand the fact that you have
24 not done this typically in the industry, and I'm just
25 giving you credit for the fact that you've had them

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 in service for a number of years, and plants have
2 withstood--they have then experience, they have had
3 seismic experience, and the valves have continued to
4 work based on operating experience.

5 Here, I don't have that. So that's the
6 issue. That's my concern. How many times do you
7 have to do this over and over again on every plant?
8 Maybe not. But every design should be confirmed.
9 That's my opinion. And so, you know, I understand
10 the analyses of clearances--oh, no, I don't, I'm not
11 a mechanical engineer--

12 [Simultaneous conversation]

13 MR. CUMMINS: Ed Cummins again. Just a
14 comment, that the ASME code comes in here, and most
15 people are pretty happy when the industry follows the
16 ASME code. So it doesn't mean that you have to be
17 happy. But that we're not inventing an analysis
18 process here.

19 MEMBER BROWN: I understand that. I
20 understand that.

21 MR. WESSEL: The other thing that gives
22 us confidence is we've taken prototype valves--
23 there's two valves that have gone through 17 firings,
24 and those valves, after every time they were fired,
25 and they were fired under loaded conditions, and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 everything, we did not see any deformation of
2 anything that would not preclude the valve to operate
3 during those 17 tests.

4 MEMBER BANERJEE: Have you ever fired
5 them after shaking them up?

6 MR. WESSEL: I'm sorry?

7 MEMBER BANERJEE: Have you ever fired a
8 valve after shaking them up?

9 MR. WESSEL: No. We have not seismically
10 test--

11 MEMBER BANERJEE: Do you plan to fire a
12 valve after shaking them up?

13 MR. WESSEL: No.

14 MEMBER BANERJEE: Even in a qualification
15 program?

16 MR. WESSEL: No.

17 MEMBER BANERJEE: It was a straight
18 answer.

19 MEMBER BROWN: It was a very easy answer.

20 CHAIRMAN RAY: Well, all right, and I
21 don't think we're making any progress here.

22 MEMBER BROWN: I think we can--you know,
23 Harold, I would go on. I mean, we've got to make a
24 decision--

25 MEMBER BANERJEE: Well, we at least have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 clarity on that.

2 MEMBER BROWN: Yes. We've got clarity--

3 CHAIRMAN RAY: Well, we're not making any
4 further progress beyond clarity.

5 [Laughter]

6 CHAIRMAN RAY: So--

7 ACRS CHAIRMAN ABDEL-KHALIK: Could you
8 just expand on the word "values" in the last bullet.

9 Which one has the minimum safety factor? What are
10 you referring--

11 MR. WESSEL: These, these are actually--
12 when I went through the design reports, the lowest
13 safety, margin of safety factor I found on stresses,
14 and everything else in the valve body, and all the
15 metallica parts, was 32 percent. I actually went
16 back and I looked at where they've calculated the
17 clearance between the valve body and the piston, and
18 those--that is all done with a combination of the
19 maximum design pressure operating loads, pipe end
20 loads, and six-g seismic, in three directions, by sum
21 of the squares, and that's where they got the point
22 zero zero six deflection of the piston, and the
23 clearance is point zero one.

24 So that gives us confidence that there is
25 more than enough clearance, 335 percent margin in the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 clearance between the wall and the piston, that the
2 valve will fire.

3 And all those loads are combined in, and
4 included in the calculations for those clearances.

5 ACRS CHAIRMAN ABDEL-KHALIK: That's fine.

6 Thank you.

7 MEMBER BANERJEE: Is there any detailed,
8 finite element sort of analysis required here for the
9 stresses and things that might arise in an
10 earthquake?

11 MR. WESSEL: That's what--the ASME code
12 analysis was done with our ANSYS.

13 MEMBER BANERJEE: And that it shows
14 you're well into the last *SIC 9:53 regime?

15 MR. WESSEL: It shows us all in great
16 shape. The 35 percent was the lowest that I found in
17 all three of the design reports.

18 MEMBER BANERJEE: And what was the
19 financial analysis code that you used for this?

20 MR. WESSEL: ANSYS.

21 MEMBER BANERJEE: ANSYS. Did you use it
22 yourself?

23 MR. WESSEL: It was done by the valve
24 manufacturer.

25 CONSULTANT KRESS: Is this the heavy

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 valve, cantilevered out *9:54...?

2 MR. WESSEL: It is well-supported right
3 at--on this, on the one that we had the picture,
4 right on--

5 CONSULTANT KRESS: As a support--

6 MR. WESSEL: --the outside. Yeah; it's
7 all supported.

8 CONSULTANT KRESS: All supported?

9 MR. WESSEL: Yeah.

10 MEMBER BANERJEE: And correct me. But
11 this analysis was done for the OBE?

12 MR. WESSEL: No. It was done for the
13 SSE, six g's; yeah.

14 MEMBER BANERJEE: SSE.

15 MR. WESSEL: It also included all
16 operating loads, piping loads, all loading
17 conditions. It's a Level D ASME code analysis level
18 that includes everything in that analysis.

19 CHAIRMAN RAY: Anything else?

20 MR. CUMMINS: May we comment on six g's.

21 This is Ed Cummins. Six g's is basically the
22 industry was frustrated with equipment manufacturers
23 because they would design their valves for the in-
24 service accelerations, and so the utility
25 requirements document decided that we need these

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 valves to go wherever we want them, and so they
2 required valves--the utility requirements document
3 required valves to be designed for six g in the three
4 separate directions, so they could be used anywhere.

5 That's the concept.

6 And the actual loading on any place from
7 the piping analysis has to be shown to be less than
8 six g, so there's margin here.

9 CHAIRMAN RAY: Thank you. Okay. Again,
10 one more time. Any other questions concerning this
11 valve, and its qualification testing, and in-service
12 testing?

13 [No response]

14 CHAIRMAN RAY: Thank you.

15 MR. WESSEL: Thank you.

16 MR. MELTON: Okay, Mr. Chairman, just a
17 second. On the phone, do I have Keith Schwab-
18 *Palozza [phonetic]?

19 CHAIRMAN RAY: Is that a question or--

20 MR. MELTON: Yes. I'm asking our team.

21 [Pause for phone]

22 CHAIRMAN RAY: This is the sampling
23 frequency and demonstration, that won't exceed 120
24 percent and so on.

25 MEMBER BROWN: Yes. They sent a writeup

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 on it and I read it, and I have a comment on it.

2 CHAIRMAN RAY: We'll take it up here in a
3 second.

4 MR. MELTON: I think we're going to go in
5 discussion mode on that one.

6 [Pause for phone]

7 MR. MELTON: I think they're on.

8 CHAIRMAN RAY: Well, if they'd something,
9 we would be more confident.

10 [Laughter]

11 MR. SCHWAB: Keith Schwab is on.

12 MR. MELTON: Thank you, Keith. We have
13 Chris Provenzano on for Ron *Waka [phonetic].

14 CHAIRMAN RAY: All right. Proceed.

15 MR. MELTON: Okay, Mr. Chairman. We are
16 moving on to action number 73, and we didn't provide--
17 --this is more of a discussion mode, or response to
18 Charlie's questions related to the overall overspeed
19 trip system. I think at this time, Keith, if you
20 could take us through the response that we gave to
21 Charlie in the ACRS in the discussion mode, and we'll
22 go from there.

23 MR. SCHWAB: Okay. My--our understand--
24 this is Keith Schwab. Our understanding is the
25 concern with Table 2.2-2 of Chapter 10 of the DCD,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 has a table that goes through a sequence of events
2 that gives the expected turbine speeds when you have
3 a turbine trip, or you open your generator breaker.
4 The control system responds when you're in normal
5 turbine control.

6 It begins to close valves as it senses
7 speed increasing on the turbine. If you're in a trip
8 mode, it will--the speed will rise to no greater than
9 108 percent overspeed.

10 If we're--we don't have a trip and we do
11 have an increase in speed, the control system will
12 respond and bring speed back under control, and you
13 continue operating.

14 That's the first part of that table. But
15 the second part of that table gives the two overspeed
16 trip points, which if there's a problem with the
17 control system, and that's the 110 percent, the 111
18 percent trip point by the diverse systems that we've
19 talked about previously, in previous meetings.

20 And those points are only reached if you
21 have a problem, which I think everybody understands.

22 That our understanding is there's a concern with the
23 note that says--at the bottom of the table that says,
24 even if you go through all that, your control system,
25 your normal speed control system fails, and you reach

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 your overspeed trip points, that the turbine will not
2 exceed 120 percent over speed, which, by the way is
3 the design speed of the turbine rotor, even though we
4 operate at a 100 percent speed, normally.

5 And I think the concern was, you know,
6 the note says we may approach 120 percent but we will
7 not exceed it. And we are basing that on our
8 existing turbine control systems design, the sampling
9 rate of the control system, and the valve closure
10 times, as documented in the DCD in table--I think
11 it's 10.2-3. I don't have that table handy. The
12 valves will close in .3 seconds, or less.

13 So we typically don't do an analysis to
14 show that 120 percent will not be exceeded because
15 there's sufficient--we feel there's sufficient margin
16 between the trip points, which are actually lower for
17 AP1000 than in the standard review plan, gives, and
18 because the response time of the control system. And
19 I think--I think that pretty much characterizes our
20 understanding of the concern.

21 MEMBER BROWN: Yes. Well, the concern
22 was that there's no specific test that verifies that,
23 in fact, due to a failure in the control systems,
24 that the overall response in the way it accelerates
25 the turbine rotor will not generate a speed which

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 has--if it performs and trips as it says, that it
2 will not exceed 120 percent.

3 And so that's what triggered my comment
4 relative to the table. And if you go look in the
5 ITAAC or other testing, or other--in service testing
6 there was--not in service, excuse me--but in other
7 plant testing, there was no specific test to verify
8 that claim, that there's no way you'll exceed, based
9 on anything, the 120 percent overspeed, since that is
10 the design speed of the rotor itself.

11 So that was it, and--

12 CHAIRMAN RAY: This is a control system
13 response question--

14 MEMBER BROWN: Well, there's two, two or
15 three issues. Number one, you can have load
16 rejections, in other words, you're at a 100 percent
17 load, the breaker opens, and now you've got all the
18 steam going in there and it's got--it speeds up
19 That's one casualty that you can have, which makes
20 them speed. The other is you can have a plant trip,
21 where similar actions occur, it's roughly the same--

22 CHAIRMAN RAY: My point, Charlie, was
23 that as we wrote the action item, the concern arises,
24 though, from the fact that you don't demonstrate that
25 you've got a sufficiently short sample time and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 response--

2 MEMBER BROWN: It wasn't sample time. It
3 was--what is--

4 CHAIRMAN RAY: That was what was written
5 here.

6 MEMBER BROWN: Yes. I know. I didn't
7 "mouse milk" every word that was in that response.
8 It was understood that the note is fairly
9 explanatory. It says you don't exceed 120 percent,
10 ever, and there was no test for it, to verify that
11 you would do that. The other mode would be to
12 postulate a failure of the control system, the demand
13 part of the control system, not the trip part of the
14 control system. I don't have any problem with the
15 overspeed trip functionality, the design of that; but
16 if you demand an acceleration, once you're at a 100
17 percent, and you start accelerating it, or you
18 accelerate it from low load, and you pass through the
19 normal operating speed, then you don't stabilize,
20 then you can have sufficient acceleration that you
21 will overshoot more than you would under some of
22 these other circumstances.

23 And there was no test to show that, or an
24 analysis. I mean, it doesn't have to be a test. It
25 could be an analysis of the turbine generator

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 response and the governor response itself.

2 So that's the concern. They provided, in
3 their white paper, that they do two tests, in Chapter
4 14. One is a 100 percent load rejection test, and
5 the other one is a plant trip from 100 percent power.

6 And they made a statement, in here, that
7 both of those tests will demonstrate that you do not
8 exceed the 108 percent, which is listed in the table
9 as a maximum under those circumstances.

10 If you go look at those tests, as they're
11 embodied in the Chapter 14, the performance criteria
12 does not say anything, at all, about speed. All it
13 does is say that the TG will stabilize. It
14 effectively measures plant response.

15 In other words, you stabilize
16 temperatures, flows, pressure, steam generator,
17 valves don't trip, etcetera, on and on and on. But
18 there is no acceptance criteria or performance
19 criteria. It doesn't have to be--you know, it says
20 we don't exceed 108 percent speed.

21 If there was some type of an acceptance
22 criteria on those two tests, which said I don't
23 exceed 108 percent, that would be fairly reasonable,
24 I would think that would be good enough, as opposed
25 to doing any other analysis. So that's my thought

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 process on that.

2 CHAIRMAN RAY: Okay. Response to what he
3 just described, then?

4 MR. MELTON: Keith, would you like to
5 elaborate.

6 MR. SCHWAB: I agree with his
7 assessment. Yes. We test the trip and the load
8 reject. I would have to look at the specific wording
9 in Chapter 14.

10 MEMBER BROWN: I've got it right here, if
11 you want.

12 MR. SCHWAB: But if we added the criteria
13 of 108 percent, would that satisfy the concern?

14 MEMBER BROWN: Yes, in both the tests.
15 I'd be happy as a pig in a mudwall.

16 MR. SCHWAB: I personally don't see an
17 issue with that.

18 MR. PROVENZANO: I do not either. this is
19 Chris Provenzano. I was trying to follow some of
20 that and I was--with the acceptance criteria. But
21 adding 108 percent there, that won't be an issue
22 because, you know, from a control system standpoint,
23 that's not an issue.

24 MEMBER BROWN: That resolves it as far as
25 we get a commitment to include that in Chapter 14--

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN RAY: All right. Well, perhaps,
2 Ed, you can feed back to us tomorrow, or later today,
3 or some other time, your willingness to--

4 MR. CUMMINS: There's just logistic
5 issues associated with submitting the Revision 18
6 tomorrow.

7 [Laughter]

8 CHAIRMAN RAY: All right. Well, I'm not
9 going to worry about that here. We're trying to
10 reach agreement and understanding. How the heck it
11 gets implemented, I just don't want to get bogged
12 down in that right now.

13 All right, Charlie?

14 MEMBER BROWN: Yes. I'm happy with that
15 one. I mean, if they put it in as a performance
16 criteria, there's two separates, as performance
17 criteria at the end, put it in along with the plant
18 stuff, and I'm--I'd say I'm satisfied. It's a
19 reasonable compromise.

20 CHAIRMAN RAY: Okay. Mike, what more do
21 you have in the open session?

22 MR. MELTON: That would conclude our open
23 session. The next item, ten, we'd like to--

24 CHAIRMAN RAY: What is the deal on item
25 ten? You have that in closed session, is that--

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. MELTON: That's correct. We want to
2 do that closed session.

3 CHAIRMAN RAY: I see. All right. Well
4 we're quite close to the scheduled break time, so
5 we'll go ahead and take the break, and when we
6 return, I'll ask that we verify that we're prepared
7 for the closed session.

8 Anybody have anything they want to say,
9 before we leave for a 15 minute break?

10 [No response]

11 CHAIRMAN RAY: So we'll be back at 10:25,
12 please.

13 [Whereupon, at 10:09 a.m., the open
14 session was concluded to resume at 2:44 p.m.]

15

16

17

18

19

20 CHAIRMAN RAY: We'll go back on the
21 record. And, we have the staff with a presentation to
22 us to complete some more open action items--action
23 items, not open items. So, floor is yours.

24 MR. ROGGENBRODT: Thank you. Good
25 afternoon. I'm Bill Roggenbrodt from instrumentation

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 controls in electrical engineering Branch one,
2 followed by Branch chief Terry Jackson and We're here
3 to present to the ACRS Subcommittee, ACRS action
4 items 65 and 72. Next slide

5 MS. MCKENNA: Go a little slow, Bill,
6 because Charles isn't back yet. He's having--

7 CHAIRMAN RAY: Is he, is he coming Eileen?

8
9 MS. MCKENNA: Yes he is, he's going to get
10 coffee.

11 CHAIRMAN RAY: All right, well, I'm going
12 to put it down to him having worked during the coffee
13 break and so okay we'll wait for a second until
14 Charlie can get back. The coffee line down there, I
15 can tell you, is pretty long.

16 For some reason. I think it's because
17 they got a blood donor set up in the lobby. We'll
18 wait a second until Member Brown returns. All right.
19 We're ready now, I think. Please proceed.

20 MR. ROGGENBRODT: Once again, I'm Bill
21 Roggenbrodt from instrumentation controls and
22 electrical engineering Branch one, along with my
23 Branch chief, Terry Jackson. We're here to present to
24 the ACRS Subcommittee the action items 65 and 72.
25 Next slide.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Purpose is to brief the ACRS Subcommittee
2 on the current status of the AP1000 safety standard
3 loading issue, sometimes referred to as the 7%
4 loading issue. The automatic depressurization system
5 for ADS style blocking signal and the diverse
6 actuation system attributes. By the end of
7 this session we hope to get, allow the ACRS to have a
8 better understanding of the items that are captured
9 above and we'll do that via our slide presentation,
10 discussion of the talking points. Next slide, please.
11

12 Background for action item 65, the
13 actuating system consists of two parts. Measures
14 taken to ensure the protection safety monitoring
15 system, our PMS, is capable of operating under
16 maximum loading conditions and the operation of the
17 PMS is watchdog timer.

18 The watchdog timer issue is considered
19 resolved based upon our meeting for, middle of last
20 month. Next slide, please, and the current status of
21 the remaining portion of that is the staff
22 understands that Westinghouse is committed to add
23 information with tier one material, chapter two,
24 section 252, table 25 2--dash, 8.

25 The inspections test analyses and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 acceptance criteria within design commitment 11, the
2 PMS hardware and software development process, and
3 particularly the languages expected to be
4 incorporated into the system integration and test
5 phase. And, the staff finds that language acceptable.

6
7 Go to the next slide. You can see those
8 items in red, as far as what's being added to the
9 acceptance criteria and discusses the response time
10 testing under maximum CPU loading.

11 CHAIRMAN RAY: Charlie?

12 MEMBER BROWN: I'm reading--it's the first
13 time I've seen it. We had a quick discussion but let
14 me--I understand the reason for saying maximum CPU
15 loading. And I, you know, in other words, to keep it
16 such that if somebody uses a different platform, that
17 has a different number, that it, you know, you, you
18 haven't limited yourself or given away the store
19 somewhere.

20 I mean, in, in the Westinghouse case, the
21 common Q case, it's established in the topical report
22 as to where they talk about the 70%. And, so that
23 one's fairly clean, I mean, you can find it. And I'm
24 just thinking about how, somebody came along in five
25 years and wanted a different platform, what that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 would mean to them.

2 CHAIRMAN RAY: Well, as with other things,
3 you may want to think about it some more. At this
4 point, I think the--

5 MEMBER BROWN: I'm not thinking--I'm
6 looking to mouse milk it right now. I'm just, it's
7 just, just my, I'm just trying to communicate my
8 thought process and, you know, that's all I was
9 trying to do. I'm not going to sit here and try to
10 debate it ADS4 infinitum. I'm going to move on. But,
11 that's in the direction. That looks, you know,
12 that's, this would be in rev 18, I take it?

13 CHAIRMAN RAY: Or is it 19, Eileen?

14 MR. CUMMINS: It's 18.

15 CHAIRMAN RAY: Okay.

16 MEMBER BROWN: Okay, now, in terms of, is,
17 is this, isn't a commitment, this is what
18 Westinghouse has agreed to with you guys, that would
19 be the response which you have agreed with and this
20 would then be--what does this reflected--

21 MR. ROGGENBRODT: This is in tier one
22 language in the ITAAC tables themselves.

23 MEMBER BROWN: Okay. Well, I understand
24 this is tier one, the tier one table.

25 MR. ROGGENBRODT: So this would become

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 part of the--

2 MEMBER BROWN: Okay. All right, let's go
3 on. Thank you. Okay.

4 MR. ROGGENBRODT: Sure. Moving onto action
5 item 72. This action item also consists of two parts.
6 That would be the status of the ADS block signal, and
7 the following diverse actuation system, or DAS
8 attributes, particularly the two out of two voting
9 logic, the 30 day technical specific per the manual
10 DAS out of service time, and the 14 day reporting
11 time for the automatic functions of DAS out of
12 service time. Next slide, please.

13 Looking over the first item. Within the
14 ADS valve blocking signal, the staff required the
15 addition--additional information, broken down into
16 three items would be a logic diagram depicting the
17 how and where.

18 ADS block signal interface with the PMS,
19 basic analysis or discussion demonstrating why the
20 addition of this circuit does not impede the, the ADS
21 valves from completing their standard design
22 function.

23 And, additional clarifying language into
24 the AP1000 DCD. The staff has received the codes from
25 Westinghouse that added the clarifying language

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 within the design control document, and other
2 secondary references and as a result the staff
3 considers this issue resolved.

4 And, it's my understanding that what was
5 discussed up to and including yesterday would be in
6 part of DCD rev 18, but you want to check with the
7 Westinghouse on that. That's--

8 MR. CUMMINS: That's true, they can.

9 MEMBER BROWN: Okay, so you have gone
10 through, I mean, since I just saw it, I'm, you all
11 looked at the logic diagram and concluded that that
12 covers--

13 MR. ROGGENBRODT: The particulars, I can
14 speak to the particulars.

15 MEMBER BROWN: I mean, this is a tier two
16 piece of material.

17 MR. ROGGENBRODT: Right. What--the final
18 determination is that the logic diagram that was
19 proposed, actually, our understanding is that it's
20 more software based than hardware based at this
21 juncture. So rather than depicting the how and where,
22 it's captured via specific note at the particular ADS
23 valve line items going into the detail that there is
24 a block signal and how it's actuated and what valves
25 are utilized.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 So, it'll lurch--it'll be the licensee
2 reviewer or the plant operator licensee that there is
3 in fact an ADS block signal.

4 MR. SANTOS: This is Dan Santos from the
5 staff. We, we have copies if the members are
6 interested of seeing the DCD under logic diagram, or-
7 -

8 MEMBER BROWN: The--you said this was
9 going to be soft--a software based logic?

10 MR. ROGGENBRODT: No. I'm simply stating
11 that the, the reason that it was implemented in such
12 a fashion of the note itself is that the manner by
13 which the ADS blocking signal is being implemented,
14 it would not have been appropriate to be placed into
15 that drawing as perhaps putting an additional and
16 gate or something like that, so the more correct or
17 acceptable manner by which to incorporate so that
18 you're still aware that this exists was through the
19 note process on the diagram itself.

20 MEMBER BROWN: So the specific execution
21 of the unblocking, you mentioned CMT levels as an
22 input.

23 MR. ROGGENBRODT: Correct.

24 MEMBER BROWN: That, how that gets
25 executed is not shown, I, I don't see how that's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 shown. It's just the note--

2 MR. ROGGENBRODT: That's correct. Because,
3 in, in that, in those particular drawings, staff's
4 understanding is that that particular component that
5 executes that would not be captured at that level on
6 the, on the PMS diagram.

7 MR. JACKSON: It's, it's essentially that,
8 that, the logic diagram captures the software logic
9 in the comment you PMS.

10 MEMBER BROWN: As it exists today.

11 MR. JACKSON: Right. But the blocker would
12 be--

13 MEMBER BROWN: This, this is there today.
14 Minus the note.

15 MR. JACKSON: Yes, the blocker would be
16 separate from the PMS software.

17 MEMBER BROWN: From where?

18 MR. JACKSON: Well, it would be, it would
19 be, it would be implemented, might be, outside, it
20 would be implemented outside the, it would be
21 implemented outside the common tube portion of the
22 PMS. And Westinghouse can probably discuss more about
23 the design details as they go further.

24 MR. CUMMINS: Yes, I think that the, at
25 least as the issue is presented in the U.K., the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 whole issue was common mode failure of common Q. So,
2 one of the functional requirements of doing this was
3 to do this independent of the common Q, and so we
4 don't have a final design yet.

5 But, we have a commitment, not to do it,
6 as far as the software of common Q. And so, it, what,
7 what was said by the staff is correct, that, that
8 it's not part of the common Q software.

9 MEMBER BROWN: Okay, no, I, I just not had
10 a chance while you were talking, I was listening at
11 the same time, multitasking is hard to do for this
12 brain. The spurious actuation, then you talk about
13 independence and you talk about, it will be diverse
14 from the PMS hardware and the note then reflects it.
15 It, it, it, go look at this, what you're going to
16 propose here. Okay. All right, I think that, I think
17 that's fine.

18 MR. ROGGENBRODT: Okay. Next slide,
19 please. Moving onto the second item within action
20 item 72, the diverse actuation system attributes.
21 Concerning those attributes, two out of two logic for
22 the DAS, that was certified in Revision 15.

23 The thirty day out of service time for
24 manual DAS functions was also certified in Revision
25 15 and also comes as more of a chapter 16 review than

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 it does the chapter 7 review, since it impacts the,
2 either investment protection or tech specs.

3 And, again, that also applies to the 14
4 day out of service time for automatic DAS functions--

5 MEMBER BLEY: I've got a question. I, you
6 know, we talked about this the also time. With
7 systems that are operating in a plant, in many
8 plants, for a long time, we have good data on how
9 often they go into maintenance, planned or repair,
10 and, and how long it takes to repair them.

11 With something that isn't out in the
12 fleet, and something we used to see was equipment
13 would often be out for the full time allowed in the
14 tech specs. On this one, we look at the PRA and the
15 PRA calculates a nice, low-level of unavailability
16 for this system that's completely unrelated to the
17 thirty day tech spec.

18 And, I'm, I'm just not sure why that's a
19 reasonable thing. Somebody here said, well, you know,
20 nobody's going to leave tout for the full thirty
21 days. Well, you can. And, in the past, a lot of
22 people did leave out for the full length of time, and
23 one something like this where we've, we don't have it
24 in the field, we don't know what might go wrong or
25 how long it takes to repair it or how--

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 You know, it just, having that 30 day
2 tech spec and then not using that as the basis for
3 the unavailability in the PRA but using something
4 much less, like, at least a tenth of that. I don't, I
5 don't quite get it, or, I don't get why staff looks
6 at it and says, yes, it's a reasonable thing.

7 I mean, the whole design when you rescind
8 this, of, of the DAS is ray based. Came in as a
9 result of the PRA, it's been used, designed based on
10 the PRA. It's, its' requirements are based on the PRA
11 and yet we don't set a, an allowed outage time that's
12 consistent with that whole basis of the design.

13 It just leaves me with a great
14 uncomfortable feeling, and I haven't heard a good
15 argument yet from anybody why that's a reasonable
16 state of the world.

17 MR. SANTOS: This is Dan Santos from the
18 staff. If we could have the Applicant address your,
19 your points, that would be better because again this
20 thing you're mentioning, aprt of the certified this
21 time but I would like to put that question to the
22 Applicant to see how they went though it.

23 MEMBER BLEY: Yes, but I'm also first
24 interested in why, why staff thinks it's a grand
25 idea.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. CUMMINS: I'm Ed Cummins. The NRC
2 rules and policies doesn't use the tech specs to
3 enforce the PRA. If they use anything to enforce the
4 PRA, they use the maintenance Rule to enforce the
5 PRA.

6 MEMBER BLEY: That's right, but we've
7 never had a system designed on the basis of the PRA
8 before either that I know of.

9 MR. CUMMINS: Yes, but, I, you know, this
10 would be, I would say, a horrible precedent to say
11 that We're going to use tech specs to, to enforce the
12 assumption of the PRA--the, the assumptions of, for
13 the, for the, past reliability are consistent with
14 the EPRI failure rates and, and, and repair rates.

15 There are some, some cases where the
16 repair of DAS would require plant shutdown and entry,
17 entry to places in the containment we can't have half
18 an ability to repair up, that instrument or a
19 connection. And so, you know, it, it can make sense
20 to have a significant time in, in the tech specs.

21 The tech specs are to enforce non basis
22 accidents, and--

23 MEMBER BLEY: Except, this system has
24 nothing to do with--if it has anything to do with,
25 with getting core damage frequency down low, then the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 plant damage frequency down low, so this is kind of
2 unique.

3 MR. CUMMINS: Yes, but I, I agree with you
4 on, the staff policy, and they can say this better
5 than I can. I don't really want to say what--it, is,
6 is, is, they look at enforcing a, a, a, I'll put
7 quotes around enforcing, the PRA assumptions through
8 the maintenance Rule.

9 Not, and so they look at how these times,
10 repair times, and in the maintenance Rule. Not in the
11 tech specs. And so if there is something that should
12 be addressed to maintain the assumptions of the PRA,
13 it should be covered in the maintenance Rule, not in
14 the technology specs.

15 MEMBER BLEY: I'm kind of sitting out on a
16 limb with this and I may saw it off eventually, but
17 when I had the system designed, you know, on the
18 basis of the PRA, there to support the PRA, it just
19 doesn't make sense to me for it to fall under the
20 normal approach to setting these outage times. Go
21 ahead.

22 MR. JACKSON: Okay. And I, I would just
23 add that, you know, from the staff's point of view,
24 my staff isn't really prepared to answer questions
25 about the technical specifications through the PRA,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 particularly on the, you know, the certified design,
2 which we weren't involved with--

3 VICE CHAIRMAN ARMIJO: Could I ask a
4 question? Clarification. Is it possible then that
5 both the manual DAS and the automatic DAS could be
6 out of service at the same time?

7 MR. ROGGENBRODT: Of course, yes.

8 MR. CUMMINS: Yes.

9 VICE CHAIRMAN ARMIJO: That's a good idea.

10 MS. MCKENNA: Well, the point, I think the
11 point is, is that the maintenance Rule does try, also
12 take into account whatever available compliment of
13 equipment. That's one of the features, I think, of the
14 maintenance Rule gives you beyond the tech specs is
15 that it, they have to account for this component being
16 out of service at the same time as that component
17 being out of service for what period of time it's out
18 of service in their risk assessments, for, for the
19 maintenance Rule.

20 So, it is certainly is possible, yes,
21 there's nothing that would prevent it. From these
22 provisions, it would be maintenance Rule and it,
23 whether the risk would be too high for the period of
24 time that you'd be in that, that situation.

25 VICE CHAIRMAN ARMIJO: But, but an operator

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 wouldn't necessarily know that the maintenance Rule is
2 going to take care of things, whereas the tech spec is
3 right there in front of you.

4 MEMBER BLEY: That, that'll come later.

5 VICE CHAIRMAN ARMIJO: So, so there's no
6 connection between, in the tech specs as saying, this
7 thirty days is okay, provided the other one is in
8 service, or--

9 MS. MCKENNA: That's correct.

10 VICE CHAIRMAN ARMIJO: --this 14 days is
11 okay, provided--there's nothing like that?

12 MS. MCKENNA: No. The tech specs are all
13 very singular in their application.

14 MR. JACKSON: And, and the 30 day, allowed
15 outage time for the manual DAS functions is in the
16 tech, technical specifications. The fourteen day
17 allowed outage time for the automatic DAS functions,
18 investment type--two different, two separate programs.

19 But as Eileen did mention, the maintenance
20 Rule would be a big player with regards to DAS,
21 particularly not only from the unavailability time
22 that may be gained if it's out of service for a while
23 but also from the A4 standpoint where they have to
24 look at the risk of, of, of current plant activities
25 on a continual basis.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER BLEY: Yes, just from what you said,
2 let me read you a line from the Westinghouse document
3 that explains all this. Because the DAS manual control
4 must be credited in order to meet the PRA safety goal-
5 -that's not a regulatory requirement--it was concluded
6 that these DAS manual action manual controls should be
7 included in the tech specs.

8 But, again, not at a level consistent with
9 the safety pool. It just seems an odd connection of
10 logic to me.

11 MEMBER BROWN: What page did you read that
12 one on?

13 MEMBER BLEY: I'd have to go find it again.
14 I've excerpted a bunch of that stuff.

15 MEMBER BROWN: It's the manual one, right?
16 Is it the manual function?

17 MEMBER BLEY: Yes. It's the manual--

18 MEMBER BROWN: Yes, okay. I mean, I'll look
19 through that, I'm trying to, I remember reading that.

20 MEMBER BLEY: Well, it, it seems like a
21 worthwhile discussion for sure. I just wonder if we've
22 exhausted all the exchange that we need to have here.

23 MEMBER BROWN: Well, Harold, I think we
24 ought to make the, one fundamental, the reason I
25 brought this up, okay, and, and try to, try to at

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 least get it articulated is if you look at the, the
2 standard primary SFAS, its' a microprocessor based
3 system, common q based.

4 It, it has the same fundamental voting
5 problem that the, that the PMS system has. In other
6 words, is the voters lock up, it doesn't actuate.
7 Argue how, but it doesn't actuate.

8 PMS, maybe we'll walk through that,
9 because there's another function called a watchdog
10 timer which provides that backup such that if the
11 voters lock up, you'll get a, you'll get a trip, and
12 the reactor shuts down.

13 With the SFAS, if they don't operate,
14 their valence is, there is no deferral or default to a
15 trip function for the, for the primary sfas. You don't
16 want it to, okay, and so--

17 MEMBER BLEY: But it's not two out of two,
18 you don't--

19 MEMBER BROWN: No, it's two out of four.
20 They all lock up, it's not going to operate. So what's
21 your backup? The backup is, the automatic DAS and then
22 the manual DAS. Well, if they're both allowed to be
23 out of service at the same time--

24 MEMBER BLEY: You don't have a backup.

25 MEMBER BROWN: They're not--have no backup.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER BLEY: I, I understand that.

2 MEMBER BROWN: And that's the fundamental
3 issue I have with not having some of the--forget
4 maintenance, how the maintenance Rule gets into this.
5 I'm, I'm not so sure, there's just nothing in these
6 documents as part of the plant operation that says
7 We're not, We're not going to have these be combined
8 at the same time.

9 MEMBER BLEY: Okay, but--

10 MEMBER BROWN: I'm not arguing with two out
11 of two. But we've been over this several times now, I
12 mean, I don't think anything's changed.

13 MEMBER BLEY: I wanted to make sure it was
14 clear.

15 MEMBER BROWN: All right. That's all.

16 CHAIRMAN RAY: Does anybody lack clarity?
17 Okay. I mean, you know, we've had the staff now
18 respond to us, they told us their position.
19 Westinghouse has told us their position. We'll have to
20 decide what our position is, but this isn't the time
21 to do it. Dennis, anything else, from your--

22 MEMBER BLEY: Oh, not a thing. Well, no, I
23 mean, I'm, I'm serious. I, I'm, I mean, We're wring
24 our hands over something--I'm not being smug about it,
25 but I mean, you go back and you read the documents and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 in fact this is, is unique in our industry so far, it
2 might not be in the future to have a system that's
3 whole design approach is based on the PRA and then
4 this seems inconsistent with that.

5 CHAIRMAN RAY: Well, yes. And I mean, I
6 could comment that I went into a plant everyday where
7 the maintenance Rule applied and we had a, the, the
8 risk in the plant that day depending on what
9 maintenance and what other failures that occurred
10 during the night and all that kind of stuff, and.

11 You know, we tried to pay attention to it,
12 but we didn't shut the plant down. Because of some
13 particularly high risk that day, usually it was a
14 turbine driven aux feed pump that was the culprit, but
15 anyway.

16 So, we, I think we got all the facts
17 before us, and if there's nothing more, we should move
18 on. Anything more you guys have?

19 MR. CUMMINS: Can I make one more comment?

20 CHAIRMAN RAY: Yes.

21 MR. CUMMINS: The, the PMS has reliability
22 equal to the PRA results of the current operating
23 fleet, by itself. By itself. With no DAS.

24 MEMBER BLEY: If We're right about common
25 cause, for which we don't have enough experience to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 know if We're right or wrong--

2 MR. CUMMINS: So, I mean, whatever. Yes.
3 That's true.

4 MEMBER BLEY: That's right.

5 CHAIRMAN RAY: Well, learning to live in
6 this world of much more, much safer plants. Okay. So,
7 comparing this plant to the plants that We're used to
8 operating probably isn't very useful most of the time.

9 Okay, with that I've got a short window
10 here when we have an opportunity for Westinghouse to
11 respond to Said's earlier question. Are you guys done?
12 Eileen? All right. Did you have something more--we had
13 a summary slide. Please, go ahead.

14 MR. ROGGENBRODT: Staff considers the
15 watchdog timer issue resolved. We PMS maximum loading
16 issue resolved. ADS block signal issue resolved, and
17 DAS attributes are again, were certified in Revision
18 15 design control document.

19 CHAIRMAN RAY: I understand. Very good.

20 MR. ROGGENBRODT: With that, that's the end
21 of our presentation. Thank you.

22 CHAIRMAN RAY: Thank you. Okay, with that
23 we'll ask Westinghouse to provide us some instant
24 follow up or feed back to question earlier today.

25 MR. OFSTUN: Okay, this is Rick Ofstun

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 again, from Westinghouse. I had time to confer with
2 colleagues back in Pittsburgh, and they, they reviewed
3 the, the kind of steady state calculation and
4 determined that we were off on that value. They
5 calculated a new time of about 353 seconds instead of
6 the 337 seconds.

7 CHAIRMAN ABDEL-KHALIK: What I calculated
8 was 378 seconds.

9 MR. OFSTUN: Okay. This, this was a
10 preliminary unverified calculation. They just did it
11 on the fly. Then I asked them to check what was used
12 in the evaluation model and the value that's used is
13 410 seconds. So, we are--

14 CHAIRMAN ABDEL--KHALIK: In terms of
15 calculating the pressure history?

16 MR. OFSTUN: Yes. And then I also asked
17 Meghan to run a case extending the time for steady
18 state coverage out to eight minutes instead of either
19 five and a half of six or whatever we're coming up
20 with here. So, 480 seconds.

21 And, and the result of that was that the
22 pressure, the peak pressure increased by approximately
23 .5 psi, so we're not very, we're not real sensitive to
24 that time of steady state water coverage.

25 CHAIRMAN ABDEL--KHALIK: How much margin

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 did you originally have, and how much margin do you
2 now have?

3 MR. OFSTUN: We have--I'm not sure exactly,
4 I think it's about one and a half to two psi.

5 CHAIRMAN ABDEL--KHALIK: So, you know, a
6 half psi increase is a--

7 MR. OFSTUN: Is about a third of our
8 margin, yes.

9 CHAIRMAN ABDEL--KHALIK: Okay. All right,
10 thank you.

11 MR. OFSTUN: Is that all?

12 CHAIRMAN RAY: I believe so. Anybody else
13 have a question they'd like to ask on that subject?
14 Have a good trip.

15 MR. OFSTUN: Thank you.

16 CHAIRMAN ABDEL--KHALIK: How often is this
17 going to be documented?

18 MR. OFSTUN: Well, we're going to take out,
19 we have a corrective action process so we'll have to
20 take out a, it's called an I.R. report, and then do
21 all the paperwork, but then I think we'll have to
22 update the report. We have another update to that
23 report going out soon anyway, to include the corrected
24 time in the report.

25 MR. CUMMINS: So that, is, what, a 400,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 evaluation model selection is in the WCAP submitted to
2 the staff, or, or somehow submitted, or--

3 MR. OFSTUN: The--the 337--

4 MR. CUMMINS: No, the 400--

5 MR. OFSTUN: --the second number iwll have
6 to change to 365 or whatever it turns out to be. You
7 need--but the model, the, the--

8 MR. CUMMINS: The results of the analysis
9 have been submitted to the staff, or have been audited
10 by the staff, or--

11 MR. OFSTUN: No changes are required to, to
12 that analysis.

13 MR. CUMMINS: This will be an internal
14 change.

15 MR. OFSTUN: Yes, it will be an internal
16 change and then the topical report will have to be
17 changed--yes, adjust to different time.

18 CHAIRMAN RAY: All right. Thank you. Ed, do
19 you guys have anything more that you want to say
20 today?

21 MR. CUMMINS: No thank you.

22 CHAIRMAN RAY: Eileen?

23 MS. MCKENNA: No, sir.

24 CHAIRMAN RAY: All right, we're going to--

25 VICE CHAIRMAN ARMIJO: Can I, can I ask a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 question--clarification. I, in, in kind of looking--
2 start, through the material, stuff related to the
3 pump, I came across one Westinghouse technical report
4 that I, I, may not understand.

5 And that is, with relationship to the
6 primary loop piping materials. And there's some
7 changes where they now refer to 300 series stainless
8 steels and previous versions, they refer to low carbon
9 versions. And, the question is, is, is it
10 Westinghouse's intent to use the, the high carbon
11 stainless steels for the piping and coolant boundary?

12 CHAIRMAN RAY: Okay--

13 VICE CHAIRMAN ARMIJO: And, and, and, is,
14 is that okay with the staff.

15 CHAIRMAN RAY: Well, let's-let's first
16 direct the question the way he did it, which is to the
17 Applicant, and then--

18 MR. CUMMINS: Okay.

19 CHAIRMAN RAY: You may need to reframe it,
20 he may not have been listening--

21 MR. CUMMINS: I did listen. I think the
22 question is, what is the material for the primary loop
23 piping, and, and, I know it's a stainless steel
24 forging, but I don't know what it is and we'll have to
25 find out.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 VICE CHAIRMAN ARMIJO: Well, it, it says in
2 these tables, it, it, what used to be the low carbon
3 grade, the 316 and 304, it can now be the high carbon
4 grades, which we know have caused enormous propblems
5 on BWRs but it's also caused problems in some PWR's.
6 And so the question is, is, is that really
7 Westinghouse's intent, and the justification has to do
8 something with availability and cost and stuff like
9 that, and just, and it's part of the DCD section 5.2
10 table 5.2.1, so, you know, I, I just think that's,
11 just want to know if both Westinghouse and the staff
12 really intend to use these more susceptible materials
13 in those, in those components.

14 CHAIRMAN RAY: Okay. All right.

15 MR. CUMMINS: We'll have to look this one
16 up.

17 VICE CHAIRMAN ARMIJO: Okay. If you get
18 back to us, I'd appreciate it.

19 CHAIRMAN RAY: So we'll look for you to
20 give us an answer tomorrow.

21 VICE CHAIRMAN ARMIJO: I can't believe that
22 you would want to use the high carbon.

23 CHAIRMAN RAY: Okay. Eileen, we want to ask
24 you for a response--

25 MS. MCKENNA: Yes, I don't have the right

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 people here to do that.

2 CHAIRMAN RAY: Did you follow it well
3 enough--

4 MS. MCKENNA: I think so, it was what the
5 primary loop piping material, whether it was this high
6 carbon, and what the, the, that was--

7 CHAIRMAN RAY: Yes. We'll ask was he enough
8 to respond before hearing anything from you guys, but
9 that'll be a followup item that we'll have to look at
10 tomorrow probably. While we're still on the record,
11 and then we'll end, being on the record, I wanted to
12 do at least two things.

13 And then, anything else that members want
14 done. One will be to just scan through all the action
15 items that we created, not attempting to read them in
16 any detail. In fact, you can take this and look at it
17 later in more detail, if you wish, to, in order to
18 make sure that we've identified anything of importance
19 to any of the members.

20 And we've overlooked that. Another item
21 that I wanted to do at this point in time was to say
22 that in these discussions, particularly here at this
23 point in time, I've tried to emphasize the technical
24 issue at hand and the response to it, whatever that
25 may be.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 There is left open the question that has
2 been asked several times by Bill and Charlie, for
3 example. Well, how does this get captured? And, I
4 don't want to pick on any one item, but I do trust
5 that where the ACRS is asked a question, we've gotten
6 a response.

7 Probably we will reflect that that
8 occurred in our letter, that there will then be some
9 way of ensuring that it in fact gets done. I can't
10 believe that that wouldn't be the case. But as to
11 whether or not it's going to be in ITAAC, if that's
12 the right vehicle, we can have that discussion further
13 if anybody wishes to do so.

14 But, I'm not sure we want to try and
15 prescribe that either in our letter or to decide it
16 here. Do you have any comment, Eileen?

17 MS. MCKENNA: I, I think that that's true,
18 I'd hope that would be true. I think certainly if
19 there was a lot of information has already been
20 provided to the Committee you have it, and there's no
21 future tense, if you will, to it.

22 There is a few like the test report for
23 the, the test you have to be done on the 18 manganese
24 chromete material that obviously has, hasn't, is not
25 available at this point, and, and Westinghouse has

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 made a commitment to provide that.

2 And we will be sure to follow up and make
3 sure that they did and we provide it to the Committee.
4 I think in some other cases, there were changes for
5 example, the issue about the PMS response time, where
6 there was an actual change to the ITAAC that's been
7 proposed that was in the response to an issue that had
8 come up to the Committee and that that's how that is
9 being reflected in the DCD. So, I think there's a
10 range of, of methods to capture this information
11 depending on what it is.

12 CHAIRMAN RAY: Yes, so, you know, I think
13 it would be, yes, if we said nothing about whatever
14 the issue happened to be, then perhaps people could
15 say, well, you know, we answered their question but
16 We're not bound to do it in any particular way or what
17 not.

18 But if we do say, well, we asked this
19 question, we got this answer, then I think its'
20 between the staff and the Applicant to decide how to
21 memorialize that from that point forward.

22 Okay. With that, then, as I say, everyone
23 has received a copy of the action items. I don't plan
24 to plow through these item by item by item. But I did
25 want to afford members the opportunity to--Weidong and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 I believe that we've addressed all these items.

2 I believe the staff and Westinghouse think
3 that we have. And, I just want to tender this to you,
4 and say if that's not the case, either speak up now or
5 advise us later that, but hopefully as soon as
6 possible, that there's something that we haven't yet
7 addressed fully.

8 Okay. Well, with that, let me ask if
9 there's anything else to be discussed on the record. I
10 hope to recall Sanjoy here after we go for the record,
11 get from him some discussion that may prompt some
12 feedback from you relative to where he stands on his
13 letter.

14 I'll do the same on the status of a letter
15 addressing the Amendment application. And then we'll
16 be miraculously done for the day. Anything else? Okay,
17 with that, we will adjourn the meeting, and we will
18 continue the discussion briefly of the status of work
19 for the preparation for the full Committee.

20 (Whereupon, the above entitled matter was
21 taken off the record at 3:21 p.m.)
22
23
24
25

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1
2
3
4
5
6
7
8
9
10
11
12
13

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701



United States Nuclear Regulatory Commission

Protecting People and the Environment

Presentation to the ACRS SubCommittee

**Westinghouse AP1000 Design Certification
Amendment Application Review
Seismic Design Requirements – Controls**

December 1, 2010

Outline

- **REVISION 15**
- **TIER 2* IN REVISION 15**
- **CHANGES FOR REVISION 17 (AND 18)**
- **STATUS OF STAFF REVIEW**

Revision 15

- Revision 15 had seismic design information in Tier 1, Tier 2* and the majority as Tier 2
- Tier 1 section 3.3 (Buildings)
 - design basis loads
 - key dimensions
 - critical sections
 - figures
- Tier 2* designation for information in sections 3.7, 3.8 and 3H, for information such as descriptions, criteria, member forces, required plate thicknesses, stress results

Tier 2* in Revision 15 (and Appendix D to Part 52)

- Specific information is marked as tier 2*, requiring prior NRC approval if a COL wants to change it
- Broadly listed in the DC rule as:
 - Nuclear Island Structural dimensions
 - Design summary of critical sections
 - Use of ACI-318, 349, and AISC-690
 - Definition of critical locations and thicknesses
 - Seismic qualification methods and standards
 - Piping design acceptance criteria

Changes for Revision 17 (and 18)

- Due to reanalysis for range of soil conditions, and new design for shield building, the specific Tier 2* details needed to updated
- Realization that Tier 2* application to member forces and stress results was overly restrictive
- As part of RAI responses, submittal of shield building report, Westinghouse proposed DCD markups to reflect new design and analysis information, including subset to be designated as tier 2*

Staff Review

- Staff technical review focused on information in technical reports
- Staff general agreement about Tier 2* for critical sections, required reinforcements, but not on stress results
- Staff is in process of detailed review of W proposals, as planned for Revision 18
- Any changes would be reflected in future DCD revision

Construction Oversight

- COL application of change control processes
- Engineering Design Verification Inspection
- Construction Inspection Program
- ITAAC Inspection Program

AP1000 Reactor Coolant Pump Flywheel Action #4 Closure


December 1st, 2010

Safety of the Flywheel Retaining Ring Component

- Locked rotor analyses completed and reviewed and accepted by NRC staff
- Safety consequences accepted
- Risk assessment accepted
- A625 Ni-based alloy enclosure has proven primary water SCC resistance
- Low service temperature (300F design)
- Materials
 - Austenitic stainless steel – not duplex structure, no martensitic structure
 - Manganese is austenitic stabilizer to address cold work
 - Immune to boric acid corrosion
 - Widely used in higher temperature primary water applications
 - Corrosion data applicable to potential exposure to upset primary water conditions

Back-up Slides

AP1000 RCP
CONFIGURATION FOR
PROTOTYPE TEST
APRIL 15, 2009




AP1000 RCP Outline


Upper Flywheel Assembly

Lower Flywheel Assembly

Flywheel Configurations



DCD Revision 15
Depleted Uranium Alloy
Enclosure



DCD Revision 17
Inner Hub
Heavy Tungsten Alloy
Outer Retainer Ring
Enclosure Plates and Shell

Flywheel Materials

	Shaft	Inner Hub	Flywheel	Retainer Ring	Enclosure
DCD Rev 15	403 SST	N/A	Depleted Uranium Alloy U-2Mo	N/A	Alloy 690
DCD Rev 17	403 SST	403 SST	Tungsten Heavy Alloy	18 Ni Maraging Steel	Alloy 625
Post DCD R17 (RAI 5/09)	403 SST	403 SST	Tungsten Heavy Alloy	18Cr-18Mn	Alloy 625

Flywheel Materials Specifications

	Shaft	Inner Hub	Flywheel	Retainer Ring	Enclosure
DCD Rev 15	ASTM 336 – Gr F6	N/A	Design Spec Specified	N/A	ASTM B168 and B564
DCD Rev 17	ASTM 336 – Gr F6	ASTM 336 – Gr F6	ASTM B777 Class 4	AMS 6519	ASTM B443 and B564
Post DCD R17 (RAI 5/09)	ASTM 336 – Gr F6	ASTM 336 – Gr F6	ASTM B777 Class 4	ASTM A289	ASTM B443 and B564

Discussion of Material Changes

- **High Density Flywheel Material Change – Depleted Uranium to Tungsten Heavy Alloy**
 - Increase in Required Inertia - As the RCP Design was Finalized, Friction Losses Increased Due to Increased Power Requirements, Detailed Loss Calculations, etc.
 - Depleted Uranium was Structural Component – Increase in Inertia Required Increase in Diameter Which Resulted in High Stress Levels
 - Evaluated Alternate Materials – Tungsten Heavy Alloy
 - Advantages of Tungsten Heavy Alloy – Multiple Suppliers, Known Material Properties/Fracture Toughness (ASTM), Volumetric Examinations Standard, No Environmental/Health Issues, Owning/Handling Not Regulated
 - DCD Revision 17 Flywheel Configuration Changed Such that High Density Material is Not a Structural Part
 - Retainer Ring Holds Tungsten Heavy Alloy Segments, Only Structural Components are Ring and Inner Hub

Discussion of Material Changes (Con.)

- Flywheel Enclosure
 - Change from Alloy 690 to Alloy 625
 - Advantages of Alloy 625 – Lower Coefficient of Thermal Expansion (Reduces Stresses in Enclosure); Higher Yield Strength; Easier to Weld
- Retainer Ring
 - DCD Revision 17 – 18 Ni Maraging Steel for High Strength
 - Flywheel Mockup for Manufacturability and Demonstrate Balancing
 - Cracked Retainer Ring
 - Hydrogen Embrittlement/Stress Corrosion Cracking
 - Retainer Ring Material Change Included in Response to RCP RAI in May 2009
 - Ring Changed to 18Cr-18Mn
 - Material Developed for Retainer Ring Applications in Generators Because of Cracking in the Materials in Use (18Mn-5Cr)
 - Not Susceptible to Corrosion or Hydrogen Assisted Stress Corrosion Cracking
 - Lower Strength Requires Thicker Retainer Ring, Reduces Tungsten Alloy Mass

Summary of Inertia Changes

	Rotating Inertia (lb-ft ²)	Reason for Change
DCD Rev 15	16,500	
DCD Rev 17	23,510	Detailed Design- Additional Losses
Post DCD R17 (RAI 5/09)	23,110	Change in Retainer Ring Reduced Tungsten Volume/Mass

- Flow Coastdown Requirements in Design Spec Have Not Changed
- Calculated Pump Coastdown Flows Have Always Been Higher Than Those Used in the Safety Analyses

Flywheel Inspection/Testing Requirements

- Each Structural Component Inspected Prior to Final Assembly According to Requirements In Section III, NB-2500 of ASME Code
 - Inner Hub
 - Ultrasonic Examination
 - Magnetic Particle Examination
 - Liquid Penetrant Examination of Inside Surface After Finishing Operations
 - Retainer Ring
 - Liquid Penetrant Examination
 - Ultrasonic Examination
 - Liquid Penetrant Examination of Outside Surface After Finishing Operations
 - Enclosure (Non-Structural)
 - Dye Penetrant of Welds
 - Enclosure Leak Tested
- Impact Testing – Inner Hub and Retainer Ring Material
- No In-Service Inspection Required
 - Postulated Flywheel Missiles are Contained Within the Pressure Boundary
 - In-Service Inspection of the Flywheel Would Require Pump Removal, Disassembly, and Removal of Flywheel Enclosures
 - High Radiation Exposure

Flywheel Missile Analyses

- Follows Procedure Used for Turbine Disk Fractures (Hagg and Sankey, “The Containment of Disk Burst Fragments by Cylindrical Shells”)
 - Stage 1 – Inelastic Impact and Transfer of Momentum to the Pressure Boundary (PB)
 - Stage 2 – Dissipation of Energy in Plastic Tensile Strain in the PB
 - Calculation Assumptions
 - Ignore the Retainer Ring and Enclosure Components
 - Minimum ASME Material Strength Properties @ Design Temperature
 - All Heavy Alloy Segments Impact the PB
 - Upper Flywheel – Check Penetration Through Thermal Barrier and Stator Closure
 - Lower Flywheel – Check Penetration Through Stator Lower Flange
 - DCD Rev 17 Minimum Margin is 1.8 for Upper Flywheel Stage 2
 - Minimum Margin for Flywheel Design Change in Retainer Ring Material (May 2009 RAI Response) Increased to 2.0 for Upper Flywheel Stage 2 Due to Small Changes in Tungsten Alloy Segments and Pressure Boundary

AP1000 Reactor Coolant Pump Flywheel

April 2010

Purpose

- Respond to ACRS request for information on the reactor coolant pump (RCP) flywheel failure frequency used in the AP1000 Probabilistic Risk Assessment (PRA) model

AP1000 PRA Model Information

- AP1000 PRA does not model the failure of the RCP flywheel
 - Not modeled as an initiating event
 - Not modeled as a consequence of another initiating event or as a random failure during another initiating event
- A RCP flywheel failure frequency has not been used in the AP1000 PRA model

AP1000 PRA Model Information

- Not explicitly considering the failure of the RCP flywheel is consistent with current operating plant PRA models
- RCP flywheel failure is considered a very low probability event
- RCP flywheel failure could result in:
 - A transient event
 - A loss of coolant accident (LOCA) if the reactor coolant system is damaged

AP1000 PRA Model Information

- The frequencies of transient events and LOCAs from other sources is much larger than from RCP flywheel failures, therefore:
 - the impact on plant risk is negligible
 - RCP flywheel failure is not explicitly modeled