

**Official Transcript of Proceedings**  
**NUCLEAR REGULATORY COMMISSION**

Title:                   Advisory Committee on Reactor Safeguards  
                              580th Meeting

Docket Number:   (n/a)

Location:                 Rockville, Maryland

Date:                    Thursday, February 10, 2011

Work Order No.:        NRC-700

Pages 1-376

**NEAL R. GROSS AND CO., INC.**  
**Court Reporters and Transcribers**  
**1323 Rhode Island Avenue, N.W.**  
**Washington, D.C. 20005**  
**(202) 234-4433**

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S  
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, as reported herein, is a record of the discussions recorded at the meeting.

This transcript has not been reviewed, corrected, and edited, and it may contain inaccuracies.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION  
+ + + + +  
580TH MEETING  
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS  
(ACRS)  
OPEN SESSION  
+ + + + +  
THURSDAY  
FEBRUARY 10, 2011  
+ + + + +  
ROCKVILLE, MARYLAND  
+ + + + +

The Advisory Committee met at the Nuclear Regulatory Commission, Two White Flint North, Room T2B1, 11545 Rockville Pike, at 8:30 a.m., Said Abdel-Khalik, Chairman, presiding.

COMMITTEE MEMBERS: SAID ABDEL-KHALIK, Chairman

J. SAM ARMIJO, Vice Chairman

SANJOY BANERJEE, Member

DENNIS C. BLEY, Member

MICHAEL L. CORRADINI, Member

DANA A. POWERS, Member

HAROLD B. RAY, Member

JOY REMPE, Member

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MICHAEL T. RYAN, Member

2 WILLIAM J. SHACK, Member

3 JOHN D. SIEBER, Member

4 NRC STAFF PRESENT:

5 FRANK AKSTULEWICZ

6 MARISSA BAILEY

7 OM CHOPRA, NRO/DE/EEB

8 DENNIS R. DAMON, NMSS

9 MELANIE GALLOWAY, NRR/DLR

10 TONY GARDNER, NRR/DLR

11 DON HABIB, NRO/DNR/NWEI

12 CHARLES S. HINSON, NRO/DCIP/CHPB

13 ALLEN HISER, NRR/DLR

14 BRIAN HOLIAN, NRR/DLR

15 WILLIAM HOLSTON, NRR/DLR/RAPB

16 YONG LI

17 JAMES MEDOFF, NRR/DLR/RARB

18 CLIFFORD MUNSON\*

19 SHI JENG PENG, NRO/DSRA/SPCV

20 LISA REGNER, NRR/DLR

21 STEVE SCHAFFER

22 JOE SEBROSKY, NRO/DNRL/NWEI

23 KEN SEE, NRO/OSER/RHEB

24 GERRY L. STIREWALL\*

25 LARRY WHEELER, NRO/DSRA/SBP

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

NED WRIGHT, NSIR/DPR  
DAVE WRONA, NRR/DLR  
KENT L. HOWARD, SR., Designated Federal Official  
for Palo Verde Portion of the Meeting  
WEIDONG WANG, Designated Federal Official for  
Summer Section  
MICHAEL BENSON, Designated Federal Official for  
ISA/PRA Section  
JOHN LAI, Designated Federal Official for NFPA  
805 Section

ALSO PRESENT:

ERIC BLOCHER, STARS  
TIM BONNETTE, South Carolina Electric & Gas  
(SCE&G)  
RANDAL BOYD, Arizona Public Service Company  
(APS)  
BIFF BRADLEY, NEI  
ANGELOS FINDIKAKIS, Bechtel Power  
JOHN HESSER, APS  
MARK HYPSE, APS  
ANGELA KRAINIK, APS  
JAMES C. LaBORDE, SCE&G  
SCOTT LINDVALL, WLA\*  
LARS LIPPARD, Shaw Group\*  
JOE LITEHISER, Bechtel Power\*

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26

ALSO PRESENT

JIM MCGREGOR, Shaw Group\*

ROBIN MCGUIRE, Risk Engineering Associates\*

GLENN MICHAEL, APS

AMY M. MONROE, SCE&G

AL PAGLIA, SCE&G

SHABBIR PITTALWALA, APS

MARK RADSPINNER, APS

JANET R. SCHLUETER, NEI

TIM SCHMIDT, SCE&G

MARK STELLA, Westinghouse

STEPHEN SUMMER, SCANA

DOUG TRUE, ERIN Engineering

CHARLES VAUGHAN, NEI

RICK WACHOWIAK, EPRI

BOB WHORTON, SCE&G

\*Present via telephone

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

C-O-N-T-E-N-T-S

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

1) Opening Remarks by the ACRS Chairman .....7

2) Final Safety Evaluation Report Associated with  
the License Renewal Application for the  
Palo Verde Nuclear Generating Station  
2.1) Remarks by the Subcommittee Chairman ....9  
2.2) Briefing by and discussions with  
representatives of the NRC staff and Arizona  
Public Service Company regarding the final  
Safety Evaluation Report associated with the  
License Renewal Application for the Palo  
Verde Nuclear Generating Station .....10

3) Final Safety Evaluation Report Associated with  
the Virgil C. Summer Units 2 and 3 Combined  
License Application  
3.1) Remarks by the Subcommittee Chairman  
3.2) Briefing by and discussions with  
representatives of the NRC staff and South  
Carolina Electric & Gas regarding the final  
Safety Evaluation Report associated with the  
Virgil C. Summer Units 2 and 3 Combined License  
Application .....57

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 4) Comparison of Integrated Safety Analyses (ISAs)  
2 for Fuel Cycle Facilities and Probabilistic  
3 Risk Assessments (PRAs) for Reactors

4 4.1) Remarks by the Subcommittee Chairman

5 4.2) Briefing by and discussions with  
6 representatives of the NRC staff regarding a  
7 comparison of ISAs for fuel cycle facilities and  
8 PRAs for reactors including a critical  
9 evaluation of how ISAs differ from PRAs 186

10 5) Current State of Licensee Efforts to Transition  
11 to National Fire Protection Association (NFPA)

12 5.1) Remarks by the Subcommittee Chairman

13 5.2) Briefing by and discussions with  
14 representatives of the Industry and the NRC  
15 staff regarding the current state of licensee  
16 efforts to transition to NFPA-805 258

17  
18  
19  
20  
21  
22  
23  
24  
25

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701



1  
2 P-R-O-C-E-E-D-I-N-G-S

3 8:29 a.m.

4 CHAIRMAN ABDEL-KHALIK: The meeting will  
5 now come to order. This is the first day of the 580th  
6 meeting of the Advisory Committee on Reactor  
7 Safeguards. During today's meeting the Committee will  
8 consider the following: (1) Final Safety Evaluation  
9 Report associated with the license renewal application  
10 for the Palo Verde Nuclear Generating Station. (2)  
11 Final Safety Evaluation Report associated with the  
12 Virgil C. Summer Units 2 and 3 combined license  
13 application. (3) Comparison of integrated safety  
14 analyses (ISAs) for fuel cycle facilities and  
15 probabilistic risk assessments (PRAs) for Reactors.  
16 (4) Current state of licensee efforts to transition  
17 to National Fire Protection Association (NFPA 805).  
18 And (5) Preparation of ACRS reports.

19 This meeting is being conducted in  
20 accordance with the provisions of the Federal Advisory  
21 Committee Act. Mr. Kent Howard is the Designated  
22 Federal Official for the initial portion of the  
23 meeting.

24 Portions of the sessions dealing with the  
25 Final Safety Evaluation Report associated with the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Virgil C. Summer Units 2 and 3 combined license  
2 application may be closed to protect information  
3 designated as propriety by Westinghouse.

4 We have received written comments from Mr.  
5 Bob Leyse regarding the Palo Verde license renewal  
6 application. Mr. Charles Vaughan of the Nuclear  
7 Energy Institute will provide an oral statement  
8 regarding the comparison of ISAs for fuel cycle  
9 facilities and PRAs for reactors.

10 There will be a phone bridge line. To  
11 preclude interruption of the meeting, the phone will  
12 be placed in a listen-only mode during the  
13 presentations and Committee discussion.

14 A transcript of portions of the meeting is  
15 being kept and it is requested that the speakers use  
16 one of the microphones, identify themselves, and speak  
17 with sufficient clarity and volume so that they can be  
18 readily heard.

19 We will now proceed to the first item on  
20 the agenda, Final Safety Evaluation Report associated  
21 with the license renewal application for the Palo  
22 Verde Nuclear Generating Station. And Mr. Sieber will  
23 lead us through that discussion.

24 MEMBER SIEBER: Thank you very much, Mr.  
25 Chairman. Before we begin this morning, Member Harold

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 Ray would like to make a statement.

2 MEMBER RAY: Thank you, Jack. Due to a  
3 conflict, I will not participate in the deliberations  
4 on Palo Verde.

5 MEMBER SIEBER: Okay, thank you, Mr. Ray.  
6 We had a Subcommittee meeting on the Palo Verde  
7 license renewal on September 8th of last year. At  
8 that time there was one open item and five  
9 confirmatory items in the Safety Evaluation Report and  
10 I believe we will hear about how those items have been  
11 resolved this morning.

12 In addition to those items, the staff  
13 reviewed five additional items related to first  
14 inaccessible medium-voltage cables not subject to 10  
15 CFR 50.49 Environmental Qualification Requirements  
16 Program; second, buried piping in tanks inspection  
17 program; third, NUREG/CR-6260 limiting locations;  
18 fourth, selective leaching; and fifth, steam generator  
19 tube denting and weld susceptible to primary water  
20 stress corrosion cracking after the September  
21 Subcommittee meeting.

22 I believe that both the Applicant and the  
23 staff are prepared to discuss them.

24 As stated by the Chairman, we have  
25 received written comments from a member of the public,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 Mr. Bob Leyse. Mr. Leyse's written comments have been  
2 provided to you. They're on the table before each one  
3 of you and they will be considered during Committee  
4 deliberations on this matter.

5 With that, I would like to turn the  
6 meeting over to Mr. Brian Holian, Division Director  
7 for the Division of License Renewal.

8 Brian?

9 MR. HOLIAN: Yes, thank you, Mr. Sieber.  
10 Thank you, Chairman, and good morning, members of the  
11 Committee. My name is Brian Holian. I am the  
12 Director of the Division of License Renewal. We're  
13 here today for the second of three STARS plants that  
14 have come in for license renewal. We had Wolf Creek  
15 several years ago, Palo Verde, and Diablo Canyon just  
16 came to the Subcommittee yesterday afternoon.

17 The agenda for today is to have brief  
18 introductions by myself and then right to the  
19 Applicant for the discussion of the open and  
20 confirmatory items, followed by the staff, where we'll  
21 give our assessment of closing out the Safety  
22 Evaluation Report.

23 Brief introductions now: to my left is  
24 Melanie Galloway, the Deputy Director of the Division  
25 of License Renewal. Behind me is the Branch Chief,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 Projects Branch Chief for Palo Verde. Palo Verde is  
2 one of the plants, Mr. Dave Wrona. And next to him is  
3 Lisa Regner, the Senior Project Manager. And she'll  
4 be leading the staff's presentation when we go next.

5 As was mentioned by Mr. Sieber, the one  
6 open item dealt with metal fatigue issues, very  
7 similar to what you saw, the Subcommittee members saw  
8 yesterday on Diablo Canyon. Some of those were  
9 repeated on that application from STARS. We had a  
10 good discussion yesterday with the Subcommittee on  
11 those and at the Subcommittee for Palo Verde a couple  
12 of months ago. We'll address how that was closed out.

13 The confirmatory items were very similar  
14 to some of the items that we've had on recent  
15 operating experience. The staff wants to verify that  
16 they're proper and updated aging management programs  
17 were in place. So we'll cover that as we go on.

18 With that I'll save any other comments we  
19 have or particular items for the beginning of the  
20 staff's presentation and with that, I'll turn it over  
21 to Mr. John Hesser, the site VP for Palo Verde.

22 MR. HESSER: Thank you, Brian. Mr.  
23 Chairman and honorable members of the ACRS, good  
24 morning. I'm John Hesser, the Vice President of  
25 Nuclear Engineering at Palo Verde and I am the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 executive sponsor for our license renewal application.

2 Next slide, please.

3 We are pleased to be here today to provide  
4 you a discussion of our license renewal application  
5 and our Draft Safety Evaluation Report. Here with me  
6 to facilitate that discussion and to answer any  
7 questions you might have are Ms. Angela Krainik, our  
8 manager for license renewal at Palo Verde; Mr. Eric  
9 Blocher, who is our project manager for our license  
10 renewal application; Mr. Glenn Michael, who is our  
11 lead licensing engineer for license renewal; and to my  
12 right is Mr. Mark Radspinner. He's the supervisor of  
13 system engineering, specifically in the mechanical and  
14 NSSS section.

15 Also with me today is several members of  
16 our technical and operations staff at Palo Verde. I  
17 would like to introduce one of those members, Mr.  
18 Randal Boyd.

19 Randal, would you stand up, please?

20 Randal is our lead engineer for the  
21 implementing of our living license renewal program at  
22 Palo Verde. He takes care of all aspects of that. So  
23 he'll be with us today and may enter into the  
24 conversation.

25 Next slide.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           This is the agenda for our presentation.  
2 I will give you a very brief station description  
3 overview as a reminder from our Subcommittee meeting,  
4 along with a time line on our current license. Then  
5 Ms. Krainik will discuss the license renewal  
6 application open items and confirmatory, along with  
7 the resolution of those five additional items  
8 previously mentioned, and will facilitate any  
9 questions that you may have. And if time allows, I'll  
10 make some concluding remarks.

11           At Palo Verde, our mission is to safely  
12 and efficiently generate electricity for the long  
13 term. If you please note, the word "safely" is  
14 capitalized and underscored. This is done on purpose  
15 so that it remains a constant presence to the station  
16 leadership and personnel, that safety and the  
17 protection of health and safety of the public is job  
18 one at all times. And that now includes license  
19 renewal and the period of extended operations that we  
20 hope to be granted for the long term.

21           Next slide, please.

22           At Palo Verde, we have three units that  
23 are common design. They all work with a common  
24 operating procedure and we maintain the configuration  
25 at Palo Verde as close to similar as possible. As

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 noted in our license renewal application, we do have  
2 minor differences such as field-routed conduit and  
3 piping, but they're all done to a common design  
4 criteria.

5 Each unit is rated at 3,990 megawatts  
6 thermal and 1346 megawatts electric. Our nuclear  
7 steam supply system is supplied by combustion  
8 engineering, is a System 80 design. The turbine  
9 generator is by General Electric and Bechtel Power  
10 Corporation was the designer of our balance of plant  
11 and the constructor of record.

12 Next slide, please.

13 Our initial construction permit was issued  
14 on May 25, 1976 and our operating license was issued  
15 in 1985, 1986, and 1987, respective of Units 1, 2, and  
16 3. Our current license will expire in 2025, '26, and  
17 '27, again respective of Units 1, 2, and 3.

18 Currently at Palo Verde, all three units  
19 are in their 16th operating cycle. I would note that  
20 we're on an 18-month fuel cycle and that we have in  
21 the spring Unit 2 is scheduled for refueling outage  
22 and Unit 1 is scheduled in the fall for its refueling  
23 outage. Today, all three units are operating at 100  
24 percent and there are no challenges leading to  
25 shutdown today.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701



1           And if you have no questions for me, I'll  
2 turn it over to Ms. Angela Krainik who will lead us  
3 through our discussion.

4           MS. KRAINIK:       John, thanks for the  
5 introduction.

6           Chairman and members of the ACRS, as John  
7 stated, I've had the opportunity to lead the license  
8 renewal team at Palo Verde and have been the primary  
9 interface with the NRC staff during their review and  
10 response to their inquiries for information.

11          I'll be providing an overview, as John  
12 mentioned, of the SER items that were discussed  
13 earlier, mentioned earlier, I should say, and then  
14 provide an overview of our implementation status to  
15 date.

16          The SER was issued on January 11th with  
17 the staff's conclusion and review that addressed both  
18 the open and the confirmatory items from the SER from  
19 open items that was issued in August. We did have one  
20 open item which was a compilation of 18 RAIs or  
21 requests for additional information in the area of  
22 metal fatigue. All of these RAIs were responded to  
23 and after staff review, the open item has been closed.

24          As I discussed in the Subcommittee  
25 meeting, we had to change the presentation and the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 discussion of our metal fatigue monitoring program in  
2 our license renewal application. We added consistency  
3 and some clarity to it in response to the questions  
4 from the staff. As a result, we believe that we ended  
5 up with an improved program for fatigue monitoring  
6 under our aging management program.

7 We also had five confirmatory items in the  
8 SER with open items. We responded to these and/or  
9 completed actions and provided the documentation to  
10 the staff, the SER documents, the staff's review and  
11 completion or closure of those as well. For example,  
12 one of the items that we had had to do with our spray  
13 chemical addition tanks that we needed to drain. We  
14 have identified that some fluid containing a small  
15 amount of hydrazine in previously abandoned tanks and  
16 piping was left from the prior flushing operations.  
17 We had committed to drain the tanks and the piping and  
18 we did that. If you also recall, we had originally  
19 intended to have it done by August of last year. We  
20 ended up having to extend that through November, but  
21 we were able to complete the evolution at all three  
22 units in October.

23 In the additional items that were  
24 mentioned earlier, these are items that following the  
25 issuance of the Safety Evaluation Report with open

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 items, we worked with the staff to address some  
2 operating experience. These are titled as additional  
3 items in the SER. I'd like to review these items, if  
4 I could.

5 The first one is the inaccessible medium  
6 voltage cabling. As a result of industry operating  
7 experience, we were asked to and we were going to  
8 include low-voltage cabling down to 480 volts within  
9 the scope of our aging management program. For buried  
10 piping and tanks, we addressed industry operating  
11 experience having to do with fluids contained within  
12 buried piping. We added a commitment that we would  
13 inspect our diesel fuel oil piping or a portion of  
14 that in the three inspection periods we have in front  
15 of us.

16 The next one has to do with the NUREG  
17 62.60 limiting locations. The staff requested that we  
18 confirm the limiting locations for the  
19 environmentally-assisted fatigue analysis for the  
20 reactor coolant pressure boundary components. We  
21 committed to complete the review and add any  
22 additional analysis as required prior to the period of  
23 extended operation.

24 For the selective leaching aging  
25 management program, we included specific details about

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 our sampling program to select locations to be  
2 inspected. And finally, we committed to address the  
3 aging of the primary side welds in our steam  
4 generators and add that to our aging management  
5 program. That's the divider bar plate welds and tube-  
6 to-tube sheet welds.

7 Although our primary focus for the license  
8 renewal program or the application has been taking --  
9 has been the application, we are taking steps, as we  
10 mentioned, to ready the plant for implementation. For  
11 the 40 aging management programs identified for Palo  
12 Verde, we have 149 station procedures and programs  
13 that will be invoked to implement these.

14 We're pretty well along with the process  
15 of incorporating the aging management activities into  
16 those programs and procedures, but we still have a few  
17 yet to complete. Although the procedures are used to  
18 implement at the station, it's also the infrastructure  
19 that needs to be ready in order to implement the  
20 programs. To this end, we've added an implementation  
21 engineer to our staff, as John has already introduced  
22 Randal. And he's been working to develop the  
23 implementation plan.

24 This is, in part, based on information  
25 that we're gathering from the industry for those that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 are in the process of either readying for  
2 implementation or those that are in their period of  
3 extended operation now, getting operating experience  
4 from them on how best to implement the programs.

5 We continue to also participate with the  
6 industry in efforts coordinated by NEI for  
7 implementation. And although not all the  
8 implementation work to date has been identified, we  
9 have added a place holder in the Palo Verde long-range  
10 plan to acknowledge that there's work scope,  
11 particularly inspections during outages that we need  
12 to make sure that we're ready for.

13 I'd like to return the presentation back  
14 to John for his closing remarks.

15 MR. HESSER: Thank you. Mr. Chairman, and  
16 members of the ACRS, that concludes our presentation.

17 I would like to on behalf of the Palo Verde owners  
18 and the station personnel recognize the hard work and  
19 rigorous reviews of the NRC staff. We truly do  
20 believe that they have positively enhanced some of our  
21 implementing programs and license renewal application  
22 at Palo Verde. As a learning organization, we do  
23 appreciate critical feedback and we'll continue to  
24 work on that application implementing programs by the  
25 review of operating experience as we go forward and I

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 would like to thank you again and appreciate your time  
2 and consideration for Palo Verde's license renewal.

3 This slide here shows again that our  
4 license will expire in 2025, '26, and '27 and if we  
5 are granted license renewal, the period of extended  
6 operation will go to 2045, '46, and '47.

7 Next slide.

8 I do again want to emphasize that at Palo  
9 Verde, we are truly committed to the safe and  
10 efficient generation of electricity for the long term.

11 And if you have any questions of us, we'll conclude.

12 MEMBER SIEBER: No questions. I think the  
13 Applicant can begin to consider life after 60.

14 MEMBER BLEY: Is there?

15 (Laughter.)

16 (Pause.)

17 MR. HOLIAN: This is Brian Holian again,  
18 Division Director, License Renewal. I'd like to  
19 complete staff introductions at the table. We do have  
20 additional staff, branch chiefs, in the audience here  
21 to support questioning, but at the table we have Bill  
22 Holston, the Senior Engineer in the Division of  
23 License Renewal, Mechanical Engineer, and deals with  
24 buried piping and other issues in the mechanical area.

25 Dr. Allen Hiser, our senior level advisor in the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Division of License Renewal will be addressing the  
2 metal fatigue issues. Lisa Regner, who I mentioned  
3 earlier, the Senior Project Manager in License  
4 Renewal, she's dealt with us on both the environmental  
5 side and the safety side for the Palo Verde review, so  
6 we thank Lisa for taking on both of those projects  
7 during the time. And finally, a new person from  
8 License Renewal at the table, Tony Gardner is our new  
9 project manager. He's been assisting Lisa throughout  
10 the Palo Verde project.

11 With that, I'll turn it over to Lisa  
12 Regner.

13 MS. REGNER: Thank you, Brian. Good  
14 morning. As Brian said, my name is Lisa Regner and  
15 I'm pleased to again be sitting before you to present  
16 the staff's findings for the Palo Verde Nuclear  
17 Generating Station license renewal project.

18 I would like to recognize the staff.  
19 There is an extensive number of staff who worked on  
20 this and some of them are in the room. Some of them  
21 are in the overflow room, so I do want to thank them  
22 for their tireless support of this review. I didn't  
23 do it on my own.

24 My agenda for this presentation includes  
25 discussions of the staff's efforts involved in closing

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the open end confirmatory items and a brief discussion  
2 of other topics of interest. I'll try not to repeat  
3 any information that you've heard before. These were  
4 all resolved following issuance of the Safety  
5 Evaluation Report with open items.

6 Last September, the staff discussed with  
7 you the Safety Evaluation Report with open items which  
8 was issued in August. Since then, all outstanding  
9 concerns have been resolved. We have received the  
10 Region IV Administrator's letter recommending license  
11 renewal. That was issued in January. And the final  
12 SER was also issued in January.

13 The lead inspector for the Palo Verde  
14 license renewal inspection, Mr. Greg Pick, and his  
15 chief, you probably heard from them yesterday at the  
16 Diablo Canyon Subcommittee meeting. They were unable  
17 to join us today. I don't think -- I'm not sure  
18 whether they got back to Texas with the weather there,  
19 but I don't see them shouting out.

20 I would like to remind you though that the  
21 Region and headquarters staff did work very well  
22 together, especially on an issue associated with the  
23 structures monitoring program which I think I  
24 discussed with most of you at the Subcommittee  
25 meeting. Headquarters staff identified concerns with

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 the frequency of inspections of external stressors  
2 during their aging management program audit and issued  
3 a request for additional information. Subsequently,  
4 and independently, the Region inspectors identified  
5 the same issue and an additional item associated with  
6 structural baseline inspections that the Applicant had  
7 not performed completely. Both Headquarters and the  
8 Region coordinated well and ensured that those  
9 concerns were resolved to everyone's satisfaction  
10 without duplication of effort.

11 MEMBER STETKAR: Lisa, I was looking  
12 through my notes here. Can you refresh our memory,  
13 were there concerns with specific structures or was it  
14 just the general frequency of monitoring?

15 MS. REGNER: There were specific  
16 structures that were more important. Obviously, the  
17 safety-related structures the staff was very concerned  
18 about making sure they were in accordance with the  
19 guidance in the American Concrete Institute 349  
20 standards which are recognized in the GALL. And that  
21 had recommended a five-year periodicity. There were  
22 other structures where the Applicant was able to  
23 provide us some technical justification for a longer  
24 time period in between those frequencies, those  
25 inspection frequencies.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MEMBER STETKAR: Thank you.

2 MS. REGNER: We now would like to discuss  
3 a few main topics from the open item, the metal  
4 fatigue analysis. Again, as a reminder, the metal  
5 fatigue analysis was an extensive and complex review  
6 for Palo Verde. During the acceptance review of the  
7 license renewal application, the staff effort was  
8 postponed due to incomplete cumulative usage factor  
9 information for Class 1 valves. APS staff submitted  
10 that information by April, but subsequently staff  
11 identified additional concerns related to design basis  
12 information inconsistencies, irregularities between  
13 metal fatigue analysis subsections and dispositioning  
14 of the time limiting age analyses.

15 Staff issued over 70 questions, held  
16 approximately 15 conference calls and conducted a  
17 public working meeting with Arizona Public Service  
18 Company staff in May of last year. And 95 percent of  
19 these efforts were all conducted before the Safety  
20 Evaluation Report with open items was issued. So by  
21 the time we met with you in September, we were really  
22 down to a few fairly minor issues that the staff still  
23 needed to resolve. And those were identified in the  
24 18 subcategories of the open item.

25 Also, the Applicant did submit an

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 extensive rewrite of major portion of the license  
2 renewal application on metal fatigue analysis which  
3 the staff needed to thoroughly review.

4 And now I would like to turn it over to  
5 Dr. Allen Hiser, so he can discuss a few of the more  
6 important concerns.

7 DR. HISER: The first thing that I want to  
8 describe, metal fatigue calculations, I think maybe  
9 more than almost any other calculation in reactor  
10 safety. You can do a simple analysis to demonstrate  
11 that you meet the acceptance criteria which in this  
12 case would be a cumulative usage factor, less than  
13 one, or a cumulative usage factor incorporating  
14 environmental effects that's less than one. If you  
15 find that you do not meet that criteria, you can less  
16 conservatively, more accurately, model certain  
17 portions of the analysis.

18 One of the issues where this is really  
19 important is the first item listed here. That's with  
20 the reactor vessel instrument nozzle. We had a lot of  
21 discussion at the Subcommittee meeting. The Applicant  
22 had calculations for one or two calculations, one for  
23 Unit 1, one for Units 2 and 3. In the case of the  
24 Unit 1 calculation, the CUF, they calculated was a  
25 0.68. So it's less than the factor of one. This

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 calculation had many simplifying assumptions in how  
2 vortex shedding in particular was treated. It met the  
3 acceptance criteria. The Applicant was satisfied with  
4 the result. For Units 2 and 3, using a more rigorous  
5 analysis, the CUF came out to a factor of 0.140.

6 There was a lot of discussion within the  
7 NRC staff had as to the differences. As part of the  
8 RAI responses, the Applicant described the differences  
9 in the calculations. Our conclusion was that both  
10 calculations were acceptable. They both met ASME code  
11 requirements. So even though there's a factor of five  
12 difference, it is simply the modeling differences  
13 between the two.

14 MEMBER CORRADINI: But both are less than  
15 one.

16 DR. HISER: Both are less than one, that's  
17 correct.

18 MEMBER CORRADINI: So has -- I'm sorry, I  
19 didn't mean to interrupt you, but I guess my thought  
20 is not knowing metal fatigue analysis, is this  
21 surprisingly different, noticeably different, normally  
22 different?

23 DR. HISER: I think given the modeling  
24 differences that were used, the simplifying  
25 assumptions that went into the Unit 1 calculation,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 this is what we would expect.

2 MEMBER CORRADINI: Okay.

3 DR. HISER: I wouldn't have been surprised  
4 if maybe they had more than a factor of 5, maybe a  
5 factor of 10 or 50 which is what we have seen in many  
6 cases.

7 MEMBER BANERJEE: Can you just briefly  
8 describe what this simplified analysis versus less  
9 simplified analysis?

10 DR. HISER: Partly, it relates to the way  
11 that the stresses due to vortex shedding were combined  
12 with other stresses. In the KC Unit 1 in one case,  
13 they did an arithmetic summation of the stresses as  
14 opposed to a vector-based summation. So that creates  
15 much higher stresses.

16 I think ultimately what was identified  
17 from the Unit 2 and 3 calculation was that the vortex  
18 shedding loads were sufficiently low that they really  
19 could be -- could have been ignored in the  
20 calculation. But in terms of completeness for Unit 1,  
21 they did include them in a very conservative manner.  
22 As I mentioned before it did meet the acceptance  
23 criteria so the plant did not do a more conservative  
24 and more realistic, more accurate calculation for Unit  
25 1.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MEMBER BANERJEE: Just the way you sum the  
2 stresses?

3 DR. HISER: I think that's the most  
4 significant contributor. Okay?

5 MEMBER BANERJEE: And the shedding  
6 phenomena is well understood?

7 DR. HISER: I believe that it is. The one  
8 concern that we had and I think the Subcommittee had  
9 expressed was it appeared that vortex shedding was not  
10 treated for Units 2 and 3 and so we wanted to verify  
11 that indeed the phenomenon was considered for all  
12 three units. It's just that the way that it was  
13 treated for Unit 1 made it a much more significant  
14 factor in the CUF calculation.

15 MEMBER BANERJEE: So the question I had  
16 was when a flow goes past a body it becomes vortices  
17 behind it.

18 DR. HISER: Yes.

19 MEMBER BANERJEE: Depending on the  
20 situation that the vortices can form a von Karman  
21 street or they can form other types of structures,  
22 what was happening here?

23 DR. HISER: I don't know that we know the  
24 details on how they --

25 MEMBER BANERJEE: So how did you know

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 about the frequency and the temperature fluctuation  
2 and things that might occur due to the vortex  
3 shedding?

4 DR. HISER: We did not do any confirmatory  
5 thermal hydraulic calculations.

6 MEMBER BANERJEE: But how did they do it?

7 DR. HISER: I'm not familiar with the  
8 details of their analysis. Maybe they --

9 MEMBER BANERJEE: Do you accept it, what  
10 they did?

11 MEMBER CORRADINI: They followed the ASME  
12 Code.

13 MEMBER BANERJEE: So there's a code that's  
14 giving you the velocity past object which gives you  
15 the vortex.

16 DR. HISER: Well, the ASME Code provides  
17 the criteria that they have to use in the calculation.

18 MEMBER BANERJEE: But what are the inputs?

19 DR. HISER: One of the inputs would be the  
20 results from thermal hydraulic calculations.

21 MEMBER BANERJEE: Right, and how is that  
22 done? I don't need you to pursue this. I just want  
23 to know what depth you looked at it.

24 DR. HISER: We did not look at it at the  
25 thermal hydraulic calculation in detail.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER BANERJEE: So who did? Did the  
2 Applicant do this?

3 DR. HISER: Yes. They did the  
4 calculation.

5 MEMBER BANERJEE: How do you know it's  
6 right?

7 DR. HISER: This is consistent with what  
8 we had found for other plants. There are no unique  
9 characteristics with Palo Verde that we are aware of  
10 that --

11 MEMBER BANERJEE: Perhaps the Applicant  
12 would speak to this. Just tell us how you did it and  
13 perhaps that will take care of the problem.

14 MR. RADSPINNER: Hello, my name is Mark  
15 Radspinner, System Engineering at Palo Verde. I can  
16 attempt to address your concern. As I understand the  
17 question is a level of understanding of how that  
18 analysis was performed in terms of calculating the  
19 alternating stresses that are produced by vortex  
20 shedding. Of course, the analysis was performed back  
21 in 1979. The techniques used though are standard with  
22 respect to the hydraulic loads for vortex shedding.  
23 They're dependent on correlations that are well  
24 developed, flow rates, and the geometry of the  
25 protruding nozzle, so they calculate the lift and the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 drag forces and then the subsequent frequency of the  
2 eddies that are produced as the flow goes around the  
3 nozzles.

4 So it's a very standard methodology. The  
5 primary purpose, of course, of the calculation is to  
6 show that the natural frequency of the protruding  
7 nozzle is sufficiently away from the vortex shedding  
8 frequency so that you don't get a resonance condition  
9 and that's clearly demonstrated in the analyses.

10 MEMBER BANERJEE: So it's some form of a  
11 correlation that's used?

12 MR. RADSPINNER: Yes.

13 MEMBER BANERJEE: Okay. Thanks.

14 MR. RADSPINNER: Thanks.

15 MEMBER ARMIJO: Now in this analysis, you  
16 didn't have, at least for these nozzles, you didn't  
17 have a thermal cycling as a result of that vortex  
18 shedding as well? Is that correct? This is just  
19 strictly --

20 MEMBER BANERJEE: Mechanical.

21 MR. RADSPINNER: Yes. I'm sorry, I was  
22 walking away from the microphone.

23 MEMBER ARMIJO: Yes, did you have any kind  
24 of a thermal cycling? You know in some nozzles you  
25 can have a thermal cycling, depending on how it's

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 designed and whether you have safe end designs.

2 MR. RADSPINNER: If I understand the  
3 question correctly, it's whether the vortex shedding  
4 frequencies were combined with the --

5 MEMBER ARMIJO: No. Was there any thermal  
6 cycling as a result of high cycle thermal cycling as a  
7 result of this vortex shedding if everything was  
8 isothermal, then there's no problem?

9 MR. RADSPINNER: There was no  
10 consideration of thermal effects in conjunction with  
11 the vortex shedding.

12 MEMBER SIEBER: I would think thermal  
13 effects have to do with frequency of vortex shedding,  
14 once frequency becomes sufficiently high, there's not  
15 a --

16 MEMBER ARMIJO: Yes, but if everything is  
17 isothermal there's no problem.

18 MEMBER SIEBER: Okay. We're clear.

19 MR. RADSPINNER: Yes.

20 MEMBER BROWN: Can I ask a question? What  
21 was the concern that led them to do a more refined  
22 analysis for Units 2 and 3 as opposed to Unit 1? I  
23 mean they passed Unit 1, so they go through a more  
24 elaborate analysis for Unit 2 and Unit 3 and that's  
25 supposedly based on the earlier comments. Identical?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 DR. HISER: I don't know what their -- the  
2 geometry is identical for all three units. My guess  
3 is different analysts did the two calculations.

4 MS. REGNER: Correct me if I'm wrong, but  
5 I believe the same analysts did both evaluations, but  
6 they were done about a year apart and they just  
7 decided to use more advanced modeling techniques. Is  
8 that pretty accurate?

9 MEMBER CORRADINI: They're engineers,  
10 Charlie.

11 MR. RADSPINNER: Yes. Mark Radspinner.  
12 That's essentially correct. I did talk to not the  
13 analyst who did these particular calculations, but one  
14 who worked at Combustion Engineering at that time  
15 frame. The approach was the Unit 1 analyses were  
16 meant to be prototypical and the follow-on analyses  
17 were meant to be addressing any material changes, as-  
18 built dimensions and things like that. And in this  
19 particular case, there were no changes of that nature,  
20 but as Brian Holian mentioned earlier, they do have  
21 the opportunity to come back and decide that well, we  
22 did take a very conservative approach in the previous  
23 analysis and one can only conclude that they decided  
24 that a more accurate, more detailed approach was  
25 appropriate for the follow-on analysis.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MEMBER BROWN: Okay, so there wasn't some  
2 technical concern that drove it. That was the point  
3 of my question.

4 MR. RADSPINNER: Right. Not that we're  
5 aware of, yes.

6 MEMBER BROWN: Thank you.

7 DR. HISER: Okay, in terms of  
8 environmental effects on fatigue, the staff questioned  
9 the Applicant on assumptions that go into that  
10 calculation. For environmental fatigue, there's a  
11 factor called Fen, fatigue environmental factor that  
12 depends on the material type whether it's alloy steel,  
13 stainless steel, or nickel alloy. And involves  
14 assumptions or inputs of oxygen content, temperature  
15 during the transient and also the strain rate. The  
16 Applicant indicated that they did use conservative  
17 values of oxygen, maximum temperature and strain rate,  
18 so they confirm that the Fen factors were at a  
19 maximum.

20 In addition, we found that the Fen factor  
21 that was used for nickel alloy was a prior value that  
22 staff no longer believes is limiting. One of the  
23 commitments that the Applicant made was to reanalyze  
24 the nickel, pressurized nickel alloy heater  
25 penetrations using a more updated value of Fen. That

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that will be completed two years before they enter the  
2 period of extended operation.

3 MEMBER ARMIJO: Allen, in these  
4 conservative analyses, was this -- is there a  
5 systematic approach here or Fen, let's say is 50  
6 percent than what is believed to be the case or strain  
7 rate is higher or is each analysis kind of ad hoc,  
8 somebody decides?

9 DR. HISER: It's either based on parameter  
10 values that would maximize the Fen factor or it's  
11 based on assumption on the characterizations on the  
12 transients that can be verified as being reasonable.

13 MEMBER SHACK: Typically, the hardest  
14 thing to come up with is the strain rate, so you set  
15 that at a max. And the temperature is sort of the  
16 most next difficult thing to deal with, so you  
17 typically set that at the max if you can live with it.

18 The dissolved oxygen is something you can  
19 actually probably make reasonable estimates for BWRs  
20 and PWRs and so --

21 DR. HISER: And we do -- oxygen, in  
22 particular, is one that applicants frequently will not  
23 assume the maximum value and we do ask them to  
24 demonstrate that whatever assumption they make is  
25 appropriate for their case.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MEMBER ARMIJO: But it's some factor  
2 greater than their normal dissolved oxygen operating  
3 level.

4 DR. HISER: Yes.

5 MEMBER ARMIJO: Okay.

6 DR. HISER: Well, it's an oxygen level  
7 that gives a higher Fen. The stainless steel --

8 MEMBER ARMIJO: It goes the other way  
9 because the carbon steel --

10 DR. HISER: It makes it very difficult in  
11 trying to assume an oxygen level. It's easier just to  
12 assume since you generally have both stainless and  
13 carbon steels, it's easier just to assume that the  
14 perimeter maximizes for each so that you don't have to  
15 justify values that would give you a lower Fen.

16 Next slide.

17 One of the other areas that I wanted to  
18 highlight relates to transient occurrence assumptions  
19 that the Applicant did not have measured transients  
20 for the entire operating period of the plant. They  
21 did go back and assess logs, LERs, operating reports,  
22 all of the information that they had available to them  
23 to come up with transient counts for the period in  
24 which they did not have transient counting.

25 The assumption that they made for this

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 ten-year period was that for each transient, the  
2 transient count was 25 percent of their design basis  
3 number. They did go back through the items listed  
4 here and were able to demonstrate that that 25 percent  
5 assumption was valid for all of the transients. So on  
6 that basis, the staff found that that was an  
7 acceptable assumption for the Applicant to make.

8 MEMBER STETKAR: Allen, do you have -- we  
9 had a little bit of discussion about this one in the  
10 Subcommittee meeting. Do you have a list of the  
11 specific transients for which that 25 percent  
12 assumption was applied?

13 MS. REGNER: I'm sorry, we don't. I can  
14 give you general numbers.

15 MEMBER STETKAR: Does the Applicant have a  
16 list of the specific transients for which the 25  
17 percent assumption was applied?

18 MS. REGNER: Mr. Medoff?

19 MR. MEDOFF: Jim Medoff of the staff.  
20 Yes, we were looking at the transients in the  
21 application versus the transients in their FSAR and  
22 what they're putting down for the values for that, I  
23 was marking up which ones we had issues with the 25  
24 percent assumption. So the answer is yes.

25 MEMBER STETKAR: Do you have a list of the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 transients for which the 25 percent assumption --

2 MR. MEDOFF: It should be back in my room.

3 I can get it.

4 MEMBER STETKAR: Maybe Applicant would  
5 have it.

6 MR. MEDOFF: They have a fairly large  
7 contingent here.

8 MS. REGNER: Yes. The Applicant does.

9 MR. RADSPINNER: Mark Radspinner, Systems  
10 Engineering at Palo Verde. I understand the question  
11 is if we have a list of the subset of transients for  
12 which the 25 percent assumption was retained?

13 MEMBER STETKAR: Yes.

14 MR. RADSPINNER: It's contained within  
15 Table LRA 4.3-3 and it's indicated in there which ones  
16 --

17 MEMBER STETKAR: The only thing I have is  
18 an interim response to the RAI. So I'm asking you now  
19 what are those transients.

20 MR. RADSPINNER: Okay, there's a list of  
21 about 12 --

22 MEMBER STETKAR: More than six than was  
23 available, 14.

24 MR. RADSPINNER: Yes, approximately 14.  
25 Approximately half of those were actually emergency

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 and faulted conditions for which fatigue analyses are  
2 not even performed and then the remaining six or  
3 seven, most of those are, in fact, all of them are  
4 lower significant transients. They're so  
5 insignificant generally that there's no way to go back  
6 into the records because they would not necessarily be  
7 even acknowledged in control room logs.

8 But by comparison with the subsequent  
9 operating history, we were able to demonstrate that  
10 those were all very conservative assumptions.

11 MEMBER STETKAR: The reason I ask this and  
12 apparently I'm not going to get the list --

13 MS. REGNER: You will.

14 MEMBER STETKAR: -- that I asked for. Let  
15 me -- I had to try to guess when I was trying to do  
16 this for the Subcommittee meeting which specific  
17 transients because I can multiply .25 times a number.

18 And some of those transients, the total number of  
19 events are things like 1 or 2. So I was curious how  
20 one determines that that assumption of 25 percent is  
21 certainly conservative when you're looking at numbers  
22 of 1 or 2 in 10 years.

23 I can understand if you're looking at  
24 numbers of 20 or 30 or something like that.

25 DR. HISER: I think the conclusion was

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that 10 of the 14 transients had not occurred, so the  
2 1 or 2 assumption would be conservative. For 2 of  
3 them, they were verified to have occurred at less than  
4 5 percent of the design rate, so 25 percent assumption  
5 is again conservative. And two were known to have  
6 occurred at specific intervals because they were test  
7 conditions and that was less than 25 percent.

8 MEMBER STETKAR: So if I can understand,  
9 they had some other way of bounding how big it was  
10 not.

11 DR. HISER: Yes.

12 MEMBER STETKAR: Okay. Thanks, that helps  
13 a little bit. I still would like a list -- that's  
14 fine. What you just said helps me a little bit to  
15 understand why they couldn't be larger than certain  
16 amounts.

17 DR. HISER: Yes, these are not heat ups  
18 and cool downs and trips and things.

19 MEMBER BANERJEE: I'm sorry, I'm still --  
20 have you finished?

21 MEMBER STETKAR: Yes.

22 MEMBER BANERJEE: I'm still back at this  
23 fatigue thing. Are there in this system -- the thing  
24 about vortices reminded me -- stand pipes where there  
25 are vortices that go in and out causing thermal

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 fatigue? Not even stand pipes, but things that come  
2 off the main pipe where it dead ends which can lead to  
3 a --

4 MEMBER SHACK: The small diameter pipe  
5 where you get the thermally-induced mixing kind of  
6 thing I think is what Sanjoy is talking about.

7 MEMBER BANERJEE: I don't know what it's  
8 called, but you know the idea. Larger pipes.

9 DR. HISER: There are some pipes such as  
10 the pressurized surge line which is well studied.

11 MEMBER SIEBER: That's different than what  
12 he's talking about.

13 DR. HISER: I'm not aware that there's  
14 been a lot of consideration of those locations.

15 MEMBER SIEBER: Generally, the very small-  
16 bore things like vents and drains they fail because  
17 they're not supported properly as opposed to cycling  
18 fatigue and what's in the internals that go on.

19 MEMBER BANERJEE: I'm just wondering if  
20 you took a look at these and any issues related to --

21 DR. HISER: The calculations that we deal  
22 with under metal fatigue are those that have ASME code  
23 calculations. So they have cumulative usage factors,  
24 based on ASME code. Locations that do not have a  
25 fatigue calculation are not addressed by this TLAA on

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 metal fatigue. They would be potentially subject to  
2 inspection which is a different management process, if  
3 you will.

4 MEMBER BANERJEE: And how would inspection  
5 detect this?

6 DR. HISER: Use of ultrasonics or things  
7 like that would be the -- they would detect cracking  
8 that would be -- it would not give you an indication  
9 of precursors to macro cracking, but it would be able  
10 to detect macro cracks. In general, we would expect  
11 with the fatigue calculation that even if you hit a  
12 cumulative usage factor of one, that you would only  
13 have micro cracks at best and you may have nothing at  
14 that point.

15 MEMBER BANERJEE: And these locations are  
16 usually inspectable?

17 DR. HISER: The instrument lines and  
18 things like that, I believe --

19 MEMBER BANERJEE: I think it would be  
20 fairly difficult.

21 DR. HISER: I'm not aware of inspections  
22 that are done at Palo Verde or elsewhere in particular  
23 looking at these locations.

24 MEMBER BANERJEE: So in your view, is this  
25 phenomena which is fairly well understood, I think,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 although Bill probably knows more about this than I  
2 do, is this something which is of any concern in the  
3 aging of plants?

4 DR. HISER: I do not believe so for these  
5 other locations. There is no operating experience  
6 that would indicate that we should be concerned. I  
7 believe the ASME code would have addressed those  
8 locations in a more quantitative manner if there were  
9 concerns in that area.

10 MEMBER SHACK: I mean you do have a small  
11 bore piping program for aging management. This is  
12 really meant to address this kind of a problem.

13 MEMBER BANERJEE: And it's just sort of  
14 empirical correlation of some sort?

15 MEMBER SHACK: They do the inspections.  
16 There's also a screening criteria that EPRI has  
17 developed to tell you which of these small bore  
18 locations might be the most susceptible to this kind  
19 of thing. But they don't try to do CFD calculations  
20 or --

21 MEMBER BANERJEE: No, I don't expect they  
22 would, but there would be some sort of --

23 MEMBER SHACK: Right, so they're handled  
24 within this program basically under the small bore  
25 piping as Allen suggested. It's not the cycle

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 counting, cumulative usage thing you look for.  
2 There's industry programs to tell you that these are  
3 the locations that are most likely to be it and to  
4 focus your attention a little bit.

5 MEMBER BANERJEE: And then what do you do  
6 after that? Suppose you do locate a few of these.

7 MEMBER SHACK: You have a problem. You  
8 fix it.

9 MEMBER BANERJEE: How do you fix it?

10 MEMBER SIEBER: You end up with expanded

11 --

12 MEMBER CORRADINI: You replace it.

13 MEMBER BANERJEE: So are there any  
14 locations here that needed to be addressed?

15 DR. HISER: None that I'm aware of.

16 MEMBER BANERJEE: Maybe we should ask the  
17 Applicant.

18 MEMBER SHACK: Small-bore piping program.

19 DR. HISER: They do have small-bore socket  
20 weld and piping inspections that they do.

21 MEMBER SIEBER: That's done on a  
22 percentage basis.

23 DR. HISER: Yes. I'm not aware that  
24 there's --

25 MEMBER SHACK: But there's a difference

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 between small-bore and socket welds.

2 DR. HISER: Yes.

3 MEMBER SIEBER: Yes, and the fatigue  
4 failure might not necessarily be at the socket welds.

5 DR. HISER: Yes.

6 MEMBER POWERS: The screening criteria  
7 that's developed apparently by EPRI, this is an  
8 empirical basis, that is, we've totaled up all of the  
9 incidences of unacceptable fatigue and found where  
10 they occur?

11 MEMBER SHACK: No, I think it looks more  
12 like where you might have temperature differences  
13 between the lines, relative diameters that you might  
14 generate, the vortices that penetrate in that give you  
15 this kind of thermal fluctuation. It's a kind of a --

16 MEMBER POWERS: Are there recorded  
17 incidences where the screening criteria would say we  
18 did not need to be concerned, but in fact, we found  
19 that there was?

20 MEMBER SHACK: I don't know. I assume  
21 when they set up the screening criteria that was  
22 obviously the thing that you would set up the  
23 criteria. Then you would look at all the known data  
24 and you fix it. Now whether subsequently you come up  
25 with something --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           MEMBER POWERS: We have a -- I wouldn't  
2 say a dismal record, but we certainly have had  
3 incidences where other screening criteria have been  
4 applied and we've been surprised. Full assisted  
5 corrosion comes to mind. It's one of those areas  
6 where we've done empirical things and then  
7 subsequently been surprised and learned to augment our  
8 empirical database that we were using. I mean that's  
9 a painful way to augment that.

10           MEMBER SHACK: Well, you're augmenting it  
11 here because you're doing these inspections and so you  
12 will be augmenting your database.

13           MEMBER BANERJEE: If they're inspectable.

14           MEMBER SHACK: Yes. You have to inspect a  
15 certain sample.

16           MEMBER BANERJEE: This problem has always  
17 concerned me. It sort of goes under the radar screen.  
18 The French found this was quite a problem I remember.  
19 But you feel -- are you going to look at this, Bill,  
20 what they're doing?

21           MEMBER SHACK: When you brought it up to  
22 the AP1000 several years ago, I did go take a look at  
23 it at that time, but that's -- I looked at the report  
24 and it is the screening criteria. I place more faith  
25 in the inspection programs. You use the screening to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 try to eliminate these things when you have a design  
2 basis. You use it to focus the inspections, but  
3 basically the inspections start to build your database  
4 that gives you the comfort level eventually.

5 It's a very hard problem to analyze your  
6 way out of.

7 MEMBER BANERJEE: Yes, all right.

8 DR. HISER: The one point I'd like to make  
9 in addition is with the recent revision of the GALL  
10 report. We did go through LERS and all the operating  
11 experience of a failure in this area would be a  
12 reactor coolant pressure boundary breach that has a  
13 very high visibility so if there were problems in this  
14 area, corrections would have been made to programs and  
15 there probably would have been engineer communications  
16 to remedy the situation. We're not aware of any. So  
17 I think we're satisfied with where the program is at  
18 this point.

19 MEMBER BANERJEE: Let's move on.

20 DR. HISER: Now the last item here is on  
21 cycle-counting. Lisa may have mentioned some of the  
22 inconsistencies between UFSAR and tech spec  
23 requirements for cycle-counting. The Applicant is  
24 committed to update their procedure to include  
25 transients that are not currently being counted and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 also to ensure consistency between their UFSAR and  
2 their tech specs. And those are the four main items  
3 on metal fatigue open items that I wanted to discuss.

4 MS. REGNER: Thank you. Moving on, just  
5 briefly, the confirmatory items that -- there were  
6 five confirmatory items that the staff resolved and  
7 prior to the SER with open items, they had been  
8 resolved informally. The staff just needed formal  
9 closure in the form of docketed correspondence and a  
10 review.

11 The first one, Palo Verde staff identified  
12 in their example, so I won't go over that one. The  
13 scoping of liquid-filled tanks. The next one is aging  
14 management of elastomers. The staff had identified  
15 thermoplastics and elastomer-lined carbon steel  
16 components that the staff was concerned about erosion  
17 in those components. The Applicant submitted  
18 information identifying that these components were in  
19 the essential spray pond and well water portion of the  
20 domestic water systems, therefore, they were not  
21 subject to high velocities nor high particulate  
22 levels. So erosion was not a concern.

23 The third, cavitation erosion which the  
24 Generic Aging Lessons Learned Report recognizes as an  
25 aging effect, requiring management due to operating

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 experience at Palo Verde of a through-wall leak in  
2 their infrequently used stainless steel piping and in  
3 the HPSI system. Palo Verde, they identified that as  
4 cavitation erosion and put this piping on a  
5 replacement schedule. So the staff's concern was more  
6 associated with the extent of condition review where  
7 there may have been other components also susceptible  
8 to this aging management effect and we wanted to know  
9 more about their extent of condition. And so the  
10 Applicant committed to complete their inspections of  
11 susceptible piping locations before June of 2012. And  
12 if they did note degradation, they would incorporate  
13 that into a replacement plan.

14 MEMBER REMPE: Seven and a half years for  
15 replacement, is that just based on well-documented  
16 experience and everybody agrees that's the appropriate  
17 time frame?

18 MS. REGNER: They based that -- they did  
19 do fairly significant calculation using degradation  
20 over an assumed time period, used conservative numbers  
21 to come up. And the staff did review that. They did  
22 find some nonconservativisms, but still, it was still  
23 well within the conservative range, so we did look at  
24 their calculation closely.

25 MEMBER ARMIJO: This was stainless steel

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 piping, is that correct?

2 MS. REGNER: Yes. For the HPSI system.

3 MEMBER ARMIJO: Yes, it seems like this is  
4 more of a design problem than a material problem, just  
5 replacing the same material with the same design.

6 MS. REGNER: It is.

7 MEMBER ARMIJO: Seven and a half years  
8 doesn't seem like a good solution.

9 MS. REGNER: And you know, they did  
10 identify it as a design problem. We somewhat  
11 disagreed that since there was the time component  
12 involved that we considered aging as well. And that's  
13 why we looked a little more closely at it. But once  
14 they come up with a replacement program, it's  
15 basically out of the scope of license renewal. That's  
16 why we turned our attention to other susceptible  
17 materials and locations that could be susceptible to  
18 this aging effect.

19 MEMBER ARMIJO: Maybe this is for the Palo  
20 Verde people, but are they working on a design  
21 solution?

22 MS. REGNER: I believe they are, but I'll  
23 let them speak.

24 MEMBER ARMIJO: Are they saying well, it  
25 will wear out every seven years and we'll replace it.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 That doesn't sound like a very good approach.

2 MS. REGNER: Mr. Radspinner?

3 MR. RADSPINNER: Mark Radspinner, Systems  
4 Engineering at Palo Verde. We did look at other  
5 alternatives. In this particular case it would take a  
6 well-designed control valve, a drag valve that's  
7 designed specifically to take a very large pressure  
8 drop on a small piece of pipe and not produce any type  
9 of incipient cavitation. So we did look at that. But  
10 based on the simplicity of the replacement, we went in  
11 and replaced it and we were done and we've done  
12 conservative projections for what the replacement  
13 interval would be and we interjected a halfway  
14 inspection, a UT inspection halfway through that first  
15 interval and that inspection has occurred, the halfway  
16 inspection on Unit 1. And there was no detectable  
17 wall loss using ultrasonics. So we would expect that  
18 when we do make the replacement in two more operating  
19 cycles that we would expect at most, just the very  
20 beginning onset of some cavitation.

21 MEMBER ARMIJO: Okay, thank you.

22 MS. REGNER: Anything else? Four, steam  
23 generator feedring flow accelerated corrosion. Steel  
24 feedrings and supports are susceptible to this aging  
25 phenomenon and the Applicant confirmed that this steam

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 generator feedring is P-11 steel and therefore FAC  
2 resistant. And they also do consider this aging  
3 mechanism during their secondary side steam generator  
4 degradation assessment which is performed every  
5 outage.

6 The last one, small bore piping which  
7 you've seen many times in the past. The Applicant did  
8 provide a commitment to inspect ten percent of its  
9 Class 1 socket welds for each unit, up to a maximum of  
10 25. And they will use a sample selection methodology  
11 to inspect the most susceptible components for  
12 significant welds.

13 MEMBER SIEBER: When are these  
14 inspections, small-bore piping inspections and socket  
15 and weld inspections to be completed? Is this before  
16 the period of extended operation?

17 MS. REGNER: Correct. That's in the  
18 commitment.

19 MEMBER SIEBER: Okay. And then after  
20 that, you go back to ASME?

21 MS. REGNER: Right. If they identify any  
22 issues --

23 MEMBER SIEBER: Then that expands the  
24 sample and takes on a new life.

25 DR. HISER: Yes. Then it would become a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 specific periodic program.

2 MEMBER SIEBER: Right.

3 DR. HISER: And generally, ASME would not  
4 require inspection of these welds.

5 MEMBER SIEBER: Right.

6 MS. REGNER: Lastly, the Applicant covered  
7 the other topics of interest identified here. I did  
8 want to point out for inaccessible cables they did  
9 mention that they increased the scope to low voltage,  
10 480 volts and above. But they did also commit to  
11 increasing their cable inspections to yearly and their  
12 cable testing to every six years.

13 MEMBER SIEBER: Does Palo Verde have a  
14 history of any cable failures and if so, by what  
15 voltage category were they in?

16 MS. REGNER: I'll let them provide  
17 details, but most of their cable failures were  
18 connections, rather than the actual cables, but I'll  
19 let them give details.

20 MR. HYPSE: My name is Mark Hypse,  
21 Electrical Engineering, Palo Verde. I understand the  
22 question is have we had a history of cable failures.

23 MEMBER SIEBER: Yes, what is your  
24 operating experience?

25 MR. HYPSE: We have not had a history of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 cable failures. We have had reported in Generic  
2 Letter 2007-01 that we had a couple of cables that  
3 failed acceptance criteria during Megger testing.  
4 We've also had some medium voltage splices that have  
5 failed Megger testing as well, but no actual cable  
6 failures.

7 MEMBER SIEBER: Okay, thank you.

8 MEMBER BLEY: Well, as Lisa pointed out,  
9 she said something about there being connection  
10 failures. Is that what --

11 MEMBER SIEBER: That's not a cable.

12 MEMBER BLEY: I know it's not.

13 (Laughter.)

14 MEMBER BLEY: It seemed to be related.

15 MR. HYPSE: I think she's referring to the  
16 spliced connections in the manholes.

17 MEMBER BLEY: Okay, thank you.

18 MS. REGNER: Sorry. And then the last  
19 topic that did want to mention, there was one late  
20 identified material discrepancy associated with the  
21 steam generators that the staff does consider minor  
22 and easily resolved. We will use appropriate channels  
23 to communicate this resolution with ACRS staff.

24 Any questions on the other topics of  
25 interest?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701



1           MEMBER SIEBER: I do have a question. My  
2 memory of Arizona and this area is that it's pretty  
3 dry. Have you found water in manholes for buried  
4 piping with external corrosion? I know that you have  
5 cathodic protection on almost, but not all of your  
6 piping. Is that a degradation mechanism for your  
7 plant, of any real serious importance?

8           MR. PITTALWALA: My name is Shabir  
9 Pittalwala, Underground Piping and Special Projects  
10 for Palo Verde. I understand the question to be the  
11 presence of water in the ground is it a significant  
12 issue for us in terms of corrosion and degradation of  
13 buried piping.

14           We do have a pretty extensive cathodic  
15 protection system, so the majority of our underground  
16 structures are covered by that cathodic protection  
17 system and that does act as a significant preventive  
18 measure.

19           Obviously, the presence of water and  
20 chlorides, electrolytes in the soil has -- we've had  
21 an operating experience on our fire protection piping  
22 where the protective coating on the piping, the  
23 wrapping had been abraded away by some sharp rocks in  
24 the backfill and that caused corrosion.

25           On our safety-related piping, we have

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 looked at that and demonstrated that the wrapping was  
2 intact. The backfill material was, of course, sand,  
3 fine-grain sand, and we showed that that is in good  
4 condition.

5 We have an inspection program in place now  
6 for all of that.

7 MEMBER SIEBER: Your fire protection  
8 piping, what material was that made of? For example,  
9 the main protection for the plant, is that a cast-iron  
10 piping or --

11 MR. PITTALWALA: Fire protection piping?

12 MEMBER SIEBER: Yes.

13 MR. PITTALWALA: So that was ductile iron  
14 piping, but there's about 20,000 linear feet of  
15 ductile iron piping. We have replaced 11,000 of the  
16 -- of what we considered the most susceptible portion  
17 of the piping with fiberglass ring, fiber ring plus  
18 plastic piping.

19 MEMBER SIEBER: Okay, fine. Thank you.

20 MS. REGNER: Okay, so in conclusion, staff  
21 determines that Arizona Public Service Company has met  
22 the requirements of 10 CFR 54.29A for the license  
23 renewal of Palo Verde Nuclear Generating Station.

24 Are there any final questions? Thank you  
25 for your time.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1                   MEMBER SIEBER:     Okay, I would ask the  
2 members if they have any questions for the staff or  
3 the Applicant at this time? If not, Mr. Chairman, I  
4 turn it back to you.

5                   CHAIRMAN ABDEL-KHALIK:   Thank you. Our  
6 schedule calls for us to reconvene at 10:15 a.m. So  
7 given that fact, I'd like for the Committee to utilize  
8 its time a little more efficiently. At this time we  
9 are in recess. We are off the record.

10                   (Off the record.)

11                   CHAIRMAN ABDEL-KHALIK:   We're back in  
12 session.

13                   At this time, we will consider the next  
14 item on the agenda, Final Safety Evaluation Report  
15 Associated with the Virgil C. Summer Units 2 and 3  
16 Combined License Application. And Mr. Ray will lead  
17 us through this discussion.

18                   MEMBER RAY:     Thank you, Mr. Chairman. I  
19 believe I am correct in saying this is our first  
20 experience in what we will know increasingly as a  
21 SCOLA or subsequent combined license application. So  
22 there are some aspects to it that may be a little  
23 different.

24                   Also in this case, we are dealing with a  
25 site unlike Vogtle's where there is no early site

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 permit. And those of you who recall our recent review  
2 in Vogtle, which is the reference combined license for  
3 the AP1000, this will be different in that regard and  
4 will be focused. And we will begin this morning  
5 discussing the site related matters, specifically  
6 geology and seismology.

7 You may recall that in the case of Vogtle,  
8 we were dealing with COLA which referenced an  
9 amendment to the Design Certification for the AP1000  
10 that had not yet been approved. Well now we will be  
11 dealing with the subsequent COLA that uses standard  
12 content in the reference COLA, which also has not yet  
13 been approved.

14 So we are dealing with things in parallel  
15 there. I believe we last time when through the  
16 mechanism by which these things all do get reconciled  
17 at the end of the day. But we do have in our Vogtle  
18 letter and I expect we may have in this letter as  
19 well, a reminder to the staff to let us know if  
20 anything changes as a result of the reference  
21 documents being finalized.

22 The subcommittee met in July 2010 and  
23 again in January of this year to review Summer and we  
24 are prepared to present it to the full committee here  
25 with the anticipation that we may be able to get a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 letter out from the full committee this session; if  
2 not, the next one I would expect, but we will see.

3 With that, let me ask Frank if the staff  
4 has any comments they would like to make.

5 MR. AKSTULEWICZ: This is Frank  
6 Akstulewicz from the staff. I have no opening remarks  
7 to make. Again, thanks to the committee for working  
8 with us to complete these reviews in a timely manner.

9 MEMBER RAY: Okay, Al, it's up to you.

10 MR. PAGLIA: Okay. Well, good morning Mr.  
11 Chairman and the committee members. I am Al Paglia,  
12 manager of licensing for VC Summer, their nuclear  
13 department. I certainly appreciate the opportunity to  
14 present to the committee this morning the final  
15 aspects of our COLA for the 2 AP1000 unit. Our team  
16 is ready to discuss the agenda items and answer any  
17 questions you may have.

18 As we mentioned before, we made  
19 significant progress in preparing the site for nuclear  
20 construction. Mr. Bob Whorton will begin today with  
21 an overview of the site and the status of the  
22 preconstruction activities.

23 So, if there are no further questions, I  
24 will turn it over to Mr. Whorton.

25 MR. WHORTON: Good morning. Before we get

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 started, could we go and take mute off so we can get a  
2 roll call of some of our call-in attendees? I would  
3 like to know who would be on the phone. Is that  
4 acceptable?

5 MEMBER RAY: Okay, let's see. Let's take  
6 a minute to arrange for that.

7 MR. WHORTON: I think the staff also has  
8 some members that are calling in.

9 MR. SEBROSKY: Yes.

10 MEMBER RAY: From the Region?

11 MR. SEBROSKY: No, they are out at a  
12 conference on the West Coast. Dr. Cliff Munson and  
13 Dr. Gerry Stirewall.

14 MEMBER RAY: Well?

15 MR. LINDVALL: Can you hear us?

16 MEMBER RAY: We can now, yes.

17 MR. LINDVALL: All right. Yes, you are  
18 right. Scott Lindvall, Fugro WLA and Joe Litehiser,  
19 Bechtel are here on behalf of Summer. And I will let  
20 the rest of the folks speak for themselves.

21 DR. MUNSON: Cliff Munson from the staff.

22 DR. STIREWALL: Good morning. Gerry  
23 Stirewall from the NRC staff also.

24 MR. MCGREGOR: This is Jim McGregor from  
25 the Shaw Group on the Summer project.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. LIPPARD: Lars Lippard from the Shaw  
2 Group on the VC Summer project.

3 MR. WHORTON: Do we have Robin McGuire on  
4 the line?

5 MR. LINDVALL: I don't think so yet. He  
6 is, as you know, in San Diego. He is available if we  
7 need him, you might want to give him a shout on the  
8 cell phone.

9 MR. WHORTON: Okay, and Dave Fenster, I  
10 believe, another Bechtel attendee?

11 MR. WHORTON: Okay, that's good.

12 MEMBER RAY: Okay now I think normally we  
13 will keep this on mute or listen only and you will  
14 have to ask us to take it off, if you need input from  
15 these folks.

16 So let's return to that mode and you can  
17 continue.

18 MR. WHORTON: Very good. Thank you.

19 I was involved in the original licensing,  
20 construction, engineering and operation ends of the  
21 Unit 1 project and have been part of the original team  
22 for the siting, layout, design and construction of  
23 Units 2 and 3.

24 The Summer site is located in the central  
25 portion of South Carolina, approximately 26 miles

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 northwest of Columbia, the state capital. Units 2 and  
2 3 are located approximately one mile southwest of Unit  
3 1 in Monticello Reservoir and approximately one mile  
4 east of the Parr Reservoir Broad River drainage  
5 system.

6 The next view I thought would be of  
7 interest again to bring back a 2007 aerial photo of  
8 the site area. And you can see in the center where  
9 Units 2 and 3 are to be constructed. To the north is  
10 Unit 1 and also Monticello Reservoir to the north.

11 The terrain of the area as you can maybe  
12 make out from the photo here is gently rolling hills  
13 with local relief to the streams and the Broad River  
14 to the west.

15 We have a satellite view from October of  
16 2010 and this frame captures an area of approximately  
17 two square miles; two miles by two miles. The table  
18 top for Unit 2/3 construction is shown in the center  
19 and represents the plant site at a nominal elevation  
20 of 400 feet above sea level. Unit 1 and Monticello  
21 Reservoir are again located to the north of the  
22 construction site and a substation for Units 2 and 3  
23 is shown to the west of the table top area. Parr  
24 Reservoir is also shown to the far left, which is also  
25 a part of the Broad River drainage system.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1                   MEMBER RAY:   Bob, would you outline the  
2 rail line?

3                   MR. WHORTON:   We have got the cursor going  
4 along it.  It parallels the river on the east side of  
5 the Broad River Parr Reservoir system.  So that rail  
6 line is approximately one mile to the west of the  
7 construction site.

8                   MEMBER RAY:   And elevation differences?

9                   MR. WHORTON:   The site elevation will be  
10 established at 400 feet.  The river, I believe, is  
11 nominally like 266,130 some-odd feet long.

12                  MEMBER RAY:   So there is a drop to the  
13 west of the site.

14                  MR. WHORTON:   Correct.

15                  And the next photo, it is a little closer  
16 satellite view of the table top construction area.  
17 And we will just point out a few features.

18                  The Unit 2 power block excavation is  
19 shown; the foundation installation for the heavy lift  
20 derrick, which is the main crane for lifting modular  
21 components into the construction site; the modular  
22 assembly building, which is where a fabrication of  
23 most of the large modules will take place; and then  
24 off to the left or to the west is the Chicago Bridge  
25 and Iron lay down pad area, which is where the head

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 assemblies will be assembled.

2 After achieving our nominal plant grade  
3 for the site table top at elevation 400, excavation --

4 MEMBER RAY: I'm trying to get it on  
5 listen only but we haven't succeeded yet.

6 MEMBER BROWN: -- of the Unit 2 power  
7 block area commenced.

8 A temporary soldier power retaining wall  
9 system was installed with geologic mapping of the  
10 vertical walls and floor in approximately five to six  
11 foot increments, prior to placement of the wooden  
12 lagging for safety on the sheet piles.

13 This is a northeast view across the Unit 2  
14 power block excavation showing the second and third  
15 excavation lifts which were underway at that time.  
16 The vertical piles are spaced approximately eight to  
17 ten feet apart. Each panel section of each lift is  
18 then geologically mapped using GPS survey and  
19 photographs. And then all of the recorded results are  
20 digitally stitched together to provide a panoramic  
21 view of the record of the excavation. And our purpose  
22 here is to capture all of the geological evidence of  
23 the excavation prior to reaching the foundation rock  
24 level.

25 Now again back to our satellite view from

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 October of 2010, this is the Unit 2 excavation,  
2 showing the top surface of rock as was found. We had  
3 removed all of the upper soil materials.

4 And the next view is a more recent January  
5 2011 view of the Unit 2 nuclear island excavation  
6 after some of the initial blasting had taken place.  
7 And you will note that the backhoe is sitting on sound  
8 rock at a nominal elevation now of 357 feet, above  
9 which filled concrete will be placed for nuclear  
10 island. The sound rock slopes downwards in the  
11 foreground towards the rubble and blast mats as is  
12 being shown.

13 MEMBER SIEBER: Will there be construction  
14 in the rubble area?

15 MR. WHORTON: Yes. We will continue to --  
16 we are in the process of continually tracking the rock  
17 down at that slope into the foreground. And so we are  
18 going to achieve sound rock in that area. All of that  
19 will be cleaned up.

20 MEMBER SIEBER: Okay. And what are you  
21 going to put in there, select fill or --

22 MR. WHORTON: No. For the nuclear island,  
23 it will be a concrete fill material, high strength  
24 concrete fill material.

25 MEMBER SIEBER: Oh, okay. There is going

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 to be a lot of it.

2 MR. WHORTON: Quite a lot for the nuclear  
3 island. And for the other associated structures, the  
4 turbine building, rad waste, and the annex building,  
5 those will be founded on an engineered backfill, which  
6 is being imported into the site. And I will cover  
7 some of those aspects a little later here.

8 MEMBER SIEBER: Will you use Franki piles  
9 or equivalent any place to get support from bedrock in  
10 the filled areas?

11 MR. WHORTON: No, the compacted fill is  
12 like a crushed rock granular fill that will have  
13 adequate bearing capacity without and it will be  
14 directly on top of rock. And it is coming from  
15 locally?

16 MR. WHORTON: Locally a quarry in the  
17 vicinity.

18 MEMBER SIEBER: Okay and you are going to  
19 process that prior to using it as fill.

20 MR. WHORTON: That is correct.

21 MEMBER SIEBER: Okay, thank you.

22 MR. WHORTON: Yes, we will have a  
23 gradation and all the other parameters necessary.

24 For Chapter 2.5 of the SAR, a team of  
25 SCE&G and Bechtel pulled together the COLA application

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 and FSAR. And we used a number of different  
2 subcontractors; William Lettis and Associates mainly  
3 for the Geology and Seismic and Geotech Association,  
4 Risk Engineering were on the seismic side; Mactec was  
5 our local contractor that did all the geotechnic  
6 investigations; and the results and evaluations were  
7 reviewed by an expert panel which we call the Seismic  
8 Technical Advisory Group.

9 Now the Seismic TAG, Technical Advisory  
10 Group consisted of experts familiar to the committee  
11 members. We had Dr. Martin Chapman from Virginia  
12 Tech; the late Dr. Allin Cornell from Stanford  
13 University; Dr. Robert Kennedy, a consultant; Mr. Don  
14 Moore from Southern Company, he was very knowledgeable  
15 from the Vogtle application; and Dr. Carl Stepp, also  
16 a consultant.

17 Now this group provided technical  
18 oversight to ensure consistency of the evaluations  
19 meeting regulatory guidance. They worked with  
20 industry to ensure consistency among the ESP and COL  
21 applications that were ongoing at the time and  
22 provided a written endorsement of the Summer Units 2  
23 and 3 results, which were attached also as part of our  
24 application, one of the appendices.

25 Briefly reviewing Sections 2.5.1 and 2.5.3

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 on geologic and siting information, in accordance with  
2 the regulatory guidance, geologic maps were prepared  
3 for a 200-mile radius, a 25-mile radius, 5-mile  
4 radius, and 0.6-mile radius. And using these results,  
5 along with the geologic and geotechnic evaluations,  
6 including the soil and rock borings, the Unit 2/3 site  
7 foundation was defined as sound rock, which obviously  
8 is different from the Vogtle application of being a  
9 soil site.

10 In addition, the Unit 1 geologic mapping  
11 and studies from 1974 were also incorporated into the  
12 current evaluations. This is a sketch of the  
13 excavation foundation map and the Unit 1 area is shown  
14 on the right side. A second unit was excavated on the  
15 left side but it was never constructed. So there is  
16 only one unit at the existing site.

17 Small bedrock shears were mapped in the  
18 excavation for Unit 1 and after extensive evaluations  
19 and age dating through various processes, the minor  
20 features were demonstrated to have last moved between  
21 300 million and 45 million years ago. So therefore,  
22 it was concluded that the minor bedrock shears would  
23 exist throughout the site area but they did not  
24 represent a surface rupture hazard.

25 A view from 1973 of the Unit 1 excavation,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 this is a northeasterly view, shows one of the shear  
2 fractures running across the rock surface. The next  
3 slide is a reverse view of that same shear zone and it  
4 also crosses the Unit 1 site area. So when we are  
5 talking about shear zones, that is what they look like  
6 physically in the site area.

7 Consistent with results at the Unit 1  
8 investigation, it was expected that the Unit 2 and 3  
9 excavation would expose similar shear features and in  
10 fact a few minor ones have now been observed as part  
11 of the excavation and mapping. These shears are  
12 consistent, however, with our expectations and have  
13 not exhibited any features or concerns which would  
14 suggest movement more recent than the previously  
15 documented 45 million to 300 million year age.

16 The Unit 2/3 excavations are being  
17 geologically mapped with results being documented and  
18 reviewed by the NRC staff. An initial visit to the  
19 site area occurred in August of 2010 and that is when  
20 we had initially exposed the surface of the rock. And  
21 then one is planned again for March 2011, which is a  
22 time frame we are expecting to have completed the  
23 blasting of the nuclear island and cleanup to an  
24 adequate presentation for the NRC staff to be able to  
25 visually see the entire nuclear island rock surface.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1           The staff in Region 2 had also visited the  
2 site earlier in the '06-'07 time frame during the  
3 development of our COL to observe the initial geologic  
4 and geotechnic investigations, which were ongoing at  
5 that time.

6           So therefore, in summary, we have not  
7 identified any new data to change our current  
8 interpretations and, therefore, conclude that the  
9 shear features are not capable tectonic sources.

10           Moving on to Vibratory Ground Motion under  
11 Section 2.5.2, our seismic hazard evaluation  
12 incorporated updated seismicity catalogues. Our  
13 probabilistic seismic hazard analysis replicated the  
14 EPRI 1989 hazard results, evaluated effects of the  
15 updated seismicity, updated the Charleston, South  
16 Carolina seismic source zones, developed seismic  
17 hazard and Uniform Hazard Response Spectrum for hard  
18 rock, and then developed vertical to horizontal  
19 ratios, and finally the ground motion response  
20 spectra, which is the design spectra for the site.

21           As part of the evaluation, three seismic  
22 source areas where we evaluated the effects of the  
23 additional seismicity. This was standard among all  
24 the ESP and COL applications. Four geometries were  
25 used for the updated Charleston seismic source hazard

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 model. It has a summary of the VC Summer seismic  
2 source model. No new capable tectonic sources were  
3 identified within the site region. No modifications  
4 to the eastern Tennessee seismic zone were required.  
5 The updated Charleston model replaced the EPRI  
6 sources, as was adopted in the Vogtle application.  
7 And the new Madrid, Missouri seismic source zone was  
8 added, which was adopted from the Clinton  
9 characterization.

10 From all of these evaluations, peak ground  
11 acceleration seismic hazard curves were developed,  
12 followed by development of uniform hazard response  
13 spectra. And finally, we developed the ground motion  
14 response spectra, horizontal and vertical, using  
15 approaches described in Regulatory Guide 1.208 and the  
16 ASCE Standard 4305.

17 So we are looking at a comparison of the  
18 various spectra here, which was presented back in  
19 January by the staff. And then comparing the spectra,  
20 the blue dashed line represents the Summer Units 2 and  
21 3 ground motion response spectra, which you can see is  
22 bounded by the solid black line, which is the AP1000  
23 generic hard rock high frequency spectra. The red  
24 line in the background is the AP1000 certified seismic  
25 design response spectra, which is basically a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 replication of the Reg Guide 1.60 spectra with some  
2 minor tweaks made to it.

3 As we had developed our GMRS, the ground  
4 motion response spectra, you can see that there are  
5 exceedances above the red line or the certified  
6 seismic design. The three sites that were currently  
7 ongoing evaluation at the time, Bellefonte, Lee and  
8 Summer all developed GMRS.

9 And so recognizing that each site had very  
10 similar looking spectra for their GMRS, Westinghouse  
11 enveloped three sites, Bellefonte, Lee and Summer, and  
12 then added approximately a two percent margin to that  
13 spectra to develop the HRHF, the hard rock high  
14 frequency and then pursued evaluation of the HRHF  
15 exceeding their certified design.

16 Over a three-year process this review  
17 occurred, many tech reports were developed by  
18 Westinghouse and the conclusions by both Westinghouse  
19 and the NRC staff are that these high frequency  
20 exceedances are non-damaging.

21 MEMBER RAY: This is an important point  
22 that Bob is making now.

23 MEMBER CORRADINI: Can you repeat it then  
24 so I am clear about it?

25 You said you took a few steps in the last

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 -- The conclusion is what I was trying to -- Can you  
2 repeat it please?

3 MR. WHORTON: Yes. There is an exceedance  
4 at high frequency of the certified design. And in  
5 light of the applications that were going forward,  
6 Summer, Belefonte and Lee, all three sites had a very  
7 similar looking GMRS. So there was exceedance. So  
8 Westinghouse then enveloped those three sites, added a  
9 little margin to them, two percent or so, and  
10 developed the black curve or the HRHF, that curve.

11 Then Westinghouse did a generic evaluation  
12 against structures, key structures, systems and  
13 components to ensure that the demand did not exceed  
14 the capacity. And that was documented through a whole  
15 series of generic tech reports, which were also put  
16 into the DCD, the AP1000 DCD.

17 MEMBER CORRADINI: The revised, the  
18 amended DCD.

19 MEMBER RAY: Yes. In other words, for a  
20 hard rock site, the certified design is the curve, --

21 MEMBER CORRADINI: Yes, I got it.

22 MEMBER RAY: -- in essence.

23 MR. WHORTON: Correct.

24 MEMBER SHACK: Or it will be.

25 MEMBER RAY: I used the present tense when

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 in fact I should be saying the future tense often, but  
2 we all understand.

3 MEMBER BROWN: Can I ask one question? I  
4 was at the meeting but I just need you to reemphasize  
5 something.

6 So the black curve, Westinghouse analyzed  
7 that, even though it was outside their design spectrum  
8 of the red curve and found that the structures were  
9 adequate under the response, the ground motions.

10 MR. WHORTON: The additional response.

11 MEMBER BROWN: The black curve.

12 MR. WHORTON: Correct. That is correct.

13 MEMBER BROWN: So I mean, to put it  
14 another way, the red curve could be changed for this  
15 site, to say you meet the requirements now. I am not  
16 saying you do that. I am just saying that they  
17 evaluated the differences and the variance in sound it  
18 was satisfactory as is, without changing the design.

19 MR. WHORTON: That is correct. So there  
20 are actually two design curves now. And they are  
21 treated independently because they, in the analyses,  
22 high frequency is treated a little differently from  
23 the low frequency and you can't just envelope both of  
24 the two curves to do the analysis.

25 MEMBER BANERJEE: So it is either the red

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 or the black?

2 MR. WHORTON: Yes, that is correct.

3 And as you can see, the Summer GMRS is  
4 bounded by either the red or the black.

5 MEMBER BANERJEE: Right.

6 MEMBER RAY: Well, the exceedance is in  
7 the high frequency area and that is the important  
8 point.

9 MR. WHORTON: If there are no further  
10 questions, we will move on then to the geotechnical  
11 characterization, Section 2.5.4.

12 The foundation site profile at Units 2 and  
13 3 consist of five layers. The upper surface layer of  
14 soils is called residual soil in our area and it is  
15 basically a reddish clay-type material. It is the  
16 upper range of soil.

17 Below that is a layer of material that we  
18 call saprolite, which is a completely weathered rock  
19 but it still retains some of the structure of rock and  
20 it is mainly silty sands in composition. It is more  
21 yellow silty sand looking.

22 Below that is when you start encountering  
23 the partially weathered rock. Below that is the  
24 moderately weathered rock and then finally sound rock.

25 So for the nuclear island again, we are

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 going to the sound rock layer for the nuclear island.

2 We will achieve a minimum of sound rock or moderately  
3 weathered rock below the other power block  
4 structures.

5 MEMBER SIEBER: That is sort of similar to  
6 the Vogtle site, at least in the upper layers.

7 MR. WHORTON: I believe they are  
8 considerably different from Vogtle. Vogtle is more in  
9 a sandy region there. Their overburden material is  
10 over a thousand feet.

11 MEMBER SIEBER: Right.

12 MR. WHORTON: Okay.

13 MEMBER SIEBER: And what is the overburden  
14 layer here for Summer?

15 MR. WHORTON: Summer, the residual soil is  
16 typically 20 to 30 feet. The saprolite is, again, 20  
17 to 30 feet and then you start encountering the rock.

18 MEMBER SIEBER: Okay.

19 MR. WHORTON: The rock, nominally, is 50  
20 or so feet below ground surface and it typically  
21 follows the rolling terrain of the area.

22 MEMBER SIEBER: And so the bedrock is  
23 buckled.

24 MR. WHORTON: Yes.

25 MEMBER SIEBER: Okay.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. WHORTON: And from the photos I showed  
2 on Unit 1, you could see that pretty clearly.

3 MEMBER SIEBER: Yes, I gathered that.

4 MR. WHORTON: Unfortunately it is not a  
5 flat, smooth surface that we encountered.

6 From the Geotech evaluations, as we  
7 mentioned, Unit 2 and 3 is defined as a hard rock  
8 site. And what this graph shows you here is the  
9 average shear wave velocity for Unit 2 on the left and  
10 Unit 3 on the right. And of note, the horizontal  
11 green line represents the average shear wave velocity  
12 at our foundation level, 357. If you recall from the  
13 earlier photo, I said the track hoe was sitting at  
14 357. So at that layer, you can see that we are  
15 generally above the 8,000 feet per second shear wave  
16 velocity, which is also consistent with the AP1000  
17 foundation design assumptions that were used from  
18 their DCD.

19 And finally as part of the developing  
20 Section 2.5, we needed to evaluate liquefaction  
21 potential for the site. The nuclear island, as I have  
22 mentioned, is on sound rock or on concrete.

23 MEMBER POWERS: Must have been a tough  
24 evaluation.

25 MR. WHORTON: Yes, it was. I had earlier

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 mentioned also the other power block structures,  
2 including the Seismic Category II Annex Building  
3 portion and the Turbine Building First Bay, which is  
4 also Seismic Category II are being founded on a  
5 compacted engineered backfill being imported to the  
6 site because we did find out that the residual and  
7 saprolite materials were not really good foundation  
8 materials. And so therefore, there is no saprolite or  
9 residual soils in the zone of influence for loading of  
10 any of the power block structures.

11 So our final conclusion is liquefaction  
12 cannot impact plant safety.

13 MEMBER SIEBER: Where are you getting the  
14 backfill from?

15 MR. WHORTON: A quarry exists in the area  
16 about 20 miles south of our site and they make riprap  
17 and gravel and stone and everything. So this is the  
18 byproduct of the crushing operations.

19 MEMBER SIEBER: Okay.

20 MR. WHORTON: So it is a crushed,  
21 granitic-type material.

22 MEMBER SIEBER: Okay.

23 MR. WHORTON: So therefore, I guess if  
24 there are any further comments on this --

25 MEMBER STETKAR: Bob, I didn't sit in on

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701



1 any of the subcommittee meetings on pretty much, back  
2 when you said you did probabilistic seismic hazard  
3 analysis, you said you replicated the '89 EPRI hazard  
4 results and evaluated effects of updated seismicity.  
5 Did this updated seismicity analyses account for the,  
6 I think it is, 2008 USGS seismic hazard maps?

7 MR. WHORTON: The basic answer is no  
8 because our COLA went in prior to the USGS 2008 study  
9 being completed.

10 Now, the staff --

11 MEMBER RAY: The staff did it and they  
12 will speak to that.

13 MEMBER STETKAR: Okay, thanks.

14 MR. WHORTON: And staff did discuss that  
15 at the subcommittee meeting.

16 MEMBER STETKAR: Thanks. Sorry, I wasn't  
17 there.

18 MEMBER RAY: It's all right.

19 MR. WHORTON: Okay, that is from Summer,  
20 that is our presentation. Any further questions?

21 MR. SEBROSKY: Mr. Ray, we would like to  
22 take the phone off mute, if we could so that Gerry,  
23 Dr. Stirewall can do a portion of this presentation.  
24 If it doesn't work out, then we are prepared to try to  
25 do the presentation from here. But we can start the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 presentation while the phone is being taken off mute.

2 MEMBER RAY: All right, let's take it off  
3 mute then and ask everybody to try and be as quiet as  
4 they possibly can while one of the participants makes  
5 input to the meeting here.

6 MR. SEBROSKY: You should have them mute  
7 their phones.

8 MEMBER RAY: Well, if you -- Yes.

9 MEMBER CORRADINI: They should be able to  
10 do it on their end.

11 MEMBER RAY: They should be. However,  
12 that often results in people hanging up and then  
13 calling back again.

14 DR. STIREWALL: So are we ready for a  
15 little touch of geology then?

16 MEMBER RAY: That's up to Joe.

17 MR. SEBROSKY: My name is Joe Sebrosky. I  
18 am the lead project manager for the Summer COL Safety  
19 Review. To my right is Dr. Yong Li and on the phone  
20 is Dr. Cliff Munson and Dr. Gerry Stirewall.

21 The first part of this presentation, Dr.  
22 Li is going to present. The latter part of the  
23 presentation, Dr. Stirewall is going to present.

24 MEMBER RYAN: Joe, could you just move  
25 that microphone in front of you, please?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. SEBROSKY: Sorry. Gerry we are on  
2 slide three now.

3 DR. LI: Okay. We are taking this  
4 opportunity to present the two topics which are key  
5 issues originating from the Section 2.5 review.  
6 Actually more specifically, one is related to  
7 seismology section; one is related to the geology  
8 section.

9 So the first issue actually originated  
10 from concern from Dr. Hines during the subcommittee.  
11 He is concerned about the applicant did not compare  
12 the USGS model with 2008, which is updated version in  
13 relation to the 2002 version. That is a concern here.

14 And the second topic we are going to  
15 present here is the field observation by NRC  
16 geologists for the requirement of license condition  
17 addressed in 2.5.1, who observed during the excavation  
18 about any existence of the table tectonics beneath the  
19 Category I structure.

20 So as I mentioned, the applicant compared  
21 the EPRI source model with USGS 2002 version but not  
22 compare it with 2008 version at the time when they  
23 prepared the application. So let me just give you a  
24 little bit background about USGS seismic hazard  
25 mapping project.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1           The USGS hazard mapping is targeting at  
2 the building codes for the purpose of -- for the  
3 building codes purpose. They serve as basis for  
4 people planning their construction. For example,  
5 school building, residential building, and the  
6 government buildings. So they are targeting at the  
7 relative shorter term period, which is normally 500  
8 years and 2,500 years ground motion level.

9           So normally they update the map every six  
10 years, normally. That is a basic features of the USGS  
11 mapping project.

12           And another feature we did not address  
13 here is that they use a different approach as NRC  
14 endorsed.

15           So, but NRC Regulatory 1.208 is a basic  
16 guidance document followed by applicant and also by  
17 NRC staff, of course. It specifies that the minimum  
18 ground motion level required for the critical facility  
19 as nuclear power plant in this case, has to be 1,000  
20 years to define the sit SSE or safe shutdown  
21 earthquake ground motion.

22           So it also recommends in this regulatory  
23 guide that applicant use EPRI or Lawrence Livermore  
24 National Lab model as the starting point to address  
25 the seismic hazard. Of course, they have to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 incorporate all the updates since then.

2 MEMBER ARMIJO: You said one thousand  
3 years and you chart says ten thousand years.

4 DR. LI: Ten thousand years. Sorry.

5 MEMBER ARMIJO: Okay.

6 DR. LI: Yes, it is 10,000 years.

7 And also it recommends to compare with any  
8 updated model, not necessarily just USGS. Any  
9 relating model in that particular area. If there is,  
10 you know, any new development or update, you have to  
11 address those in your application process.

12 So such as, if there is a source, the  
13 manuals change, you have to address that, or recurrent  
14 interim period, you have to address that, too.

15 So next please. Yes, in this case, in the  
16 USGS 2002 seismic hazard mapping project, they use a  
17 single maximum magnitude of 7.5 to address whole  
18 background source for that particular area. So it is  
19 7.5, was the magnitude 7.5.

20 And EPRI developed many specific source  
21 models. Basically we call them tectonic-specific,  
22 which have a maximum  $M_{\max}$  ranging from M5 to M7, a  
23 slight difference on USGS.

24 And for the major source which contribute  
25 to the site significantly, that is the Charleston

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 source, which had an earthquake in 1886 with a  
2 magnitude of seven something. So in that particular  
3 source, USGS defined as magnitude 7.2 versus  
4 applicant's or EPRI's model 7.1, which is the weighted  
5 average in this case. And in the return period, a  
6 recurrence interval of 550 years from the USGS and 630  
7 years from the EPRI. And also EPRI source geometry is  
8 more detailed. As I mentioned before, it is tectonic-  
9 specific because they set up different groups  
10 individually, starting the source characteristics  
11 based on lots of different information, such as  
12 geology, seismology, and other geotechnical  
13 information. Next please.

14 This figure outlines the information for  
15 this area approximately with 200 miles radius. That  
16 radius circle there is 200 miles radius. The center  
17 of the circle is the site. The red star indicates the  
18 site.

19 You see the contour line on this map here,  
20 the red at the bottom there, that is the center of  
21 maybe it is energy center for the Charleston  
22 earthquake, which the earthquake that occurred in  
23 1886. All the evidence pointing to that particular  
24 location as where the earthquake energy focused.

25 So the confine is the intensity of ten

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 around that red area and then moving away, it is  
2 decreased to around six or seven at the site. And  
3 there is also other evidence such as the liquefaction  
4 evidence on this figure, which indicated by a  
5 different diamonds and different color triangular  
6 shape there.

7 And other evidence indicated here is the  
8 red line in the offshore. That is some active faults  
9 which was found to correlate with recent seismicity  
10 there. So that is basic evidence.

11 So no matter USGS applicant they based on  
12 those basic evidence to define their seismic source.

13 The blue box, the big box, it is the  
14 USGS's outline for the Charleston source. And that  
15 also in parallel to the black rectangular shape, those  
16 are USGS sources defined in their 2002 seismic hazard  
17 mapping project. Next please.

18 MEMBER POWERS: Let me ask you one  
19 question about this slide. All your liquefaction  
20 evidence is online. How do you know that the  
21 epicenter is not in the ocean and that what you are  
22 calling on the contour of ten is in fact attenuated in  
23 the maximum of the actual earthquake?

24 DR. LI: That is a good question I should  
25 say. Basically you are questioning the liquefaction

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 evidence was mostly found on the land. You are  
2 missing the offshore part. Right? How do you  
3 determine --

4 MEMBER POWERS: Yes, you are not going to  
5 be able to get liquefaction evidence offshore.

6 DR. LI: Yes, but in the paleoliquefaction  
7 stories, there is some information which can enhance  
8 your analysis with regard to the determination of the  
9 so-called energy center. Because the intensity of  
10 liquefaction, you know, for example in this case, you  
11 found a lot of recent liquefaction evidence  
12 concentrated around where the Charleston, where the  
13 intensity ten is. And also the geometry of the size  
14 of the liquefaction so-called sand blows, they  
15 decrease relative with as you move away from the  
16 energy center. So all those evidence combined  
17 together, plus the current micro-seismicity we can  
18 call them, so all those information added together to  
19 help people to decide where the 1886 epicenter or  
20 energy center is.

21 DR. MUNSON: If I might add something.  
22 This is Cliff Munson from the NRC staff. We are not  
23 really -- We are not sure where the earthquake  
24 occurred, which is why the USGS and both EPRI, which  
25 you will see on the next slide, draw a big large

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 source zone boundaries around the Charleston area.  
2 That reflects our uncertainty as to where the  
3 earthquake actually occurred.

4 MEMBER POWERS: It seems to me that the  
5 problem, one of many problems with liquefaction  
6 evidence is that it is always an incomplete dataset.  
7 If you have three more geology students, you will  
8 three more points up there in the course of a Ph.D.  
9 thesis.

10 Micro-seismicity on the other hand, seems  
11 like it would be very useful data for pinpointing the  
12 center. What is the micro-seismicity database that  
13 you have to work with?

14 DR. LI: What years? Sorry.

15 MEMBER POWERS: What is? I mean, how big  
16 of a micro-seismicity database do you have and how  
17 does it get analyzed?

18 DR. LI: We have regional seismic network  
19 which recorded all the latest seismicity from  
20 different magnitudes. That is called micro-  
21 seismicity. Relatively those magnitudes are  
22 relatively small. That is why we call it --

23 MEMBER POWERS: Yes, they are tiny little  
24 things but they clearly point toward an epicenter of  
25 seismic activity. I mean, how do they get analyzed

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 and what do they point to?

2 DR. LI: They are more concentrated where  
3 the intensity ten is. That is what I meant.

4 MR. WHORTON: This is Bob Whorton again.  
5 For Unit 1, we did extensive studies back in the '70s  
6 on the Charleston earthquake. And a couple of things  
7 --

8 MEMBER POWERS: You and half the world.

9 MR. WHORTON: Exactly. The most intense  
10 shaking actually occurred in a town called, near  
11 Summerville, South Carolina, which is about 20 miles  
12 inland. So that was the more severe shaking. And  
13 that is why the circle is drawn basically centered  
14 around the Summerville area. It is called the  
15 Charleston Earthquake.

16 MEMBER POWERS: I bet you I can find  
17 academic papers that have an offshore epicenter on  
18 there.

19 MR. WHORTON: And you are exactly right.  
20 There were many papers written that had different  
21 hypotheses. Now I am very familiar with the work that  
22 Dr. Talwani from the University of South Carolina did  
23 and he was looking at two intersecting faults that are  
24 in the region of Summerville. And he plotted the  
25 micro-seismic activity along those to help describe

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 and define the two intersecting faults. So his theory  
2 was that there was a cause mechanism for the  
3 Charleston area.

4 But again, there are many hypotheses on  
5 the cause.

6 MEMBER POWERS: You are not the first to  
7 come and talk about the Charleston Earthquake with us,  
8 as surprising as that may be to you. And we have seen  
9 lots and lots of liquefaction evidence but we never  
10 see this micro-seismicity which seems to me to be much  
11 more likely to refine these uncertainty diagrams. I  
12 mean, these are consequential things. I mean you are  
13 lucky because of you hard rock site, if you had Vogtle  
14 site where you star is right now, we would be debating  
15 these uncertainty bounds a lot.

16 I am just wondering why we don't see more  
17 of the micro-seismicity.

18 DR. MUNSON: Dr. Powers, this Cliff Munson  
19 --

20 MEMBER POWERS: Yes, Cliff.

21 DR. MUNSON: -- from the staff. The  
22 applicants are required to develop an extensive  
23 earthquake catalogue as part of their seismic  
24 characterization. So they take all the earthquakes  
25 all the way down to magnitude three and map all those

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 earthquakes and use those earthquakes to characterize  
2 the seismic source. So they so use the micro-seismic  
3 activity.

4 MEMBER POWERS: That's great, Cliff. How  
5 come you guys don't?

6 DR. MUNSON: Excuse me? I didn't quite  
7 get that.

8 MEMBER POWERS: Well, the emphasis that is  
9 placed always on the liquefaction data that I am  
10 questioning a little bit here with Charleston, that  
11 the micro-seismicity seems to me that is much more  
12 likely to point to an epicenter of seismic activity  
13 than plotting contours of liquefaction because the  
14 liquefaction database is always incomplete. It is  
15 guaranteed to be incomplete because certain  
16 liquefaction spots are going to be removed by human  
17 activity. Certain ones are never going to be  
18 discovered because they are obscured, there are a  
19 bunch of trees in the way. Get rid of those trees, we  
20 can see this stuff easier.

21 DR. MUNSON: If I --

22 MEMBER POWERS: The micro-seismicity as an  
23 ongoing thing tells you something.

24 DR. MUNSON: In fact, those contours that  
25 you see on that plot are not liquefaction contours.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Those are damage contours from the Charleston  
2 Earthquake in 1886. And I would say that the  
3 applicant equally uses micro-seismic activity as well  
4 as liquefaction to try to draw their source zone  
5 boundaries. In fact, if you look at the next slide,  
6 which is actually the updated EPRI source model for  
7 Charleston, you will see that the applicant has quite  
8 an extensive number of source zones to try to capture  
9 the uncertainty in where Charleston was located.

10 MEMBER RAY: Anything more, Dana?

11 MEMBER POWERS: No.

12 MEMBER RAY: Okay.

13 MEMBER POWERS: I have had my fun.

14 MEMBER RAY: Proceed, Joe.

15 MR. SEBROSKY: Slide seven.

16 MEMBER RAY: Go ahead.

17 DR. LI: Okay. This figure indicates the  
18 EPRI source calculation which also use a rectangular  
19 box defined the seismic source for this area. It is  
20 quite similar to the USGS model, I would say. Next,  
21 please.

22 So the 2008, in 2008 USGS update their  
23 seismic hazard map in comparison to 2002. So here are  
24 some highlights some of the updates there.

25 The maximum magnitude was changed. It was

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 replaced by multiple values with respect to a single  
2 value. It was 7.5 before; now it is 7.1 to 7.7. And  
3 also they updated the ground motion attenuation models  
4 using the latest ground motion attenuation models.  
5 And the Charleston seismic source was enlarged  
6 offshore actually a little bit away from the 2002  
7 center.

8 So the overall, the most important thing  
9 here is that 2008 hazard results is 10 to 15 percent  
10 lower in comparison USGS 2002 model for the CEUS.  
11 This was addressed in the USGS Open File Report 2008-  
12 1128.

13 And staff addressed this update issue in  
14 the next version of the SER.

15 MEMBER BLEY: When you say 10 to 15  
16 percent lower, what is lower?

17 DR. LI: Lower means that is the ground  
18 motion, and your probability of exceedance with the --

19 MEMBER BLEY: But the frequency of a  
20 particular acceleration is lower by 10 to 15 percent.

21 DR. LI: Right. Yes, that 10 to 15  
22 percent --

23 MEMBER BLEY: Applies to the frequency for  
24 a given acceleration.

25 DR. LI: And your probability of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 exceedance level is lower. Yes, in this case 10 to 15  
2 is for the one hertz and it actually was even lower  
3 for the PGA, which is 25 to 30 percent, if I remember  
4 correctly.

5 MEMBER BLEY: So this is for the one  
6 hertz.

7 DR. LI: Yes, only one hertz, yes.

8 MEMBER BLEY: Thank you.

9 MEMBER STETKAR: Yong, it may be lower  
10 than the 2002 but I just plotted out the 2008 USGS  
11 seismic for the coordinates of the site. And at a  
12 10,000 year recurrent frequency, it gives me a mean  
13 peak ground acceleration of about 0.43 g. So that is  
14 notably different, regardless of what 2008 is to 2002,  
15 it is a measurable difference.

16 So I was curious when you say you are  
17 going to update the summary SER, when are you going to  
18 do that?

19 DR. LI: The updated summary SER which is  
20 what I meant here is to address this comparison issue.

21 MEMBER STETKAR: Okay.

22 DR. LI: So you say it is 0.43 g PGA?

23 MEMBER STETKAR: Yes, well it is roughly.  
24 Yes, it is, you know, the seismic hazard maps that  
25 you can download only give you point values that they

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 say are supposed to be mean. And I have got to  
2 interpolate between points here and I am not doing my  
3 interpolation. But is somewhere between about 0.42 g  
4 and about 0.44 g at a 10,000 year recurrence interval.

5 DR. LI: Yes.

6 MEMBER STETKAR: You know, and you can  
7 talk about 10 or 15 percent, but that is still a  
8 measurable difference. I might be off a little bit in  
9 my plot here.

10 DR. LI: Yes, a general practice endorsed  
11 by NRC in 2008 1.208 is to compare the USGS sources  
12 with the source that they adopt in their application.

13 In this case, they compared a USGS source model.

14 MEMBER STETKAR: I understand that.

15 DR. LI: Specifically, area sources or  
16 point sources but not compare the final hazard result.

17 MEMBER STETKAR: Why wouldn't you compare  
18 the final -- yes, okay.

19 DR. LI: Because as I mentioned, the USGS  
20 hazard modeling, actually I mentioned this in previous  
21 slide, is targeting at short early term period and it  
22 has served the purpose for building codes.

23 MEMBER STETKAR: Well does that mean you  
24 totally disregard it? I mean, it goes out to about a  
25 2.1 g, you know, peak ground acceleration. And of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 course there is uncertainty out at that level. But  
2 you totally disregard it for higher return periods or  
3 lower frequencies because they don't know about  
4 geology out in those return periods? I mean, I don't  
5 understand.

6 DR. LI: It is not totally disregard it at  
7 all. It was totally considered but from the seismic  
8 source calculation part. Your maximum magnitude, your  
9 area source geometry and your return period. From  
10 those perspectives, you have to fully consider what  
11 the others have done in this area.

12 So that is the staff position addressing  
13 1.208.

14 MEMBER STETKAR: Okay, thanks. You can go  
15 on.

16 MEMBER RAY: Well if you followed that,  
17 you are doing better than I am.

18 MEMBER STETKAR: No, I don't because I  
19 tend to think of seismic hazard as a frequency of  
20 occurrence, with some uncertainty, as a function of  
21 acceleration.

22 MEMBER RAY: The earthquake for this site  
23 has a PGA of 0.2 something horizontal. Now, it sounds  
24 like what you are saying John is in conflict with  
25 that.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MEMBER STETKAR: What I am saying is that  
2 according to the USGS seismic hazard map for these  
3 geologic coordinates, a 10,000 year recurrence period  
4 corresponds to about a 2.43 peak ground acceleration.

5 MEMBER RAY: Yes, which sounds  
6 inconsistent with what I said, you would think.

7 So the question I think you are asking is  
8 how do you --

9 MEMBER STETKAR: My question is how did --

10 MEMBER RAY: -- reconcile --

11 MEMBER STETKAR: -- people reconcile that.

12 MEMBER RAY: That's right.

13 MEMBER STETKAR: On a seismic --

14 MEMBER RAY: And I didn't understand the  
15 answer.

16 MEMBER STETKAR: -- hazard, not  
17 characterization of sources.

18 MEMBER RAY: Yes. I don't know that we  
19 have time to examine that. It seems like a good  
20 question to me but I don't know.

21 MEMBER STETKAR: And I will admit, I am  
22 certainly not a seismic expert but I plot out curves  
23 and I look at different pieces of information and see  
24 where the different estimates come, you know, to try  
25 to estimate uncertainties. But this seems to be a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 different, a large enough difference that I am not  
2 sure how it was reconciled.

3 MEMBER RAY: Nor am I.

4 MEMBER STETKAR: And I don't want to --  
5 You know, we are relatively short on time so, Harold,  
6 keep going.

7 MEMBER RAY: Okay but I don't mean to  
8 slight the question, John. It is not something I can  
9 answer, though. And I am not sure I hear anybody else  
10 answering it either.

11 MR. SEBROSKY: Can we try taking him off  
12 mute one more time?

13 MEMBER RAY: Yes, please. Peter, I am  
14 sure there are people out there who are striving to  
15 communicate with us.

16 MEMBER STETKAR: They mentioned Robin  
17 McGuire's name was on the line.

18 DR. MUNSON: Hello? This is Cliff Munson.  
19 Am I on the line?

20 MEMBER RAY: Yes, you are. Can you answer  
21 the question, then?

22 DR. MUNSON: Yes. Yes, we specifically,  
23 following our regulatory guidance, we used, we  
24 recommend specified use of EPRI or Livermore as a  
25 starting point and then the applicants are required to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 update. We do not, applicants are not required to  
2 look at USGS hazard maps and make comparisons to their  
3 hazard curves. What we tried to show in a couple of  
4 slides preceding is that the USGS is for building  
5 codes and standards and not for critical facilities.  
6 They do not do the same PSHA that we do for citing  
7 critical facilities.

8 So the rigor, the expert elicitation  
9 methodology, the consideration of uncertainty, it is  
10 all different than what we require.

11 MEMBER RAY: Okay, that is sort of a  
12 statement of fact. Can you give us any brief, very  
13 brief rationalization of why that is okay?

14 DR. MUNSON: For the purposes I just  
15 stated. They look at return periods that focus from  
16 500 to 2,500 years. We require 10,000 years at a  
17 minimum for siting for the SSE. So, there is a big  
18 difference in the focus of the two PSHAs, what they  
19 develop for their maps and what we, EPRI and other  
20 modelers develop for nuclear power plants.

21 MEMBER BLEY: So let me rephrase what I  
22 think I heard you say. And that would be that because  
23 of the way they focus in developing their hazard,  
24 their estimates are that the 10,000 year return period  
25 you don't have much confidence in because they didn't

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 focus out at that kind of time frame. Is that what  
2 you are saying?

3 DR. MUNSON: Yes, that is what I am  
4 saying.

5 MEMBER RAY: Well and more specifically,  
6 the consequence is that they over-predict, apparently.

7 At least, that is the only conclusion that I can  
8 draw, --

9 MEMBER BLEY: At least at this point.

10 MEMBER RAY: -- the peak ground  
11 acceleration.

12 Go head, John.

13 MEMBER STETKAR: There is some evidence  
14 that -- You know, USGS doesn't due a rigorous  
15 uncertainly analysis. That is certainly true. And if  
16 you talk to the people, it is not clear how they  
17 account for uncertainties. There is some evidence  
18 looking at, stuff that I have done looking at other  
19 areas that EPRI tends to under predict the  
20 uncertainties and be somewhat optimistic at the high g  
21 level of long return period, high g level is some  
22 evidence that USGS tends to over predict the peak  
23 ground acceleration and they don't do uncertainty  
24 analysis. So you have to somehow deal with that.

25 My only question was how extensively,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 given this apparent difference on what is  
2 characterized as a mean exceedance frequency, how  
3 rigorously did the various entities examine those  
4 differences.

5 DR. MUNSON: Again --

6 MEMBER STETKAR: And I think I hear what  
7 was done. So I don't need to hear it again.

8 DR. MUNSON: Right. I mean, we don't  
9 require them to compare their hazardous results to the  
10 map that USGS develops. It is not for nuclear power  
11 plant siting.

12 They do compare their source model,  
13 maximum magnitudes, recurrence intervals, how often  
14 these earthquakes happen, the maximum magnitudes and  
15 the source geometries, where they happen. Those are  
16 all things that we have looked at with respect to not  
17 only USGS but South Carolina has their own hazard. So  
18 it is not just USGS. There are various other ones  
19 that we do look at.

20 But we do not look at USGS hazard maps,  
21 specifically, for comparison.

22 MEMBER RAY: Are you satisfied, John?

23 MEMBER STETKAR: Yes, we should go on  
24 here, Harold.

25 MEMBER POWERS: You succeeded in confusing

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 me. You come up with a factor of two, the difference  
2 between in the peak ground acceleration at one hertz.

3 And they say that was because they over predict.

4 How in the world do you explain to the  
5 public that there is a factor of two here, based on  
6 errors in mathematics?

7 MEMBER STETKAR: That's an excellent  
8 question, I think. But I don't think we are going to  
9 answer that question in this forum.

10 MEMBER RAY: It seems the generic -- Okay,  
11 that's fine with me. I just don't want to not somehow  
12 recognize it as a question and we can move on, unless  
13 somebody here want to try and answer it in the context  
14 of Summer, I would suspect we just make it an  
15 observation to be dealt with by the committee later  
16 and move on.

17 I thought there was going to be a simple  
18 answer emerging but obviously not.

19 Go ahead, Joe.

20 MR. SEBROSKY: Gerry, we are on slide nine  
21 now.

22 DR. STIREWALL: Okay. That slide should  
23 be titled "Update on Observations by NRC Geologists."  
24 Is that correct?

25 MR. SEBROSKY: That's correct.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 DR. STIREWALL: Okay. Well let's talk a  
2 little bit about the geology of what we observed in  
3 the excavation. I appreciate Bob Whorton setting this  
4 up so smoothly. Bob actually talked about the real  
5 reason for the licensing condition 2.5.1-1, really  
6 which requires the applicant to do the mapping. Bob  
7 illustrated and spoke about the shear zones that were  
8 discovered in Unit 1. There is a date on those.  
9 There are at least 45 million. And in fact, that  
10 really was the impetus for why this particular  
11 licensing condition was formulated. So Bob, thanks  
12 for setting that up.

13 We did do a site visit, an initial one in  
14 August 2010. Again, as Bob said, and sort of our  
15 bottom line is in fact we believe the applicant has,  
16 in fact, that they did characterize in the FSAR what  
17 they are finding in the excavation. They are not  
18 finding features that are young. That is to say none  
19 of these structures. Well, are there tectonic  
20 features? Yes. Are they young? No. They are much  
21 older than quaternary.

22 What I would like to do is just sort of  
23 give you a little walk into the excavation to turn you  
24 all into field geologists for just a few minutes. So  
25 if we could look at the next illustration where the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 geologist is lying atop bedrock and looking at a  
2 fracture face, and I assume that we are on that slide  
3 now.

4 MR. SEBROSKY: That is correct.

5 DR. STIREWALL: Okay. What is going on  
6 here -- And by the way, I think Yong may have brought  
7 a hand sample from a piece of core from Unit 2. Is  
8 that visible?

9 DR. LI: Yes.

10 DR. STIREWALL: Okay. Well that  
11 particular rock in that core is in fact granite  
12 diorite. It is about three hundred million years old  
13 and it really does form the foundation bedrock here.

14 What this geologist is looking at, he is  
15 looking at a natural fracture face that was uncovered  
16 by the excavation. This fracture, it is, it was  
17 generated tectonically but looking very carefully,  
18 there are no features on this particular fracture  
19 surface in the granite diorite that indicate that it  
20 is related to slip. In other words, it is not a  
21 fault. It is simply a fracture, no displacement.

22 But I would like to do now passing from  
23 that slide again on top of the granite diorite, a  
24 sample of which you can see, I would like to look at  
25 just a couple of different scales of features and show

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 you the field evidence for why these things are not in  
2 fact young.

3 So if we could look at the next slide that  
4 talks about or illustrates a small scale hill, shear  
5 fracture that cuts an igneous vein, that is the lower  
6 part of the title. I am assuming that we are on that  
7 slide.

8 MR. SEBROSKY: That's correct.

9 DR. STIREWALL: Okay. You can see the  
10 little, there is a vein, an igneous vein that is  
11 offset that runs sort of from the top to the bottom of  
12 the photograph vertically. That particular vein, it  
13 is called a pegmatite. And the point is that the  
14 pegmatite vein is sort of part and parcel, for the  
15 last juices of these magmatic plutonic masses, like  
16 the granite diorite. So it is directly associated  
17 with formation of these major intrusive bodies, the  
18 granite diorite in this case. So in other words, the  
19 age of those veins is also very old.

20 Now, that vein is offset in this one by a  
21 rather small scale fracture that crosses horizontally  
22 on this figure and clearly, clearly that is offset.  
23 But if you look at the lighter colored mineral in that  
24 fracture zone, that is in fact quartz. That is also  
25 an igneous mineral. So this particular little

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 fracture, very small scale -- What do I mean by small  
2 scale? If you look at the rectangular scale, the  
3 arrow on that little rectangular scale is ten  
4 centimeters in length. So we are looking at a rather  
5 small scale feature. Again, it is healed by minerals  
6 that were sort of the last juices of this intrusion.  
7 So it has very, very old minerals growing in it. So  
8 this kind of feature, there is no reason from the  
9 relative ages from the field evidence, to think that  
10 it is any younger than 300 million or so.

11 If we could look at the next slide,  
12 please, that shows a slightly larger scale. And  
13 again, Bob illustrated from Unit 1 something that sort  
14 of looks very much like this. This particular, there  
15 is a zone that runs vertically across the slide top to  
16 bottom and it is a zone of really rather intense,  
17 closely spaced fractures that probably suggest  
18 shearing. But low and behold, that zone is crosscut  
19 by the igneous veins. And remember, the lighter  
20 colored lines that you see in the background, show no  
21 offset or those same sorts of pegmatites and again,  
22 they are in the range of 300 million. So they  
23 actually cross the shear zone and again give us  
24 relative ages that these are not young features. I  
25 mean, the field evidence just shouts it at you very,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 very loudly.

2 So if we could just, sort of in summary  
3 then, using those kinds of field relationships, we  
4 really found from our visit in August that what the  
5 applicant said in Section 2.5 is absolutely fully  
6 consistent with the geologic features that we have  
7 observed to date in Unit 2. Tectonic features are  
8 there. They are old features. And we will do, again,  
9 as Bob alluded to, we will do a follow-up visit post-  
10 blasting, once they are down at a lower level. We  
11 will actually get a third dimensional view of any of  
12 these fractures that might crosscut. And we will do  
13 similar visits to Unit 3 sort of in the same, to  
14 accomplish the same process.

15 That is really all I had. Again, just our  
16 bottom line being that what the applicant expected to  
17 find is what they are finding, based on our field  
18 assessment from really good and very, very solid field  
19 relationships.

20 That is it, unless you have some  
21 questions.

22 MR. SEBROSKY: If there is no other  
23 questions, we can go on mute for the rest of them.

24 MEMBER RAY: All right, we will do that.  
25 Thank you.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MR. SEBROSKY: Thanks, Gerry.

2 DR. STIREWALL: Thank you.

3 MR. SEBROSKY: Thanks, Cliff.

4 MEMBER RAY: Fellas, are you done with  
5 this piece here?

6 MR. SEBROSKY: Yes.

7 MEMBER RAY: Okay, Amy, can you catch us  
8 up?

9 MS. MONROE: Yes.

10 MR. SEBROSKY: Just so you know, we are  
11 going to be bringing staff in and out. They will  
12 bring in more subject matter experts while Amy does  
13 her presentation.

14 MEMBER RAY: Okay.

15 MEMBER ARMIJO: So you are switching.

16 MS. MONROE: I get to drive the mouse the  
17 whole time. We will switch people in and out but we  
18 will try to keep the discussions moving as rapidly as  
19 we can and flowing.

20 Yes, my name is Amy Monroe. I am a  
21 licensing engineer with South Carolina Electric and  
22 Gas Company. Our team is here today to discuss with  
23 you the site specific portions of our COL application.

24 I am going to address the more significant items that  
25 were in Chapter 1 and the first three sections of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Chapter 2.

2 As we have noted before, the Summer site  
3 is located in the central portion of South Carolina in  
4 a town called Jenkinsville. Here we are showing it in  
5 relationship to two of the other applicants for the  
6 AP1000.

7 As we have noted, these units will be the  
8 standard AP1000 design. The Westinghouse design  
9 incorporated by reference in our application and  
10 reutilizing the standard material found in the RCOLA,  
11 Vogtle Units 3 and 4.

12 We have just recently submitted an  
13 amendment to our application. It is Revision 4. And  
14 in that amendment, we address the confirmatory items  
15 that are found in the NRC's SER and incorporates  
16 Revision 18 of the DCD by reference.

17 You will note here that this is an  
18 artist's rendering of the AP1000 units on our site.  
19 Unit 2 is to the north of Unit 3. And over here we  
20 have the four, two per unit, mechanical draft cooling  
21 towers that we will be utilizing.

22 Within our application we have a total of  
23 five departures, two of which are considered standard  
24 departures and are accepted by all AP1000 units. One  
25 deals with the section numbering within the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 application. The other deals with testing of the  
2 voltage regulating transformer in Chapter 8. Again,  
3 both of these were discussed in more detail during the  
4 RCOLA or Vogtle presentation a month ago.

5 We have three site-specific departures.  
6 One again for the section numbering. This is  
7 primarily in Chapter 2. One for the relocation of our  
8 technical support center and operational support  
9 center relocation. We will be discussing that  
10 departure in a little more detail here when we talk  
11 about our emergency plan.

12 And we have a wet bulb temperature  
13 departure. We departed from the maximum safety non-  
14 coincident wet bulb that is contained in the DCD. And  
15 here in just a few minutes, we will go through a more  
16 detailed discussion on the acceptability of that  
17 departure.

18 We have a total of three exemptions, two  
19 of which again are considered standard for an AP1000  
20 plant. One deals with the section numbering. The  
21 other is an exemption to 10 C.F.R. Part 70. This is  
22 to make consistent with the requirements for Part 70  
23 that are required of the Part 50 applicant. We are  
24 trying to get online with the same requirements as  
25 Part 50. And again, the one site specific exemption

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 which deals with the maximum wet bulb temperature.

2 As discussed in FSAR Chapter 1, the units  
3 for the project are jointly owned by South Carolina  
4 Electric and Gas with a 55 percent ownership and  
5 Santee Cooper or the South Carolina Public Service  
6 Authority with a 45 percent ownership.

7 Westinghouse Electric Company and Shaw  
8 Group are considered the AP1000 provider, architect  
9 engineer and constructor.

10 Other groups that have been utilized in  
11 support of our application in our initial efforts have  
12 been Bechtel, NuStart Energy, Mactec Engineering and  
13 Consulting, Risk Engineering, Tetra Tech and William  
14 Lettis. Several of those which Mr. Whorton discussed  
15 with you a few minutes ago.

16 Chapter 2 discusses the siting  
17 characteristics for the Summer site. Basically to  
18 summarize, the Summer site has what we consider fairly  
19 typical southeastern climatology; hot humid summers,  
20 milder winters. Icing is not a concern either in the  
21 lakes or the rivers in the area. However, we will  
22 talk about the exemption due to the humid conditions.

23 Analysis of our wind and tornado data  
24 demonstrates that the wind speeds and tornado  
25 frequencies encountered in the vicinity are bounded by

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 the DCD requirements and also meet the necessary  
2 requirements for external missile hazard protection.

3 The location of the site is on a rock  
4 plateau, as you sort of remember perhaps from Mr.  
5 Whorton's discussion, and it is greater than 100 feet  
6 above the flood level of the Broad River, which again,  
7 was located about a mile to the west of the site.

8 The local topography essentially moves all  
9 the water from that plateau down over to the west,  
10 over to the east, it tends to encounter streams which  
11 feed into the river. Therefore again, the flooding is  
12 not an issue at our plant.

13 Ground water levels are also very low and  
14 in fact, they are about 18 feet below the DCD required  
15 level. And as Mr. Whorton discussed with you earlier,  
16 we are considered a hard rock site for the AP1000  
17 design.

18 Regional climatology as discussed in  
19 Section 2.3 is basically characterized by four very  
20 distinct seasons: mild and short winters; long mild  
21 but sunny weather in the autumn; a little bit breezier  
22 and windier in the spring, but mild; and then very  
23 long hot summers.

24 For our initial COLA submittal, we took  
25 three years of data, it was collected, analyzed and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 submitted utilizing the Unit 1 meteorological towers,  
2 as the Units 2 and 3 tower was being constructed and  
3 the initial data was being collected.

4 After obtaining and analyzing the data  
5 from the Units 2 and 3 tower, it was determined that  
6 the lake effects on Monticello Reservoir had a greater  
7 impact than we had anticipated from the Unit 1 tower  
8 data. Therefore, we continued to collect two years of  
9 data from the Unit 2 and 3 tower and updated the  
10 application with that data, simply because it was more  
11 representative of the conditions right there at the  
12 Unit 2 and 3 site.

13 Overall however, the initial conclusions  
14 were essentially unaffected with the new data. So it  
15 was consistent with the initial data. It was just  
16 more representative to use the new data.

17 You keep hearing me bring up the  
18 exemption. That was kind of the biggest issue we ran  
19 across. The humid conditions did result in our  
20 maximum safety wet bulb temperature being about a  
21 degree, 1.2 degrees higher than the DCD value of 86.1.

22 The basis for that is contained in FASAR Sections 5,  
23 6 and 9 and it will be discussed here in just a few  
24 minutes.

25 Hazard sources, including site-specific

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 chemical, asphyxiation, and explosive hazards were  
2 evaluated with the ALOHA computer model utilizing  
3 guidelines in the applicable Reg Guide and found to be  
4 acceptable.

5 Siting conditions such as distance from  
6 the applicable hazard and local topography, again the  
7 rolling hills which provide for greater dispersion,  
8 were additional favorable factors for the evaluation.

9 Three more significant hazards that we  
10 evaluated were the Unit 1 site which is located again  
11 approximately one mile to the north and there was an  
12 ammonium hydroxide tank there that we evaluated  
13 specifically. There is the railroad line that we  
14 pointed out at the very beginning of our presentation  
15 that runs along the Broad River west of the site. And  
16 there is a gas pipeline that runs from the south  
17 towards the north that ends up at our Parr Facility,  
18 which again is located approximately just over a mile  
19 to the south of our unit. So the line never runs  
20 further north than that.

21 Other hazards that required evaluation by  
22 the regulatory requirements were either not applicable  
23 or probabilistically insignificant.

24 Does anybody have any specific questions  
25 we could try and answer for you?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           MEMBER RAY:   Is there going to be any  
2 further discussion of the treatment of the railroad  
3 line hazardous source?

4           MS. MONROE:   Not specifically but if you  
5 would --

6           MEMBER RAY:   Is there anything you wanted  
7 to say?

8           MR. SEBROSKY:   There is going to be a  
9 discussion about those stats, toxic gas --

10          MEMBER BANERJEE:  That is separate.  There  
11 is a whole presentation.  Right?

12          MEMBER RAY:   I thought there was.

13          MR. SEBROSKY:   So the staff will do a  
14 presentation.

15          MS. MONROE:   Yes, there is someone from  
16 the staff that will be discussing.

17          MEMBER BANERJEE:  Yes, I noticed that.  So  
18 I thought that would be the time to take it up.

19          MEMBER RAY:   I've been looking at too many  
20 things.  I can't keep track of everything that's  
21 coming up but I thought there was.  Thank you.

22          MS. MONROE:   Okay.  If there are no  
23 further questions on that, we will move to, if you  
24 keep going through your slide handouts, we have got  
25 them together, we will have a discussion by Mr. Mark

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 Stella of Westinghouse dealing with our specific wet  
2 bulb exemption.

3 MR. STELLA: Thank you, Amy.

4 As Amy noted, I am Mark Stella from the  
5 Westinghouse Balance Plan Engineering Group. I would  
6 like to just briefly go over the historical basis of  
7 the wet bulb temperature exemption request; describe  
8 the evaluation process that we use to determine that  
9 the exemption would be a valid exemption, it wouldn't  
10 result in any changes to the performance of the AP1000  
11 standard systems at the VC Summer site; and then  
12 summarize the results of some of the evaluations that  
13 were impacted by the increase in wet bulb temperature.

14 Before I start going through this, I would  
15 like to point out, I am sure most people know there  
16 are actually two wet bulb temperatures that are  
17 defined in the AP1000 DCD which relate to the  
18 performance of various safety defense-in-depth and  
19 non-safety systems. There is the maximum safety non-  
20 coincident wet bulb temperature, which is what we are  
21 talking about here today. Then there is a lower wet  
22 bulb temperature, the maximum normal wet bulb  
23 temperature, which is used to evaluate the performance  
24 of the plant in terms of time to cool the plant down  
25 and things of that nature.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1           So the exemption is only for the maximum  
2 safety ambient wet bulb temperature of the non-  
3 coincident value, which in the current revision of the  
4 DCD is, as Amy pointed out, 86.1 degrees Fahrenheit.

5           When Summer started preparing its COLA and  
6 responding to NRC questions on the COLA review, the  
7 NRC actually asked the question what would happen if  
8 we, instead of using the zero percent exceedance wet  
9 bulb temperature as measured at the site using the Met  
10 Towers, what if we calculated the 100 year return  
11 temperature for the site? Would that number be higher  
12 or lower than the zero percent exceedance temperature,  
13 which is typically the measure that utilities use to  
14 compare with the DCD limits to make sure that their  
15 plant site is within the assumptions made for the  
16 AP1000.

17           Summer did the analysis and found that the  
18 100 year return temperature was indeed higher than the  
19 zero percent exceedance temperature, which had been  
20 the previous standard for the site. And Amy did point  
21 out the number was 87.3 degrees Fahrenheit, as opposed  
22 to the 86.1 that is currently in the DCD.

23           The question then arises, how significant  
24 is that in terms of affecting the performance of the  
25 safety systems, defense-in-depth systems and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 investment protection systems that are sited in the  
2 DCD. There are a number of performance statements in  
3 the DCD based on the maximum safety wet bulb  
4 temperature.

5 So Westinghouse had previously done a  
6 number of analyses for increasing the maximum safety  
7 wet bulb temperature because initially the DCD wet  
8 bulb temperature maximum safety non-coincident wet  
9 bulb temperature was 80.1 degrees. That was the  
10 initial wet bulb temperature which was based on a  
11 survey of a large number of potential AP1000 sites in  
12 the continental United States.

13 So that temperature had been raised from  
14 80.1 to 85.5 and finally to 86.1 in Rev 18, actually I  
15 think in Rev 15 of the DCD. It was at 86.1 degrees  
16 and it has remained there since then. To do that,  
17 Westinghouse performed a number of quantitative  
18 analyses of the performance of the various systems.  
19 And those analyses are the same ones that we use to  
20 assess the performance of the VC Summer systems at the  
21 87.3 degrees Fahrenheit maximum safety non-coincident  
22 wet bulb temperature.

23 MEMBER RAY: Educate me. Non-coincident  
24 here means what?

25 MEMBER CORRADINI: Didn't have the same

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 temp.

2 MR. STELLA: That means it is irrespective  
3 of the local dry bulb temperature. There is another  
4 measure that is specified in the tables for the DCD,  
5 which is a combination of the maximum dry bulb and  
6 maximum coincident wet bulb temperature.

7 MEMBER RAY: Okay. Non-coincident refers  
8 to dry bulb.

9 MR. STELLA: Non-coincident is by itself.  
10 It does turn out though that the non-coincident wet  
11 bulb temperature of 86.1 and the combined dry bulb  
12 maximum wet bulb temperature, it is also 86.1 degrees.

13 So there really is no difference. But these  
14 parameters have very tongue-tying names. So if you  
15 will excuse me, I will just use maximum wet bulb  
16 temperature from now on, rather than trying to give it  
17 its perfect name. Because we are talking about the  
18 maximum safety in non-coincident wet bulb temperature.

19 I will just call it maximum wet bulb temperature to  
20 save time.

21 MEMBER RAY: Okay.

22 MR. STELLA: When we evaluated the  
23 impacts, as I pointed out, we used the same methods  
24 that we did to increase the DCD value of the maximum  
25 wet bulb temperature. There are number of performance

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 areas that are affected by the change in this wet bulb  
2 temperature.

3 In fact, there was an earlier effort in  
4 Westinghouse to assess the impact of changing this  
5 temperature, raising it above 86.1, which was done for  
6 the Turkey Point site for Florida Power and Light.  
7 That maximum wet bulb temperature was 87.4 degrees,  
8 which of course bounds very nicely the 87.3 at the VC  
9 Summer site. We had all the calc notes available for  
10 every one of the changes that would occur if we raised  
11 that temperature. So we compared those results to the  
12 Summer and the comparison is easy.

13 The Summer systems and structures are  
14 exactly the same as the standard AP1000 systems and  
15 structures. The only difference is the maximum wet  
16 bulb temperature. Our conclusion for Florida Power  
17 and Light was that the performance of the systems was  
18 acceptable in all respects, that all the systems that  
19 were affected by this increase in temperature.  
20 Therefore, the same conclusion would be drawn for VC  
21 Summer.

22 MEMBER SIEBER: That would include  
23 containment maximum pressure?

24 MR. STELLA: That does. That is the  
25 major, in fact I think the only safety-related

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 parameter that needs to be looked at.

2 MEMBER SIEBER: And so you are below the  
3 design pressure of containment. The depressurization  
4 in cool down will take longer.

5 MR. STELLA: It will.

6 MEMBER SIEBER: Have you reanalyzed to  
7 take into account this and --

8 MR. STELLA: The GOTHIC analysis was  
9 redone with this higher wet bulb temperature. In  
10 fact, we actually took the maximum safety wet bulb  
11 temperature quite a bit higher than the 87.4 to see  
12 what the impact might be.

13 MEMBER SIEBER: And you still fit within  
14 the parameters?

15 MR. STELLA: We still fit within the  
16 curves that we published initially and that apply to  
17 the 86.1 Fahrenheit maximum wet bulb temperature.

18 MEMBER SIEBER: Thank you.

19 MR. STELLA: The effect on pressure, Mr.  
20 Sieber, is very minuscule. It is a couple of  
21 hundredths of a psi caused by an increase in temp.

22 MEMBER SIEBER: It is there nonetheless.

23 MR. STELLA: So that was a good result.

24 We looked at the investment protection  
25 parameter, the control of potential steaming from the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 in-containment refueling water storage tank, RIWST.  
2 The objective is to maintain that tank fluid below  
3 saturation temperature, in the event of a PRHR  
4 actuation so that you don't steam in the containment  
5 and possibly affect very expensive and good equipment.

6 That parameter was also maintained well below  
7 saturation temperature. It did go up by about the  
8 same amount as the wet bulb temperature went up but it  
9 is still in the 200 degree Fahrenheit range. So there  
10 is quite a bit of margin for that one.

11 The component fueling cooling system  
12 normal operating temperature limit is 100 degrees  
13 Fahrenheit. That is set by the design of the reactor  
14 coolant pumps. That temperature is the limiting  
15 temperature for operation of the pumps at full RPM  
16 during normal plant operation. We normally try to  
17 keep our component cooling water temperature below 95  
18 degrees. But even with the 86.1 degree DCD maximum  
19 wet bulb temperature limit, at times it does go above  
20 95 degrees into the 96 degree range. And for Summer,  
21 it goes a little higher because of the additional 1.2  
22 degrees added on wet bulb. However, these are  
23 excursions of limited extent, a few hours at most and  
24 the temperature will come back down below 95.  
25 Therefore, our conclusion was that this performance

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 requirement was also meant for Summer.

2 We are committed to maintain the spent  
3 fuel pool temperature below 120 degrees Fahrenheit  
4 following a normal refueling. And that goal is also  
5 met, even with the 87.3 degree Fahrenheit maximum  
6 safety wet bulb temperature.

7 The last item that was affected by an  
8 increase in maximum wet bulb temperature was the  
9 performance of the low capacity chilled water system,  
10 in terms of its ability to cool the main control room,  
11 I should say cool and dehumidify the main control  
12 room, the battery rooms, and the electrical equipment  
13 rooms to maintain the assumed preliminary conditions  
14 in the event of a design basis accident.

15 We found that the increase in the wet bulb  
16 temperature caused the coolant requirements for those  
17 rooms that go up basically because of the  
18 humidification caused by the additional wet bulb  
19 temperature increase.

20 And the performance of the chiller itself  
21 was not affected. These were air cooled chillers that  
22 are sensitive only to dry bulb temperature. What  
23 happened was that the load on the chiller was  
24 increased by some 20 to 30 tons but the chiller itself  
25 was not running at full output. It was quite a bit

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 below full output. We had plenty of margin. So, the  
2 87.3 degrees posed no problem with respect to the  
3 operation of the system.

4 All the other parameters and performance  
5 goals that are stated in the DCD are based on either  
6 performance against dry bulb temperature or  
7 performance against the other wet bulb, the maximum  
8 normal wet bulb temperature, which is 80.1 degrees.  
9 These are mostly performance requirements related to  
10 cool down of the plant. That did not change for VC  
11 Summer. Its maximum normal wet bulb temperature is  
12 below the 80 degrees Fahrenheit temperature that  
13 applies to the DCD. And so we didn't have to look at  
14 that because the system performance would be the same  
15 or better than for the standard design at the limiting  
16 site.

17 That is all I have for this topic. Any  
18 questions?

19 MEMBER RAY: Thank you.

20 MS. MONROE: Now if Mr. Steve Summer will  
21 come forward and Angelos. We will move on to a  
22 discussion on hydrology. Mr. Steve Summer will  
23 provide the presentation. Steve?

24 MR. SUMMER: Thank you. Good morning.

25 Again, my name is Steve Summer and I will

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 be discussing FSAR Section 2.4, hydrologic  
2 engineering.

3 Again, this slide shows the major surface  
4 water features. The site is located about a mile to  
5 the south of Monticello Reservoir, which is the upper  
6 pool of the Fairfield Pumped Storage Facility and the  
7 source of makeup water for normal operation of Units 2  
8 and 3. The reservoir also provides cooling and makeup  
9 water for Unit 1.

10 The Broad River and Parr Reservoir, which  
11 is a dammed section of the river, runs generally  
12 northwest to southeast. We note the locations of the  
13 Summer Station 1, United 2 and 3, and also Fairfield  
14 Pumped Storage Facility.

15 There is no risk to safety-related  
16 systems, structures, or components from flooding. The  
17 probable maximum flood level is more than 100 feet  
18 below site grade and the site is not susceptible to  
19 surges, seiches, or tsunamis. Ice effects are highly  
20 unlikely. The Broad River is adequate for non-safety  
21 uses, even during low-flow conditions.

22 This slide shows the site topography. And  
23 as we discussed before, Units 2 and 3 are situated on  
24 a ridge top with a designed plant grade elevation of  
25 400 feet in a VD 88, which is the North American

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 Vertical Datum of 1988. And that elevation is the  
2 equivalent to the AP1000 design plant grade of 100  
3 feet. The plant grade is about 150 feet above the  
4 Broad River Flood Plain.

5 As can be seen from the figure, surface  
6 water drains away from the site and eventually flows  
7 to the Broad River. Again, this topography figure  
8 illustrates why flooding is not an issue at this site.

9 Surface water will move to ground water.  
10 Again, located on the ridge top. This figure  
11 represents the piezometric contours, which indicate  
12 that the shallow subsurface flows away from the site.

13 Our subsurface flow would be expected to flow from  
14 high to low levels, as shown by the red arrows.

15 There are no plans to use local ground  
16 water for construction or operation of Summer Station  
17 Units 2 and 3. Water for construction purposes will  
18 be obtained from the Monticello Reservoir and the  
19 Jenkinsville Water District.

20 Continuing with groundwater, the design  
21 plant grade elevation is 400 feet, again, equivalent  
22 to 100 feet from the AP1000 DCD. The maximum  
23 allowable groundwater level is 398 feet and the  
24 maximum expected groundwater level is 380 feet, or 20  
25 feet below the plant grade and well below the design

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 value of 398.

2 Accident release of liquid effluents. The  
3 evaluation shows that an accident liquid release of  
4 effluents in groundwater would not exceed 10 C.F.R.  
5 Part 20 limits. Three conceptual flow transport  
6 models, one saprolite and two bedrock, are presented.

7 The accidental release scenario assumes an  
8 instantaneous release from an effluent holding tank  
9 located in the lowest level of the AP1000 auxiliary  
10 building. The next three slides are examples of the  
11 conceptual models of the transport pathways for  
12 saprolite, shallow bedrock, and deep bedrock to the  
13 Broad River to the west or to Mayo Creek to the east  
14 and deep bedrock to a hypothetical well at the nearest  
15 point outside the SCE&G property line.

16 This figure represents the saprolite  
17 pathway. In this flow transport pathway, flow is  
18 through the saprolite zone and discharges to a stream.

19 We believe that this pathway is the most probable.

20 The second figure here represents the  
21 bedrock pathway to the Broad River or stream, Mayo  
22 Creek. And this flow transport pathway flows through  
23 the bedrock and discharges to a stream. And thirdly,  
24 the figure represents the bedrock pathway that is not  
25 intercepted by a stream. And this flow transport

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 pathway flows through bedrock, continues under Mayo  
2 Creek, and discharges to a hypothetical well located  
3 at the property boundary, approximately 4500 feet or  
4 three-quarters of a mile to the east/southeast.

5 Again, none of these pathways resulted in  
6 values exceeding 10 C.F.R. Part 20 limits.

7 MEMBER RYAN: Were you conservative about  
8 dilution and dispersion?

9 MR. SUMMER: I'm sorry.

10 MEMBER RYAN: How conservative were you  
11 about dilution and dispersion assumptions?

12 MR. SUMMER: I could get Angelos  
13 Findikakis with Bechtel to address that.

14 MR. FINDIKAKIS: In estimating dilutions  
15 in the streams, we considered the minimum 100 year  
16 low-flow and that was the basis for estimating the  
17 dilution factor.

18 MEMBER RYAN: How about dispersion in the  
19 plume as it travels down?

20 MR. FINDIKAKIS: We considered dispersion  
21 in only one of the pathways. For all the other  
22 pathways, it wasn't necessary to consider the  
23 dispersion because the concentrations were very low.

24 MEMBER RYAN: Okay, thanks.

25 MR. SUMMER: Any other questions? Thank

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 you.

2 MR. SEBROSKY: Again, my name is Joe  
3 Sebrosky, the lead project manager for Summer. To my  
4 right is Don Habib. He is the chapter project manager  
5 for four chapters; Chapter 6, Chapter 11, 12 and 15.  
6 And to his right is Ken See. Ken did the surface  
7 water hydrology review. And to Ken's right is Shi  
8 Jeng Peng. Peng did the toxic gas review for Chapter  
9 6.

10 This first slide just gives the dates when  
11 we got the application, when the acceptance review was  
12 complete and when the advanced safety evaluation  
13 report was complete, which was December 10, 2010.

14 There has been two subcommittee meetings,  
15 one July 21 and 22nd, 2010 and another this past  
16 January 11th and 12th.

17 The Summer application consists of three  
18 things, material incorporated by reference by the  
19 AP1000 DCD, the standard content material that is  
20 applicable to all the AP1000 COLs and then Summer  
21 plant specific information.

22 The standard content material was not  
23 discussed in either of the two Summer ACRS  
24 subcommittee meetings because the standard content  
25 material was discussed during the Vogtle subcommittee

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 and full committee meetings. So we did not brief the  
2 subcommittee separately on the standard content.

3 This slide just reemphasizes what has  
4 already been stated, that Summer is a subsequent COL.

5 It references the Vogtle advanced safety evaluation  
6 report. The second sub-bullet, if you looked in our  
7 safety evaluation report, you know that it comes from  
8 Vogtle, based on the fact that it is double indented  
9 and italicized. If it is not doubled indented and  
10 italicized, then it is unique to Summer.

11 The third sub-bullet, this was discussed  
12 in subcommittee meetings with Vogtle. But there is a  
13 history with Bellefonte at one point, was the RCOL.  
14 The only safety evaluation report with open items that  
15 is going to be written on the AP1000 COLs was  
16 Bellefonte. That is the only one that we wrote. The  
17 rest of them are going to go to skip that stage and  
18 use a four-phase review schedule. So there were no  
19 plans to issue any more safety evaluation reports with  
20 open items.

21 Because of that, that is why you see  
22 mentioned in Vogtle and you also see mentioned in  
23 Summer going back to the Bellefonte open items.

24 The reason that this slide is shown is  
25 that there are 16 parts of the application. It is not

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 just the final safety analysis report that the staff  
2 reviewed in its SER. The final safety analysis report  
3 is Part II of the application.

4 There are a couple other things I wanted  
5 to point out here, if you look at parts 13, 14, 15 and  
6 16; 13 is the quality assurance program, 14 is the  
7 mitigative strategies document for loss of large area  
8 of fires, commonly referred to as LOLA, 15 is a cyber  
9 security plan, and then 16 is the material control and  
10 accounting program for special nuclear material. All  
11 four of those take advantage of the standard review  
12 approach.

13 So if you look in Chapter 17 of our SER,  
14 you would see mention of the quality assurance program  
15 description and it utilizes the double indent.  
16 Similarly, if you look in Appendix 19A, the LOLA  
17 evaluation there is a public version of the document  
18 and there is a nonpublic version of the document. You  
19 have to go to the nonpublic version of document and  
20 when you look at that nonpublic version of the  
21 document, the safety evaluation report, you will see  
22 the use of double indented and italicized safety  
23 evaluations by the staff, taking advantage of the  
24 design-centered review approach.

25 Cyber security plan, there is just a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 public version of that, double indented, italicized  
2 portions in 13.8. And the same thing with the special  
3 nuclear material control and accounting program. That  
4 is in section 1.5.5.

5 The other thing to note on this and we  
6 will reemphasize this in a later presentation, if you  
7 look at Part 5 of the application emergency plan,  
8 Chapter 2 of the FSAR and Part 5 of the application  
9 emergency plan contain the majority of the site-  
10 specific information that we briefed the subcommittee  
11 on.

12 Go to the next slide and I will turn it  
13 over to Don.

14 MR. HABIB: This slide addresses the  
15 exemption requested by the applicant for maximum  
16 safety wet bulb temperature. It was requested in the  
17 COLA Revision 2, an increase of 1.2 degrees from 86.1  
18 to 87.3 degrees and it was based on 100 year return  
19 temperature.

20 And the other two temperature  
21 specifications from the DCD, the maximum coincident  
22 normal wet bulb temperature, that did not change. And  
23 also the maximum dry bulb temperature, that did not  
24 change.

25 When we did the evaluation, there were

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 several areas that were affected. The first one in  
2 Chapter 2, site characteristics comparison and the  
3 meteorology reviews; in Chapter 5, the normal residual  
4 heat removal system; in Chapter 6 containment systems  
5 and habitability systems for the control room. And  
6 for the control room we look at two systems, the  
7 nuclear island nonradioactive ventilation system and  
8 low capacity chilled water system.

9 And then in the chapter on auxiliary  
10 systems, the spent fuel pool cooling system, component  
11 cooling water system, and the central chilled water  
12 system.

13 And the staff had audited calculations  
14 made available by the applicant. And in all of these  
15 evaluations, the conclusions were not affected.

16 And the next portion of our presentation  
17 is for the toxic gas.

18 MR. PENG: This is Shi Jeng Peng. I am  
19 the reviewer for control room habitability.

20 The purpose of the toxic gas review is to  
21 evaluate the impact of any potential or possible  
22 chemical release within five miles of control room on  
23 control room habitability.

24 Section 2, the reviewer has already  
25 identified three chemicals will impact, will

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 potentially impact control room habitability. These  
2 three chemicals are 28 percent ammonium hydroxide from  
3 Unit 1, and cyclohexylamine from the rail, and the  
4 last one is chlorodifluoromethane from rail, too  
5 because they have a lot of --

6 MEMBER POWERS: Cyclohexylamine is not  
7 standard nomenclature. What is that compound?

8 MR. PENG: The compound is, I could find  
9 it for you but it is already heavy case and type  
10 chemical anyway. It is about three times heavier than  
11 air. But I also have idea IDLH limit is about 100  
12 ppm.

13 MEMBER POWERS: Is that a CAS number?

14 MR. PENG: I'm sorry?

15 MEMBER POWERS: A CAS number?

16 MR. PENG: I cannot follow you.

17 MEMBER POWERS: Does it have a CAS number?  
18 I'm trying to figure out what it is.

19 MR. PENG: Oh, a CAS number, I don't know.  
20 I'm sorry.

21 The staff identified the concentration at  
22 the control room intake exceed IDLH limit so they  
23 asked me continue to evaluate will control room  
24 habitability impact by this high, higher than IDLH  
25 concentration.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 I used a HABIT computer code, which is Reg  
2 Guide 1.78 recommend to use. And this computer code  
3 has been used by Pacific Northwest Lab for in last  
4 1988 and 1998, has been used for a while. So I got  
5 some results. The result is the next slide, please.

6 MEMBER BANERJEE: Now before you go on,  
7 the HABIT code does not handle heavy gases and these  
8 are heavy gases. So you have to take what they say  
9 with a pinch of salt. Though, ALOHA does. ALHOA does  
10 but the staff doesn't.

11 I can give you the structure of  
12 cyclohexylamine as well. It is just a benzene ring  
13 with an NH<sub>2</sub> on the end.

14 MEMBER POWERS: Monoamine, one monoamine  
15 benzene.

16 MEMBER BANERJEE: One, one -- yes.

17 MEMBER POWERS: All right. Why don't we  
18 use standard nomenclature?

19 MEMBER BANERJEE: Whatever it is. That is  
20 what it is.

21 MR. PENG: My conclusion is I have  
22 confirmed the applicant's licensing basis analysis and  
23 found the chemicals would not pose any threat to the  
24 control room operators.

25 MEMBER POWERS: I mean, the significance

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701



1 of finding this is a little bit lost on me, if the  
2 code can't handle heavier-than-air gases. I mean, why  
3 is significant?

4 MEMBER BANERJEE: This is not but ALOHA  
5 can and is a fairly well recognized industry code  
6 which is used in the chemical industry.

7 MEMBER POWERS: Why is the staff using a -  
8 -

9 MEMBER BANERJEE: I don't know.

10 MEMBER POWERS: -- code that doesn't  
11 apply?

12 MEMBER BANERJEE: We raised in the  
13 question in the subcommittee.

14 MEMBER RAY: Yes, well I think that is  
15 what they are trying to get at with the last bullet  
16 here on the preceding slide.

17 MEMBER BANERJEE: Now whether this dilutes  
18 enough that the early heavy gas behavior is lost, I  
19 don't know. But you will see that the ALOHA  
20 concentrations are higher than the HABIT, which is to  
21 be expected.

22 And also the topography of the site is  
23 such that the site is higher than where the release  
24 points would be.

25 MEMBER POWERS: Four hundred feet.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER BANERJEE: Yes, so I don't think  
2 that there is any really issue with the calculations  
3 with ALOHA being acceptable. I don't think we need to  
4 say more than that at this point, unless you want to  
5 pursue it.

6 CHAIRMAN ABDEL-KHALIK: What is the  
7 difference in elevation?

8 MR. PENG: It is 150 feet.

9 MR. SEBROSKY: Well you have to be careful  
10 about the question. If you are asking for the  
11 difference in the elevation from the railroad line --

12 CHAIRMAN ABDEL-KHALIK: Correct.

13 MR. SEBROSKY: Okay from the railroad line  
14 --

15 MR. PENG: To control room impact is 150  
16 feet. One hundred fifty feet.

17 CHAIRMAN ABDEL-KHALIK: Okay, thank you.

18 MEMBER BANERJEE: So it is going up. I  
19 don't think there is any reason --

20 MEMBER RAY: The issue is it came up, had  
21 to do more with applications for other --

22 MEMBER BANERJEE: Other plants, yes.

23 MEMBER RAY: -- other circumstances and  
24 that is what they are trying to say here in the last  
25 bullet is that they agree that it should be looked at.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1                   MEMBER BANERJEE:    Yes, I actually went  
2 through the report carefully.   And it cannot handle  
3 heavy gases.

4                   MEMBER RAY:    Proceed.

5                   MR. SEE:    Okay, let me be the first to say  
6 good afternoon to you.   My name is Ken See.   I am a  
7 senior hydrologist in the Office of New Reactors.   I  
8 am here to discuss the surface water hydrology issues.

9                   In my talk I am going to be referring to  
10 just this slide.   It is the only one I have.   This  
11 slide shows basically the major surface water features  
12 at or near the site.   One with their respective  
13 surface water elevations or floor elevations.

14                   As part of its review, the staff reviewed  
15 the various flood mechanisms and scenarios identified  
16 by the applicant in the FSAR.   Additionally, the staff  
17 postulated various other mechanisms and scenarios that  
18 may generate large floods at or near the site.

19                   After conducting our review, the staff  
20 agrees with the applicant that the design basis flood  
21 is that caused by the local intense precipitation as  
22 described in Section 2.4.2 of the final safety  
23 analysis report.

24                   The fact that this flood is, the design  
25 basis flood is caused by the local intense

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 precipitation is not unusual, we are finding out at  
2 many sites. Additionally the margin that we found  
3 here at the Summer site is also typical of other  
4 sites.

5 Details of the Monticello Reservoir Dam  
6 Breach analysis were not included in Section 2.4.4 of  
7 the FSAR because the applicant considered this to be  
8 sensitive information. However, the applicant did  
9 provide to the staff detailed information and detailed  
10 calculations during our site audit. Based upon a  
11 review of this information, we found their analysis to  
12 be acceptable.

13 In addition to the breach of the  
14 Monticello Reservoir as discussed by the applicant,  
15 the staff also postulated a breach in the berm between  
16 the Mayo Creek and the Monticello Reservoir, leading  
17 to a flood down Mayo Creek, which is this bright red  
18 line to the right of the figure there.

19 Flow values used in this analysis were  
20 obtained from the Bureau of Reclamations Dam Safety  
21 Office Projects. These values were then increased for  
22 additional conservatism. These values were then used  
23 --

24 MEMBER POWERS: When you increase  
25 something arbitrarily for additional consideration,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 how do you know what increase to make?

2 MR. SEE: It is a judgment call.

3 MEMBER POWERS: How does one tutor one's  
4 judgment in making an arbitrary increase?

5 MR. SEE: Well if we increase these values  
6 and then we exceed the site flood elevation here, in  
7 this case 400 feet, then we would probably back off.  
8 But when we increase the value and yet we still don't  
9 exceed the flood elevation, in this case 400 feet,  
10 that just gives us additional confidence in the  
11 analysis.

12 MEMBER POWERS: Why don't you go the other  
13 way, just assume a biblical flood and keep dropping it  
14 down until you get to the site elevation and then say  
15 is that more or less?

16 MR. SEE: We could take the 2012 approach,  
17 I suppose, but then we wouldn't license very many of  
18 these things. I mean, the analysis that was done was  
19 very conservative. That is the main point. I can't -  
20 - that is, I think different analysts would probably  
21 come up with a different number. If you were going to  
22 increase something, I think you would come up with a  
23 different number than somebody else.

24 MEMBER ARMIJO: Do you use a physical  
25 model of --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. SEE: Yes.

2 MEMBER ARMIJO: -- let's say a blockage of  
3 the flow channels by flood debris?

4 MR. SEE: I am going to talk about that a  
5 little bit later. But in this particular case, this  
6 is different. You are talking about the site  
7 drainage.

8 MEMBER ARMIJO: Yes, the drainage. But  
9 let's say if you had a really severe dam break and it  
10 takes a lot of debris down your normal flow channels,  
11 is that a mechanism by which you could back up and  
12 flood the site?

13 MR. SEE: No, not in this case. We don't  
14 see any potentials for land slides or anything of this  
15 nature. You know, the dam breach analysis, both  
16 analysis would indicate that the site is not subject  
17 to that flooding. The design basis flood for the site  
18 is based upon what is called the local intense  
19 precipitation, which is a little over six inches of  
20 rain in five minutes.

21 MEMBER ARMIJO: Okay.

22 MR. SEE: And that is almost, I mean, that  
23 is an event not to be exceeded. I mean, it is a  
24 biblical flood, if you will.

25 MEMBER POWERS: I guess I don't understand

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 it. It starts to rain and it is going to be seven  
2 inches within five minutes. What do you tell the  
3 clouds not to? They are going to be fine? There is  
4 an enforcement action against the clouds?

5 MR. SEE: I'm not following you.

6 MEMBER POWERS: I mean you say six inches  
7 over five minutes is not to be exceeded. What does  
8 that mean?

9 MR. SEE: Well that is, the National  
10 Weather Service puts out documents of the  
11 hydrometeorological reports and their HMR 51 and HMR  
12 52 of the documents that cover this region of the  
13 country. And that is based upon moisture  
14 maximization.

15 And what they have done is they have gone  
16 through and they have observed large storm events and  
17 they have correlated available atmospheric moisture  
18 with observed rain events. And then they have gone  
19 through and said okay, now given these conditions,  
20 let's try to maximize the moisture that the atmosphere  
21 can hold and then correlate that back out to our  
22 rainfall amounts called the probable maximum  
23 precipitation. That is called the probable maximum  
24 precipitation not the absolute maximum precipitation  
25 because could it be exceeded? In theory, possibly.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 But to my knowledge, in this area it has never been  
2 exceeded.

3 MEMBER POWERS: Now that may be more a  
4 statement of your knowledge than the facts of the  
5 situation.

6 MR. SEE: Well, could we have missed  
7 something? Absolutely. But it is all we can -- You  
8 know, our current state of knowledge tells us that it  
9 has yet to be exceeded in this area.

10 Now one critique of the HMRs is that the  
11 data is 20 or 30 years old. And our Office of  
12 Research is currently trying to update these reports,  
13 bringing the data up to the year I think 2000 or 2005.

14 And then preliminary results of that analysis  
15 indicate that we are not seeing any large increase.

16 But I think I may have confused you here.

17 There are two separate events. The design basis  
18 flood here at the site is called the local intense  
19 precipitation which is a one square mile PNP. The dam  
20 breach analysis that I was talking about is a separate  
21 issue.

22 MEMBER POWERS: And we have got to use  
23 judgment and decide how close to biblical. That I  
24 don't understand either.

25 MR. SEE: Well if we did not, let's say we

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701



1 did not increase those values, we just took the values  
2 out of the dam safety office documents, we would get a  
3 flood elevation less than what we got here, which is  
4 392 feet.

5 Okay, --

6 MEMBER POWERS: Well, I mean on this  
7 intense precipitation what you are saying is based on  
8 all the information you have, you are not going to  
9 exceed six inches in five minutes.

10 MR. SEE: Yes, sir.

11 MEMBER POWERS: Okay. We are not going to  
12 fine the clouds if they should happen to give seven.

13 MR. SEE: Well that is what the physics  
14 tells the meteorologist.

15 MEMBER POWERS: I understand that.

16 MR. SEE: You know, that is an estimated  
17 maximum.

18 MEMBER POWERS: Now let me ask you about  
19 this. They have developed that information on the  
20 maximum intense precipitation based on an historical  
21 body of data and it is an empirical construction. We  
22 are told by numerous people that on the east coast of  
23 the United States we experience weather cycles. Does  
24 that experiential base cover enough time periods that  
25 we have captured that cyclical weather?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MR. SEE: Now that is a simple question.  
2 Actually it is a good question.

3 Based upon my reading of the research, we  
4 are seeing changes in lower magnitude events. For  
5 example, what used to be considered a 40-year event  
6 may now considered a 30-year event. But at the  
7 extreme values that we are discussing here in the PNP,  
8 no one is willing to make a statement at that level.

9 My own personal opinion is that as you  
10 head towards to the extreme, you know, that will level  
11 off. I mean, if the data is correct and the physics  
12 behind their estimates are correct, if there is truly  
13 indeed a maximum, the climate change and weather cycle  
14 should not exceed those values. But that is a  
15 question that gets asked frequently by me and other  
16 hydrologists at the NRC to researchers. And no one  
17 has told us yes, we are seeing changes that would  
18 cause us to change our results and increase their  
19 values.

20 But it is an ongoing topic. And if I  
21 could answer that question, I would be making a lot  
22 more money than I am right now.

23 MEMBER POWERS: I mean, it is a question  
24 because these guys are going to build a plant that is  
25 going to be here for 60 years.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MR. SEE: Yes, sir. Yes, sir, I mean as I  
2 said earlier, one of the criticisms of this method is  
3 that the data stopped, you know, the data for the  
4 study stopped in 1975, something like that. And so  
5 what happens if we now take data up to the year 2000  
6 and redo the analysis using the same methods? We have  
7 got the bureau, our Office of Research has the Bureau  
8 of Reclamation working this area for the Carolinas  
9 because a lot of the plants that we are relicensing  
10 are in the Carolinas. So they were told to start  
11 looking at that area first. And they have gone  
12 through and they have got some preliminary results and  
13 they have not seen an increase in the PNP value, based  
14 upon that new data.

15 MEMBER ARMIJO: Well, you actually have  
16 more conservatism in this 399.4 foot than just the  
17 six-inch of rain in an hour.

18 MR. SEE: Yes, sir.

19 MEMBER ARMIJO: And that bothered me  
20 during the subcommittee meeting. You provided an  
21 explanation of how you treated the drainage, that it  
22 wasn't a perfect drainage during this time, that you  
23 assume some blockage of --

24 MR. SEE: We assumed all of the culverts  
25 were blocked for this analysis. The 399.4 assumes the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 culverts are not working.

2 MEMBER ARMIJO: So did you do a  
3 sensitivity that said hey if the culverts are  
4 partially blocked, 50 percent, what would the number  
5 be?

6 MR. SEE: The value would be lower. You  
7 are reducing the conveyance.

8 MEMBER ARMIJO: How much? Ten feet lower  
9 or an inch lower?

10 MR. SEE: I don't have that number. If  
11 you assume all the culverts are blocked, the  
12 depressions are going to fill up and the roadways are  
13 going to overtop. So, I mean, that is --

14 MEMBER ARMIJO: Okay, so that approach  
15 says no matter how bad everything is blocked, it won't  
16 go over the 400 -- up to the 400 foot.

17 MR. SEE: You think of it as, you know,  
18 the topography is a like a little bathtub and you  
19 block the culvert and that bathtub fills up and spills  
20 over the roadways and all the infrastructure. Okay?  
21 If that culvert is working 50 percent or working  
22 properly, then you would not --

23 MEMBER ARMIJO: You are nowhere close.

24 MR. SEE: You would not get it as high.

25 MEMBER ARMIJO: Okay.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. SEE: But I do want to point out that  
2 the applicant has provided a confirmatory item where  
3 prior to large storm events, they will do a walk-down.

4 They will develop an inspection of their facility to  
5 ensure that these culverts are indeed not blocked. So  
6 I think the 399.4 is very conservative.

7 MEMBER RAY: Okay. Now are we done with  
8 this part, Joe?

9 MR. SEBROSKY: Yes.

10 MEMBER RAY: We are going to begin as  
11 series of what is shown on the agenda as discussions  
12 involving both the applicant and the staff. I guess  
13 Amy, you and Joe are going to orchestrate this, are  
14 you?

15 MS. MONROE: Yes, sir.

16 MEMBER RAY: I am not going to get in the  
17 middle of it.

18 MS. MONROE: Actually what we intend to do  
19 is we will take through and go through the next items  
20 six, seven, and eight together. South Carolina will  
21 do our presentations and then let the staff follow.

22 MEMBER RAY: All right. Well, so I don't  
23 take up time, just go ahead.

24 MS. MONROE: Okay. And we will need to be  
25 moving people in and out but we will find they are

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 kind of sitting there ready and waiting.

2 MR. SEBROSKY: I'll just do a brief  
3 introduction for the NRC staff. This is Steve  
4 Schaffer. Steve is a health physicist that did the  
5 liquid radwaste review.

6 MS. MONROE: Now we are going to discuss a  
7 question. During the subcommittee, there were some  
8 questions discussing our wastewater discharge line.  
9 And so Mr. Tim Schmidt from South Carolina Electric  
10 and Gas Company is going to give you a more detailed  
11 discussion on that topic.

12 MR. SCHMIDT: Okay, good morning. I am  
13 Tim Schmidt with SCE&G. Today we are going to talk  
14 about those items of interest that Amy mentioned. We  
15 will be talking about the interface of our liquid  
16 radwaste system with our waste water system. We will  
17 also be talking a little bit about the design and  
18 construction of our wastewater system blow down line.

19 And before I get into this slide, I  
20 brought a sample high-density polyethylene material  
21 that I would like to offer to the committee to pass  
22 around and if they would like to see a representation  
23 of what this material is. I will speak to a little  
24 bit more with respect to this construction on the  
25 upcoming slides.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           On this slide here, I want to point out  
2 some design considerations of our wastewater system  
3 its interface with liquid radwaste. Our wastewater  
4 system has a gravity drainage blowdown line that  
5 carries a number of effluents from Units 2 and 3. One  
6 of these is diluted liquid radwaste effluent. These  
7 wastes are gravity drained from the plant, which we  
8 were talking elevation 400 all the way down to a  
9 diffuser in Parr Reservoir, which is around elevation  
10 235.

11           Our liquid radwaste effluents that enter  
12 our blowdown line come from a radwaste building and  
13 there is a mechanical joint-type interface for these  
14 lines entering the blowdown line. At this interface,  
15 we do have a high-density polyethylene manhole. It  
16 serves two purposes. One is to contain any leakage  
17 that might occur at those mechanical joints and also  
18 provides a point which we can monitor for leakage at  
19 that interface. Having this manhole is implementing  
20 guidance from NRC Reg Guide 4.21, to make sure we are  
21 compliant with 10 C.F.R. 20.1406.

22           The next bullet here points out some  
23 features in our wastewater system. Blowdown line  
24 design, we are using a high-density polyethylene  
25 material that is very corrosion resistant, resistant

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 to organic growth, as opposed to carbon steel. And  
2 this material does not require mechanical joint for  
3 installation, as with ductile iron or fiberglass. I  
4 talked a little bit more about that in the upcoming  
5 slides.

6 Along our blowdown line, we don't have any  
7 pumps, valves, or vacuum breaker type components along  
8 this line. As folks are aware, vacuum breaker valves  
9 in particular have been sources of ground water  
10 contamination events in the industry.

11 MEMBER ARMIJO: Is this blowdown line at  
12 operated ambient temperatures and pressures or does it  
13 ever get up --

14 MR. SCHMIDT: We expect temperatures below  
15 100 degrees. The driver there is our circulating  
16 water blowdown laces that goes through the line. We  
17 don't expect it to go above 95 degrees.

18 The other waste streams as mentioned on  
19 the next slide, but I will go ahead and mention them  
20 here, are effluents from our wastewater retention  
21 basins out in the yard, we would expect high  
22 temperatures there.

23 And there is also some treated effluents  
24 from the sanitary treatment plant on-site. Our flow  
25 again is gravity from the plant all the way down to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 Parr Reservoir, essentially open channel flow to this  
2 line. We don't have pressurized flow going through  
3 this line.

4 Okay on this next slide here is just a  
5 little schematic of our blowdown line. It is  
6 interface with the liquid radwaste system. Our  
7 blowdown line is a 36" diameter high-density  
8 polyethylene line. As I mentioned before, it is  
9 carrying a number of effluents of circulating water  
10 blowdown wastewater retention basin effluents,  
11 sanitary treatment plant effluents at approximate  
12 elevation 380 feet.

13 We have an intersection here with our  
14 liquid radwaste systems here, treated release lines  
15 from our radwaste buildings dump into our blowdown  
16 line. As I mentioned before, that is a mechanical  
17 joint-type interface where we have this monitored  
18 manhole rounded.

19 At this point, we call this our dilution  
20 point. This is where we have sufficient dilution,  
21 primarily from circulating water blowdown to ensure we  
22 need our Part 20 release limits for the liquid  
23 radwaste. This does occur within our exclusionary  
24 boundary.

25 And I would like to mention just for a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 point of reference the flow rates we expect going  
2 through this blowdown lines. For typical coolant  
3 tower operations, we expect about 10,000 gallons per  
4 minute for both units.

5 Depending on cycles of concentrations that  
6 can be upwards of 30,000 gallons per minute, the  
7 liquid radwaste releases into the line. We expect  
8 less than 100 gallons per minute per unit for those  
9 releases. And it is important to note that those are  
10 intermittent. It is a batch-type release that we only  
11 expect one to two times a week per unit. And  
12 describing the system a little bit further, the piping  
13 between the dilution point and the diffuser at the  
14 plant outfall is entirely welded HTP. We don't have  
15 any mechanical joints in this installation.

16 Again, there is no other type of  
17 components, mechanical joints that could leak.

18 MEMBER ARMIJO: Is that a straight run  
19 pipe or are you using any mitered curves or anything  
20 like that or is it just straight pipe?

21 MR. SCHMIDT: Right now the plan for the  
22 blowdown line is that it follows the railroad spur  
23 down to the river. Any fittings that would be used  
24 for any of those turns would be HTP welded fittings.  
25 There would not be any mechanical joints on them.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1                   MEMBER RYAN: And what is the fall? It is  
2 elevation 380 to 235. What is the typical grade? Is  
3 it always continuous down or how does it work?

4                   MR. SCHMIDT: With respect to the slope, I  
5 can't give you exact percentages there but I know that  
6 it follows the railroad spur down. It is such that we  
7 don't have any situations where we need vacuum  
8 breakers or anything like that. We expect to open  
9 channel flow conditions.

10                  MEMBER ARMIJO: How long is that pipe from  
11 start to finish?

12                  MR. SCHMIDT: A rough estimate that we  
13 talked about is about 5,000 linear feet of pipe. It  
14 is a good bit.

15                  MR. WHORTON: Excuse me. This is Bob  
16 Whorton again. The blowdown line basically follows  
17 the railroad spur line from the table top grade down  
18 to the river. And the grade on the railroad is  
19 approximately two percent.

20                  MEMBER RYAN: Two percent. Thanks.

21                  MR. SCHMIDT: Thanks, Bob.

22                  Okay, this next slide and I hope the  
23 samples made it around to most of the committee  
24 members, for information the sample that you see going  
25 around the table is from a 12-inch diameter HDPE pipe

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 with a little under an inch and a half wall thickness  
2 to it. Our pipe again is 36-inch diameters and has  
3 approximately and inch and three-eighths inch wall  
4 thickness.

5 What you see here is a typical  
6 installation example for HDPE. Here you see 16-inch  
7 HDP pipe being installed in the field and actually two  
8 pipe segments being welded together. During this  
9 operation, a machine operated by a crew of persons  
10 lines both pipe ends, preps both ends for welding.  
11 There is a step where a heater element is applied to  
12 both ends to create melt for the fusion, which is  
13 achieved through pressures applied to both ends of the  
14 pipe to create a fused weld.

15 The sample you see going around the table  
16 is a good cross-sectional cut of the fused weld.

17 MEMBER ARMIJO: Could you explain how that  
18 thing works just briefly?

19 MR. SCHMIDT: Yes.

20 MEMBER ARMIJO: That big guillotine thing,  
21 is that the heater plate or what?

22 MR. SCHMIDT: This thing right here --

23 MEMBER ARMIJO: Yes.

24 MR. SCHMIDT: -- that looks like a big saw  
25 going down there, it has blades on it. And what that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 does is where you have the two sections, it goes in  
2 there and it cuts both sections, cuts them, cleans off  
3 any type of contamination that could be on there.

4 A separate heating element which isn't  
5 shown in the figure, essentially a big, I call it the  
6 big paddle-looking device, is then inserted in there  
7 for a period of time to melt both ends. And they  
8 measure the bead that comes out to make sure that they  
9 have sufficient melt. And then the clamps here, and I  
10 don't know if you can see there is actually that  
11 presses both ends of the pipe together.

12 MEMBER ARMIJO: Thank you.

13 MEMBER SHACK: And what kind of inspection  
14 do you do after that fusion?

15 MR. SCHMIDT: Yes, in the next slide, if I  
16 could, it points out some of the quality assurance  
17 that goes into these installations. For information,  
18 our installation will be per ASME B31.1 Appendix 3,  
19 which addresses plastic pipe installations.

20 Our operating crews are all qualified and  
21 trained, as well as their fusion equipment. There is  
22 a monthly test that these folks go under after  
23 initially being qualified for those mechanical  
24 destructive tests taken or performed on samples taken  
25 from installations they have done to verify joint

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 integrities. They will take a sample, probably a  
2 little bit longer than that in which they bent it into  
3 almost a horseshoe shape looking for any cracks,  
4 material defects, and especially the weld quality.

5 The installations themselves have  
6 incorporated a lot of operating experience over the  
7 years with HDPE. In particular things that could lead  
8 to bad quality welds, such as insufficient pressure,  
9 insufficient temperatures, contaminants, where their  
10 prep is are all things controlled and documented.  
11 Each weld has a datasheet to it.

12 Also documented is a weld inspection. And  
13 that is a visual type inspection. What they look at  
14 is what you see on the sample going around. People  
15 call it weld beads or even a rollback, that material  
16 that oozes out during the melting fusion gives you a  
17 good indication that you have adequate melt time, was  
18 there sufficient pressure when those ends came  
19 together for you know, experience is shown with that  
20 is a good method for inspections.

21 MEMBER BROWN: Are you just looking -- You  
22 are just looking at the external bead, though. Isn't  
23 that correct?

24 MR. SCHMIDT: That's correct.

25 MEMBER BROWN: Okay. So effectively, I am

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 trying to recall what you said in the subcommittee  
2 meeting and that this is effectively a process that  
3 has been qualified and you are depending on the  
4 process, not an inspection, other than the external  
5 inspection of that bead. You can't do the inside. So  
6 you are dependent upon the qualification and the  
7 procedure and the process to be performed and melt the  
8 crunch or whatever it is to come out right.

9 MR. SCHMIDT: The process, the quality  
10 assurance that goes into making these things, is where  
11 I believe the control --

12 MEMBER BROWN: Yes, I just wanted to  
13 confirm that.

14 MR. SCHMIDT: -- and the contractor --

15 MEMBER BROWN: I saw the word inspections  
16 here and I just wanted to clarify and make sure I  
17 understood it was not an internal. So you don't see  
18 the same bead on the inside just the external bead.

19 MR. SCHMIDT: That is correct. It is  
20 external. That is a true statement.

21 MEMBER SHACK: And the wall thickness is  
22 what?

23 MR. SCHMIDT: Approximately an inch and  
24 three-eighths. An inch thick. A little thinner than  
25 what you see going around. That is 1.47 inches thick.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 It is a DR26 HDP material.

2 In addition to the inspections on the  
3 exterior of the pipe, hydros are done on pipe segments  
4 or the whole system, depending on the installation.  
5 These are performed at one and a half times the  
6 pressure rating of the pipe. The DR26 material that  
7 we have is rated for 80 pounds. So hydro that would  
8 be done on this line would be at 120 pounds.

9 MEMBER ARMIJO: Will that be sort of an  
10 end-to-end hydro of the whole line or is it done as  
11 you go along?

12 MR. SCHMIDT: It is permissible for long  
13 runs to do them in segments. However, at some point  
14 in time, as you keep building the segments, it is  
15 required that every weld experience that hydro. And  
16 during the hydros that extend for several hours, the  
17 line is walked down looking for any through wall  
18 material defects that could be in the pipe, as well as  
19 in the welds.

20 In addition, pressure is monitored during  
21 the hydro to look for any fluctuations that indicate  
22 something is wrong.

23 MEMBER BROWN: Since this depends on the  
24 qualifications of the welders and the hardware that  
25 you use to crunch it together, is there a periodic

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701



1 requalification of the welders --

2 MR. SCHMIDT: Yes, --

3 MEMBER BROWN: -- and the hardware to see  
4 and then a destructive test that you generate  
5 something like that to see if you get the same thing?

6 Is it every five years, every six months, or --

7 MR. SCHMIDT: Well in addition to the  
8 initial classroom and practical, they do any type or  
9 anytime that operating crew or machine goes to a  
10 different size pipe, they go through, I think it is  
11 three days where destructive tests are done every day  
12 --

13 MEMBER BROWN: Okay.

14 MR. SCHMIDT: -- from the sample. Then in  
15 addition to that, there is a monthly destructive test,  
16 the samples they are doing.

17 MEMBER BROWN: Okay. You answered my  
18 question. Just something to make sure everything is  
19 still calibrated.

20 MR. SCHMIDT: And it is a continual type  
21 process. If there is a -- If the contractor's  
22 procedures require it, or if there is a change in  
23 machines or person on that crew, they start that  
24 protocol again.

25 MEMBER BROWN: Okay, thank you.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. SCHMIDT: High-density polyethylene  
2 material has been evolving in the industry. From what  
3 I understand, it first commercially started being  
4 available in the late '60s early 1970s. Nuclear power  
5 plants have started using it in applications a little  
6 over ten years ago.

7 Based on experience with the HDPE, we  
8 expect long life with this material.

9 MEMBER RYAN: Have you examined any in-  
10 service failures in the nuclear industry with this  
11 pipe that are on record?

12 MR. SCHMIDT: I know from the fossil  
13 industry that there has been weld failures. It is  
14 believed that the quality assurance into the  
15 fabrication may have been attributed to that. A  
16 sister utility also informed us with their  
17 installation of service pipe at one of their stations  
18 during the hydros, they had weld failures and that was  
19 attributed in adequate heater element temperatures not  
20 being controlled.

21 MEMBER RYAN: So you really, I mean, at  
22 the end of the day, you really rely on the  
23 hydrotesting to confirm that whatever run of pipe you  
24 are evaluating is intact.

25 MR. SCHMIDT: Yes. I mean, that is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 correct. That is kind of the last step in it. I  
2 mean, I think the quality assurance --

3 MEMBER RYAN: That is the only proof of  
4 the system behavior that you have.

5 MR. SCHMIDT: Right.

6 MEMBER RYAN: Everything else is based on  
7 QA and qualification.

8 MR. SCHMIDT: Keep in mind here again,  
9 this line, even though it is being hydrated, it  
10 shouldn't see any real significant pressures. It is  
11 open channel flow the whole way.

12 MEMBER RYAN: Well I mean, that is a  
13 different question.

14 MR. SCHMIDT: Right.

15 MEMBER RYAN: I mean, to see if the weld  
16 is working and it is not going to leak anywhere along  
17 its run, you normally test your pipe.

18 And you say it is 100 and --

19 MR. SCHMIDT: It would be performed at 120  
20 psi --

21 MEMBER RYAN: At 120 pounds and held for  
22 how long?

23 MR. SCHMIDT: There is an initial, they  
24 call it soak time where they pump up the system while  
25 the pipe does expand to a certain degree.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER RYAN: Right. Right.

2 MR. SCHMIDT: That is done for four hours.  
3 And then there is a narrow hold time.

4 MEMBER RYAN: One hour is all it is held  
5 for?

6 MR. SCHMIDT: That is what is required.  
7 And that is where inspection of the line and the welds  
8 is performed.

9 MEMBER RYAN: And is pressure continually  
10 added or do you look to see if it leaks over time?

11 MR. SCHMIDT: During that soak time, you  
12 build the system up to the pressure to allow for an  
13 expansion.

14 MEMBER RYAN: Yes, that is with still that  
15 pressure on it.

16 MR. SCHMIDT: But during that one hour  
17 hold time, no pressure is to be added.

18 MEMBER RYAN: Okay.

19 MR. SCHMIDT: You are monitoring for any  
20 fluctuation at that time.

21 MEMBER RYAN: Okay, great. Thanks.

22 MEMBER ARMIJO: Now the staff has required  
23 non-UT exam of the welds for I think Catawba and  
24 Callaway. Maybe it is -- I think those were service  
25 water lines, essential service water.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MR. SCHMIDT: Right, safety-related.

2 MEMBER ARMIJO: Now is that not required  
3 or you do not believe that would be required to make  
4 sure that these welds wouldn't have the same kind of  
5 flaws that had failed in other cases?

6 MR. SCHMIDT: For this application is it  
7 not required for B31.1.

8 MEMBER ARMIJO: I'll ask the staff the  
9 same question.

10 MR. SCHMIDT: Okay, in summary we talked a  
11 lot about the design and construction of our  
12 wastewater system blowdown line. It is interfaced  
13 with the liquid rad waste system.

14 We believe the design features that we  
15 have mentioned, the gravity drainage open channel  
16 flow, lack of mechanical joints in its installation,  
17 lack of components with mechanical joints that could  
18 leak, that gives us confidence in long-term operations  
19 for this pipe, further assured through our  
20 construction and installation. Quality assurance that  
21 I spoke to earlier, we believe that this line that  
22 will have long-term leak-free operations with this  
23 installation.

24 MEMBER RYAN: Do you see any issues for a  
25 20-year plant life with maybe a 20-year extension?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 These materials really aren't all that experienced  
2 over many decades of in-service use.

3 MR. SCHMIDT: I know for the code case, I  
4 think the N755 code case for some of the safety  
5 related applications, there is testing that has been  
6 done behind that to come up with the 50-year design  
7 life.

8 MEMBER RYAN: Well it is not 50 years of  
9 actual in-service. It is some accelerated test  
10 protocol. Right?

11 MR. SCHMIDT: Yes. I can't speak to the -  
12 -

13 MEMBER RYAN: Okay.

14 MR. SCHMIDT: -- testing itself but I know  
15 that a 50-year design life is what was called out  
16 there. There is other -- The Plastics Pipe Institute  
17 speaks to 50 to 100-year design life. There is a  
18 culvert design guide that has a two-year design life.  
19 You know, we are looking at 60 years with this  
20 application with the development of the material that  
21 we are using, the DE-4710 material, which is the same  
22 material that is being used or is being requested in  
23 the relief request with the service water  
24 applications.

25 MEMBER RYAN: I think I read somewhere

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that the NRC has not endorsed the code case at this  
2 point.

3 MR. SCHMIDT: No, that is correct. It is  
4 currently at Rev 0 Blue Book. Rev 1 is being pursued  
5 as well as a second edition. However, I just want to  
6 note that the material that we are using is the same  
7 material that is being discussed in that code case.

8 MEMBER RYAN: So it is a little bit up in  
9 the air that the code case isn't done and the NRC  
10 hasn't endorsed it at this point. But you are  
11 confident that you have got 60 years of --

12 MR. SCHMIDT: I mean, it doesn't apply to  
13 our case but for information I think the test that  
14 went into generating that code case is part of the  
15 material properties in endurance.

16 MEMBER RYAN: Yes, can endure in your  
17 application.

18 MR. SCHMIDT: Right. Okay, that's all I  
19 have.

20 MR. SEBROSKY: Mr. Ray, the staff doesn't  
21 have a prepared presentation but we do have the  
22 subject matter experts in the room. Larry Wheeler  
23 reviewed the welding aspects of the pipe and Steve did  
24 the review of the health physics aspects of the liquid  
25 radwaste. So if there are any questions from the full

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 committee, we can address those.

2 MEMBER RAY: Sam?

3 MEMBER ARMIJO: Yes, just what are the  
4 consequences if you do have failures or leakage from  
5 these welds after they have been in service? There is  
6 some slow crack growth that can occur, maybe not at  
7 these temperatures but if there is a weld defect. You  
8 know, the consequences, other than being a nuisance,  
9 is there any other? There is certainly no safety  
10 problem or is there?

11 MR. SCHAFFER: I guess I can address that.  
12 You know, we are talking at the lowest level of  
13 safety significance.

14 MEMBER ARMIJO: Contamination maybe it.

15 MR. SCHAFFER: Right. If you remember the  
16 DCD in Chapter 11, they have the ratio of the  
17 discharge once it is diluted by the blowdown, compared  
18 to what is in 10 C.F.R. 20 Appendix B. And that level  
19 is about ten percent of the Appendix B limits. If you  
20 drank the water in that pipe as your water supply, you  
21 would get five millirems per year. You know, it is  
22 very low.

23 MEMBER ARMIJO: I am convinced of that but  
24 that is not what would happen in the press if you had  
25 a local tritium get into your ground water somewhere.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 That is a --

2 MR. SCHMIDT: I could speak to the slow --

3 MEMBER ARMIJO: -- public relations not  
4 safety. Go ahead.

5 MR. SCHMIDT: Yes, I was going to say I  
6 can speak to the slow crack growth concerns. That is  
7 one of the safety-related applications driving the  
8 request for UT-type inspections. That is driven by  
9 our higher temperatures than what we would expect as  
10 well as pressurized service.

11 I wouldn't expect that failure mechanism  
12 with our application.

13 MEMBER ARMIJO: No, I wouldn't either.

14 MEMBER RYAN: You talked a little bit in  
15 the subcommittee about the fact that you were going to  
16 have some kind of a secondary monitoring effort with  
17 localized groundwater wells or some other kind of  
18 measurement near the pipe or at certain locations  
19 along the pipe. Could you review that for us?

20 MR. SCHMIDT: Yes, in our application we  
21 commit to a groundwater monitoring program that goes  
22 beyond our radiological effluent monitoring program.  
23 That will be in accordance with NEI 08-08(a). That is  
24 for the site that would evaluate buried piping and  
25 install welds as needed.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER RYAN: I guess you are probably not  
2 at the stage where you have got specific details on  
3 distance from pipe to welds. That is all yet to be  
4 determined.

5 MR. SCHMIDT: That's correct. We haven't  
6 started developing that program yet.

7 MEMBER RYAN: And again, I appreciate,  
8 Steve, your comment that those consequences are  
9 certainly not significant but that is not from a  
10 public standpoint what it is significant. What is  
11 significant is there was a leak that wasn't expected.

12 MR. SCHMIDT: Right.

13 MEMBER RYAN: We have many cases of that.  
14 So, I take comfort as a health physicist doing those  
15 numbers but certainly not an undetected leak.

16 MEMBER RAY: Nothing else on this then?  
17 Emergency plan.

18 MR. SCHMIDT: Thank you.

19 MR. HINSON: Now have -- This is Charles  
20 Hinson, NRC. What is the approximate length of the  
21 piping segments that will be welded together?

22 MR. SCHMIDT: I think we mentioned before  
23 we are looking at about 5,000 linear feet.

24 MR. HINSON: No, I mean the individual  
25 segments. What is the distance between welds?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MR. SCHMIDT: That I can't speak to  
2 directly. I know they come in sticks of a certain  
3 prefabricated length to haul on a truck, that kind of  
4 thing. But I can't speak to a specific length.

5 MEMBER ARMIJO: They could make them as  
6 long as they want. They extrude these things.

7 MR. SCHMIDT: But you have got to build a  
8 transport to ship them on.

9 MEMBER ARMIJO: You have got to get them  
10 there.

11 MR. SCHMIDT: You have got to be able to  
12 transport it.

13 MEMBER SIEBER: For a long truck.

14 MR. SCHMIDT: We haven't procured this  
15 pipe.

16 MEMBER RAY: Okay, we are one minute from  
17 the announced time when we adjourn this session. Can  
18 we move on then, please?

19 MS. MONROE: The remainder of the  
20 presentations will take approximately just several  
21 more minutes from the applicant's standpoint.

22 Next we are going to go into emergency  
23 planning. Mr. Tim Bonnette will address that.

24 MR. BONNETTE: Thank you. As Amy said, I  
25 am Tim Bonnette, SCE&G Emergency Preparedness. Our

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 presentation is going to cover, discuss our emergency  
2 plan design, the DCD departure, our emergency  
3 facilities, emergency response, our emergency panning  
4 zone, and public awareness.

5 Our emergency plan design is a single  
6 emergency plan for all three units. It is developed  
7 in accordance with NUREG-0654/FEMA-REP-1 Rev 1, 10  
8 C.F.R. 5.47 and 10 C.F.R. 50, Appendix E.

9 Our emergency action levels are developed  
10 in accordance with NEI 07-01 Rev. 0 for Units 2 and 3  
11 and have been developed in accordance with NEI 9901  
12 Rev. 5 for Unit 1. And I would like to note that we  
13 have a proposed licensed condition to develop the  
14 Units 2 and 3 EALs in accordance with this NEI  
15 document.

16 Our DCD departure, as Amy mentioned  
17 briefly a little earlier in presentation is a  
18 departure of the locations of our Technical Support  
19 Center and our operational support center. Our  
20 Technical Support Center is being relocated to the  
21 Nuclear Operations Building which is being constructed  
22 by Unit 1 for Unit 1 site upgrades. The building will  
23 house the Unit 1 staff, support staffing, and also  
24 Unit 1 TSC until Units 2 and 3 move forward towards  
25 operation.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1           The TSC is designed to support staffing  
2 for Unit 1 and Units 2 and 3 in the event of an  
3 emergency. The building that Unit 1 is constructing  
4 will begin construction early this year and we are  
5 expecting construction to be done in mid to late-2012.

6           The second part of our departure is the  
7 departure of the Operational Support Center. The  
8 Operational Support Centers will be relocated to each  
9 of the respective units annex buildings in the area  
10 designated within DCD as the Technical Support Center  
11 or TSC. And that is on the DCD elevation 117.6.

12           MEMBER SIEBER: How far away is your EOF?

13           MR. BONNETTE: Our EOF we will discuss in a  
14 little bit but it is actually outside of our ten mile  
15 EPZ.

16           MEMBER SIEBER: How far outside? Less  
17 than 25 miles?

18           MR. BONNETTE: It is a little over ten  
19 miles. It is not 15 miles out.

20           MEMBER SIEBER: Oh, okay. Thanks.

21           MR. BONNETTE: The Technical Support  
22 Center will be a common Technical Support Center for  
23 all three units to allow us a single point for  
24 technical support of on-site evaluations, on-site  
25 development of mitigation strategies and on-site

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 emergency response.

2           Again, it is located outside of both fire  
3 protected areas, which I will discuss in just a  
4 moment. In the basement, in a harden facility of the  
5 nuclear operations, I mean the new Nuclear Operations  
6 Building. Thank you.

7           Access is controlled by security card  
8 readers and limited ingress and egress points into  
9 that facility. The facility itself has a backup power  
10 supply, which is diesel backed and an independent  
11 ventilation system with high efficiency particulate  
12 air filters, as well as charcoal air filters.

13           MEMBER SIEBER: How about shielding?

14           MR. BONNETTE: The building design is  
15 designed just as if it would have been in adjacent to  
16 the control room. So it matches 0696.

17           MEMBER SIEBER: Okay, thanks.

18           MR. BONNETTE: Real quick, it also has the  
19 human factors engineering that will support either  
20 one-unit emergency, a two-unit emergency, or a three-  
21 unit emergency.

22           This is the picture I was talking about  
23 that shows the location of the Nuclear Operations  
24 Building with the Technical Support Center in the  
25 basement. It is located between Unit 1's protected

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 area and the Unit 2 and 3 protected area of the site.

2 And this is just an overall picture of our  
3 site with the nuclear exclusion area boundary, which  
4 is the security patrolled area and controlled area for  
5 the site itself.

6 The emergency facilities for all three of  
7 our units include the three units' control rooms, the  
8 three units' Operational Support Centers, single  
9 Technical Support Center, the single Emergency  
10 Operations Facility, and a single Joint Information  
11 Center. Again, the OSC for Units 2 and 3 and the  
12 Technical Support Center were discussed earlier in the  
13 departure section.

14 The Emergency Operations Facility and the  
15 Joint Information Center are in a co-located facility  
16 again outside of our Emergency Planning Zone, which is  
17 outside of the ten mile radius.

18 MEMBER STETKAR: Tim?

19 MR. BONNETTE: Yes, sir.

20 MEMBER STETKAR: The TSC mentioned -- I'll  
21 try to make this quick. The security entrance, card  
22 readers, etcetera, etcetera, does that come from Unit  
23 1, Unit 2, Unit 3, its own power supply?

24 MR. BONNETTE: That part of the design  
25 detail I don't know has been finalized yet. So, I

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 cannot speak to that.

2 MEMBER STETKAR: Okay, thanks.

3 MR. BONNETTE: Our emergency response, if  
4 you look at our emergency plan, it discusses basically  
5 three levels of hierarchy of response. Site level,  
6 individual protected area level, and then a single  
7 unit emergency response.

8 In these hierarchies, if there is a site  
9 level emergency response, the unit 1 control room is  
10 the lead control room for the initial notifications  
11 and the initial declarations. If we reach an alert or  
12 higher classification, then we will be activating our  
13 entire emergency response organization and all  
14 emergency response facilities.

15 If we have an event that affects only a  
16 single protected area, either the Unit 2/3 protected  
17 area or the Unit 1 protected area, the Unit 1 has the  
18 lead for its protected area and Unit 2 will be the  
19 lead control room for the initial notifications and  
20 declarations of the emergency.

21 And then for the individual units, if they  
22 have an emergency, their respective control rooms will  
23 be the lead control room for the emergency response.

24 Our Emergency Planning Zone, and just to  
25 note I do have a slide picture of it following this

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 one, will remain -- the boundaries of the Emergency  
2 Planning Zone will remain the same as the existing  
3 Unit 1 Emergency Planning Zone. And this has been  
4 reviewed and agreed upon by the State of South  
5 Carolina in a letter and by resolution by the full  
6 risk counties. These boundaries have also been  
7 reviewed and accepted for Units 2 and 3 and Unit 1 by  
8 FEMA.

9 This is the boundary map of our Emergency  
10 Planning Zone. You can see the sectors are outlined  
11 in color. The radiuses from Units 1 are two miles,  
12 five miles, and ten miles. And what we would like to  
13 note is boundaries were based on population  
14 demographics, the topography, and then local  
15 jurisdictional lines.

16 When we did these boundaries, we went  
17 ahead and took into account and the populations within  
18 these boundaries include the daycares, medical  
19 facilities, assisted living facilities that may be  
20 close to the ten mile radius but are outside of it.  
21 So those are already included.

22 And our public awareness annually we  
23 distribute to all residences businesses within our  
24 Emergency Planning Zone a calendar which includes a  
25 map of our Emergency Planning Zone, evacuation sector

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 boundaries, both in description and in maps. It  
2 includes the evacuation routes and descriptions and in  
3 maps, as well as public action guidance for an  
4 emergency, the shelter welcome center locations, and  
5 also the local radio and television stations, to which  
6 the public can tune into to get emergency information.

7 The calendar also includes a special needs  
8 assistance card, which any resident with special needs  
9 can fill out and it can be returned to VC Summer  
10 through a postage-paid pre-addressed card. And once  
11 VC Summer collects those cards, they distribute them  
12 to the applicable counties so the county can also plan  
13 for the emergency and the public assistance.

14 We also make sure that we try to keep our  
15 public informed if we are doing any scheduled testing  
16 to not cause undue alert. We do press releases. We  
17 also support a community coalition meeting, currently  
18 supporting it with our chief nuclear officer. So we  
19 are trying to make sure we are staying in contact with  
20 the public as we move forward and with what is going  
21 on at the site.

22 In addition, we make sure that the  
23 emergency responders for fire, EMS, and local law  
24 enforcement for our risk counties are all trained in  
25 basic radiological monitoring and handling. And we

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 also train select populations of the state emergency  
2 management divisions, state law enforcement, state  
3 highway patrol, and state department of natural  
4 resources.

5 That's all I have.

6 MR. SEBROSKY: Mr. Ray, it is the same  
7 thing. Ned Wright is our lead reviewer. The staff  
8 doesn't have a separate presentation for this.

9 MEMBER RAY: Any comments for either the  
10 applicant or for the staff?

11 All right. The last item prior to our  
12 committee discussion, Amy do you have something to  
13 present?

14 MS. MONROE: Yes, there was one more.

15 MEMBER RAY: Okay.

16 MS. MONROE: Actually what we are going to  
17 show you today is one of the benefits of being an  
18 RCOLA and utilizing the design-centered approach. The  
19 vast majority of our application is either the DCD,  
20 which we incorporate, or the standard RCOLA material,  
21 which we replicate exactly within our application.

22 We found the process to be very effective,  
23 efficient, and actually beneficial for everyone. One  
24 of the greatest benefits has been the ability to pool  
25 our resources throughout the industry. Technical

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 expertise, we are taking advantage of everybody's  
2 technical expertise within their own company and we  
3 are able to significantly increase reviews that are  
4 performed on the material.

5 What we think that has done is improve the  
6 depth of the review than would be expected in a single  
7 applicant coming forward. Basically what that means  
8 is we have covered essentially everything from a true  
9 safety concern has been incorporated in our  
10 application. However, we did feel like it was  
11 worthwhile the committee's time for about three  
12 minutes to have Mr. LaBorde here discuss some of our  
13 offsite electrical power.

14 So, Jamie?

15 MR. LaBORDE: Hello, my name is Jamie  
16 LaBorde. We are a standard AP1000 plant, as Amy said.

17 Our grid connections are site-specific as well as our  
18 interface agreements and procedures for transmission.

19 Each one of the overhead transmission  
20 lines can carry the maximum power required for both  
21 units simultaneously for normal, abnormal, or accident  
22 conditions. ITAAC in Table 2612-1 confirms the as-  
23 built condition meets this requirement.

24 A new switchyard is being built for Units  
25 2 and 3. A breaker and a half configuration is used

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 for the 12 line connections and the two reserve aux  
2 transformer connections. The two generator step-up  
3 transformers are connected using a double bus, double  
4 breaker configuration.

5 Failure analysis for the transmission  
6 system was performed with acceptable results. We have  
7 done our stability studies and we have no issues  
8 meeting the requirements from the North American  
9 Reliability Corporation, commonly known as NARC. The  
10 AP1000 interface requirement which includes the  
11 requirement to maintain voltage to the reactor coolant  
12 pumps for three seconds after a turbine trip in Reg  
13 Guide 1.206. An as-built grid stability study is also  
14 required by ITAAC contained in 2612-1.

15 Information on this figure can be found on  
16 COLA figure 82201. The Unit 2/3 switchyard is to the  
17 left. The Unit 1 switchyard is to the top right.  
18 Lines exit the Unit 2/3 switchyard to the west and  
19 south and one line to the north. Lines exit the Unit  
20 1 switchyard to the east, south, and one line to the  
21 north. And there are three connections between the  
22 two switchyards. We presently have just south of the  
23 plant a par 230 kV switchyard. It is going to be  
24 retired as part of the effort for the plant.

25 Over 95 percent of the lines that we are

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 adding or in existing right-of-ways, we have  
2 identified the routes and we are working toward  
3 getting the required easements for the remainder of  
4 our lines, which is about six miles.

5 This is a single line diagram of the Unit  
6 2/3 switchyard. The generator connections are made to  
7 each bus by dedicated breakers, which is a double bus,  
8 double breaker configuration. Both breakers open to  
9 isolate the generator. Breaker and a half connections  
10 are used for the lines and the reserve aux  
11 transformers.

12 And if there are no questions, this  
13 concludes my presentation.

14 MEMBER SIEBER: How are you going to get  
15 to three seconds under all conditions?

16 MR. LaBORDE: Well it is on the turbine  
17 trip that the requirement exists there because that is  
18 the condition two event. And it is that condition.

19 MEMBER SIEBER: Okay. You can get it that  
20 way.

21 MR. LaBORDE: But actually for offsite  
22 power, the grid stability event some of the follow-  
23 ups, we don't have problems with that.

24 MEMBER SIEBER: How long does it take if  
25 you lose all offsite power, do you automatically get a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 thing in your generator trip immediately or does it  
2 run back?

3 MR. LaBORDE: If we disconnect the unit  
4 from the grid?

5 MEMBER SIEBER: If the grid is dead.

6 MR. LaBORDE: It can run back.

7 MEMBER SIEBER: It can run.

8 MR. LaBORDE: The unit is designed to run  
9 back.

10 MEMBER SIEBER: So you get to three  
11 seconds that way.

12 MR. LaBORDE: Well actually the  
13 requirement is on the turbine trip condition where the  
14 turbine trips.

15 MEMBER SIEBER: Okay. That one is easy.

16 MR. LaBORDE: It is a coast down issue for  
17 a condition two event.

18 MEMBER SIEBER: Okay, thanks.

19 MEMBER RAY: Yes, Joe?

20 MR. SEBROSKY: It is the same thing. On  
21 Chopra is our Chapter 8 subject matter expert and  
22 reviewer, if there are any questions for him.

23 MEMBER RAY: Thank you for coming. Sorry  
24 you missed your lunch.

25 Is there any questions for either

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 applicant or staff on Chapter 8?

2 MR. SEBROSKY: And then this is the last  
3 slide.

4 MEMBER RAY: Okay. And you are going to  
5 speak to that?

6 MR. SEBROSKY: Yes. So this last slide  
7 presentation, what we are attempting to do here is  
8 just give an overview of the site-specific information  
9 in the Summer COL application.

10 The first bullet just goes to what I had  
11 said earlier, when we briefed the subcommittee, we  
12 spent a lot of time on Chapter 2 and 13.3. We tried  
13 to give the full committee a sense of everything that  
14 was high level discussions in Chapter and in the  
15 emergency plan.

16 The second bullet talks to what we did not  
17 brief the subcommittee on. There was nothing in 4, 7,  
18 or 14 that we briefed the subcommittee on because it  
19 is all standard material.

20 Slides 3 through 22 is for your later  
21 review. It just shows every plant-specific item that  
22 is in every one of those other chapters. And in a  
23 yellow highlight, it shows the areas that we briefed  
24 the subcommittee on. If you go through that list, you  
25 are going to see that we briefed the full committee on

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 the majority of those issues, with the exception of  
2 there is some material in 15, 17, and 19 that we  
3 provided to the subcommittee that we did not think  
4 rose to the level that the full committee needed to be  
5 briefed on.

6 So if you go back to the earlier  
7 presentation and you take the standard material out of  
8 what we briefed the subcommittee and full committee  
9 on, this is what you are left with. And it just  
10 attempts to give you a sense of what we briefed the  
11 subcommittee on and how we tried to touch on that with  
12 the full committee.

13 The last bullet is just a note that we did  
14 have a closed session with the subcommittee where we  
15 talked about some site-specific differences associated  
16 with the LOLA review. The subcommittee is aware of  
17 that. We have not, obviously, briefed the full  
18 committee on that.

19 And that is all I have.

20 MEMBER RAY: All right. Thank you, Joe.

21 Said, we should ask if there is any public  
22 comments. And so I believe the line is open now and I  
23 will make that request. If there is anyone on the  
24 line who wishes to make comments to the full  
25 committee, please first identify yourself.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           Hearing none, is there anyone in the  
2 audience who wishes to make comments or statements?

3           Okay and if there is none, we should go  
4 around the table, I think. Jack?

5           MEMBER SIEBER: I'm satisfied with the  
6 presentations that all the issues are correctly  
7 analyzed and documented.

8           MEMBER RAY: Okay, Sanjoy?

9           MEMBER BANERJEE: I think I am fine. I  
10 have given you some information on the off-site  
11 hazards which you have.

12           MEMBER RAY: Yes, and basically that is in  
13 the nature of the concern that was discussed and  
14 responded to here and we simply want to track that.

15           Dennis?

16           MEMBER BLEY: Nothing.

17           MEMBER RAY: Sam?

18           MEMBER ARMIJO: Nothing.

19           MEMBER RAY: Said?

20           CHAIRMAN ABDEL-KHALIK: No additional  
21 comments.

22           MEMBER RAY: John, what are we going to do  
23 with your item?

24           MEMBER STETKAR: I have no idea. We will  
25 discuss that later, I guess.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER RAY: Are you going to write it  
2 down?

3 MEMBER STETKAR: We will discuss that  
4 later.

5 MEMBER RAY: Okay.

6 MEMBER SIEBER: We will work on that  
7 during lunch.

8 MEMBER RYAN: All right, thanks. After  
9 the subcommittee meeting, we did get some additional  
10 information independently on the HDPE pipe and related  
11 performance questions. And I appreciate the  
12 additional information today. That was very helpful.

13 So I will write something up and offer it to you for  
14 putting in the letter.

15 MEMBER RAY: Okay. Well, be sure and have  
16 it by 6:00 today.

17 MEMBER RYAN: No problem. I've got all  
18 that time?

19 MEMBER RAY: That's when we are going to  
20 need it. Bill?

21 MEMBER SHACK: No comment.

22 MEMBER RAY: Joy?

23 MEMBER REMPE: No comments.

24 MEMBER RAY: Mike?

25 MEMBER CORRADINI: No comment.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER RAY: Back to you.

2 CHAIRMAN ABDEL-KHALIK: Thank you. At  
3 this time, we will break for lunch. We will reconvene  
4 at 1:45.

5 (Whereupon, the foregoing matter went off the record  
6 at 1:05 p.m. and went back on the record  
7 at 1:46 p.m.)

8 CHAIRMAN ABDEL-KHALIK: We're back in  
9 session.

10 At this time, we will move to the next  
11 item on the agenda, Comparison Between ISAs for Fuel  
12 Cycle Facilities and PRAs for Reactors. And Mike Ryan  
13 will lead us through this discussion.

14 MEMBER RYAN: Thank you, Mr. Chairman.

15 On January 11th, the ACR Radiation  
16 Protection Nuclear Materials Subcommittee reviewed the  
17 staff's White Paper entitled A Comparison of  
18 Integrated Safety Analyses and Probabilistic Risk  
19 Assessments. We heard presentations from the NRC  
20 staff and representatives of the Nuclear Energy  
21 Institute then had detailed discussions with them at  
22 that time.

23 Today the full Committee will hear a  
24 presentation from the NRC staff, by Dennis Damon and  
25 Charles Vaughan from NEI will also make an oral

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 statement a little bit later in the briefing.

2 So with that, Dennis, I'll turn it over to  
3 you please.

4 MR. DAMON: Good afternoon. My name is  
5 Dennis Damon. I'm the Senior Level Advisor for Risk  
6 Assessment in the Office of Nuclear Material Safety  
7 and Safeguards although I'm officially assigned to the  
8 Division of Fuel Cycle Safety and Safeguards. I've  
9 been with the NRC for 16 years, ten of which I've been  
10 actually in this division, Fuel Cycle Division.

11 This briefing this morning -- this  
12 afternoon rather -- should be relatively quick because  
13 most of the slides which we presented to the  
14 Subcommittee have been moved to the back of the  
15 presentation as simply background material. There's  
16 only 12 slides with contents in what I'm going to say  
17 here. I'm just going to basically quickly run through  
18 the -- what the paper does.

19 This slide two is the objectives of the  
20 briefing here this afternoon -- is to present this  
21 paper that was -- the Commission directed that the  
22 staff produce this paper comparing integrated safety  
23 analyses and probabilistic risk assessment. And we  
24 would like to obtain a review by the ACRS and a letter  
25 from the ACRS on this subject that, in particular, we

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 hope that it would address what we see as being the  
2 key points that are made in the paper and to address  
3 what the Commission was really asking for.

4 And I'll quote what they said in the  
5 second -- the SRM to the SECY-10-0031, which was --  
6 the subject of which was revised the Fuel Cycle  
7 Oversight Program. And in the SRM to that SECY, the  
8 Commission said, "The Commission looks forward to the  
9 staff's concise comparison to integrated safety  
10 analyses and probabilistic risk assessment along with  
11 the accompanying review and letter report of the ACRS  
12 to better inform proposed enhancements to the  
13 oversight process."

14 So the paper tries to address what we  
15 thing the Commissioners are interested in.

16 MEMBER ARMIJO: Dennis?

17 MR. DAMON: Yes.

18 MEMBER ARMIJO: I just want to make a  
19 clarification because I was confused. I had the  
20 impression that this exercise was based on fuel cycle  
21 facilities licensed under Part 70. And limited to  
22 that.

23 Now we know MOX facility out there. And  
24 it's not a Part 70 license, as far as I know. It's  
25 some other.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MR. DAMON: No, it is?

2 MEMBER ARMIJO: It's Part 70? I thought  
3 it was -- okay, so MOX falls into this category?

4 MR. DAMON: Yes.

5 MEMBER ARMIJO: Okay.

6 MR. DAMON: The difference --

7 MEMBER ARMIJO: Savannah River does?

8 MR. DAMON: Yes. There is in Section  
9 70.22 and 70.23, there are some specific requirements  
10 applicable only to a plutonium -- a facility licensed  
11 to possess a large quantity of plutonium in that  
12 respect. But all the rest of Part 70 also applies to  
13 them.

14 MEMBER ARMIJO: Okay. So that's part of  
15 the family of fuel cycle facilities that you're  
16 addressing?

17 MR. DAMON: Yes.

18 MEMBER ARMIJO: Okay.

19 MR. DAMON: They did an ISA.

20 MEMBER ARMIJO: That clear up my question.

21 MR. DAMON: So here on this slide, and I  
22 will come back -- this is at the end -- is we tried --  
23 the paper ends up making two points. One has to --  
24 the first point has to do with discussion ISA- and  
25 PRA-type analyses in the context of the safety of the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 facility and in compliance with the Part 70. And the  
2 point here is the staff has concluded that ISAs are  
3 acceptable for the functions that they are required to  
4 do within that context of Part 70.

5 And the second point relates back to this  
6 what we think the Commission is interested in in this  
7 paper, in that it came up in the context of revising  
8 the Fuel Cycle Oversight Program, and that is how one  
9 does use either ISA results or PRA in the context of  
10 trying to -- the Fuel Cycle Oversight Program that  
11 presumably has some kind of risk significance  
12 determination. And specifically the paper has an  
13 example in Section 5 of an actual -- of a hypothetical  
14 rather inspection finding and how one would evaluate  
15 that quantity -- the risk significance of such a  
16 finding quantitatively and under two circumstances,  
17 one where an ISA had produced quantitative risk  
18 indices, which is one of the methods used, and the  
19 other way, where the ISA had actually produced  
20 quantitative frequencies of the accident sequences.

21 And so it makes the point that -- the  
22 second point here, which is -- the example is in there  
23 to illustrate this second point. And that is that in  
24 most cases and inspection finding will only effect a  
25 very small part of the plant and just a accident

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 sequences. And in addition, there's another point,  
2 that based on the fact the staff actually looked at  
3 all the inspection deficiencies for the last five  
4 years and the total number of deficiencies that have  
5 some kind of risk significance is only about one or  
6 two per plant per year.

7 So it is a small number. And each one  
8 typically only effects a very small part of the plant.

9 So the conclusion is this second point, namely that  
10 the efficient way to evaluate risk significance is to  
11 do it when you need to evaluate a particular  
12 deficiency. So you do it case by case, when it  
13 happens as opposed to let's do the whole plant up  
14 front, you know, in advance the way it was, in fact,  
15 done for reactors.

16 So this is a new slide that was put in  
17 just to familiarize people with how many and what kind  
18 of facilities we're talking about. The facility that  
19 Sam Armijo mentioned here is under fuel fabrication,  
20 the MOX Fuel Fabrication Facility is one. Then  
21 there's three commercial white water fuel  
22 manufacturing plants and two that are involved with  
23 the production of naval reactors.

24 Then there are four enrichment facilities.

25 And you'll notice under the enrichment, the diffusion

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 plants, the gaseous diffusion plants are not there  
2 because they are not licensed under Part 70. They  
3 have a separate part of the regulation. When we  
4 inherited those plants from the Department of Energy,  
5 they were regulated under a different part of the  
6 rule.

7 MEMBER BLEY: Do they do anything like  
8 ISA?

9 MR. DAMON: No, they have a completely --  
10 they have a DOE-like analysis that they do.

11 MEMBER CORRADINI: You said this is --

12 MR. DAMON: It hasn't -- it does -- it is  
13 actually somewhat analogous to an ISA. But its under  
14 DOE's requirements.

15 MEMBER CORRADINI: This is for enrichment  
16 you said, right?

17 MR. DAMON: Yes. For diffusion enrichment  
18 that -- they're not on this list. They have a  
19 different. They focus only on public risk. And they  
20 do the -- they kind of do it in a reverse order. In  
21 ISA, you identify an accident sequence. And the first  
22 thing you do is to say well what consequence level is  
23 this at? And then you evaluate likelihood.

24 They do it the other way around. They  
25 have very coarse likelihood bins. And they place a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 sequence in a likelihood bin. Then they do a very  
2 elaborate and detailed consequence evaluation to the  
3 offsite public. So they just -- it's a little bit  
4 different than what we do but it has the same --  
5 similar purpose.

6 So -- by the way, many of these facilities  
7 have never been operated yet. And some of them  
8 haven't received their licenses either. And two of  
9 them on here, as is noted, are to license under Part  
10 40, which does not have an ISA requirement. But the  
11 intent of the staff is to have a rulemaking that will  
12 require that Part 40 plants have an ISA.

13 MEMBER SHACK: How many have actually done  
14 their ISAs already?

15 MR. DAMON: I think ten. I think -- let  
16 me think --

17 MEMBER SHACK: So some of the asterisked  
18 ones have actually done it?

19 MR. DAMON: Yes. Mostly -- almost  
20 everything on this list has actually done -- I don't  
21 thing GE, the SILEX one may not be done. I don't -- I  
22 really don't know. Honeywell did something. It's like  
23 an ISA but not exactly. And, of course, International  
24 Isotopes is a new -- is in the process, so --

25 MEMBER STETKAR: Dennis, are you aware of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 any of these facilities that have done any  
2 quantitative PRA work?

3 MR. DAMON: You mean for their own  
4 purposes other than an ISA?

5 MEMBER STETKAR: I just -- are you aware  
6 of any of them that have done any quantitative PRA?

7 MR. DAMON: Well, both GE and Westinghouse  
8 did at least -- well, in the case of GE, their ISA is  
9 quantitative. In other words, they've got a  
10 quantitative frequency for each accident sequence.  
11 And in the case of Westinghouse, most of their  
12 sequences do also have a quantitative frequency. And  
13 their -- in other words, if you look in their ISA  
14 summary that they sent in, they'll have tables of  
15 where they -- the basis on which they assign  
16 frequencies to the various events.

17 MEMBER STETKAR: Okay. Thanks.

18 MR. DAMON: So it's quantitative in that  
19 sense. But that's not like -- they don't add up the  
20 sequences --

21 MEMBER STETKAR: They don't -- okay.

22 MR. DAMON: -- the risks from all  
23 sequences to a --

24 MEMBER STETKAR: That's sort of what I was  
25 talking about.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MR. DAMON: -- a given receptor like a  
2 pickle worker, add up all the sequences that effect  
3 that worker, they don't do that.

4 MEMBER STETKAR: They don't do that?  
5 Okay. Thanks.

6 MS. BAILEY: Dennis, can I just make a  
7 clarification and answer the question about which of  
8 those facilities have done ISAs? If you go back to  
9 the slide, the enrichment and fuel fabrication  
10 facilities are licensed or are being licensed under 10  
11 CFR Part 70. So they're all required to have an  
12 integrated safety analyses. So either they've done it  
13 or in their application they have an ISA.

14 MEMBER STETKAR: I understand that. I was  
15 asking --

16 MS. BAILEY: The conversion and  
17 deconversion facilities, Honeywell has an ISA that is  
18 incorporated as a license condition. International  
19 Isotopes, in anticipation of the Part 40 rulemaking,  
20 does have an ISA in its application.

21 MEMBER ARMIJO: But all the operating  
22 facilities have ISAs.

23 MS. BAILEY: All the operating facilities  
24 that are licensed under 10 CFR Part 70 that are  
25 subject to Subpart H has ISAs.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MEMBER STETKAR: Okay.

2 MR. DAMON: Yes, they were required in the  
3 rule to have them done and submitted by October of  
4 2004. And they all did. And the staff reviewed them  
5 and approved them.

6 MEMBER SHACK: So the GE-Hitachi, where  
7 they had paper about PRA versus ISA, they just used  
8 those thoughts to kind of inform their ISA to a  
9 certain extent? Or that was just a paper that  
10 somebody there wrote?

11 MR. DAMON: Right. They did that because  
12 they -- they had initially done an ISA in which they  
13 used a risk index method.

14 MEMBER SHACK: Oh.

15 MR. DAMON: Then they changed and they did  
16 it in this quantitative way with event trees and with  
17 different people doing -- participating that were PRA  
18 people. As you may know, at a certain point in the  
19 middle of this process, GE moved their staff, which  
20 probably included some PRA people, from San Jose to  
21 Wilmington where the fuel fab is. So at that point in  
22 time, they had their PRA people right there at the  
23 facility. And so they -- that's where the paper came  
24 from.

25 MEMBER CORRADINI: So just one quick

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 question. So this is the fuel cycle. If there are  
2 isotopes, did they also -- if you're making isotopes,  
3 does that fit into this as a Part 70?

4 MR. DAMON: Well, it depends on how you  
5 make the isotopes. If you make it in a reactor, then  
6 they have to have a Part 50 license.

7 MEMBER CORRADINI: I see. Okay. But if  
8 not, I guess I was looking under International  
9 Isotopes. I assumed that was the manufacture of  
10 isotopes outside of a reactor.

11 MR. DAMON: No, what they're doing is  
12 deconversion. They are going to recover the fluorine  
13 from depleted uranium in order to sell it.

14 MEMBER CORRADINI: I see.

15 MR. DAMON: To sell the fluorine.

16 MEMBER CORRADINI: Okay.

17 MR. DAMON: In fact, yes, the flow --  
18 there is a flow of material through these plants. And  
19 over the years, the licensees eventually figured out  
20 who -- somebody they could sell the material to.

21 (Laughter.)

22 MEMBER ARMIJO: You can either have it in  
23 saleable fluorine or calcium fluoride piled up in  
24 mountains.

25 MR. DAMON: Yes. And so actually there's

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 no like waste. As far as I'm aware, there's no like  
2 waste stream anymore really. It all goes and it gets  
3 sold somewhere.

4 MEMBER CORRADINI: There's always a waste  
5 stream. The second lost also.

6 (Laughter.)

7 MR. DAMON: There isn't like oh, yes, this  
8 big -- there used to be a gigantic pile of calcium  
9 fluoride out behind GE.

10 MEMBER ARMIJO: I got rid of that. We  
11 changed our whole conversion system to a process where  
12 we could sell fluorine instead of piling up calcium  
13 fluoride.

14 MR. DAMON: And so --

15 MEMBER POWERS: So you're the responsible  
16 for fluoridating water?

17 MEMBER ARMIJO: But your teeth are better.  
18 And it's a communist plot, I understand.

19 MR. DAMON: On this slide, the first part  
20 of this slide refers to the idea of ISA-PRA  
21 comparison. And it's sort of semi -- I will quote  
22 from the SRM that directed us to do this, we're  
23 directed to a do a comparison and critical evaluation.  
24 And as we started to do that, it was realized well,  
25 you have -- to evaluate something or compare using ISA

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701



1 or PRA, it has to be with respect to some use, some  
2 particular thing you are going to use either the ISA  
3 or PRA for.

4 So in the paper, it does this with respect  
5 to two specific uses. And I might mention that PRAs  
6 are used -- and ISAs also are actually used for more  
7 than just these two things. There are other things  
8 that you can do with these types of analyses.

9 But the first one is the actual regulator  
10 purpose of an ISA, which is for safety under 10 CFR 70  
11 Subpart H, which requires that the ISA be done. And  
12 so we're going to evaluate what's been done with ISA  
13 and how that -- in the paper, it discusses well, what  
14 if you did it more like a PRA.

15 And number two, the second use is this use  
16 of ISA or PRA in doing risk significance determination  
17 for inspection findings because that's the context in  
18 which this -- we were directed to do this paper.

19 But this is an outline of the contents of  
20 the paper. It has five sections. The first two  
21 simply discuss what ISAs and PRAs are as sort of a  
22 background reference for -- in case -- for those who  
23 may not be familiar with one or the other of these  
24 things.

25 Then section three is addressing the first

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 one of these two uses, namely for safety under Subpart  
2 H. It is an evaluation of ISA and PRA in that  
3 context.

4 Then sections four and five are the second  
5 thing, which is this risk significance thing. Section  
6 four just sets the background and the context because  
7 risk significance determination is not the be all and  
8 end all of an oversight program. It's just one little  
9 piece that's used in it. So it sets the context.

10 And then section five discusses ISA and  
11 PRA in the context of doing risk significance  
12 determination. And specifically it is a quantitative  
13 risk significance determination. It's the exact  
14 analog of what is done in the reactor oversight  
15 program for quantitative. And has a specific example  
16 to illustrate how this might be done.

17 We're not asserting that it should be done  
18 at this point or that or anything else. This is  
19 something that would be evaluated as part of a  
20 developmental program of trying to do something like  
21 this. But it is an illustration of what you might be  
22 able to do.

23 And that serves as a point of reference  
24 when you discuss and ISA and a PRA and how they might  
25 differ. And that example is evaluated using results

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 of both a risk index method and a fully quantitative  
2 ISA result, which would be what you would have also  
3 available if you had actually done a PRA.

4 This slide refers to the first two  
5 sections, which simply are discussing what ISAs and  
6 PRAs are. And the point here is that ISA and a PRA --  
7 a typical -- like I say, PRAs are used for many  
8 different applications in the NRC. But none of them  
9 are exactly what ISAs are doing. So that ISA and PRA  
10 are typically being used in the Agency for different  
11 purposes.

12 The functions of an ISA under the Part 70  
13 Safety Program are primarily these two things. And  
14 there's much more to the Safety Program in Part 70  
15 than just the ISA. The ISA does this function here --  
16 these functions here. It identifies the hazards and  
17 accident sequences.

18 And this is intended to be comprehensive  
19 to the -- in other words, the scope of an ISA is  
20 completeness of all things that could result in what  
21 we are defined as intermediate consequence events or  
22 above. And that's defined in the rule what that level  
23 of consequence is both for workers and the public. As  
24 I say, we do workers whereas the DOE analyses don't.

25 And that's -- one of the reasons for that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 is that most accident sequences only do effect the  
2 worker. There are really very few that could impact  
3 the public offsite. So this is what an ISA does. It  
4 identifies the accidents and what are the items relied  
5 on for safety that are preventing or mitigating those  
6 accidents. And a list of those items and the accident  
7 sequences is required by the -- to be sent to the NRC  
8 as a thing called an ISA summary. And that summary is  
9 kept up to date. It's updated annually.

10 MEMBER BLEY: So the summary is required  
11 to be submitted?

12 MR. DAMON: Yes, a summary.

13 MEMBER BLEY: Okay.

14 MR. DAMON: Now the summary is, you know -  
15 -

16 MEMBER BLEY: Can be very large. I've  
17 seen it large.

18 MR. DAMON: Whereas the ISA documentation,  
19 I mean at least is like a whole room full of stuff  
20 when it's on paper.

21 MEMBER BLEY: I had a question about the  
22 second part of that, the compliance with the  
23 performance requirements. When you go to the  
24 regulation, it's very clear on definition of high  
25 consequence and intermediate consequence exactly what

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 that means.

2 Then it says for high consequence events,  
3 they must be very unlikely or extremely unlikely --

4 MR. DAMON: Highly.

5 MEMBER BLEY: -- highly unlikely and for  
6 intermediate consequence, they must be unlikely. Is  
7 there any guidance to people about what that means?  
8 Do people interpret it differently?

9 MEMBER CORRADINI: Are you asking is there  
10 a number associated with the adjective?

11 MEMBER BLEY: I would like to see a number  
12 associated with it. The way it's written, it seems  
13 like everyone that comes in could have their own  
14 interpretation of what those words mean.

15 MR. DAMON: Yes, they could. There was a  
16 Standard Review Plan that was written and it actually  
17 was forward drafted at the time the rule was  
18 promulgated. So everyone knew what was going to be in  
19 it. And it has some guidance on numbers.

20 MEMBER BLEY: Okay. I didn't go back and  
21 look at that.

22 MR. DAMON: Yes. It says if you do, that  
23 quantitatively this is one number the staff -- and it  
24 has a rationale for why that number was chosen and so  
25 on. Now licensees didn't necessarily pick that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 number. Some licensees picked a different number. Or  
2 they used the risk -- and then there is the risk index  
3 method. And they picked a number from that that's  
4 also equivalent to a frequency.

5 MEMBER BLEY: But they all picked numbers?  
6 Or did some just use adjectives to describe?

7 MR. DAMON: Nine out of ten --

8 MEMBER BLEY: Used numbers of some sort?

9 MR. DAMON: One did not use a number.

10 MEMBER BLEY: Can you give us a hint of  
11 what the ranges of those numbers might have been?

12 MR. DAMON: Ten to the minus four and ten  
13 to the minus five for highly unlikely. Some picked  
14 one number and some picked --

15 MEMBER BLEY: Okay.

16 MR. DAMON: -- the other one.

17 MEMBER BLEY: That's not too bad.

18 MR. DAMON: Right. So, you know --

19 MEMBER BLEY: And for unlikely?

20 MR. DAMON: And order of magnitude  
21 difference --

22 MEMBER BLEY: Okay.

23 MR. DAMON: -- is usually -- I think it's  
24 true for all of them.

25 So the other thing that the ISAs do is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 evaluate these performance requirements that Dennis  
2 Bley mentioned. And there is one other performance  
3 requirement and it is a direct quote of a requirement  
4 -- the principle requirement in ANSI 8.1, this  
5 criticality safety standard. And it says that for all  
6 normal and credible abnormal events, the system shall  
7 be subcritical. And partly that was put in in case  
8 you had a shielded facility, we still want to prevent  
9 criticalities even if there is no, you know, shield  
10 there, shielding to protect you from the results.

11 And the functions of PRA are various. So  
12 I just sort of synopsized it. But typically a PRA,  
13 the quantitative results of PRA are used in many  
14 different ways. And, therefore, it requires basically  
15 that you quantify a risk metric to do most of those  
16 applications although you can get obviously  
17 qualitative insights that don't involve numbers.

18 But most of the applications that PRAs are  
19 used for, it differs in that you must quantify it and  
20 you must add up the accident sequences to obtain a  
21 metric that are used in the applications like, for  
22 example, regulatory analysis uses a collective risk  
23 metric and most of the other applications, the main  
24 metric used is large early release frequency which is  
25 large enough to produce substantial dose to the public

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 offsite.

2           And what do ISAs exactly product? Well,  
3 they're different. Each one is different because a  
4 lot of flexibility -- not having ever done these  
5 before, at the time the rule was promulgated, there  
6 was only one licensee that had actually completed an  
7 ISA. It was B&W.

8           And so not knowing how these things would  
9 come out, a lot of flexibility was left to the  
10 licensees. So they -- and they don't necessarily  
11 share everything with one another. So each ISA is  
12 different.

13           However, the rule is quite a bit of  
14 prescription about what an ISA has to do and what you  
15 have to send in an ISA summary. Consequently, they  
16 all do this. They all have a list of accident  
17 sequences. They all have a list of the items relied  
18 on for safety that prevent those sequences.

19           The accident -- each accident sequence is  
20 assigned to a consequence category, like I said and as  
21 was mentioned, these are quantitative categories.  
22 They're defined in the rule and by the licensee. And  
23 high, intermediate, and low -- for example, high  
24 consequence to a worker is a, for example, a dose  
25 exceeding 100 rem. Well, for example, a criticality,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 if you were within a couple of meters, would be way  
2 over that and would be a high consequence event.

3 And then the other thing is that the  
4 likelihood of each sequence has to be evaluated. But  
5 interestingly, the rule does not require that that  
6 likelihood evaluation be submitted in the summary. So  
7 for some licensees, if you want to know what the --  
8 how they evaluated the likelihood, you would have to  
9 go to the facility and look, okay, but for most of  
10 them they did -- like as I said, nine out of ten  
11 actually did either a risk index method or  
12 quantitative evaluation of each accident sequence.

13 But in some -- in at least one case that I  
14 know of, it's not in the ISA summary. So --

15 MEMBER BLEY: Dennis?

16 MR. DAMON: Yes?

17 MEMBER BLEY: Before you leave here, I  
18 didn't see it later so let me ask it now. In  
19 selecting IROFs, in the meetings we talked -- or the  
20 group talked often about the double contingencies.  
21 And the report cites the ANSI standard for critical  
22 safety -- criticality safety as requiring double  
23 contingency.

24 The report goes on to say a commitment to  
25 apply the double contingency principle is often part

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 of a fuel license -- fuel facility license. Is it not  
2 always for criticality? And is it mostly for the  
3 others, too? Or how is that applied?

4 MR. DAMON: Well, strictly speaking, in  
5 the standard, the ANSI standard, it's the same one  
6 ANSI 8.1, the double contingency principle is not a  
7 requirement. It's a should.

8 MEMBER BLEY: Oh, that's right. You're  
9 right. Yes.

10 MR. DAMON: Yes, it's a recommendation.  
11 Because it's believed that there would be  
12 circumstances where strictly speaking, you couldn't do  
13 it, you couldn't really get true double contingency  
14 because it's a fairly stringent statement. It says  
15 that before a criticality is possible, the safety  
16 margins will be such that before a --

17 MEMBER BLEY: I have it here in front of  
18 me if you'd like.

19 MR. DAMON: Oh, well, you can read it if  
20 you want.

21 MEMBER BLEY: Two unlikely independent and  
22 concurrent changes in process must occur.

23 MR. DAMON: Yes. And so the independent -  
24 - fully independent, no single failure type of a  
25 requirement is a pretty tough requirement. But it can

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 be done. When you have low enriched material, you  
2 need both a mass and you need moderator. So you can  
3 control these two things quite a bit independently so  
4 that there is no way of --

5 MEMBER BLEY: So for criticality, it's  
6 usually applied. How about for other consequence  
7 elements? That wasn't clear to me. In the meetings,  
8 I thought that I heard they always used double  
9 contingency for everything. But when I read the  
10 words, it doesn't quite say that.

11 MR. DAMON: No, it doesn't. It's not  
12 absolutely required. But there is -- for new  
13 facilities, facilities that came to us and got a  
14 license after the rule went into effect --

15 MEMBER BLEY: Yes.

16 MR. DAMON: -- there's a -- I believe it  
17 is Section 70.64 has a list of things called baseline  
18 design criteria.

19 MEMBER BLEY: Yes.

20 MR. DAMON: And one of those is double  
21 contingency. But the way it is worded, it is not  
22 absolutely requirement. It's -- basically the burden  
23 is on you to tell me why you can't do this. But it's  
24 that kind of a thing.

25 MEMBER BLEY: Okay. So it essentially

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 asks for it unless there's --

2 MR. DAMON: Yes.

3 MEMBER BLEY: -- some reason to --

4 MR. DAMON: Right. And so that's the way  
5 it works in practice. But even before that, some  
6 licensees had committed to being doubly contingent.  
7 And it's, like I say, for a low-enriched facility, it's  
8 relatively -- you can do that. But high enriched,  
9 it's much tougher.

10 MEMBER BLEY: Yes, okay.

11 MEMBER STETKAR: Dennis, I must admit, I  
12 couldn't the Subcommittee meeting and I haven't looked  
13 at any results from ISAs. But I was curious. One of  
14 the things that PRAs spend quite a bit of time looking  
15 at are dependencies or certain whether you want to  
16 call them initiative events or hazards that might cut  
17 across lines that otherwise might be considered  
18 independent.

19 So, for example, we look at fires. We  
20 look at floods. We look at seismic events. We look  
21 at common power supply dependencies that might effect  
22 several systems. Do the ISAs also do that? Do they  
23 look at, for example, a ten to the minus four per year  
24 seismic event that might effect several process  
25 streams throughout a facility and examine the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 consequences for that --

2 MR. DAMON: Yes.

3 MEMBER STETKAR: -- in an integrated --

4 MR. DAMON: Yes.

5 MEMBER STETKAR: They do? Okay.

6 MR. DAMON: The rule is explicit on that.

7 That external events shall be considered in the ISA.

8 And so --

9 MEMBER STETKAR: And are considered -- you  
10 don't have a single -- they don't parse them up so that  
11 you're led to believe that a seismic event that would  
12 effect the whole facility indeed is subdivided into a  
13 thousand independent sequences?

14 MR. DAMON: No, I mean it's --

15 MEMBER STETKAR: Okay.

16 MR. DAMON: But they do --

17 MEMBER STETKAR: Okay. That's --

18 MR. DAMON: -- they are required to look  
19 at these. I mean, in fact, fire was pretty strongly  
20 called out. There's a whole section, a whole chapter  
21 --

22 MEMBER STETKAR: Okay, that's --

23 MR. DAMON: -- in the standard review plan  
24 of fire, for example. It was realized that's an  
25 important one to look at. And so yes, they look at

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 fires.

2 And also, there's an explicit language in  
3 the rule that says thou shalt consider process  
4 interactions.

5 MEMBER STETKAR: Okay. But your White  
6 Paper recognizes a difference between the two in  
7 treating dependencies. I mean the conclusion is, in  
8 principle, no difference. But risk index method does  
9 not have dependency analysis built in but must be  
10 added via double contingency or other analysis.

11 MR. DAMON: Right. That's a true  
12 statement. Now it turns out --

13 MEMBER BLEY: I mean it doesn't have to be  
14 that way. But it seems that it is.

15 MEMBER SHACK: Well, that's the in  
16 principle no difference.

17 (Laughter.)

18 MR. DAMON: Yes, it --

19 MEMBER BLEY: But in practice, it seems a  
20 very large difference.

21 MR. DAMON: Well, I mean it isn't just the  
22 fact that the Standard Review Plan didn't have a big  
23 section on common cause analysis or a beta factor  
24 method or anything like that because the licensees  
25 recognize this. And they adopted methods for doing

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 such things.

2 I mean they have -- GE's methodology, they  
3 have an explicit factor in there for if you have like  
4 identical redundancy, you don't take full credit for  
5 the second control. Some licensees -- often what I've  
6 seen is they don't take any credit for a second  
7 control. So they all do that kind of thing.

8 But the more problematic thing is the fact  
9 that you have a whole lot of processes in the plant.  
10 And so it's, in principle, there would be a lot of  
11 interactions. But in practice, there aren't because  
12 the processes don't interact with one another much.

13 And, in addition, they don't have common  
14 support systems that are actually needed for safety.  
15 For example, electric power. To my knowledge, except  
16 for the, you know, for the few exceptions like the MOX  
17 plant ventilation system that maintains the negative  
18 pressure, except for things like that, they don't --  
19 the power is not needed for a safety function. It's  
20 needed to allow you to continue to operate the process  
21 and shut it down in an orderly manner so that the  
22 material goes where you want it to go and so on.

23 And so as a result of that, you don't have  
24 as much concern about these cross-cutting events that  
25 effect multiple processes.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MEMBER STETKAR: Except for perhaps some  
2 external events like severe storms, winds --

3 MR. DAMON: Yes, external, the fire --

4 MEMBER STETKAR: -- seismic events is the  
5 one, even fires, depending on the facility, it might  
6 be difficult to get a fire large enough. But large,  
7 whatever you want to call them, I'll call them  
8 external events that despite the physical distribution  
9 of things could effect several things simultaneously.

10 MR. DAMON: Yes.

11 MEMBER STETKAR: But you said those are  
12 explicitly --

13 MR. DAMON: They are required.

14 MEMBER STETKAR: -- considered. I mean if  
15 you're talking about ten to the minus four to ten to  
16 the minus five per year as sort of the conceptual  
17 threshold for unlikely, you can get some fairly  
18 interesting phenomena occurring at those frequencies.

19 So --

20 MR. DAMON: Yes.

21 MEMBER STETKAR: -- I was curious --

22 MR. DAMON: That's true.

23 MEMBER STETKAR: -- how people consider  
24 that.

25 MR. DAMON: Another aspect of that though

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701



1 is -- the other things about like electric power is  
2 that with a reactor, the safety functions that are  
3 done, such as coolant heat removal usually require an  
4 active system to remove the heat or something, right,  
5 so you need power for -- you have a mission to  
6 complete when you trip the plant.

7 But a typical fuel cycle facility safety  
8 function just stops doing whatever they're doing. And  
9 there's no power needed to do some function usually.  
10 They just have to stop. And then you're in a safe  
11 condition.

12 So -- I mean it's not always true. But I'm  
13 just saying --

14 MEMBER STETKAR: I suspect sometimes you  
15 need to get some material from point A to point B  
16 before it's kind of okay. But --

17 MR. DAMON: Yes, well usually the  
18 processes are designed so that movement isn't an  
19 issue. And you try to make -- either the amount of  
20 material in the process is limited to the point where  
21 you don't have a problem with criticality or the  
22 process geometry is safe by geometry no matter what  
23 you put in there. So they try to achieve that goal.

24 MEMBER POWERS: A problem you run into in  
25 chemical process facilities, when you leave things in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 line, that tends to be a very bad thing. First of  
2 all, corrosion process get up, you get this weird  
3 crevice corrosion that only Shack and Armijo  
4 understand. And they disagree.

5 The other thing that you run into with  
6 plutonium is that you can get the plutonium hydroxide  
7 precipitations occurring if your acidities change on  
8 you. And so leaving things in lines for protracted  
9 periods of time is really a bad idea. Nearly always.

10 MR. DAMON: And so, yes, like I say, they  
11 have power so that they don't -- they don't get caught  
12 in that situation. So they can, in fact, off load the  
13 material that's in the process when they need to.

14 So this slide was put in here as the  
15 result of some discussions that went on at the  
16 Subcommittee meeting. That the configuration of a  
17 fuel cycle facility, a typical one, in the enrichment  
18 plants this is not quite true. I mean the enrichment  
19 there is basically on process going on there although  
20 there's a process of feeding and withdrawal and  
21 enrichment. So there's at least three things there.

22 But the fuel fab facilities have many  
23 process -- separate process steps. And for each step  
24 there is a type of equipment used for that. And  
25 there's usually multiple process units for each of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 these steps. So the point of mentioning this was  
2 because of a discussion we had and that is if  
3 something goes wrong in a particular piece of  
4 equipment, typically you can just shut that equipment  
5 down. You're not shutting down the whole plant.  
6 You're just shutting down that particular piece of  
7 equipment that may be one out of five identical ones  
8 that are being used to do that particular step in the  
9 process.

10 And here's the sort of sequence of process  
11 steps. Conversion from a uranium oxide, U-308-type  
12 composition that you get from a uranium mill,  
13 converting that to uranium hexafluoride so that you  
14 can do the next step, which is you make that  $UF_6$  into  
15 a gas and enrich -- and run it through an enrichment  
16 process.

17 Then put it back in a cylinder, a two-and-  
18 a-half ton cylinder, sent it to a fuel fabrication  
19 plant, which does the next step, which converts the  
20  $UF_6$  into  $UO_2$  powder. And in one type of process, the  
21 wet chemistry type process, that's done in multiple  
22 process steps, multiple pieces of equipment. And in  
23 other ones, there's one reactor that does that  
24 conversion there.

25 Then there's powder blending to get

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 enrichment and additives just right, milling of the  
2 powder to get the powder range just right. The  
3 pressing it into pellets. The sintering -- grinding -  
4 - sintering -- there's sintering of the pellets,  
5 grinding them to precise dimensions, loading them into  
6 pins, and manufacturing assemblies.

7 And they typically plants also have scrap  
8 recovery processes and manufacturing of absorber  
9 elements in the facility. So a typical facility has a  
10 whole lot of processes in it.

11 And as the -- the fourth bullet is the  
12 main reason for this slide -- is just to emphasize  
13 that when you have a process upset or an IROFs becomes  
14 inoperable so that you are no longer sufficiently  
15 safe, then typically all you have to do is to stop the  
16 process or take some other action that renders it  
17 safe. But you don't need to perform some kind of  
18 active safety function usually. There are exceptions  
19 to that.

20 Control failure may not cause a parameter  
21 to exceed a safety limit. At one point in time, I  
22 looked at all the upset conditions where they were  
23 down to just one control preventing a criticality.  
24 And out of 64 events like that in a four-year period,  
25 there were only six where the parameter that was being

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 controlled actually exceeded its safety limits.

2 So that's what I'm -- what I'm saying here  
3 is that most processes have big safety margins built  
4 into them. And just because you lose the control  
5 doesn't mean that the parameter goes to an unsafe  
6 condition.

7 MEMBER STETKAR: Do they look at the kind  
8 of things we look at in PRAs? Not only -- when people  
9 talk about control failure, they usually say well, it  
10 fails in the way that it was designed to fail. So  
11 something that is actively controlling the position of  
12 a valve, that valve goes closed, for example, if it is  
13 designed to fail closed. Do they look at what we call  
14 spurious operations? In other words, faults that  
15 would convince the control system to drive that valve  
16 full open and keep it open?

17 MR. DAMON: I mean all I can say is they  
18 should. I can't recall an example -- maybe there's  
19 somebody else in the audience that can remember an  
20 example of something like that.

21 MEMBER BLEY: If they're doing HAZOP, they  
22 have to do that. That's part of doing a HAZOP --

23 MEMBER STETKAR: Yes, okay.

24 MEMBER BLEY: -- so that in principle,  
25 again --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: Too much, too little.

2 MEMBER BLEY: -- they sure shouldn't be  
3 doing too much, too little --

4 MEMBER STETKAR: Well, I don't know. As I  
5 said, I haven't looked -- I know nothing about these  
6 things. I was just trying to think of possible  
7 differences.

8 MEMBER CORRADINI: So just so I'm clear,  
9 when you said a HAZOP, I just assumed that a HAZOP and  
10 ISA were the same. Not true?

11 MEMBER RAY: Not true.

12 MEMBER RYAN: No.

13 MR. DAMON: Yes, HAZOP is a specific  
14 analysis step that is used in many of the ISAs and  
15 it's very applicable to chemical and things that are  
16 handling fluids and that --

17 MEMBER RYAN: Anywhere there's flammable  
18 solvents, it's a big deal.

19 MEMBER BLEY: In the operation but you go  
20 around and you find a hunk of the plant and you said  
21 what happens if, you know, you get more flow, less  
22 flow, higher temperature, lower temperature. And so  
23 it is a way to generate the sequences that you look  
24 at.

25 And if any of those cause trouble --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER CORRADINI: And the ISAs are  
2 qualitative renderings of these sequences without  
3 summation of the probabilities of what -- I'm just --

4 MEMBER RAY: The ISAs take these sequences  
5 to a full sequence definition, not just what happens  
6 at this point. Often it's a one point thing but it  
7 could be more. So the ISA is an analysis that tries  
8 to put all these pieces together.

9 MEMBER SHACK: Yes, the White Paper says  
10 that ISA uses hazard ops for accident identification.  
11 And then you add the risk index for likely --

12 MR. DAMON: As would a PRA.

13 MEMBER SHACK: Yes.

14 MEMBER RAY: HAZOPs are really good, too,  
15 for identifying the potential problem areas in a  
16 plant.

17 MR. DAMON: So and then the last two  
18 points here from this is that -- is this -- because  
19 this whole subject of process interactions, as has  
20 often been mentioned, is something that you have to be  
21 very careful with in a PRA -- and you do -- you should  
22 -- also it's an issue for any kind of, you know, for  
23 an ISA within a -- but it's usually within the  
24 process.

25 You know, interactions between processes

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 are restricted because these plants, as I said at the  
2 first bullet, the process steps are really separated  
3 from one another. They don't -- they're not  
4 automatically feeding the output of one process into  
5 the other. It's a manual step where the output has  
6 always been in one container and is moved to another  
7 process and fed to something else. But they're not --  
8 it's not a continuous process. It's a batch operation.  
9 And then --

10 MEMBER ARMIJO: There really is no  
11 feedback either. There's no way to feed back, you  
12 know. If something goes wrong in pelletizing, it  
13 doesn't effect conversion or, you know, if they're  
14 really batch processes.

15 MR. DAMON: Yes. So it is different. You  
16 know a reactor is all one big integrated machine doing  
17 one thing. And these plants are all these separate  
18 pieces of things that aren't doing -- it isn't just one  
19 big thing usually. Now obviously the enrichment  
20 plants, they are, you know, connected together. But  
21 the fuel fab plants are this separate step type of  
22 thing.

23 And I've been told anyway that like  
24 centrifuge plants, when a centrifuge goes bad, they  
25 just reroute the flow around it and they just leave it

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 there. That's the -- you know.

2 Now this is addressing the first  
3 application of this ISA PRA comparison thing. And the  
4 comparison in the materials in the paper, it goes  
5 through all the different aspects of what's done in  
6 PRAs and ISAs and discusses each aspect of them.

7 But I wanted to mention in this slide that  
8 ISAs are not -- they're not trying to quantify the  
9 risk accurately. What they're trying to do is make  
10 sure that you've got an adequate safety. And so  
11 frequently things are done in a conservative way. And  
12 that's perfectly acceptable for the purposes that an  
13 ISA is doing in the -- for safety under Part 70, which  
14 is what this slide is talking about.

15 So that's the thing is that you're not  
16 trying -- they weren't trying to do an accurate  
17 estimate of risk for some application that needs that  
18 kind of an estimate. Consequently, they aren't. The  
19 ISAs are often quite conservative. Not always, you  
20 know, but I'm just saying it is quite frequent that  
21 you'll find something that's done very conservatively.

22 The ISAs use the systematic methods such  
23 as the HAZOP that had actually been in practice and  
24 being used because they were required by OSHA for  
25 chemical plants that possess more than a certain

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 amount of material, of hazardous chemicals. And so  
2 there's really vast experience with using -- doing  
3 these types of analyses.

4 And the chemical industry also uses fault  
5 trees and event -- some of them use fault trees and  
6 event trees. Some do, you know, fully quantitative  
7 PRA-like evaluations. But they also do these process  
8 hazard analyses that are more qualitative like was  
9 done in a HAZOP.

10 And the rule that was put in place wasn't  
11 really just to do -- make the licensees do ISAs. It  
12 was really -- the more general idea was to bring  
13 chemical hazards under NRC regulation. We were  
14 directed by Congress basically and told to do this.

15 And so the question here that I'm trying  
16 to answer with this slide is why are they acceptable.

17 Well, it's based on systematic methods that have  
18 been, you know, where there's a large experience base.

19 And the licensees have acquired this same experience  
20 by doing these.

21 The process started in the middle or early  
22 1990s. So we're almost 20 years into this. So that's  
23 why I say that the licensees themselves have quite a  
24 bit of experience now with doing this kind of a thing.

25 And then, of course, the NRC staff

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 reviewed -- expended quite a bit of resources  
2 reviewing each ISA when they were -- the summaries  
3 were submitted. They didn't just review the summary.

4 They went to the plant and looked at the actual ISA  
5 documentation on site.

6 But these plants are so extensive in terms  
7 of numbers of things and so on that the staff did not  
8 review every single thing in the plant. They made  
9 sure that the plant had been covered. But as far as  
10 doing a detailed review and questioning how each  
11 number -- where each number came from, they only did  
12 that for like a subset, a representative subset.

13 And ISA -- and the other thing to say  
14 about ISAs and their acceptability is they can -- they  
15 can be fully quantitative and some of them are. And  
16 they do use PRA-type events in places where it's  
17 applicable. But again, as this first bullet, they're  
18 not necessarily accurate risk assessments --

19 MEMBER REMPE: Before you leave that one,  
20 like with reactor safety analysis, you say that they  
21 always have conservative evaluations. There's some  
22 cases where if a relief valves goes off early, it's  
23 beneficial to the plant's safety because you've  
24 depressurized. What happens if there's a situation --  
25 is there a situation in one of the facilities that's

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 like that? Where something that appears maybe to be  
2 conservative may not be conservative for other  
3 situations? And how do they address something like  
4 that? Or am I thinking of an example that just won't  
5 happen?

6 MR. DAMON: Well, they're not -- I'm not  
7 saying everything they do in the ISA analyses are  
8 conservative.

9 MEMBER REMPE: Do they look at a couple of  
10 different cases when something like that could occur?  
11 Where -- and I'm not -- I don't have enough knowledge  
12 of the facilities that you're looking at to say could  
13 something like that occur or can't occur.

14 MR. DAMON: Yes, I'm not -- I cannot think  
15 of something that has that characteristic. They two  
16 typical things that when I use this word conservative  
17 are they will have safety controls. They'll say they  
18 have three safety controls. They'll only tell you  
19 about two of them. And they'll only take credit for  
20 two them in doing their evaluation if they put numbers  
21 on them.

22 And if they get below the ten to the minus  
23 whatever, they're good. And they don't take any credit  
24 for the third one. So when you go in and if you --  
25 this will come up later when I say well, what if you

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 want to use ISA results to do risk significance, well,  
2 you've got to know whether they got another control  
3 there. So that's a conservatism.

4 The other one, the big one, is for offsite  
5 consequences -- actually the rule reads this way, if a  
6 release could cause high consequences, then the  
7 release is categorized as a high consequence sequence,  
8 okay, even if 99 percent of the time it would not  
9 because of the weather would be -- it would be blowing  
10 in the wrong direction or something.

11 So the offsite consequence evaluations are  
12 done like that. They just determine if you were worst  
13 case weather and the thing was blowing at the peak  
14 nearest person, would it be high consequences. So  
15 that's not a risk --

16 MEMBER RYAN: Joy, I think the HAZOP might  
17 catch some of these things that you've talked about in  
18 your example. If they did a HAZOPs analysis right,  
19 they would catch that difference, you know. Normally  
20 often it's on that kind of thing. It would flush out  
21 on those unit operations, HAZOP kind of evaluations.  
22 I'm not saying it would be perfect. But that's usually  
23 where that kind of thinking gets flushed out.

24 MEMBER REMPE: I had to ask.

25 MR. DAMON: Yes, it's hard to make any

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 kind of generalization about the plant. Each type of  
2 equipment, the way it's achieving safety are quite  
3 different from one another. They're not all like  
4 analogous to a reactor. And different kinds of  
5 reactors or something they did, they just have totally  
6 different strategies for making things safe.

7 And so it is very difficult to generalize  
8 about what goes on. There's just a huge collection of  
9 various different things.

10 This has to do with the second  
11 applications of, you know, using an ISA or a PRA. And  
12 like I say, in the first one, what I'm basically  
13 saying is you can -- if you do a good ISA, it's good  
14 enough for the purposes of safety under the rule.

15 The second point here, well, what if  
16 you're going to use ISA or PRA and you're going to do  
17 this risk significance determination? Well, if you're  
18 going to do it quantitatively, guess what? You need  
19 quantitative information. And it has to be a  
20 reasonable -- it doesn't have to be, you know, six  
21 decimal places accurate but it has to be roughly an  
22 accurate representation of the risk to do the  
23 significance determination because what you're trying  
24 to do is rank things.

25 And do it on a consistent basis because

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that's kind of what the fuel cycle oversight program  
2 it's first thing it wants to achieve is consistency  
3 and to rate the significance in a rough way but in a  
4 relative way correctly. So that the high significance  
5 things are correctly categorized as such and lowest --  
6 so if you're going to do it quantitatively, obviously  
7 you need quantitative information.

8 Well, it turns out most ISAs do have some  
9 quantitative information. They, like I said, two fo  
10 them did it fully quantitatively. At least they put -  
11 - not fully. They have a sequence frequency assigned  
12 to each sequence.

13 Seven of them use this thing called risk  
14 index method, which is a very crude way of scoring  
15 sequences. And it is intended to be used in a  
16 quantitative way. I, myself, reviewed -- looked over  
17 the evaluation reports that the staff did on all the  
18 ISAs to see if, in fact, the staff was sort of holding  
19 the licensees to interpreting it as quantitative.  
20 And, in fact, the staff did do that.

21 In other words, they didn't let the --  
22 they tried to make sure that the licensees weren't  
23 doing something that didn't -- that if you understood  
24 it in a quantitative way, it was wrong, you know.  
25 They were trying to do it -- but it is very crude.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 And you could call -- we actually call it qualitative  
2 it's so rough.

3 And so -- but they do have this  
4 information. Of course, they have -- they're telling  
5 you relatively accurate information about consequences  
6 also because the consequence criteria in the rule are  
7 quantitative or could be interpreted as such.

8 So you do have the -- now sometimes that's  
9 done, again, conservatively. Like I mentioned the  
10 offsite consequence, well sometimes the assumption is  
11 made if there is a release of a hazardous chemical  
12 inside a building, they will just -- some licensees  
13 just simply assume the worker would be a high  
14 consequence exposure, which is life threatening. They  
15 would just assume that, which is not -- often not  
16 true.

17 So they do have some information but it's  
18 not necessary accurate for these reasons that I'm  
19 mentioning. And so, therefore, if you're going to use  
20 it for a quantitative evaluation of risk significance,  
21 sometimes you're going to have to make changes or add  
22 things to it. Like I say, safety controls in some  
23 plants are not all declared IROFs. So they're not  
24 listed. And safety margins are usually not -- there  
25 is usually not credit taken for that.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1           And the ISAs are also -- another thing  
2 that relates to risk significance determination is the  
3 ISAs aren't standardized in any way. They're not using  
4 the same database of things necessarily.

5           Now that's not quite true in the sense  
6 that there really are only, I think, two types of risk  
7 index tables. One that was -- they kind of -- they  
8 are kind of using the risk index is somewhat common  
9 but what I'm saying is the licensees do these analyses  
10 separate from one another. And the full details of  
11 their analyses are not communicated. They're  
12 proprietary information so they're not available to  
13 the other licensees in detail.

14           Section 5 of the report is this thing  
15 about an evaluation of risk in the context of risk  
16 significance determination. And it has this example  
17 in there which is a very typical safety feature of a  
18 plant. And that is that you would have a piece of  
19 process equipment that would be safe by geometry.

20           Meaning that for criticality safety, no  
21 matter what the composition of what's in the vessel,  
22 it won't go critical because it's either a column that's  
23 too small in diameter or it is a flat surface that's  
24 too thin. And no matter what's in there, it won't go  
25 critical. And so that that's the example analysis.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1           And then typically this is to contain --  
2 fissile material in solution, which all but one  
3 criticality -- actual criticality accident in the  
4 world have been in solution systems. That's why I  
5 used this example. It's a very typical one. The way  
6 you do things -- make things safe is you -- wherever  
7 you've got your ambient solution, it's in a safe  
8 geometry vessel.

9           Now what could happen is it could leak.  
10 And then it goes out of the vessel. So underneath you  
11 have a typically some way of where that the process  
12 fluid goes. And there are usually also overflow lines  
13 in case you overfill something, it goes over and into  
14 another safe geometry, which is usually -- it's  
15 usually a dike around the process equipment to contain  
16 whatever leaks out.

17           And that's there for multiple purposes,  
18 one of them being criticality safety that stays in a  
19 flat slab. So that's the example. And in the  
20 example, the point is it postulates some hypothetical  
21 defect, namely that the dike around there has a leak  
22 in it. And the point of the example is to show that  
23 there's only a few accident sequences effected by a  
24 typical deficiency that you would find in an  
25 inspection.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1           And so it supports this key point we're  
2 trying to make that these significance evaluations --  
3 the efficient way to do this is to do them on a case-  
4 by-case basis.       When you have an inspection  
5 deficiency, you will do the quantitative analysis of  
6 that process when you need that information as opposed  
7 to the way reactors did.   They already had the PRAs.  
8 So they went around and sort of predigested the PRAs  
9 into these inspector notebooks where they can then do  
10 a significance analysis very quickly when something  
11 happens.

12           Well, it would be very inefficient for  
13 these plants because you wouldn't use most of it.   All  
14 this analysis you would do, 90 percent of it would  
15 never get used because of the number -- because each  
16 deficiency would only effect one little part of the  
17 plant and you would only have one or two a year.   And  
18 so the rest of it would never get looked at.

19           MEMBER BLEY:   Dennis?

20           MR. DAMON:   Yes.

21           MEMBER BLEY:   I know you've warned us in  
22 the report not to look at the numbers you provided in  
23 the example -- I thought the example was interesting.  
24           I thought getting to the ISA quantification result in  
25 the end was a little difficult to work through but you

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 get there.

2 But I still have to ask. And I'm  
3 wondering if this is kind of typical. You have two  
4 scenarios. And in one of them, the risk index  
5 approach through the ISA comes out in an overestimate  
6 compared to the PRA. But, you know, within a factor  
7 of six. That's pretty close.

8 In the other case, it's just the opposite.  
9 And it's an underestimate by almost a factor of 50.  
10 And is that what we ought to expect?

11 That the ISA risk index thing can have  
12 several orders of magnitude change with respect to  
13 what you might get if you did a PRA on some of these  
14 things?

15 MR. DAMON: I would say it's not -- it's  
16 not typical that you would get a real big difference.  
17 But it wouldn't be at all unexpected to get one order  
18 of magnitude, you know, a factor of ten or so  
19 different between what you would easily -- I mean  
20 actually it's reflected --

21 MEMBER BLEY: I guess what kind of got me  
22 a little -- I won't say upset but just to have one  
23 case go one way and the other case swing the other in  
24 the same analysis, I would have hoped it was biased  
25 one way and not the other. But it doesn't seem to be.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER POWERS: No such luck.

2 MEMBER BLEY: That's what it looks like.

3 MR. DAMON: No, it's no -- yes, no such  
4 luck. As I mentioned, the conservatism, not all these  
5 things are conservative. I mean, you know, some of  
6 them are -- they did whatever the lookup table told  
7 them to stick in there.

8 MEMBER BLEY: A factor of 36 low is not  
9 conservative I would guess.

10 MR. DAMON: No, so like I say, they're not  
11 -- it's not all conservative. I mentioned that  
12 because often when it's done explicitly, you know,  
13 when they think about it, they often do do it  
14 conservatively. But sometimes they're just looking it  
15 up in the table. And yes, this is a passive control  
16 so it gets this.

17 ut if you thought about it, oh, gee, that  
18 number is probably not an accurate -- I mean I'll give  
19 you an example of one that I found myself in the early  
20 years was plugging of a -- there was a -- you don't  
21 want fissile bearing solutions to accumulate in some  
22 certain places. And so you put a hole in the bottom  
23 so it would drain out.

24 And they identified that as well, that's a  
25 passive control. So that's ten to the minus three per

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 year. Normally, it's not -- plugging of a hole, you  
2 know, is more likely than ten to the minus per year,  
3 you know? It depends -- of course, it depends on what  
4 you might have but I mean it's happened before, you  
5 know. You've have something in there in that vessel  
6 other than something solid can migrate over there and  
7 plug the hole, you know.

8 MEMBER BLEY: It's always seemed to me  
9 there's something nice about being quantitative in  
10 that it forces you to see if you're things are making  
11 sense when you get done.

12 MR. DAMON: Oh, yes. I mean AFLAC has  
13 said this in a meeting that we had with the industry  
14 once and I concur with it. And that is yes, when you  
15 try to do things quantitatively, it forces you to  
16 think more -- a little bit more carefully about really  
17 what's happening.

18 Like, for example, HAZOP -- HAZOP has  
19 these guide words like flow and it says well, what if  
20 the flow is too high, what if the flow is to low. And  
21 so you'll have all these different things. If it's  
22 high, then this is what -- but often there isn't any  
23 discussion of well, how would you get high flow? What  
24 is actually causing this to -- and so when you have to  
25 quantify something, you have to go that extra step of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 saying okay, well, really what's going on here? What's  
2 happened? And how likely is that?

3 So it does refine you --

4 MEMBER BLEY: Actually when you take the  
5 HAZOP to an ISA, I would hope you would at least do  
6 the one you just talked about to make -- turn this  
7 into a scenario. Not just this is high but what is  
8 the scenario that --

9 MR. DAMON: Oh, yes, they have to march  
10 through the scenario of yes, it's high. And then this  
11 happens. Then usually there is some other thing, you  
12 know, double contingency, something else has to  
13 happen. And then oh, now we get a criticality. Or  
14 like for hazardous chemicals, double piping is often  
15 used. So you have to get two leaks in order to get to  
16 the unsafe condition.

17 MEMBER BANERJEE: But in a HAZOP, you have  
18 to document why you think something can happen, right?  
19 It's a systematic procedure when you use a guide  
20 word.

21 MEMBER BLEY: And you have a good team.

22 MEMBER BANERJEE: Yes, you have a good  
23 team.

24 MEMBER BLEY: The right people.

25 MEMBER BANERJEE: You write it down. And

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 then you write down what remedial action, if any. And  
2 if the consequences are of no importance, then you  
3 just cancel that.

4 So there is a qualitative consequence  
5 evaluation as well as a qualitative cause evaluation.

6 If it's incredible then you don't consider it. And if  
7 the consequences are negligible, you don't consider  
8 it. It sort of gets written off.

9 So I think most of you know what a HAZOP  
10 is but you go vessel by vessel, line by line,  
11 auxiliary by auxiliary. And you do a certain number.

12 And this goes on using all the guide words. And  
13 there's a lot of software that helps you to do it.

14 So it's a qualitative assessment but, you  
15 know, it's probably better than most qualitative  
16 assessments because it's done by people who know what  
17 they are doing. Whereas it's not sort of just putting  
18 some numbers down, you know.

19 MR. DAMON: Yes, that's a good point to  
20 make is, in fact, it's in the guidance, like the  
21 Standard Review Plan, and even in the regulation it  
22 very clearly identifies that you need qualified people  
23 to do this. It's done -- the ISA analyses are done  
24 not by an individual usually. It's done by a team --

25 MEMBER BANERJEE: Right.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701



1 MR. DAMON: -- of people who, you know,  
2 would typically like a process engineer who is  
3 familiar with the process, the operator of the  
4 process, the criticality safety engineer, maybe a  
5 chemical safety engineer, a fire safety guy, and then  
6 an ISA expert, an ISA-PRA/expert.

7 MEMBER RYAN: And, Dennis, very often the  
8 vendors of various components and systems and  
9 equipment pieces are involved as well. Or at least  
10 their information is available.

11 MR. DAMON: So, yes, that's a very crucial  
12 thing. In fact, at the time the ISAs were done for  
13 the existing plants, of course the plants had already  
14 been operating for 25 years or something like this.  
15 And had the people there that had been operating them  
16 for 25 years. So they've got that kind of knowledge  
17 in their head. You know does this thing ever fail?  
18 You know they would know that yes, it's never failed  
19 in the life of this plant.

20 MEMBER BANERJEE: I happen to be a big fan  
21 of HAZOPs.

22 MEMBER CORRADINI: We sense that.

23 MEMBER BANERJEE: Yes. Because I've seen  
24 it work in a real way, identify real things.

25 MEMBER CORRADINI: But it is a qualitative

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 first step that leads you to what they're doing here.

2 MEMBER BANERJEE: Yes, you can take it as  
3 a first step and do more.

4 MR. DAMON: So anyway, this is just  
5 summarizing the key -- what we, the staff, sees as the  
6 key points of the paper. That firstly, that ISAs are  
7 adequate for the safety function that they perform  
8 within the context of the rule.

9 But we didn't come to that conclusion just  
10 because of say the abstract -- that the technique used  
11 was good. We came to this conclusion by reviewing the  
12 ISAs and seeing that yes, they were done. Staff  
13 agrees that these were done adequate to cover what  
14 they were trying to do. And that is to identify the  
15 items for safety and make sure that the safety design  
16 is adequate.

17 And the point is with respect to how you  
18 would do risk significance. And the efficient way to  
19 do this, we believe, is to just do these evaluations,  
20 quantitative evaluations if you're going to do them.  
21 And that's an if.

22 You know if that's what is decided that  
23 the way to do this, that you would do them on a case-  
24 by-case basis. And to not just try to redo the ISAs  
25 quantitatively in order to feed this process because

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 you're not going to be using most of that information.

2 So it's just not efficient. So that's basically it.

3 MEMBER ARMIJO: Dennis, how often are the  
4 ISAs reviewed by the staff? Let's say you have annual  
5 inspection or maybe more often than that. Is the  
6 review or the ISA or parts of the ISA typically done  
7 during those inspections of the facilities?

8 MR. DAMON: Yes. The inspectors love to  
9 look at stuff. They go right to the ISA material to  
10 look for things. And, in fact, one of the  
11 requirements in the rule is that those items that are  
12 identified as IROFs in the ISA, if there is a failure  
13 of an IROFs, there must be a log kept on site for all  
14 IROFs failures.

15 So inspectors can go right to this log and  
16 look up well, what's gone wrong since I was here last.

17 MEMBER ARMIJO: How about the process  
18 changes? You know these facilities always have some  
19 changes going on. Just --

20 MEMBER CORRADINI: You mean operating  
21 changes?

22 MEMBER ARMIJO: Oh, people change the  
23 coolant tulip fuel pump or the additive concentration.

24 And you can't stop changes. So how often do they  
25 have to be incorporated to see if they effect their

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 IROFs.

2 MR. DAMON: Well, of course, if they make  
3 a change, the doing of an ISA-type analysis, there is  
4 a requirement --

5 MEMBER ARMIJO: Prior to the change?

6 MR. DAMON: Within the licensee's license  
7 it says if they make a change, they have to redo the  
8 analysis. And, in fact, in like the ANSI standard on  
9 crit safety, it says of course it must be done -- and  
10 analysis is supposed to be done and reach a correct  
11 conclusion before you operate the process.

12 MEMBER ARMIJO: Yes, I would think so.

13 MR. DAMON: And so, yes, it is required to  
14 be done. And then, of course, it is required to be  
15 submitted, the summary of the ISA. And that includes  
16 the entire ISA, all the changes that occurred during  
17 the year have to be -- the ISA summary has to be  
18 updated and sent in every year annually.

19 So the NRC -- that was one of the primary  
20 reasons for the rule other than bringing chem safety  
21 under NRC jurisdiction was to -- that the staff felt  
22 that in the past, before this rule, we had five-year  
23 license renewals. And the staff felt that just  
24 getting a picture of what the plant was like, every  
25 five years wasn't sufficient. That there were too

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 many changes going on in the interim. And so they  
2 wanted a more current description of what was -- the  
3 way the plant was being run. So it's an annual -- now  
4 it's an annual thing.

5 MEMBER RYAN: Okay. Thank you, Dennis.

6 I think we have Charles Vaughan from NEI  
7 up to make a statement. And then we'll have more  
8 questions, okay?

9 MR. VAUGHAN: Good afternoon. I'm Charles  
10 Vaughan from the Nuclear Energy Institute.

11 And I have about 45 years experience in  
12 the nuclear industry in various aspects. And I  
13 mention that because I, as Dennis, go back to the  
14 early '90s and the mid-'90s when the development of the  
15 Subpart H in the rule was being developed.

16 And, in fact, that was, in part, in  
17 response to a petition that was made by NEI at a point  
18 when the NRC and industry both felt that there were  
19 opportunities to strengthen the rule with regard to  
20 defining the basis of safety at these particular types  
21 of plants.

22 So there has been a lot of history, as  
23 Dennis mentioned, in terms of some ten years to  
24 develop the rule and four to five years invested by  
25 licensees to implement the ISAs and then a couple of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 years of effort on the NRC's part to review the  
2 initial ISAs. And so we're pretty far down that path.

3 NEI had transmitted to you by letter, I  
4 think, a series of points and we didn't write a big  
5 fancy paper but what we tried to do was take the  
6 results of our public interactions with the NRC as  
7 they had been working on this and our interaction with  
8 your subcommittee. And simply highlight a number of  
9 points that we felt were appropriate out of those  
10 discussions. So I'm not going to read those points  
11 here because I'm sure all of you are quite capable of  
12 reading that.

13 But there are some things that while they  
14 may be a little bit redundant from what you've heard  
15 from Dennis Damon because we are pretty much --  
16 industry and the NRC are pretty much in tune on most  
17 of these points with regard to the ISA and the PRA  
18 question. There are some things that I want to  
19 highlight.

20 And one is as the rule, the Part 70 rule  
21 that we're licensed to follow is written, ISAs are the  
22 ways to demonstrate that we meet those performance  
23 requirements. And they seem to be effective in doing  
24 that as evidenced by what you've heard from the NRC  
25 and industry feels the same way, that they are

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 workable for doing that.

2 And the ISA methodology that we use is  
3 relying on at least hazards identification tools that  
4 have been used successfully by the chemical industry  
5 for quite a number of years. And most of these fuel  
6 cycle facilities are more of a chemical process than  
7 they are anything else. So using those techniques,  
8 particularly HAZOP for the more complicated processes  
9 and then some of the other discipline techniques for  
10 identifying hazards and working with the hazards has  
11 been effective. And the ISA process then goes farther  
12 and assigns items relied on for safety principally to  
13 prohibit, not just mitigate but actually prohibit  
14 those accident sequences from taking place.

15 So -- and in the process of doing that, it  
16 is a semi-quantitative process in that in terms of  
17 treating these on a numeric continuum, we typically  
18 treat them by putting the consequences and the  
19 frequencies in boxes. So instead of trying to deal  
20 with a numeric continuum, we're putting them in boxes  
21 which makes them somewhat easier to use.

22 There's been a lot of discussion as to  
23 whether that always turns out to be conservative or  
24 not. And I'm not sure that that's really the answer.  
25 The answer there seems to be that putting them in the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 boxes with the definition and the discipline that goes  
2 along with that, is providing us with a reasonable  
3 characterization of the particular parameter that  
4 we're dealing with.

5 Most any technique you use is not perfect.

6 It has some degree of uncertainty. And, of course,  
7 bias is what we're really worried about. And there's  
8 no indication that these techniques are biased in any  
9 undesirable direction, even though they may not  
10 necessarily be perfect.

11 The other thing that I wanted to point out  
12 and I think you saw that in one of Dennis' charts is  
13 there's a huge amount of diversity within these  
14 facilities, even some of the ones that are doing their  
15 own job are using different techniques and different  
16 technology for certain of the chemical processes. And  
17 there is a significant foreign influence in the  
18 different companies. And there's preferences for  
19 different types of equipment.

20 I bring that up because it really doesn't  
21 lend itself to developing a database such as you would  
22 need to support PRAs with a significant degree of  
23 accuracy and would take a tremendous amount of work.  
24 So using or trying to go with a PRA type of analysis  
25 in this diverse industry is somewhat of a complicated

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 task compared to a fleet of reactors that are all,  
2 while somewhat different, are generally similar in  
3 nature.

4 MEMBER STETKAR: Charles, can I ask you  
5 about that?

6 MR. VAUGHAN: Yes.

7 MEMBER STETKAR: Because I read that  
8 bullet. And having worked in data for nuclear risk  
9 assessment for more than 30 years, that was always an  
10 excuse for not doing risk assessment 30 years ago.  
11 Well, we need to have precise data. And your two-and-  
12 a-half inch motor-operated globe valve is different  
13 than my three inch motor-operated gate valve so,  
14 therefore, we need precise data for each of those  
15 valves and it's different.

16 MR. VAUGHAN: Right.

17 MEMBER STETKAR: We have operating  
18 experience. We found that those two valves don't  
19 really have all that different failure rates. And we  
20 quantify the uncertainties and we sort of learned that  
21 the differences don't make a difference. And by and  
22 large, the desire to have extremely precise numbers  
23 for superficially different pieces of equipment was  
24 something that really wasn't justified as an excuse  
25 for not doing something.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           So I don't -- I know nothing about these  
2 facilities. So when you say you have such vastly  
3 difference equipment that it would be, you know,  
4 virtually impossible to develop data that would  
5 characterize failures. We've been through that  
6 experience and kind of learned that that isn't always  
7 true.

8           Now, you know, if you have some really  
9 exotic jet pump as compared to a standard centrifugal  
10 motor-driven pump, you know, there I can understand  
11 why you might need different data to characterize.

12           MR. VAUGHAN: Let me respond to a few --  
13 you've raised several points in your comment. One  
14 thing. I didn't say it was impossible. I simply said  
15 it was difficult. But there are significant  
16 differences in a number of the processes.

17           For example, the fuel fabricators, I think  
18 every single one of them uses a different conversion  
19 process for UF<sub>6</sub> to UO<sub>2</sub>. And so, therefore, the types  
20 of equipment that are used in them are just different.

21           It's not a question of one manufacturer or another.  
22 The equipment is just different.

23           MEMBER STETKAR: Yes.

24           MR. VAUGHAN: The other thing is this is a  
25 commercial industry that is competitive. And we don't

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 share some of the technical details that may be are  
2 shared in some other arenas for one reason or another.

3 And so it's possible if all of that information was  
4 shared, there would be some degree of similarity.

5 I mean within a particular company, you  
6 obviously have your favorite valves because you know  
7 which ones fail less frequently than others. You know  
8 which ones have the best maintenance history and  
9 things like that.

10 So within a particular company, within a  
11 particular process there is knowledge and, in fact,  
12 that is a lot of the knowledge that is used in the  
13 judgment when these teams do their HAZOPs and the  
14 what-ifs and different types of hazard identification  
15 and then begin to assign, you know, frequencies to  
16 failures.

17 So it's not like we don't use any of that.

18 It's just that it's not shared universally across the  
19 industry.

20 MEMBER STETKAR: Okay.

21 MR. VAUGHAN: Did that help?

22 MEMBER STETKAR: That does a bit, yes.

23 Thank you.

24 MR. VAUGHAN: Okay. So that was --

25 MEMBER RYAN: And we're going to have to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 wrap up at 3:15.

2 MR. VAUGHAN: Yes, there's one --

3 MEMBER RYAN: And I want to have an  
4 opportunity for members to ask you questions so if you  
5 would --

6 MR. VAUGHAN: One other little comment --

7 MEMBER RYAN: Please, yes.

8 MR. VAUGHAN: -- I wanted to make and that  
9 is we are particularly concerned about the thought of  
10 intermixing within these facilities the use of the ISA  
11 techniques and PRA techniques within the same  
12 environment. And suggest that we should try to avoid  
13 that if at all possible.

14 So those are the main points that I wanted  
15 to cover. And I'd be happy to entertain questions.

16 MEMBER RYAN: Great. Thank you. And  
17 again I make note for the record, we do have a letter  
18 signed by Janet Schlueter, who is here in the audience  
19 as well, dated February 8th, 2011, on your  
20 presentation. So thanks very much.

21 Are there any questions for Mr. Vaughan?  
22 And comments from members as we finish up?

23 MEMBER POWERS: Well, let me ask one  
24 question.

25 MEMBER RYAN: All right.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1                   MEMBER POWERS:     When you look at the  
2 results of an ISA and all that's gone before it, you  
3 have typically a list of IROFs.  And that list being,  
4 at least in one circumstance that I imagine is fairly  
5 extensive IROFs, a list of IROFs.  And those demand  
6 regulatory attention which means they demand attention  
7 from the owner/operator of the facility.

8                   When you use the results of the ISAs, do  
9 they tell you how to prioritize your attentions to  
10 those IROFs?  And if not, should not one look for some  
11 way to prioritize this attention?  Especially as the  
12 lists get very long?

13                  MR. VAUGHAN:     That's a very good point.  
14 And the way things work right this minute, basically  
15 all IROFs are treated equally in terms of attention.  
16 But yet we know from the hazards analysis that some of  
17 those IROFs are being used to prohibit things that  
18 have high consequences and some of those IROFs are  
19 being used to prohibit things that have medium  
20 consequences.

21                  But all IROFs basically get the same level  
22 of attention.  But there is information there to grade  
23 them if that was desired.

24                  MEMBER POWERS:    You could.

25                  MR. VAUGHAN:     But we have --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER BROWN: Dana?

2 MEMBER POWERS: But, certainly, Charlie,  
3 criticality -- IROFs, do they have anything to do with  
4 criticality in a fabrication facility, they have the  
5 top priority.

6 MR. VAUGHAN: Right, well critical IROFs  
7 that deal with criticality go in the high consequence  
8 category, right, wrong, or indifferent, that's where  
9 they go. But what I was saying is we know what IROFs  
10 are protecting against accident sequences that fall  
11 into the high consequence and which ones protect  
12 against medium consequence.

13 MEMBER BROWN: I have a question for you.  
14 No, go head, Charlie.

15 MR. VAUGHAN: No, I was just going to make  
16 the observation that when we did -- I'm trying to  
17 remember the ISG number -- I think it was seven in the  
18 application of digital systems to the IROFs, there was  
19 a discussion where you had redundant and non-  
20 redundant.

21 And whether one was you had to pay more  
22 attention and you did more of this and more of that to  
23 it. We actually made a comment in our letter that  
24 said -- it went backward in the ISG to say no, you  
25 can't -- and I've forgotten all the details -- it's been

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 a while since we did that.

2 But I was saying, in that conversation,  
3 they were not all treated the same as opposed to the  
4 statement that was just made. There was a  
5 consideration that some circumstances they would have  
6 less attention than others. So I don't know how extensive  
7 that is.

8 Mr. Vaughan's experience may be different  
9 than mine but I think there's one point that the HAZOP  
10 tends, at least in my own experience, to bias the  
11 analyst. If he sees something that has a high hazard  
12 or high operational consequence, that tends to focus  
13 more attention on it.

14 MEMBER POWERS: Do you see how one  
15 dimensional that all is? I mean what he just said is  
16 that when I do these things, I know which ones are  
17 protecting me against high consequence and which  
18 things are protecting me against mid consequences. In  
19 other words, he can prioritize based on consequences.  
20 And that's very one dimensional.

21 Because one would really like to protect  
22 against is based on risk, which means that the more  
23 vulnerable, the less reliable, times its consequences  
24 should be the metric. But you can't do that so easily  
25 this way, I think.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MEMBER RYAN: And the HAZOP part, while it  
2 is a little bit of a step toward ranking, it is biased  
3 by the observers.

4 MEMBER POWERS: Well, you can't get around  
5 that.

6 MEMBER RYAN: Let me point out also that  
7 within, if one has a facility that uses a PRA, that  
8 you will say oh, well, gee, I can do that ranking  
9 there because I can do all kinds of wonderful things.

10 And it is also not true because in a PRA, typically  
11 there might be 1,000 components. On the Q list, there  
12 might be 30,000 components.

13 And consequently, we pay attention to the  
14 29,000 of them based on the same kinds of judgmental  
15 sorts of things he's talking about with the ISA. And  
16 only a thousand of them could get this risk. So I  
17 mean it's not cut and dried.

18 MEMBER POWERS: I understand. Yes, no,  
19 it's not.

20 MR. VAUGHAN: Yes, let me say in addition  
21 to just knowing whether they're high consequence or  
22 intermediate consequence, most of the licensees, I  
23 think, have reported their information so they also  
24 understand frequency. So, you know, instead of just  
25 consequence, you could -- you do have the information

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701



1 there to be able to grade these IROFs rather  
2 significantly.

3 MEMBER POWERS: Yes. I mean I think  
4 you're absolutely right and you benefit because of  
5 memory and experience. And we see this a lot within  
6 the DOE complex that we have extremely experienced,  
7 long-term operators of hazardous facilities. They  
8 know everything about it. They can tell you the  
9 history of every bolt that went into the plant.

10 Unfortunately, those guys are going away.  
11 And the preservation of that experience is a problem.  
12 And even if it is documented, the retrieval of that  
13 information is not so easy. Not so easy.

14 MR. VAUGHAN: It's much more easy now in  
15 the digital world. If you're using some of the good  
16 software to record your hazards analysis and the  
17 balance of the ISA, you really have a lot of  
18 information there at your fingertips that is now  
19 recorded where it wasn't always recorded in the past.

20 MEMBER POWERS: Well, one of the things  
21 you quickly run into is that the evolution of software  
22 and the evolution of the recording media are not  
23 parallel.

24 (Laughter.)

25 MEMBER BANERJEE: Mr. Vaughan, I have a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 question for you, you know. Can I just comment on  
2 what Dana said because I think this is a very serious  
3 and interesting point. You can record where every  
4 bolt is and stuff. But you cannot record the  
5 expertise of the people. And I think that's really  
6 the problem.

7 Remember there was a guy called Arthur  
8 Bebbington who designed distillation columns. And  
9 DuPont sent five guys around with him, you know, to  
10 learn what he know when he retired. And they couldn't  
11 figure it out. That's the real problem.

12 MEMBER ARMIJO: Well, yes, I just wanted  
13 to expand a little bit on that on Dana's issue because  
14 I think it is important. And it's different than, you  
15 know, in the fact that these fuel cycle facilities,  
16 and I'm not talking about all of them because I don't  
17 know all of them but the fuel factories, during the  
18 period when there were no plant orders, you know,  
19 power plant, you know, we lost a lot of technical  
20 people from the industry.

21 And we wound up with this situation where  
22 we had a lot of older people retiring, new guys coming  
23 in. But that's never happened with the fuel cycle  
24 facilities. They've always had a business. They've  
25 always had products. So there is a continuity of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 personnel learning from the experienced people that we  
2 don't necessarily have in --

3 MEMBER BANERJEE: The chemical industry.

4 MEMBER ARMIJO: -- well, in nuclear power  
5 plants, you know new people.

6 MEMBER POWERS: But, Sam, we had this  
7 problem in chemical plants where the same situation  
8 exists. They have not had downturns and upturns of  
9 decade-long periods.

10 MEMBER ARMIJO: Yes.

11 MEMBER POWERS: And we still find that  
12 they experience base gets lost.

13 MEMBER RYAN: Said, you had a question?

14 CHAIRMAN ABDEL-KHALIK: You made a point  
15 that this is a highly competitive industry where a lot  
16 of things are not being shared. Does that represent  
17 an impediment to learning from operating experience at  
18 other competitor's facilities?

19 MR. VAUGHAN: To a degree, it does.  
20 However, in the last years where safety-significant  
21 things are involved, there has been a significant  
22 amount of sharing the fuel fabrication industry. But  
23 there is still a lot of protection of the technology  
24 and the techniques that are used within the plant.  
25 And so there is a line by which you really can't cross

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 over even though there is a significant amount of  
2 sharing of safety-related information and concerns  
3 now.

4 CHAIRMAN ABDEL-KHALIK: Thank you.

5 MEMBER SHACK: Just a question. You made  
6 a point that you didn't like the idea of mixing PRA  
7 and ISA. Is that a veiled hint that you didn't like  
8 the idea of the using of a PRA-like to determine risk  
9 in increments of findings?

10 MR. VAUGHAN: It would extend into that  
11 area.

12 MEMBER RYAN: Very good. Any other  
13 questions for Mr. Vaughan? Or Dennis?

14 (No response.)

15 MEMBER RYAN: Mr. Chairman, back to you.

16 CHAIRMAN ABDEL-KHALIK: Thank you.

17 At this time, we will take a break until  
18 3:35. We will reconvene at 3:35.

19 (Whereupon, the foregoing matter went off the record  
20 at 3:22 p.m. and went back on the record  
21 at 3:35 p.m.)

22 CHAIRMAN ABDEL-KHALIK: At this time,  
23 we'll move to the next item on the agenda --

24 MEMBER SHACK: I'm waiting for today to  
25 see -- he said he was misquoted.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN ABDEL-KHALIK: -- current state  
2 of licensee efforts to transition to NFPA-805, and  
3 John Stetkar will lead us through this.

4 MEMBER STETKAR: Thank you, Mr. Chairman.  
5 And in light of time, I've got a couple of  
6 introductory remarks here just to orient the other  
7 Committee members on where we are and what to expect  
8 here.

9 By way of reference, the reason -- we all  
10 know why the reason we're here. We are -- we have  
11 been tasked by the Commission, through an SRM dated  
12 June 25, 2010, to conduct a review and report back to  
13 the Commission on the current state of licensee  
14 efforts to transition to National Fire Protection  
15 Association Standard 805.

16 The review should include methodological  
17 and other issues that may be impeding the transition  
18 process, lessons learned from the pilot projects, and  
19 recommendations to address any issues identified.

20 To help us to develop this response, what  
21 we have accomplished so far is we have had two  
22 Subcommittee meetings -- a one-day meeting on  
23 November 16th that was a -- characterized it as a  
24 fact-finding mission, and a two-day Subcommittee  
25 meeting on December 13th and 14th where we tried to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 drill down into some more details of specific  
2 technical issues, and a little bit of discussion of  
3 programmatic issues.

4 In addition to those Subcommittee  
5 meetings, we also had input from a consultant to the  
6 Committee, Mardy Kazarians, who independently went out  
7 into the industry and talked to practitioners who are  
8 actually performing a lot of these studies to develop  
9 his own information base for feed-in in a forum that  
10 isn't quite the same as the public meetings that we  
11 have here.

12 And the only other thing I wanted to note  
13 is a couple of pieces of information about the  
14 schedule. The original SRM requested a report from  
15 the Committee by the end of February of this year.  
16 That deadline has since been extended until -- I don't  
17 have the right -- the date in front of me, but late  
18 May essentially.

19 Our current plans are we will not write a  
20 letter during this meeting. We will write a letter in  
21 March, and, because of the coordinating schedules, our  
22 internal schedules, external schedules, because we had  
23 published the date for the presentations. We will  
24 hear the presentations at this meeting. We will have  
25 a month to kind of collect our thoughts, and we will

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 write the letter next month. So the letter will be  
2 actually going in earlier than the extended SRM date,  
3 but not this --

4 MEMBER SHACK: That's the plan.

5 MEMBER STETKAR: That's the plan. I'm  
6 hoping that even if we don't -- anyway, that's the  
7 plan.

8 And with that, I don't know whether anyone  
9 on the staff wants to say anything.

10 MR. WEERAKKODY: Not at this time.

11 MEMBER STETKAR: We'll have a presentation  
12 from the staff. With that, I will turn it over to  
13 Biff Bradley of NEI.

14 MR. BRADLEY: Thank you, John. We  
15 appreciate the opportunity to brief the full Committee  
16 on this subject. I have with me Rick Wachowiak of  
17 EPRI and Doug True of ERIN, who are two of our key  
18 technical people, and they are going to be discussing  
19 the technical aspects of this presentation.

20 Basically, what we are going to do today  
21 is a slimmed down version of what we presented to the  
22 Subcommittee. We don't really have anything new, but  
23 for the benefit of those that weren't at the  
24 Subcommittee meeting, we wanted to go through our main  
25 points, and so I appreciate that opportunity.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1           It was pointed out to me today that we  
2 don't know how to spell NFPA, and I guess I have to  
3 take the hit for that.

4           (Laughter)

5           I guess a little dyslexia must have crept  
6 in somewhere, but I think -- anyway, let me move  
7 forward here and discuss -- I wanted to just give a  
8 little bit of the overall, you know, why we believe  
9 this is important, why the industry believes this is  
10 important from a regulator perspective, from the  
11 perspective of risk-informed regulation.

12           I know sometimes it seems like we're  
13 beating this horse beyond death on the need to get  
14 fire PRA to a more realistic level, but we do believe  
15 it's that important, and have a lot of work laid out  
16 that Rick will be talking about through EPRI. The  
17 industry has taken the initiative.

18           We've got the resources and the experts  
19 lined up to do a lot of work over the next several  
20 years to try to get fire PRA methods to a more  
21 realistic place. And we know it does require work,  
22 and we are willing and able to do that, and look  
23 forward to NRC staff involvement in that activity, so  
24 that we can all come out with more realistic methods  
25 to support both 805 and all of the uses of PRA.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1           Those of us that have been in the industry  
2 for a number of years know that fire protection is one  
3 of those things that keeps coming up, and I think  
4 there is a laudable goal of both the Commission and  
5 the industry to try to stabilize once and for all the  
6 expectations and the regulatory approach for fire  
7 protection.

8           So 50.48(c) is believed to be a way to do  
9 that, and we remain hopeful that ultimately it can do  
10 that. We have about -- over half the industry  
11 currently transitioning. We have had two pilot plants  
12 approved, and so it has been a pretty -- I think even  
13 the NRC would agree it has been a fairly arduous and  
14 maybe a little more challenging than we thought, but  
15 we are -- it is a major effort.

16           And I guess it was recently indicated it  
17 may be into 2020 to get approvals of the existing  
18 plants in the pipeline, so I think that speaks to the  
19 difficulties.

20           Obviously, fire PRA is a major piece of  
21 the transition to 805. There have been on the order  
22 of 50 fire PRAs developed to support 805, as well as a  
23 number of other non-805 fire PRAs under development.  
24 So it's safe to say that the vast majority of the  
25 industry is out there developing fire PRAs right now,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 and that is appropriate.

2 But we want to make sure that these PRAs  
3 are usable, not just for 805, but there are a lot of  
4 places we intend to use these models for other risk-  
5 informed applications, many of which are approved and  
6 ready for use, such as the tech spec applications for  
7 B(5)(b), 50.69, and some of these applications are  
8 actually comparing fire-initiated risk to other  
9 initiators. So we need to be careful that we are  
10 getting these things on as level a playing field as we  
11 can.

12 Everyone is aware that the NRC policy  
13 statement calls for realism in PRA to the extent  
14 practicable. This has been a little bit of a  
15 challenge for fire PRA -- a number of reasons for  
16 that. We don't have the 20-plus years of intensive  
17 development in regulatory use of PRA that we have had  
18 for internal events.

19 We have had some fire PRAs developed for  
20 the IPEEEs, but we really hadn't entered into an  
21 application where there was intensive regulatory  
22 application of a fire PRA. And I think that has been  
23 a learning experience for a lot of us.

24 There is an NRC-EPRI document, NUREG/CR-  
25 6850, EPRI-101-1989, that provides a fire PRA

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 methodology and approach. And that has been used,  
2 provided basically the framework for the fire PRA  
3 standard, and has also been the basic process that has  
4 been used to develop all of the PRAs that we are  
5 developing now for fire.

6 Early on, back in 2008, we started seeing  
7 some initial results from application of these  
8 methods, and it became clear to us that there was  
9 additional refinement needed to some of these methods,  
10 not unlike most of the other PRA methods we have  
11 developed over time. And we made these concerns known  
12 to NRC. We outlined the specific areas where we  
13 thought work was needed and requested their  
14 collaboration to help resolve these issues.

15 This resulted in over a two-year effort  
16 using a frequently asked question process that is  
17 under the auspices of NFPA-805 and Reg Guide 1205, to  
18 try to reach agreement on some of these methods.

19 This was a difficult process. I think  
20 there was -- there were some incremental results from  
21 this that did incrementally improve the fire PRA  
22 methods, but our believe on the industry side is that  
23 we -- that this process was not effective at really  
24 getting to truly -- getting us close enough to realism  
25 to be able to use these PRAs in the way we normally

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 have been using PRAs in applications.

2 And there was also issues of the  
3 timeliness and just the general difficulty of  
4 achieving consensus with the schedule pressures for  
5 805 and other things looming over everyone involved.  
6 So it was a difficult undertaking.

7 Back in the latter part of 2009, we  
8 essentially stopped submitting further inquiries into  
9 this process, or FAQs into this process, just for some  
10 of the reasons I mentioned. So we are searching now  
11 for a way to achieve a better process going forward.  
12 Obviously, NRC is going to be involved in these  
13 methods, but we hope to come up with a better way to  
14 do this going forward.

15 In December 2009, we sent a letter to the  
16 Commission. This was after some experience with the  
17 FAQ process, and still we had some lingering concerns  
18 with the lack of realism, so we did provide that  
19 letter to the Commission and attached to that letter  
20 the initial EPRI fire PRA action plan.

21 Since that time, we have substantially  
22 developed and fleshed out that plan, and it is a much  
23 more comprehensive plan now that Rick and Doug can  
24 speak to.

25 We are committed to, you know, doing the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 work to get these methods right, and we support the  
2 use of fire PRA and risk-informed decisionmaking for  
3 805 and everything else we're doing. And we are -- we  
4 hope that we can achieve that. I think our -- you  
5 know, our concern right now is that -- with the  
6 schedule we are on for 805, we don't -- we are not  
7 going to get these methods complete in the timeframe  
8 that these plants are having to submit applications.  
9 That's the --

10 MEMBER STETKAR: Can I interrupt you --

11 MR. BRADLEY: Yes, sure.

12 MEMBER STETKAR: -- for just a second  
13 here? I understand, you know, the timeliness of the  
14 FAQ resolutions, certainly for the two pilot plants,  
15 because in practice their efforts were the genesis of  
16 the FAQs.

17 And in practice, if you look at the pilot  
18 plant submittals, for the large -- for the most part,  
19 they did not take benefit of any of the FAQ  
20 resolutions or very, very limited benefit. And yet  
21 they made submittals, and the submittals indeed were  
22 approved by the staff for conversion to, you know, the  
23 risk-informed framework.

24 One would presume that, given at least  
25 even the nominal time delays for the in-progress

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 submittals, you know, that are currently scheduled for  
2 end of June of this year, they have at least had the  
3 time benefits to take advantage of a larger fraction,  
4 if not all of the available information, to reduce at  
5 least some level of conservatism in their studies,  
6 and, therefore, you know, in principle have at least a  
7 more realistic assessment, however you want to  
8 characterize it, for their submittals.

9           Could you speak to that, I mean, you know,  
10 so --

11           MR. BRADLEY: Sure.

12           MEMBER STETKAR: -- because the way you  
13 kind of presented it was more of an absolute that the  
14 FAQs were inadequate.

15           MR. BRADLEY: Nothing is absolute. I --  
16 one, I think the pilots did use the FAQs to a fair  
17 degree. There may have been a couple of facts that  
18 weren't incorporated for Harris and Oconee, but  
19 generally they did, as well as some additional methods  
20 improvements that may not have been reflected in the  
21 FAQs. But they had to be scrutinized and approved by  
22 NRC, which is something we don't necessarily want to  
23 replicate 50 more times.

24           MEMBER STETKAR: Sure. Sure.

25           MR. BRADLEY: The second part of your

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 question, I think, you know, the evidence we provided  
2 to the Subcommittee, which we are going to go over  
3 today, is based on PRAs that have incorporated all of  
4 the FAQs.

5 MEMBER STETKAR: Okay.

6 MR. BRADLEY: And we are still seeing the  
7 results that we are going to present post-FAQ  
8 incorporation. I agree there has been some progress  
9 there. I think the question is: how do we keep that  
10 going and get all of the way to where we need to be?

11 MEMBER STETKAR: Okay, good. Thanks.

12 MR. BRADLEY: Okay? So I'm just going to  
13 mention that Doug and Rick here are going to go over  
14 this technically in more detail. We did have the  
15 opportunity to look at a number of fire PRAs that have  
16 been developed for 805, and based on those complete  
17 models, we provided some evidence to the Subcommittee  
18 looking at some of the intermediate PRA results.

19 We weren't trying to look at CDF,  
20 obviously, because of the very low numbers. But  
21 looking at things such as high conditional core damage  
22 probability, number of spurious operations, number of  
23 large challenging fires, things of that nature, and  
24 comparing those to what we have seen in the 3,000  
25 reactor-years of operating experience. So Doug will

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 be speaking to that momentarily, and the technical  
2 basis for our belief that we still haven't achieved a  
3 reasonable level of realism.

4 From a regulatory perspective, there is  
5 really nothing different about fire or 805 or fire  
6 PRAs. It is really no different from any other  
7 regulatory application of PRA. We have been using PRA  
8 to make risk-informed decisions and risk-informed  
9 applications.

10 Generally, these involve some change from  
11 the original deterministic licensing basis. That is  
12 what we use risk-informed to do. There is guidance in  
13 1174 that discusses how we accommodate defense-in-  
14 depth safety margins and the general concept of  
15 conservatism into this process. And we believe those  
16 elements of 1174 are appropriate to do that.

17 Our concern is that it -- in some cases it  
18 appears here we are trying to address the issue of  
19 conservatism directly in the PRA model versus relying  
20 on those other elements of 1174. And we are concerned  
21 that that is a little different road than we have been  
22 down in the applications we have done to date, given  
23 that we did have more experience with internal events  
24 before we started doing major applications.

25 But whether it's an artifact of the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 schedule or the level of development or what, the fact  
2 is that we are entering into a very large risk  
3 application with some level of I believe conservatism  
4 that is in the models that is still subject to being  
5 improved through methods development.

6 And this could lead to inappropriate  
7 decisionmaking. You know, it's hard to predict that.

8 But it's certainly something that concerns us.

9 So going forward, we believe it's really  
10 important to establish an improved process on the  
11 regulatory interaction. I expect the staff will speak  
12 to this, and I think we have seen indications of  
13 understanding and acceptance of the need to come up  
14 with a good process to work together to get these  
15 methods to a better place.

16 And this is just referring back to some  
17 previous letters we had a couple of years ago, and  
18 maybe things are a little different now. But NRC did  
19 state in writing that, you know, we need to have a  
20 balance of conservatism and realism in the PRA. And,  
21 to me at least, that was a new regulatory concept in  
22 light of the other things we have done.

23 This is now 2011. Maybe we are moving  
24 more in the direction of realism, and maybe the NRC  
25 staff can speak to that. But that's just what they

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 stated in 2009.

2 Okay. So we provided a report -- a  
3 technical report to ACRS. We also provided the  
4 support to NRC staff, and Doug and Rick are going to  
5 be overviewing that report for the full Committee here  
6 today. That report was intended to point us in the  
7 direction of what areas of methods improvements are  
8 important, what our priorities should be, where our  
9 resources should go, as we seek to improve these  
10 methods.

11 So we wanted to use these insights,  
12 understand what the PRAs we've done to date have  
13 indicated, where they seem to be diverging from  
14 operational experience, and how do we -- what work do  
15 we need to do to address that?

16 So that's what Doug and Rick are going to  
17 be speaking to, and I think that's probably the area  
18 of this presentation that will be of the most interest  
19 to the Committee. So unless you have any questions  
20 for me, I want to go ahead and turn it over to our  
21 technical folks here.

22 VICE CHAIRMAN ARMIJO: I have a  
23 clarification. These bounding assumptions and  
24 simplifications, are those -- the staff decides what  
25 these are, and you have to apply them, and that's the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 problem?

2 MR. BRADLEY: It's not --

3 VICE CHAIRMAN ARMIJO: I'm trying to find  
4 out exactly what the problem is, or at least --

5 MR. BRADLEY: Right.

6 VICE CHAIRMAN ARMIJO: -- the major one.  
7 If you could expand on that, I would appreciate it.

8 MR. BRADLEY: Okay, yes. NUREG/CR-  
9 6850/EPRI-101-1989 provides a level of detail that  
10 goes beyond the PRA standard as endorsed in Reg  
11 Guide 1.200, Rev 2. Our expectation was that if you  
12 did fire PRA, had a peer review done, and met 1.200  
13 through that process, that that was sufficient.

14 What we found in actuality in going into  
15 805 is that, in addition to the full expectation to  
16 comply with 1.200, and have the peer review, there is  
17 an additional layering on of expectations relative to  
18 the methods that are in the NUREG, the EPRI  
19 report/NUREG.

20 And we have learned from experience that  
21 these methods need some improvements, and there has  
22 been, for the pilot plants at least, expectations if  
23 they explain any deviations from these methods, even  
24 though they may have met one, two, three, Rev 2. So  
25 this -- I wouldn't say this is directly imposed, but

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 it is certainly a different level of expectation on  
2 methods than what we have seen before.

3 And if you use a method that is different  
4 from 6850 or the facts, there will be questions about  
5 it. You are going to have to justify it. I won't say  
6 the staff just unilaterally imposes it, but they do  
7 make it more difficult to --

8 VICE CHAIRMAN ARMIJO: That's their  
9 expectation --

10 MR. BRADLEY: Right.

11 VICE CHAIRMAN ARMIJO: -- that you will --

12 MR. BRADLEY: Right.

13 VICE CHAIRMAN ARMIJO: -- use that.

14 MR. BRADLEY: And they should really speak  
15 to this, you know, let --

16 VICE CHAIRMAN ARMIJO: Okay.

17 MR. BRADLEY: -- let them say it as they  
18 would say it.

19 MR. HARRISON: This is Donnie Harrison  
20 from the NRC staff. I will just point out that the  
21 position of the staff is that if you are using a  
22 method that is different than what is in the 6850  
23 consensus guidance, that you have a technical basis  
24 for the use of that method.

25 And so you should be able to justify why

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 it is a technically correct method to be applied. And  
2 to get that information, we'd probably have to ask an  
3 RAI.

4 VICE CHAIRMAN ARMIJO: Okay. I'll just --  
5 I'll wait.

6 MR. TRUE: Okay. I'm Doug True from ERIN  
7 Engineering. And I'm going to walk through some of  
8 the technical contents, and then Rick is going to take  
9 over and talk through the more research program part  
10 of the report. This report -- I wanted to preface  
11 with this is not an one individual's report.

12 In fact, the fire PRA task force at NEI  
13 chairs -- played an active role in helping identify  
14 issues, providing data that we used in compiling  
15 information in the report. And so it's really a  
16 compilation of work that was done by a lot of  
17 different people. I have become sort of the  
18 spokesperson for it, but it is actually -- a lot of  
19 different people's work went into it.

20 The fire PRA calculation, if we try to  
21 boil it down to just the simplest form of what we try  
22 and do is we -- we try to characterize some frequency  
23 of a fire, and we associate with that fire some  
24 severity characteristics, usually as a function of  
25 time, that a fire will grow to a certain size over a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 certain length of time.

2 We will account for some probability of  
3 suppressing that fire event over time, whether you  
4 have an automatic suppression system or you have a  
5 manual brigade response to that fire. And then, we  
6 take -- for the consequence of that damage condition,  
7 and we attach it to our PRA, and we calculate a  
8 conditional probability of core damage given that fire  
9 damage condition.

10 And so you can think of it sort of as a  
11 function of each of those elements goes into our  
12 overall calculation. There are many dimensions to it,  
13 and we spent several days talking through many of the  
14 details of those previously, and I'm not going to drag  
15 you through that again.

16 The thing that -- what we found in going  
17 back and trying to unravel what we're seeing coming  
18 out of these fire PRAs is that we have conservatism in  
19 almost every step of this.

20 And so while it would have been really  
21 convenient if we could have just said, "Oh, you know,  
22 the frequencies are too high, or the severities are  
23 too high," we found that it actually kind of tends to  
24 show up and there's a little bit of synergy between  
25 each of those elements that actually compounds the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 effect of these conservatisms, because the -- for  
2 saying we have a fire frequency and we are overstating  
3 its severity and how rapidly that severity builds,  
4 those combine to give us this frequency of a very  
5 severe fire happening very fast, which then minimizes  
6 the likelihood of being able to suppress it, and which  
7 minimizes -- which creates an overstated emphasis on  
8 the damage, which gives us a higher additional core  
9 damage probability.

10 So they all kind of tie together, and it's  
11 really hard to unravel and break it into any one place  
12 so we can tackle it. And so that was our first  
13 challenge was to -- how do we get this all unraveled  
14 and understand what's going on?

15 The conclusion from the analysts who have  
16 been doing these studies is that there is not any one  
17 single factor that we think we can focus on. And, in  
18 fact, as you will see in the -- in Rick's  
19 presentation, there's a whole bunch of things we think  
20 need to be tackled, not that they all have equal  
21 priority. There certainly are some that are more  
22 significant, and there are certainly some that can be  
23 done in a more timely manner.

24 But it is not just one thing we can point  
25 to to say that this is -- this is what's driving us to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the results which we think don't reflect operating  
2 experience.

3 And then, the last thing is that you find  
4 when you go from plant to plant to plant, the thing  
5 that is driving each plant to slightly different --  
6 because this is a very spatial problem, and all of  
7 these plants have different designs and different  
8 orientations, different system capabilities, and that  
9 makes drawing broad conclusions very challenging.

10 MEMBER STETKAR: When you talk about  
11 conservatism, when I think of numerical conservatism,  
12 there can be a couple of connotations that that word  
13 might apply. One is that if I have one estimate that  
14 is, let's say,  $10^{-3}$  -- I'm not going to put units --  
15  $10^{-3}$  plus or minus a factor of five versus  $10^{-2}$  plus or  
16 minus a factor of five.

17 Those are clearly different values,  
18 because we have essentially the same confidence in  
19 those values, and it is clear that one is an order of  
20 magnitude higher than the other.

21 On the other hand, if I have very, very  
22 broad uncertainty, I might have a mean value of  $10^{-2}$ ,  
23 but it could be plus or minus a factor of 100. And  
24 it's not -- that's a different notion of conservatism  
25 compared to the first case. Is there any way you can

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 speak to that? Because the notion of the influence of  
2 uncertainty on a particular numerical value I think is  
3 important to kind of understand in this.

4 In the one case, collecting more  
5 information really won't help you -- the first one --  
6 because the uncertainties are rather narrow, and it  
7 just -- it is just apparent that if you're using the  
8  $10^{-2}$ , and you ought to be using the  $10^{-3}$ , it's just  
9 clear you are using the wrong data, if you will.

10 In the second case, in the sense of  
11 collecting more information, if that information is  
12 available, one, in principle, depending on the shape  
13 of the distribution, ought to be able to improve your  
14 state of knowledge, reduce the uncertainties, and,  
15 therefore, have more realism, a better estimate of  
16 that mean value.

17 That's -- could you speak to that a bit?

18 MR. TRUE: I can speak to it. I'm  
19 probably going to give you a somewhat unsatisfying  
20 answer, because I think it depends a little bit on  
21 which dimension of this we're looking at.

22 MEMBER STETKAR: Okay.

23 MR. TRUE: I mean, certainly, data on how  
24 often fires happen, we have a reasonable amount of  
25 data for many of those fire events. So collecting

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 more data isn't really an issue.

2           Some of the others related to the severity  
3 and the growth rate are certainly issues where there  
4 is a great deal of uncertainty, and the authors of  
5 6850, from the industry and the NRC, I think, you  
6 know, made a reasonable first attempt to try and  
7 characterize that in a certain way, but -- and the  
8 uncertainties are large there.

9           There could be some benefit in gathering  
10 additional data, but, as we talked about in previous  
11 discussions, it is very hard to do a test of a  
12 realistic fire. It's a lot easier to do a test of a  
13 bounding fire, and so everything you are anchoring to  
14 is not really what you are trying to characterize in a  
15 PRA. So it is a challenging area.

16           I think I want to go back a little bit to  
17 the question about simplifications and bounding,  
18 because some of this is that we think that the  
19 simplifications -- for example, electrical cabinets,  
20 we spent a great deal of time talking about electrical  
21 cabinets. It is a pretty simplified approach to  
22 characterizing electrical cabinet fire severities and  
23 growth rates.

24           And we think that while there may be  
25 certain cabinets under certain conditions that could

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 have those kind of characteristics, it probably isn't  
2 reflective of the vast majority of the cabinets and  
3 the different characteristics that exist in those  
4 cabinets.

5 So we simplified it, made it easy, to have  
6 a cookbook to be able to go and calculate things from,  
7 but those simplifications were skewed by certain  
8 anchor points that don't really reflect some of the  
9 conditions that we think exist.

10 And that's one of the things that EPRI is  
11 working hard on, particularly with respect to  
12 electrical cabinets, is to try and unravel that  
13 simplification and turn it into a more diverse set, a  
14 more reflective set, of inputs that more closely match  
15 what we think is really out there in the plants, and  
16 the way the plants would behave.

17 So that's another way that conservatism  
18 gets brought in. If we put everything together, we  
19 have to bound kind of that condition to make sure we  
20 are not understating risk. So I think that is another  
21 dimension in this.

22 One other thing I should say probably at  
23 this point, because I have taken some, you know, what  
24 might be considered shots at 6850. I think that the  
25 original authors did a good job of compiling together

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 a lot of really good information into a very good  
2 framework.

3 I think it moved the state of practice  
4 forward considerably, but in their defense, in light  
5 of some of these criticisms, it was never tested  
6 completely. And so they didn't know what the  
7 ramifications of it being a little bit conservative  
8 here and a little bit conservative there, and when you  
9 combine all of that together, the answer doesn't come  
10 out to match it. They didn't have that opportunity.

11 I think they did a great job of trying to  
12 put this together. It was just untested until these  
13 first few NFPA-805 plants got through the process and  
14 got to the end and said, "Egads, this doesn't seem to  
15 be adding up."

16 So this is not a hindsight is 20/20 thing.  
17 It is just -- that was the situation they had. They  
18 couldn't have fully known the ramifications of that --  
19 of these assumptions.

20 MEMBER STETKAR: They were -- back when  
21 they were developing that, there was an intent at that  
22 time, back in the -- whenever it was -- 2003, '04, '05  
23 timeframe to actually do, you know, a pilot -- an  
24 integrated pilot of the whole process. It just never  
25 came to fruition.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MR. TRUE: Yes. What ended up happening  
2 was the industry was distracted. I mean, you have to  
3 have a plan, so you have to have a place to actually  
4 go apply it and go through the process. And I think  
5 the industry was a little bit distracted at the time.

6 Fire PRA wasn't really on the forefront of  
7 everything, and then we had this fire protection issue  
8 that got raised, and 805 got brought up as a solution,  
9 and then, oh, there's this EPRI NUREG document we can  
10 use to solve this problem, and all of a sudden we're  
11 off and running.

12 And it was just -- it was sort of an  
13 unfortunate, in my opinion, confluence of some events  
14 that rushed it into use a little bit before it had  
15 been fully tested.

16 And so that's a little bit off topic, but  
17 I think a fair perspective of sort of how we got here.

18 So one of the things that we wanted to  
19 look at was, how do we compare the fire PRA results  
20 we're getting out of these studies to operating  
21 experience? And, as Biff said, you can't do it on the  
22 basis of core damage events, because, thankfully, we  
23 don't have enough core damage events from fires to  
24 base it on.

25 We had the one, you know, significant

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 event at Browns Ferry that was a close call, and, in  
2 fact, involved some significant spurious operations in  
3 that plant in that fire. But we have done an awful  
4 lot to try and respond to that -- also, that fire --  
5 in improving our fire protection programs.

6 And so one of the things we looked at was  
7 spurious ops. It's the main -- major focus of NFPA-  
8 805 and the new fire protection evaluations, whether  
9 you're falling 50.48(c) or the other path. And we  
10 realized that fire PRAs give us the ability to -- if  
11 you interrogate them properly, you can go in and  
12 actually calculate, "Well, how likely does the fire  
13 PRA say these spurious operations are? How likely  
14 will we expect it to be that we would have a fire that  
15 involved one or more spurious operations?"

16 And so we took a sampling of a few PRAs,  
17 went in and tried to figure out that interim state  
18 that is short of core damage, short of CCDP, but it is  
19 a condition where some spurious ops were predicted to  
20 have occurred.

21 And the way we did that was we pretty much  
22 went into the PRA, looked at each of the scenarios to  
23 see if it triggered a spurious op flag in the model,  
24 and those -- and then summed up those frequencies of  
25 all of those scenarios across the PRA.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1           MEMBER STETKAR: Before you get into the  
2 math here, because the math is going to be important  
3 -- I'm not going to interrupt you as you walk through  
4 the thought process -- oftentimes I need to get myself  
5 calibrated when you use the term "a PRA." Given the  
6 fact that the fire risk models are developed in a  
7 sequential or a hierarchical --

8           MR. TRUE: Iterative.

9           MEMBER STETKAR: -- iterative -- okay,  
10 iterative is a phrase also, in the sense that very  
11 often you insert -- you develop simplified,  
12 conservative models as a sort of screening process to  
13 focus you down successively to determine the locations  
14 or the scenarios that you really need to refine more.

15           In that context, you are going to start  
16 presenting results here from fire PRAs. And I think  
17 it's important for the Committee to understand at what  
18 level of refinement or sophistication, at least in  
19 your perspective because you are familiar with the  
20 studies --

21           MR. TRUE: Right.

22           MEMBER STETKAR: -- in that sort of  
23 iterative process or successive refinement process, if  
24 you will, where are these studies? I mean, how far  
25 have they progressed? Are they just after the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 beginning, or are they, you know, ready to go public?

2 MR. TRUE: No. These were all -- you'll  
3 notice if you inspect the study, I use Plant X,  
4 Plant Y, Plant A, B, C, 1, 2, 3, was all to --

5 MEMBER STETKAR: We don't need to know the  
6 plants.

7 MR. TRUE: -- protect the names of the  
8 innocent. So there's a spectrum of plants. There's  
9 actually a little bit of overlap between A, B, C, D,  
10 and 1, 2, 3, 4, 5, I think, and -- but we tried to use  
11 studies that were well down that road.

12 MEMBER STETKAR: Okay.

13 MR. TRUE: And in some cases, some of the  
14 studies cited are actually the pilots also. So those  
15 are very well down the road. And so, yes, we wanted  
16 to do a fair assessment of if we actually implement  
17 these methods, what are we -- what is the answer going  
18 to look like, and we didn't want to, you know, cook  
19 the books and use some, you know, quick and dirty  
20 thing that was the wrong way.

21 These are well developed. I wouldn't say  
22 they are necessarily the exact one that was -- will be  
23 submitted as part of the 805 submittal, but they were  
24 well down the road, so that we --

25 MEMBER STETKAR: It's just important

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701



1 for --

2 MR. TRUE: -- follow some reasonable  
3 representation.

4 MEMBER STETKAR: Yes, a general context,  
5 because you are going to be using numerical examples  
6 to demonstrate conservatism.

7 MR. TRUE: The other thing is that we --  
8 like I said, we had a couple of the pilot results in  
9 here, we had -- we had results from several different  
10 vendors who are different vendors that supported  
11 different utilities. And, in fact, at the first  
12 meeting we had Jim Chapman come, who is from  
13 ScienTech, who between ERIN and ScienTech we have done  
14 the majority of the support for the industry in this  
15 area.

16 And we have tried to make sure we weren't  
17 just using one company's bias for something to  
18 represent this. It was intended to be representative  
19 of a reasonably well completed fire PRA. So thanks  
20 for --

21 MEMBER STETKAR: That -- no --

22 MR. TRUE: -- bring it up.

23 MEMBER STETKAR: It's important,  
24 because --

25 MR. TRUE: It is important.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: -- two or three of us  
2 have heard this story, but --

3 MR. TRUE: Yes.

4 MEMBER STETKAR: -- most of us haven't.

5 MR. TRUE: So in this case what we did was  
6 we went into a couple of those PRAs, and we summed up  
7 the frequency of scenarios that would have been  
8 predicted to cause one or more spurious operations.  
9 In many cases, the fire -- significant fire could  
10 cause more than one spurious op. We just decided to  
11 lump them all together and say, "Just any one that  
12 causes one or more we will count them the same."

13 And for the two plants we looked at, the  
14 results came out around four times  $10^{-3}$ . And if you  
15 take that and extrapolate it across the 100 plants in  
16 the industry, I would say that, you know, every couple  
17 of years -- two, three, four years, something like  
18 that, we would expect to maybe see a fire that has  
19 spurious ops occurring.

20 And we don't see that in the operating  
21 experience. There are anecdotal things here and there  
22 where certain things might have happened, cable  
23 failures in particular have happened, but actual  
24 spurious op, which is a shorting of either within a  
25 cable or between cables to spuriously cause something

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 to change state, we are just not seeing that kind of a  
2 rate across the industry.

3 So we think that is an indication that we  
4 have -- we are overstating the severity of the damage,  
5 and, therefore, the spurious operation rate.

6 MEMBER POWERS: Is it assured that you  
7 would get accurate reporting? I mean, if it's a  
8 spurious operation in a non-safety system, would it be  
9 reported?

10 MR. TRUE: Well, yes, these are -- these  
11 are spurious ops we're predicting in -- in safe  
12 shutdown equipment primarily. So I think it --

13 MEMBER POWERS: So you are counting things  
14 about --

15 MR. TRUE: -- would be pretty accurate.

16 MEMBER POWERS: -- correctly, then.

17 MR. TRUE: I mean, certainly we can be off  
18 a little bit, but --

19 MEMBER POWERS: In factors of two, five.

20 MR. TRUE: Yes.

21 MEMBER POWERS: But they don't mean  
22 anything here.

23 MR. TRUE: I think we are -- we are seeing  
24 a pretty good-sized gap here, and, you know, there was  
25 some discussion in the second meeting I guess about

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 some events that had had things happen. But even  
2 those events weren't the kind of things we are  
3 predicting here, that -- where safe shutdown  
4 equipment, the valve -- when the systems closes it, we  
5 need it to be open, that kind of thing. We have just  
6 not seen that happen.

7 MEMBER BLEY: I might be wrong. I thought  
8 the reporting requirements now -- maybe staff can help  
9 me on this -- were such that you have to effect both  
10 trains of a safety system before it has to be  
11 reported. I'm not sure about fires. So I'm not -- I  
12 wonder if you're right about these needing to be  
13 reported or you're having a pretty good case. Can  
14 anybody clarify that?

15 MR. KLEIN: This is Alex Klein. I'm the  
16 NRR Fire Protection Branch Chief. In terms of  
17 reporting requirements, it's not necessarily based on  
18 the consequences. It's based upon the time of the  
19 fire. So licensees report fires that last more than  
20 10 minutes.

21 MEMBER BLEY: Okay. So all fires lasting  
22 more than 10 minutes are reported.

23 MR. KLEIN: That's one criterion.

24 MEMBER BLEY: That probably has to  
25 happen --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MEMBER SIEBER: Regardless of size or  
2 location?

3 MR. TRUE: Yes, just duration.

4 MEMBER SIEBER: That's --

5 MR. TRUE: For an LER report.

6 MEMBER SIEBER: That's probably one of the  
7 distortions in the whole process is the reporting of  
8 fires, because there aren't very many fires that  
9 actually have safety-related consequences. They don't  
10 occur at that frequency that -- to my knowledge. That  
11 would be the first thing I would look at.

12 MR. TRUE: Yes. We also have a fire  
13 events database that includes many other events beyond  
14 the LER reporting. So from a regulatory reporting  
15 process, I think that 10-minute rule is true, but the  
16 other events that we have access to through the EPRI  
17 data collection stuff haven't borne that out.

18 MEMBER BLEY: I'm trying to remember. Jim  
19 Chapman or Pat Baranowsky or you guys, one of you were  
20 talking about you are actually going back to all of  
21 the utilities and collecting additional --

22 MR. TRUE: Yes.

23 MEMBER BLEY: -- data.

24 MR. TRUE: That's one of the things Rick  
25 will talk about later.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER BLEY: Okay.

2 MR. WACHOWIAK: That's our highest  
3 priority activity.

4 MR. TRUE: I should probably get going  
5 here.

6 MEMBER STETKAR: We're good on time. I'll  
7 hustle you along.

8 MR. TRUE: All right. So another thing we  
9 looked at was the consequences of the fire and its  
10 effect on mitigating equipment. And we were -- in  
11 particular thought we'd look at the conditional core  
12 damage probability.

13 The way that the fire PRA calculation is  
14 done is there is sort of two pieces to it. There is  
15 one as the frequency of the scenario and the damage it  
16 causes, and then we hook that onto our PRA and we  
17 calculate, well, given that damage, what's the  
18 conditional core damage probability that results? So  
19 it's a nice, simple break point.

20 And we can look at for each scenario what  
21 its conditional core damage probability is. In a  
22 typical PRA today, there would be many hundreds, maybe  
23 a thousand, of these scenarios that would be present  
24 in the PRA. CCDPs are also used routinely in the  
25 accident sequence frequency program that NRC research

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 does and the reactor oversight process, so it's a  
2 common metric we are all used to looking at.

3 And so what we did was we wanted to go  
4 back and look at some fire PRAs to see what the  
5 predicted frequency of fires were that involved these  
6 relatively higher conditional core damage  
7 probabilities.

8 We started looking at the -- what the  
9 Accident Sequence Precursor Program told us about  
10 these events. This is actual events that have  
11 occurred in the industry. Research culls through  
12 those, looks for the ones that appear to have effects  
13 on plant safety, and they go into each one of those  
14 events and use a SPAR model to calculate CCDP. And  
15 there is an iteration with the utilities to figure  
16 out, you know, does that really reflect what the  
17 utility thinks their PRA would say?

18 And they come up with a representative  
19 estimate of the CCDP for each of those events. And  
20 this is everything from, you know, a loss of offsite  
21 power event to a flood event to a fire or anything  
22 else. So it's all -- it's indiscriminate on which  
23 kind of events go into this.

24 They have a category they call significant  
25 precursors, and then -- that they have a list of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 actual events that -- for example, the Browns Ferry  
2 fires on there, Davis-Besse head is on there, and  
3 there's a lot of events you would be very familiar  
4 with on that list. And then, there's a trending done  
5 of the high CCDP events, which are those greater than  
6  $10^{-4}$ .

7           There hasn't been a significant precursor  
8 since Davis-Besse head, and there have been a total of  
9 34 in the history of the industry. Only one of those  
10 involved a fire, and that was the Browns Ferry fire  
11 back in 1975. So that's significant over the  $10^{-3}$   
12 CCDPs.

13           So in this case we looked at five  
14 different PRAs, and we went in and just basically  
15 sorted the scenarios based on CCDP, and then summed up  
16 cumulatively the frequency of each bin's worth of  
17 scenarios. And so for the middle column there, the  
18 significant greater than -- CCDPs greater than  $10^{-3}$ ,  
19 we found that there was -- you know, it ranged from  
20 about one times  $10^{-3}$  up to  $10^{-2}$ , by an order of  
21 magnitude range on that, but a pretty well behaved  
22 distribution actually of results.

23           On the right-hand column, there we  
24 actually have a pretty tight grouping of somewhere  
25 between one times  $10^{-3}$  and three times -- one times

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 10<sup>-2</sup> and three times 10<sup>-2</sup> frequency came out of these  
2 studies. So that would say on an industry basis we  
3 should be seeing these significant precursor events  
4 every one to 10 years, every handful of years if you  
5 will, whereas on the 10<sup>-4</sup> CCDP event we should see one  
6 or more or a handful per year showing up.

7 MEMBER BROWN: For the uneducated like me,  
8 the previous page you said there are no significant  
9 precursor events since 2002.

10 MR. TRUE: Right.

11 MEMBER BROWN: And of all the 34  
12 significant precursor events, only one involved a  
13 fire --

14 MR. TRUE: Right.

15 MEMBER BROWN: -- yet you develop all of  
16 these statistics for fire PRA from no data. I mean,  
17 that's what I drew out of -- I'm not sure whether I  
18 stated that right or not, but that's what -- that's  
19 the message I got. You've had one involving a fire,  
20 and yet you've got --

21 MR. TRUE: We would predict that we would  
22 have lots. That's the basic message.

23 MEMBER BROWN: Oh, that's the point.

24 MR. TRUE: Yes.

25 MEMBER BROWN: Oh, okay.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. TRUE: So we are predicting that we  
2 should be seeing one every handful of years or a  
3 handful per year, and in actuality we haven't seen  
4 that -- anything like that in the operating  
5 experience.

6 MEMBER BROWN: Yes, okay.

7 MR. TRUE: And then, this is just an  
8 excerpt from the most recent SECY-2010 on the -- the  
9 frequency of these events in the industry are a total  
10 of eight since 2001. None of them involved fires,  
11 whereas that previous chart would have said we should  
12 have seen, you know, 10-ish, 15, 20, 30-ish, across  
13 the industry, and we're not seeing that.

14 MEMBER SIEBER: Fifteen, yes.

15 MR. TRUE: Yes. So we think that the  
16 predictions that we're getting out of these methods  
17 are not really lining up with our operating  
18 experience. That's sort of our plan from the  
19 beginning.

20 MEMBER SIEBER: How safe you are.

21 MR. TRUE: Yes, we actually are versus how  
22 safe we predict we are.

23 So the ROP is another place where we look  
24 at CCDPs, and that is done based on actual plant  
25 conditions that would include events as well as any

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 other non-conformance. And those range anywhere from  
2  $10^{-6}$  all the way up to  $10^{-4}$ , and in the ROP process,  
3 since it was implemented 10 years or so ago, we  
4 haven't had any factual fire events that even got  
5 above a CCDP of  $10^{-5}$ . So now we've gone another order  
6 of magnitude lower than the ASP considers, and we  
7 still don't see any actual fire events that are  
8 getting us CCDPs in that range. And we would have  
9 predicted, you know, even more than that, how many  
10 each year occurring from the fire PRA methods.

11 So we think there is a disconnect between  
12 what we are calculating and what we are observing, and  
13 it is a pretty sizeable disconnect. And that occurred  
14 both on -- whichever one of these metrics we wanted to  
15 look at, whether it was spurious ops or CCDPs. And  
16 that ends up, we think, in an overprediction of the  
17 computed fire core damage frequencies.

18 So the conclusions out of the technical  
19 portion of the road map that lead into Rick's plan for  
20 what we are going to try and do about this is that we  
21 think we don't conform with the operating experience.

22 We've got an overprediction in the number of severe  
23 fires that are causing significant damage.

24 One of the specific technical details is  
25 we think that the fire growth rate and severity is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 overstated in the way that oil fires and electrical  
2 cabinet fires in particular are covered, and the  
3 methodology is leading to this calculation.

4 We spent a lot of time in the Subcommittee  
5 meetings talking about those two topics. And another  
6 thing which we don't have a good way of accounting for  
7 in the current methods is that sometimes when you  
8 have, for example, an oil fire that is burning, the  
9 response might be to control that and let it burn out.

10 As long as it's not causing any damage to  
11 the equipment around it, they will let it burn. But  
12 it is being characterized as a more significant fire  
13 than that, even though it's under control. And that's  
14 a nuance that's in part of EPRI's research in the long  
15 term.

16 The result of this is that since we don't  
17 conform with -- we don't see intermediate states  
18 conforming with our operating experience, we think  
19 that the CDFs and interim solutions of the fire PRA  
20 are overstating the frequency of these severe fires,  
21 and we don't have any operating experience that  
22 supports that. And in spurious ops, which we're  
23 spending a lot of time and effort trying to chase,  
24 it's not lining up with our operating experience  
25 either.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1           Finally, when it gets to decisionmaking,  
2           our concern is that if you have an uneven level of  
3           conservatism, and it's very -- it's almost impossible  
4           to have an even level of conservatism -- that you can  
5           mask risk insights, and that that can make  
6           decisionmaking very difficult, and that some of these  
7           simplifications and groupings of bounding treatments  
8           of different bins of different fire types are going to  
9           make it hard to know exactly what is really -- what  
10          really are the risk drivers.

11           Another thing which we go into some detail  
12          in an example in the report on is that just -- by  
13          overstating fire damage you can actually end up  
14          understating a delta risk calculation, and that's  
15          challenging because we have -- it's okay to -- it may  
16          be okay to have an overstated base risk, but when  
17          you're trying to judge the importance of a change to  
18          the plant, whether it's a design change or it's a --  
19          taking equipment in and out of service for an  
20          application, we'd like to believe that that is  
21          representative, and we can show how you can  
22          underestimate that risk difference.

23           And then, we have some other aspects of  
24          the methodology, the way that plant trips are handled  
25          and the way administrative controls are credited that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 we spent some time talking with the Subcommittee about  
2 areas that we think are -- where we think those would  
3 help us improve the methods. So --

4 MEMBER STETKAR: In terms of timing, we  
5 are scheduled through 6:00. And we will probably take  
6 that. I'd like to leave the staff about 45 minutes,  
7 and maybe 15 minutes more, so in a sense we've got  
8 about half an hour more --

9 MR. TRUE: Right.

10 MEMBER STETKAR: -- for you folks.

11 MR. TRUE: Right.

12 MEMBER STETKAR: If I could, only because  
13 it got so much attention and I think it's really neat,  
14 and I know you have a backup slide for it --

15 (Laughter)

16 You know what's coming. Just put it up  
17 there and show the rest of the Committee something  
18 that they haven't seen. Well, go backward one. There  
19 you go.

20 MR. TRUE: John's favorite shirt.

21 MEMBER STETKAR: I love this. This is  
22 important, because it not only shows you -- you know,  
23 Doug has talked about overall conservatism, but this  
24 is a lot more information on this.

25 MR. TRUE: Yes. So, you know, it's one

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 thing to calculate spurious op frequencies and CCDPs  
2 and total CDFs. It's another thing to say, "Okay,  
3 what do we need to do about it? And how do we best  
4 attack it?" So one of the ways we tried to unravel  
5 and sort through the fire PRAs was we looked at the  
6 CDF contribution of different of these bins.

7 Each of the ignition sources is considered  
8 in a bin, and the x-axis of this chart along the front  
9 there is those bins from 6850, and then the y-axis is  
10 the relative contribution to CDF. So this is just a  
11 fraction of that plant's CDF, and some of these plants  
12 have higher or lower CDFs. It was just to sort of see  
13 what are the main contributors, and then the z-axis of  
14 course is a list of plants.

15 So, obviously, the first thing that jumps  
16 out quickly at you in this chart is that there is this  
17 -- every plant has a sizeable, and maybe even it's  
18 largest contribution coming from this -- what we call  
19 the ridge line or whatever of this chart, which is  
20 related to electrical cabinets.

21 Now, big surprise, I mean, that that's the  
22 case. There are a lot of electrical cabinets. We  
23 have a lot of electrical cabinet -- well, I don't know  
24 about a lot, but we have more electrical cabinet fires  
25 than we do any other type of fire in plants. But

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 power is important to operating the systems in the  
2 powerplants, so it's -- it would be important.

3 But the thing I like about this chart is  
4 it says, "That's important, but if you look around the  
5 chart, depending upon the plant, other bins are also  
6 contributors." So if you did something to drop  
7 electrical cabinets, for example, in my green plant  
8 here, Plant 3, it is going to rapidly -- the next  
9 important thing is going to be the high-energy arcing  
10 faults followed by some in-plant transformers followed  
11 by some battery chargers in that particular plant.

12 This was the point I was trying to make  
13 early on, that it's very plant-specific and it's very  
14 scenario-specific. The second chart -- wrong  
15 direction. Second chart here, basically in this one  
16 all I did was I made the bin 15 electrical cabinets  
17 invisible, and I changed the scale, so it sort of like  
18 zoomed in and removed the big mountain in the middle.

19 And this gives you a little bit better  
20 view of the fact that it is kind of all over the place  
21 across the plants.

22 MEMBER STETKAR: Thank you.

23 MR. TRUE: Okay?

24 MEMBER STETKAR: We spent -- in the  
25 Subcommittee, we spent quite a bit of time on those

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701



1 charts, and I thought they are really informative and  
2 it's worthwhile for the rest of the Committee to at  
3 least be introduced to them.

4 MEMBER POWERS: I guess, John, I -- I  
5 wonder -- I'm puzzled why you are so enthusiastic  
6 about this chart. Doesn't it just say what we kind of  
7 know?

8 MEMBER STETKAR: It says what we kind of  
9 know from people who have done a lot of fire PRA work.

10 If you haven't, it is worth recognizing it. But it  
11 also -- the reason I wanted to get it into the record  
12 and in front of the rest of the Committee members is  
13 it also is an integral part of some of the things I  
14 think we are going to hear in EPRI's path forward.

15 In other words, you know, why are they  
16 focusing in certain areas? Why are they maybe not  
17 focusing in other areas? So that's another reason why  
18 I wanted to get it in there, even though perhaps from  
19 a results perspective it might be intuitively obvious  
20 to some of us.

21 MEMBER POWERS: Well, I mean, we have the  
22 IPEEEs, we have the experience. Where else would you  
23 expect fires, except cabinets, transformers, and  
24 battery chargers? I mean, those are the kind of  
25 places that you'd kind of look for fires.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1                   MEMBER STETKAR:     Well, but it's also  
2 important -- I mean, Doug mentioned -- in the first  
3 line up there he mentioned things like oil fires. You  
4 don't see oil fires contributing.

5                   MEMBER POWERS:    If I walk through a plant,  
6 I see elaborate --

7                   MR. TRUE:     There's one right here.

8                   MEMBER POWERS:    -- efforts to maintain and  
9 control oil spills.

10                  MR. TRUE:     Diesel generator fire is an oil  
11 fire.

12                  MEMBER STETKAR:   After you cut out the  
13 cabinets.

14                  MR. TRUE:     After we've -- but it's still  
15 -- I mean, it's --

16                  MEMBER STETKAR:   Well, no, eventually --  
17 you know, this is risk assessment, so eventually you  
18 get the grains of sand, one of which has a little  
19 higher knob and the other one doesn't, so --

20                  Well, perhaps I erred in terms of my  
21 desire to have the Committee see that, but they've  
22 seen it now.

23                  MEMBER POWERS:    I think you just wanted to  
24 see where you were, you know?

25                  VICE CHAIRMAN ARMIJO:  I liked it, John.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: Thank you, Sam.

2 MEMBER CORRADINI: Do you count all  
3 electrical cabinets as being the same?

4 MR. TRUE: Sort of. There are a small  
5 number of bins. I think there are five bins for  
6 electrical cabinets, depending upon the type of cables  
7 and a couple of other factors.

8 MEMBER BROWN: Why differentiate between,  
9 say, instrumentation cabinets and what I call  
10 switchboards and/or a cabinet full of power  
11 electronics where I am, you know, trying to convert it  
12 from one form to another and run a pump or something  
13 like that where you have a lot of power?

14 So low power cabinets, I'm just going back  
15 through 40 years or 45 years, and I never had a fire  
16 in the vast majority of what I call the control  
17 instrumentation cabinets. They were almost always in  
18 a switchboard of some kind, you know, a regular  
19 switchboard, and they were normally localized in terms  
20 of locality to types of cabinets, at least in my Navy  
21 experience, the molded case circuit breakers, the 50  
22 amp, 100 amp, 250 amp, 450-volt breakers.

23 We never did ever find out why we kept  
24 having fires in those other than the Navy ones are  
25 kind of compact, which creates another issue. The ACV

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 cabinets, the ones with the big air circuit breakers,  
2 had few, if any, other than if you had an arc fault,  
3 where it kind of -- you never knew it.

4 It would kind of eat its way through the  
5 cabinet, saw no spurious operations, and then it would  
6 explode out of the cabinet when it started eating the  
7 metal, and then it would just explode out into the  
8 manned areas. Hopefully, there were no men there.

9 So that's why I asked about, you know, if  
10 you treat -- if every cabinet, then -- is then treated  
11 the same, then you get a different range of  
12 probabilities I guess or input into the spurious  
13 operation and possible problems. That's why I ask the  
14 question, just to see. If you're going to sort, you  
15 ought to try to fiddle stuff around, so that you don't  
16 count -- everything is not the same.

17 MR. TRUE: We're working in that  
18 direction. Today it's pretty simplistic, and --

19 MR. BRADLEY: Even more simplistic than  
20 you just stated.

21 (Laughter)

22 We don't want to go there probably today.

23 MEMBER SIEBER: That's probably one of the  
24 sources of the problem that you have. Unfortunately,  
25 I have experienced cabinet fires. Generally, they

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 only take out one component, and they typically,  
2 unless it's a high energy cabinet, don't spread --

3 MEMBER BROWN: Exactly.

4 MEMBER SIEBER: -- to anything else.

5 MEMBER BROWN: Yes.

6 MEMBER SIEBER: There it is, and you've  
7 got a brown mark on the front of the cabinet, and  
8 something failed. And that's the end of the fire.

9 MEMBER BROWN: Exactly.

10 MR. TRUE: That's not what we're seeing in  
11 the application of these methods, so there's a --  
12 there's a disconnect.

13 Okay. This is my handoff to Rick. Rick  
14 is going to go into the research activities. Is there  
15 any questions about the technical stuff I presented,  
16 which -- cover those now or we will just continue with  
17 Rick.

18 (No response)

19 MR. WACHOWIAK: Okay.

20 MR. TRUE: All right.

21 MR. WACHOWIAK: So just one last thing to  
22 bring up in -- in an area with the bar chart. From  
23 the results that we saw on comparing what the PRAs  
24 would predict to the industry experience, what we're  
25 seeing there is that we are off by at least an order

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 of magnitude in those, and in some cases it is  
2 probably -- that would just barely bring us to where  
3 maybe you would expect zero events.

4 To get it right in the middle, you would  
5 have to go more than one order of magnitude. So  
6 that's why the bar chart is important to see that  
7 there is nothing on there, there is no one thing that  
8 if you fix electrical cabinets, it will bring this all  
9 into range. You have to fix some of the other ones,  
10 too. That's not the -- that's a significant piece of  
11 it, but it's not the only piece that needs to be  
12 addressed.

13 So, of that --

14 MEMBER BROWN: Can I ask one other  
15 technical question? Are there any fire protection  
16 methods incorporated in the commercial -- in the  
17 cabinets, the big power -- electrical switchboard  
18 cabinets and stuff like that in the commercial plants?

19 MR. TRUE: Do you mean, for example,  
20 incipient detectors and --

21 MEMBER BROWN: Yes. I mean, like when we  
22 -- to address our problem, we ended up installing a  
23 system called an arc fault detector to try to trigger  
24 and isolate sections of the bus, so that it couldn't  
25 spread, particularly in the high-powered ones. It

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 works very, very well, and we have backfitted it into  
2 all of the -- almost all of the nuclear ships. So --

3 MR. TRUE: I don't know if those, for  
4 example, are --

5 MEMBER BROWN: I just wondered if they  
6 did. It was just --

7 MEMBER STETKAR: Charlie, for the most  
8 part, there aren't even automatic suppression systems.

9 MEMBER BROWN: There's not?

10 MEMBER STETKAR: There's --

11 MEMBER BROWN: Well, I guess ships would  
12 worry a little bit more about fire.

13 (Laughter)

14 Fires are a big deal on a submarine.  
15 There's no place to go to breathe.

16 MEMBER SIEBER: Big deal.

17 MEMBER BROWN: Okay.

18 MR. WACHOWIAK: Yes. There's not a lot of  
19 information on those types of protective equipment by  
20 nuclear powerplants.

21 MEMBER BROWN: Okay. I was just curious,  
22 that's all. Thank you.

23 MR. WACHOWIAK: So Doug described the  
24 issues, and what I want to talk about right now is  
25 what it is that the industry is actively doing about

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 trying to rectify some of these things, and maybe give  
2 you an idea of the timeframe that -- where we think we  
3 will have significant results.

4 This slide, and the next three,  
5 essentially say the same thing. It's for different  
6 types of people, whether you think pictorially like  
7 this or whether you think in lists, we'll cover it --  
8 most of the items on the list.

9 But what we wanted to do, as Biff said,  
10 back in 2009 we came up with an action plan, the  
11 industry came up with an action plan, that had a bunch  
12 of things that we were going to work on to address  
13 these things. They were -- it was organized based on  
14 expert opinion, and our gut feel for where we needed  
15 to address these things.

16 Since then, we have gone through and  
17 looked for the evidence of where we have issues, and  
18 we have also gone back through the genesis of the fire  
19 PRA fact process and the resolutions from the fact  
20 process to see what was left on the table from all of  
21 that.

22 And then, we took that -- took our action  
23 plan and compared it to the things that we were seeing  
24 were left -- left undone and the things that looked  
25 like they were significant contributors to the PRA.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 And this is our organization for how we are doing  
2 this.

3 We are looking at things that are  
4 addressing the fire ignition frequency piece of it.  
5 We are looking at things that are looking at the  
6 damage assessment, like what happens in the different  
7 types of cabinets, and we are looking at things  
8 associated with how you put these phenomena into your  
9 PRA model. And we've got actions going on in all of  
10 those different areas.

11 VICE CHAIRMAN ARMIJO: Do you have  
12 mitigation in that category, or is that treated?

13 MR. TRUE: What aspect of mitigation?

14 MR. WACHOWIAK: Yes. What aspect? Fire?

15 VICE CHAIRMAN ARMIJO: Well, any aspect to  
16 put out the fire. Does it --

17 MR. WACHOWIAK: So non-suppression  
18 probability is in Category 1. That is, given a fire,  
19 what is -- given a fire of a certain type, what is the  
20 probability that the -- that operations at the plant  
21 will put the fire out?

22 So that's covered in there, and then  
23 there's some of the other things, the damage  
24 assessment and fire propagation kind of gets a little  
25 bit to mitigation once you have a fire that -- is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 there some aspect to the design of the cabinet or  
2 where it's located, things like that, that could  
3 prevent damage from occurring in other pieces of  
4 equipment? So the mitigation is -- is across the  
5 board I think there.

6 So in area one, the important things that  
7 we are working on now are the fire events database.  
8 We want to get a better idea of what are the  
9 frequencies of fires, and what do the fires look like  
10 once they happen.

11 There was a presentation in one of the  
12 Subcommittee meetings that went through the  
13 excruciating details of what we're collecting in the  
14 database and how we intend to use the data. But just  
15 to say that right now it's a collection of the data  
16 from about the last 10 years, 2000 to 2009.

17 We are reevaluating the events that are in  
18 the current database from about -- what is it -- 1990  
19 to 2000, going back to the plants to see if we can get  
20 more information about those events and try to get a  
21 better feel for what are the kinds of fires and things  
22 that we are going to have, and where they have -- what  
23 types of equipment they happen in and what do those  
24 fires look like.

25 We are trying to gather more data into the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 database, or more information about each fire event  
2 into the database now, and so that we can look at what  
3 actually happened and maybe try to match the types of  
4 fires that have actually occurred up to the treatment  
5 in the PRA for what is -- how it proceeds to damage  
6 additional equipment or not.

7 We are looking at the severity  
8 characterization. Once again, that is by looking at  
9 the events that have actually happened. That is what  
10 we are doing in here. We are going to try to look at  
11 some aspects of incipient detection, and this is the  
12 -- some of the kind of things you are looking at here.

13 Our intent isn't to quantify, what is the  
14 reliability of incipient detection or things like  
15 that? What we want to do is look at the fires that  
16 are there and try to understand what types of  
17 incipient fire detectors could have been used to  
18 detect those types of fires, so that we can end up  
19 figuring out how to use them in a PRA model, should a  
20 plant decide to install those.

21 We think that the reliability of those  
22 detectors comes in in a -- from a different program,  
23 not from actual events that have happened in nuclear  
24 powerplants. Too few and far between to try to grab  
25 that type of data, at least at this point in time.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1           And then, we are also going to look at the  
2 fire suppression and control. One of the things that  
3 we are finding in the database now, as we are  
4 collecting the data, is if -- if the fires were small,  
5 very small or very well behaved, they didn't happen --  
6 they didn't really write down much about it, and  
7 that's to be expected.

8           And when we're looking at things like fire  
9 suppression and control, those tend to be the things  
10 that work right, and they don't write a lot about  
11 that. So we are trying to figure out how we can --  
12 how we can glean this data from the plants where  
13 things went well and where things worked like they  
14 were supposed to, so that we can more accurately --

15           MEMBER STETKAR: Since it's only the last  
16 10 to 20 years, are you making any efforts to go back  
17 and talk to human beings who may have --

18           MR. WACHOWIAK: Yes.

19           MEMBER STETKAR: Okay.

20           MR. WACHOWIAK: Yes. So --

21           MEMBER STETKAR: -- the fires, because  
22 they might recall more.

23           MR. WACHOWIAK: Yes. As a matter of fact,  
24 in the most recent set of plants that are farthest  
25 along in the data collection effort, we have

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 identified what we know from their reports and what we  
2 don't know that we would like to know from their  
3 reports.

4 And we have gone back to them and said,  
5 "Okay. Here is all the stuff that you didn't tell us  
6 about in your report. Can you get us this  
7 information? This is what we need to calculate fire  
8 frequencies, and this is what we need to identify  
9 credit for suppression and other things."

10 So we are trying to go back while the  
11 information is somewhat fresh in the minds of the  
12 people at the plants, and we are factoring that into  
13 the going forward, how do we do continuous data  
14 collection going into the future where everyone knows  
15 if you had a fire you need to keep track of these  
16 types of things, so that we can refine our models.

17 In the area of damage assessment, we are  
18 looking at the fire growth and how that compares with  
19 things that we see in the data, that we have seen in  
20 the database. That is one of the things that we are  
21 really going to need to collect the data up front or  
22 ahead of doing a lot of significant data reduction  
23 there. But that is a planned activity.

24 One of the things we are working on now is  
25 peak heat release rates in certain types of equipment.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 We know that we have to work on electrical cabinets  
2 -- that is, the discrimination amongst the different  
3 types of cabinets, what is in there, what its  
4 potential for causing a severe fire needs to be  
5 characterized, and I think I talk about that on a  
6 slide toward the end.

7 We want to look at the damage that has  
8 actually occurred from some of these fire events.  
9 Hopefully, we will be able to get that out of the data  
10 that is there, and certainly in talking with the  
11 plants about some of these events.

12 The other one that falls into this range  
13 here -- I'm not sure if it's so much in Category 2,  
14 maybe it's in Category 3, is the guidance for doing  
15 fire modeling. Fire modeling is becoming more and  
16 more important, as we want to show that some of these  
17 fires do not actually damage adjacent equipment.

18 And there are various tools that are out  
19 there, and we have gathered a -- through a  
20 collaborative effort of EPRI and NRC Research, we are  
21 about to put out a guide for users of fire models and  
22 how they should be used in nuclear powerplants.

23 In Category 3, we are working with  
24 Research again on the treatment of hot shorts. There  
25 is an experimental data interpretation going on as we

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 speak. It is in the early phases of that for the  
2 latest DC circuit tests that were done, and the team  
3 is also looking at the AC circuit tests that were done  
4 before to see if there's anything we can glean from  
5 the new information. That's a collaborative effort,  
6 and the PIRT panels that are working on that are made  
7 up of both NRC and industry experts.

8 We put out -- I think the report is out in  
9 draft now for the human reliability methods for -- in  
10 your fire PRAs. We will start to see some more and  
11 more use of that, and our intent with reports like  
12 this is to put it out for use, get feedback from the  
13 plants that are using them, and then, on approximately  
14 a year and a half to two-year timeframe, go back and  
15 refine those reports to pick up the information that  
16 came from the users and try to refine it to make it  
17 more usable or more realistic if -- as time goes on.

18 The human reliability is one of the first  
19 ones out of the chute in this -- in that sequence of  
20 events. We are looking at how to better model control  
21 room fires and control room evacuation, and then, in  
22 general, addressing or advancing the models. Are  
23 there better ways to do these calculations? Are there  
24 more efficient ways of doing them?

25 I think we mentioned this early, but I

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 just want to say again that all of these activities  
2 are being coordinated under one action plan. We have  
3 got the things on the action plan that are led by  
4 EPRI, but also things that are led by the owners'  
5 groups and by NEI, and, as a matter of fact, we have  
6 put the research and testing activities that have been  
7 going on at the NRC, integrated that into our matrix  
8 as well, so that we can see, in a broad way, what  
9 everybody is doing and how it ties together, and try  
10 to minimize duplication to the extent possible.

11 The road map document that Doug talked  
12 about earlier has a snapshot of that -- of the action  
13 plan or the action matrix as an appendix. So if you  
14 want to see what the specific activities are, you can  
15 go into that document that you have and see the  
16 specific activities.

17 We use the road map, and we use our -- use  
18 the industry committees to focus what it is we should  
19 be working on. Through NSIAC and the Executive  
20 Oversight Group at NEI, the utility executives, they  
21 have been through this plan. We have presented it to  
22 them, and they are on board with this being a priority  
23 for the next couple of years until we get the bulk of  
24 these activities in control and get the products out  
25 for use in the fire PRAs. It is a very high priority

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 activity for the industry.

2 Let's see, I think I've talked about most  
3 of these already when I was talking about the specific  
4 things, but let me just make sure that I have covered  
5 it. One of the things that we want to make sure of  
6 with the new fire events database data is something  
7 that was left on the table with one of the earlier  
8 facts.

9 From the old fire events, the existing  
10 fire events database, EPRI had gone through and  
11 relooked at the data that was out there and noticed an  
12 inflection of the fire frequencies that happened at  
13 around 1990. But there was some concern that there  
14 wasn't enough data after 1990 to really confirm  
15 whether or not that was a trend or whether it was not  
16 real, something -- they were just looking there.

17 One of the things that we -- our intent  
18 here is to look at that. We will have another 10  
19 years worth of data, it will put it on par with the  
20 earlier data that we have, and will investigate  
21 whether that trend was indeed -- or whether that  
22 change in frequency was indeed true. And it will --  
23 we'll let it fall where it does when we look at the  
24 data.

25 We want to get better data about the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 fires. And, as John said, we want to talk to the  
2 people who were there to the extent possible now and  
3 get better information for how these fires actually  
4 behaved and try to make -- try to be able to link what  
5 we are calculating in a fire frequency with what we  
6 are actually modeling as the effects of those fires in  
7 the PRAs.

8 We are going to look and see if we have  
9 enough data for doing component-based fire frequencies  
10 rather than the plant-based bin frequencies that we  
11 talked about in one of the Subcommittee meetings. We  
12 think in some of the bins, some of the types of  
13 components, we are going to have enough information to  
14 do that. In other ones, we won't have enough  
15 information to do that.

16 So we will -- we will look at what is  
17 there and determine whether we have a basis for doing  
18 that. And, to the extent possible, we will calculate  
19 component-based frequencies where it's warranted.

20 MEMBER STETKAR: The problem -- and I  
21 think you mentioned -- the problem there is not  
22 necessarily counting the numerator, because you are  
23 doing that. It's counting the denominator, the  
24 population of --

25 MR. WACHOWIAK: Right. We've got the --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: -- equipment per plant.

2 MR. WACHOWIAK: We understand that. We  
3 have the owners' groups working on an activity to  
4 collect the data from the plants on how many of the  
5 different types of components they have, and then try  
6 to link that with the records that are coming into the  
7 database. So we understand that difficulty. It's not  
8 a trivial task. We do think, though, that's best led  
9 by the owners' groups.

10 In our frequency report, we are going to  
11 address the plant-to-plant variability. I think Pat  
12 Baranowsky, in his presentation, discussed how they  
13 were going to do that when they reduce the data, and  
14 that will be addressed in the new version of the  
15 database.

16 The other thing that we are working on in  
17 the near term is this vertical electrical cabinet heat  
18 release rate. We recognize some of the same things  
19 that you brought up in terms of not all cabinets  
20 behave the same. And we didn't do any new  
21 experiments, but we went back through and looked at  
22 the experimental base that we had to try to understand  
23 what other types of information do we know about these  
24 cabinets in the plant that we can use to influence the  
25 kind of heat release rates that we would calculate

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 from a power level of the equipment in the cabinet is  
2 one thing that we are looking at.

3 We are also looking at the ability for the  
4 cabinet to ventilate itself, so that the fire can grow  
5 inside the cabinet. Much of the testing that was done  
6 were with well-ventilated cabinets, and so we  
7 developed a model that could -- that could predict a  
8 maximum heat release rate based on the ventilation  
9 characteristics of the cabinet.

10 Double-edged sword of course. If you are  
11 going to use these methods, you have to know more  
12 information about your cabinets. That means you have  
13 to collect more information about a whole bunch of  
14 cabinets to put it into the model. But we're trying  
15 to strike a balance, and we've got -- in the reviewers  
16 that are looking at this, they are not only looking at  
17 the correctness of the methods, they are also looking  
18 at how can this method be implemented, and is it  
19 something that is actually useful to the plant,  
20 because we don't want to put something out there as  
21 the state-of-the-art method if nobody can do it,  
22 because it's just too hard.

23 MEMBER STETKAR: Yes. You showed some  
24 examples of thousands of cabinets in a plant.

25 MR. WACHOWIAK: Right.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1                   MEMBER STETKAR:    And the implication is  
2                   somebody would have to go out and really examine each  
3                   one of those.

4                   MR. WACHOWIAK:   Right.   So if you had to  
5                   know specifically, what is the combustible mass in  
6                   every cabinet, that wouldn't be a useful thing to do.

7                   But what we think we were able to do in this report,  
8                   which is under review right now, is correlate the type  
9                   of cabinet and the size of the cabinet to a reasonable  
10                  range of combustible material that is inside the  
11                  cabinet.

12                  So those types of things were looked at,  
13                  so -- and we actually have two -- I believe it's two  
14                  plants that are trying to implement the method as the  
15                  test case for the review.   So usability and accuracy  
16                  are both being tested.

17                  MEMBER BLEY:        Are they focusing on  
18                  screening especially the cabinets that essentially  
19                  have nothing in them?   I mean, we talked about that at  
20                  the Subcommittee meeting, and it sounded like people  
21                  were putting an awful lot of work into cabinets that  
22                  they really, even by the NUREG, could have screened  
23                  based on the fuel loading within the cabinet.

24                  MR. WACHOWIAK:   Probably.   That is an  
25                  aspect of it.   And the method that is in the report

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that is in review right now addresses that, and that  
2 is one of the steps through the flowchart for that  
3 method is to characterize, what is the loading within  
4 the cabinet? And you can get out to a screening value  
5 to remove those cabinets from --

6 MEMBER BLEY: So the two plants are using  
7 that?

8 MR. WACHOWIAK: There are -- there is one  
9 that is using it, and we have solicited another that  
10 -- and the one that is using it actually has one of  
11 the authors of the report as their -- as one of their  
12 contractors.

13 Now, we wanted to have another plant with  
14 someone who is not one of the authors or one of the  
15 author's contractors to try to implement the same  
16 thing, because, as we all know, it's -- if you develop  
17 the method, you know how to do it right. But did we  
18 sufficiently write the report so that somebody else  
19 can pick it up and also --

20 MEMBER BLEY: But that hasn't begun.

21 MR. WACHOWIAK: That's not done yet.

22 VICE CHAIRMAN ARMIJO: Quick question,  
23 Rick. You mentioned plant-to-plant variability, and I  
24 was looking at your chart on page -- Slide 29. And  
25 there is -- I don't know if this is a fluke or if it's

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 real, and that's Plant 7. It looks like they have --  
2 they don't have very many -- they don't have any major  
3 contributors. Is that the way to interpret?

4 MEMBER CORRADINI: The arc transforms --

5 MR. WACHOWIAK: Yes, I --

6 VICE CHAIRMAN ARMIJO: They didn't have  
7 certainly not the big electrical cabinet thing. They  
8 didn't -- maybe I'm just not reading this right.

9 MR. WACHOWIAK: You can't tell from  
10 looking at this what they have. They could have a  
11 very large CDF, and their CDF for electrical cabinets  
12 is the same as everyone else's, and then there are  
13 just other things that are up. Or they have a  
14 different distribution. You just can't tell from  
15 looking at this chart, so I don't -- I don't know that  
16 that's the case.

17 MEMBER STETKAR: I think, Sam, in this  
18 context of the data, it is plant-to-plant variability  
19 and the frequency of fires.

20 VICE CHAIRMAN ARMIJO: Right.

21 MEMBER STETKAR: In other words, if you  
22 have 100 plants, it -- and 100 fires, if all 100 fires  
23 occurred in one of those plants, that's a much  
24 different measure of the uncertainty than if you had  
25 one fire in each of the 100 plants. And that's I

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 think the context, not -- not in terms of these  
2 results, plant-to-plant variability, which are  
3 influenced by the plant-to-plant variability in the  
4 frequency, but also by the specific geometry and --

5 VICE CHAIRMAN ARMIJO: Okay.

6 MEMBER STETKAR: -- PRA vulnerabilities,  
7 etcetera.

8 MEMBER REMPE: You mentioned several times  
9 about the database for the heat release rate, and I'm  
10 not familiar with it. When was it done? Who did it?  
11 And give me a few details about how they did it.  
12 Were there a lot of different cabinets? I heard this  
13 was discussed a lot at the Subcommittee meeting, but I  
14 missed it. And you don't have to go into the --

15 MR. WACHOWIAK: There have been, oh, how  
16 many sets of tests that we looked at? Twenty? Twenty  
17 or so different tests. Some of them are written in  
18 NUREGs. Some of them are international documents that  
19 we have gone back and gotten the data from those  
20 tests, and, to the extent possible, we are trying to  
21 relook at, what are the common characteristics here?

22 So we could get for you the listing of  
23 what all of the different tests were, but they were  
24 essentially fire -- in-cabinet fire tests that were  
25 done at various labs.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 MEMBER REMPE: Okay.

2 MR. WACHOWIAK: The intent of most of  
3 those were to determine, what is the maximum heat  
4 release rate you could get out of a fire in an  
5 electrical cabinet? And the focus of those -- of  
6 those tests were, how can we make the biggest fire  
7 possible?

8 And, as Doug was saying, we are taking the  
9 information from that and trying to apply it to every  
10 fire that happens in an electrical cabinet at a  
11 nuclear powerplant. And that is no easy task to do.  
12 You have to understand that smaller fires do behave  
13 differently than bigger fires, and we have a  
14 sparseness of data at the smaller, wider end of the  
15 spectrum.

16 CHAIRMAN ABDEL-KHALIK: I understand that  
17 this entire effort started because you did all of this  
18 work, and then you compared the results against plant  
19 data, and, lo and behold, there was a huge difference.

20 And, therefore, you are now going back to change the  
21 models to add more data. So I assume you will define  
22 success of your current effort when whatever  
23 predictions you get will match the data, or closely  
24 resemble the data.

25 MR. WACHOWIAK: Rather than "match," I

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 would say "when they are not inconsistent with the  
2 data."

3 CHAIRMAN ABDEL-KHALIK: Okay.

4 MR. WACHOWIAK: Operating data, yes. So  
5 you could --

6 CHAIRMAN ABDEL-KHALIK: If that is the  
7 case, if that is the success criteria, what you are  
8 saying is that, you know, based on these results we  
9 expect the future to be the same as the past. And if  
10 that is the case, what additional insights would you  
11 actually gain from the PRAs beyond the insights that  
12 you could gain by just simply looking at the data?

13 MR. WACHOWIAK: Yes. I think you might be  
14 going a little farther along this path than we were  
15 intending to go. I don't think we were ever intending  
16 to continue to monitor high CCDP events or spurious  
17 operations and see how that matches up with the  
18 predictions.

19 What I think we're seeing right now,  
20 though, is in this first cut the predictions from the  
21 PRA are off by at least an order of magnitude, right?

22 So where can we address -- with the methods that we  
23 are developing, how can we address getting some of  
24 these things into the range where you would predict  
25 very few events?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           At that point, I don't think we would  
2 continue to look at that sort of data anymore. We may  
3 want to look at other things, but I don't -- I don't  
4 know that we would --

5           CHAIRMAN ABDEL-KHALIK:     But the sanity  
6 check came when you did the comparison, right?

7           MR. WACHOWIAK:     Right.

8           CHAIRMAN ABDEL-KHALIK:     And you are  
9 telling me that, you know, if you just bring the  
10 numbers down, there is no need for a sanity check.

11          MR. WACHOWIAK:     I'm not saying that we  
12 were just trying to bring the numbers down. You can't  
13 just bring the numbers down. You have to bring the  
14 numbers down based on some physical reality. Okay?

15          So the ignition frequencies, we think  
16 there are -- we think the ignition frequencies should  
17 be lower, because we saw what appeared to be a trend  
18 change back in 1990. We are going to confirm that,  
19 and if that trend has persisted, then, sure, we will  
20 say the frequencies really are lower now, but at that  
21 point we are not going to say, "Well, okay, what is  
22 the -- let's try to find some way to come up with the  
23 real number." It's there, the method is sound, and we  
24 will continue with that.

25          So I'm not sure that these same particular

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 events would be used as the gauge of whether we are  
2 successful or not. I think we want to -- like in the  
3 internal events PRAs, we want to come up with methods  
4 that are -- that match up with the physics, that match  
5 up with the data collection, the statistics, and that  
6 produce results that you could say, "Yes, this  
7 predicts very few of these high-consequence events,  
8 spurious operation events."

9 And the model predicts very few, the data  
10 says there are very few. Let's go and -- we'll look  
11 at other ways of doing intermediate events at that  
12 point. I don't -- so I don't think we're ever going  
13 to try to say, "Let's match what the PRAs say to the  
14 data that we collect." It was not the intent.

15 CHAIRMAN ABDEL-KHALIK: I understand.  
16 But, nevertheless, that is sort of the only sanity  
17 check you have. And if that is the case, then the  
18 point I made is that, you know, you are essentially  
19 saying that the future will be the same as the past.  
20 And the insight that you would gain from reaching that  
21 state would be no more than the insight that you would  
22 gain by looking at the raw data.

23 MR. TRUE: Well, yes and no. I think --

24 MEMBER SIEBER: That's the case with all  
25 PRAs. It's all dependent on past history. Failure

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 data and what have you, it's all -- and so what you're  
2 doing is saying, "I have looked at all the individual  
3 characteristics of this plant and matched its failure  
4 rates that I see over all plants, and, therefore, I  
5 assessed this probability of core damage at this  
6 amount." And I think you are doing the same thing by  
7 pursuing these objectives with -- in terms of the  
8 fire.

9 MR. WACHOWIAK: And I think one of the  
10 things that we want to make sure that we do here is  
11 that the objective of doing the PRA -- one is to get  
12 the insights, but we want to have it as a useful tool  
13 or a test bed to say, "If I'm going to change the  
14 plant, what will it do to my fire risk  
15 characterization?"

16 So if our fire PRA is matched, the real  
17 characterization in the plant, the real way that fires  
18 behave in the plant, and the risks from those fires,  
19 if we can reliably put a proposed change into the  
20 model and calculate a change in the risk, that will  
21 help us -- help inform us on how best to improve the  
22 plants or to not do things that are detrimental to the  
23 plant.

24 MR. BRADLEY: All right. I know we've got  
25 to give the staff their due time here, so I just

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 wanted to close. I do appreciate all of the time we  
2 have had with the Committee and the Subcommittees and  
3 the opportunity that you have given us to make our  
4 case here.

5 We do believe that there is still work to  
6 be done. There is the remaining concern that we are  
7 in the middle of a large-scale regulatory application  
8 where we are using the results of these models to make  
9 large decisions relative to plant modifications and  
10 other activities. And we remain concerned that these  
11 decisions are being made ahead of the curve of getting  
12 these models to the point where we believe they need  
13 to be.

14 I know ACRS is going to be writing a  
15 letter to the Commission, and we hope that you will  
16 consider the points we have made. We believe this is  
17 a legitimate concern. We have done our best to try to  
18 give you a technical basis for it, and we encourage  
19 NRC. We hope ACRS can help us encourage NRC to  
20 continue our quest for realism.

21 I know it's a difficult thing, and we have  
22 state of knowledge --

23 MEMBER POWERS: They don't like realism,  
24 right, yes.

25 (Laughter)

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. BRADLEY: I know since the time I  
2 wrote these slides last week things have -- there has  
3 been some action on the part of NRC relative to  
4 previous requests the industry had made back in  
5 November to consider extending the schedule for 805.

6 And as I understand it, and I guess the  
7 staff can speak to this, there is now an expectation  
8 that you can come in with something called a partial  
9 submittal. It -- I don't know how well that is  
10 defined at this point. I believe it would be  
11 important -- an important consideration for these  
12 submittals that may not be complete that more time  
13 might be needed to refine the PRA model and arrive at  
14 the correct decision relative to plant modifications.

15 And that's a legitimate and reasonable  
16 basis for a plant to request some additional time or  
17 to give a partial submittal that provides time to get  
18 that work done. And I believe that -- you know, if  
19 the ACRS -- if they are considering encouraging that,  
20 that would be useful.

21 MEMBER POWERS: Let me -- you have  
22 proposed, and are undertaking, some very creative and  
23 useful work that is reexamining things in some depth,  
24 and no question it is -- that is going to be valuable  
25 to see what would come out of there. But is not your

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 real essence of your problem that you are identifying  
2 -- you are -- that we have not completed the pilot  
3 plants and examined the results of those in light of a  
4 document that EPRI and NRC completed and presumably  
5 revised in light of that?

6 Is that not the essential -- before we  
7 undertake applying these methods to other plants, is  
8 not the --

9 MR. BRADLEY: Yes.

10 MEMBER POWERS: -- essence of the  
11 difficulty here?

12 MR. BRADLEY: That is the essence, I  
13 think, to a great degree. The pilots haven't really  
14 -- we haven't had time to take those results and --

15 MEMBER POWERS: You need to take the pilot  
16 results and have a chance to digest it, and then  
17 probably carry out many of the things that you  
18 described here.

19 Where do things make sense? And where do  
20 they not make sense? And when they don't make sense,  
21 find out why they don't make sense and either change  
22 your sensibilities or change the methodologies. I  
23 mean, it could be either way, right? I mean, you  
24 don't know a priori.

25 I could prove my engineering judgment I

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701



1 think has a batting average of pretty close to zero,  
2 you know? So, and after all, they pay baseball  
3 players thousands and thousands of dollars for being  
4 right only one-third of the time. So, I mean, we  
5 can't ask too much here. But one way or another,  
6 things need to be changed -- may need to be changed  
7 based on once you've had a chance to digest these  
8 results.

9 MEMBER STETKAR: Any other questions for  
10 the folks up front?

11 (No response)

12 If not, thank you very, very much for a  
13 really good compilation of stuff that was presented  
14 over three long days. So thanks for your effort. It  
15 came across I think quite well.

16 And with that, we will have the staff come  
17 up.

18 (Pause)

19 MR. WEERAKKODY: Would you like me to go  
20 ahead and start?

21 MEMBER STETKAR: Take it away.

22 MR. WEERAKKODY: Okay. I'm Sunil  
23 Weerakkody. I'm the Deputy Director in charge of fire  
24 protection in NRR, and Donnie Harrison is the Branch  
25 Chief of the PRA Licensing Branch, and Alex Klein is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 the Branch Chief of the Fire Protection Branch.

2 And sitting in the back, I know Mark  
3 Salley we invited, he is our peer -- right there -- he  
4 is our peer in the Office of Research campaigning a  
5 lot of fire research.

6 So with that, let me go to the next slide,  
7 Alex.

8 I always when I come to talk to the  
9 Subcommittee I brought this, just to remind myself,  
10 you know, what the Commission SRM means. And I have  
11 to say, like John said, we had I believe two  
12 Subcommittee meetings, and our staff was interviewed  
13 by the independent consultants that John hired.

14 So one thing to say is that the staff had  
15 ample opportunities during the Subcommittee meetings  
16 to share our perspectives, and the plan here today is  
17 to not take too much time, give you a high level  
18 overview, and then Donnie and Alex will do that. But  
19 the biggest purpose would be to answer any of the  
20 questions that the Committee members have.

21 For that purpose, we basically invited a  
22 number of cognizant staff sitting in the audience,  
23 people who, for example, completed the Harris safety  
24 evaluation. Harry Barrett is there, and then our  
25 senior-level advisor in PRA. So I basically said,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 depending on the question, the staff could get up and  
2 go to the front and answer your questions.

3 Let's go to the next slide, please.

4 A couple of the oral comments I wanted to  
5 make before hand over the presentation to Alex and  
6 Donnie is we have completed the pilot activities.  
7 What I specifically mean by that is we have issued the  
8 safety evaluation for our two pilot plants in Harris  
9 and Oconee, and Oconee was published in -- on --  
10 Oconee SE was issued on December 29, 2010.

11 We used the pilot to update or create our  
12 infrastructure documents. These are the reg guides  
13 and the SRPs. And we are, at this stage, getting  
14 ready to proceed and begin the reviews of the large  
15 number of non-pilot LARs that we expect in the June  
16 timeframe.

17 I do want to -- I wanted -- just one  
18 technical issue, and I want to make it, too, just  
19 because of a number of the things that were in the  
20 presentations with respect to the consistency of the  
21 fire PRAs and the operating experience. I want to  
22 make one comment on that before I hand it over to  
23 Donnie.

24 First point, I have made the statement --  
25 I made it in the Subcommittee also -- and I would like

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 to really reemphasize with the full Committee members.

2 We believe -- we, the staff, believe that the fire  
3 PRAs have matured sufficiently for the regulator to  
4 make regulatory decisions in support of implementing  
5 10 CFR 50.48(c).

6 At the risk of boring the Subcommittee  
7 members who were here for that meeting, I still want  
8 to repeat what I said at that meeting. When we look  
9 at 50.48(c) or NFPA-804, it is an alternative to  
10 deterministic regulation. What we are telling the  
11 plant is we are enabling you to use PRAs to deviate  
12 from the deterministic requirements.

13 If I simplify this to a very simple  
14 example, typically in an area where they have  
15 redundant safety cranes, we would say those cables of  
16 those cranes should be either separated by 20 feet or  
17 separated by a three-hour barrier, or a one-hour  
18 barrier with a different separation.

19 And if you do that, and do that for all of  
20 your fire areas, going to 805 really is not necessary.

21 If we conclude your plant is safe, you don't have to  
22 do anything else.

23 Now, we understand that there's a number  
24 of plants out there that does not have that -- those  
25 requirements fully met. And the intent of -- and I'm

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 oversimplifying this. In terms of 805, it is to allow  
2 the licensees to go in and area by area look at their  
3 situations and make a determination of whether that  
4 deviation is acceptable.

5 For that purpose, I can say absolutely  
6 that PRAs -- fire PRAs I mentioned, but now I'm not --  
7 you know, it could lead to occasionally conservative  
8 additions. Now, as regulators we don't lose a lot of  
9 sleep on that. Okay? but the fundamental point is  
10 the fire PRAs handled it sufficiently for the 50.48(c)  
11 application.

12 The second point I am going to touch upon  
13 this -- and hopefully down the line Donnie and some of  
14 the other staff in the audience can elaborate on that  
15 -- we have not fully analyzed the numbers that the  
16 industry presented with respect to, you know, support  
17 that the operating experience is, you know, far -- you  
18 know, inconsistent with the fire PRAs.

19 But what we can speak to is the two fire  
20 PRAs from the Oconee and Harris we carefully looked  
21 at. Okay? Both of those plants had mid to low,  $10^{-5}$   
22 times core damage frequencies. And the staff, having  
23 had the opportunity to look at the methodologies that  
24 they used, would agree that there are some  
25 conservatisms even on those numbers. Okay?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1           So if someone says, "Hey, you know, five  
2 PRAs have conservatisms," you know, based on our two  
3 full reviews you would say, "Yes. Yes, there are  
4 some." I think when I get concerned is when I hear  
5 numbers like, "Well, you my have a factor of 10, 15,"  
6 you know, that type of conservatism, because what I  
7 want to be careful is in terms of looking at operating  
8 experience, it depends on how you pass it there.

9           I can use the same operating experience to  
10 come to a different conclusion. And, for example, if  
11 you think of our operating experience and throw away  
12 everything and look at the Browns Ferry event, and  
13 look at the contributors to the Browns Ferry event, so  
14 we have one event that almost came to -- I think  
15 conditional core damage probability was like .2.  
16 Okay?

17           So if you say you had a .2 core damage  
18 event, over the last, you know, 100 reactors, 30  
19 years, you know, you are getting close to the  $10^{-5}$   
20 number. Now, one could argue, well, you have to throw  
21 away Browns Ferry, because it was so old and the  
22 conditions have changed. And I would argue that some  
23 conditions have. Some of the practices using -- to  
24 check for the, you know, temperatures, leak, we don't  
25 do that anymore.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1           But I would also say that number of the  
2 design -- like, for example, one of the other  
3 contributors that led to Browns Ferry was that the  
4 inadequate separation between cranes. And some plants  
5 have made significant changes; others have not. So I  
6 can't throw Browns Ferry totally away.

7           So if I do a Bayesian -- I don't know -- I  
8 have lost some of the terms -- you have  $10^{-5}$  number.  
9 So that's why I'm concerned when the industry uses  
10 operating experience to say, not just conservatism,  
11 but there may be orders of magnitude. That's the part  
12 that I would have a little heartburn with.

13           I think I took too much time for the  
14 purpose of the staff introduction, but I really wanted  
15 to make those few points. So --

16           MR. HARRISON:    If I can just jump on  
17 that --

18           MR. WEERAKKODY:  I'm going to turn it over  
19 to you and Alex anyways, but I want to -- any  
20 questions for me from the --

21           MEMBER SHACK:    Can I just ask you a  
22 regulator question?    What was this thing we heard  
23 about from -- at the very end from Biff about partial  
24 submittals?    Has there been some change now that we  
25 should know about?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. WEERAKKODY: Well, it -- let me --  
2 we've got to be careful there, because we have a  
3 policy in place, and we have given the policy. We  
4 have a long public meeting yesterday with TRESPEC to  
5 -- you know, what kind of things should be accepted,  
6 transformed, and so forth. So I really got a look at  
7 the words that were said.

8 And I've got to be careful in terms of,  
9 you know, our -- I think -- I remember the words  
10 clearly. There will be -- what he said was -- what  
11 Dan Gobe said was like, "There will be certain limited  
12 circumstances under which we would doubt our  
13 flexibility." Why don't you speak to that. I can't  
14 remember the words.

15 MR. HARRISON: Okay. Yes, this is Donnie  
16 Harrison.

17 MR. WEERAKKODY: I just want to be careful  
18 in terms of policy -- or confusing policy meetings  
19 like this.

20 MR. HARRISON: Right. And it's worth  
21 clarifying, because I don't think the intent was to  
22 tell the industry to take another six months and work  
23 on things and don't worry about that submittal that's  
24 due in June. That was not the intent of that meeting,  
25 nor was it the intent of the actual comments that were

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 made. It was more of a recognition that if licensees  
2 are -- licensees have -- their fire PRAs have to be  
3 peer reviewed.

4 Out of that peer review there might be  
5 findings that either are because of new methods are  
6 involving a task -- this task force the EPRI mentions.

7 They may not have resolution on those methods. There  
8 might be findings that have come out that the licensee  
9 hasn't been able to resolve at the time of the June  
10 submittal.

11 The idea was licensees need to come talk  
12 to us if they were in that kind of a situation, so  
13 that we can understand when we get the submittal if  
14 there are any gaps in that submittal like that. It  
15 wasn't take two years to wait for Research, and in the  
16 meantime we'll wait for it. That wasn't the intent.  
17 And so just to -- I don't want to oversimplify it.

18 The real intent is if you have issues and  
19 you are working on those issues, but they are not  
20 going to be completely gone or they are -- you are  
21 waiting for something to come from this task force,  
22 come talk to us, and then you can move forward with  
23 your application.

24 MR. WEERAKKODY: Yes. And the clear  
25 message that I don't mind repeating, because Jack has

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 said this many times, what Jack wants to see is that  
2 if a licensee has concerns that they may have  
3 deficiencies, Jack really will encourage them to come,  
4 have pre-meetings with us now, and talk to his staff  
5 -- his staff understands the gap -- and work on those  
6 gaps, so that in June they are probably -- that is  
7 clearly -- that he has communicated to us several  
8 times, and he wanted to come to the meeting.

9 Any other questions for me? Go ahead.

10 MR. KLEIN: Okay. Hand it over to me.  
11 I'm Alex Klein. I'm the NRR Fire Protection Branch  
12 Chief. Let me just go to several of my slides that  
13 I'll speak to, and I think the meat of it will be  
14 Donnie. So I think that's the guy you want to pay  
15 more attention to than me.

16 (Laughter)

17 MR. HARRISON: Thanks.

18 MEMBER BLEY: Nice try.

19 MR. KLEIN: But anyway --

20 MR. HARRISON: Remember there's payback.

21 MR. KLEIN: Right. I understand.

22 Just for the benefit of the Committee  
23 members who may be fairly new to NFPA-805, to give you  
24 a very brief background, let me just take half a  
25 minute, if I could. NFPA-805 is a national consensus

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 standard. It was developed by the National Fire  
2 Protection Association back in the late 1990s/early  
3 2000s. NFPA-805 was actually issued in 2001. It is a  
4 standard that allows licensees to use a performance-  
5 based approach.

6 You heard Sunil talk about the three-hour  
7 barriers, the one-hour barriers, and so forth. Those  
8 are -- under Appendix R, those are very prescriptive  
9 rules. So a licensee that wants to do something  
10 different from a three-hour fire barrier and is  
11 obligated to meet Appendix R would have to come in and  
12 see staff for an exemption request.

13 Or as opposed to an NFPA-805 approach  
14 using performance-based methods, the licensee has some  
15 flexibility in terms of demonstrating how they meet  
16 these performance goals that are outlined in NFPA-805.

17 The rule was issued in 2004. It incorporates NFPA-  
18 805 by reference.

19 As Sunil indicated, it is a voluntary  
20 rule. Licensees can opt to stay with their existing  
21 licensing basis. And, as we know, approximately half  
22 the fleet has elected to transition to NFPA-805 at  
23 this point in time.

24 Let me go to the next slide.

25 MEMBER STETKAR: Alex, did --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. KLEIN: Yes.

2 MEMBER STETKAR: Since you wanted to go  
3 hide under a rock, I guess I have to ask you a  
4 question.

5 MR. KLEIN: I didn't say "hide under a  
6 rock."

7 MEMBER STETKAR: I think the -- and if the  
8 Committee isn't fully aware of this -- that the second  
9 sub-bullet at the bottom of the slide there is a bit  
10 important, because it -- the rule explicitly refers to  
11 the 2001 addition of NFPA-805.

12 MR. KLEIN: That's correct.

13 MEMBER STETKAR: Therefore, that's now  
14 law. NFPA-805 has been updated since then. It was --

15 MR. KLEIN: Yes.

16 MEMBER STETKAR: An update was issued in  
17 2006. Are there substantive differences between the  
18 two versions in terms of guidance from --

19 MR. KLEIN: I do not know offhand the  
20 substantive differences. I don't know if we have  
21 other folks here, if Harry can speak to that, or Paul.

22 MR. BARRETT: Yes. Harry Barrett, Senior  
23 Fire Protection Engineer from Fire Branch. The update  
24 -- I tried to fix a couple of typos that were in the  
25 standard. Really, no substantial difference as far as

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 the technical content in the standard.

2 MR. HARRISON: It did significantly  
3 renumber --

4 MR. BARRETT: Yes.

5 MR. HARRISON: -- a number of -- the  
6 layout of the standard, which creates some --

7 MEMBER STETKAR: Technical framework.

8 MR. BARRETT: Yes, there were no technical  
9 changes.

10 MEMBER STETKAR: Okay. Thank you.

11 MR. KLEIN: Thanks for that clarification.

12 MEMBER STETKAR: That has been brought up  
13 a couple of times in context, so it was worth --

14 MR. KLEIN: Because 10 CFR 50.48(c)  
15 referenced the 2001 edition of NFPA-805. So that  
16 becomes the regulation.

17 MEMBER STETKAR: Thanks.

18 MR. KLEIN: Just to give you a flavor for  
19 some of the history and the background of how we got  
20 where we are today, you heard Sunil talk about the  
21 infrastructure, and so forth. As we processed through  
22 the transition with these plants through NFPA-805,  
23 plants started working on their transition to NFPA-805  
24 I believe near the end of 2005 or so timeframe.

25 Shortly thereafter, we issued a regulatory

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 guide as one way for licensees to demonstrate their  
2 transition to NFPA-805. That Reg Guide 1.205 endorsed  
3 sections and portions of NEI-04-02, Revision 1, where  
4 we thought appropriate.

5 Now, as we went through the pilot process,  
6 we learned a lot of lessons. We then revised Reg  
7 Guide 1.205 and issued that revision to the reg guide  
8 in 2009, it looks like. Okay. I'm getting -- my  
9 years seem to run together here I have been involved  
10 in this issue for so long.

11 (Laughter)

12 So the infrastructure in terms of the  
13 regulatory guide I think is well in place. The staff  
14 also put together a standard review plan for an  
15 NFPA-805 transitioning licensee for the staff to --  
16 staff guidance for the review of these. As part of  
17 that SRP, the staff also put together a safety  
18 evaluation template to help the staff be more  
19 efficient and consistent in terms of when we write our  
20 safety evaluations in the future moving forward.

21 Again, what I wanted to emphasize, too, is  
22 that when we stepped through this process of  
23 developing this reg guide, we had a lot of public  
24 meetings, a lot of I think collaborative -- kind of a  
25 working relationship with the industry to develop our

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 reg guide in order for us to endorse their guidance  
2 document as appropriate.

3 As Sunil indicated, we issued the Harris  
4 safety evaluation first in June of 2010, and about  
5 half a year later we completed the second pilot plant,  
6 the Oconee pilot plant safety evaluation, in December.

7 Commensurate with all of that, or  
8 concurrent I guess with that, NEI and the industry had  
9 also been working on putting together a license  
10 amendment request template. The industry worked,  
11 again, with the staff in a collaborative manner over  
12 the last two months I think of last year.

13 We held I think meetings almost every two  
14 weeks to discuss the license amendment request  
15 template, and I think that was a fairly successful  
16 effort, and my understanding is is that the license  
17 amendment request template has been made available to  
18 the NFPA-805 task force members and to the rest of the  
19 industry.

20 So in terms of infrastructure, I think  
21 that we've got the right documents in place at the  
22 right level at this point in time.

23 For the next slide -- I'm going to hand  
24 the next slide over to Donnie. But before I move on,  
25 are there any questions with respect to the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 infrastructure?

2 (No response)

3 If not, Donnie is going to talk about fire  
4 PRA methods.

5 MR. HARRISON: And we are going to bounce  
6 back and forth just a little bit between these  
7 different slides as the topics fall into our different  
8 areas. But to followup on the infrastructure, there  
9 is the issue of fire PRA methods. And I'm just  
10 pointing out here that there has been -- fire PRA  
11 methodology guidance has existed for many decades.

12 It dates all the way back to NUREG/CR-  
13 2300, which was written in 1983, which is the PRA  
14 procedures guide. It was high level. It wasn't real  
15 detailed. It gives you a high-level expectation of  
16 what should be in a fire PRA.

17 That was developed with ANS and IEEE.  
18 There was a history between then and now that includes  
19 EPRI's work on FIVE methodology. I remember there  
20 were draft FIVE topical and final topical on the  
21 FIVE methodology, which is a fire-induced  
22 vulnerability evaluation I think, something like that,  
23 that was part of this process.

24 That gets us up to the more recent time.  
25 And as Biff had trouble with spelling NFPA, I have

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701



1 trouble with dates.

2 (Laughter)

3 NUREG/CR-6850 was actually originally  
4 issued in September of 2005, so the 2006 date there is  
5 wrong. It was supplemented in 2010. That was a  
6 collaborative effort between our Office of Research  
7 and EPRI in developing that. There is an EPRI number,  
8 and I always have trouble remembering the EPRI number,  
9 so I will stick with 6850. I will also say NFPA-805  
10 instead of 10 CFR 50.48(c). They are synonymous in my  
11 mind.

12 I do want to point out in this slide -- as  
13 I go through, I'm going to touch on some of the  
14 presentation from the industry. The PRA policy  
15 statement says we should use realistic methods that  
16 are supported by state-of-the-art methods and data.  
17 And they are supposed to be used in a complementary  
18 fashion with the deterministic principles or  
19 approaches of defense-in-depth and safety margins.

20 It is not an optimistic, realistic  
21 approach versus a conservative approach. They are two  
22 different kind of paradigms. There is the  
23 deterministic way of doing things under defense-in-  
24 depth and safety margins, and then there is the PRA  
25 approach, which is an attempt to be a different way of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 looking at problems.

2 So it's not like you are balancing  
3 conservatism and realism. It is two different  
4 approaches. The deterministic world does tend to be  
5 conservative. In PRAs, the goal is to be more  
6 realistic. However, when you don't know something  
7 about a topic, you tend to be conservative even in  
8 PRAs.

9 So I just want to say that as we go  
10 through I'll give some examples from the internal  
11 events that are very similar experiences to what  
12 happens in the fire PRA realm at various times in  
13 their life.

14 I also want to point out that these are  
15 guidance documents. Again, you heard about the staff  
16 looking at these methods, when the industry thought  
17 that they met the PRA standard, that's all they had to  
18 do. I'm constantly correcting this view.

19 The PRA standard is what you have to do.  
20 It's a quality standard that says what is -- what does  
21 a PRA look like? What is the elements? These are not  
22 -- these guidance documents are not that. These are  
23 methodology guidance that tells you how to do that  
24 analysis. They are different. Okay? So you have to  
25 do both.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1           There is not -- you can't just run off and  
2 say, "I met the PRA standard, and oh, by the way, I'm  
3 using some method no one has ever even heard of, and I  
4 made up my data, and here it is. I meet the  
5 standard." You can't do that. There is methods  
6 behind everything.

7           MEMBER BLEY: Can I say -- you have to  
8 meet 1.200.

9           MR. HARRISON: Well, it's a regulatory  
10 guide. It's one acceptable approach to meeting PRA  
11 quality. Someone could actually come in and propose  
12 something else.

13           MEMBER BLEY: So both are --

14           MR. HARRISON: Guidance documents.

15           MEMBER BLEY: -- guidance documents.

16           MR. HARRISON: Right. There is no  
17 requirement for those.

18           MEMBER BLEY: If you meet those, you need  
19 to be happy. If you don't meet those, you want to  
20 understand --

21           MR. HARRISON: Right.

22           MEMBER BLEY: -- what they are doing.

23           MR. HARRISON: Right. That is a good  
24 summary. And, again, there is the acceptable methods  
25 path, which is a much easier review path. If you are

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 not following that path, then you should expect to get  
2 questions for the staff to understand the  
3 acceptability of the method you are proposing.

4 And, again, so these are guidance  
5 documents. They're not regulations. They are not  
6 requirements. Licensees can deviate from those  
7 methods. And, in fact, NUREG/CR-6850 recognizes, just  
8 like all of the other fire PRA methodologies are, they  
9 are progressive screening approaches. I think you --  
10 in an iterative approach, I always grew up in this  
11 area thinking of them as progressive screening  
12 methods.

13 You start at a high screening level. If  
14 you stop there, you are going to get a really high  
15 CDF. If you progress to the next level, you start to  
16 focus in on the areas that are risk-significant, you  
17 will bring that risk number down, and you progress to  
18 focus in on the risk-significant areas until you are  
19 satisfied with the results that you are getting.  
20 That's a decision a licensee needs to make. That is  
21 not something that the NRC dictates.

22 So they can do that. The process allows  
23 them to make those refinements. It may not tell them  
24 the details of how to do the refinements, but it does  
25 allow them to refine the method. And if you do refine

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 the method, you need to have a technical basis for why  
2 you are doing that.

3 So you can't just say, you know, "I did  
4 this analysis, and I did a comparison to what I  
5 expected to see in the industry. And this is 10 times  
6 too high, so I'm going to divide by 10." That's not a  
7 sound technical basis. Okay?

8 I would also caution about using a micro  
9 approach -- again, Sunil kind of referenced this --  
10 when the macro says you might be actually calculating  
11 close to the right numbers. There is a micro part  
12 where you are taking pieces, and then you are  
13 projecting what that means.

14 When the macro is done, you actually get a  
15 number that makes sense. So you've got to balance  
16 that all out. You can't just pick pieces and start --  
17 and nickel and dime the analysis.

18 MEMBER SIEBER: Unfortunately, the macro  
19 approach sometimes causes you to fix the wrong thing.

20 MR. HARRISON: Correct. You would either  
21 be -- and, again, I'm a strong supporter of refining  
22 the methods. I'm a strong supporter of doing the  
23 research and evolving, looking for those areas that  
24 are critical and fixing them.

25 MEMBER SIEBER: Right.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. HARRISON: I am a strong supporter of  
2 that. I just don't want us to be deceived into  
3 thinking I looked at this piece, and that gave me this  
4 answer, therefore, there must be something drastically  
5 wrong with the methods. Again, these methods are  
6 evolving methods. They will continue to evolve.

7 The other point I want to make is  
8 sometimes licensees will not pursue a method  
9 refinement. It may be easier and cheaper to just fix  
10 something in the plant. And in the 805 arena, through  
11 the pilots, that happened. There were fixes that  
12 licensees -- both pilots are committed to implementing  
13 that reduce not just fire risk, but reduce the overall  
14 plant risk.

15 The Harris plant implemented a reactor  
16 coolant pump seal LOCA alternative injection system.  
17 Now, that wasn't their -- it may have been their  
18 dominant fire contributor, but that wasn't really why  
19 they put that mod in. That mod helps them on the  
20 internal event side, where that is one of their most  
21 dominant risk-significant contributors at that plant.

22 So sometimes a licensee, if they can find  
23 a smart fix, they gain some -- lots of benefit, they  
24 can live with a higher number or a simpler method,  
25 because now they can lower it, base it on a physical

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 change at the plant. That has ramifications from the  
2 NRC side. I see that as safety enhancements through  
3 this process. And, again, it is being smart with how  
4 you do that.

5 And the other point I want to make is, you  
6 know, you saw a slide that said the staff is injecting  
7 conservatism into the PRAs. That's not true. I just  
8 want to make that clear.

9 The staff -- oftentimes you can have  
10 disagreements, different interpretations of data, data  
11 is incomplete sometimes, so you have to make judgments  
12 about what the right answer is. Sometimes you  
13 compromise and you pick a half of an event, which you  
14 really can't have a half an event, but without any  
15 information you decide, "I don't know, so I'll say  
16 it's half."

17 That doesn't necessarily mean it's wrong.

18 It means you really just don't know. that's valid.  
19 And so it's not injecting in conservatism. It's  
20 actually looking at the information and making  
21 decisions. And, again, I do want to say Research --  
22 the Office of Research has worked collaboratively with  
23 the industry, with EPRI, in a lot of this area.

24 This is not the NRC going off and looking  
25 at data and saying, "Here's the answer. Now that is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 -- you have to use it." This has been many years of  
2 effort working together, and sometimes you just  
3 disagree on what the answer ought to be. so you have  
4 to make a decision and move forward.

5 I'll stop my rant and move on to --

6 MR. KLEIN: If I could, I would like to  
7 just spend a minute or two on the FAQ. You heard the  
8 industry speak about the FAQ process, the frequently  
9 asked question process, and, you know, their view of  
10 it and the success of it.

11 I've got the opposite view, actually. I  
12 think that the FAQ and the process that was there is  
13 very, very successful. The FAQ process was actually  
14 put in place to enable licensees to develop their  
15 license amendment requests. It provided them with a  
16 stable and predictable regulatory environment, as we  
17 process through these frequently asked questions.

18 We documented the question, we documented  
19 the results, all in public domain, so everybody had  
20 access to it. So as these lessons were learned from  
21 processes, this frequently asked question process was  
22 put in place back in 2006. So it has been five years  
23 in the running. We have met monthly.

24 We have dispositioned, I don't know, 50 or  
25 so some-odd issues ranging anywhere from these PRA

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701



1 issues down to, you know, what does something in NFPA-  
2 805 mean, for example, with power block. We have  
3 questions like that that were dispositioned through  
4 this FAQ process, which I think was a great success.

5 And so I think it facilitated licensees'  
6 ability to develop their transition in their license  
7 amendment request moving forward. So the fire PRA  
8 facts that you heard the industry speak about, we did  
9 put a slightly modified version of the FAQ process in  
10 place.

11 When we recognized that there were some  
12 delays, that things just weren't moving forward, we  
13 wanted to eliminate any of these further delays, so we  
14 put this process in place. And I think we stepped  
15 through that process and were able to at least in some  
16 manner disposition those facts.

17 You heard the industry say that they did  
18 not introduce any further facts into the process. I  
19 think you will hear Donnie talk about perhaps an  
20 alternative way that they will try and address some of  
21 the questions that they have got.

22 That's all I wanted to say about the FAQ  
23 process. Any questions from the Committee on this?

24 (No response)

25 Okay. Let me hand it back to Donnie, and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 he'll complete the rest of the presentation from here  
2 on out.

3 MR. HARRISON: And this follows on with  
4 the FAQ discussion. Again, as Alex said, again, the  
5 professionals can disagree on the interpretation of  
6 data, and I think that was -- the FAQ process early on  
7 was struggling with a number of issues, because there  
8 was -- through the process there was just disagreement  
9 on how to interpret things or how to model specific  
10 things.

11 The June letter that was referenced by NEI  
12 was actually a letter sent out to say we -- this is a  
13 revised way of resolving things, so that we can move  
14 forward. It was actually intended to solve the  
15 problem, not try to inject conservatism or try to  
16 balance. That sentence is just a paraphrase of -- in  
17 the midst of a paragraph, so the real intent was to  
18 move forward, not to make some policy decision in the  
19 midst of that letter.

20 Within the lessons that were learned  
21 through the pilots -- and, again, we had the facts  
22 that -- the 16 related to the PRA that have  
23 subsequently been put into the supplement to the  
24 NUREG/CR-6850. There were also lessons learned during  
25 the pilot reviews that resulted in us revising Reg

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 Guide 1.205.

2 We came to the Committee, I believe it was  
3 last year, with that revision, and talked through why  
4 those things occurred. We had some good Subcommittee  
5 and full Committee discussions on that reg guide and  
6 what led to it actually needing to be revised. And,  
7 again, those were direct lessons learned from the  
8 pilot reviews.

9 Those pilot reviews are also resulting in  
10 the industry developing a license amendment request  
11 template, us developing a safety evaluation template.

12 Those are all geared towards, if you will,  
13 streamlining the path forward, making things a little  
14 more stable and understandable of how the reviews are  
15 going to be at least formatted and how license  
16 amendments are going to be presenting information to  
17 the staff.

18 The staff is also developing a paper on  
19 the additional lessons learned that have come out of  
20 the pilot process, and we plan to issue that lessons  
21 learned paper in I think May of this year.

22 Next slide, Alex.

23 Throughout this process, again, we  
24 recognize that as people use NUREG/CR-6850, and what  
25 it allows, that there would be new methods being

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 proposed. Within, again, the fire PRA when you --  
2 before you make your application to us, the  
3 expectation is the fire PRA gets peer reviewed by the  
4 industry. They have an industry peer review process.

5 The guidance is NEI-07-12 that they follow. That is  
6 endorsed in Reg Guide 1.200.

7 However, it's my understanding that  
8 through the early part of the industry peer reviews  
9 they were identifying issues with these new fire PRA  
10 methods, partly because they hadn't seen them before.

11 So without significant technical basis being provided  
12 as part of that peer review -- and there is a timing  
13 element to peer reviews -- you may not have had the  
14 time to actually -- as a peer reviewer, to get the  
15 information to decide if the method was acceptable.

16 It was difficult for the peer review teams  
17 to accept deviations from the NUREG/CR-6850. Again,  
18 this is the industry peer reviews we are having  
19 trouble accepting deviations.

20 MEMBER STETKAR: Donnie, just for the  
21 benefit of the Committee, neither of the pilot  
22 submittal -- the PRAs in the pilot submittals went  
23 through a full industry peer review. Is that correct?

24 MR. HARRISON: Correct. For their  
25 submittal, they had not been peer reviewed. The

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 staff, through our Rev 0 of the Reg Guide 1.205, we  
2 stated that we would perform audits of their PRAs to  
3 determine their sufficiency/adequacy for the  
4 applications. Subsequently, I believe, is it correct,  
5 that Harris has subsequently been peer reviewed? So  
6 it wasn't as part of our review but afterwards they  
7 have been.

8 So, yes, but the expectation -- and,  
9 again, that was a pilot. That's an exception to what  
10 the normal expectation --

11 MEMBER STETKAR: But the expectation going  
12 forward is that they would come to you --

13 MR. HARRISON: Right.

14 MEMBER STETKAR: -- after at least the  
15 performance of the peer review, not necessarily with  
16 all of the -- as was mentioned earlier --

17 MR. HARRISON: Well --

18 MEMBER STETKAR: -- maybe without all of  
19 the peer review issues resolved.

20 MR. HARRISON: Right. And this is no  
21 different than any other risk-informed application.  
22 And, again, I say that recognizing this is a large  
23 application. Normally, a licensee makes a submittal  
24 to us. The expectation is that you had your peer  
25 review and you resolve findings from those peer

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 reviews before you submit to us.

2 For the 805 plants, we understand there  
3 are situations both in just staffing the peer reviews,  
4 getting them conducted. Again, there is this issue of  
5 new methods that has created some issues. Because of  
6 all those things, there isn't -- we are open to the  
7 idea of them coming and talking to us, explaining what  
8 is left to be done on that aspect of it.

9 Again, it doesn't mean, you know, you  
10 don't have to have a PRA finished. The expectation is  
11 your PRA will be done. You may just have some issues  
12 out there. And, again, maybe this is a prime time to  
13 talk about this. The industry has formed this task  
14 force. I think you heard briefly about that.

15 The expectation is that task force will be  
16 dealing with new methods, so it's -- the peer review  
17 teams have a category that they call "unanalyzed  
18 methods."

19 So if that peer review gets to a piece --  
20 and different peer reviews handle that differently --  
21 some will get to something and they will say, "We  
22 don't understand this. We haven't seen this method  
23 before," and they will take an entire element of a  
24 standard -- again, this is my understanding -- and  
25 say, "We are not going to review this. We will just

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 push this off to an unanalyzed methods category," let  
2 the task force and the industry then address that  
3 method.

4 And then, when the task force is done  
5 doing what it's going to do with that method, and I'm  
6 the interface with that task force, we want to be  
7 aware of what those methods are before they actually  
8 show up at the NRC. So this is a way for us to at  
9 least be engaged, to see them.

10 That then comes back and then can resolve  
11 that peer review. Again, if it's where the peer  
12 review just pushes it off, then there is a question  
13 about what do you have to do to close that review  
14 element. Does the peer review team have to do -- come  
15 back and review that element over again?

16 If a peer review actually looks at each of  
17 the supporting requirements in the peer review, and  
18 finds an unanalyzed method but goes ahead and says,  
19 "It looks like they implemented that method according  
20 to the standard," so we can have our own little  
21 findings, however, we don't know if that method is  
22 acceptable, again, that's another way to push it off  
23 to the task force.

24 That one is a little cleaner in the sense  
25 of when the task force is done. You've already got

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the findings and how that method was applied, if it  
2 was applied through the peer -- the PRA standard. So  
3 then they can just resolve findings from potentially  
4 what's clean and not have to do another focus scope  
5 peer review.

6 MEMBER STETKAR: If I recall right from  
7 the Subcommittee meetings, the task force has been  
8 established. There is this now interface with --

9 MR. HARRISON: Right.

10 MEMBER STETKAR: -- exist. Is the task  
11 force actively involved? In other words, is it  
12 currently reviewing -- it might be a question for the  
13 industry -- in other words, you know, there are in  
14 progress a reasonably large number of PRAs that are  
15 targeting submittal, you know, in now about four and a  
16 half months I think.

17 Is the task force actively involved in  
18 making determinations that, yes, indeed, for Plant X,  
19 Creative Method Y seems reasonable, and, therefore,  
20 you know, and NRC is signed on to that, so, therefore,  
21 all of the plants in progress could, in principle, use  
22 that?

23 MR. WACHOWIAK: This is Rick Wachowiak  
24 from EPRI. Where we are right now is that one vendor  
25 has submitted a document that contains new methods to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 EPRI look at, and another vendor has indicated an  
2 intent to send in a method but has not actually sent  
3 it yet.

4 I looked at the one that was submitted and  
5 determined that the information that was submitted,  
6 while it explained the method, was not sufficient to  
7 go and put together a team and have it reviewed to  
8 accomplish what we are trying to do. So I sent back a  
9 list of things that I need in order to establish a  
10 team that has independence and has the right expertise  
11 and can review the method along with and an example  
12 implementation of the method.

13 MEMBER STETKAR: So they were saying what  
14 they were doing, but not necessarily why or the  
15 background.

16 MR. WACHOWIAK: Yes, there are some pieces  
17 missing. So right now that's where we are on the  
18 first one, and the other vendor that has not yet given  
19 their method, I also said this is all the things you  
20 need to have to make it a complete submittal.

21 So I am hoping that in the next few weeks  
22 we will have the information back, and I will be able  
23 to start establishing the first team that will pilot  
24 it on -- on the method.

25 MEMBER STETKAR: Thanks. Good. That

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 helps.

2 MR. HARRISON: So we're in the early  
3 stages.

4 MEMBER STETKAR: Yes, I just wanted to  
5 make sure that I --

6 MR. HARRISON: And, again, that's partly  
7 why the staff was wanting to have these conversations  
8 with licensees. One is to find out exactly how many  
9 plants are doing what method. And, again, the intent  
10 of the staff is to gain efficiency by -- and we  
11 mentioned this yesterday at the public meeting. If  
12 multiple plants are using the same method that is off  
13 with this task force, when that gets resolved then  
14 that will apply to all of those plants, all of those  
15 licensees. So we want to gain efficiency that way.

16 I will speed up, because I was reminded  
17 that we are approaching 6:00. I do want to point out  
18 that NFPA-805 -- well, I can do it on this one. NFPA-  
19 805 actually requires that the -- what does AHJ stand  
20 for?

21 MR. KLEIN: Authority having jurisdiction.

22 MR. HARRISON: Authority having  
23 jurisdiction. The NRC -- it requires the NRC to  
24 actually -- the methods used have to be acceptable to  
25 us. So that is a difference between normal

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 applications that we get. We actually have a --  
2 essentially a rule telling us that the methods have to  
3 -- we have to find those methods acceptable. And so  
4 that may be also why you're seeing the NRC is a little  
5 more engaged on methods, a detail that we might not be  
6 on other types of applications. That being --

7 MEMBER BROWN: Does that mean in advance,  
8 before they submit it, accept it in --

9 MR. HARRISON: What I would say is  
10 typically the way methods are approved are through  
11 topical report reviews or through industry guidance  
12 documents that get submitted to the NRC in advance of  
13 submittals. And then, we endorse those methods. We  
14 do this in risk-informed in-service inspection. There  
15 is at least two methods, plus ASME Code cases, that we  
16 actually review, endorse, and then people start making  
17 submittals that cite those topical reports.

18 MEMBER BROWN: Okay. That's what I meant.  
19 So you do it in advance, in other words.

20 MR. HARRISON: Right.

21 MEMBER BROWN: So they're not sending it  
22 in and then hoping that you will eventually agree.

23 MR. HARRISON: Right. Typically. I mean,  
24 I can't say categorically that is always the case. It  
25 is -- sometimes the method will come in. Sometimes we

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 discover a new method in the midst of a review --

2 MEMBER BROWN: Okay.

3 MR. HARRISON: -- that we hadn't seen  
4 before, and then we start asking questions and driving  
5 towards, is that an acceptable method or not? But the  
6 normal pathway is to do it up front.

7 And, again, there are similarities between  
8 that part, because of the topical reports, and I will  
9 just say this quickly. Reactor coolant pump seal  
10 LOCAs -- again, that is important to the industry --  
11 there were questions about the model that was being  
12 used and how you model that in your PRA.

13 There was arguments that it was overly  
14 conservative, and much of what you're hearing about  
15 fire PRA you heard about reactor coolant pump seal  
16 LOCA models. We then had two topicals, one for --  
17 well, two different vendors made applications through  
18 topical reports to us to endorse different models.  
19 Those went through reviews by the staff.

20 We eventually endorsed, with certain  
21 conditions and limitations on those models, their use,  
22 and now they are used. So, again, that is the normal  
23 process.

24 And that takes me to this, actually. What  
25 usually drives model enhancements are because either

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 there is large model uncertainties that -- the  
2 industry will say conservatism. I say there is large  
3 uncertainties. When you have large uncertainties, you  
4 tend to use conservative numbers, if you don't  
5 understand the topic that well.

6 So it is large model uncertainties can  
7 drive you to do -- to proceed towards trying to find  
8 ways to enhance the model. You might have to do  
9 testing. You might have to collect additional data to  
10 try to do that.

11 The other thing you look at is, what's  
12 driving your risk results? Is it a significant  
13 contributor to the results? If it is, that's an area  
14 where you want to look and say, "Let's start there to  
15 enhance the model."

16 This is true for internal events, external  
17 events, fires is part of that. So that's just the  
18 normal approach. The staff will continue to actively  
19 be involved in these activities.

20 Again, Research is involved with EPRI  
21 under a Memorandum of Understanding. NRR has  
22 established this interface with the industry fire PRA  
23 methods task force. Again, I do believe there are  
24 places in the method that are probably conservative  
25 and need to be worked on. However, I also don't think

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 the ceiling is falling down on us either, so --

2 VICE CHAIRMAN ARMIJO: I just want to make  
3 sure that you clearly do not support any extension in  
4 the time, extended schedule for the submittals.

5 MEMBER BLEY: I don't think staff can do  
6 that.

7 VICE CHAIRMAN ARMIJO: You haven't made --  
8 that's not your decision.

9 MR. HARRISON: That's not my job.

10 (Laughter)

11 VICE CHAIRMAN ARMIJO: But your arguments  
12 sound to me that it is -- they are ready to go now.  
13 They could submit stuff to you on time. That's what I  
14 got out of what you said.

15 MR. HARRISON: Yes. Yes, we can jump  
16 right to the conclusion. I -- I think it -- the proof  
17 is in the pudding. We have had two pilots. We wrote  
18 SEs. Somehow they got through this process. So they  
19 got -- they made submittals, we learned a lot of  
20 lessons through that, we issued safety evaluations for  
21 both of those pilot applications. They are 805  
22 plants.

23 The pilots have identified practical  
24 safety enhancements. You have protected surface water  
25 at Oconee, which is a major benefit. You have the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 reactor coolant pump alternate fuel injection at  
2 Harris. Both of those mods are really not fire mods.

3 Harris also did incipient detection,  
4 which, by the way, I will caution. On the incipient  
5 detection model, the staff attempted to be as  
6 realistic as possible. Some would say we were  
7 actually overly optimistic about the performance of  
8 the reliability of those incipient detectors. Time  
9 will tell. We will be collecting data on their  
10 performance.

11 But, again, that is a wrinkle that we have  
12 to be cautious about -- again, this micro versus macro  
13 level. If you put in an incipient detector, you now  
14 can't count fires, because the incipient detector  
15 caught them before they got to be a fire.

16 How do you address that in your initiating  
17 event frequency? They are intertwined now. The  
18 system and the initiating frequency are intertwined  
19 together. So you can't just go use the generic  
20 industry data if you're that plant.

21 MEMBER BROWN: What's wrong with detecting  
22 a fire and putting it out before it --

23 MR. HARRISON: It's not that --

24 MEMBER BROWN: -- seems like a good plan  
25 to me.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           MEMBER STETKAR: Part of it is that the --  
2 we need to be aware of the time, but part of it is the  
3 industry data has gone through a screening process  
4 where they have thrown out fires that were really  
5 small.

6           MEMBER BROWN: And here it doesn't exist.  
7 I mean, it's not only very small, it is --

8           MR. HARRISON: Right. But now you're  
9 relying on -- what I'm saying is when that plant goes  
10 back to update its data, and it starts counting fires,  
11 well, there aren't any at that plant potentially  
12 unless the incipient detector fails. And then, you  
13 might get some surprises.

14           There is a tradeoff that is going on, and  
15 so you've just got to be aware of it. It's more to be  
16 aware how you count your generic data, because that  
17 doesn't apply to you anymore. You've got incipient  
18 detectors.

19           MEMBER STETKAR: But you could have a  
20 hundred shots at the incipient detector to work, and  
21 the one time it failed you then have a fire. But if  
22 you only counted one fire, because it was big enough,  
23 you can't take a 99 percent reliability of the  
24 incipient detector for that --

25           MR. HARRISON: You're double-counting the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701



1 reliability of the system. So, again, it's just --  
2 again, the caution you want to make is --

3 MR. WEERAKKODY: But they are good. We  
4 like the incipient detectors.

5 MEMBER BROWN: I'm just sorry. I would  
6 always opt to keep the fire from starting, even if I  
7 lost data.

8 MEMBER BLEY: Nobody is saying the  
9 opposite. They are saying be careful how you treat  
10 the data to say --

11 MEMBER BROWN: No. We're going to say,  
12 "Don't put this stuff in, because you're going to ruin  
13 our data."

14 (Laughter)

15 Excuse me for --

16 MEMBER STETKAR: Let's wrap up here,  
17 because we -- you guys get to go home. We don't.

18 MR. HARRISON: We believe the methods are  
19 sufficiently mature to be able to be used to support  
20 an application. And they are going to continue to  
21 evolve, and the staff is going to support working with  
22 the industry to make sure there is a technical basis  
23 for those new methods as they come through.

24 MR. WEERAKKODY: Okay. And I don't have  
25 anything else to say, unless there are questions.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: Very good. Any members  
2 have any questions for the staff?

3 (No response)

4 If not, thank you very much. Again, I  
5 really appreciate you compressing an awful lot of  
6 information into about 45 or 50 minutes, which is a  
7 heroic effort. So thanks. Thanks very, very much.

8 And with that, Mr. Chairman, I turn it  
9 back to you.

10 CHAIRMAN ABDEL-KHALIK: Thank you. All  
11 right. At this time, we are off the record.

12 (Whereupon, at 6:07 p.m., the proceedings in the  
13 foregoing matter went off the record  
14 briefly.)

15 MEMBER STETKAR: Keep us on the record, if  
16 you could. Are there any members of the public who  
17 would wish to make a statement?

18 (No response)

19 If not, thank you. So off the record.

20 (Whereupon, at 6:07 p.m., the proceedings in the  
21 foregoing matter went off the record.)

22

23

24

25

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

# Palo Verde Nuclear Generating Station

ACRS Full Committee Meeting for License Renewal

February 10, 2011



# **John Hesser**

**Vice President  
Nuclear Engineering**



# Palo Verde Nuclear Generating Station

## *Personnel In Attendance*

- **Angela Krainik**, Department Leader, License Renewal
- **Mark Radspinner**, Supervisor, Mechanical Primary System Engineering
- **Glenn Michael**, Lead Licensing Engineer
- **Eric Blocher**, Project Manager, STARS
- **Technical Staff**
  - Randal Boyd, License Renewal Implementation Engineer



# Agenda

- **Plant Overview**
  - Station Description
  - Plant History
- **Safety Evaluation Report**
  - Open Item and Confirmatory Item Closure
  - Additional Item Resolution
- **License Renewal Implementation Progress**
- **Concluding Remarks**



# Our Mission...

**SAFELY** and efficiently generate  
electricity for the long term.



# Station Description

- **Three Common-Design Units**
  - Common Operating Procedures
  - Maintain Common Design
  - 3990 MWt /1346 MWe per Unit
- **Combustion Engineering System 80 — Nuclear Steam Supply System**
- **General Electric — Turbine Generator**
- **Bechtel Power Corporation — Architect and General Contractor**






# Plant History and Background

- **Initial Construction Permit — May 1976**
- **Operating Licenses Issued**
  - Unit 1: June 1, 1985
  - Unit 2: April 24, 1986
  - Unit 3: November 25, 1987
- **Operating Licenses Expire**
  - Unit 1: June 1, 2025
  - Unit 2: April 24, 2026
  - Unit 3: November 25, 2027



# License Renewal



# **Angela Krainik**

**Department Leader  
License Renewal**



# License Renewal Program

- Safety Evaluation Report items
- Implementation Status



# Safety Evaluation Report (SER) License Renewal

- **Open Item - Closed**
  - Open Item 4.3-1 Metal Fatigue resolved
- **Confirmatory Items (5) – Complete**
  - Example – Confirmatory Item 2.1.4.2
    - Spray Chemical Addition Tanks drained



# Safety Evaluation Report (SER) License Renewal (continued)

- **Additional Items - Resolved**
  - Inaccessible Medium Voltage Cable
    - Low Voltage Cable to be added to Aging Management Program
  - Buried Piping and Tanks
    - Diesel Fuel Oil pipe inspection included
  - NUREG/CR-6260 Limiting Locations
    - Commitment to Confirm Limiting Locations
  - Selective Leaching Sample Size
    - Documented Sample Size Criteria
  - Steam Generator - Divider Plate Bar Welds and Tube-to-Tubesheet Welds
    - Welds added to Aging Management Program



# License Renewal Program Implementation Status

- 40 Aging Management Programs
- 149 Procedures Required to Implement Aging Management Programs
  - 132 Complete
  - 17 Work in Progress
    - 3 new procedures
    - 14 revisions in process



# Implementation and Sustainability

- **Implementation Engineer on Staff**
  - Developing License Renewal Implementation Plan
- **Participating in NEI License Renewal Implementation Working Group**
- **Benchmarking Others in the Industry**
  - Lessons-learned captured
- **Incorporated into Palo Verde Long-Range Plan**





# **John Hesser**

**Vice President  
Nuclear Engineering**



# License Renewal



# Our Mission...

**SAFELY** and efficiently generate  
electricity for the long term.





United States Nuclear Regulatory Commission

*Protecting People and the Environment*

# **Advisory Committee on Reactor Safeguards**

## **Safety Evaluation Report Palo Verde Nuclear Generating Station**

February 10, 2011

Lisa Regner, Project Manager

Office of Nuclear Reactor Regulation

# Introduction

- **Overview**
- **Closure of Open Item**
- **Closure of Confirmatory Items**
- **Resolution of Other Topics of Interest**
- **Conclusion**

# Overview

- Safety Evaluation Report (SER) with Open Items was issued August 6, 2010
- The Open Item and Confirmatory Items for the SER are closed
- Region IV Administrator's Letter of Recommendation received January 7, 2011.
- The final Safety Evaluation Report (SER) was issued January 11, 2011

# Metal Fatigue Concerns Resolved

## Reactor Vessel Instrument Nozzle CUF Differences

- All units consider the effect of vortex shedding
- Unit 1 more conservative, simplified analysis yielding higher CUF
- Units 2 & 3 used more refined analysis in critical areas

## Environmental Factors ( $F_{en}$ ) Analyses

- $F_{en}$  for low-alloy steel and stainless steel components is conservative relative to the assumptions of dissolved oxygen content, max temperature, and strain rate.
- Committed to perform a reanalysis of pressurizer nickel-alloy heater penetrations using NUREG/CR-6909

# Metal Fatigue Concerns Resolved

## 25 Percent Transient Occurrence Assumption

- Transient numbers verified by logs, LERs, operating reports, and test records
- Staff confirmed that applicant's use of 25% was conservative

## Cycle-Counting Procedure

- Amended the program description and enhancement to reflect the applicable TS tracking and counting requirements in TS 5.5.5
- Committed to update the cycle counting surveillance procedure to include a transient that is not currently being counted (completed)



# Confirmatory Items

## Scoping of Liquid-filled Tanks

Tanks were drained of liquid and are no longer in scope for license renewal.

## Aging Management of Elastomers

Components were found not to be susceptible to erosion since they are in low-velocity systems with low particulate levels. Items will be managed by the Internal Surfaces Monitoring Program.

## Cavitation Erosion

Applicant committed to complete inspections of susceptible piping locations by July 2012. Components found to exhibit flow-related degradation are incorporated into the replacement plan.

# Confirmatory Items

## **Steam Generator Feeding Flow Accelerated Corrosion**

Staff confirmed that feeding material is FAC resistant. Further, the applicant's SG tube integrity program considers this aging mechanism during secondary side assessments performed every outage.

## **One-Time Inspection of Small-Bore Piping**


Applicant committed to inspect 10% of its Class 1 socket welds for each unit (maximum of 25 welds) using ultrasonic testing, and use a sample selection methodology to inspect the most susceptible and risk significant welds.

## **Resolution of Other Topics of Interest**

- Inaccessible Medium Voltage Cables
- Buried Piping and Tanks Inspection
- Environmentally-Assisted Fatigue Analyses
- Selective Leaching Program Sampling Criteria
- Steam Generator Aging Effects

# Conclusion

On the basis of its review, the staff determines that Arizona Public Service Company has met the requirements of 10 CFR 54.29(a) for renewal of the licenses for Palo Verde Nuclear Generating Station, Units 1, 2, and 3.



**U.S. NRC**

United States Nuclear Regulatory Commission

---

*Protecting People and the Environment*



*SCE&G • Santee Cooper  
Shaw • Westinghouse Electric Company*


# **VC Summer Unit 2/3 Site Overview & SAR Section 2.5**

**Bob Whorton**

**SCE&G - Consulting Engineer**



# VC Summer Unit 2/3





# Unit 1 – 2007 Aerial Photo



UNITS 2/3





State Access Rd

© 2010 Europa Technologies  
US Dept of State Geographers  
© 2010 Google  
© 2010 Tele Atlas

# U2 Power Block Excavation & Geologic Mapping



# Unit 2 Power Block Excavation





© 2010 Europa Technologies  
US Dept of State Geographers


© 2010 Google

© 2010 Tele Atlas

# NUCLEAR ISLAND EXCAVATION – JANUARY 2011



# **SAR SECTION 2.5 TECHNICAL DEVELOPMENT**





# **SUMMER - SEISMIC TECHNICAL ADVISORY GROUP (TAG)**


- **Dr. Martin Chapman – Virginia Tech**
- **Dr. Allin Cornell – Stanford**
- **Dr. Robert Kennedy – Consultant**
- **Mr. Don Moore – Southern Company**
- **Dr. Carl Stepp – Consultant**


# **SCE&G VC Summer COL**

## **FSAR Sections 2.5.1 and 2.5.3**

### **Basic Geologic and Seismic Information & Surface Faulting**

# 200-mi Map of Tectonic Features







# 25-mi Geologic Map

Modified from Horton and Dicken (2001), Hibbard et al (2006), and Secor (2007)


# 5-mi Geologic Map




# 0.6-mi Surficial Geologic Map



# Top of Sound Rock Beneath Units 2 and 3




# Unit 1 Foundation Map



## Explanation

- |  |   |
|--|---|
| <span style="background-color: yellow; border: 1px solid black; padding: 2px;">B</span> Contact breccia                    | Pink-filled fractures with sense of slip as shown; U = upside, D = downside |
| <span style="background-color: lightgreen; border: 1px solid black; padding: 2px;">CBGN</span> Charlotte belt gneiss       | Other fractures with sense of slip as shown                                 |
| <span style="background-color: orange; border: 1px solid black; padding: 2px;">MG</span> Migmatite of gneissic composition | Displaced vein with dip   |
| <span style="background-color: yelloworange; border: 1px solid black; padding: 2px;">GF</span> Granofels                   | Geologic contact  |
| <span style="background-color: lightbrown; border: 1px solid black; padding: 2px;">GD</span> Medium-grained granodiorite   | Angle boring  |
| <span style="background-color: pink; border: 1px solid black; padding: 2px;">R</span> Fine-grained granodiorite            | Overcone boring   |
| Aplite and/or pegmatite dike   |   |



Map modified after Dames & Moore (1975), Addendum I

## UNIT 1



# Unit 1 Surface Faulting Summary

- Small bedrock shears were mapped in the excavation. After extensive evaluations and age dating, these minor features were demonstrated to have last moved between 300 and 45 Ma
- It was concluded that minor bedrock shears exist throughout site area, but these do not represent a surface rupture hazard

# Unit 1 Excavation (Northeast View)



1973

# Unit 1 Excavation (South View)



1973

# UNITS 2 & 3 CONCLUSIONS

- Consistent with the results of the Unit 1 investigation, it was expected that excavations for Units 2 & 3 would expose similar shear features, and a few minor ones have now been observed
- Units 2 & 3 excavation are being geologically mapped with results documented and reviewed by NRC Staff (initial visit in August 2010 and one planned for March 2011)

# UNITS 2 & 3 CONCLUSIONS


- Current geological investigations have not identified any new data to change our current interpretations
- SAR Section 2.5.1 concludes that the shear features are not capable tectonic sources and do not represent ground motion or surface rupture hazards to the site

# **SCE&G VC Summer COL**

## **FSAR Sections 2.5.2**

### **Vibratory Ground Motion**

# Updated Seismicity Catalogs




# Probabilistic Seismic Hazard Analysis


- Replicated the 1989 EPRI hazard results
- Evaluated effects of updated seismicity
- Updated the Charleston seismic source zones
- Developed Seismic Hazard and UHRS (hard rock)
- Developed V/H ratios and GMRS (hard rock)



# Historical seismicity in vicinity of Summer site and three areas used to test the effects of additional seismicity




# Geometry of Four Sources Used in Updated Charleston Seismic Source (UCSS) Model




# Summary of VC Summer Seismic Source Model

- No new Capable Tectonic Sources were identified within the site region
- No modifications to the Eastern Tennessee Seismic Zone were required
- Updated Charleston model replaced the EPRI sources (as adopted from Vogtle)
- New Madrid Source was added (which adopted the Clinton characterization)

# Mean and Median Uniform Hazard Response Spectra



# Horizontal and Vertical GMRS



V. C. Summer Nuclear Station, Units 2 and 3  
COL Application  
Part 2, FSAR




Figure 2.0-201. Comparison Plot of V. C. Summer GMRs and HRHF Spectra for the Horizontal Component of Motion

# **SCE&G VC Summer COL**

## **FSAR Sections**

### **2.5.4**

## **Site Geotechnical Characterization/ Foundations**


# Description of Subsurface Materials

- **Residual Soil** – reddish silty sands and sandy silts with variable clay content
- **Saprolite** – completely weathered rock but w/preserved relict rock structure, mainly silty sands
- **Partially Weathered Rock (PWR)** – decomposed rock matrix mixed w/semi-hard rock fragments
- **Moderately Weathered Rock (MWR)** -- >50% by volume of sound rock interspersed w/decomposed zones
- **Sound Rock** – Hard fresh to slightly discolored rock (granodiorite, quartz diorite, gneiss, schist, migmatite)




# 2.5.4.7.2 Vs Average at 5 Ft Intervals

Shear Wave Velocity (ft/sec) - Unit 2



UNIT 2

Shear Wave Velocity (ft/sec) - Unit 3



UNIT 3

## Section 2.5.4.8 Liquefaction Potential

- Nuclear Island is on sound rock or on concrete on sound rock
- Power Block structures, including Seismic Category II Annex Building and Turbine Building (1<sup>st</sup> Bay) are on compacted structural fill above rock
- There is no saprolite within the zone of influence of the foundation loading of the Seismic Category I / II structures

**CONCLUSION: Liquefaction cannot impact plant safety**

# Comments



*SCE&G • Santee Cooper  
Shaw • Westinghouse Electric Company*

# **VC Summer Units 2 and 3 Liquid Radwaste/ Waste Water System Interface and Discharge**

**Tim Schmidt – Engineer  
SCE&G New Nuclear Deployment**


# Topics of Interest

- Interface of the Liquid Radwaste System (WLS) with the Waste Water System (WWS)
- WWS blowdown line to the plant outfall at Parr Reservoir

# Design Considerations

- Meets regulatory requirement (10CFR20.1406) and guidance (RG 4.21)
  - Monitored manhole at WWS/WLS interface
- Incorporated industry OE and lessons learned into the WWS design
  - HDPE utilized versus carbon steel, ductile iron or fiberglass
  - No pumps, valves or vacuum breakers along the line
  - Blowdown flow is via gravity

# Design Overview



# HDPE Installation Example





# Construction Considerations

- Construction requirements ensure long-term integrity
  - Qualified welders and processes
  - Proven installation techniques based on operating experience
  - Weld inspections
  - Hydrostatic testing
- Expect long life with HDPE
  - Over 40 years industry experience with HDPE
  - Over 10 years experience in Nuclear HDPE applications

# Summary

- Single wall design of the WWS beyond the dilution point provides reasonable assurance of leak free service
- WWS blowdown line installation and testing processes assure reliable long term operations

# Comments



*SCE&G • Santee Cooper  
Shaw • Westinghouse Electric Company*

# **VC Summer Units 2 and 3**

## **FSAR Section 13.3**

### **Emergency Planning**

Tim Bonnette

SCE&G – Emergency Preparedness

# Presentation Overview

- Emergency Plan Design
- DCD Departure
- Emergency Facilities
- Emergency Response
- Emergency Planning Zone
- Public Awareness

# Emergency Plan Design

- Single plan for all three Units
- Developed in accordance with:
  - NUREG-0654/FEMA-REP-1 Rev 1
  - 10 CFR 50.47
  - 10 CFR 50 Appendix E
- Emergency Action Level (EALs) developed in accordance with:
  - NEI 07-01 Rev 0 (Units 2 & 3)
  - NEI 99-01 Rev 5 (Unit 1)

# DCD Departure


- VCS DEP 18.8-1 – Locations of the Technical Support Center (TSC) and Operational Support Center (OSC)
  - TSC will be located in the New Nuclear Operations Building
  - Each OSC for Units 2 & 3 will be located in its respective Annex Building, in the area designated as the DCD TSC (DCD Elev 117' 6").

# Technical Support Center


- Common for all three Units
- Meets the requirements of NUREG-0696, with exception of being adjacent to the Control Rooms
- Incorporates human factors engineering (HFE) to support emergencies involving one, two, or three Units



# Technical Support Center Location



# Site Map- Exclusion Area



# Emergency Facilities

- 3 Control Rooms
- 3 Operational Support Centers (OSC)
- Technical Support Center (TSC)
- Emergency Operations Facility (EOF)
- Joint Information Center (JIC)


# Emergency Response

- Site level emergency response
- Protected Area level emergency response
- Single Unit emergency response

# Emergency Planning Zone (EPZ)

- EPZ boundaries remain the same
- Agreed upon by the State of SC and the risk counties (Fairfield, Lexington, Newberry, & Richland)
- Reviewed and accepted by FEMA

# EPZ Map



# Public Awareness

- Annual Calendar Distribution
  - Details actions and guidance for members of the public
  - Distributed to all residents and businesses within the EPZ
  - Includes self addressed and postage paid cards for residents with special needs
- Press Releases
- Emergency Responder Training

# Comments





*SCE&G • Santee Cooper  
Shaw • Westinghouse Electric Company*

# **VC Summer Units 2 and 3 FSAR Chapter 8**

**James LaBorde – Consulting  
Engineer**


**New Nuclear Deployment**

# Section 8.2


## Offsite Power

- 12 overhead transmission lines connect the new 230 kv switchyard to other substations
- Switchyard is robust
- Failure Analysis performed
- Grid Stability Study performed
  - Includes the Westinghouse interface requirement for maintaining Reactor Coolant Pump voltage for 3 seconds after a turbine trip

# Units 1, 2, & 3 Transmission Lines



# Switchyard Single-line Diagram



# Comments



*SCE&G • Santee Cooper  
Shaw • Westinghouse Electric Company*

# **VC Summer Units 2 and 3 Application Overview and Required Siting Characteristics**

Amy Monroe

SCE&G – Licensing Engineer




LEE

SUMMER

VOGTE

# VCSNS Units 2 and 3 AP1000





# Departures

- 2 Standard
  - Section numbering
  - Testing of the voltage regulating transformer
- 3 VCSNS site specific
  - Section numbering
  - Technical Support Center/Operational Support Center relocation
  - Wet bulb temperature

# Exemptions

- 2 Standard
  - Section numbering
  - 10 CFR 70
- 1 Site Specific
  - Wet bulb temperature DCD siting requirement

# Project Overview

- Co-owned with South Carolina Public Service Authority (Santee Cooper)
- EPC with Consortium – Westinghouse Electric Company and Shaw Group
- Other Technical Support

# Site Characteristics

- Typical southeastern climatology
- Wind and tornado conditions bounded by DCD wind and missile design requirements
- No flooding issues
- Consistent with DCD requirements, VCSNS is characterized as a hard rock site

# Regional Climatology

- The general climate in the region is characterized by mild, short winters; long periods of mild sunny weather in the autumn; somewhat more windy but mild weather in spring; and long, hot summers.

# Meteorological Data

- Initially 3 years of data obtained from VCSNS Unit 1 Metrological Towers
- Subsequently data from newly constructed Units 2 and 3 Metrological Tower was utilized to update COLA
- Overall conclusions remained consistent based on new data

# Exemption

- Humid conditions resulted in a maximum safety wet bulb (noncoincident) air temperature of 87.3°F, a value 1.2°F above the AP1000 DCD value of 86.1°F
  - The technical basis for the acceptability of the exemption is documented within the FSAR.

# Hazard Sources

- VCSNS Unit 1 is located approximately 1 mile to the north
- Railroad line runs along Broad River west of the site
- Gas Pipeline runs from the south to the Parr Facility which is located approximately 1 mile south of the site
- Marine, aeronautical, additional industrial hazards are either N/A or probabilistically insignificant



# Comments



*SCE&G • Santee Cooper  
Shaw • Westinghouse Electric Company*

# **VC Summer Units 2 and 3 Chapters 5, 6 and 9 Site –Specific Wet Bulb Temperature Exemption**

Amy M. Monroe – Licensing  
New Nuclear Deployment  
Mark Stella - Westinghouse

# Basis for Exemption Request

- NRC RAI on site temperature limits generated during COLA review
- 100-year ambient wet bulb return temperature for site determined to exceed DCD maximum safety wet bulb limit
- Several areas potentially affected by the higher wet bulb temperature at the site

# Wet-Bulb Temperature Exemption

- Site-specific maximum safety non-coincident wet-bulb temperature was determined to be 87.3°F (1.2°F above the AP1000 DCD Tier 1, Chapter 5, Table 5.0-1 value) based on the 100 year return value.

# Evaluation of Impacts

- Evaluated AP1000 systems to determine those affected by change in maximum safety wet bulb temperature
- Assessed performance of systems and components affected by quantitative evaluations and calculations
- Performance of systems still acceptable with increased wet bulb temperature

# AP1000 DCD Areas Potentially Affected and Outcomes of Assessments

- 6.2.2 – Passive Containment Cooling System Performance – *negligible pressure increase*
- 5.4.7.1.2.3 – Normal Residual Heat Removal System – In-Containment Refueling Water Storage Tank temperature control – *minor increase in IRWST fluid temperature; remains well below saturation temperature*

# AP1000 DCD Areas Potentially Affected and Outcomes of Assessments

- 9.2.2.1.2.1 – Component Cooling System – Normal Operation temperature limit – *maximum CCS temperature remains below limiting temperature for acceptable RCP cooling (100°F)*
- 9.1.3.1.3.1 – Spent Fuel Pool Cooling – Partial Core shuffle (Normal refueling pool temperature control) – *SFS pool temperature remains below 120 °F*

# AP1000 DCD Areas Potentially Affected (continued)

- 9.2.7.2.4 – Central Chilled Water System – Normal Operation - *effect of increased wet bulb temperature on MCR cooling, instrument and battery room cooling, and pump room cooling can be accommodated within the available capacity margin of the air-cooled chiller units*



# Safety Systems Not Impacted

- Systems affected only by Maximum Safety Dry Bulb Temperature
- Systems whose performance is based on the Maximum Normal Non-coincident Wet Bulb Temperature or on the Coincident Maximum Dry Bulb and Wet Bulb Temperature

# Comments




*SCE&G • Santee Cooper  
Shaw • Westinghouse Electric Company*

# **VC Summer Units 2 and 3 FSAR Section 2.4**


**Steve Summer**

**SCANA Services – Supervisor  
Environmental Services**


# Major Surface Water Features



# Site Topography



# Groundwater



# Groundwater


- Design plant grade elevation is 400 feet NAVD88.
- The maximum allowable groundwater level is 398 feet NAVD88 (AP1000 DCD).
- The maximum expected groundwater level is 380 feet NAVD88 (20 feet below the plant grade elevation), well below DCD value.

# Major Items of Interest


- Accidental Release of Liquid Effluents into Ground and Surface Water
  - Evaluation shows that an accidental liquid release of effluents in groundwater would not exceed 10 CFR Part 20 limits.
  - Three conceptual flow transport models (one saprolite and two bedrock) are presented.




# Saprolite Pathway (conceptual)



# Bedrock Pathway to Broad River or Mayo Creek (conceptual)



# Bedrock Pathway to the site boundary below Mayo Creek (conceptual)



# Comments



**U.S.NRC**

UNITED STATES NUCLEAR REGULATORY COMMISSION

*Protecting People and the Environment*

# **Presentation to the ACRS Full Committee**

**V.C. Summer Nuclear Station Units 2 and 3 COL  
Application Review**

**Advanced Safety Evaluation Section 2.5  
Geology, Seismology, and Geotechnical Engineering**

**February 10, 2011**

# Staff Review Team

- Technical Staff
  - Dr. Clifford Munson, Senior Level Advisor and Seismologist
  - Dr. Yong Li, Senior Geophysicist
  - Dr. Gerry L. Stirewalt, Senior Geologist

# Overview

- Section 2.5

- Topics of Interest

- Action item from July 2010 ACRS meeting to compare EPRI seismic source model used by applicant with most recent USGS model
    - Field observations by NRC geologists on geologic mapping of the Unit 2 excavation for assessing the presence of potential tectonic features (August 2010)

# EPRI and USGS Seismic Source Model Comparisons

- Applicant compared EPRI seismic source model with USGS (2002) but not USGS (2008) models
- USGS seismic source models used to develop National Seismic Hazard Maps
  - Maps used for Building Codes and National Standards
  - Maps Target 500 yr to 2500 yr ground motions
- NRC Regulatory Guide 1.208:
  - Specifies a minimum ground motion return period of 10,000 years for site SSE
  - Recommends use of EPRI or LLNL seismic hazard models as a starting point to develop site SSE
  - Recommends using USGS source models for comparison (magnitude, earthquake recurrence, etc.)




# EPRI and USGS Seismic Source Model Comparisons (cont.)


- USGS uses a single  $M_{\max}$  value of 7.5 for one large extended margin seismic source zone
- EPRI developed many source models which have  $M_{\max}$  values ranging from about M5 to M7
- EPRI and USGS Charleston seismic source models are similar
  - Maximum Magnitudes:  $M=7.2$  (USGS) vs  $M=7.1^*$  (EPRI)
  - Recurrence Interval: 550 yrs (USGS) vs 630 yrs\* (EPRI)
  - EPRI Source Geometries more detailed than USGS

\* average value

# USGS Source Model for Charleston



# Updated EPRI Source Model for Charleston



# USGS (2008) Seismic Source Model Updates

- USGS (2008) updates
  - Maximum magnitude distribution replaced single value (M=7.5 vs M=7.1 to M=7.7)
  - Updated ground motion attenuation models
  - Charleston source model enlarged offshore
- Overall USGS (2008) results 10 to 15% lower than USGS (2002) for CEUS (USGS OFR 2008-1128)
- Staff to update Summer SER to include latest USGS models


## 2.5.1 Basic Geologic and Seismic Information

- **Update on observations by NRC geologists on geologic mapping of the Unit 2 excavation to assess the presence of tectonic features**
  - License Condition 2.5.1-1 requires the applicant to perform geologic mapping of excavations for safety-related structures; evaluate geologic features discovered; and notify NRC when excavations are ready for examination.
    - Minor shear zones proven by the applicant to be at least 45 Ma in age were mapped in the Unit 1 excavation, and similar features may occur in the excavations for Units 2 and 3.
  - In August 2010, staff directly examined geologic features being mapped by the applicant in the Unit 2 excavation to ensure that no capable tectonic structures existed therein.

Potential tectonic features were carefully examined by NRC geologists



Tectonic features are present, but field relationships indicate they are very old and not capable tectonic structures



Small-scale healed shear fracture cutting an igneous vein



Shear zone cross-cut by igneous veins that show no offset.



## 2.5.1 Basic Geologic and Seismic Information

- **NRC geologists found that descriptions provided by the applicant in AFSAR Section 2.5 are fully consistent with geologic features observed in the Unit 2 excavation to date.**
  - A follow-up visit to the Unit 2 excavation by NRC geologists and a geotechnical engineer will occur after controlled blasting to reach the foundation level is completed.
  - Similar visits to carefully examine the Unit 3 excavation will also be conducted.



United States Nuclear Regulatory Commission

*Protecting People and the Environment*

# **Presentation to the ACRS Full Committee**

**Summer Units 2 and 3 COL Application Review**

**Overview of staff review including wet bulb  
temperature exemption, toxic gas, and hydrology**

February 10, 2011

# Overview of Safety Evaluation

- Received Summer COL application – March 27, 2008
- Acceptance Review Completed – July 31, 2008
- Advanced Safety Evaluation Report was issued on a chapter-by-chapter basis – Completed December 10, 2010
- Two ACRS subcommittee meetings (July 21 – 22, 2010 and January 11 – 12, 2011)
- Summer application consists of
  - Material incorporated by reference from the AP1000 DCD
  - Standard content material (applicable to all AP1000 COL applicants)
  - Summer plant specific information

# Overview of Safety Evaluation

- Summer is a subsequent COL
  - Summer's safety evaluation for standard content references Vogtle's advanced safety evaluation report
  - Standard content evaluation material is double indented and italicized
  - Standard content evaluation contains some language from the Bellefonte safety evaluation report with open items to capture evaluations that were performed when Bellefonte was the reference COL

# Summer COL Overview

Part Number	Description	Evaluation
1	General and Administration Information	Section 1.5.1
2	Final Safety analysis Report	In appropriate SER Chapters
3	Environmental Report	Final Environmental Impact statement
4	Technical Specifications	Chapter 16
5	Emergency Plan	Chapter 13
6	Limited Work Authorization	Not applicable
7	Departure Reports	In appropriate SER Chapters
8	Security Plan	Section 13.6
9	Withheld Information	In appropriate SER Chapters
10	Proposed Combined License Conditions (Including ITAAC)	In appropriate SER Chapters
11	Subsurface report detailing the results of geotechnical exploration	Section 2.5
12	Seismic Technical Advisory Group review letter	Section 2.5
13	Quality Assurance Program Description	Chapter 17
14	Mitigative Strategies Document for loss of large areas of the plant due to explosions or fire	Appendix 19.A
15	Cyber Security Plan	Section 13.8
16	Special Nuclear Material Control and Accounting Program Description	Section 1.5.5

# Maximum Safety Wet-bulb (noncoincident) Air Temperature Exemption

- COL Revision 2, maximum safety wet-bulb (noncoincident) air temperature increased from 86.1°F to 87.3°F
  - Based on 100 year return temperature (Chapter 2)
  - Maximum coincident wet bulb temperature (86.1°F) and maximum dry bulb temperature (115°F) have not changed from the standard AP1000 values
- Evaluations Affected
  - 2.0, Site characteristics comparison
  - 2.3, Meteorology
  - 5.4.7, Normal residual heat removal system
  - 6.2, Containment systems
  - 6.4, Habitability systems (for main control room)
    - Nuclear island nonradioactive ventilation system (VBS)
    - Low capacity chilled water system (LCCWS)
  - 9.1.3, Spent fuel pool cooling system (SFS) –nonsafety
  - 9.2.2, Component cooling water system (CCS) –RTNSS
  - 9.2.7, Central Chilled Water system (VWS) –nonsafety

# Chapter 2 and Section 6.4 – Toxic Gas Review

- Staff evaluated chemical hazards stored or transported within 5 miles of the site
- Staff used ALOHA to determine safe distances
- Distance to the control room at ground level was less than the calculated safe distances for the majority of the chemicals
- Three site-specific chemicals could exceed IDLH at the Control Room Intake:
  - 28% ammonium hydroxide (Unit 1)
  - Cyclohexylamine (Norfolk Southern rail)
  - Chlorodifluoromethane (Norfolk Southern rail)
- Staff conducted an audit of the applicant's calculations and performed confirmatory calculations with HABIT
- Independent of the Summer COL review, staff is pursuing validation of some aspects of the HABIT code.


# VCS COL 6.4-1, Concentrations of Site-Specific Chemicals, Staff Confirmative Calculation Results (HABIT)

- Staff analysis confirmed the applicant's licensing basis analysis and staff found the chemicals would not pose a threat to the control room operators.

<b>Chemical</b>	<b>MCR Concentration</b>	<b>IDLH Limit</b>
28% Ammonium hydroxide (VCSNS Unit 1)	68 ppm	300 ppm
Cyclohexylamine (Offsite railcar)	4 ppm	10 ppm
Chlorodifluoromethane (Offsite railcar)	357 ppm	1,200 ppm



# FSAR Sections 2.4.4: Major Hydrologic Surface Water Features





# **Presentation to the ACRS Full Committee**

**V. C. Summer Units 2 and 3 Combined License (COL)  
Application Review**

**Overview of Site-Specific Information in Summer  
COL Application**

February 10, 2011

# Overview of Site-Specific Information in Summer COL application

- In the ACRS July 2010 and January 2011 subcommittee detailed presentations were provided for:
  - All sections in Chapter 2, “Site Characteristics”
  - Section 13.3, “Emergency Planning”
- Because of the lack of site-specific information, no presentations were provided to the ACRS subcommittee for the following chapters
  - Chapter 4, “Reactor”
  - Chapter 7, “Instrumentation and Control”
  - Chapter 14, “Initial Test Program”
- Slides 3 through 22 provide a high-level overview of the site-specific information that is in the remaining chapters
  - Yellow highlight indicates that the ACRS subcommittee was briefed on a topic
- ACRS subcommittee briefed on site-specific differences in loss of large area of the plant due to fire or explosion evaluation in a session that was closed to the public

# Overview of Summer COL FSAR Chapter 1

FSAR Section	Summary of Departures/Supplements
1.1 Introduction	Incorporated By Reference (IBR) with standard and site specific supplements
1.2 General Plant Description	IBR with site-specific supplements
1.3 Comparisons with Similar Facility designs	Completely IBR
1.4 Identification of Agents and Contactors	IBR with site-specific supplements
1.5 Requirements for Further Technical Information	Completely IBR
1.6 Material Referenced	IBR with standard and site-specific supplements
1.7 Drawings and Other Detailed Information	IBR with site-specific supplements
1.8 Interface for Standard Designs	IBR with site-specific supplements
1.9 Compliance with Regulatory Criteria	IBR with standard and site-specific supplements
1.10 Nuclear Power Plants to be Operated on Multi-Units Sites	Standard and site-specific supplemental information

# Summer FSAR Chapter 3

## Design of Structures, Components, Equipment and Systems

<b>FSAR Section</b>	<b>Site-Specific Evaluations</b>
3.1 Conformance With Nuclear Regulatory Commission General Design Criteria	<ul style="list-style-type: none"><li>• None*</li></ul>
3.2 Classification of Structures, Components, and Systems	<ul style="list-style-type: none"><li>• None*</li></ul>
3.3 Wind and Tornado Loadings	<ul style="list-style-type: none"><li>• VCS COL 3.3-1 Wind Velocity Characteristics</li><li>• VCS COL 3.5-1 Tornado Velocity Characteristics</li></ul>
3.4 Water Level (Flood) Design	<ul style="list-style-type: none"><li>• VCS COL 3.4-1 Dewatering System and Water Levels</li></ul>
3.5 Missile Protection	<ul style="list-style-type: none"><li>• VCS SUP 3.5-1 Turbine Missile from Unit 1</li></ul>

\* This section is entirely IBR or IBR/standard

# Summer FSAR Chapter 3

## Design of Structures, Components, Equipment and Systems

FSAR Section	Site-Specific Evaluations
3.6 Protection Against the Dynamic Effects Associated With the Postulated Rupture of Piping	<ul style="list-style-type: none"><li>• None*</li></ul>
3.7 Seismic Design	<ul style="list-style-type: none"><li>• VCS SUP 3.7-3 Design Ground Motion Response Spectra</li></ul>
	<ul style="list-style-type: none"><li>• VCS COL 3.7-1 Seismic Analysis of Dams</li></ul>
3.8 Design of Category I Structures	<ul style="list-style-type: none"><li>• VCS COL 2.5-17 Waterproofing Material for Category I Structures</li></ul>
3.9 Mechanical Systems and Components	<ul style="list-style-type: none"><li>• None*</li></ul>
3.10 Seismic and Dynamic Qualification of Seismic Category I Mechanical and Electrical Equipment	<ul style="list-style-type: none"><li>• None*</li></ul>
3.11 Environmental Qualification of Mechanical and Electrical Equipment	<ul style="list-style-type: none"><li>• None*</li></ul>

\* This section is entirely IBR or IBR/standard.

# Summer FSAR Chapter 5

## Reactor Coolant System and Connected Systems

FSAR Section	Site-Specific Evaluations
5.2.1.1 Compliance with 10 CFR 50.55a 5.2.1.2 Applicable Code Cases 5.2.1.3 Alternate Classification 5.2.2 Overpressure Protection 5.2.3 Reactor Coolant Pressure Boundary Materials 5.2.4 Inservice Inspection and Testing of Class 1 Components 5.2.5 Detection of Leakage through Reactor Coolant Pressure Boundary 5.3.1 Reactor Vessel Design 5.3.2 Reactor Vessel Materials 5.3.3 Pressure Temperature Limits 5.3.4 Reactor Vessel Integrity 5.3.5 Reactor Vessel Insulation	<ul style="list-style-type: none"> <li>• None*</li> </ul>
5.4 Component and Subsystem Design	<ul style="list-style-type: none"> <li>• VCS DEP 2.0-2, Maximum Safety Wet Bulb (Noncoincident) Air Temperature</li> </ul>

\* This section is entirely IBR or IBR/standard.

# Summer FSAR Chapter 6

## Engineered Safety Features

FSAR Section	Site-Specific Evaluations
6.1.1 Engineered Safety Materials Features, Metallic Materials	<ul style="list-style-type: none"> <li>• None *</li> </ul>
6.1.2 Engineered Safety Materials Features, Organic Materials	<ul style="list-style-type: none"> <li>• None *</li> </ul>
6.2 Containment Systems	<ul style="list-style-type: none"> <li>• VCS DEP 2.0-2, Maximum Safety Wet Bulb (Noncoincident) Air Temperature</li> </ul>
6.3 Passive Core Cooling System	<ul style="list-style-type: none"> <li>• None *</li> </ul>
6.4 Habitability Systems	<ul style="list-style-type: none"> <li>• ACRS Action Item #63, Staff confirmatory calculation regarding VCS COL 6.4-1, Concentrations of Site-Specific Chemicals</li> <li>• VCS DEP 2.0-2, Maximum Safety Wet Bulb (Noncoincident) Air Temperature</li> </ul>
6.5 Fission Product Removal and Control Systems	<ul style="list-style-type: none"> <li>• None *</li> </ul>
6.6 Inservice Inspection of Class 2, 3, and MC Components	<ul style="list-style-type: none"> <li>• None *</li> </ul>

\* This section is entirely IBR or IBR/standard.



# Summer FSAR Chapter 8 Electric Power

FSAR Section	Site-Specific Evaluations
8.1 Introduction	<ul style="list-style-type: none"> <li>• VCS SUP 8.1-1 Summer Units 2 and 3 connection to the utility grid</li> <li>• VCS SUP 8.1-2 Additional information on regulatory guidelines and standards</li> </ul>
8.2 Offsite Power System	<ul style="list-style-type: none"> <li>• VCS COL 8.2-1 Transmission system description, and its testing and inspection plan</li> <li>• VCS COL 8.2-2 Switchyard description and protection relaying</li> <li>• VCS SUP 8.2-1 FMEA of the switchyard</li> <li>• VCS SUP 8.2-2 Transmission system requirements and studies</li> <li>• VCS SUP 8.2-3 Transmission system planning</li> <li>• VCS SUP 8.2-4 Stability and reliability of the offsite transmission power system</li> <li>• Interface Requirements</li> </ul> <p>• VCS Conceptual Design Information (CDI) describing the transformer area located next to each unit's turbine building</p>

# Summer FSAR Chapter 8 Electric Power

<b>FSAR Section</b>	<b>Site-Specific Evaluations</b>
8.3.1 AC Power Systems (Onsite)	<ul style="list-style-type: none"><li data-bbox="662 451 1692 489">• VCS COL 8.3-1 Grounding system and lightning protection</li><li data-bbox="662 525 1557 604">• VCS SUP 8.3-1 Site-specific switchyard and power transformer voltage</li><li data-bbox="662 615 1576 654">• VCS SUP 8.3-2 EDG rating based on site conditions</li></ul>
8.3.2 DC Power Systems (Onsite)	<ul style="list-style-type: none"><li data-bbox="662 711 803 749">• None*</li></ul>

\*This section is entirely IBR or IBR/Standard

# Summer FSAR Chapter 9

FSAR Section	Site-Specific Evaluations
9.1.1 New Fuel Storage	<ul style="list-style-type: none"> <li>• None*</li> </ul>
9.1.2 Spent Fuel Storage	<ul style="list-style-type: none"> <li>• None*</li> </ul>
9.1.3 Spent Fuel Pool Cooling System	<ul style="list-style-type: none"> <li>• VCS DEP 2.0-2, Maximum Safety Wet Bulb (Noncoincident) Air Temperature</li> </ul>
9.1.4 Light Load Handling System	<ul style="list-style-type: none"> <li>• None*</li> </ul>
9.1.5 Overhead Heavy Load Handling Systems	<ul style="list-style-type: none"> <li>• None*</li> </ul>
9.2.1 Service Water System	<ul style="list-style-type: none"> <li>• VCS SUP 9.2-3 provides additional information regarding the service water system cooling tower potential interactions</li> </ul>
9.2.2 Component Cooling Water System	<ul style="list-style-type: none"> <li>• VCS DEP 2.0-2, Maximum Safety Wet Bulb (Noncoincident) Air Temperature</li> </ul>
9.2.3 Demineralized Water Treatment System	<ul style="list-style-type: none"> <li>• None*</li> </ul>
9.2.4 Demineralized Water Transfer and Storage System	<ul style="list-style-type: none"> <li>• None*</li> </ul>

\* This section is entirely IBR or IBR/standard.

# Summer FSAR Chapter 9

FSAR Section	Site-Specific Evaluations
9.2.5 Potable Water System	<ul style="list-style-type: none"> <li>VCS COL 9.2-1, Potable water system description outside the power block</li> </ul>
9.2.6 Sanitary Drains	<ul style="list-style-type: none"> <li>VCS SUP 9.2-1, Sanitary waste system discharge description</li> </ul>
9.2.7 Central Chilled Water System	<ul style="list-style-type: none"> <li>VCS DEP 2.0-2, Maximum Safety Wet Bulb (Noncoincident) Air Temperature</li> </ul>
9.2.8 Turbine Building Closed Cooling Water System (TCS)	<ul style="list-style-type: none"> <li>VCS CDI provides the source of cooling water for the TCS heat exchangers</li> </ul>
9.2.9 Waste Water System	<ul style="list-style-type: none"> <li>VCS COL 9.2-2 provides information on the waste water retention basins and associated discharge piping</li> </ul>
9.2.10 Hot Water Heating System	<ul style="list-style-type: none"> <li>None*</li> </ul>
9.2.11 Raw Water System	<ul style="list-style-type: none"> <li>VCS SUP 9.2-2 provides site-specific information related to the raw water system</li> </ul>
9.3.1 Compressed and Instrument Air System	<ul style="list-style-type: none"> <li>None*</li> </ul>
9.3.2 Plant Gas System	<ul style="list-style-type: none"> <li>None*</li> </ul>

\* This section is entirely IBR or IBR/standard.

# Summer FSAR Chapter 9

FSAR Section	Site-Specific Evaluations
9.3.3 Primary Sampling System	<ul style="list-style-type: none"> <li>• None*</li> </ul>
9.3.4 Secondary Sampling System	<ul style="list-style-type: none"> <li>• None*</li> </ul>
9.3.5 Equipment and Floor Drainage Systems	<ul style="list-style-type: none"> <li>• None*</li> </ul>
9.3.6 Chemical and Volume Control System	<ul style="list-style-type: none"> <li>• None*</li> </ul>
9.4.1 Nuclear Island Nonradioactive Ventilation System	<ul style="list-style-type: none"> <li>• VCS COL 9.4-1b provides local toxic gas evaluations</li> </ul>
9.4.2 Annex/Auxiliary Buildings Nonradioactive HVAC System	<ul style="list-style-type: none"> <li>• None*</li> </ul>
9.4.6 Containment Recirculation Cooling System	<ul style="list-style-type: none"> <li>• None*</li> </ul>
9.4.7 Containment Air Filtration System	<ul style="list-style-type: none"> <li>• None*</li> </ul>
9.4.8 Radwaste Building HVAC System	<ul style="list-style-type: none"> <li>• None*</li> </ul>
9.4.9 Turbine Building Ventilation System	<ul style="list-style-type: none"> <li>• None*</li> </ul>
9.4.10 Diesel Generator Building Heating and Ventilation System	<ul style="list-style-type: none"> <li>• None*</li> </ul>
9.4.11 Health Physics and Hot Machine Shop HVAC System	<ul style="list-style-type: none"> <li>• None*</li> </ul>

\* This section is entirely IBR or IBR/standard.

# Summer FSAR Chapter 9

FSAR Section	Site-Specific Evaluations
9.5.1 Fire Protection System	<ul style="list-style-type: none"> <li>• VCS COL 9.5-1, qualification requirements for the fire protection program</li> <li>• VCS COL 9.5-2, site-specific hazards analysis of the yard areas and outlying buildings</li> </ul>
9.5.2 Communication System	<ul style="list-style-type: none"> <li>• VCS COL 9.5-9, offsite interfaces</li> <li>• VCS COL 9.5-10, emergency offsite communications</li> <li>• VCD COL 9.5-11, security communications</li> </ul>
9.5.3 Plant Lighting Systems	<ul style="list-style-type: none"> <li>• None*</li> </ul>
9.5.4 Diesel Generator Fuel Oil System	<ul style="list-style-type: none"> <li>• None*</li> </ul>
9.5.5 Standby Diesel Generator Cooling Water System	<ul style="list-style-type: none"> <li>• None*</li> </ul>
9.5.6 Standby Diesel Generator Air System	<ul style="list-style-type: none"> <li>• None*</li> </ul>
9.5.7 Standby Diesel Generator Lubrication System	<ul style="list-style-type: none"> <li>• None*</li> </ul>
9.5.8 Standby Diesel Generator Combustion Air Intake and Exhaust System	<ul style="list-style-type: none"> <li>• None*</li> </ul>

\* This section is entirely IBR or IBR/standard.

# Summer FSAR Chapter 10

## Steam and Power Conversion

FSAR Section	Site-Specific Evaluations
10.1 Summary Description	<ul style="list-style-type: none"> <li>• None*</li> </ul>
10.2 Turbine Generator	<ul style="list-style-type: none"> <li>• None*</li> </ul>
10.3 Main Steam Supply System	<ul style="list-style-type: none"> <li>• None*</li> </ul>
10.4 Other Features of Steam and Power Conversion System	<ul style="list-style-type: none"> <li>• VCS CDI, relating to COL Section 10.4.2 for the site specific cooling water source for the vacuum pump seal water heat exchangers.</li> <li>• VCS CDI, relating COL Section 10.4.5 for the site specific Circulating Water System design information.</li> <li>• VCS COL 10.4-1 relating to the Circulating Water System design parameters.</li> <li>• VCS COL 10.4-2 relating to Condensate, Feedwater and Auxiliary Steam System Chemistry Control.</li> </ul>

\* This section is entirely IBR or IBR/standard.

# Summer FSAR Chapter 11

## Radioactive Waste Management

FSAR Section	Site-Specific Evaluations
11.1 Source Term	<ul style="list-style-type: none"> <li>• None*</li> </ul>
11.2 Liquid Radioactive Waste Management	<ul style="list-style-type: none"> <li>• VCS COL 11.2-2, Liquid waste discharge cost-benefit analysis</li> <li>• VCS COL 2.4-5 and VCS 15.7-1, Doses from accidental release from liquid waste tank failure</li> <li>• VCS COL 11.5-3, Compliance with 10 CFR Part 50, Appendix I, Sections II.A and II.D for liquid waste discharges</li> <li>• VCS SUP 11.2-1, Liquid waste discharge pipe</li> </ul>
11.3 Gaseous Radioactive Waste Management	<ul style="list-style-type: none"> <li>• VCS COL 11.3-1, Gaseous waste discharge cost-benefit analysis</li> <li>• VCS COL 11.5-3, Compliance with 10 CFR Part 50, Appendix I, Sections II.B and II.C for gaseous waste discharges</li> </ul>
11.4 Solid Radioactive Waste Management	<ul style="list-style-type: none"> <li>• None*</li> </ul>
11.5 Radiation Monitoring	<ul style="list-style-type: none"> <li>• VCS COL 11.5-2, QA for effluent and environmental monitoring program</li> <li>• VCS COL 11.5.3, Compliance with 10 CFR Part 50, Appendix I</li> </ul>

\* This section is entirely IBR or IBR/standard.



# Summer FSAR Chapter 12

## Radiation Protection

FSAR Section	Site-Specific Evaluations
12.1 Assuring ALARA	<ul style="list-style-type: none"> <li>• None*</li> </ul>
12.2 Radiation Sources	<ul style="list-style-type: none"> <li>• None*</li> </ul>
12.3 Radiation Protection Design Features	<ul style="list-style-type: none"> <li>• VCS DEP 18.8-1, Relocation of Operations Support Center</li> <li>• VCS SUP 11.2-1, Liquid waste discharge pipe</li> </ul>
12.4 Dose Assessment	<ul style="list-style-type: none"> <li>• VCS SUP12.4-1, Construction worker dose</li> </ul>
12.5 Health Physics Facility Design	<ul style="list-style-type: none"> <li>• VCS DEP 18.8-1, Relocation of Operations Support Center</li> </ul>

\* This section is entirely IBR or IBR/standard.

# Summer FSAR Chapter 13

## Conduct of Operations

FSAR Section	Site-Specific Evaluations
13.1 Organizational Structure of Applicant	<ul style="list-style-type: none"> <li>• VCS COL 13.1-1 Organization structure</li> <li>• VCS COL 9.5-1 Fire protection</li> <li>• VCS COL 18.6-1 Qualifications of the nuclear plant technical support personnel</li> <li>• VCS COL 18.10-1 Responsibilities of the manager in charge of nuclear training</li> </ul>
13.2 Training	<ul style="list-style-type: none"> <li>• None*</li> </ul>
13.3 Emergency Planning	<ul style="list-style-type: none"> <li>• Presented separately</li> </ul>
13.4 Operational Programs	<ul style="list-style-type: none"> <li>• None*</li> </ul>
13.5 Plant Procedures	<ul style="list-style-type: none"> <li>• VCS SUP 13.5-1 Plant Procedures</li> <li>• VCS SUP 13.5-2 Plant Procedures</li> </ul>
13.6 Security	<ul style="list-style-type: none"> <li>• Not presented to ACRS</li> </ul>
13.7 Fitness for Duty	<ul style="list-style-type: none"> <li>• None*</li> </ul>
13.8 Cyber Security	<ul style="list-style-type: none"> <li>• None*</li> </ul>

\* This section is entirely IBR or IBR/standard.

# Summer FSAR Chapter 15

## Accident Analysis

FSAR Section	Site-Specific Evaluations
15.0 Accident Analysis	• None*
15.1 Increase in Heat Removal from Primary System	• None*
15.2 Decrease in Heat Removal by the Secondary System	• None*
15.3 Decrease in Reactor Coolant System Flow Rate	• None*
15.4 Reactivity and Power Distribution Anomalies	• None*
15.5 Increase in Reactor Coolant Inventory	• None*
15.6 Decrease in Reactor Coolant Inventory	• None*
15.7 Radioactive Release from a Subsystem or Component	• VCS COL 15.7-1, Consequence of Liquid Waste Tank Failure
15.8 Anticipated Transients without Scram	• None*
15A Evaluation Models and Parameters for Analysis of Radiological Consequences of Accidents	• <b>VCS COL 2.3-4, DBA Radiological Consequences Analyses</b>
15B Removal of Airborne Activity from the Containment Atmosphere Following a LOCA	• None*

\* This section is entirely IBR or IBR/standard.

# Summer FSAR Chapter 16

## Technical Specifications

<b>FSAR Section</b>	<b>Site-Specific Evaluations</b>
16.1 Technical Specifications	<ul style="list-style-type: none"><li>• VCS COL 16.1-1 related to technical specifications for use as a guide in development of the plant-specific technical specifications.</li></ul>
16.2 Design Reliability Assurance Program	<ul style="list-style-type: none"><li>• None*</li></ul>
16.3 Investment Protection	<ul style="list-style-type: none"><li>• None*</li></ul>

\* This section is entirely IBR or IBR/standard.

# Summer FSAR Chapter 17

## Quality Assurance Program

FSAR Section	Site-Specific Evaluations
17.1 Quality Assurance During the Design and Construction Phases	<ul style="list-style-type: none"> <li>• VCS COL 17.5-1 QAP prior to COL issuance</li> </ul>
17.2 Quality Assurance During the Operations Phase	<ul style="list-style-type: none"> <li>• None*</li> </ul>
17.3 Quality Assurance During the Design, Procurement, Fabrication, Inspection, and/or Testing of Nuclear Power Plant Items	<ul style="list-style-type: none"> <li>• None*</li> </ul>
17.4 Design Reliability Assurance Program	<ul style="list-style-type: none"> <li>• None*</li> </ul>
17.5 Quality Assurance Program Description – New License Applicants	<ul style="list-style-type: none"> <li>• VCS COL 17.5-1 QAP following COL issuance</li> </ul>
17.6 Maintenance Rule Program	<ul style="list-style-type: none"> <li>• None*</li> </ul>

\*This section is entirely IBR or IBR/Standard

# Summer FSAR Chapter 18

## Human Factors Engineering (HFE)

FSAR Section	Site-Specific Evaluations
18.1 Overview	<ul style="list-style-type: none"> <li>• None*</li> </ul>
18.2 HFE Program Management	<ul style="list-style-type: none"> <li>• VCS COL 18.2-2, Location of the Emergency Operations Facility</li> </ul>
18.3–18.7	<ul style="list-style-type: none"> <li>• None*</li> </ul>
18.8 Human-System Interface Design	<ul style="list-style-type: none"> <li>• VCS DEP 18.8-1, Location of the Technical Support Center (TSC) and Operational Support Center (OSC)</li> </ul>
18.9–18.14	<ul style="list-style-type: none"> <li>• None*</li> </ul>

\* This section is entirely IBR or IBR/standard.

# Summer FSAR Chapter 19

## Probabilistic Risk Assessment

FSAR Section	Site-Specific Evaluations
19.1–19.54, 19.56, 19.57	<ul style="list-style-type: none"> <li>None*</li> </ul>
19.55 Seismic Margins Analysis	<ul style="list-style-type: none"> <li>VCS SUP 19.59.10-6 Site-Specific Seismic Margin Analysis</li> </ul>
19.58 Winds, Floods, and Other External Events	<ul style="list-style-type: none"> <li>VCS SUP 19.58-1 External Event Frequencies</li> </ul>
19.59 PRA Results and Insights	<ul style="list-style-type: none"> <li>None*</li> </ul>

\* This section is entirely IBR or IBR/Standard

# A COMPARISON OF INTEGRATED SAFETY ANALYSIS TO PROBABILISTIC RISK ASSESSMENT

for the  
Advisory Committee on Reactor Safeguards

**Dennis R. Damon**  
Senior Advisor for Risk Assessment  
Office of Nuclear Material Safety and Safeguards

February 10, 2011






# Objective

- Present paper comparing Integrated Safety Analysis (ISA) and Probabilistic Risk Assessment (PRA)
- Obtain ACRS Review – ACRS Letter

# Key Points



- ◎ ISAs are acceptable for establishing the safety basis for fuel facilities
- ◎ Quantitative analysis to determine risk significance: a case-by-case basis is efficient



# Fuel Facilities Performing ISAs

## ⦿ Enrichment

- LES
- AREVA Eagle Rock\*
- USEC ACP\*
- GE-Hitachi\*

## ⦿ Fuel Fabrication

- MOX FFF\*
- NFS
- AREVA-Richland
- B&W NOG
- Global Nuclear Fuel
- Westinghouse

## ⦿ Conversion/Deconversion

- Honeywell†
- International Isotopes\*†

\* Not yet operational, under review or construction

† Part 40 rulemaking will require ISA for these facilities



# ISA – PRA Comparison

- ◎ A comparison and critical evaluation with respect to use...
  1. for safety under 10 CFR 70 Subpart H
  2. for risk significance determination of inspection findings




# Contents of Paper

- I. Integrated Safety Analysis
- II. Probabilistic Risk Assessment
- III. Evaluation for safety under 10 CFR 70
- IV. Potential risk significance determination for fuel cycle oversight program
- V. Evaluation for use in risk significance determination, with example



# Sections I ISAs and II PRAs

- Functions of ISAs under Part 70 Safety Program:
  - IDENTIFY hazards, accidents, and items relied on for safety
  - EVALUATE compliance with (likelihood / consequence) performance requirements
- Functions of PRA:
  - QUANTIFY risk metrics as needed to inform regulatory decisions





# What do ISAs produce?

- ⦿ Each differs but:
- ⦿ List of accident sequences with ...
  - Items Relied on for Safety (IROFS)
  - Accidents are assigned to consequence categories (high, intermediate, low)
  - Likelihood of each sequence evaluated: 2 quantitative, 1 qualitative, 7 risk index



# Fuel Cycle Facilities

- Many separate process steps (series)
- Multiple process units for each step (parallel)
- Conversion, enrichment,  $UF_6$   $\rightarrow$   $UO_2$  powder, blending, milling, pellets, grinding, pins, assemblies, scrap recovery, absorbers, etc.
- For process upsets or IROFs failures: stop process or render safe
- Control failure may not cause parameter to exceed safety limit
- Key point: a deficiency in one process typically does not affect others; hence risk impact only involves that process (Sec. V)
- Relatively few accident sequences that could affect the public





# Why is ISA acceptable for Safety under 10 CFR 70?

- ⦿ ISA consequence-likelihood evaluations differ from PRA: conservative evaluation establishes adequate safety
- ⦿ ISA used systematic methods from chemical industry / OSHA Process Hazard Analysis (PHA) experience, including fault/event trees
- ⦿ Licensee ISA experience and NRC reviews: improved guidance
- ⦿ ISAs can be quantitative

# ISAs and Risk Significance Determination



- Most ISAs have some quantitative information on consequences/likelihood
- BUT: ISAs were not done to produce accurate risk, hence sometimes results would need to be supplemented
- E.g. safety controls not credited, bounding consequences – not average, safety margins not credited
- ISAs are not standardized like SPAR models



# V. Evaluation for Risk Significance Determination

- Example of quantitative risk significance
- The example is typical: only a few accident sequences are affected
- Few significant inspection findings/plant-year
- Key point #2: risk-significance evaluations on a case-by-case basis are efficient



# ISA-PRA Key Points

- ⦿ ISAs are adequate for establishing the safety basis for fuel facilities
- ⦿ Analysis to determine risk significance: a case-by-case basis is efficient



Questions?



# Summary

- ⦿ Present paper comparing ISA and PRA
- ⦿ Obtain ACRS Review – ACRS Letter
  - ISAs are acceptable for establishing the safety basis for fuel facilities
  - Quantitative analysis to determine risk significance: a case-by-case basis is efficient



# Supplementary Slides

- More detailed discussion of ISA-PRA comparison follows.



# Commission Direction

- ① “... a concise paper comparing Integrated Safety Analyses (ISAs) for fuel cycle facilities and Probabilistic Risk Assessments (PRAs) for reactors.”
- ② “The Commission looks forward to the staff’s concise comparison of integrated safety analyses and probabilistic risk assessment, along with the accompanying review and letter report of the Advisory Committee on Reactor Safeguards, to better inform proposed enhancements to the oversight process.”





# Commission Direction

- ① Prepare a paper comparing ISA for fuel facilities and PRA for reactors
- ① Develop a set of cornerstones
- ① Provide assessment and recommendations for next steps
  
- ① Provide incentives for licensees to maintain a strong corrective actions program



# Why Revise the Fuel Cycle Oversight Process?

- ⦿ Existing process is effective and ensures safety and security
- ⦿ But the process could be made more:
  - Focused on risk-significant performance issues
  - Objective (transparent)
  - Consistent (predictable)
- ⦿ Risk-significance process, plus licensee Corrective Action Programs, should make progress possible



# Next Steps

- ① ACRS review and feedback on ISA/PRA comparison
- ① Develop cornerstones
- ① Integrate knowledge gained to provide recommendations for next steps
- ① Develop criteria for an acceptable CAP and coordinate changes to the Enforcement Policy



# Contents of Paper

- I. Integrated Safety Analysis
- II. Probabilistic Risk Assessment
- III. Evaluation for safety under 10 CFR 70
- IV. Potential risk significance determination for fuel cycle oversight program
- V. Evaluation for use in risk significance determination, with example



# I. What is ISA?

- ◎ 10 CFR 70: ISA is a systematic analysis to identify:
  - (1) hazards
  - (2) accident sequences
  - (3) consequence and likelihood of each sequence
  - (4) items relied on for safety (IROFS); and
  - (5) evaluate compliance with performance requirements of sec. 70.61.



# I. ISA defined in Part 70

- ⦿ ISA results are used by other requirements in Part 70
- ⦿ 10 CFR 70.62(d): “..management measures shall ensure that...IROFS...are available and reliable to perform their function when needed to comply with the performance requirements of 70.61 of this part.”



# I. What is ISA?

- ⦿ ISA was based on chemical industry PHA.
- ⦿ Differences from chemical PHA:
  - Integrated analysis of radiation, nuclear criticality, and chemical hazards
  - Evaluation of compliance with consequence – likelihood “performance requirements” of 70.61



# I. ISA Performance Requirements

- ⦿ High consequence accident sequence must be “highly unlikely”
  - Worker high consequences =
    - (1) 100 rem or more (criticality or rad)
    - (2) Chemical – ‘endanger the life’
  
  - Public (outside “controlled area”) high consequences =
    - (1) 25 rem or more
    - (2)  $\geq 30$  mg soluble U intake
    - (3) Irreversible chemical injury





# I. Performance Requirements

- Intermediate consequence accident sequence must be “unlikely”

Worker intermediate consequences:

- (1) 25 rem to 100 rem
- (2) Irreversible chemical injury

Public intermediate consequences:

- (1) 5 rem to 25 rem
- (2) Chemical transient illness



# I. Performance Requirements

- ⦿ Environment (outside “restricted area”)  
Conc. > 5000 times 10 CFR Part 20, Appendix B, Table 2 values
- ⦿ Evaluation is of single accident sequences, not the sum to an individual as in PRA
- ⦿ The structure of the evaluation of performance requirements is dictated by the regulation

# I. ISA Guidance

- ① NUREG-1513, “Integrated Safety Analysis Guidance Document,” May 2001
  - Accident identification methods based on extensive experience with chemical industry / OSHA Process Hazards Analysis
- ① NUREG-1520, “Standard Review Plan for the Review of a License Application for a Fuel Cycle Facility, Rev. 1”, May 2010



# III. Evaluation for Safety under 10 CFR 70

- ◎ ISAs identify (hazards, accidents, IROFS)
  - This function is, in principle, the same as PRA
  - But fault/event trees only for complex events
  - Problems are mostly in execution, not methods. (e.g. unanticipated scenarios)
- ◎ ISAs evaluate likelihoods and consequences; but not fully quantitative
  - quantitative better in some cases, but generally ISAs are conservative, which is acceptable and efficient.

# III. Evaluation of Technical Features



- ⦿ End states:
  - ISA – high or intermediate consequence sequence,
  - PRA – sum of frequencies
- ⦿ Completeness: in principle no difference.
- ⦿ Accident quantification:
  - Most ISAs have some sequence frequency information
  - PRA – quantified sequences
- ⦿ Human error – Simple error lists, sometimes very conservative.
- ⦿ Hardware failures – ISA at level of IROFS

# III. Evaluation of Technical Features



- ⦿ System interactions – 70.4 Definitions. ISA: “...An ISA can be performed process by process, but all processes shall be integrated, and process interactions considered.”
- ⦿ Dependencies / common cause: Some ISAs evaluate via checklists. Some use dependency factors for likelihoods. Criticality safety: double contingency standard (ANSI/ANS 8.1)
- ⦿ Uncertainties: ISAs usually handle with conservative assumptions
- ⦿ Importance metrics: Not used in the safety program under Subpart H



# III. Evaluation for Safety under 10 CFR 70

- ISAs have been developed, updated, reviewed, revised, and improved over an extended time frame
- Methods borrowed from chemical industry
- NRC reviews of ISAs were substantial. A risk-informed selection of process designs were reviewed in detail



# III. Evaluation for Safety under 10 CFR 70

- PRA methods have been used in certain areas; and could be applied in others as recommended in NRC guidance.
- Difficulties in doing ISAs: anticipating all credible accidents, large number of processes, errors of commission
- Bottom line evaluation: NRC Staff has approved ISA programs as acceptable for safety





# V. Evaluation for Risk Significance

- ⦿ ISAs were not done to provide a good estimate of risk.
- ⦿ Most ISAs do have some quantitative risk information, but...
- ⦿ ISA quantitative results sometimes very conservative
- ⦿ ISA quantitative evaluations not consistent between different licensees



# V. Evaluation for Risk Significance

- ⦿ Common large conservatisms:
  - Not crediting a safety control (non-IROFS)
  - Worst case dispersion for offsite releases
  - No credit for safety margins
- ⦿ Other risk quantification gaps:
  - No NRC validated hardware failure data
  - Quantifying human errors of commission
  - Probabilistic chemical consequences
  - Criticality magnitudes



# V. Evaluation for Risk Significance

- ⦿ Factors that aid in quantifying risk significance of fuel cycle inspection findings:
  - Very few significant findings per plant per year
  - Simple designs: few accident sequences are affected by one inspection finding
- ⦿ Risk significance metric:  $\Delta$  frequency of high consequence event caused by deficiency  $\times$  duration of deficiency
- ⦿ Fuel cycle needs multiple metrics: worker/public, high/intermediate, other



# V. Example Risk Significance Calculation

- ⦿ Example Risk Significance Evaluation
  - Typical simplicity: few affected sequences
  - Only need delta risk for these sequences
  - but has none of the quantification difficulties (failure data is provided for all quantities).
- ⦿ Key point: Quantitative risk significance can often be done for fuel cycle inspection findings on a case-by-case basis. A priori re-evaluation of all sequences by licensees would not be efficient.



# V. Example Risk Significance Determination

- ⦿ Process: geometrically safe tank, containment dike
- ⦿ Potential accident scenarios:
  - fissile solution leaks or overflows into dike, dike leaks, solution accumulates into critical geometry, criticality accident
  - Two scenarios: 1) leak initiator 2) overflow
- ⦿ Normal accident frequency = initiator frequencies x dike failure probability



# V. Example Risk Significance Determination

- ⦿ Deficiency: dike found to have been in leaking condition for 4 years
- ⦿ Frequency of accident during these 4 years had increased to frequency of initiators
- ⦿ Significance metric =  $\Delta \text{frequency} \times \text{duration of deficiency}$

# ISA – Chemical Industry PHA



- 29 CFR 1910.911 Process safety management of highly hazardous chemicals
- 1910.911(e) Process Hazards Analysis (PHA): what-if, what if-checklist, HAZOP, FMEA, fault trees
- OSHA-NRC Memorandum of Understanding

# **Fire PRA Impacts to NPFA 805 Transitions**

**ACRS Committee Meeting**

**February 10, 2011**

**Biff Bradley, NEI**

**[reb@nei.org](mailto:reb@nei.org)**



NUCLEAR  
ENERGY  
INSTITUTE



# Industry Introduction

- **Industry very supportive of achieving closure of fire protection issues**
  - **Goal: Achieve stable regulatory state**
- **Adoption of 50.48(c) is a major undertaking**
  - **Nearly half of the industry well on their way**
- **Fire PRA a major element of the transition effort**
- **These Fire PRAs should be usable for all risk-informed applications**

# Realism of Fire PRAs

- **NRC PRA Policy Statement calls for realism in PRA**
- **NEI first identified lack of realism with NUREG CR/6850 (EPRI 1011989) in January 2008**
  - **Letter to NRC staff outlining specific technical concerns, requesting collaboration on resolution**
- **FAQ process for Fire PRA**
  - **Over two years, most topics only partially addressed, but process was slow and ineffective.**
  - **By late 2009, industry stopped submitting FPRA-related FAQs**

## **Realism of Fire PRAs (Cont.)**

- **In December 2009, NEI notified the Commission of industry's continued concerns and initiation of EPRI FPRA Action Matrix**
- **Industry committed to improving FPRA methods for use in risk-informed decision-making in NFPA-805 and other risk-informed applications**

# Industry Feedback

- **Industry has provided detailed presentations in two PRASC meetings**
- **Provided evidence of the issues based on actual PRAs completed and detailed plan for enhancing methods**
- **PRA results (e.g. high CCDP events, spurious operations) were compared with operating experience**

# Realism in Fire PRAs




- **By their nature, risk-informed applications provide for “changes” from deterministic licensing basis**
- **Fire protection and NFPA 805 are not unique in this regard**
- **Other elements of the NRC risk-informed regulatory decision making process (Reg Guide 1.174) were established to provide conservatism as appropriate, and have been effective in application**
- **Injection of conservatism directly into PRA sets a troubling precedent for risk-informed regulation**

# Industry Perspective on Path Forward

- **Establish an improved process for regulatory interaction on PRA methods**
  - **NFPA 805 is the first case where NRC approval of all PRA methods has been expected in addition to meeting Regulatory Guide 1.200**
  - **June 1, 2009 NRC letter to NEI states: “FAQs must give appropriate consideration of the balance between realism and conservatism in the fire PRA....”**
  - **This is inconsistent with NRC PRA policy statement**
- **We believe the revised process should focus on realism**

# Industry Roadmap

- **Use results & insights from industry fire PRAs to identify the important areas where bounding assumptions/simplifications are skewing FPRA results**
- **Objectives of industry report:**
  - **Provide objective evidence of conservatism in FPRA results**
  - **Identify key areas needing additional realism**
  - **Inform & update the EPRI FPRA Action Matrix**
  - **Provide a vehicle for discussion**



**EPRI**

ELECTRIC POWER  
RESEARCH INSTITUTE

## Roadmap For Attaining Realism In Fire PRAs

**Rick Wachowiak, EPRI**

**Doug True, ERIN Engineering & Research**

**ACRS**

February 10, 2011



# Computation of Fire CDF

- In the simplest form, the risk from an individual fire scenario is a function of:
  - The frequency of the fire event ( $F_{\text{fire}}$ )
  - The fire severity characteristics as a function of time ( $S(t)$ )
  - The probability of suppressing the fire event as a function of time ( $\text{NSP}(t)$ )
  - The conditional core damage probability given the damage caused by the postulated fire ( $\text{CCDP}_{\text{damage}}$ )

$$\text{Scenario CDF} = f(F_{\text{fire}}, S(t)_{\text{fire}}, \text{NSP}(t), \text{CCDP}_{\text{damage}})$$

# Computation of Fire CDF (Cont.)

$$\text{Scenario CDF} = f(F_{\text{fire}}, S(t)_{\text{fire}}, \text{NSP}(t), \text{CCDP}_{\text{damage}})$$

- Conservatism exists in each of these components
  - Some fire frequencies overstated
  - Fire severities overstated
  - Suppression under-credited
  - Resulting CCDPs overstated
- No single factor causing the unrealistic results
- Results are very scenario specific, i.e., plant, location, ignition source

# Conformance with Operating Experience: Spurious Operations

- Addressing spurious operations is an important element of a comprehensive FPRA
  - Essential part of 50.48(c)
- Operating experience has not indicated significant spurious operations have occurred in real fire events (except Browns Ferry)
- Investigation of FPRA results shows over-prediction of spurious operations
- Sampling of PRAs investigated to compute the predicted frequency of one or more spurious operations

# Conformance with Operating Experience: Spurious Operations

- The FPRA model scenarios include spurious operations (SOs) caused by assumed fires
- Fire scenario damage “vectors” identify those with one or more SOs
- Plant-wide SO frequency (one or more SOs):  
$$\sum \text{Frequency of Scenarios involving one or more SOs}$$
- Results:
  - Plant X: 0.0041/yr
  - Plant Y: 0.0043/yr
- If extrapolated to entire U.S. industry (100 plants):
  - Expect to see a fire involving SO every 2 or 3 years
- No operating experience to support such a rate

**Likelihood of spurious operations significantly overstated in  
FPRAs versus operating experience**

# Over-Prediction of Fire Risk

- Difficult to use CDF values for comparison with industry performance
- However, it is straightforward to identify scenarios involving a high conditional core damage probability (CCDP) for comparison to industry experience
- CCDPs are routinely assessed by:
  - NRC's Accident Sequence Precursor (ASP) Program
  - Reactor Oversight Process (ROP)
- Approach:
  - Review set of representative FPRAs to identify the frequency of fires involving high CCDPs

# Over-Prediction of Fire Risk: Industry Experience with Fire CCDPs (Cont.)

- ASP Program
  - Maintains a list of “significant precursor” events
    - $\text{CCDP} \geq 1\text{E-}3$
  - Trends high CCDP events
    - $\text{CCDP} \geq 1\text{E-}4$
- “Significant precursor” events are relatively rare in recent operating experience:
  - No “significant precursor” events have occurred in the industry since 2002
- Of the 34 “significant precursor” events, only one involves a fire (1975 Browns Ferry)

# FPRA Model Prediction of High CCDP Damage Conditions

FPRA Model	Predicted Frequency of “Significant Precursor” Events (CCDP > 1E-3)	Predicted Frequency of High CCDP Events (CCDP > 1E-4)
Plant A	1.0E-3/yr	1.0E-2/yr
Plant B	9.9E-3/yr	2.0E-2/yr
Plant C	3.3E-3/yr	1.4E-2/yr
Plant D	1.3E-3/yr	3.2E-2/yr
Plant E	4.7E-3/yr	3.2E-2/yr
Range	1.0E-3/yr to 9.9E-3/yr	1.0E-2/yr to 3.2E-2/yr
Industry-wide Recurrence Interval	Every 1 to 10 yrs	1 to 3 <u>per year</u>
Actual Experience	Extremely infrequent. No evidence of such a rate	None from 2001-2009 based on SECY-10-0125

# SECY 10-0125 Results for CCDP >1E-4




Figure 2. Precursors with High Safety Significance.

- Total of 8 events
- None involved fires
- FPRAs would have predicted ~9 to ~30 fire events, industry-wide for same period

**FPRAs prediction of high CCDP conditions does not comport with actual operating experience**



# ROP Experience

- ROP routinely evaluates CCDP of events and conditions
  - Based on actual plant condition
- ROP Criteria:
  - Green: CDP/CCDP  $< 1E-6$
  - White: CDP/CCDP  $1E-6$  to  $1E-5$
  - Yellow: CDP/CCDP  $1E-5$  to  $1E-4$
  - Red: CDP/CCDP  $>1E-4$
- To date, no actual fire events have been considered Red or Yellow (CCDP  $>1E-5$ )
- Fire PRA models would have predicted many each year across the industry

# Over-Prediction of Fire Risk: Conclusions


- Evidence that FPRA methods are significantly over-predicting the frequency of:
  - Spurious Operations
  - High CCDP conditionsas compared to actual industry experience
- This directly contributes to the over-prediction of computed Fire CDF

# Summary of Roadmap Conclusions

Conclusion	Primary Bases
Fire characterization does not conform with operating experience	<ul style="list-style-type: none"> <li>• Over-prediction of number of severe fires</li> <li>• Assumed rate of fire growth &amp; severity, e.g., 12 mins in electrical cabinets, oil fire severity</li> <li>• No credit for control of fires</li> </ul>
The level of quantified risk is overstated	<ul style="list-style-type: none"> <li>• FPRAs based on NUREG/CR-6850 predict high frequency of fires with high CCDPs, but NRC's ASP &amp; ROP have not demonstrated this</li> <li>• Predicted frequency of spurious operations not consistent with operating experience</li> </ul>
Uneven level of conservatism can mask key risk insights and lead to inappropriate decision-making	<ul style="list-style-type: none"> <li>• Simplifications result in bounding treatment of "bin"</li> <li>• Overstated fire damage can lead to underestimation of risk increases from plant changes</li> <li>• Assumes plant challenge for all fires, e.g., plant trip</li> <li>• No credit for administrative controls</li> </ul>

**Many areas of expedited research needed to provide enhanced methods**

# FPRA Issues Framework



# Category 1: Fire Initiation, Detection, Suppression

## Areas In Need of Additional Realism:

- Fire Event Data Characterization
  - Fire Events Database
  - Fire Ignition Frequency
- Fire Severity Characterization
  - Incipient Fire Growth in Electrical Cabinets
  - Oil Fire Severity
- Incipient Detection
  - Credit for Incipient Detection
- Fire Suppression & Control
  - Credit for Fire Suppression & Control

# Category 2: Fire Damage Assessment

## Areas In Need of Additional Realism :

- Fire Growth Assumptions
  - Fire growth and comparison with data
- Peak Heat Release Rates
  - Electrical cabinet peak heat release rate (HRR)
  - Transient Ignition Source HRR
  - Hot Work HRR
  - Other HRRs
- Damage Assessment
  - Switchgear High Energy Arcing Faults
  - Bus Duct High Energy Arcing Faults
  - Damage to Sensitive Electronic Equipment
- Fire Propagation
  - Electrical cabinet propagation
- Fire Modeling
  - Fire Modeling Guidance

# Category 3: Plant Impact, Fire PRA Scenarios & Quantification

## Areas In Need of Additional Realism:

- Treatment of Hot Shorts
  - AC Circuits Hot Short Probability and Duration
  - DC Circuits Hot Short Probability and Duration
- Human Reliability
  - Human Reliability Methods (HRA) methods and performance shaping factors for fire PRAs
- Modeling of Control Room Fires
  - Control Room Modeling and Treatment in the Fire PRA
- PRA Model Advancement
  - Address unrealistic model simplifications

# EPRI Fire PRA Action Plan

- Initiated in late 2009 as a means to clarify and coordinate industry activities related to fire PRA methods
  - Updated as new issues are identified
- Includes activities led by EPRI, NEI, PWROG, BWROG
- Roadmap used to align and help establish priorities
- Reports to NSIAC via an Executive Oversight Group
- Technical tasks coordinated within the NEI FPRATF



# EPRI's Immediate-term Focus


- Fire Events Database (through 2009)
  - Pre-2000 data in NUREG/CR-6850 shows a reduction in fire frequencies around 1990 (EPRI-1016735). Updated FEDB will investigate this trend
  - Gather more information about the events to better couple with treatment in FPRA
  - Determine if and when component based frequencies are warranted
  - Begin to address plant-to-plant variability
- Vertical electrical cabinet heat release rate
  - Incorporate more information on actual configuration
- Review of alternative methods that address conservatisms

# Summary

- **Results using current fire PRA methods do not comport with operating experience and make good risk-informed decision-making difficult**
- **EPRI actively working to provide more realistic methods and data**
- **Industry requests that the ACRS:**
  - **Confirm the legitimacy of industry's concern**
  - **Encourage NRC Staff to embrace need for additional realism**
  - **Support an extended schedule for NFPA-805 submittals, consistent with NEI's November 15 letter**


# BACKUP SLIDES

# Fire CDF Contribution by Ignition Source



**Electrical cabinets generally important, but other sources can be important on a plant-specific basis**

# Fire CDF Contribution by Ignition Source (without Electrical Cabinets)





# U.S. NRC

United States Nuclear Regulatory Commission

---

*Protecting People and the Environment*

## Transition to 10 CFR 50.48(c), NFPA 805

**Presentation to Full ACRS Committee  
February 10, 2011**

Sunil D. Weerakkody, Ph. D – Deputy Director – Fire Protection  
Division of Risk Assessment – Office of Nuclear Reactor Regulation

# Commission SRM – 6/25/2010

*“The ACRS should conduct a review and report back to the Commission on the current state of licensee efforts to transition to National Fire Protection Association (NFPA) Standard 805. The review should include methodological and other issues that may be impeding the transition process, lessons learned from the pilot projects and recommendations to address any issues identified. The review should determine whether the level of conservatism of the methodology is appropriate and whether any adjustments should be considered. This review should not influence the staff’s actions regarding the pilot projects or the pending license amendment reviews.”*

# Status

- ▶ Pilot activities are complete.
- ▶ Infrastructure documents are complete.
- ▶ NRR plans to begin receiving and reviewing LARs from non-pilots.
- ▶ Fire PRAs have matured sufficiently for the regulator to make regulatory decisions in support of implementing 10 CFR 50.48(c).





# U.S. NRC

United States Nuclear Regulatory Commission

---

*Protecting People and the Environment*

## ACRS Briefing on NFPA 805

Alexander Klein – Chief of Fire Protection Branch

Donnie Harrison – Chief of PRA Licensing Branch

Office of Nuclear Reactor Regulation

Division of Risk Assessment

# Performance-Based Fire Protection

- ▶ NFPA 805 is a national consensus standard that allows licensees to utilize performance-based methods to demonstrate that the installed fire protection systems and features are sufficient to meet specific fire protection and nuclear safety goals, objectives and performance criteria.
- ▶ 10 CFR 50.48(c) “National Fire Protection Association Standard NFPA 805”
  - Issued June 16, 2004
  - Incorporates by reference NFPA 805, “Performance-Based Standard for Fire Protection for Light Water Reactor Electric Generating Plants – 2001 Edition” with limited exceptions
  - Performance-based fire protection program is a voluntary alternative to the existing prescriptive, deterministic fire protection regulations.

# History of Performance-Based Fire Protection Guidance

- ▶ NEI 04-02, Revision 1 issued September 2005
- ▶ RG 1.205 issued May 2006
- ▶ NEI 04-02, Revision 2 issued April 2008
- ▶ RG 1.205, Revision 1 issued December 2009
- ▶ SRP 9.5.1.2 issued December 2009
- ▶ Harris NFPA 805 safety evaluation issued 6/28/2010
- ▶ Oconee NFPA 805 safety evaluation issued 12/29/2010
- ▶ NEI made an updated LAR template available to NFPA 805 Task Force members December 2010

# Fire PRA Methods

- ▶ Fire PRA methodology guidance has existed for several decades, involving industry and standards organizations
  - NUREG/CR-2300 (1983)
    - Developed under auspices of ANS and IEEE
  - NUREG/CR-6850 (2006) & Supplement (2010)
    - Collaborative with EPRI
- ▶ As guidance documents, they are not regulations or requirements
  - Licensees can deviate from these methods and process allows for methods refinements
  - Methods used must have a sound technical bases

# NRC FAQ Process

- ▶ As lessons were learned through the pilot process, licensees asked for a semi-formal process to address guidance document changes
- ▶ Frequently Asked Question (FAQ) process established to provide interim staff approval of changes to NEI 04-02 guidance
- ▶ Process has had substantial impact on transition
  - Facilitated resolution of over 50 significant technical/regulatory issues related to NFPA 805 transition
  - Dispositioned 16 fire PRA related FAQs (e.g. modeling Incipient Fire Detection Systems)

# Incorporating Lessons Learned

- ▶ PRA-related FAQs incorporated in Supplement to NUREG/CR-6850
- ▶ Lessons learned during pilot reviews reflected in:
  - Revision to RG 1.205
  - License amendment request template
  - Safety evaluation template
- ▶ Staff developing a paper on additional lessons learned from pilot process

# Reviews of New Methods

- ▶ Early industry peer reviews identified issues with new fire PRA methods
  - Without significant technical bases provided, difficult for peer review teams to accept deviations from NUREG/CR-6850
- ▶ NEI fire PRA peer review guidance (NEI 07-12) revised to include additional guidance and address previously “unanalyzed methods”
  - Industry formed a task force to review these unanalyzed methods
  - NRC interface established with the task force

# Going Forward

- ▶ Fire PRA methods will continue to evolve
  - Similar to all PRA methods, areas of modeling uncertainty or model simplifications usually have some conservatism
  - Method/modeling enhancements are typically driven by risk significant contributors to results and large model uncertainties
    - RCP seal LOCA modeling
- ▶ NRC will continue to be actively involved in these activities
  - NRC/RES involved with EPRI under MOU
  - NRC/NRR established interface with industry fire PRA methods task force



# Conclusion

- ▶ NRC has reviewed and issued safety evaluations for both pilot applications
- ▶ Pilots have indentified practical safety enhancements
- ▶ NRC staff believes the fire PRA methods are sufficiently mature to support NFPA 805 applications
- ▶ Fire PRA methods will continue to evolve and the NRC staff will continue to work interactively and collaboratively with industry