

**Official Transcript of Proceedings**  
**NUCLEAR REGULATORY COMMISSION**

Title: Advisory Committee on Reactor Safeguards  
Power Uprates Subcommittee Open Session

Docket Number: (n/a)

Location: Rockville, Maryland

Date: Wednesday, October 5, 2011

Work Order No.: NRC-1179

Pages 1-132

**NEAL R. GROSS AND CO., INC.**  
**Court Reporters and Transcribers**  
**1323 Rhode Island Avenue, N.W.**  
**Washington, D.C. 20005**  
**(202) 234-4433**

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

UNITED STATES OF AMERICA

NUCLEAR REGULATORY COMMISSION

+ + + + +

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

(ACRS)

+ + + + +

POWER UPDATES SUBCOMMITTEE

+ + + + +

OPEN SESSION

+ + + + +

WEDNESDAY, OCTOBER 5, 2011

+ + + + +

ROCKVILLE, MARYLAND

+ + + + +

The Subcommittee met at the Nuclear Regulatory Commission, Two White Flint North, Room T2B1, 11545 Rockville Pike, at 8:30 a.m., J. Sam Armijo, Chairman, presiding.

SUBCOMMITTEE MEMBERS:

- J. SAM ARMIJO, Chairman
- SAID ABDEL-KHALIK, Member
- SANJOY BANERJEE, Member
- JOY REMPE, Member
- WILLIAM J. SHACK, Member
- JOHN D. SIEBER, Member

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

ACRS CONSULTANTS :

MARIO BONACA

GRAHAM WALLIS

DESIGNATED FEDERAL OFFICIAL :

PETER WEN

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

AGENDA

Opening Remarks . . . . . 4

Staff Opening Remarks . . . . . 6

Introduction . . . . . 7

NMPNS EPU Overview . . . . . 11

Reactor Thermal-Hydraulic Design . . . . . 25

Long-Term Stability Solution Option . . . . . 69

Nuclear Design: Interim Methods . . . . . 82

Material, Mechanical/  
 Civil Engineering Topics

    NMPNS . . . . . 86

    NRR . . . . . 112

    Steam Dryier . . . . . 126

Adjourn . . . . .

## P R O C E E D I N G S

8:28 a.m.

CHAIRMAN ARMIJO: Good morning. This is a meeting of the Power Upgrades Subcommittee. I'm Sam Armijo, Chairman of this subcommittee. ACRS members in attendance are Said Abdel Khalik, Bill Shack, Jack Sieber and Joy Rempe. I saw Dick Skillman around, but perhaps he's attending the other meeting. Dr. Sanjoy Banerjee will not be able to attend the morning session, but will attend this afternoon.

ACRS consultants are Dr. Mario Bonaca and Professor Graham Wallis. Peter Wen is the Designated Federal Official for this meeting. The purpose of this meeting is to review the extended power upgrade request for Nine Mile Unit 2, the staff's draft safety evaluation and associated documents.

You will hear presentations from the Office of Nuclear Reactor regulation and the licensee, Nine Mile Point Nuclear Station, LLC. As shown in the agenda, some presentations will be closed in order to discuss information that is proprietary to the licensees and its contractors, pursuant to 5 U.S.C. 552(b), (c), (3) and (4). Attendance at this portion of the meeting dealing with such information will be limited to the NRC staff, licensee representatives,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 and its consultants and those individuals and  
2 organizations who have entered into an appropriate  
3 confidentiality agreement with them.

4           Consequently, we need to confirm that we  
5 have only eligible observers and participants in the  
6 room, and the closure of the public phone line for the  
7 closed portion. The subcommittee will gather  
8 information, analyze relevant issues and facts, and  
9 formulate proposed positions and actions as  
10 appropriate for deliberation by the full Committee.

11           The rules for participation in today's  
12 meeting have been announced as part of the notice of  
13 the meeting, previously published in the *Federal*  
14 *Register*. We have received no written comments or  
15 requests for time to make oral statements for members  
16 of the public regarding today's meeting.

17           The transcript of the meeting is being  
18 kept and will be made available, as stated, in the  
19 *Federal Register* notice. Therefore, we request that  
20 participants in this meeting use the microphones  
21 located throughout the meeting room when addressing  
22 the subcommittee. The participants should first  
23 identify themselves and speak with sufficient clarity  
24 and volume, so that they may be readily heard.

25           We have several people on the phone bridge

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 lines listening to the discussion. To preclude  
2 interruption of the meeting, the phone lines are  
3 placed on listen in mode. We will now proceed with  
4 the meeting, and I call on Ms. Louise Lunn of NRR to  
5 introduce the presenters. Louise.

6 MS. LUND: Thank you, good morning. I'm  
7 Louise Lund, the Deputy Director of the Division of  
8 Operator Reactor Licensing in the Office of Nuclear  
9 Reactor Regulation. I appreciate the opportunity to  
10 brief the ACRS Power Uprate Subcommittee this morning.  
11 In the interest of time, my opening remarks will be  
12 brief.

13 At this meeting, the NRC staff present to  
14 you the results of our very thorough safety and  
15 technical review of the licensee's application. The  
16 thoroughness of the review is supported by the fact  
17 that we had several pre-application meetings with the  
18 licensee, starting as early as September of 2008, in  
19 which the licensee scheduled an overall proposed EPU  
20 implementation plans were discussed with the NRC.

21 The NRC staff also performed an extensive  
22 acceptance review before initiating our detailed  
23 review of the application. We believe this helped  
24 with the efficiency and effectiveness of our review.

25 During the course of our review, the staff

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 had frequent communications with the licensee, as well  
2 as two audits and numerous conference calls to discuss  
3 the EPU application and its supplemental responses to  
4 several rounds of requests for additional information,  
5 covering multiple technical disciplines.

6 Some of the more challenging review areas  
7 that you'll hear about today include steam dryer  
8 stress analysis, in which Nine Mile submitted its  
9 revised acoustic circuit model, thermal hydraulic  
10 stability analyses, interim methods, specifically the  
11 applicability of GE methods to expanded operating  
12 demands.

13 As presented in the draft safety  
14 evaluation, which was provided to ACRS a month ago,  
15 there are currently no open technical issues in the  
16 NRC staff's review of the licensee proposed extended  
17 power uprate application. We'd like to give our  
18 thanks to the ACRS staff, who assisted us with the  
19 preparations for this meeting, especially Peter  
20 Yarsky.

21 At this point I'd like to turn over the  
22 discussion to our NRR project manager, Rich Guzman,  
23 who will introduce the discussions. Rich.

24 MR. GUZMAN: Good morning. My name is  
25 Rich Guzman. I am the senior project manager in NRR,



1 assigned to Nine Mile Point Nuclear Station. First  
2 off, I'd like to apologize. I'm having some technical  
3 difficulties in projecting the presentation onto the  
4 screen. So at this time I'd ask that you use a hard  
5 copy, the color copies that you have.

6 The first presentation is from the NRC  
7 staff binder, which is titled "Opening Remarks."  
8 During today's Subcommittee meeting, you will hear  
9 presentations from the Nine Mile Point Nuclear Station  
10 and the NRC staff. The objective is to provide you  
11 with sufficient information related to the details of  
12 the EP application, as well as the evaluation  
13 supporting the staff's reasonable assurance  
14 determination that public health and safety will not  
15 be endangered during the operation of this proposed  
16 EPU.

17 Before I cover the agenda items, I would  
18 like to go over some background information really of  
19 the staff review of the Nine Mile Point 2 EPU. On May  
20 27th, 2009 -- well there you have my script --

21 (Laughter.)

22 MR. GUZMAN: All right.

23 CHAIRMAN ARMIJO: Just go ahead. Don't  
24 worry about it.

25 MR. GUZMAN: All right. As you see there,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 on May 27th, 2009, the licensee submitted its license  
2 request for Nine Mile Point 2 EPU. The increase would  
3 be 34.67 megawatts thermal, their current license  
4 thermal power, to 39.88 megawatt thermal. This would  
5 represent a 15 percent increase from their current  
6 license, and a 20 percent increase from their original  
7 license thermal power.

8 The staff's method of review was based on  
9 the RS 001, which is NRC's review plan for EPUs. As  
10 you know, it provides a safety evaluation template, as  
11 well as major C's that cover the multiple technical  
12 areas that the staff is to review.

13 There are no associated or linked  
14 licensing actions associated with this. Nine Mile  
15 previously submitted, and the staff approved two  
16 license amendments, mainly the maximum extended load  
17 line limit analysis, and the AST amendment in 2007 and  
18 2008, respectively. Finally, there were numerous  
19 supplements to the application, responding to multiple  
20 staff RAIs. Overall, there were approximately 25  
21 supplemental responses, which supported our draft  
22 safety evaluation.

23 The staff projects December 2011 to  
24 complete our review, and this would be in support of  
25 the licensee's scheduled implementation in the second

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 quarter of 2012.

2 The next slide on your hard copy binder  
3 there covers the agenda items for the Subcommittee  
4 meeting. The morning will cover the fuel methods and  
5 the thermohydraulic design review areas, mainly the  
6 anticipated transient without scram, and the stability  
7 review. Then the afternoon will go into materials and  
8 the mechanical and civil engineering review, which  
9 will also include the steam dryer analysis.

10

11 Finally, at the conclusion of the meeting,  
12 as needed, we can cover any open items in preparation  
13 for a full Committee meeting. And also to note, there  
14 will be closed sessions during the latter parts of  
15 both the morning and afternoon sessions.

16 So if there's any proprietary information  
17 that needs to be discussed, it can be deferred over to  
18 the designated closed session for the agenda. This  
19 concludes my presentation. I would like to now turn  
20 the presentation over to the licensee, specifically  
21 Mr. Sam Belcher, who is the Senior Vice President for  
22 Operations for the Constellation Fleets.

23 And that said, I am going to eventually in  
24 parallel, as you guys just need, talk to the slides  
25 that is in your binder, I'll eventually get this

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 posted on the wall. I apologize.

2 MR. BELCHER: Thank you. As mentioned, I  
3 am Sam Belcher. I'm the Senior Vice President of  
4 Operations for Constellation Energy Nuclear Group, and  
5 I'll be walking through a presentation. I don't know  
6 if it will make it up not the slide or not, but it is  
7 in your binder and it's titled "ACRS Subcommittee  
8 Presentation," and I'm on point 2, "Extended Power  
9 Uprate, October 5th."

10 I'll be walking us through a very high  
11 level overview, and then we'll get into more technical  
12 details as we move through the morning and into the  
13 afternoon. We'll start with an overview, followed by  
14 a discussion on the plant modifications necessary for  
15 the extended power uprate, anticipated transient with  
16 scram and stability discussion, and then, as mentioned  
17 the closed sessions for fuel methods, material  
18 mechanical civil engineering topics, and then steam  
19 dryer analysis also will be a closed session.

20 At a very high level, Nine Mile Point Unit  
21 2 is a GE BWR 5, with a Mark II containment. Original  
22 license thermal power was 33.23 megawatts thermal. In  
23 1995, a stretch uprate was done of 104.3 percent,  
24 which takes us to the existing license power limit of  
25 34.67 megawatts thermal.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           This amendment would take us to 39.88  
2 megawatts thermal, with the intention to implement  
3 second quarter of next year. This is a constant  
4 pressure power uprate. Additionally, Nine Mile Point  
5 Unit 2 is not requesting any containment accident  
6 pressure credit to support ECCS positive suction head.  
7 I see some smiles there.

8           Also, no new fuel will be introduced as a  
9 part of this uprate. The current core and the EPU  
10 core will be GE 14 fuel consistently. Also, as  
11 mentioned previously, alternate source term has  
12 already been completed, and that was at the EPU power  
13 level as the base assumption. Also previously  
14 discussed is the maximum extended load line limit  
15 analysis, expanded operating domain as well.

16           Finally, the New York state ISO has  
17 reviewed and approved the full EPU power uprate, with  
18 no grid modifications being necessary. The only  
19 modifications that I would note were revenue metering  
20 type modifications for the increased output. But  
21 nothing for grid stability or anything along those  
22 lines.

23           The first two phases of the EPU  
24 modification have been completed, and then the third  
25 and final phase of the modification will be completed

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 in the second quarter of 2012, consistent with the  
2 refueling outage. At this point, unless there are  
3 some questions for me, I will turn it over to Dale  
4 Goodney, who is our lead engineer, to talk in more  
5 detail around some of the plant modifications required  
6 moving forward.

7 MR. GOODNEY: Okay, good morning. As Sam  
8 indicated, I'm Dale Goodney. I'm with Constellation  
9 Energy and the EPU lead, engineering lead for the EPU  
10 project. I'll provide an overview of EPU plant  
11 modifications. We'll cover the general approach, the  
12 review plant parameters and modification installation  
13 time line.

14 We'll summarize the major plant  
15 modifications and then we'll review other Nine Mile 2  
16 plant improvements that are being implemented at the  
17 station.

18 In support of the license amendment  
19 request, a series of engineering studies were  
20 performed to determine the plant's ability to operate  
21 at EPU conditions, and to identify what modifications  
22 may be needed. These studies were developed by a team  
23 of Constellation engineers, industry consultants, GE  
24 Hitachi for the nuclear steam supply system, and  
25 Sargent & Lundy for balance of plant systems.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           These studies analyzed the effects of the  
2           increase in steam flow, feedwater flow, electrical  
3           power output and reactor power on various plant  
4           systems and components. As Sam mentioned, this uprate  
5           is not increasing reactor pressure. Therefore, the  
6           evaluations were performed based on the methodologies  
7           outlined in the past and pressure power uprate  
8           licensing topical report.

9           The analyses were all based on the target  
10          power level of 120 percent of the original license  
11          thermal power. Each study included a review of  
12          relevant operating experience, both internal and  
13          external, and were applicable to results were  
14          incorporated into these evaluations.

15          Another element of the engineering  
16          evaluations were the margin reviews. Design and  
17          operating margins were identified and evaluated for  
18          both NSSS and balance of plant systems, to determine  
19          if there would be adequate margin under EPU  
20          conditions.

21          As a result of these reviews, over 20  
22          physical plant modifications, mostly in the balance of  
23          plant area were identified and described in the  
24          license amendment request. The primary purpose of  
25          these modifications are to (1) restore material

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 condition, (2) install instrumentation for data  
2 collection and analysis, or (3) upgrade or replace  
3 equipment to restore design and operating margins at  
4 EPU conditions.

5 This next slide shows the fundamental  
6 plant process parameters that would change due to the  
7 uprate, and compares the EPU conditions to the CLPP  
8 conditions. These parameters are the primary starting  
9 point for the evaluations that I just described, and  
10 they also form the key design inputs for the  
11 modifications that were developed for the power  
12 uprate.

13 The next slide is the modification  
14 installation time line, and as mentioned in our  
15 earlier slides, the Phase 1 and Phase 2 implementation  
16 is completed. Those are the modifications shown in  
17 the two left-hand columns. The remainder of the  
18 modifications will be installed prior to the end of  
19 the 2012 refueling outage.

20 On the next slide, or next few slides,  
21 will summarize some of these modifications. It will  
22 cover basically four general categories. Feedwater  
23 and condensate, steam path, electrical I&C systems,  
24 and auxiliary support systems.

25 DR. WALLIS: Can I ask you about the steam

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 dryer? This isn't the -- you know, GE has a new  
2 design of steam dryer. That's not the one, right?  
3 It's the old steam dryer, modified because the  
4 analysis says you need to do so. So you're putting in  
5 strengthening at various places and perforated plates  
6 and so on?

7 So just to clarify, that's the old steam  
8 dryer, strengthened because of the results of  
9 analysis?

10 MR. GOODNEY: That's correct, and we'll be  
11 covering those modifications --

12 (Simultaneous speaking.)

13 MR. GOODNEY: Due to the higher feedwater  
14 flow requirements, the feedwater pumps will be  
15 modified with new rotating elements, new step-up gears  
16 and modified flow control valve trim. In addition,  
17 the heater drain pumps in motors were replaced in  
18 2010, to increase the capacity of the pumps. These  
19 changes will provide the additional flow margin  
20 required for normal, off normal and transient  
21 conditions.

22 Reactor recirculation runback logic is  
23 being modified to maintain scram avoidance margin  
24 following a single feedwater pump trip. This will be  
25 accomplished by initiating the runback immediately on

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 a feedwater pump trip, increasing the runback rate of  
2 the reactor recirc flow control valve, and -- the  
3 higher feedwater pump runoff flow capacity.

4 In terms of the steam path, the high  
5 pressure turbine we replaced with a monoblock rotor,  
6 new diaphragms and buckets to increase the steam flow,  
7 six relief valves located on the reheat piping will be  
8 replaced with valves with a higher set pressures to  
9 increase the steam relieving capacity.

10 Moisture separate reheaters on the fifth  
11 and sixth point feedwater heaters, will be rerated to  
12 higher pressures, and as you mentioned earlier, the  
13 steam dryer will be modified to provide the required  
14 structural margin at the higher steam flows, and we'll  
15 provide more details of those modifications in the  
16 afternoon session.

17 Two electrical modifications are needed to  
18 support the higher power output. The isophase bus  
19 duct will be upgraded by installing a higher capacity  
20 cooling system, and the coolers on the main  
21 transformers will be replaced with larger coolers, to  
22 provide additional thermal margin.

23 Instrumentation affected by the uprate  
24 include two tech spec instrument set points, the APRM  
25 flow-biased scram, and the main steam high flow

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 isolation. Those changes are included as part of the  
2 license amendment request. The balance of plant  
3 instrument loops are being rescaled, as required, to  
4 accommodate the higher flows, temperatures and  
5 pressures under EPU conditions.

6 Due to the high heat load in the turbine  
7 building, the turbine building HVAC system will be  
8 modified to install four additional area coolers near  
9 the condensate and condensate booster pumps.

10 The turbine building cooling, although it  
11 does have adequate margins for EPU conditions, it's  
12 going to be modified to isolate retired loads to  
13 provide additional margin, and the system will be  
14 rebalanced to ensure that we get accurate cooling to  
15 all the power-dependent loads supplied by the system.

16 So that completes the preview of the EPU  
17 modifications.

18 CHAIRMAN ARMIJO: I have a question, not  
19 about modifications, but many years ago, a number of  
20 the BWRs had stress corrosion cracking problems in  
21 their recirc piping, core repiping, and a number of  
22 them did some replacements of the original type 304  
23 stainless steel with an improved material, 316 nuclear  
24 grade.

25 I didn't, don't remember. What did you do

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 at Nine Mile 2? Are you still using the original  
2 recirc piping?

3 MR. INCH: Yes, the original Unit 2 was,  
4 went into service in '87, and the piping was  
5 originally, you know --

6 CHAIRMAN ARMIJO: You'll have to speak a  
7 little bit louder, so that the microphone --

8 MR. INCH: The piping at Unit 2 was  
9 originally considered as upgraded piping. I believe  
10 it's 316. I'll have to verify that.

11 CHAIRMAN ARMIJO: Yes, if you could. So  
12 it was built at a time. By that time, people knew  
13 this was a better way to build it, and you just  
14 happened to be at the right place at the right time.

15 MR. INCH: It was a safe end replacement  
16 prior to service, where they replaced the safe ends  
17 with IGSCC-resistant materials. That was all done  
18 prior to service.

19 CHAIRMAN ARMIJO: Okay, all right. Thank  
20 you.

21 MEMBER SHACK: But just on that point, you  
22 do have a number of Class D welds left.

23 MR. INCH: Yes.

24 MEMBER SHACK: At least there's a  
25 discussion of that in the --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. INCH: The Class D welds are the  
2 similar metal welds, the safe end to nozzle welds. So  
3 that is the --

4 MEMBER SHACK: But they're what, ferritic  
5 to a normal carbon steel safe end? Is that --

6 MR. INCH: It's the stainless steel safe  
7 end to the low alloy steel nozzle. It's the similar  
8 metal weld, and that's the -- those are the category,  
9 considered Category D welds, per 8801, Generic Letter  
10 8801.

11 CHAIRMAN ARMIJO: And some of those you've  
12 done a weld overlay, repair, mechanical stress  
13 improvement?

14 MR. INCH: There was one indication on one  
15 of the high pressure core spray lines, that a  
16 mechanical stress improvement was done in the early  
17 90's. We've been monitoring that since then, with no  
18 growth.

19 It was an indication identified in one of  
20 the feedwater nozzles, approximately ten years ago.  
21 There was an overlay done on that. Otherwise, we're  
22 not tracking any --

23 CHAIRMAN ARMIJO: So with the exception of  
24 those two components, it's the as-built material?

25 MR. INCH: Yes.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN ARMIJO: Okay, thank you. And  
2 when did you start the hydrogen water chemistry?

3 MR. INCH: Hydrogen water chemistry was  
4 started in, it was either 2000 or 2001. We  
5 implemented hydrogen water chemistry in combination  
6 with noble metals. So it's always been a noble metals  
7 hydrogen water chemistry application.

8 MEMBER SIEBER: I may have I missed it,  
9 but in my review of the material that was included,  
10 that Nine Mile Point 2 has a Mark II containment,  
11 which is the upside down lightbulb or ice cream cone,  
12 similar to the Mark I containments in containment  
13 volume, but the geometry was different.

14 Did you analyze the containment  
15 capability, insofar as you now have approximately 20  
16 percent over the original design stored heat acumen  
17 environment?

18 MR. INCH: Yes.

19 MEMBER SIEBER: And if so, did that  
20 consider fuel failures, cladding oxidation and so  
21 forth? How far did you go in that analysis?

22 MR. INCH: The design bases analyses were  
23 redone for the higher megawatt thermal.

24 MEMBER SIEBER: Right.

25 MR. INCH: And decay heat levels, and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 those were performed by GE, using their design bases  
2 methods for the higher power levels, and mainly  
3 because it's -- the peak pressure is governed by the  
4 short-term blowdown, and because it's a constant  
5 pressure power uprate, the peak pressure associated  
6 with that blowdown has not changed.

7 MEMBER SIEBER: Right, that's true.

8 MR. INCH: And the long-term response --

9 MEMBER SIEBER: Has to be increased.

10 MR. INCH: Long-term response was  
11 mitigated by the suppression pool cooling systems.  
12 There's significant margin built into the original  
13 design on those systems, that the original design  
14 analyses had not credited. So by actually crediting  
15 those systems capability, we were able to maintain the  
16 suppression pool temperature effectively the same in  
17 design bases space as current.

18 So there really wasn't any significant  
19 change in the long-term pressure temperature profile  
20 for the --

21 MEMBER SIEBER: Or change at all?

22 MR. INCH: Effectively, yes.

23 MEMBER SIEBER: I have to think about  
24 that.

25 MEMBER SHACK: While we're at it, is this

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 a vented Mark II? Is there a vent on this Mark II?

2 MR. GOODNEY: Phil.

3 MEMBER SIEBER: Has to be.

4 MR. AMWAY: My name is Phil Amway, and I'm  
5 the extended power uprate operations lead, and I  
6 maintain an active senior reactor operator's license  
7 for the facility. Nine Mile Point 2 is able to vent  
8 the containment through a path that will divert the  
9 containment out directly to the stack, using a bypass  
10 around the PTS train. We have that capability.

11 CHAIRMAN ARMIJO: You know, this is a  
12 little bit off the scope, but you can't help it,  
13 because of the Fukushima events. How do you test  
14 those vents? Do you ever test them or that they --

15 MR. AMWAY: We have performed, and again,  
16 my name is Phil Amway. We have performed walkdowns of  
17 those procedures. We have procedures in place that  
18 line up that vent path. All the materials are staged  
19 to do so. We cover it in training. We have not  
20 actually physically made the alignments, to actually  
21 vent in that mode. But it is a fairly simple  
22 mechanical arrangement that could be done.

23 CHAIRMAN ARMIJO: Is there a rupture disc  
24 in that design or not?

25 MR. AMWAY: There is no rupture disc, no.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 DR. BONACA: So it's a duct. Is it the  
2 hard piping or --

3 MR. AMWAY: It's hard piping. We actually  
4 bypass around any duct work that would be subject to  
5 the high pressure condition.

6 MR. BELCHER: If I may add, I'm Sam  
7 Belcher, the Senior Vice President for Operations for  
8 Constellation Energy Group. While we have processes  
9 and procedures and training in place, based on the  
10 recent events, we are looking in detail at  
11 improvements, not only at the Nine Mile Point site,  
12 but at our other sites as well.

13 I think there are lessons learned that  
14 will ultimately lead to us doing things differently.  
15 But we are looking at that.

16 CHAIRMAN ARMIJO: Okay, continue on.

17 MR. GOODNEY: No problem. This final  
18 slide covers other plant improvements that the station  
19 has implemented or is planning to implement, to  
20 restore material condition, improve margin, improve  
21 equipment reliability. Some examples are replacement  
22 of the third point feedwater heaters in 2010; the  
23 standby flow control relief valve margin was improved.

24 Cleaning tower upgrades were implemented.  
25 New feedwater pump seals will be installed, according

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 to the feedwater pump modifications I mentioned  
2 earlier. One of the more significant improvements,  
3 the station plans to replace all 20 jet pump inlet  
4 mixers during the 2012 refueling outage. That will  
5 restore the equipment back to the original design  
6 performance, restore core flow margin, and address  
7 operating experience relative to flow-induced  
8 vibration.

9 Then finally, there have been several PRA-  
10 related risk reduction improvements, consisting of  
11 procedure changes and other minor modifications. As  
12 a result of these improvements, since 2008, the core  
13 damage frequency at Nine Mile Point has been reduced  
14 by 78 percent.

15 So that concludes my presentation on  
16 modification overview. Pending any questions, I'll  
17 turn this over to Phil Amway, to discuss power  
18 ascension testing.

19 MR. AMWAY: Thank you, Dale. Again, to  
20 reiterate, my name is Phil Amway. I'm the extended  
21 power operations lead. I'll be giving two  
22 presentations this morning. The first area is for the  
23 power ascension testing program. Under this topical  
24 area, we'll discuss the preparation of the program,  
25 approach to uprated power --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER ABDEL-KHALIK: I'm sorry. Can we  
2 go back to the previous slide?

3 MR. AMWAY: Sure.

4 MEMBER ABDEL-KHALIK: You indicated that  
5 you will replace the jet pump inlet mixers?

6 MR. GOODNEY: That's correct.

7 MEMBER ABDEL-KHALIK: Could you explain  
8 more of the rationale for that?

9 MR. GOODNEY: I apologize. Excuse me.  
10 You'd like to know the rationale behind replacing the  
11 jet pump inlet mixers, and whether that will impact  
12 the core flow measurement instrumentation.

13 MR. INCH: Oh, the jet pumps become fouled  
14 over years of operation, from a mechanism that I don't  
15 fully understand. But they call it a zeta potential,  
16 where you get deposits that affect the efficiency of  
17 the jet pumps. At Nine Mile, that's been occurring  
18 for several years.

19 There's several options available. Ultra  
20 high pressure cleaning is an option that was  
21 considered, and but there's essentially the new mixers  
22 we're putting in are identical to the original design.  
23 So it restores the jet pumps to a new condition, and  
24 so that's what is going on.

25 So therefore, the instrumentation is not

1 affected. It just basically restores the performance  
2 to the original performance.

3 MEMBER ABDEL-KHALIK: But the relation  
4 between the driver flow, the jet pumps and the actual  
5 core flow will change as a result of that  
6 modification; is that correct?

7 MR. INCH: It will be restored to the  
8 design bases, drive flow design basis and ratio, but  
9 it's not a change to the design. So operational  
10 procedures, every refuel outage, do a new baseline for  
11 where those jet pumps are, to establish the  
12 correlation between dry flow and core flow.

13 Then that's put into the instrumentation,  
14 and it's all proceduralized, because it does change  
15 over time. So the procedures account for that change.

16 MEMBER ABDEL-KHALIK: So that when the  
17 operators, the current procedures for knowing where  
18 they are on the power flow map, they use the driver  
19 flow or they use the direct total core flow, as  
20 measured from the 20 jet pumps?

21 MR. INCH: Operations has core flow.  
22 Phil.

23 MR. AMWAY: We use total core flow direct  
24 indication.

25 MR. INCH: When we plot our --

1 MR. AMWAY: Yes.

2 MEMBER ABDEL-KHALIK: But in that process,  
3 you use the relationship between the driver flow and  
4 the core flow, which you say you empirically calibrate  
5 every outage?

6 MR. INCH: Yes.

7 MR. AMWAY: Every outage, and it's part of  
8 our start-up test program as well. We will do the  
9 core flow calibration, which will calibrate the dry  
10 flow to the jet pump flow.

11 MEMBER ABDEL-KHALIK: How much has that  
12 calibration changed since the jet pump inlet mixers  
13 were replaced? Oh, you have no idea.

14 (Simultaneous speaking.)

15 MEMBER ABDEL-KHALIK: How much has that  
16 changed over the years, as a result of fouling?

17 MR. AMWAY: It has changed gradually over  
18 the years. It's actually a reactor engineering  
19 procedure. It's done at the conclusion of each  
20 outage, once we get the full rated power. We'll do  
21 that procedure and the trend has been, the acceptance  
22 criteria of that procedure is as long as the  
23 calibration is within two percent, no additional  
24 action is required.

25 It's about every third outage we actually

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 have to go in and make a change, and adjust the gains  
2 on the dry flow to match the core flow.

3 MEMBER ABDEL-KHALIK: So the allowable  
4 deviation between the two flow indications is two  
5 percent you said?

6 MR. AMWAY: Two percent.

7 MEMBER REMPE: Do you expect the new  
8 plants that you're replacing to have similar fouling  
9 characteristics?

10 MR. INCH: The new mixers, we hope to be  
11 able to manage the fouling a little bit better. The  
12 plan is to they'll have a coating on them, that will  
13 resist fouling. It's not 100 percent, but it should  
14 reduce the rate of fouling.

15 MEMBER SHACK: What is this magic coating?

16 MR. INCH: That's proprietary. I can't --  
17 we can talk about that in closed session, I guess.

18 MEMBER SHACK: Yes.

19 CHAIRMAN ARMIJO: You may want to do that.

20 MEMBER SHACK: But otherwise its geometry  
21 is identical, with the exception of a coating to  
22 surface treatment of some sort, to minimize the  
23 fouling rate.

24 MR. INCH: To try and minimize future  
25 fouling, yes, right.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER ABDEL-KHALIK: But generally th  
2 trend is that the actual core flow will likely be less  
3 than the indicated core flow. Is that the -- or is it  
4 the other way around?

5 MR. INCH: Right now, the design M ration  
6 for the jet pump mixers is -- at EPU, it will be about  
7 2.28.

8 MEMBER ABDEL-KHALIK: No, no, no. I'm  
9 asking about the effect of fouling, and you're  
10 allowing a two percent deviation between or two  
11 percent variation on the calibration, in the empirical  
12 calibration between driver flow and actual core flow.

13 MR. INCH: I believe what Phil's referring  
14 to is just the instrumentation tolerances --

15 MEMBER ABDEL-KHALIK: That's right.

16 MR. INCH: That are built into the design  
17 bases. The fouling occurs over very long periods of  
18 time, over many years in the cycle.

19 It's a very gradual process, and the  
20 frequency for the calibrations will maintain and  
21 ensure that the relationship between dry flow and core  
22 flow is accurate to within the design tolerances at  
23 all times. But it's not something that occurs  
24 suddenly. I'm not sure if I'm --

25 MEMBER ABDEL-KHALIK: I'm just trying to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 understand the direction of the trend.

2 MR. INCH: Okay.

3 MEMBER ABDEL-KHALIK: Okay, and the time  
4 line associated with that trend. You say that you  
5 need to do that roughly every third outage?

6 MR. AMWAY: About every third cycle. We  
7 actually have enough mismatch between the two  
8 measurements that we actually adjust the gains of the  
9 dry flow.

10 MEMBER ABDEL-KHALIK: So that sort of  
11 gives you an indication of how quickly the core flow  
12 is being impacted as a result of fouling? Or is it  
13 just drift?

14 MR. AMWAY: It's just looking at the total  
15 -- I mean some of that could be drift, some of that  
16 could be fouling. I'm just looking at the total  
17 measurements of drive to driven flow when we do that  
18 procedure. It's not really looking at specific  
19 factors that may input to that deviation of two  
20 percent.

21 MR. INCH: I can give you a feel for some  
22 of the numbers. The original, when we first started  
23 the plant up in '87, the original calibration for dry  
24 flow was approximately 41,000 GPM for a rated core  
25 flow, which is 108-1/2, 108-1/2 million pounds per

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 hour. That's the relationship. So M ratio, drive to  
2 driven of approximately 2.4 or 2.5, I believe, at  
3 OLTP.

4 Now, for to achieve 108, the rated core  
5 flow, 108 million, we need 46,000 GPM drive flow, and  
6 that's occurred over 22 years. That's the -- it's a  
7 gradual change. It is affected by the stretch uprate  
8 in effect. When we did the stretch uprate in 1995,  
9 that was the original design, five percent uprate.

10 Then fuel type has some effect on it. C  
11 Core DP has some effect on it. So as the, you get  
12 some of the newer fuel design, you have a higher two  
13 phase pressure drop. So that, the jet pumps have to  
14 work a little bit harder. So that's in the mix with  
15 some of those relationship changes.

16 CHAIRMAN ARMIJO: So do you expect the  
17 fouling rate to be greater with the higher flows at  
18 EPU?

19 MR. INCH: Again, our flows are really not  
20 higher. They're the design flows. So the fouling  
21 rates really shouldn't change from what it's been  
22 historically. The change for power uprate, changes to  
23 the core DP are slightly. So we need basically it's  
24 a 1.9 percent effect on the dry flow relationship.

25 MEMBER ABDEL-KHALIK: But if the fouling

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 is some sort of a deposition of some, let's say an  
2 iron oxide or some other material on those mixers,  
3 you're putting a lot more water with all that same  
4 material through, over a given period of time. So I  
5 would expect the fouling to be faster.

6 MR. INCH: It's important that -- we're  
7 really not putting any more -- the core flow stays the  
8 same, and the dry flow really is the same. Now what  
9 we're doing is put it back to the original core  
10 relationship and efficiency of the jet pump. So the  
11 rate of fouling should be equivalent.

12 MEMBER SHACK: And with your magic  
13 coating, less.

14 MR. INCH: Well, hopefully yes.

15 CHAIRMAN ARMIJO: Okay.

16 DR. BONACA: Just one question I had  
17 regarding the vent. Do you have that venting  
18 procedures?

19 MR. AMWAY: Yes, we do have venting  
20 procedures. It's part of our emergency operating  
21 procedures, support procedures. But we do have those  
22 in place.

23 DR. BONACA: All right, thank you.

24 MR. AMWAY: All right. If I may continue  
25 on under power ascension testing, I'm on Slide 17.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 The topical areas that I want to address under power  
2 sensitive testing are preparation, approach, schedule,  
3 the test plan and the acceptance criteria and actions.

4 Under the preparations, our objective of  
5 the start-up test program is to demonstrate  
6 satisfactory equipment performance, ensure we have a  
7 careful, monitored approach to EPU power level, and to  
8 ensure that we meet established requirements.

9 We define the roles and responsibilities  
10 in the master start-up test procedure. We have used  
11 industry benchmarking to confirm that our test program  
12 matches similarly uprated BWRs, and also that our test  
13 plan and implementing test procedure development is  
14 consistent with industry standards.

15 We will also perform operator training on  
16 the power ascension test program, including the test  
17 procedures that will be performed. The approach is  
18 similar to that used for other BWRs that have  
19 implemented extended power uprate, and that is  
20 incremental testing approach. We collect baseline  
21 data at 75, 90, 95 and 100 percent of current licensed  
22 thermal power.

23 Once we rise above the 100 percent current  
24 licensed thermal power, we will perform data  
25 acquisition and incremental steps of one percent, and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 an analysis of two and a half percent. Every five  
2 percent plateau is a major testing window that  
3 includes the active as well as the passive testing,  
4 and there is an NRC data review with those five  
5 percent incremental levels.

6 DR. WALLIS: And in doing this, you have  
7 instrumented the steam lines? They go and look at the  
8 fluctuations and that sort of thing.

9 MR. AMWAY: That is correct. That's part  
10 of the ascension program. Power ascension testing  
11 approach for Nine Mile 2 does not include large  
12 transient testing. The basis for that is the  
13 substantial industry operating experience from uprated  
14 plants that have experienced large transient post-EPU  
15 implementation, and also Nine Mile Point specific data  
16 for large transients that have occurred at the station  
17 at 104.3, which is the uprate, stretch uprate power  
18 level.

19 We were able to use that data to  
20 accurately project, using the analytical methods that  
21 are available today, such that we fully understand how  
22 the plant will respond post-uprate for large  
23 transients.

24 MEMBER ABDEL-KHALIK: If you'll go back  
25 again to the previous slide, please.

1 MR. AMWAY: Sure.

2 MEMBER ABDEL-KHALIK: Have you had any  
3 experience with the SRV leaks?

4 MR. AMWAY: With SRV leaks, and I may ask  
5 George to provide additional information here, but  
6 recently our SRV leakage has been very good.

7 We had problems, I'll say in the mid-90's,  
8 with SRV leakage that was indicated by rising  
9 suppression pool temperatures, and the frequency at  
10 which we had to place suppression pool cooling in  
11 service, to maintain pool temperatures just at normal  
12 power.

13 That has not been the experience that I've  
14 seen in the power plant for the last 10-12 years, and  
15 I would say that we're not seeing it in tail pipe  
16 temperatures, or the suppression pool temperatures.  
17 George, do you have anything additional to add to  
18 that?

19 MR. INCH: No. I might add that when we  
20 stopped doing the steam flow surveillance tests,  
21 actually opening the SRVs and closing them, which  
22 challenges the receding, the SRV leakage has gone away  
23 as a problem. So it's been very effective.

24 MEMBER ABDEL-KHALIK: And post-outage  
25 testing of the SRVs, they meet the specs, as far as

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 set point?

2 MR. INCH: Oh yes. I'm not prepared right  
3 now to go into any of those details, but yes. They  
4 change them out in accordance with a rotation plan.  
5 They are tested at offsite. I believe they're sent  
6 offsite and tested each outage. If you need more  
7 details, I would have to come back.

8 MEMBER ABDEL-KHALIK: I'm just trying to  
9 get just step by step here. So this emphasis on  
10 instrumentation is in primarily during the power  
11 upgrade, is in primarily concerns with regard to the  
12 steam dryers.

13 MR. AMWAY: It's primarily with the steam  
14 dryer, but it also includes balance of plant piping,  
15 because of the increased steam flows and feed flows,  
16 and we will be monitoring that vibration in those same  
17 increments on the way out.

18 MEMBER ABDEL-KHALIK: Is there any concern  
19 about increased leakage from the SRVs, as a result of  
20 the increased steam flow, and the potential acoustic  
21 coupling associated with the SRVs?

22 MR. INCH: No. We've looked at that  
23 fairly significantly with our instrumenting. The main  
24 steam lines with accelerometers in the vicinity of  
25 SRVs, to make sure that there's no coupling.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 Analytically, we're not seeing any, haven't seen and  
2 are not predicting to see any issues with this --

3 MEMBER ABDEL-KHALIK: How would your  
4 instrumentation tell you whether or not you have  
5 increased leakage out of the SRVs, as a result of the  
6 --

7 MR. INCH: Well have, there's tailpipe  
8 instrumentation to tell us if it's leaking. They  
9 know.

10 MR. AMWAY: That's correct.

11 CHAIRMAN ARMIJO: And you have what kind  
12 of measurement?

13 MR. AMWAY: It's a temperature  
14 measurement, right on the tailpiping.

15 MEMBER ABDEL-KHALIK: Do you have a two-  
16 stage or a three-stage SRV?

17 MR. GOODNEY: Are you referring to Target  
18 Rock?

19 MEMBER ABDEL-KHALIK: Right.

20 MR. GOODNEY: No, we don't have Target  
21 Rock.

22 MEMBER ABDEL-KHALIK: You don't have  
23 Target Rock. So what kind of SRVs do you have?

24 MR. INCH: They're Dikkers.

25 MR. GOODNEY: Dikkers.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER ABDEL-KHALIK: And they're  
2 instrumented only by measuring temperature in the  
3 tailpipe?

4 MR. INCH: I believe so. I would have to  
5 verify that.

6 MEMBER ABDEL-KHALIK: Okay.

7 MR. AMWAY: As far as what we see in the  
8 control room, the temperature is our primary  
9 indicator, the tailpipe temperature. You know,  
10 they're also fitted with acoustic monitors that would  
11 tell you to actually lift it.

12 MR. INCH: That's what I think, yes.

13 MR. AMWAY: But for the leaking, it's just  
14 the thermocouples on the tailpipe.

15 MEMBER ABDEL-KHALIK: All right, thank  
16 you.

17 MR. AMWAY: You're welcome. I'm up to  
18 Slide 21 now, the power ascension testing schedule.  
19 Data collection in one percent intervals, data  
20 evaluation, two and a half percent intervals, and then  
21 the major testing plateaus at five percent intervals.

22 That five percent test plateau includes  
23 passive data collection, which includes the vibration  
24 monitoring, radiation monitoring and plant parameter  
25 monitoring. The active testing is associated with the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 stability of the various pressure control and  
2 feedwater level control systems.

3 We will perform data analysis of both the  
4 active and passive testing, and then that data will be  
5 reviewed by station management through the Plant  
6 Operations Review Committee, and then submitted to the  
7 NRC for review.

8 This next slide just shows an overview of  
9 the various tests that are performed at the power  
10 levels. Across the top of the slide, you'll see the  
11 percent for current license thermal power, and the  
12 intervals that we're doing the testing. Those power  
13 levels in red, that are red highlighted, are those  
14 associated with the five percent test plateaus at  
15 which data will be transmitted to the NRC for review.

16 Then all the X's in the box along the left  
17 column, you see the various tests that are performed,  
18 and the X's designate how often they're performed, at  
19 what power levels. Those indicated in the blue  
20 shading are those that also have one percent data  
21 collection requirements.

22 For power ascension testing acceptance  
23 criteria, there's two major levels. The Level 1  
24 acceptance criteria is associated with a limit  
25 associated with plant safety.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           If we reach a Level 1 criteria, we abort  
2           from the test. We reduce power level to a known safe  
3           condition, and that would be the power level at which  
4           the Level 1 criterion was verified met, and that we  
5           will use our corrective action program to evaluate the  
6           condition and determine required actions. Then we  
7           will repeat the testing, to verify Level 1 criterion  
8           is satisfied and document results.

9           Level 2 is the limit associated with plant  
10          or equipment performance that does not meet design  
11          expectations, but is not immediately adverse to plant  
12          safety. We will perform similar actions, in the terms  
13          of we will place the test on hold, and if needed,  
14          lower power, and then again use the corrective action  
15          program to determine the requirements.

16          In the Level 2, we may make a  
17          determination that the data is satisfactory and that  
18          we can continue testing. In either event, we will  
19          have to also document the results as a test exception.  
20          The final acceptance criterion that we may encounter  
21          following the start-up program includes things such as  
22          technical specification required surveillance tests.

23          They have their own acceptance criteria,  
24          based on tech spec limits, and if we reach one of  
25          those limits, we would follow the actions in the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 procedures and the plant technical specifications.

2 MEMBER ABDEL-KHALIK: Can you give me an  
3 example of a Level 2 acceptance criterion, and an  
4 example of a Level 1 acceptance criterion that you can  
5 immediately indicate with a test?

6 MR. AMWAY: Yes, I can. For a Level 1,  
7 for the control systems which are tuned, we will  
8 introduce step changes, for example, reactor pressure.  
9 We would expect that the system will respond in a  
10 quarter wave damping fashion, so that any oscillation  
11 is quickly dampened, then maintain steady control of  
12 the plant pressure.

13 If for some reason that we don't meet the  
14 quarter wave damping, but the oscillations are  
15 convergent, such that you reach a final steady value  
16 and pressure, that would be an example of not meeting  
17 Level 2. It doesn't meet the design expectation, that  
18 we should be able to meet the quarter wave damping.

19 If we did that same step change, and we  
20 got a divergent behavior in the oscillations, which  
21 means they did not dampen out and in fact got worse,  
22 then we would have actions in the procedure for how to  
23 deal with that. That would be a Level 1 criterion,  
24 and we would abort that test, to figure out why that  
25 happened.

1 MEMBER ABDEL-KHALIK: Okay.

2 DR. WALLIS: Are these limit curves  
3 evaluated directly by computer, or does someone have  
4 to look at this and look at that, and compare them?

5 MR. AMWAY: We will have both guidance in  
6 the procedure for what the operators can look at  
7 directly by plant instrumentation. But there will  
8 also be backup confirmatory database reviews of the  
9 parameters using computers.

10 DR. WALLIS: So there will be something  
11 set in place, so that when something unusual happens,  
12 it's right there on the computer or there's a warning  
13 or something?

14 MR. AMWAY: That is correct.

15 DR. WALLIS: You don't have to wait for  
16 someone to look at something?

17 MR. AMWAY: That's exactly right. If  
18 there's no further questions on the power ascension  
19 test program, I'd like to proceed on to the long-term  
20 stability, Option 3.

21 In this topical area, I'll discuss an NRR  
22 audit that was performed at Nine Mile 2 in support of  
23 our uprate. We'll discuss long term stability, Option  
24 3, and under that topical area, we'll discuss the  
25 oscillation power range neutron monitor that's

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 installed at Nine Mile 2, the OPRM settings, the  
2 backup stability protection.

3 We'll discuss the 2003 Nine Mile Point  
4 stability event, and conclude with the effects of  
5 extended power uprate on long-term stability solution.  
6 Under the ATWS stability, we'll discuss the Unit 2-  
7 specific ATWS mitigation design features, preparation  
8 for the simulator demonstration that was done in  
9 support of the NRR audit.

10 We'll discuss the MSIV closure with  
11 failure to scram and turbine trip with failure to  
12 scram events, and then we'll address the conclusions  
13 associated with ATWS stability.

14 NRR audit was performed at Nine Mile 2 in  
15 October of 2009. The purpose of that audit was to  
16 demonstrate procedure actions and operator response to  
17 ATWS transience, that EPU conditions conform to  
18 regulatory requirements.

19 The audit reviewed implementation of long-  
20 term stability, Option 3, and it also observed  
21 operator performance in the plant reference simulator  
22 for the two events I discussed, the MISV (ph) closure  
23 and turbine trips with failure to scram.

24 The audit included a review of related  
25 procedures and mitigation strategies, and that audit

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 also concluded in 2009 the simulator was not ready yet  
2 to show comparison data for EPU versus current license  
3 thermal power data. That has since been completed and  
4 provided to the NRC.

5 In terms of a time line for the  
6 oscillation power range monitor, in 1998, Nine Mile 2  
7 received Amendment No. 80, which allowed the  
8 installation of the system, and it ran in the unarmed  
9 condition while we evaluated the performance of the  
10 simulator and performed tuning, to make sure that it  
11 was set up for the Nine Mile 2-specific application.

12 In 2000, we received Amendment 92, which  
13 armed the system, to make the OPRM trips active. In  
14 2002, we implemented a plant-specific DIVOM curve, as  
15 a result of GE Safety Communication 01-01. In 2003,  
16 we implemented further changes to filter frequency and  
17 period tolerance setting for GE Safety Communication  
18 03-20, and that was as it related to the Nine Mile  
19 Point 2003 event.

20 For the OPRM settings, we have cycle-  
21 specific DIVOM analysis performed using a TRACG  
22 methodology. The cycle-specific amplitude set points  
23 are defined in the core operating limits report, and  
24 for extended power uprate, we have reduced the enabled  
25 region from 30 percent of rated thermal power to 26

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 percent of rated thermal power, and that's to maintain  
2 the level of protection the same for extended power  
3 uprate, as it is for current license thermal power.

4 For backup stability protection, the  
5 backup stability protection regions are determined  
6 using cycle-specific ODYSY decay ratio calculations,  
7 and the regions are defined on the plant's power to  
8 flow operating maps. The backup stability protection  
9 actions are defined in plant procedures, with routine  
10 reinforcement in the operator training program, and  
11 the BSP exit regions --

12 MEMBER ABDEL-KHALIK: So if you'll back to  
13 the pervious slide, please.

14 MR. AMWAY: Sure.

15 MEMBER ABDEL-KHALIK: The set point for  
16 recirculation dry flow less than 60 percent. This two  
17 percent uncertainty between the dry flow, in the  
18 calibration between dry flow and actual core flow.  
19 Which direction does that normally go? Does it push  
20 you inside the exclusion zone, or outside the  
21 exclusion zone?

22 MR. AMWAY: The way we actually have our  
23 procedures set up is we implement the enabled region  
24 at 62 percent. So it's active up to 62 percent core  
25 flow, which gives us margin to the 60 percent

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 requirement.

2 MEMBER ABDEL-KHALIK: So even if there was  
3 --

4 MR. AMWAY: So even if it was in a non-  
5 conservative direction, we're still bounded the way we  
6 set the system parameters.

7 MEMBER ABDEL-KHALIK: By the way you set  
8 it up?

9 MR. AMWAY: That's correct.

10 MEMBER ABDEL-KHALIK: Okay, thank you.

11 MR. AMWAY: On Slide 32, I discuss the  
12 2003 stability event. That event was initiated by a  
13 component failure that resulted in a high to low speed  
14 transfer of both reactor recirculation pumps. In that  
15 event, the period-based detection algorithm initiated  
16 an automatic scram, because of core-wide oscillations.

17 The reactor in the post-trip event review,  
18 we determined that the reactor was properly tripped by  
19 the period-based detection algorithm. However, we did  
20 see some unexpected confirmation count resets prior to  
21 the scram.

22 The post-review analysis determined that  
23 two parameter settings needed to be changed, to  
24 address the confirmation count resets, and those  
25 parameters changes had been implemented for a BWR

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 owner's group recommendation.

2 MEMBER ABDEL-KHALIK: So the net effect of  
3 these resets was a delay in reactor trip?

4 MR. AMWAY: That's correct.

5 MEMBER ABDEL-KHALIK: And how much of a  
6 delay was that, time-wise?

7 MR. AMWAY: I would have to take that as  
8 an action to take a look. It was, I mean I was on the  
9 event review team that looked at that data.

10 I can tell you that the backup stability  
11 protection actions that the operators would normally  
12 take and look for in that event were to the point that  
13 the operators even saw any oscillatory behavior, when  
14 the period-based detection algorithms scrambled the  
15 reactor.

16 CHAIRMAN ARMIJO: But we're talking  
17 seconds, minutes, hours?

18 MR. AMWAY: Seconds.

19 CHAIRMAN ARMIJO: Seconds, okay.

20 MEMBER ABDEL-KHALIK: So you'll follow up  
21 on this, and let us know?

22 MR. AMWAY: I will follow up on the actual  
23 time delay between when we think the reactor should  
24 have --

25 MEMBER ABDEL-KHALIK: Should have tripped,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 and the time when it actually tripped.

2 MR. AMWAY: Correct, and when it actually  
3 did, but that is a period of seconds.

4 MEMBER ABDEL-KHALIK: Okay, thank you.

5 MR. AMWAY: You're welcome. Effects of  
6 extended power uprate on the long-term stability  
7 solution. There are no methods changes for extended  
8 power uprate. The maximum rod line remains the same,  
9 and that is the maximum extended load line limit  
10 analysis boundary.

11 The OPRM armed region maintains the same  
12 level of stability protection. Cycle-specific set  
13 point analysis captures core design variations.  
14 Option 3 long-term stability solution remains  
15 unchanged, and the Option 3 OPRM set points will be  
16 developed based on plant-specific DIVOM curves for the  
17 extended power uprate cycle-specific reload analysis.

18 That concludes the overview of the Option  
19 3. We'll move on to the next topic area, the ATWS  
20 mitigation for Nine Mile 2. We'll start off with a  
21 review of the mitigation system design features at  
22 Nine Mile 2. We have a redundant reactivity control  
23 system that is there to protect against ATWS events  
24 and provide mitigation actions.

25 That system is initiated on RPV high

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 pressure of 1,065 psig. At time zero, once that  
2 system actuates, we get a backup scram method, which  
3 is the alternate rod insertion. At the same time,  
4 time zero, we get an automatic reactor recirc pump  
5 trip, to slow speed. Normally, the plant would be at  
6 high speed operation of the recirc pumps.

7 At 60 hertz operation, that would transfer  
8 to low speed at 15 hertz. At 25 seconds into the  
9 transient, which the IRCSS is initiated if reactor  
10 power remains above four percent, which means the ARI  
11 was ineffective at completing the scram, then we get  
12 an automatic feedwater runback.

13 That's going to drop reactor water level  
14 down to where we want it for ATWS mitigation. It's  
15 very effective at mitigating any instabilities that  
16 may occur during the ATWS transient. We also at 25  
17 seconds receive an automatic reactor recirc trip to  
18 off, which would be zero speed.

19 If reactor power remains above four  
20 percent, at 98 seconds, we get automatic boron  
21 injection, and that's with both trains of standby  
22 liquid control.

23 MEMBER ABDEL-KHALIK: And where does the  
24 98 come from?

25 MR. AMWAY: The 98 seconds is a timer

1 that's built into the redundant reactivity control  
2 system. In our accident analysis, we assume 120  
3 seconds. So the 98 seconds bounds the 120 second  
4 analysis.

5 When we prepared for the simulator  
6 demonstration, that demonstration was performed in  
7 2009. So it was before any operator-specific EPU  
8 training on EPU conditions. The crews were provided  
9 with a 10 or 15 minute brief, just to say this is what  
10 EPU is in terms of power levels, steam flow, feedwater  
11 flows, and I used an SRO for the demonstration that is  
12 not part of the extended power uprate team, to avoid  
13 biasing the operator response.

14 The purpose of the setup was to confirm  
15 the expectation that the current procedures that exist  
16 today, and the actions and action times, are  
17 sufficient to address the ATWS event at EPU  
18 conditions, post-EPU compared to current license  
19 thermal power.

20 The initial conditions that we set up  
21 prior to the demonstration. We establish a reactor  
22 power, a full EPU power level of 39.88 megawatts  
23 thermal and 99 percent core flow, which is consistent  
24 with the upper end of the MELLLA boundary. We  
25 establish a pressure pool temperature at 90 degree

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 Fahrenheit, and a suppression pool level at 199.5  
2 feet. Service water temperature, 84 degrees  
3 Fahrenheit, and no control rod motion occurred during  
4 the scram.

5 These initial conditions are consistent  
6 with worse case conditions that could occur prior to  
7 the ATWS initiation, and it's also consistent with the  
8 design analysis inputs.

9 As a result of that demonstration, we  
10 confirmed that the operators are able to place both  
11 loops of suppression pool cooling in service in 404  
12 seconds, which is well within the assumed action time  
13 of 1,080 seconds. We were able to achieve hot  
14 shutdown in 406 seconds, and we maintained peak  
15 suppression pool temperature below the heat capacity  
16 temperature limit, with a five degree margin.

17 It's also important to note that five  
18 degree margin is based on a pressure band of 800 to  
19 1,000 pounds, which is the normal pressure that we  
20 would maintain post-ATWS, until we confirmed that we  
21 were in hot shutdown. There is alternate strategies  
22 available, that if the approach the heat capacity  
23 temperature limit, we would take manual action to  
24 reduce reactor pressure, to gain margin for the heat  
25 capacity temperature limit, and avoid the blowdown.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER ABDEL-KHALIK: Do you have a  
2 schematic of how your power flow map will change after  
3 this power uprate? I'm particularly interested in the  
4 upper right corner of the power flow map.

5 MR. AMWAY: I do have that. If it's okay,  
6 if you let me get through here, before I conclude this  
7 presentation I can bring up my backup slides and show  
8 you the power to flow map.

9 MEMBER ABDEL-KHALIK: Thank you.

10 MR. GUZMAN: This is Rich Guzman. After  
11 the break, we can actually get this laptop working,  
12 and we do have backup slides available. Particularly  
13 if it's something we need to go in closed session, we  
14 can also cover it during the closed session.

15 CHAIRMAN ARMIJO: Yes. Probably we'll  
16 finish this part of the presentation, then take a  
17 break, and so --

18 MR. AMWAY: I can review the two loop  
19 power flow map right at the end of this presentation,  
20 I've got a few more pages, and Joel, that's going to  
21 be my backup Slide No. 10, if you want to get that  
22 ready.

23 So continuing on with Slide No. 37, for  
24 the MISV closure with failure to scram, as I stated,  
25 the containment parameters remain well within design

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 analysis, and when we evaluated the simulator response  
2 to compare critical parameter response, they closely  
3 matched the design analysis for that event.

4 For turbine trip with failure to scram, we  
5 set up the same initial conditions, which again  
6 conform for the worse case conditions expected, and  
7 are consistent with the Design analysis inputs for  
8 that event. The results of the turbine trip with  
9 failure to scram, we again demonstrated the operators  
10 can place both loops of suppression pool cooling in  
11 service at rated flow, in 425 seconds.

12 Again, that's well within the assumed  
13 action time of 1,080 seconds. We achieved hot  
14 shutdown at 465 seconds. We maintained a suppression  
15 pool temperature margin to heat capacity temperature  
16 limit of 19 degrees Fahrenheit. Containment  
17 parameters remained well within design limits, and  
18 again the plant reference simulator behavior, in terms  
19 of critical parameter response, closely matched the  
20 analysis.

21 MEMBER ABDEL-KHALIK: Well, what are you  
22 trying to prove by the fourth bullet?

23 MR. AMWAY: The fourth bullet being the  
24 containment parameters --

25 MEMBER ABDEL-KHALIK: Right, indicated by

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 the simulator.

2 MR. AMWAY: Oh. It would be the fourth or  
3 the fifth bullet then?

4 MEMBER ABDEL-KHALIK: Either this slide or  
5 Slide 37. It's the same kind of information.

6 MR. AMWAY: Okay. The containment  
7 parameters, I'm speaking there in terms of the  
8 suppression pool, peak temperature, the containment  
9 pressures in both the dry well and the supp chamber,  
10 those are the parameters I'm discussing.

11 The design analysis assumes approximately  
12 six to seven psig for these events. That's largely  
13 driven by the expected suppression pool temperature  
14 response.

15 MEMBER ABDEL-KHALIK: But I was just  
16 trying to get to the point of what are you trying to  
17 -- let's go back to Slide 37, please. So if we look  
18 at the fourth bullet here, okay, what are you trying  
19 to prove with this statement?

20 MR. AMWAY: What I'm trying to prove is  
21 that the operator -- that we can meet the operator  
22 response times, and maintain the containment parameter  
23 within design assumptions, or design analysis for  
24 these events.

25 MEMBER ABDEL-KHALIK: Is this a reflection

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 on the simulator model, or a reflection on the design  
2 analysis, or a reflection on the operator ability to  
3 respond to the event?

4 MR. AMWAY: It's based on the operator's  
5 ability to respond to the event.

6 MEMBER ABDEL-KHALIK: So this is not a  
7 statement regarding the fidelity of the simulator?

8 MR. AMWAY: No.

9 MR. INCH: The simulator's not an  
10 engineered model. We don't use it for design. We use  
11 it for operator training. It's been benchmarked to  
12 plant data, and transient data in accordance with the  
13 guidance. I think there's, you know, for simulator  
14 fidelity.

15 MEMBER ABDEL-KHALIK: And that's why I'm  
16 asking the questions, right. The simulator is not an  
17 engineering model. It's simply an empirical model  
18 that's fit to analysis and plant data. So what does  
19 this statement tell you, other than --

20 MR. AMWAY: What I was trying to  
21 demonstrate was the simulator was providing an  
22 accurate training tool to the operators in this event.  
23 So what I did was I looked at critical parameters. So  
24 I'll give you an example. For the boron initiation  
25 temperature, 110 degrees.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           The analysis assumption assumes that we  
2           would reach that temperature limit of 110 degrees in  
3           59 seconds. When I reviewed the simulator data, it  
4           achieved 110 degrees in 60 seconds.

5           MEMBER ABDEL-KHALIK: Sure, because --

6           MR. AMWAY: In other words, it's just a  
7           qualitative analysis to say the simulator's performing  
8           similarly to how we expect the plant to behave, based  
9           on our design analysis.

10          MEMBER ABDEL-KHALIK: But isn't that a  
11          circular argument? If the simulator is based on the  
12          analysis, wouldn't you expect it to perform according  
13          to what the analysis said it should do?

14          MR. AMWAY: I would, and I'm not trying to  
15          qualify the simulator by that, but just to make sure  
16          that we have the simulator modeled to match what the  
17          design analysis says.

18          CHAIRMAN ARMIJO: But basically, the  
19          operators didn't have to do anything different for  
20          this event at EPU than they would have done at current  
21          licensed thermal power?

22          MR. AMWAY: That is correct.

23          CHAIRMAN ARMIJO: And you demonstrated  
24          that.

25          MR. AMWAY: That's right.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN ARMIJO: That's what I get out of  
2 this.

3 MR. AMWAY: And that's really what we were  
4 trying to demonstrate with this, that we can use the  
5 same EOPs, same EOP actions, same action times and  
6 mitigate the event.

7 CHAIRMAN ARMIJO: But if, just for this  
8 slide, the only thing that you might expect to have  
9 changed was the margin on the suppression pool  
10 temperature.

11 MEMBER SHACK: Well, if he actually, if  
12 the operators took 1,500 seconds rather than 404  
13 seconds, then the other bullets wouldn't have  
14 followed.

15 CHAIRMAN ARMIJO: Sure.

16 MR. AMWAY: That's correct.

17 MEMBER ABDEL-KHALIK: Oh, I see.

18 MEMBER SHACK: I mean that's -- so it  
19 really is a test of the operator action, assuming that  
20 in fact the design analysis --

21 MEMBER ABDEL-KHALIK: Is valid.

22 MEMBER SHACK: Is valid. But you know,  
23 what else can you expect?

24 MEMBER ABDEL-KHALIK: In a sense, you  
25 know, if the response on the procedure matches the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 assumptions in the analysis, and since the --

2 MEMBER SHACK: Because you expect it to.

3 (Simultaneous speaking.)

4 MEMBER ABDEL-KHALIK: The simulator is  
5 sort of fit into what the analysis says, you would  
6 expect it --

7 MEMBER SHACK: But you want to make sure  
8 that in fact that operators can do what the analysis  
9 assumes they do, and they seem to have -- they do it  
10 with some margin.

11 MEMBER ABDEL-KHALIK: I think I  
12 understand.

13 MR. AMWAY: That brings me to Slide No.  
14 40, the conclusions. The conclusion of the  
15 demonstration showed that the existing procedures,  
16 operator reaction times and strategies are effective  
17 in mitigating ATWS and ATWS instability events.

18 Nine Mile 2 features an ATWS recirc trip  
19 function, and as a result, the transient power levels  
20 are primarily based on the maximum control rod line,  
21 which is unchanged for extended power uprate, and that  
22 operators can perform actions in a timely manner, to  
23 bring the plant to safe shutdown.

24 CHAIRMAN ARMIJO: If you could bring up  
25 that backup slide and take a look at it before we take

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 a break.

2 MR. INCH: We want to take a break first,  
3 to look at it.

4 CHAIRMAN ARMIJO: Well, you know, I'd like  
5 to wrap it up with this, because this is --

6 (Simultaneous speaking.)

7 MR. AMWAY: I have a hard copy here.

8 CHAIRMAN ARMIJO: Can't get it up on the  
9 screen conveniently?

10 MR. AMWAY: Well the staff presumably is  
11 going to address the same issue after the break, so we  
12 can do it either way.

13 CHAIRMAN ARMIJO: Let's get it done now.  
14 We're a little bit ahead of schedule. Just take a  
15 minute, to kind of freshen your mind.

16 (Off record discussion between panel  
17 members.)

18 CHAIRMAN ARMIJO: Yeah, why don't we do  
19 that? We'll reconvene at 10:00, give us a 15 minute  
20 break.

21 (Whereupon, a short recess was taken.)

22 CHAIRMAN ARMIJO: Okay, let's come back  
23 into session. I think now we'll address the question  
24 before the break on the power flow map.

25 MEMBER ABDEL-KHALIK: I think you

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 indicated that you will stay on MELLLA.

2 MR. AMWAY: That's correct.

3 MEMBER ABDEL-KHALIK: Could you show us  
4 where the boundary is before the power uprate, and  
5 where it's going to be after the power uprate?

6 MR. AMWAY: I can. This is our two loop  
7 power flow operating map, and you can see on here  
8 these are the backup stability protection regions that  
9 are defined on our map that I spoke of, in that  
10 section on stability. This line right here is the  
11 MELLLA boundary, okay.

12 So right now, the operating point, this is  
13 shown for extended power uprate, but our current  
14 licensed thermal power is at roughly 85 percent, which  
15 would be about right across in here, okay.

16 So the expanded domain is really above  
17 this line, up to in this triangular area right here is  
18 the EPU power level. Where we're permitted to operate  
19 is anywhere within the white regions or the green  
20 regions, okay.

21 So the difference between current license  
22 thermal power and extended power uprate is this domain  
23 that used to be our MELLLA domain. It's considerably  
24 shrunk by, there's actually two lines shown here. The  
25 Gulf 1 line that's indicated by this marker right

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 here, is the 100 percent rod line.

2 So the 100 percent rod line is defined as  
3 the rod line at which if you get to 100 percent core  
4 flow, you should be at 100 percent of rated power.  
5 There is actually a thin boundary domain within those  
6 two lines. It's very small. It's on the order of one  
7 percent.

8 So we have used most of that MELLLA  
9 operating room to achieve the uprate power level, such  
10 that when we're at 100 percent of EPU power level,  
11 we're in this corner.

12 MEMBER ABDEL-KHALIK: So you don't have  
13 much --

14 MR. AMWAY: We don't have much operating  
15 room, which underscores the reasons why we're trying  
16 to restore the original design margin in the reactor  
17 recirc system, which will enable us to go into the  
18 green region here, which will give us the operational  
19 flexibility we need at 100 percent of rated power  
20 for, you know, to account for small pattern  
21 adjustments of the control rod system, and for, you  
22 know, depletion of the fuel cycle.

23 MEMBER ABDEL-KHALIK: But you can go the  
24 other way?

25 MR. AMWAY: I cannot go into this yellow

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 region.

2 MEMBER ABDEL-KHALIK: Right.

3 MR. AMWAY: I can only go, this is my  
4 boundary to the left, and I can go all the way to the  
5 green boundary on the right.

6 MEMBER ABDEL-KHALIK: Five percent.

7 MR. AMWAY: It's roughly about five  
8 percent.

9 MEMBER ABDEL-KHALIK: How much will you  
10 gain by this improvement in the jet pumps?

11 MR. AMWAY: Right now, and I'll ask George  
12 to back me up a little bit on it, but we were going to  
13 -- we would not be able to achieve EPU power level  
14 with the existing condition of the jet pumps.

15 We would maximize our core flow, and we  
16 would not be at an operating point consistent with  
17 100 percent EPU power level. George, did you want to  
18 add anything else?

19 MR. INCH: No, that's correct.

20 MEMBER ABDEL-KHALIK: So currently on this  
21 map, where is your maximum core flow, given the fouled  
22 condition of the jet pumps?

23 MR. INCH: Approximately 97 percent core  
24 flow.

25 MR. AMWAY: So that would be --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 MR. INCH: At our current power level.

2 MR. AMWAY: --about right in this region.

3 The flow is across the bottom, so you'd be measuring  
4 flow vertically, and they're in five percent  
5 increments. So this is 100 percent core flow here.  
6 This would be 95 percent core flow at this point.

7 MEMBER ABDEL-KHALIK: So is there a  
8 condition being proposed, that the power uprate be  
9 limited pending demonstrated performance of the  
10 refurbished jet pumps?

11 MR. GUZMAN: This is Rich Guzman. We do  
12 not have a proposed license condition on that at this  
13 time. But certainly we'll take that in development of  
14 our final safety evaluation. But I will certainly  
15 talk to the staff regarding that matter, and update  
16 our safety evaluation as needed, to address that  
17 matter.

18 MR. INCH: But we definitely don't believe  
19 there is any need for any license condition. I mean  
20 that's a limitation of --

21 MEMBER ABDEL-KHALIK: But you're assuming  
22 that when you do that, you'll get the right flow, to  
23 allow you to go to, you know, 120 percent of the  
24 original license thermal power.

25 MR. INCH: If, for example, if the jet

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 pumps don't perform as designed, then we'll have a  
2 shortfall in core flow, and we may not be able to  
3 complete the test program up to 120. But more than  
4 likely what will happen is that we won't be able to  
5 use the full increase core flow domain. But we'll be  
6 able to get to 120 percent.

7           Along the MELLLA line, 120 percent power  
8 is at 99 percent core flow. So and if we go to  
9 maximize dry flow on the system, we'll be able to get  
10 there. So we'll be able to achieve 120 percent,  
11 especially with the clean jet pumps.

12           MEMBER ABDEL-KHALIK: Okay. The point is  
13 currently, the way the plant is, you can't get the  
14 core flow required to allow you to remain within the  
15 power flow map at 120 percent power.

16           MR. INCH: I'd state it a little bit  
17 differently.

18           MEMBER ABDEL-KHALIK: Okay.

19           MR. INCH: We'll be within the power flow  
20 map.

21           MEMBER ABDEL-KHALIK: Okay.

22           MR. INCH: We may not be able to --

23           MEMBER ABDEL-KHALIK: To reach 120  
24 percent.

25           (Simultaneous speaking.)

1 MR. INCH: --full power. But at all  
2 times, we're within the licensing envelope.

3 MEMBER ABDEL-KHALIK: Sorry, okay. That's  
4 fine.

5 MR. INCH: So that's why I was saying --

6 MEMBER ABDEL-KHALIK: Well, wouldn't it be  
7 reasonable then? I mean in other words, achievement  
8 of 120 percent power and remaining within the power  
9 flow map is contingent upon your ability to improve  
10 the jet pump performance?

11 MR. INCH: Well, it's really an  
12 operational flexibility issue, and Phil --

13 MR. AMWAY: You can operate with a small  
14 core flow window.

15 MEMBER ABDEL-KHALIK: But you can't even  
16 get there now.

17 MR. INCH: Well, you can get there without  
18 a flow window. Even with fouled jet pumps. You know  
19 with clean jet pumps, we're going to be able to get to  
20 99 percent core flow. We'll be able to get to the  
21 full 105 percent core flow window.

22 There's no reason to anticipate any reason  
23 why we wouldn't, because the design analysis and all  
24 the original start-up testing supports that with a  
25 clean jet pump, we'll get there, you know.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           Even with the higher DPs associated with  
2 EPU, all the numbers say we'll be able to get to 104  
3 percent rated core flow. So we'll be within the power  
4 flow map the whole time.

5           MEMBER ABDEL-KHALIK: I guess this is  
6 really not the place to argue it, but you know, my  
7 feeling is that without demonstrated performance of  
8 the new jet pumps, it's --

9           MEMBER SHACK: That's sort of his problem.  
10 He has to stay within the power flow map.

11          MR. INCH: Right.

12          MR. AMWAY: I'm going to stay within the  
13 power flow map.

14          MEMBER ABDEL-KHALIK: Regardless.

15          MR. AMWAY: I've got nothing that tells me  
16 I can deviate. The way I see it, I mean we're taking  
17 out the existing inlet mixers, replacing them with the  
18 same type of inlet mixer that I have today. The  
19 reason why I'm doing that is to restore the original  
20 design margin of what the system was designed to do  
21 from day one when the plant was built.

22                 It's not really a change, in terms of a  
23 different type of jet pump that would have different  
24 flow characteristics. It has all the same flow  
25 characteristics of the jet pumps today.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN ARMIJO: And you'll demonstrate  
2 that in your power ascension test program.

3 MR. AMWAY: Right.

4 CHAIRMAN ARMIJO: So it's a flexibility  
5 issue, really.

6 MR. AMWAY: Yes.

7 MEMBER ABDEL-KHALIK: We'll just argue  
8 this point. We'll think about it. Thank you.

9 MR. AMWAY: Are there any other questions  
10 on the power flow map?

11 CHAIRMAN ARMIJO: Just keep it around.

12 (Laughter.)

13 CHAIRMAN ARMIJO: All right. I think  
14 we're going to go now to Peter.

15 MR. INCH: Oh, I do have an answer to the  
16 materials question, the 316 stainless.

17 CHAIRMAN ARMIJO: Oh yes.

18 MR. INCH: It's not the nuclear grade, but  
19 it is low carbon.

20 CHAIRMAN ARMIJO: Right.

21 MR. INCH: The carbon level is .02.

22 CHAIRMAN ARMIJO: Probably .03, isn't it?

23 MR. INCH: .023, I believe. It's a low  
24 carbon.

25 CHAIRMAN ARMIJO: It's a low carbon,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 right. Okay. It is --

2 MEMBER SHACK: The spec on low carbon is  
3 .03, so he's well within that.

4 CHAIRMAN ARMIJO: 03, yeah. Okay, thank  
5 you.

6 MEMBER REMPE: Maybe it's a closed session  
7 question, but are there other plants that have used  
8 these new jet pumps with this new coating and had  
9 great experience? Or would you rather talk about it  
10 later?

11 MR. INCH: I think we need to discuss it  
12 later on that.

13 MEMBER REMPE: Okay.

14 MR. AMWAY: Thank you.

15 MR. GUZMAN: Good morning. At this time,  
16 the NRC staff will be presenting the Nine Mile Point  
17 2 EPU ATWS instability review, specifically covering  
18 the audited areas that they covered, which the  
19 licensee did mention earlier. This presentation will  
20 be followed with an open session version of the fuel  
21 methods discussion by Dr. Yarsky, and then at that  
22 point, we'll go to closed session.

23 All right. So with that, I'm going to  
24 turn it over to Dr. Huang, to introduce his team, and  
25 go with the first slide.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 DR. HUANG: Yes. I'm Tai Huang, from  
2 Reactor System Branch, along with Dr. Jose March-  
3 Leuba, who will present the subcommittee member on the  
4 staff evaluation on the Nine Mile Point 2 EPU.

5 There are two portion of the review. One  
6 is, you know, the submittal of available documents on  
7 their Option 3, long-term stability solution  
8 implementation, and second one would be the staff  
9 audit on their simulator, to verify whether their  
10 operating reactor, operating procedural to the  
11 training of their operator are adequate.

12 So that current long-term stability  
13 implementation, according to the staff evaluation,  
14 it's adequate for EPU. They satisfy the 10 CFR Part  
15 50 design criteria 10 reactor design, and 12,  
16 suppression of the reactor power oscillation.

17 So level of protection in EPU is similar  
18 to the current licensed thermal power, and as well as  
19 the staff audit goes, we conclude that the Nine Mile  
20 Point 2 operator show good understanding of stability  
21 in ATWS issue for EPU, in staff observations of  
22 operators' action in the simulator support customary,  
23 assume a 120 second delay, assume for calculation.

24 You know, in their run, I mean the license  
25 run, you see they're using less than 120 seconds

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 there. Nine Mile Point 2 EOP adequate for EPU, as the  
2 staff evaluation in SER shows. As we go on for that  
3 generic, you know, on that power flow map here, what  
4 the different from the curling (ph) thermal power to  
5 the EPU, you can see, you know, that in the power flow  
6 diagram here, you know, curling thermal power is  
7 right, corner is right here.

8 MEMBER SHACK: You need to do it on the  
9 mouse, I think.

10 DR. HUANG: Yeah, okay, on the mouse.

11 CHAIRMAN ARMIJO: Use the mouse.

12 DR. HUANG: Yeah, okay, and then EPU be  
13 extended out on that same narrow line to the EPU  
14 corner. You see the power flow map just is shorter.  
15 You see that EPU corner over there, all right. Then  
16 that there's no like end point are the same, is the  
17 same, after, you know, that reactor trip.

18 The end point would be the end point,  
19 following the pump trip, right here on the corner. So  
20 EPU and curling thermal power condition and not that  
21 would be the same point there. So that try to make  
22 EPU does not change the end point after the  
23 recirculation pump trip. So that diagram show this.

24 Next slide. Now there are two parts. One  
25 is Option 3, long-term stability implementation on the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 stability issue. You know the story on that, in the  
2 licensee's presentation. This is just summarized.  
3 They install since 1998 an arm since 2000, and plant  
4 has a very good experience on this Option 3.

5           According to that information, 2003 Nine  
6 Mile Point 2 event was detected and the scram  
7 activated. So that mean that OPRM on the Option 3  
8 system is working. But the lesson learned from that,  
9 that the owners group, they come out with adjustment  
10 of parameter setting, so that that's already done for  
11 this plant.

12           So there's no impact expected for EPU.  
13 Option 3 and DIVOM methodology are applicable to this  
14 plant. Now ATWS, the second part on the ATWS  
15 instability, that the Nine Mile Point 2 has  
16 implemented latest EPZ and SAGs. So early level  
17 reduction in boron injection are accomplished through  
18 automated ATWS action. If high pressure is detected  
19 with power grid at four percent, then there's  
20 automatic flow runback, automatic boron injection.

21           At Nine Mile Point, we had excellent ATWS  
22 response, because they have a select system injections  
23 through high pressure core spray system on the top.  
24 So they don't need to worry about at the bottom up  
25 there. So they don't have that problem.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           So 100 percent water driving feedwater,  
2       yeah, for this Nine Mile Point 2. So EOPs are  
3       reviewed every cycle, but are not affected  
4       significantly by EPU, because boron is injected in a  
5       high pressure core spray system, and there is no need  
6       to define a hot shutdown boron weight, you know,  
7       because from the top down.

8           So EPU does not affect heat capacity  
9       thermal limits slightly. It's by one degree,  
10      according to the analysis. So that's the only  
11      difference right there, right.

12           Now staff, second part. The staff has  
13      audited, and the purpose of that when staff review the  
14      performance, OPRM, there are two parts. OPRM Solution  
15      3 system in the simulator, and staff reviewed the ATWS  
16      performance in the simulator as three events.

17           One is turbine trip ATWS from the MELLLA  
18      corner. MELLLA corner was simulated on stable  
19      observation in the slides. MELLLA corner will be the,  
20      you know, it's back in the slides, the MELLLA corner.

21           CHAIRMAN ARMIJO: The upper right-hand  
22      corner.

23           DR. HUANG: I understand that, okay.  
24      Mainstream oscillation valve, oscillation case ATWS  
25      from the MELLLA corner, and also from EPU conditions.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 So we compare to that, and we can show on later slide  
2 what the difference between EPU and curling thermal  
3 power condition.

4 Nine Mile Point 2, you know, submit  
5 additional information, because at the time the staff  
6 audit at the plant, simulator not up to the EPU  
7 conditions for the ATWS. So they ran the results and  
8 show additional information to the staff. So we show  
9 that, you know, in a later presentation on the  
10 simulator. Now turn over this to Jose, Dr. March-  
11 Leuba on the simulator portion.

12 DR. MARCH-LEUBA: I'm Jose March-Leuba  
13 from Oak Ridge National Laboratory, an NRR consultant,  
14 and the recent discussion this morning about what is  
15 the purpose of doing simulator calculations of ATWS.  
16 Let me reemphasize your conclusion, that it is to  
17 review the operator actions.

18 You can ask Dr. Yarsky, who has  
19 presentation 20 minutes from now, how long it takes to  
20 run an ATWS calculation with engineering code, and  
21 he'll tell you several days, if not weeks, of CPU  
22 time.

23 This is with multiple restarts and  
24 multiple stops and backtracks, when the computer  
25 didn't do what it was supposed to, and five engineers

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 looking at the results, to see what feedwater strategy  
2 you should have been using.

3 So we have two types of scenarios. I mean  
4 one is a very accurate code trace, for example, of  
5 Type G, that very accurately models the conservation  
6 of energy, mass and momentum and does everything well.  
7 On the other side, we have a pretty good simulator  
8 model, but it has a human in the loop, as the real  
9 operator doing the real control system on real time.

10 The first 120 seconds go in that time real  
11 fast. So it is not abundantly clear to anybody  
12 looking at it that with the 120 seconds, operator will  
13 be able to do anything. So the purpose of this audit  
14 that we performed was to go and in the real simulator  
15 with real operator, to see what they're supposed to  
16 do. My goal, just to give you a visual, is do we need  
17 Superman in the control room to do everything that  
18 we're asking these operators to do?

19 The conclusions after watching this is  
20 indeed, we don't need Superman in there. The  
21 operators are really well-trained, they're very  
22 professional, and if I were to show you a video of the  
23 operators handling an ATWS, and operators handling a  
24 control room in motion, you will not see the  
25 difference if you didn't have audio with it.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           The operators just walked to the panel.  
2           They're not running from panel to panel. There's one  
3           operator in charge of level control; there's another  
4           operator in charge of the control rows, and they're  
5           doing their job. Indeed, the timing turned out to be  
6           -- the 120 seconds turned out to be very realistic.  
7           So that was the purpose of --

8                   MEMBER ABDEL-KHALIK: During these  
9           observations, the operators knew in advance what event  
10          they're going to be responding to?

11                   DR. MARCH-LEUBA: Not always. They knew  
12          they were going to be doing an ATWS, and I was going  
13          to point out that you do all these runs in sequence.  
14          So by the time you do the third simulation, they  
15          already know the procedures by heart, okay. So there  
16          is a variability from time to time, but not always.

17                   We do go there and we kind of moved  
18          operators into oh, why don't you run this case now for  
19          us, and they didn't know it in advance. We really, we  
20          didn't do it on purpose, but we have extra time. We  
21          said well, let's run now assumption that the control  
22          room's not going at all, or let's run an assumption  
23          that there's a leak doesn't come in at all.

24                   So they, we do change. We put some  
25          variability in the system. But even if they were to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 know it in advance, they have the procedures in big  
2 panels and there's a flow chart, and the first thing  
3 there the senior operator does is go get the right  
4 flow chart, put it on top of the table, and he's just  
5 following it.

6 He gets his marker, that's done. We enter  
7 in this branch, that's done. So they're well-trained.  
8 They're well-trained in advance. It's maybe knowing  
9 what training scene they're going to get reduces their  
10 anxiety a little bit, but I don't think it changes the  
11 results.

12 So the real difference was probably  
13 adrenalin. I realize the adrenalin will be flowing a  
14 little differently, and they might be doing things a  
15 little faster. But that's where training comes on.  
16 You do faster the right procedure, and they do follow  
17 procedure.

18 No operator goes and touches any panel  
19 unless the senior operator from behind says "it's time  
20 to do EOP 3G," and gives the order. So here we have  
21 very small description, because I don't want to show  
22 the details. Two MSRVS closures, a cooling seal,  
23 cooling licensing thermal power at EPU. The very  
24 first thing that happens, you have this kickout here,  
25 which this is the MSRVS closure.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           You have a big pressure transient, and  
2 they have this on both. Right after that, you trip  
3 the pumps, and the moment you trip the pumps, both  
4 CLTP and EPU become the same condition. Then you see  
5 approximately the same thing happens.

6           There are some difference out here, and  
7 this is not due to the initial condition. It's what  
8 the operator did differently in these two runs. This  
9 run was done before, and this has to do with  
10 maintaining level once you reach the fuel, and he did  
11 it better on the second run. But there is no  
12 significant difference between the two.

13           We'll go to the next slide here. Again,  
14 this is not the engineering simulator, but it's pretty  
15 good. It does concern mass and energy and momentum,  
16 and we see it in Nine Mile Point, the peak capacity  
17 temperature limit, which is 140 degrees F, or 139, is  
18 not even reached for an MSR/V closure. The maximum  
19 temperature in the suppression pool is 130 degrees F.

20           This is in part because Nine Mile Point 2  
21 is a really great ATWS plant. I mean if God forbid we  
22 don't have an ATWS, but we're allowed to have an ATWS.

23           (Laughter.)

24           DR. MARCH-LEUBA: Because everything,  
25 everything is right in that plant. I mean everything

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 is done automatically. The boron is injected in the  
2 top of the core, so it is no issue with remixing, and  
3 there's plenty of margin to everything.

4 CHAIRMAN ARMIJO: A slight reduction in  
5 margin is just the result of having more heat to get  
6 rid of, or is that an artifact of the --

7 DR. MARCH-LEUBA: It's an artifact. In  
8 principle, there should be no difference in the HCTL,  
9 heat capacity temperature limit, between the two.

10 CHAIRMAN ARMIJO: The actual.

11 DR. MARCH-LEUBA: Oh, you're talking about  
12 the --

13 CHAIRMAN ARMIJO: The actual could be  
14 higher, wouldn't it? You're getting rid of more.

15 DR. MARCH-LEUBA: You're not getting rid  
16 of more heat. That's the point. After you trip the  
17 pumps, you are at the same power than you were before,  
18 or an approximation. Now you do have a different  
19 core, you have a different coefficient. So you end up  
20 having the slightly different numbers, one, two, three  
21 percent difference.

22 CHAIRMAN ARMIJO: Yes, okay.

23 DR. MARCH-LEUBA: The difference between  
24 EPU and OLTP is in decay heat. There, you have 20  
25 percent more decay heat. But as long as you don't go

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 into a one week extended outage, decay heat is  
2 removed. It's before your scram and you are still  
3 putting 50, 60 percent power into your containment.  
4 That's what you have in ATWS.

5 So in summary, the staff found the EPU  
6 operation acceptable from a stability point of view,  
7 because the long-term solution, which is Solution 3,  
8 provides exactly the same level of protection under  
9 EPU than under the coolant power. Therefore, the OPRM  
10 scram and the OPRM procedures satisfy the GDC, general  
11 design criteria 10 and 12, which is the criteria that  
12 we have to satisfy.

13 On the ATWS scenarios, really the ATWS  
14 stability is not affected significantly by EPU event,  
15 and it's because after you trip the pumps, you are in  
16 exactly the same condition. I mean that satisfy all  
17 our acceptance criteria, which are three criteria, if  
18 you remember.

19 They are the core coolability, meaning you  
20 don't destroy your fuel and put it in the bottom of  
21 the vessel; you maintain vessel integrity; and you  
22 maintain containment integrity, and the containment  
23 integrity has to do with the suppression pool  
24 temperature we were talking about before.

25 Just to emphasize that Nine Mile Point 2

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 has an excellent ATWS pro forma design, and I wish all  
2 the plants were like it. I mean it has automatic  
3 trips, so we really don't even have to worry about the  
4 operator doing the right thing. The control system  
5 will do it for them. They inject the boron on the top  
6 of the core, so there's no mixing problems, and the  
7 feedwater pumps are 100 percent motor-driven, meaning  
8 that there is no issue with how much availability of  
9 inventory to maintain level in the vessel during ATWS,  
10 and that's the end of our presentation.

11 CHAIRMAN ARMIJO: Any questions? I  
12 suspect one. Thank you.

13 MEMBER ABDEL-KHALIK: What is the last  
14 bullet?

15 DR. MARCH-LEUBA: If you do not have  
16 motor-driven feedwater pumps, which many plants don't;  
17 they use steam-driven, the moment you close the MSRV,  
18 then you don't have steam for those pumps and you  
19 don't have feedwater, and you rely on other ACCS  
20 systems, which are not as large.

21 If you were to increase, in some of these  
22 plants, if you were to increase the power  
23 significantly, you will not have enough. HPCI will  
24 not be sufficient to maintain level. Here, you have  
25 100 percent feedwater available. You don't have any

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 problems.

2 MEMBER ABDEL-KHALIK: Okay, thank you.

3 CHAIRMAN ARMIJO: Thank you. Let's keep  
4 going. I guess we're getting into Peter Yarsky's  
5 presentation.

6 DR. YARSKY: Hello. I'm Dr. Peter Yarsky  
7 from the staff. I'm a member of the Office of  
8 Research, and I'm going to be talking about the  
9 applicability of the interim methods to the Nine Mile  
10 Point 2 extended power uprate LER. The basis for our  
11 methods review was the safety evaluation for the  
12 interim methods license and topical report, NEDC-  
13 33173P.

14 In the course of our review, we have  
15 confirmed that the EPU LER is fully consistent with  
16 all of the conditions and limitations in the staff's  
17 SE for the IMLTR. The IMLTR specifies 24 different  
18 conditions and limitations. In the Nine Mile Point 2  
19 EPU application, no supplements to the IMLTR are  
20 referenced.

21 The Appendix A to the power uprate safety  
22 analysis report provides the disposition of each of  
23 the conditions limitations, and in the course of our  
24 review, we found that all 24 conditions limitations  
25 were acceptably met. In the course of our review, we

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 conducted one regulatory audit pertaining to the  
2 IMLTR.

3 Then the audit had to do with initially  
4 guiding LPRM calibration interval. The frequency with  
5 which the LPRMs are calibrated, that's sometimes  
6 referred to as the LPRM update, affects core monitor  
7 accuracy to predict core power distribution. In the  
8 Nine Mile Point 2 technical specifications, the LPRM  
9 calibration interval is specified in units of  
10 effective full power hours. So at EPU conditions, the  
11 equivalent exposure interval between LPRM calibration  
12 intervals would increase along with the thermal power  
13 by approximately 15 percent.

14 We asked RAI SMPB-1, which was the only  
15 RAI coming from the methods review, to address LPRM  
16 calibration interval, and the outcome of that RAI was  
17 that the staff conducted an audit at GEH, to confirm  
18 that the power distribution uncertainties were  
19 acceptable for this longer exposure interval.

20 MEMBER ABDEL-KHALIK: Was this issue  
21 raised at the original stretch uprate?

22 DR. YARSKY: I'm not familiar with the  
23 stretch power uprate review.

24 MEMBER ABDEL-KHALIK: But it would have  
25 been equally applicable, wouldn't it?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 DR. YARSKY: The extension of the  
2 interval, yes, would have been applicable, but not  
3 equally applicable --

4 (Simultaneous speaking.)

5 MEMBER ABDEL-KHALIK: Well, I mean  
6 essentially the same issue.

7 DR. YARSKY: Yes. I personally became  
8 first familiar with this topic during the review of  
9 the Monticello EPU, and the conclusion and resolution  
10 of that issue was different in Monticello than for  
11 Nine Mile Point 2.

12 MEMBER ABDEL-KHALIK: Okay.

13 DR. YARSKY: Yes. The Subcommittee was  
14 briefed on this issue during a generic review related  
15 to interim methods, I believe, in August.

16 CHAIRMAN ARMIJO: This summer.

17 DR. YARSKY: It is June, in June. So it's  
18 the same topic, just applied on a plant-specific  
19 basis.

20 CHAIRMAN ARMIJO: Peter, if the  
21 uncertainties hadn't been acceptable, wouldn't the  
22 solution be pretty straightforward? You just  
23 recalibrate?

24 DR. YARSKY: The solution would have been  
25 straightforward. It could easily have been an

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 adjustment to the LPRM calibration level. That has  
2 been done by other licensees seeking power uprate.

3 CHAIRMAN ARMIJO: Okay.

4 DR. YARSKY: That's all I have. So --

5 CHAIRMAN ARMIJO: That's it. Okay. Well  
6 then I think we're ready to go into closed session,  
7 and first I'd like the staff and the applicant to  
8 confirm that the right people are here, and that  
9 nobody's on the bridge line that shouldn't be on the  
10 bridge line.

11 (Whereupon, at 10:29 a.m., the meeting was  
12 adjourned to closed session.)

13

## O P E N S E S S I O N

10:59 a.m.

1  
2  
3 CHAIRMAN ARMIJO: Ready to go.

4 MR. AMWAY: Okay. Before we begin the  
5 material mechanical civil discussion, I wanted to  
6 respond to the open question on the quantifying the  
7 scram delay back in the Stability section, where I  
8 presented the 2003 stability event for Nine Mile Point  
9 2, and the question of that was what kind of time  
10 delay do we have from the onset of oscillation to  
11 where we should have scrambled to when we actually  
12 scrambled the reactor.

13 The answer to that question is 15 to 20  
14 seconds.

15 CHAIRMAN ARMIJO: That's the delta between  
16 the ideal and the somewhat delayed because of the  
17 resets?

18 MR. AMWAY: The time delay from when the  
19 OPRM should have scrambled the reactor, based on  
20 confirmation counts, and when it actually did, that  
21 total delta is 15 to 20 seconds.

22 CHAIRMAN ARMIJO: Okay, and with the  
23 corrections and the updates, that has disappeared  
24 where you expected?

25 MR. AMWAY: That's correct. That would

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 eliminate that 15 to 20 second delay.

2 MEMBER SHACK: And you're not going to run  
3 an experiment to verify that?

4 MR. AMWAY: That is also correct.

5 CHAIRMAN ARMIJO: And we don't expect you  
6 to.

7 MR. INCH: My name is George Inch. I'm  
8 the physical engineer for mechanical structural for  
9 the power uprate of Unit 2. I'm going to be going  
10 through the reactor pressure vessel internal materials  
11 issues, and related flow-induced vibration  
12 evaluations.

13 So for the internals, the EPU evaluations  
14 included the effect effluence, the effect of flow-  
15 induced vibration, structural effects that are non  
16 flow-induced vibration-related, and the impact of EPU  
17 on the current material condition with regard to  
18 intergranular stress corrosion cracking, and  
19 irradiation-assisted stress corrosion cracking.

20 The accepted threshold for effluence,  
21 where irradiation-assisted stress corrosion becomes a  
22 significant factor in the growth rate of an existing  
23 IGSCC flaw and potential IASCC that's accepted in the  
24 BWR vessel internals program is 5E to the 20 neutrons  
25 per centimeter squared.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1           The existing components that are expected  
2           to exceed that threshold in the current license term,  
3           and that's expected, anticipated in the vessel  
4           internal program scope are the top guide, the shroud  
5           and the core plate.

6           CHAIRMAN ARMIJO: George, you know, that  
7           threshold is a pretty fuzzy threshold. It's not a  
8           hard line.

9           MR. INCH: Right.

10          CHAIRMAN ARMIJO: So what other components  
11          are close to that 5 times 10 to the 20th? You know,  
12          these were, this is the same list as pre-EPU.

13          MR. INCH: Yes.

14          CHAIRMAN ARMIJO: So as you go up 20  
15          percent more in flux, I would expect more components  
16          come into this population, and others get closer.

17          MR. INCH: Additional components really  
18          don't come into the mix. I mean the effluence level  
19          goes up, but the threshold, that threshold really  
20          isn't exceeded by any additional components.

21          CHAIRMAN ARMIJO: So okay.

22          MR. INCH: So that the --

23          MEMBER ABDEL-KHALIK: What's the next --  
24          I mean the question --

25          (Simultaneous speaking.)

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. INCH: It would be some jet pump  
2 components that are in the core region. Everything  
3 that's going to --

4 (Simultaneous speaking.)

5 MR. INCH: And, you know, these are the  
6 core region components and then, you know, what's  
7 outside of the reactor, I mean the core shroud would  
8 be the jet pump components. But because of the size  
9 of the annular region, you get significant  
10 attenuation. So those components are, you know, don't  
11 approach --

12 CHAIRMAN ARMIJO: None of the guide tubes,  
13 whether it's drives or instrumentation.

14 MR. INCH: All the instrumentation in the  
15 core is above this, just as a matter of course. So  
16 and the guide tubes are all below the core plate, and  
17 so you get significant attenuation as you go down.

18 CHAIRMAN ARMIJO: Okay. So these are  
19 still the same components you worried about pre-EPU?

20 MR. INCH: Yes.

21 MEMBER ABDEL-KHALIK: What's the condition  
22 of your shroud now?

23 MR. INCH: The Nine Mile Point 2 core  
24 shroud has IGSCC cracking associated with the belt  
25 line welds. The H-4 weld and H-5 weld have OD IGSCC

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 cracking. Cracks are approximately 70 percent of the  
2 circumference. They're relatively shallow, as it's a  
3 two inch shroud, and the cracks are less than half of  
4 an inch in depth.

5 They were first identified in the baseline  
6 inspections performed in the 90's. I believe it was  
7 in '97 where they were identified. We've  
8 ultrasonically inspected those multiple times, at  
9 least four times.

10 Since we implemented hydrogen water  
11 chemistry and noble metals, we haven't seen measurable  
12 growth that we consider to be real growth. With UT,  
13 there's always variation. So you never match it up  
14 within the uncertainty of the deployment tools and the  
15 UT devices. But the condition has been stable for at  
16 least ten years.

17 CHAIRMAN ARMIJO: Are these shrouds  
18 clamped? Have you put any of these --

19 MR. INCH: There's no tie rods.

20 CHAIRMAN ARMIJO: There's no tie rods, so  
21 it's just as-built, and you're monitoring and testing  
22 the cracks?

23 MR. INCH: Yes. The flaw evaluation for  
24 the core shroud has been updated for the power uprate  
25 higher loads for differential pressures. It's, that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1       flaw evaluation still shows that the normal upset  
2       event is the controlling event for the core shroud.  
3       It's not the faulted event.

4               The vertical welds, all the vertical welds  
5       are clean. There's no cracking on the vertical welds.  
6       Very minor cracking on other locations, less than ten  
7       percent, very typical. So the location of the  
8       indications on the core shroud are consistent with the  
9       understanding in the fabrication process. So it was  
10      the final weld built --

11              CHAIRMAN ARMIJO: After you, on the  
12      shroud, since you've inspected it a lot, after you  
13      implemented the hydrogen water chemistry and the noble  
14      metals, have you found any new cracks that hadn't been  
15      there pre-hydrogen?

16              MR. INCH: Not that we consider -- we  
17      don't consider them new. The UTs have evolved over  
18      the past ten years. I'm always seeing, you know, I  
19      get a scan and the percent cracking is essentially the  
20      same. But we get a little additional coverage at a  
21      location. There's a lot of starts and stops, but  
22      there's been no significant change in with the new  
23      cracking.

24              CHAIRMAN ARMIJO: Okay, just a couple of  
25      other things. On the top guide and the core plate,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 have you, do you have any -- can you inspect them  
2 well, and do you have cracks, IGSCC, in those  
3 components?

4 MR. INCH: The top guide, we have the  
5 inspection can be performed of the top guide grid  
6 beams. That was inspections that were recently added  
7 to the VIP program, approximately --

8 MEMBER SHACK: These are enhanced VT1?

9 MR. INCH: These are enhanced VT1, where  
10 we clear the cell and they have a cleaning process, to  
11 get the enhanced visual capability. We've done,  
12 completed an initial deployment of this new tool in  
13 2010, and that worked quite well. So we haven't  
14 established that Unit 2A baseline yet on the top  
15 guide, but we --

16 CHAIRMAN ARMIJO: Have you seen anything  
17 that looks like a crack?

18 MR. INCH: No, no. We've looked at two  
19 cells. We've done standard refueling inspections.  
20 We've looked at two cells with the enhanced VT1, and  
21 we've done the standard VT inspections that would  
22 normally detect any significant structural issues.  
23 But we haven't completed the five percent baseline  
24 that is recommended as planned for implementation over  
25 the next --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   MEMBER SHACK: Now these are one of these  
2 milled top guides, right? Solid, or do you have the  
3 interlocking beam kind of thing?

4                   MR. INCH: This is a BWR-5, so it's not  
5 the BWR-6 top guide.

6                   MEMBER SHACK: The 6 is the one that's  
7 milled out?

8                   MR. INCH: I believe so.

9                   CHAIRMAN ARMIJO: So these are  
10 interlocking, welded?

11                   MR. INCH: I'll verify that, but I'm  
12 pretty sure these are interlocking designs.

13                   MEMBER SHACK: So there's lots of corners  
14 to look at.

15                   CHAIRMAN ARMIJO: Okay so -- yeah, that's  
16 the problem. Now the shroud is UT inspectible, but  
17 what about the core plate?

18                   MR. INCH: Core plate at Unit 2, the only  
19 inspection requirements for core plate are for the  
20 bolting, and it's part of the program. The evaluation  
21 that we have right now is a generic evaluation for the  
22 inspectability of the bolting, and so we have in  
23 place, as pretty much all the, most of the BWRs do, an  
24 interim analyses that shows that the bolting will  
25 retain its integrity through the 40-year term.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           The VIP is working on alternatives to the  
2 inspection recommendations, so --

3           CHAIRMAN ARMIJO: But basically, they're  
4 not inspectible?

5           MR. INCH: Not currently, that's correct.

6           CHAIRMAN ARMIJO: Okay. So you're really  
7 relying on the analysis and the mitigation afforded  
8 by the water chemistry?

9           MR. INCH: That's correct.

10          CHAIRMAN ARMIJO: Okay.

11          MR. INCH: So the effect of effluence is  
12 not insignificant on the core shroud. It's a 40 to 60  
13 percent increase at peak locations in the core barrel  
14 there, and you know, that's because we're loading  
15 higher batch fractions and the higher power bundles  
16 are getting closer. So there is a, it does increase  
17 effluence.

18                 We have taken that fluence out through the  
19 60-year term, looked at the peak fluence. We stay  
20 within the currently accepted range, where hydrogen  
21 water chemistry will remain effective.

22          MEMBER SHACK: What is that end of life  
23 fluence?

24          MR. INCH: Let me get back to you. It's  
25 less than 10 to the 22, I know that.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER SHACK: It's cold comfort, but --

2 MR. INCH: It's above the threshold by  
3 which radiation-assisted crack growth rate  
4 acceleration is expected to occur. We also have  
5 reduced ductibility of the materials.

6 CHAIRMAN ARMIJO: Sure.

7 MR. INCH: So we're within, we're applying  
8 the VIP guidance.

9 MEMBER SHACK: The normal guide for  
10 effectiveness of hydrogen water chemistry, somewhere  
11 around three times ten to the 21, and it's sounds like  
12 you're probably pushing that.

13 MR. INCH: Towards the end of the 60  
14 years. Yes, we'll be pushing that number. But let me  
15 verify, get you a good number on that. But so that  
16 covers the slide, I think.

17 CHAIRMAN ARMIJO: Not really. Your last  
18 bullet, I just, I think it's -- I have to argue with  
19 that statement, because your actions are much better  
20 than the words on this chart.

21 The fluence does everything. It does  
22 nothing good for you except make power. Your  
23 radiolysis rate goes up in proportion to the power  
24 uprates. So that means the water chemistry gets more  
25 aggressive.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1                   But you're compensating that by increasing  
2 your hydrogen input rate by the same ratio.

3                   MR. INCH: Yes.

4                   CHAIRMAN ARMIJO: So you are addressing  
5 that. Radiation hardening is going to push things in  
6 the wrong direction. So I looked at your various  
7 documents, and you're doing everything that I think  
8 can be done, that addresses the mechanism of this  
9 stress corrosion cracking, either IASCC or IGSCC.

10                  But I just take exception to that  
11 statement, that it doesn't represent a significant  
12 increase in potential, because I think it really does,  
13 and your actions indicate that you kind of think so  
14 too. So I don't know where that statement came from.  
15 But maybe you want to get rid of it in the full  
16 Committee.

17                  MR. INCH: We don't need to debate that,  
18 except -- the flow-induced vibration of the internal,  
19 Nine Mile's well in the pack of the GE operating  
20 experience for the flow rates that were taken in the  
21 Unit 2. The components that are really impacted are  
22 the shroud head separator assembly, because you've got  
23 the higher steam flows coming up through it.

24                  The jet pumps to a lesser extent. As I  
25 said, it's a 1.9 percent effect there versus an 18

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 percent on a steam flow.

2 DR. WALLIS: So the effect is really a V-  
3 squared effect? Is that what it does?

4 MR. INCH: It's a turbulent -- that's how  
5 it's evaluated, yes. For those internals, it's a  
6 velocity squared due to turbulent loading.

7 DR. WALLIS: Resonance or anything?

8 MR. INCH: No. They do a separation  
9 evaluation to any vortex setting, and that's the  
10 standard procedure that GE's used. The peak stresses  
11 for that shroud head remain less than 5,000. GE uses  
12 a 10,000 psi criteria. So the internals really are  
13 robustly made. There's significant margin to any FIV  
14 issues.

15 The top head region where you have the  
16 higher steam flow, those velocities remain very low,  
17 where you have the spray nozzles and the head or the  
18 head vent lines. So those stay below two feet per  
19 second, and the cross-flow configuration has been  
20 taken into account, and there's large margins there.

21 So the conclusion is, you know, pretty  
22 clear that there's no impact or detrimental effects on  
23 any of the internals due to potential for the FIV.

24 Structural effects. You know, the higher  
25 power levels, you do have higher internal pressure

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 differences, and there's some small temperature  
2 changes. All the analyses are done consistent with  
3 the original design bases. For Unit 2, there's really  
4 no structural change has been made to the internals  
5 that need to be considered. As I said, the  
6 thermohydraulic changes are fairly straightforward.

7           With the pressure differences and the  
8 temperature changes, there's a little bit change in  
9 the carry-under fractions. The way GE does these  
10 analyses is with scaling factors to the original  
11 design, and with that, you know, for example the core  
12 plate and core shroud goes from 11,000 to about  
13 14,000, and that's with primary membrane bending is  
14 limiting, with an allowable of 21,450 psi.

15           So the shroud head bolt. The limiting  
16 component there is the T bolt and bearing stress, and  
17 that goes from 8,000 to 13,500, with an allowable of  
18 18,000. Now that shroud head bolt analyses is taking  
19 credit for the reduced number of shroud head bolts  
20 than we actually currently have installed. So it's a  
21 conservative evaluation.

22           So all the usage factors really didn't  
23 have for the internals, they didn't have a significant  
24 change. The only one of note was really the shroud  
25 went from .43 to .507. That's primarily due to the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 slightly larger temperature variation on heat up and  
2 cool-downs. That's not a high cycle fatigue.

3 So all the internal components are fully  
4 qualified, and as I mentioned previously, the core  
5 shroud flaw evaluations that we work have been updated  
6 to reflect the higher pressure differences, the higher  
7 fluences, reflective of the power uprate condition.

8 We covered pretty well in the questions  
9 the, you know, what's been done for IGSCC and IASCC.  
10 It's procedurally controlled. The program that's been  
11 implemented has always considered, you know, aging  
12 effects and the higher fluence level. So the  
13 selection of the components and the intervals that are  
14 selected aren't impacted by the higher fluence levels.  
15 They're still fairly conservative intervals for all  
16 the components.

17 Like for the shroud, it's a maximum of ten  
18 years, even with hydrogen water chemistry and  
19 ultrasonic inspections. We talked about the hydrogen  
20 water chemistry and noble metals. There is an  
21 increase in the hydrogen, just to keep, maintain the  
22 three to one molar ratio in the downcomer.

23 CHAIRMAN ARMIJO: How do you monitor the  
24 molar ratio water chemistry program?

25 MR. INCH: At Unit 2, the implementation

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 of the hydrogen water chemistry currently uses molar  
2 ratio. We are evaluation the recently-issued staff  
3 approved BWRVIP-62-Alpha guidance, where the staff has  
4 allowed, on an interim basis, to use molar ratio. But  
5 they want to see electrochemical potential monitoring  
6 being performed, to credit the hydrogen water  
7 chemistry. We haven't implemented that at Unit 2 at  
8 this time.

9 CHAIRMAN ARMIJO: Yeah. Instrumentation  
10 is tough. It's not necessarily survivable.

11 MR. INCH: Yes. That's a very challenging  
12 request from the staff right now.

13 CHAIRMAN ARMIJO: Yes, yes. But molar  
14 ratio gives you good indication that it's working.

15 MR. INCH: Yes.

16 CHAIRMAN ARMIJO: You have, also you have  
17 online noble metal capability, so you don't have to do  
18 this during an outage.

19 MR. INCH: Yes. We implemented, we were  
20 one of the first plants to implement online. We did  
21 it in 2008, and it's done on a yearly basis, and it  
22 works. It's about two, two and a half weeks every  
23 year done, at least 90 days after the new fuel is  
24 installed, and it's working well for us.

25 It's much easier to do and less of a plant transient

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 than the offline process.

2 MEMBER SHACK: Thank you, and you don't  
3 have to -- I mean this goes on forever. You don't  
4 ever have to do an offline noble metal injection  
5 again?

6 MR. INCH: Yes. That's --

7 MEMBER SHACK: That's the goal.

8 MR. INCH: That's the qualification of the  
9 process, yes, that you don't have to ever do an  
10 offline application. Yes, the details of the process  
11 are, you know, I don't think we probably need to get  
12 into. But it's a different particle size, much finer.  
13 It's engineered to penetrate deeper into cracks, and  
14 so --

15 CHAIRMAN ARMIJO: So this is platinum that  
16 you're added or not palladium?

17 MR. INCH: Yes. I believe with online,  
18 they eliminated the, I think it was rhodium that they  
19 had in there. But it's only platinum. So it's a  
20 different cocktail that they're using. But it's  
21 fundamentally the same.

22 CHAIRMAN ARMIJO: Okay.

23 MR. INCH: I think we already talked about  
24 the control blade cracking. One of the impacts of  
25 power uprate is scaling of the reactor pressure

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 vessel, you know, nozzles, and one of the -- so the  
2 scale factors were applied to the design bases fatigue  
3 usage, accounting for both 40 and 60 years in design  
4 bases.

5           When we get our license renewal for 60  
6 years at Unit 2, it was identified that the feedwater  
7 nozzle and another location in feedwater had the  
8 potential to exceed one in the license renewal term.  
9 At that time, we took a hard look at, you know, what's  
10 the best way to approach this, and you know, design  
11 bases fatigue usage calculations are usually very  
12 conservative, and they take up a design cycle, and a  
13 number of design cycles.

14           So when we looked at it, it was clear to  
15 us that we could optimize, you know, get a more  
16 realistic usage factor by actually more accurately  
17 trending. So we committed for the locations that were  
18 predicted to be above one, to implement a fatigue  
19 monitoring program, such that long before we would  
20 approach one, we would be predicting it and could plan  
21 any appropriate actions.

22           Those remain the case for the power uprate  
23 conditions. The scaling of the -- well, before I go  
24 to that, the one location that we did select for  
25 fatigue monitoring using stress-based monitoring was

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 the feedwater nozzle location. That's not unusual for  
2 the BWRs. Where that location is part of power  
3 uprate, we did a fatigue, a refined fatigue usage  
4 calc.

5 MEMBER SHACK: Oh yeah. I guess what  
6 caught my eye was computing usage with FatiguePro,  
7 which has generally not been received well, unless  
8 there's a new version of FatiguePro that eliminates  
9 the one stress factor kind of approach.

10 MR. INCH: The numbers I'm showing here,  
11 this is an important clarification; I'm on Slide 62,  
12 these are based on design, not FatiguePro. So the  
13 numbers we're quoting here for the EPU 40-year CUF are  
14 a refined design basis usage for the 40 year term, not  
15 keyed to FatiguePro.

16 But as you can see, the standard  
17 multiplication factor for license renewal is a 1.5  
18 factor on, you know, for the additional 20 years.  
19 Even with the refined usage, we would still predict  
20 the stainless steel clad portion of the feedwater  
21 nozzle safe end to be above one.

22 So we're using FatiguePro right now. It  
23 was first, the software was first installed in 2008,  
24 as a simplified way and a more accurate way to count  
25 cycle. We are doing the stress-based monitoring of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 this location, and the current FatiguePro software  
2 does use the simplified greens (ph) function. So the  
3 RIS is applicable.

4 The EPU scaling is relatively small. It's  
5 a six percent to 15 percent change, and --

6 MEMBER SHACK: Now does that include an  
7 environmental factor?

8 MR. INCH: No.

9 MEMBER SHACK: What would happen if I put  
10 in an environmental factor?

11 MR. INCH: This usage factor is a design  
12 bases usage factor. The power, the license renewal  
13 provisions have evaluations for environmental effects  
14 in the license renewal term. So the FatiguePro  
15 monitoring does include environmental usage, and I  
16 believe there was an environmental usage evaluation  
17 done.

18 I would have to get back to you on this  
19 particular nozzle, on how environmental fatigue  
20 affects these numbers.

21 MEMBER SHACK: If you could go back to the  
22 next bullet, it says there's still a discussion going  
23 on, I guess.

24 MR. INCH: Well, yes. You know, the whole  
25 industry is working to address the RIS. There is a --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 Structural Integrity is working on a FatiguePro update  
2 that would address the full NB-32 fatigue methodology,  
3 and to include environmental fatigue usage in the  
4 rules. You know, right now, we're not required in  
5 using this to manage below one in the 40 year term.

6 So we enter the license renewal term in  
7 2026 at Unit 2, so there's quite a bit of time to get  
8 this right. We are committed to implementing, you  
9 know, fatigue monitoring, and as part of that, the RIS  
10 requires us to evaluate that, you know, before we're  
11 actually crediting it for usage below one. So that is  
12 what our current status us.

13 CHAIRMAN ARMIJO: George, could you go  
14 back to Slide 62?

15 MR. INCH: Yes.

16 CHAIRMAN ARMIJO: I don't understand how  
17 the cumulative usage factor at current license thermal  
18 power is higher than that at EPU. Am I reading this  
19 thing wrong, or --

20 MR. INCH: Well, that's the refined  
21 calculation.

22 CHAIRMAN ARMIJO: But they're two  
23 different calculations?

24 MR. INCH: Yes. The original calc had a,  
25 for multiple events, had --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN ARMIJO: Well, you would say that  
2 was a crude calculation?

3 MR. INCH: It was conservative, and you  
4 know, there's a way --

5 MEMBER SHACK: Unconcerned. It was less  
6 than one. That was all you needed.

7 MR. INCH: It's the way they did the  
8 calcs. If you were less than one, you were done.  
9 Everybody knew they were conservative, so --

10 CHAIRMAN ARMIJO: Okay. So now this is a  
11 refined?

12 MR. INCH: Yes.

13 CHAIRMAN ARMIJO: The EPU is a refined?  
14 Okay.

15 MR. INCH: Now when I say "refined," what  
16 they did is they went back and looked at each  
17 particular event, and then for each event, there was  
18 a thermal FEA, where they looked at what the actual  
19 cycling on the stress --

20 CHAIRMAN ARMIJO: It was detailed.

21 MR. INCH: It was a detailed accumulation  
22 for each event.

23 MEMBER SHACK: Now it's got four  
24 significant figures rather than three?

25 CHAIRMAN ARMIJO: Yeah, right. It's

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 really good.

2 (Simultaneous speaking.)

3 CHAIRMAN ARMIJO: So it's an analysis of  
4 -- so you did cycle by cycle you did?

5 MR. INCH: Yes. There's, to get these  
6 numbers, they started from a natural baseline, and  
7 then they refined each event, and then refined each  
8 cycle and what the usage for each cycle is.

9

10 CHAIRMAN ARMIJO: And then they added them  
11 up?

12 MR. INCH: And then added them up.

13 CHAIRMAN ARMIJO: Okay, got it.

14 DR. WALLIS: What is this EPU scaling  
15 factor small mean? What's that?

16 MR. INCH: You know, relative to what does  
17 EPU do to the usage factor?

18 DR. WALLIS: But does it mean that without  
19 the refined calculation, it would actually increase  
20 the CUF above one?

21 MR. INCH: I'm not sure I understand here.

22 DR. WALLIS: Well, to me, it implies that  
23 the EPU increases things by 6 percent to 15 percent.

24 MEMBER SHACK: Right.

25 DR. WALLIS: So if you use the old CUF

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 calculation, you get something closer to one?

2 MR. INCH: That's right.

3 DR. WALLIS: Okay. So you need to refine  
4 the calculation?

5 MR. INCH: Yes sir.

6 DR. WALLIS: Thank you.

7 CHAIRMAN ARMIJO: This scaling, it's a  
8 stress, scaling on stress?

9 MR. INCH: Yes.

10 CHAIRMAN ARMIJO: Certainly not cycles.

11 MR. INCH: Right. It's a scaling on  
12 stress.

13 CHAIRMAN ARMIJO: Okay, okay.

14 MR. INCH: That's all I have.

15 CHAIRMAN ARMIJO: Well, we have a dilemma  
16 here. We could take a quick look here. The staff,  
17 let me ask the staff. Could they get their  
18 presentation done in half an hour?

19 MR. GUZMAN: Actually, the assigned  
20 presenter is not here.

21 CHAIRMAN ARMIJO: Well, that answered my  
22 question. I think we'll take an early lunch, and  
23 we'll be back at 11:30, unless somebody's got an  
24 objection to that. At 12:30, I'm sorry.

25 (Simultaneous speaking.)

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN ARMIJO: Okay. We're going to  
2 take a lunch. Be back at 12:30. Thank you, Bill.

3 (Whereupon, at 11:31 a.m., a luncheon  
4 recess was taken.)  
5

1 A F T E R N O O N S E S S I O N

2 12:57 p.m.

3 CHAIRMAN ARMIJO: Okay, gentlemen. We're  
4 going to reconvene. For those who don't know, that  
5 jackhammer is actually outside. It's not in the  
6 building, so structurally the building is sound, I  
7 think.

8 MEMBER SHACK: Of course, there's  
9 resonance.

10 CHAIRMAN ARMIJO: Right. So we'll go  
11 ahead. Rich, your group is up.

12 MR. GUZMAN: Good afternoon again. My  
13 name is Rich Guzman. Before we transition over to the  
14 staff giving their presentations on the materials and  
15 mechanicals and civil engineering reviews, the  
16 licensee requested to give some clarifications from  
17 the morning meeting. I thought this would be a good  
18 time to provide that, before we start delving into the  
19 materials and steam dryer discussions.

20 MR. WENGLOSKI: Good afternoon. Phil  
21 Wengloski, Constellation Energy Nuclear Group. I just  
22 wanted to clarify my response. It was brought to my  
23 attention on the control blade cracking issue, that my  
24 answer could have been taken one of two different  
25 ways.

1           The response I intended to give, which was  
2           consistent with George's Slide 60, is that we do not  
3           have the control blade models, marathon models as  
4           susceptible to the cracking. We may have other  
5           marathon models present in the core, but not the  
6           models that are susceptible to cracking.

7           CHAIRMAN ARMIJO: Is yours a C lattice  
8           plant?

9           MR. WENGLOSKI: That's correct.

10          CHAIRMAN ARMIJO: Yes, but I saw the  
11          comment about C lattice plants having susceptibility  
12          to this problem, and I think that's very -- I don't  
13          want to (papers shuffling). Anyway, it doesn't make  
14          any sense to me. But you do have marathon blades in  
15          a C lattice plant?

16          MR. WENGLOSKI: Correct.

17          CHAIRMAN ARMIJO: And GE has told you  
18          that's not susceptible?

19          MR. WENGLOSKI: Right. The models that  
20          we're using are not susceptible to cracking.

21          CHAIRMAN ARMIJO: Time well tell, but  
22          okay. But you do have marathon blades?

23          MR. WENGLOSKI: Correct.

24          CHAIRMAN ARMIJO: Okay.

25          MR. WENGLOSKI: Any further questions?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 CHAIRMAN ARMIJO: No.

2 MR. WENGLOSKI: Thank you for that.

3 MR. INCH: Yes, George Inch. The peak  
4 effluence were approaching 22 EFPY (ph), probably out  
5 two years. So it's approximately 2E to 21 each  
6 location on the H4 well, projected out at EPU  
7 effluences until the end of 40 years would be 2E to  
8 the 21. Then it goes to 4E to the 21 at that H4  
9 location.

10 CHAIRMAN ARMIJO: That's at 60 year or 54

11 --

12 MR. INCH: The 54 EFPY in 60 years, yes.  
13 So it looks like we're just below at the 60 year mark

14 --

15 MEMBER SHACK: Well, people have various  
16 opinions.

17 CHAIRMAN ARMIJO: About how long it will  
18 last, how long it will work.

19 MR. INCH: The top guide clearly is above  
20 that at these locations.

21 MR. GUZMAN: Okay. With that, we'll go  
22 ahead and start our presentation. Pat Purtscher will  
23 be giving his brief on the materials engineering  
24 review. Pat, you want to get started?

25 MR. PURTSCHER: Okay. We looked for the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 reactor vessel embrittlement, and there are several  
2 factors that we always consider. The EPU is going to  
3 increase the total fluence in the vessel, so we're  
4 going to check initially the material surveillance  
5 program.

6 That's the fundamental program we use to  
7 monitor. We build with the limiting materials in the  
8 plants. At Nine Mile, they are enrolled in the BWR  
9 VIP integrated surveillance program.

10 As part of that program, they're not a  
11 host plant. They're limiting materials are  
12 characterized by capsules that are in other plants,  
13 BWR plants. So the change in effluence for Nine Mile  
14 doesn't directly affect the capsules that will be used  
15 to characterize the limiting beltline materials.

16 They do still have two capsules in their  
17 reactor vessel that are being irradiated, but there's  
18 no current plans to use those at this point. They're  
19 backup capsules. Some of the other factors that we  
20 look at are all related to Appendix G requirements.  
21 The PT limits, the upper shelf energy projections for  
22 all the materials in the beltline, and then there's an  
23 inspection exemption that's been granted for the circ  
24 weld on the vessel.

25 So we examine that to see if that, how

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 that changes with the increased fluence. In all  
2 cases, they have passed, they still meet these  
3 requirements from Appendix G, with significant margins  
4 remaining. So there really is no concern from the  
5 staff, based on this increased fluence due to the EPU.

6 Next slide. We're now going to look at  
7 the internals and the core support materials. Again,  
8 due to the -- now that the fluences are higher on the  
9 internals than they're on the reactor vessel itself,  
10 and as they mentioned in their presentation, now the  
11 top guide, the shroud and the core plate are all  
12 exceeding what we take to be the threshold for  
13 radiation-assisted stress corrosion cracking.

14 So now we consider them to be susceptible  
15 materials once they get above that threshold. To  
16 address that, they have instituted, you know, using  
17 BWRVIP-62, that's been characterized as a Category 3  
18 plant, they're using noble metal additions to mitigate  
19 the possibility of stress corrosion cracking. This is  
20 following all the EPRI guidelines.

21 So they are following all the industry  
22 standards, and the staff sees no issues related to the  
23 increased fluence.

24 MEMBER SHACK: Well, there was sort of a  
25 discussion this morning that as a Category 3B plant,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 where they're only looking at molar ratio, you guys  
2 take a somewhat skeptical view of that, and you're  
3 asking them to do ECP measurements.

4 MR. PURTSCHER: Well, but they did do one  
5 time measurement of EPC when they instituted noble  
6 metal online additions. So they did it once, and kind  
7 of validated the secondary parameters that they're  
8 monitoring.

9 So as long as they monitored, as long as  
10 they checked that once, and there have been no major  
11 changes to the nodding and the environment, we feel  
12 that's enough justification. So with that one time  
13 measurement, to validate it.

14 So really that's, to the vessels and the  
15 internals, that's really the summary. Just to say it  
16 again, the EPU has a minimal effect on the  
17 embrittlement issues, the upper shelf values, the PT  
18 limits and the surveillance program. These three  
19 internal components we've talked about, that exceeded  
20 the threshold for IASCC, are being managed by BWRVIP  
21 documents that have been accepted the staff.

22 So this, since there should be no problem  
23 associated with the increased fluence related to the  
24 EPU. So we're satisfied with their submittal. Okay.  
25 Any questions?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. TSIRIGOTIS: My name is Alexander  
2 Tsirigotis. I work in the Mechanical and Civil  
3 Engineering Branch, which reviews the EPU impact on  
4 the structural integrity of the system structural  
5 components.

6 Mainly, the pressure retaining components  
7 and the supports, the reactor pressure vessels and  
8 supports, the control mechanisms, reactor situation  
9 pumps and supports, reactor pressure vessel internals  
10 and core support --, and the seismic and dynamic  
11 qualifications of the mechanical and electrical  
12 equipment.

13 The approach to evaluate the Nine Mile  
14 Point 2 EPU impact on the structural integrity of the  
15 -- follows the guidance which is provided in the  
16 staff-approved Z topical report entitled "Constant  
17 Pressure Power Uprate," and it's licensing report  
18 NEDC-33004P-A.

19 This is commonly referred to at the BWR  
20 EPU as the CLTR. The CLTR also refers into two other  
21 Z topical reports, the ELTR-1 and ELTR-2, which  
22 provide more detail on the generic guidelines and  
23 generic evaluations.

24 These two topical reports, together with  
25 associated NRC staff position paper on safety

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 evaluation, incorporated in the topical reports, have  
2 been applied for all BWR extended power uprate  
3 submittals, since the NRC review and acceptance or  
4 endorsement for --.

5 The staff approved the CLTR is for  
6 constant pressure power uprates, commonly referred to  
7 as CPPUs. With a power increase up to 20 percent from  
8 the plant's 100 percent original thermal power, and  
9 with a minimum and maximum steam and feedwater flow  
10 increases up to about 24 percent.

11 The CPPU approach assumes that the maximum  
12 reactor pressure dome remains unchanged from the  
13 licensed power level, and the dome temperature is also  
14 unchanged. The Nine Mile Point 2 proposed EPU does  
15 not change the current plant maximum normal operating  
16 reactor dome pressure, and it increases the original  
17 thermal power by 20 percent, with a maximum steam and  
18 feedwater flow increases of nearly 24 percent.  
19 Therefore, we found that it meets the limitations of  
20 the topical reports.

21 In addition to the main steam and  
22 feedwater piping, which are the main systems that are  
23 affected by the EPU due to its increase in the flows,  
24 other piping systems that are mostly affected by the  
25 EPU due to increased system temperatures and pressures

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 within those systems are the extraction steam, the  
2 feedwater heater vents and drains, the moisture  
3 separator heater vents and drains, and the auxiliary  
4 condensate.

5 The licensee's evaluation of flow-induced  
6 vibration levels for piping follows the vibration  
7 acceptance criteria found in ASME OM-S/G Part 3, which  
8 provides requirements for pre-operational and initial  
9 start-up vibration testing of nuclear power plant pipe  
10 and systems.

11 The OM-S/G Part 3 provides monitoring  
12 requirements, acceptance criteria, and it includes  
13 equations for calculating the vibratory alternating  
14 stress for Class 1 and Class 2 and 3 piping, and for  
15 thickness for Class 1 piping. It also contains  
16 guidance and visual inspection methods, displacement  
17 methods and vibrational deflectional values for  
18 various pipe sizes and spans.

19 The structural evaluations for the system  
20 structures and components under EPU conditions employ  
21 the current plant design base methodology and  
22 acceptance criteria. The structural evaluations also  
23 met design basis code and record allowable values.  
24 That's why we found there is reasonable assurance  
25 that the plant SSAs (ph) important to safety as

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 structurally adequate to perform the internal design  
2 functions under the EPU conditions.

3 MEMBER SHACK: But you can't really be  
4 sure they're not going to need any modifications to  
5 the pipe supports until you run that FIV test, right?  
6 I mean they could well need to do something.

7 MR. TSIRIGOTIS: The SIV test?

8 MEMBER SHACK: The FIV test.

9 MR. TSIRIGOTIS: Oh yes. You are right  
10 about that. During the -- so far, the evaluations  
11 that they have done, they have found out that they  
12 don't need any piping modifications or any support  
13 modifications or additions. During the start-up  
14 testing, they had a plan in place which they will  
15 monitor the vibration levels, and if there is a need  
16 for any modifications through the corrective code,  
17 they will provide corrective actions to do that work.

18 CHAIRMAN ARMIJO: But that will indicate  
19 that their analysis wasn't really that good --

20 (Simultaneous speaking.)

21 MR. TSIRIGOTIS: They have already done --  
22 I understand what you're saying. They have already  
23 done walk-downs to establish the baseline. From those  
24 walk-downs, they have identified whether there is an  
25 issue with the vibration levels that the pipe's

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 supposed to see.

2 CHAIRMAN ARMIJO: That's where they'll put  
3 instrumentation.

4 MR. TSIRIGOTIS: Right, right. They have  
5 instrumentation. They have -- there are locations  
6 which have been gauged, strain gauges, and --

7 CHAIRMAN ARMIJO: Accelerometers.

8 MR. TSIRIGOTIS: Accelerometers where  
9 needed. The OM-S/G Part 3 is being applied in just  
10 about every power uprate, and it's during the initial  
11 start-up also for the plants.

12 MEMBER SHACK: What's been the experience?  
13 I mean if they found they need to add supports, or the  
14 analysis have been generally satisfactory?

15 MR. TSIRIGOTIS: So far from what we've  
16 seen in the power uprates from the walk-downs, they  
17 haven't identified, from what I know at least, they  
18 haven't identified an issue where they needed to add  
19 something, mainly because when they established the  
20 baseline, they project that baseline to the EPU flows,  
21 with velocity square, which is customary to do so. If  
22 they find an issue, then they take a corrective  
23 action.

24 DR. BONACA: I have a question regarding  
25 environmental qualification.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. TSIRIGOTIS: Uh-huh.

2 DR. BONACA: There is a statement in the  
3 SER that says that, you know, for inside containment,  
4 licensee noted that post local conditions, radiation  
5 levels will increase above the levels using the  
6 current EQ program. Then it says the NRC staff  
7 reviewed the increase EQ evaluation and confirmed that  
8 the increase should not affect the qualification of  
9 the equipment. What would be the basis for that?

10 MR. TSIRIGOTIS: I'm sorry. I can't hear  
11 you very well. Are you reading from the SER, from the  
12 staff SER?

13 DR. BONACA: Yes, yes, page 57.

14 MR. TSIRIGOTIS: 57. That's not my page.  
15 (Simultaneous speaking.)

16 DR. BONACA: Yeah, inside containment.

17 MR. TSIRIGOTIS: Is that Section 2.2.5,  
18 seismic and dynamic qualifications of mechanical and  
19 electrical equipment?

20 DR. BONACA: It must be, yes. Do you have  
21 the page?

22 (Off record discussion.)

23 MR. TSIRIGOTIS: I don't see that. That's  
24 not in my evaluation. That's the same part. I think  
25 it might be in the electrical part. Anyway, it's in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 the SER.

2 (Simultaneous speaking.)

3 DR. BONACA: -- stand by. Clearly, the  
4 radiation field must be higher. Why is --

5 (Simultaneous speaking.)

6 MR. TSIRIGOTIS: (reading to self)

7 MR. GUZMAN: What we can do is we'll take  
8 that -- I just need to get back to the safety  
9 evaluation, and find out the technical staff --

10 DR. BONACA: What's the basis for it, yes.

11 MR. TSIRIGOTIS: This is not my writing.  
12 I will find out whose review this falls under, and  
13 we'll get back to you.

14 DR. BONACA: Okay, I appreciate it.  
15 Thanks.

16 CHAIRMAN ARMIJO: Okay. Any other  
17 questions from the committee?

18 (No response.)

19 CHAIRMAN ARMIJO: All right. I think  
20 we're ready to move on to the next topic.

21 MR. GUZMAN: The next topic is intended to  
22 be in closed session.

23 CHAIRMAN ARMIJO: So we're going to go  
24 into closed session. Again, remind everyone here, it  
25 should only be folks from Nine Mile and their

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 consultants, and make sure the bridge line is closed.

2 (Whereupon, at 1:15 p.m., the meeting

3 adjourned to closed session.)

4

## O P E N S E S S I O N

4:35 p.m.

1  
2  
3 CHAIRMAN ARMIJO: If not, we're going to  
4 come out of closed session and do a public session,  
5 and at this point, I'll ask if there are any comments  
6 for members of the public, either on the bridge line  
7 or open the door so they can come in to this room. Is  
8 there anyone on the bridge line who would like to make  
9 a comment? If so, please identify yourself.

10 (No response.)

11 CHAIRMAN ARMIJO: Maybe the bridge line  
12 isn't open yet. Peter will -- is it open now?

13 DR. YARSKY: The bridge line is open.

14 CHAIRMAN ARMIJO: Okay. The bridge line's  
15 open. Is there anyone, a member of the public, who  
16 would like to make a comment concerning this review?  
17 If so, please identify yourself.

18 (No response.)

19 CHAIRMAN ARMIJO: Okay. How about someone  
20 in here, n this meeting room?

21 (No response.)

22 CHAIRMAN ARMIJO: Okay. I'm going to take  
23 that as there's no comment from the public. At this  
24 point, I'd like to turn it over, just as far as  
25 Subcommittee discussion. I'd just like to go around

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 the table, and see if there's any added points that  
2 the members would like to make, and then after that,  
3 maybe try and give the staff and licensee some  
4 guidance on the full Committee meeting, because this  
5 obviously all has to get done in two hours. So that's  
6 the challenge. Joy?

7 MEMBER REMPE: Some education. During the  
8 discussion, this last topic, there was a mention of an  
9 upcoming audit. Could you provide a little more  
10 background? I think Stephen was the one who mentioned  
11 it and was talking to people in the crowd. What  
12 exactly is going to happen here? Is there going to be  
13 an end to end audit or what exactly is it?

14 DR. SHAH: This is Vik Shah. I think we  
15 have to plan it out before we finalize what kind of  
16 audit we'll be doing. I think we are going to review  
17 the (breaking up) 194, and during that review, we will  
18 be having an audit. I think we will have a (breaking  
19 up).

20 MEMBER REMPE: I'm having trouble  
21 understanding you.

22 CHAIRMAN ARMIJO: It's breaking up.

23 DR. BASAVARAJU: We have already submitted  
24 a topical report.

25 MEMBER REMPE: Who submitted it? Say it

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 again. Who submitted the topical?

2 DR. BASAVARAJU: BWR Vessel Internals  
3 program. They submitted a topical report, BWR 194.

4 MEMBER REMPE: Okay.

5 DR. BASAVARAJU: And it just came in for  
6 review, and that is the one which will summarize and  
7 give all the steam dryer evaluation, the ACM and the  
8 structural evaluation. So during that review, we were  
9 planning to have an audit, but we have not still  
10 identified the times or extent. So that's --

11 MEMBER REMPE: Thank you.

12 MEMBER BANERJEE: What is the time scale?  
13 I don't want to go out of turn, because this is new  
14 information. What is the time scale for review of the  
15 topical and I assume it will come to us as well?

16 DR. BASAVARAJU: Yes.

17 DR. SHAH: It's about two years, right  
18 Pani?

19 DR. BASAVARAJU: Yes. It's a topical  
20 report. Because this is an important topical report,  
21 we may accelerate it. But the typical topical report  
22 reviews, NRC's time is for two years.

23 CHAIRMAN ARMIJO: Okay. So it won't help  
24 us for Nine Mile. Bill, nothing. Said? No, any  
25 comments.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 DR. BONACA: No. Well, a little input.  
2 I thought in general that this was a good application.  
3 I felt it was thorough and the steam dryer issue,  
4 there are a number of questions which were raised  
5 today. I think that I feel pretty comfortable with  
6 what I saw.

7 CHAIRMAN ARMIJO: Thank you.

8 DR. BONACA: Anyway, I will make comments  
9 to you.

10 CHAIRMAN ARMIJO: Yes, okay, in your  
11 report. Mr. Wallis?

12 DR. WALLIS: Well, I thought on most  
13 issues, Nine Mile Point people did a very good job.  
14 I'm still working on the steam dryer. I'm still  
15 puzzled, because I'm told that this small scale test  
16 was only used to establish resonance, and yet I read  
17 the report, the objective was to develop a bump-up  
18 factor relating (coughing) to those anticipated at  
19 EPU, to use in the acoustic circuit model.

20 I mean the whole thing says, the whole  
21 purpose of the report is to develop numbers to put  
22 into a model. I'm really puzzled by this assertion  
23 that none of that was the case. I don't understand  
24 that, and I'm still working on the numbers. I have  
25 learned some things which have been very helpful about

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 some of the issues I raise, and I thank the  
2 participants for doing that for me.

3 CHAIRMAN ARMIJO: Sanjoy.

4 MEMBER BANERJEE: Nothing more than I said  
5 already.

6 CHAIRMAN ARMIJO: Nothing more. Jack?

7 MEMBER SIEBER: I have no comments or  
8 questions at this time.

9 CHAIRMAN ARMIJO: Okay, all right. Well,  
10 my view is I think the Nine Mile people and staff are  
11 very well prepared for this. I think we can beat the  
12 steam dryer to death, but and we obviously can't,  
13 won't be able to spend that much time at the full  
14 committee meeting.

15 So that between the staff and the Nine  
16 Mile, I think we really need one good presentation,  
17 without any repetition at all. So you're going to  
18 have to sort that out. I think the plant's in -- the  
19 impression I got from the presentation, the plant's in  
20 very good shape for EPU.

21 I think the work you've done on the  
22 materials, and on the various upgrades and  
23 modifications, that goes a long way to making me feel  
24 pretty comfortable --

25 MEMBER SHACK: And they use that good

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 barrier clad --

2 CHAIRMAN ARMIJO: And they use my  
3 cladding, so that's great.

4 (Laughter.)

5 CHAIRMAN ARMIJO: But I'm still surprised  
6 at how conservative the fuel design is. It's got more  
7 capability, but that's okay. But overall, I think  
8 you're well-prepared. I think our problem will be to  
9 manage the time, so that you get, the full Committee  
10 gets a good feel for the entire plant, and that we  
11 don't let the steam dryer dominate everything.

12 So that's going to be hard to do, but I  
13 think since so many of us have heard this  
14 presentation, and as soon as we get Mr. Wallis' report  
15 and Mario's reports, we probably can sort out our  
16 questions and focus down. But overall, I think you're  
17 well-prepared. We'll work with Rich.

18 MR. GUZMAN: I was hoping I could close  
19 out one quick action item, and I wanted to make sure  
20 I responded to Dr. Bonaca's question and concern on  
21 part of the safety evaluation, and I'll just restate  
22 it. The section is part of the Electroengineering  
23 review, under Environmental Qualifications for  
24 Electrical Equipment.

25 The statement said that "The NRC staff

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 reviewed the licensee's environmental qualification  
2 evaluation, and confirmed that the increase should not  
3 affect the qualification of the EQ equipment located  
4 inside containment." The question is why? Because  
5 they should not. Does it or does it not?

6 The staff recognizes the obscurity in that  
7 wording, and so it was in error, and we should or we  
8 will correct that, and --

9 MEMBER SHACK: No, I think the question  
10 was that the statement was made that it exceeded the  
11 environmental qualification, and then the statement  
12 followed that --

13 MR. GUZMAN: Okay.

14 MEMBER SHACK: It's still all right.

15 MR. GUZMAN: Still all right, okay.

16 MEMBER SHACK: It was that first line that  
17 was the killer.

18 MR. GUZMAN: Okay, yes. So right. So the  
19 preceding statement says the licensee noted that the  
20 radiation levels would increase above the levels used  
21 in the current EQ program.

22 MEMBER SHACK: Right.

23 MR. GUZMAN: And NRC staff review  
24 confirmed that these increases should not affect the  
25 qualifications. So I guess the question is why, and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 if you go further in the safety evaluation, I mean  
2 recognizing that the "should not" was not the  
3 appropriate words. It should have said, for lack of  
4 a better word, "would not" or "will not."

5 But further down in the safety evaluation,  
6 it does go into the, you know, that the staff reviewed  
7 the licensee's assessment of the effects of the  
8 proposed EPU on EQ equipment, and ultimately we  
9 reviewed it against 10 C.F.R. 5049, which is the  
10 electrical equipment qualification.

11 MEMBER SHACK: Maybe you should give  
12 something like "Despite this step."

13 MR. GUZMAN: Right. So we recognize that  
14 the wording needed to be tightened up. It certainly  
15 should have been more definitive and explain it. So  
16 we will make sure on the final --

17 DR. BONACA: This is an example of the way  
18 that the information is provided. There were two  
19 other, three other in the SER, I believe goes to the  
20 outside containment portion. There is a statement  
21 that simply says that's okay, and the question is why  
22 is it okay?

23 I mean it's counterintuitive that if you  
24 have a higher radiation field, it doesn't make any  
25 difference. There has to be some reason why, and I

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 mean the qualification exceeded the value. Therefore,  
2 there was margin. But something should be said.

3 MR. GUZMAN: And as you know, I mean the  
4 intent is to give you the best product that we can for  
5 the draft safety evaluation. But in parallel, what we  
6 tried to is we actually send the draft safety  
7 evaluation to the licensee. They provide some  
8 comments to us and we will incorporate those comments,  
9 as well as another round of quality check by the  
10 staff, to strengthen the product, which would be the  
11 final safety evaluation.

12 So there will be some changes, and we will  
13 note that one, as well as the other ones that you did  
14 note.

15 DR. BONACA: Okay, thank you.

16 CHAIRMAN ARMIJO: Okay. Well with that,  
17 I think I'd again like to thank Nine Mile Point and  
18 the staff. Good presentations. Good discussion, and  
19 with that we're going to adjourn the meeting. Thank  
20 you.

21 (Whereupon, at 4:46 p.m., the meeting was  
22 adjourned.)

23

24

25



**U.S.NRC**

UNITED STATES NUCLEAR REGULATORY COMMISSION

*Protecting People and the Environment*

# **ACRS Subcommittee on Power Upgrades**

## **NRC Staff Review Nine Mile Point, Unit 2 Extended Power Upgrade**

**October 5, 2011**

# Opening Remarks

**Louise Lund**

Deputy Director

Division of Operating Reactor Licensing

Office of Nuclear Reactor Regulation

# Opening Remarks

- NRC staff effort
  - Pre-application review and public meetings
  - Acceptance Review
  - Requests for additional information
- Challenging review areas included:
  - Steam dryer stress analysis
  - Thermal Hydraulic Design: Stability / ATWS-Stability
  - Interim Methods: Applicability of GE Methods to Expanded Operating Domains
- Draft SE – no open technical issues





# Introduction

**Rich Guzman**

Senior Project Manager

Division of Operating Reactor Licensing

Office of Nuclear Reactor Regulation

# Introduction

- Objective
- Background
  - NMPNS EPU Application – May 27, 2009
  - 3467 to 3988 MWt, 15 % increase (521 MWt)
  - 20 % increase above original licensed thermal power
- EPU Review Schedule
  - Followed RS-001
  - No linked licensing actions under review
  - Supplemental responses to NRC staff RAIs
- EPU Implementation

## Topics for Subcommittee

- NMPNS EPU Overview
- Anticipated Transient without Scram and Stability
- Fuel Methods - IMLTR
- Materials and Mechanical & Civil Engineering
- Steam Dryer Analysis
- Review of open items / Conclusions



**U.S.NRC**

UNITED STATES NUCLEAR REGULATORY COMMISSION

*Protecting People and the Environment*

**Nine Mile Point, Unit 2  
Extended Power Uprate  
ACRS Subcommittee Meeting**

**Materials Engineering**

**Patrick Purtscher**

Vessel & Internals Integrity Branch

October 5, 2011

## Reactor Vessel Embrittlement

- EPU increases total fluence on RV
- RV Material Surveillance Program,  
Uses BWRVIP ISP, but not a host plant,  
still has 2 capsules in RV
- Meets Appendix G requirements for  
P-T limits, USE projections, circ weld  
inspection exemption, significant margins  
remain

# Internals and Core Support Materials

- EPU increases total fluence on RV Internals
- Top guide, shroud, and core plate all exceed IASCC threshold for susceptibility
- BWRVIP-62, Category 3b plant – uses NMCA for mitigation of SCC, follows EPRI guidelines for effectiveness

## Conclusion

- EPU has minimal impact on RV embrittlement issues
- Three RVI components exceed threshold for IASCC, but adequately managed;
  - Core plate – BWRVIP-25-A
  - Top guide – BWRVIP-26-A
  - Shroud – BWRVIP-76-A

# QUESTIONS





**U.S.NRC**

UNITED STATES NUCLEAR REGULATORY COMMISSION

*Protecting People and the Environment*

**Nine Mile Point, Unit 2  
Extended Power Uprate  
ACRS Subcommittee Meeting**

**Mechanical & Civil Engineering Review**

**Alexander Tsirigotis**

Mechanical & Civil Engineering Branch

October 5, 2011

## Review Scope

- EPU impact on structural integrity of systems, structures, and components (SSCs):
  - Pressure-retaining components and their supports
  - RPV and supports
  - Control rod drive mechanisms
  - Reactor recirculation pumps and supports
  - RPV internals and core supports
  - Seismic and dynamic qualification of mechanical and electrical equipment.

## Review Results

- Piping systems that are mainly affected from the EPU:
  - Main steam, condensate, feedwater, extraction steam and heater vents and drains.
  - Evaluation for FIV levels of piping in accordance with the ASME OM –S/G Part 3.
  - There are no modifications to piping and pipe supports that are required due to EPU.
- Structural evaluations of SSCs at EPU conditions employed current plant design basis methodology and acceptance criteria.
- Structural evaluations met design basis code allowable values.

## Conclusion


- Reasonable assurance that plant SSCs important to safety are structurally adequate to perform intended design functions under EPU conditions.

# QUESTIONS

# Power / Flow Operating Map

Z1-0056-03

NINE MILE POINT 2  
POWER-FLOW OPERATING MAP  
2 RECIRC LOOPS IN OPERATION



- A. ORIGINAL ESTIMATED NATURAL CIRCULATION, LOW RECIRC PUMP SPEED BOTH FCV'S MIN. POS. LINE (SEE NOTE H)
- B. LOW RECIRC PUMP SPEED BOTH FCV'S MAX. POS
- C. EXPECTED POWER/FLOW RANGE AT RATED RECIRC PUMP SPEED, BOTH FCV'S AT UPSHIFT POSITION TYPICAL FOR POWER ASCENSION
- D. FLOW-BASED THERMAL POWER SCRAM
- E. CAVITATION INTERLOCKS
- F. MINIMUM ROOLINE FOR TRANSFER TO RATED RECIRC PUMP SPEED (472)
- G. ROOLINES L. MIN. 2, 61% 3, 54%
- H. LOWER BOUND OF NATURAL CIRCULATION LOW RECIRC PUMP SPEED BOTH FCV'S MIN. POS.
- I. THIS REGION IS AN EXIT REGION WITH ≥ 3 OPRM's OPERABLE. OTHERWISE (< 3 OPRM's OPERABLE) THIS REGION IS A SCRAM REGION (SEE NOTE K) (TECH SPEC 3.3.1.1).
- X. ROO LINE = PERCENT POWER  $\frac{22591 + (8.9734 \times 10^{-3}) \text{ PERCENT CORE FLOW} - (1.9165 \times 10^{-6}) \text{ PERCENT CORE FLOW}^2}{100}$
- J. THE ROO LINES SHOWN ARE BASED ON CALCULATIONS THAT ARE NOT CYCLE SPECIFIC AND THAT ACTUAL PLANT RESPONSE NOT FOLLOW THE ROO LINE EXACTLY DURING A REACTOR RECIRCULATION FLOW CHANGE.
- K. ALTERNATE METHODS FOR BACKUP STABILITY PROTECTION MEASURES FOR LESS THAN 3 OPRM's OPERABLE (TECH SPEC 3.3.1.1)
  - K.1 BACKUP STABILITY PROTECTION IMPLEMENTATION LINE
  - K.2 BACKUP STABILITY PROTECTION SCRAM LINE (SEE NOTE I)

THIS IS A COLOR CODED DRAWING  
SAFETY RELATED



# CENG

a joint venture of



## **ACRS Subcommittee Presentation Nine Mile Point 2 Extended Power Uprate**

**October 5, 2011**



# CENG

a joint venture of



## Nine Mile Point 2 Extended Power Uprate

### NMP2 EPU Overview

**Sam Belcher**  
**SVP-Site Operations**



# NMP2 EPU Agenda

- Overview Sam Belcher
- Plant Modifications Dale Goodney
- Power Ascension Testing Phil Amway
- Anticipated Transient Without Scram (ATWS) and Stability Phil Amway
- CLOSED SESSION - Fuel Methods (IMLTR) Phil Wengloski
- Material, Mechanical/Civil Engineering Topics George Inch
- CLOSED SESSION - Steam Dryer Analysis George Inch



# NMP2 EPU Overview

- GE BWR 5
- Mark II Containment
- Thermal Power
  - Original License Thermal Power (OLTP) 3323 MWth
  - Current License Thermal Power (CLTP) 3467 MWth
    - Stretch Uprate 104.3% (1995)
  - EPU Thermal Power (120% OLTP) 3988 MWth
    - Implement 2<sup>nd</sup> Quarter 2012



# NMP2 EPU Overview (cont'd)

- Attributes of the NMP2 constant pressure power uprate:
  - NMP2 is not requesting any Containment Accident Pressure (CAP) credit to support ECCS NPSH
  - No new fuel introduction; the current core and the EPU core are composed entirely of GE 14 fuel
  - The Alternative Source Term for accident radiological consequences was previously implemented using the EPU power level as a base assumption
- NMP2 has implemented Maximum Extended Load Line Limit Analysis (MELLLA) expanded operating domain



# NMP2 EPU Overview (cont'd)

- The NYISO has reviewed and approved the EPU full power output - no grid modifications are necessary
- The first two phases of EPU modifications have been installed
- The third and final phase of modifications needed to support EPU operation will be complete by 2<sup>nd</sup> Quarter of 2012



# CENG

a joint venture of



## **Nine Mile Point 2 Extended Power Uprate Plant Modifications**

**Dale Goodney  
EPU Lead Project Engineer**

# Plant Modifications

- General Approach
- Plant Parameters
- Installation Timeline
- Major Modifications
- NMP2 Plant Improvements



# Plant Modifications - General Approach

- Engineering studies were performed to evaluate structures, systems and components to determine the plant's ability to operate at EPU conditions
  - Analyzed effects of increase in steam flow, feedwater flow, reactor power and electrical output
  - Evaluations were based on NEDC-33004P-A, "Licensing Topical Report Constant Pressure Power Uprate," Revision 4 (CLTR)
  - Analyses are based on the target power level of 120% OLTP
  - Operating Experience was evaluated and applied



# Plant Modifications - General Approach (cont'd)

- Design and operating margins were identified and evaluated for both NSSS and BOP systems
- Over 20 physical plant modifications were described in the License Amendment Request
  - Restore Material Condition
  - Instrumentation for data collection and analysis
  - Upgrades to restore design and operating margin at EPU conditions
- Installation began in 2007 and will continue through 2012 Refueling Outage





# Plant Modifications - Plant Parameter Changes

Parameter	CLTP (104.3% OLTP)	EPU (120% OLTP)
Thermal Power (MWth)	3467	3988
Reactor Pressure (psia)	1035	1035
Rated Steam Flow (Mlb/hr)	15.002	17.636
Rated Feedwater Flow (Mlb/hr)	14.970	17.604
Generator Output (Mwe)	1211	1369
Feedwater Temperature (°F)	425.1	440.5



# Plant Modifications - Installation Timeline

2007 and 2008	2010 and 2011	2011 through 2012 Refueling
<ul style="list-style-type: none"> <li>• Main Steam (MS) Line Vibration Monitoring Strain Gages</li> <li>• Partial Bypass Around the Condensate Demineralizers</li> </ul>	<ul style="list-style-type: none"> <li>• Replace 3<sup>rd</sup> Point Feedwater Heater</li> <li>• Replace Feedwater Heater Drain Pumps and Motors</li> <li>• Install Piping Vibration Monitoring</li> <li>• Install Shielding for Equipment Qualification</li> </ul>	<ul style="list-style-type: none"> <li>• Upgrade Feedwater Pumps and Gear Sets</li> <li>• Replace Feedwater Pump Motor Cables</li> <li>• Recirculation Runback Initiation and Runback Rate</li> <li>• Replace High Pressure Turbine</li> <li>• Replace Low Pressure Turbine Cross Around Relief Valves</li> <li>• Replace Low Pressure Turbine Atmospheric Relief Diaphragms</li> <li>• Steam Dryer Modifications</li> <li>• Feedwater Heater Rerate</li> <li>• Generator Isolated Phase Bus Duct Cooling Improvements</li> <li>• Improve Main Transformer Cooling</li> <li>• Instrument Replacement and Scaling</li> <li>• Improve Turbine Building HVAC</li> <li>• Turbine Building Closed Loop Cooling Enhancements</li> <li>• Extraction Steam Expansion Joint Replacement</li> <li>• Main Steam/Feedwater Pipe Supports</li> </ul>



# Major Plant Modifications

## ➤ Condensate and Feedwater

- Feedwater Pump Upgrades
- Heater Drain Pumps and Motors
- Reactor Recirculation Runback

## ➤ Steam Path

- High Pressure Turbine
- Cross-Around Relief Valves
- Moisture Separator Reheater and 5<sup>th</sup>/6<sup>th</sup> Point Feedwater Heater Requalification
- Steam Dryer



# Major Plant Modifications (cont'd)

## ➤ Electrical/I&C

- Isophase Bus Duct Cooling
- Main Transformer Cooling
- Technical Specification Instrument Setpoints
- BOP Instrument Rescaling and Setpoints

## ➤ Auxiliary Support Systems

- Turbine Building HVAC
- Turbine Building Closed Loop Cooling



# NMP2 Plant Improvements

- NMP2 has implemented, or is planning to implement prior to EPU, a number of upgrades to restore margin, improve equipment reliability and reduce risk. Examples are:
  - Replaced Third Point Feedwater Heaters in 2010
  - Increased Standby Liquid Control Relief Valve Margin in 2010
  - Performed Cooling Tower Upgrades in 2008 and 2010
  - New Feedwater Pump Seals in 2012
  - Replace Jet Pump Inlet Mixers in 2012
  - Several PRA-related risk reduction improvements. Since 2008, Core Damage Frequency (CDF) has been reduced by 78%



# CENG

a joint venture of



## **Nine Mile Point 2 Extended Power Uprate Power Ascension Testing**

**Phil Amway  
EPU Operations Lead - SRO**

# Power Ascension Testing

- Preparation
- Approach
- Schedule
- Test Plan
- Acceptance Criteria and Actions



# Power Ascension Testing - Preparation

- Test Objective Development
  - Satisfactory Equipment Performance
  - Careful, Monitored Approach to EPU Power
  - Meet Established Requirements
- Roles & Responsibility Development
- Industry Benchmarking
- Test Plan and Implementing Test Procedure Development
- Power Ascension Test Training





# Power Ascension Testing – Approach

- Similar to approach used in other EPU's – Incremental Testing
- Baseline data at 75%, 90%, 95% and 100% CLTP
- Greater than 100% CLTP
  - Data acquisition performed in incremental steps of 1% and 2.5%
  - Active Testing and NRC Data Review at incremental steps of 5%



# Power Ascension Testing – Approach (cont'd)

## ➤ No Large Transient Testing

- Industry OE indicates that plants will continue to respond to transients as designed following EPU implementation
- Plant specific OE at 104.3% OLTP (Generator Load Reject and MSIV Closure)
- NMP2 has previously performed Large Transient Testing and documented results
- Plant operators will be trained on large transient events in the simulator
- Analytical methods and training facilities adequately simulate large transient events



# Power Ascension Testing – Schedule

- Data collection – 1% intervals
- Data evaluation – 2.5% intervals
- EPU Major Testing Plateau – 5% intervals
  - Passive data collection (e.g. vibration, radiation monitoring, plant parameter monitoring)
  - Active control system stability dynamic testing
    - Pressure regulator step test
    - Feedwater level control step test
  - Data Analysis
  - Plant Management (PORC) Review
  - NRC Review



# EPU Power Ascension Testing – Test Plan

## Major Testing

Test #	Description	70% CLTP up to 85% CLTP as evaluated	75% CLTP	80% CLTP	85% CLTP	90% CLTP	95% CLTP	100% CLTP	102.5% CLTP	105% CLTP	107.5% CLTP	110% CLTP	112.5% CLTP	115% CLTP	115% CLTP (@ point "D" 100% EPU power and 99% flow)	115% CLTP (@ point "F" 100% EPU power and 105% flow)	First controlled shutdown after EPU implementation	
1A	Chemical and Radiochemical Water Chemistry and Gaseous Effluent Data Collection								X	X	X	X						
1B	Steam Dryer/Separator Moisture Carryover								X	X	X	X			X	X		
2	Radiation Measurement Data Collection								X	X	X	X						
10	IRM Overlap																X	
11	LPRM Calibration	X												X				
12A	APRM Calibration/Functional Test							X						X				
12B	APRM Calibration to Heat Balance						X	X	X	X	X	X	X	X				
18	TIP Probe Uncertainty													X				
19	Core Performance						X	X	X	X	X	X	X	X	X			
22A	Pressure Regulator Testing						X	X	X	X	X	X	X	X				
23A	Feedwater Level Control Testing						X	X	X	X	X	X	X	X				
23B	Feedwater Flow Data Collection						X	X	X	X	X	X	X	X				
23C	Max Feedwater Runout Data Collection						X	X	X	X	X	X	X	X				
24A	Turbine Valve Surveillance Margin Test	X																
24B	MSIV Partial Closure Surveillance Margin Test								X	X	X	X	X	X				
35	Recirc Drive Flow Gain Adjustment Calibration								X					X				
74	Offgas System Performance						X	X	X	X	X	X	X	X				
75	Drywell Cooling					X	X	X	X	X	X	X	X	X				
100A	Piping Vibration Testing: MS, FW, and other key systems > 100% CLTP: • Data Collection Every 1% • Data Evaluation Every 2.5%			X			X	X	X	X	X	X	X	X	X	X		
100B	Dryer/Separator Stress Analysis > 100% CLTP: • Data Collection Every 1% • Data Evaluation Every 2.5%			X			X	X	X	X	X	X	X	X	X	X		
101	Key Parameter Monitoring						X	X	X	X	X	X	X	X	X	X		
102	Reactor Recirculation Performance Data				X		X	X	X	X	X	X	X	X				



# Power Ascension Testing – Acceptance Criteria and Actions

- **Level 1 Acceptance Criteria:** A limit associated with plant safety
- If Level 1 criterion is not met:
  - Abort the test
  - Reduce power to last known safe condition
  - Use the Corrective Action Program to evaluate the condition and to determine and implement required actions
  - Repeat testing to verify that the Level 1 criterion is satisfied
  - Document problem resolution



# Power Ascension Testing – Acceptance Criteria and Actions (cont'd)

- **Level 2 Acceptance Criteria:** A limit associated with plant or equipment performance that does not meet design expectations but is not immediately adverse to plant safety
- If Level 2 criterion is not met:
  - Place the test on hold and confirm the plant is in a safe condition
  - Use the Corrective Action Program to evaluate the condition and to determine and implement required actions
  - Repeat testing to verify the Level 2 criterion is satisfied unless the as-found condition is determined satisfactory
  - Document problem resolution



# Power Ascension Testing – Acceptance Criteria and Actions (cont'd)

- **Other Acceptance Criteria:** A limit associated with plant surveillance requirements, plant operating procedures, rounds or alarm responses
- When this criteria is not met, plant procedures will be followed



# CENG

a joint venture of



## **Nine Mile Point 2 Extended Power Uprate**

## **Long Term Stability Solution Option III and ATWS – Stability Events**

**Phil Amway  
EPU Operations Lead - SRO**



# Long Term Stability Solution – Option III/ATWS

- NRR Audit at Nine Mile Point 2
- Long Term Stability Solution – Option III
  - Oscillation Power Range Neutron Monitor (OPRM)
  - OPRM Settings
  - Backup Stability Protection (BSP)
  - 2003 NMP2 Stability Event
  - Effects of EPU on the Long Term Stability Solution
- Impact of EPU on ATWS – Stability Events
  - NMP2 ATWS Mitigation Design Features
  - Preparation for Simulator Demonstration
  - MSIV Closure with Failure to Scram
  - Turbine Trip with Failure to Scram
  - Conclusions



# NRR Audit at NMP2

- Performed October 28, 2009 to demonstrate procedure actions and operator response to ATWS transients at EPU conditions conform to regulatory requirements
- Reviewed implementation of Long Term Stability Solution – Option III
- Observed operator performance in plant reference simulator
  - MSIV Closure with Failure to Scram
  - Turbine Trip with Failure to Scram
- Included review of related procedures and mitigation strategies
- Requested follow up information when plant reference simulator was modified to provide ATWS - Stability transient response data



# Oscillation Power Range Monitor (OPRM)

- 1998 – NUMAC Power Range Neutron Monitor OPRM hardware installed (Amendment 80) - system tuning performed for plant specific settings
- 2000 – Reactor Protection System (RPS) OPRM trips armed (Amendment 92)
- 2002 – Implemented Plant Specific Delta CPR Over Initial CPR Versus Oscillation Magnitude (DIVOM) curve per GE Safety Communication 01-01, Stability Setpoint Calculation using Generic DIVOM Curve
- 2003 – Implemented filter frequency and period tolerance settings per GE Safety Communication 03-20, Stability Option III Period Based Detection Algorithm Allowable Settings



# OPRM Settings

- Cycle specific DIVOM analysis is performed using TRACG methodology
- Cycle specific amplitude setpoint is defined in the Core Operating Limits Report
- OPRM trips will be enabled  $\geq 26\%$  RTP and  $\leq 60\%$  recirculation drive flow to maintain the same enabled region in terms of MWth power



# Backup Stability Protection (BSP)

- BSP regions are determined using cycle specific ODYSY decay ratio calculations
- BSP regions are defined on plant power/flow operating maps
- Operator actions are defined in plant procedures with routine training reinforcement
- BSP exit region procedures are enforced at all times



# 2003 NMP2 Stability Event

- Component failure resulted in high to low speed transfer of both Reactor Recirculation pumps
- OPRM Period Based Detection Algorithm (PBDA) initiated an automatic reactor scram because of core wide oscillations
- The reactor was properly tripped by the PBDA
- Unexpected Confirmation Count (CC) resets occurred prior to the scram
- Post scram analysis determined that two parameter settings needed to be changed to address CC resets
- Parameter setting changes have been implemented per BWROG recommendations



# Effects of EPU on Long Term Stability Solution

- No methods changes for EPU
- Maximum rod line remains the same (MELLLA boundary)
- OPRM armed region maintains the same level of stability protection
- Cycle specific setpoint analysis will capture core design variations
- Option III long term solution remains unchanged
- Option III OPRM setpoints will be developed based on plant specific DIVOM curves for the EPU cycle specific reload analysis



# NMP2 ATWS Mitigation Design Features

## ➤ High RPV pressure initiates ATWS systems

T=0 seconds

- Automatic Alternate Rod Insertion (ARI)
- Automatic Reactor Recirculation Pump Trip (RPT) to slow speed

T=25 seconds and power >4%

- Automatic Feedwater Runback
- Automatic Reactor RPT to off

T=98 seconds and power >4%

- Automatic Boron Injection





# Preparation for Simulator Demonstration

- Simulator demonstration performed prior to operator training for EPU conditions
- Operating crew was provided with a briefing on EPU power level, steam and feedwater flows
- An SRO other than the EPU Operations Lead participated in the demonstration to avoid biasing operator response
- Simulator demonstration confirmed that current procedures and strategies successfully mitigate ATWS events



# MSIV Closure with Failure to Scram

- 3988 MWth at 99% core flow (MELLLA boundary)
- Maximum Suppression Pool temperature 90°F
- Minimum Suppression Pool level 199.5 feet
- Maximum Service Water temperature 84°F
- No Control Rod Motion
- The above worst case conditions are consistent with design analysis inputs



# MSIV Closure with Failure to Scram (cont'd)

- Both loops of Suppression Pool cooling in service at rated flow in 404 seconds vs action time of 1080 seconds
- Hot shutdown (<0.1% power) achieved in 406 seconds
- Peak Suppression Pool temperature remains below Heat Capacity Temperature Limit with 5°F margin
- Containment parameters remain well within design analysis
- Plant reference simulator critical parameter response closely matched the design analysis for this event



# Turbine Trip with Failure to Scram

- 3988 MWth at 99% core flow (MELLLA boundary)
- Maximum Suppression Pool temperature 90°F
- Minimum Suppression Pool level 199.5 feet
- Maximum Service Water temperature 84°F
- No Control Rod Motion
- The above worst case conditions are consistent with design analysis inputs



# Turbine Trip with Failure to Scram (cont'd)

- Both loops of Suppression Pool cooling in service at rated flow in 425 seconds vs. action time of 1080 seconds
- Hot shutdown (<0.1% power) achieved in 465 seconds
- Peak Suppression Pool temperature remains below Heat Capacity Temperature Limit with 19°F margin
- Containment parameters remain within design analysis
- Plant reference simulator critical parameter response closely matched the design analysis for this event



# Conclusions

- Existing procedures, operator action times and strategies are effective in mitigating ATWS and ATWS instability transients
- NMP2 features an ATWS RPT function. As a result, transient power levels are primarily based on the maximum control rod line which is unchanged for EPU
- Operators can perform actions in a timely manner to bring the plant to safe shutdown



# CENG

a joint venture of



## **Nine Mile Point 2 Extended Power Uprate**

## **Material, Mechanical/Civil Engineering Topics**

**George Inch**

**Principal Engineer - Mechanical/Structural Lead**

# RPV Internals

- Fluence
- Flow Induced Vibration (FIV)
- Structural Effects (Non-FIV)
- Intergranular Stress Corrosion Cracking (IGSCC) and Irradiation Assisted Stress Corrosion Cracking (IASCC)





# RPV Internals – Fluence

- Irradiation assisted stress corrosion cracking (IASCC) fluence threshold is  $5 \times 10^{20} \text{ n/cm}^2$
- The following components exceeded the IASCC fluence threshold:
  - Top Guide (BWRVIP-26-A)
  - Shroud (BWRVIP-76-A)
  - Core Plate (BWRVIP-25-A)
- Continued implementation of the current program in accordance with the BWRVIP recommendations assures the prompt identification of any degradation of reactor vessel internal components
- NMP2 Utilizes Hydrogen Water Chemistry and Noble Metals
- Reactor vessel water chemistry conditions maintained consistent with the EPRI and established industry guidelines
- Peak fluence increase does not represent a significant increase in the potential for IASCC



# RPV Internals – Flow Induced Vibration

- Vibration levels for EPU were estimated by extrapolating vibration data from prototype plant or similar plants and on GEH BWR operating experience
- The following components were evaluated: a) shroud head and separator assembly; b) jet pumps; c) core delta P line; d) guide rods; e) in-core guide tubes and control rod guide tubes; f) jet pump sensing lines; g) feedwater sparger; h) fuel assembly, top guide, and core plate; i) RPV top head spare instrument nozzle; j) RPV top head vent nozzle; k) RPV head spray pipe and head spray nozzle; l) core spray piping
- Results show that continuous operation at EPU conditions does not result in any detrimental effects on the safety-related reactor internal components



# RPV Internals – Structural Effects (Non-FIV)

- Evaluations/stress reconciliation was performed consistent with the Design Basis Analysis
- Original configurations of the internal components utilized, unless a component had undergone permanent structural modification
- Effects of thermal-hydraulic changes due to EPU were evaluated
- EPU loads compared to those in the existing design basis analysis
- For increases in load, linearly scaled the critical/governing stresses based on increase in loads – compare resulting stresses against the allowable stress limits
- All stresses and fatigue usage factors are within the design basis ASME code allowable values
- RPV internal components demonstrated to be structurally qualified for operation at EPU conditions



# RPV Internals – IGSCC and IASCC

- Procedurally controlled program consistent with BWRVIP issued documents
- Components inspected include: core spray piping and spargers; core shroud and core shroud support; jet pumps and associated components; top guide; lower plenum; vessel inner diameter attachment welds; instrumentation penetrations; steam dryer drain channel welds; and feedwater spargers
- Program assures prompt identifications of any degradation
- Hydrogen water chemistry and noble metal applications to mitigate the potential for IGSCC and IASCC
- Recent Control Blade Cracking OE
  - Not applicable to GEH Marathon “C” lattice models
  - GEH concluded no lifetime reduction for “C” lattice



# Fatigue Monitoring Program

- NMP2 implemented FatiguePro for fatigue monitoring in 2008 independent of EPU
  - Automated event tracking and usage based on cycle counting for most event
    - Assumed design basis event severity, records actual event severity
  - Stress based monitoring of FW nozzle location to improve the accuracy of usage



# Fatigue Monitoring Program (cont'd)

- The EPU evaluation performed refined fatigue usage calculations for the FW nozzle
  - Reduced usage from original design basis
- FW nozzle high usage defined by off-normal rapid cycling events occurring during partial loss of feedwater heating and hot standby operation
  - EPU scaling factor small (between 6% and 15%)
  - Stress based fatigue monitoring anticipated to demonstrate usage less than 1.0 for 60 years

	CLTP 40 year CUF	EPU 40 year CUF
Carbon Steel Safe End	0.965	0.6537
Stainless Steel Clad	0.916	0.8299



# Fatigue Monitoring Program (cont'd)

- FatiguePro implemented at NMP2 uses a single stress term for stress based monitoring
  - Simplified Greens function
  - RIS-2008-30 is applicable to NMP2
- NMP2 is following industry developments to reconcile RIS-2008-30 issue
  - FatiguePro 4
    - ASME Code Sub article NB-3200 fatigue analysis methodology
    - Environmental Fatigue rules (NUREG/CR-5704/6583/6909)
  - NMP2 is considering alternative confirmatory analyses as proposed by RIS-2008-30





**U.S.NRC**

UNITED STATES NUCLEAR REGULATORY COMMISSION

*Protecting People and the Environment*

# **NMP2 EPU ATWS & Stability**

Dr. Tai L. Huang (NRR/ADES/DSS/SRXB)

Dr. Jose March-Leuba (ORNL)


ACRS Subcommittee Meeting  
October 5, 2011



## Staff SER

- Staff has completed an SER with positive findings based on the review of available documents and a staff audit
  - Current LTS implementation (Sol III) is adequate for EPU
    - Satisfies GDC 10 & 12
    - Level of protection in EPU is similar to CLTP
  - Staff audit concluded that
    - NMP2 operators show good understanding of stability and ATWS issues for EPU.
    - Staff observations of operators' action in the simulator support the customary 120 s delay assumed for safety calculations
    - NMP2 EOPs are adequate for EPU

# EPU Does Not Change the End Point After The Recirculation Pump Trip



- End Point is the same for CLTP and EPU because it is defined by
  - Natural Circulation
  - Subcooling (lower pressure of FW heating-steam)
- Stability characteristics of end point are similar

## Stability

- LTS Option III installed since 1998, and armed since 2000
- Plant has good experience with Option III
  - 2003 NMP2 event was detected and scram actuated
    - very low amplitude oscillations, which kept on resetting the OPRM confirmation counts
  - Lessons learned (parameter settings) implemented at NMP2 per BWROG recommendations
- No impact expected for EPU
  - Option III and DIVOM methodology are applicable



# ATWS-Instability

- NMP2 has implemented latest EPG/SAGs
  - Early level reduction & boron injection are accomplished through automated ATWS actions if high pressure is detected with power >4%:
    - Automatic flow runback
    - Automatic boron injection
- NMP2 has excellent ATWS response:
  - SLC injection through HPCS (early shutdown)
  - 100% motor driven FW (sufficient HP inject capacity)
  - EOPs are reviewed every cycle, but are not affected significantly by EPU because boron is injected in HPCS and there is no need to define a HSBW.
    - EPU does affect HCTL slightly (from 140°F to 139°F)

## Staff Audit


- Staff reviewed the performance of the OPRM Solution III system in the simulator
- Staff reviewed ATWS performance in the simulator (3 different scenarios)
  - Turbine Trip ATWS From The MELLLA Corner with simulated unstable oscillations
  - MSIV Isolation ATWS from MELLLA corner
  - MSIV Isolation ATWS from EPU conditions
- NMPNS submitted additional information with the simulator ATWS results

# Simulator shows similar response at EPU and CLTP




# Simulator shows margin to emergency depressurization

CLTP



EPU



# Summary

- EPU operation is acceptable from stability point of view
  - Installed LTS (Sol III) provides similar level of protection under EPU and CLTP
  - OPRM scram satisfies GDC 10 and 12
- ATWS and ATWS-Stability not affected significantly by EPU
  - Satisfies ATWS Acceptance Criteria (10CFR 50.62)
  - NMP2 has excellent ATWS performance design
    - Automatic trips
    - Upper plenum boron injection
    - 100% motor-driven FW pumps





**U.S.NRC**

UNITED STATES NUCLEAR REGULATORY COMMISSION

*Protecting People and the Environment*

**Nine Mile Point Unit No. 2  
Extended Power Uprate  
ACRS Subcommittee Meeting**

**Interim Methods Applicability of GE  
Methods to Expanded Operating  
Domains**

**Dr. Peter Yarsky  
RES/DSA/RSAB**

Thanks,  
Rich



## Methods Review Basis

- Review based on approved LTR NEDC-33173P “Applicability of GE Methods to Expanded Operating Domains,” (the IMLTR)
- Staff confirmed that the EPU LAR is fully consistent with the conditions and limitations specified in the staff’s SE for the IMLTR

## Staff Review Items

- IMLTR: 24 Conditions and Limitations
  - No Supplements to the IMLTR referenced in the NMP2 EPU LAR
  - PUSAR Appendix A dispositions each condition and limitation
  - All 24 conditions and limitations acceptably met
  - Staff conducted one regulatory audit pertaining to the IMLTR

## Staff Review Items

- LPRM Calibration Interval
  - LPRM update affects core monitor accuracy to predict power distribution
  - Interval is 1,000 EFPH
  - Post EPU, exposure interval between calibrations would increase 15 percent
  - Staff audited GEH data to confirm that power distribution uncertainties were acceptable for longer exposure interval

## Conclusions

- Methods application acceptable because all staff SE conditions and limitations on the IMLTR are met