

Official Transcript of Proceedings

NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards
Materials, Metallurgy and Reactor Fuels

Docket Number: (n/a)

Location: Rockville, Maryland

Date: Thursday, December 15, 2011

Work Order No.: NRC-1341

Pages 1-163

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1323 Rhode Island Avenue, N.W.
Washington, D.C. 20005
(202) 234-4433

1 UNITED STATES OF AMERICA

2 NUCLEAR REGULATORY COMMISSION

3 + + + + +

4 ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

5 (ACRS)

6 + + + + +

7 MATERIALS, METALLURGY AND REACTOR FUELS SUBCOMMITTEE

8 + + + + +

9 THURSDAY

10 DECEMBER 15, 2011

11 + + + + +

12 ROCKVILLE, MARYLAND

13 + + + + +

14 The Subcommittee met at the Nuclear
15 Regulatory Commission, Two White Flint North, Room
16 T2B1, 11545 Rockville Pike, at 8:30 a.m., J. Sam
17 Armijo, Chairman, presiding.

18
19 SUBCOMMITTEE MEMBERS PRESENT:

20 J. SAM ARMIJO, Chairman

21 DENNIS C. BLEY (via telephone)

22 JOY REMPE

23 WILLIAM J. SHACK

1 NRC STAFF PRESENT:

2 CHRISTOPHER L. BROWN, Designated Federal
3 Official

4 QUYNH NGUYEN, Cognizant Staff Engineer

5 WILLIAM RULAND

6 TARA INVERSO

7 PAUL CLIFFORD

8 RALPH LANDRY

9 GEARY MIZUNO

10 MICHELLE FLANAGAN

11
12 ALSO PRESENT:

13 TOM RODACK

14 TOM EICHENBERG

15 KURT FLAIG

16 BERT DUNN

17 GORDON CLEFTON (via telephone)

1	A G E N D A	
2	OPENING REMARKS	4
3	S. Armijo, ACRS	
4	STAFF INTRODUCTION	6
5	W. Ruland, NRR	
6	NRC - BACKGROUND OF 50.46c RULEMAKING	9
7	T. Inverso, NRR	
8	NRC - OVERVIEW OF 50.46c RULE (PART 1)	15
9	P. Clifford, NRR	
10	BREAK	64
11	NRC - OVERVIEW OF ASSOCIATION REGULATORY	
12	GUIDANCE	64
13	M. Flanagan , RE	
14	INDUSTRY - OVERVIEW OF BWR OWNERS' GROUP	
15	REPORT	72
16	T. Eichenberg, TVA	
17	K. Flaig, Dominion	
18	NRC - OVERVIEW OF SAFETY ASSESSMENT	106
19	P. Clifford, NRR	
20	LUNCH	136
21	NRC - 50.46c IMPLEMENTATION SCHEDULE	136
22	P. Clifford, NRR	
23	R. Landry, NRO	
24	COMMITTEE DISCUSSION	159
25	ADJOURN	163

P R O C E E D I N G S

(8:30:25 a.m.)

CHAIR ARMIJO: Okay, good morning. The meeting will now come to order.

This is a meeting of the Materials, Metallurgy and Reactor Fuels Subcommittee. I am Sam Armijo, Chairman of the Subcommittee. Members in attendance will be Dr. Dennis Bley, who is on the phone listening in and can make comments when he so chooses. Dr. Bill Shack, Dr. Joy Rempe, Dr. Abdul Said-Khalik will join us in the afternoon, and Dr. Mike Ryan will be cycling in and out.

As you may know, we have a concurrent meeting on the Watts Bar Plant in the next room, so it's going to be a little hectic this morning.

Christopher Brown of the ACRS Staff is the Designated Federal Official for this meeting. Quynh Nguyen of the ACRS Staff is the lead Cognizant Engineer.

The purpose of this briefing is for the Staff to discuss the Draft Proposed Rule Language for 10 CFR 50.46c, the path forward, and potential impacts to industry during its implementation.

We will hear presentations from representatives of the Office of Nuclear Reactor

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

1 Regulation (NRR), Nuclear Regulatory Research (RES),
2 and New Reactors.

3 In addition, presentations will be heard
4 from the Boiling Water Reactor Owners' Group (BWROG)
5 and Pressurized Water Reactor Owners' Group.

6 The Subcommittee will gather information,
7 analyze relevant issues and facts, and formulate a
8 proposed position and action as appropriate for
9 deliberation by the full Committee.

10 The rules for participation in today's
11 meeting were announced as part of the Notice of this
12 meeting previously published in the Federal Register
13 on November 23rd, 2011 and revised on December 7th,
14 2011.

15 The meeting will be open to the public
16 attendance with the exception of portions that may be
17 closed to protect information that is proprietary
18 pursuant to 5 USC 552(b)(c)(4).

19 We have received no written comments or
20 requests for time to make oral statements from members
21 of the public regarding today's meeting.

22 A transcript of the meeting is being kept
23 and will be made available as stated in the Federal
24 Register Notice. Therefore, we request the
25 participants in this meeting to use the microphones

1 located throughout the meeting room when addressing
2 the Subcommittee.

3 Participants should first identify
4 themselves and speak with sufficient clarity and
5 volume so that they can be readily heard.

6 A telephone bridge line has been
7 established for this meeting. To preclude
8 interruption of the meeting, the phone will be placed
9 in a listen-in mode during the presentations and
10 Committee discussions. I'd like to ask everyone to
11 please silence all phones, and that includes me, which
12 I just remembered.

13 We will now proceed with the meeting. I
14 call on Mr. Bill Ruland of the Office of Nuclear
15 Reactor Regulation to make introductory remarks.

16 MR. RULAND: Good morning, and thank you,
17 Mr. Chairman, and good morning to Subcommittee
18 members.

19 Before I start, while NRR is taking the
20 lead for this rulemaking, I just want to acknowledge
21 both the Office of Research, and the Office of New
22 Reactors who have worked -- really spent a lot of time
23 with us in developing this rule package, so I'd just
24 like to acknowledge their fine contribution to this
25 rulemaking package.

1 The purpose of this briefing, of course,
2 is to present the proposed 50.46c Rule package. This
3 proposed rule will eventually replace the existing
4 40.46 ECCS Rule. And it is not an alternative to the
5 existing requirement, nor is it an optional
6 regulation.

7 The main objectives of this rulemaking are
8 to capture the research finding which identified new
9 cladding embrittlement mechanisms and to respond to
10 the Commission Directive to develop a more
11 performance-based ECCS Rule.

12 This rulemaking also responds to two
13 petitions for rulemaking. Both this ACRS Subcommittee
14 and the full Committee have been previously briefed on
15 local research which comprises the technical basis for
16 this rulemaking.

17 In a letter to the Commission, the ACRS
18 stated that the technical basis was sufficient and
19 rulemaking should proceed.

20 This briefing -- today's briefing focuses
21 on the proposed rule language and the strategy for
22 implementing the new regulatory requirements on the
23 commercial fleet.

24 To support the performance-based aspects
25 of the proposed rule, the Staff has developed three

1 new Draft Regulatory Guides. Today's briefing includes
2 a brief summary of these Reg Guides to better
3 understand the connection between the rule language
4 and the Staff Guidance. The ACRS has been previously
5 briefed on these documents and has recommended that
6 the Staff issue them for public comment.

7 Upon receipt of the local research
8 findings in 2008, NRR completed an initial safety
9 assessment to determine the regulatory path forward.
10 When new information becomes available generally to
11 the Staff which shows that existing regulations may
12 not achieve their intended safety goals, the Staff
13 must decide the speed at which new requirements are
14 imposed upon the industry.

15 In 2008, the Staff determined that no
16 imminent safety risk existed, and that the rulemaking
17 process should proceed. Recognizing that finalization
18 and implementation of the new ECCS requirements should
19 take several years, the Staff decided that a more
20 detailed Safety Assessment was necessary.

21 Today's briefing also includes
22 presentations by representatives from the industry and
23 the Staff on the joint effort to confirm and document
24 on a plant-specific basis the continued safe operation
25 of the U.S. nuclear fleet.

1 As I know Tara and Paul are going to
2 outline, this is really a soup to nuts briefing about
3 the 50.46c rulemaking. Virtually all aspects of the
4 rulemaking will be covered.

5 So, that concludes my remarks.

6 CHAIR ARMIJO: Okay. Thank you, Bill.
7 Tara, before you start, I just want to make a double
8 check to make sure that Dennis Bley is still on the
9 phone. Sometimes Skype drops these calls.

10 Dennis, are you on the line?

11 MEMBER BLEY: Yes, I am. I'm here. I had to
12 figure out how to unmute my phone.

13 CHAIR ARMIJO: Okay, thank you very much.
14 All right, Tara, all your's.

15 MS. INVERSO: Thank you. As Bill mentioned,
16 I'm Tara Inverso, and I'm the Rulemaking Project
17 Manager for the 50.46c Proposed Rule.

18 The purpose of today's meeting is to
19 present the 50.46c Proposed Rule to the Advisory
20 Committee on Reactor Safeguards. Michelle Flanagan
21 from the Office of Nuclear Regulatory Research will
22 review three associated draft regulatory guides, and
23 then Paul Clifford and Ralph Landry will provide an
24 overview of the Safety Assessment, the NRC audit, and
25 also the implementation of the Proposed Rule.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 The meeting agenda for today will begin
2 with this background presentation. Then Paul will
3 walk through each paragraph of the Proposed Rule
4 language. Michelle will then move into her
5 presentation on the regulatory guides. And then the
6 industry will present aspects of the information
7 contained in the Boiling Water Reactor and Pressurized
8 Water Reactor Owners' Group Reports.

9 Paul will then discuss the NRC's
10 assessment of those reports in the audit, and then
11 Paul and Ralph will talk about the proposed
12 implementation schedules.

13 This rulemaking has three main objectives.
14 The first objective is to revise the ECCS Acceptance
15 Criteria to reflect research findings. This research
16 program focused on high exposure fuel rod cladding
17 under accident conditions. The research program
18 identified new cladding embrittlement mechanisms and
19 also expanded the NRC's knowledge of previously
20 identified mechanisms.

21 Specifically, the research pointed to the
22 possibility that zirconium-based alloy fuel cladding
23 could embrittle at a lower combination of temperature
24 and oxygen absorption that currently allowed under the
25 current regulation due to the effects of hydrogen

1 absorption.

2 Because of this, the Staff has concluded
3 that this rule is necessary to insure the adequate
4 protection to public health and safety by restoring
5 that level of protection which the NRC thought was
6 guaranteed by the current regulation.

7 Also, through SECY-02-0057, the Commission
8 directed the Staff to while revising the ECCS
9 Acceptance Criteria modify them in such a way that
10 they're more performance-based.

11 The Commission also directed the Staff to
12 expand the applicability of the rule. And this
13 proposed rule goes to all -- applies to all fuel
14 designs and cladding materials.

15 As Bill mentioned, the rule also addresses
16 two Petitions for Rulemaking. The first is Petition
17 for Rulemaking 50.71. That was submitted on March
18 14th, 2000 by David Modine on behalf of the Nuclear
19 Energy Institute, and a request that the NRC expand
20 the applicability of the rule to apply to all
21 zirconium-based cladding alloys, not just Zircaloy and
22 ZIRLO, as mentioned in the current regulation.

23 The second Petition for Rulemaking that's
24 addressed is PRM-50-84, and that one was submitted by
25 Mr. Mark Lacey on March 15th of 2007, and requested

1 rulemaking in a couple of areas, one of which was that
2 the NRC consider the effects of the thermal resistance
3 of crud and oxide layers in their analyses.

4 The Staff has had a lot of public
5 interaction developing this rule, the first of which
6 is not noticed on this slide, but on July 31st of 2008
7 the NRC published the regulatory basis for this rule,
8 which was summarized in Research Information Letter
9 0801, and the details of which was really in NUREG/CR-
10 6967.

11 The NRC had a public meeting on that
12 regulatory basis on September 23rd, 2008 to discuss
13 the public comments received on the technical basis.
14 The Staff presented the technical basis to the ACRS in
15 December of 2008, and on December 18th the ACRS wrote
16 a letter stating that there was sufficient
17 understanding and data to proceed with the rulemaking.

18 So, on August 13th, 2009 the NRC published
19 the Advance Notice of Proposed Rulemaking, and that
20 laid out the four objectives of the rulemaking, and
21 also posed 12 questions for specific response. The
22 NRC received 19 comment letters in response to the
23 ANPR from a variety of sources, the industry,
24 international community, and some public citizens.

25 There was a public workshop held between

1 April 28th and 29th, 2010 to discuss the ANPR comments.
2 The ANPR comments and the NRC responses were discussed
3 on April 28th.

4 The purpose of the April 29th public
5 workshop was to introduce the concept of a prospective
6 generic letter that would address the potential
7 embrittlement of fuel rods during loss of coolant
8 accidents.

9 It was during that public meeting that the
10 industry presented a concept by which that information
11 would be provided through a voluntary initiative. So,
12 public meetings were held on August 12th and December
13 2nd, 2010, and then again on March 3rd, 2011 to work
14 with the industry to make sure that that information
15 provided in that report was similar to that that would
16 be requested through a generic letter.

17 We've also had several meetings with the
18 ACRS. We already mentioned the meetings on the
19 regulatory basis. In June and July, Michelle presented
20 a technical document called "The Mechanical Behavior
21 of Ballooned and Ruptured Cladding," and that
22 addressed the applicability of the hydrogen-based
23 embrittlement correlation to areas of the fuel rod
24 which may rupture. And that technical document will
25 supplement RIL-0801 for the regulatory basis in that

1 region of the rod.

2 In May and June, we also presented the
3 three Draft Regulatory Guides to ACRS Subcommittee and
4 full Committees.

5 During the May meeting, we listed a slide
6 of things that we were considering along with this
7 rulemaking, and one of the topics listed was fuel
8 fragmentation, relocation, and dispersal. And we
9 committed to ACRS that we would follow-up with our
10 final determination of how that would be addressed
11 through this rulemaking.

12 The Staff's conclusion is that further
13 research is necessary to understand fuel dispersal and
14 its significance, so it is not included in this
15 proposed rule.

16 The NRC Staff is recommending to the
17 Commission that the Commission do, indeed, publish
18 this proposed rule for comment. This proposed rule is
19 complete, and it's current written addresses all of
20 the Commission direction and all of the original
21 rulemaking objectives.

22 CHAIR ARMIJO: So, Tara, can I conclude
23 that as far as the Staff is concerned there is no
24 serious deficiency in the Proposed Rule by leaving out
25 the issue of fuel dispersal?

1 MS. INVERSO: Right. And the current
2 understanding of that phenomena is not complete to
3 even include it at this point. We don't know whether
4 or not it would needed in a regulation. Further
5 research is needed to determine that. But the rule is
6 complete. There aren't any holes at this point.

7 CHAIR ARMIJO: Okay, thank you.

8 MS. INVERSO: The current rulemaking
9 schedule, return to the full Committee of the ACRS on
10 January 19th, 2012. And the rule is due to the
11 Executive Director for Operations on February 29th,
12 2012.

13 Are there any questions?

14 (No response.)

15 (Off the record comments.)

16 MR. CLIFFORD: Good morning. My name is
17 Paul Clifford. I work in NRR, and I am the Technical
18 Lead for the 50.46c Rulemaking. My presentation will
19 focus on the 50.46c Rule, its purpose, its structure,
20 and its basis.

21 The design function of the Emergency Core
22 Cooling System is to mitigate the consequences of a
23 postulated loss of coolant accident. Specifically, the
24 performance objectives of the many systems,
25 structures, and components that comprise the ECCS is

1 to replenish the liquid inventory lost out the break
2 in order to maintain core temperatures at an
3 acceptable level.

4 This slide provides a regulatory
5 definition of a loss of coolant accident. A LOCA
6 means a hypothetical accident involving a break in the
7 primary system piping which results in a loss of RCS
8 coolant beyond the capability of the reactor makeup
9 system.

10 The accident progression of a primary
11 system piping break consists of a loss of RCA liquid
12 inventory, depressurization of the primary system, and
13 a consequential heat up of the fuel rods. The rate of
14 change in these parameters depends strongly on the
15 break size and the break location.

16 This figure illustrates a predicted fuel
17 rod cladding temperature during the initial phase of
18 a double-ended guillotine break in the cold leg of a
19 CE two-loop PWR. Water injected into the primary
20 system initially via the safety injection tanks and
21 then via safety injection pumps re-establishes core
22 liquid level and turns around the cladding temperature
23 excursion.

24 For this case the principal performance
25 goal of the ECCS was achieved since core temperatures

1 were maintained at an acceptable level as defined by
2 the current regulation at 2200 degrees Fahrenheit peak
3 clad temperature.

4 CHAIR ARMIJO: Paul, before you leave that,
5 this is for a large-break LOCA.

6 MR. CLIFFORD: This is a large-break LOCA.

7 CHAIR ARMIJO: Now, what's the time scale
8 for a small-break LOCA? What's a range -- what are we
9 talking about typical, not that there is anything
10 typical but just for perspective. Are we talking
11 about several thousands of seconds? What kind of peak
12 temperatures just roughly?

13 MR. CLIFFORD: I'll look to our LOCA system
14 expert.

15 MR. LANDRY: Mr. Chairman, this is Ralph
16 Landry from the Office of New Reactors.

17 The time scale for a small-break LOCA is
18 very large spread because of the size of the break. It
19 can be from hundreds of seconds out to thousands of
20 seconds. A typical break, such as a two-inch break,
21 is going to be about a 3,000 second event, about an
22 hour's event.

23 CHAIR ARMIJO: Okay. And the temperature
24 is --

25 MR. LANDRY: Temperatures in a small-break

1 typically do not reach the kind of temperatures they
2 do in a large break.

3 CHAIR ARMIJO: Right. But that's --

4 MR. LANDRY: A high-temperature small-break
5 would be probably on the order of 1600 degrees
6 Fahrenheit.

7 CHAIR ARMIJO: Okay.

8 MR. LANDRY: But the small break has a
9 tendency to oxidize a great deal because you're
10 staying up a moderately high temperature for a very
11 long period of time.

12 CHAIR ARMIJO: Yes, that's what I was
13 trying to get at, is the breakaway oxidation issue.
14 And it's my understanding that above 800 degree
15 Centigrade is where this really kicks in.

16 MR. LANDRY: That's correct.

17 CHAIR ARMIJO: And below that we're not
18 particularly concerned, or are we?

19 MR. LANDRY: Paul is going to get into what
20 we've put into the regulation, proposed regulation on
21 breakaway oxidation. And if we get into talking about
22 the total package, one of the questions -- one of the
23 concerns we have is that fuel vendors can demonstrate
24 that the timed breakaway oxidation is longer than the
25 time that they would predict a particular plant would

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 stay above our at the breakaway temperature.

2 CHAIR ARMIJO: Okay.

3 MR. LANDRY: So, we're relating the two
4 through the total package that supports this rule.

5 MR. CLIFFORD: Right. And you'll see this
6 afternoon that 103 of the power plant predict time
7 above 800 at less than 2,000 seconds.

8 CHAIR ARMIJO: Okay.

9 MR. CLIFFORD: Whereas, the breakaway
10 oxidation usually occurs at around 5,000 seconds.

11 CHAIR ARMIJO: Okay.

12 MR. CLIFFORD: So, it's not -- it turns out
13 that it's not that challenging.

14 CHAIR ARMIJO: Okay. Thanks, Paul.

15 MR. CLIFFORD: The existing 50.46 Rule
16 dictates prescriptive analytical limits with no
17 defined performance objective. To achieve the
18 Commission Directive of a more performance-based
19 regulation, the working group essentially started with
20 a blank sheet of paper. As a result, 50.46c
21 represents a major restructuring of the rule. In a
22 side-by-side comparison you wouldn't even know it was
23 the same regulation.

24 This slide shows kind of the Table of
25 Contents for the rule. It's important to note that the

1 existing rule was limited in applicability to the LWRs
2 fueled with uranium oxide pellets within cylindrical
3 Zircaloy or ZIRLO cladding. So, legally, there was no
4 ECCS regulatory requirements for licensees opting to
5 use more advanced claddings that weren't covered under
6 the umbrella of Zircaloy or ZIRLO. Further, there were
7 no regulations governing the performance of any new
8 cladding material during a LOCA.

9 So, the first step in the development of
10 50.46c was to define an expanded applicability. The
11 new rule is meant to be universally applicable to all
12 LWRs independent of ECCS design, independent of fuel
13 design.

14 The second step in the development of
15 50.46c was to define kind of the tier one principal
16 ECCS performance objectives. However, since the
17 performance of the ECCS will be judged on how well the
18 fuel holds up under LOCA conditions, specific fuel
19 design-dependent performance requirements must also be
20 defined.

21 I mean, it's logical to think that
22 specific performance requirements of the current
23 generation of fuel which is ceramic UO2 pellet within
24 metallic Zircaloy cladding would be different than
25 what the specific performance objectives would be for

1 say a metallic thorium-plutonium pellet within a
2 ceramic cladding.

3 Therefore, the capacity and the capability
4 of the ECCS may differ based on the type of fuel for
5 which it is trying to cool. However, the principal
6 requirement, the tier one performance objectives would
7 still be universal.

8 The third step in the development of
9 50.46c was to define the specific fuel design-specific
10 requirements for the current generation of fuel.

11 Regulatory requirements for the ECCS
12 consist of, one, principal performance objectives
13 which are to maintain acceptable core temperatures
14 during a LOCA and to remove decay heat following a
15 LOCA. In addition, there are principal analytical
16 requirements.

17 Simply put, each LWR must be equipped with
18 an ECCS capable of satisfying the principal
19 performance objectives, and each licensee must provide
20 a performance demonstration showing compliance.

21 For each fuel design the rule must specify
22 specific performance requirements and analytical
23 limits which form the basis of the acceptable core
24 temperatures, because an acceptable temperature for
25 one fuel is going to be different than an acceptable

1 temperature for a different fuel. And these must be
2 established based upon the degradation mechanisms and
3 any other unique features specific to that fuel
4 design. In addition, specific analytical requirements
5 which impact the predicted performance of the fuel
6 under LOCA condition must also be defined.

7 CHAIR ARMIJO: I just want to make sure I
8 understand this, Paul.

9 MR. CLIFFORD: Sure.

10 CHAIR ARMIJO: Take a Westinghouse 17x17
11 fuel assembly with ZIRLO cladding. If either the
12 vendor does sufficient work to define these specific
13 performance requirements and analytical limits, is
14 that applicable to all PWRs that use that fuel or to
15 a subset of PWRs that use that fuel?

16 MR. CLIFFORD: It would be applicable --
17 it's really material-specific, but there may be fuel
18 design specific analytical requirements which need to
19 be considered based on the design of the fuel.

20 I guess what we're trying to say here is
21 you need to make it universal. For instance, we have
22 a wealth of information through all the testing that's
23 been done for the last 30 years, and especially all
24 the data we received from the high-burnup LOCA
25 research program at Argonne on zirconium. So, we know

1 all -- we've identified all the degradation
2 mechanisms, and we've defined a regulatory performance
3 objective, and that is to maintain ductility, because
4 we know for that cladding material we want to maintain
5 ductility. And we have a sufficient empirical database
6 where we define what impacts the degradation and
7 ductility. But for say a ceramic cladding, there is no
8 inherent ductility, so we wouldn't use ductility as a
9 performance metric. We would have to define another
10 performance metric, maybe just strength. And then we
11 would have to identify any degradation mechanisms that
12 occur under LOCA conditions which affect its strength.

13 CHAIR ARMIJO: Okay, so this much broader
14 than just zirconium-based alloys.

15 MR. CLIFFORD: That's why it's universal.
16 But they all relate to temperature. That's how we are
17 able to define overall performance objectives;
18 maintain an acceptable level. But the acceptable
19 level is then defined by the experimental database on
20 that particular material.

21 And we'll be getting into that for the
22 current generation, so I think it'll be more clear as
23 we walk through it. Actually, it's on some of this
24 slide right here.

25 For the current fuel designs which consist

1 of uranium oxide or a mixed uranium-plutonium oxide
2 within zirconium alloy cladding, 50.46 defines these
3 specific performance requirements and analytical
4 requirements based upon our extensive experimental --
5 our empirical database.

6 For new designs, additional research may
7 be necessary to identify all degradation mechanisms
8 and any unique features. New performance objectives,
9 analytical limits, and analytical requirements would
10 need to be established based upon the research
11 findings on any new fuel design.

12 CHAIR ARMIJO: And I just want to know how
13 much flexibility do you have with current fuel designs
14 and current fuel cladding materials? For example, you
15 have a ZIRLO and an optimized ZIRLO, and maybe
16 there'll be in the future a really super optimized
17 ZIRLO. It's basically a zirconium-based alloy with
18 some tweaking. Would that fall under your current fuel
19 design definition, or would you consider that a new
20 fuel design?

21 MR. CLIFFORD: We have guidance which has
22 been developed which addresses how do you validate
23 that a new zirconium alloy falls under the umbrella of
24 what has been tested in the past.

25 CHAIR ARMIJO: Okay.

1 MR. CLIFFORD: So, there would be a
2 required test program for any new zirconium alloy to
3 either define new analytical limits, or to show that
4 it falls under the umbrella of the previous extensive
5 zirconium database.

6 CHAIR ARMIJO: Okay.

7 MR. CLIFFORD: And that's provided in a Reg
8 Guide. And Michelle will be discussing that later on
9 somewhere.

10 CHAIR ARMIJO: All right.

11 MEMBER REMPE: And there's guidance if
12 someone comes in with something totally different to
13 help them start, because basically you're saying new
14 performance objectives limits and requirements will
15 need to be established based on the research that a
16 new design would come in, and how would they interact
17 to -- could you elaborate on how they'd interact to
18 come up with the new requirements like some of these
19 ceramic cladding --

20 MR. CLIFFORD: Right.

21 MEMBER REMPE: -- that are being proposed?

22 MR. CLIFFORD: That's a great question. We
23 can't define what the performance objective is for a
24 new material without first testing the new material.

25 MEMBER REMPE: Right.

1 MR. CLIFFORD: And we can't define what the
2 analytical limit on temperature may or may not be to
3 insure that you meet your performance objective until
4 you've actually tested the material. So, it's almost
5 impossible to write -- the guidance would be just so
6 general.

7 I think what we would expect is they would
8 look at the guidance for zirconium, and they would
9 follow the logic on what was done, how it was
10 interpreted, how you defined your performance metric,
11 and then how you defined analytical limits to insure
12 that you met your performance objective.

13 CHAIR ARMIJO: But they'd have the
14 obligation to look for degradation mechanisms that are
15 different than existing zirconium alloys. They'd have
16 to look for something that's unique to their
17 particular material.

18 MR. CLIFFORD: Exactly, because our tests
19 are set up to measure ductility. Like I said, ceramic
20 you wouldn't have ductility, so you wouldn't even -- I
21 mean, you would never use those tests specifically.
22 But the concept of how do I insure that the fuel
23 performs in an acceptable manner, you would have to
24 define what an acceptable manner is; whether it's a
25 retention of fission gas, the retention of fuel

1 pellets, or an overall coolable geometry. And then you
2 would have to show that you maintained temperatures
3 below whatever limit you define based on your
4 experiments to insure that you maintain that
5 acceptable behavior. And that's really what's meant
6 by truly performance-based.

7 MEMBER SHACK: But, I mean, they would have
8 to develop all that information.

9 MR. CLIFFORD: Yes.

10 MEMBER SHACK: Then you would have to write
11 a new section of the rule.

12 MR. CLIFFORD: Absolutely.

13 MEMBER SHACK: You're going to --

14 MR. CLIFFORD: Absolutely. You can see from
15 this slide in Paragraph G we're defining the specific
16 requirements to maintain, for one particular instance,
17 ductility for zirconium, and all the analytical limits
18 associated with temperature to preserve ductility. But
19 Paragraphs H, I, and J are reserved, so if someone
20 came in with a ceramic cladding then we would have to
21 work through their experimental database, maybe run
22 confirmatory testing, develop the regulatory envelope
23 around which we would license the new fuel, and how it
24 behaved under LOCA conditions, and then define
25 analytical limits and then go to rulemaking.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIR ARMIJO: Okay.

2 MR. CLIFFORD: In the next section I will
3 walk through the rule language and discuss the
4 regulatory and technical basis of each paragraph.

5 Paragraph (a). As I mentioned earlier, one
6 of our objectives was to expand the applicability and
7 to make the rule universally applicable to all ECCS
8 system, and all fuel designs. This paragraph achieves
9 the objective to expand the applicability to all
10 plants, and especially to remove the burden of
11 Zircaloy or ZIRLO only. And this eliminate the need
12 for exemptions.

13 We issued dozens of exemptions for M5, and
14 more recently for optimized ZIRLO, so this change in
15 the structure of the rule will eliminate those
16 exemptions.

17 Paragraph (b) simply adds the definition
18 of breakaway oxidation which was new embrittlement
19 mechanisms identified by the LOCA research program and
20 included in this rule.

21 Paragraph (c) is the relationship to other
22 regulations. The first thing you'll notice is there's
23 gray text and there's black text. And I think was
24 also included in the rule language that was provided
25 to the ACRS staff.

1 Gray indicates that it's unchanged from
2 the current regulation. We may have moved it, but the
3 text itself is unchanged, so when you see anything in
4 gray that means it's the same as the current 50.46.
5 And all we did here was just to clarify that ECCS
6 valuation models must be approved by the Staff.

7 CHAIR ARMIJO: Okay.

8 MR. CLIFFORD: Paragraph (d) is the
9 Emergency Core Cooling System Design. These are the
10 principal design requirements for any ECCS system.
11 Section (1) of the paragraph defines these performance
12 objectives and states that all LWRs must satisfy these
13 performance objectives.

14 The two principal performance objectives
15 are that core temperatures remain below defined fuel-
16 specific analytical limits. And that the ECCS system
17 have sufficient capability to remove the decay heat
18 from long-lived radioactive isotopes.

19 Very general in nature, really it's very
20 general in nature but the specifics come when you
21 analyze the fuel, because you are judging the
22 performance of ECCS on how well the fuel holds up
23 under LOCA conditions.

24 Okay, item (2) of the section requires
25 that all licensees perform a compliance demonstration,

1 and that they're allowed to use either a realistic
2 model or an Appendix K model. And these requirements
3 are consistent with the current 50.46, as you can see
4 from the gray text.

5 Now, embedded in the analytical
6 requirements for ECCS are that --

7 CHAIR ARMIJO: Paul, just to go back. So,
8 when the licensee performs its performance
9 demonstration document or evaluation, does that --
10 will that be submitted to the Staff, reviewed and
11 approved by the Staff? And that's plant-specific?

12 MR. CLIFFORD: Absolutely.

13 CHAIR ARMIJO: Okay.

14 MR. CLIFFORD: Although you see the first
15 part of the paragraph is in black, so it's new.

16 CHAIR ARMIJO: Yes.

17 MR. CLIFFORD: It was always understood,
18 but it wasn't legally documented.

19 The next analytical requirement is that
20 factors which impact the predicted core geometry and
21 coolant flow be included in the evaluation model. And
22 these would be fuel-specific factors which would be
23 defined in subsequent sections.

24 CHAIR ARMIJO: Here's where I get confused.
25 We want to maintain coolable geometry.

1 MR. CLIFFORD: Yes.

2 CHAIR ARMIJO: But we don't have a measure,
3 a direct measure of what a coolable geometry is. So,
4 as a surrogate for that we use a ductility parameter.
5 And, first of all, is that really accurate what I just
6 said, or --

7 MR. CLIFFORD: Well, ductility is a
8 favorable material property that provides a level of
9 assurance that the fuel rods won't shatter during
10 quenching, and that the fuel rods and the fuel will
11 stay as they were. They're in a geometry which is, I
12 shouldn't say simple, but I'm going to use the word
13 simple to model and to analyze, and to demonstrate
14 with high confidence that you can show that
15 temperatures stay below 2200 degrees. So, any change
16 in that geometry would introduce a lot of uncertainty
17 into your compliance demonstration. So, by
18 maintaining ductility you're saying that you're
19 maintaining rods in their existing rod lattice array,
20 and that that rod lattice array can be shown with high
21 confidence to be coolable.

22 CHAIR ARMIJO: But having some fuel
23 fracture break, there's got to be an acceptable amount
24 of damage to the core while it's still very coolable,
25 but you don't have a position on that. You just --

1 MR. CLIFFORD: No, this paragraph basically
2 says that if you predict any changes in geometry, and
3 I can give you two examples for current fuel designs.
4 The first would be if because the RCS pressure is
5 dropping so quickly and you have high rod internal
6 pressure and the cladding temperatures are getting
7 high, you creep out, and you balloon and burst fuel
8 rods. You have to specifically model the fuel that
9 balloons and bursts, and that would be dictated in a
10 subsequent fuel-specific.

11 Another example would be that if the loads
12 applied to the structure of your fuel assembly were to
13 cause degradation; in other words, you were to break
14 grid straps and the fuel rods would -- the fuel rod
15 lattice array would deform, then you would need to
16 specifically model that.

17 CHAIR ARMIJO: Okay, let's --

18 MR. CLIFFORD: So, you are taking that into
19 account.

20 CHAIR ARMIJO: If someone says okay, look,
21 during the quench there's enough either bending
22 stresses or tensile stresses on the assembly that --
23 and this is already oxidized cladding. I'm going to
24 break the cladding in let's say the peak temperature
25 region, and I'm going to break some of the rods. I

1 don't know how many but let's pick a number, and they
2 -- but it breaks and the pellets don't fall out. I
3 mean, it's just not a double-ended guillotine where
4 pellets pour out, but it just simply breaks, but the
5 geometry is maintained.

6 Now, if they came to you with an analysis
7 showing hey, that's the worst that can happen, what
8 then? Do they have to do that, or do they -- or do you
9 say I really don't care as long as you have adequate
10 ductility in your cladding?

11 MR. CLIFFORD: Well, we've done some
12 research where we tried to evaluate or quantify the
13 mechanical properties in the balloon burst region, for
14 instance. And at the end of the day, we're
15 maintaining the same regulatory approach or regulatory
16 position that it's difficult to quantify all of the
17 stresses of loads that are applied on fuel during a
18 LOCA. So, if you were trying to say that only so many
19 rods would break, you would then have to truly
20 understand all the loads that could be applied during
21 a LOCA.

22 You can't have a strength-based criteria
23 unless you understand what the strength requirements
24 are. But we fall back to ductility because it's a
25 favorable property that provides a high level of

1 confidence that --

2 CHAIR ARMIJO: You'll never get a
3 metallurgist to argue against ductility, but what
4 we're just trying to get a sense of --

5 MEMBER SHACK: But looking at it here, I
6 mean, your high level requirement is, in fact, your
7 coolable geometry.

8 MR. CLIFFORD: Correct.

9 MEMBER SHACK: For the Zircaloy alloys your
10 specific requirement is the ductility requirement,
11 which certainly does insure the coolability. You could
12 argue that it also provides some defense-in-depth;
13 that is, it's certainly possible to make arguments as
14 Sam did that even if you lost ductility, you wouldn't
15 have lost coolable geometry. But as you say, that's
16 a much more complex argument. But that is one level
17 down from the rule. The rule high-level requirement as
18 I see is coolable geometry.

19 MR. CLIFFORD: But then we specific that
20 fuel-specific is ductility.

21 MEMBER SHACK: Right. The fuel-specific is
22 ductility.

23 MR. CLIFFORD: So, if someone wanted to
24 come in and say we're not going to maintain ductility,
25 but we're going to alter our performance metric, then

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that would be either -- that would be an exemption.
2 You'd have to issue an exemption.

3 CHAIR ARMIJO: They'd have to --

4 MR. CLIFFORD: The burden of proof would be
5 on them --

6 MEMBER SHACK: Right.

7 MR. CLIFFORD: -- to demonstrate why that
8 was acceptable.

9 CHAIR ARMIJO: Why this is coolable even
10 though their ductility isn't 1 percent, it's half a
11 percent.

12 MR. CLIFFORD: Right.

13 CHAIR ARMIJO: Or some other number. Okay.

14 MR. CLIFFORD: This paragraph provides the
15 analytical requirement related to identifying the most
16 limiting combination of break size and location. It
17 remains largely unchanged from the current regulation.

18 New text has been added to clarify that
19 the existing requirements, that the demonstration must
20 cover the entire duration of the transient.

21 This paragraph simply provides a pointer
22 to the new analytical requirements for current fuel
23 designs from subsequent paragraphs.

24 Section (3) under Paragraph (d) is largely
25 unchanged. Essentially, we move the documentation

1 requirements from Appendix K into the main body of the
2 rule so that they would be applicable to both Appendix
3 K and realistic models. And the last section here is
4 a pointer to the implementation schedule.

5 CHAIR ARMIJO: Okay.

6 MR. CLIFFORD: Paragraph (g) specifies
7 performance requirements and analytical limits used to
8 judge ECCS performance for current fuel designs. And
9 those current fuel designs are uranium oxide or mixed
10 uranium-plutonium oxide within cylindrical zirconium
11 alloy cladding.

12 Peak clad temperature is the first of five
13 fuel temperature analytical limits associated with the
14 ECCS principal performance objective in Paragraph
15 (d)(1)(i) which is to maintain an acceptable core
16 temperature. So, we've defined five temperature
17 requirements under the heading of acceptable core
18 temperature.

19 With respect to PCT, research confirmed
20 that there is rapid embrittlement above 2200, so the
21 2200 degree upper limit is being maintained. PCT also
22 prevents runaway oxidation in high temperature failure
23 but is governed by cladding embrittlement based upon
24 the research findings.

25 Paragraph (g)(II), Cladding Embrittlement.

1 This paragraph defines the preservation of cladding
2 ductility as a performance objective. It is consistent
3 with the current regulatory requirements. This
4 paragraph captures the research finding which is a new
5 embrittlement mechanism that was referred to as
6 hydrogen-enhanced beta-layer embrittlement. This
7 paragraph requires the use of an approved analytical
8 limit on PCT and integral time at temperature based on
9 an approved experimental technique.

10 The Staff has developed Reg Guides which
11 provide acceptable analytical limits for licensees who
12 do not want to run further testing on the current
13 zirconium alloys. In addition, the Staff has developed
14 a Reg Guide which provides an acceptable experimental
15 technique for conducting post-quench ductility tests
16 if they choose to refine the Staff's analytical
17 limits, or for newer alloys.

18 Paragraph (iii), Breakaway Oxidation. This
19 paragraph captures the new embrittlement mechanism
20 identified by the high-burnup LOCA research program.
21 It requires the use of approved analytical limits on
22 breakaway oxidation based upon an approved
23 experimental technique. And we have developed a Reg
24 Guide which provides an acceptable experimental
25 technique for defining analytical limits for each

1 zirconium alloy.

2 Paragraph (iv), Maximum Hydrogen
3 Generation. This paragraph limits the generation of
4 combustible gas, which in the case of zirconium is --
5 the zirconium water reaction is hydrogen, and remains
6 unchanged from the current regulation.

7 CHAIR ARMIJO: For some reason this is not
8 in gray.

9 MR. CLIFFORD: Oh. I'm not sure why it's
10 not in gray. It's word-for-word. Oversight.

11 CHAIR ARMIJO: That's okay.

12 MR. CLIFFORD: The last fuel temperature
13 analytical limit relates to long-term cooling. The
14 current 50.46(b)(5) paragraph states, "After any
15 calculated successful initial operation of the ECCS,
16 the calculated core temperature shall be maintained at
17 an acceptable low value and decay heat shall be
18 removed for the extended period of time required by
19 the long-lived radioactive activity remaining in the
20 core. However, there are no performance requirements
21 or analytical limits which defines acceptably low
22 value."

23 For 50.46c, the working group has decided
24 to use the preservation of cladding ductility as the
25 performance metric, same as during the initial stages

1 of the LOCA. The Federal Register Notice includes
2 specific requests for comment on this topic.

3 CHAIR ARMIJO: Has anyone satisfied that
4 requirement, as far as you know? Is it currently
5 satisfied?

6 MR. CLIFFORD: In some of the analysis that
7 I'm familiar with, it's done differently. They're
8 concerned about boron precipitation and how it affects
9 the circulation. But generally if you look at long-
10 term cooling, they show that the core liquid level --

11 CHAIR ARMIJO: Is covered.

12 MR. CLIFFORD: The core is covered.

13 CHAIR ARMIJO: Okay.

14 MR. CLIFFORD: And they do heat balance to
15 show that the rate of circulation matches or exceeds
16 boil-off. This would require that they define a
17 temperature which is associated to a favorable
18 material property. Here we're saying ductility, we're
19 maintaining the ductility theme. And we've asked
20 questions of whether this is -- is this the right
21 performance metric for long-term cooling? Should we
22 be looking at some other performance metric? Is there
23 an analytical limit already established? Has the
24 industry already done testing which has defined a new
25 analytical limit for long-term cooling?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIR ARMIJO: Well, if you went back to
2 your figure where you show the LOCA transient.

3 MR. CLIFFORD: Sure.

4 CHAIR ARMIJO: And you get out to those
5 500-600 seconds, okay, that one there. And now your
6 clad temperature is down to what, somewhere around
7 1,000, but it's already been embrittled due to
8 transient, but it's been demonstrated that the
9 cladding ductility is acceptable at that point.

10 Now, it just keeps -- it's still being
11 cooled, and the core is covered. Isn't that sufficient
12 for a definite period of time? I mean, is there any
13 other mechanism going on that the embrittlement
14 precedes?

15 MR. CLIFFORD: In general, when you bring
16 a material up in high temperature, especially when you
17 go above your phase transition temperatures, and then
18 you quench it rapidly, you freeze the micro structure
19 in a non-equilibrium condition. And it generally has
20 strength but it lacks ductility.

21 If you then subsequently age the material,
22 you generally improve ductility as you're allowing the
23 micro structure to change. But that's general. We
24 don't have specific tests where we've heated up
25 cladding, quenched cladding, and then gone through

1 subsequent heat up cycles to find out if there is some
2 other mechanism that's occurring which is affecting
3 ductility. We don't have those tests.

4 There are tests out there where they've
5 taken cladding and they've put it in an autoclave
6 under steam environment for a long period of time, and
7 they're looking for really corrosion properties. Is
8 there nodular corrosion that's occurring? Is there
9 hydrogen uptake that's occurring, and how that affects
10 ductility. But that's a different embrittlement
11 mechanism than simply oxygen ingress into the micro
12 structure.

13 CHAIR ARMIJO: This is so diffused, so how
14 can anyone meet that requirement, though, Paul? Are
15 you -- right now this is just something going out for
16 comment? Is it something that the Staff feels yes,
17 we've got to have some requirements there for that?

18 MR. CLIFFORD: We believe there needs to be
19 -- in a true performance-based rule, you have to
20 define what you're trying to protect. What's the
21 performance metric, and then how do you achieve that
22 metric?

23 Right now, the rule just says an
24 acceptably low temperature, but it doesn't say what an
25 acceptably low temperature is. It's understood -- it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 was understood that you go through a quench,
2 temperatures continue to go down and you stay at a
3 very low temperature, close to normal operating
4 temperatures like 700 degrees Fahrenheit. But it's not
5 written down that way.

6 So, in theory you could have a second, I
7 shouldn't say transient, but if you have boron
8 precipitation concerns and you have to change your
9 injection point, maybe you have a small heat up that
10 occurs during cold-leg to hot-leg injection swap-over
11 and what's an acceptable temperature for them to then
12 escalate to during that operation or maneuver?

13 CHAIR ARMIJO: But let me just --

14 MR. CLIFFORD: It's just not defined.

15 CHAIR ARMIJO: -- make it real simple.
16 Let's say you finish up at 500 seconds. Your clad
17 temperature is down -- back down to about 1,000
18 degrees F, and it sits there for 70 hours, 100 hours
19 long-term, aren't you finished, or do you have to do
20 more testing? I mean, what's --

21 MEMBER SHACK: Well, suppose we had
22 something like that we talked about yesterday where
23 they're going to be switching the boron injection and
24 they've got three minutes to do it, so it doesn't heat
25 up again. And the three minutes I think is determined

1 on 2200 F, and the question is --

2 CHAIR ARMIJO: They see themselves going up
3 again?

4 MEMBER SHACK: Yes.

5 CHAIR ARMIJO: Cycling between --

6 MEMBER SHACK: Because you're turning off
7 the coolant.

8 CHAIR ARMIJO: Okay.

9 MEMBER SHACK: And it's going to heat up.
10 And you say it's going to do your -- so you have a
11 limit of three minutes. I don't know, if they do it in
12 two minutes it gets to 1600 F or something. And
13 they're going to do that every 16 hours.

14 CHAIR ARMIJO: I could see that, you know,
15 where you're actually raising the temperature back up
16 again or thermally cycling it, or doing something that
17 changes the cladding temperature dramatically in the
18 wrong direction. But just if they -- if it just sits
19 there and --

20 MR. CLIFFORD: If it sits at a low
21 temperature everybody believes it's going to be fine,
22 but it's this perturbation --

23 MR. LANDRY: Paul, this is Ralph Landry
24 from NRO. The plant will not come down to 1000 degrees
25 in a large-break LOCA and then just sit there. This is

1 the point at which quench is going to occur, and the
2 temperature of the cladding is going to drop down to
3 about 200 degrees. This curve just ends at this
4 point. This isn't going through the full quench.

5 Now there's going to be a full quench, and
6 what we're concerned about is codifying what is not in
7 the regulation today with regard to long-term cooling
8 that has come out through the GSI-191 resolution
9 program. And there when -- even though you've
10 quenched the core and the core is covered, the core is
11 not covered water solid. There's still two-phase
12 mixture and there's still boiling going on in the core
13 during this long-term period.

14 And our concern with GSI-191 was that you
15 not reheat the core beyond the point at which there
16 were data that showed the cladding would not be
17 further embrittled. That's where the 800 degree
18 Fahrenheit number came from.

19 When we talked about putting that in this
20 regulation, we realized that the data supporting that
21 800 degrees were proprietary, so we could not put into
22 the regulation proprietary information. So, that's
23 why we came up with the wording that we have in this
24 paragraph, that you have to come in with a supportable
25 number for the reheat up of a core if you get blockage

1 or any reason that impedes your long-term cooling of
2 the core.

3 Today the plants through the GSI-191
4 program are being shown to meet the stated goals, but
5 we wanted to codify it in the regulation now instead
6 of a simple statement provide long-term cooling. Does
7 that help explain what's behind this?

8 CHAIR ARMIJO: I think I understand it and
9 I just have to wait and see what the public comments
10 are on this thing. It's hard for me to understand
11 that -- a rule where really there's no specific or
12 demonstrated way of saying you've satisfied that rule.

13 For example, in this particular event it's
14 still not down to 200 or it's not down to boiling at
15 one atmosphere. But if it -- unless it goes up in
16 temperature over where it is at the end of the
17 transient, shouldn't you be finished? Isn't that
18 enough? And I get the feeling that you don't really
19 know that you're finished, that you've satisfied the
20 requirements.

21 MR. CLIFFORD: Well, I mean, the
22 requirement is that you're able -- the ECCS has a
23 capability of a removing heat for a long period of
24 time because you have decay heat that goes out --

25 CHAIR ARMIJO: Right, but it's --

1 MR. CLIFFORD: -- 30 days or beyond, so
2 you need to show that you can maintain recirculation
3 and remove the heat out to 30 days or beyond. And if
4 there is a subsequent heat up for whatever reason,
5 there has to be a codified performance metric. Why is
6 it acceptable to go back to 1,000 degrees? Why is it
7 acceptable to go to 1,200? Why is it acceptable to go
8 back to 2,200? We don't think 2,200 is the right
9 number, that you shouldn't have --

10 (Simultaneous speech.)

11 CHAIR ARMIJO: No, you're not going to get
12 an argument with me on that, but I'm just -- and I can
13 see situations where actually the clad temperature
14 increases again. You know, that's an undesirable thing
15 because it's already in a poor state. But if you're
16 actually -- you've stabilized temperature and it's
17 either constant or dropping, when are you finished,
18 and what's an acceptable answer to this --

19 MR. CLIFFORD: I believe right now it's 30
20 days.

21 CHAIR ARMIJO: Okay. So, if you maintain
22 temperature at or below the temperature at the end of
23 the transient for 30 days, you're finished?

24 MR. CLIFFORD: Well, you're trying to
25 maintain inventory in your --

1 CHAIR ARMIJO: Of course, you --

2 MR. CLIFFORD: Temperature is down and you
3 match boil-off rates, so you're always keeping it cool
4 and keeping it covered. That's what --

5 CHAIR ARMIJO: Okay. Well, look, I've got
6 to think about it some more, but I think that helps.

7 MEMBER SHACK: But coming back to Ralph's
8 thing, you then have a requirement for the maximum
9 temperature that it can reach during that 30 days as
10 part of the GSI-191?

11 MR. LANDRY: That was the performance
12 metric that we used during the review of the WCAP on
13 core blockage because that was the only performance
14 metric that we had that was supported by data. Now, we
15 didn't say that it would be impossible to support
16 going to a higher temperature than 800. There were
17 just no data that showed that you could support a
18 higher temperature. And during some of the
19 discussions on the WCAP-16793 resolution we had said
20 you want to go for a higher temperature, you have data
21 to support it. And these were the only data that
22 supported that temperature so we said okay, that's the
23 limit.

24 MR. CLIFFORD: And you're probably going to
25 have a different embrittlement mechanism which is

1 probably going to be nodular corrosion as opposed to
2 the 2,200 which is different.

3 MR. LANDRY: And that's what we're saying
4 in the rule, this proposed language. Come in with
5 supportable analytical basis.

6 CHAIR ARMIJO: Okay.

7 MR. LANDRY: That's what makes it
8 performance-based.

9 MR. CLIFFORD: Right.

10 MEMBER REMPE: Is the 30 days specified
11 somewhere in a Reg Guide, or where did that come --
12 where does that show up at?

13 MR. CLIFFORD: Ralph, do you know the
14 historical basis for the 30 days?

15 MR. LANDRY: I'm sorry?

16 MEMBER REMPE: Where is the 30 days
17 specified, is it in a Reg Guide, or where would they
18 find the time?

19 CHAIR ARMIJO: Could you repeat that?

20 MEMBER REMPE: Well, there's been mention
21 of 30 days, and I just wondered where that was
22 documented.

23 MR. LANDRY: It's not in the regulation.

24 MEMBER SHACK: Is it Reg Guide 1.82?

25 MR. LANDRY: It could be in 1.82. I'm

1 trying to recall where that number comes in. It's
2 like one of those urban legends.

3 MR. RULAND: Could we do -- we'll do some
4 research on that --

5 CHAIR ARMIJO: Okay.

6 MR. RULAND: -- and try to -- and provide
7 an answer subsequent. Okay, Tara?

8 CHAIR ARMIJO: Thanks, Paul.

9 MR. CLIFFORD: Okay. The next Paragraph
10 (g) (2) defines the fuel-specific analytical
11 requirements for the current generation of fuel. The
12 first item captures the research finding that oxygen
13 ingress from the cladding ID surface promotes cladding
14 embrittlement and reduces the allowable time at
15 temperature to nil ductility. And the way it's worded
16 it really is performance-based. If you can show
17 there's an oxygen source, you must consider it.

18 The second fuel-specific analytical
19 requirement relates to crud and oxide layers, and the
20 effect on initial stored energy. The addition of this
21 paragraph achieves one of the rulemaking objectives
22 which is to address the petition we received from the
23 public.

24 Paragraph (k), Use of an NRC-approved fuel
25 in the reactor. This paragraph clarifies the existing

1 requirement on use of NRC-approved fuel designs for
2 which specific ECCS performance requirements have been
3 established and demonstrated. It also recognizes the
4 importance of lead test assemblies for collecting
5 irradiated data to support the NRC review and approval
6 of new fuel designs.

7 Paragraph (l), Authority to impose
8 restrictions on operation. This paragraph is not new,
9 but it has been expanded to identify that there is two
10 offices within the NRC, the NRR which affects Part 50
11 licensees, and NRO which addressees Part 52 licensees.

12 Paragraph (m), Reporting. The language in
13 Paragraph (m) has been significantly upgraded from the
14 existing regulation. However, there's been no change
15 in the intent or the requirements of this section.
16 What we were trying to accomplish is to clarify the
17 existing requirements because this has been a source
18 of confusion in the past.

19 Paragraph (m)(2), with respect to
20 reporting the definition of a significant error or
21 change to an evaluation model has been expanded to
22 include 0.4 percent ECR as a threshold in addition to
23 the existing 50 degree Fahrenheit change in peak clad
24 temperature.

25 CHAIR ARMIJO: What is the basis for that

1 0.4? Why isn't higher, why isn't it lower?

2 MR. CLIFFORD: 0.4 equates to roughly a
3 change of 50 degrees Fahrenheit up at around 2,100
4 degrees Fahrenheit. If you were to change --

5 CHAIR ARMIJO: For any zirconium-based
6 alloy?

7 MR. CLIFFORD: Correct.

8 CHAIR ARMIJO: Okay.

9 MR. CLIFFORD: The thought here was if you
10 change something in the evaluation model which
11 resulted in prolonging the transient but not
12 necessarily changing the peak clad temperature,
13 previously we wouldn't be able to evaluate that. But
14 by providing both a peak clad temperature and a
15 integral time at temperature that you would capture
16 changes which would affect both the peak and the
17 prolonged nature of the transient.

18 CHAIR ARMIJO: And the way it's written
19 right now in the rule, this 50 degrees at the .4 ECR
20 would not only be a single change, but an accumulation
21 of changes over time.

22 MR. CLIFFORD: It's the absolute --

23 CHAIR ARMIJO: In the original analysis, I
24 guess.

25 MR. CLIFFORD: Some of the absolute

1 changes. So, if you had a -20 degree Fahrenheit change
2 and a +40 degree change because you discovered two
3 errors then that would be beyond a summation of the
4 absolutes, so it would be more than 50, even though if
5 you added them directly it would be 20. And that's the
6 way the current regulation is working.

7 CHAIR ARMIJO: And the purpose of that
8 reporting is to find out that there's some
9 deficiencies in the way the thing is modeled, or that
10 the material really is much more susceptible to
11 fracture than you believed.

12 MR. CLIFFORD: No, the report requirements
13 are not related to the material performance. It's
14 really related to the analytical models that are being
15 used to simulate the LOCA. It's a way of, in a sense,
16 controlling changes to the models. If they're
17 discovering small errors, we want to know about them,
18 but we don't need to know about them right away. But
19 if they're finding that they made an error in their
20 calculations that's significant, we want to know about
21 it right away.

22 CHAIR ARMIJO: Even if it's in a favorable
23 temperature direction?

24 MR. CLIFFORD: Even if it's in a favorable
25 temperature -- what's favorable?

1 CHAIR ARMIJO: Well, lower temperature is
2 favorable.

3 MR. CLIFFORD: But if it was a lower
4 temperature and then they next cycle increased power
5 to take advantage of that, we would want to know about
6 that.

7 CHAIR ARMIJO: Okay, I'll think about that.
8 I'm just trying -- the purpose of this thing is to see
9 if something is going wrong. That's what I thought
10 that reporting thing -- requirement was, not whether
11 somebody has done something favorable and will later
12 want to take advantage of that, and would come to you
13 with a proposal and say look, we found that peak clad
14 temperatures because of this widget are going to be
15 much, much lower. And we want to take advantage of it
16 for fuel economy, or some other reason. I would think
17 that would be a separate kind of a proposal; whereas,
18 the idea here in this reporting is to spot anything
19 that's going wrong either over time or in let's say
20 one significant change, or finding. But I get the
21 feeling that this is mixed up with a lot of other
22 issues, this requirement.

23 MR. CLIFFORD: No.

24 MR. LANDRY: Paul, this is Ralph Landry
25 again, if I can help out.

1 CHAIR ARMIJO: Yes, Ralph.

2 MR. LANDRY: The reporting requirement in
3 the rule today has been a very misunderstood
4 requirement, and it has been subject to a number of
5 cases of misinterpretation and misunderstanding over
6 the years.

7 Because the purpose of the rule is to say
8 that if you have a cumulative change or some absent
9 value, so you can't offset yourself 50 degrees, that
10 indicates that you've made some pretty big differences
11 and big changes in your analytical models. Whether
12 they're errors, or changes in the models, you've made
13 some pretty big changes if you're seeing that much
14 change in temperature, and you have to notify us. You
15 have to let us know that you have a change of this
16 amount. And then you have to tell us what are you
17 going to do, give us a schedule, what are you going to
18 do with regard to this change?

19 Now, what we've done with adding the
20 oxidation change is said a big part of this rule
21 revision is due to an understanding of oxidation
22 phenomena which are occurring with burnup. That makes
23 the oxidation phenomena as important now as simple
24 temperature has been in the past. So, we want to know
25 if you see a big change in oxidation, relatively big

1 compared to the -- about the same relative sizes with
2 temperature. If you're seeing that much change in your
3 predicted oxidation we want to know that, too. Not
4 just temperature, it's not temperature and oxidation,
5 it's either/or.

6 CHAIR ARMIJO: Okay. Well --

7 MR. LANDRY: So, this is to tell us -- this
8 is to make us aware are you making changes that are of
9 a significant magnitude that we need to be aware of
10 them. Otherwise, you report them annually.

11 CHAIR ARMIJO: Okay.

12 MR. LANDRY: Everyone has to report
13 annually changes.

14 CHAIR ARMIJO: Let me give you an example.
15 Let's say you have a best estimate model and your peak
16 clad temperature is 1600 F, and it's got a lot of
17 assumptions even in a best estimate model, and they've
18 done some testing. They found that a lot of those
19 conservatisms were really excessive, and they
20 calculate now that they can -- the real peak clad
21 temperature is now 1600. The time at temperature
22 hasn't been extended so there's no real significant
23 change in ECR. If anything, it's reduced; all
24 favorable. Now, to me that's good news. And why is
25 that reportable?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. CLIFFORD: Well, it's --

2 MR. LANDRY: It's reportable because you've
3 made a significant change. It's not that you've gone
4 to a lower temperature and you were going to do
5 something about it. It's that you've made enough
6 change that we deem is a significant change, and we
7 want to know why we see the significant change. What
8 are you doing that's causing it?

9 MR. RULAND: The -- actually, we've been
10 looking at this particular reporting section in 50.46
11 over the past couple of weeks associated with the
12 thermal degradation issue that you might have heard
13 about.

14 CHAIR ARMIJO: Yes.

15 MR. RULAND: And we went back and looked at
16 the Statements of Consideration for this particular
17 part of the rule, and the Statements of Consideration
18 speaks to a generalized notion that maybe there's
19 something -- maybe there's a more generalized problem
20 with the way the particular vendor or licensee deals
21 with their models. So, if you see a number of
22 different changes it's an indication to us that maybe
23 there's something we need to look at. So, if there's
24 a whole host of different changes, what's going on and
25 alerts the staff, and we can go out and we can get

1 some information about it, and examine it.

2 Maybe there's no problem, but it's just a
3 way to alert the staff that some significant changes
4 are going on in the model, and maybe it's something we
5 need to look at.

6 MR. CLIFFORD: And another way to think
7 about it is, it's a way of controlling the analytical
8 models. They're very large, very complex models and
9 they require extensive NRC review and approval. So, if
10 they were to identify an error and then correct that
11 error on their own and say okay, temperatures went
12 down 300 degrees, we would want to review that model.
13 We will want to be notified that they found a
14 significant change in their algorithms and that it
15 resulted in a significant change in consequences, so
16 we would want to review that. So, they would then
17 have to submit it and let us know. But if it changed
18 by -- if it only changed by 10 degrees then we don't
19 want to be bothered with a formal review if it's only
20 a 10 degrees correction.

21 CHAIR ARMIJO: But separate from this
22 regulation, you approve these models that they use.
23 Right?

24 MR. CLIFFORD: They're all NRC approved.

25 CHAIR ARMIJO: They're all NRC approved, so

1 isn't the change requirement appropriate within that
2 approval process rather than in this regulation? I
3 could see this regulation wanting to trigger
4 notification if there were significant increases in
5 PCT or significant increases in calculated time at
6 temperature which is in the wrong direction from a
7 safety standpoint, but just change because things are
8 changing within a model, it seems to me that's --

9 MR. CLIFFORD: Right.

10 CHAIR ARMIJO: -- easily handled within
11 the approval process of analytical models, that you
12 want to keep track of what's going on.

13 MR. CLIFFORD: I understand. And if you
14 read the section, we define -- we broke it up into
15 several paragraphs, and it kind of follows a logic.
16 The first one is, okay, if you find an error or
17 discover a change then -- discover an error or make
18 a change, and the results are beyond the acceptance
19 criteria, beyond 2200 --

20 CHAIR ARMIJO: Sure.

21 MR. CLIFFORD: -- we need action to bring
22 the plant back into compliance, so that's the first
23 variability on this, is that you're beyond your
24 acceptance criteria, your fuel is not going to behave
25 in an acceptable manner, take immediate actions.

1 The next one is you find a change and the
2 change results either positive or negative, a
3 significant difference than what the NRC last
4 reviewed. And we want to know about it, and we want
5 you to revise your analysis and then submit it to us
6 so we can review it, because we may not agree.

7 You may say well, it went down 300
8 degrees, but when we look at it we said oh, no, no, it
9 didn't go down 300 degrees, it only went down 100
10 degrees. We hadn't reviewed it yet, so we need to be
11 notified of the change, and then there needs to be a
12 schedule for submitting the new analysis.

13 And then the next potential is that it's
14 only a minor correction. It's a little tiny
15 correction, and in that case we don't need to review
16 the model. We don't need to be notified right away,
17 just on an annual basis they would say we made a
18 correction to the model. It wasn't -- it didn't
19 change significantly either way.

20 So, the second two which don't involve
21 plant safety are really a way of controlling the
22 approval or maintaining the approval of the model
23 itself.

24 CHAIR ARMIJO: Well, I can see what you're
25 trying to do, but it just seems like this isn't the

1 regulation in which you should do it. It's in the
2 approval of the models and the maintenance of the
3 models, and things like that. But, you know, let's
4 just go on, because I think I understand.

5 MR. MIZUNO: This is Geary Mizuno from the
6 Office of General Counsel for the NRC. And I wanted
7 to just address the legal aspect of whether a licensee
8 and, in fact, the fuel vendor is required to report
9 these changes.

10 Simply as a result of the NRC Staff's
11 approval, as I understand it, these -- the approvals
12 are typically not done by the licensee. They're done
13 on a vendor-specific basis. And the -- in that
14 situation where we're not having a licensing action,
15 okay, one could argue that there is no legal basis for
16 us to impose a -- the kind of approval scheme -
17 sorry - reporting scheme that you're talking about.
18 That is to avoid any legal issue with respect to
19 whether we have the authority to request information
20 regarding these changes, subsequent changes.

21 The regulation has that reporting scheme
22 directly in it, and it makes no difference ultimately
23 who -- how we approve the model. It puts the licensee
24 in the position of having to report to us.

25 And, again, I'll just repeat for the

1 Staff. We're not saying that a change is bad. The
2 reporting requirement is there so that the NRC Staff,
3 in particular, is aware of the change so that they can
4 review it. If they find that there is no problem with
5 it, there is not going to be any further action.

6 You just have to understand that the
7 reporting requirement is there so that the NRC Staff
8 has the ability to decide whether it needs to look
9 into it further, and based upon their evaluation,
10 inspection, audit, whatever it may be, if additional
11 regulatory action is necessary, then they will take
12 it. That's typically the reason why you have reporting
13 requirements.

14 CHAIR ARMIJO: Okay, I understand what
15 you're saying, so why don't we just move on.

16 MEMBER SHACK: Well, I'll just note the
17 current reporting requirement I can see. This
18 certainly clarifies the current reporting requirement
19 where it wouldn't be so clear that a favorable change
20 would have to be reported even if it was significant.
21 So, I mean, that is a substantive difference between
22 the two reporting requirements.

23 MR. CLIFFORD: Right. And it's not a
24 change, it really is a clarification.

25 MEMBER SHACK: It's a -- whether it's a

1 change or a clarification, that's for --

2 CHAIR ARMIJO: The lawyers --

3 MEMBER SHACK: -- regulators and lawyers
4 to decide. But it's certainly different.

5 CHAIR ARMIJO: Yes. Well, you know, I'm
6 going to have to do some more homework on it. When
7 you writing a licensing topical report with an ECCS
8 model and you get it approved by the Staff, I don't
9 know if in the current approvals there are
10 notification requirements of errors or changes.

11 MR. RULAND: Maybe this will help. When we
12 do a vendor topical report and review it, that is not
13 a licensing action. It is a -- basically, a
14 gentleman's agreement that we have approved this
15 topical report for use, but that's it. It doesn't
16 become a licensing action until a licensee actually
17 submits a license amendment request and then it's
18 incorporated, or there's a technical specification
19 that needs to refer to a particular topical report.
20 So, there's -- a topical report is, like I said, not
21 a licensing action, and I think that probably goes to
22 what --

23 CHAIR ARMIJO: That makes me even more
24 confused, Bill, but I appreciate it. It's a matter of
25 fact, and I appreciate your telling me that.

1 MR. RULAND: Okay.

2 MR. CLIFFORD: Okay, the next Paragraph
3 (m)(iii). This is a new reporting requirement which
4 has been added for measured breakaway oxidation. This
5 cycle-specific reporting requirement is necessary to
6 insure that cladding alloy's susceptibility to
7 breakaway oxidation has not been inadvertently
8 affected due to either planned or unplanned changes in
9 fuel fabrication.

10 CHAIR ARMIJO: Well, here's another one
11 where I have a big problem; and that is, because this
12 is technical, this is not regulatory language or --
13 but let's defer that discussion until we talk about
14 the Reg Guides and the findings of your audit.

15 MR. CLIFFORD: Okay.

16 CHAIR ARMIJO: Because that's one where I
17 think it's -- my understanding, my experience in
18 working in the fuel business, fuel fabrication,
19 zirconium fabrication, my view is it's an excessive
20 requirement. But let's hold off on that when we get
21 into the technical part of it.

22 MR. CLIFFORD: Okay. And the last slide is
23 on implementation, and we will be talking about that
24 this afternoon in detail.

25 CHAIR ARMIJO: Okay. Any questions from

1 Bill or Joy? Dennis, any questions?

2 MEMBER BLEY: No, Sam, thank you.

3 CHAIR ARMIJO: Okay. We're pretty much on
4 schedule. Let's reconvene in 15 minutes at 10:05.
5 We'll take a break right now.

6 (Whereupon, the proceedings went off the
7 record at 9:51:11 a.m., and went back on the record at
8 10:06:44 a.m.)

9 CHAIR ARMIJO: Okay, we're ready for the
10 Staff. Michelle, okay.

11 (Off the record comments.)

12 MS. FLANAGAN: Okay. My name is Michelle
13 Flanagan, and I work in the Office of Research in the
14 Division of Systems Analysis. And we were asked to
15 review what the Regulatory Guides were that accompany
16 this rule. We have been before the Subcommittee and
17 the full Committee and got into a lot of details about
18 the Regulatory Guides, how they were constructed, and
19 what the contents were. So, really my presentation
20 today just focuses on how they link to the
21 regulations, and how they enable performance-based
22 language.

23 And some of this sort has been said
24 already. Rulemaking was initiated to revise the ECCS
25 criteria to reflect new research findings. And we

1 wanted those revisions to enable performance-based
2 features; and, therefore, to satisfy both of these
3 objectives the proposed rule language calls for
4 material-specific analytical limits which account for
5 material-specific burnup effects. And ECCS performance
6 that's consistent with avoiding measured breakaway
7 behavior. And then also the need for periodic testing
8 for breakaway behavior.

9 So, while the performance-based rule
10 language identifies the high level performance
11 objectives and provides a lot of flexibility we still
12 need to have an acceptable method outlined in order to
13 provide smooth and straightforward implementation of
14 the performance-based rule.

15 So, we've developed through Regulatory
16 Guides that make it possible to revise 50.46 in a
17 performance-based manner by providing a means of
18 consistent comparable data generation to establish
19 regulatory limits for peak cladding temperature and
20 oxidation, for providing a means of consistent
21 comparable data generation to establish and
22 periodically confirm regulatory limits related to
23 breakaway oxidation, and then a consistent means of
24 using experimental data to establish regulatory
25 limits; basically what kind of margins do you need and

1 how many data points are necessary before you can
2 establish an analytical event.

3 This also simplifies the Staff's review
4 process, and reduces the regulatory uncertainty of
5 implementing performance-based rule language, and
6 minimizes the cost associated with the implementation.

7 MEMBER BLEY: Excuse me a minute, this is
8 Dennis Bley. Could you tell me, Michelle, are you on
9 your set of slides? And which one are you on?

10 MS. FLANAGAN: Yes, sorry. I am on my set
11 of slides, and I'm on Slide 4.

12 MEMBER BLEY: Okay.

13 MS. FLANAGAN: And I just completed Slide
14 4, so I'm about to go to Slide 5.

15 MEMBER BLEY: Okay, thanks.

16 MS. FLANAGAN: So, there's three separate
17 regulatory guides that were developed to support this
18 rule. The first one is the test procedure for
19 measuring breakaway oxidation behavior, and then it
20 also -- that test procedure can be used to
21 periodically confirm breakaway behavior.

22 And then another test procedure is in
23 Draft Guide 1262, and that is for measuring close
24 quench ductility using ring compression tests. And
25 then, finally, the third regulatory guide establishes

1 a way to use the data that's generated in those two
2 test procedures to establish analytical limits.

3 MEMBER SHACK: Now, are you going to have
4 a new regulatory guide related to long-term cooling?

5 MS. FLANAGAN: At this point, no. It may --
6 - through the public comment period it may come out
7 that that is necessary or appropriate, but at this
8 time that's not planned.

9 Okay, so these three --

10 MEMBER SHACK: Well, just -- what are they
11 supposed to use for guidance then, if you're not going
12 to have one?

13 MR. CLIFFORD: Well, in the SOC we include
14 a question where we're asking whether or not the basis
15 for the 800 degree temperature that has been used for
16 GSI-191 is appropriate, and whether the data is
17 complete, and whether it could be made publicly
18 available. And if the Staff -- one example would be
19 that we would review that material, find it acceptable
20 for zirconium, and then put that in the rule as an
21 analytical limit.

22 Another option would be to define a test
23 program. In that case we would then need to develop
24 a reg guide before we went final with the rule.

25 MS. FLANAGAN: So, the public comment

1 period for the rule language and the regulatory guides
2 will be at the same time. And the intention of the
3 public comment period is to make sure that the details
4 and expectations that we've outlined in these
5 regulatory guides are communicated effectively and
6 completely.

7 We also want to make sure that the
8 regulatory guides provide a way that measured behavior
9 can be repeatable within a laboratory, and also
10 repeatable between laboratories. And that analytical
11 limits can be developed consistently across fuel
12 designs.

13 So, in this -- Paul in his previous
14 presentation presented the rule language, and in this
15 slide I just highlight how it points out to our two
16 regulatory guides for cladding embrittlement. So, the
17 actual language points to the establishment of an
18 analytical limit, and the use of an NRC-approved
19 experimental technique. So, Draft Guide 1263 outlines
20 a method of establishing analytical limits, and Draft
21 Guide 1262 identifies an experimental technique which
22 NRC considers acceptable for informing those
23 analytical limits.

24 And the same is true for breakaway
25 oxidation. The rule language requires a limit, and

1 that the performance is shown to be not greater than
2 that limit, and that the limit be informed by an
3 acceptable experimental technique. And, again, we have
4 Draft Guide 1263 outlining a method for establishing
5 the limit, and then Draft Guide 1261 identifying an
6 acceptable experimental technique.

7 So, as I said before, the public comment
8 period for these regulatory guides will be the same as
9 for the rule. And after that public comment period,
10 the reg guides will follow a standard review process.

11 CHAIR ARMIJO: That comment period is what,
12 60 days, 90 days?

13 MS. FLANAGAN: Ninety days, right?

14 MR. CLIFFORD: Ninety days.

15 MS. FLANAGAN: Ninety days.

16 CHAIR ARMIJO: Ninety days. Okay, and then
17 you receive these, and then you take some time to --

18 MR. LANDRY: Sam, Ralph Landry.

19 CHAIR ARMIJO: Sure.

20 MR. LANDRY: The comment period is going to
21 be 75 days.

22 MS. FLANAGAN: Oh.

23 CHAIR ARMIJO: Okay.

24 MR. LANDRY: We're splitting the
25 difference.

1 CHAIR ARMIJO: Then you consolidate them,
2 evaluate them, and make a disposition, and that's
3 going to take you roughly how long, typically?

4 MR. CLIFFORD: Well, for the rule I believe
5 we have a schedule that we would have to go final
6 within one year.

7 CHAIR ARMIJO: Okay.

8 MR. CLIFFORD: I believe that was what was
9 on Tara's slides. And then the reg guides, then run
10 parallel with the rule.

11 CHAIR ARMIJO: Yes, okay.

12 MR. RODACK: This is Tom Rodack from
13 Westinghouse. May I just comment at this point, that
14 this is a tremendous amount of information to review
15 and provide salient comments back on in a 75-day
16 period. I would urge that you consider a longer time
17 for review of these documents. I made this point at
18 previous ACRS Subcommittee meetings on this topic.
19 Just going back to the Advanced Notice of Proposed
20 Rulemaking, and the effort involved in reviewing those
21 documents from experience it will require quite some
22 time on the part of industry to come up with comments
23 on these documents.

24 MR. CLIFFORD: Do you have a specific time
25 frame that you would like to recommend, 90, 120?

1 MEMBER SHACK: Ten years.

2 MR. RODACK: I would recommend 120.

3 CHAIR ARMIJO: Really?

4 MR. RODACK: I think there's a lot of
5 information here. Granted we have seen drafts of this
6 previously, but there have been changes to these
7 documents. Well, anyway, for your consideration.

8 MR. CLIFFORD: Thank you.

9 MS. FLANAGAN: That was actually my last
10 slide so if -- are there any questions on --

11 CHAIR ARMIJO: No, we've been through these
12 in detail, unless members --

13 MR. CLIFFORD: Sam, did you have that
14 question on breakaway oxidation testing?

15 CHAIR ARMIJO: I think you have a
16 presentation that was more detailed. When you do your
17 talk about your audit -- at least in your draft slides
18 that I received.

19 MR. CLIFFORD: Right, it gives measured
20 breakaway times.

21 CHAIR ARMIJO: Yes, and that's where I'd
22 like to bring it up.

23 MR. CLIFFORD: Okay.

24 MS. FLANAGAN: Okay.

25 MR. CLIFFORD: We are way ahead of

1 schedule.

2 CHAIR ARMIJO: We're a very efficient
3 committee. But we've done a lot of work reviewing a
4 lot of this in a lot of detail earlier, so unless
5 there's some questions we should just move along. And
6 I have no problem of next on the agenda would be
7 industry. And I propose we just move ahead, if Mr.
8 Eichenberg is ready from TVA.

9 MR. EICHENBERG: I'll check with everybody
10 to make sure that we've got copies of the --

11 CHAIR ARMIJO: Yes, they're not separate
12 presentations.

13 MR. EICHENBERG: Right. We had talked
14 earlier about whether we'd do separate or a combined
15 report, and we finally decided it would be a little
16 bit better for time purposes to have a combined
17 report. We weren't sure whether we were going to be
18 behind schedule at this point or ahead of schedule, or
19 on schedule.

20 CHAIR ARMIJO: We're very much ahead of
21 schedule, so don't feel rushed. If there's something
22 you want to say, please do it.

23 MR. EICHENBERG: Now, let me make sure I
24 know which button is the forward button for --

25 (Off the record comments.)

1 MR. EICHENBERG: Okay, I'm Tom Eichenberg
2 from TVA, and I'm here representing the BWR Owners'
3 Group. And this is Kurt Flaig of Dominion. He's here
4 representing the PWR Owners' Group.

5 What we wanted to do was to provide just
6 sort of an overview of what these margin assessment
7 reports are, how they came into being, what their
8 purposes really was, the goals of them. So, we're
9 going to talk about the objectives of the reports,
10 give a little bit of background on how they came into
11 being, talk a little bit about the overall margin
12 assessment process, and then what the conclusions of
13 that process turned out to be.

14 For our objectives we want to talk about
15 the industry assessments at a relatively high level,
16 and we want to show that the operating plants in the
17 fleet have margin with respect to the research
18 findings.

19 A little bit of background. As has been
20 discussed earlier and at other meetings, there's been
21 a longstanding amount of research from Argonne
22 National Lab, and that was embodied in NUREG/CR-6967.
23 That really has been the impetus for moving to a
24 rulemaking process which says that the current regs
25 are not adequate.

1 NRC Staff has requested an assessment of
2 the research results with respect to the operating
3 fleet. This came out of two processes, one was the
4 ANPR process, and another was an internal NRC process
5 to review safety, which ultimately was leading down
6 the path of a Generic Letter.

7 So, in the course of our meetings with NRC
8 it became clear that a Generic Letter path was going
9 to put a substantial overhead burden on the industry
10 and not really produce the very information that the
11 NRC needed.

12 So, what NRC did was we proposed to
13 provide separate reports on a voluntary basis, and the
14 benefit of this would be that it would reduce the
15 overhead burden, but it would also give NRC the
16 information they wanted on a faster schedule. And in
17 order to coordinate all of these things, the process
18 was coordinated through NEI.

19 CHAIR ARMIJO: Well, I'd like to compliment
20 the Staff and the industry for finding a very
21 practical way to skin this cat, because it needed to
22 be done.

23 MR. EICHENBERG: Yes.

24 CHAIR ARMIJO: And this was the right way
25 to do it, rather than the ponderous regulatory Generic

1 Letter process.

2 MR. EICHENBERG: Right. And we felt it was
3 important to have a central point of contact, so we
4 established NEI as that central point of contact
5 simply because there are what I'll call overlapping
6 interests amongst the various groups in the industry.
7 So, with NEI being able to coordinate things it was
8 easier to assign responsibilities and get the process
9 moving.

10 We want to talk shortly about the
11 assessment itself. We want to talk about the approach
12 to what we call the initial survey. It's kind of
13 really talking about the starting point, where do you
14 start this whole analysis from.

15 We wanted to go through some mechanism to
16 identify what are the criteria we're going to measure
17 against, because as we all know, there is no rule in
18 place. So, we're sort of going as we take each step.

19 One of the goals was to identify in
20 current methodologies what are the conservatisms that
21 we know of, and what are those conservatisms worth,
22 and how can they help us to establish that we really
23 do have margin to these research limits even though a
24 specific licensing methodology was never intended to
25 compute that type of margin.

1 And then we also want to explain a little
2 bit about the plant grouping approach that we took,
3 and why plants have been kind of lumped into groups
4 rather than just going through each individual single
5 plant.

6 So, with respect to the survey, the
7 starting point was a bit difficult to try to figure
8 out how could we get all the plants to be at the same
9 place at the same time and have some sense of it all.
10 And in the end, we came down to saying each plant at
11 some point had to have a full-blown analysis of
12 record, which loosely translates into a break spectrum
13 analysis. So, that was one point where all the vendors
14 could say every single licensee has been analyzed. So,
15 we chose that as the starting point.

16 Now, there was some confusion because some
17 people consider their analysis of record to be the
18 actual 50.46 annual reporting rack-ups, but not
19 everybody treats it that way because the rack-ups
20 themselves are not a full-blown break spectrum
21 analysis, so we chose just to start at a more common
22 point that everybody could basically fulfill.

23 And then in looking at the individual
24 licensees and trying to establish what is their
25 initial margin; so, for example, everybody or I

1 shouldn't say everybody, some plants maybe they have
2 an Appendix K-based analysis, very conservative, and
3 it is using oxidation mechanisms primarily through the
4 Baker-Just correlation. So, you might say let's look
5 at every plant and see what their Baker-Just oxidation
6 is, and maybe we'll get lucky, and some of them will
7 already meet the existing criteria, and we can
8 effectively say that there is no need to take any kind
9 of credit whatsoever. But there are going to be places
10 where some amount of conservatisms and credits would
11 have to be determined, and then we would have to take
12 those into account as we process each and every
13 licensee.

14 So, I'll turn it over here to Kurt.

15 MR. FLAIG: Thank you, Tom. Good morning.

16 I'm just going to take you through the
17 next few slides here. We're going to talk a little
18 bit about the evaluation basis. Basically, the ground
19 rules for the two groups to perform the analysis, talk
20 a little bit about the embrittlement limit. This is
21 an NRC proposed limit that was used here, 18 percent
22 at zero ppm, the break point at 6 percent at 400 ppm,
23 and then down to 4 percent at 600 ppm.

24 The PWR Owners' Group modified that
25 slightly and presented that to the NRC in their

1 assessment report. And we'll look at that in a slide
2 down the way here.

3 Obviously, the embrittlement limit is
4 based on hydrogen uptake models that need to be
5 approved by the NRC. And they are alloy-specific
6 models then, and each one of those models was provided
7 in our assessment report.

8 We need to understand how to deal with
9 double-sided ECR. The evaluation models typically
10 handle double-sided corrosion at burst limiting
11 locations but away from burst limiting locations we
12 needed to account for the oxygen ingress, so that was
13 done.

14 We also had a criteria for breakaway
15 oxidation. We've talked about that earlier today, 800
16 degrees is what was used in the assessment reports.

17 This is the embrittlement criteria that
18 was used by the PWR Owners' Group. It is only
19 slightly different from the values that I indicated
20 before. We reduced the zero ppm number down to 17
21 percent, and we extended the curve out to 800 ppm.

22 CHAIR ARMIJO: But the break point at 400
23 ppm and 6 percent ECR is the same as the --

24 MR. FLAIG: Yes, this break point is the
25 same.

1 CHAIR ARMIJO: Yes.

2 MR. FLAIG: That break point is the same.

3 CHAIR ARMIJO: So you just extended it
4 beyond -- what did the Staff --

5 MR. EICHENBERG: Well, one of the problems
6 with the original proposed limit as it was in the GL
7 proposal was that it just kind of stopped at 600, and
8 there was no step change, there was no nothing. It
9 just kind of said stop. So, we said we need to have
10 some sort of meaningful continuous line that will
11 cover us should we happen to get out to such ppm
12 numbers.

13 CHAIR ARMIJO: So you dropped the --

14 MR. EICHENBERG: So, we just chose to
15 linearly extend what was there.

16 CHAIR ARMIJO: Okay.

17 MR. EICHENBERG: Now, I believe that we in
18 the end turned out we didn't need to take any
19 advantage of that really high ppm values. I'm not
20 entirely sure of that. We have some of the vendors'
21 representatives here who could probably speak
22 specifically to that.

23 CHAIR ARMIJO: If I recall there was never
24 test data out at those --

25 MR. EICHENBERG: I think 600 is where the

1 highest test data --

2 CHAIR ARMIJO: Yes, so that was just a pure
3 extrapolation.

4 MR. EICHENBERG: Just a pure extrapolation
5 to say we have a continuous curve.

6 CHAIR ARMIJO: Okay, we'll talk about that
7 later.

8 MR. FLAIG: Okay. We need a hydrogen-uptake
9 model to apply for each alloy, and here's an example
10 of the one for Zircaloy-4 that is in the public forum,
11 fairly straightforward here. Lower values at lower
12 burnups going up to higher values at higher burnups.

13 For double-sided ECR contribution it was
14 applied at rod exposures above 45 kilowatt-days per
15 metric ton, something that we discussed in front of --
16 - at public meetings back in December 2010.

17 CHAIR ARMIJO: Could you step back to that
18 previous chart? Do you have -- just for the
19 convenience, do you have a chart on that same scale
20 for all the current alloys in use in the U.S. fleet?

21 MR. FLAIG: I have in the assessment report
22 for the PWR Owners' Group there is plots, and I have
23 them with me on some backup slides for both ZIRLO and
24 -- ZIRLO-1 is proprietary and it's just an example.
25 We have an M5 one, as well, and I believe there is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 some information for the BWR Owners' Group.

2 MR. EICHENBERG: Yes, the BWR has a ZIRC-2
3 type curve on it. Right?

4 CHAIR ARMIJO: And the -- well, if we want
5 to see the proprietary stuff we have ways of closing
6 the meeting and discussing that if we need to.

7 MR. EICHENBERG: Right.

8 CHAIR ARMIJO: But at some point it would
9 be nice to have all of these curves on one chart so we
10 have an idea where we are.

11 MR. EICHENBERG: Yes, a consolidated chart
12 could prove interesting just in terms of clarifying
13 the whole situation.

14 CHAIR ARMIJO: Yes.

15 MR. FLAIG: Okay, we'll move forward here.
16 I talked about double-sided ECR contribution.
17 Breakaway oxidation, we applied 5,000 seconds above
18 800 degrees as a basis based on some ANL testing and
19 industry testing.

20 CHAIR ARMIJO: And where did the 45
21 gigawatt days per ton come from? Why is that a --

22 MR. EICHENBERG: My understanding of 45
23 gigawatt days is that that is the proposed value in
24 the Draft Reg Guide.

25 CHAIR ARMIJO: I remember seeing something

1 like 50, maybe I'm --

2 MR. CLIFFORD: The value -- it's really
3 when you start having a fuel cladding bond layer to
4 the extent to which you have that bond layer. And it
5 would be fuel design-dependent, and it would also be
6 dependent on operating history. We felt for the
7 purpose of this exercise, 45 was a reasonable
8 threshold to start consider this oxygen in the
9 cladding.

10 In the regulation, the proposed regulation
11 it would be up to the licensee for his specific fuel
12 design to provide evidence of when that oxygen --

13 (Coughing.)

14 MR. CLIFFORD: So it could vary from 40 to
15 50. It's going to be somewhere around 45 based on what
16 we know today.

17 CHAIR ARMIJO: Okay. So, if particular
18 fuel manufacturer has data, hot-cell data or something
19 that shows he's got little or no fuel clad bonding at
20 45 or 50, he could actually propose a different value
21 at which he applies that.

22 MR. CLIFFORD: Absolutely.

23 CHAIR ARMIJO: Okay. And conversely, if
24 he's got a particular situation where he's seeing that
25 in significant amount of bonding at lower burnups

1 that's his job to show you?

2 MR. CLIFFORD: Yes.

3 CHAIR ARMIJO: Or does that 45 protect him?

4 MS. FLANAGAN: The Regulatory Guide
5 provides an option if no data is available or if it's
6 just not productive to collect data, the Regulatory
7 Guide provides an option that you can just say 45 as
8 a limit that can be supported without any other data.
9 It's like a default.

10 CHAIR ARMIJO: And is the extent of fuel
11 clad bonding, in your mind are you thinking in terms
12 of half the ID surface, 10 percent of the ID surface
13 has got fuel bonded to the cladding? Do you have a
14 position on that of what --

15 MS. FLANAGAN: We wanted to select a value
16 that was low enough that we knew that the bond - sorry
17 - the hard contact existed, but then it isn't
18 necessarily true that that will be sufficient for
19 diffusion of oxygen. It's just that we think it's
20 conservative. And then a vendor would have to supply
21 information that says how much hard contact plus an
22 actual bonding layer would be required until you
23 actually get diffusion of oxygen during that
24 transient. And that may be a different burnup.

25 CHAIR ARMIJO: Okay. Well, hard contact by

1 itself isn't a guarantee you have fuel clad bonding.
2 It's time, temperature, burnup, a whole bunch of
3 things, and unless you have hot-cell data where you
4 can actually see the extent of bonding you're kind of
5 guessing. And I just wanted to know if the Staff is
6 expecting -- and I guess you answered my question. You
7 don't expect -- you would not request any data below
8 45. And if somebody wanted to propose that they don't
9 need to account for double-sided oxidation up to 50 or
10 60 they have to show you a pretty convincing set of
11 data.

12 MS. FLANAGAN: Right.

13 CHAIR ARMIJO: Okay, I understand.

14 MR. FLAIG: Okay. The next slide is an
15 example of some of the applied conservatisms that were
16 used during the evaluation of the individual plants.
17 The obvious ones are Appendix K versus Best Estimate
18 methodology. There are many plants out there that
19 still have Appendix K methods, so moving to Best
20 Estimate methodology is a conservatism that can be
21 applied and used to improve the outcomes.

22 Another one is approved Best Estimate
23 methodology improvements; basically moving from one
24 approved Best Estimate method to another. The use of
25 Cathcart-Pawl in place of Baker-Just. We also looked

1 at reload power histories. We looked at peak cladding
2 temperature-dependent brittle fracture transition.
3 Essentially, a reduction in PCT will provide an
4 increase in ECR.

5 We looked at using the ANS-1979 decay heat
6 standard plus two-sigma uncertainty, and then another
7 example would be thermal mechanical limits to
8 operation, linear heat generation limit, that was
9 applied.

10 So, these were just some examples of
11 conservatisms that are laying out there for us to look
12 at in the process of going through the assessment.
13 These are ones that are not unapproved type of
14 conservatisms, but those that have been used by the
15 industry in various places.

16 Talk a little bit about the plant grouping
17 factors. We talked when we were here before about
18 grouping them with regards to plant design and ECCS
19 features, but we also considered things of large
20 versus small break being limited. We considered the
21 type of cladding material. We considered what type of
22 evaluation model, and whether or not to group
23 according to that because you would apply different
24 conservatisms potentially for those types, so, to
25 group that way was considered. So, the types of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 conservatism credits were considered then in how we
2 wanted to group the plants so that they would be best
3 able to present in the assessment what the results
4 were. So, we just have on the next few pages here
5 some basic summary information about the grouping that
6 was done.

7 For the PWR large-break, and for PWR we
8 had seven groups for the large breaks, and we have
9 three separate groups for the small breaks. You see
10 before you the group 1-4. For Group 1 which contains
11 41 units, the majority, no adjustments were required
12 to meet the limits. For Group 2, just two units in
13 there. We needed to --

14 CHAIR ARMIJO: These were all Appendix K?

15 MR. FLAIG: No, sir.

16 CHAIR ARMIJO: The Group 1 were not?

17 MR. FLAIG: Group 1 was a combination.

18 CHAIR ARMIJO: A combination.

19 MR. EICHENBERG: Group 1 for the --

20 MR. FLAIG: I'll step back for a second.

21 For the PWR Owners' Group we very much decided to look
22 at the type and number of adjustments required in
23 order to show that we met the limits, so the groups
24 are on that basis; the types of adjustments necessary
25 to show that we meet the limit. So, each individual

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 group may contain more than one type of methodology,
2 one type of plant design, more than one type of ECCS
3 design. So, with regards to the adjustments, none
4 were needed for Group 1, and that's the basis for the
5 grouping there, is that no adjustments were necessary
6 to meet the limits.

7 CHAIR ARMIJO: Including Baker-Just --

8 MR. FLAIG: Nothing at all.

9 CHAIR ARMIJO: Okay.

10 MR. FLAIG: Okay? For Group 2 we looked at
11 approved Best Estimate methodology improvements to
12 show that those met the limits, and the calculated ECR
13 was reduced by approximately 50 percent by using those
14 improvements.

15 For Group 3 which contains six units, the
16 conservatism applied there was Appendix K. Moving to
17 a Best Estimate methodology provided us a calculated
18 ECR reduction of approximately 60 percent.

19 Group 4 contains four. We looked at
20 improved statistics in the ASTRUM methodology,
21 reducing a calculated ECR by approximately 40 percent.

22 And then for the last three here, for
23 Group 5 we looked at an explicit burnup study reducing
24 ECR by 50 percent. Group 6 we looked at -- Group 6
25 and 7 we have multiple conservatisms that are used.

1 For Group 6 the approved Best Estimate methodology
2 improvements, as well as improved ASTRUM statistics
3 improved our ECR calculated value by 60 percent. We
4 also increased the allowable ECR criteria by looking
5 at the reduction in PCT.

6 For Group 7, eight units in that group. We
7 looked at moving to Cathart-Pawl as well as reload
8 power histories, and we reduced the calculated ECR by
9 40 percent. So, you can see that the conservatisms
10 are rather large that we looked at for the large-break
11 LOCAs.

12 For small-break we just have three groups.
13 Again, Group 1 contained 59, and this is the group
14 that there are no adjustments required for to meet the
15 limits. For Group 2, contained five units, and we
16 applied the ANS-1979 decay heat standard plus two-
17 sigma uncertainty. That's something that is typically
18 applied in Best Estimate methodologies, and the ECR
19 was reduced by 90 percent, so significant change
20 there.

21 And then for Group 3, the last group here
22 contains five units. And we looked at moving to
23 Cathart-Pawl, as well as reload power histories and
24 reduced the ECR by 30 percent.

25 CHAIR ARMIJO: I'm curious why you didn't

1 use the reload power histories more.

2 MR. FLAIG: More?

3 CHAIR ARMIJO: Generally, you know, you
4 have all this.

5 MR. FLAIG: They are available. They are
6 plant-specific values, but we didn't want to use
7 everything in the bag necessarily. Okay? We used what
8 was easiest to grab. Obviously, moving from Appendix
9 K to Best Estimate models was an easy thing to look
10 at. Looking at -- in this case, this slide here
11 looking at ANS-1979 decay heat plus two-sigma
12 uncertainty was an easy adjustment to grab. So, there
13 wasn't a need to look at reload power histories for
14 all the different groups, so if it wasn't required we
15 didn't apply it.

16 MR. EICHENBERG: Maybe one more way to
17 think about this is that for these groups there may be
18 only be one or two, in some cases three credits that
19 were taken in order to show that there's positive
20 margin to the proposed limit, but that's not to say
21 that we went through every single possible
22 conservatism that's out there. So, there's still a
23 lot of conservatism sitting out there that has not
24 been credited. And, ultimately, as the process
25 evolves and we get to new methods that are reviewed

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 and approved by NRC, we'll step through all these
2 conservatisms and come to some agreement about what is
3 the proper amount of conservatism to keep in the
4 basis. But we're really just trying to show that it
5 doesn't take a lot in order to meet the margin. So,
6 that pretty much covers the breakdown of the PWR
7 groups.

8 The BWR groups, in coming up with these
9 groupings --

10 MEMBER SHACK: Well, just let me --

11 MR. FLAIG: Sure.

12 MEMBER SHACK: The way you've done it, that
13 means I really shouldn't put too much stake in any
14 margin that you found. You just sort of got credit
15 until you met the goal, sort of like a CUF in
16 analysis, if you get below one, you quit.

17 MR. EICHENBERG: Yes. The purpose was
18 simply to --

19 MEMBER SHACK: To get what's necessary to
20 say that there is margin. Okay. So, the --

21 MR. EICHENBERG: As opposed to a full-blown
22 licensing calculation which essentially can't be done
23 because there's no approved method.

24 CHAIR ARMIJO: Let's take just a
25 hypothetical. You take one of these plants and you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 pull out all the stops. You use all of your, I won't
2 call them approved margins but certainly --

3 MR. EICHENBERG: Rational margins.

4 CHAIR ARMIJO: Yes. Are we talking about
5 reductions in ECR over 100 percent, not 100 --

6 (Simultaneous speech.)

7 CHAIR ARMIJO: How big of a --

8 MR. EICHENBERG: Maybe one thing to keep in
9 mind is that these reductions are -- they are the
10 relative percent change from that starting point. So,
11 as soon as you start to mix apples and oranges
12 together, it's affecting PCT -- it's affecting your
13 temperature profiles, and it's affecting, obviously,
14 then your oxidation rates in very different manners.
15 So, it's not real easy to compare the end state to the
16 beginning state.

17 CHAIR ARMIJO: Unless you do a full
18 analysis.

19 MR. EICHENBERG: Unless you do the full-
20 blown thing. So, while some of these reductions,
21 particularly in the case of the decay heat curve being
22 90 percent reduction, we just need to remember that
23 the reason it's 90 percent is because the starting
24 point was so big compared to where just this one
25 credit got you.

1 CHAIR ARMIJO: Okay.

2 MEMBER SHACK: But when I see, for example,
3 a grouping with plants it looked to me like pretty
4 similar beasts, and yet the margins --

5 CHAIR ARMIJO: Vary.

6 MEMBER SHACK: -- vary markedly. That's
7 just an accident perhaps of the --

8 MR. EICHENBERG: And it's the result of
9 choosing the binning structure in this manner based on
10 credits. And what we'll see when we look at the
11 boiler stuff is that those bin structures were not
12 necessarily based on credits. They were more based on
13 -- it was easier to say break them up by design.

14 MR. CLIFFORD: Yes, and if I could say
15 something. If you had two identical plants, if one was
16 using Appendix K and the other one was using Best
17 Estimate, there would be an enormous difference in
18 initial margin. And, also, if one was using say M5
19 and one was Zirc-4, there would be an initial heat
20 difference in initial margin, even though they both
21 had the same --

22 MEMBER SHACK: What I was looking at was
23 the final margin after they took all the credits. I
24 looked at a group of plants it seemed to me relatively
25 similar, same design, roughly same power, same

1 cladding. And yet when I get down to the margin
2 that's left, it can be quite dramatically different in
3 some cases.

4 MR. EICHENBERG: Right, because each bin
5 has just got a homogenized group of plants in it.

6 CHAIR ARMIJO: Okay.

7 MR. EICHENBERG: On the BWR side, the
8 groupings were -- it just turned out to be easier to
9 do it by plant design. So, there was no Group 1
10 because we don't have any BWR-1s to evaluate, so we
11 just jumped right to Group 2. So, we started out with
12 Group 2 designs which are the BWR-2s, the non-jet pump
13 plants. And in that context we took credit for the
14 conversion from Baker-Just to Cathart-Pawl. And then
15 we took credit for what we call the thermal mechanical
16 operating limit. And what that essentially says is
17 that at no point during operation can you be running
18 at an LHGR limit above what your COLR says you're
19 allowed to run at. And just the simple act of saying
20 that's how much power density I have limits how far
21 the PCT can go. And there's a meaningful benefit to
22 that.

23 So, for the BWR-2s we just took a couple
24 of simple credits and we were able to reduce the ECR
25 by about 20 percent from the starting point. And that

1 was sufficient to show margin to the proposed rule.

2 In the case of BWR-3s it was even more
3 simple, yet we only really needed to take credit for
4 the fact that LHGR limit existed. And just in doing
5 that we got about a 95 percent reduction in ECR
6 relative to the starting point.

7 But for the vast majority of boilers, all
8 the BWR-4, 5, and 6 designs, there was no requirement
9 for any adjustments, that you were able to meet it
10 with the current licensing methods. So, in that
11 respect the BWR groupings were actually a much more
12 simple matter than the PWR.

13 CHAIR ARMIJO: Okay.

14 MR. EICHENBERG: So, to kind of summarize
15 what the margin was showing was that for embrittlement
16 purposes 41 of 69, which was roughly two-thirds of the
17 fleet in large-break space required no adjustment. And
18 some were upwards of 80 percent or so, and the PWR
19 small-break required no adjustments whatsoever to meet
20 the current margins. And almost all the boilers were
21 in the same situation, no real adjustments or credits
22 were required.

23 And then in the case of all the remaining
24 plants, as we discussed, various credits were taken
25 but we didn't take any sort of wild conceptual

1 credits, and we certainly tried not to take advantage
2 of any kind of a plant-specific I'll call them design
3 type things that change from cycle to cycle.

4 Now, in the case of the boilers this
5 thermal mechanical limit, one could argue that that
6 has the potential to change from cycle to cycle, but
7 in reality those limits are pretty much fixed, and
8 they very rarely change. Every cycle is pretty much
9 the same. Every plant uses the same thermal
10 mechanical limit, and it's pretty much a non-changing
11 entity.

12 In terms of breakaway oxidation what we
13 found was that all the plants were able to meet the
14 5,000 second margin without any credit.

15 CHAIR ARMIJO: And that's Bs and Ps.

16 MR. EICHENBERG: Bs and Ps.

17 CHAIR ARMIJO: So, this even applies to --

18 MR. EICHENBERG: Just as blanket. And
19 then, basically, as a result all the operating plants
20 we were able to show margin with respect to the
21 research findings.

22 CHAIR ARMIJO: Okay.

23 MR. EICHENBERG: And then concluding, we
24 just wanted to state that the industry was able to
25 provide the margin assessment reports that encompass

1 the entire operating fleet, and that all the operating
2 plants showed margin with respect to the research
3 findings.

4 CHAIR ARMIJO: So, if you just go a couple
5 of steps, when this rule comes out, assuming there's
6 not radical changes, the actual implementation and
7 compliance with the rule should be pretty
8 straightforward. Some work to do, but if you guys
9 have concerns, this is a good time to raise them.

10 MR. FLAIG: Well, I think that these
11 assessments show that for the criteria considered
12 there is margins there and that we can achieve that
13 success. I think it's the process that we need to go
14 through in terms of what methodology changes have to
15 be made to various evaluation models, what's the
16 approval through that evaluation model review and
17 approval practice? What do licensees need to do to
18 then pick that up, work the vendors to get that work
19 accomplished, submit it to the NRC. What type of
20 additional licensing actions are required through text
21 spec changes or COLR reference list changes that need
22 to be made to put all of this in place.

23 It seems rather simple and straightforward
24 to look at the plants that have really no adjustments
25 required, but there's a fair amount of work that has

1 to go into meeting the rule language as we've heard it
2 this morning in terms of demonstrating that the
3 methods that the vendors have are sufficient to meet
4 that rule language, and to then have all the licensees
5 put that information in a place where it needs to be.

6 Many licensees have listed in their COLRs
7 the approved LOCA methodology approved by the NRC as
8 a basis for their peaking factors. So, this would be
9 what I would think would be an update to that
10 information in the COLR, and that's not a simple
11 process as you know it in the NRC. And it's not a
12 simple process as the licensees know it.

13 So, you asked me do I have a concern? I
14 think the industry has a concern of the length of
15 time, the resources necessary both at the licensees
16 and at the vendors, and at the NRC to accomplish this
17 effort in a timely manner without doing something up
18 and above --

19 CHAIR ARMIJO: Well, let me put my question
20 a different way. If you've got 68 plants, BWRs and
21 PWRs combined that you say needed no adjustment to
22 show margin, and using approved --

23 MR. EICHENBERG: Using the existent --

24 CHAIR ARMIJO: -- existing approved
25 methods -- and yes, I know there's always

1 implementation work that has to be done, but if that
2 was the only problem -- if that was the only set of
3 plants you had to deal with, why isn't this pretty
4 straightforward? I mean, nothing changes.

5 MR. EICHENBERG: In some sense it's
6 straightforward, but in other senses it's not.
7 Typically, if you were to have a methodology change as
8 a licensee you're going to have to have an approved
9 method, and then you're going to have to put in a
10 license amendment request citing that you want to have
11 that new method as part of your text spec references.
12 And then has to get approved so that you can then do
13 that and update your FSAR.

14 In the process of doing that, you're
15 really complying with two different things. One is,
16 I'm complying with the new rule. The other is, I have
17 to comply with my text spec as written at any given
18 instant in time. So, that entire process that I just
19 described is really trying to get you through both
20 compliance phases.

21 One of the problems that the industry has
22 in digesting this is what is going to be the
23 definition of compliance demonstration. And
24 hypothetically just reading the language that I've
25 seen, you've got a situation where you could say well,

1 maybe the first group of plants which has a 24-month
2 block of time, we're going to give some special
3 allowance for what the definition of compliance
4 demonstration is.

5 Okay, maybe that doesn't mean I have to go
6 all the way through a text spec submittal and all
7 these other things. What happens to those licensees
8 on day 24 months plus a day, because all you've done
9 is answered the I complied with the rule part. You
10 still haven't addressed the how do I comply with
11 making my tech specs work, because I'm still required
12 to comply on a daily basis with the way my tech specs
13 are written.

14 So, there's two pieces to the puzzle, and
15 we really need to figure out how we're going to
16 conquer both pieces of that puzzle and not let them
17 get so disjointed that we create I'll say a tank trap
18 to fall into, and that nobody can get out of.

19 So, we haven't had a lot of time to look
20 at the language. Plus one important piece that we
21 haven't had any chance to see is what will the
22 Statements of Consideration be. So, until the rule is
23 published as a draft, we're not really going to have
24 any access to that. We need to understand that first
25 before we can come up with real specific comments.

1 So, we have some concerns, but we think
2 they're the kinds of things that can be worked out.
3 Just speaking from my personal preference, I would
4 prefer not to have literal licensee names in the rule.
5 I'd prefer to do something that was more along the
6 lines of what NRC has done in other rulemaking
7 situations where the licensees provided a plan within
8 say 60 or 90 days of how they intend to comply. And
9 then you've got a situation where NRC Staff and
10 licensees can sit down and come up with an orderly
11 schedule of who needs to go first, helps you to
12 understand which methodologies need to get into the
13 pipeline first, because we really have, for lack of a
14 better term, a resource issue with how quickly can we
15 process methodology reviews, how quickly can we
16 process tech spec license amendment reviews, and how
17 much of that can be done in parallel.

18 And, ultimately, that's going to drive how
19 you get to some sort of schedule date. So, we're
20 really going to need to see not only the rule language
21 as proposed, but the Statements of Consideration so
22 that we can go through and develop some kind of -- the
23 industry will develop some sort of alternative. And
24 we'd really like to have the opportunity to sit down
25 with Staff and have a public workshop to talk about

1 how we best get to that best place.

2 MR. LANDRY: This is Ralph Landry from NRO.
3 You've already seen the exact rule language so far,
4 and as you said, you haven't seen the SOC. We have a
5 lot of questions in the SOC that we're asking for
6 specific feedback on. And this is one of those areas.
7 So, we're going to be giving you the opportunity to
8 give us feedback and figure out what is the best
9 approach for the implementation of the rule.

10 CHAIR ARMIJO: You know, just being real
11 simplistic, assuming that everything you found is
12 accurate and correct, and you're in de facto
13 compliance right now, is that wrong?

14 MR. EICHENBERG: The bulk of the plants
15 with the existing license methods could make a
16 statement that they meet proposed rule language based
17 on what we right now would have to say are assumed
18 hydrogen uptake performance models. And that's one
19 issue that I don't think has been addressed at all, is
20 how are we going to define an acceptable hydrogen
21 uptake model? There's no reg guidance on that. It's
22 not really discussed in the rule itself, and it's hard
23 to step -- take that first step to say I'm in
24 compliance when we don't have anything that says what
25 constitutes compliance for hydrogen uptake.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIR ARMIJO: I thought we had models or
2 data that have been approved.

3 MR. EICHENBERG: Well, we have -- the
4 vendors have some data, but that's not the same thing
5 as saying that we have methodologies that have topical
6 reports submitted that have SERs associated with.

7 MR. CLIFFORD: This is Paul Clifford. We
8 have reviewed hydrogen uptake data, and we have used
9 that data to make regulatory decisions. For example,
10 there's a SAFDL on cladding strength, during an AOO
11 you get an overpower transient, how much strain can
12 your cladding -- how much strain in the cladding go
13 before it fails? And say there's 1 percent as a
14 number, well, that's dependent on how much hydrogen is
15 in the cladding. If there's a lot of hydrogen maybe
16 you're not able to achieve 1 percent.

17 So, we have reviewed data for regulatory
18 purposes, but we haven't reviewed data to establish
19 what --

20 CHAIR ARMIJO: But assuming that you had a
21 set of data for one particular type of cladding that
22 was acceptable in that review, wouldn't it be
23 reasonable that -- to find that same set of data
24 acceptable for this application?

25 MR. CLIFFORD: I believe there's data out

1 there. I believe --

2 CHAIR ARMIJO: Okay.

3 MR. EICHENBERG: There is certainly the
4 potential for that. And one of the issues that would
5 not yet be settled is, does hydrogen uptake need to be
6 upper bound toleranced, or does it need to -- or is it
7 okay just to be a best estimate mechanism?

8 MR. CLIFFORD: Yes, that level of detail is
9 what needs to be worked out. Whether you have a peak
10 nodal average, whether it's a circumferential average,
11 or a peak, or --

12 MR. EICHENBERG: There are more technical
13 issues of how you define acceptable, but we can
14 clearly, I think, get to acceptable, but it's going to
15 take some time to get there.

16 CHAIR ARMIJO: Okay. And those kinds of
17 issues you'll raise, or somebody is going to raise in
18 the --

19 MR. EICHENBERG: Yes, we will certainly
20 bring those issues up during the draft comment period.

21 CHAIR ARMIJO: Okay.

22 MR. FLAIG: The other thing I guess I'd
23 like to note since we're talking freely here a little
24 bit, and you mentioned it, too, which is the long-term
25 core cooling and its relationship to GSI-191, and even

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 trying to come to an establishment of a limit for that
2 embrittlement, it's kind of sitting out there very
3 bare bones at this point in time. And to say that we
4 meet that limit, there's no limit, there's no reg
5 guide, there's no structure to that at this point in
6 time. So, I'm personally left in a quandary of where
7 am I going to go here.

8 CHAIR ARMIJO: Okay.

9 MR. LANDRY: This is Ralph Landry again.
10 That's one of the things that we want to get feedback
11 on. As I said earlier this morning, we tried to take
12 something that has no definition virtually and put
13 some definition to it in a performance-based manner so
14 that it's not just picking an arbitrary number, an
15 arbitrary statement of how you meet it. We're trying
16 to make it performance-based so that you tell us how
17 you meet it. But we're -- this is one of those areas
18 that we're waiting for feedback on. We can't guess at
19 everything.

20 MR. EICHENBERG: Obviously, we're at this
21 stage of the process.

22 MR. LANDRY: We're trying to take
23 uncertainty out of the process.

24 MR. EICHENBERG: We're not quite at bring
25 me a rock part of the process, but we're still not

1 fully away from it.

2 CHAIR ARMIJO: I think that particular one
3 sounds little bit -- but I'm sure you can work it out.

4 MR. EICHENBERG: Okay. That's what we had
5 for slides.

6 CHAIR ARMIJO: Okay. Any questions? Bill,
7 Joy? I think that's very helpful, and we did get your
8 material. We've been looking at it.

9 MR. EICHENBERG: Okay.

10 CHAIR ARMIJO: So, I think that's all we've
11 got, so we're moving right along.

12 MR. EICHENBERG: Right along.

13 CHAIR ARMIJO: That's all I can tell you.

14 MR. BROWN: Sam, don't forget Dennis is on
15 the phone.

16 CHAIR ARMIJO: Dennis, I'm sorry, did you
17 have any comments or questions?

18 MEMBER BLEY: Sam, thank you. Not really.
19 I was a little uncomfortable, I guess, seeing all the
20 different criteria apply to different plants, but
21 given the purpose of the analysis I think that's fine.
22 And I got a better picture of what some of the
23 problems might be on implementation, but I don't have
24 any further questions. Thank you.

25 CHAIR ARMIJO: Okay. All right. Well, it's

1 11:00 and we're way ahead of schedule, and I think we
2 should just keep moving, and there's no law against
3 finishing early.

4 MEMBER SHACK: Just a quick question. Is
5 there -- I was trying to figure out whether there was
6 some rationale for the way the implementation dates
7 were picked, and I couldn't come up with --

8 MR. CLIFFORD: We'll discuss that in the
9 next one.

10 MEMBER SHACK: Okay.

11 (Off the record comments.)

12 MR. CLIFFORD: Okay. When research yields
13 new information which brings into question existing
14 regulatory requirements, the Staff must address the
15 following questions. First, are the research findings
16 credible? Second, is it complete? Third, is there an
17 imminent risk to public health and safety? The
18 answers to these three questions inform the decision
19 on how quickly new requirements are developed and
20 enforced throughout the community or the industry.
21 The next two presentations will address these three
22 items and the Staff's recommendation on implementing
23 new requirements.

24 As some quick background we will touch
25 upon the research findings, and then we will go into

1 Staff's initial safety assessment followed by the
2 Generic Letter, and then the Staff's ECCS performance
3 assessment which builds upon the BWR and PWR Owners'
4 Group reports.

5 The first new embrittlement mechanism
6 identified by the Argonne Research Program was
7 hydrogen-enhanced beta-layer embrittlement.

8 Essentially, the pre-transient cladding hydrogen which
9 occurs as a result of water site corrosion during
10 normal operation has a direct impact on the rate of
11 embrittlement.

12 This figure here shows measured ductility
13 or deflection on samples that were fresh Zirc-4 and
14 high-burnup Zirc-4. You could see a clear shift in the
15 measured ductility as a function of CP ECR.

16 As a result of this new embrittlement
17 mechanism the allowable time at temperature to reach
18 nil ductility decreases, and this is clearly shown on
19 this plot. All of this information has been presented
20 prior to the ACRS.

21 CHAIR ARMIJO: Sure. That is the ring
22 compression test strain?

23 MR. CLIFFORD: Correct.

24 CHAIR ARMIJO: Okay.

25 MR. CLIFFORD: Well, actually, this would

1 be the ring compression test.

2 CHAIR ARMIJO: Yes, that one.

3 MR. CLIFFORD: And this would be the
4 threshold.

5 CHAIR ARMIJO: Right.

6 MR. CLIFFORD: You achieve 1 percent.

7 CHAIR ARMIJO: That's what I meant.

8 MR. CLIFFORD: The second embrittlement
9 mechanism is that oxidation which may be present on a
10 cladding ID can diffuse into the base metal, and
11 increase the rate of embrittlement. And whether or not
12 there is an oxygen source which is directly related to
13 a fuel clad bonding sensitive to burnup, power
14 history, and fuel rod design.

15 These figures just illustrate that an
16 alpha layer -- oxygen-stabilized alpha layer occurred
17 during testing both on the ID and the OD of high-
18 burnup fuel rod segments.

19 The third embrittlement mechanism
20 identified by research was a phenomenon we refer to as
21 breakaway oxidation. Essentially, there's a shift in
22 the structure of the oxide layer which causes it to
23 become unstable, and as a result it degrades and gross
24 amounts of hydrogen are taken up and it becomes
25 brittle due to hydrogen uptake.

1 We believe that the sensitivity of a
2 particular alloy to the timing at which breakaway
3 occurs, it would be sensitive to alloy composition and
4 fabrication.

5 MEMBER SHACK: We always show the worst-
6 case picture.

7 MR. CLIFFORD: Yes.

8 CHAIR ARMIJO: Yes, I think that's -- I
9 won't use the term "yellow journalism" but it's close.

10 MR. CLIFFORD: Remember the first question
11 was is the research credible? Well, the answer is yes.
12 NUREG-CR-6967 documents the research data. The
13 findings have been presented to this Subcommittee, and
14 I think everyone in this room believes that the new
15 embrittlement mechanisms are real and well supported.

16 The second question is, is the research
17 complete? The research conducted at Argonne included
18 testing on unirradiated hydrogen-charged and
19 irradiated fuel rod cladding segments, and included
20 many different zirconium alloy compositions.

21 The Staff did identify some small gaps
22 which needed to be filled to enhance this already
23 extensive empirical database to support the
24 rulemaking, and these are identified here on this
25 slide. And they were that there needed to be a few

1 additional tests at intermediate hydrogen levels,
2 there needed to be some breakaway oxidation tests
3 performed on transient temperature profiles, and there
4 needed to be a more robust technical basis for the
5 treatment inside the fuel rod burst region.

6 All this research has been completed.
7 This research has been presented to the ACRS
8 Subcommittee, and RIL-0801 is being supplemented to
9 capture all of the research that's been done since the
10 original July 2008 RIL-0801.

11 The third question was is there an
12 imminent risk to public safety? In response to RIL-
13 0801 NRR completed an initial assessment which its
14 purpose was to determine what course of action do we
15 take. Should we say oh, there's a problem, we need to
16 issue orders, we need to issue bulletins, we can
17 forward with rulemaking. So, you need to identify
18 first whether there's an immediate risk.

19 Well, based upon the measured cladding
20 performance from Argonne, crediting realistic rod
21 power histories and some current analytical
22 conservatisms in July 2008 we determined that there
23 was no imminent safety risk, and that the best course
24 of action was to proceed with rulemaking.

25 Recognizing that the finalization and

1 implementation of the new requirements would take
2 several years, the Staff decided that a more detailed
3 plant-specific safety assessment was necessary. To
4 obtain the necessary information, we developed a draft
5 Generic Letter, and held several public workshops.
6 And during those public workshops the industry
7 volunteered to provide all the data that the NRC was
8 seeking using an alternative means. And that was the
9 BWR/PWR Owners' Group reports which was previously
10 presented.

11 In addition to reviewing the Owners' Group
12 the Staff conducted audits of the Westinghouse, AREVA,
13 and GE engineering calculations, and based upon those
14 audits, the information collected during those audits
15 and the Owners' Group reports we concluded that there
16 was sufficient plant-specific information to complete
17 our safety assessment. And, therefore, no further
18 regulatory action was necessary, and the draft Generic
19 Letter need not be issued.

20 The next section we'll discuss how we use
21 the information that became available as a result of
22 the effort from the PWR/BWR Owners' Group to confirm
23 individual plant safety.

24 These ground rules were previously
25 discussed, so I won't go back into them except for

1 this plot. Dr. Armijo, you mentioned that you wanted
2 to see a plot where all the alloys are presented.
3 Here's kind of an illustration of the alloy dependency
4 of hydrogen pickup. If you convert the same -- if you
5 convert this curve using alloy-specific hydrogen
6 content convert from hydrogen to burnup you end up
7 with something that looks like this.

8 CHAIR ARMIJO: Yes. Now, in the case of the
9 ZIRLO is that the -- is optimized ZIRLO any different
10 than plain original ZIRLO?

11 MR. CLIFFORD: Yes, the oxidation can
12 significantly improve with optimized ZIRLO.

13 CHAIR ARMIJO: Okay.

14 MR. CLIFFORD: Hence, the name.

15 CHAIR ARMIJO: And it was optimized for
16 hydrogen pickup. Was that basically the --

17 MR. CLIFFORD: The pickup fraction was
18 approximately the same, so it would have a lower
19 oxidation, and at the same pickup fraction less
20 hydrogen.

21 CHAIR ARMIJO: Okay. But we don't have
22 that on that curve there. Is that proprietary? Is that
23 a reason for that?

24 MR. CLIFFORD: Yes.

25 CHAIR ARMIJO: Okay. But in time the

1 ZIRCALOY-4 will disappear from the fleet, and even the
2 old ZIRLO I would assume disappear, and optimized
3 ZIRLO would become their standard?

4 MR. CLIFFORD: I believe right now there
5 are only four plants that currently load fresh fuel
6 with ZIRC-4. And I believe they have plants -- I've
7 been informed that they have plans to migrate to some
8 advanced alloy. I can't speak -- Tom Rodack is
9 sitting behind you. Maybe he can speak to whether or
10 not the industry is moving off of ZIRLO to optimized
11 ZIRLO.

12 CHAIR ARMIJO: Yes.

13 MR. CLIFFORD: A handful of plants, but we
14 don't know the intent of the remaining fleet.

15 CHAIR ARMIJO: Okay. And in the pipeline
16 there would be new alloys. We know they're in
17 development, but they would have to comply with these
18 regulations and go through the testing to make sure
19 they were consistent.

20 MR. CLIFFORD: Absolutely.

21 CHAIR ARMIJO: Okay.

22 MR. CLIFFORD: Absolutely. Okay, a brief
23 survey of the available data that's in the plant
24 FSARs, here's a plot. The number of plants on the Y
25 axis and then you have calculated local oxidation.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 These may be a little -- what I did here was took the
2 maximum local oxidation from either the small break or
3 the large break. So, as you can see there are
4 approximately 40 plants that are calculated less than
5 3 percent ECR. And the numbers drops to about 25
6 between three and six, roughly 15 percent between six
7 and nine, and nine and twelve, and greater than
8 twelve. So, this just gives you a feel for how close
9 they were to the research data had they taken no
10 credit.

11 Here's a similar plot, number of plants
12 versus the calculated time above 800 C. As you can
13 see, a majority of the plants are less than 500
14 seconds. There's roughly 30 plants between 500 and
15 1,000, 10 plants between 1,000 and 2,000, and there's
16 one single unit greater than 2,000.

17 Post quench ductility. The revised post
18 quench ductility analytical limits. There may be a
19 slight difference between what was presented here and
20 what was presented by the Owners' Group only because
21 I combined the small-break and large-break, as I
22 mentioned. So, 65 of the 104 plants, approximately 63
23 percent of the fleet needed no adjustments, or new
24 calculations. That's 27 of 35 BWRs, and 38 of 69 PWRs.

25 All 104 plants continue to satisfy the

1 2,200 degree peak clad temperature criteria. And I
2 think that's important because most plants are limited
3 by that criteria, as opposed to being limited by local
4 oxidation. So, changes in local oxidation don't
5 necessarily restrict operation because they're limited
6 by 2,200.

7 Eight BWRs performed new LOCA calculations
8 using existing approved methods and credit to the COLR
9 TMOLs to reduce rod power to satisfy the new
10 requirements. Here's an example of a tech spec COLR
11 TMOL from a BWR.

12 This reduction in allowable rod power as
13 a function of burnup is not related to LOCA, it's
14 related to rod internal pressure concerns. So, the
15 thermal mechanical operating limits are driving or
16 requiring the power be lower at higher burnups for
17 another reason, but you can take credit for it in LOCA
18 space.

19 Thirty-one PWRs either performed new LOCA
20 calculations or identified credits. Some of this is a
21 repeat of what you presented so I won't spend too much
22 time on it.

23 CHAIR ARMIJO: Well, I'd like to make sure
24 you agree that those were okay to apply those credits.

25 MR. CLIFFORD: The next slide, when I talk

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 about the audit. I think it's important to note that
2 all the calculations were performed and documented in
3 accordance with the vendors' Appendix B Quality
4 Assurance Program. So, these weren't back of the
5 envelope calculations, these were documented, these
6 were validated, verified.

7 CHAIR ARMIJO: Good.

8 MR. CLIFFORD: With respect to breakaway
9 oxidation, all plants exhibit margin of breakaway. As
10 I mentioned, 103 plants predicted a time duration
11 above 800 of less than 2,000 seconds. On this table
12 you will see the measured breakaway times.

13 MEMBER REMPE: Is there a reason why the
14 ZIRLO value is different than what it was in your
15 letter in September? I mean, it's only 500 seconds,
16 but you had an asterisk in your table and I was always
17 wondering what the asterisk was for. And since we're
18 way ahead of time and schedule, I'll ask what it's
19 for. Then I noticed the time had actually changed.

20 CHAIR ARMIJO: It was 3,000, wasn't it?

21 MEMBER REMPE: It was 3,000 in the
22 September -- and then there was like an asterisk in
23 that table and I was just kind of wondering because I
24 couldn't figure out what the asterisk is for.

25 MR. CLIFFORD: Maybe someone from Research

1 wants to answer this. I mean, I could answer it, but
2 I'm not sure I'd give the right answer.

3 MEMBER REMPE: A wrong answer is fully
4 okay. Typo?

5 MR. CLIFFORD: No, it's definitely not a
6 typo. I would say there's been more testing done on
7 ZIRLO and there's been testing both by Westinghouse,
8 and testing at Argonne.

9 CHAIR ARMIJO: Yes, I recall that. There
10 was a difference of opinion --

11 MR. CLIFFORD: There was a difference of
12 opinion.

13 CHAIR ARMIJO: -- between Westinghouse and
14 Argonne, and there was more testing going on, but
15 that's all I remember. And at some point it would be
16 good to understand how he came to that number.

17 MS. FLANAGAN: Well, I'll say that the
18 asterisk in the previous presentation was to identify
19 that that value was under discussion. Why it's 3,500
20 seconds here I don't know. Is that -- because I didn't
21 make that slide. I don't know. There hasn't been an
22 agreement amongst everybody that there is a new value
23 and that is reflected there. I think it's just still
24 something that may come out in public comments that
25 there's still more work to do to come to agreement.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIR ARMIJO: At some point will we see a
2 chart showing optimized ZIRLO, if that's the direction
3 which the PWR -- at least Westinghouse is going with
4 their -- for breakaway?

5 MR. CLIFFORD: Correct. To implement the
6 final rule then each of the vendors would need to test
7 their alloys --

8 CHAIR ARMIJO: Right.

9 MR. CLIFFORD: -- propose a breakaway
10 time, minimum breakaway time. And we would review
11 those analyses.

12 CHAIR ARMIJO: You'll have to agree that
13 that's --

14 MR. CLIFFORD: Yes.

15 MR. RODACK: This is Tom Rodack from
16 Westinghouse. Just to clarify on the ZIRLO time to
17 breakaway oxidation, I haven't checked on this
18 recently but the last time we spoke I think the
19 agreement was that we would wait until the round robin
20 testing had proceeded and the Reg Guide was more
21 firmed up, and then decide on what the appropriate
22 value is for ZIRLO. We still think the value is too
23 low that's quoted here, so --

24 CHAIR ARMIJO: Well, you don't have to
25 answer but I sure would like to know what the

1 breakaway time for optimized ZIRLO is. Is it any
2 different, or is it better, or what?

3 MR. RODACK: We've done tests that confirm
4 that the breakaway oxidation time for ZIRLO and
5 optimized ZIRLO are greater than 5,000 seconds. And we
6 need to come to agreement on where those tests -- what
7 the appropriate procedures and so forth, and that's
8 the discussion.

9 CHAIR ARMIJO: Well, it would be pretty
10 important to resolve that thing before this all gets
11 settled.

12 MR. CLIFFORD: Absolutely.

13 CHAIR ARMIJO: Yes, because there's an
14 awful lot of ZIRLO out there in the plants.

15 MR. CLIFFORD: There is, and this is a good
16 exercise, but at the same time it doesn't influence
17 the safety assessment because there are now PWRs that
18 are close to 3,500.

19 CHAIR ARMIJO: No, I understand. I
20 understand, but it gets to another point that I wanted
21 to raise, and that's the issue of retesting and
22 reporting on breakaway oxidation. And this is
23 probably as good a time to raise that issue, is you've
24 got a lot of margin to breakaway. And the breakaway
25 picture that you show is really a demonstration of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 effects of fluoride contamination on a particular
2 Russian alloy. That's not radically different than
3 zirc-niobium alloys that we might use, but it's --
4 fluoride contamination has long been known in the
5 zirconium fabrication industry that it's bad news for
6 normal corrosion in any reactor, and enormous amounts
7 of care is taken to prevent that kind of
8 contamination. An enormous amount of care is taken on
9 all sorts of surface treatments on cladding because
10 without that you can get highly variable performance
11 under normal operating conditions, much less during
12 accidents.

13 And there's also a lot of effort on change
14 control because it's well recognized in the zirconium
15 fabrication business that changes in processing,
16 thermal processing, surface processing, etching,
17 cleaning, all of these things can have a profound
18 effect on just the standard operation of the fuel. So,
19 there's -- every change goes through a qualification
20 process. That doesn't mean that somebody couldn't make
21 a mistake sometime, an error which would be a Quality
22 Assurance issue, but as far as once the material is
23 qualified and demonstrates significant margin, I don't
24 see a justification for every reload to be tested as
25 if this was a highly variable, uncontrolled material.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So, I just don't see where the justification is to
2 require that. And the industry guys may think it's
3 just fine, but I'll just tell you, I just don't see
4 where it's -- it makes a lot of regulatory sense to
5 require something like that.

6 Maybe a new material where you don't have
7 much experience, even if it demonstrates margin, you
8 may want to keep track of it for a few reloads or few
9 years, but these pretty well known materials, I just
10 don't see how you can require that kind of reporting.

11 MR. CLIFFORD: Well, as you mentioned, the
12 vendor Quality Control process is aimed at oxidation
13 kinetics during normal operation. It's not targeting
14 what the oxidation kinetics are during a small-break
15 LOCA, so they haven't added a test to their QA or
16 Quality Control manufacturing process to account for
17 this.

18 CHAIR ARMIJO: They will.

19 MR. CLIFFORD: Will now.

20 CHAIR ARMIJO: They will now because -- and
21 that'll become just part of their normal Quality
22 Assurance program. It's just another thing they've got
23 to do. But to say -- and, obviously, they'll keep
24 track of that. But for every reload to say we've
25 tested this reload specifically for breakaway

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 oxidation every time you get a new reload seems to be
2 totally unnecessary. It's as if we required a specific
3 chemistry test when we buy something to an ASTM
4 standard, just -- okay, I've said all I want to say,
5 but maybe other members of the Committee have a
6 different -- want to add something there. It just
7 seems like regulatory overkill.

8 MR. CLIFFORD: Right. Well, our position
9 was the limited amount of testing that we had done
10 identified that there were alloying effects. And even
11 minor changes in alloy could affect the timing. I'm
12 not saying it would go from 5,000 to 500, but it would
13 change. And, also, that surface roughness and surface
14 contamination had a big impact on the timing of
15 breakaway. So, it's either that you do a very thorough
16 experimental set where you investigate all of these
17 variabilities and say okay, now that I've identified
18 all the sensitivities, I can then build it into a QA
19 process, so you don't have to run tests all the time
20 if you don't vary those one or two that are limiting.

21 Or you do the opposite and say just test
22 it before you put it in the reactor every time and
23 that way I don't have to worry about defining what all
24 the sensitivities are.

25 CHAIR ARMIJO: Well, remember that's a

1 sample. It's not -- what you really want to rely on is
2 that the process is under control. And let me tell
3 you what at least one vendor does, and I think it's
4 typical of all of the fuel manufacturers, is when you
5 have a process change, let's say you're going to go
6 from belt grinding to chemical etch, big change.

7 That process change goes through
8 qualification processing which it's varied. There's
9 a standard procedure, then there's variations on
10 temperature, the etchant, and concentration, so it
11 goes through a rather very broad testing to see if
12 you're on the edge of a cliff which relates to normal
13 corrosion. They test in steam, they test in water,
14 and in this case they would add a test or breakaway.
15 And they qualify the material, and they qualify the
16 process. And if they change the process, they'll go
17 through it again.

18 Now, what you've got to watch out for are
19 creeping changes that nobody spotted, and that's a
20 Quality Assurance thing, that's a change control
21 process, but -- and I could see if you were right on
22 the edge of margin, instead of 5,000 -- your ZIRCALOY-
23 2 having greater than 5,000, you were right up at
24 4,500, I'd say yes, you've got to keep a really close
25 -- you almost have to test each batch to be sure. But

1 when you have this much margin on a well known
2 material and a very controlled fabrication process, it
3 just seems excessive.

4 MR. CLIFFORD: I'm sure we'll get similar
5 comments from the industry.

6 CHAIR ARMIJO: Well, I don't know. It's up
7 to them. I'm not in the business any more.

8 MEMBER REMPE: Well, if they did they could
9 come in and ask for an exemption, and you'd review the
10 whole process.

11 MR. CLIFFORD: Well, this is still a draft
12 rule.

13 MEMBER REMPE: Right.

14 MR. CLIFFORD: If they provided significant
15 comment and could backup some of these strategies for
16 insuring that the cladding doesn't become more
17 susceptible, then we would consider them and maybe
18 alter the rule when it goes final. I mean, that's the
19 purpose of a draft rule is to go out there and let
20 everybody provide comment, and tweak as necessary.

21 CHAIR ARMIJO: Okay.

22 MEMBER SHACK: I mean, I thought the
23 original motivation was the one you described. You
24 really weren't quite sure what the mechanism was, and
25 until you're confident that you've controlled every

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 variable that could affect it --

2 MR. CLIFFORD: Right, and this margin is
3 really a snapshot in time. I mean, plants could make
4 some changes or there could be a new LWR design that
5 comes in that say has a time above 800 at 4,000
6 seconds. I don't know what the future is going to
7 bring.

8 CHAIR ARMIJO: You know, I think you would
9 -- you know, the closer you are to the margin, the
10 more you have to control it. It's as simple as that.
11 When you're far away from margin, that's -- I'm
12 repeating myself, so let's move on.

13 MR. CLIFFORD: Okay. As I mentioned, the
14 Staff conducted audits at the local offices of each of
15 the vendors to confirm -- first of all, we confirmed
16 that what they were assuming for analytical limits, in
17 other words, what targets they were shooting for were
18 acceptable, and that they were accurate and supported
19 by data. And that really goes down to the hydrogen
20 pickup models.

21 We also evaluated the quantification,
22 justification, and application of the analytical
23 credits. For instance, a good example would be six of
24 the PWRs large-breaks credited, the transition or the
25 potential transition from Appendix K to a Best -- or

1 realistic model. So, maybe they said okay, there would
2 be a 50 percent reduction -- if I had rerun my
3 analysis using one of these available realistic
4 models, it would be a 50 percent reduction.

5 During the audit we made sure that okay,
6 well that 50 percent was actually a minimum credit
7 they could get based upon a wide spectrum of plants
8 that already had demonstrated that that 50 percent
9 existed. In other words, it would look at every plant
10 that went from Appendix K to Best Estimate, what the
11 deltas were, and that what they were assuming in the
12 analysis was --

13 CHAIR ARMIJO: It passed the sanity check.

14 MR. CLIFFORD: That was reasonable and it
15 wasn't the maximum. We reviewed a sampling of the new
16 LOCA calculations in order to identify any changes to
17 the approved methods and models. And, finally, we
18 compiled plant-specific information to evaluate each
19 individual plant with respect to margin.

20 We created what we're calling the ECCS
21 margin database. It's an Excel spreadsheet that was
22 made available for this meeting. I don't know if
23 you've had a chance to look at it.

24 CHAIR ARMIJO: Yes.

25 MR. CLIFFORD: It's pretty comprehensive.

1 It goes through each of the -- plant by plant what the
2 current analysis of record, what cladding material
3 they are using, what sort of margin they're crediting,
4 and what their margin to the new requirements would
5 be.

6 Now, for the existing fleet our individual
7 plant safety assessment confirms and documents a
8 continued safe operation for the entire fleet. We
9 also evaluated the future operation of Watts Bar 2 and
10 potential startup of Bellefonte Units 1 and 2 with
11 respect to post quench ductility and breakaway.

12 But, in general, you know, the industry is
13 moving off of these old zirconium claddings and
14 they're moving on to advanced claddings, not to make
15 themselves have more margin for LOCA. They're doing
16 it for other reasons, but the net result is these new
17 cladding alloys have significantly improved corrosion
18 resistance. So, I'm not saying that this goes away,
19 but if you look at some of these advanced cladding, if
20 you end up with less than 100 ppm hydrogen uptake at
21 your end of life, you're pretty much around 17
22 percent, so it's not a big change.

23 CHAIR ARMIJO: Full circle.

24 MR. CLIFFORD: Yes, right. We also
25 evaluated the DCDs that are under review or have been

1 approved. This table here provides the calculated
2 peak clad temperature and ECR for four of the advanced
3 designs.

4 In general, the advanced designs have
5 enhanced ECCS capabilities, so that LOCA is not as
6 limiting as it is for the current fleet.

7 MEMBER SHACK: Until they do their uprates.

8 (Laughter.)

9 MR. CLIFFORD: But also remember when these
10 plants startup, they're going to be starting up with
11 the latest and greatest cladding alloy. They're not
12 going to be starting up with some of the alloys that
13 a higher hydrogen pickup.

14 CHAIR ARMIJO: In these assumptions you use
15 the old standard materials like for the --

16 MR. CLIFFORD: No, these results were just
17 right from the design certification documents. Like
18 for instance, ESBWR there's no uncover or heat up.

19 CHAIR ARMIJO: Yes.

20 MR. CLIFFORD: The other one, the peak clad
21 temperatures are all below 1,900 and the ECRs are very
22 low.

23 CHAIR ARMIJO: Right.

24 MR. CLIFFORD: So, they all have a lot of
25 margin to what you would expect with the cladding

1 alloy they'd be using. So, all I'm trying to say is
2 that the advanced reactors have significant margin.

3 Now, the plant safety assessment is really
4 a snapshot in time. We took the current analysis of
5 record, we said where are they relative to what the
6 research data, and we showed that there was sufficient
7 margin. But, once again, it's a snapshot in time. How
8 do we insure that going forward that before the new
9 rule is implemented that they don't migrate into an
10 area where they have less margin or no margin?

11 But I think it's important to recognize
12 that plan changes which could impact the margin
13 assessment would most likely involve a license
14 amendment request. I mean, what's going to impact your
15 LOCA analysis would be a major plant modification like
16 new steam generators, a power uprate, a change in fuel
17 vendors or fuel design, or changes in LOCA methods.
18 That's what's going to impact your LOCA analysis of
19 record, and then potentially impact the amount of
20 margin you have.

21 And when a new license amendment request
22 comes in that gives us a vehicle for then asking the
23 question, how does this impact how much margin you
24 have relative to the data, since you haven't
25 transitioned yet?

1 And with respect to unplanned changes, we
2 have the existing 50.46(a)(3) reporting requirements.
3 Now, this is the 30-day notice, or the annual notice
4 that we get from each of the licensees if they were to
5 discover an error or make a change to their model.
6 So, we get periodic updates that let us know whether
7 or not they've changed their analysis of record. If
8 they haven't changed their analysis of record in that
9 year, then we know the margin assessment is still
10 valid. And if it has changed, we have a vehicle to
11 then ask the question.

12 So, how we're going to use this
13 information is really -- the next slide. This is kind
14 of our action plan. If it takes five or six years, or
15 ten years, or however it long it takes to implement
16 these new requirements, we're going to follow this
17 action plan to make sure the plants continue to be
18 safe.

19 And the first is, on an annual basis we're
20 going to update the ECCS margin database. That
21 doesn't mean that we're not reviewing it all the time.
22 I'm just saying on an annual basis, we'll just pick a
23 date, September 1st say and just update the margin
24 assessment database. On a continuous basis we'll
25 scrutinize any 30-day reports that were received which

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 would be more than 50 degrees. If it's less than 50
2 degrees, it's probably not going to impact how much
3 margin you have because none of these plants are that
4 close. But if it's several hundred degrees, we'll
5 have to question that. But we have a vehicle for doing
6 that.

7 On a continuous basis each time we receive
8 a license amendment request, we'll ask about existing
9 margin, and the continued applicability of the margin
10 assessment.

11 And, finally, we conduct annual meetings
12 with the fuel vendors where we go through pretty much
13 everything that's fuel-related, new topical reports,
14 new cladding materials, new alloys, fuel performance.
15 And during those meetings we can use those to get a
16 feel for what's changing, what's down the road. Who's
17 doing an uprate, how all that impacts --

18 CHAIR ARMIJO: You also visit their
19 factories and go over their processing and things like
20 that, don't you? You get a chance to talk to them
21 about their -- literally, their Quality Control on
22 issues like this.

23 MR. CLIFFORD: Well, we certainly tour
24 their facilities, and we're well aware of their
25 facilities. I believe Region II, though, has the

1 responsibility of their Appendix B-type fuel-fab
2 program.

3 CHAIR ARMIJO: That's an ideal place to
4 find out what kind of process changes are going on
5 that would affect --

6 MR. CLIFFORD: Exactly. Okay, conclusions.
7 The Research identified new embrittlement mechanisms
8 which need to be addressed. Based upon our
9 assessment, a majority of plants need no new
10 calculations or analytical adjustment to show margin
11 for these potentially new requirements. The margin
12 database confirms and documents on a plant-specific
13 basis the continued safe operation of the existing
14 fleet. And the Staff will continue to confirm plant
15 safety until new regulations have been implemented.

16 CHAIR ARMIJO: Any questions from the
17 Committee?

18 MEMBER SHACK: There was a statement that
19 the new rule was going to address Mr. Lacey's
20 petition, and I haven't seen anything that really does
21 that. Is it something in the Statement of
22 Considerations?

23 MR. CLIFFORD: There was an analytical
24 requirement added to the rule itself that said the
25 effects of crud have to be accounted for.

1 MEMBER SHACK: I missed it. I missed it.

2 MR. CLIFFORD: So, any new LOCA model we
3 review they would have to say how are they accounting
4 for crud.

5 MEMBER SHACK: I missed it.

6 CHAIR ARMIJO: Paul, don't most of them
7 already do that?

8 MR. CLIFFORD: A lot of them. I can't say
9 -- there are a lot of LOCA models dating back decades
10 some of them. A lot of them do.

11 CHAIR ARMIJO: Yes.

12 MR. CLIFFORD: I can't say that they all
13 do.

14 CHAIR ARMIJO: Okay.

15 MR. CLIFFORD: But they may not
16 specifically account for it, but the way you measure
17 oxidation layers, sometimes you get the tenacious crud
18 that's mixed in with the oxide when you do your eddy
19 current testing.

20 CHAIR ARMIJO: Yes.

21 MR. CLIFFORD: You get a combination of the
22 two, so when you adjust your oxidation model you're
23 kind of getting the inherent -- some inherent effects
24 of tenacious crud.

25 CHAIR ARMIJO: Yes. Yes. Is that it?

1 MEMBER BLEY: This is Dennis Bley. I have
2 one question about the database you gave us. Are the
3 results that are in there based on the Owners' Group
4 calculations that we heard about from them earlier?

5 MR. CLIFFORD: Yes.

6 MEMBER BLEY: Okay, so these aren't what I
7 call real margins. These are margins adjusted for the
8 kind of calculations they explained to us.

9 MR. CLIFFORD: Correct.

10 MEMBER BLEY: Enough to show margin, but
11 not enough to really define what the margin is. To set
12 a bound on the margin.

13 MR. CLIFFORD: Correct.

14 MEMBER BLEY: Okay, thanks.

15 MR. CLIFFORD: Right. It's a minimal amount
16 of margin necessary to meet the research data. Were
17 there any more questions on the database itself?

18 CHAIR ARMIJO: No, good job.

19 MR. CLIFFORD: The next presentation
20 involves the implementation plan, and it really builds
21 on what we learned from this margin assessment.

22 CHAIR ARMIJO: Yes. What I'd like to do is
23 just poll the Committee. We're well ahead of
24 schedule, but we're getting close to noon and we have
25 the implementation presentation, then we have some

1 Committee discussion. And how do you guys feel about
2 just adjourning for lunch and coming back at -- pick
3 a time, 1:00 and wrapping it up? We were supposed to
4 go to lunch between 1:30 -- I'm sorry, between 11:30
5 and 12:30, so we could come back at -- give ourselves
6 another 5 minutes, come back at 1:00 and wrap this up?
7 I don't really want to push through lunch.

8 MEMBER REMPE: But he only has 10 slides in
9 his next presentation. It's up to you all. I'm willing
10 to do either.

11 CHAIR ARMIJO: Well, you don't have to
12 leave until 3:00.

13 MEMBER REMPE: Right. I'm good either way.
14 It doesn't matter. It's just that it's a fairly short
15 presentation.

16 CHAIR ARMIJO: Well, just for continuity,
17 because then -- why don't we just take a lunch break
18 and regroup at 1:00. Okay, so we'll have an hour and
19 15 minutes for lunch, and then we'll wrap everything
20 up, and you can go home, and we'll be done.

21 MEMBER SHACK: Well, if Joy's got a 3:00
22 flight --

23 MEMBER REMPE: No, I have a 5:00. I have to
24 leave here about 3:00 or so.

25 CHAIR ARMIJO: Yes, she's got it at 3:00.

1 MEMBER REMPE: So, I've got plenty of time
2 either way. I just thought --

3 CHAIR ARMIJO: Okay, so why don't we do
4 that? We'll reconvene at 1:00.

5 MEMBER REMPE: Great.

6 (Whereupon, the proceedings went off the
7 record at 11:43:18 a.m., and went back on the record
8 at 12:58:16 p.m.)

9 CHAIR ARMIJO: Okay, let's resume. And we
10 are now on Implementation Schedule. Paul is going to
11 present that.

12 MR. CLIFFORD: Okay, welcome back. I've got
13 a handful of slides I'm going to go through, but as
14 I'm going through it, it may be helpful to kind of --

15 (Simultaneous speech.)

16 CHAIR ARMIJO: Get out the big gun.

17 MR. CLIFFORD: And this will give you a
18 feel as I walk through it how it all falls together,
19 and how much work there is.

20 (Off the record comments.)

21 MR. CLIFFORD: We're just going to talk
22 about the work scope, the overall implementation
23 strategy, and then how it all comes together for the
24 existing fleet, and for new plants.

25 This slide is just intended to illustrate

1 the potential scope of work that needs to be completed
2 by the industry and the NRC to implement this rule. We
3 don't have to walk through all of them, but you can
4 kind of see the magnitude of work. And I highlighted
5 in blue the actual plant-specific LOCA analysis,
6 preparation of any license amendment request, and then
7 Staff review as being an exceptional amount of work,
8 more so than updating a single model.

9 Don't get me wrong, it takes some effort,
10 but then implementing that model across 50 plants is
11 a significant effort. So, we've kind of devised a
12 strategy to limit that one particular aspect of the
13 implementation, and I'll get to that.

14 Based upon comments we received in the
15 ANPR which identified workforce limitations to
16 complete a parallel analysis stream, we came up with
17 a staged implementation plan as being the most
18 effective and efficient way to implement 50.46c.

19 Our original intent was that plants with
20 the least available safety margin would be required to
21 be in compliance at the earliest date. And this shows
22 you Track 1 would be the least amount, Track 3 would
23 be the most available margin. And this would be
24 informed by the safety assessment that we completed.

25 MEMBER SHACK: We've just agreed it doesn't

1 really show the actual margin. They just carried it
2 out far enough to demonstrate margin.

3 MR. CLIFFORD: Right. Well, I'll get to
4 that point. Next is you need to recognize that the
5 plants with the least amount of margin are going to
6 require the most amount of effort, and probably the
7 longest calendar time to demonstrate compliance. And
8 that as we learned earlier, there's a substantial
9 number of plants that don't have to do a lot of re-
10 analysis to show compliance. So, why would you want
11 the 60 or so plants that could be in compliance now to
12 wait years for the handful of plants that have to do
13 a lot of work?

14 So, you still -- so, we tried to combine
15 those two thoughts. Let's try to get as many plants
16 into compliance as fast as we can, but at the same
17 time give more time to the plants that need more time
18 to update models and methods.

19 So, we balanced those two initiatives and
20 we came up with a plan that, one, expedites the
21 implementation as soon as possible on as many plants,
22 still maintains a prioritization except now it's
23 between Track 2 and Track 3, and balances the work
24 load. We drew lines on the number of analysis so that
25 we could balance the workload between Tracks 2 and 3.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And what we came up with is summarized in this table.

2 There's three tracks. The first track
3 would be plants that do not need any new analysis or
4 changes to their existing LOCA models or methods. We
5 anticipate that the level of effort is low, and we've
6 identified 27 BWRs and 38 PWRs that fall into this
7 category.

8 The second implementation track is plants
9 that we feel have the least inherent margin. And those
10 are plants that require analytical credits in
11 combination with realistic LOCA models. And then we
12 divided by BWRs between BWR-2s and 3s, and we felt
13 BWR-2s had the least amount of margin so we moved them
14 into Track 2.

15 And Track 3 is the PWRs that required some
16 analytical margins, but at the same time used Appendix
17 K. So, we knew there was a lot of inherent margin in
18 an Appendix K analysis. So, although they may not have
19 credited all that margin, it's available. So, we
20 lumped in those plants with the BWR-3s. And you may
21 see differences, there are 16 plants on Track 2, and
22 there's 23 plants on Track 3, but if you look at the
23 number of multi-unit sites, it turns out to be the
24 identical number of analyses that have to be done. Any
25 questions on that?

1 (No response.)

2 MR. CLIFFORD: Okay. Ralph is going to go
3 through these next two slides, because I know he's
4 been wanting to talk.

5 (Laughter.)

6 CHAIR ARMIJO: Okay.

7 MR. LANDRY: Okay. When we started looking
8 at how to implement the new regulation, we started
9 looking at where are plants with regard to licensing
10 today, and said we have plants in various stages. We
11 have plants that are already licensed.

12 First we said okay, we've got the
13 operating plants, those are already licensed. And we
14 have the new reactors. And then we started going
15 through the new reactors and saying with the new
16 reactors we have probably ever possible permutation
17 and combination you could get. And then went back and
18 looked at the operating reactors or the old reactors
19 and said what we really need to do is break this down
20 into Part 50 reactors, and Part 52 reactors, because
21 under the Part 50 plants, we have those who are
22 operating. We have those that have now reinstated or
23 resumed their construction permits.

24 How do we apply this regulation to those
25 plants and said well, we have to consider those that

1 have construction permits issued after the effective
2 date of the rule under Part 50, and say those plants
3 have to be in compliance with the rule when they come
4 in.

5 On the other hand, those operating
6 licenses are issued based on a construction permit
7 already in effect, which is really only two plants
8 today. They have to comply with the requirements of
9 the rule according to the dates set forth in Table 1,
10 which Paul has gone through that whole table and
11 tracking system.

12 Those whose operating license were issued
13 prior to the effective date of the rule have to come
14 into compliance according to Table 1, the layout of
15 the multi-track system. And those with operating
16 license issued after the effective date of the rule
17 have to comply with the conditions of the rule.

18 So, this separates a little bit those that
19 are already under an old construction permit from
20 those who might get a new construction permit under
21 Part 50. And we put this in because some of the
22 advanced reactors, not the new reactors, but some of
23 the advanced reactors are saying they might come in
24 under Part 50 instead of Part 52, even though right
25 now the plan is that they will be reviewed in the

1 Office of New Reactors, but they will be Part 50
2 plants. So, they will have to go through the two-step
3 process of a construction permit followed by an
4 operating license.

5 So, we tried to go through the logic of
6 the plants that exist today and plants that are being
7 built today, the plants that would be under Part 50,
8 this is one group. Now we're going to look at the
9 Part 52. And what is in the proposed regulation today
10 for the Part 52 plants is significantly different than
11 what it was four months ago, because we have changed
12 this a couple of times trying to figure out what is
13 the most streamlined way to approach the Part 52
14 plants?

15 And this becomes complicated because we
16 have plants that have design certifications already
17 approved. Some of those will probably never be built,
18 some of those will be built, some of those are going
19 to have to get a certification renewal before they can
20 get built. We have certifications in for review today
21 that are nearing completion that have combined license
22 applications associated with them which will be
23 completed before this rule is approved.

24 We have some certifications that we
25 project out won't be approved until after the

1 effective date of the rule. And we have some that will
2 no doubt come in after the rule is effective. So, how
3 do we make sense out of this group?

4 We in the Office of New Reactors felt very
5 strongly that the new reactors should not be treated
6 according to Table 1, or any kind of requirement that
7 they have to comply with the rule immediately if
8 they're already in the stream, because they will not
9 have fuel that has been exposed.

10 A new reactor is going to, by definition,
11 have completely clean fuel. It's not going to be a
12 reload core with partially burned fuel, it's going to
13 be a completely clean core. Plus the fact that a lot
14 of the plants that are in for certification we know
15 are going to have different fuel when they actually
16 start to operate than the fuel that's reviewed for
17 their certification.

18 So, how do we make sense out of this?
19 Well, we came back and said okay, all applications
20 docketed after the effective date of the rule, that
21 means design certifications, combined licenses, you
22 come in after the effective date of the rule, you
23 comply with the rule.

24 Those standard designs renewals that are
25 sent in after the effective date of the rule; in other

1 words, if some plant that's on the shelf right now
2 does not have to have a renewal until after the
3 effective date of the rule, that design certification
4 renewal must comply with the rule.

5 Standard design applications pending at
6 the effective date of the rule, those that we have
7 right now, assuming that AP1000 will be complete
8 before the effective date; there's pretty good
9 indication of that. If we have one of the others
10 that's in, the design certification gets in before the
11 effective date, is pending at the effective date, they
12 have to comply with the conditions of the rule when a
13 renewal is submitted, so that if US-APWR is not
14 completed by the time the rule is final, the US-APWR
15 design certification would not have to comply with the
16 rule until it submits a renewal.

17 The combined licenses that are docketed
18 after the effective date of the rule have to comply
19 with conditions of the rule. It's a pretty simple
20 requirement. But the combined licenses that have been
21 docketed or issued -- now that means if you get in
22 before the rule is final, or you're in and you get
23 your combined license before the rule is final, you
24 don't have to comply with the rule until your first
25 refueling outage. You can refuel the plant, but before

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 you can start the plant up again, you now have to be
2 in compliance with the rule.

3 So, that's saying if Vogtle gets their
4 COL, they get the plant built, and then the rules come
5 in, they don't have to meet the rule until they refuel
6 the plant. When they refuel it before they can start
7 back up they have to be in compliance. And we're
8 covered on all these plants anyway because all of them
9 still have to meet 50.46.

10 When we look at all the different plant
11 states that you could mix together here, we tried to
12 find what was the most rational way to handle all the
13 combinations and permutations that could exist. It
14 makes it very complex, and it could be very confusing
15 to work through and say I have a plant, where does my
16 plant fall in this implementation plan? But we're
17 trying to do it in a fair manner. And sometimes people
18 say well, you're the NRC.

19 CHAIR ARMIJO: Ralph, I'd like to ask you
20 a question.

21 MR. LANDRY: Seriously, we tried to look at
22 all the conditions that you could have, and we tried
23 to find what is a logical way to treat them.

24 CHAIR ARMIJO: Let me ask a question. Let's
25 hypothesize that you had ESBWR certified. Now, based

1 on the design the core is never uncovered. You don't
2 get peak clad temperatures. Does this rule apply to
3 the ESBWR?

4 MR. LANDRY: Yes, the rule will still
5 apply.

6 CHAIR ARMIJO: Do they have to do anything?

7 MR. CLIFFORD: It would be simple for them
8 to show compliance, but they would still have an
9 analysis that shows they don't uncover, so they're
10 still calculating --

11 CHAIR ARMIJO: That's part of the
12 certification that's been done.

13 MR. LANDRY: But you have to keep in mind
14 if they get their certification before the rule is
15 final, they don't have to comply with the rule until
16 they come in for a renewal. They have 15 years from
17 the date of certification until they have to renew.

18 CHAIR ARMIJO: But that's not the first
19 reload then. It's not --

20 MR. LANDRY: But a plant referencing them
21 falls into the operating combined license group. Now,
22 they have to comply according to when they get their
23 COL.

24 MR. CLIFFORD: It's compliance of the
25 licensee versus compliance of the design.

1 CHAIR ARMIJO: But the licensee would
2 reference the design and say we don't uncover the
3 core.

4 MR. LANDRY: But you're still covered by
5 the rule.

6 CHAIR ARMIJO: Yes, but they'd be able to
7 say we don't uncover the rule, we comply with the rule
8 by virtue of the fact we don't uncover, and we're
9 certifying that --

10 MR. LANDRY: Well, they have to show it
11 somehow.

12 MR. CLIFFORD: It would be on the analysis.
13 They would not have to repeat the analysis because it
14 shows that they're --

15 CHAIR ARMIJO: Unless something changed a
16 lot.

17 MR. LANDRY: Keep in mind, Sam, that once
18 every operating reactor has implemented the
19 regulation, 50.46 goes away and is replaced by 50.46
20 what is now (c), we'll drop the (c), and that will be
21 50.46.

22 CHAIR ARMIJO: Right.

23 MR. LANDRY: So, you have to be in
24 compliance with something. If you're in compliance
25 with the regulation on the books today and that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 regulation goes away, what do you do?

2 CHAIR ARMIJO: Yes.

3 MR. LANDRY: You have to come into
4 compliance.

5 CHAIR ARMIJO: Okay.

6 MR. LANDRY: Now, this gets really messy
7 when we look at --

8 CHAIR ARMIJO: It sure does.

9 MR. LANDRY: -- all these conditions, and
10 we look at -- we don't want all of these different
11 regulations on the books. Eventually, we want one
12 regulation.

13 MR. DUNN: Dr. Armijo?

14 CHAIR ARMIJO: Yes?

15 MR. DUNN: Could I ask one question?

16 CHAIR ARMIJO: Sure. Can you state your
17 name for the record.

18 MR. DUNN: My name is Bert Dunn. I'm from
19 AREVA. Thank you.

20 In the case that we just brought up where
21 we've got a BWR that never uncovers the core, are you
22 still going to apply the breakaway oxidation testing
23 to the fuel, things that apply that the plant will be
24 using, or would you wind up making an exception for
25 that point? It's a little bit ridiculous for a plant

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that's never going to go over 600 degrees testing for
2 breakaway oxidation.

3 MR. CLIFFORD: I agree, but it's unlikely
4 that that plant will use a unique cladding type, so
5 there will be -- if it's using M5, first of all --

6 (Simultaneous speech.)

7 MR. DUNN: -- tested every reload. Right?

8 CHAIR ARMIJO: Well, that's something that
9 should be raised in the public comment.

10 MR. DUNN: Okay.

11 (Simultaneous speech.)

12 CHAIR ARMIJO: The specific issues that
13 you've got to take --

14 MR. LANDRY: Bring it up in the public
15 comment, but there always the exemption route also.

16 CHAIR ARMIJO: But exemptions are painful
17 processes, at least to somebody. One of the reasons
18 we're doing this is because too many exemptions.

19 MR. LANDRY: Well, we've tried to make the
20 implementation and application of the regulation as
21 uniform and as logical as we could. And you can
22 probably go out and find some exception to it if you
23 really want to.

24 CHAIR ARMIJO: Yes, I understand that. You
25 know, there's a lot of complications. Certainly, we're

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 not going to sort this out, you guys do this all the
2 time.

3 MR. CLIFFORD: I don't have a slide listing
4 Table 1, but it was provided in the handout. This
5 just lists all of the plant -- identify all the plants
6 that fall into this implementation logic. I wanted to
7 clarify something here.

8 Even though we're moving the Track 3
9 plants, the ones with the most margin to the
10 beginning, that doesn't affect the implementation
11 schedule for Track -- for the Track 1, Track 2 as
12 labeled here.

13 (Simultaneous speech.)

14 MR. CLIFFORD: -- limited by first you've
15 got to do the models, get the models approved, and
16 then do the analysis. So, it's going to take as long
17 as it's going to take. And by moving these 65 plants
18 in front of them, that doesn't necessarily push those
19 further down in the implementation schedule. I think
20 that's important to say.

21 And another thing is, at the beginning I
22 mentioned that the blue highlighted text here
23 represents a significant amount of work. I'll give you
24 an example. Okay, there's a plant out there that's
25 using an Appendix K model that's calculating 1 percent

1 ECR. So, in theory to show full compliance they would
2 have to -- some of them would have to come in with a
3 revision to their Appendix K model whereby they would
4 update it to include a Cathcart-Pawl calculation of
5 local oxidation which is the equation you need to
6 integrate time at temperature to be consistent with
7 the experimental database. And they would need to have
8 an alloy-specific hydrogen uptake model -- uptake
9 model, sorry.

10 So, they would need to get those models
11 approved. Then they would redo their LOCA analysis,
12 calculate integrate time at temperature with both
13 Baker-Just and Cathcart-Pawl, compare their Cathcart-
14 Pawl ECR to the allowable value for their given alloy-
15 specific hydrogen model, generate a license amendment
16 request, and then submit that to the NRC, and then we
17 would review that.

18 Now, that's a significant amount of work
19 for a plant that's calculating 1 percent now. So, one
20 idea we were pushing, and we started to include in the
21 Statement of Considerations was a way to avoid the
22 license amendment request for the Track 1 plants.

23 We would review and approve each hydrogen
24 uptake model and the licensees in Track 1 would simply
25 just refer to it, update their FSAR to capture that

1 they're in compliance now, and they're using approved
2 methods. And we wouldn't review the plant-specific
3 application of those models.

4 CHAIR ARMIJO: Paul, that sounds like a
5 very good idea, but I'm hung up on the hydrogen uptake
6 models for the conventional materials that we're
7 currently using.

8 Who actually submits that? Different
9 people make Zircaloy-2, different fuel vendors. Is it
10 going to be a combined hydrogen uptake model, is it
11 going to be an NRC hydrogen uptake model? Don't we
12 have enough data now to literally say this is it? The
13 same goes for the other alloys.

14 MR. CLIFFORD: We have -- based upon
15 information that's available in the public domain,
16 we've developed hydrogen uptake models for each of the
17 cladding alloys, and we have them built into FRAPCON
18 right now. But we would expect that each of the
19 vendors would use both a combination of proprietary
20 and publicly available data to come up with the best
21 hydrogen model that they could and submit it. We
22 would approve it, and with that approval they would
23 provide a chart of allowable ECR versus burnup for
24 each of their alloys. We would approve that, so now
25 we've approved the new limits, analytical limits for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 each of the plants.

2 CHAIR ARMIJO: What if the vendors said
3 we'll use your FRAPCON hydrogen uptake model, and we
4 won't take exception to it, would that be acceptable?

5 MR. CLIFFORD: That's a good question
6 because we said at the beginning of this exercise with
7 the Owners' Group that we would allow them to do that
8 for this margin assessment, but we would expect that
9 they would supplement that database with data they
10 have -- we believe that they have available that's not
11 publicly available. Everything in FRAPCON has to be
12 publicly available.

13 CHAIR ARMIJO: I understand that.

14 MR. CLIFFORD: We expect that they have a
15 larger database available to them to improve upon the
16 models. Plus our models are somewhat simplistic as
17 we've taken all the data as a function of burnup. You
18 really don't want corrosion models as a function of
19 burnup. Burnup is not the correct dependency.

20 CHAIR ARMIJO: No, it's exposure time.

21 MR. CLIFFORD: It's exposure time.

22 CHAIR ARMIJO: Right.

23 MR. CLIFFORD: I mean, the last two years
24 a fuel rod is in the reactor for its third cycle. It's
25 only getting five or six gigawatt days, but it's in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 their for two years.

2 CHAIR ARMIJO: Right.

3 MR. CLIFFORD: Whereas, in the first two
4 years it's getting 24-gigawatt days. So, burnup is
5 not the right variable there. So, they would probably
6 come in with more of a fuel duty or time at
7 temperature model.

8 CHAIR ARMIJO: Do you perceive that
9 different vendors would have different hydrogen uptake
10 models for the same alloy?

11 MR. CLIFFORD: Absolutely.

12 CHAIR ARMIJO: AREVA, Zircaloy,
13 Westinghouse, Zircaloy.

14 MR. CLIFFORD: Absolutely.

15 CHAIR ARMIJO: GE --

16 MR. CLIFFORD: They have different thermal
17 treatments, and the thermal treatments can affect the
18 corrosion.

19 CHAIR ARMIJO: That would be your logic for
20 that.

21 MR. CLIFFORD: Yes.

22 CHAIR ARMIJO: Okay.

23 MR. CLIFFORD: I think we've seen enough
24 data to know that the Westinghouse BWR Zirc-2 has a
25 different hydrogen uptake than say the GE Zirc-2.

1 CHAIR ARMIJO: Okay. All right. So, I see
2 why this thing is not done already.

3 MR. CLIFFORD: That's what I was --

4 CHAIR ARMIJO: You had enough to do this
5 assessment but it's not really good enough, in your
6 opinion, for --

7 MR. CLIFFORD: Correct.

8 CHAIR ARMIJO: -- an amendment, or even
9 the Track 1 analysis, or do they need that?

10 MR. CLIFFORD: No, I believe they're going
11 to have to submit hydrogen uptake models for each of
12 the alloys before Track 1.

13 CHAIR ARMIJO: Okay.

14 MR. CLIFFORD: Is there any questions --

15 MEMBER SHACK: Well, I guess, I mean you
16 can use that, you can use it as some sort of a
17 bounding model. I presume you could include it into
18 your Best Estimate or your realistic calculation as
19 part of the sampling process. You'd have a
20 statistically-based model. There are lots of
21 permutations one could get into here.

22 MR. CLIFFORD: That is true. That is true.

23 MEMBER SHACK: And I could envision
24 Appendix K guys looking for a bounding model,
25 realistic people looking for distribution models.

1 CHAIR ARMIJO: Right.

2 MR. CLIFFORD: If they would statistically
3 sample hundreds of cases, each one would be a
4 different rod at a different burnup with a different
5 hydrogen model -- a different amount of hydrogen in
6 it, and a different allowable ECR --

7 MEMBER SHACK: Well, I haven't thought
8 through whether it's sensible to do that, or just what
9 the sampling would look like.

10 CHAIR ARMIJO: Well, it's a long schedule.

11 MR. LANDRY: We're saying in theory yes,
12 that's possible. It all depends on what the vendor
13 wants to do. If they want to take enough data to
14 support a PDF, or do they want to just use a bounding
15 number? We're not telling them what to do.

16 MEMBER SHACK: If you don't have enough
17 data for a PDF, it's hard to know that you've got a
18 bounding value.

19 CHAIR ARMIJO: Yes.

20 MR. LANDRY: When they come in we'll review
21 it.

22 CHAIR ARMIJO: Yes. Okay, I understand what
23 you're doing.

24 MR. CLIFFORD: But, also, the variability
25 in measured hydrogen actually and circumferentially is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 tremendous, but that's on alloys that have a lot of
2 hydrogen. When you get to the more advanced alloys
3 that are only picking up 100 or 200 ppm, that
4 variability is not that big of a deal any more.

5 CHAIR ARMIJO: Yes, who cares? Yes, so it
6 all depends how long it takes to put these packages
7 together and you could clear out Track 1 pretty quick.

8 MR. CLIFFORD: Yes.

9 CHAIR ARMIJO: But is that your proposed
10 plan, not requiring license amendment requests for the
11 Track 1 guys?

12 MR. CLIFFORD: That's what we're going to
13 put in the Statement of Considerations.

14 CHAIR ARMIJO: Okay. All right. Any other
15 questions? Joy? Bill? Dennis, are you on the phone?

16 MEMBER BLEY: Yes, I am, Sam.

17 CHAIR ARMIJO: Do you have any questions or
18 comments on Paul's presentation?

19 MEMBER BLEY: No. They're right, it's very
20 complex.

21 CHAIR ARMIJO: Do you have the big chart?

22 MEMBER BLEY: Yes, I have it. I'm looking
23 at it.

24 CHAIR ARMIJO: All right. We're all
25 staring, but I think it lays it out. It's a lot more

1 work than I thought was needed. Okay.

2 All right, Paul. Have you presented
3 everything you want to do? All right. Before we go
4 into Committee discussion, is there anyone on the --
5 in the room who would like to make any comments,
6 members of the public, Staff, anyone?

7 (No response.)

8 CHAIR ARMIJO: Okay. Let's open up the
9 bridge line and see if anyone is on the bridge line
10 that would like to make a comment.

11 MR. CLEFTON: This is Gordon Clefton, NEI
12 on the bridge line.

13 CHAIR ARMIJO: Okay. I'm sorry, I didn't
14 hear the last name.

15 MR. CLEFTON: Last name is Clefton.

16 CHAIR ARMIJO: Clefton?

17 MR. CLEFTON: Gordon Clefton.

18 CHAIR ARMIJO: Please go ahead.

19 MR. CLEFTON: Yes, sir. I'd like to
20 compliment Paul for the great job that he did in
21 recognizing how complex the issue is, and encouraged
22 to see the NRC cooperation that we've had in the past
23 year to get to the level we are now.

24 Of course, we have quite a bit of ways to
25 go. Paul and I have talked in terms of workshops and

1 public meetings to insure data transfer in the spring,
2 and we certainly encourage that activity to continue
3 and look for your endorsement of it.

4 CHAIR ARMIJO: Very good, thank you. Is
5 there anyone else on the bridge line that would like
6 to make a comment?

7 (No response.)

8 CHAIR ARMIJO: Okay, hearing no comments
9 we'll just close the bridge line and I'll just now
10 turn to Committee members if they want to make any
11 closing remarks or observations, or things that you
12 might suggest the Staff consider for the presentation
13 in January. We have let's see, January 19th or 20th?

14 MR. CLIFFORD: I think it's the 19th.

15 CHAIR ARMIJO: The 19th we have a full
16 Committee. And, obviously, we don't have as much
17 time, but -- so we'll have to really condense this
18 down, but I think you've got a very solid presentation
19 so I don't think it's going to be much of a problem.
20 But let's start with Joy.

21 MEMBER REMPE: I just wanted to thank the
22 Staff. I thought the presentations were well
23 organized, and I learned a lot, even though we viewed
24 this previously, it just was a nice overview and I
25 appreciated it.

1 CHAIR ARMIJO: Bill?

2 MEMBER SHACK: No, I think they're working
3 hard to get through a fairly complex sort of thing in
4 a fairly effective and efficient manner. When will
5 the Statement of Considerations be available?

6 CHAIR ARMIJO: We haven't received them
7 yet.

8 MEMBER SHACK: Yes, at least as far as I
9 know we haven't received them. And then there's
10 apparently lots of interesting goodies in there.

11 MS. INVERSO: That usually gets released to
12 the public at the same time the SECY Paper does, so
13 the rule is due to the EDO on February 29th, and then
14 to the Commission on March 14th, so I would imagine it
15 would be sometime after that. And that's not for
16 comment, just publicly available within ADAMS.

17 CHAIR ARMIJO: How about for us prior to
18 our January 19th meeting?

19 MS. INVERSO: We could talk and --

20 CHAIR ARMIJO: Sneak one over?

21 MS. INVERSO: -- try to arrange something.
22 I would have to talk to with my management and working
23 group, but --

24 CHAIR ARMIJO: Yes, just consider that a
25 request on our part.

1 MS. INVERSO: Okay.

2 CHAIR ARMIJO: Is that it, Bill?

3 MEMBER SHACK: Yes, I think so.

4 CHAIR ARMIJO: Okay.

5 MEMBER SHACK: Well, I guess the only other
6 thing is -- well, I guess if I see the Statement of
7 Considerations whether there needs to be any further
8 consideration of this long-term cooling criteria,
9 whether everybody agrees to use what's been used for
10 the GSI-191. I suppose that would make life simpler.

11 CHAIR ARMIJO: Right.

12 MEMBER SHACK: But at least it would be
13 nice if there was a good -- well, I'm not sure how
14 that was justified in the GSI-191. I guess there was
15 data, and if that data -- okay, that would be made
16 available.

17 MR. CLIFFORD: Right. And it's my
18 understanding that was long-term steam oxidation
19 tests, but it was all proprietary.

20 CHAIR ARMIJO: Yes. Well, look, I'd like
21 to add my compliments to the Staff and also to the
22 industry for very good presentations, but also as
23 important the ability to work together to address a
24 real problem, real issues, and cut a lot of wasted
25 time and effort by avoiding the need for a Generic

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Letter. I thought that was terrific.

2 I think you're well prepared for the full
3 Committee presentation. I think the focus should be on
4 the rule itself, the rule language and what it means.
5 And, of course, the assessment -- your assessment of
6 what the findings from the audit and the industry
7 submittals, and then the implementation, I think it
8 will be tough to get all of that in in two hours, but
9 actually it may not take that long, as much time as I
10 think. But I think that's where your focus should be.

11 I wouldn't spend much time on the Reg
12 Guides. We've seen them before. Maybe it's --

13 MR. BROWN: One and a half hours.

14 CHAIR ARMIJO: Is it one and a half? Okay,
15 well then don't spend any time on the Reg Guides and
16 say you guys have got to remember what --

17 MEMBER SHACK: There will be Reg Guides.

18 CHAIR ARMIJO: There will be Reg Guides,
19 and we're working on them. But overall, I think the
20 Staff has done an excellent job in handling a
21 complicated problem. I think we'll be better off for
22 it.

23 You've heard my comments on the breakaway
24 oxidation, the need for periodic testing. There's got
25 to be a better way to do that, but that may or may not

1 be what the rest of the members of the full Committee
2 think.

3 As far as a letter, it's really up to the
4 Staff to either request a letter from us, or say --
5 and if you don't really need one, just let us know at
6 the full Committee meeting. I can't guarantee that we
7 will do what you request, but we will take it into
8 consideration. That's the best I could say.

9 I'm very pleased with this meeting. I
10 think everybody has done a really good job, and I
11 think made a lot of progress. So, with that, unless
12 there's any other comments.


13 MR. NGUYEN: Dennis is on the phone.

14 CHAIR ARMIJO: Dennis? I'm sorry, Dennis,
15 I didn't -- I overlooked you because you were not
16 here. But if you would like to make some comments.

17 MEMBER BLEY: Me, no. I just -- after
18 everything everyone else said, I was a little
19 surprised by how complex this process is, but I guess
20 that's just the nature of it.

21 CHAIR ARMIJO: Okay. With that, I'd like to
22 thank everybody and the meeting is now adjourned way
23 ahead of schedule.

24 (Whereupon, the proceedings went off the
25 record at 1:35 p.m.)





U.S.NRC

UNITED STATES NUCLEAR REGULATORY COMMISSION

Protecting People and the Environment

Background of the 10 CFR 50.46c Proposed Rule and Related Activities

December 15, 2011

Tara Inverso
Division of Policy and Rulemaking
Office of Nuclear Reactor Regulation

Meeting Purpose

- Present the 10 CFR 50.46c proposed rule to ACRS
- Review the three associated draft regulatory guides
- Provide an overview of the related safety assessment/audit

Meeting Agenda

1. Background of 50.46c Rulemaking Activities
2. Overview of 50.46c Proposed Rule
3. Overview of Associated Regulatory Guidance
4. Overview of BWR/PWR Owners' Group Report
5. Overview of Safety Assessment
6. Proposed Implementation Schedule

Rulemaking Purpose

- Revise ECCS acceptance criteria to reflect recent research findings
- SECY-02-0057
 - Replace prescriptive analytical requirements with performance-based requirements
 - Expand applicability to all fuel designs and cladding materials
- Address concerns raised in two PRMs: PRM-50-71 and PRM-50-84

Public Interaction

- Advance Notice of Proposed Rulemaking Published
 - August 13, 2009 (74 FR 40765)
 - Requested specific comment on 12 issues/questions
- Public Workshop
 - April 28-29, 2010
- Public Meetings on Safety Assessment
 - August 12, 2010; December 2, 2010; March 3, 2011

Recent ACRS Interaction

- Research Findings – Regulatory Basis for 50.46c Rule
 - Presented RIL-0801 and NUREG/CR-6967 on December 2, 2008 (sub-committee) and December 4, 2008 (full committee)
 - “Mechanical Behavior of Ballooned and Ruptured Cladding” presented on June 23, 2011 (sub-committee) and July 13, 2011 (full committee)
- Draft regulatory guidance:
 - Presented to ACRS on May 10, 2011 (sub-committee) and June 8, 2011 (full committee)

Fuel Fragmentation, Relocation, and Dispersal

- Further research is necessary to understand fuel dispersal and its significance
- The staff recommends that the 50.46c rulemaking proceed to address the known embrittlement phenomenon
 - As written, the proposed rule satisfies all objectives/Commission direction

Rulemaking Schedule

- ACRS Meetings on Proposed Rule:
 - Sub-committee: December 15, 2011
 - Full committee: January 19, 2012
- Proposed Rule Due to the Executive Director for Operations:
 - February 29, 2012



Questions?

Tara Inverso, Project Manager

301-415-1024; tara.inverso@nrc.gov



Overview of the 10 CFR 50.46c Proposed Rule

December 15, 2011

Paul Clifford
Division of Safety Systems
Office of Nuclear Reactor Regulation

Agenda

- ECCS Design Function
- Structure of Performance-Based Rule
- Overview of 50.46c Rule Language

ECCS Design Function

- Emergency Core Cooling System consists of SSCs designed to replenish liquid inventory and maintain core temperatures at an acceptable level during and following a postulated LOCA.

Loss of Coolant Accident

Definition from 50.46(c)(1):


Loss-of-coolant accident (LOCA) means a hypothetical accident that would result from the loss of reactor coolant, at a rate in excess of the capability of the reactor coolant makeup system, from breaks in pipes in the reactor coolant pressure boundary up to and including a break equivalent in size to the double-ended rupture of the largest pipe in the reactor coolant system.

LOCA (cont.)

- As a result of a primary system piping break:
 - Loss of primary coolant inventory
 - Depressurization of primary pressure
 - Consequential heat up of fuel rods
- Initial rate of change in above parameters depends on break size and location.

LOCA (cont.)

PWR LBLOCA, Double Ended Guillotine At Pump Discharge



Rule Structure

Performance-based nature necessitated major restructuring of proposed 50.46c rule.

Rule Structure (cont.)

50.46c ECCS Performance During LOCA

- (a) Applicability
- (b) Definitions
- (c) Relationship to Other NRC Regulations
- (d) ECCS Design
- (e) [reserved]
- (f) [reserved]
- (g) Fuel System Design – (current designs)
- (h) [reserved]
- (i) [reserved]
- (j) [reserved]
- (k) Use of NRC Approved Fuel
- (l) Authority to Impose Restrictions on Operation
- (m) Reporting
- (n) [reserved]
- (o) Implementation

Rule Structure (cont.)

Emergency Core Cooling System:

1. Define **principal** performance objectives
 - Maintain acceptable core temperature during a LOCA.
 - Remove decay heat following a LOCA.
2. Define **principal** analytical requirements for ECCS performance demonstration

> > Dependent of Fuel Design < <

Rule Structure (cont.)

For each fuel design:

1. Define **specific** performance requirements and analytical limits which form the basis of “acceptable core temperature” based upon all established degradation mechanisms and unique features.
2. Define **specific** analytical requirements which impact the predicted performance of the fuel under LOCA conditions.

Rule Structure (cont.)

Current Fuel Designs:

- Based upon extensive empirical database, including recent findings from High Burnup LOCA Research Program, 50.46c defines specific performance and analytical requirements for current fuel designs.

New Fuel Designs:

- Additional research may be necessary to identify all degradation mechanisms and any unique features.
- New performance objectives, analytical limits, and analytical requirements would need to be established based upon this research.
- Several paragraphs reserved within 50.46c for future rulemaking on new fuel designs.

50.46c Rule Language

Paragraph (a)

(a) Applicability. The requirements of this section apply to the design of a light water nuclear power reactor (LWR), and to the following entities who design, construct or operate an LWR: each applicant for or holder of a construction permit under this part, each applicant for or holder of an operating license under this part (until the licensee has submitted the certification required under 10 CFR 50.82(a)(1) to the NRC), each applicant for or holder of a combined license under 10 CFR part 52, each applicant for a standard design certification (including the applicant for that design certification after the NRC has adopted a final design certification rule), each applicant for or holder of a standard design approval under 10 CFR part 52, and each applicant for or holder of a manufacturing license under 10 CFR part 52.

- Achieves rulemaking objective to expand applicability beyond “zircaloy or ZIRLO” to all LWRs
- Eliminates need for exemption requests for new zirconium alloys.

Paragraph (b)

(b) Definitions. As used in this section:

(1) *Loss-of-coolant accident* (unchanged)

(2) *Evaluation model* (unchanged)

(3) *Breakaway oxidation*, for zirconium-alloy cladding material, means the fuel cladding oxidation phenomenon in which weight gain rate deviates from normal kinetics. This change occurs with a rapid increase of hydrogen pickup during prolonged exposure to a high temperature steam environment, which promotes loss of cladding ductility.

- Defines new cladding embrittlement mechanism.

Paragraph (c)

(c) Relationship to other NRC regulations. The requirements of this section are in addition to any other requirements applicable to an emergency core cooling system (ECCS) set forth in this part. The analytical limits established in accordance with this section, with cooling performance calculated in accordance with an NRC approved evaluation model, are in implementation of the general requirements with respect to ECCS cooling performance design set forth in this part, including in particular Criterion 35 of appendix A of this part.

- Clarifies approval of evaluation model.

Paragraph (d)

(d) *Emergency core cooling system design.*

(1) *ECCS performance criteria.* Each LWR must be provided with an ECCS designed to satisfy the following performance requirements in the event of, and following, a postulated loss-of-coolant accident (LOCA). The demonstration of ECCS performance must comply with paragraph (d)(2) of this section:

- (i) Core temperature during and following the LOCA event does not exceed the analytical limits for the fuel design used for ensuring acceptable performance as defined in this section.
- (ii) The ECCS provides sufficient coolant so that decay heat will be removed for the extended period of time required by the long-lived radioactivity remaining in the core.

- Defines ECCS performance objectives.
 - Core temperature must remain below fuel-specific analytical limits.
 - Sufficient capability for long-term cooling.

Paragraph (d) (cont.)

(2) ECCS performance demonstration.

ECCS performance must be demonstrated using an evaluation model meeting the requirements of either paragraph (d)(2)(i) or (d)(2)(ii), paragraph (d)(2)(iii), and paragraph (d)(2)(iv), and satisfy the analytical requirements in paragraph (d)(2)(v) of this section. The evaluation model must be reviewed and approved by the NRC.

(i) *Realistic ECCS model.* A realistic model must include sufficient supporting justification to show that the analytical technique realistically describes the behavior of the reactor system during a loss-of-coolant accident. Comparisons to applicable experimental data must be made and uncertainties in the analysis method and inputs must be identified and assessed so that the uncertainty in the calculated results can be estimated. This uncertainty must be accounted for, so that when the calculated ECCS cooling performance is compared to the applicable specified and NRC-approved analytical limits there is a high level of probability that the limits would not be exceeded.

(ii) *Appendix K model.* Alternatively, an ECCS evaluation model may be developed in conformance with the required and acceptable features of appendix K ECCS Evaluation Models.

- Requires ECCS demonstration using approved evaluation model (either App.K or realistic).

Paragraph (d) (cont.)

(iii) *Core geometry and coolant flow.* The ECCS evaluation model must address calculated changes in core geometry and must consider those factors that may alter localized coolant flow or inhibit delivery of coolant to the core.

- Requires factors which impact predicted core geometry and coolant flow be included in the evaluation model.
 - Fuel-specific factors defined in subsequent sections.

Paragraph (d) (cont.)

(iv) *LOCA analytical requirements.* ECCS performance must be demonstrated for a range of postulated loss-of-coolant accidents of different sizes, locations, and other properties, sufficient to provide assurance that the most severe postulated loss-of-coolant accidents have been identified. ECCS performance must be demonstrated for the accident, and the post-accident recovery and recirculation period.

- Clarifies demonstration during and following postulated LOCA.

Paragraph (d) (cont.)

(v) *Modeling requirements for fuel designs-uranium oxide or mixed uranium-plutonium oxide pellets within zirconium-alloy cladding.* If the reactor is fueled with uranium oxide or mixed uranium-plutonium oxide pellets within cylindrical zirconium-alloy cladding, then the ECCS evaluation model must address the fuel system modeling requirements in paragraph (g)(2) of this section.

- Pointer to analytical requirements for current fuel designs.

Paragraph (d) (cont.)

(3) Required documentation.

- (i)(A) (unchanged from Appendix K)
- (B). (unchanged from Appendix K)
- (ii). (unchanged from Appendix K)
- (iii). (unchanged from Appendix K)
- (iv). (unchanged from Appendix K)
- (v). (unchanged from Appendix K)
- (vi) For operating licenses issued under this part as of **[EFFECTIVE DATE OF RULE]**, required documentation of Table 1 must be submitted to demonstrate compliance by the date specified in Table 1.

- Specifies documentation requirements for Appendix K and realistic models.
- Pointer to implementation schedule.

Paragraph (g)

(g) Fuel system designs: uranium oxide or mixed uranium-plutonium oxide pellets within cylindrical zirconium-alloy cladding.

(1) Fuel performance criteria. Fuel consisting of uranium oxide or mixed uranium-plutonium oxide pellets within cylindrical zirconium-alloy cladding must be designed to meet the following requirements:

(i) *Peak cladding temperature.* Except as provided in paragraph (g)(1)(ii) of this section, the calculated maximum fuel element cladding temperature shall not exceed 2200° F.

- Specifies performance requirements and analytical limits used to judge ECCS performance for current fuel designs.
- Research confirmed embrittlement above 2200 °F.
- PCT limit also prevents runaway oxidation and high temperature failure.

Paragraph (g) (cont.)

(ii) *Cladding embrittlement.* Analytical limits on peak cladding temperature and integral time at temperature shall be established which correspond to the measured ductile-to-brittle transition for the zirconium-alloy cladding material based on a NRC-approved experimental technique. The calculated maximum fuel element temperature and time at elevated temperature shall not exceed the established analytical limits. The analytical limits must be approved by the NRC. If the peak cladding temperature, in conjunction with the integral time at temperature analytical limit, established to preserve cladding ductility is lower than the 2200° F limit specified in (g)(1)(i), then the lower temperature shall be used in place of the 2200° F limit.

- Maintains cladding ductility as performance objective.
- Captures research finding.
 - Hydrogen enhanced beta-layer embrittlement.
- RG provides acceptable analytical limits.
- RG provides acceptable experimental technique.

Paragraph (g) (cont.)

(iii) *Breakaway oxidation.* The total accumulated time that the cladding is predicted to remain above a temperature at which the zirconium-alloy has been shown to be susceptible to breakaway oxidation shall not be greater than a limit which corresponds to the measured onset of breakaway oxidation for the zirconium-alloy cladding material based on a NRC-approved experimental technique. The limit must be approved by the NRC.

- Maintains cladding ductility as performance objective.
- Captures research finding.
 - Breakaway oxidation (hydrogen uptake)
- RG provides acceptable experimental technique.

Paragraph (g) (cont.)

(iv) *Maximum hydrogen generation.* The calculated total amount of hydrogen generated from any chemical reaction of the fuel cladding with water or steam shall not exceed 0.01 times the hypothetical amount that would be generated if all of the metal in the cladding cylinders surrounding the fuel, excluding the cladding surrounding the plenum volume, were to react.

- Maintains existing requirement for combustible gas.

Paragraph (g) (cont.)

(v) *Long-term cooling.* An analytical limit on long-term peak cladding temperature shall be established which corresponds to the measured ductile-to-brittle transition for the zirconium-alloy cladding material based on a NRC-approved experimental technique. The calculated maximum fuel element temperature shall not exceed the established analytical limit. The analytical limit must be approved by the NRC.

- Maintains cladding ductility as performance objective.

Paragraph (g) (cont.)

(2) *Fuel system modeling requirements.* The evaluation model required by paragraph (d)(2) of this section must model the fuel system in accordance with the following requirement:

(i) If an oxygen source is present on the inside surfaces of the cladding at the onset of the LOCA, then the effects of oxygen diffusion from the cladding inside surfaces must be considered in the evaluation model.

- Specifies analytical requirements for current fuel designs.
- Captures research finding.
 - Oxygen ingress from cladding inside surface reduced time-at-temperature to nil ductility.

Paragraph (g) (cont.)

(ii) The thermal effects of crud and oxide layers that accumulate on the fuel cladding during plant operation must be evaluated. For purposes of this paragraph crud means any foreign substance deposited on the surface of fuel cladding prior to initiation of a LOCA.

- Achieves rulemaking objective to address petition for rulemaking.

Paragraph (k)

(k) *Use of NRC-approved fuel in reactor.* A licensee may not load fuel into a reactor, or operate the reactor, unless the licensee either determines that the fuel meets the requirements of paragraph (d) of this section, or complies with technical specifications governing lead test assemblies in its license.

- Clarifies requirement on use of NRC approved fuel designs for which specific ECCS performance requirements have been established.
- Recognizes importance of LTAs for collecting irradiated data to approve new fuel designs.

Paragraph (I)

(I) Authority to impose restrictions on operation. The Director of the Office of Nuclear Reactor Regulation (for licenses issued under 10 CFR part 50) or the Director of the Office of New Reactors (for licenses issued under 10 CFR part 52) may impose restrictions on reactor operation if it is found that the evaluations of ECCS cooling performance submitted are not consistent with the requirements of this section.

- Separates authority between NRR and NRO for imposing restrictions on operation.

Paragraph (m)

(m) *Reporting.*

(1) Each entity subject to the requirements of this section, which identifies any change to or error in an evaluation model or the application of such a model, or any operation inconsistent with the evaluation model or resulting noncompliance with the acceptance criteria in this section, shall comply with the requirements of this paragraph.

- Clarifies existing reporting requirements.

Paragraph (m) (cont.)

(2) For the purposes of this section, a significant change or error is one which results in a calculated –

(i) Peak fuel cladding temperature different by more than 50 °F from the temperature calculated for the limiting transient using the last NRC-approved model, or is a cumulation of changes and errors such that the sum of the absolute magnitudes of the respective temperature changes is greater than 50 °F; or

(ii) Integral time at temperature different by more than 0.4 percent ECR from the oxidation calculated for the limiting transient using the last NRC-approved model, or is a cumulation of changes and errors such that the sum of the absolute magnitudes of the respective oxidation changes is greater than 0.4 percent ECR.

- Maintains threshold for significant change in calculated PCT at 50°F.
- Adds a new threshold for significant change in calculated integral time at temperature of 0.4% ECR.

Paragraph (m) (cont.)

(3) Each holder of an operating license or combined license shall measure breakaway oxidation for each reload batch. The holder must report the results to the NRC annually i.e., anytime within each calendar year, in accordance with § 50.4 or § 52.3 of this chapter, and evaluate the results to determine if there is a failure to conform or a defect that must be reported in accordance with the requirements of 10 CFR part 21.

- Adds new reporting requirement for measured breakaway oxidation.
- Recognizes potential manufacturing-related changes in breakaway susceptibility.



Paragraph (o)

(o) *Implementation.*

LATER



U.S.NRC

UNITED STATES NUCLEAR REGULATORY COMMISSION

Protecting People and the Environment

Regulatory Guidance to support Emergency Core Coolant System rulemaking

December 15, 2011

Michelle Flanagan
Division of Systems Analysis
Office of Nuclear Regulatory Research

Background

- Presented to Materials, Metallurgy & Reactor Fuels Sub-committee on May 10, 2011
- Presented to ACRS Full Committee on June 8, 2011
 - ACRS letter to staff: “Draft Regulatory Guides DG-1261, DG-1262, DG-1263,” June 22, 2011 (ADAMS Accession No. ML11164A048)
 - Staff reply to ACRS: “Draft Regulatory Guides DG-1261, DG-1262 and DG-1263,” July 21, 2011 (ADAMS Accession No. ML111861706).

Background

- Rulemaking initiated to revise ECCS acceptance criteria to reflect new research findings
- The revisions are also intended to develop performance-based features of 10 CFR 50.46
- Therefore, 10 CFR 50.46c calls for:
 - Material-specific analytical limits which account for material-specific burnup effects
 - ECCS performance consistent with avoiding measured breakaway behavior
 - Periodic testing for breakaway behavior

Approach

These regulatory guides make it possible to revise 10 CFR 50.46c in a performance-based manner by:

- Providing a means of consistent, comparable generation of data to establish regulatory limits for peak cladding temperature (PCT) and oxidation
- Providing a means of consistent, comparable data generation to establish, and periodically confirm regulatory limits related to breakaway oxidation
- Providing a consistent means of using experimental data to establish regulatory limits
- Simplifying the staff's review process
- Reducing regulatory uncertainty, minimizing the costs associated with the implementation of the regulatory requirements proposed for 50.46c.

Approach

- DG-1261: Test procedure for measuring breakaway oxidation behavior and periodically confirming consistent behavior
- DG-1262: Testing procedure for measuring post-quench ductility using ring compression tests
- DG-1263: Developing analytical limits from measured data

Approach

Through stakeholder interaction and public comment, ensure that:

- the details and expectations of acceptable methods for measuring zirconium-based alloy behavior and developing limits are communicated effectively and completely
- measured behavior is expected to be repeatable within a laboratory
- measured behavior is expected to be repeatable between laboratories
- analytical limits will be developed consistently across fuel designs

Context

Relationship to rule language

(1) *Fuel performance criteria.* Fuel consisting of uranium oxide or mixed uranium-plutonium oxide pellets within cylindrical zirconium-alloy cladding must be designed to meet the following requirements:

DG-1263

(i) ...

(ii) *Cladding embrittlement.* **Analytical limits on peak cladding temperature and integral time at temperature shall be established** which correspond to the measured ductile-to brittle transition for the zirconium-alloy cladding material based on a **NRC-approved experimental technique**. The calculated maximum fuel element temperature and time at elevated temperature shall not exceed the established analytical limits. The analytical limits must be approved by the NRC. If the peak cladding temperature, in conjunction with the integral time at temperature analytical limit, established to preserve cladding ductility is lower than the 2200° F limit specified in (g)(1)(i), then the lower temperature shall be used in place of the 2200° F limit.

(iii) ...

DG-1262

Context

Relationship to rule language

(1) *Fuel performance criteria.* Fuel consisting of uranium oxide or mixed uranium-plutonium oxide pellets within cylindrical zirconium-alloy cladding must be designed to meet the following requirements:

(i)

(ii)...

(iii) Breakaway oxidation. The total accumulated time that the cladding is predicted to remain above a temperature at which the zirconium-alloy has been shown to be susceptible to breakaway oxidation **shall not be greater than a limit** which corresponds to the measured onset of breakaway oxidation for the zirconium-alloy cladding material based on a **NRC-approved experimental technique**. The limit must be approved by the NRC.

DG-1263

DG-1261

Schedule

- Draft guides will be issued for public comment at the same time as the proposed rule is issued for public comment
- Draft guides will then follow standard revision and review process



Overview of Industry Margin Assessment

Kurt Flaig - PWROG Representative

Tom Eichenberg - BWROG Representative

ACRS Subcommittee Meeting

December 15, 2011

Agenda

- Objectives
- Background
- Overview of Margin Assessments
- Conclusion

Objectives

- Provide Overview of Industry Assessment
- Show Operating Plants Have Margin with Respect to Research Findings

Background

- NRC Research Results Regarding Cladding Embrittlement (NUREG/CR-6967)
- NRC Staff Requested an Assessment of Research Results with Respect to the Operating Fleet
- Industry Proposed a Vehicle Providing Relevant Information to NRC
- NEI Provided the Industry Assessment Reports

Assessment Overview

- Survey Approach
- Identify Evaluation Criteria Based on Research
- Identify Conservatism and Margin
- Plant Grouping Approach


Survey Approach

- Starting Point
 - Analyses of Record
- Establish Initial Margins
- Determine Creditable Conservatism as Necessary

Evaluation Basis


- Embrittlement Limit
 - Hydrogen uptake models
- Double-Sided Equivalent Clad Reacted (ECR)
 - Burst rods accounted for by current evaluation models
 - Accounted for inside ECR contribution
- Breakaway Oxidation
 - Time above 800°C

Embrittlement Criteria



Hydrogen Uptake

- Alloy-Specific Models presented in Assessment Report
 - Best estimate hydrogen vs. exposure conversion
 - Allowable ECR based on initial hydrogen concentration



Double-Sided ECR Contribution

- Rod Exposures Above 45 GWd/MTU

Breakaway Oxidation

- 5000 Seconds Above 800°C
 - Based on ANL and industry testing

Examples of Applied Conservatisms

- Appendix K vs. Best-Estimate Methodology
- Approved Best-Estimate Methodology Improvements
- Baker-Just vs. Cathcart-Pawel
- Reload Power History
- Peak Cladding Temperature Dependent Brittle-Ductile Transition
- ANS-1979 Decay Heat Plus 2σ Uncertainty
- Thermal-Mechanical Limits to Operation
 - LHGR limit

Plant Grouping Factors

- Large vs. Small Break Limited
- Plant Design/ECCS Features
- Type of Cladding Material
- Type of Evaluation Methodology
- Conservatism Credits

PWR LBLOCA Groupings

- Group 1 Contains 41 Units
 - No adjustments required to meet limits
- Group 2 Contains 2 Units
 - Approved best-estimate methodology improvements
 - ECR reduced ~50%
- Group 3 Contains 6 Units
 - Appendix K to a best-estimate methodology
 - ECR reduced ~60%
- Group 4 Contains 4 Units
 - Improved statistics in ASTRUM
 - ECR reduced ~ 40%

PWR LBLOCA Groupings (Continued)

- Group 5 Contains 1 Unit
 - Explicit burnup study
 - ECR reduced ~ 50%
- Group 6 Contains 7 Units
 - Approved best-estimate methodology improvements
 - Improved ASTRUM statistics
 - ECR reduced ~ 60%
 - Increased allowable ECR criteria
- Group 7 Contains 8 Units
 - Baker-Just to Cathcart-Pawel
 - Reload power histories
 - ECR reduced ~40%

PWR SBLOCA Groupings

- Group 1 Contains 59 Units
 - No adjustments required to meet limits
- Group 2 Contains 5 Units
 - ANS-1979 decay heat plus 2σ uncertainty
 - ECR reduced ~ 90%
- Group 3 Contains 5 Units
 - Baker-Just to Cathcart-Pawel
 - Reload power histories
 - ECR reduced ~30%

BWR Groupings

- Group “2” Contains 2 Units
 - BWR/2 designs
 - Baker-Just to Cathcart-Pawel
 - Thermal-mechanical operating limits
 - ECR reduced ~ 20%
- Group “3” Contains 6 Units
 - BWR/3 designs
 - Thermal-mechanical operating limits
 - ECR reduced ~ 95%
- Groups “4”, “4a”, “5”, and “6” Contain 27 Units
 - BWR/4, 5, & 6 designs
 - No adjustments required to meet limits

Margin to Proposed Criteria

- Embrittlement
 - 41 of 69 PWR LBLOCA needed no adjustments
 - 59 of 69 PWR SBLOCA needed no adjustments
 - 27 of 35 BWR's needed no adjustments
 - Remaining plants took credit for various conservatisms
- Breakaway Oxidation
 - No adjustments needed
- All Operating Plants Show Margin
 - With respect to research findings

Conclusion

- Industry Provided Margin Assessment Reports Encompassing the Operating Fleet
- All Operating Plants Show Margin with Respect to Research Findings



U.S.NRC

UNITED STATES NUCLEAR REGULATORY COMMISSION

Protecting People and the Environment

ECCS Performance Safety Assessment

December 15, 2011

Paul Clifford
Division of Safety Systems
Office of Nuclear Reactor Regulation

Agenda


1. Research Findings
2. Initial Safety Assessment
3. Draft Generic Letter
4. ECCS Performance Assessment

Research Findings

New Embrittlement Mechanisms:


1. Hydrogen-enhanced beta layer embrittlement.

- Pre-transient cladding hydrogen content impacts rate of embrittlement.
- Hydrogen absorption sensitive to alloy composition, fabrication, and in-reactor service.



Research Findings (cont.)

- Allowable time-at-temperature reduced from current regulatory requirement (17%ECR).





Research Findings (cont.)

New Embrittlement Mechanisms:

2. Cladding ID oxygen diffusion expedites embrittlement.

- Oxygen ingress from cladding ID reduces allowable time-at-temperature to nil ductility.
- ID oxygen source sensitive to burnup, power history, and fuel rod design.




Micrograph images of Halden LOCA test specimens of outer cladding surface (left) and inner cladding surface (right) indicating oxygen-stabilized zirconium layers on both surfaces.

New Embrittlement Mechanisms

3. Degradation of protective oxide layer (breakaway oxidation).

- Breakaway oxidation results in cladding embrittlement due to hydrogen uptake.
- Susceptibility to breakaway sensitive to alloy composition and fabrication.



Initial Safety Assessment

- In response to RIL-0801, NRR completed initial safety assessment (July 2008)
 - Due to measured performance, realistic rod power history, and current analytical conservatisms, sufficient safety margin exists for operating reactors.
 - No imminent safety risk. Proceed with rulemaking.
 - Additional research needs:
 - PQD measurements at intermediate hydrogen levels.
 - Breakaway measurements on transient temperature profiles.
 - Treatment of fuel rod burst region.

Generic Letter

- Recognizing that finalization and implementation of the new ECCS requirements would take several years, the staff decided that a more detailed safety assessment was necessary
- To obtain the necessary plant-specific information, the staff developed a draft GL entitled, “Potential Embrittlement of Fuel Rods During Postulated Loss-of-Coolant Accidents.”

Generic Letter (cont.)


- Industry volunteered to provide requested information via PWROG and BWROG reports.
- Based upon the information provided OG reports and the information collected during the staff audits of the Westinghouse, AREVA, and GEH engineering calculations, the staff concludes that sufficient plant-specific information has been documented to complete the safety assessment.
- Therefore, no further regulatory action to request information is required and the draft GL need not be issued.

ECCS Performance Assessment

Draft GL Groundrules


Revised Analytical Limits:

- Alloy-specific PQD analytical limit.
- Cladding ID oxygen ingress ≥ 45 GWd/MTU.
- Alloy-specific breakaway oxidation (time above 800°C).




UFSAR AOR Results - MLO

UFSAR LOCA Analysis-of-Record



UFSAR AOR Results – Breakaway

UFSAR LOCA Analysis-of-Record




Post Quench Ductility

Revised PQD Analytical Limits:

- 65 of 104 plants (63% of entire operating fleet) needed no adjustment or new calculations.
 - 27 of 35 BWRs (77% of BWR fleet)
 - 38 of 69 PWRs (55% of PWR fleet).
- All 104 plants continue to satisfy 2200°F PCT criteria.

Revised PQD Analytical Limits:

- 8 BWRs performed new LOCA calculations which credit COLR Thermal-Mechanical Operating Limits (TMOL) reduced rod power at higher burnup to satisfy new analytical limits.
- Approved models with no analytical adjustments.



Post Quench Ductility (cont.)

Revised PQD Analytical Limits:

- 31 PWRs either performed new LOCA calculations or identified credits to satisfy new analytical limits.
 - 9 PWRs performed new LOCA calculations which credit diminished fuel rod power at higher burnup.
 - 11 PWRs credit transition to improved evaluation models (e.g., ASTRUM LBLOCA or ANS 1979+2 σ decay heat SBLOCA).
 - 4 PWRs credit improved statistics in ASTRUM methods.
 - 7 PWRs credited multiple items.
- All of the calculations were performed and documented in accordance with the fuel vendor's 10 CFR 50 Appendix B quality assurance program.

Breakaway Oxidation

Measured Breakaway Time:

- All plants exhibit margin to breakaway.
- 103 of 104 plants predict a time duration above 800°C of less than 2,000 seconds.

Alloy	Measured Breakaway Time
Zircaloy-2	>5,000 seconds
Zircaloy-4	5,000 seconds
ZIRLO™	3,500 seconds
M5	>5,000 seconds

- New requirement prevents introduction of susceptible cladding material like old E110.

NRC staff audited Westinghouse, AREVA, and GEH calculations supporting OG reports.

- Confirmed that the revised PQD and breakaway analytical limits were in accordance with the research findings and that alloy-specific corrosion and hydrogen uptake models were accurate and supported by data.
- Evaluated the quantification, justification, and application of analytical credits.
- Reviewed a sampling of the new LOCA calculations and identified any changes to existing, approved models and methods.
- Compiled plant-specific data and evaluated each individual plant with respect to margin to the revised analytical limits.

ECSS Margin Database

ECSS Margin Database documents plant-specific information:

- Fuel vendor
- Fuel rod cladding alloy
- Evaluation model
- AOR results (calculated PCT, MLO, and time above 800°C)
- Plant grouping
- Margin to PQD analytical limit
- Margin to breakaway oxidation analytical limit
- Credited analytical adjustment(s)

Existing Commercial Fleet

- ECCS performance safety assessment **confirms** and **documents**, on a plant-specific basis, the continued safe operation of the U.S. commercial nuclear fleet.
- Future operation of Watts Bar Unit 2 and Bellefonte Units 1 and 2 expected to have sufficient margin to PQD and breakaway limits.
- Improved, corrosion resistant zirconium alloys being developed and implemented.

Certified Reactor Designs

- Advanced reactor designs include enhanced ECCS performance characteristics.
- Certified designs have significant margin relative to research data.

Design	PCT (°F)	ECR (%)
ESBWR	No uncover or heatup	
AP1000	1837	2.25
EPR	1695	1.53
US-APWR	1766	3.70

Future Confirmation

- Planned changes which may impact margin assessment and involve License Amendment Requests:
 - Power uprate.
 - Major plant modifications.
 - New fuel design or design limits.
 - New LOCA methods.
- Unplanned changes which may impact margin assessment would be captured via existing 10CFR50.46(a)(3) reporting requirements.
 - Any change to or error discovered in evaluation model requires NRC notification.
 - Either 30 day (significant) or annual reporting requirement.

Future Confirmation (cont.)

The staff will perform the following actions to confirm plant safety in the interim until the revised rule (10 CFR 50.46c) is implemented.

1. On an annual basis, the staff will update the ECCS Margin Database using the annual licensee 50.46(a)(3) reports .
2. On a continuous basis, the staff will scrutinize all 30-day significant 50.46(a)(3) reports to confirm existing margin assessment.
3. On a continuous basis, the staff will scrutinize any License Amendment Request which necessitates a change to the LOCA analysis-of-record and may impact the existing margin assessment .
4. As part of the annual vendor/NRC fuel update meetings, the staff will confirm that all changes which may impact the existing margin assessment have been identified and discuss future LARs which may impact the LOCA analysis-of-record.

Conclusions

1. Research findings necessitate new ECCS requirements.
2. Majority of plants needed no new calculations or adjustments to show positive margin to the research data.
3. ECCS margin database confirms and documents, on a plant-specific basis, the continued safe operation of the U.S. commercial nuclear fleet.
4. NRC staff will continue to confirm plant safety until new regulations have been implemented.



U.S.NRC

UNITED STATES NUCLEAR REGULATORY COMMISSION

Protecting People and the Environment

Implementation of 10 CFR 50.46c

December 15, 2011

Paul Clifford
Division of Safety Systems
Office of Nuclear Reactor Regulation

Agenda

1. Work Scope
2. Strategy
3. Implementation – Existing Plants
4. Implementation – New Plants

Work Scope

Industry:


1. Develop alloy-specific hydrogen uptake models.
2. Update LOCA models.
3. Establish PQD analytical limits.
4. Establish breakaway oxidation analytical limits.
5. Perform plant-specific LOCA analyses.
6. Prepare LARs.
7. Revise UFSARs.
8. Ongoing breakaway tests.

NRC:

1. Review alloy-specific hydrogen uptake models.
2. Review LOCA models.
3. Review breakaway test results
4. Review PQD and breakaway analytical limits.
5. Review LARs.


Strategy

- Based upon ANPR comments which identified workforce limitations to complete parallel analyses, a staged implementation plan would be the most effective and efficient way to implement 50.46c.
- Plants with the least available safety margin would be required to be in compliance earliest.



Strategy (cont.)

- Recognizing that (1) plants with the least amount of safety margin are likely to require the most effort and calendar time to document compliance and (2) a substantial number of plants do not require new LOCA analyses, the implementation plan was revised.



Strategy (cont.)

- Implementation plan designed to achieve the following objectives:
 1. Expedite implementation to as many plants as soon as possible,
 2. Prioritize implementation on plants with less inherent safety margin, and
 3. Balance work load.

Implementation – Existing Fleet

Implementation Track	Basis	Anticipated Level of Effort	Number of Plants		Compliance Demonstration
			BWR	PWR	
1	All plants which satisfy new requirements without new analyses or model revisions.	Low	27	38	No later than 24 months from effective date of rule
2	PWR plants using realistic LBLOCA models requiring new analyses. BWR/2 plants.	Medium	2	14	No later than 48 months from effective date of rule
3	PWR plants using Appendix K LB and SB models requiring new analyses. BWR/3 plants.	Medium - High	6	17	No later than 60 months from effective date of rule

Paragraph (o)

(o) Implementation

Reactors under Part 50:

- **Construction permits issued after the effective date of the rule must comply with the conditions of the rule.**
- **Operating licenses issued based on construction permits in effect as of the effective date of the rule must comply with the conditions of the rule no later than the date set forth in Table 1 of the rule.**
- **Operating licenses issued prior to the effective date of the rule must comply with the conditions of the rule no later than the date set forth in Table 1 of the rule.**
- **Operating licenses issued after the effective date of the rule must comply with the conditions of the rule.**

Paragraph (o)

(o) Implementation.

Reactors under Part 52:

- **All applications docketed after the effective date of the rule must comply with the conditions of the rule prior to approval.**
- **Standard design renewals after the effective date of the rule must comply with the conditions of the rule prior to approval.**
- **Standard design applications pending at effective date of the rule must comply with the conditions of the rule when renewal is submitted.**
- **Combined licenses docketed after the effective date of the rule must comply with the conditions of the rule.**
- **Combined licenses docketed or issued prior to the effective date of the rule must comply with the conditions of 50.46 until completion of the refueling outage after the initial fuel load, at which time they must comply with the conditions of this rule.**

Implementation Flow Chart

