

Official Transcript of Proceedings
NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards
Fukushima Subcommittee

Docket Number: (n/a)

Location: Rockville, Maryland

Date: Wednesday, October 31, 2012

Work Order No.: NRC-1993

Pages 1-170

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1323 Rhode Island Avenue, N.W.
Washington, D.C. 20005
(202) 234-4433

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

UNITED STATES OF AMERICA

NUCLEAR REGULATORY COMMISSION

+ + + + +

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

(ACRS)

+ + + + +

FUKUSHIMA SUBCOMMITTEE

+ + + + +

WEDNESDAY, OCTOBER 31, 2012

+ + + + +

ROCKVILLE, MARYLAND

The Subcommittee met at the Nuclear
Regulatory Commission, Two White Flint North, Room
T2B3, 11545 Rockville Pike, at 1:00 p.m., Stephen P.
Schultz, Chairman, presiding.

SUBCOMMITTEE MEMBERS:

STEPHEN P. SCHULTZ, Chairman

J. SAM ARMIJO, Member

CHARLES H. BROWN, Member

MICHAEL L. CORRADINI, Member

JOY REMPE, Member

MICHAEL T. RYAN, Member

WILLIAM J. SHACK, Member

GORDON R. SKILLMAN, Member

JOHN W. STETKAR, Member

1 NRC STAFF PRESENT:

2 ANTONIO DIAS, Designated Federal Official

3 JERRY BETTLE, NRR

4 BOB DENNIG, NRR

5 BOB FRETZ, NRR/Japan Lessons Learned Project

6 Directorate

7 TINA GHOSH, RES/DRA

8 JOHN MONNINGER, NRR/Japan Lessons Learned

9 Project Directorate

10 WILLIAM RULAND, NRR

11

12 ALSO PRESENT:

13 JEFF GABOR, ERIN Engineering

14 PAUL GUNTER, Beyond Nuclear

15 STEVE KRAFT, NEI

16

17

18

19

20

21

22

23

24

25

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

TABLE OF CONTENTS

Welcome 4

Industry Perspective 6

Supporting Evaluations, NRC Staff

 Bill Ruland 53

 Bob Fretz 54

 John Monninger 57

Conclusions, NRC Staff

 Bob Dennig 113

Recommendations

 Jerry Bettle 124

Public Comments 156

Recommendations (cont.)

Ajourn

P R O C E E D I N G S

1:02 p.m.

1
2
3 CHAIR SCHULTZ: I'd like to call the
4 meeting to order. This is a meeting of the Advisory
5 Committee on Reactor Safeguards Subcommittee on
6 Fukushima. I'm Stephen Schultz, Chairman of the
7 Subcommittee. Members in attendance today are Dick
8 Skillman, Sam Armijo, John Stetkar, Bill Shack, Joy
9 Rempe, Mike Corradini. I believe Mike Ryan is going
10 to join us, and other members may join us later in the
11 afternoon.

12 The purpose of today's meeting is to
13 receive a briefing and hold discussions with the staff
14 and the industry on the discussion of a position paper
15 addressing the value of filtered vents. The entire
16 meeting will be open to public attendance. Rules for
17 the conduct of and participation in this meeting have
18 been published in the Federal Register as part of the
19 notice for this meeting.

20 The Subcommittee will hear presentations
21 by and hold discussions with representatives of the
22 NRC staff and other interested persons regarding this
23 matter. The Subcommittee will gather information,
24 analyze relevant issues and facts, and formulate
25 proposed positions and actions, as appropriate, for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 deliberation by the full committee.

2 The staff is currently finalizing a
3 position paper that is due to the Commission by the
4 end of November. The full committee briefing on this
5 same topic is scheduled for tomorrow, November 1st,
6 starting at 10:15 a.m. Also, the ACRS will be writing
7 a letter on this topic during this week's full
8 committee meeting.

9 Antonio Dias is the Designated Federal
10 Official for this meeting. A transcript of this
11 meeting is being kept and will be made available, as
12 stated in the Federal Register notice. It's requested
13 that speakers first identify themselves and speak with
14 sufficient clarity and volume so that they can be
15 readily heard.

16 We've received no written comments
17 associated with this topic today. We have received
18 requests for time to make oral statements from Mr.
19 Paul Gunter. I understand that there are other
20 stakeholders in the audience, as well as on the bridge
21 line who are listening in today for these proceedings,
22 and they will also be given the opportunity to address
23 the Committee at the end of this briefing.

24 We do want to welcome both the industry
25 and the staff. This is not the first meeting we have

1 had on this topic. Rather, as indicated, it's one
2 that just precedes the publication or the transmittal
3 of the staff's report to the Commission later this
4 month.

5 We'll now proceed with the meeting, and
6 we're going to start with presentations by Steve Kraft
7 and Jeff Gabor from NEI and ERIN Engineering
8 respectively. And so I'll call upon you, Steve, to
9 open the meeting. Thank you.

10 **MR. KRAFT:** Well, thank you, Mr. Chairman.
11 Pleased to be here. Thank you, Subcommittee, for the
12 invitation. Thanks to Antonio for organizing our
13 attendance. I am Steven Kraft. I am Senior Director,
14 Fukushima coordination and strategy at NEI. I am
15 pleased to have Dr. Jeff Gabor with me from ERIN
16 Engineering. Rick Wachowiak from EPRI was going to
17 join us but travel and whatnot and I understand he has
18 a personal issue at home, so he's unable to be here.
19 And I don't believe he'll be on the phone either.

20 **MR. DIAS:** I provided him with the phone
21 at the --

22 **MR. KRAFT:** Yes. I'll tell you later.
23 It's a personal matter, I think, this afternoon. So
24 before we move on and go through our slides, go
25 through our discussion here, I just wanted to disabuse

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 anyone in the room who thinks that somehow the nuclear
2 industry is all-powerful. I attempted to get the
3 Metro shut down for one more day so we could avoid the
4 meeting. Alas, I was unable to do so, so here we are.

5 As you know, we have been working on this
6 question of filtering strategies for some time. There
7 have been numerous interactions with the staff, many
8 in this room, all in public. I appreciate the staff's
9 time with us, understanding their work they've done,
10 they're wanting to understand the work we've done.
11 And the discussion we're going to have with you in the
12 short time we have available will be based on our
13 October 5 letter that I believe has been circulated,
14 as well as what we're doing beyond that letter. There
15 are some other activities that we're engaging in.

16 I just want to, at the very top of the
17 discussion, state the industry position so there is no
18 question that you don't think, as we walk through some
19 of the further discussion, that somehow we think that
20 filtering and preventing land contamination is not a
21 good idea. Of course we think it's a great idea.
22 It's something that we learned from following the
23 Fukushima event, and you see right here in three
24 bullets the position that is stated in the October 5th
25 letter. We've explained it to the NRC Fukushima

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 steering committee. We've briefed commissioners on
2 this. MARK I and MARK II containment should have the
3 capability to use a variety of containment filtering
4 strategies. This is not limited to MARK Is and MARK
5 IIs. We know this goes beyond at some point, but this
6 is what's before the Commission at the moment because
7 of the way the reliable hardened vent order worked.
8 This should be a performance-based strategy
9 requirement, in our view, founded on scientifically
10 factual analyses and a comprehensive approach that
11 ensures containment. I cannot stress more strongly
12 our view that keeping the radionuclides in containment
13 ought to be the goal, and that's kind of where we
14 start our discussion of filtering strategies.

15 Now, having said that, let me drop back
16 and let me discuss with you the context with which we
17 look at this. The reason this context is so important
18 is the very first bullet: beyond design basis events.
19 The way we look at beyond design basis events, the way
20 this agency appears to be approaching beyond design
21 basis events is different in many respects than design
22 basis events. As we worked our way through
23 application of the three orders that we're now
24 implementing, as working our way through seismic and
25 the flooding, walk-downs, evaluations, things like

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that, the approach is different; and it's because we
2 don't know where the line is. We all know what design
3 basis is. It could change in the future. We may have
4 to make adjustments, but that's different than beyond
5 design basis.

6 Secondly, there's an extremely low chance
7 of ever needing filtering. I don't think it's news to
8 anyone that the goal is to prevent the accident in the
9 first place. And by the way we have added additional
10 enhancements to what everyone knows we call the B.5.b
11 capability as a result of the terrorist attacks back
12 in '01, we've now expanded that into what we call
13 FLEX. In fact, this last event, Sandy, coming through
14 unexpectedly, unprecedentedly, we exercised the
15 system. When Oyster Creek lost offsite power and one
16 of its diesels kicked on, they immediately called
17 INPO. INPO immediately walked down, INPO had their
18 ERC staff, immediately walked down the list to find
19 who had a backup portable generator of the right size,
20 etcetera, that could be moved immediately to that
21 plant. They identified three or four different places
22 that had one. The nearest one was Susquehanna
23 Station, I believe, PP&L. They were preparing to
24 mobilize and move that generator when they got the
25 call to stand down. So that wasn't without, you know,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 going after a way to create this drill. We had a
2 drill, and it worked extremely well. And all that
3 goes to this point of preventing the accident.

4 Now, granted, I don't think we're anywhere
5 near close having an event at Oyster Creek. It was
6 just an opportunity because they were offline, they
7 had the rising water, they lost offsite power, you
8 know, things like that.

9 Reliable hardened vents provide a heat
10 removal path while filtering and filtering strategies,
11 whichever way you want to do it, has to do with
12 reducing the impact of potential containment releases.
13 One is not the other, and that's an important point.
14 I sometimes hear confusion in that discussion that
15 begins substituting one for the other. Again, all
16 this goes to the way you think about what's an
17 appropriate requirement in a beyond design basis event
18 when you have core damage and you have to consider
19 preventing or mitigating releases coming from
20 containment. And I don't think there's any secret
21 that previous NRC evaluations on containment filters,
22 they've never made the grade. Every time they've done
23 an analysis, they've said it doesn't make the grade.
24 They've sat in this room and briefed you on October
25 3rd. You know, again, no surprise there.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 That leads me to the last bit of context
2 is the use of qualitative factors in extreme
3 scenarios. There's absolutely nothing wrong with
4 using qualitative factors. There are certain things
5 where it's only appropriate: EP, emergency planning;
6 security, really not amenable to traditional risk and
7 cost benefit analyses, so you use qualitative factors.

8 In the case of the filtering analysis,
9 what NRC staff said was, well, we can't make it to
10 justify a filter, so we're going to go on to
11 qualitative factors, and that's perfectly okay,
12 provided, of course, the Commission makes that
13 decision, and I think that's what the staff is aiming
14 at. But the point being, again, when you're at a
15 point where you have to go all the way through these
16 analyses and get to qualitative factors to make a
17 determination, I think that gives you cause to think
18 what is it you're really trying to accomplish here and
19 what's the best way of going about doing it? And
20 extreme scenarios fits in that same way.

21 And the reason I put that up there, and
22 I'm not trying to suggest something is not right in
23 the way these analyses are being done, but I have met
24 with a lot of people, have met with a lot of vendors,
25 have sat down and met in our meetings with NRC, even

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 our own industry. There's some cherry picking of
2 scenarios going on. So, for example, if you want to
3 posit that during the event and you're flooding up
4 containment and you have to switch over in the
5 scenario that Jeff and his colleagues devised where
6 you switch over from the wet well vent to the dry well
7 vent and, all of a sudden, quote, all hell breaks
8 loose, gee, and your scenario ain't going to work,
9 well, that can't be limited to just my scenario. If
10 all hell breaks loose and takes down my spray header,
11 what makes you think the filter survives? Think about
12 what you're designing these things to. So I just
13 think the point that -- and, again, it's a matter of
14 not purposely picking scenarios that make the case one
15 way or another, and I think the EPRI report, and Jeff
16 can talk about it if need be, is very comprehensive,
17 particularly in the sensitivity analysis.

18 And going to this point of keeping and
19 having the accident is that we continue to take
20 actions and adding activities and FLEX and everything
21 else to ensure a very low frequency of release. There
22 is in the backup slides an event tree that was
23 prepared by Jeff and his colleagues that make this
24 point about how much you have to go through, how much
25 has to break, how much has to go wrong until you get

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 to releases. I won't bother to read this list. You
2 all know better than I do. We'll note on the bottom,
3 just to emphasize what I said before with the NRC
4 analysis, using the traditional regulatory analysis
5 did not justify filters and never has. Again, that's
6 why I put our position up first. I'm not saying that
7 to avoid filtering. I'm saying it to give you context
8 as to where we are in making this decision.

9 So the EPRI work, which was presented to
10 you by Rick and Jeff a month or so ago, these are the
11 insights that we got out of the EPRI report but also,
12 as we paid attention to the NRC evaluations, are the
13 same insights. First is all filtering strategies with
14 or without external filters. Whether you stick a
15 filter on the end of the vent pipe or not, you must
16 rely on operator actions to cool the core debris to be
17 effective. Let me repeat that: rely on, first,
18 operator actions. Operator actions are not unique to
19 filtering strategies. And, secondly, cool the core
20 debris to be effective. If you look at the event
21 tree, any scenario where you fail to cool the core
22 debris results in a release, regardless of whether you
23 have a filter or a filtering strategy in play. So the
24 goal is to always cool the core debris. Prevent the
25 accident in the first place and cool the core debris.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 We'll make that point in the next slide.

2 Filtering strategies and external filters
3 require the same conditions to be effective. That's
4 the whole point of that event tree. Active core
5 debris cooling. We added the idea of containment vent
6 cycling, which is in the EPRI report. You want to
7 keep the torus or the suppression pool as long as
8 possible below saturation, so you maintain the
9 filtering capability. You have to inject water in
10 containment to filter potential releases through water
11 spray and flooding. They also filter the airborne
12 aerosol. You cycle the vent. It also manages -- let
13 me just mention hydro before someone else does.
14 Hydrogen has not been explored. The NRC made hydrogen
15 control a Tier 3 issue, so I don't think that they're
16 there yet. But we've talked about it a little bit.
17 The EPRI report points to the possibility of the vent
18 cycling as part of a strategy. It can help manage
19 hydrogen. It may not be the complete answer, and it's
20 something that needs to be worked on. I'll just say
21 that right now.

22 And then, of course, we think you can get
23 an achieved decontamination factor over the event of
24 1,000 DF, and that seems to be a common international
25 requirement.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1

2

3

4

5

6

MEMBER SKILLMAN: Steve, before you go on, on your first bullet, the comment "filtering strategies and external filters require same conditions to be effective," could you explain that a little more, please?

7

8

9

10

11

12

13

14

15

16

17

18

MR. KRAFT: If you're not cooling the core debris, it doesn't matter if you have a filter at the end of the pipe or not. You have to cool the core debris in order to prevent releases that will bypass the vent, either going through the liner, a seal failure, various things like that. That water on the core debris also gives you the filtering that our filtering strategies take advantage of. So you got to get the water in to cool the core debris no matter what, and then you can take credit for the water in containment to provide filtering. That's what that concept is.

19

20

21

22

23

24

25

But remember what I said earlier in our basic position is that it's a performance-based approach in the way we see it, which means if some plant has a unique situation or wants to do, for whatever reason, their own analysis, they want to take an action and put in a filter, put in a filter. The EPRI report makes a conclusion, which is extremely

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 important, that small specific DF filters may be
2 useful to help give you that additional DF if you need
3 to do it for whatever reason. And we can get into
4 this question as to whether that's the same water-
5 based filter or not. We think it's not. We think
6 it's going to be something else because of the aerosol
7 size issue that was discussed by Jeff and Rick when
8 they were here.

9 MEMBER SHACK: Just on the containment
10 vent cycle, will the containment hardened vent that
11 you're going to put in in response to the current
12 order do you think be sufficient to use the
13 containment vent cycling strategy?

14 MR. KRAFT: The answer is we don't know,
15 but we are going to be engaging in, and the last slide
16 I have here will discuss this, a pilot tabletop
17 project. We actually began discussing that this
18 afternoon on the phone, planning for it, where we want
19 to look at the practicalities of how you implement
20 these strategies and how do you make a plant look like
21 the analysis. I don't think plants look like the
22 analysis yet. I don't think all the plants have the
23 capability to inject the water. They certainly don't
24 have both the dry well and the wet well vent. SAMGs
25 have to be updated. I'll cover that a little bit

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 later.

2 But, yes, your point is that's how you do
3 that. And the answer is it would have to. Can it do
4 it now the way it's being designed? I wouldn't think
5 so, but I don't know all the different . . .

6 DR. GABOR: Yes, I think, you know, the
7 two, obviously there's an automated valve that could
8 provide that benefit also through operator action. I
9 mean, even if you look at some of the plant-specific
10 technical support guidelines and you look in the
11 details of their current strategies on containment
12 venting, you might see discussion in there, depending
13 on the plant, about re-closing the vent and trying to
14 control the pressure within a band.

15 MEMBER SHACK: No. I mean, the staff
16 makes a distinction between a severe-accident-capable
17 vent and an vent that essentially gets rid of decay
18 heat before you have core damage. Now, EPRI doesn't
19 seem to be drawing that distinction.

20 DR. GABOR: Clearly, in our strategy --

21 MEMBER SHACK: To be accident capable?

22 DR. GABOR: Yes, yes, because in our
23 strategies you're going to be venting fission
24 products, radionuclides, hydrogen. So that is part,
25 you know, a severe accident type event is implicit in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 our strategy.

2 MR. KRAFT: And it's hard to imagine NRC
3 wanting to require a filter without also requiring
4 that vent. I mean, they go hand in hand. It's not an
5 option.

6 MEMBER CORRADINI: But maybe just to
7 clarify, so the difference in character of the event
8 that would have severe-accident-capability is what?
9 Not the filter part but --

10 DR. GABOR: I think it's issues around
11 shielding and accessibility.

12 MR. KRAFT: The ability to operate it with
13 a melted core present, things like that. And I think
14 utilities are looking, you know, they know that water
15 stops short of core damage, but I think a lot of them
16 are looking forward saying, okay, if I have to make a
17 change to it, what do I have to do? Shielded
18 operating stations, retrods, you know, things along
19 those lines. When you look at the photos that NRC has
20 shown of the European plants, you see lots of retrods.
21 I don't like retrods myself, but that's another
22 matter. But they, you know, some kind of
23 remotability.

24 MEMBER ARMIJO: Absent the issue of
25 shielding, are there any BWRs today that have the

1 capabilities of the --

2 DR. GABOR: I think there are manual-
3 operated valve capabilities in some of the existing
4 plants.

5 MEMBER ARMIJO: But if they had the
6 shielding and it's --

7 MR. KRAFT: Well, one thing we learned
8 from the post Fukushima reviews is some of those valve
9 locations require you to --

10 MEMBER STETKAR: It might take some
11 ladders and ropes.

12 MR. KRAFT: -- require you to be an
13 acrobat to get to, so that's part of the change on
14 reliable. So the answer is yes. The question is how
15 you actually execute it. That's another question.

16 CHAIR SCHULTZ: But I do hear that,
17 although there may be a comparable understanding of
18 the hardened vent versus the severe-accident-capable
19 vent, that there is a thought process ongoing that the
20 industry feels one ought to move in the direction of
21 a severe-accident-capable vent. However, it still
22 sounds as if the full push isn't there to achieve that
23 by all utility owners.

24 MR. KRAFT: Okay. I'll come back to the
25 one before, but, since we're talking about this, the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 tabletop calculation exercise we want to do, it will
2 be in, basically, three phases. The first phase,
3 which is a feasibility phase, is to investigate, it
4 says here, the practicalities of how you make this
5 work. Containment vent filter consideration is one of
6 the bullets, obviously. We need to figure out how you
7 actually operationalize what it is EPRI came up with
8 in the analysis. So we need to figure out, sitting
9 with plant people, using a specific plant, you know,
10 with their operating staff involved, saying, okay, how
11 would you do this or what changes would you need to
12 make to do this. We need to figure this out. We hope
13 to have that done sometime in January, the first
14 phase.

15 MEMBER STETKAR: Have you talked to any of
16 the European boiler owners? I know of one plant in
17 Switzerland, for example, who has a filtered vent,
18 SAMGs in place. Have you looked at how they actually
19 implemented? Have you talked with them?

20 MR. KRAFT: No, but we rely on the BWR
21 owners to have that information.

22 DR. GABOR: I mean, if it's the one I'm
23 thinking about, they made a presentation at the RIC,
24 and they went into some detail about their design,
25 which, by the way, did include debris cooling

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 capability, all of that. And I remember there were
2 some questions that came up about did they factor in
3 in their design of their external filtering, did they
4 factor in any containment filtering going on or
5 changes to aerosols or any of that. And the answer we
6 got back was, no, they hadn't, that they really didn't
7 take, I mean, they knew they had to have the debris
8 cooling, but that wasn't really part of the specs on
9 what they wanted to filter.

10 MEMBER STETKAR: I was thinking more in
11 terms of, you know, the first bullets look at
12 integration of the design, operational considerations,
13 and that type of exercise.

14 DR. GABOR: I think to a large extent,
15 what we're going to find is a lot of these strategies
16 are too far astray from what the current, at least in
17 the boiler, what the current SAMGs would indicate.
18 There might be, like Steve points out, there might be
19 some design changes or some procedure enhancements,
20 but, you know, the basic functions of venting and
21 flooding containment and spraying containment already
22 exists there.

23 MEMBER STETKAR: That's the reason I asked
24 about the Swiss because they've implemented
25 extensively SAMGs. I actually haven't looked at them.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 It's not my area of expertise. But I know they have
2 them, and they've walked through them pretty carefully
3 or extensively walked through them pretty carefully.
4 So I was curious whether you talked to them to see how
5 far astray they go from the U.S. SAMGs, in a sense.

6 MEMBER ARMIJO: Could I go back to your
7 second slide, Steve?

8 MR. KRAFT: Sure.

9 MEMBER ARMIJO: You made the point that
10 the industry approach is really emphasizing that you
11 should ensure containment. But one of the arguments
12 in favor of the filters is it reduces the reluctance
13 of operators to vent earlier. They have the filters
14 there and, rather than threaten the containment in any
15 way, to vent them at lower pressures or something.
16 And is that counter to the industry philosophy that,
17 hey, we're going to contain as long as we can and
18 we'll vent only at very high --

19 MR. KRAFT: No, we didn't say contain as
20 long as we can. We said contain the radionuclides in
21 containment, which may require early venting in order
22 to control pressures and temperatures in the
23 suppression pool.

24 MEMBER ARMIJO: Okay. So there's no
25 objection to earlier --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. KRAFT: Absolutely not. The contain
2 is contained radionuclides in containment. One of the
3 things that's not been lost on utilities where we do
4 look at, when they have looked at what it would take
5 to put a vent filter, external filter is it's outside
6 containment, it's in a shielded building. It's
7 another hazard in the yard you have to worry about
8 when you're approaching the damaged plant, etcetera,
9 etcetera. The biggest question I get asked by the
10 utility CNOs is can you get me one small enough I can
11 keep in containment? And so that's when you look at
12 the small, the specific DF built-ins that are not
13 water-based, because you're using the water to strip
14 out the larger aerosols, you see some designs that
15 look like high-grade, you know, steel wool sort of
16 thing and progressively finer mesh. There's other
17 designs around. That part of the filter, if you look
18 at the water filters, as I understand the designs,
19 you'd have the sparger and the water at the bottom of
20 the tank, and at the top you've got some sort of
21 metallic device of some kind. Something like that
22 could be done in smaller spaces. And because it's not
23 a water tank, it could be split up in pieces and put
24 in different compartments and pipes so you don't have
25 to get it outside. Keeping it in containment seems to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 be a very important matter to our utilities, so that's
2 what we meant by containment, not that you don't open
3 the vent.

4 So if I could just go to the slide I
5 skipped. Okay. So as I discussed with Dr. Shack, the
6 goal here is you have to figure out how to make the
7 plant look like the analysis. Each plant would do its
8 own analysis. There's a lot of uniqueness in plants.
9 In fact, in the tabletop discussions, just kind of
10 looking around the fleet of BWRs, we could choose. Of
11 course, initially, we'd stay away from the twos
12 because there's only six of them, although you have to
13 look at them eventually. And then in the ones, two of
14 them have isocondensors and the rest of don't. So you
15 have to sort of pick something that's representative.
16 You'll have a number of different fleets involved in
17 the discussions. We'll have the BWR Owners Group
18 looking at it with us. But at the end of the day,
19 you're going to have to do this performance-based
20 analysis.

21 And then we imagine at this point, having
22 looked at what EPRI has done, here's a list of the
23 plant modifications that need to be made. Wet well
24 and dry well vents require it. You know, the order
25 doesn't say wet well or dry well. It's sort of up to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 you. Well, if you want to make the plant look like
2 the analysis, you need both and you need some kind of
3 valving arrangement or some kind of auto-actuating
4 valves or something or control circuit or something to
5 make that work, which, of course, would have to be
6 reliable, proven to be reliable. We'd have to include
7 FLEX. For example, if you look at the EPRI report, it
8 talks a 500-gallon per minute minimum pump capability.
9 Now, that's not going to run your spray header like
10 the 5,000 or 10,000 spray pumps. It's going to
11 dribble it. But it's the way you get water in
12 containment.

13 But FLEX now calls for a 300-gallon per
14 minute pump. So one of the things we need to do in
15 the pilot plant is come up with a list of things,
16 okay, wait a minute, I need to get something else.

17 And then one thing I want to mention in
18 Mark IIs, and Jeff could talk about this at great
19 length because he's the one who taught me all about
20 it, is that you have the capability to bypass the wet
21 well in Mark II through a drain line and maybe other
22 mechanisms that have to be cut off during the
23 accident, and that needs to be worked out. There is
24 one plant, a Mark II plant, that, for other reasons,
25 did that, so there's precedent for that. And then,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 again, I'll say possible additional specific plants
2 maybe putting a filter in, but the kind of filter I
3 think more research is needed.

4 And then just to point out that we've been
5 talking to vendors. We are encouraging the
6 renovation. They're looking at this question. And
7 something that I said at one of the technical
8 exchanges, and I won't repeat who this vendor is
9 because it's unfair, but over dinner with one of the
10 vendors, a fellow was making the point we put in 60
11 filters successfully around the world. Well, sure you
12 have. What did the design spec ask for? Filters.
13 Did anyone ever ask you the question how do I approach
14 this, keeping radionuclides in containment, taking
15 advantage of the water? Inherently, I have to put in
16 containment control. Every vendor has said we've
17 never been asked that question.

18 So when they've been asked that question
19 and they put all their smart engineers on it, they're
20 actually coming up with first results similarly to
21 EPRI's results and, secondly, some innovative
22 approaches to how you would come up with a smaller,
23 perhaps -- I say dry. Dry is a misnomer. It's dry in
24 a sense that it's not a water media filter, but it
25 gets wet when you use it. Dry doesn't exactly work

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 there, but you know what I mean. It's not a water --

2 MEMBER STETKAR: It's not a tank of water

3 --

4 MR. KRAFT: Thank you very much, Dr.

5 Stetkar. That's right. So that's what I wanted to
6 cover in my slides. I'm not going to go through all
7 the technical stuff in the back. You've seen it
8 before, but Jeff is here to answer those kinds of
9 questions if you want to talk some more.

10 MEMBER ARMIJO: Yes, I had a question on
11 the containment spray. In the analysis by the staff,
12 I think Marty Stutzke's analysis showed that the weak
13 link as far as land contamination or dose seems to be
14 when you're in a situation where you can't vent
15 through the suppression pool and you don't have enough
16 flow to cold ignite the nozzles and have a containment
17 do the job. Has the industry, has it looked at means
18 of improving the containment spray system, you know,
19 bigger pumps or better nozzles or something to ensure
20 that it would be more effective than it's currently
21 given credit for? It seems like that's -- the staff
22 pinpointed a problem --

23 MR. KRAFT: Let me answer the question,
24 answer two ways.

25 MEMBER ARMIJO: Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. KRAFT: First, the pilot project will
2 identify if there's a need to do that and how we might
3 do that. That's one of the things that we'll look at
4 for sure. But, secondly, as I understand the
5 scenarios, and I'll ask Jeff to comment in a second,
6 we're not relying on the spray to achieve that
7 carefully designed spray pattern to scrub the
8 atmosphere. The ring header is there to put water in
9 containment, and it's the water in containment that
10 does the stripping. The question that has come up is,
11 once you get to the point where the wet well vent, you
12 know, has been flooded out and you've got a core to
13 the dry well, if you can't, how long can you wait
14 before you have to open up that valve? In other
15 words, are you re-volatilizing the plated out? And
16 the answer, Jeff, is quite a few days.

17 DR. GABOR: Yes. So in the EPRI analysis,
18 we looked at a lot of different sensitivities to
19 degrading the effectiveness of the spray. We changed,
20 you know, parameters associated with how effective you
21 can sweep out the atmosphere. We changed droplet
22 sizes. And we found about, I think about a factor of
23 two benefit out of sprays versus just flooding. As
24 Steve says, the primary benefit is getting water on
25 the debris because that controls temperature in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 containment. It prevents any failures, additional
2 sneak paths or leak paths out of containment that
3 would bypass a filter, could bypass a suppression
4 pool. So, clearly, the fact that you're putting water
5 in is where we get the most bang for the buck. And
6 like I said, about a factor of two we see by the
7 sprays themselves.

8 We know there's variation in the spray
9 nozzles that people have. I think at our last meeting
10 Dana Powers mentioned that he thought there were two
11 primary types of nozzles that were used, some that
12 would provide a spray coverage at low flow and some
13 that would not.

14 So we haven't surveyed the industry yet.
15 We'll have to figure that out when we do our pilot.
16 But I think it is a good point we want to make sure we
17 understand what the capability is. But, again, the
18 primary benefit was in just getting the water on the
19 floor.

20 MR. KRAFT: Yes. I think, though, if you
21 look at existing designs, you probably have to achieve
22 a 5,000 or 10,000 gpm flow to make that spray work the
23 way it's intended, and I don't know anyone that's
24 getting those kind of FLEX points.

25 MEMBER ARMIJO: I don't know what it takes

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 to get a pump to do that, but it's probably a pretty
2 expensive thing or, you know --

3 DR. GABOR: The one thing I was going to
4 say, though, when you mentioned this scenario, and
5 maybe I misinterpret it, you were talking about a case
6 I thought where the wet well venting didn't work or
7 didn't properly function, and then we had to go to a
8 dry well. I know that scenario was presented by the
9 staff at your last meeting, and I think there was some
10 discussion. I had to leave early, and I think Rick
11 said the next day that he had some dialogue with the
12 staff on it. But we have to be sure. I mean, we can
13 always hypothesize different types of failures. But
14 by going to a dry well vent initially violates the
15 procedures that we have. They're very clear that you
16 start with the wet well vent, you maintain that vent
17 path until you have a water level. It's very clear.
18 In that scenario, where it does tend to show a higher
19 release and potentially more benefit from an external
20 filter, it is important to realize where it fits into
21 the procedures and the strategies.

22 MEMBER ARMIJO: That's an event that would
23 not happen if you followed the industry procedures.

24 DR. GABOR: And, again, from a
25 probabilistic point of view, you could say that maybe

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 there's a probability that that valve failed but the
2 other one didn't and they would go there. There is a
3 likelihood, of course.

4 MR. KRAFT: The other way to look at it,
5 and, again, I won't mention the vendor, but one vendor
6 approached us with the concept that you forget wet
7 well venting altogether. Just eliminate it and forget
8 it. Flood containment, flood-up, only have a dry well
9 vent. When the piston effect occur, you open up the
10 vent and you have a filter. You just have that one
11 filter. Well, that completely violates the industry's
12 desire to keep all the radionuclides in containment.
13 There, the only way you have filtering is outside
14 containment and that doesn't make any sense to anyone
15 that I've asked about it, but it is one of the
16 concepts that we've heard about.

17 MEMBER ARMIJO: Okay. Thank you.

18 CHAIR SCHULTZ: Could we go to the -- the
19 next slide is the pilot study associated with that.
20 It's described as a tabletop --

21 MR. KRAFT: Right.

22 CHAIR SCHULTZ: -- pilot. And is the
23 investigation on one particular design or several?
24 What I'm concerned about is a sequence of pilot
25 studies that examines this plant and that plant and so

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 forth, and we get into a mode where the information
2 that we're gathering and learning and evaluating is
3 not shared through the industry and --

4 MR. KRAFT: Right. I --

5 CHAIR SCHULTZ: -- we're spinning our
6 wheels and taking a long time to get --

7 MR. KRAFT: Excellent point. We had
8 precisely that conversation about an hour ago. To do
9 a pilot plant pilot, you have to have a plant. So
10 there will be a plant volunteer. Not free to say who
11 it is just yet. That plant will be a BWR. Whether
12 it's a one or a two, don't know yet. I'm arguing for
13 one, greater portability. And then what we'll be
14 doing is working with the BWR Owners Groups and
15 probably two fleets that have lots of those plants.
16 And I don't have to tell you who they are; you know.
17 And we will then look at that plant and then say,
18 okay, how is that plant different from its neighbor?
19 Then let's do a sensitivity study.

20 For example, if you pick the plant that
21 has a RCIC system, not an isocondensor, we'll then do
22 a sensitivity study the other way around. Things like
23 that. So we'll be using the BWR Owners Groups and the
24 industry to -- by the way, the PWR Owners Group has
25 consented, as well, so they're familiar with what's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 going on -- to identify what the differences are so
2 when we do come up with here's what we think this
3 tells us, how applicable it is around the industry.
4 That's definitely the plan.

5 And we brief you about, you know, pilot
6 plant. No one is interested in, you know, a sump
7 strainer-style science fair. I've heard that from the
8 staff. They're not interested, and we're not
9 interested. But let's figure this out. Let's work
10 the milestones, you know. And so we want to prevent
11 that kind of -- what do you want to call it -- scope
12 creep as much as we can.

13 CHAIR SCHULTZ: I call it a lesson
14 learned, and I was hoping we would not repeat such
15 lessons learned. I did want to just reconfirm again,
16 because when I read the work that was done by EPRI and
17 the way that, in that document, the capability of the
18 event is described, it appears as if it meets the same
19 definition that would be described as a severe-
20 accident-capable vent. And I just want to --

21 MR. KRAFT: You're right.

22 CHAIR SCHULTZ: -- get that square that
23 the intention and the work that has been done by EPRI
24 is well understood by the industry that it would go
25 beyond what was ordered already in terms of hardening

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the vent to an approach that would allow the vent to
2 be considered severe-accident-capable --

3 MR. KRAFT: We have made that point to our
4 Fukushima steering committee. And while I can't speak
5 for everyone in the industry, I was talking to the
6 responsible individual at one of the large fleets who
7 said we already understand we have to do that. So I
8 think the answer to your question is, yes, but part of
9 the pilot plant pilot study is to then socialize all
10 this information throughout the industry so there's
11 uniform understanding as to what's required.

12 CHAIR SCHULTZ: And when you put the words
13 out to say we understand we need to do that, is that,
14 I'd like to believe that that was based upon an
15 understanding of the EPRI work and an understanding
16 that there's a real benefit to doing that in order to
17 be able to say we have additional capability to
18 respond to severe accidents if we get to that point.

19 MR. KRAFT: Well, I mean, we can't make
20 commitments for every licensee, but that's certainly
21 the intent. I don't think we say it any stronger.
22 The chairman of our steering committee, Jim Scarola
23 from Duke, has made clear to me and clear to, you
24 know, the steering committee that we're going to do
25 this right, you know, uncompromising. So I think the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 answer to your question is yes, and we'll just have to
2 make sure that it's understood that way.

3 I don't know what the staff paper is going
4 to say. And the last I heard, and I see John
5 Monninger is going to look at me over here, the last
6 I heard were four options. So if an option is severe-
7 accident-capable vent, which I don't know what that is
8 when it's at home but I understand that's the words
9 they use, how is that an option? Unless your decision
10 is to recommend nothing, no change, then --

11 CHAIR SCHULTZ: That's an option.

12 MR. KRAFT: I know that's an option, but
13 I'm saying once you recommend any of your other
14 options to have a filtering capability, either order
15 a filter or performance based or whatever, you have to
16 have the event capability the way you describe it. I
17 don't understand how you don't myself.

18 CHAIR SCHULTZ: That's true.

19 MR. KRAFT: So I don't get, I just never
20 understood how that was an option in this because what
21 that said, as an option in this paper, you need the
22 event capability to survive the accident. I don't get
23 it. It seemed like a fairly limited application to
24 me.

25 CHAIR SCHULTZ: Well, it fits into the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 work that EPRI has done if, in fact, it's described
2 and intended the same way. One concern would be that
3 we would describe it that way in doing an evaluation
4 and a study and demonstrating what could be done, but,
5 in fact, what we have done is we've put in a hardened
6 vent and the operators can't get to it to do those --

7 MR. KRAFT: No, but you can't do the
8 controlled venting in the EPRI study without having a
9 vent that's capable like that. And that goes to my
10 point about how do you make the plants look like the
11 study? So I see that as a natural occurrence, but
12 your point is well taken about what the entire
13 industry understands. I agree with you that you
14 couldn't find everyone in the industry understands
15 this because it's not been promulgated widely enough
16 yet because there's no requirement. The studies have
17 been done. Everyone, you know . . .

18 MEMBER CORRADINI: Can I ask a different
19 question. I'm looking at this slide, and you talk
20 about the tabletop pilot. So are you going to work
21 this backwards in the sense that you're going to start
22 off, or at least I would expect you to work it
23 backwards, you start off with an overall system
24 performance and then see what required design changes,
25 SAMG enhancements, and filter considerations we would

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 need to achieve that? I mean, the way you have it,
2 it's linear this way. It seems to me, if you're going
3 to do this --

4 MR. KRAFT: It's iterative, isn't it?
5 Isn't it more iterative?

6 MEMBER CORRADINI: Well, maybe, but I'm
7 trying to understand, because I'm looking at your last
8 bullet, I've been reading it two or three times, and
9 I think I get it. So you're going to have some sort
10 of overall representative, and it has to be plant
11 specific, but just some overall value at some sort of
12 reliability, and then you're going to look at what
13 might be needed to be done to achieve that with a
14 particular plant under a set of particular SAMGs,
15 etcetera, etcetera?

16 DR. GABOR: I think that's right. I mean,
17 we identified in the EPRI report that, you know, a
18 viable strategy had to provide at least a DF of 1,000,
19 overall DF of 1,000, a 0.1 volatile releases of
20 cesium, which we think is consistent with what we've
21 seen in Europe 20 years ago when they were looking at
22 these. That seemed consistent. So we wouldn't judge
23 a strategy, a plant-specific strategy, to be really
24 viable if it didn't at least achieve that objective.

25 So I think Steve is right. It is going to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 be iterative because there is some flexibility in the
2 SAMGs. There ought to be. There should be. And
3 we're going to probably iterate to see, you know,
4 within the realm of what's allowed in the SAMGs and
5 perhaps some enhancements to the SAMG, what works best
6 and what doesn't. So I do think that we'll exercise
7 a fair number of scenarios to better understand, you
8 know, what works the best. And that might involve
9 things like early containment venting. There are
10 strategies prior to the severe accident where you
11 could be venting early that the Owners Group has been
12 looking at. Those things need to be rolled into this
13 tabletop, as well, to see what kind of additional
14 benefit does it provide. And we included a
15 sensitivity in the report to say, prior to core
16 damage, if you could keep the pressure low, and this
17 is consistent with updates that are being done about
18 to be rolled out on the technical basis report, and
19 that is to try to maintain a moderately low
20 containment pressure even prior to core damage event.

21 So I think it will be an iteration, but I
22 do think that, you know, consistent with the EPRI
23 study, we don't --

24 MEMBER CORRADINI: That's your starting
25 point.

1 DR. GABOR: Our starting point is going to
2 be you're pushing to get at least a DF of 1,000.

3 MEMBER SHACK: Now, I mean, you agree that
4 you do need to do dry well venting in some situations?

5 DR. GABOR: No, I don't. I won't agree to
6 that. I think there are strategies, and there have
7 been some additional -- the reason we have to go to a
8 dry well vent is because of inventory control. There
9 may be other ways to manage inventory, and I've seen
10 some of these. And the utilities are coming up with
11 some of these strategies. So it's not a given, and
12 what's interesting about it, depending on, you know,
13 you can see the tradeoff. At first, you'd say, oh,
14 the more gpm I put into containment the better.
15 That's not always true because that's going to push
16 you to that to quickly make the decision that you
17 would require dry well venting.

18 But, again, in the analysis that we did,
19 we saw that, you know, initially venting through the
20 wet well brought the pressure down such that, yes, you
21 would eventually get to a point where you had, if you
22 needed to vent later, it would have to be through the
23 dry well. But it turned out that the early venting
24 and all the cold water you're putting in soaked up
25 enough decay heat that your requirement to open that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 dry well vent got pushed way out in time, and you can
2 see that in our report.

3 So I'm not saying dry well venting is a
4 given. It's clearly handled in the SAMGs. It's
5 addressed in the EPRI report. We'll see how it plays
6 out with our pilot and the actual strategies.

7 MEMBER CORRADINI: Can I go back to your
8 slides real quick? So these are just examples. There
9 are other things that you would have to, that might
10 come up on the list when you run the calculational
11 experiment?

12 MR. KRAFT: Yes, absolutely.

13 DR. GABOR: We have seen a strategy to let
14 down the torus, to find a way to pump water out of it.

15 MEMBER CORRADINI: Okay. Because that's
16 exactly where I was going with it because, if you did
17 that, then you'd have to have some sort of external
18 place to put it, given all the stuff that might be in
19 it.

20 DR. GABOR: Exactly.

21 MEMBER CORRADINI: Okay.

22 DR. GABOR: Exactly.

23 MEMBER CORRADINI: And then remind me
24 about the fifth one about Mark II. I don't remember
25 that and that geometry.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 DR. GABOR: Yes. And we talk about this
2 kind of generally in the report, but, as Steve pointed
3 out, there's five sites that have Mark II plants --

4 MEMBER CORRADINI: And they're all
5 different.

6 DR. GABOR: And they're all different.
7 But one of the common things that we did see in four
8 out of the five was that, at least beneath the reactor
9 vessel in the cavity or pedestal region, was, you
10 know, a collection system, a drain system.

11 MEMBER CORRADINI: It's empty. There's no
12 water.

13 DR. GABOR: Right. But it involves a
14 four-inch pipe or multiple four-inch pipes that go
15 down through the diaphragm floor and likely take a
16 right turn and exit out of containment. Some of them
17 go into a hold-up tank that's still in containment.
18 I think some of them may actually get pumped out. I'm
19 sure, you know, there's isolation valves. But debris
20 in a four-inch pipe taking a right angle poses a
21 potential threat, melting. It's likely not going to
22 stay coolable in there, so it's going to melt and
23 create --

24 MEMBER CORRADINI: That's what I thought
25 you were talking about.

1 MEMBER SKILLMAN: Let me ask this. In a
2 tabletop exercise, how do you pick the plant? Here's
3 an example. You talked about Cooper, Columbia,
4 Vermont Yankee, Pilgrim, Peach. They're all
5 different. They have different population densities,
6 different economies, different types of land
7 surrounding them. How is choosing one representative?

8 MR. KRAFT: Well, we're trying to
9 represent the plant itself, not the surrounding
10 community population density. We're not doing
11 consequences calculations or anything like that.
12 We're trying to figure out how do you operationalize
13 in the plant these activities, so the selection is
14 easier than you just described but it's really going
15 to be picking a plant that is representative,
16 initially, of as many as possible and understand what
17 sensitivity analyses we have to do and then also
18 picking a plant that the company is willing to put the
19 resources into it on behalf of the industry. You
20 know, there was a plant we talked about picking that,
21 frankly, has been the subject of a lot of studies in
22 the last two years by this agency, and I don't know
23 whether they want to do it again, you know, because
24 the plant has to, themselves, put resources into this,
25 which is not to say they wouldn't be willing to. I'm

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 just pointing out that there's a way to pick these
2 things.

3 But the idea that -- we're not going to
4 exercise the MACCS2 code part of it. We're going to
5 be looking at the MAP code part of it.

6 MEMBER SKILLMAN: Just a minute here. I
7 hear your words, but I'm not as comfortable as you
8 are. If I'm going to be talking about SAMGs, I'm in
9 the EALs. Now, if I'm in the EALs, I'm looking at
10 doses and population. That's what's going to trigger
11 the EALs, and the SAMGs are going to get me there.
12 And so when you say they're really not connected,
13 Steve, I don't share that point of view.

14 DR. GABOR: Well, let me try. As Steve
15 said, we've picked our surrogate for offsite
16 consequences, and that is achieving an overall DF of
17 1,000 or better, limiting the release of cesium to
18 less than a tenth of a percent. So by picking that as
19 our surrogate, we don't have to do the offsite
20 planning work. We don't have to investigate. I'm not
21 saying we're not. That might be another phase of
22 this. But it doesn't affect the actions that we're
23 taking to achieve a DF of 1,000.

24 MEMBER SKILLMAN: I can see that from
25 inside the plant.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. KRAFT: Although, having said that, we
2 did this afternoon on our planning call, we looked at
3 it from the other way around. I mean, should we have
4 an EP representation at the table, not so much for
5 when you kick off emergency action or anything like
6 that, but because, at some point, this activity does
7 bleed out into that planning, as well.

8 MEMBER SKILLMAN: Absolutely.

9 MR. KRAFT: But you have to keep the scope
10 controlled enough so you can get it done in a
11 reasonable amount of time. The target for getting the
12 first phase of it done, which is the feasibility, is
13 to be able to have the industry discuss the results at
14 the public meeting the Commission will have on that
15 report probably in January. So that's not a lot of
16 time.

17 DR. GABOR: I think the other thing, you
18 know, the subject of the pilot was motivated by
19 feedback we initially got from the staff when we
20 presented the EPRI findings because, obviously, the
21 EPRI analysis is I didn't have to worry about the
22 reliability of the pump, I didn't have to worry
23 whether the operator could successfully perform those
24 actions. I just said they did, it worked. I'm a
25 deterministic kind of guy. But the questions we got

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 from the staff went beyond that and said, okay, we
2 understand these strategies, but how can they be
3 implemented, how successfully can they be implemented
4 from equipment reliability, human actions. That's the
5 focus and that's the product we want to get out of
6 this pilot is to demonstrate that.

7 MR. KRAFT: For example, we'll have at
8 least one license, you know, SRO at the table to talk
9 to that issue, you know, as we work on it from that
10 plant, you know, understands how that plant, whatever
11 plant it is we pick.

12 MEMBER STETKAR: Jeff, you left yourself
13 wide open. Rich isn't here. I'm not a deterministic
14 guy. I'm kind of a probabilistic guy. One of the --
15 in terms of selecting your pilot plant, somewhere in
16 your slides you make the note of representative
17 scenarios. And when I think of representative
18 scenarios, those are sequences of events that have
19 frequencies assigned to them, and those frequencies
20 account for the things that you said are not part of
21 your world, you know, valve failures and human error
22 probabilities and timing of scenarios and dependencies
23 among human actions if there's a lot of manual things,
24 the effects of external events on availability of FLEX
25 equipment perhaps or the ability to connect it and so

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 forth.

2 Are you going -- I would hope, because I'm
3 a probabilistic kind of guy, that the pilot plant that
4 you take would have a fairly well-developed PRA so
5 that you can actually look at those scenarios so you
6 don't rely on only, you know, pardon me, the
7 deterministic guys to pick the scenarios that are
8 interesting to them.

9 DR. GABOR: You know, we, as a group,
10 we've been talking about, you know, we're still kind
11 of formulating the pilot and what we want out of it.
12 And there were initially some discussions about, well,
13 we might want to see some probabilities playing in
14 here. I don't think we're going to go there, but I do
15 think, I do agree with you that we ought to, if this
16 is a plant-specific pilot, we ought to take the
17 insights that are coming out of the plant-specific PRA
18 and at least make sure that the scenarios we're
19 picking are consistent with what's driving risk for
20 that plant.

21 Now, we all think we understand long-term
22 station blackouts. We think we're going to cover a
23 pretty --

24 MEMBER STETKAR: That's part of the
25 problem, though. Everybody understands station

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 blackout and everybody knows that's the worst thing
2 that can possibly happen or that it's the most
3 representative. In some cases, it's not. In some
4 cases, there's a fairly high conditional probability
5 that things that don't look like a station blackout
6 with successful RCIC operation for, you pick the time,
7 is the most important contributor. And understanding
8 where in relative space those other scenarios are I
9 think is an important perspective.

10 MR. KRAFT: One of the first things we
11 talked about was initial conditions. It was exactly
12 what you're getting at. So I think that is first on
13 the list that --

14 DR. GABOR: Yes, I don't disagree with
15 where you're pushing us. I think we do have to
16 consider the insights from the plant-specific PRA.
17 And, you know, we tried to do that in the EPRI study
18 to some extent to look at, you know, even though we
19 did focus on a station blackout, we tried to do things
20 like, well, let's change the time at which RCIC can
21 operate it, is that going to influence anything? And
22 what if RCIC doesn't start? I mean, you know, what if
23 we lost at time zero? So we tried to cover that. We
24 didn't go out and look at a full PRA.

25 MEMBER STETKAR: And I think part of it,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 you know, you can select scenarios, but without a
2 context for saying, well, there's 75-percent
3 probability that this is at the top of the heap, but
4 there's 15-percent probability that the scenario might
5 look like this, as opposed to, you know, 0.015-percent
6 probability, is an important perspective, rather than
7 just kind of selecting scenarios.

8 DR. GABOR: No, I agree. I think we have
9 to be cautious of that, and we have to be paying
10 attention. I mean, the only thing I'll say is from a
11 Level 2 point of view. A lot of that stuff just
12 really isn't going to change the outcome, so the
13 strategies that we employ may not be sensitive to was
14 it a LOCA or not a LOCA. They could be because
15 fission product transport changes. Same thing with,
16 you know, from a Level 2 PRA, we always, as you know,
17 we always address high pressure/low pressure core
18 melt. So those factors I understand we could have
19 some sensitivity to, and we need to address that.

20 MEMBER STETKAR: But some of the
21 integration, some of the transitions from Level 1 to
22 Level 2 to SAMGs and so forth, especially if you're
23 talking about severe initiating events, seismic events
24 in some cases, other types. I mean, I use the seismic
25 event, but other types of even internal initiating

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 events that could get you to similar conditions and
2 especially if you're talking about human actions,
3 operator actions. Your operators don't know the
4 difference between Level 1 PRA and Level 2 PRA. They
5 respond to an event.

6 So some of the notions of, well, if there
7 are scenarios that might benefit from early venting
8 prior to core damage, not your ballpark, what's the
9 likelihood that they would do that? And if they don't
10 do that, you know, what's the likelihood that they
11 would then implement in your kind of Level 2 space the
12 actions that you're presuming that they would do
13 following the SAMGs? That sort of integrated
14 perspective might benefit, at least in terms of the
15 context of --

16 DR. GABOR: Yes, I don't disagree with
17 you.

18 MEMBER STETKAR: -- those representative
19 scenarios.

20 DR. GABOR: And we made it clear up-front
21 that we wanted PRA presence on the pilot for those
22 reasons.

23 MEMBER STETKAR: Thanks.

24 MEMBER ARMIJO: Just a quick question.

25 This pilot, how long will that take? Is it a one-year

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 thing, two years?

2 MR. KRAFT: Well, the full pilot, we, back
3 of the envelope, think is a year. But this initial
4 part of feasibility, probably a few months in January,
5 and then we'll determine, when we meet for the next
6 phase, we'll be looking at specific systems and
7 components; and the third phase will be what you do
8 actually in the plant. So we're not committing -- we
9 want to do the whole thing, but we want to be able to
10 talk to the agency earlier. If we had to wait until
11 the whole thing, we'd, you know, I don't think anyone
12 would tolerate that.

13 One thing I want to mention, as we've
14 exceeded our time here, Mr. Chairman, is that all this
15 discussion we've had that involves how you put water
16 on the corium outside the vessel applies whether you
17 accept our notion of filtering strategies or an
18 external filter because if you go back to the event
19 tree you have to do that. You have to do all these
20 things Jeff is talking about. And all the questions
21 about how operators behave, how valves behave, all
22 apply regardless. So it's not unique to what we're
23 proposing as a performance-based requirement,
24 performance-based approach. I just want to make that
25 point because sometimes it sounds like, because we're

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 talking about it, it's unique to what we're proposing,
2 but I don't think it is. It has to be done no matter
3 what. You could have a Mark II bypass directly into
4 the dry well whether you've got a filter on the pipe
5 or not. And so you still have to close up that
6 pathway, so this kind of work is still needed.

7 DR. GABOR: Yes. The other thing I'll
8 just add, I know you mentioned the additional slides
9 we had. But Doug True put together an FMEA, and you
10 can see from that we were asked a question, if not by
11 you but multiple times by the staff, is if you had
12 FLEX you wouldn't have core damage, so how can you
13 then have that equipment to mitigate an accident. So
14 the FMEA was to try to put some perspective --

15 MR. KRAFT: By the way, that's an
16 extremely fair question. I mean, if you assume you
17 have core damage, you have to assume FLEX didn't work
18 for some reason, so how does FLEX now work? That's a
19 key issue in our, in this pilot. I mean, how do you
20 mobilize to people? Can you get the hookups? You
21 know, things like that. But, again, back to my
22 context, we're beyond design basis, so how you think
23 about things is different and how you think about
24 what's the appropriate thing to do is different than
25 a design basis where everything is not easy to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 predict.

2 CHAIR SCHULTZ: And, Steve, the project
3 managerial focus on the pilot study is the Owners
4 Group?

5 MR. KRAFT: Yes.

6 CHAIR SCHULTZ: And their activity and
7 their leadership which would drive it through the next
8 steps and assure that there's --

9 MR. KRAFT: Well, BWR Owners Group is
10 managing it. There's a heavy component from EPRI.
11 NEI, of course, is involved. But the leader is from
12 our Fukushima steering committee. The leader is Maria
13 Korsnick, who is the CNO of Constellation. It needs
14 that level of attention in the industry to get done
15 right. We learned that lesson. And the way the
16 industry function is when we have big issues like this
17 we name an executive sponsor, and that's Maria. So
18 that's where the management starts, and, you know,
19 she's a pretty good taskmaster, I'll tell you that.

20 CHAIR SCHULTZ: Thank you. Other comments
21 or questions from the Subcommittee? With that, I'd
22 like to thank you, Steve, and you, Jeff, for the
23 discussions. It's been very helpful in terms of
24 understanding more than what we learned from the EPRI
25 report and certainly our previous discussions and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 presentations, to thank you very much.

2 And with that, I would like to move into
3 the staff's presentation. So a moment or two to
4 rearrange chairs, but we'll move forward with this
5 presentation and we'll pick an appropriate time to
6 take a break later in the meeting. So with that, I
7 would like to introduce Bill Ruland, who would like to
8 make some opening comments and introduce the staff to
9 us. Bill?

10 **MR. RULAND:** Good afternoon. Today, the
11 staff will add to our previous discussions about the
12 qualitative and quantitative factors. And we're going
13 to add to that our recommendation for recommendation
14 three, which is a recommendation for filtered
15 containment ventilation systems.

16 As at our previous meeting, the
17 qualitative factors in the cost benefit analysis were
18 key, as we described at the previous ACRS meeting.
19 Contrary to what you just heard from the industry that
20 the staff regulatory analysis demonstrates additional
21 filters is not justifiable, we believe we applied the
22 backfit rule, as the Commission envisioned, for SRM.
23 And, obviously, we know that this is a beyond design
24 basis analysis of the beyond design basis event, as is
25 virtually everything associated with Fukushima. So we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 understand that.

2 And in addition, you heard the description
3 from EPRI and NEI about what their presentation was.
4 The staff was aware of basically everything that the
5 industry presented, and we encourage questions from
6 the Committee specifically concerning the things that
7 the industry said today. So we're prepared to respond
8 to those questions and, hopefully, we will get a
9 fruitful dialogue with this matter.

10 So with that, I'd like to -- John -- Bob
11 Fretz, you want to get started?

12 **MR. FRETZ:** Sure, I'll get started. Thank
13 you, Bill. Good afternoon, Dr. Schultz and members of
14 the ACRS Subcommittee. My name is Bob Fretz, and I am
15 a project manager within the Japan Lessons Learned
16 Project Directorate. I'll be kicking off our briefing
17 this morning. I will dispense from any other further
18 introductions. I believe we have a number of members
19 of the staff who will be presenting information in
20 addition, as you see up here at the table right now.
21 So I'll then dispense with that.

22 Again, we are here today to discuss the
23 draft commission paper regarding the NRC staff's
24 evaluation of options and proposed recommendations on
25 whether or not to impose additional requirements for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 BWR Mark I and Mark II containment venting systems.
2 Our agenda is quite simple. I will provide a brief
3 summary of the staff's tasking and schedule update.
4 Now, again, the bulk of our presentation will be to
5 discuss the draft commission paper, including the
6 staff's proposed recommendation. As you know, the
7 staff has been working under a tight schedule over
8 these past few months. As of less than a week ago,
9 our plans included a discussion of the most current
10 draft of the SECY paper with the Japan Lessons Learned
11 Steering Committee, and that meeting was scheduled for
12 this past Monday. And the meeting that we had hoped
13 to have was the staff had hoped to obtain the Steering
14 Committee's endorsement of the staff's proposed
15 recommendation or at least one of the other options
16 based upon the review of the paper.

17 Unfortunately, Hurricane Sandy had
18 something to say about our plans and schedules for
19 this past week, so we were unable to meet with the
20 Steering Committee prior to meeting here today. So,
21 therefore, the Subcommittee should be aware that, when
22 we do talk proposed recommendations, they are
23 currently proposed recommendations. We have met with
24 the Steering Committee a number of times. They've
25 been generally supportive of the staff's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 recommendations. However, we have not received a
2 final recommendation, so we hope to receive that
3 shortly.

4 Again, our tasking really came to be from
5 last December when the Commission told the staff that
6 it should shift the issue of filtration of containment
7 events from the additional issues category and merge
8 it as a Tier 1 activity. In addition, this past
9 August, the Commission directed the staff to include
10 a discussion of accident sequences where filters are
11 and are not needed as part of its Commission paper.
12 We consider it our second tasking.

13 And, again, our current schedule. We
14 first met with the Subcommittee way back in June where
15 we had talked about the experiences and insights that
16 we gained from foreign regulators, including Sweden
17 and Switzerland, as well as Canada. We did meet in
18 September to discuss the additional items and
19 introduced some of the information of the studies that
20 we got from our MELCOR analysis. And, again, we met
21 as recently as October 3rd, I believe, where we had
22 talked about some of our preliminary results from our
23 MACCS analysis. Again, this is, essentially, a
24 continuation of those meetings we've had with the
25 Subcommittee, and I understand we're still on schedule

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 to meet for tomorrow with the full committee.

2 And, again, I'd like to turn the rest of
3 this discussion over to John Monninger.

4 **MR. MONNINGER:** Good afternoon, Dr.
5 Schultz and ACRS members. My name is John Monninger.
6 I'm the Associate Director of the Japan Lessons
7 Learned Project Directorate in the Office of Nuclear
8 Reactor Regulation. I want to thank you very much for
9 the opportunity to brief the ACRS today on the staff's
10 development of a draft commission paper, which you
11 have a copy of, entitled "Consideration of Additional
12 Requirements for Containment Venting Systems for
13 Boiling Water Reactors with Mark I and Mark II
14 Containments."

15 In developing this paper, the staff is
16 providing the Commission with information options and
17 a recommendation on imposing new requirements related
18 to containment venting systems for BWRs with Mark I
19 and Mark II containments. Specifically, the options
20 presented include requiring containment venting
21 systems capable of operation under severe accident
22 conditions, containment venting systems that include
23 filters within the control release pathways, and a
24 performance-based approach to containment filtration
25 strategies.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 We've performed various assessments and
2 analysis of the possible requirements for licensees to
3 ensure that the containment venting systems are
4 capable of operation under severe accident conditions.
5 We've had numerous public meetings and interactions
6 with the ACRS to date, and we thank you very much for
7 your feedback and we have taken it into consideration
8 and are fully prepared to discuss that today.

9 The evaluation of the options use existing
10 NRC processes and address possible updates to our
11 associated guidance documents, in particular the
12 regulatory analysis guidelines. The evaluations also
13 included consideration of several key factors that are
14 not readily representative in quantitative terms,
15 whereas a comparison of only the quantifiable costs
16 and benefits of the proposed mods considered safety
17 enhancements would not justify new requirements
18 relating to severe accident containment venting
19 systems. When these costs and benefits are considered
20 with other qualitative factors, such as the importance
21 of containment systems within the NRC's defense-in-
22 depth philosophy, the staff concludes that a
23 reasonable argument can be made to require the
24 installation of filter vent systems for Mark I and
25 IIs, and the staff is recommending such action.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Our presentations and discussions today
2 will cover the staff's analysis and information used
3 in developing our draft recommendation. We look
4 forward to your questions and comments.

5 This slide summarizes the outline of the
6 paper, which you do have a copy of. It's a draft
7 internal NRC-only paper, but we are fully prepared to
8 discuss it. And our presentations today will
9 essentially run through the order of the paper.

10 The main paper provides an overview of our
11 analysis. It includes a discussion of the licensing
12 history of Mark I and II containments and how the
13 consideration of beyond design basis accidents and
14 severe accidents led to the consideration of venting.
15 The potential need for venting under beyond design
16 basis accident conditions and severe accidents for
17 Mark I and II containments goes back to the early
18 1980s. As a matter of fact, the NRC approved venting
19 back in 1982 for these designs.

20 So what you're talking about now is not
21 whether the designs will or won't vent. What we're
22 really talking about is whether the system structures
23 and components within the plant can withstand what
24 we've already approved. We've already approved
25 venting. The question is now are we going to require

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 system structures and components to live up to that?

2 MEMBER CORRADINI: Can I just clarify that
3 statement?

4 MR. MONNINGER: Yes.

5 MEMBER CORRADINI: I guess I think I heard
6 what you said, but I thought the equivalent in '82 was
7 within the context of not in severe accident space but
8 in before severe accident space. So the way you frame
9 it there sounds a bit mushier than that.

10 MR. MONNINGER: So if you go back, the BWR
11 Owners Group developed what's called EPGs, Emergency
12 Procedure Guidelines. And the industry then takes
13 those EPGs and develops the plant-specific EOPs. When
14 you go into the EPGs and the EOPs, they are symptom-
15 based issues: hydrogen generation, the containment
16 pressures, the analysis supporting the development of
17 the EPGs, and the staff's SER. It clearly discusses
18 beyond design basis accidents, and it discusses severe
19 accidents. It discusses the need to vent regardless
20 of the accident consequences. It discusses the need
21 of controlled venting, although very unlikely, is much
22 more preferred to some type of catastrophic
23 containment failure. So when you look at the NRC's
24 approval of it, it explicitly did include severe
25 accident conditions back in the 1980s.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER CORRADINI: Okay. Then maybe I'm
2 mis-remembering it. It was my impression, though,
3 that it followed the emergency operating procedures.
4 The venting would occur before core damage.

5 MR. MONNINGER: I don't think --

6 MEMBER CORRADINI: I'm just pretending
7 they did it right all the way through. That's what my
8 memory is, so is that just wrong? I have it wrong?

9 MR. MONNINGER: Well, they're symptom-
10 based procedures, so it doesn't say whether core
11 damage has occurred or not. If you're in a long-term
12 station blackout and you approach the primary
13 containment pressure limit, you may not have had core
14 damage yet. But if you're in a different accident
15 sequence, you could. There's also venting provisions
16 for hydrogen control, and the only way you're going to
17 get hydrogen is from the severe accident. So any of
18 your venting for hydrogen is from the severe accident,
19 and those procedures currently exist within there.

20 So the whole issue with procedures versus
21 equipment, the venting was approved, but it was
22 recognized that they would use existing plant
23 equipment or licensees could potentially upgrade
24 equipment. Some designs, some plants may have had
25 robust piping. Others may have had duct work, so that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 led to Generic Letter 89.16, which was to beef up the
2 piping or beef up the duct work to what's called
3 hardened piping.

4 MEMBER CORRADINI: Let me just proceed.
5 I don't want to hold you up, but I want to make sure
6 I'm clear. But the venting is a decay heat removal
7 procedure. It's not a --

8 MR. MONNINGER: The venting can be used in
9 all procedures.

10 MEMBER CORRADINI: But its only useful
11 purpose is to essentially maintain containment
12 integrity within a limit by essentially mass laws for
13 decay heat removal instead of heat law. That's all it
14 is.

15 MR. MONNINGER: You know, the venting is
16 there to prevent the catastrophic failure of the
17 containment. For issues like the TW sequence, the
18 laws of containment heat removal, they would utilize
19 those procedures and vent hopefully prior to core
20 damage. For other accident sequences where you
21 already had core damage, the venting was intended to
22 be through the wet well, and there's discussions
23 within, you know, within the basis for the EPGs and
24 within the staff's SER talking about the scrubbing
25 capability of, you know, of the suppression pool. But

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 it also recognizes that there is the potential that
2 they could vent through the dry well.

3 MEMBER CORRADINI: No, no, I was trying to
4 make a -- I don't disagree with anything you're
5 saying. I'm just saying that, I mean, from the
6 standpoint of what it does, it's removing energy by
7 removing mass instead of removing energy by removing
8 heat. So it's really a containment, it's only that
9 containment, some sort of catastrophic containment
10 failure by essentially controlling pressure in a
11 different manner. That's all I'm trying to say.

12 MR. MONNINGER: Yes. So we have four
13 potential options that we will discuss. We did use
14 our existing regulatory process. There were comments
15 made with regard to whether qualitative analysis or
16 qualitative arguments is consistent with our
17 regulatory analysis guidelines. And, yes, it is
18 consistent with our guidelines. If you look at
19 NUREG/BR-0058 or 56, 0058, it talks about that. If
20 you go back to the Commission's SRM from 1993 talking
21 about the backfit rule, the Commission explicitly
22 recognized the need to include qualitative arguments.
23 With regard to the federal government, the notion when
24 you do a regulatory analysis is you are to bring in
25 all the costs and all the benefits. And if those

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 benefits cannot be quantified, you are supposed to
2 talk to them in a qualitative manner. So it is within
3 our current regulatory analysis process.

4 Flipping the slide to slide nine, the
5 options considered. The first one is no change to the
6 current order which was issued this past March, and
7 it's a reliable hardened vent for prevention of core
8 damage. And what we mean there is we did not put any
9 additional design consideration within the
10 requirements of the order for severe accident
11 conditions. We also did not specify whether the
12 pathway for that venting order 12-50 shall be through
13 the wet well or dry well. So licensees could, if they
14 want, and we'll see the submittals this February, in
15 response to the current order, their reliable hardened
16 containment vent could be through the dry well, and
17 that would meet all the requirements of the current
18 order. There is nothing in there for severe accident
19 conditions with elevated temperatures, pressures,
20 radiological environments, hydrogen, etcetera, within
21 the existing order.

22 So that takes us to the second potential
23 option, to beef up or to add on to the existing order
24 out there to explicitly address severe accident
25 conditions. Should the valves be different? Should

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 there be different duty cycles associated with the
2 valves? Should there be shielding for operator action
3 where the current valves are located? If they were to
4 do it in accordance with 12-050, can they then do that
5 now for a severe-accident-capable vent? It would also
6 look at the routing through the reactor building.
7 Would there be shine associated with venting post core
8 damage?

9 So that's the notion of the severe-
10 accident-capable vent. We actually look at one, two,
11 and three as sort of building upon a foundation. So
12 you have the foundation 12-050 there. We would add
13 potentially additional requirements for the severe-
14 accident-capable vents, and that then takes us to the
15 filtered vents. From options one and two, you would
16 then potentially add a filter, external filter on that
17 pathway. So in the filtered vent, the design
18 requirements would include the requirements in 12-050.
19 They would also include the severe-accident-capable
20 vent requirements, and then they would add on a
21 filtered vent to the end.

22 The fourth one is the performance-based
23 approach there, which could be -- whereas, options two
24 or three would be, I don't want to say one size fits
25 all, but it would be, generally, a deterministic

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 requirement out there that all plants would meet, the
2 fourth potential option out there would be to
3 establish some type of performance requirement and
4 allow licensees to come in and propose and justify a
5 series of operator action, existing plant equipment,
6 and enhancements to plant equipment to meet the
7 performance-based approach. We would look at the
8 fourth option as being some type of potential
9 rulemaking, and it's also potentially in line with
10 what NEI's letter earlier this month talks about.

11 MEMBER STETKAR: Are you going to talk a
12 little bit more about option four in this
13 presentation? I thumbed through the slides, and I
14 didn't see any discussion of it. Are you?

15 MR. MONNINGER: We can. Yes --

16 MEMBER STETKAR: I would like to talk
17 about it at some time, either now or let you get
18 through all of your discussion of options two and
19 three. And it's your choice of when we're going to
20 discuss it.

21 MR. MONNINGER: Might as well do it now.
22 I don't see any other --

23 MEMBER STETKAR: Okay. Quite honestly, as
24 I read through the SECY paper, I couldn't follow your
25 rationale for just sort of dismissing it. As best as

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 I can tell, you dismissed it because you think it
2 would require rulemaking and you assert that NEI says
3 that it would take a long time to do. Is that
4 basically your conclusion of why you just basically
5 dismissed it?

6 MR. MONNINGER: I don't think we've
7 dismissed it. It isn't the recommendation. I don't
8 believe we have dismissed it. I think --

9 MEMBER STETKAR: I didn't find --

10 MR. MONNINGER: -- there are good reasons
11 --

12 MEMBER STETKAR: I didn't find a good
13 well-structured rationale for why it basically is not
14 considered.

15 MR. DENNIG: There are two considerations,
16 I believe. Number one, and this is not quite to the
17 point but it's been done before. It was done in
18 Sweden between 1982 and 1985. They did that. They
19 came out the other end. Utilities participated. They
20 looked at all the assets in terms of sprays and
21 floods, and all these things that are talked about in
22 the EPRI study, and they came out the other end and
23 they said you're going to need a filter, you're going
24 to need an external filter. That's all very good,
25 that's all to the good, but you're going to need an

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 external filter. And the reason was because of the
2 uncertainties in the analysis. The primary part was
3 because of the uncertainties and the mechanistic
4 analyses and the core damage progression analyses and
5 the release analyses that just could not be set aside,
6 and the filter had the advantage of not being
7 sensitive to sequence, being useful for all-over
8 pressure incidents. In the words of STUK in Finland,
9 being useful for all situations where there are energy
10 and fission products in the containment.

11 So because of the wide usage of it, and
12 they did look at all-over pressure incidents and they
13 did look at, specifically they were told in the law to
14 look at alternatives as they were going through this
15 program, they came out the other end you need a
16 filter, it needs to do this. So the uncertainties, I
17 think we've confirmed, looking through our own work,
18 that those uncertainties are there, that a filtered
19 vent has certainly been tested and proven to a degree
20 beyond what you can achieve with the analyses; and,
21 therefore, it's a superior choice from a technical
22 perspective.

23 MEMBER STETKAR: I still didn't hear a
24 rationale of why the performance-based approach
25 wouldn't work where I design a filtration system and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 I design an integrated accident management process on
2 a plant- and site-specific basis that is not, and John
3 used the term, one size fits all based on
4 deterministic thou shall have this and everybody shall
5 have this because we've determined deterministically
6 that this will work. We've learned, for example, for
7 risk assessment that this does not work equally well
8 for everybody. This, for example, after TMI with
9 specific reliability requirements on auxiliary
10 feedwater systems without the knowledge that auxiliary
11 feedwater systems are probably 10 or 20 different
12 designs of auxiliary feedwater systems with different
13 dependencies, different timing considerations, so that
14 this didn't work for everybody. It wasn't the most
15 effective solution to manage and reduce risk. And
16 that's part of the problem of the one size fits all
17 deterministic requirement that I don't see the
18 sensitivity to --

19 MR. DENNIG: The rationale goes a bit
20 farther into looking at the two components of risk, if
21 you will: the prevent core damage and mitigate the
22 core damage. The containment performs in a different
23 way than the prevent core damage aspect. You can
24 multiply two numbers together and have a small number
25 and a big number, and you get the same number. But

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 from the standpoint of design and the standpoint of
2 performance, the containment can be made passive. It
3 can be pretty stupid. It does not have to be very
4 smart. It addresses a lot of things that you haven't
5 thought about.

6 MEMBER STETKAR: And having done
7 integrated Level 3 risk assessments for several
8 plants, I've found that stupid passive designs are
9 stupid passive designs. Sometimes, stupid passive
10 designs don't work as well because you've not thought
11 of all of the scenarios, you've not thought of the
12 nuances of a particular plant, you've not thought of
13 the nuances of the particular surroundings around the
14 plant.

15 MR. DENNIG: One of the nuances of the
16 Mark I is that when there's no threat of fission
17 products in the containment under design basis, you're
18 in good shape, so you don't need the containment,
19 right?

20 MEMBER STETKAR: I'll give you that.

21 MR. DENNIG: So when there's a threat of
22 fission products in the containment, you open it.

23 MR. MONNINGER: Yes. And I think that is
24 where the staff looks sort of at the issue with the
25 Mark I and II containments. If you look at the entire

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 design, they have pretty robust injection systems, you
2 know, primary systems, depressurization systems.
3 There looks to be weaknesses in the containment
4 design. And so the question comes in if you develop
5 performance-based approaches and those performance-
6 based approaches are so heavily tied back to the
7 containment and uncertainty in the containment's
8 response, and the staff thought about, you know, where
9 are we going to go with this issue on testing, testing
10 for sprays, testing for decontamination factors for
11 the sprays, you know, flow rates, coverage, etcetera,
12 you know, the suppression pool, the suppression pool
13 temperature. And given all the various variables out
14 there, the need for the plant-specific analysis, the
15 potential need for significant research development
16 and testing, we did not see the performance-based
17 approach as being a short-term, you know, solution.
18 We saw this as being an extended very comprehensive
19 resource-intensive effort for quite a while.

20 MEMBER ARMIJO: But wouldn't you have the
21 same requirements for a filter, the same testing
22 requirements, the same kind of analysis, you know, all
23 that you would put on the current systems? Wouldn't
24 you put those on the filters and see if they met the
25 goals?

1 MR. MONNINGER: And we've had meetings
2 with at least three vendors out there, and we haven't
3 seen the actual testing, you know, reports, etcetera.
4 But there's been significant testing that has occurred
5 for the various designs, and they've been developed
6 over the past 20 or 25 years or so. And we've also
7 put a level of respect or trust in the reviews and
8 approvals that have been done of these filtering
9 systems around the world versus we've asked the
10 industry for information on testing for containment
11 sprays and what would have to be done to demonstrate
12 that. And certain things, the temperature of the
13 suppression pool, the decontamination factor is a
14 direct function of that. Are we going to be able to
15 reliably predict the accident sequence that we're in?
16 The decontamination factors associated with that
17 existing plant are dependent upon that particular
18 accident sequence. We view a filtered vent as being,
19 to a large extent, independent upon the coupled
20 reactor containment response during a severe accident,
21 so that's -- I'm not sure if that scratches the itch.

22 MEMBER ARMIJO: No, it doesn't. It just
23 seems that you put a lot of faith in these filters and
24 these factory tests or laboratory tests and it's never
25 been used in service and never been needed. You put

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 a lot more requirements on the equipment and
2 strategies in the U.S. plants, you put more, you have
3 greater, let's say you lack confidence in those
4 systems, but you seem to have a lot of confidence in
5 the filters. And I just don't see where you get that
6 confidence, other than the vendors say it works and
7 other people have licensed them.

8 MR. DENNIG: Well, certainly, the first
9 thing that we would have to do is write those
10 specifications and then follow up to look at the
11 testing. What we're saying is that outside the United
12 States there is a very large database of design
13 experience with filters. We stopped looking at
14 filters in 1982 and, essentially, not followed that
15 whole technology. So we could do it all over again.
16 We could do all the testing and design over again, but
17 it seems like we could benefit from what others have
18 done and review that to the extent that it needs to be
19 reviewed and adopt it to the extent it makes sense.

20 CHAIR SCHULTZ: The filtration systems
21 that were installed a few decades ago on European
22 plants, have they been upgraded to this new filter
23 technology that has been described for you?

24 MR. DENNIG: The MSSV, which is the filter
25 that was installed on the Swedish plants between 1986

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 and 1988 -- yes?

2 MEMBER STETKAR: Oh, the new one?

3 MEMBER SHACK: The Barseback one.

4 MEMBER STETKAR: The Barseback one is
5 gone.

6 MR. DENNIG: Yes, Barseback was a big
7 thing or rocks, and it was never duplicated. But
8 during the program that was performed by the Swedish
9 authority and their utilities from 1982 to 1985, they
10 designed and tested scrubber technology, borrowing
11 from coal-fired pollution scrubbing techniques, and
12 that was the design that got installed between '86 and
13 '88 on all the Swedish plants. So that's early or mid
14 80s technology. They haven't upgraded that system on
15 those plants.

16 Follow-on filter design have basically
17 shrunk down the size of the equipment and still using
18 a scrubber technology, a Venturi scrubber technology,
19 and there are some dry filters that we've heard about.
20 But they have built on that. Basically, the size has
21 gotten smaller. The testing has gone on through that
22 development. The vendors assert that they can achieve
23 very, very high DFs, which, essentially, aren't really
24 necessary. In fact, they're not necessary. The
25 Swedish authority determined that above 2,000 to 3,000

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 DF it was neither here nor there, so it really didn't
2 matter. And the MSSV was designed and tested at
3 1,000. And procuring what is on the market today, we
4 can't really, you can't get less than 1,000. You can
5 get less capacity. You can get something that will
6 take less decay heat. You can get something that will
7 assume a certain level of processes in the containment
8 to remove heat and scrub, but it would be designed
9 basically from scratch.

10 CHAIR SCHULTZ: Okay, thank you.

11 MR. MONNINGER: So the next slide. You
12 know, in looking through the combination of our
13 quantitative and qualitative analysis, we believe that
14 the best potential recommendation to the Commission is
15 to require the installation of a filtered vent, and
16 that's option three. So we wanted to bring that up
17 front within our presentation, so, you know, as
18 opposed to wait to the end, so your questioning, so
19 you know exactly where we're coming from.

20 MEMBER ARMIJO: And just for the record,
21 I asked it previously but I'll ask it again, option
22 three really includes option two?

23 MR. MONNINGER: Yes.

24 MEMBER ARMIJO: So it's a combination of
25 two --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. MONNINGER: It's actually option one,
2 two, and three.

3 MEMBER ARMIJO: Option one is already
4 there.

5 MR. MONNINGER: Yes. We are -- the one
6 slide says there's Enclosure 7 which is draft orders,
7 which you don't have a copy of and we don't have a
8 copy of it either because we're still working on it,
9 but it starts with the language from the existing
10 order. And if you were to look at Enclosure 7A for
11 option two, it would take the current language plus
12 add some additional design requirements. And then if
13 you were to look at option B, which would be the
14 filtered vent order, it would then start with 7A,
15 which is 12-050 plus severe-accident-capable vent, and
16 add additional design parameters for the filtered
17 vent. So it's a series maybe. It's a combination.

18 And then our thought with regard to the
19 option four, the performance-based approach, if that
20 was the preferred option, there may be logic in there
21 that says, all right, performance-based option four
22 rulemaking down the road, but in the short-term it
23 looks like that there's general agreement that the
24 current venting system should be designed for severe
25 accident conditions. The Commission may wish to, if

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 they were interested in option four, to also require
2 the near term upgrading of the vent path to make it
3 severe accident capable.

4 MEMBER STETKAR: So the presumption would
5 be option four would involve two?

6 MR. MONNINGER: Yes.

7 MEMBER STETKAR: Essentially, there's no
8 way of getting around two.

9 MEMBER SHACK: Two would be done in short
10 order compared to four overall.

11 MR. MONNINGER: The staff would propose
12 that.

13 MEMBER SHACK: But you always base the
14 comparison of option three with option one. Why not
15 compare it to option two?

16 MR. DENNIG: One reason is that, while we
17 think of it in terms of a progression of functionality
18 from a TW sequence event to a more fission product
19 severe accident vent to a filtered severe accident
20 vent, it's not entirely clear that you would start
21 with what you have now as a Mark I and then add to
22 that to make it severe accident capable and then add
23 a filter to that that you would necessarily use what's
24 in place in actually implementing the different
25 options. There are Mark I plants that have their

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 current 89-16 hardened vents intertwined with their
2 standby gas treatment systems. They have circuitous
3 paths. They have valves sitting on top of the torus
4 in the torus room. So it's not clear -- you know, you
5 can think of it in terms of I've got that now and in
6 a little while I'll get that and now in a little while
7 I'll get that. I think you're going to have to stand
8 back and look at where you eventually want to wind up,
9 and a straight piece of pipe from one place to another
10 might make a whole lot more sense than trying to work
11 with what you've got there.

12 MR. BETTLE: Especially with the filter
13 being a more sizeable component in the system and, in
14 large part, dictate where pipes have to be routed to
15 get to it.

16 MEMBER SHACK: No, I just meant in terms
17 of the cost benefit analysis, where it seems like you
18 get a lot of benefit from option two at a relatively
19 low cost compared to option three.

20 MR. MONNINGER: And then there's our
21 quantitative analysis and our qualitative analysis.
22 So when you were, if you were to go from two to three
23 in our quantitative analysis, we assumed a
24 decontamination factor of 10 for the filters. MELCOR
25 calculates certain decontamination factors, etcetera,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the same as the MAP code. But, you know, and if one
2 was to believe those plant conditions at the time, the
3 potential additional benefits from the filter may not
4 be that great. So, you know, if you were to use the
5 quantitative analysis, there probably wouldn't be that
6 much of a difference, and I think that's where the
7 qualitative arguments come in. The qualitative
8 arguments are what sort of takes you to option three,
9 this notion of another tool in your toolbox, a notion
10 of a potential design fix that is independent of your
11 primary system and your containment intertwine. So
12 it's probably predominantly the qualitative arguments
13 that we currently have that takes you from option two
14 to three versus the actual quantitative analysis.

15 You know, the whole issue with dry well
16 venting, when we did all the analysis we didn't do an
17 integrated analysis based on time of, you know, the
18 first 70 percent of the venting is through the wet
19 well, but by that time they had flooded up in the
20 remainder 30 percent. So this issue of dry well
21 venting came up, you know, rather late on us. So we
22 tried to consider that in a qualitative manner. We're
23 not saying it's a definitive. But one of the issues
24 with the containment design is its small size, and a
25 lot of these issues just come back to its sheer small

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 size and, you know, the non-condensable gasses impact
2 it and also the flooding impacts it on that. If you
3 look at units two and three at Fukushima versus unit
4 one, you know, all the measures in the first couple of
5 days to add water, thinking you're on a success path,
6 you know, whether it's RCIC, HPSI, and a recirc, or if
7 it's the fire trucks. You know, all those fire trucks
8 are adding mass, and that mass eventually gets to your
9 suppression pool and eventually fills up your
10 containment. And it's not a ton of time between when
11 you start injecting, and it's based on the flow rate,
12 of course, when you would have to move from wet well
13 venting to dry well venting.

14 So, you know, we did not, in our
15 regulatory analysis, throw in the dry well venting
16 because we'd have to assign some type of numbers there
17 and some type of probability to that, and we didn't
18 want to get caught up in arguments with regard to the
19 staff defaulting to very low probability events. So
20 we intentionally did not put that in our analysis, but
21 we do think there is the potential there.

22 I mean, it's not only that, but there are
23 differences between MAP and MELCOR, the issues with
24 whether the entire core comes out of your vessel or
25 whether some of the core is held up and late

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 volatilization of the fission products and the
2 releases. Once you move from the wet well to the dry
3 well, you know, the EPRI analysis, it assumes it's
4 essentially a clean release coming out there. But,
5 you know, later on in the accident you can have heat-
6 up of structures within the reactor within the
7 containment.

8 There's also issues with ex-vessel
9 interactions. When the core is on the floor, is it
10 coolable all at once and there's no core concrete
11 interaction and there's no additional hydrogen
12 generation? I mean, there's some fundamental
13 differences between what NRC's codes will predict and
14 the industry code will predict.

15 MEMBER REMPE: John, if you don't have
16 some sort of performance-based analysis done, how will
17 you define the requirements for the filtered vents in
18 option three for testing, like Sam was mentioning? I
19 mean, you've got to have some sort of assessment. I
20 mean, it's more than just the decontamination factor
21 but how well will it perform for down to what range of
22 events. And how will you come up with that?

23 MR. MONNINGER: Right. Well, a lot of it,
24 you know, and we're still putting together the draft
25 order now, but we believe it would have to specify the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 fission products, the releases coming out, the gasses,
2 the aerosols to be scrubbed out, etcetera, and a
3 decontamination factor --

4 MEMBER REMPE: Seismic capability --

5 MR. MONNINGER: We have to include, you
6 know, consideration for seismic, for EQ, etcetera.
7 That's not to say it would be seismic category 1, but
8 they are things that we explicitly need to address.
9 You know, does it have to be safety-related or not?
10 Does it have to be seismic category 1 or not? Does it
11 have to meet Appendix B?

12 MEMBER STETKAR: Remember the seismic
13 events that get us into trouble are way beyond seismic
14 category 1, so be careful there. If you're not going
15 to design it for really big seismic events, you might
16 as well make it non-seismic because it's going to
17 fail.

18 MEMBER SKILLMAN: Those last several items
19 that you identified are the ones that we wrestled with
20 in the months following TMI, too. Is it safety grade?
21 Is it Appendix B? Which reg guides do we use? Is it
22 1.26, 1.29, neither? Do we use the 1.114, waste or
23 whatever it was? And those are showstopper questions
24 when it comes to the costs of this thing because it
25 isn't too hard for me to get the ASME Section III

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 class 2 seismic 1, just like everything else that's
2 supposed to be ECCS. We never asked that question
3 when the vendors were up here, but if you go down that
4 path I've got to think that it changes the costs to
5 the point where one might say it simply can't be
6 justified, it is just exorbitantly expensive. So I
7 think you should say some more about that right now.

8 MR. MONNINGER: Yes, and we believe we
9 have to go through -- and the difficulty is we haven't
10 finalized on those issues. But with regard to safety-
11 related, we've asked what they have done in other
12 countries, and it's not a safety-related system
13 structure or component. It's seismic category 1, but
14 it is not a safety-related system structure.

15 MEMBER STETKAR: They're robust in the
16 other countries seismically.

17 MR. MONNINGER: And in terms of cost,
18 we've asked for cost numbers, and the best cost
19 numbers we've gotten has been from the foreign
20 countries, and that's the value of 15 million. We
21 heard informally from industry, well, the price
22 doubles if the filter has to be put into a seismic
23 category 1 building, so that's the 30 million. At the
24 last ACRS meeting, Dr. Corradini said, well, he's
25 heard it three times the cost, and so that's why we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 put the 15 to the 45, but we don't have reliable cost
2 estimates at this time besides those that have been
3 provided by other countries who have installed them,
4 and that's the \$15 million value.

5 MEMBER STETKAR: I think, in some cases,
6 the other countries were fortunate. Because of other
7 requirements, they had robust structures adjacent to
8 their containments for bunkered, you know, independent
9 cooling systems that had some extra space in it. So
10 they were fortunate. I've seen several installed in
11 those locations where we don't have that here.

12 MR. MONNINGER: The next slide. So the
13 basis for the proposed recommendation option three, we
14 believe it's a cost-justified substantial safety
15 enhancement based on both our quantitative analysis
16 and our qualitative analysis. In particular, the
17 qualitative analysis we believe it substantially
18 enhances defense-in-depth for the Mark Is and the Mark
19 IIs. It addresses containment vulnerability, you
20 know, in particular the high conditional containment
21 failure probability. And it also provides an
22 independent means to address severe accident
23 uncertainty. And the last bullet there, it provides
24 a system that is independent of the coupled reactor
25 and containment response.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER SKILLMAN: John, just for the sake
2 of discussion here, supposing it cost \$100 million,
3 supposing it cost as much as changing out steam
4 generators, a big project, a lot of radiological
5 issues, a lot of plumbing issues, a lot of containment
6 boundary violation issues, a lot of work to heal all
7 the undoing that you've done, if it were to cost that
8 much, how does that affect what you're presenting on
9 this slide?

10 MR. MONNINGER: So on that, we'll get
11 there in three slides.

12 MEMBER SKILLMAN: Okay.

13 MR. MONNINGER: How about that?

14 MEMBER SKILLMAN: Fine, thank you.

15 MR. MONNINGER: Hopefully, it will scratch
16 the itch in three slides.

17 MEMBER SKILLMAN: Okay.

18 MR. MONNINGER: So we're at Enclosure 1,
19 the evaluation of the options. The Commission paper
20 is actually written at a very high level, and it
21 pushes a lot of the details in particular to Enclosure
22 1. And it's a summary of our considerations and the
23 decision-making process. It includes the results of
24 the quantitative analysis, the MELCOR, the MACCS
25 results, the PRA, the foreign experience, what we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 believe with regard to the various decontamination
2 factors out there. And it also brings in the
3 qualitative arguments.

4 The second bullet there, consideration of
5 adequate protection. The NRC and the NRC staff, when
6 we go about considering additional requirements, the
7 first thing we should do is ask is this needed for
8 adequate protection? We looked at the NRC's
9 historical use of the adequate protection standard,
10 and we looked at what we're trying to do to address
11 residual risk, and the staff came down to a view that
12 it's, the NRC has historically, to address these types
13 of issues, pursued the substantial safety enhancement
14 type of improvement, as opposed to trying to invoke
15 adequate protection. Adequate protection has
16 generally been reserved for issues associated with
17 design basis accident, some beyond design basis
18 accidents. Within the severe accident world, we
19 generally have not pursued residual risk issues
20 invoking the adequate protection standard, but we did
21 look at that.

22 The Commission, of course, is the ultimate
23 decider. They could look at it and they could make a
24 decision that we view this as an adequate protection,
25 or they could look at it as saying we believe nothing

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 at all is needed or, in other words, option one.

2 MEMBER ARMIJO: But just to be clear, the
3 staff is not saying it is an adequate protection
4 issue?

5 MR. MONNINGER: That's correct. That's
6 correct. Or our recommendation would be based on a
7 substantial safety enhancement, which would include
8 both qualitative and quantitative arguments.

9 So the next slide summarizes the
10 quantitative analysis. So on the second column there,
11 the severe accident capable vent, that's the option
12 two. And the third column is the filtered vent. The
13 total cost of the modification, including the industry
14 cost and the NRC cost. The NRC cost associated with
15 licensing inspection reviews. The industry cost
16 associated with the initial installation, plus routine
17 maintenance and operations costs.

18 We looked at a baseline core damage
19 frequency of two times ten to the minus fifth, and we
20 propagated that through, and you have your benefits
21 and your net value. As a sensitivity study, we
22 increased the core damage frequency by a factor of 10.
23 So you can see that the potential cost benefit
24 analysis is sensitive to your CDF. And there is a
25 footnote there, and it relates to Jeff's discussion

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 earlier with regard to the Mark II containment
2 designs.

3 So option two, the severe-accident-capable
4 vent, with this drain line under the pedestal, that
5 represents the potential for suppression pool bypass.
6 If you were to proceed with the severe-accident-
7 capable vent, that bypass pathway invalidates the
8 benefits of a severe-accident-capable vent. So the
9 staff's thoughts are that, for the Mark II
10 containments, for option two to be an option, we would
11 also propose additional requirements to address that
12 issue.

13 So in there we say that the cost for the
14 Mark IIs are expected to be higher. You know, we
15 believe that there are potential solutions out there.
16 If you look at the ABWR, for example, they have sumps
17 within the lower dry well, and there's two different
18 sumps. There's a floor drain sump and an equipment
19 sump, and they essentially build houses out of
20 refractory bricks to protect those sumps. So we
21 believe something can potentially be done for the Mark
22 IIs to address that issue of suppression pool bypass.

23 CHAIR SCHULTZ: So here, John, I
24 understand that here's the quantitative part of the
25 discussion, and we're not relying heavily upon it.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 But we do present it, and in the summary of
2 justification we say on the quantitative and
3 qualitative features we agree that this is a way to
4 move forward. And I wanted to go to Bill's point with
5 this slide up here, and that is with regard to the
6 evaluations as shown, if we look at the filtered vent,
7 we see that, we do see that for the case where we go
8 to a very high frequency, two times and four per year,
9 that we show a barely demonstrated benefit to cost
10 balance. But that does presume that we have done the
11 severe-accident-capable vent as well as the filtered
12 vent.

13 MEMBER STETKAR: The way that it's done in
14 the PRA is the vent works under severe accident
15 conditions, and it's just whether it's filtered or
16 not. So the PRA doesn't really, the risk assessment
17 input to this doesn't really compare three to one
18 differently. It's two plus three.

19 MR. MONNINGER: The cost of the severe-
20 accident-capable vent are within the cost number for
21 the filtered vent.

22 CHAIR SCHULTZ: But I'm looking at the
23 benefits. The benefits associated with filtered vent
24 incorporate the benefits of the severe-accident-
25 capable vent; and, therefore, if you were to look at

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 this sequentially, you would say that, yes, the cost
2 benefit evaluation for the severe-accident-capable
3 ventilation system is shown here. But if you said I'm
4 going to do, I'm going to do option two, then you
5 would get these benefits. If you say you're going to
6 do option two, and then you say and in addition I'm
7 going to implement the filter, then the benefit you
8 get from the filter is the difference between what you
9 show here and the result with the severe-accident-
10 capable vent.

11 So really the bottom line for option
12 three, in comparison to option two, is that delta of
13 the benefit. In other words, half the benefit is
14 coming from the severe-accident-capable vent, a little
15 more than half of it. So your looking at what am I
16 gaining by doing the filter biases the presentation a
17 bit.

18 MR. MONNINGER: And part of that is in the
19 way that we modeled it. Within our MELCOR and MACCS
20 model, we, for the good or for the bad, we only
21 assigned a decontamination factor of 10 of the
22 residual release coming out of the wet well. So the
23 MELCOR analysis, similar to the MAP analysis,
24 provides, you know, a fair amount of fission product
25 scrubbing for that particular accident sequence. So

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 our benefit there of the filter is only that
2 additional decontamination factor of 10.

3 CHAIR SCHULTZ: So that could have been
4 assigned a higher value.

5 MR. MONNINGER: But then there's things if
6 you were to assume that all the risk goes away, you
7 could do a simplification where you would just take
8 mod zero and, you know, you could take all the risk
9 away, and the number wouldn't be significantly
10 greater.

11 MEMBER STETKAR: I think somewhere in the
12 report it says they looked at that and it still didn't
13 work out.

14 MR. MONNINGER: Yes, because that's the
15 way they do a lot of times. They assume it's perfect.
16 But built in that perfect system where we're assuming
17 the risk goes to zero is a high level reliance upon
18 what you believe the suppression pool temperatures
19 are, the pathways, the depositions, the plate-outs,
20 you know, within the containment.

21 CHAIR SCHULTZ: I just wanted to be
22 certain that, as it's presented in the document to the
23 Commissioners, that it's clear that what is shown here
24 is the benefit of both the severe-accident-capable
25 vent and the filtration added to that. If I'm going

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 to look at passenger safety, I can buy seatbelts or I
2 can buy airbags. And if I buy both of them, I might
3 be able to justify a certain amount. But if I'm
4 looking at both of them together and then I look at
5 them individually, the seatbelts might cost very
6 little and give me a huge benefit and I may not want
7 to spend the extra money for the airbag.

8 MR. MONNINGER: And that also goes into
9 where our qualitative arguments and taking you from
10 option two to option three. So the next slide. So
11 the next slide, the things that are plotted aren't on
12 there precise. It's meant more as a schematic to say,
13 mentally, what would it take, based on my quantitative
14 results, what would it take to walk me across the line
15 to be cost beneficial? You know, and these are the
16 two lines. This is the 15 million line and the 45
17 million line, and you could draw a \$100 million line.
18 And based upon the staff's current, you know,
19 quantitative analysis, you know, the CDF and CDF, what
20 does it take to move from this point to above here or
21 above this line or above the \$100 million line? What
22 is the strength, what is the value or the reliance
23 you're putting in those qualitative arguments to
24 mentally walk you across that line?

25 MEMBER STETKAR: And on this, your

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 previous slide and most of the comparisons that are
2 made looks at, horizontally isn't shown on here, two
3 times ten to the minus five up to two times ten to the
4 minus four CDF. But if I take that two times ten to
5 the minus five and move up, it says if the economic
6 consequences exceed, pick a number, somewhere in the
7 range of \$30 to \$40 billion, even at the lower core
8 damage frequency, it would show cost-beneficial. Is
9 that the right way for me to interpret --

10 MR. MONNINGER: Yes.

11 MEMBER STETKAR: -- what I'm seeing?

12 Okay. Thanks.

13 MR. MONNINGER: And within the pervious
14 slide and this one, some of the benefits for the
15 filtered vent would come in if you were to ever
16 potentially go to the dry well venting, and we did not
17 try to quantify that at all or at least include it in
18 our quantification.

19 So that takes us to our next slide, slide
20 15, our potential or our proposed qualitative
21 arguments.

22 CHAIR SCHULTZ: John, before you go
23 forward, I think this is a good time for a break, and
24 I think it's a good place in the presentation. It
25 will give us some time to reflect on the quantitative

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 evaluations which we've heard and prepare ourselves
2 for the qualitative discussion. So I would like to
3 take a break now, and I would like to return at 3:25.

4 (Whereupon, the foregoing matter went off
5 the record at 3:07 p.m. and went back on
6 the record at 3:26 p.m.)

7 CHAIR SCHULTZ: I'd like to call the
8 meeting back to order. And, John, if we can pick up
9 where we left off, moving into -- it looks like you've
10 got a different slide up where you'd like to start,
11 perhaps to introduce the connection between the
12 quantitative and qualitative analyses.

13 MR. MONNINGER: We did do a little bit of
14 brief caucusing, and there were two items I did want
15 to mention prior to the qualitative arguments. You
16 know, up front, we talked about the Steering
17 Committee, and just to make sure the ACRS members are
18 clear, the NRC Steering Committee, the Japan Lessons
19 Learned Steering Committee, fully supports option
20 three, recommendation three, the recommendation for
21 the filtered vents. They just have not weighed in on
22 the specifics of the order yet. So, you know, we have
23 met several times with them to cover recommendation
24 three, and the Steering Committee fully supports
25 recommendation three.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 The second topic, and, unfortunately,
2 Marty is not here, but with regard to this, we also
3 did an uncertainty analysis, and this was more the
4 point estimate. But when one looks at the 95th, it
5 also approaches, and that's within it. Your 5th and
6 95th percentile also --

7 MEMBER STETKAR: I was going to ask --
8 well, I'll ask it now. I didn't see that in 5C, the
9 vertical differentiation. I saw the horizontal.

10 MR. MONNINGER: We did do the uncertainty
11 analysis --

12 MEMBER STETKAR: It said that you did it,
13 but I didn't actually see any results from when you
14 did it because I could at least run out distributions
15 and see where you were on the horizontal axis in a
16 sense.

17 MR. MONNINGER: Well, how about we'll get
18 that for the full committee and we'll bring it in and
19 we'll show them --

20 MEMBER STETKAR: That would help because
21 I was looking for it and I didn't find it anywhere.

22 MR. FRETZ: Let's put that on the list to
23 discuss tomorrow. That would be very beneficial.

24 MR. MONNINGER: So then rolling into the
25 qualitative arguments, we identified 10, 11, or 12 or

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 so. There's others that could potentially be
2 considered, and these are the ones that we put more
3 weight on and they're discussed in the back end of
4 Enclosure 1. Many of these arguments, in the staff's
5 view, support the notion of additional requirements,
6 whether that's option two, option three, or option
7 four. However, some of these arguments would be
8 against, some of these qualitative arguments argue
9 against imposing additional requirements, and we
10 wanted to include them for the Commission's
11 consideration. And we'll go through those in the next
12 several slides.

13 The first one, and this is the
14 preponderance of the staff's argument, is the notion
15 of defense-in-depth, in particular for the Mark I and
16 Mark II containment designs. We do view these
17 containments as being outliers than the rest of the
18 fleet within the U.S., and the containment has always
19 been recognized as an essential element of the NRC's
20 defense-in-depth policy. They do have a very high
21 conditional containment failure probability. And if
22 you look at the accidents that did occur in Japan,
23 that's what our analysis over the years would have
24 predicted also.

25 The filtering, if one was to go with

1 option three, it compensates for the loss of the
2 containment barrier. We believe that significant
3 fission products would be withheld within the
4 filtering to essentially reach a conclusion that
5 defense-in-depth for the containment has been
6 underscored. It also improves confidence in
7 utilization of that so that operators could address
8 other challenges.

9 It's been discussed the notion of operator
10 actions for filters or for venting systems versus for
11 cavity flooding, and it's true, you know, that
12 operator performance is required for both. Within the
13 filter path, you could have a ruptured disk to make it
14 more passive. But if you look at the PRA that the
15 staff did include within Enclosure 5C, there's a
16 change in the conditional containment failure
17 probability. And, you know, whether that number is
18 currently 0.8, 0.9, 0.95, wherever it is, the staff
19 did an assessment with a manual venting system or with
20 a passive venting system. And even though the
21 reliability that the staff assigns to the passive
22 venting system is significantly higher than the manual
23 venting system, you still see CCFP out there of around
24 0.3 or 0.4. And what's that then is dominated by is
25 the notion of operator performance for cavity

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 flooding. We assigned a 0.3 to the failure for cavity
2 flooding in there. So if, you know, you can, as
3 industry pointed out, you need both. You need a
4 cavity flooding system and a vent.

5 MEMBER STETKAR: I wish you hadn't brought
6 the numbers into it. I was going to wait and let you
7 get through this, but, sorry, you walked into it and
8 I might as well say it now. Yes, indeed, you did.
9 Cavity flooding through the portable FLEX equipment is
10 evaluated only during scenarios when the vent is
11 available because, obviously, you need both. It's
12 difficult for me, as kind of an ex-operator and people
13 who have looked at emergency procedures, to say that
14 if, if I'm an operator and I'm following my severe
15 accident management guidelines and I've opened that
16 vent manually, I pretty much know what I'm trying to
17 do. Now, it's hard for me to understand now why I'm
18 very likely to fail to get the pump going. And in the
19 little model, they're treated as conditionally
20 independent numbers, 0.3, from some SPAR HRA that
21 doesn't account for timing or dependencies or
22 anything. So this notion that, you know, operator
23 actions do not get flooding are an important
24 contributor I think it is an artifice of the way that
25 you did the analysis, quite honestly. If they're

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 successful opening the vent, they might be limited by
2 the hardware of the pump, but that's a lot better than
3 0.3 failure. And that's where you get into the kind
4 of scenario-specific performance, if you want to call
5 it that, analysis of what's going on in these things.

6 MR. MONNINGER: And then using that
7 number, that actually diminishes the potential value
8 of the containment vent. If you were to use a higher
9 value for human performance, higher likelihood of
10 success, it would have made the analysis even more
11 positive. It probably would have --

12 MEMBER STETKAR: It would have made --
13 you're absolutely right there. I mean, when we get
14 into the PRA, I'm going to discuss a couple of things
15 that are more appropriate to discuss in that content.
16 You're absolutely right. It would make the vent look
17 better, but it would have made the passive vent not
18 incrementally as beneficial as might be implied from
19 this analysis. This analysis is biased in a sense to
20 say that a passively-activated vent is the way you
21 want to go, and it's not at all clear to me that
22 that's the appropriate conclusion. That's not in the
23 SECY paper, but it's hovering right below the surface
24 in terms of when you start thinking about design
25 options. So there's two parts of the PRA in terms of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 what benefit do you get, vent versus no vent, filter
2 versus no filter. And then it's this passive versus
3 active or manual.

4 MR. BETTLE: But it wouldn't be an
5 either/or, you know. You can have a passive, and you
6 can also have an active.

7 MR. MONNINGER: Right. The staff has
8 proposed, essentially, parallel paths of passive and
9 then --

10 MEMBER STETKAR: I'll let you get back to
11 the --

12 MR. MONNINGER: Okay. So the next slide,
13 uncertainties. There's, of course, the known
14 uncertainties out there, and then there's the unknown
15 unknowns out there. We believe that the filter, in
16 this case, would go a long way to addressing
17 uncertainties, uncertainties with the event frequency,
18 uncertainties associated with the consequence
19 calculations, uncertainties associated with core melt
20 progression, and uncertainties associated with the
21 economic consequences modeling out there. We did do
22 some studies, we did do some analysis out there trying
23 to quantify some of these uncertainties, but they are
24 not exhaustive.

25 The next slide, international practices.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 A very high number or a very large percentage of the
2 nuclear countries around the world have already
3 installed or have committed to installing filtered
4 vents. You know, from the extraordinary meeting, the
5 members agreed to the statement that member countries
6 should look to the need for filtration strategies to
7 improve the containment performance.

8 If you go back to the Commission's SRM in
9 1993, they talked about one of the potential
10 qualitative arguments that could be used is
11 consistency with international standards. Now,
12 filtered vents are not an international standard.
13 There isn't an IAEA tech document or standard out
14 there that requires filtered vents. But,
15 nevertheless, their consistency with what the rest of
16 the world is doing is one consideration in a
17 qualitative argument.

18 MEMBER ARMIJO: Is that a very strong
19 consideration for the staff?

20 MR. MONNINGER: No, our strongest one is
21 defense-in-depth. You know, and, actually, our second
22 and third one is also defense-in-depth.

23 MEMBER ARMIJO: Okay. Well, I think
24 that's very important because I think NRC is a U.S.
25 regulatory body. It's not, it doesn't have to go

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 along.

2 MR. MONNINGER: Without a doubt, that is
3 true, yes.

4 MEMBER STETKAR: John, and I don't know
5 the answer to this, do you know what the Russians and
6 the Chinese, what their position is regarding this?
7 When you say most European countries --

8 MR. DENNIG: I think we sort of know but
9 not very definitively. We have heard about China from
10 a number of different sources about plants, to
11 filtered and non-filtered plants. The last thing that
12 we heard was that the decision was made to not build
13 plants inland and just build plants on the coast.
14 That was one way of handling this. Now, I don't, you
15 know -- we had heard that they were fitting filters on
16 new built plants, and we have seen pictures of those
17 filters. They will fit inside a building, actually.
18 They split it into two pieces. But the extent to
19 which they're doing it and what their official
20 position is --

21 MEMBER STETKAR: I was just curious, you
22 know, in the context, kind of the high level --

23 MR. DENNIG: Yes, we don't know. There
24 are VVERs that have filtered vents on them. Whether
25 they're Russia, Ukraine. I think Ukraine still hasn't

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 made a decision.

2 MR. MONNINGER: The next slide, slide 19,
3 severe accident decision-making. The three options,
4 options two, three, and four, we believe all of them
5 provide enhanced potential for severe accident
6 management. The notion of using the existing reliable
7 hardened vent and putting a high-level of confidence
8 by the operators in using it and post-core damage, we
9 think there are issues associated with that. And as
10 a result, if you were to upgrade that system to, as a
11 minimum, a severe-accident-capable vent would allow
12 operators to focus on other recovery actions at the
13 same time. We believe the filtered vent system is the
14 potential simplest solution out there.

15 With regard to the performance-based
16 approach, option four, it could be also, as Mr.
17 Stetkar mentioned, it could be integrated with other
18 efforts that are ongoing out there, though we do
19 believe or we would require, if a filter was required,
20 they would then have to incorporate that within their
21 emergency operating procedures, SAMGs, EDMGs,
22 etcetera.

23 Emergency planning. The NRC, as the third
24 tier of defense-in-depth, requires a robust emergency
25 planning system. And to a large extent, the filters

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 or the severe-accident-capable vents or the filtered
2 vents, you know, one of the reasons why the benefits
3 aren't necessarily as high is because the releases are
4 occurring after the evacuation has occurred. So
5 there's a residual population of 0.5 percent that we
6 assume within the analysis that, for one reason or
7 another, does not evacuate. A lot of the dose comes
8 from the time period from when the population returns
9 home.

10 So, anyway, we believe that there is merit
11 in looking at emergency planning and the benefits of
12 a filter for emergency planning. There could be
13 different protective action recommendations issued if
14 one knew you had a filter, if one knew you had an
15 engineered safety feature that you had a high-level of
16 assurance for scrubbing the fission products out of.
17 We believe it would facilitate emergency planning more
18 than a potential severe-accident-capable vent. We
19 believe there would be a higher level of assurance in
20 a potential release, a potential higher scrubbed
21 release coming from the filter than through the
22 unfiltered vent pathway.

23 CHAIR SCHULTZ: It's an interesting point
24 you raise, John. I mean, it appears obvious, but I
25 think it's a good feature to document appropriately.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So I'm glad it's included. Can you go back one slide
2 and just, looking at that second bullet, I was
3 interested in why, if you could go over it one more
4 time why you chose the phrase that filtered systems
5 are the simplest. The word simplest struck me, and I
6 couldn't figure why it was chosen.

7 MR. MONNINGER: If you were to look at,
8 potentially, option three versus option four, the
9 containment has historically been viewed as a passive
10 structure. You know, containment sprays are active.
11 Your containment building, your torus, your dry well,
12 your wet well, is essentially a passive structure.
13 You want it to isolate -- well, you know, a strategy
14 reliant upon cycling of valves, you're fundamentally
15 changing your containment from a passive structure to
16 an actively-managed system.

17 MEMBER STETKAR: John, you say it's
18 passive. It's passive for design basis accidents.
19 They've never been passive in that sense for beyond
20 design basis accidents.

21 MR. MONNINGER: Well, the notion has been
22 you open the vent pathway --

23 MEMBER STETKAR: Oh, okay.

24 MR. MONNINGER: -- but do you, you know,
25 do you open and close it, open and close it several

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 times an hour or multiple times within a 24-hour
2 period?

3 MEMBER STETKAR: I see what you --

4 MR. MONNINGER: You know, are you actively
5 monitoring containment pressures, suppression pool
6 level for flood-up, and then transitioning between wet
7 well venting to then dry well venting. It becomes
8 more of a, I don't want to call it an active system,
9 but it becomes more of an actively-managed system --

10 CHAIR SCHULTZ: I think that's a good way
11 to describe the difference that you're proposing here,
12 that one is relying upon active approaches by the
13 operations crew, facility management, versus filtered
14 system. In that regard, I understand the phrase
15 simple. Thank you.

16 MR. MONNINGER: So we mentioned emergency
17 planning, the potential to have different types of
18 protective action recommendations. You know, to a
19 large extent, you know, emergency planning, what are
20 the weather patterns, the wind blowing, the rain,
21 etcetera. You know, the timing of venting would not
22 be as dependent upon the success of those if one had
23 a filter.

24 Hydrogen. Maybe the word "clean" here
25 will get us the same place as "simple" in the other

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 slide. Improves operator confidence in a clean
2 release for hydrogen control. Both options two and
3 option three and most likely option four also would
4 address hydrogen. You know, you want the hydrogen to
5 be removed from the wet well and the dry well and
6 released into the environment to prevent any types of
7 threats.

8 You know, one consideration in here with
9 hydrogen is the notion of the containment seals. And,
10 you know, for the hydrogen to be released from the dry
11 well to the reactor building, there has to be hydrogen
12 there, but then there also has to be a forcing
13 function there.

14 And that also gets into the notion of
15 keeping your containment at elevated pressures and
16 cycling it. You know, the staff believes, to a large
17 extent, with the filters particularly, it could go a
18 long ways to addressing the hydrogen issue, the
19 hydrogen issue for the Mark Is and Mark IIs. If there
20 was a filter there, you know, you could potentially
21 reduce pressure to close to ambient pressure and have
22 a high level of confidence that all your radionuclides
23 have been significantly held up in the filter, as
24 opposed to the long-term, you know, holding up your
25 containment from 45 to 65 pounds or whatever, and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 having that driving function for the hydrogen and the
2 high temperature through your seals. So the staff,
3 you know, as documented within the Commission paper,
4 we discuss what we believe to be the benefits of an
5 appropriate system in addressing the hydrogen, the
6 Tier 3 hydrogen control issue. There's other
7 sequences out there, like containment bypass or IS-
8 LOCAs that we know within the paper we would have to
9 address to a large extent.

10 This is one of the potential cons, the
11 severe accident policy statement that the NRC issued
12 in the 1980s in response to the TMI accident. The NRC
13 had an integration plan for a closure of severe
14 accidents, which include the IPE, the IPEEE, SAMGs,
15 improved plant operations, a severe accident research
16 program, etcetera. And it talked about the generic
17 need, there was no longer the view back then of the
18 need for additional generic severe accident design
19 features placed upon operating plants. You can argue
20 that what we would potentially be doing today with
21 options two, three, or four is counter to the severe
22 accident policy statement.

23 MEMBER ARMIJO: That's independent of the
24 options.

25 MR. MONNINGER: That's independent, right.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 But you could also argue what we did with FLEX and all
2 the other stuff is counter to this, also. But we
3 figured on --

4 MEMBER ARMIJO: Yes, that's what I'm
5 saying. So it's not really a factor.

6 MR. MONNINGER: Yes. But we thought it
7 would be good to --

8 MEMBER SHACK: It occurs to people many
9 times that somebody should mention this during the
10 discussion.

11 MR. MONNINGER: The independence of
12 barriers. The notion of a filter, we believe it would
13 minimize the dependencies between the containment and
14 the reactor coolant system. We believe the filter
15 would provide a system that is independent of the, to
16 a large extent, independent of what's going on in the
17 integrated plant response.

18 MEMBER STETKAR: But for it to be
19 effective, you still need to get water.

20 MR. MONNINGER: Yes, yes.

21 MEMBER STETKAR: So when you say
22 integrated plant response, I think of ways to get
23 water in, regardless of whether they're piped into the
24 plant or there are fire trucks. So it's not divorced
25 in that sense.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. MONNINGER: Yes. Because without the
2 cooling systems, you're subject to liner melt-through,
3 you're subject to containment over-temperature failure
4 or over-pressure, well, containment over-temperature
5 failure or liner melt-through.

6 Slide 24, we've labeled this consistency
7 between reactor technologies. This could also
8 potentially be a con. When you look at NUREG 1150 or
9 some of the various risk assessments out there, when
10 you look at the societal risk measures, there's a
11 certain level of equivalence between the Bs and the Ps
12 and all of that, and it's sort of a washout with the
13 higher CDF versus a lower CDF, a stronger containment
14 versus a weaker containment. If a filter is proposed
15 or is required for the Mark I and Mark II
16 containments, you could say that's an inconsistency.
17 If they're all currently providing an equivalent level
18 of safety, why are you now requiring a filter for the
19 Mark Is and Mark IIs? So that argument could be made
20 out there. The staff, our thought is we recognize
21 that, but, given the high conditional containment
22 failure probability for Mark Is or IIs and for
23 defense-in-depth purposes, we believe it's the right
24 thing to do.

25 External vents. Not only do they

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 potentially impact the reactor sight, but they also
2 impact the local community. We believe a filtered
3 vent would avoid the nuclear power plant contributing
4 significantly to the impact, the other impact in the
5 local community following external events.

6 The next slide, multi-unit events. Within
7 our analysis, we assumed just one core damage event.
8 We didn't assume multi-unit events. If you look at
9 some of the studies, some of the results that have
10 come out of Japan, they talk about the complications
11 that occurred due to the failure of the containment
12 failure, the reactor building's closure, with unit one
13 impacting the response to units two and three. We
14 believe that if there was a potential filter there and
15 if the filter was successful, it would benefit the
16 operation's response to the other non-impacted units.

17 CHAIR SCHULTZ: I'm just struggling with
18 the word, with the choice of the phrase up on this
19 slide and in the previous slide, and there may be
20 others, where we call it a significant advantage. Of
21 course, the likelihood comes into play if we describe
22 an event that affects the local community and so
23 forth, and then the vent would have a significant
24 advantage. It presumes that the plant is in a
25 particular condition, and it could have a significant

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 advantage, we know, for certain sequences but there
2 are many in which it could not have a significant
3 advantage at all. So I just, I struggle with the use
4 of the word in each of the qualitative evaluations.

5 MR. MONNINGER: And we'll go back and look
6 at that to see how we could be more clear in our
7 intent, given the low likelihood of the events.

8 CHAIR SCHULTZ: That's what strikes me,
9 the low likelihood of the events. And in some cases,
10 it will not provide an advantage. A release will
11 occur in any case, whether you have the vent or not,
12 the filter or not, as we saw at Fukushima.

13 MR. MONNINGER: And I guess the thought is
14 you can have failures in the vent pathways, you could
15 have failures associated with providing cooling to the
16 core debris on the floor or you could be in other
17 sequences, you know, bypass sequences or etcetera.
18 But when you look at the entire spectrum of sequences,
19 we believe a filtered vent would provide a benefit to
20 a very high percentage of the accident sequences out
21 there for Mark Is and Mark IIs. You know, given that
22 the containment has a very high failure probability,
23 you know, then you come in and what does the filter
24 vent do to decrease that high conditional containment
25 failure probability? So we believe it would be of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 benefit to a significant number of sequences, a very
2 high percentage.

3 CHAIR SCHULTZ: Okay. I'll think about
4 that and come back tomorrow.

5 MR. MONNINGER: Well, I think it's driven,
6 you know, by the failure of water to the cavity floor.
7 If you were to assume water goes to the floor, then
8 all those sequences there, especially with the passive
9 one, goes to --

10 MEMBER STETKAR: That's true. Or if it's
11 there to begin with.

12 MR. MONNINGER: All right. So I'll turn
13 over to --

14 MR. DENNIG: Yes, I'm about to get us back
15 on schedule. Slides 27, 28, and 29, I cannot see
16 anything that has not been spoken about here before at
17 some extent and detail. And it's just a
18 recapitulation of things that you'll find in the CPIP
19 documents and all that stuff. So rather than waste
20 your time on that, I'd like to just pick up at slide
21 30, if I could, please. And this, again, is a
22 recapitulation, and it's not new to anybody. But the
23 one thing that I did want to mention briefly was that,
24 in response to the Generic Letter 89.16, which did
25 discuss prolonged SBO and did discuss possible uses

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 for severe accident mitigation, what that translated
2 into what the plants did was not SBO capable. And the
3 severe accident aspects were also not incorporated in
4 the designs that resulted from the requests in the
5 generic letter. So that's all I had to say on that.

6 I get to talk about foreign experience,
7 which John has already said does not play much into
8 our thinking. But --

9 MEMBER CORRADINI: Can I -- I thought your
10 response to, if I heard that right, I thought your
11 response mainly to John about performance-based was,
12 maybe I misinterpreted, is that the fact the Swedes
13 went through a performance-based thinking process and
14 came to the conclusion this was essentially --

15 MR. DENNIG: Yes, I'm going to go through
16 that. I'll go through that. Okay. Within the paper,
17 you already read about the status of filtered vents
18 and regulatory basis in other countries. We did speak
19 with the folks that we met with about the downside of
20 having an external engineered filtered venting system,
21 and, before I forget them, the impacts of that and the
22 possible unforeseen circumstances, if you will, were
23 appreciated up-front and avoided by making the system
24 independent of everything else. The FCVS does not,
25 for power instruments, piping, there's no reliance on

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 any other system. And that also allowed them to do --
2 the work to put the system in was done in two regular
3 outages. The outages weren't extended. And most of
4 that work is the tie-in to the penetration.

5 And in terms of the other downsides,
6 things like external events and tornadoes and
7 hurricanes and so on and so forth come up. And in
8 those cases, they either incorporated what they knew
9 at the time to be the most extreme circumstance that
10 they wanted to deal with or they're revisiting that as
11 a result of their stress tests. It's on a to-do list
12 for some countries to go back and revisit earthquakes
13 and floods and icing and the rest of those things. So
14 they may have some additional things that they're
15 going to do.

16 So the next slide, please.

17 MEMBER SKILLMAN: Bob, before you go, on
18 that slide, the third bullet, how do they handle the
19 source term that comes from removal of the cesium?

20 MR. DENNIG: In terms of outside the
21 containment or --

22 MEMBER SKILLMAN: Okay. Here's this box.
23 Maybe it's concrete, and maybe it's steel. And inside
24 that box, a regular core, 17 billion curies on the
25 fission product isotope curve, major, major fraction

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 of cesium-134 and -137, the operators repair. And so
2 there will be, eight or ten hours out, a huge amount
3 of cesium, and it's potent. So what do they say about
4 the source term? Where do you put this stuff?

5 MR. DENNIG: The external filters are
6 installed in places that are already inaccessible or
7 made inaccessible or, failing that, there are shield
8 walls that are put up. Point Lepreau installed theirs
9 up against containment and put seismic and shield wall
10 on two sides and then on the top. So the source term
11 is acknowledged. There are provisions for getting the
12 stuff back from the filter back into the containment
13 when you're done, when you're finished and when you
14 want to get it back. There's usually a drain line,
15 sometimes a pump to pump it back into the containment
16 so that it doesn't stay out there. So it's out there
17 for the necessary period. It's in a shielded or
18 inaccessible location. Piping is routed such that
19 it's not a hazard, and there are provisions for
20 getting the source term back into the containment when
21 you're finished using the filter.

22 MR. BETTLE: Yes, that pretty much covers
23 it. Most of them have the capability of either
24 gravity draining or hopping back in compartments with
25 a shielded filter drain pumps.

1 MEMBER REMPE: In one of these prior
2 meetings, we talked about changes to the operating
3 procedures to accommodate these vents, and did we ever
4 hear back the answer to what specific things we
5 changed in the operating procedures?

6 MR. MONNINGER: From the foreign
7 countries?

8 MEMBER REMPE: Yes.

9 MR. MONNINGER: Yes. And the Germans were
10 in with Westinghouse, and we asked them that question
11 and they said, well, we didn't, I guess -- so
12 Westinghouse bought out -- anyway, they said when the
13 various countries that they were representing either
14 as vendors or because they lived in Germany or
15 wherever, they said, well, we didn't model it just for
16 the filters, we had a whole package of improvements
17 that were done for the plant. So we asked them what
18 was the change in risk for the filters, and we looked
19 at everything that was required, so it was more of a,
20 I guess, integrated type response that the European
21 countries had. So the procedures would need to be
22 revised, but they're were advised the procedures, not
23 just for the filters but for all the other things that
24 they require.

25 MEMBER STETKAR: So I think, actually, in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 timing, the filters were installed primarily in the
2 late 80s into the 90s, if I recall, in most European
3 countries. And the SAMGs, what you're talking about,
4 Westinghouse was a leader over there, weren't
5 developed until the early 2000s really. So,
6 essentially, they already had something, you know, the
7 hardware --

8 MEMBER REMPE: So has anyone stopped to
9 think about what changes will have to be accommodated
10 because of it and to avoid any adverse --

11 MEMBER STETKAR: That's why I asked the
12 industry whether they had thought about that.

13 MEMBER REMPE: Has the staff?

14 MR. MONNINGER: Well, part of the order
15 says, you know, you have to incorporate it into
16 operating procedures, and the procedures were venting.
17 The preferential first pathway we would hope would be
18 the filter vent and then others. They are currently
19 in the process of revising the SAMGs, and you would
20 expect that if a filter was required they would
21 incorporate the operation of the filter into the
22 SAMGs, and the NRC will be involved in the transition
23 between the SAMGs, the European --

24 MR. DENNIG: Are you thinking in terms of
25 there is some way of operating this system that will

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 make the accident worse that we haven't anticipated --

2 MEMBER REMPE: Well, one of the things to
3 consider is adverse type of actions, opening it at a
4 wrong time for example or something or another, and I
5 just was wondering if you started to think about that
6 yet or have thought about --

7 CHAIR SCHULTZ: The other piece of
8 unintended consequences that operations involved or
9 diverted in some fashion that's going to make the
10 situation worse rather than better.

11 MR. MONNINGER: We asked the question, and
12 it's always come back with they hadn't identified
13 anyone. I mean, one of the issues that you do have
14 with the boilers, of course, if you were to vent
15 through the filter, through the option four or option
16 two, is the loss of a non-condensable, and there are
17 issues, potential issues with implosion of these
18 containments. You do have vacuum breakers, but the
19 vacuum breakers would not be sized to make up for this
20 loss of non-condensables. If you go into the EOPs,
21 currently there is a thing called the DWSIL, the dry
22 well spray initiation limit. Fundamental within the
23 calculation of that limit is the number of molds and
24 non-condensables, and it assumes that, you know, you
25 know the number of molds, so you don't draw a vacuum

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 on it. And there's been one or two people who
2 attended some of our public meetings that did raise
3 this issue of negative containment factoring, but,
4 other than that, I can't think of -- we have routinely
5 asked the question. The only one we've heard about is
6 the negative containment pressure. But you currently
7 have that issue out there.

8 MR. DENNIG: Slide 32, please.

9 CHAIR SCHULTZ: Well, John, it's out
10 there, but if you've got something that would suggest
11 to an operator that, oh, we can go ahead and do it
12 because we've got a filter, and so the propensity may
13 be do it and perhaps at the wrong time and without
14 proper attention.

15 MR. DENNIG: I guess we should think about
16 that, but the issues that came up at Fukushima were
17 the inability to vent was causing the problem and,
18 certainly, you know, not venting at the wrong time.
19 We should think about that. And like John said, we
20 asked the question routinely, and the answer is that,
21 well, we've got this, we developed our SAMGs, the
22 SAMGs work, you know, the usual answer. And nobody
23 has said we've got to be careful with one of the --
24 you know, one of the negative things of this or one of
25 the things you've got to look out for that we haven't

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 gotten.

2 MR. MONNINGER: A lot of it goes to the
3 initiation of some type of active cooling system where
4 you would suck out your steam very quickly, so there's
5 limits in there on the sprays or there would be a
6 potential limit in there on fan coolers or something
7 like that. But if you were to vent and then shut it
8 off, you know, just the decay heat within the
9 containment should maintain that, but it would be more
10 of a concern if you actively then went in and were to
11 spray a high, high capacity spray and really take out
12 your steam very quickly.

13 MR. DENNIG: Slide 32. I think you've
14 seen this slide before. Nothing much new. The point
15 I wanted to talk about was the third bullet. And the
16 way this develops in other countries is that they go
17 into the question of how can I make the containment
18 stronger and, in particular, with regard to over-
19 pressure and reduce the consequences of a release.
20 And out of that comes three basic functions. One is
21 flooding underneath the pedestal. The other is the
22 ability to continue to put water into flood-up, and
23 the filter containment venting system which can be
24 used as feed and bleed with the system that puts in
25 the water into the containment. That system is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 normally the spray system that's run off of a smaller
2 pump. It's not used for decontamination. It's,
3 again, used for this cooling function. But the three
4 things work together. And in the case of the
5 containment flooding and core debris coverage, they
6 put in an independent system that has its own piping
7 tubes. The only thing that they've used is the dry
8 well sparger and the spray and ring in the
9 containment, and it's an independent pipe that runs to
10 a fire system or it can be hooked to a fire truck or
11 it goes to a dedicated diesel-driven pump. So that's
12 who they assure themselves that they have a reliable
13 source of this debris management.

14 So they did a filter containment venting
15 system, which opens passively and, in most cases, can
16 operate for 24 hours before it needs any kind of
17 attention. They always have a bypass with an active
18 capability. They have also the ability to isolate the
19 ruptured disk path if they want to keep the ruptured
20 disk intact.

21 But in terms of, you know, overall, they
22 view it as a severe accident management package for
23 the containment function. And so that's where we get
24 into, yes, everybody agrees that you have to have the
25 water in there eventually if you're going to do

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 anything, and that's how they approach it. So that's
2 slide 32.

3 Slide 33. I don't see anything new to
4 point out there. Slide 34. The Swedes started this,
5 and they have a released performance goal, which is
6 the 0.1 percent of cesium and iodine from a 1,800
7 megawatt thermal reactor period, and that's the source
8 term. And you won't release more than 0.1 percent of
9 that. That's the overall.

10 One of the side conditions is that you're
11 not going to have a filtered vent that does any better
12 than the containment does if you're not venting, if
13 you don't need to vent. That was another
14 consideration.

15 And then pretty much, as best we can tell,
16 as best I can tell, that from that point in
17 development of the technology, other countries have
18 pretty much adopted the external filters on a DF
19 basis. They specify a minimum decontamination factor
20 for the vent path, and that's how they go at it.
21 That's all I have to say on that.

22 MEMBER ARMIJO: And this is a
23 decontamination factor that's principally focused on
24 cesium?

25 MR. DENNIG: Cesium, iodine, and there are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 words, like in anything else, that would contribute to
2 a long-term dose returning populations. But it boils
3 down to cesium and iodine 131, I think is where it
4 goes.

5 And next slide. This is just the -- we
6 are interested in the Mark Is and the Mark IIs and the
7 pressure suppression containments. That's what's in
8 the NTTF report, and that's what the history tells us
9 we should be interested in. And this just an
10 illustration of the populations outside the U.S. for
11 those containment designs. We have 23 Mark Is and 8
12 Mark IIs. Considering Mark I is Spain and the Mark
13 III is also Spain, no FSDS decision -- Mark Is is
14 India, and Mark IIs is Mexico, and that's pretty all
15 I had to say on that slide, just to put that in
16 perspective.

17 And I'm finished.

18 MR. BETTLE: Okay. My name is Jerry
19 Bettle. I work in the Containment and Ventilation
20 branch. I'm going to speak to a couple slides here on
21 Enclosure 4, the slide 36, Mark I and II containment
22 severe accident performance. The enclosure discusses
23 the existing containments, spray systems, flooding,
24 venting, as well as fr the existing containment
25 configurations. With decontamination you can inspect

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 from the dry well spray through the wet well and what
2 the performance is with the external engineered filter
3 systems.

4 Also, discuss the EPRI evaluation. In our
5 comprehensive report, we provided a little critique
6 there. And also talk about past containment vent
7 actuation capability and early venting.

8 I guess I'm talking about early venting,
9 and it's come up several times. People talk about it
10 kind of like in two time frames. One, before we
11 actually get to core damage to depressurization the
12 containment, allow for a low-pressured pump injection
13 for both putting water onto the floor, as well as into
14 the vessel. But later, when you do start to drop
15 level through the core and you get hydrogen production
16 before you have a significant fission product
17 inventory containment to get ahead of the game and
18 vent out a lot of the non-condensable. The nitrogen
19 and the early part of the hydrogen production. So I
20 guess when people talk about early vent, it really
21 covers kind of two situations.

22 At the plant's existing guidance and the
23 emergency operation procedures severe accident
24 management guides, and extreme damage mitigation
25 guides prescribe multiple containment vent pathways

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 and use of portable pumps for reactor and dry well
2 injection. Focus is where it should be: on preventing
3 core damage.

4 Also, in Enclosure 4, we talk about dry
5 well sprays, how they perform for decontamination.
6 The existing spray headers for the Mark Is and Mark
7 IIs are designed for, as been discussed before,
8 anywhere from 3,000 to 10,000 gallon per minute. The
9 portable pumps, the B5B requirement was at least 300
10 gallons per minute. The EPRI study assumed a flow
11 rate of 500 gallons per minute. Either of those, it's
12 basically the low hundreds of GPM. You're really not
13 going to have spray in the normal sense of sprays as
14 far as the decontamination usefulness.

15 MEMBER ARMIJO: Do you agree with the EPRI
16 conclusion that the spray part only improves the
17 decontamination by a factor of two compared to just
18 getting the water on the floor?

19 MR. BETTLE: It's possible. I mean that
20 would be really hard to measure. I don't think
21 there's been any testing to go with the particular
22 configuration of that kind of spray flow. Just as an
23 example there's one alternative source term evaluation
24 that was done for Mark II. And although their spray
25 headers were like 61 feet up from the floor, they're

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 only giving credit for 8 feet of free fall for the
2 droplets. They did scale down about 50 percent on the
3 spray flow rate assuming that the spray at 50 percent
4 flow would still be spray and still be affecting this.
5 But they cut it down.

6 If you talk about droplets size, if you're
7 just talking about garden hose type flow coming out of
8 a number of nozzle heads, it's going to impact the
9 surface and just be surface runoff pretty quickly.
10 And if you've ever been a Mark I containment, that's
11 pretty tight there. You can't go very many feet
12 before you hit something hard.

13 So it's going to be very low and it's
14 almost to the point I guess where we pretty much
15 considered it negligible. Maybe it cools down the
16 structures. You see a little bit of that are played
17 out. You don't get revolatilization. It might have
18 that kind of effect.

19 MEMBER ARMIJO: Unless you have the high
20 flow rates you would --

21 MR. BETTLE: You're not going to get much
22 to the contamination. They do have a flow in there.
23 It does provide it. It gives a good distribution in
24 contamination. It runs down to protect from the wall
25 melt-through and in a sense it's distributed inside

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 containment. At the flow rates, you do get 500
2 gallons per minute principal sub-cooling when it runs
3 down into the suppression pool.

4 MEMBER ARMIJO: My question that I'm --

5 MR. BETTLE: I don't think it's the spray.
6 I don't think that you would necessarily even count on
7 decontamination too from the actual spray in the air,
8 the droplets.

9 MEMBER ARMIJO: Not if it's just dribbling
10 out.

11 MR. BETTLE: Yes.

12 MEMBER ARMIJO: Yes, I agree with that.
13 But I'm just wondering. The systems there --

14 MR. BETTLE: Yes.

15 MEMBER ARMIJO: -- and in the reports or
16 the briefings we had October 3rd I was taken by Marty
17 Stutzke's bar charts for all these mod cases of
18 filtered versus unfiltered venting through the
19 suppression pool versus venting through the dry well.
20 The only case that stood out as really a bad news was
21 venting and unfiltered through the dry well.

22 MR. BETTLE: Yes.

23 MEMBER ARMIJO: And so it kind of pointed
24 out the weakness in the system. So why wouldn't it be
25 worthwhile to address how to solve that problem by

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 either making the flow to the dry well sprays more
2 reliable or a back-up system? It's just a matter of
3 how you want to spend your money. Why wasn't that
4 evaluated or studied?

5 MR. BETTLE: In terms of actually
6 requiring enough flow to make the existing containment
7 spray headers work as effective decontamination.

8 MEMBER ARMIJO: I don't know what it would
9 cost.

10 MR. BETTLE: Thousands of gallons per --

11 MEMBER ARMIJO: I don't think anybody
12 studied it. And as somebody said, "Well, we'll put in
13 different nozzles to do this. We'll bring in the
14 bigger pumps." How does that compare in the cost
15 benefit with adding a filter?

16 MR. BETTLE: I don't think anybody has
17 suggested bringing in the kind of pumps, the portable
18 pumps. They kind of lose their portable connotation
19 when you start getting several thousand gallons.

20 MR. DENNIG: Other places it wasn't a
21 tradeoff. It was both. I mean it didn't evaluate
22 that or the filtered vent. It was both. So I don't
23 think that they broke it out in other countries.

24 At the time of the generic letter, the
25 staff did talk about using spray versus the value of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 covering the core debris. And the opinion then was
2 that the spray was not -- And again this was at the
3 low flows -- anything to be considered vis-à-vis what
4 you would get from eventually flooding and covering
5 the core debris.

6 MEMBER STETKAR: Jerry, when you say
7 feasible for portability, do you mean on a little red
8 wagon or?

9 MR. BETTLE: Yes.

10 MEMBER STETKAR: No, I've been in power
11 plants the size of a 3,000 gallon per minute
12 centrifugal low pressure, not high pressure -- This is
13 a low pressure pump -- would easily fit in this space
14 in front of us here. Easily.

15 MR. BETTLE: Right.

16 MEMBER STETKAR: So that's pretty portable
17 if I have a decent sized pickup truck I think.

18 MR. BETTLE: Yes, and in which case soon
19 you'd be locked into making sure you had some
20 motorized ability to push it around. It's something
21 that three guys couldn't push very far around.

22 MEMBER STETKAR: Yes. I mean if you're
23 thinking about literally something that portable
24 you're absolutely right.

25 MR. BETTLE: Yes, when you get down to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that 300-400 gallon range that's the size a couple of
2 guys could muscle around if you needed to.

3 MEMBER STETKAR: You're right. Yes.
4 That's true.

5 MEMBER ARMIJO: No matter what we're
6 talking about spending tens of millions of dollars and
7 I'm just trying to find out is the addition of a
8 filtered vent to optimum solution for every feet of
9 the Mark I and Mark II or are there smarter ways or
10 different ways that would be better by upgrading or
11 improving or protecting existingsystems that provide
12 that decontamination function? And it looks like the
13 suppression pool does a great job of decontamination
14 and the dry well apparently doesn't.

15 CHAIR SCHULTZ: Put the slide up.

16 MR. MONNINGER: Okay.

17 CHAIR SCHULTZ: So much so that if the
18 filtered vent were there it wouldn't provide much
19 extra benefit.

20 MR. BETTLE: Let's jump ahead to this
21 slide here. This comes out of Brookhaven.

22 MEMBER CORRADINI: Do you want to come up
23 and use my chair, Sam?

24 MEMBER ARMIJO: No, I'll squint.

25 MR. BETTLE: If you have the ability to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 read this. If you look at it, that's Brookhaven
2 National Labs Technical Report. This is basically the
3 general understanding of the effectiveness of the
4 various existing containment decontamination system
5 capabilities.

6 Up at the top, you have it when the core
7 is exited the vessel. It's on the floor. That's why
8 you have the shallow pool over the core debris. The
9 bottom two are what you're getting when the core is
10 still in the vessel. You can see there's a
11 considerable amount of uncertainty as to what
12 decontamination factor you'd get.

13 MR. DENNIG: And that spray assumes 10,000
14 gpm.

15 MR. BETTLE: That's normal spray flow, not
16 the reduced flex style of spray flow. Most of those
17 tend down towards defaulting down in the 10 to 100
18 range.

19 Now this didn't involve the EPRI study
20 with vent cycling to try to maximize what you can get
21 there or get into maintaining substantial sub-cooling
22 in the pool for the pool decontamination factor.

23 You go back to slide eight just talking a
24 little bit about what you get for decontamination in
25 the pool. You start out with the relief coming

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 through the safety relief valves into the T-quenchers
2 down near the bottom of the pool and starts out cool.
3 And everybody pretty much agrees you're going to get
4 a pretty high decontamination factor.

5 The pool heats up. That will drop off a
6 little bit. The core comes out of the vessel and hits
7 the floor. Then flow from that is coming down all
8 those great big down-coming pipes that are sized for
9 the initial LOCA blowdown. So you're going to have a
10 very mild discharge through those down-coming pipes.

11 And the bottom half of the suppression
12 chamber is going to be more or less thermally
13 isolated. And you're just heating up the top half and
14 the decontamination factor is going to be very, very
15 minimal at that point. And I think that's what you
16 kinda see on that graph on page 40.

17 MEMBER ARMIJO: It's time-dependent or
18 it's temperature-dependent.

19 MR. BETTLE: Yes. As you progress to the
20 accident. You know, when you get down there. A pool
21 near saturation is not giving you a whole lot as far
22 as decontamination and spray especially at very, very
23 low flow rate sprays. It's not giving you very much.
24 Now this is pretty much the accepted, expected
25 capabilities as far as for the system.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Slide 41. As was discussed in the
2 previous presentation, EPRI for the comprehensive
3 study pretty much a computer modeling feasibility
4 study. If I did this, if I did that, as far as what
5 the inputs are. What kind of a decontamination factor
6 could I get out of the containment of the containment
7 systems as they work?

8 The employable portable pump, the melt
9 core analysis that the Office of Reactor Research did
10 assumed the 300 gallon per minute because that's the
11 required minimum capacity. And the EPRI study assumed
12 500 gallons per minute. That does provide much more
13 than you need for decay heat removal.

14 So it maintains quite a bit of suppression
15 pool sub-cooling. Maintains a reasonably good
16 decontamination capability there.

17 They also in their strategy maintain
18 containment pressure elevated. I say elevated 40 to
19 60 pounds. That's above the -- right at the
20 containment design pressure typically.

21 And they have to open the vent at 60 and
22 close it at 40 and have to maintain that pretty
23 rigidly to achieve a DF. Otherwise, they roll back
24 down towards the values you see on the chart on page
25 40.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 This places a lot of reliance on
2 instrumentation for containment pressure, containment
3 water level, suppression chamber water level and in
4 the operator actions. There was some mention that,
5 yes, you could put in some sort of automated relief
6 valve or automate the control of these vent valves to
7 open and close them precisely on schedule.

8 However, you also have to be maintaining
9 an accurate indication of what the containment
10 pressure and level are to achieve it. So you're
11 utilizing the system. But you're kind of walking a
12 little bit of a tightrope in that you get off that
13 management schedule for the containment. Then your
14 decontamination factors will roll back down
15 considerably. So, as far as its feasibility, at this
16 point, we don't see that it necessarily has a high
17 likelihood of a successful implementation.

18 And that comes to the --

19 MEMBER STETKAR: Jerry.

20 MR. BETTLE: Yes.

21 MEMBER STETKAR: Come back to the question
22 though how do the European severe accident management
23 guidelines address that issue. Do they simply open it
24 and keep it depressurized or do they cycle it and keep
25 it --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. BETTLE: For the most part, they just
2 open it and leave it open.

3 MEMBER STETKAR: They just leave it open.

4 MR. BETTLE: Yes. I mean they have the
5 capability of closing it if for some reason they
6 wanted to close.

7 MEMBER STETKAR: They don't use it.

8 MR. BETTLE: And obviously when they
9 regain power in other design systems, they'll close it
10 up and start cooling containment otherwise.

11 MEMBER STETKAR: Okay. Thanks.

12 MR. BETTLE: And there are a couple other
13 things in going with that when you open it and leave
14 it open. If you start out with inerted containment,
15 you're constantly pushing out on this line. If you go
16 into a sequential cycling a vent valve and you have
17 100-150 feet, maybe plus, of this piping, you close
18 it. It's going to have a mixture of steam of hydrogen
19 in there and the system is going start condensing.
20 You're going to wind up with a flammable explosive
21 mixture being recreated repeatedly in this line.

22 MR. MONNINGER: I think another question
23 that comes up is the end state if you were to have an
24 accident. There was a lot of interest especially in
25 Fukushima for if there was a safe shutdown or

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 whatever.

2 But what is the end state that you want?
3 How long would you be relying upon the containment
4 vent cycle? The analysis may be an artifact. They
5 keep it at 72 hours. What kind of interest or
6 pressure would there be put in that first day, that
7 first three days, that first week, to take away that
8 challenge to the containment?

9 It is over containment design pressures,
10 the temperatures, your containment penetrations are
11 leaking, etc. Is it a long-term success fact?

12 MR. BETTLE: The other thing of
13 maintaining the pressure high is that especially in a
14 Mark I you know you have a heat source in there.
15 You're going to have some residual in the reactor
16 vessel putting flow in through spray headers. They're
17 down usually at the transition to the spherical
18 section. You're not really providing that much
19 cooling to the upper head. So any penetrations there
20 that would be susceptible to heat are probably getting
21 well above their design temperatures and may be going
22 into leak excessively at, let's say, design pressure.

23 MR. MONNINGER: The next enclosure to the
24 draft Commission papers, Enclosure 5, we have it
25 divided into Enclosure 5A, B and C for the MELCOR,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MACCS and PRA suction. This was worked on by the
2 NRC's Office of Nuclear Regulatory Research. They
3 were integral to the entire project, not only the work
4 with ME's enclosures, but the qualitative analysis,
5 the work throughout the Commission paper.

6 MELCOR, we had a half day session on that
7 in September and then an additional discussion in
8 early October. And one of the interests from the ACRS
9 was a copy of the MELCOR report which we have
10 provided.

11 This is just the summary of the approach.
12 We used the SOARCA modeling, the accident sequence as
13 we looked at the long-term Station Blackout.

14 We looked at various mitigation actions
15 whether it's providing cavity flooding through the
16 core spray system or the dry well spray system. And
17 we also did a series of sensitivity analysis. This
18 work was done by Sub Basu who is here in conjunction
19 with Sandia National Laboratory.

20 One thing I would like to mention is this
21 notion of cavity flooding. It's discussed within the
22 paper and the staff's current view or the current
23 position that we documented in the paper is it's a
24 current requirement.

25 If you look at 50.54(hh), it talks about

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the need for mitigation measures post 9/11 and the NRC
2 has a reg guide out there and that reg guide then
3 endorses the NEI document. That NEI document
4 discussed the need to provide cavity to the dry well
5 floor for core debris cooling.

6 MEMBER SHACK: But doesn't it allow it to
7 go to the pressure vessel also? It's an or, isn't it?

8 MR. MONNINGER: Yes. It assumes if you
9 melt the core comes at the bottom of the vessel --

10 MR. DENNIG: If you melt through it, it
11 will break through.

12 MR. MONNINGER: But there were some
13 statements whether that is viewed to be a current
14 requirement or not. Within our reg analysis, we have
15 taken credit for that being a current requirement. A
16 statement was made that plants would have to look at
17 that and have to do that. The staff at least on the
18 team here used that as being a current requirement.
19 So it either is or it isn't.

20 And for one case if we go back and we say
21 that it is determined that it isn't, we would then add
22 that also within the proposed order. So it is either
23 currently required by 50.54(hh) or if it isn't
24 currently required you would see that within the
25 order. I just wanted to clarify that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER REMPE: John, I know we asked for
2 this report and the version that we got on the 26th of
3 October is a mark-up. So I realize it's a draft. And
4 maybe these things have already been fixed. But I
5 appreciated the fact that the staff has gone through
6 and tried to explain some things that are counter
7 intuitive, the calculation results. But I did just a
8 quick scan and there are some typos in there still
9 with respect to some figures and having numbers
10 mislabeled.

11 MR. MONNINGER: Okay.

12 MEMBER REMPE: But also I would encourage
13 that someone go through and think a little bit more
14 about non-intuitive results.

15 For example, Case 2 and Case 6 shouldn't
16 have any differences in results presented until the
17 vessel fails because we're talking about core spray
18 and yet I did see some differences. So some things
19 like that I think before this is final I hope will be
20 attended to. But then maybe they've already been
21 fixed. I know you guys are all fishing as hard as you
22 can.

23 MR. MONNINGER: No, that's a good comment
24 and we'll definitely go back in it.

25 The next slide, slide 43, it's been

1 mentioned several times by the industry and NRC staff
2 that you need to water on dry well floor to provide
3 liner melt-through. That was one of the observations
4 coming out of the Containment Performance Improvement
5 Program in the `80s, the Theofanos work at University
6 of California Santa Barbara in the `90s, etc.

7 So it does various things. It prevents
8 the liner melt-through and would also scrub fission
9 products. The venting whether it's option 2, 3, or 4
10 would prevent overpressurization failure and that you
11 do need a combination of both for success.

12 In Enclosure 5b, we discussed that at the
13 October 34rd meeting. And that's the MACCS
14 calculation. This summarizes the various outputs that
15 we use from the MACCS codes. These are the typical
16 outputs that are calculated and we use them within our
17 regulatory analysis.

18 MEMBER STETKAR: And you did vary the
19 economic costs associated with those outputs over
20 ranges.

21 MR. MONNINGER: The economic costs?

22 MEMBER STETKAR: That's my question about
23 what did you do on that vertical axis. In your plot,
24 it shows the break even.

25 MR. MONNINGER: Yes. So go back to --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MS. GHOSH: I think it talks about --

2 CHAIR SCHULTZ: Go ahead and identify
3 yourself, Tina, please. Thank you.

4 MS. GHOSH: This is Tina Ghosh from the
5 Office of Research. I think you're talking about
6 Marty Stutzke's analysis. Is that right? You're
7 looking at the -- I see on your computers. Are you
8 looking at the event tree that he's --

9 MEMBER STETKAR: No, I'm looking at -- No,
10 the event tree don't look at my computer.

11 MS. GHOSH: Okay.

12 MEMBER STETKAR: I'm looking at my
13 computer. You don't have to look at my computer.
14 Don't presuppose what I'm asking.

15 MS. GHOSH: I apologize. Let me back up
16 here.

17 MEMBER STETKAR: No. It's Marty -- The
18 event tree that I'm looking at just sorts out the
19 logical combinations of things. But within that logic
20 structure that analysis was done let's say to
21 investigate uncertainty on what I'll call the
22 horizontal scale on this plot of varying core damage
23 frequency by a factor of 10 higher from the nominal 2
24 $\times 10^{-5}$. And that showed that you barely made it into
25 the cost beneficial range at the costs associated with

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the nominal MACCS 2 analysis.

2 My question is I thought that I read that
3 an uncertainty analysis or whatever you want to call
4 it, sensitivity analysis, was done to vary the costs
5 which would be fix someplace on the horizontal scale
6 and vary it vertically. And I was curious if that was
7 done. I asked you before. What range was associated
8 or was the basis for that variation? What was it not
9 done?

10 MS. GHOSH: As far as the economic costs
11 that MACCS calculates, those are deterministically
12 calculated based on the scenarios that we ran. So,
13 for example, in the enclosure we talk about the eight
14 cases that we ran with the filtered and unfiltered
15 venting or no venting for some of the cases. For each
16 of those cases we have a deterministic economic cost
17 calculated by MACCS which is actually the average of
18 the weather child (phonetic).

19 MEMBER STETKAR: I understand that.

20 MS. GHOSH: Yes. And then Marty on top of
21 that added an uncertainty -- Well, I think John is
22 going to get to that in the next enclosure. Marty
23 tried to look at holistically combining the
24 uncertainties across all the different pieces of the
25 analysis and he added in an error factor to the MACCS

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 outputs. So maybe that's what you're talking about.

2 MEMBER STETKAR: That's what I'm asking
3 about.

4 MS. GHOSH: Yes.

5 MEMBER STETKAR: That's what I'm
6 characterizing in this simple sense an uncertainty on
7 the vertical axis here.

8 MS. GHOSH: Right.

9 MEMBER STETKAR: I know exactly what he
10 did in terms of addressing uncertainties on the
11 horizontal axis.

12 MS. GHOSH: So he did that part of the
13 MACCS output.

14 MEMBER STETKAR: Okay.

15 MS. GHOSH: So MACCS gave a deterministic
16 number. And then he added an uncertainty factor on
17 top of that.

18 MEMBER STETKAR: Okay

19 MEMBER SHACK: But you did the cost for a
20 single economic cost and basically a single site.

21 MS. GHOSH: That's right.

22 MEMBER SHACK: A fixed cost, a fixed
23 population.

24 MS. GHOSH: That's right. It's a
25 deterministic calculation based on the site

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 characteristics. We used Peach Bottom.

2 MEMBER SHACK: Peach Bottom, right.

3 MEMBER STETKAR: She punted it back to
4 you, John.

5 MR. MONNINGER: I know. And the table's
6 not in here. And this is the version --

7 MEMBER STETKAR: No, it's not.

8 MR. MONNINGER: -- that you guys have
9 also. And I do recall --

10 MEMBER STETKAR: There are words in there.
11 I didn't do the word search. There are words to say
12 and Tina just said there's an impression that that was
13 done.

14 MR. MONNINGER: So for the various
15 parameters whether it was CDF or whether it was
16 operator response what he had was best estimate. And
17 then they assigned a distribution, etc. I don't
18 recall --

19 MEMBER STETKAR: But all that that does is
20 change the split fractions if you call it that --

21 MR. MONNINGER: Right.

22 MEMBER STETKAR: -- for the different
23 sequence frequencies in this event tree that I am now
24 looking at.

25 MR. MONNINGER: And I don't recall him

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 assigning anything like that to the economic
2 consequences.

3 MEMBER STETKAR: Okay.

4 MR. MONNINGER: We can't get back.

5 MEMBER STETKAR: Yes, because I thought I
6 read the words in there somewhere that that was done.
7 And it if wasn't then I misread the words someplace.

8 MR. MONNINGER: I mean at one time I think
9 the base case we had a table in there comparing the
10 base case offsite costs versus other hurricanes out
11 there.

12 CHAIR SCHULTZ: Could you bring that back
13 tomorrow, John? So we can see if there are any
14 additional information. Because I don't think we have
15 that detail in what we were provided in 5B.

16 MR. MONNINGER: Okay. We were on slide
17 44. These are the outputs that Tina talked about and
18 we'll come back and we'll address whether there was
19 uncertainty analysis done that included the economic
20 costs. And these are the insights or results from the
21 calculations. Essentially there was no prompt
22 fatality risk calculated.

23 The level of exposure was too low to
24 incur. So therefore the latent cancer fatality risk
25 is one of the metrics out there of interest. In

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 addition, we looked at land contamination being the
2 shine from cesium-137. And there was a lot of
3 discussion within the past meeting and actually within
4 the paper of the various correlations between the
5 decontamination factor and the help effects or
6 economic consequences where land contamination being
7 super-linear or sub-linear. And that's discussed
8 within the report.

9 Slide 46 summarizes the PRA work that was
10 done by Amarti. Condition contamination failure
11 probability, the NRC, our SPAR models basically have
12 the limited level 2 that stop at LERF. They don't
13 look at the pool conditional contamination
14 probability.

15 So we went back to the IPE reports and
16 also we looked at the license amendment supplementals
17 submitted by industry for the integrated leak break
18 test. And generally that information shows high
19 conditional containment failure probabilities which is
20 still reflective of NUREG-1150 somewhere in the 0.7,
21 0.8, 0.9 order.

22 We also looked at insights from SAMA
23 analysis and how the SAMA analysis had or had not
24 evaluated filtered vents. As was mentioned earlier
25 today, all the past NRC analysis for filtered vents

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 have historically shown them to be not cost
2 beneficial. And that also comes out of the results
3 from the SAMA analysis.

4 Marty discusses his technical approach
5 results in uncertainty analysis which we'll get
6 additional information for you.

7 MS. GHOSH: John, this is Tina Ghosh again
8 from the Office of Research. I would just point out
9 there's a couple of tables in the Enclosure 5c that
10 explain what Marty did with respect to the uncertainty
11 for the cost consequences. Then the table -- I might
12 have a slightly older version of the enclosures but
13 100 percent sure of the table number. But in the
14 version I have there's a Table 12 called "Uncertainty
15 Distributions" where he explains for all the
16 consequence metrics what he did.

17 And then there is a figure for offsite
18 cost risk which shows essentially the error bars, the
19 point estimate mean, the 5th-95th given what he
20 assigned in the table for the uncertainty
21 distribution.

22 MEMBER STETKAR: Just to clarify things,
23 Table 12 are uncertainty distributions that primarily
24 except for the last line in it affect the split
25 fractions in terms of sequence frequencies.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 There is a line in my version of Table 12
2 that says "Consequences" under "Mean Value." It says,
3 "Per Tables X-7 and X-8." I couldn't find those. And
4 it's a log normal with an error factor of 10.

5 But I don't know what that meant. And
6 then, yes, indeed you can see uncertainty bars in the
7 final figures with things in them. But it wasn't --
8 I looked. I couldn't really find those. I'm not sure
9 what those tables X-7 and X-8 are, John.

10 MR. MONNINGER: We'll have to get that
11 information on that.

12 MEMBER STETKAR: Thank you.

13 And then as Tina mentioned, the plots at
14 the end of Marty's work, it summarizes. We look at
15 the base case going to Option 2 or Option 3 or Option
16 4. And we look at the change in the person dose and
17 the change in the offsite cost. And we quantify all
18 those and convert that into a dollar value. And you
19 look at the benefits then for your proposed
20 modification.

21 MEMBER STETKAR: John, one quick and I
22 don't want to take up too much time because I know
23 we're getting tight on time here. So rather than
24 going through specific examples, as I went through the
25 whole PRA section and looked at the numbers, I came

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 away with kind of two conclusions. And that is that
2 in some cases it seems that the model that was used
3 may have selected so-called conservative values -- It
4 might be human error probabilities. Might be
5 equipment reliabilities -- that because of the values
6 that were used effectively showed less numerical
7 benefit to event or event with a filter than if
8 perhaps more realistic or less conservative values.

9 And now I'm not talking necessarily about
10 the uncertainty analysis. I'm talking about sliding
11 that uncertainty range linearly along a scale of
12 conservativeness if you want to call it that. That
13 doesn't particularly affect your overall conclusions
14 in the SECY paper because you're making the
15 qualitative arguments.

16 The other part and I mentioned this
17 earlier is there is I believe probably an unintended
18 but there is a bias that tends to point toward a
19 passively activated filter vent versus a manually
20 activated vent.

21 And there are couple of examples that if
22 we had more time I'd kind of walk you through them.
23 But they're a little bit convoluted. It's I think
24 another sense where perhaps conservative values for
25 the purposes of SPAR models for one purpose might not

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 necessarily give you the appropriate perspective from
2 this type of application.

3 I mention the one in terms of coupling,
4 saying, that given the fact the operators successfully
5 opened the vent. Why are they not very good about
6 lining up the flooding capability. And there's at
7 least one other or two others that sort of work that
8 way.

9 MR. MONNINGER: Yes.

10 MEMBER STETKAR: There are two. That
11 doesn't affect the conclusions of the SECY paper
12 because right now the SECY paper doesn't say make it
13 passive. Make it active. Do not make it active. So
14 not seeing how the orders are going to come down, it
15 could affect that.

16 MR. MONNINGER: At risk, so my thought
17 though is if you looked at the failure we assigned of
18 0.3 for the manual venting versus 0.001 for passive
19 that's significantly a higher reliability for the
20 passive.

21 MEMBER STETKAR: It is.

22 MR. MONNINGER: But then when you looked
23 at the probability of a venting it only goes down by
24 a factor -- by 20 percent. So I would have thought to
25 me it undersells the value as opposed to oversells the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 passive venting.

2 MEMBER STETKAR: It undersells --

3 MR. MONNINGER: Because it shows that
4 there's not much of a difference in the breakdown of
5 the containment failure mode. So its venting is 47
6 percent for manual. The containment release is
7 through a filtered vent is 47 percent if it's manual.
8 And it's only 67 percent if it's passive on Table 9.

9 So you only get an increase in 20 percent
10 for the venting --

11 MEMBER STETKAR: In those absolute senses,
12 you're right.

13 MR. MONNINGER: Yes.

14 MEMBER STETKAR: There's not a big
15 absolute difference.

16 MR. MONNINGER: Right. And the reason you
17 get that is because the stuff still goes to liner
18 melt-through of 28 percent. And that's driven by the
19 0.3.

20 MEMBER STETKAR: That's driven by the 0.3
21 of not getting the water in.

22 MR. MONNINGER: Right.

23 MEMBER STETKAR: Which might be close to
24 zero. Well, not zero because the hardware.

25 MR. MONNINGER: And it would show a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 significantly greater benefit for venting and passive
2 venting.

3 MEMBER STETKAR: It would show a greater
4 benefit for venting. It might show a greater benefit
5 for manual -- less of a difference. Given the fact
6 that the difference for passive versus manual in an
7 absolute sense is not very large, they might not be
8 even that small a difference if you want to think of
9 it that way. If you looked at manual with a
10 conditional high probability of getting the water in
11 limited by whatever number you stuck in there for the
12 hardware.

13 MR. MONNINGER: And we can get back to you
14 tomorrow morning on this.

15 MEMBER STETKAR: As I said, in terms of
16 the SECY paper itself, it doesn't affect the
17 conclusions.

18 MR. MONNINGER: Right.

19 MEMBER STETKAR: You know, your
20 recommendation within the context of the SECY paper.
21 But the follow-on in terms of emphasis on manual
22 versus passive systems, actively managed systems
23 rather than passive systems, it could have a secondary
24 effect.

25 MR. MONNINGER: Whereas we could have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 tried to do some of these things more realistic or
2 best estimate. We tried to take out any type of
3 ammunition that could be used against the staff for
4 stretching the case for it.

5 MEMBER STETKAR: You know, I originally
6 thought of that.

7 MR. MONNINGER: Yes. We accepted that
8 it's not cost beneficial. We could move it up but we
9 knew it would never cross the threshold.

10 MEMBER STETKAR: Right.

11 MR. MONNINGER: So as opposed to arguments
12 back and forth just say "This is what it is. We
13 believe our qualitative arguments are significantly
14 strong."

15 MEMBER STETKAR: And in a sense,
16 numerically I agree with you. But I think that the
17 net effect of the numerical part of the PRA suppresses
18 the benefit of the vent and the filter.

19 CHAIR SCHULTZ: But it wouldn't drive the
20 conclusion.

21 MEMBER STETKAR: It wouldn't drive -- I
22 don't think it could make the number.

23 CHAIR SCHULTZ: Right.

24 MEMBER STETKAR: I don't think you could
25 cook the numbers if you will in a way that would drive

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 you at least in terms of the frequency of the event
2 scenarios. Now the uncertainty -- You know, the other
3 part of the problem that I raised earlier, the
4 uncertainties, where the mean value of the cost, the
5 economic consequences, and the assessment of the
6 uncertainties around that, could make a difference.

7 MR. MONNINGER: I think if you look at the
8 SAMDAs when they do the simplified analysis to
9 eliminate all risk it's maybe \$3 million or \$4 million
10 or so that the typical plant can spend to come up with
11 the perfect plant to eliminate all risk.

12 MEMBER STETKAR: Even that, you don't make
13 it.

14 MR. MONNINGER: Yes.

15 Slide 48, Stakeholder Interactions, we've
16 had significant public meetings, a very good input
17 from the nuclear industry, public interest groups, in
18 person and via phone. We've also had written input
19 that the staff has considered within its assessment.

20 CHAIR SCHULTZ: John, I know you've got
21 some more slides to present including some discussion
22 of ACRS comments and give and take there. I think
23 given our schedule on the meeting, I'd like to pause
24 here for the opportunity for public comment. And then
25 come back to your presentation.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And in that regard as I mentioned at the
2 beginning, we did have a request for time for oral
3 statements from Mr. Paul Gunter. And I wanted to
4 provide that opportunity first. Then we will have
5 opportunity for other members of the public who would
6 like to make comment.

7 MR. GUNTER: Paul Gunter with Beyond
8 Nuclear. And I'm going to pass.

9 CHAIR SCHULTZ: Thank you, Paul.

10 Are there other members of the public in
11 the meeting who would like to make comment in the
12 meeting room? And while we think of that, Antonio, is
13 the line open?

14 MR. DIAS: It should be open.

15 CHAIR SCHULTZ: Check on that, please.

16 Anyone else here present that would like
17 to make comments?

18 (Off the record comments.)

19 I'd like to check and see that the line is
20 open.

21 PARTICIPANT: I'm here. Can you hear me?

22 CHAIR SCHULTZ: Thank you. We can hear.

23 PARTICIPANT: Okay.

24 CHAIR SCHULTZ: And so knowing that the
25 line is open, I'd like to ask anyone on the line is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 they would like to make a comment. Please introduce
2 yourself and make a comment for the benefit of the
3 meeting.

4 (No verbal response.)

5 I hear no volunteers for comment. And
6 hearing none I'll close the public comment section of
7 the meeting. He's had an opportunity certainly.

8 And so therefore, John, we will return
9 back to your presentation. Thank you very much.

10 **MR. MONNINGER**: So it was a very good,
11 dynamic stakeholder engagement, a lot of interested
12 parties out there.

13 Slide 49, Enclosure 7, the draft orders
14 which the ACRS does not have a copy of. Some of the
15 considerations is the proposed implementation date.
16 The current order out there requires industry to
17 provide an integrated plan by February 2013 and then
18 full implementation of the reliable hard vent by EA-
19 12-050 by two refueling outages or December 31, 2016.
20 So we are currently looking at assessing that
21 implementation date. If we were to go with option B
22 or option 2, the sealed accident capable vent, is that
23 still a realistic schedule? If we were recommend
24 option 3, a filter vent, or if we were to recommend
25 option 4, the performance-based approach with option

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 2 tagged in there.

2 Some of the things we're looking at is the
3 implementation date. We would propose similar to the
4 other orders to provide high level technical
5 requirements. Followed that up with a series of
6 meetings with stakeholders to develop a guidance
7 document that would be endorsed.

8 CHAIR SCHULTZ: From what you just
9 described, John, you indicated that you were going to
10 provide some element of schedule expectation for each
11 of the options or focusing on two and three?

12 MR. MONNINGER: We have some --

13 MR. DENNIG: We have draft orders for all
14 of them.

15 MR. MONNINGER: Yes, we would just have
16 draft orders for two and three. And then four would
17 be a potential rulemaking. And what we talk in there
18 is that rulemakings, especially performance-based, the
19 time frames are typically pretty significant. So we
20 think it would definitely have an impact on the 2016
21 date for any rulemaking for the performance-based
22 approach.

23 The filter vent was tied to the reliable
24 hard vent. Both of these issues are Tier 1 issues
25 which the Commission has established an expectation of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 completion by December 31, 2016.

2 With that said, we do recognize that any
3 potential order, be it recommendation two or three,
4 would be one year after the first order. Does it make
5 -- Is there logic there to keep the current schedule
6 or is there logic there to provide some amount of
7 additional time?

8 CHAIR SCHULTZ: Thank you.

9 MR. MONNINGER: The bigger factor of
10 course would be the filter vent. It could be a
11 significant plant modification.

12 Slide 50, some previous ACRS questions
13 that we had. There were questions about the particle
14 removal capabilities be it for the filter vents or for
15 suppression pools or sprays. The particle sizes,
16 there's a distribution of sizes. There is I guess a
17 zone in there which historically researchers have
18 identified difficulties in removing particles of that
19 particular size. More recently, the presentations and
20 the discussions that we've have with the various
21 vendors out there of filters, they discuss this issue.
22 And they discuss testing for these difficult-to-
23 capture particles.

24 We believe it's a known issue out there.
25 It's not just for the filters. It's for the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 suppression pool. It's for the sprays, etc. And they
2 are explicitly trying to address this issue.

3 MR. DENNIG: Yes, I think the way I
4 understand it is if you have a really good performance
5 from a pool and you've alter the spectrum of
6 particles, what gets to a filter is then a
7 distribution at the lower end and much more difficult
8 to move. So the size-specific efficiency of filter
9 you would expect to not be so good.

10 It's premised on the pool doing something
11 in the first place to change that spectrum. But in
12 the discussions we've had, the efficiency for the sub-
13 micron particles are not 100 percent or 99.9, but
14 they're high. They're represented as being high in
15 that there are test results that demonstrate that.

16 And as John said, the rationale for
17 pursuing Venturi scrubbing was for sub-micron
18 particle, for efficient removal of sub-micron
19 particles.

20 And there is this three levels within the
21 wet scrubbing system. There's this larger portion of
22 it with the Venturi and then there's the cool portion
23 of it and then there's the metallic fiber portion of
24 it. And those are given different DFs for different
25 size particles. I don't know how that adds up.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIR SCHULTZ: It seems to me that that
2 adds up to a pretty complication specification is one
3 were to sit down and write it for a number of plants
4 that are designed differently and have different
5 capabilities and essentially with regard to severe
6 accident mitigation. But that's just a quick view.

7 MR. DENNIG: I think we were to
8 concentrate --

9 CHAIR SCHULTZ: But it sounds very
10 complicated.

11 MR. DENNIG: -- on cesium and iodine that
12 gives us an idea of the particle sizes.

13 CHAIR SCHULTZ: Yes.

14 MR. DENNIG: And we can look at testing
15 for that distribution of particle size to see if there
16 is a significant roll-off in the DF. Usually, cesium
17 distribution is, the average is 1.0 to 1.5 microns.
18 And it's a log linear distribution that's input. And
19 we know about this issue. But we believe it's been
20 addressed and we would follow up to look at the
21 testing to make sure that that is the case.

22 CHAIR SCHULTZ: Okay. I guess the other
23 way I could phrase my feeling based on what I heard
24 you say is that you just described a research program
25 and that research program might take a long time to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 do. And it didn't match up with John's schedule.

2 MR. DENNIG: What I'm saying is that I
3 think the research program has been completed.

4 CHAIR SCHULTZ: Okay.

5 MR. DENNIG: Basically over the last 30
6 years. And it's a matter of auditing that material to
7 make sure that the representations and the statistics
8 and the slides and the discussions we've had are
9 verifiable in the test data.

10 CHAIR SCHULTZ: I appreciate that. Thank
11 you.

12 MR. MONNINGER: Slide 51. The results.
13 A question that was raised regarding the impact of
14 noble gases on site operations. This issue was raised
15 in connection with the staff's statements that there
16 may be a higher level of confidence or I won't say a
17 higher frequency of venting. But if the operators
18 believe that they have a good system they may be more
19 likely to use it.

20 If that then is the case, what is the
21 impact on site operations, personnel within a control
22 room, etc. from noble gases and, in particular,
23 heavier-than-air noble gases?

24 We engaged our Radiological Protection
25 branch and basically said, "It's a big function of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 weather." Traditionally, where these releases were to
2 occur at the top of the stack, the wind velocities,
3 the stabilities, etc., a typical release would have
4 little to no impact from typical meteorological
5 conditions.

6 Where it could potentially have an impact
7 would be for the unstable, the inversion I guess, of
8 weather, wherein the release would be a push down onto
9 the site. Given the control room, suite of buildings,
10 etc., the staff thought that there would be shielding
11 available to the operators and a rough level
12 assessment we didn't believe that it would exceed the
13 regulatory dose limits for an exposure.

14 MR. DENNIG: But, John, so the worst-case
15 weather conditions, he didn't expect that they would
16 exceed the 25 in a lifetime.

17 MR. MONNINGER: Lifetime.

18 MR. DENNIG: And that was just thinking
19 based on some rough calculations and his experience.

20 MR. MONNINGER: Can I go back to the small
21 particle thing? Another way to think about it is if
22 you have a vent on a wet well and you get zip. You
23 get nothing from the wet well. So the spectrum going
24 to the filter is unchanged from the release spectrum.

25 And I don't think there's any argument

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 about the filter doing 1,000 or greater DF on that
2 spectrum.

3 If you put that in series with a wet well
4 and argue that you've gotten a really good scrub on
5 larger sized particles from the wet well so that what
6 goes to the external filter has gone through a window
7 so to speak. And it's a lot smaller or highly
8 penetrating than you would expect. You can argue that
9 you're going to get less than 1,000. If you think the
10 thing can be 2,000, you're going to get less than
11 2,000.

12 The way it was modeled, the way we modeled
13 it, was to give it a 10. So we haven't represented
14 the ability of the external filter in a way that is
15 inconsistent with the idea that sub-micron particles
16 are harder to stop.

17 CHAIR SCHULTZ: That's correct. I
18 understand that. Thank you.

19 MR. MONNINGER: The last slide.

20 MEMBER RYAN: Jerry, just one quick
21 question out of curiosity. Did you do any re-
22 entrainment from filters over a long use period
23 particularly employing the real small particles?

24 MR. BETTLE: The designs that have that
25 metal fiber filters on the top.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. DENNIG: Do you mean within the filter
2 itself?

3 MEMBER RYAN: And eventually out the back
4 end, yes.

5 MR. BETTLE: They either have a droplet
6 separator or a filter metal fiber at the top to catch
7 anything that bubble up from very small droplets to
8 come up. They're supposed to capture essentially
9 everything like just dry steam or gas coming up.

10 MEMBER RYAN: Thank you.

11 MR. MONNINGER: In conclusion, the staff
12 believes that the combination of quantitative and
13 qualitative factors best supports the installation of
14 filter venting for Mark I and Mark II. That's option
15 3. Preponderance of that evidence or preponderance of
16 the staff's argument is the qualitative defense-in-
17 depth argument and the notion to have a system that is
18 independent of the existing weaknesses within the
19 containment design.

20 The other thing I'll mention is if you do
21 look at the guidance within NUREG-0058, it talks about
22 the need to consider qualitative factors and in
23 particular when addressing containment performance or
24 when addressing issues associated with late
25 containment failure.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So what the staff did do here, any
2 consideration of the qualitative is consistent with
3 our finding. It's not --

4 MEMBER RYAN: You ought to take that off
5 your microphone.

6 MR. MONNINGER: Yes. It's not done
7 frequently, but it is within our guidance that is out
8 there. And that concludes the staff's presentation.

9 CHAIR SCHULTZ: First, any general
10 questions over the last portion here that someone has
11 not had an opportunity to ask?

12 MEMBER ARMIJO: Just a comment on some of
13 these enclosures. I think enclosure 5C and I think B.
14 There are some very nice colored pie charts, but there
15 is no scales. You kind of have to decipher what
16 Marty's -- I believe those are Marty's reports. I'm
17 not sure.

18 MR. MONNINGER: We can look at that.

19 MEMBER ARMIJO: Maybe you have some with
20 scales and numbers.

21 MR. MONNINGER: We can look at that this
22 evening.

23 MEMBER ARMIJO: Yes. That's what we got
24 in the packet.

25 CHAIR SCHULTZ: With that then, I'd like

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 to go around the room and ask the members for
2 particular comments they might have with regard to the
3 presentations we've heard this afternoon, knowing that
4 we will have an opportunity to do this again in short
5 form tomorrow.

6 But, Dick, any comments you'd like to
7 present?

8 MEMBER SKILLMAN: I thank you for the
9 thoroughness of this presentation. I would like to
10 express a concern. And the concern is that the staff
11 has concluded that a hardware fix is the right fix.
12 And if I go back to my history after the TMI2 accident
13 at TMI2 with the NRC we spent probably one to two
14 years battling over what should be the quality level,
15 the fabrication requirements, the welding
16 requirements, the NED requirements.

17 When you choose to write an order, please
18 ensure that you've packaged the requirements with that
19 order so industry is not left to fight among itself or
20 with you over what you really intend. For instance,
21 you might require this to be Appendix B in containment
22 quality which makes it at least quality group C,
23 probably B. Or you might say robust industrial
24 standards with QA requirements only for the
25 containment portion that's not isolated that's within

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the containment boundary.

2 But the specificity of the hardware
3 accompanying order will at least give industry a
4 target to begin with. Absent that, I believe that
5 this will go into freefall.

6 Mr. Chairman, thank you.

7 CHAIR SCHULTZ: Sam?

8 MEMBER ARMIJO: No, I'll just comment
9 after.

10 CHAIR SCHULTZ: John.

11 MEMBER STETKAR: Nothing. Thanks for a
12 very good, thorough presentation. Nothing else.

13 MEMBER RYAN: I second John's comment.
14 Thank you.

15 MEMBER SHACK: No comment.

16 CHAIR SCHULTZ: Charlie.

17 MEMBER BROWN: No comment.

18 MEMBER REMPE: No comment. Very good.

19 MEMBER CORRADINI: Not yet.

20 CHAIR SCHULTZ: John will have an
21 opportunity to sleep on this one.

22 MEMBER ARMIJO: Come back tomorrow.

23 CHAIR SCHULTZ: And we did have some
24 bring-backs associated with the discussion today.

25 MR. MONNINGER: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIR SCHULTZ: Because of the weather
2 we've had a few members unable to be here this
3 afternoon who I know wanted to be here and they will
4 be here tomorrow. I would suggest that knowing the
5 time is shorter that you go through the presentation
6 and focus on those areas that you feel are most
7 important to the case that you've presented today.

8 I think that our discussion ought to focus
9 on the qualitative arguments knowing that the
10 quantitative analysis has been done, but is not the
11 key feature upon which you based your recommendation.
12 So I would like to see that come through again and it
13 is in those areas that we've raised some questions for
14 responses from you tomorrow.

15 With that, I also want to thank each of
16 you for the discussions that you've presented today.
17 In spite of the shortness of time you've had to
18 prepare it, given the weather, it's been quite a very
19 well organized and insightful presentation that you've
20 made. And I appreciate that very much. On behalf of
21 the Committee, I thank you.

22 And we'll see you again tomorrow. I would
23 hope that you would all be here again tomorrow because
24 I think you've all contributed to the discussion.
25 Thank you very much.

1 MR. MONNINGER: Thank you.

2 CHAIR SCHULTZ: Off the record.

3 (Whereupon, at 5:15 p.m., the above
4 entitled matter was concluded.)

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

Containment Filtering –Industry Perspective–

Fukushima Subcommittee
Advisory Committee on Reactor Safeguards
October 31, 2012

Industry Position

- BWR Mark I and II should have capability to use various containment filtering strategies to mitigate releases and land contamination during core damage events.
- Performance-based strategies founded on scientific and factual analysis
- Comprehensive approach that ensures containment and filtering for extreme core damage events.

Context

- Beyond design basis events
- Extremely low chance of needing filtering
- Reliable hardened vents provide heat removal path to prevent containment overpressure
- Filtering strategies reduce the impact of potential containment releases in the event of core damage
- Previous NRC evaluations of containment filters
- Use of qualitative factors and extreme scenarios

Ensuring Very Low-Frequency of Release

- Protecting facilities from extreme natural phenomena
- Preventing fuel damage through design-basis measures
- Preventing fuel damage through beyond-design-basis measures
- Arresting the accident progression
- Minimizing radionuclide release by retaining in containment

NRC Staff Regulatory Analysis Demonstrates
Addition of Filters is not Justifiable

Important Insights from EPRI and NRC Evaluations

- All filtering strategies (with or without external filters) rely on operator action to cool the core debris to be effective
 - Filtering strategies and external filters require same conditions to be effective
- Maintain containment integrity
 - Active debris cooling
 - Containment vent cycling
- Water injection into containment filters potential releases
 - Water spray and flood filter airborne aerosols
 - Cycling of vent maximizes aerosol capture and manages hydrogen
- Decontamination factor greater than 1000 achievable
 - Common international requirement

Industry Recommendation and Impact on Plants

- Individual plant evaluations determine strategy
 - Performance basis required
- Plant modifications may be needed
 - Ensure severe event spray and/or flood
 - Wetwell and drywell vents required
 - FLEX capability enhanced
 - SAMGs enhanced
 - Mark II pedestal drains require protection
 - Possible additional filters needed on plant specific basis (more research needed)
- Encourage innovation; vendor response

Industry Next Steps

- Perform a table top pilot to:
 - Investigate practicalities of plant-specific implementation of filtering strategies:
 - Required design changes
 - Procedural/SAMG enhancements
 - Containment vent filter considerations
 - Develop example plant-specific performance-based assessment of filtering strategies
 - Overall containment system DF for representative plant-specific scenarios


BACKUP SLIDES

Containment Filtering Strategies for BWR Mark I and II Plants

- Filtering strategies have been developed through an initiative to provide the best, safest and most comprehensive methods to mitigate land contaminating releases from BWR Mark I and Mark II containments during severe events with a damaged core.
- The findings were released by the Electric Power Research Institute on Sept. 25, 2012, in a comprehensive technical report.
- The findings demonstrate that substantial decontamination factors for releases can be achieved by a comprehensive strategy that includes operator actions, installed equipment, and FLEX.


BWR Mark I Results

(EPRI 1026539)




BWR Mark II Results

(EPRI 1026539)




Filtering Strategies Scenario Classification Event Tree



Failure Modes and Effects Analysis of Enhanced SAMG Capability

Functional Failure Mode	Failure Cause Leading to Core Damage	Effect on Enhanced SAMG Capability	Failure Cause Prevents Enhanced SAMG?	Relevant FLEX Provisions (NEI 12-06)
Early Core Cooling Fails	RCIC fails to operate until FLEX can be deployed	None	NO	---
	DC control power lost	None	NO	Capability to manually initiate RCIC required
	RCIC water source unavailable	None	NO	Essentially indefinite supply of water required.
	RPV instrumentation inadequate	None	NO	Reference source required for all available sources for required parameters
	Substantial LOCA occurs	None	NO	---
FLEX Deployment Ineffective	Operators do not diagnose need for FLEX	None	NO	FLEX interfaced with EOPs. Training and drill requirements
	Operators fail to deploy in a timely manner	None	NO	Training and drill requirements
	Difficulties transporting equipment	Could delay implementation	YES	Transport and debris removal equipment required
	FLEX deployment precluded by initiating event	Unavailable	YES	---
	SRVs fail to open to depressurize RPV	None	NO	---
	RPV injection paths impaired	None	NO	Primary and alternate injection path required
	Containment pressure instrumentation inadequate	Degraded capability. SAMG should address actions without instrumentation.	DEGRADED	Reference source required for all available sources for required parameters
	Wetwell vent fails to open	Wetwell vent required for SAMG	YES	EA 12-050 requirements
FLEX Equipment Failures	FLEX pump(s) fail to start	Degrades or fails enhanced SAMG	YES	N+1 pumps provided
	FLEX pump(s) fail to operate long-term	Degrades or fails enhanced SAMG	YES	N+1 pumps provided
	Essential supplies not replenished (e.g., fuel, water, etc.)	Long-term loss of enhanced SAMG	DEGRADED	Regional response center provides short-term and long-term supplies
	FLEX hoses fail	None. Separate hoses provided.	NO	---

Performance Basis Decontamination Factor (DF)



CONSIDERATION OF ADDITIONAL REQUIREMENTS FOR CONTAINMENT VENTING SYSTEMS FOR BWRs WITH MARK I AND MARK II CONTAINMENTS

ACRS Subcommittee Meeting
October 31, 2012

Purpose

- To discuss the staff's draft Commission paper and proposed recommendations on imposing new requirements related to containment venting systems for boiling water reactors with Mark I and Mark II containments

Agenda

- Taskings
- Schedule update
- Discussion of draft SECY paper and proposed recommendation

Tasking (1)

- SRM on SECY-11-0137, “Prioritization of Recommended Actions to be Taken in Response to Fukushima Lessons Learned”
 - The staff should quickly shift the issue of “Filtration of Containment Vents” from the “additional issues” category and merge it with the Tier 1 issue of hardened vents for Mark I and Mark II containments such that the analysis and interaction with stakeholders needed to inform a decision on whether filtered vents should be required can be performed concurrently with the development of the technical bases, acceptance criteria, and design expectations for reliable hardened vents

Tasking (2)

- SRM from August 7, 2012 Commission Meeting on status of actions taken in response to lessons learned from the Fukushima Dai-ichi accident
 - In the forthcoming notation vote paper on filtered vents, the staff should include a discussion of accident sequences where the filters are and are not beneficial

Schedule

- **Current Schedule**
 - November 30 SECY Paper to Commission
 - November 20 SECY Paper to EDO
 - ACRS Interactions
 - November 1 Full Committee mtg
 - October 31 Subcommittee mtg
 - October 26 Draft Rev. 2 Commission Paper
 - October 19 Draft Rev. 1 Commission Paper
 - October Subcommittee mtg
 - September Subcommittee mtg
 - June Subcommittee mtg

Draft Paper Outline

- SECY Main Paper and Enclosures
 1. Evaluation of Options
 2. Design and Regulatory History
 3. Foreign Experience
 4. BWR Mark I & II Containment Performance During Severe Accidents
 5. Technical Analyses (MELCOR/MACCS/PRA)
 6. Stakeholder Interactions
 7. Draft Orders

Main Paper

- Discuss issues associated with severe accident containment venting and relevance to Mark I and II containments
- Identify potential options
- Basis for staff's recommendation
- Discuss role of quantitative analysis and qualitative analysis
- Provide concise writeups referencing enclosures for details

Options Considered

1. No change (EA-12-050)
2. Severe accident capable vent
3. Filtered vent
4. Performance-based approach

Proposed Recommendation

- Option 3 – Filtered Vent
 - The NRC staff finds that the combination of quantitative and qualitative factors best supports the installation of filtered venting systems at BWRs with Mark I and II containments

Basis for Proposed Recommendation

- Cost-justified substantial safety enhancement
 - Quantitative analysis
 - Qualitative analysis
 - Enhances defense-in-depth (containment vulnerabilities and severe accident uncertainties)
 - Filter provides a fission product retention capability independent of plant accident response

Enclosure 1


Evaluation of Options

- Summary of considerations in decision-making
- Consideration of adequate protection
- Decision on substantial safety enhancement
- Inclusion of qualitative arguments
- Presentation of results including sensitivity analysis

Cost-Benefit Analysis

Quantitative Cost/Benefit Analysis Per Plant				
	Severe Accident Capable		Filtered	
Total Costs (\$k)	(2,027) ¹		(16,127)	
Core Damage Frequency	2x10 ⁻⁵ /yr	2x10 ⁻⁴ /yr	2x10 ⁻⁵ /yr	2x10 ⁻⁴ /yr
Total Benefits (\$k)	938	9,380	1,648	16,480
Net Value (Benefits – Costs)	(1,089)	+7,353	(14,479)	+353
<p>(¹) As discussed in Enclosures 1 and 4, the costs for severe accident capable vents for Mark II containment designs will likely be higher. The higher cost reflects the likely need to modify the containments to prevent molten core debris in the lower drywell sump drain lines from causing a bypass of the suppression pool. Avoidance of wetwell bypass is needed to make the severe accident capable vents a viable option for the Mark II containment design.</p>				

Break Even Cost/Benefit Considerations



Qualitative Arguments

- Providing defense in depth
- Addressing significant uncertainties
- International experience and practices
- Supporting severe accident management and response
- Improving Emergency Preparedness
- Hydrogen control
- Severe Accident Policy Statement
- Independence of barriers
- Consistency between reactor technologies
- External events
- Multi-unit events

Enhances Defense-in-Depth

- Containment is an essential element of defense-in-depth
- Addresses high conditional containment failure probability
- Filtering compensates for the loss of the containment barrier due to venting
- Filtering improves confidence to depressurize containment to address other severe accident challenges

Uncertainties

- Uncertainties in prevention and mitigation of severe accidents
 - Event frequency
 - Severe accident progression
 - Radiological consequences
 - Economic consequences

International Practices

- Extraordinary Meeting of Members of Convention on Nuclear Safety recommended “measures to ensure containment integrity, and filtration strategies and hydrogen management for the containment”
- Consistent with decisions of most European countries, Canada, Taiwan, and Japan

Severe Accident Management Decision Making

- Each option enhances the management of the accident by allowing operators to focus on recovery actions other than preventing gross containment failure
- Each proposed option provides some benefit but filtered systems are the simplest
- A performance-based approach could be integrated into other severe accident management activities and procedures

Emergency Planning

- The most benefit in terms of reducing the demands on emergency planning would be associated with Option 3 (filter) while the proposed change with the least benefit would be from Option 2 (unfiltered venting)

Hydrogen

- Improves operator confidence in a “clean” release for hydrogen control
 - Allows early operator intervention to vent hydrogen and control containment pressure
 - Sustained lower pressure reduces leakage of hydrogen thru penetration seals
 - Decreased leakage reduces threat from hydrogen explosion to reactor building, spent fuel pool, and emergency responders

Severe Accident Policy Statement

- The Severe Accident Policy Statement specifies that severe accident design features could be imposed on operating reactors using the established backfit process
- The importance of the qualitative factors suggests a need to revisit portions of the current regulatory framework (including the Severe Accident Policy Statement)
- The status quo option fits the current policy statement and its traditional application

Independence of Barriers

- Minimize dependencies and address the high conditional failure probability of Mark I and Mark II containments following a compromise of the preceding barriers (fuel and coolant system)
- The filtered system would provide the most independence while the unfiltered vent could result in large releases in the attempts to reduce containment overpressure conditions

Consistency Between Reactor Technologies

- While the proposed improvements to venting systems for BWRs with Mark I and II containments address a known weakness in the severe accident performance for those plants, the pursuit of these improvements without resolving broader issues (e.g., NTTF Recommendation 1 and Severe Accident Policy Statement) introduces the possibility for inconsistent treatment of severe accident capabilities for the various reactor technologies

External Events

- Beyond design basis external events such as the 2011 earthquake and tsunami will challenge normal and emergency power and cooling systems at a nuclear power plant
- There is a significant advantage to having installed equipment and/or strategies in place to address such events and conditions and thereby avoid the nuclear power plant compounding the consequences from the event

Multi-unit Events

- A concern highlighted by the Fukushima accident is conditions or events (e.g., external hazards) which challenge multiple units at a nuclear facility
- There is a significant advantage to having installed equipment and/or strategies in place to address such multi-unit events

Enclosure 2

Design and Regulatory History

- Summarize the licensing and design considerations for Mark I and Mark II containments
- Why are Mark I and Mark II containments being discussed?
 - Ability of designs to withstand severe accident challenges
 - Defense in depth
 - Residual risk

Enclosure 2

Design and Regulatory History

- Mark I Containments
 - WASH-1400 & NUREG-1150 found that Mark I containments could be severely challenged if a severe accident occurred
 - Relatively small volume
 - Gas and steam buildup affect pressure more dramatically
 - BWR cores have ~3 times the quantity of zirconium as PWRs
 - Potential for hydrogen gas and containment pressurization

Enclosure 2

Design and Regulatory History

- Mark II Containments
 - Similar to Mark I, the most challenging severe accident sequences are station blackout and anticipated transients without scram
 - Risk profile dominated by early failure with a release that bypasses the suppression pool
 - Hardened venting was considered not beneficial because of unacceptable offsite consequences without an external filter like MVSS
 - Staff did not recommend generic backfit of hardened vent, but recommended a comprehensive evaluation as part of the IPE program

Enclosure 2

Design and Regulatory History

- Mark I Containments
 - Containment Performance Improvement Program
 - Determine what actions, if any, should be taken to reduce the vulnerability to severe accidents
 - Staff recommended
 - Improve hardened vent
 - Improve RPV depressurization system
 - Provide alternate water supply to RPV and drywell sprays
 - Improve emergency procedures and training
 - Commission approved hardened vent
 - Other recommendations evaluated as part of IPE program

Enclosure 3

Foreign Experience

- Status of filtered vents and regulatory basis in other countries
- Identify basis for pursuing filtered vents
- Identify any operational experience or adverse systems interactions

Enclosure 3

Foreign Experience

- Staff visited Sweden, Switzerland, and Canada
- Insights from visits and public meetings consistent with previous findings
 - 1988 CSNI Report 156, Specialists' Meeting on Filtered Containment Venting Systems
- Together, FCVS and containment flooding scrub fission products from core debris and remove decay heat

Enclosure 3

Foreign Experience

- Technical Bases Summary
 - Manage severe accident overpressure challenges
 - Defense-in-depth to address uncertainties associated with severe accidents
 - Significantly reduce offsite release
- After Barsebäck filter was installed, subsequent filter costs considered low to modest

Enclosure 3

Foreign Experience

- Quantitative Bases Summary
 - Release performance goal
 - Risk informed
 - Level 1 frequencies low but not sufficient
 - After the decision, ensure equipment performance is acceptable generically and on plant-specific basis
 - Acceptable not judged quantitatively – “significantly reduce”, “almost eliminate”, etc.
 - Factored into emergency planning

Enclosure 3

Foreign Experience

FCVS Status at Non-U.S. BWR Facilities

FCVS Status	GE Mark I	GE Mark II	ABB Mark II	GE Mark III	Other	ABWR	Totals	
FCVS Operational	1	0	6	1	5	0	13	30%
Committed	6	7	0	5	4	3	25	57%
Considering	1	0	0	1	0	0	2	5%
No FCVS	2	2	0	0	0	0	4	9%
Non-U.S. Totals	10	9	6	7	9	3	44	

Enclosure 4

Mark I & II Severe Accident Performance

- Containment Spray Systems
- Containment Flooding
- Containment Venting
- Decontamination by Drywell Spray
- Decontamination by the Wetwell
- Mark I Containments
- Mark II Containments
- Decontamination by External Engineered Filter Systems
- EPRI Evaluation of Severe Accident Venting Strategies for Mitigation of Radiological Releases
- Passive Containment Vent Actuation Capability
- Early Venting

Enclosure 4

Mark I & II Severe Accident Performance

- EOPs, SAMGs, and EDMGs describe multiple containment vent pathways and use of portable pumps for reactor and drywell injection with focus on preventing core damage

Enclosure 4

Mark I & II Severe Accident Performance


- DW Sprays for Decontamination
 - Spray headers designed for DBA purposes (pressure control and heat removal) with flow rates of 1,000's GPM
 - Portable pumps with flow rates in low 100's GPM which is good for cavity flooding and not as effective for decontamination

Enclosure 4

Mark I & II Severe Accident Performance

- **Suppression Pool for Decontamination**
 - SRV discharge via T-quencher in bottom of subcooled suppression pool
 - Downcomer pipes which discharge higher in the suppression pool at or near saturation temperatures

Decontamination Factors



**FIGURE 1: Uncertainty Distributions for Cesium Decontamination Factors (DFs)
Mark I Containment – Peach Bottom**

Source: "Assessment of In-Containment Aerosol Removal Mechanisms."
BNL Technical Report L-1535, 1992

Enclosure 4

Mark I & II Severe Accident Performance

- EPRI Investigation of Strategies for Mitigating Radiological Releases in Severe Accidents
 - Employs a portable pump to flood drywell cavity and maintain suppression pool subcooling
 - Controls containment pressure near design value for holdup, settling, plate-out, spray effect, and high velocity discharge into suppression pool
 - Cycles containment vent valves to maintain containment pressure band (substantial reliance on instrumentation, valves/actuators, and operator actions)
 - Swap-over from WW to DW vent after 20 hours as containment floods up

Enclosure 5a

MELCOR

- Based on SOARCA MELCOR modeling
- Accident sequences
 - Informed by SOARCA and Fukushima
 - Long-term SBO (base case 16 hr RCIC)
- Mitigation actions
 - B.5.b and/or FLEX provide core spray or drywell spray (300 gpm)
 - Containment venting
- Sensitivity analysis
 - Spray flow rate and timing, wetwell versus drywell venting, and RCIC duration

Insights from MELCOR

Calculations

- Water on the drywell floor is needed to prevent liner melt-through
 - Also scrubs fission products and reduces drywell temperature
- Venting prevents over-pressurization failure
 - Wetwell venting is preferable to drywell venting
- Need combination of venting and drywell flooding
 - More reduction in fission product release
 - Maintain reactor building integrity

Enclosure 5b

MACCS2

- Offsite population doses, including doses to off-site decontamination workers
- Individual latent cancer fatality risk and prompt fatality risk
- Land contamination
- For different thresholds of Cs-137 concentration in soil (Ci/km²)
- Economic costs

Insights from MACCS2 Calculations

- The health effect of interest is latent cancer fatality risk, which is controlled in part by the habitability (return) criterion
 - Essentially no prompt fatality risk
- In terms of long-term radiation, the most important isotope is Cs-137, and most of the doses are from ground shine
- There is a non-linear relationship between decontamination factor and both land contamination area, health effects, and economic consequences

Enclosure 5c

PRA

- Conditional containment failure probability
- Insights from Severe Accident Mitigation Alternatives (SAMA) Analyses
- Technical approach
- Results
- Uncertainties

Enclosure 5c

PRA

- To estimate the risk reduction resulting from installation of a severe accident containment vent for use in regulatory analysis
 - 50-mile population dose (Δ person-rem/ry)
 - 50-mile offsite cost (Δ \$/ry)
 - Onsite worker dose risk (Δ person-rem/ry)
 - Onsite cost risk (Δ \$/ry)
 - Land contamination (Δ conditional contaminated land area)

Enclosure 6

Stakeholder Interactions

- Numerous public meetings
- Stakeholder input and presentations
 - Filter vendors
 - Public interest groups
 - Regulated industry

Enclosure 7

Draft Orders

- Considerations
 - Assessing proposed implementation date
 - Provide high level technical requirements
 - Detailed guidance document to be developed with consideration of stakeholder input

Previous ACRS Questions

- Uncertainties on particle removal capabilities
 - Discussed in Enclosures 4 and 5a
 - Particle removal efficiency is dependent upon various parameters including particle size
 - Submicron particles are difficult to remove
 - Uncertainty in particle size distribution given an accident

Previous ACRS Questions

- Impact of noble gases on site operations
 - Elevated release with stable meteorological conditions have a relatively low impact
 - Elevated release with unstable meteorological conditions (i.e., plume washdown to site) would have greater impact
 - Shielded locations should limit doses to regulatory limits

Conclusions

- The NRC staff finds that the combination of quantitative and qualitative factors best supports the installation of filtered venting systems at BWRs with Mark I and II containments (Option 3)