



Tennessee Valley Authority, 1101 Market Street, Chattanooga, Tennessee 37402

April 30, 2013

10 CFR 50.4  
10 CFR 50.36a

ATTN: Document Control Desk  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555-0001

Browns Ferry Nuclear Plant, Units 1, 2, and 3  
Facility Operating License Nos. DPR-33, DPR-52, and DPR-68  
NRC Docket Nos. 50-259, 50-260, and 50-296

Subject: 2012 Annual Radioactive Effluent Release Report

In accordance with the Browns Ferry Nuclear Plant (BFN), Units 1, 2, and 3, Technical Specification Section 5.6.3, the Tennessee Valley Authority is submitting the BFN Annual Radioactive Effluent Release Report for the period January through December 2012. This document is in conformance with Title 10 of the Code of Federal Regulations (10 CFR) 50.36a and 10 CFR Part 50, Appendix I Section IV.B.1.

Attachment 1 to the Enclosure documents deviations which have occurred from Offsite Dose Calculation Manual (ODCM) controls and surveillance requirements. Attachment 2 to the Enclosure provides information on radiological effluent instrumentation inoperable for greater than 30 days. There were no revisions to the ODCM during 2012.

There are no new regulatory commitments contained in this letter. Should you have any questions concerning this submittal, please contact Tom Hess, at (423) 751-3487.

Respectfully,

J. W. Shea  
Vice President, Nuclear Licensing

Enclosure: 2012 Annual Radioactive Effluent Release Report

cc (w/ Enclosure):

NRC Regional Administrator - Region II  
NRC Senior Resident Inspector - Browns Ferry Nuclear Plant

IE48  
NRR

**ENCLOSURE**

**Browns Ferry Nuclear Plant  
Units 1, 2, and 3**

**2012 Annual Radioactive Effluent Release Report**

---

**See Enclosed**

**2012  
BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

**TABLE OF CONTENTS**

<b><u>Section Title</u></b>	<b><u>Page Number</u></b>
Supplemental Information	E-3 — E-10
Gaseous Effluents	E-11 — E-19
Liquid Effluents	E-20 — E-24
Solid Waste	E-25 — E-31
Radiological Impact	E-32 — E-47
Meteorological Data	E-48 — E-171
Attachment 1 (Deviations)	E-172
Attachment 2 (Inoperable Instrumentation)	E-173

<b><u>Tables</u></b>	<b><u>Page Number</u></b>
Table 1A, Gaseous Effluents - Summation of All Releases	E-11 — E-12
Table 1B, Gaseous Effluents - Elevated Releases	E-13 — E-14
Table 1C, Gaseous Effluents - Ground Level Releases	E-15 — E-16
Table 1D, Gaseous Effluents - Mixed Mode Releases	E-17 — E-19
Table 2A, Liquid Effluents - Summation of All Releases	E-20 — E-21
Table 2B, Liquid Effluents	E-22 — E-24
Table 3, Solid Waste and Irradiated Fuel Shipments	E-25 — E-31
Table 4, Radiological Impact, Doses from Airborne Effluents	E-39 — E-42
Table 5, Radiological Impact, Doses from Liquid Effluents	E-43 — E-46
Table 6, Radiological Impact, Total Dose from Fuel Cycle	E-47
Table 7A, Meteorological Data, Joint Frequency Distribution Ground Level Releases, First Quarter	E-48 — E-55
Table 7B, Meteorological Data, Joint Frequency Distribution Ground Level Releases, Second Quarter	E-56 — E-63

**2012**  
**BROWNS FERRY NUCLEAR PLANT**  
**UNITS 1, 2, AND 3**  
**EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

**TABLE OF CONTENTS**

<u>Tables</u>	<u>Page Number</u>
Table 7C, Meteorological Data, Joint Frequency Distribution Ground Level Releases, Third Quarter	E-64 — E-71
Table 7D, Meteorological Data, Joint Frequency Distribution Ground Level Releases, Fourth Quarter	E-72 — E-79
Table 8A, Meteorological Data, Joint Frequency Distribution Split Level Releases, First Quarter	E-80 — E-94
Table 8B, Meteorological Data, Joint Frequency Distribution Split Level Releases, Second Quarter	E-95 — E-109
Table 8C, Meteorological Data, Joint Frequency Distribution Split Level Releases, Third Quarter	E-110 — E-124
Table 8D. Meteorological Data, Joint Frequency Distribution Split Level Releases, Fourth Quarter	E-125 — E-139
Table 9A, Meteorological Data, Joint Frequency Distribution Elevated Releases, First Quarter	E-140 — E-147
Table 9B, Meteorological Data, Joint Frequency Distribution Elevated Level Releases, Second Quarter	E-148 — E-155
Table 9C, Meteorological Data, Joint Frequency Distribution Elevated Level Releases, Third Quarter	E-156 — E-163
Table 9D, Meteorological Data, Joint Frequency Distribution Elevated Level Releases, Fourth Quarter	E-164 — E-171

2012  
**BROWNS FERRY NUCLEAR PLANT**  
**UNITS 1, 2, AND 3**  
**EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

**SUPPLEMENTAL INFORMATION**

**1. Regulatory and BFN ODCM Limits**

a. **Fission and Activation Gases in Gaseous Effluent:**

The release of fission and activation gases is regulated by the dose limits of Title 10 of the Code of Federal Regulations (10 CFR) 50 Appendix I and Browns Ferry Nuclear Plant (BFN) Offsite Dose Calculation Manual (ODCM). The air dose to areas at and beyond the site boundary due to noble gases released in gaseous effluents per unit shall be limited during any calendar quarter to  $\leq$  5 millirad (mrad) for gamma radiation and  $\leq$  10 mrad for beta radiation; and during any calendar year to  $\leq$  10 mrad for gamma radiation and  $\leq$  20 mrad for beta radiation.

b. **Iodines and Particulates with Half-Lives Greater than Eight Days in Gaseous Effluents:**

The release of iodines and particulates in gaseous effluent is regulated by the dose limits of 10 CFR 50 Appendix I and the BFN ODCM. The dose to a member of the public from radioiodines, radioactive materials in particulate form, and radionuclides other than noble gases with half-lives greater than eight days in gaseous effluent released per unit to areas at and beyond the site boundary shall be limited to any organ during any calendar quarter to  $\leq$  7.5 millirem (mrem), and during any calendar year to  $\leq$  15 mrem.

c. **Liquid Effluents:**

The release of radioactive liquid effluents is regulated by the dose limits of 10 CFR 50 Appendix I and the BFN ODCM. The doses or dose commitment to a member of the public from radioactive materials in liquid effluents released from each unit to unrestricted areas shall be limited during any calendar quarter to  $\leq$  1.5 mrem to the total body and  $\leq$  5 mrem to any organ and during any calendar year to  $\leq$  3 mrem to the total body and  $\leq$  10 mrem to any organ.

**2. Limitation on Dose Rate**

a. **Fission and Activation Gases in Gaseous Effluent:**

1. The instantaneous release rate of fission and activation gases is based on the dose rate limits of 10 CFR 20.1301 and the BFN ODCM. The dose rate at any time to areas at and beyond the site boundary due to noble gases released in gaseous effluents from the site shall be limited to  $\leq$  500 mrem per year to the total body and  $\leq$  3000 mrem per year to the skin.

2. The BFN ODCM Section 7.2 determines the maximum noble gas release rate.

2012  
**BROWNS FERRY NUCLEAR PLANT**  
**UNITS 1, 2, AND 3**  
**EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

**SUPPLEMENTAL INFORMATION**

**2. Limitation on Dose Rate (Continued)**

- b. Iodines and Particulates with Half-Lives Greater than Eight Days in Gaseous Effluents:
  - 1. The instantaneous release rate of particulates and iodines is regulated by the dose rate limits of the BFN ODCM. The dose rate at any time to areas at and beyond the site boundary, due to I-131, I-133, H-3, and particulates with half-lives greater than eight days in gaseous effluent released from the site, shall be limited to  $\leq$  1500 mrem per year to any organ.
  - 2. The BFN ODCM Section 7.3 determines the maximum particulate and iodine dose rates.
- c. Liquid Effluents:
  - 1. The concentration of radionuclides in liquid effluents released at any time from the site to unrestricted areas shall be limited to the concentrations specified in 10 CFR 20.1001-20.2402, Appendix B, Table 2, Column 2 for radionuclides other than dissolved or entrained noble gases
  - 2. For dissolved or entrained noble gases, the concentration shall be limited to 2E-4  $\mu$ Ci per milliliter (ml) total activity.

**3. Average Energy**

The BFN ODCM limits the dose equivalent rates due to the release of noble gases to less than or equal to 500 mrem/year to the total body and less than or equal to 3000 mrem/year to the skin. The use of dose rate is in accordance with NUREG-0133, "Preparation of Radiological Effluent Technical Specifications for Nuclear Power Plants." Since the release rate is not used for effluent control, the average beta and gamma energies (E) for gaseous effluents discussed in Regulatory Guide 1.21, "Measuring, Evaluation, and Reporting Radioactivity in Solid Wastes and Releases of Radioactive Materials in Liquid and Gaseous Effluents from Light-Water-Cooled Nuclear Power Plants," are not applicable and not included in this report.

2012  
BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT

**SUPPLEMENTAL INFORMATION**

**4. Measurements and Approximations of Total Radioactivity**

a. Fission and activation gases:

1. Noble gases in the building vent and stack (elevated) gaseous effluents are continuously monitored. The flow rate of the stack is continuously monitored and the building vent effluent flow rates are calculated once a shift based on the configuration of operating exhaust fans. The vent flow is calculated for each release. Gas grab samples of the stack are taken and analyzed weekly. Gas grab samples of in-service vents are taken and analyzed monthly. The specific noble gas activity concentrations and total volume of the gases are used to calculate the total Curies of noble gases released.
2. The tritium concentration is determined by the analysis of a monthly grab sample for each release point.

b. Iodines and Particulates:

1. Iodines and particulates are continuously sampled on impregnated charcoal filters and particulate filters, respectively. The charcoal and particulate samples are replaced at least weekly and analyzed to determine specific activity concentrations. The specific activity concentrations and vent flow rate data are used weekly to verify that release rate limits were not exceeded. The specific activity concentrations and total volume of gaseous effluent are used on a monthly basis to determine the total curies of each particulate and iodine released during the month.
2. The gross alpha concentration is determined by analysis of a monthly particulate filter composite sample, and strontium-89 and strontium-90 are determined by analysis of a quarterly particulate filter composite sample for each release point.

c. Liquid effluents:

1. The gamma ray emitting radionuclide concentrations are determined for each batch by gamma ray spectroscopy analysis of a grab sample. The allowable release rate is calculated for each batch based upon the known dilution flow. The flow rate of the liquid effluent is continuously monitored and the total volume released in each batch is determined. The total gamma activity released in each batch is determined by multiplying the radionuclide concentrations by the total volume discharged. The total gamma activity released during the month is then determined by summing the gamma activity content of each batch discharged during the month.

**2012**  
**BROWNS FERRY NUCLEAR PLANT**  
**UNITS 1, 2, AND 3**  
**EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

**SUPPLEMENTAL INFORMATION**

**4. Measurements and Approximations of Total Radioactivity (Continued)**

- c. Liquid effluents (Continued):
2. The gross alpha and tritium concentrations are measured on a monthly composite sample. The strontium-89, strontium-90, and iron-55 are measured on a quarterly composite sample.
  - d. The Radioactive Gaseous and Liquid Waste Monitoring Sampling and Analysis Program is specified in ODCM Sections 1/2.2.1 and 1/2.2.2. No liquid or gaseous concentration or dose limits were exceeded.

**5. Batch Releases**

a. Liquid	<u>Units</u>	<u>Quarter</u>	<u>Quarter</u>	<u>Quarter</u>	<u>Quarter</u>
		1	2	3	4
1. Number of batches released	Each	2	-	-	-
2. Total time for batches released	Minutes	485.00	-	-	-
3. Maximum time period for a batch release	Minutes	250.00	-	-	-
4. Average time period for a batch release	Minutes	242.50	-	-	-
5. Minimum time period for a batch release	Minutes	235.00	-	-	-
6. Average BFN beach flow during period of release into the river stream	ft <sup>3</sup> /sec	74339	-	-	-

Note: There were no batch releases during the 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> quarters.

b. Gaseous

None

**2012**  
**BROWNS FERRY NUCLEAR PLANT**  
**UNITS 1, 2, AND 3**  
**EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

**SUPPLEMENTAL INFORMATION**

**6. Abnormal Releases**

a. Liquid

1. Number of releases: 4
2. Total activity released:

<u>Destination</u>	<u>Nuclide</u>	<u>Quarter 1</u>	<u>Quarter 2</u>	<u>Quarter 3</u>	<u>Quarter 4</u>
Leak to River	H-3	-	1.63E+00	8.42E-01	5.70E+00
	F-18	-	-	7.72E-02	-

b. Gaseous

1. Number of releases: 2
2. Total activity released:

<u>Destination</u>	<u>Nuclide</u>	<u>Quarter 1</u>	<u>Quarter 2</u>	<u>Quarter 3</u>	<u>Quarter 4</u>
Air	H-3	-	1.99E-02	-	5.49E-03

2012  
**BROWNS FERRY NUCLEAR PLANT**  
**UNITS 1, 2, AND 3**  
**EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

**SUPPLEMENTAL INFORMATION**

**6. Abnormal Releases (Continued)**

**Summary of Abnormal/Unplanned Releases**

The release of radioactive material to the environment from BFN has been a small fraction of the 10 CFR 20 Appendix B and 10 CFR 50 Appendix I limits. There were no limits exceeded as specified in 10 CFR 20 Appendix B and 10 CFR 50 Appendix I.

Four abnormal liquid releases occurred in 2012.

1. From April 2, 2012 to April 4, 2012, a liquid release containing tritium was discharged from the pond structure. A sample from the sump trough on the north end of the Intake Cable Tunnel was obtained. It was discovered that a sump pump was hooked to a discharge line which ran the length of the tunnel and was open to discharge at the south end (forebay end) of the tunnel. The sump pump is located in an Radiologically Controlled Area (RCA) and discharged into a clean area (Problem Evaluation Report (PER) 532416)
2. On September 13, 2012, the BFN, Unit 1 Station Sump was sampled at 0800. The gamma isotopic analysis indicated the presence of Fluorine-18 (F-18). A resample was obtained at 0850 and it confirmed the presence of F-18 (PER 611022).
3. From September 17, 2012 to September 21, 2012, a liquid release containing tritium was discharged from the pond structure (PER 621299).
4. Beginning April 12, 2012, tritium was detected and released through the BFN Unit 1, Unit 2, and Unit 3 Station Sumps. The probable source was the Turbine Building Air Wash System (PER 536459 and PER 706704).

Two abnormal gaseous releases occurred in 2012.

1. The Auxiliary Decay Heat Removal (ADHR) system was placed in service on April 9, 2012. The initial sample of the ADHR catch basin indicated tritium concentration at 1.33E-05 uCi/ml. The system was isolated on April 30, 2012 (PER 536466).
2. On October 20, 2012, the ADHR system was returned to service. The initial sample of the ADHR catch basin following the return to service indicated tritium concentration at 2.10E-06 uCi/ml. The system was isolated on December 1, 2012 (PER 706710).

**2012**  
**BROWNS FERRY NUCLEAR PLANT**  
**UNITS 1, 2, AND 3**  
**EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

**SUPPLEMENTAL INFORMATION**

**6. Abnormal Releases (Continued)**

**Ground Water Monitoring**

Onsite groundwater monitoring locations were sampled during the year. These locations were not part of the BFN Radiological Environmental Monitoring Program (REMP). The purpose of these shallow wells was to monitor for potential leaks from plant equipment. Trace levels of tritium were detected in several of these monitoring locations. BFN initiated a groundwater study to identify the source of the tritium. Results from a groundwater study completed in June 2006 suggest the source of the tritiated groundwater is associated with the Radwaste/Condensate Transfer tunnel. Water that may leak into the tunnel could egress via expansion joints and/or cracks through the tunnel wall. These joints and/or cracks were grouted during 2008 with several more leaks grouted in 2010. The highest concentration identified in the groundwater for the year was 3560 pCi/L. Groundwater and surface water level measurements during the study indicated the return channel and subsequently the Tennessee River will ultimately be recipient to tritiated groundwater discharge from the site. The estimated groundwater/channel water dilution ratio is 1:20,000 at a rate of approximately 0.5 gpm. The tritium concentrations obtained in 2012 from these non-REMP wells are listed below.

<u>Well ID</u>	<u>Date</u>	<u>Activity in pCi/L</u>	<u>Well ID</u>	<u>Date</u>	<u>Activity in pCi/L</u>
R-3 (1307)	10/19/2012	381	BH25(1309)	9/10/2012	385
R-3 (1307)	7/24/2012	255	BH25(1309)	5/4/2012	296
R-3 (1307)	5/4/2012	396	DEWAT A(1311)	12/21/2012	846
BH25(1309)	12/21/2012	694	DEWAT A(1311)	11/8/2012	1998
BH25(1309)	12/17/2012	542	DEWAT A(1311)	10/18/2012	809
BH25(1309)	11/14/2012	753	DEWAT A(1311)	7/24/2012	1600
BH25(1309)	11/5/2012	540	DEWAT A(1311)	5/4/2012	3560
		(PER 624796 and PER 679394)			
BH25(1309)	10/29/2012	531	DEWAT E(1312)	12/21/2012	2946
		(PER 679394)			
BH25(1309)	10/24/2012	588	DEWAT E(1312)	11/8/2012	1126
BH25(1309)	10/18/2012	637	DEWAT E(1312)	10/18/2012	1409
BH25(1309)	10/15/2012	648	DEWAT E(1312)	7/24/2012	300
BH25(1309)	10/9/2012	689	DEWAT E(1312)	5/4/2012	348
BH25(1309)	10/3/2012	679	DSN015	11/15/2012	227
BH25(1309)	9/24/2012	668	DSN 015b	11/16/2012	209
BH25(1309)	9/17/2012	671	DSN150d	11/15/2012	221

**2012**  
**BROWNS FERRY NUCLEAR PLANT**  
**UNITS 1, 2, AND 3**  
**EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

**SUPPLEMENTAL INFORMATION**

**6. Abnormal Releases (Continued)**

**Liquid Radwaste or Temporary Storage Tanks**

BNF used three outside temporary liquid radwaste storage tanks to store approximately 55,000 gallons of radwaste water from March 10, 2012 to April 5, 2012. Concentrations of the tanks were monitored and verified to be less than the limits of 10 CFR 20, Appendix B, Table 2, Column 2, at the nearest potable water supply and the nearest surface water supply in an unrestricted area (Technical Specifications 5.5.8 (b) and Technical Requirements Manual 3.7.1).

**Changes to the Radwaste System and Changes to the Process Control Program**

In calendar year 2012, BFN had no changes to the radwaste system. The Process Control Program was revised on January 26, 2012.

**2012**  
**BROWNS FERRY NUCLEAR PLANT**  
**UNITS 1, 2, AND 3**  
**EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

**GASEOUS EFFLUENTS**

**TABLE 1A**  
**Page 1 of 2**  
**Gaseous Effluents - Summation of All Releases**

		<u>Units</u>	<u>Quarter 1</u>	<u>Quarter 2</u>	<u>Quarter 3</u>	<u>Quarter 4</u>	<u>Error %</u>
<b>A. Fission and Activation Gases</b>							
1. Total Releases		Curies	**	**	3.99E+02	2.94E+02	45
2. Average Release Rate for Period		$\mu\text{Ci/sec}$	**	**	5.02E+01	3.70E+01	
3. Percent of Applicable Limit		%	**	**	****	****	
<b>B. Iodines</b>							
1. Total Iodine-131		Curies	2.71E-03	1.70E-03	2.24E-03	1.77E-03	36
2. Average Release Rate for Period		$\mu\text{Ci/sec}$	3.44E-04	2.17E-04	2.82E-04	2.23E-04	
3. Percent of Applicable Limit		%	****	****	****	****	
<b>C. Particulates</b>							
1. Particulates with half-lives > eight days		Curies	9.02E-04	7.73E-04	4.21E-04	4.54E-04	35
2. Average Release Rate for Period		$\mu\text{Ci/sec}$	1.15E-04	9.83E-05	5.30E-05	5.71E-05	
3. Percent of Applicable Limit		%	****	****	****	****	
4. Gross Alpha Radioactivity		Curies	**	**	**	**	
<b>D. Tritium</b>							
1. Total Release		Curies	4.16E+02	6.22E+01*	6.90E+01	4.97E+01*	21
2. Average Release Rate for Period		$\mu\text{Ci/sec}$	5.29E+01	7.92E+00*	8.68E+00	6.25E+00*	
3. Percent of Applicable Limit		%	****	****	****	****	

**2012**  
**BROWNS FERRY NUCLEAR PLANT**  
**UNITS 1, 2, AND 3**  
**EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

**GASEOUS EFFLUENTS**

**TABLE 1A (Continued)**  
**Page 2 of 2**  
**Gaseous Effluents - Summation of All Releases**

	<u>Units</u>	<u>Quarter 1</u>	<u>Quarter 2</u>	<u>Quarter 3</u>	<u>Quarter 4</u>	<u>Error %</u>
E. Carbon-14***						
1. Total Release	Curies	9.93E+00	7.76E+00	1.02E+01	8.22E+00	N/A
2. Total as CO <sub>2</sub>	Curies	9.43E+00	7.37E+00	9.69E+00	7.81E+00	

\* - Includes Activity from Abnormal Release

\*\* - Not Detected.

\*\*\* - Estimated using Electric Power Research Institute (EPRI) methodology provided in EPRI Report 1021106.

\*\*\*\* - Applicable Limits are expressed in terms of dose. See Radiological Impact Report.

**2012**  
**BROWNS FERRY NUCLEAR PLANT**  
**UNITS 1, 2, AND 3**  
**EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

**GASEOUS EFFLUENTS**  
**(Continuous Mode Only)**

**TABLE 1B**  
**Page 1 of 2**  
**Gaseous Effluents - Elevated Releases**

<u>CURIES</u>	<u>Quarter 1</u>	<u>Quarter 2</u>	<u>Quarter 3</u>	<u>Quarter 4</u>
1. Fission Gases				
Kr-85m	*	*	3.49E+00	*
Kr-85	*	*	*	*
Kr-87	*	*	*	*
Kr-88	*	*	*	*
Xe-133	*	*	*	*
Xe-135m	*	*	*	*
Xe-135	*	*	*	*
Xe-138	*	*	*	*
Others (N-13)	*	*	3.96E+02	2.94E+02
<u>Total for Period</u>	<u>*</u>	<u>*</u>	<u>3.99E+02</u>	<u>2.94E+02</u>
2. Iodines				
I-131	5.89E-04	3.96E-04	5.35E-04	2.73E-04
I-135	*	5.41E-04	*	*
I-133	1.34E-03	1.05E-03	1.30E-03	5.62E-04
<u>Total for Period</u>	<u>1.93E-03</u>	<u>1.99E-03</u>	<u>1.83E-03</u>	<u>8.35E-04</u>

\* - Not Detected.

**2012**  
**BROWNS FERRY NUCLEAR PLANT**  
**UNITS 1, 2, AND 3**  
**EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

**GASEOUS EFFLUENTS**  
**(Continuous Mode Only)**

**TABLE 1B (Continued)**

Page 2 of 2

**Gaseous Effluents - Elevated Releases**

<u>CURIES</u>	<u>Quarter 1</u>	<u>Quarter 2</u>	<u>Quarter 3</u>	<u>Quarter 4</u>
3. Particulates*				
Sr-89	1.47E-04	1.03E-04	1.88E-04	1.87E-04
Sr-90	**	**	**	**
Sr-91	2.67E-03	9.48E-04	2.31E-03	2.72E-03
Cs-134	**	**	**	**
Cs-137	**	**	**	**
Ba-140	2.38E-04	1.07E-04	2.33E-04	2.67E-04
La-140	1.45E-04	6.81E-05	1.56E-04	1.83E-04
Te-132	7.03E-07	**	**	**
Others (Zn-69m)	**	**	9.17E-06	**
Others (Au-199)	**	**	1.22e-06	**
RB-89	2.29E-02	**	**	**
Y-91m	1.81E-03	8.53E-04	1.80E-03	1.97E-03
Cs-138	7.32E-03	**	**	**
Ba-139	2.07E-01	8.57E-02	2.48E-01	2.41E-01
<u>Total for Period*</u>	<u>2.42E-01</u>	<u>8.78E-02</u>	<u>2.53E-01</u>	<u>2.46E-01</u>
4. Tritium	2.68E+00	2.43E+00	5.39E+00	3.97E+00
5. Carbon-14***	9.43E+00	7.37E+00	9.69E+00	7.81E+00

\* - Includes all nuclides, even those with less than an eight day half-life.

\*\* - Not Detected.

\*\*\* - Estimated using EPRI methodology provided in EPRI Report 1021106.

**2012**  
**BROWNS FERRY NUCLEAR PLANT**  
**UNITS 1, 2, AND 3**  
**EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

**GASEOUS EFFLUENTS**  
**(Continuous Mode Only)**

**TABLE 1C**  
**Page 1 of 2**  
**Gaseous Effluents - Ground Level Releases**

<u>CURIES</u>	<u>Quarter 1</u>	<u>Quarter 2</u>	<u>Quarter 3</u>	<u>Quarter 4</u>
1. Fission Gases				
Kr-85m	*	*	*	*
Kr-85	*	*	*	*
Kr-87	*	*	*	*
Kr-88	*	*	*	*
Xe-133	*	*	*	*
Xe-135m	*	*	*	*
Xe-135	*	*	*	*
Xe-138	*	*	*	*
Ar-41	*	*	*	*
Other (specify)	*	*	*	*
<u>Total for Period</u>	<u>*</u>	<u>-</u>	<u>-</u>	<u>-</u>
2. Iodines				
I-131	1.03E-03	4.53E-04	3.49E-04	4.69E-04
I-132	4.61E-05	*	*	*
I-133	4.25E-03	5.42E-04	1.16E-03	1.83E-03
<u>Total for Period</u>	<u>5.33E-03</u>	<u>9.95E-04</u>	<u>1.51E-03</u>	<u>2.30E-03</u>

\* - Not Detected.

\*\* - Activity from Abnormal Release.

**2012**  
**BROWNS FERRY NUCLEAR PLANT**  
**UNITS 1, 2, AND 3**  
**EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

**GASEOUS EFFLUENTS**  
**(Continuous Mode Only)**

**TABLE 1C (Continued)**

Page 2 of 2

**Gaseous Effluents - Ground Level Releases**

<u>CURIES</u>	<u>Quarter 1</u>	<u>Quarter 2</u>	<u>Quarter 3</u>	<u>Quarter 4</u>
3. Particulates*				
Co-60	**	2.53E-05	7.81E-06	**
Sr-89	6.26E-05	9.85E-07	**	1.54E-05
Sr-90	**	**	**	**
Cs-134	**	**	**	**
Cs-137	**	**	**	**
Ba-140	9.95E-05	5.69E-06	**	1.25E-05
La-140	5.05E-05	2.67E-06	**	**
Sr-91	8.21E-04	1.63E-05	**	**
Other (Mn-54)	**	**	2.89E-06	**
Other (Au-199)	**	**	**	**
Y-91m	2.28E-03	7.85E-05	6.15E-05	4.17E-04
Cs-138	2.42E-02	**	**	1.31E-02
Ba-139	1.05E-01	6.04E-03	4.93E-03	1.66E-02
<u>Total for Period*</u>	<u>1.32E-01</u>	<u>6.17E-03</u>	<u>5.00E-03</u>	<u>3.01E-02</u>
4. Tritium	<u>9.32E+00</u>	<u>2.70E+00***</u>	<u>8.95E-01</u>	<u>5.68E+00***</u>

\* - Include all nuclides even those with less than an eight day half-life.

\*\* - Not Detected.

\*\*\* - Includes Activity from Abnormal Release.

**2012**  
**BROWNS FERRY NUCLEAR PLANT**  
**UNITS 1, 2, AND 3**  
**EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

**GASEOUS EFFLUENTS**  
**(Continuous Mode Only)**

**TABLE 1D**  
**Page 1 of 3**  
**Gaseous Effluents - Mixed Mode Releases**

<u>CURIES</u>	<u>Quarter 1</u>	<u>Quarter 2</u>	<u>Quarter 3</u>	<u>Quarter 4</u>
1. Fission Gases				
Kr-85m	**	**	**	**
Kr-85	**	**	**	**
Kr-87	**	**	**	**
Kr-88	**	**	**	**
Xe-133	**	**	**	**
Xe-135m	**	**	**	**
Xe-135	**	**	**	**
Xe-138	**	**	**	**
Other (specify)	**	**	**	**
<u>Total for Period</u>	<u>**</u>	<u>**</u>	<u>**</u>	<u>**</u>
2. Iodines				
I-131	1.09E-03	8.53E-04	1.36E-03	1.03E-03
I-132	4.63E-04	**	**	**
I-133	5.19E-03	2.86E-03	6.20E-03	5.24E-03
<u>Total for Period</u>	<u>6.73E-03</u>	<u>3.71E-03</u>	<u>7.56E-03</u>	<u>6.27E-03</u>

\* - The Reactor Building and Radwaste Building are treated as split-level releases.

\*\* - Not Detected.

**2012**  
**BROWNS FERRY NUCLEAR PLANT**  
**UNITS 1, 2, AND 3**  
**EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

**GASEOUS EFFLUENTS**  
**(Continuous Mode Only)**

**TABLE 1D (Continued)**

Page 2 of 3

**Gaseous Effluents - Mixed Mode Releases**

<u>CURIES</u>	<u>Quarter 1</u>	<u>Quarter 2</u>	<u>Quarter 3</u>	<u>Quarter 4</u>
3. Particulates**				
Sr-89	5.56E-05	1.36E-06	4.69E-05	8.23E-04
Ru-103	***	***	3.50E-06	***
Ag-110m	***	***	4.93E-06	4.28E-05
Cs-137	3.23E-05	4.87E-06	2.55E-05	1.89E-05
Ba-140	1.59E-04	5.91E-05	1.48E-04	3.33E-04
La-140	7.21E-05	3.50E-05	3.31E-05	1.53E-04
Na-24	***	5.56E-05	1.45E-04	1.75E-04
Cr-51	***	2.04E-05	***	3.50E-05
Mn-54	1.56E-05	1.79E-05	4.59E-05	6.70E-05
Mn-56	1.17E-02	9.98E-03	1.97E-02	2.70E-02
Co-58	4.44E-05	1.97E-05	1.02E-04	9.32E-05
Co-60	3.38E-05	4.08E-04	5.05E-04	3.39E-04
Zn-65	1.36E-05	***	5.66E-05	4.92E-05
Zn-69m	4.22E-05	1.80E-05	7.75E-05	9.51E-05
Y-91m	2.90E-03	6.78E-04	1.85E-03	3.22E-03
Sr-91	3.13E-03	1.23E-04	8.94E-04	2.63E-03
Sr-92	***	***	***	4.98E-04

\* - The Reactor Building and Radwaste Building are treated as split-level releases.

\*\* - Includes all nuclides, even those with less than an eight day half-life.

\*\*\* - Not Detected.

**2012**  
**BROWNS FERRY NUCLEAR PLANT**  
**UNITS 1, 2, AND 3**  
**EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

**GASEOUS EFFLUENTS**  
**(Continuous Mode Only)**

**TABLE 1D (Continued)**

Page 3 of 3

**Gaseous Effluents - Mixed Mode Releases**

<u>CURIES</u>	<u>Quarter 1</u>	<u>Quarter 2</u>	<u>Quarter 3</u>	<u>Quarter 4</u>
3. Particulates** (Continued)				
Mo-99	1.62E-06	2.12E-06	1.74E-06	***
Tc-99m	1.58E-06	2.07E-06	1.70E-06	***
Cs-138	7.51E-03	***	1.10E-02	1.91E-02
Ba-139	1.26E-01	1.56E-02	7.16E-02	1.16E-01
Y-92	***	***	***	7.14E-04
Total for Period**	<u>1.52E-01</u>	<u>2.70E-02</u>	<u>1.06E-01</u>	<u>1.71E-01</u>
4. Tritium	<u>4.04E+02</u>	<u>5.71E+01</u>	<u>6.27E+01</u>	<u>4.01E+01</u>

\* - The Reactor Building and Radwaste Building are treated as split-level releases.

\*\* - Includes all nuclides, even those with less than an eight day half-life.

\*\*\* - Not Detected.

**2012**  
**BROWNS FERRY NUCLEAR PLANT**  
**UNITS 1, 2, AND 3**  
**EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

**LIQUID EFFLUENTS**  
**(Batch Mode Only)**

**TABLE 2A**  
**Page 1 of 2**  
**Liquid Effluents - Summation of All Releases**

	<u>Units</u>	<u>Quarter 1</u>	<u>Quarter 2</u>	<u>Quarter 3</u>	<u>Quarter 4</u>	<u>Error %</u>
A. Fission and Activation Products (Does not include tritium, gases, Alpha)						
1. Total Release	Curies	9.43E-04	-	7.72E-02**	-	9
2. Average Diluted Concentration Released During Period	µCi/ml	3.67E-10	-	1.44E-07**	-	
3. Percent of Applicable Limit	%	***	-	***	-	
B. Tritium						
1. Total Releases	Curies	1.41E+00	1.63E+00**	8.42E-01**	5.70E+00**	6
2. Average Diluted Concentration Released During Period	µCi/ml	5.49E-07	4.98E-03**	1.58E-06**	1.97E-05**	
3. Percent of Applicable Limit	%	***	***	***	***	
C. Dissolved and Entrained Noble Gases						
1. Total Releases	Curies	*	-	-	-	8
2. Average Diluted Concentration Released During Period	µCi/ml	*	-	-	-	
3. Percent of Applicable Limit	%	***	-	-	-	
D. Gross Alpha Radioactivity						
1. Total Releases	Curies	*	-	-	-	48
2. Average Diluted Concentration Released During Period	µCi/ml	*	-	-	-	

**2012**  
**BROWNS FERRY NUCLEAR PLANT**  
**UNITS 1, 2, AND 3**  
**EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

**LIQUID EFFLUENTS**  
**(Batch Mode Only)**

**TABLE 2A (Continued)**

Page 2 of 2

**Liquid Effluents - Summation of All Releases**

	<u>Units</u>	<u>Quarter 1</u>	<u>Quarter 2</u>	<u>Quarter 3</u>	<u>Quarter 4</u>	<u>Error %</u>
E. Volume of Liquid Waste to Discharge Canal (Prior to dilution)	Liters	2.61E+05	4.67E+08**	6.32E+08**	2.89E+08**	3
F. Volume of Dilution Water for Period	Liters	2.57E+09	**	**	**	10
G. Total CCW	Gigagal	2.31E+02	2.23E+02	2.66E+02	2.34E+02	

---

\* - Not Detected.

\*\* - Includes activity from abnormal releases. Dilution flow was not determined for the abnormal releases.

\*\*\* - The applicable limit is expressed in terms of dose. See Radiological Impact Report.

**2012**  
**BROWNS FERRY NUCLEAR PLANT**  
**UNITS 1, 2, AND 3**  
**EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

**LIQUID EFFLUENTS**  
**(Batch Mode Only)**

**TABLE 2B**  
**Page 1 of 3**  
**Liquid Effluents**

<u>CURIES</u> <u>Isotope</u> <u>(Required by Regulatory</u> <u>(REG) Guide 1.21)</u>	<u>Quarter 1</u>	<u>Quarter 2</u>	<u>Quarter 3</u>	<u>Quarter 4</u>
1. Ba-140	*	-	-	-
2. Ce-141	*	-	-	-
3. Co-58	*	-	-	-
4. Co-60	3.02E-04	-	-	-
5. Cr-51	*	-	-	-
6. Cs-134	1.23E-05	-	-	-
7. Cs-137	6.01E-04	-	-	-
8. Fe-59	*	-	-	-
9. I-131	*	-	-	-
10. La-140	*	-	-	-
11. Mn-54	1.30E-05	-	-	-
12. Mo-99	*	-	-	-
13. Nb-95	*	-	-	-
14. Sr-89	*	-	-	-
15. Sr-90	*	-	-	-
16. Tc-99m	*	-	-	-
17. Xe-133	*	-	-	-

---

\* - Not Detected.

2012  
BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT

**LIQUID EFFLUENTS**  
(Batch Mode Only)

**TABLE 2B (Continued)**  
**Page 2 of 3**  
**Liquid Effluents**

<u>CURIES</u> <u>Isotope</u> <u>(Required by Regulatory</u> <u>(REG) Guide 1.21)</u>	<u>Quarter 1</u>	<u>Quarter 2</u>	<u>Quarter 3</u>	<u>Quarter 4</u>
18. Xe-135	*	-	-	-
19. Zn-65	*	-	-	-
20. Zr-95	*	-	-	-

---

\* - Not Detected.

**2012**  
**BROWNS FERRY NUCLEAR PLANT**  
**UNITS 1, 2, AND 3**  
**EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

**LIQUID EFFLUENTS**  
**(Batch Mode Only)**

**TABLE 2B (Continued)**  
**Page 3 of 3**  
**Liquid Effluents**

	<u>CURIES</u>		<u>Quarter 1</u>	<u>Quarter 2</u>	<u>Quarter 3</u>	<u>Quarter 4</u>
	<u>Isotope</u>					
	<u>Others (Not Required by REG</u>					
	<u>Guide 1.21)</u>					
1.	F-18		**	-	7.72E-02*	-
2.	Fe-55		7.74E-06	-	-	-
3	Mn-56		**	-	-	-
4	Zn-69m		**	-	-	-
5	Kr-88		**	-	-	-
6	Nb-97		**	-	-	-
7	Ag-110m		6.68E-06	-	-	-
8	Sb-124		**	-	-	-
9	I-133		**	-	-	-
10	As-76		**	-	-	-
11	Na-24		**	-	-	-
12	Y-91m		**	-	-	-
13	Xe-133m		**	-	-	-

\* - Activity from abnormal release.

\*\* - Not Detected.

**2012**  
**BROWNS FERRY NUCLEAR PLANT**  
**UNITS 1, 2, AND 3**  
**EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

**SOLID WASTE**

**TABLE 3**  
**Page 1 of 7**  
**Solid Waste and Irradiated Fuel Shipments**

**A. Solid Waste Shipped Offsite for Burial or Disposal (not Irradiated Fuel)**

<b>1. Type of Waste</b>	<b>Unit</b>	<b>Jan - Jun 2012</b>	<b>July-Dec 2012</b>	<b>Error %</b>
a. Spent resins, filters, sludges, evaporator bottoms, etc.	m <sup>3</sup>	1.53E+02	9.80E+01	+/- 25%
	Ci	6.29E+02	6.01E+02	+/- 25%
b. Dry Active Waste, Compressible Waste Contaminated Equipment, etc.	m <sup>3</sup>	2.25E+03	1.48E+03	+/- 25%
	Ci	1.97E+01	5.88E-01	+/- 25%
c. Irradiated Components, Control Rods, etc.	m <sup>3</sup>	0.00E+00	3.18E+00	+/- 25%
	Ci	0.00E+00	1.86E+04	+/- 25%
d. Other (Describe)	m <sup>3</sup>	4.67E+01	3.77E+01	+/- 25%
	Ci	1.09E+00	9.09E-01	+/- 25%

**2012**  
**BROWNS FERRY NUCLEAR PLANT**  
**UNITS 1, 2, AND 3**  
**EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

**SOLID WASTE**

**TABLE 3 (Continued)**  
**Page 2 of 7**  
**Solid Waste and Irradiated Fuel Shipments**

**2. Estimate of Major Nuclide Composition**

**a. Spent resins, filters, sludges, evaporator bottoms, etc.**

<u>Nuclide</u>	<u>Percent</u>	<u>Curies</u>
H-3	3.29E-02	4.04E-01
C-14	5.38E-02	6.62E-01
Cr-51	9.76E-02	1.20E+00
Mn-54	3.46E+00	4.26E+01
Fe-55	1.70E+01	2.09E+02
Fe-59	1.59E-02	1.95E-01
Co-57	2.32E-03	2.85E-02
Co-58	6.71E-01	8.25E+00
Co-60	4.27E+01	5.25E+02
Ni-59	5.01E-04	6.16E-03
Ni-63	1.20E+00	1.48E+01
Cu-64	2.66E-07	3.27E-06
Zn-65	2.07E+00	2.54E+01
Zn-69m	2.85E-15	3.51E-14
Sr-89	8.78E-03	1.08E-01
Sr-90	4.11E-02	5.05E-01
Zr-95	4.58E-05	5.63E-04
Nb-95	5.50E-05	6.77E-04
Mo-99	5.58E-06	6.86E-05
Tc-99	1.36E-02	1.67E-01
Tc-99m	2.39E-22	2.94E-21
Ag-110m	3.68E-01	4.53E+00
Sb-124	4.86E-05	5.98E-04
Te-132	6.25E-46	7.69E-45
I-129	1.24E-05	1.52E-04
I-131	4.98E-02	6.13E-01
I-133	9.11E-08	1.12E-06
Cs-134	1.74E+00	2.14E+01
Cs-136	6.72E-45	8.27E-44
Cs-137	3.03E+01	3.73E+02
Ba-140	6.07E-02	7.46E-01
La-140	1.85E-03	2.27E-02

2012  
BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT

**SOLID WASTE**

**TABLE 3 (Continued)**  
**Page 3 of 7**  
**Solid Waste and Irradiated Fuel Shipments**

**2. Estimate of Major Nuclide Composition (Continued)**

**a. Spent resins, filters, sludges, evaporator bottoms, etc. (Continued)**

<u>Nuclide</u>	<u>Percent</u>	<u>Curies</u>
Ce-141	2.50E-02	3.08E-01
Ce-144	3.89E-02	4.78E-01
Pu-238	2.53E-04	3.11E-03
Pu-239	9.59E-06	1.18E-04
Pu-240	9.59E-06	1.18E-04
Pu-241	3.07E-02	3.77E-01
Am-241	1.26E-04	1.55E-03
Cm-242	1.37E-05	1.69E-04
Cm-243	1.52E-04	1.87E-03
Cm-244	1.03E-04	1.27E-03

**2012**  
**BROWNS FERRY NUCLEAR PLANT**  
**UNITS 1, 2, AND 3**  
**EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

**SOLID WASTE**

**TABLE 3 (Continued)**  
**Page 4 of 7**  
**Solid Waste and Irradiated Fuel Shipments**

**2. Estimate of Major Nuclide Composition (Continued)**

**b. Dry Active Waste, Compressible Waste  
 Contaminated Equipment, etc.**

<u>Nuclide</u>	<u>Percent</u>	<u>Curies</u>
H-3	2.37E+01	4.81E+00
C-14	2.23E-03	4.52E-04
K-40	1.99E-01	4.04E-02
Cr-51	8.38E-04	1.70E-04
Mn-54	8.23E+00	1.67E+00
Fe-55	2.28E+01	4.62E+00
Fe-59	1.29E-03	2.61E-04
Co-58	1.02E+00	2.06E-01
Co-60	3.45E+01	7.00E+00
Ni-63	1.40E+00	2.83E-01
Zn-65	4.77E+00	9.68E-01
Sr-89	2.56E-02	5.20E-03
Sr-90	4.93E-03	1.00E-03
Zr-95	1.15E-04	2.33E-05
Nb-95	0.00E+00	0.00E+00
Tc-99	6.46E-03	1.31E-03
Ag-110m	1.81E+00	3.67E-01
Sb-124	2.31E-04	4.68E-05
I-131	8.82E-06	1.79E-06
Cs-134	2.89E-02	5.86E-03
Cs-137	1.11E+00	2.26E-01
Ba-140	8.28E-05	1.68E-05
La-140	1.77E-17	3.60E-18
Ce-141	2.57E-04	5.22E-05
Ce-144	3.56E-01	7.23E-02
Pu-238	1.14E-04	2.32E-05
Pu-239	1.37E-05	2.77E-06
Pu-240	1.37E-05	2.77E-06
Pu-241	3.45E-02	6.99E-03
Am-241	7.99E-05	1.62E-05
Cm-242	2.41E-04	4.89E-05
Cm-243	1.68E-05	3.40E-06
Cm-244	1.68E-05	3.40E-06

**2012**  
**BROWNS FERRY NUCLEAR PLANT**  
**UNITS 1, 2, AND 3**  
**EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

**SOLID WASTE**

**TABLE 3 (Continued)**  
**Page 5 of 7**  
**Solid Waste and Irradiated Fuel Shipments**

**2. Estimate of Major Nuclide Composition (Continued)**

**c. Irradiated Components, Control Rods, etc.**

<u>Nuclide</u>	<u>Percent</u>	<u>Curies</u>
H-3	2.22E-03	4.14E-01
C-14	1.26E-02	2.35E+00
Mn-54	4.89E-01	9.10E+01
Fe-55	4.81E+01	8.95E+03
Co-60	4.42E+01	8.23E+03
Ni-59	3.61E-02	6.72E+00
Ni-63	7.17E+00	1.34E+03
Nb-94	1.33E-04	2.47E-02
Tc-99	5.71E-05	1.06E-02
U-235	2.71E-10	5.05E-08
Np-237	7.58E-09	1.41E-06
Pu-238	1.14E-04	2.13E-02
Pu-239	9.90E-08	1.84E-05
Pu-240	1.68E-07	3.13E-05
Pu-241	2.05E-05	3.82E-03
Am-241	2.03E-07	3.79E-05
Am-243	6.89E-09	1.28E-06
Cm-242	3.99E-08	7.42E-06
Cm-243	6.27E-09	1.17E-06
Cm-244	1.70E-06	3.17E-04

**2012**  
**BROWNS FERRY NUCLEAR PLANT**  
**UNITS 1, 2, AND 3**  
**EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

**SOLID WASTE**

**TABLE 3 (Continued)**  
**Page 6 of 7**  
**Solid Waste and Irradiated Fuel Shipments**

**2. Estimate of Major Nuclide Composition (Continued)**

**d. Other (Combined Packages)**

<u>Nuclide</u>	<u>Percent</u>	<u>Curies</u>
H-3	6.56E-03	1.31E-04
C-14	4.89E-02	9.77E-04
Mn-54	3.79E+00	7.56E-02
Fe-55	1.34E+01	2.67E-01
Co-58	4.70E-01	9.39E-03
Co-60	6.31E+01	1.26E+00
Ni-63	1.12E+00	2.23E-02
Zn-65	2.06E+00	4.11E-02
Sr-89	5.21E-02	1.04E-03
Sr-90	2.05E-02	4.09E-04
Nb-95	9.11E-02	1.82E-03
Tc-99	1.05E-04	2.10E-06
Ag-110m	1.26E+00	2.51E-02
Cs-134	9.71E-01	1.94E-02
Cs-137	1.34E+01	2.68E-01
Ce-141	7.01E-02	1.40E-03
Ce-144	1.50E-01	2.99E-03
Pu-238	3.26E-06	6.52E-08
Pu-239	1.26E-06	2.51E-08
Pu-241	1.80E-02	3.59E-04
Am-241	1.86E-04	3.71E-06
Cm-242	6.56E-06	1.31E-07
Cm-243	1.34E-04	2.67E-06

**2012**  
**BROWNS FERRY NUCLEAR PLANT**  
**UNITS 1, 2, AND 3**  
**EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

**SOLID WASTE**

**TABLE 3 (Continued)**  
**Page 7 of 7**  
**Solid Waste and Irradiated Fuel Shipments**

**3. Solid Waste Disposition**

<u>Number of Shipments</u>	<u>Mode of Transportation</u>	<u>Destination</u>
66	Cask, tankers, Sole Use Trucks (Hittman)	Energy Solutions Oak Ridge, TN (Bear Creek)
54	Sole Use Trucks (Tri-State)	Energy Solutions Oak Ridge, TN (Bear Creek)
1	Sole Use Truck (TVA HED)	Energy Solutions Oak Ridge, TN (Bear Creek)
6	Non Sole Use Trucks (Hittman)	Energy Solutions Memphis, TN
2	Sole Use Tucks	Energy Solutions Memphis, TN
29	Sole Use Trucks, Tankers  Casks (Hittman)	Energy Solutions  Oak Ridge, TN (Kingston)
2	Non Sole Use Trucks (Tri-State)	Energy Solutions Oak Ridge, TN (Kingston)
40	Sole Use Trucks and Tankers (Hittman)	Barnwell Processing Facility Barnwell, SC
5	Sole Use Trucks, Cask (Hittman)	Waste Control Specialist Andrews, TX

**B. Irradiated Fuel Shipments**

<u>Number of Shipments</u>	<u>Mode of Transportation</u>	<u>Destination</u>
2	Hittman	Waste Control Specialist Andrews, TX

**2012  
BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

**SOLID WASTE**

2012  
**BROWNS FERRY NUCLEAR PLANT**  
**UNITS 1, 2, AND 3**  
**EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

**RADIOLOGICAL IMPACT**

**1. Introduction**

Potential doses to the "maximum exposed individual" and the population around Browns Ferry Nuclear Plant (BFN) are calculated for each quarter as required in Section 5.2 of the Offsite Dose Calculation Manual (ODCM). The methodology used to estimate dose for determining plant releases for the reporting period is specified in Sections 6 and 7 of the ODCM. Dispersion of radioactive effluents in the environment is estimated using meteorological data and river flow measured during the period. In this report, the doses resulting from releases are described and compared to limits established for BFN.

**2. Dose Limits**

The ODCM specifies limits for the release of radioactive effluents, as well as limits for doses to the general public from the release of radioactive effluents. These limits are set well below the Technical Specification limits which govern the concentrations of radioactivity and doses permissible in unrestricted areas. This ensures that radioactive effluent releases are As Low As Reasonably Achievable.

The air dose limits in areas at and beyond the Site Boundary due to noble gases released in gaseous effluents per unit are:

$\leq$  5 mrad per quarter and  
 $\leq$  10 mrad per year for gamma radiation.  
- and -  
 $\leq$  10 mrad per quarter and  
 $\leq$  20 mrad per year for beta radiation.

The dose limits to a member of the public in an unrestricted area from radioiodines, radioactive materials in particulate form, and radionuclides other than noble gases with half-lives > 8 days released in gaseous effluents for each unit are:

$\leq$  7.5 mrem per quarter and  
 $\leq$  15 mrem per year to any organ.

The dose or dose commitment to a member of the public from radioactive material in liquid effluents released to unrestricted areas are:

$\leq$  1.5 mrem per quarter and  
 $\leq$  3 mrem per year to the total body,  
- and -  
 $\leq$  5 mrem per quarter and  
 $\leq$  10 mrem per year to any organ.

The limit for the total effective dose equivalent to an individual member of the public inside the site boundary is:

100 mrem per year.

2012  
**BROWNS FERRY NUCLEAR PLANT**  
**UNITS 1, 2, AND 3**  
**EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

**RADIOLOGICAL IMPACT**

**2. Dose Limits (Continued)**

The Environmental Protection Agency limits for total dose to any member of the public in the vicinity of a nuclear power plant, established in the Environmental Dose Standard of 40 CFR 190, are:

$\leq$  25 mrem per year to the whole body,  
 $\leq$  75 mrem per year to the thyroid,  
- and -  
 $\leq$  25 mrem per year to any other organ.

**3. Dose Calculations**

Estimated doses to members of the public are determined using computer models (the Gaseous Effluent Licensing Code, and the Quarterly Water Dose Assessment Code (QWATA)). These models are based on guidance provided by the Nuclear Regulatory Commission (NRC) for determining the potential dose to individuals and populations living in the vicinity of the plant. The area around the plant is analyzed to determine the pathways through which the public may receive a dose. The doses calculated are a representation of the dose to a "maximum exposed individual." Some of the factors used in these calculations (such as ingestion rates) are maximum values to ensure conservative reporting data. The values chosen will tend to overestimate the dose. The expected dose to actual individuals is lower. The calculated doses are presented in Tables 4, 5, and 6.

**4. Doses From Airborne Effluents**

For airborne effluents, members of the public can be exposed to radiation from several sources: direct radiation from the radioactivity in the air, direct radiation from radioactivity deposited on the ground, inhalation of airborne radioactivity, ingestion of vegetation which contains radioactivity deposited from the atmosphere, and ingestion of milk and beef which contains radioactivity deposited from the atmosphere onto vegetation and subsequently consumed by animals.

**a. Airborne Release Points**

There are four monitored release points from BFN: the turbine building, the radwaste building, the reactor building, and the stack.

Releases from the turbine building are considered ground-level releases. The ground-level Joint Frequency Distribution (JFD) is derived from wind speeds and directions measured 10.5 meters above the ground and from the vertical temperature difference between 10.03 and 45.30 meters, and are presented for each quarter in the 2012 Meteorological Data Tables 7A, 7B, 7C, and 7D.

2012  
BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT

**RADIOLOGICAL IMPACT**

**4. Doses From Airborne Effluents (Continued)**

**a. Airborne Release Points (Continued)**

Releases from the radwaste and reactor buildings are considered split-level releases. Portions of the release are treated as ground-level while other portions are considered elevated depending on the ratio of the vertical exit velocity to the horizontal wind speed. The split-level dispersion approach is implemented using a model that requires two complete quarterly JFDs for each effluent vent, one for the ground-level releases and one for the elevated releases. The ground-level portion of the split-level JFD is based on wind speeds and directions measured 10.5 meters above ground-level and from the vertical temperature difference between 10.03 and 45.30 meters. The elevated portion of the split-level JFD is based on wind speeds and direction measurements at the 45.74 meter level and the vertical temperature difference between 10.03 and 89.59 meters. Both of these JFDs are given for each quarter in the 2012 Meteorological Data Tables 8A, 8B, 8C, and 8D.

Releases from the stack are considered to be elevated releases. The JFDs for elevated releases are based on wind directions and wind speeds measured at 90.29 meters and the vertical temperature difference between 10.03 and 89.59 meters, and are given for each quarter in the 2012 Meteorological Data Tables 9A, 9B, 9C, 9D.

**b. Meteorological Data**

Meteorological variables at BFN are measured continuously. Measurements collected include wind speed and wind direction at heights of 10.5, 45.74, and 90.29 meters above the ground, and temperature at heights of 10.03, 45.30, and 89.59 meters above the ground. Quarterly JFDs are calculated for each release point using the appropriate levels of meteorological data. A quarterly JFD gives the percentage of the time that the wind is blowing out of a particular upwind compass sector in a particular range of wind speeds for a given stability class A through G. The wind speeds are divided into nine wind speed ranges. Calms are distributed by direction in proportion to the distribution of noncalm wind directions less than 1.6 m/s (3.5 mph). Stability classes are determined from the vertical temperature difference between two measurement levels.

The generally open terrain around BFN does not cause any significant effects on the transport and dispersion of gaseous effluents from the plant. Within 30 kilometers of BFN, the terrain is mostly gently rolling hills (30-60 meters). Between 30 and 80 kilometers, the hills become larger to the north and south and mountainous to the east and northeast. The Tennessee River/Wheeler Lake may have a minor effect on transport and dispersion in the immediate vicinity of BFN during periods of winds with a southerly component, overcast skies, and relatively high wind speeds. Also, the lower layer (10-45 meters) stability class tends to be more stable. However, during this infrequent condition, dose estimates will be conservative.

2012  
BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT

**RADIOLOGICAL IMPACT**

**4. Doses From Airborne Effluents (Continued)**

**c. External Exposure Dose**

Dose calculated for maximum external air dose (gamma-air and beta-air) are made for points at and beyond the unrestricted area boundary as described in the BFN ODCM. The highest of these doses is then selected.

**d. Submersion Dose**

External doses to the skin and total body, due to submersion in a cloud of noble gases, are calculated for the nearest residence in each sector. The residence with the highest dose is then selected from all sectors.

**e. Organ Dose**

Dose to an organ due to releases of airborne effluents are estimated for the inhalation, ground contamination, and ingestion pathways. The ingestion pathway is further divided into three possible contributing pathways: ingestion of cow/goat milk, ingestion of beef, and ingestion of vegetables. Doses from applicable pathways are calculated for each receptor location identified in the most recent land use survey. To determine the maximum organ dose, the doses from the pathways are summed for each receptor. However, for the ingestion dose, only those pathways that exist for each receptor are considered in the sum, e.g., milk ingestion doses are included only for locations where milk was consumed without commercial preparation and vegetable ingestion is included only for those locations where a garden was identified. To conservatively account for beef ingestion, a beef ingestion dose equal to that for the highest unrestricted area boundary location is added to each identified receptor. For ground contamination, the dose added to the organ dose being calculated is the total body dose calculated for that location, i.e., it is assumed that the dose to an individual organ is equal to the total body dose.

The maximum organ dose, thyroid dose, and total body dose from airborne effluents are presented in Table 4.

**5. Doses From Airborne Effluents**

For liquid effluents, the public can be exposed to radiation from three sources: the ingestion of water from the Tennessee River, the ingestion of fish caught in the Tennessee River, and direct exposure from radioactive material deposited on the river shoreline sediment (recreation).

The concentration of radionuclides in the Tennessee River is calculated by a computer model which uses measured hydraulic data downstream of BFN. Parameters used to determine the doses are based on guidance given by the NRC for maximum ingestion rates, exposure times, etc.

2012  
**BROWNS FERRY NUCLEAR PLANT**  
**UNITS 1, 2, AND 3**  
**EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

**RADIOLOGICAL IMPACT**

**5. Doses From Airborne Effluents (Continued)**

Wherever possible, parameters used in the dose calculation are site specific. The models that are used to estimate doses, as well as the parameters input to the models, are described in detail in the BFN ODCM.

**a. Liquid Release Points and River Data**

Radionuclide concentrations in the Tennessee River are calculated assuming that releases in liquid effluents are continuous. When necessary, liquid releases from BFN, located at Tennessee River Mile 294, are made through diffusers which extend into the Tennessee River. It is assumed that releases to the river through these diffusers will initially be entrained in one-fifth of the water which flows past the plant. The QWATA code makes the assumption that this mixing condition holds true until the water is completely mixed at the first downstream dam (Wheeler Dam), at Tennessee River Mile 283.

Doses are calculated for locations within a 50 mile radius downstream of the plant site. The maximum potential recreation dose is calculated for a location immediately downstream from the plant's release point. The maximum exposed individual dose from ingestion of fish is assumed to be that calculated for the consumption of fish caught anywhere between the plant and the first downstream dam. The maximum exposed individual dose from drinking water is assumed to be that calculated at the nearest downstream public water supply [West Morgan - East Lawrence (WMEL)]. This could be interpreted as indicating that the maximum exposed individual, as assumed for liquid releases from BFN, is an individual who obtains all of his drinking water at WMEL, consumes fish caught from the Tennessee River between BFN and Wheeler Dam, and spends 500 hours per year on the shoreline just downstream of the plant's release point. Doses calculated for the maximum exposed individual due to liquid effluents for each quarter in the period are presented in Table 5 along with the average river flows past the plant site for the periods.

**6. Population Doses**

Population doses due to airborne effluents are calculated for an estimated 778,266 people living within a 50-mile radius of the plant site. Doses from external pathways and inhalation are based on the 50-mile human population distribution. Ingestion population doses are calculated assuming that each individual consumed milk, vegetables, and meat produced within the sector in which the individual resides.

Population doses due to liquid effluents are calculated for the entire downstream Tennessee River population. Water ingestion population doses are calculated using actual population figures for downstream public water supplies. Fish ingestion population doses are calculated assuming that all sport fish caught in the Tennessee River are consumed by the Tennessee River population. Recreation population doses are calculated using historical recreational data on the number of shoreline visits at downstream locations.

2012  
**BROWNS FERRY NUCLEAR PLANT**  
**UNITS 1, 2, AND 3**  
**EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

**RADIOLOGICAL IMPACT**

**6. Population Doses (Continued)**

Population doses calculated for airborne and liquid effluents are presented in Tables 4 and 5

**7. Offsite Direct Radiation Dose**

External gamma radiation levels were measured by environmental dosimeters deployed around BFN as part of the offsite Radiological Environmental Monitoring Program (REMP). The quarterly gamma radiation levels determined from these dosimeters during this reporting period averaged approximately 18 mrem/quarter at onsite (at or near the site boundary) stations and approximately 15 mrem/quarter at offsite stations or approximately 2.5 mrem/quarter higher onsite than at offsite stations. This difference is consistent with levels measured for pre-operation and construction phases of the Tennessee Valley Authority nuclear plants where the average radiation levels onsite were generally 2-6 mrem/quarter higher than the levels offsite. This may be attributable to natural variations in environmental radiation levels, earth moving activities onsite, the mass of concrete employed in the construction of the plants, or other undetermined influences. Fluctuations in natural background dose rates and in dosimeter readings tend to mask any small increments which may be due to plant operations. Thus, there was no identifiable increase in dose rate levels attributable to direct radiation from plant equipment and/or gaseous effluents.

**8. Dose To A Member Of The Public Inside The Site Boundary**

Pursuant to ODCM Section 7.7.5, a review was performed to determine the highest dose to a member of the public in the site boundary. The dose to a member of the public consists of the sum of dose commitments from effluent releases as well as any direct radiation dose. The gaseous effluent dose commitment is negligible compared to the direct radiation dose.

The direct radiation dose was determined from area environmental dosimeters located onsite. It consisted of gamma dose from the plume, ground contamination, and from equipment sources (i.e., tanks, turbine shine, radioactive material storage areas, etc.). The critical location was determined to be a Thermoluminescent Dosimeter near the Livewell Center (Training Center). The direct radiation dose accounting for background and occupancy was 0.63 mrem during 2012.

The total annual dose commitment to a member of the public for 2012 is 0.63 mrem. It can be concluded that the dose limit for a member of the public at the site boundary as specified in 10 CFR 20.1301 was not exceeded.

2012  
BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT

**RADIOLOGICAL IMPACT**

**9. Total Dose**

To determine compliance with 40 CFR 190, annual total dose contributions to the maximum exposed individual from BFN radioactive effluents and all other nearby uranium fuel cycle sources are considered.

The annual dose to any organ other than the thyroid for the maximum exposed individual is conservatively calculated by summing the following doses: the total body air submersion dose for each quarter, the critical organ dose (for any organ other than the thyroid) from airborne effluents for each quarter from ground contamination, inhalation and ingestion, the total body dose from liquid effluents for each quarter, the maximum organ dose (for any organ other than the thyroid) from liquid effluents for each quarter, and any identifiable increase in direct radiation dose levels as measured by the REMP. This dose is compared to the 40 CFR 190 limit for total body or any organ dose (other than the thyroid) to determine compliance.

The annual thyroid dose to the maximum exposed individual is conservatively estimated by summing the following doses: the total body air submersion dose for each quarter, the thyroid dose from airborne effluents for each quarter, the total body dose from liquid effluents for each quarter, the thyroid dose from liquid effluents for each quarter, and any identifiable increase in direct radiation dose levels as measured by the REMP. This dose is compared to the 40 CFR 190 limit for thyroid dose to determine compliance.

Total dose from the fuel cycle is presented in Table 6.

**2012**  
**BROWNS FERRY NUCLEAR PLANT**  
**UNITS 1, 2, AND 3**  
**EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

**RADIOLOGICAL IMPACT**

**TABLE 4**  
**Page 1 of 4**  
**Doses from Airborne Effluents**

**First Quarter**

**Individual Doses**

Pathway	Dose	Quarterly Limit	Percent of Limit	Location
<b>External</b>				
Gamma Air	8.7E-10 mrad	5 mrad	< 1 %	NNW/1650 meters
Beta Air	2.7E-09 mrad	10 mrad	< 1 %	NNW/1650 meters
<b>Submersion</b>				
Total Body	1.4E-04 mrem	NA	NA	NNW/1650 meters
Skin	1.6E-04 mrem	NA	NA	NNW/1650 meters
<b>Organ Doses</b>				
Child/Bone	1.2E-01 mrem	7.5 mrem	1.6 %	NNW 1790 meters
Child/Thyroid	1.3E-01 mrem	7.5 mrem	1.7 %	NNW 1790 meters
Child/Total Body	1.1E-01 mrem	7.5 mrem	1.5 %	NNW 1790 meters

**Population Doses**

Total Body Dose      3.3E-01 man-rem

Maximum Organ Dose (organ)  3.6E-01 man-rem (thyroid)

*Population doses can be compared to the natural background dose for the entire 50-mile population of about 70,044 man-rem/year (based on 90 mrem/yr for natural background).*

**2012**  
**BROWNS FERRY NUCLEAR PLANT**  
**UNITS 1, 2, AND 3**  
**EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

**RADIOLOGICAL IMPACT**

**TABLE 4 (Continued)**  
**Page 2 of 4**  
**Doses from Airborne Effluents**

**Second Quarter\***

**Individual Doses**

Pathway	Dose	Quarterly Limit	Percent of Limit	Location
<b>External</b>				
Gamma Air	1.8E-10 mrad	5 mrad	< 1 %	NW/2275 meters
Beta Air	3.5E-10 mrad	10 mrad	< 1 %	S/2250 meters
<b>Submersion</b>				
Total Body	9.3E-04 mrem	NA	NA	NNW/1650 meters
Skin	1.1E-03 mrem	NA	NA	NNW/1650 meters
<b>Organ Doses</b>				
Child/Bone	3.0E-02 mrem	7.5 mrem	< 1 %	NNW/1790 meters
Child/Thyroid	1.7E-02 mrem	7.5 mrem	< 1 %	NNW/1790 meters
Child/Total Body	1.2E-02 mrem	7.5 mrem	< 1 %	NNW/1790 meters

**Population Doses**

Total Body Dose      1.3E-01 man-rem

Maximum Organ Dose (organ)  5.1E-01 man-rem (bone)

*Population doses can be compared to the natural background dose for the entire 50-mile population of about 70,044 man-rem/year (based on 90 mrem/yr for natural background).*

\* Includes dose from abnormal releases.

2012  
**BROWNS FERRY NUCLEAR PLANT**  
**UNITS 1, 2, AND 3**  
**EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

**RADIOLOGICAL IMPACT**

**TABLE 4 (Continued)**  
**Page 3 of 4**  
**Doses from Airborne Effluents**

**Third Quarter**

**Individual Doses**

Pathway	Dose	Quarterly Limit	Percent of Limit	Location
<b>External</b>				
Gamma Air	2.6-06 mrad	5 mrad	< 1 %	N/4900 meters
Beta Air	4.1E-06 mrad	10 mrad	< 1 %	N/4900 meters
<b>Submersion</b>				
Total Body	1.4E-03 mrem	NA	NA	E/1410 meters
Skin	1.6E-03 mrem	NA	NA	E/1410 meters
<b>Organ Doses</b>				
Child/Bone	3.4E-02 mrem	7.5 mrem	< 1 %	E/1410 meters
Child/Thyroid	2.1E-02 mrem	7.5 mrem	< 1 %	E/1410 meters
Child/Total Body	1.3E-02 mrem	7.5 mrem	< 1 %	NNW/1790 meters

**Population Doses**

Total Body Dose      1.8E-01 man-rem

Maximum Organ Dose (organ)    7.6E-01 man-rem (bone)

*Population doses can be compared to the natural background dose for the entire 50-mile population of about 70,044 man-rem/year (based on 90 mrem/yr for natural background).*

**2012**  
**BROWNS FERRY NUCLEAR PLANT**  
**UNITS 1, 2, AND 3**  
**EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

**RADIOLOGICAL IMPACT**

**TABLE 4 (Continued)**  
**Page 4 of 4**  
**Doses from Airborne Effluents**

**Fourth Quarter\***

**Individual Doses**

Pathway	Dose	Quarterly Limit	Percent of Limit	Location
<b>External</b>				
Gamma Air	2.6E-10 mrad	5 mrad	< 1 %	S/2250 meters
Beta Air	7.9E-10 mrad	10 mrad	< 1 %	S/2250 meters
<b>Submersion</b>				
Total Body	6.9E-4 mrem	NA	NA	ESE/1750 meters
Skin	8.1E-04 mrem	NA	NA	ESE/1750 meters
<b>Organ Doses</b>				
Child/ Bone	2.2E-02 mrem	7.5 mrem	< 1 %	N/2540 meters
Child/Thyroid	1.3E-02 mrem	7.5 mrem	< 1 %	NNW/1790 meters
Child /Total Body	9.4E-03 mrem	7.5 mrem	< 1 %	NNW/1790 meters

**Population Doses**

Total Body Dose      1.2E-01 man-rem

Maximum Organ Dose (organ)  4.6E-01 man-rem (bone)

*Population doses can be compared to the natural background dose for the entire 50-mile population of about 70,044 man-rem/year (based on 90 mrem/yr for natural background).*

\* Includes dose from abnormal releases.

**2012**  
**BROWNS FERRY NUCLEAR PLANT**  
**UNITS 1, 2, AND 3**  
**EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

**RADIOLOGICAL IMPACT**

**Table 5**  
**Page 1 of 4**  
**Doses from Liquid Effluents**

**First Quarter**

**Individual Doses (mrem)**

Age Group	Organ	Dose Pathway	Dose	Quarterly Limit	Percent of Limit
<b>Adult</b>	<b>Total Body</b>	Fish Ingestion	9.0E-05		
		Recreation	1.3E-05		
		Water Ingestion	7.1E-06		
		<b>Total</b>	<b>1.1E-04</b>	1.5 mrem	< 1 %
<b>Adult</b>	<b>Liver</b>	Fish Ingestion	1.4E-04		
		Recreation	1.3E-05		
		Water Ingestion	7.9E-06		
		<b>Total</b>	<b>6.1E-05</b>	5 mrem	< 1 %
<b>Child</b>	<b>Thyroid</b>	Fish Ingestion	9.0E-08		
		Recreation	1.3E-05		
		Water Ingestion	7.3E-06		
		<b>Total</b>	<b>2.0E-05</b>	5 mrem	< 1 %

Average Riverflow past BFN (cubic feet per second): 74339

**Population Doses**

Total Body Dose      8.1E-04 man-rem

Maximum Organ Dose (organ) 1.3E-03 man-rem (liver)

*Population doses can be compared to the natural background dose for the entire 50-mile population of about 70,044 man-rem/year (based on 90 mrem/yr for natural background).*

**2012**  
**BROWNS FERRY NUCLEAR PLANT**  
**UNITS 1, 2, AND 3**  
**EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

**RADIOLOGICAL IMPACT**

**Table 5 (Continued)**  
**Page 2 of 4**  
**Doses from Liquid Effluents**

**Second Quarter**

**Individual Doses (mrem)**

Age Group	Organ	Dose Pathway	Dose	Quarterly Limit	Percent of Limit
<b>Child</b>	<b>Total Body</b>	Fish Ingestion	5.9E-07		
		Recreation	0.0E+00		
		Water Ingestion	4.7E-05		
		<b>Total</b>	<b>4.8E-05</b>	1.5 mrem	< 1 %
<b>Child</b>	<b>Liver**</b>	Fish Ingestion	5.9E3-07		
		Recreation	0.0E+00		
		Water Ingestion	4.7E-05		
		<b>Total</b>	<b>4.8E-05</b>	5 mrem	< 1 %
<b>Child</b>	<b>Thyroid</b>	Fish Ingestion	5.9E-07		
		Recreation	0.0E+00		
		Water Ingestion	4.7E-05		
		<b>Total</b>	<b>4.8E-05</b>	5 mrem	< 1 %

Average Riverflow past BFN (cubic feet per second): 13255

**Population Doses**

Total Body Dose      8.1E-04 man-rem

Maximum Organ Dose (organ)    8.1E-04 man-rem (liver\*\*)

*Population doses can be compared to the natural background dose for the entire 50-mile population of about 70,044 man-rem/year (based on 90 mrem/yr for natural background).*

\* Includes dose from abnormal releases.

\*\*All organ doses are equal.

**2012**  
**BROWNS FERRY NUCLEAR PLANT**  
**UNITS 1, 2, AND 3**  
**EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

**RADIOLOGICAL IMPACT**

**Table 5 (Continued)**  
**Page 3 of 4**  
**Doses from Liquid Effluents**

**Third Quarter\***

**Individual Doses (mrem)**

<b>Age Group</b>	<b>Organ</b>	<b>Dose Pathway</b>	<b>Dose</b>	<b>Quarterly Limit</b>	<b>Percent of Limit</b>
<b>Child</b>	<b>Total Body</b>	Fish Ingestion	1.5E-07		
		Recreation	0.0E+00		
		Water Ingestion	1.2E-05		
		<b>Total</b>	<b>1.2E-05</b>	1.5 mrem	< 1 %
<b>Child</b>	<b>Liver**</b>	Fish Ingestion	1.5E-07		
		Recreation	0.0E+00		
		Water Ingestion	1.2E-05		
		<b>Total</b>	<b>1.2E-05</b>	5 mrem	< 1 %
<b>Child</b>	<b>Thyroid</b>	Fish Ingestion	1.5E-07		
		Recreation	0.0E+00		
		Water Ingestion	1.2E-05		
		<b>Total</b>	<b>1.2E-05</b>	5 mrem	< 1 %

Average Riverflow past BFN (cubic feet per second): 27679

**Population Doses**

Total Body Dose      2.0E-04 man-rem

Maximum Organ Dose (organ) 2.0E-04 man-rem (liver\*\*)

*Population doses can be compared to the natural background dose for the entire 50-mile population of about 70,044 man-rem/year (based on 90 mrem/yr for natural background).*

\* Includes dose from abnormal releases.

\*\*All organ doses are equal.

**2012**  
**BROWNS FERRY NUCLEAR PLANT**  
**UNITS 1, 2, AND 3**  
**EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

**RADIOLOGICAL IMPACT**

**Table 5 (Continued)**  
**Page 4 of 4**  
**Doses from Liquid Effluents**

**Fourth Quarter\***

**Individual Doses (mrem)**

Age Group	Organ	Dose Pathway	Dose	Quarterly Limit	Percent of Limit
<b>Child</b>	<b>Total Body</b>	Fish Ingestion	7.4E-07		
		Recreation	0.0E+00		
		Water Ingestion	6.0E-05		
		<b>Total</b>	<b>6.1E-05</b>	1.5 mrem	< 1 %
<b>Child</b>	<b>Liver**</b>	Fish Ingestion	7.4E-07		
		Recreation	0.0E+00		
		Water Ingestion	6.0E-05		
		<b>Total</b>	<b>6.1E-05</b>	5 mrem	< 1 %
<b>Child</b>	<b>Thyroid</b>	Fish Ingestion	7.4E-07		
		Recreation	0.0E+00		
		Water Ingestion	6.0E-05		
		<b>Total</b>	<b>6.1E-05</b>	5 mrem	< 1 %

Average Riverflow past BFN (cubic feet per second): 36693

**Population Doses**

Total Body Dose      9.8E-04 man-rem

Maximum Organ Dose (organ)  9.8E-04 man-rem (liver\*\*)

*Population doses can be compared to the natural background dose for the entire 50-mile population of about 70,044 man-rem/year (based on 90 mrem/yr for natural background).*

\* Includes dose from abnormal releases.

**2012**  
**BROWNS FERRY NUCLEAR PLANT**  
**UNITS 1, 2, AND 3**  
**EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

**RADIOLOGICAL IMPACT**

**Table 6**  
**Page 1 of 1**  
**Total Dose from Fuel Cycle**

Dose	First Quarter	Second Quarter	Third Quarter	Fourth Quarter	
<b>Total Body or any Organ (except thyroid)</b>					
Total body air submersion	1.4E-04	9.3E-04	1.4E-03	6.9E-04	
Critical organ dose (air)	1.2E-01	3.0E-02	3.4E-02	2.2E-02	
Total body dose (liquid)	1.1E-04	4.8E-05	1.2E-05	6.1E-05	
Maximum organ dose (liquid)	6.1E-05	4.8E-05	1.2E-05	6.1E-05	
Direct Radiation Dose	0.0E+00	0.0E+00	0.0E+00	0.0E+00	
<b>Total</b>	<b>1.2E-01</b>	<b>3.1E-02</b>	<b>3.5E-02</b>	<b>2.3E-02</b>	
<b>Cumulative Total Dose (mrem) (Total body or any other organ)</b>					<b>2.1E-01</b>
<b>Annual Dose Limit (mrem)</b>					<b>2.5E+01</b>
<b>Percent of Limit</b>					<b>&lt; 1 %</b>
<b>Thyroid Dose (mrem)</b>					
Total body air submersion	1.4E-04	9.3E-04	1.4E-03	6.9E-04	
Thyroid dose (airborne)	1.3E-01	1.7E-02	2.1E-02	1.3E-02	
Total body dose (liquid)	1.1E-04	4.8E-05	1.2E-05	6.1E-05	
Thyroid dose (liquid)	2.0E-05	4.8E-05	1.2E-05	6.1E-05	
Direct Radiation Dose	0.0E+00	0.0E+00	0.0E+00	0.0E+00	
<b>Total</b>	<b>1.3E-01</b>	<b>1.8E-02</b>	<b>2.2E-02</b>	<b>1.4E-02</b>	
<b>Cumulative Total Dose (Thyroid) mrem</b>					<b>1.8E-01</b>
<b>Annual Dose Limit (mrem)</b>					<b>7.5E+01</b>
<b>Percent of Limit</b>					<b>&lt; 1 %</b>

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

**BROWNS FERRY NUCLEAR PLANT**

**2012 METEOROLOGICAL DATA**

**TABLE 7A**

**JOINT FREQUENCY DISTRIBUTION IN PERCENT**

**FOR GROUND LEVEL RELEASES**

**FIRST QUARTER**

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS A                    (DELTA T<=-1.9 C/100 M)

BROWNS FERRY NUCLEAR PLANT

JAN 1, 2012 - MAR 31, 2012

WIND DIRECTION	CALM	WIND SPEED (MPH)									TOTAL
		0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5		
N	0.000	0.000	0.000	0.000	0.000	0.143	0.000	0.000	0.000	0.143	
NNE	0.000	0.000	0.000	0.000	0.000	0.048	0.000	0.000	0.000	0.048	
NE	0.000	0.000	0.000	0.000	0.000	0.048	0.000	0.000	0.000	0.048	
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
E	0.000	0.000	0.048	0.000	0.000	0.000	0.000	0.000	0.000	0.048	
ESE	0.000	0.000	0.000	0.143	0.000	0.000	0.000	0.000	0.000	0.143	
SE	0.000	0.000	0.238	0.571	0.190	0.095	0.000	0.000	0.000	1.094	
SSE	0.000	0.000	0.238	0.571	0.000	0.000	0.000	0.000	0.000	0.809	
S	0.000	0.000	0.190	0.523	0.000	0.000	0.000	0.000	0.000	0.714	
SSW	0.000	0.000	0.000	0.238	0.095	0.000	0.000	0.000	0.000	0.333	
SW	0.000	0.000	0.000	0.190	0.143	0.000	0.000	0.000	0.000	0.333	
WSW	0.000	0.000	0.000	0.000	0.095	0.048	0.000	0.000	0.000	0.143	
W	0.000	0.000	0.000	0.000	0.000	0.095	0.000	0.000	0.000	0.095	
WNW	0.000	0.000	0.000	0.000	0.048	0.048	0.048	0.000	0.000	0.143	
NW	0.000	0.000	0.000	0.000	0.048	0.000	0.000	0.048	0.000	0.095	
NNW	0.000	0.000	0.000	0.000	0.000	0.095	0.048	0.000	0.000	0.143	
SUBTOTAL	0.000	0.000	0.714	2.236	0.618	0.618	0.095	0.048	0.000	4.329	

TOTAL HOURS OF VALID STABILITY OBSERVATIONS	2107
TOTAL HOURS OF STABILITY CLASS A	91
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS A	91
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS	2102
TOTAL HOURS CALM	0

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS  
 WIND SPEED AND DIRECTION MEASURED AT 10.50 METER LEVEL

MEAN WIND SPEED = 5.48

DATE PRINTED: 2012/05/15

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS B      (-1.9 < DELTA T <=-1.7 C/100 M)

BROWNS FERRY NUCLEAR PLANT

JAN 1, 2012 - MAR 31, 2012

WIND DIRECTION	WIND SPEED (MPH)										TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5		
N	0.000	0.000	0.000	0.048	0.000	0.000	0.000	0.000	0.000	0.048	
NNE	0.000	0.000	0.000	0.000	0.048	0.000	0.000	0.000	0.000	0.048	
NE	0.000	0.000	0.000	0.000	0.000	0.048	0.000	0.000	0.000	0.048	
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
ESE	0.000	0.000	0.000	0.048	0.000	0.048	0.000	0.000	0.000	0.095	
SE	0.000	0.000	0.143	0.428	0.095	0.000	0.000	0.000	0.000	0.666	
SSE	0.000	0.000	0.000	0.143	0.000	0.000	0.000	0.000	0.000	0.143	
S	0.000	0.000	0.000	0.190	0.000	0.000	0.000	0.000	0.000	0.190	
SSW	0.000	0.000	0.095	0.048	0.000	0.000	0.000	0.000	0.000	0.143	
SW	0.000	0.000	0.048	0.095	0.000	0.000	0.000	0.000	0.000	0.143	
WSW	0.000	0.000	0.000	0.095	0.048	0.000	0.000	0.000	0.000	0.143	
W	0.000	0.000	0.000	0.000	0.048	0.143	0.000	0.000	0.000	0.190	
WNW	0.000	0.000	0.000	0.000	0.000	0.048	0.190	0.000	0.000	0.238	
NW	0.000	0.000	0.000	0.000	0.048	0.000	0.095	0.048	0.000	0.190	
NNW	0.000	0.000	0.000	0.000	0.000	0.048	0.143	0.000	0.000	0.190	
SUBTOTAL	0.000	0.000	0.285	1.094	0.285	0.333	0.428	0.048	0.000	2.474	

TOTAL HOURS OF VALID STABILITY OBSERVATIONS	2107
TOTAL HOURS OF STABILITY CLASS B	52
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS B	52
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS	2102
TOTAL HOURS CALM	0

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS  
 WIND SPEED AND DIRECTION MEASURED AT 10.50 METER LEVEL

MEAN WIND SPEED = 7.06

DATE PRINTED: 2012/05/15

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS C      (-1.7 < DELTA T <=-1.5 C/100 M)

**BROWNS FERRY NUCLEAR PLANT**

JAN 1, 2012 - MAR 31, 2012

WIND DIRECTION	WIND SPEED (MPH)									TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5	
N	0.000	0.000	0.000	0.048	0.095	0.190	0.000	0.000	0.000	0.333
NNE	0.000	0.000	0.000	0.000	0.143	0.190	0.000	0.000	0.000	0.333
NE	0.000	0.000	0.000	0.000	0.000	0.095	0.000	0.000	0.000	0.095
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
E	0.000	0.000	0.000	0.000	0.000	0.048	0.000	0.000	0.000	0.048
ESE	0.000	0.000	0.048	0.048	0.000	0.000	0.000	0.000	0.000	0.095
SE	0.000	0.000	0.143	0.285	0.048	0.000	0.000	0.000	0.000	0.476
SSE	0.000	0.000	0.095	0.095	0.000	0.000	0.000	0.000	0.000	0.190
S	0.000	0.000	0.095	0.190	0.000	0.000	0.000	0.000	0.000	0.285
SSW	0.000	0.000	0.048	0.048	0.000	0.000	0.000	0.000	0.000	0.095
SW	0.000	0.000	0.048	0.048	0.000	0.000	0.000	0.000	0.000	0.095
WSW	0.000	0.000	0.000	0.095	0.000	0.095	0.000	0.000	0.000	0.190
W	0.000	0.000	0.000	0.000	0.095	0.143	0.000	0.000	0.000	0.238
WNW	0.000	0.000	0.000	0.048	0.000	0.285	0.285	0.048	0.000	0.666
NW	0.000	0.000	0.000	0.000	0.048	0.238	0.048	0.095	0.000	0.428
NNW	0.000	0.000	0.000	0.000	0.000	0.190	0.238	0.000	0.000	0.428
SUBTOTAL	0.000	0.000	0.476	0.904	0.428	1.475	0.571	0.143	0.000	3.996

TOTAL HOURS OF VALID STABILITY OBSERVATIONS	2107
TOTAL HOURS OF STABILITY CLASS C	85
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS C	84
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS	2102
TOTAL HOURS CALM	0

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS  
WIND SPEED AND DIRECTION MEASURED AT 10.50 METER LEVEL

MEAN WIND SPEED = 8.35

DATE PRINTED: 2012/05/15

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS D      (-1.5 < DELTA T <= -0.5 C/100 M)

BROWNS FERRY NUCLEAR PLANT

JAN 1, 2012 - MAR 31, 2012

WIND DIRECTION	CALM	WIND SPEED (MPH)									TOTAL
		0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5		
N	0.000	0.000	0.095	0.714	0.333	0.333	0.143	0.000	0.000	1.618	
NNE	0.000	0.000	0.095	0.428	0.381	0.523	0.095	0.000	0.000	1.522	
NE	0.000	0.000	0.143	0.428	0.285	0.143	0.000	0.000	0.000	0.999	
ENE	0.000	0.000	0.048	0.333	0.285	0.143	0.000	0.000	0.000	0.809	
E	0.000	0.000	0.000	0.285	0.000	0.000	0.000	0.000	0.000	0.285	
ESE	0.000	0.000	0.190	0.333	0.285	0.000	0.000	0.000	0.000	0.809	
SE	0.000	0.000	0.381	0.714	0.333	0.000	0.000	0.000	0.000	1.427	
SSE	0.000	0.000	0.523	0.190	0.048	0.048	0.000	0.000	0.000	0.809	
S	0.000	0.000	0.618	0.238	0.095	0.000	0.000	0.000	0.000	0.951	
SSW	0.000	0.000	0.428	0.285	0.048	0.048	0.000	0.000	0.000	0.809	
SW	0.000	0.000	0.190	0.095	0.000	0.048	0.000	0.000	0.000	0.333	
WSW	0.000	0.048	0.238	0.428	0.523	0.285	0.000	0.000	0.000	1.522	
W	0.000	0.000	0.095	0.333	0.238	1.094	0.190	0.000	0.000	1.951	
WNW	0.000	0.000	0.143	0.143	0.761	0.951	0.904	0.143	0.000	3.045	
NW	0.000	0.000	0.048	0.381	0.381	1.475	0.714	0.095	0.000	3.092	
NNW	0.000	0.000	0.190	0.381	0.523	1.284	0.523	0.095	0.000	2.997	
SUBTOTAL	0.000	0.048	3.425	5.709	4.520	6.375	2.569	0.333	0.000	22.978	

TOTAL HOURS OF VALID STABILITY OBSERVATIONS	2107
TOTAL HOURS OF STABILITY CLASS D	485
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS D	483
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS	2102
TOTAL HOURS CALM	0

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS  
WIND SPEED AND DIRECTION MEASURED AT 10.50 METER LEVEL

MEAN WIND SPEED = 7.34

DATE PRINTED: 2012/05/15

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS E      (-0.5 < DELTA T <= 1.5 C/100 M)

BROWNS FERRY NUCLEAR PLANT

JAN 1, 2012 - MAR 31, 2012

WIND DIRECTION	CALM	WIND SPEED (MPH)									TOTAL
		0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5		
N	0.000	0.000	0.856	0.428	0.381	0.143	0.048	0.000	0.000	1.855	
NNE	0.000	0.048	0.761	0.761	0.476	0.143	0.000	0.000	0.000	2.188	
NE	0.000	0.000	0.714	0.333	0.381	0.095	0.000	0.000	0.000	1.522	
ENE	0.000	0.190	0.333	0.714	0.095	0.000	0.000	0.000	0.000	1.332	
E	0.000	0.095	0.951	0.285	0.000	0.000	0.000	0.000	0.000	1.332	
ESE	0.000	0.143	1.047	2.236	0.714	0.143	0.000	0.000	0.000	4.282	
SE	0.000	0.143	1.332	1.094	0.381	0.190	0.000	0.000	0.000	3.140	
SSE	0.000	0.333	2.093	0.428	0.000	0.095	0.000	0.000	0.000	2.950	
S	0.000	0.238	0.904	1.237	0.714	0.571	0.000	0.000	0.000	3.663	
SSW	0.000	0.048	0.714	0.571	0.618	0.714	0.000	0.000	0.000	2.664	
SW	0.000	0.095	0.571	0.095	0.048	0.048	0.000	0.000	0.000	0.856	
WSW	0.000	0.048	0.571	0.381	0.190	0.095	0.000	0.000	0.000	1.284	
W	0.000	0.048	0.428	0.809	0.190	0.285	0.048	0.000	0.000	1.808	
WNW	0.000	0.000	0.190	0.333	0.095	0.190	0.095	0.000	0.000	0.904	
NW	0.000	0.048	0.381	0.714	0.571	1.475	0.618	0.000	0.000	3.806	
NNW	0.000	0.000	0.285	0.618	0.523	0.714	0.333	0.000	0.000	2.474	
SUBTOTAL	0.000	1.475	12.131	11.037	5.376	4.900	1.142	0.000	0.000	36.061	

TOTAL HOURS OF VALID STABILITY OBSERVATIONS	2107
TOTAL HOURS OF STABILITY CLASS E	759
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS E	758
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS	2102
TOTAL HOURS CALM	0

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS  
 WIND SPEED AND DIRECTION MEASURED AT 10.50 METER LEVEL

MEAN WIND SPEED = 4.90

DATE PRINTED: 2012/05/15

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS F      ( 1.5 < DELTA T <= 4.0 C/100 M)

BROWNS FERRY NUCLEAR PLANT

JAN 1, 2012 - MAR 31, 2012

WIND DIRECTION	CALM	WIND SPEED (MPH)									TOTAL
		0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5		
N	0.000	0.000	0.904	0.571	0.000	0.048	0.000	0.000	0.000	1.522	
NNE	0.000	0.048	0.571	0.571	0.333	0.048	0.048	0.000	0.000	1.618	
NE	0.000	0.048	0.476	0.143	0.048	0.000	0.000	0.000	0.000	0.714	
ENE	0.000	0.190	0.476	0.143	0.000	0.000	0.000	0.000	0.000	0.809	
E	0.000	0.143	0.571	0.761	0.000	0.000	0.000	0.000	0.000	1.475	
ESE	0.000	0.381	0.428	0.428	0.000	0.000	0.000	0.000	0.000	1.237	
SE	0.000	0.333	1.713	0.428	0.095	0.000	0.000	0.000	0.000	2.569	
SSE	0.000	0.190	2.617	0.381	0.000	0.000	0.000	0.000	0.000	3.187	
S	0.000	0.238	1.665	0.761	0.714	0.285	0.000	0.000	0.000	3.663	
SSW	0.000	0.048	0.285	0.333	0.285	0.285	0.000	0.000	0.000	1.237	
SW	0.000	0.048	0.238	0.048	0.000	0.000	0.000	0.000	0.000	0.333	
WSW	0.000	0.048	0.190	0.048	0.000	0.000	0.000	0.000	0.000	0.285	
W	0.000	0.000	0.190	0.000	0.000	0.048	0.000	0.000	0.000	0.238	
WNW	0.000	0.000	0.190	0.000	0.000	0.000	0.000	0.000	0.000	0.190	
NW	0.000	0.000	0.285	0.095	0.000	0.000	0.000	0.000	0.000	0.381	
NNW	0.000	0.000	0.714	0.523	0.143	0.000	0.000	0.000	0.000	1.380	
SUBTOTAL	0.000	1.713	11.513	5.233	1.618	0.714	0.048	0.000	0.000	20.837	

TOTAL HOURS OF VALID STABILITY OBSERVATIONS	2107
TOTAL HOURS OF STABILITY CLASS F	438
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS F	438
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS	2102
TOTAL HOURS CALM	0

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS  
 WIND SPEED AND DIRECTION MEASURED AT 10.50 METER LEVEL

MEAN WIND SPEED = 3.32

DATE PRINTED: 2012/05/15

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS G                   (DELTA T > 4.0 C/100 M)

BROWNS FERRY NUCLEAR PLANT

JAN 1, 2012 - MAR 31, 2012

WIND DIRECTION	CALM	WIND SPEED (MPH)									TOTAL
		0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5		
N	0.005	0.238	0.618	0.428	0.000	0.000	0.000	0.000	0.000	1.290	
NNE	0.003	0.095	0.381	0.048	0.000	0.190	0.048	0.000	0.000	0.764	
NE	0.001	0.190	0.048	0.095	0.095	0.048	0.000	0.000	0.000	0.477	
ENE	0.002	0.095	0.238	0.000	0.000	0.000	0.000	0.000	0.000	0.335	
E	0.002	0.238	0.048	0.000	0.000	0.000	0.000	0.000	0.000	0.287	
ESE	0.004	0.428	0.285	0.000	0.000	0.000	0.000	0.000	0.000	0.718	
SE	0.006	0.523	0.428	0.000	0.000	0.000	0.000	0.000	0.000	0.957	
SSE	0.015	0.571	2.046	0.143	0.000	0.000	0.000	0.000	0.000	2.775	
S	0.007	0.285	0.904	0.095	0.000	0.000	0.000	0.000	0.000	1.292	
SSW	0.000	0.000	0.048	0.000	0.000	0.000	0.000	0.000	0.000	0.048	
SW	0.000	0.000	0.048	0.000	0.000	0.000	0.000	0.000	0.000	0.048	
WSW	0.000	0.048	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.048	
W	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
NW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
NNW	0.001	0.095	0.143	0.048	0.000	0.000	0.000	0.000	0.000	0.287	
SUBTOTAL	0.048	2.807	5.233	0.856	0.095	0.238	0.048	0.000	0.000	9.324	

TOTAL HOURS OF VALID STABILITY OBSERVATIONS	2107
TOTAL HOURS OF STABILITY CLASS G	197
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS G	196
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS	2102
TOTAL HOURS CALM	1

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS  
 WIND SPEED AND DIRECTION MEASURED AT 10.50 METER LEVEL

MEAN WIND SPEED = 2.31

DATE PRINTED: 2012/05/15

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

**BROWNS FERRY NUCLEAR PLANT**

**2012 METEOROLOGICAL DATA**

**TABLE 7B**

**JOINT FREQUENCY DISTRIBUTION IN PERCENT**

**FOR GROUND LEVEL RELEASES**

**SECOND QUARTER**

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS A (DELTA T<=-1.9 C/100 M)

## BROWNS FERRY NUCLEAR PLANT

APR 1, 2012 - JUN 30, 2012

WIND DIRECTION	CALM	WIND SPEED (MPH)									TOTAL
		0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5		
N	0.000	0.000	0.000	0.000	0.275	0.505	0.000	0.000	0.000	0.780	
NNE	0.000	0.000	0.000	0.000	0.275	0.550	0.000	0.000	0.000	0.826	
NE	0.000	0.000	0.000	0.000	0.046	0.229	0.000	0.000	0.000	0.275	
ENE	0.000	0.000	0.046	0.046	0.000	0.000	0.000	0.000	0.000	0.092	
E	0.000	0.000	0.046	0.000	0.000	0.000	0.000	0.000	0.000	0.046	
ESE	0.000	0.000	0.138	0.459	0.183	0.000	0.000	0.000	0.000	0.780	
SE	0.000	0.000	0.780	1.835	0.000	0.000	0.000	0.000	0.000	2.615	
SSE	0.000	0.000	1.422	1.284	0.000	0.000	0.000	0.000	0.000	2.706	
S	0.000	0.000	1.743	0.734	0.000	0.000	0.000	0.000	0.000	2.477	
SSW	0.000	0.000	0.780	0.642	0.000	0.000	0.000	0.000	0.000	1.422	
SW	0.000	0.000	0.046	0.550	0.000	0.000	0.000	0.000	0.000	0.596	
WSW	0.000	0.000	0.000	0.505	0.092	0.000	0.000	0.000	0.000	0.596	
W	0.000	0.000	0.000	0.550	0.092	0.092	0.000	0.000	0.000	0.734	
WNW	0.000	0.000	0.000	0.092	0.183	0.092	0.046	0.000	0.000	0.413	
NW	0.000	0.000	0.000	0.000	0.092	0.367	0.413	0.000	0.000	0.872	
NNW	0.000	0.000	0.000	0.000	0.229	0.688	0.229	0.000	0.000	1.147	
SUBTOTAL	0.000	0.000	5.000	6.697	1.468	2.523	0.688	0.000	0.000	16.376	

TOTAL HOURS OF VALID STABILITY OBSERVATIONS 2180

TOTAL HOURS OF VARIOUS STABILITY OBSERVATIONS 2100  
TOTAL HOURS OF STABILITY CLASS A 357

TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS A 357

TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS A 2180

TOTAL HOURS CALM

Digitized by srujanika@gmail.com

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS  
WIND SPEED AND DIRECTION MEASURED AT 10.50 METER LEVEL

MEAN WIND SPEED = 5.34

DATE PRINTED: 2012/08/20

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS B      (-1.9 < DELTA T <=-1.7 C/100 M)

BROWNS FERRY NUCLEAR PLANT

APR 1, 2012 - JUN 30, 2012

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)						>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4			
N	0.000	0.000	0.046	0.000	0.229	0.321	0.000	0.000	0.000	0.000	0.596
NNE	0.000	0.000	0.000	0.000	0.138	0.138	0.000	0.000	0.000	0.000	0.275
NE	0.000	0.000	0.000	0.046	0.138	0.138	0.000	0.000	0.000	0.000	0.321
ENE	0.000	0.000	0.000	0.000	0.092	0.000	0.000	0.000	0.000	0.000	0.092
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ESE	0.000	0.000	0.000	0.459	0.046	0.000	0.000	0.000	0.000	0.000	0.505
SE	0.000	0.000	0.275	0.092	0.000	0.000	0.000	0.000	0.000	0.000	0.367
SSE	0.000	0.000	0.367	0.046	0.000	0.000	0.000	0.000	0.000	0.000	0.413
S	0.000	0.000	0.367	0.138	0.000	0.000	0.000	0.000	0.000	0.000	0.505
SSW	0.000	0.000	0.275	0.138	0.000	0.000	0.000	0.000	0.000	0.000	0.413
SW	0.000	0.000	0.092	0.092	0.000	0.000	0.000	0.000	0.000	0.000	0.183
WSW	0.000	0.000	0.046	0.183	0.092	0.000	0.000	0.000	0.000	0.000	0.321
W	0.000	0.000	0.046	0.138	0.046	0.000	0.000	0.000	0.000	0.000	0.229
WNW	0.000	0.000	0.000	0.138	0.138	0.092	0.000	0.000	0.000	0.000	0.367
NW	0.000	0.000	0.000	0.000	0.183	0.229	0.138	0.000	0.000	0.000	0.550
NNW	0.000	0.000	0.000	0.000	0.000	0.183	0.046	0.000	0.000	0.000	0.229
SUBTOTAL	0.000	0.000	1.514	1.468	1.101	1.101	0.183	0.000	0.000	0.000	5.367

TOTAL HOURS OF VALID STABILITY OBSERVATIONS	2180
TOTAL HOURS OF STABILITY CLASS B	117
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS B	117
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS	2180
TOTAL HOURS CALM	0

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS  
 WIND SPEED AND DIRECTION MEASURED AT 10.50 METER LEVEL

DATE PRINTED: 2012/08/20

MEAN WIND SPEED = 5.65

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS C            (-1.7 < DELTA T <=-1.5 C/100 M)

BROWNS FERRY NUCLEAR PLANT

APR 1, 2012 - JUN 30, 2012

WIND DIRECTION	CALM	WIND SPEED (MPH)									TOTAL
		0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5		
N	0.000	0.000	0.000	0.183	0.092	0.092	0.000	0.000	0.000	0.367	
NNE	0.000	0.000	0.000	0.046	0.138	0.092	0.000	0.000	0.000	0.275	
NE	0.000	0.000	0.046	0.046	0.000	0.000	0.000	0.000	0.000	0.092	
ENE	0.000	0.000	0.000	0.046	0.046	0.000	0.000	0.000	0.000	0.092	
E	0.000	0.000	0.046	0.046	0.046	0.000	0.000	0.000	0.000	0.138	
ESE	0.000	0.000	0.046	0.229	0.092	0.000	0.000	0.000	0.000	0.367	
SE	0.000	0.000	0.459	0.046	0.000	0.000	0.000	0.000	0.000	0.505	
SSE	0.000	0.000	0.321	0.000	0.000	0.000	0.000	0.000	0.000	0.321	
S	0.000	0.000	0.505	0.092	0.000	0.000	0.000	0.000	0.000	0.596	
SSW	0.000	0.000	0.229	0.138	0.000	0.000	0.000	0.000	0.000	0.367	
SW	0.000	0.000	0.275	0.046	0.000	0.000	0.000	0.000	0.000	0.321	
WSW	0.000	0.000	0.138	0.138	0.000	0.000	0.000	0.000	0.000	0.275	
W	0.000	0.000	0.092	0.183	0.046	0.000	0.000	0.000	0.000	0.321	
WNW	0.000	0.000	0.000	0.092	0.092	0.229	0.000	0.000	0.000	0.413	
NW	0.000	0.000	0.000	0.000	0.092	0.138	0.138	0.000	0.000	0.367	
NNW	0.000	0.000	0.000	0.092	0.046	0.183	0.000	0.000	0.000	0.321	
SUBTOTAL	0.000	0.000	2.156	1.422	0.688	0.734	0.138	0.000	0.000	5.138	

TOTAL HOURS OF VALID STABILITY OBSERVATIONS	2180
TOTAL HOURS OF STABILITY CLASS C	112
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS C	112
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS	2180
TOTAL HOURS CALM	0

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS  
WIND SPEED AND DIRECTION MEASURED AT 10.50 METER LEVEL

MEAN WIND SPEED = 4.92

DATE PRINTED: 2012/08/20

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS D      (-1.5 < DELTA T <= -0.5 C/100 M)

BROWNS FERRY NUCLEAR PLANT

APR 1, 2012 - JUN 30, 2012

WIND DIRECTION	WIND SPEED (MPH)									TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5	
N	0.000	0.000	0.092	0.642	0.734	0.459	0.046	0.000	0.000	1.972
NNE	0.000	0.000	0.092	0.505	0.367	0.275	0.000	0.000	0.000	1.239
NE	0.000	0.000	0.183	0.183	0.367	0.046	0.000	0.000	0.000	0.780
ENE	0.000	0.000	0.046	0.000	0.138	0.000	0.000	0.000	0.000	0.183
E	0.000	0.046	0.275	0.642	0.092	0.000	0.000	0.000	0.000	1.055
ESE	0.000	0.092	0.780	1.284	0.092	0.046	0.000	0.000	0.000	2.294
SE	0.000	0.000	0.826	0.000	0.000	0.000	0.000	0.000	0.000	0.826
SSE	0.000	0.046	1.284	0.092	0.000	0.000	0.000	0.000	0.000	1.422
S	0.000	0.000	0.550	0.092	0.000	0.000	0.000	0.000	0.000	0.642
SSW	0.000	0.046	0.780	0.321	0.000	0.000	0.000	0.000	0.000	1.147
SW	0.000	0.092	0.596	0.183	0.000	0.000	0.000	0.000	0.000	0.872
WSW	0.000	0.000	1.101	0.321	0.229	0.046	0.000	0.000	0.000	1.697
W	0.000	0.046	0.413	0.872	0.459	0.229	0.000	0.000	0.000	2.018
WNW	0.000	0.000	0.229	0.550	0.780	1.101	0.000	0.000	0.000	2.661
NW	0.000	0.000	0.138	0.596	0.642	0.963	0.092	0.000	0.000	2.431
NNW	0.000	0.000	0.275	0.734	0.688	0.780	0.046	0.000	0.000	2.523
SUBTOTAL	0.000	0.367	7.661	7.018	4.587	3.945	0.183	0.000	0.000	23.761

TOTAL HOURS OF VALID STABILITY OBSERVATIONS	2180
TOTAL HOURS OF STABILITY CLASS D	518
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS D	518
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS	2180
TOTAL HOURS CALM	0

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS  
WIND SPEED AND DIRECTION MEASURED AT 10.50 METER LEVEL

MEAN WIND SPEED = 5.00

DATE PRINTED: 2012/08/20

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR  
STABILITY CLASS E      (-0.5 < DELTA T <= 1.5 C/100 M)

BROWNS FERRY NUCLEAR PLANT

APR 1, 2012 - JUN 30, 2012

WIND DIRECTION	CALM	WIND SPEED (MPH)									TOTAL
		0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5		
N	0.000	0.046	1.284	0.459	0.413	0.092	0.000	0.000	0.000	2.294	
NNE	0.000	0.046	0.596	0.688	0.550	0.367	0.000	0.000	0.000	2.248	
NE	0.000	0.138	0.275	0.321	0.275	0.183	0.000	0.000	0.000	1.193	
ENE	0.000	0.183	0.688	0.183	0.000	0.000	0.000	0.000	0.000	1.055	
E	0.000	0.229	1.606	0.917	0.092	0.000	0.000	0.000	0.000	2.844	
ESE	0.000	0.275	1.284	1.055	0.275	0.046	0.000	0.000	0.000	2.936	
SE	0.000	0.229	0.642	0.000	0.000	0.000	0.000	0.000	0.000	0.872	
SSE	0.000	0.275	0.963	0.000	0.000	0.000	0.000	0.000	0.000	1.239	
S	0.000	0.138	1.376	0.046	0.000	0.000	0.000	0.000	0.000	1.560	
SSW	0.000	0.092	1.376	0.321	0.000	0.000	0.000	0.000	0.000	1.789	
SW	0.000	0.046	0.459	0.046	0.000	0.000	0.000	0.000	0.000	0.550	
WSW	0.000	0.000	0.734	0.046	0.046	0.000	0.000	0.000	0.000	0.826	
W	0.000	0.000	0.917	0.917	0.275	0.046	0.000	0.000	0.000	2.156	
WNW	0.000	0.046	0.413	0.229	0.092	0.046	0.000	0.000	0.000	0.826	
NW	0.000	0.092	0.046	0.275	0.138	0.183	0.000	0.000	0.000	0.734	
NNW	0.000	0.000	0.642	0.917	0.183	0.367	0.000	0.000	0.000	2.110	
SUBTOTAL	0.000	1.835	13.303	6.422	2.339	1.330	0.000	0.000	0.000	25.229	

TOTAL HOURS OF VALID STABILITY OBSERVATIONS	2180
TOTAL HOURS OF STABILITY CLASS E	550
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS E	550
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS	2180
TOTAL HOURS CALM	0

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS  
WIND SPEED AND DIRECTION MEASURED AT 10.50 METER LEVEL

MEAN WIND SPEED = 3.50

DATE PRINTED: 2012/08/20

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS F      ( 1.5 < DELTA T <= 4.0 C/100 M)

BROWNS FERRY NUCLEAR PLANT

APR 1, 2012 - JUN 30, 2012

WIND DIRECTION	WIND SPEED (MPH)									TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5	
N	0.000	0.183	1.422	0.550	0.046	0.000	0.000	0.000	0.000	2.202
NNE	0.000	0.000	0.963	0.963	0.046	0.000	0.000	0.000	0.000	1.972
NE	0.000	0.367	0.688	0.275	0.000	0.000	0.000	0.000	0.000	1.330
ENE	0.000	0.550	0.826	0.138	0.000	0.000	0.000	0.000	0.000	1.514
E	0.000	0.367	1.284	0.459	0.000	0.000	0.000	0.000	0.000	2.110
ESE	0.000	0.183	0.688	0.046	0.000	0.000	0.000	0.000	0.000	0.917
SE	0.000	0.138	0.229	0.000	0.000	0.000	0.000	0.000	0.000	0.367
SSE	0.000	0.138	0.183	0.000	0.000	0.000	0.000	0.000	0.000	0.321
S	0.000	0.046	0.138	0.000	0.000	0.000	0.000	0.000	0.000	0.183
SSW	0.000	0.046	0.092	0.000	0.000	0.000	0.000	0.000	0.000	0.138
SW	0.000	0.092	0.138	0.000	0.000	0.000	0.000	0.000	0.000	0.229
WSW	0.000	0.092	0.505	0.000	0.000	0.000	0.000	0.000	0.000	0.596
W	0.000	0.046	0.229	0.183	0.000	0.000	0.000	0.000	0.000	0.459
WNW	0.000	0.046	0.138	0.000	0.000	0.000	0.000	0.000	0.000	0.183
NW	0.000	0.092	0.092	0.000	0.000	0.000	0.000	0.000	0.000	0.183
NNW	0.000	0.275	0.505	0.138	0.138	0.000	0.000	0.000	0.000	1.055
SUBTOTAL	0.000	2.661	8.119	2.752	0.229	0.000	0.000	0.000	0.000	13.761

TOTAL HOURS OF VALID STABILITY OBSERVATIONS	2180
TOTAL HOURS OF STABILITY CLASS F	300
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS F	300
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS	2180
TOTAL HOURS CALM	0

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS  
 WIND SPEED AND DIRECTION MEASURED AT 10.50 METER LEVEL

MEAN WIND SPEED = 2.52

DATE PRINTED: 2012/08/20

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS G                    (DELTA T > 4.0 C/100 M)

BROWNS FERRY NUCLEAR PLANT

APR 1, 2012 - JUN 30, 2012

WIND DIRECTION	WIND SPEED (MPH)										TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5		
N	0.016	1.284	1.881	0.734	0.000	0.000	0.000	0.000	0.000	3.915	
NNE	0.007	0.321	1.009	0.275	0.000	0.000	0.000	0.000	0.000	1.612	
NE	0.006	0.596	0.688	0.046	0.000	0.000	0.000	0.000	0.000	1.337	
ENE	0.005	0.275	0.688	0.046	0.000	0.000	0.000	0.000	0.000	1.014	
E	0.002	0.275	0.183	0.092	0.000	0.000	0.000	0.000	0.000	0.553	
ESE	0.001	0.138	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.138	
SE	0.000	0.046	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.046	
SSE	0.001	0.046	0.138	0.000	0.000	0.000	0.000	0.000	0.000	0.184	
S	0.000	0.092	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.092	
SSW	0.001	0.092	0.046	0.000	0.000	0.000	0.000	0.000	0.000	0.138	
SW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
WSW	0.000	0.046	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.046	
W	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
WNW	0.000	0.000	0.000	0.046	0.000	0.000	0.000	0.000	0.000	0.046	
NW	0.001	0.183	0.046	0.000	0.000	0.000	0.000	0.000	0.000	0.231	
NNW	0.005	0.413	0.596	0.000	0.000	0.000	0.000	0.000	0.000	1.014	
SUBTOTAL	0.046	3.807	5.275	1.239	0.000	0.000	0.000	0.000	0.000	10.367	

TOTAL HOURS OF VALID STABILITY OBSERVATIONS	2180
TOTAL HOURS OF STABILITY CLASS G	226
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS G	226
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS	2180
TOTAL HOURS CALM	1

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS  
WIND SPEED AND DIRECTION MEASURED AT 10.50 METER LEVEL

MEAN WIND SPEED = 2.00

DATE PRINTED: 2012/08/20

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

**BROWNS FERRY NUCLEAR PLANT**

**2012 METEOROLOGICAL DATA**

**TABLE 7C**

**JOINT FREQUENCY DISTRIBUTION IN PERCENT**

**FOR GROUND LEVEL RELEASES**

**THIRD QUARTER**

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

## JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS A (DELTA T<=-1.9 C/100 M)

## BROWNS FERRY NUCLEAR PLANT

JUL 1, 2012 - SEP 30, 2012

WIND DIRECTION	WIND SPEED (MPH)										TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5		
N	0.000	0.000	0.000	0.000	0.053	0.053	0.000	0.000	0.000	0.106	
NNE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
NE	0.000	0.000	0.000	0.000	0.053	0.000	0.053	0.000	0.000	0.106	
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
E	0.000	0.000	0.053	0.000	0.000	0.000	0.000	0.000	0.000	0.053	
ESE	0.000	0.000	0.106	0.690	0.053	0.000	0.000	0.000	0.000	0.850	
SE	0.000	0.000	0.797	0.903	0.000	0.000	0.000	0.000	0.000	1.699	
SSE	0.000	0.000	1.328	0.584	0.000	0.000	0.000	0.000	0.000	1.912	
S	0.000	0.000	1.168	0.478	0.000	0.000	0.000	0.000	0.000	1.646	
SSW	0.000	0.000	1.753	0.850	0.000	0.000	0.000	0.000	0.000	2.602	
SW	0.000	0.000	0.372	0.637	0.000	0.000	0.000	0.000	0.000	1.009	
WSW	0.000	0.000	0.000	0.584	0.053	0.000	0.000	0.000	0.000	0.637	
W	0.000	0.000	0.053	0.690	0.903	0.266	0.000	0.000	0.000	1.912	
WNW	0.000	0.000	0.000	0.159	0.106	0.584	0.106	0.000	0.000	0.956	
NW	0.000	0.000	0.000	0.000	0.053	0.159	0.159	0.000	0.000	0.372	
NNW	0.000	0.000	0.000	0.000	0.053	0.106	0.053	0.000	0.000	0.212	
SUBTOTAL	0.000	0.000	5.629	5.576	1.328	1.168	0.372	0.000	0.000	14.073	

TOTAL HOURS OF VALID STABILITY OBSERVATIONS	1884
TOTAL HOURS OF STABILITY CLASS A	266
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS A	265
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS	1883
TOTAL HOURS CALM	C

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS  
WIND SPEED AND DIRECTION MEASURED AT 10.50 METER LEVEL

MEAN WIND SPEED = 4.56

DATE PRINTED: 2012/11/19

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS B      (-1.9 < DELTA T <=-1.7 C/100 M)

BROWNS FERRY NUCLEAR PLANT

JUL 1, 2012 - SEP 30, 2012

WIND DIRECTION	WIND SPEED (MPH)										TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5		
N	0.000	0.000	0.000	0.053	0.159	0.106	0.000	0.000	0.000	0.319	
NNE	0.000	0.000	0.000	0.053	0.159	0.106	0.000	0.000	0.000	0.319	
NE	0.000	0.000	0.000	0.053	0.053	0.000	0.000	0.000	0.000	0.106	
ENE	0.000	0.000	0.000	0.106	0.000	0.000	0.000	0.000	0.000	0.106	
E	0.000	0.000	0.053	0.000	0.000	0.000	0.000	0.000	0.000	0.053	
ESE	0.000	0.000	0.106	0.266	0.000	0.000	0.000	0.000	0.000	0.372	
SE	0.000	0.000	0.372	0.053	0.000	0.000	0.000	0.000	0.000	0.425	
SSE	0.000	0.000	0.956	0.053	0.000	0.000	0.000	0.000	0.000	1.009	
S	0.000	0.000	0.319	0.000	0.000	0.000	0.000	0.000	0.000	0.319	
SSW	0.000	0.000	0.797	0.053	0.000	0.000	0.000	0.000	0.000	0.850	
SW	0.000	0.000	0.159	0.212	0.000	0.000	0.000	0.000	0.000	0.372	
WSW	0.000	0.000	0.159	0.266	0.000	0.000	0.000	0.000	0.000	0.425	
W	0.000	0.000	0.000	0.478	0.319	0.053	0.000	0.000	0.000	0.850	
WNW	0.000	0.000	0.000	0.053	0.266	0.053	0.000	0.000	0.000	0.372	
NW	0.000	0.000	0.000	0.000	0.106	0.425	0.053	0.000	0.000	0.584	
NNW	0.000	0.000	0.000	0.159	0.106	0.159	0.000	0.000	0.000	0.425	
SUBTOTAL	0.000	0.000	2.921	1.859	1.168	0.903	0.053	0.000	0.000	6.904	

TOTAL HOURS OF VALID STABILITY OBSERVATIONS	1884
TOTAL HOURS OF STABILITY CLASS B	130
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS B	130
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS	1883
TOTAL HOURS CALM	0

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS  
WIND SPEED AND DIRECTION MEASURED AT 10.50 METER LEVEL

MEAN WIND SPEED = 4.75

DATE PRINTED: 2012/11/19

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS C      (-1.7 < DELTA T <=-1.5 C/100 M)

BROWNS FERRY NUCLEAR PLANT

JUL 1, 2012 - SEP 30, 2012

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)							>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4				
N	0.000	0.000	0.000	0.159	0.212	0.000	0.000	0.000	0.000	0.000	0.372	
NNE	0.000	0.000	0.053	0.053	0.053	0.000	0.000	0.000	0.000	0.000	0.159	
NE	0.000	0.000	0.000	0.000	0.000	0.053	0.000	0.000	0.000	0.000	0.053	
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
E	0.000	0.000	0.000	0.053	0.000	0.000	0.000	0.000	0.000	0.000	0.053	
ESE	0.000	0.000	0.053	0.053	0.000	0.000	0.000	0.000	0.000	0.000	0.106	
SE	0.000	0.000	0.266	0.053	0.000	0.000	0.000	0.000	0.000	0.000	0.319	
SSE	0.000	0.000	0.478	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.478	
S	0.000	0.000	0.637	0.053	0.000	0.000	0.000	0.000	0.000	0.000	0.690	
SSW	0.000	0.000	0.531	0.053	0.000	0.000	0.000	0.000	0.000	0.000	0.584	
SW	0.000	0.000	0.319	0.053	0.000	0.000	0.000	0.000	0.000	0.000	0.372	
WSW	0.000	0.000	0.106	0.159	0.000	0.000	0.000	0.000	0.000	0.000	0.266	
W	0.000	0.000	0.159	0.637	0.159	0.053	0.000	0.000	0.000	0.000	1.009	
WNW	0.000	0.000	0.000	0.106	0.266	0.053	0.000	0.000	0.000	0.000	0.425	
NW	0.000	0.000	0.000	0.266	0.159	0.212	0.000	0.000	0.000	0.000	0.637	
NNW	0.000	0.000	0.000	0.053	0.106	0.053	0.000	0.000	0.000	0.000	0.212	
SUBTOTAL	0.000	0.000	2.602	1.753	0.956	0.425	0.000	0.000	0.000	0.000	5.736	

TOTAL HOURS OF VALID STABILITY OBSERVATIONS	1884
TOTAL HOURS OF STABILITY CLASS C	108
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS C	108
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS	1883
TOTAL HOURS CALM	0

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS  
WIND SPEED AND DIRECTION MEASURED AT 10.50 METER LEVEL

MEAN WIND SPEED = 4.38

DATE PRINTED: 2012/11/19

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS D      (-1.5 < DELTA T <= -0.5 C/100 M)

**BROWNS FERRY NUCLEAR PLANT**

JUL 1, 2012 - SEP 30, 2012

WIND DIRECTION	WIND SPEED (MPH)									TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5	
N	0.000	0.000	0.266	0.425	0.106	0.000	0.000	0.000	0.000	0.797
NNE	0.000	0.000	0.319	0.372	0.319	0.053	0.053	0.000	0.000	1.115
NE	0.000	0.000	0.478	0.743	0.106	0.053	0.000	0.000	0.000	1.381
ENE	0.000	0.000	0.159	0.478	0.000	0.106	0.000	0.000	0.000	0.743
E	0.000	0.000	0.319	0.743	0.319	0.053	0.000	0.000	0.000	1.434
ESE	0.000	0.000	1.540	1.699	0.690	0.159	0.000	0.000	0.000	4.089
SE	0.000	0.053	1.593	0.319	0.000	0.000	0.000	0.000	0.000	1.965
SSE	0.000	0.000	1.381	0.053	0.000	0.000	0.000	0.000	0.000	1.434
S	0.000	0.053	2.602	0.053	0.000	0.000	0.000	0.000	0.000	2.708
SSW	0.000	0.053	2.921	0.159	0.000	0.000	0.000	0.000	0.000	3.133
SW	0.000	0.106	1.328	0.000	0.053	0.000	0.000	0.000	0.000	1.487
WSW	0.000	0.000	1.328	0.956	0.000	0.000	0.000	0.000	0.000	2.284
W	0.000	0.053	0.266	1.328	0.478	0.053	0.000	0.000	0.000	2.177
WNW	0.000	0.000	0.106	0.478	0.266	0.212	0.000	0.000	0.000	1.062
NW	0.000	0.000	0.212	0.053	0.053	0.266	0.000	0.000	0.000	0.584
NNW	0.000	0.000	0.266	0.319	0.319	0.212	0.000	0.000	0.000	1.115
SUBTOTAL	0.000	0.319	15.082	8.178	2.708	1.168	0.053	0.000	0.000	27.509

TOTAL HOURS OF VALID STABILITY OBSERVATIONS	1884
TOTAL HOURS OF STABILITY CLASS D	518
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS D	518
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS	1883
TOTAL HOURS CALM	0

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS  
WIND SPEED AND DIRECTION MEASURED AT 10.50 METER LEVEL

MEAN WIND SPEED = 3.68

DATE PRINTED: 2012/11/19

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS E      (-0.5 < DELTA T <= 1.5 C/100 M)

BROWNS FERRY NUCLEAR PLANT

JUL 1, 2012 - SEP 30, 2012

WIND DIRECTION	WIND SPEED (MPH)										TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5		
N	0.000	0.053	0.850	0.584	0.000	0.000	0.000	0.000	0.000	1.487	
NNE	0.000	0.053	0.584	0.478	0.319	0.159	0.000	0.000	0.000	1.593	
NE	0.000	0.053	0.850	0.425	0.106	0.159	0.000	0.000	0.000	1.593	
ENE	0.000	0.159	1.009	0.690	0.053	0.000	0.000	0.000	0.000	1.912	
E	0.000	0.425	1.806	1.699	0.053	0.053	0.000	0.000	0.000	4.036	
ESE	0.000	0.212	1.434	0.637	0.053	0.000	0.000	0.000	0.000	2.337	
SE	0.000	0.425	0.743	0.000	0.000	0.000	0.000	0.000	0.000	1.168	
SSE	0.000	0.106	0.797	0.053	0.000	0.000	0.000	0.000	0.000	0.956	
S	0.000	0.637	1.275	0.000	0.000	0.000	0.000	0.000	0.000	1.912	
SSW	0.000	0.319	1.646	0.000	0.000	0.000	0.000	0.000	0.000	1.965	
SW	0.000	0.212	0.956	0.000	0.000	0.000	0.000	0.000	0.000	1.168	
WSW	0.000	0.159	1.062	0.372	0.000	0.000	0.000	0.000	0.000	1.593	
W	0.000	0.000	1.062	0.690	0.000	0.000	0.000	0.000	0.000	1.753	
WNW	0.000	0.106	0.319	0.266	0.000	0.053	0.000	0.000	0.000	0.743	
NW	0.000	0.000	0.106	0.266	0.106	0.106	0.000	0.000	0.000	0.584	
NNW	0.000	0.000	0.319	0.584	0.106	0.053	0.000	0.000	0.000	1.062	
SUBTOTAL	0.000	2.921	14.817	6.745	0.797	0.584	0.000	0.000	0.000	25.863	

TOTAL HOURS OF VALID STABILITY OBSERVATIONS	1884
TOTAL HOURS OF STABILITY CLASS E	487
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS E	487
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS	1883
TOTAL HOURS CALM	0

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS  
WIND SPEED AND DIRECTION MEASURED AT 10.50 METER LEVEL

MEAN WIND SPEED = 3.02

DATE PRINTED: 2012/11/19

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS F      ( 1.5 < DELTA T <= 4.0 C/100 M)

BROWNS FERRY NUCLEAR PLANT

JUL 1, 2012 - SEP 30, 2012

WIND DIRECTION	WIND SPEED (MPH)										TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5		
N	0.008	0.319	0.850	0.266	0.000	0.000	0.000	0.000	0.000	1.441	
NNE	0.008	0.425	0.743	0.266	0.000	0.000	0.000	0.000	0.000	1.441	
NE	0.007	0.266	0.797	0.212	0.000	0.053	0.000	0.000	0.000	1.335	
ENE	0.010	0.159	1.434	0.531	0.000	0.000	0.000	0.000	0.000	2.135	
E	0.009	0.212	1.168	0.690	0.000	0.000	0.000	0.000	0.000	2.080	
ESE	0.004	0.159	0.425	0.000	0.000	0.000	0.000	0.000	0.000	0.588	
SE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
SSE	0.001	0.053	0.106	0.000	0.000	0.000	0.000	0.000	0.000	0.160	
S	0.001	0.000	0.159	0.000	0.000	0.000	0.000	0.000	0.000	0.160	
SSW	0.001	0.053	0.159	0.000	0.000	0.000	0.000	0.000	0.000	0.214	
SW	0.001	0.000	0.159	0.000	0.000	0.000	0.000	0.000	0.000	0.160	
WSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
W	0.000	0.000	0.000	0.053	0.000	0.000	0.000	0.000	0.000	0.053	
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
NW	0.001	0.106	0.106	0.000	0.000	0.000	0.000	0.000	0.000	0.214	
NNW	0.002	0.000	0.372	0.319	0.000	0.000	0.000	0.000	0.000	0.693	
SUBTOTAL	0.053	1.753	6.479	2.337	0.000	0.053	0.000	0.000	0.000	10.674	

TOTAL HOURS OF VALID STABILITY OBSERVATIONS	1884
TOTAL HOURS OF STABILITY CLASS F	201
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS F	201
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS	1883
TOTAL HOURS CALM	1

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS  
WIND SPEED AND DIRECTION MEASURED AT 10.50 METER LEVEL

MEAN WIND SPEED = 2.62

DATE PRINTED: 2012/11/19

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS G      (DELTA T > 4.0 C/100 M)

BROWNS FERRY NUCLEAR PLANT

JUL 1, 2012 - SEP 30, 2012

WIND DIRECTION	WIND SPEED (MPH)										TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5		
N	0.000	0.584	1.115	1.062	0.000	0.000	0.000	0.000	0.000	2.762	
NNE	0.000	0.743	0.743	0.106	0.000	0.000	0.000	0.000	0.000	1.593	
NE	0.000	0.319	0.743	0.053	0.000	0.000	0.000	0.000	0.000	1.115	
ENE	0.000	0.159	0.584	0.212	0.053	0.000	0.000	0.000	0.000	1.009	
E	0.000	0.053	0.319	0.106	0.000	0.000	0.000	0.000	0.000	0.478	
ESE	0.000	0.053	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.053	
SE	0.000	0.000	0.053	0.000	0.000	0.000	0.000	0.000	0.000	0.053	
SSE	0.000	0.053	0.159	0.000	0.000	0.000	0.000	0.000	0.000	0.212	
S	0.000	0.053	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.053	
SSW	0.000	0.053	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.053	
SW	0.000	0.053	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.053	
WSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
W	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
WNW	0.000	0.053	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.053	
NW	0.000	0.106	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.106	
NNW	0.000	0.797	0.743	0.106	0.000	0.000	0.000	0.000	0.000	1.646	
SUBTOTAL	0.000	3.080	4.461	1.646	0.053	0.000	0.000	0.000	0.000	9.241	

TOTAL HOURS OF VALID STABILITY OBSERVATIONS	1884
TOTAL HOURS OF STABILITY CLASS G	174
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS G	174
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS	1883
TOTAL HOURS CALM	0

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS  
 WIND SPEED AND DIRECTION MEASURED AT 10.50 METER LEVEL

MEAN WIND SPEED = 2.19

DATE PRINTED: 2012/11/19

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

**BROWNS FERRY NUCLEAR PLANT**

**2012 METEOROLOGICAL DATA**

**TABLE 7D**

**JOINT FREQUENCY DISTRIBUTION IN PERCENT**

**FOR GROUND LEVEL RELEASES**

**FOURTH QUARTER**

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

### JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS A (DELTA T<=-1.9 C/100 M)

## BROWNS FERRY NUCLEAR PLANT

OCT 1, 2012 - DEC 31, 2012

WIND DIRECTION	WIND SPEED (MPH)										TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5		
N	0.000	0.000	0.000	0.000	0.142	0.142	0.000	0.000	0.000	0.284	
NNE	0.000	0.000	0.000	0.000	0.000	0.189	0.000	0.000	0.000	0.189	
NE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
ENE	0.000	0.000	0.000	0.047	0.332	0.000	0.000	0.000	0.000	0.379	
E	0.000	0.000	0.000	0.237	0.000	0.000	0.000	0.000	0.000	0.237	
ESE	0.000	0.000	0.000	0.332	0.000	0.000	0.000	0.000	0.000	0.332	
SE	0.000	0.000	0.095	0.332	0.000	0.000	0.000	0.000	0.000	0.426	
SSE	0.000	0.000	0.379	0.047	0.000	0.000	0.000	0.000	0.000	0.426	
S	0.000	0.000	0.568	0.189	0.000	0.000	0.000	0.000	0.000	0.758	
SSW	0.000	0.000	0.284	0.237	0.000	0.000	0.000	0.000	0.000	0.521	
SW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
WSW	0.000	0.000	0.000	0.000	0.000	0.047	0.000	0.000	0.000	0.047	
W	0.000	0.000	0.000	0.000	0.000	0.095	0.000	0.000	0.000	0.095	
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.047	0.000	0.000	0.047	
NW	0.000	0.000	0.000	0.000	0.000	0.047	0.000	0.095	0.000	0.142	
NNW	0.000	0.000	0.000	0.000	0.000	0.047	0.000	0.000	0.000	0.047	
SUBTOTAL	0.000	0.000	1.326	1.421	0.474	0.568	0.047	0.095	0.000	3.932	

TOTAL HOURS OF VALID STABILITY OBSERVATIONS	2111
TOTAL HOURS OF STABILITY CLASS A	83
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS A	83
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS	2111
TOTAL HOURS CALM	0

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS  
WIND SPEED AND DIRECTION MEASURED AT 10.50 METER LEVEL

MEAN WIND SPEED = 5.32

DATE PRINTED: 2013/02/06

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS B      (-1.9 < DELTA T <=-1.7 C/100 M)

BROWNS FERRY NUCLEAR PLANT

OCT 1, 2012 - DEC 31, 2012

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)						>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4			
N	0.000	0.000	0.000	0.000	0.000	0.142	0.000	0.000	0.000	0.000	0.142
NNE	0.000	0.000	0.047	0.000	0.284	0.189	0.000	0.000	0.000	0.000	0.521
NE	0.000	0.000	0.000	0.000	0.000	0.047	0.047	0.000	0.000	0.000	0.095
ENE	0.000	0.000	0.000	0.047	0.047	0.000	0.000	0.000	0.000	0.000	0.095
E	0.000	0.000	0.000	0.095	0.047	0.000	0.000	0.000	0.000	0.000	0.142
ESE	0.000	0.000	0.047	0.237	0.047	0.000	0.000	0.000	0.000	0.000	0.332
SE	0.000	0.000	0.284	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.284
SSE	0.000	0.000	0.189	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.189
S	0.000	0.000	0.095	0.047	0.000	0.000	0.000	0.000	0.000	0.000	0.142
SSW	0.000	0.000	0.189	0.142	0.000	0.000	0.000	0.000	0.000	0.000	0.332
SW	0.000	0.000	0.047	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.047
WSW	0.000	0.000	0.000	0.095	0.000	0.047	0.000	0.000	0.000	0.000	0.142
W	0.000	0.000	0.000	0.047	0.000	0.000	0.000	0.000	0.000	0.000	0.047
WNW	0.000	0.000	0.000	0.000	0.000	0.095	0.095	0.095	0.000	0.000	0.284
NW	0.000	0.000	0.000	0.000	0.000	0.379	0.189	0.047	0.000	0.000	0.616
NNW	0.000	0.000	0.000	0.000	0.000	0.047	0.000	0.000	0.000	0.000	0.047
SUBTOTAL	0.000	0.000	0.900	0.711	0.426	0.947	0.332	0.142	0.000	3.458	

TOTAL HOURS OF VALID STABILITY OBSERVATIONS	2111
TOTAL HOURS OF STABILITY CLASS B	73
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS B	73
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS	2111
TOTAL HOURS CALM	0

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS  
 WIND SPEED AND DIRECTION MEASURED AT 10.50 METER LEVEL

DATE PRINTED: 2013/02/06

MEAN WIND SPEED = 7.21

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR  
STABILITY CLASS C      (-1.7 < DELTA T <=-1.5 C/100 M)

BROWNS FERRY NUCLEAR PLANT

OCT 1, 2012 - DEC 31, 2012

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)						>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4			
N	0.000	0.000	0.095	0.095	0.237	0.284	0.000	0.000	0.000	0.000	0.711
NNE	0.000	0.000	0.000	0.000	0.237	0.142	0.000	0.000	0.000	0.000	0.379
NE	0.000	0.000	0.000	0.000	0.047	0.047	0.000	0.000	0.000	0.000	0.095
ENE	0.000	0.000	0.000	0.142	0.000	0.000	0.000	0.000	0.000	0.000	0.142
E	0.000	0.000	0.000	0.095	0.000	0.000	0.000	0.000	0.000	0.000	0.095
ESE	0.000	0.000	0.095	0.047	0.000	0.000	0.000	0.000	0.000	0.000	0.142
SE	0.000	0.000	0.426	0.047	0.000	0.000	0.000	0.000	0.000	0.000	0.474
SSE	0.000	0.000	0.568	0.047	0.000	0.000	0.000	0.000	0.000	0.000	0.616
S	0.000	0.000	0.142	0.047	0.000	0.000	0.000	0.000	0.000	0.000	0.189
SSW	0.000	0.000	0.095	0.095	0.000	0.000	0.000	0.000	0.000	0.000	0.189
SW	0.000	0.000	0.095	0.047	0.047	0.000	0.000	0.000	0.000	0.000	0.189
WSW	0.000	0.000	0.000	0.095	0.000	0.047	0.000	0.000	0.000	0.000	0.142
W	0.000	0.000	0.047	0.095	0.095	0.000	0.000	0.000	0.000	0.000	0.237
WNW	0.000	0.000	0.000	0.095	0.000	0.237	0.047	0.000	0.000	0.000	0.379
NW	0.000	0.000	0.000	0.047	0.047	0.521	0.095	0.047	0.000	0.000	0.758
NNW	0.000	0.000	0.000	0.047	0.047	0.474	0.000	0.000	0.000	0.000	0.568
SUBTOTAL	0.000	0.000	1.563	1.042	0.758	1.753	0.142	0.047	0.000	5.306	

TOTAL HOURS OF VALID STABILITY OBSERVATIONS	2111
TOTAL HOURS OF STABILITY CLASS C	112
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS C	112
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS	2111
TOTAL HOURS CALM	0

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS  
WIND SPEED AND DIRECTION MEASURED AT 10.50 METER LEVEL

MEAN WIND SPEED = 6.23

DATE PRINTED: 2013/02/06

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS D      (-1.5 < DELTA T <= -0.5 C/100 M)

BROWNS FERRY NUCLEAR PLANT

OCT 1, 2012 ~ DEC 31, 2012

WIND DIRECTION	WIND SPEED (MPH)										TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5		
N	0.000	0.000	0.047	0.805	0.663	0.758	0.000	0.000	0.000	2.274	
NNE	0.000	0.000	0.142	0.805	0.805	0.568	0.000	0.000	0.000	2.321	
NE	0.000	0.000	0.237	0.379	0.426	0.805	0.000	0.000	0.000	1.847	
ENE	0.000	0.047	0.142	0.284	0.095	0.000	0.000	0.000	0.000	0.568	
E	0.000	0.000	0.284	0.474	0.000	0.000	0.000	0.000	0.000	0.758	
ESE	0.000	0.000	0.568	0.426	0.095	0.000	0.000	0.000	0.000	1.090	
SE	0.000	0.047	0.758	0.426	0.000	0.000	0.000	0.000	0.000	1.232	
SSE	0.000	0.000	0.758	0.189	0.000	0.000	0.000	0.000	0.000	0.947	
S	0.000	0.000	0.474	0.474	0.095	0.000	0.000	0.000	0.000	1.042	
SSW	0.000	0.000	0.568	0.237	0.095	0.000	0.000	0.000	0.000	0.900	
SW	0.000	0.047	0.426	0.142	0.047	0.000	0.000	0.000	0.000	0.663	
WSW	0.000	0.000	0.237	0.474	0.095	0.047	0.000	0.000	0.000	0.853	
W	0.000	0.000	0.379	0.853	0.332	0.379	0.332	0.047	0.000	2.321	
WNW	0.000	0.000	0.142	0.616	0.379	1.184	0.805	0.568	0.000	3.695	
NW	0.000	0.000	0.237	0.284	0.521	1.611	1.516	0.142	0.000	4.311	
NNW	0.000	0.000	0.142	0.332	1.184	1.184	0.095	0.000	0.000	2.937	
SUBTOTAL	0.000	0.142	5.542	7.200	4.832	6.537	2.748	0.758	0.000	27.759	

TOTAL HOURS OF VALID STABILITY OBSERVATIONS	2111
TOTAL HOURS OF STABILITY CLASS D	586
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS D	586
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS	2111
TOTAL HOURS CALM	0

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS  
 WIND SPEED AND DIRECTION MEASURED AT 10.50 METER LEVEL

MEAN WIND SPEED = 7.06

DATE PRINTED: 2013/02/06

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS E      (-0.5 < DELTA T <= 1.5 C/100 M)

BROWNS FERRY NUCLEAR PLANT

OCT 1, 2012 - DEC 31, 2012

WIND DIRECTION	CALM	WIND SPEED (MPH)									TOTAL
		0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5		
N	0.000	0.000	0.474	0.663	0.189	0.095	0.000	0.000	0.000	1.421	
NNE	0.000	0.047	0.474	0.426	0.379	0.332	0.000	0.000	0.000	1.658	
NE	0.000	0.047	0.474	0.758	0.332	0.284	0.095	0.000	0.000	1.990	
ENE	0.000	0.047	0.663	0.521	0.189	0.142	0.000	0.000	0.000	1.563	
E	0.000	0.142	1.090	0.379	0.047	0.000	0.000	0.000	0.000	1.658	
ESE	0.000	0.095	0.900	0.758	0.189	0.142	0.000	0.000	0.000	2.084	
SE	0.000	0.142	0.900	0.142	0.000	0.047	0.000	0.000	0.000	1.232	
SSE	0.000	0.000	0.521	0.142	0.000	0.000	0.000	0.000	0.000	0.663	
S	0.000	0.047	1.516	1.847	0.474	0.047	0.000	0.000	0.000	3.932	
SSW	0.000	0.095	0.663	0.616	0.047	0.000	0.000	0.000	0.000	1.421	
SW	0.000	0.047	0.568	0.237	0.095	0.000	0.000	0.000	0.000	0.947	
WSW	0.000	0.047	0.616	0.237	0.142	0.000	0.000	0.000	0.000	1.042	
W	0.000	0.000	0.332	0.332	0.237	0.047	0.000	0.000	0.000	0.947	
WNW	0.000	0.047	0.189	0.332	0.142	0.237	0.047	0.000	0.000	0.995	
NW	0.000	0.000	0.379	0.379	0.426	0.426	0.616	0.000	0.000	2.226	
NNW	0.000	0.047	0.616	1.374	0.663	0.474	0.000	0.000	0.000	3.174	
SUBTOTAL	0.000	0.853	10.374	9.143	3.553	2.274	0.758	0.000	0.000	26.954	

TOTAL HOURS OF VALID STABILITY OBSERVATIONS	2111
TOTAL HOURS OF STABILITY CLASS E	569
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS E	569
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS	2111
TOTAL HOURS CALM	0

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS  
WIND SPEED AND DIRECTION MEASURED AT 10.50 METER LEVEL

MEAN WIND SPEED = 4.49

DATE PRINTED: 2013/02/06

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS F      ( 1.5 < DELTA T <= 4.0 C/100 M)

BROWNS FERRY NUCLEAR PLANT

OCT 1, 2012 - DEC 31, 2012

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)						>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4			
N	0.000	0.189	1.184	1.326	0.142	0.000	0.000	0.000	0.000	0.000	2.842
NNE	0.000	0.095	0.853	1.090	0.332	0.047	0.000	0.000	0.000	0.000	2.416
NE	0.000	0.047	1.042	0.900	0.711	0.189	0.000	0.000	0.000	0.000	2.890
ENE	0.000	0.095	1.279	0.521	0.000	0.000	0.000	0.000	0.000	0.000	1.895
E	0.000	0.142	0.995	0.189	0.000	0.000	0.000	0.000	0.000	0.000	1.326
ESE	0.000	0.142	1.042	0.189	0.000	0.000	0.000	0.000	0.000	0.000	1.374
SE	0.000	0.284	0.853	0.000	0.000	0.000	0.000	0.000	0.000	0.000	1.137
SSE	0.000	0.142	0.521	0.189	0.000	0.000	0.000	0.000	0.000	0.000	0.853
S	0.000	0.095	0.568	0.474	0.000	0.000	0.000	0.000	0.000	0.000	1.137
SSW	0.000	0.000	0.095	0.095	0.000	0.000	0.000	0.000	0.000	0.000	0.189
SW	0.000	0.047	0.142	0.000	0.000	0.047	0.000	0.000	0.000	0.000	0.237
WSW	0.000	0.000	0.095	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.095
W	0.000	0.047	0.142	0.047	0.000	0.000	0.000	0.000	0.000	0.000	0.237
WNW	0.000	0.000	0.095	0.047	0.047	0.000	0.000	0.000	0.000	0.000	0.189
NW	0.000	0.000	0.284	0.095	0.047	0.047	0.000	0.000	0.000	0.000	0.474
NNW	0.000	0.047	0.900	0.711	0.237	0.000	0.000	0.000	0.000	0.000	1.895
SUBTOTAL	0.000	1.374	10.090	5.874	1.516	0.332	0.000	0.000	0.000	0.000	19.185

TOTAL HOURS OF VALID STABILITY OBSERVATIONS	2111
TOTAL HOURS OF STABILITY CLASS F	405
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS F	405
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS	2111
TOTAL HOURS CALM	0

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS  
 WIND SPEED AND DIRECTION MEASURED AT 10.50 METER LEVEL

MEAN WIND SPEED = 3.33

DATE PRINTED: 2013/02/06

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS G                   (DELTA T > 4.0 C/100 M)

BROWNS FERRY NUCLEAR PLANT

OCT 1, 2012 - DEC 31, 2012

WIND DIRECTION	CALM	WIND SPEED (MPH)									TOTAL
		0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5		
N	0.013	0.758	2.037	0.521	0.000	0.000	0.000	0.000	0.000	3.329	
NNE	0.007	0.284	1.279	0.711	0.142	0.000	0.000	0.000	0.000	2.423	
NE	0.007	0.379	1.090	0.758	0.284	0.189	0.000	0.000	0.000	2.707	
ENE	0.004	0.237	0.521	0.095	0.000	0.000	0.000	0.000	0.000	0.856	
E	0.002	0.047	0.332	0.000	0.000	0.000	0.000	0.000	0.000	0.381	
ESE	0.002	0.095	0.237	0.000	0.000	0.000	0.000	0.000	0.000	0.333	
SE	0.001	0.095	0.095	0.000	0.000	0.000	0.000	0.000	0.000	0.190	
SSE	0.000	0.000	0.047	0.000	0.000	0.000	0.000	0.000	0.000	0.048	
S	0.001	0.142	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.143	
SSW	0.000	0.047	0.047	0.000	0.000	0.000	0.000	0.000	0.000	0.095	
SW	0.000	0.000	0.000	0.000	0.047	0.000	0.000	0.000	0.000	0.047	
WSW	0.000	0.095	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.095	
W	0.000	0.047	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.048	
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
NW	0.001	0.189	0.095	0.095	0.000	0.000	0.000	0.000	0.000	0.380	
NNW	0.009	0.426	1.421	0.379	0.095	0.000	0.000	0.000	0.000	2.330	
SUBTOTAL	0.047	2.842	7.200	2.558	0.568	0.189	0.000	0.000	0.000	13.406	

TOTAL HOURS OF VALID STABILITY OBSERVATIONS	2111
TOTAL HOURS OF STABILITY CLASS G	283
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS G	283
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS	2111
TOTAL HOURS CALM	1

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS  
WIND SPEED AND DIRECTION MEASURED AT 10.50 METER LEVEL

MEAN WIND SPEED = 2.68

DATE PRINTED: 2013/02/06

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

**BROWNS FERRY NUCLEAR PLANT**

**2012 METEOROLOGICAL DATA**

**TABLE 8A**

**JOINT FREQUENCY DISTRIBUTION IN PERCENT**

**FOR SPLIT LEVEL RELEASES**

**(GROUND LEVEL RELEASE MODE AND ELEVATED RELEASE MODE)**

**FIRST QUARTER**

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS A (DELTA T<=-1.9 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 1 OF 2 GROUND LEVEL RELEASE MODE

JAN 1, 2012 - MAR 31, 2012

WIND DIRECTION	WIND SPEED (MPH)										TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5		
N	0.000	0.000	0.000	0.000	0.000	0.025	0.000	0.000	0.000	0.025	
NNE	0.000	0.000	0.000	0.000	0.000	0.009	0.000	0.000	0.000	0.009	
NE	0.000	0.000	0.000	0.000	0.000	0.007	0.000	0.000	0.000	0.007	
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
ESE	0.000	0.000	0.000	0.006	0.000	0.000	0.000	0.000	0.000	0.006	
SE	0.000	0.000	0.000	0.048	0.032	0.038	0.000	0.000	0.000	0.000	0.118
SSE	0.000	0.000	0.005	0.082	0.000	0.000	0.000	0.000	0.000	0.000	0.087
S	0.000	0.000	0.006	0.051	0.000	0.000	0.000	0.000	0.000	0.000	0.058
SSW	0.000	0.000	0.000	0.029	0.017	0.000	0.000	0.000	0.000	0.000	0.046
SW	0.000	0.000	0.000	0.021	0.028	0.000	0.000	0.000	0.000	0.000	0.049
WSW	0.000	0.000	0.000	0.000	0.014	0.009	0.000	0.000	0.000	0.000	0.023
W	0.000	0.000	0.000	0.000	0.000	0.017	0.000	0.000	0.000	0.000	0.017
WNW	0.000	0.000	0.000	0.000	0.000	0.007	0.010	0.000	0.000	0.000	0.017
NW	0.000	0.000	0.000	0.000	0.002	0.000	0.000	0.040	0.000	0.042	
NNW	0.000	0.000	0.000	0.000	0.000	0.015	0.020	0.000	0.000	0.036	
SUBTOTAL	0.000	0.000	0.011	0.237	0.093	0.126	0.030	0.040	0.000	0.538	

TOTAL HOURS OF VALID OBSERVATIONS	2103.000
TOTAL HOURS OF GROUND LEVEL RELEASE	316.170
TOTAL HOURS OF STABILITY CLASS A	21.010
TOTAL HOURS OF GROUND LEVEL STABILITY CLASS A	11.310

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS  
 WIND DIRECTION MEASURED AT 10.50 METER LEVEL  
 WIND SPEED MEASURED AT 10.50 METER LEVEL  
 EFFLUENT VELOCITY = 12.60 M/S

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2012/05/15

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS B (-1.9 < DELTA T <=-1.7 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 1 OF 2 GROUND LEVEL RELEASE MODE

JAN 1, 2012 - MAR 31, 2012

WIND DIRECTION	CALM	WIND SPEED (MPH)									TOTAL
		0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5		
N	0.000	0.000	0.000	0.001	0.000	0.000	0.000	0.000	0.000	0.000	0.001
NNE	0.000	0.000	0.000	0.000	0.006	0.000	0.000	0.000	0.000	0.000	0.006
NE	0.000	0.000	0.000	0.000	0.000	0.007	0.000	0.000	0.000	0.000	0.007
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ESE	0.000	0.000	0.000	0.000	0.000	0.010	0.000	0.000	0.000	0.000	0.010
SE	0.000	0.000	0.000	0.014	0.015	0.000	0.000	0.000	0.000	0.000	0.029
SSE	0.000	0.000	0.000	0.046	0.000	0.000	0.000	0.000	0.000	0.000	0.046
S	0.000	0.000	0.000	0.009	0.000	0.000	0.000	0.000	0.000	0.000	0.009
SSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WSW	0.000	0.000	0.000	0.009	0.006	0.000	0.000	0.000	0.000	0.000	0.015
W	0.000	0.000	0.000	0.000	0.004	0.021	0.000	0.000	0.000	0.000	0.025
WNW	0.000	0.000	0.000	0.000	0.000	0.007	0.039	0.000	0.000	0.000	0.045
NW	0.000	0.000	0.000	0.000	0.004	0.000	0.032	0.042	0.000	0.000	0.078
NNW	0.000	0.000	0.000	0.000	0.000	0.008	0.041	0.000	0.000	0.000	0.049
SUBTOTAL	0.000	0.000	0.000	0.078	0.035	0.052	0.112	0.042	0.000	0.320	
TOTAL HOURS OF VALID OBSERVATIONS				2103.000							
TOTAL HOURS OF GROUND LEVEL RELEASE				316.170							
TOTAL HOURS OF STABILITY CLASS B				19.790							
TOTAL HOURS OF GROUND LEVEL STABILITY CLASS B				6.730							

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS  
 WIND DIRECTION MEASURED AT 10.50 METER LEVEL  
 WIND SPEED MEASURED AT 10.50 METER LEVEL  
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2012/05/15

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS C (-1.7 < DELTA T <=-1.5 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 1 OF 2 GROUND LEVEL RELEASE MODE

JAN 1, 2012 - MAR 31, 2012

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)						>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4			
N	0.000	0.000	0.000	0.000	0.008	0.032	0.000	0.000	0.000	0.000	0.040
NNE	0.000	0.000	0.000	0.000	0.012	0.029	0.000	0.000	0.000	0.000	0.041
NE	0.000	0.000	0.000	0.000	0.000	0.014	0.000	0.000	0.000	0.000	0.014
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
E	0.000	0.000	0.000	0.000	0.000	0.005	0.000	0.000	0.000	0.000	0.005
ESE	0.000	0.000	0.000	0.001	0.000	0.000	0.000	0.000	0.000	0.000	0.001
SE	0.000	0.000	0.000	0.014	0.018	0.000	0.000	0.000	0.000	0.000	0.032
SSE	0.000	0.000	0.004	0.006	0.000	0.000	0.000	0.000	0.000	0.000	0.010
S	0.000	0.000	0.000	0.025	0.000	0.000	0.000	0.000	0.000	0.000	0.025
SSW	0.000	0.000	0.007	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.007
SW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WSW	0.000	0.000	0.000	0.005	0.000	0.018	0.000	0.000	0.000	0.000	0.023
W	0.000	0.000	0.000	0.000	0.009	0.023	0.000	0.000	0.000	0.000	0.032
WNW	0.000	0.000	0.000	0.000	0.000	0.042	0.106	0.036	0.000	0.000	0.183
NW	0.000	0.000	0.000	0.000	0.005	0.037	0.010	0.082	0.000	0.000	0.134
NNW	0.000	0.000	0.000	0.000	0.000	0.028	0.074	0.000	0.000	0.000	0.102
SUBTOTAL	0.000	0.000	0.011	0.053	0.051	0.229	0.189	0.118	0.000	0.651	

TOTAL HOURS OF VALID OBSERVATIONS	2103.000
TOTAL HOURS OF GROUND LEVEL RELEASE	316.170
TOTAL HOURS OF STABILITY CLASS C	56.880
TOTAL HOURS OF GROUND LEVEL STABILITY CLASS C	13.700

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS  
 WIND DIRECTION MEASURED AT 10.50 METER LEVEL  
 WIND SPEED MEASURED AT 10.50 METER LEVEL  
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2012/05/15

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS D (-1.5 < DELTA T <= -0.5 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 1 OF 2 GROUND LEVEL RELEASE MODE

JAN 1, 2012 - MAR 31, 2012

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)						>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4			
N	0.000	0.000	0.000	0.031	0.039	0.065	0.083	0.000	0.000	0.219	
NNE	0.000	0.000	0.000	0.015	0.038	0.096	0.035	0.000	0.000	0.183	
NE	0.000	0.000	0.000	0.008	0.025	0.017	0.000	0.000	0.000	0.050	
ENE	0.000	0.000	0.000	0.008	0.022	0.019	0.000	0.000	0.000	0.049	
E	0.000	0.000	0.000	0.016	0.000	0.000	0.000	0.000	0.000	0.016	
ESE	0.000	0.000	0.009	0.039	0.059	0.000	0.000	0.000	0.000	0.107	
SE	0.000	0.000	0.016	0.120	0.086	0.000	0.000	0.000	0.000	0.223	
SSE	0.000	0.000	0.033	0.025	0.032	0.010	0.000	0.000	0.000	0.100	
S	0.000	0.000	0.024	0.035	0.024	0.000	0.000	0.000	0.000	0.083	
SSW	0.000	0.000	0.016	0.030	0.010	0.044	0.000	0.000	0.000	0.099	
SW	0.000	0.000	0.003	0.009	0.000	0.012	0.000	0.000	0.000	0.025	
WSW	0.000	0.000	0.000	0.027	0.075	0.056	0.000	0.000	0.000	0.158	
W	0.000	0.000	0.002	0.010	0.031	0.188	0.056	0.000	0.000	0.287	
WNW	0.000	0.000	0.000	0.000	0.052	0.141	0.350	0.128	0.000	0.670	
NW	0.000	0.000	0.000	0.001	0.027	0.221	0.251	0.094	0.000	0.594	
NNW	0.000	0.000	0.000	0.004	0.045	0.204	0.155	0.080	0.000	0.487	
SUBTOTAL	0.000	0.000	0.103	0.379	0.566	1.071	0.929	0.301	0.000	3.349	

TOTAL HOURS OF VALID OBSERVATIONS	2103.000
TOTAL HOURS OF GROUND LEVEL RELEASE	316.170
TOTAL HOURS OF STABILITY CLASS D	654.990
TOTAL HOURS OF GROUND LEVEL STABILITY CLASS D	70.430

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS  
 WIND DIRECTION MEASURED AT 10.50 METER LEVEL  
 WIND SPEED MEASURED AT 10.50 METER LEVEL  
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2012/05/15

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR  
STABILITY CLASS E (-0.5 < DELTA T <= 1.5 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 1 OF 2 GROUND LEVEL RELEASE MODE

JAN 1, 2012 - MAR 31, 2012

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)						>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4			
N	0.000	0.000	0.012	0.043	0.065	0.047	0.020	0.000	0.000	0.000	0.186
NNE	0.000	0.003	0.019	0.072	0.069	0.023	0.000	0.000	0.000	0.000	0.186
NE	0.000	0.000	0.013	0.036	0.050	0.015	0.000	0.000	0.000	0.000	0.114
ENE	0.000	0.008	0.001	0.069	0.015	0.000	0.000	0.000	0.000	0.000	0.093
E	0.000	0.000	0.017	0.032	0.000	0.000	0.000	0.000	0.000	0.000	0.049
ESE	0.000	0.000	0.055	0.375	0.130	0.036	0.000	0.000	0.000	0.000	0.596
SE	0.000	0.000	0.147	0.281	0.094	0.107	0.000	0.000	0.000	0.000	0.629
SSE	0.000	0.000	0.297	0.147	0.000	0.045	0.000	0.000	0.000	0.000	0.488
S	0.000	0.008	0.083	0.297	0.256	0.492	0.000	0.000	0.000	0.000	1.135
SSW	0.000	0.000	0.033	0.088	0.134	0.437	0.000	0.000	0.000	0.000	0.692
SW	0.000	0.000	0.022	0.010	0.009	0.010	0.000	0.000	0.000	0.000	0.050
WSW	0.000	0.000	0.016	0.028	0.034	0.019	0.000	0.000	0.000	0.000	0.097
W	0.000	0.000	0.005	0.063	0.026	0.052	0.013	0.000	0.000	0.000	0.158
WNW	0.000	0.000	0.003	0.014	0.009	0.036	0.047	0.000	0.000	0.000	0.109
NW	0.000	0.000	0.005	0.057	0.078	0.264	0.194	0.000	0.000	0.000	0.597
NNW	0.000	0.000	0.005	0.037	0.074	0.130	0.107	0.000	0.000	0.000	0.353
SUBTOTAL	0.000	0.019	0.733	1.648	1.041	1.713	0.381	0.000	0.000	5.535	

TOTAL HOURS OF VALID OBSERVATIONS	2103.000
TOTAL HOURS OF GROUND LEVEL RELEASE	316.170
TOTAL HOURS OF STABILITY CLASS E	924.810
TOTAL HOURS OF GROUND LEVEL STABILITY CLASS E	116.400

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS  
 WIND DIRECTION MEASURED AT 10.50 METER LEVEL  
 WIND SPEED MEASURED AT 10.50 METER LEVEL  
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2012/05/15

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR  
STABILITY CLASS F ( 1.5 < DELTA T <= 4.0 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 1 OF 2 GROUND LEVEL RELEASE MODE

JAN 1, 2012 - MAR 31, 2012

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)						>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4			
N	0.000	0.000	0.059	0.078	0.000	0.009	0.000	0.000	0.000	0.000	0.146
NNE	0.000	0.000	0.026	0.080	0.055	0.010	0.010	0.000	0.000	0.000	0.180
NE	0.000	0.001	0.015	0.016	0.007	0.000	0.000	0.000	0.000	0.000	0.039
ENE	0.000	0.014	0.014	0.015	0.000	0.000	0.000	0.000	0.000	0.000	0.043
E	0.000	0.008	0.030	0.111	0.000	0.000	0.000	0.000	0.000	0.000	0.149
ESE	0.000	0.019	0.037	0.070	0.000	0.000	0.000	0.000	0.000	0.000	0.125
SE	0.000	0.011	0.179	0.079	0.055	0.000	0.000	0.000	0.000	0.000	0.324
SSE	0.000	0.013	0.485	0.178	0.000	0.000	0.000	0.000	0.000	0.000	0.676
S	0.000	0.011	0.221	0.223	0.394	0.220	0.000	0.000	0.000	0.000	1.069
SSW	0.000	0.003	0.036	0.058	0.069	0.117	0.000	0.000	0.000	0.000	0.283
SW	0.000	0.003	0.014	0.009	0.000	0.000	0.000	0.000	0.000	0.000	0.026
WSW	0.000	0.001	0.010	0.004	0.000	0.000	0.000	0.000	0.000	0.000	0.015
W	0.000	0.000	0.010	0.000	0.000	0.009	0.000	0.000	0.000	0.000	0.019
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NW	0.000	0.000	0.001	0.010	0.000	0.000	0.000	0.000	0.000	0.000	0.011
NNW	0.000	0.000	0.031	0.064	0.022	0.000	0.000	0.000	0.000	0.000	0.117
SUBTOTAL	0.000	0.084	1.166	0.997	0.602	0.364	0.010	0.000	0.000	0.000	3.223

TOTAL HOURS OF VALID OBSERVATIONS	2103.000
TOTAL HOURS OF GROUND LEVEL RELEASE	316.170
TOTAL HOURS OF STABILITY CLASS F	368.900
TOTAL HOURS OF GROUND LEVEL STABILITY CLASS F	67.770

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS  
WIND DIRECTION MEASURED AT 10.50 METER LEVEL  
WIND SPEED MEASURED AT 10.50 METER LEVEL  
EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2012/05/15

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR  
STABILITY CLASS G (DELTA T > 4.0 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 1 OF 2 GROUND LEVEL RELEASE MODE

JAN 1, 2012 - MAR 31, 2012

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)						>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4			
N	0.000	0.001	0.027	0.056	0.000	0.000	0.000	0.000	0.000	0.000	0.084
NNE	0.000	0.001	0.004	0.006	0.000	0.042	0.010	0.000	0.000	0.000	0.063
NE	0.000	0.002	0.000	0.010	0.012	0.008	0.000	0.000	0.000	0.000	0.032
ENE	0.000	0.000	0.011	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.011
E	0.000	0.029	0.003	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.031
ESE	0.000	0.046	0.045	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.091
SE	0.000	0.059	0.070	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.130
SSE	0.001	0.092	0.536	0.115	0.000	0.000	0.000	0.000	0.000	0.000	0.744
S	0.000	0.033	0.159	0.018	0.000	0.000	0.000	0.000	0.000	0.000	0.210
SSW	0.000	0.000	0.002	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.002
SW	0.000	0.000	0.002	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.002
WSW	0.000	0.007	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.007
W	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNW	0.000	0.000	0.002	0.007	0.000	0.000	0.000	0.000	0.000	0.000	0.010
SUBTOTAL	0.002	0.272	0.863	0.211	0.012	0.050	0.010	0.000	0.000	0.000	1.418

TOTAL HOURS OF VALID OBSERVATIONS	2103.000
TOTAL HOURS OF GROUND LEVEL RELEASE	316.170
TOTAL HOURS OF STABILITY CLASS G	56.620
TOTAL HOURS OF GROUND LEVEL STABILITY CLASS G	29.830

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS  
 WIND DIRECTION MEASURED AT 10.50 METER LEVEL  
 WIND SPEED MEASURED AT 10.50 METER LEVEL  
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2012/05/15

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR  
STABILITY CLASS A (DELTA T<=-1.9 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 2 OF 2 ELEVATED RELEASE MODE

JAN 1, 2012 - MAR 31, 2012

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)						>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4			
N	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ESE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SSE	0.000	0.000	0.000	0.000	0.090	0.000	0.077	0.000	0.000	0.000	0.166
S	0.000	0.000	0.000	0.048	0.046	0.000	0.078	0.000	0.000	0.000	0.172
SSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SW	0.000	0.000	0.000	0.000	0.000	0.123	0.000	0.000	0.000	0.000	0.123
WSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
W	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SUBTOTAL	0.000	0.000	0.000	0.048	0.136	0.123	0.155	0.000	0.000	0.461	
TOTAL HOURS OF VALID OBSERVATIONS					2103.000						
TOTAL HOURS OF ELEVATED RELEASES					1786.830						
TOTAL HOURS OF STABILITY CLASS A					21.010						
TOTAL HOURS OF ELEVATED STABILITY CLASS A					9.700						

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 89.59 METERS  
WIND DIRECTION MEASURED AT 45.74 METER LEVEL  
WIND SPEED MEASURED AT 45.74 METER LEVEL  
EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2012/05/15

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS B (-1.9 < DELTA T <=-1.7 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 2 OF 2 ELEVATED RELEASE MODE

JAN 1, 2012 - MAR 31, 2012

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)						>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4			
N	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNE	0.000	0.000	0.000	0.000	0.000	0.000	0.039	0.000	0.000	0.000	0.039
NE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ESE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SE	0.000	0.000	0.000	0.000	0.091	0.127	0.000	0.000	0.000	0.000	0.218
SSE	0.000	0.000	0.000	0.000	0.000	0.081	0.039	0.000	0.000	0.000	0.120
S	0.000	0.000	0.000	0.000	0.000	0.042	0.039	0.000	0.000	0.000	0.082
SSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SW	0.000	0.000	0.000	0.000	0.000	0.040	0.039	0.000	0.000	0.000	0.079
WSW	0.000	0.000	0.000	0.000	0.000	0.042	0.000	0.000	0.000	0.000	0.042
W	0.000	0.000	0.000	0.000	0.000	0.040	0.000	0.000	0.000	0.000	0.040
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SUBTOTAL	0.000	0.000	0.000	0.000	0.091	0.373	0.156	0.000	0.000	0.621	
TOTAL HOURS OF VALID OBSERVATIONS					2103.000						
TOTAL HOURS OF ELEVATED RELEASES					1786.830						
TOTAL HOURS OF STABILITY CLASS B					19.790						
TOTAL HOURS OF ELEVATED STABILITY CLASS B					13.060						

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 89.59 METERS  
 WIND DIRECTION MEASURED AT 45.74 METER LEVEL  
 WIND SPEED MEASURED AT 45.74 METER LEVEL  
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2012/05/15

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR  
STABILITY CLASS C (-1.7 < DELTA T <=-1.5 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 2 OF 2 ELEVATED RELEASE MODE

JAN 1, 2012 - MAR 31, 2012

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)						>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4			
N	0.000	0.000	0.000	0.000	0.000	0.080	0.038	0.000	0.000	0.118	
NNE	0.000	0.000	0.000	0.000	0.000	0.000	0.078	0.000	0.000	0.078	
NE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
ESE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
SE	0.000	0.000	0.000	0.143	0.140	0.204	0.077	0.057	0.000	0.621	
SSE	0.000	0.000	0.000	0.048	0.000	0.043	0.000	0.000	0.000	0.000	0.091
S	0.000	0.000	0.000	0.095	0.000	0.000	0.000	0.000	0.000	0.000	0.095
SSW	0.000	0.000	0.000	0.000	0.000	0.082	0.000	0.000	0.000	0.000	0.082
SW	0.000	0.000	0.000	0.190	0.000	0.000	0.077	0.000	0.000	0.000	0.267
WSW	0.000	0.000	0.000	0.000	0.000	0.000	0.039	0.000	0.000	0.000	0.039
W	0.000	0.000	0.000	0.000	0.000	0.204	0.000	0.000	0.000	0.000	0.204
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.190	0.022	0.000	0.212	
NW	0.000	0.000	0.000	0.000	0.000	0.040	0.038	0.000	0.013	0.091	
NNW	0.000	0.000	0.000	0.000	0.000	0.040	0.000	0.116	0.000	0.156	
<b>SUBTOTAL</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.476</b>	<b>0.140</b>	<b>0.693</b>	<b>0.536</b>	<b>0.195</b>	<b>0.013</b>	<b>2.053</b>	
TOTAL HOURS OF VALID OBSERVATIONS				2103.000							
TOTAL HOURS OF ELEVATED RELEASES				1786.830							
TOTAL HOURS OF STABILITY CLASS C				56.880							
TOTAL HOURS OF ELEVATED STABILITY CLASS C				43.180							

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 89.59 METERS  
WIND DIRECTION MEASURED AT 45.74 METER LEVEL  
WIND SPEED MEASURED AT 45.74 METER LEVEL  
EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2012/05/15

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS D (-1.5 < DELTA T <= -0.5 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 2 OF 2 ELEVATED RELEASE MODE

JAN 1, 2012 - MAR 31, 2012

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)						>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4			
N	0.000	0.000	0.143	0.190	0.367	0.786	0.308	0.198	0.000	1.992	
NNE	0.000	0.000	0.095	0.143	0.454	0.880	0.463	0.126	0.000	2.160	
NE	0.000	0.000	0.000	0.285	0.364	0.675	0.000	0.000	0.000	1.324	
ENE	0.000	0.000	0.048	0.238	0.229	0.214	0.000	0.000	0.000	0.728	
E	0.000	0.000	0.000	0.190	0.090	0.126	0.000	0.000	0.000	0.407	
ESE	0.000	0.000	0.048	0.095	0.092	0.295	0.000	0.000	0.000	0.529	
SE	0.000	0.000	0.048	0.856	0.505	0.374	0.386	0.291	0.000	2.459	
SSE	0.000	0.000	0.238	0.666	0.092	0.208	0.190	0.208	0.000	1.602	
S	0.000	0.000	0.000	0.143	0.136	0.702	0.039	0.048	0.000	1.067	
SSW	0.000	0.000	0.476	0.285	0.088	0.168	0.233	0.055	0.007	1.311	
SW	0.000	0.000	0.190	0.238	0.228	0.336	0.078	0.050	0.000	1.120	
WSW	0.000	0.000	0.095	0.333	0.271	0.750	0.422	0.000	0.000	1.870	
W	0.000	0.048	0.190	0.285	0.414	0.702	0.696	0.096	0.000	2.431	
WNW	0.000	0.000	0.095	0.238	0.410	1.332	0.690	0.402	0.015	3.183	
NW	0.000	0.000	0.000	0.285	0.318	1.034	0.773	0.446	0.014	2.869	
NNW	0.000	0.000	0.048	0.190	0.227	0.908	0.999	0.358	0.015	2.745	
<b>SUBTOTAL</b>	<b>0.000</b>	<b>0.048</b>	<b>1.712</b>	<b>4.660</b>	<b>4.284</b>	<b>9.490</b>	<b>5.274</b>	<b>2.278</b>	<b>0.051</b>	<b>27.796</b>	
TOTAL HOURS OF VALID OBSERVATIONS				2103.000							
TOTAL HOURS OF ELEVATED RELEASES				1786.830							
TOTAL HOURS OF STABILITY CLASS D				654.990							
TOTAL HOURS OF ELEVATED STABILITY CLASS D				584.560							

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 89.59 METERS  
 WIND DIRECTION MEASURED AT 45.74 METER LEVEL  
 WIND SPEED MEASURED AT 45.74 METER LEVEL  
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2012/05/15

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR  
STABILITY CLASS E (-0.5 < DELTA T <= 1.5 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 2 OF 2 ELEVATED RELEASE MODE

JAN 1, 2012 - MAR 31, 2012

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)						>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4			
N	0.000	.000	0.095	0.238	0.276	0.592	0.274	0.000	0.009	1.485	
NNE	0.000	0.000	0.238	0.143	0.231	0.750	0.426	0.036	0.000	1.824	
NE	0.000	0.000	0.095	0.333	0.318	1.166	0.197	0.000	0.000	2.109	
ENE	0.000	0.000	0.000	0.190	0.232	0.292	0.000	0.000	0.000	0.714	
E	0.000	0.000	0.143	0.285	0.232	0.466	0.000	0.000	0.000	1.126	
ESE	0.000	0.095	0.048	0.380	0.369	1.065	0.118	0.000	0.000	2.076	
SE	0.000	0.048	0.238	0.428	0.593	0.990	2.242	0.559	0.010	5.108	
SSE	0.000	0.000	0.143	0.713	0.590	0.873	1.342	0.770	0.044	4.476	
S	0.000	0.000	0.143	0.333	0.648	1.125	1.162	0.710	0.037	4.157	
SSW	0.000	0.000	0.095	0.523	0.462	0.621	1.116	0.700	0.044	3.562	
SW	0.000	0.000	0.285	0.713	0.637	0.791	0.692	0.142	0.000	3.261	
WSW	0.000	0.048	0.333	0.333	0.409	0.337	0.308	0.000	0.000	1.767	
W	0.000	0.000	0.048	0.238	0.318	0.424	0.038	0.035	0.000	1.100	
WNW	0.000	0.000	0.048	0.285	0.364	0.253	0.232	0.038	0.000	1.220	
NW	0.000	0.000	0.143	0.143	0.273	0.503	0.501	0.071	0.000	1.632	
NNW	0.000	0.000	0.095	0.190	0.320	1.507	0.659	0.056	0.000	2.827	
SUBTOTAL	0.000	0.190	2.187	5.468	6.272	11.754	9.307	3.117	0.145	38.441	
TOTAL HOURS OF VALID OBSERVATIONS				2103.000							
TOTAL HOURS OF ELEVATED RELEASES				1786.830							
TOTAL HOURS OF STABILITY CLASS E				924.810							
TOTAL HOURS OF ELEVATED STABILITY CLASS E				808.410							

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 89.59 METERS  
WIND DIRECTION MEASURED AT 45.74 METER LEVEL  
WIND SPEED MEASURED AT 45.74 METER LEVEL  
EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2012/05/15

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR  
STABILITY CLASS F ( 1.5 < DELTA T <= 4.0 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 2 OF 2 ELEVATED RELEASE MODE

JAN 1, 2012 - MAR 31, 2012

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)						>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4			
N	0.000	0.000	0.000	0.048	0.090	0.414	0.000	0.000	0.000	0.552	
NNE	0.000	0.000	0.000	0.095	0.137	0.499	0.195	0.036	0.000	0.963	
NE	0.000	0.000	0.143	0.095	0.000	0.369	0.079	0.000	0.000	0.686	
ENE	0.000	0.000	0.048	0.095	0.138	0.289	0.000	0.000	0.000	0.570	
E	0.000	0.000	0.000	0.095	0.137	0.210	0.000	0.000	0.000	0.442	
ESE	0.000	0.000	0.000	0.095	0.046	0.409	0.000	0.000	0.000	0.551	
SE	0.000	0.000	0.095	0.143	0.360	0.325	0.193	0.055	0.000	1.171	
SSE	0.000	0.000	0.048	0.190	0.364	0.872	0.887	0.374	0.029	2.764	
S	0.000	0.048	0.048	0.143	0.507	0.749	1.048	0.083	0.000	2.625	
SSW	0.000	0.000	0.000	0.143	0.554	0.380	0.117	0.000	0.000	1.194	
SW	0.000	0.000	0.048	0.000	0.411	0.594	0.000	0.000	0.000	1.053	
WSW	0.000	0.000	0.048	0.048	0.046	0.000	0.000	0.000	0.000	0.141	
W	0.000	0.000	0.095	0.048	0.139	0.043	0.000	0.000	0.000	0.325	
WNW	0.000	0.000	0.143	0.333	0.047	0.000	0.000	0.000	0.000	0.522	
NW	0.000	0.000	0.000	0.190	0.138	0.000	0.000	0.000	0.000	0.329	
NNW	0.000	0.000	0.000	0.048	0.090	0.296	0.000	0.000	0.000	0.433	
<b>SUBTOTAL</b>	<b>0.000</b>	<b>0.048</b>	<b>0.713</b>	<b>1.807</b>	<b>3.205</b>	<b>5.450</b>	<b>2.519</b>	<b>0.548</b>	<b>0.029</b>	<b>14.319</b>	
TOTAL HOURS OF VALID OBSERVATIONS				2103.000							
TOTAL HOURS OF ELEVATED RELEASES				1786.830							
TOTAL HOURS OF STABILITY CLASS F				368.900							
TOTAL HOURS OF ELEVATED STABILITY CLASS F				301.130							

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 89.59 METERS  
WIND DIRECTION MEASURED AT 45.74 METER LEVEL  
WIND SPEED MEASURED AT 45.74 METER LEVEL  
EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2012/05/15

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS G (DELTA T > 4.0 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 2 OF 2 ELEVATED RELEASE MODE

JAN 1, 2012 - MAR 31, 2012

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)						>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4			
N	0.000	0.000	0.000	0.000	0.044	0.000	0.000	0.000	0.000	0.000	0.044
NNE	0.000	0.000	0.000	0.000	0.000	0.127	0.000	0.000	0.000	0.000	0.127
NE	0.000	0.000	0.048	0.000	0.044	0.043	0.000	0.000	0.000	0.000	0.135
ENE	0.000	0.000	0.000	0.048	0.091	0.000	0.000	0.000	0.000	0.000	0.139
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ESE	0.000	0.000	0.000	0.048	0.046	0.000	0.000	0.000	0.000	0.000	0.094
SE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SSE	0.000	0.000	0.000	0.000	0.000	0.000	0.039	0.000	0.000	0.000	0.039
S	0.000	0.000	0.048	0.000	0.089	0.248	0.078	0.000	0.000	0.000	0.464
SSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SW	0.000	0.000	0.000	0.000	0.045	0.000	0.000	0.000	0.000	0.000	0.045
WSW	0.000	0.000	0.048	0.048	0.045	0.000	0.000	0.000	0.000	0.000	0.140
W	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NW	0.000	0.000	0.000	0.048	0.000	0.000	0.000	0.000	0.000	0.000	0.048
NNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
<b>SUBTOTAL</b>	<b>0.000</b>	<b>0.000</b>	<b>0.143</b>	<b>0.190</b>	<b>0.406</b>	<b>0.418</b>	<b>0.117</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>1.274</b>
TOTAL HOURS OF VALID OBSERVATIONS					2103.000						
TOTAL HOURS OF ELEVATED RELEASES					1786.830						
TOTAL HOURS OF STABILITY CLASS G					56.620						
TOTAL HOURS OF ELEVATED STABILITY CLASS G					26.790						

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 89.59 METERS  
 WIND DIRECTION MEASURED AT 45.74 METER LEVEL  
 WIND SPEED MEASURED AT 45.74 METER LEVEL  
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2012/05/15

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

**BROWNS FERRY NUCLEAR PLANT**

**2012 METEOROLOGICAL DATA**

**TABLE 8B**

**JOINT FREQUENCY DISTRIBUTION IN PERCENT**

**FOR SPLIT LEVEL RELEASES**

**(GROUND LEVEL RELEASE MODE AND ELEVATED RELEASE MODE)**

**SECOND QUARTER**

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS A (DELTA T<=-1.9 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 1 OF 2 GROUND LEVEL RELEASE MODE

APR 1, 2012 - JUN 30, 2012

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)						>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4			
N	0.000	0.000	0.000	0.000	0.027	0.091	0.000	0.000	0.000	0.000	0.118
NNE	0.000	0.000	0.000	0.000	0.029	0.097	0.000	0.000	0.000	0.000	0.126
NE	0.000	0.000	0.000	0.000	0.004	0.033	0.000	0.000	0.000	0.000	0.037
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ESE	0.000	0.000	0.022	0.041	0.035	0.000	0.000	0.000	0.000	0.000	0.098
SE	0.000	0.000	0.033	0.085	0.000	0.000	0.000	0.000	0.000	0.000	0.118
SSE	0.000	0.000	0.058	0.046	0.000	0.000	0.000	0.000	0.000	0.000	0.104
S	0.000	0.000	0.138	0.051	0.000	0.000	0.000	0.000	0.000	0.000	0.189
SSW	0.000	0.000	0.056	0.042	0.000	0.000	0.000	0.000	0.000	0.000	0.097
SW	0.000	0.000	0.009	0.010	0.000	0.000	0.000	0.000	0.000	0.000	0.019
WSW	0.000	0.000	0.000	0.027	0.012	0.000	0.000	0.000	0.000	0.000	0.039
W	0.000	0.000	0.000	0.007	0.004	0.012	0.000	0.000	0.000	0.000	0.023
WNW	0.000	0.000	0.000	0.001	0.013	0.011	0.009	0.000	0.000	0.000	0.034
NW	0.000	0.000	0.000	0.000	0.009	0.061	0.102	0.000	0.000	0.000	0.172
NNW	0.000	0.000	0.000	0.000	0.022	0.118	0.125	0.000	0.000	0.000	0.264
SUBTOTAL	0.000	0.000	0.316	0.310	0.155	0.423	0.236	0.000	0.000	1.440	

TOTAL HOURS OF VALID OBSERVATIONS	2180.000
TOTAL HOURS OF GROUND LEVEL RELEASE	179.140
TOTAL HOURS OF STABILITY CLASS A	97.030
TOTAL HOURS OF GROUND LEVEL STABILITY CLASS A	31.400

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS  
 WIND DIRECTION MEASURED AT 10.50 METER LEVEL  
 WIND SPEED MEASURED AT 10.50 METER LEVEL  
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2012/08/20

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR  
STABILITY CLASS B (-1.9 < DELTA T <=-1.7 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 1 OF 2 GROUND LEVEL RELEASE MODE

APR 1, 2012 - JUN 30, 2012

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)						>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4			
N	0.000	0.000	0.000	0.000	0.020	0.045	0.000	0.000	0.000	0.065	
NNE	0.000	0.000	0.000	0.000	0.013	0.020	0.000	0.000	0.000	0.033	
NE	0.000	0.000	0.000	0.000	0.013	0.021	0.000	0.000	0.000	0.034	
ENE	0.000	0.000	0.000	0.000	0.006	0.000	0.000	0.000	0.000	0.006	
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
ESE	0.000	0.000	0.000	0.058	0.008	0.000	0.000	0.000	0.000	0.066	
SE	0.000	0.000	0.008	0.004	0.000	0.000	0.000	0.000	0.000	0.011	
SSE	0.000	0.000	0.006	0.000	0.000	0.000	0.000	0.000	0.000	0.006	
S	0.000	0.000	0.004	0.000	0.000	0.000	0.000	0.000	0.000	0.004	
SSW	0.000	0.000	0.004	0.006	0.000	0.000	0.000	0.000	0.000	0.010	
SW	0.000	0.000	0.000	0.001	0.000	0.000	0.000	0.000	0.000	0.001	
WSW	0.000	0.000	0.000	0.011	0.012	0.000	0.000	0.000	0.000	0.023	
W	0.000	0.000	0.000	0.005	0.005	0.000	0.000	0.000	0.000	0.009	
WNW	0.000	0.000	0.000	0.001	0.011	0.015	0.000	0.000	0.000	0.028	
NW	0.000	0.000	0.000	0.000	0.012	0.039	0.039	0.000	0.000	0.090	
NNW	0.000	0.000	0.000	0.000	0.000	0.029	0.016	0.000	0.000	0.045	
<b>SUBTOTAL</b>	<b>0.000</b>	<b>0.000</b>	<b>0.022</b>	<b>0.086</b>	<b>0.100</b>	<b>0.170</b>	<b>0.055</b>	<b>0.000</b>	<b>0.000</b>	<b>0.432</b>	

TOTAL HOURS OF VALID OBSERVATIONS	2180.000
TOTAL HOURS OF GROUND LEVEL RELEASE	179.140
TOTAL HOURS OF STABILITY CLASS B	95.630
TOTAL HOURS OF GROUND LEVEL STABILITY CLASS B	9.420

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS  
 WIND DIRECTION MEASURED AT 10.50 METER LEVEL  
 WIND SPEED MEASURED AT 10.50 METER LEVEL  
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2012/08/20

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR  
STABILITY CLASS C (-1.7 < DELTA T <=-1.5 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 1 OF 2 GROUND LEVEL RELEASE MODE

APR 1, 2012 - JUN 30, 2012

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)						>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4			
N	0.000	0.000	0.000	0.004	0.011	0.012	0.000	0.000	0.000	0.027	
NNE	0.000	0.000	0.000	0.000	0.015	0.013	0.000	0.000	0.000	0.028	
NE	0.000	0.000	0.009	0.000	0.000	0.000	0.000	0.000	0.000	0.009	
ENE	0.000	0.000	0.000	0.000	0.002	0.000	0.000	0.000	0.000	0.000	0.002
E	0.000	0.000	0.000	0.000	0.003	0.000	0.000	0.000	0.000	0.000	0.003
ESE	0.000	0.000	0.008	0.024	0.014	0.000	0.000	0.000	0.000	0.000	0.046
SE	0.000	0.000	0.016	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.016
SSE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
S	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SSW	0.000	0.000	0.006	0.011	0.000	0.000	0.000	0.000	0.000	0.000	0.017
SW	0.000	0.000	0.004	0.004	0.000	0.000	0.000	0.000	0.000	0.000	0.008
WSW	0.000	0.000	0.000	0.011	0.000	0.000	0.000	0.000	0.000	0.000	0.011
W	0.000	0.000	0.000	0.003	0.006	0.000	0.000	0.000	0.000	0.000	0.010
WNW	0.000	0.000	0.000	0.000	0.007	0.036	0.000	0.000	0.000	0.000	0.044
NW	0.000	0.000	0.000	0.000	0.007	0.021	0.035	0.000	0.000	0.000	0.063
NNW	0.000	0.000	0.000	0.002	0.005	0.033	0.000	0.000	0.000	0.000	0.040
SUBTOTAL	0.000	0.000	0.043	0.058	0.071	0.117	0.035	0.000	0.000	0.324	

TOTAL HOURS OF VALID OBSERVATIONS	2180.000
TOTAL HOURS OF GROUND LEVEL RELEASE	179.140
TOTAL HOURS OF STABILITY CLASS C	157.400
TOTAL HOURS OF GROUND LEVEL STABILITY CLASS C	7.060

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS  
 WIND DIRECTION MEASURED AT 10.50 METER LEVEL  
 WIND SPEED MEASURED AT 10.50 METER LEVEL  
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2012/08/20

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR  
STABILITY CLASS D (-1.5 < DELTA T <= -0.5 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 1 OF 2 GROUND LEVEL RELEASE MODE

APR 1, 2012 - JUN 30, 2012

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)						>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4			
N	0.000	0.000	0.000	0.031	0.081	0.085	0.028	0.000	0.000	0.225	
NNE	0.000	0.000	0.000	0.012	0.043	0.048	0.000	0.000	0.000	0.102	
NE	0.000	0.000	0.000	0.001	0.035	0.006	0.000	0.000	0.000	0.042	
ENE	0.000	0.000	0.000	0.000	0.009	0.000	0.000	0.000	0.000	0.009	
E	0.000	0.005	0.032	0.056	0.015	0.000	0.000	0.000	0.000	0.000	0.108
ESE	0.000	0.000	0.067	0.190	0.018	0.017	0.000	0.000	0.000	0.000	0.292
SE	0.000	0.000	0.074	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.074
SSE	0.000	0.000	0.036	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.036
S	0.000	0.000	0.049	0.009	0.000	0.000	0.000	0.000	0.000	0.000	0.058
SSW	0.000	0.000	0.088	0.032	0.000	0.000	0.000	0.000	0.000	0.000	0.119
SW	0.000	0.000	0.002	0.011	0.000	0.000	0.000	0.000	0.000	0.000	0.013
WSW	0.000	0.000	0.011	0.028	0.034	0.008	0.000	0.000	0.000	0.000	0.081
W	0.000	0.000	0.003	0.061	0.060	0.035	0.000	0.000	0.000	0.000	0.159
WNW	0.000	0.000	0.000	0.029	0.064	0.156	0.000	0.000	0.000	0.000	0.249
NW	0.000	0.000	0.000	0.027	0.059	0.160	0.018	0.000	0.000	0.000	0.264
NNW	0.000	0.000	0.000	0.042	0.077	0.139	0.016	0.000	0.000	0.000	0.274
SUBTOTAL	0.000	0.005	0.361	0.530	0.495	0.653	0.062	0.000	0.000	2.106	

TOTAL HOURS OF VALID OBSERVATIONS	2180.000
TOTAL HOURS OF GROUND LEVEL RELEASE	179.140
TOTAL HOURS OF STABILITY CLASS D	772.060
TOTAL HOURS OF GROUND LEVEL STABILITY CLASS D	45.920

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS  
WIND DIRECTION MEASURED AT 10.50 METER LEVEL  
WIND SPEED MEASURED AT 10.50 METER LEVEL  
EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2012/08/20

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR  
STABILITY CLASS E (-0.5 < DELTA T <= 1.5 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 1 OF 2 GROUND LEVEL RELEASE MODE

APR 1, 2012 - JUN 30, 2012

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)						>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4			
N	0.000	0.000	0.072	0.058	0.065	0.017	0.000	0.000	0.000	0.000	0.212
NNE	0.000	0.001	0.010	0.090	0.094	0.066	0.000	0.000	0.000	0.000	0.261
NE	0.000	0.001	0.006	0.029	0.041	0.032	0.000	0.000	0.000	0.000	0.109
ENE	0.000	0.006	0.044	0.014	0.000	0.000	0.000	0.000	0.000	0.000	0.063
E	0.000	0.007	0.135	0.112	0.015	0.000	0.000	0.000	0.000	0.000	0.268
ESE	0.000	0.004	0.099	0.177	0.055	0.021	0.000	0.000	0.000	0.000	0.355
SE	0.000	0.000	0.024	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.024
SSE	0.000	0.005	0.091	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.096
S	0.000	0.007	0.118	0.007	0.000	0.000	0.000	0.000	0.000	0.000	0.133
SSW	0.000	0.000	0.168	0.117	0.000	0.000	0.000	0.000	0.000	0.000	0.285
SW	0.000	0.000	0.022	0.006	0.000	0.000	0.000	0.000	0.000	0.000	0.029
WSW	0.000	0.000	0.025	0.005	0.008	0.000	0.000	0.000	0.000	0.000	0.037
W	0.000	0.000	0.047	0.083	0.037	0.008	0.000	0.000	0.000	0.000	0.174
WNW	0.000	0.000	0.013	0.011	0.011	0.006	0.000	0.000	0.000	0.000	0.041
NW	0.000	0.000	0.001	0.022	0.020	0.033	0.000	0.000	0.000	0.000	0.075
NNW	0.000	0.000	0.038	0.095	0.029	0.068	0.000	0.000	0.000	0.000	0.230
SUBTOTAL	0.000	0.031	0.912	0.825	0.374	0.250	0.000	0.000	0.000	0.000	2.392

TOTAL HOURS OF VALID OBSERVATIONS	2180.000
TOTAL HOURS OF GROUND LEVEL RELEASE	179.140
TOTAL HOURS OF STABILITY CLASS E	630.820
TOTAL HOURS OF GROUND LEVEL STABILITY CLASS E	52.150

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS  
WIND DIRECTION MEASURED AT 10.50 METER LEVEL  
WIND SPEED MEASURED AT 10.50 METER LEVEL  
EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2012/08/20

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS F ( 1.5 < DELTA T <= 4.0 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 1 OF 2 GROUND LEVEL RELEASE MODE

APR 1, 2012 - JUN 30, 2012

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)						>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4			
N	0.000	0.000	0.126	0.083	0.006	0.000	0.000	0.000	0.000	0.215	
NNE	0.000	0.000	0.063	0.146	0.008	0.000	0.000	0.000	0.000	0.217	
NE	0.000	0.010	0.048	0.030	0.000	0.000	0.000	0.000	0.000	0.087	
ENE	0.000	0.019	0.046	0.015	0.000	0.000	0.000	0.000	0.000	0.079	
E	0.000	0.019	0.080	0.056	0.000	0.000	0.000	0.000	0.000	0.155	
ESE	0.000	0.002	0.040	0.007	0.000	0.000	0.000	0.000	0.000	0.050	
SE	0.000	0.008	0.007	0.000	0.000	0.000	0.000	0.000	0.000	0.015	
SSE	0.000	0.012	0.006	0.000	0.000	0.000	0.000	0.000	0.000	0.018	
S	0.000	0.000	0.001	0.000	0.000	0.000	0.000	0.000	0.000	0.001	
SSW	0.000	0.006	0.021	0.000	0.000	0.000	0.000	0.000	0.000	0.027	
SW	0.000	0.000	0.009	0.000	0.000	0.000	0.000	0.000	0.000	0.009	
WSW	0.000	0.008	0.052	0.000	0.000	0.000	0.000	0.000	0.000	0.060	
W	0.000	0.000	0.002	0.022	0.000	0.000	0.000	0.000	0.000	0.024	
WNW	0.000	0.000	0.001	0.000	0.000	0.000	0.000	0.000	0.000	0.001	
NW	0.000	0.001	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.002	
NNW	0.000	0.000	0.028	0.016	0.023	0.000	0.000	0.000	0.000	0.067	
<b>SUBTOTAL</b>	<b>0.000</b>	<b>0.084</b>	<b>0.530</b>	<b>0.373</b>	<b>0.038</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>1.025</b>	

TOTAL HOURS OF VALID OBSERVATIONS	2180.000
TOTAL HOURS OF GROUND LEVEL RELEASE	179.140
TOTAL HOURS OF STABILITY CLASS F	311.890
TOTAL HOURS OF GROUND LEVEL STABILITY CLASS F	22.350

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS  
 WIND DIRECTION MEASURED AT 10.50 METER LEVEL  
 WIND SPEED MEASURED AT 10.50 METER LEVEL  
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2012/08/20

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS G (DELTA T > 4.0 C/100 M)

**BROWNS FERRY NUCLEAR PLANT**

**PART 1 OF 2 GROUND LEVEL RELEASE MODE**

APR 1, 2012 - JUN 30, 2012

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)						>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4			
N	0.002	0.011	0.110	0.111	0.000	0.000	0.000	0.000	0.000	0.000	0.233
NNE	0.001	0.002	0.060	0.043	0.000	0.000	0.000	0.000	0.000	0.000	0.105
NE	0.001	0.004	0.041	0.006	0.000	0.000	0.000	0.000	0.000	0.000	0.051
ENE	0.001	0.006	0.037	0.003	0.000	0.000	0.000	0.000	0.000	0.000	0.047
E	0.000	0.019	0.008	0.011	0.000	0.000	0.000	0.000	0.000	0.000	0.038
ESE	0.000	0.005	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.005
SE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SSE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
S	0.000	0.007	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.007
SSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
W	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNW	0.000	0.005	0.005	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.009
<b>SUBTOTAL</b>	<b>0.005</b>	<b>0.059</b>	<b>0.261</b>	<b>0.173</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.497</b>

TOTAL HOURS OF VALID OBSERVATIONS	2180.000
TOTAL HOURS OF GROUND LEVEL RELEASE	179.140
TOTAL HOURS OF STABILITY CLASS G	115.170
TOTAL HOURS OF GROUND LEVEL STABILITY CLASS G	10.840

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS  
 WIND DIRECTION MEASURED AT 10.50 METER LEVEL  
 WIND SPEED MEASURED AT 10.50 METER LEVEL  
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2012/08/20

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR  
STABILITY CLASS A (DELTA T<=-1.9 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 2 OF 2 ELEVATED RELEASE MODE

APR 1, 2012 - JUN 30, 2012

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)						>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4			
N	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNE	0.000	0.000	0.000	0.000	0.000	0.039	0.225	0.000	0.000	0.000	0.264
NE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ESE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SE	0.000	0.000	0.046	0.138	0.090	0.161	0.036	0.000	0.000	0.000	0.471
SSE	0.000	0.000	0.000	0.138	0.439	0.369	0.076	0.000	0.000	0.000	1.022
S	0.000	0.000	0.000	0.046	0.134	0.531	0.150	0.000	0.000	0.000	0.862
SSW	0.000	0.000	0.000	0.000	0.000	0.164	0.000	0.000	0.000	0.000	0.164
SW	0.000	0.000	0.000	0.046	0.046	0.000	0.000	0.000	0.000	0.000	0.092
WSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
W	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NW	0.000	0.000	0.000	0.000	0.000	0.000	0.111	0.000	0.000	0.000	0.111
NNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.025	0.000	0.025	
SUBTOTAL	0.000	0.000	0.046	0.367	0.710	1.264	0.599	0.025	0.000	3.011	
TOTAL HOURS OF VALID OBSERVATIONS					2180.000						
TOTAL HOURS OF ELEVATED RELEASES					2000.860						
TOTAL HOURS OF STABILITY CLASS A					97.030						
TOTAL HOURS OF ELEVATED STABILITY CLASS A					65.630						

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 89.59 METERS  
WIND DIRECTION MEASURED AT 45.74 METER LEVEL  
WIND SPEED MEASURED AT 45.74 METER LEVEL  
EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2012/08/20

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS B (-1.9 < DELTA T <=-1.7 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 2 OF 2 ELEVATED RELEASE MODE

APR 1, 2012 - JUN 30, 2012

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)						>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4			
N	0.000	0.000	0.000	0.000	0.000	0.161	0.038	0.000	0.000	0.199	
NNE	0.000	0.000	0.000	0.000	0.000	0.160	0.111	0.000	0.000	0.271	
NE	0.000	0.000	0.000	0.000	0.000	0.121	0.000	0.000	0.000	0.121	
ENE	0.000	0.000	0.000	0.046	0.000	0.000	0.000	0.000	0.000	0.046	
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
ESE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
SE	0.000	0.000	0.000	0.229	0.487	0.250	0.075	0.000	0.000	1.041	
SSE	0.000	0.000	0.046	0.183	0.128	0.000	0.038	0.000	0.000	0.396	
S	0.000	0.000	0.000	0.138	0.092	0.408	0.076	0.000	0.000	0.714	
SSW	0.000	0.000	0.000	0.138	0.045	0.122	0.037	0.000	0.000	0.341	
SW	0.000	0.000	0.000	0.092	0.000	0.080	0.000	0.000	0.000	0.172	
WSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
W	0.000	0.000	0.000	0.138	0.000	0.000	0.000	0.000	0.000	0.138	
WNW	0.000	0.000	0.000	0.000	0.043	0.040	0.000	0.000	0.000	0.083	
NW	0.000	0.000	0.000	0.046	0.000	0.080	0.111	0.000	0.000	0.237	
NNW	0.000	0.000	0.000	0.000	0.000	0.080	0.074	0.043	0.000	0.197	
<b>SUBTOTAL</b>	<b>0.000</b>	<b>0.000</b>	<b>0.046</b>	<b>1.009</b>	<b>0.794</b>	<b>1.502</b>	<b>0.561</b>	<b>0.043</b>	<b>0.000</b>	<b>3.955</b>	
TOTAL HOURS OF VALID OBSERVATIONS					2180.000						
TOTAL HOURS OF ELEVATED RELEASES					2000.860						
TOTAL HOURS OF STABILITY CLASS B					95.630						
TOTAL HOURS OF ELEVATED STABILITY CLASS B					86.210						

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 89.59 METERS  
 WIND DIRECTION MEASURED AT 45.74 METER LEVEL  
 WIND SPEED MEASURED AT 45.74 METER LEVEL  
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2012/08/20

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS C (-1.7 < DELTA T <=-1.5 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 2 OF 2 ELEVATED RELEASE MODE

APR 1, 2012 - JUN 30, 2012

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)						>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4			
N	0.000	0.000	0.000	0.000	0.043	0.641	0.036	0.000	0.000	0.720	
NNE	0.000	0.000	0.000	0.000	0.000	0.444	0.037	0.000	0.000	0.481	
NE	0.000	0.000	0.000	0.000	0.000	0.078	0.038	0.000	0.000	0.117	
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
ESE	0.000	0.000	0.000	0.000	0.090	0.000	0.000	0.000	0.000	0.090	
SE	0.000	0.000	0.046	0.505	0.347	0.116	0.038	0.000	0.000	1.051	
SSE	0.000	0.000	0.138	0.138	0.092	0.042	0.038	0.036	0.000	0.483	
S	0.000	0.000	0.000	0.183	0.000	0.122	0.075	0.000	0.000	0.380	
SSW	0.000	0.000	0.046	0.229	0.089	0.202	0.000	0.000	0.000	0.567	
SW	0.000	0.000	0.000	0.183	0.130	0.121	0.000	0.000	0.000	0.434	
WSW	0.000	0.000	0.000	0.321	0.089	0.122	0.000	0.000	0.000	0.532	
W	0.000	0.000	0.000	0.413	0.089	0.084	0.000	0.000	0.000	0.586	
WNW	0.000	0.000	0.000	0.092	0.089	0.202	0.075	0.000	0.000	0.457	
NW	0.000	0.000	0.000	0.000	0.043	0.081	0.112	0.154	0.000	0.389	
NNW	0.000	0.000	0.000	0.046	0.000	0.122	0.411	0.030	0.000	0.609	
SUBTOTAL	0.000	0.000	0.229	2.110	1.100	2.378	0.859	0.220	0.000	6.896	
TOTAL HOURS OF VALID OBSERVATIONS				2180.000							
TOTAL HOURS OF ELEVATED RELEASES				2000.860							
TOTAL HOURS OF STABILITY CLASS C				157.400							
TOTAL HOURS OF ELEVATED STABILITY CLASS C				150.340							

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 89.59 METERS  
 WIND DIRECTION MEASURED AT 45.74 METER LEVEL  
 WIND SPEED MEASURED AT 45.74 METER LEVEL  
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2012/08/20

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR  
STABILITY CLASS D (-1.5 < DELTA T <= -0.5 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 2 OF 2 ELEVATED RELEASE MODE

APR 1, 2012 - JUN 30, 2012

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)						>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4			
N	0.000	0.000	0.000	0.183	0.613	1.132	0.784	0.077	0.000	2.789	
NNE	0.000	0.000	0.046	0.229	0.489	0.843	0.227	0.000	0.000	1.834	
NE	0.000	0.000	0.000	0.183	0.180	0.249	0.000	0.000	0.000	0.612	
ENE	0.000	0.000	0.092	0.000	0.173	0.084	0.000	0.000	0.000	0.350	
E	0.000	0.000	0.000	0.092	0.133	0.083	0.000	0.000	0.000	0.307	
ESE	0.000	0.000	0.138	0.229	0.222	0.612	0.038	0.000	0.000	1.239	
SE	0.000	0.046	0.550	0.275	0.443	1.075	0.563	0.125	0.000	3.078	
SSE	0.000	0.000	0.734	0.734	0.176	0.555	1.123	0.034	0.000	3.356	
S	0.000	0.000	0.505	0.688	0.304	0.599	0.522	0.000	0.000	2.618	
SSW	0.000	0.000	0.413	0.596	0.400	0.400	0.262	0.000	0.000	2.072	
SW	0.000	0.000	0.550	0.780	0.395	0.571	0.076	0.000	0.000	2.372	
WSW	0.000	0.000	0.275	0.826	0.402	0.933	0.038	0.000	0.000	2.474	
W	0.000	0.046	0.092	0.734	0.528	0.528	0.076	0.000	0.000	2.004	
WNW	0.000	0.000	0.046	0.367	0.750	1.777	0.227	0.036	0.000	3.203	
NW	0.000	0.000	0.092	0.183	0.745	1.130	0.522	0.063	0.000	2.735	
NNW	0.000	0.046	0.138	0.229	0.440	1.047	0.338	0.030	0.000	2.268	
SUBTOTAL	0.000	0.138	3.670	6.330	6.393	11.617	4.796	0.365	0.000	33.309	
TOTAL HOURS OF VALID OBSERVATIONS					2180.000						
TOTAL HOURS OF ELEVATED RELEASES					2000.860						
TOTAL HOURS OF STABILITY CLASS D					772.060						
TOTAL HOURS OF ELEVATED STABILITY CLASS D					726.140						

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 89.59 METERS  
WIND DIRECTION MEASURED AT 45.74 METER LEVEL  
WIND SPEED MEASURED AT 45.74 METER LEVEL  
EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2012/08/20

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS E (-0.5 < DELTA T <= 1.5 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 2 OF 2 ELEVATED RELEASE MODE

APR 1, 2012 - JUN 30, 2012

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)						>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4			
N	0.000	0.000	0.046	0.413	0.355	1.207	0.150	0.000	0.000	2.171	
NNE	0.000	0.000	0.138	0.183	0.043	1.329	0.715	0.000	0.000	2.408	
NE	0.000	0.000	0.046	0.000	0.263	0.445	0.152	0.000	0.000	0.906	
ENE	0.000	0.000	0.046	0.092	0.045	0.250	0.000	0.000	0.000	0.433	
E	0.000	0.000	0.138	0.138	0.351	0.165	0.000	0.000	0.000	0.791	
ESE	0.000	0.000	0.046	0.046	0.399	0.412	0.038	0.000	0.000	0.941	
SE	0.000	0.000	0.138	0.183	0.705	0.849	0.262	0.000	0.000	2.137	
SSE	0.000	0.046	0.367	0.550	0.487	1.244	0.824	0.061	0.000	3.580	
S	0.000	0.046	0.138	0.917	0.393	0.726	0.633	0.100	0.000	2.953	
SSW	0.000	0.000	0.138	0.826	0.219	0.810	0.075	0.000	0.000	2.067	
SW	0.000	0.000	0.367	0.550	0.622	0.322	0.038	0.000	0.000	1.899	
WSW	0.000	0.000	0.229	0.321	0.179	0.082	0.000	0.000	0.000	0.811	
W	0.000	0.000	0.138	0.275	0.579	0.448	0.000	0.000	0.000	1.440	
WNW	0.000	0.000	0.092	0.046	0.222	0.528	0.038	0.000	0.000	0.926	
NW	0.000	0.000	0.092	0.092	0.220	0.243	0.262	0.000	0.000	0.908	
NNW	0.000	0.000	0.229	0.229	0.358	1.057	0.300	0.000	0.000	2.174	
SUBTOTAL	0.000	0.092	2.385	4.862	5.439	10.117	3.487	0.161	0.000	26.544	

TOTAL HOURS OF VALID OBSERVATIONS	2180.000
TOTAL HOURS OF ELEVATED RELEASES	2000.860
TOTAL HOURS OF STABILITY CLASS E	630.820
TOTAL HOURS OF ELEVATED STABILITY CLASS E	578.670

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 89.59 METERS  
 WIND DIRECTION MEASURED AT 45.74 METER LEVEL  
 WIND SPEED MEASURED AT 45.74 METER LEVEL  
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2012/08/20

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR  
STABILITY CLASS F ( 1.5 < DELTA T <= 4.0 C/100 M )

BROWNS FERRY NUCLEAR PLANT

PART 2 OF 2 ELEVATED RELEASE MODE

APR 1, 2012 - JUN 30, 2012

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)						>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4			
N	0.000	0.000	0.046	0.138	0.132	0.692	0.113	0.000	0.000	0.000	1.121
NNE	0.000	0.000	0.046	0.183	0.175	0.837	0.341	0.000	0.000	0.000	1.582
NE	0.000	0.046	0.046	0.092	0.350	0.649	0.038	0.000	0.000	0.000	1.221
ENE	0.000	0.000	0.092	0.092	0.220	0.162	0.000	0.000	0.000	0.000	0.566
E	0.000	0.000	0.092	0.092	0.267	0.165	0.000	0.000	0.000	0.000	0.615
ESE	0.000	0.000	0.138	0.138	0.397	0.289	0.000	0.000	0.000	0.000	0.961
SE	0.000	0.000	0.092	0.183	0.136	0.659	0.000	0.000	0.000	0.000	1.070
SSE	0.000	0.046	0.092	0.046	0.176	0.081	0.074	0.036	0.000	0.000	0.550
S	0.000	0.000	0.046	0.505	0.533	0.245	0.038	0.000	0.000	0.000	1.367
SSW	0.000	0.046	0.229	0.229	0.222	0.328	0.000	0.000	0.000	0.000	1.055
SW	0.000	0.000	0.183	0.229	0.044	0.000	0.000	0.000	0.000	0.000	0.457
WSW	0.000	0.000	0.138	0.229	0.000	0.000	0.000	0.000	0.000	0.000	0.367
W	0.000	0.000	0.138	0.367	0.180	0.082	0.000	0.000	0.000	0.000	0.767
WNW	0.000	0.000	0.000	0.183	0.091	0.122	0.000	0.000	0.000	0.000	0.396
NW	0.000	0.000	0.046	0.138	0.135	0.042	0.000	0.000	0.000	0.000	0.361
NNW	0.000	0.000	0.046	0.275	0.224	0.282	0.000	0.000	0.000	0.000	0.827
SUBTOTAL	0.000	0.138	1.468	3.119	3.282	4.635	0.604	0.036	0.000	13.282	

TOTAL HOURS OF VALID OBSERVATIONS	2180.000
TOTAL HOURS OF ELEVATED RELEASES	2000.860
TOTAL HOURS OF STABILITY CLASS F	311.890
TOTAL HOURS OF ELEVATED STABILITY CLASS F	289.540

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 89.59 METERS  
 WIND DIRECTION MEASURED AT 45.74 METER LEVEL  
 WIND SPEED MEASURED AT 45.74 METER LEVEL  
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2012/08/20

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR  
STABILITY CLASS G (DELTA T > 4.0 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 2 OF 2 ELEVATED RELEASE MODE

APR 1, 2012 - JUN 30, 2012

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)						>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4			
N	0.000	0.000	0.092	0.092	0.000	0.399	0.038	0.000	0.000	0.621	
NNE	0.000	0.000	0.046	0.000	0.045	0.274	0.152	0.000	0.000	0.517	
NE	0.000	0.000	0.046	0.046	0.306	0.367	0.038	0.000	0.000	0.802	
ENE	0.000	0.000	0.046	0.092	0.130	0.285	0.000	0.000	0.000	0.553	
E	0.000	0.046	0.092	0.229	0.044	0.123	0.000	0.000	0.000	0.534	
ESE	0.000	0.046	0.046	0.046	0.000	0.000	0.000	0.000	0.000	0.138	
SE	0.000	0.000	0.138	0.046	0.089	0.000	0.000	0.000	0.000	0.272	
SSE	0.000	0.000	0.092	0.046	0.000	0.042	0.000	0.000	0.000	0.180	
S	0.000	0.000	0.046	0.000	0.046	0.082	0.000	0.000	0.000	0.173	
SSW	0.000	0.000	0.000	0.046	0.000	0.000	0.000	0.000	0.000	0.046	
SW	0.000	0.000	0.138	0.046	0.000	0.000	0.000	0.000	0.000	0.183	
WSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
W	0.000	0.000	0.046	0.046	0.000	0.000	0.000	0.000	0.000	0.092	
WNW	0.000	0.000	0.000	0.092	0.000	0.000	0.000	0.000	0.000	0.092	
NW	0.000	0.046	0.046	0.138	0.046	0.042	0.000	0.000	0.000	0.317	
NNW	0.000	0.000	0.092	0.046	0.089	0.039	0.000	0.000	0.000	0.266	
SUBTOTAL	0.000	0.138	0.963	1.009	0.794	1.654	0.228	0.000	0.000	4.786	
TOTAL HOURS OF VALID OBSERVATIONS					2180.000						
TOTAL HOURS OF ELEVATED RELEASES					2000.860						
TOTAL HOURS OF STABILITY CLASS G					115.170						
TOTAL HOURS OF ELEVATED STABILITY CLASS G					104.330						

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 89.59 METERS  
WIND DIRECTION MEASURED AT 45.74 METER LEVEL  
WIND SPEED MEASURED AT 45.74 METER LEVEL  
EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2012/08/20

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

**BROWNS FERRY NUCLEAR PLANT**

**2012 METEOROLOGICAL DATA**

**TABLE 8C**

**JOINT FREQUENCY DISTRIBUTION IN PERCENT**

**FOR SPLIT LEVEL RELEASES**

**(GROUND LEVEL RELEASE MODE AND ELEVATED RELEASE MODE)**

**THIRD QUARTER**

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR  
STABILITY CLASS A (DELTA T<=-1.9 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 1 OF 2 GROUND LEVEL RELEASE MODE

JUL 1, 2012 - SEP 30, 2012

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)						>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4			
N	0.000	0.000	0.000	0.000	0.011	0.007	0.000	0.000	0.000	0.018	
NNE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
NE	0.000	0.000	0.000	0.000	0.004	0.000	0.011	0.000	0.000	0.015	
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
E	0.000	0.000	0.004	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
ESE	0.000	0.000	0.013	0.103	0.008	0.000	0.000	0.000	0.000	0.000	0.124
SE	0.000	0.000	0.071	0.077	0.000	0.000	0.000	0.000	0.000	0.000	0.148
SSE	0.000	0.000	0.057	0.036	0.000	0.000	0.000	0.000	0.000	0.000	0.093
S	0.000	0.000	0.071	0.018	0.000	0.000	0.000	0.000	0.000	0.000	0.089
SSW	0.000	0.000	0.155	0.084	0.000	0.000	0.000	0.000	0.000	0.000	0.239
SW	0.000	0.000	0.019	0.025	0.000	0.000	0.000	0.000	0.000	0.000	0.045
WSW	0.000	0.000	0.000	0.009	0.001	0.000	0.000	0.000	0.000	0.000	0.010
W	0.000	0.000	0.000	0.007	0.070	0.033	0.000	0.000	0.000	0.000	0.110
WNW	0.000	0.000	0.000	0.001	0.009	0.083	0.021	0.000	0.000	0.000	0.114
NW	0.000	0.000	0.000	0.000	0.005	0.026	0.031	0.000	0.000	0.000	0.062
NNW	0.000	0.000	0.000	0.000	0.003	0.014	0.011	0.000	0.000	0.000	0.028
SUBTOTAL	0.000	0.000	0.390	0.362	0.110	0.164	0.073	0.000	0.000	1.098	

TOTAL HOURS OF VALID OBSERVATIONS                            1899.000  
 TOTAL HOURS OF GROUND LEVEL RELEASE                        114.410  
 TOTAL HOURS OF STABILITY CLASS A                            67.530  
 TOTAL HOURS OF GROUND LEVEL STABILITY CLASS A        20.860

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS  
 WIND DIRECTION MEASURED AT 10.50 METER LEVEL  
 WIND SPEED MEASURED AT 10.50 METER LEVEL  
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2012/11/19

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS B (-1.9 < DELTA T <=-1.7 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 1 OF 2 GROUND LEVEL RELEASE MODE

JUL 1, 2012 - SEP 30, 2012

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)						>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4			
N	0.000	0.000	0.000	0.000	0.016	0.014	0.000	0.000	0.000	0.000	0.029
NNE	0.000	0.000	0.000	0.000	0.014	0.013	0.000	0.000	0.000	0.000	0.027
NE	0.000	0.000	0.000	0.000	0.003	0.000	0.000	0.000	0.000	0.000	0.003
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ESE	0.000	0.000	0.009	0.032	0.000	0.000	0.000	0.000	0.000	0.000	0.041
SE	0.000	0.000	0.009	0.005	0.000	0.000	0.000	0.000	0.000	0.000	0.014
SSE	0.000	0.000	0.011	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.011
S	0.000	0.000	0.009	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.009
SSW	0.000	0.000	0.060	0.011	0.000	0.000	0.000	0.000	0.000	0.000	0.070
SW	0.000	0.000	0.011	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.011
WSW	0.000	0.000	0.000	0.003	0.000	0.000	0.000	0.000	0.000	0.000	0.003
W	0.000	0.000	0.000	0.004	0.025	0.004	0.000	0.000	0.000	0.000	0.033
WNW	0.000	0.000	0.000	0.000	0.018	0.007	0.000	0.000	0.000	0.000	0.026
NW	0.000	0.000	0.000	0.000	0.010	0.056	0.011	0.000	0.000	0.000	0.076
NNW	0.000	0.000	0.000	0.002	0.005	0.023	0.000	0.000	0.000	0.000	0.029
SUBTOTAL	0.000	0.000	0.109	0.055	0.091	0.116	0.011	0.000	0.000	0.000	0.382

TOTAL HOURS OF VALID OBSERVATIONS	1899.000
TOTAL HOURS OF GROUND LEVEL RELEASE	114.410
TOTAL HOURS OF STABILITY CLASS B	62.370
TOTAL HOURS OF GROUND LEVEL STABILITY CLASS B	7.260

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS  
 WIND DIRECTION MEASURED AT 10.50 METER LEVEL  
 WIND SPEED MEASURED AT 10.50 METER LEVEL  
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2012/11/19

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS C (-1.7 < DELTA T <=-1.5 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 1 OF 2 GROUND LEVEL RELEASE MODE

JUL 1, 2012 - SEP 30, 2012

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED(MPH)						>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4			
N	0.000	0.000	0.000	0.004	0.014	0.000	0.000	0.000	0.000	0.018	
NNE	0.000	0.000	0.000	0.000	0.004	0.000	0.000	0.000	0.000	0.004	
NE	0.000	0.000	0.000	0.000	0.000	0.005	0.000	0.000	0.000	0.005	
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
E	0.000	0.000	0.000	0.008	0.000	0.000	0.000	0.000	0.000	0.008	
ESE	0.000	0.000	0.000	0.010	0.000	0.000	0.000	0.000	0.000	0.010	
SE	0.000	0.000	0.000	0.007	0.000	0.000	0.000	0.000	0.000	0.007	
SSE	0.000	0.000	0.017	0.000	0.000	0.000	0.000	0.000	0.000	0.017	
S	0.000	0.000	0.005	0.000	0.000	0.000	0.000	0.000	0.000	0.005	
SSW	0.000	0.000	0.014	0.011	0.000	0.000	0.000	0.000	0.000	0.024	
SW	0.000	0.000	0.015	0.000	0.000	0.000	0.000	0.000	0.000	0.015	
WSW	0.000	0.000	0.000	0.019	0.000	0.000	0.000	0.000	0.000	0.019	
W	0.000	0.000	0.002	0.015	0.015	0.006	0.000	0.000	0.000	0.038	
WNW	0.000	0.000	0.000	0.001	0.026	0.007	0.000	0.000	0.000	0.033	
NW	0.000	0.000	0.000	0.001	0.008	0.032	0.000	0.000	0.000	0.040	
NNW	0.000	0.000	0.000	0.000	0.005	0.010	0.000	0.000	0.000	0.015	
<b>SUBTOTAL</b>	<b>0.000</b>	<b>0.000</b>	<b>0.052</b>	<b>0.076</b>	<b>0.072</b>	<b>0.060</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.259</b>	

TOTAL HOURS OF VALID OBSERVATIONS	1899.000
TOTAL HOURS OF GROUND LEVEL RELEASE	114.410
TOTAL HOURS OF STABILITY CLASS C	121.750
TOTAL HOURS OF GROUND LEVEL STABILITY CLASS C	4.910

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS  
 WIND DIRECTION MEASURED AT 10.50 METER LEVEL  
 WIND SPEED MEASURED AT 10.50 METER LEVEL  
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2012/11/19

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS D (-1.5 < DELTA T <= -0.5 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 1 OF 2 GROUND LEVEL RELEASE MODE

JUL 1, 2012 - SEP 30, 2012

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)						>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4			
N	0.000	0.000	0.004	0.012	0.014	0.000	0.000	0.000	0.000	0.029	
NNE	0.000	0.000	0.002	0.015	0.028	0.008	0.011	0.000	0.000	0.065	
NE	0.000	0.000	0.000	0.017	0.006	0.007	0.000	0.000	0.000	0.030	
ENE	0.000	0.000	0.000	0.014	0.000	0.018	0.000	0.000	0.000	0.033	
E	0.000	0.000	0.008	0.053	0.038	0.010	0.000	0.000	0.000	0.110	
ESE	0.000	0.000	0.138	0.245	0.146	0.039	0.000	0.000	0.000	0.569	
SE	0.000	0.000	0.098	0.031	0.000	0.000	0.000	0.000	0.000	0.129	
SSE	0.000	0.000	0.085	0.000	0.000	0.000	0.000	0.000	0.000	0.085	
S	0.000	0.002	0.128	0.000	0.000	0.000	0.000	0.000	0.000	0.130	
SSW	0.000	0.000	0.165	0.015	0.000	0.000	0.000	0.000	0.000	0.180	
SW	0.000	0.000	0.052	0.000	0.011	0.000	0.000	0.000	0.000	0.062	
WSW	0.000	0.000	0.014	0.046	0.000	0.000	0.000	0.000	0.000	0.060	
W	0.000	0.000	0.004	0.060	0.057	0.008	0.000	0.000	0.000	0.130	
WNW	0.000	0.000	0.000	0.008	0.026	0.033	0.000	0.000	0.000	0.067	
NW	0.000	0.000	0.003	0.000	0.004	0.044	0.000	0.000	0.000	0.051	
NNW	0.000	0.000	0.000	0.004	0.029	0.035	0.000	0.000	0.000	0.068	
SUBTOTAL	0.000	0.002	0.702	0.519	0.361	0.204	0.011	0.000	0.000	1.799	

TOTAL HOURS OF VALID OBSERVATIONS	1899.000
TOTAL HOURS OF GROUND LEVEL RELEASE	114.410
TOTAL HOURS OF STABILITY CLASS D	793.600
TOTAL HOURS OF GROUND LEVEL STABILITY CLASS D	34.160

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS  
 WIND DIRECTION MEASURED AT 10.50 METER LEVEL  
 WIND SPEED MEASURED AT 10.50 METER LEVEL  
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2012/11/19

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS E (-0.5 < DELTA T <= 1.5 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 1 OF 2 GROUND LEVEL RELEASE MODE

JUL 1, 2012 - SEP 30, 2012

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)						>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4			
N	0.000	0.000	0.008	0.049	0.000	0.000	0.000	0.000	0.000	0.000	0.057
NNE	0.000	0.000	0.006	0.049	0.042	0.025	0.000	0.000	0.000	0.000	0.123
NE	0.000	0.000	0.011	0.036	0.013	0.026	0.000	0.000	0.000	0.000	0.085
ENE	0.000	0.011	0.028	0.057	0.006	0.000	0.000	0.000	0.000	0.000	0.103
E	0.000	0.001	0.091	0.186	0.008	0.009	0.000	0.000	0.000	0.000	0.295
ESE	0.000	0.000	0.080	0.078	0.009	0.000	0.000	0.000	0.000	0.000	0.167
SE	0.000	0.006	0.043	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.049
SSE	0.000	0.003	0.046	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.049
S	0.000	0.032	0.108	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.140
SSW	0.000	0.008	0.097	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.105
SW	0.000	0.004	0.023	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.027
WSW	0.000	0.004	0.055	0.027	0.000	0.000	0.000	0.000	0.000	0.000	0.085
W	0.000	0.000	0.033	0.056	0.000	0.000	0.000	0.000	0.000	0.000	0.089
WNW	0.000	0.007	0.007	0.014	0.000	0.006	0.000	0.000	0.000	0.000	0.034
NW	0.000	0.000	0.000	0.017	0.012	0.016	0.000	0.000	0.000	0.000	0.045
NNW	0.000	0.000	0.000	0.039	0.015	0.009	0.000	0.000	0.000	0.000	0.063
SUBTOTAL	0.000	0.075	0.636	0.607	0.105	0.091	0.000	0.000	0.000	0.000	1.514
TOTAL HOURS OF VALID OBSERVATIONS				1899.000							
TOTAL HOURS OF GROUND LEVEL RELEASE				114.410							
TOTAL HOURS OF STABILITY CLASS E				537.700							
TOTAL HOURS OF GROUND LEVEL STABILITY CLASS E				28.750							

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS  
 WIND DIRECTION MEASURED AT 10.50 METER LEVEL  
 WIND SPEED MEASURED AT 10.50 METER LEVEL  
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2012/11/19

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR  
STABILITY CLASS F ( 1.5 < DELTA T <= 4.0 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 1 OF 2 GROUND LEVEL RELEASE MODE

JUL 1, 2012 - SEP 30, 2012

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)						>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4			
N	0.000	0.012	0.040	0.033	0.000	0.000	0.000	0.000	0.000	0.000	0.085
NNE	0.000	0.009	0.031	0.042	0.000	0.000	0.000	0.000	0.000	0.000	0.082
NE	0.000	0.005	0.015	0.012	0.000	0.009	0.000	0.000	0.000	0.000	0.041
ENE	0.000	0.003	0.073	0.033	0.000	0.000	0.000	0.000	0.000	0.000	0.108
E	0.000	0.004	0.066	0.075	0.000	0.000	0.000	0.000	0.000	0.000	0.146
ESE	0.000	0.002	0.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.029
SE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SSE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
S	0.000	0.000	0.012	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.012
SSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SW	0.000	0.000	0.010	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.010
WSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
W	0.000	0.000	0.000	0.002	0.000	0.000	0.000	0.000	0.000	0.000	0.002
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NW	0.000	0.003	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.003
NNW	0.000	0.000	0.021	0.043	0.000	0.000	0.000	0.000	0.000	0.000	0.064
SUBTOTAL	0.000	0.037	0.295	0.239	0.000	0.009	0.000	0.000	0.000	0.000	0.581

TOTAL HOURS OF VALID OBSERVATIONS	1899.000
TOTAL HOURS OF GROUND LEVEL RELEASE	114.410
TOTAL HOURS OF STABILITY CLASS F	215.770
TOTAL HOURS OF GROUND LEVEL STABILITY CLASS F	11.030

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS  
 WIND DIRECTION MEASURED AT 10.50 METER LEVEL  
 WIND SPEED MEASURED AT 10.50 METER LEVEL  
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2012/11/19

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR  
STABILITY CLASS G (DELTA T > 4.0 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 1 OF 2 GROUND LEVEL RELEASE MODE

JUL 1, 2012 - SEP 30, 2012

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)						>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4			
N	0.000	0.003	0.059	0.141	0.000	0.000	0.000	0.000	0.000	0.000	0.203
NNE	0.000	0.006	0.011	0.017	0.000	0.000	0.000	0.000	0.000	0.000	0.034
NE	0.000	0.000	0.017	0.007	0.000	0.000	0.000	0.000	0.000	0.000	0.025
ENE	0.000	0.002	0.023	0.027	0.009	0.000	0.000	0.000	0.000	0.000	0.062
E	0.000	0.000	0.023	0.004	0.000	0.000	0.000	0.000	0.000	0.000	0.027
ESE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SE	0.000	0.000	0.004	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.004
SSE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
S	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
W	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNW	0.000	0.002	0.021	0.014	0.000	0.000	0.000	0.000	0.000	0.000	0.037
SUBTOTAL	0.000	0.013	0.159	0.211	0.009	0.000	0.000	0.000	0.000	0.000	0.392
TOTAL HOURS OF VALID OBSERVATIONS				1899.000							
TOTAL HOURS OF GROUND LEVEL RELEASE				114.410							
TOTAL HOURS OF STABILITY CLASS G				100.280							
TOTAL HOURS OF GROUND LEVEL STABILITY CLASS G				7.440							

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS  
WIND DIRECTION MEASURED AT 10.50 METER LEVEL  
WIND SPEED MEASURED AT 10.50 METER LEVEL  
EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2012/11/19

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR  
STABILITY CLASS A (DELTA T<=-1.9 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 2 OF 2 ELEVATED RELEASE MODE

JUL 1, 2012 - SEP 30, 2012

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)						>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4			
N	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ESE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SE	0.000	0.000	0.000	0.000	0.000	0.508	0.000	0.000	0.000	0.000	0.508
SSE	0.000	0.000	0.000	0.000	0.300	0.184	0.000	0.000	0.000	0.000	0.483
S	0.000	0.000	0.000	0.000	0.253	0.145	0.042	0.000	0.000	0.000	0.440
SSW	0.000	0.000	0.000	0.000	0.100	0.327	0.043	0.000	0.000	0.000	0.470
SW	0.000	0.000	0.000	0.000	0.253	0.000	0.000	0.000	0.000	0.000	0.253
WSW	0.000	0.000	0.000	0.053	0.153	0.000	0.000	0.000	0.000	0.000	0.205
W	0.000	0.000	0.000	0.053	0.000	0.045	0.000	0.000	0.000	0.000	0.098
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SUBTOTAL	0.000	0.000	0.000	0.105	1.058	1.209	0.085	0.000	0.000	2.458	
TOTAL HOURS OF VALID OBSERVATIONS					1899.000						
TOTAL HOURS OF ELEVATED RELEASES					1784.590						
TOTAL HOURS OF STABILITY CLASS A					67.530						
TOTAL HOURS OF ELEVATED STABILITY CLASS A					46.670						

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 89.59 METERS  
WIND DIRECTION MEASURED AT 45.74 METER LEVEL  
WIND SPEED MEASURED AT 45.74 METER LEVEL  
EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2012/11/19

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS B (-1.9 < DELTA T <=-1.7 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 2 OF 2 ELEVATED RELEASE MODE

JUL 1, 2012 - SEP 30, 2012

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)						>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4			
N	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ESE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SE	0.000	0.000	0.000	0.105	0.100	0.096	0.085	0.000	0.000	0.000	0.387
SSE	0.000	0.000	0.053	0.000	0.049	0.137	0.000	0.000	0.000	0.000	0.240
S	0.000	0.000	0.000	0.000	0.150	0.234	0.130	0.000	0.000	0.000	0.513
SSW	0.000	0.000	0.000	0.158	0.154	0.186	0.043	0.000	0.000	0.000	0.541
SW	0.000	0.000	0.000	0.158	0.049	0.045	0.000	0.000	0.000	0.000	0.252
WSW	0.000	0.000	0.000	0.105	0.052	0.000	0.000	0.000	0.000	0.000	0.157
W	0.000	0.000	0.000	0.053	0.251	0.239	0.000	0.000	0.000	0.000	0.542
WNW	0.000	0.000	0.000	0.000	0.000	0.091	0.087	0.000	0.000	0.000	0.178
NW	0.000	0.000	0.000	0.000	0.000	0.048	0.044	0.000	0.000	0.000	0.092
NNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SUBTOTAL	0.000	0.000	0.053	0.579	0.805	1.076	0.389	0.000	0.000	2.902	

TOTAL HOURS OF VALID OBSERVATIONS	1899.000
TOTAL HOURS OF ELEVATED RELEASES	1784.590
TOTAL HOURS OF STABILITY CLASS B	62.370
TOTAL HOURS OF ELEVATED STABILITY CLASS B	55.110

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 89.59 METERS  
 WIND DIRECTION MEASURED AT 45.74 METER LEVEL  
 WIND SPEED MEASURED AT 45.74 METER LEVEL  
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2012/11/19

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS C (-1.7 < DELTA T <=-1.5 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 2 OF 2 ELEVATED RELEASE MODE

JUL 1, 2012 - SEP 30, 2012

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)						>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4			
N	0.000	0.000	0.000	0.000	0.000	0.182	0.000	0.000	0.000	0.182	
NNE	0.000	0.000	0.000	0.000	0.000	0.143	0.000	0.000	0.000	0.143	
NE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
E	0.000	0.000	0.000	0.053	0.000	0.000	0.000	0.000	0.000	0.000	0.053
ESE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SE	0.000	0.000	0.053	0.105	0.000	0.411	0.044	0.000	0.000	0.000	0.613
SSE	0.000	0.000	0.105	0.263	0.103	0.095	0.128	0.000	0.000	0.000	0.695
S	0.000	0.000	0.105	0.211	0.049	0.462	0.131	0.000	0.000	0.000	0.958
SSW	0.000	0.000	0.000	0.263	0.152	0.142	0.087	0.000	0.000	0.000	0.645
SW	0.000	0.000	0.000	0.211	0.205	0.187	0.000	0.000	0.000	0.000	0.603
WSW	0.000	0.000	0.053	0.316	0.000	0.047	0.000	0.000	0.000	0.000	0.416
W	0.000	0.000	0.000	0.316	0.515	0.143	0.000	0.000	0.000	0.000	0.974
WNW	0.000	0.000	0.000	0.000	0.150	0.369	0.042	0.000	0.000	0.000	0.560
NW	0.000	0.000	0.000	0.000	0.053	0.044	0.171	0.000	0.000	0.000	0.268
NNW	0.000	0.000	0.000	0.000	0.000	0.000	0.042	0.000	0.000	0.000	0.042
SUBTOTAL	0.000	0.000	0.316	1.738	1.226	2.226	0.646	0.000	0.000	6.153	
TOTAL HOURS OF VALID OBSERVATIONS					1899.000						
TOTAL HOURS OF ELEVATED RELEASES					1784.590						
TOTAL HOURS OF STABILITY CLASS C					121.750						
TOTAL HOURS OF ELEVATED STABILITY CLASS C					116.840						

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 89.59 METERS  
 WIND DIRECTION MEASURED AT 45.74 METER LEVEL  
 WIND SPEED MEASURED AT 45.74 METER LEVEL  
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2012/11/19

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS D (-1.5 < DELTA T <= -0.5 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 2 OF 2 ELEVATED RELEASE MODE

JUL 1, 2012 - SEP 30, 2012

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)						>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4			
N	0.000	0.000	0.158	0.316	0.657	0.427	0.000	0.000	0.000	1.558	
NNE	0.000	0.000	0.105	0.369	0.203	0.425	0.042	0.000	0.000	1.144	
NE	0.000	0.000	0.158	0.316	0.302	0.186	0.044	0.042	0.000	1.048	
ENE	0.000	0.000	0.158	0.211	0.306	0.048	0.000	0.000	0.000	0.723	
E	0.000	0.000	0.158	0.105	0.155	0.048	0.000	0.000	0.000	0.467	
ESE	0.000	0.000	0.105	0.211	0.249	0.463	0.129	0.000	0.000	1.156	
SE	0.000	0.000	0.316	0.579	0.302	1.150	0.509	0.145	0.000	3.002	
SSE	0.000	0.053	0.685	0.790	0.508	1.889	0.988	0.000	0.000	4.913	
S	0.000	0.053	0.685	1.474	0.966	2.788	0.558	0.000	0.000	6.524	
SSW	0.000	0.105	0.632	1.843	1.130	1.534	0.302	0.000	0.000	5.547	
SW	0.000	0.105	0.579	1.001	0.823	0.138	0.086	0.000	0.000	2.732	
WSW	0.000	0.000	0.474	1.106	0.817	0.234	0.000	0.000	0.000	2.631	
W	0.000	0.000	0.263	1.053	1.621	0.938	0.043	0.000	0.000	3.919	
WNW	0.000	0.000	0.000	0.421	0.360	1.078	0.085	0.000	0.000	1.944	
NW	0.000	0.000	0.053	0.316	0.255	0.693	0.087	0.000	0.000	1.403	
NNW	0.000	0.000	0.158	0.316	0.357	0.279	0.172	0.000	0.000	1.281	
SUBTOTAL	0.000	0.316	4.687	10.427	9.011	12.321	3.044	0.187	0.000	39.992	

TOTAL HOURS OF VALID OBSERVATIONS	1899.000
TOTAL HOURS OF ELEVATED RELEASES	1784.590
TOTAL HOURS OF STABILITY CLASS D	793.600
TOTAL HOURS OF ELEVATED STABILITY CLASS D	759.440

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 89.59 METERS  
 WIND DIRECTION MEASURED AT 45.74 METER LEVEL  
 WIND SPEED MEASURED AT 45.74 METER LEVEL  
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2012/11/19

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS E (-0.5 < DELTA T <= 1.5 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 2 OF 2 ELEVATED RELEASE MODE

JUL 1, 2012 - SEP 30, 2012

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)						>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4			
N	0.000	0.000	0.263	0.527	0.103	0.514	0.087	0.000	0.000	1.494	
NNE	0.000	0.053	0.053	0.579	0.559	0.553	0.000	0.000	0.000	1.797	
NE	0.000	0.000	0.105	0.211	0.457	0.412	0.043	0.000	0.000	1.229	
ENE	0.000	0.000	0.421	0.158	0.357	0.242	0.086	0.000	0.000	1.264	
E	0.000	0.000	0.158	0.105	0.349	0.711	0.044	0.000	0.000	1.367	
ESE	0.000	0.000	0.053	0.421	0.451	1.120	0.131	0.000	0.000	2.176	
SE	0.000	0.053	0.105	0.737	0.456	1.080	0.000	0.000	0.000	2.431	
SSE	0.000	0.053	0.369	0.474	0.806	0.466	0.128	0.000	0.000	2.295	
S	0.000	0.053	0.316	0.527	0.561	1.109	0.130	0.000	0.000	2.695	
SSW	0.000	0.053	0.316	0.632	0.759	0.230	0.000	0.000	0.000	1.989	
SW	0.000	0.000	0.263	0.948	0.153	0.090	0.000	0.000	0.000	1.454	
WSW	0.000	0.000	0.316	0.632	0.308	0.094	0.000	0.000	0.000	1.350	
W	0.000	0.000	0.211	0.632	1.371	0.573	0.000	0.000	0.000	2.786	
WNW	0.000	0.000	0.211	0.158	0.309	0.470	0.000	0.000	0.000	1.148	
NW	0.000	0.000	0.000	0.158	0.051	0.000	0.128	0.000	0.000	0.336	
NNW	0.000	0.053	0.211	0.053	0.355	0.188	0.131	0.000	0.000	0.989	
<b>SUBTOTAL</b>	<b>0.000</b>	<b>0.316</b>	<b>3.370</b>	<b>6.951</b>	<b>7.404</b>	<b>7.852</b>	<b>0.908</b>	<b>0.000</b>	<b>0.000</b>	<b>26.801</b>	
TOTAL HOURS OF VALID OBSERVATIONS				1899.000							
TOTAL HOURS OF ELEVATED RELEASES				1784.590							
TOTAL HOURS OF STABILITY CLASS E				537.700							
TOTAL HOURS OF ELEVATED STABILITY CLASS E				508.950							

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 89.59 METERS  
 WIND DIRECTION MEASURED AT 45.74 METER LEVEL  
 WIND SPEED MEASURED AT 45.74 METER LEVEL  
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2012/11/19

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS F ( 1.5 < DELTA T <= 4.0 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 2 OF 2 ELEVATED RELEASE MODE

JUL 1, 2012 - SEP 30, 2012

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)						>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4			
N	0.000	0.000	0.000	0.000	0.101	0.645	0.044	0.000	0.000	0.000	0.789
NNE	0.000	0.000	0.000	0.105	0.504	0.553	0.087	0.000	0.000	0.000	1.249
NE	0.000	0.000	0.053	0.211	0.202	0.504	0.044	0.000	0.000	0.000	1.013
ENE	0.000	0.000	0.105	0.263	0.151	0.185	0.086	0.000	0.000	0.000	0.791
E	0.000	0.000	0.000	0.263	0.305	0.235	0.000	0.000	0.000	0.000	0.804
ESE	0.000	0.053	0.158	0.158	0.450	1.041	0.000	0.000	0.000	0.000	1.859
SE	0.000	0.000	0.105	0.263	0.356	0.519	0.000	0.000	0.000	0.000	1.244
SSE	0.000	0.000	0.105	0.211	0.201	0.192	0.000	0.000	0.000	0.000	0.709
S	0.000	0.000	0.211	0.105	0.151	0.143	0.000	0.000	0.000	0.000	0.610
SSW	0.000	0.000	0.263	0.105	0.154	0.048	0.000	0.000	0.000	0.000	0.571
SW	0.000	0.000	0.053	0.158	0.000	0.000	0.000	0.000	0.000	0.000	0.211
WSW	0.000	0.000	0.000	0.053	0.104	0.000	0.000	0.000	0.000	0.000	0.156
W	0.000	0.000	0.053	0.053	0.000	0.000	0.000	0.000	0.000	0.000	0.105
WNW	0.000	0.000	0.105	0.053	0.051	0.000	0.000	0.000	0.000	0.000	0.209
NW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNW	0.000	0.000	0.105	0.105	0.206	0.045	0.000	0.000	0.000	0.000	0.461
SUBTOTAL	0.000	0.053	1.316	2.106	2.935	4.111	0.261	0.000	0.000	10.781	

TOTAL HOURS OF VALID OBSERVATIONS	1899.000
TOTAL HOURS OF ELEVATED RELEASES	1784.590
TOTAL HOURS OF STABILITY CLASS F	215.770
TOTAL HOURS OF ELEVATED STABILITY CLASS F	204.740

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 89.59 METERS  
 WIND DIRECTION MEASURED AT 45.74 METER LEVEL  
 WIND SPEED MEASURED AT 45.74 METER LEVEL  
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2012/11/19

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR  
STABILITY CLASS G (DELTA T > 4.0 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 2 OF 2 ELEVATED RELEASE MODE

JUL 1, 2012 - SEP 30, 2012

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)						>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4			
N	0.000	0.000	0.000	0.000	0.051	0.000	0.000	0.000	0.000	0.000	0.051
NNE	0.004	0.105	0.053	0.053	0.155	0.411	0.044	0.000	0.000	0.000	0.825
NE	0.006	0.000	0.211	0.316	0.150	0.368	0.000	0.000	0.000	0.000	1.050
ENE	0.001	0.000	0.053	0.158	0.052	0.096	0.000	0.000	0.000	0.000	0.360
E	0.006	0.053	0.158	0.105	0.050	0.145	0.000	0.000	0.000	0.000	0.517
ESE	0.001	0.000	0.053	0.000	0.053	0.000	0.000	0.000	0.000	0.000	0.107
SE	0.003	0.000	0.105	0.105	0.053	0.000	0.000	0.000	0.000	0.000	0.266
SSE	0.007	0.053	0.211	0.000	0.051	0.000	0.000	0.000	0.000	0.000	0.322
S	0.006	0.053	0.158	0.211	0.053	0.000	0.000	0.000	0.000	0.000	0.480
SSW	0.007	0.053	0.211	0.053	0.051	0.000	0.000	0.000	0.000	0.000	0.374
SW	0.000	0.000	0.000	0.105	0.000	0.000	0.000	0.000	0.000	0.000	0.105
WSW	0.006	0.053	0.158	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.216
W	0.000	0.000	0.000	0.053	0.000	0.000	0.000	0.000	0.000	0.000	0.053
WNW	0.001	0.000	0.053	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.054
NW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNW	0.003	0.000	0.105	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.108
SUBTOTAL	0.053	0.369	1.527	1.159	0.718	1.021	0.044	0.000	0.000	4.889	
TOTAL HOURS OF VALID OBSERVATIONS					1899.000						
TOTAL HOURS OF ELEVATED RELEASES					1784.590						
TOTAL HOURS OF STABILITY CLASS G					100.280						
TOTAL HOURS OF ELEVATED STABILITY CLASS G					92.840						

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 89.59 METERS  
WIND DIRECTION MEASURED AT 45.74 METER LEVEL  
WIND SPEED MEASURED AT 45.74 METER LEVEL  
EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2012/11/19

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

**BROWNS FERRY NUCLEAR PLANT**

**2012 METEOROLOGICAL DATA**

**TABLE 8D**

**JOINT FREQUENCY DISTRIBUTION IN PERCENT**

**FOR SPLIT LEVEL RELEASES**

**(GROUND LEVEL RELEASE MODE AND ELEVATED RELEASE MODE)**

**FOURTH QUARTER**

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR  
STABILITY CLASS A (DELTA T<=-1.9 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 1 OF 2 GROUND LEVEL RELEASE MODE

OCT 1, 2012 - DEC 31, 2012

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)						>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4			
N	0.000	0.000	0.000	0.000	0.010	0.024	0.000	0.000	0.000	0.034	
NNE	0.000	0.000	0.000	0.000	0.000	0.031	0.000	0.000	0.000	0.031	
NE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
ENE	0.000	0.000	0.000	0.000	0.010	0.000	0.000	0.000	0.000	0.010	
E	0.000	0.000	0.000	0.006	0.000	0.000	0.000	0.000	0.000	0.006	
ESE	0.000	0.000	0.000	0.029	0.000	0.000	0.000	0.000	0.000	0.029	
SE	0.000	0.000	0.002	0.011	0.000	0.000	0.000	0.000	0.000	0.013	
SSE	0.000	0.000	0.014	0.003	0.000	0.000	0.000	0.000	0.000	0.017	
S	0.000	0.000	0.041	0.029	0.000	0.000	0.000	0.000	0.000	0.070	
SSW	0.000	0.000	0.026	0.035	0.000	0.000	0.000	0.000	0.000	0.060	
SW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
WSW	0.000	0.000	0.000	0.000	0.000	0.008	0.000	0.000	0.000	0.008	
W	0.000	0.000	0.000	0.000	0.000	0.017	0.000	0.000	0.000	0.017	
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.024	0.000	0.000	0.024	
NW	0.000	0.000	0.000	0.000	0.000	0.008	0.000	0.052	0.000	0.060	
NNW	0.000	0.000	0.000	0.000	0.000	0.006	0.000	0.000	0.000	0.006	
SUBTOTAL	0.000	0.000	0.082	0.112	0.020	0.093	0.024	0.052	0.000	0.384	

TOTAL HOURS OF VALID OBSERVATIONS	2111.000
TOTAL HOURS OF GROUND LEVEL RELEASE	233.630
TOTAL HOURS OF STABILITY CLASS A	10.630
TOTAL HOURS OF GROUND LEVEL STABILITY CLASS A	8.100

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS  
WIND DIRECTION MEASURED AT 10.50 METER LEVEL  
WIND SPEED MEASURED AT 10.50 METER LEVEL  
EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2013/02/06

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS B (-1.9 < DELTA T <=-1.7 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 1 OF 2 GROUND LEVEL RELEASE MODE

OCT 1, 2012 - DEC 31, 2012

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)						>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4			
N	0.000	0.000	0.000	0.000	0.000	0.020	0.000	0.000	0.000	0.020	
NNE	0.000	0.000	0.000	0.000	0.022	0.019	0.000	0.000	0.000	0.041	
NE	0.000	0.000	0.000	0.000	0.000	0.001	0.008	0.000	0.000	0.009	
ENE	0.000	0.000	0.000	0.005	0.000	0.000	0.000	0.000	0.000	0.005	
E	0.000	0.000	0.000	0.002	0.001	0.000	0.000	0.000	0.000	0.003	
ESE	0.000	0.000	0.008	0.001	0.009	0.000	0.000	0.000	0.000	0.018	
SE	0.000	0.000	0.004	0.000	0.000	0.000	0.000	0.000	0.000	0.004	
SSE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
S	0.000	0.000	0.004	0.000	0.000	0.000	0.000	0.000	0.000	0.004	
SSW	0.000	0.000	0.003	0.030	0.000	0.000	0.000	0.000	0.000	0.033	
SW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
WSW	0.000	0.000	0.000	0.000	0.000	0.009	0.000	0.000	0.000	0.009	
W	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
WNW	0.000	0.000	0.000	0.000	0.000	0.013	0.045	0.072	0.000	0.130	
NW	0.000	0.000	0.000	0.000	0.000	0.048	0.040	0.027	0.000	0.114	
NNW	0.000	0.000	0.000	0.000	0.000	0.004	0.000	0.000	0.000	0.004	
<b>SUBTOTAL</b>	<b>0.000</b>	<b>0.000</b>	<b>0.019</b>	<b>0.038</b>	<b>0.032</b>	<b>0.114</b>	<b>0.093</b>	<b>0.098</b>	<b>0.000</b>	<b>0.394</b>	

TOTAL HOURS OF VALID OBSERVATIONS	2111.000
TOTAL HOURS OF GROUND LEVEL RELEASE	233.630
TOTAL HOURS OF STABILITY CLASS B	18.530
TOTAL HOURS OF GROUND LEVEL STABILITY CLASS B	8.320

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS  
 WIND DIRECTION MEASURED AT 10.50 METER LEVEL  
 WIND SPEED MEASURED AT 10.50 METER LEVEL  
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2013/02/06

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR  
STABILITY CLASS C (-1.7 < DELTA T <=-1.5 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 1 OF 2 GROUND LEVEL RELEASE MODE

OCT 1, 2012 - DEC 31, 2012

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)						>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4			
N	0.000	0.000	0.000	0.000	0.013	0.041	0.000	0.000	0.000	0.000	0.054
NNE	0.000	0.000	0.000	0.000	0.022	0.014	0.000	0.000	0.000	0.000	0.036
NE	0.000	0.000	0.000	0.000	0.000	0.002	0.000	0.000	0.000	0.000	0.002
ENE	0.000	0.000	0.000	0.006	0.000	0.000	0.000	0.000	0.000	0.000	0.006
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ESE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SE	0.000	0.000	0.009	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.009
SSE	0.000	0.000	0.010	0.002	0.000	0.000	0.000	0.000	0.000	0.000	0.013
S	0.000	0.000	0.003	0.034	0.000	0.000	0.000	0.000	0.000	0.000	0.037
SSW	0.000	0.000	0.003	0.009	0.000	0.000	0.000	0.000	0.000	0.000	0.012
SW	0.000	0.000	0.000	0.007	0.009	0.000	0.000	0.000	0.000	0.000	0.016
WSW	0.000	0.000	0.000	0.001	0.000	0.009	0.000	0.000	0.000	0.000	0.009
W	0.000	0.000	0.000	0.003	0.011	0.000	0.000	0.000	0.000	0.000	0.014
WNW	0.000	0.000	0.000	0.000	0.000	0.030	0.018	0.000	0.000	0.000	0.048
NW	0.000	0.000	0.000	0.000	0.003	0.072	0.016	0.019	0.000	0.000	0.109
NNW	0.000	0.000	0.000	0.000	0.003	0.070	0.000	0.000	0.000	0.000	0.073
SUBTOTAL	0.000	0.000	0.025	0.063	0.061	0.237	0.034	0.019	0.000	0.439	
TOTAL HOURS OF VALID OBSERVATIONS				2111.000							
TOTAL HOURS OF GROUND LEVEL RELEASE				233.630							
TOTAL HOURS OF STABILITY CLASS C				47.060							
TOTAL HOURS OF GROUND LEVEL STABILITY CLASS C				9.260							

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS  
WIND DIRECTION MEASURED AT 10.50 METER LEVEL  
WIND SPEED MEASURED AT 10.50 METER LEVEL  
EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2013/02/06

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS D (-1.5 < DELTA T <= -0.5 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 1 OF 2 GROUND LEVEL RELEASE MODE

OCT 1, 2012 - DEC 31, 2012

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)						>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4			
N	0.000	0.000	0.000	0.027	0.085	0.129	0.000	0.000	0.000	0.000	0.241
NNE	0.000	0.000	0.000	0.026	0.047	0.070	0.000	0.000	0.000	0.000	0.143
NE	0.000	0.000	0.000	0.014	0.022	0.080	0.000	0.000	0.000	0.000	0.116
ENE	0.000	0.000	0.000	0.006	0.008	0.000	0.000	0.000	0.000	0.000	0.013
E	0.000	0.000	0.003	0.031	0.000	0.000	0.000	0.000	0.000	0.000	0.034
ESE	0.000	0.000	0.018	0.044	0.017	0.000	0.000	0.000	0.000	0.000	0.079
SE	0.000	0.000	0.047	0.055	0.000	0.000	0.000	0.000	0.000	0.000	0.102
SSE	0.000	0.000	0.031	0.079	0.000	0.000	0.000	0.000	0.000	0.000	0.110
S	0.000	0.000	0.047	0.117	0.036	0.000	0.000	0.000	0.000	0.000	0.200
SSW	0.000	0.000	0.059	0.066	0.018	0.000	0.000	0.000	0.000	0.000	0.144
SW	0.000	0.000	0.015	0.012	0.009	0.000	0.000	0.000	0.000	0.000	0.036
WSW	0.000	0.000	0.001	0.030	0.013	0.009	0.000	0.000	0.000	0.000	0.053
W	0.000	0.000	0.011	0.040	0.042	0.069	0.187	0.044	0.000	0.000	0.392
WNW	0.000	0.000	0.000	0.013	0.019	0.159	0.367	0.482	0.000	1.039	
NW	0.000	0.000	0.000	0.004	0.029	0.185	0.426	0.062	0.000	0.000	0.706
NNW	0.000	0.000	0.000	0.013	0.117	0.176	0.019	0.000	0.000	0.000	0.325
SUBTOTAL	0.000	0.000	0.232	0.578	0.461	0.875	1.000	0.587	0.000	3.734	

TOTAL HOURS OF VALID OBSERVATIONS	2111.000
TOTAL HOURS OF GROUND LEVEL RELEASE	233.630
TOTAL HOURS OF STABILITY CLASS D	784.020
TOTAL HOURS OF GROUND LEVEL STABILITY CLASS D	78.820

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS  
 WIND DIRECTION MEASURED AT 10.50 METER LEVEL  
 WIND SPEED MEASURED AT 10.50 METER LEVEL  
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2013/02/06

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS E (-0.5 < DELTA T <= 1.5 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 1 OF 2 GROUND LEVEL RELEASE MODE

OCT 1, 2012 - DEC 31, 2012

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)						>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4			
N	0.000	0.000	0.019	0.062	0.028	0.018	0.000	0.000	0.000	0.000	0.127
NNE	0.000	0.000	0.022	0.030	0.043	0.048	0.000	0.000	0.000	0.000	0.143
NE	0.000	0.000	0.018	0.059	0.023	0.030	0.017	0.000	0.000	0.000	0.147
ENE	0.000	0.000	0.022	0.064	0.027	0.026	0.000	0.000	0.000	0.000	0.139
E	0.000	0.004	0.058	0.047	0.008	0.000	0.000	0.000	0.000	0.000	0.117
ESE	0.000	0.001	0.052	0.126	0.037	0.039	0.000	0.000	0.000	0.000	0.256
SE	0.000	0.000	0.114	0.023	0.000	0.038	0.000	0.000	0.000	0.000	0.175
SSE	0.000	0.000	0.066	0.086	0.000	0.000	0.000	0.000	0.000	0.000	0.152
S	0.000	0.001	0.298	0.483	0.204	0.047	0.000	0.000	0.000	0.000	1.034
SSW	0.000	0.000	0.090	0.119	0.009	0.000	0.000	0.000	0.000	0.000	0.218
SW	0.000	0.000	0.072	0.039	0.020	0.000	0.000	0.000	0.000	0.000	0.132
WSW	0.000	0.000	0.036	0.030	0.024	0.000	0.000	0.000	0.000	0.000	0.090
W	0.000	0.000	0.019	0.028	0.032	0.025	0.000	0.000	0.000	0.000	0.105
WNW	0.000	0.000	0.004	0.023	0.018	0.035	0.010	0.000	0.000	0.000	0.090
NW	0.000	0.000	0.008	0.011	0.036	0.067	0.129	0.000	0.000	0.000	0.252
NNW	0.000	0.000	0.024	0.114	0.081	0.074	0.000	0.000	0.000	0.000	0.293
SUBTOTAL	0.000	0.006	0.923	1.346	0.590	0.448	0.156	0.000	0.000	3.468	

TOTAL HOURS OF VALID OBSERVATIONS	2111.000
TOTAL HOURS OF GROUND LEVEL RELEASE	233.630
TOTAL HOURS OF STABILITY CLASS E	719.110
TOTAL HOURS OF GROUND LEVEL STABILITY CLASS E	73.220

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS  
 WIND DIRECTION MEASURED AT 10.50 METER LEVEL  
 WIND SPEED MEASURED AT 10.50 METER LEVEL  
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2013/02/06

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS F ( 1.5 < DELTA T <= 4.0 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 1 OF 2 GROUND LEVEL RELEASE MODE

OCT 1, 2012 - DEC 31, 2012

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED(MPH)						>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4			
N	0.000	0.013	0.092	0.148	0.018	0.000	0.000	0.000	0.000	0.271	
NNE	0.000	0.009	0.062	0.127	0.042	0.008	0.000	0.000	0.000	0.248	
NE	0.000	0.003	0.072	0.074	0.052	0.019	0.000	0.000	0.000	0.220	
ENE	0.000	0.001	0.090	0.034	0.000	0.000	0.000	0.000	0.000	0.126	
E	0.000	0.002	0.083	0.027	0.000	0.000	0.000	0.000	0.000	0.111	
ESE	0.000	0.003	0.090	0.032	0.000	0.000	0.000	0.000	0.000	0.124	
SE	0.000	0.016	0.111	0.000	0.000	0.000	0.000	0.000	0.000	0.126	
SSE	0.000	0.012	0.123	0.115	0.000	0.000	0.000	0.000	0.000	0.250	
S	0.000	0.011	0.101	0.147	0.000	0.000	0.000	0.000	0.000	0.260	
SSW	0.000	0.000	0.015	0.015	0.000	0.000	0.000	0.000	0.000	0.030	
SW	0.000	0.003	0.009	0.000	0.000	0.017	0.000	0.000	0.000	0.029	
WSW	0.000	0.000	0.006	0.000	0.000	0.000	0.000	0.000	0.000	0.006	
W	0.000	0.000	0.011	0.005	0.000	0.000	0.000	0.000	0.000	0.016	
WNW	0.000	0.000	0.000	0.006	0.007	0.000	0.000	0.000	0.000	0.013	
NW	0.000	0.000	0.007	0.000	0.001	0.009	0.000	0.000	0.000	0.017	
NNW	0.000	0.000	0.050	0.061	0.022	0.000	0.000	0.000	0.000	0.133	
SUBTOTAL	0.000	0.073	0.922	0.790	0.144	0.052	0.000	0.000	0.000	1.980	

TOTAL HOURS OF VALID OBSERVATIONS	2111.000
TOTAL HOURS OF GROUND LEVEL RELEASE	233.630
TOTAL HOURS OF STABILITY CLASS F	389.270
TOTAL HOURS OF GROUND LEVEL STABILITY CLASS F	41.800

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS  
 WIND DIRECTION MEASURED AT 10.50 METER LEVEL  
 WIND SPEED MEASURED AT 10.50 METER LEVEL  
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2013/02/06

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS G (DELTA T > 4.0 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 1 OF 2 GROUND LEVEL RELEASE MODE

OCT 1, 2012 - DEC 31, 2012

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)						>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4			
N	0.000	0.012	0.069	0.054	0.000	0.000	0.000	0.000	0.000	0.000	0.135
NNE	0.000	0.003	0.045	0.094	0.002	0.000	0.000	0.000	0.000	0.000	0.144
NE	0.000	0.027	0.045	0.052	0.021	0.011	0.000	0.000	0.000	0.000	0.156
ENE	0.000	0.020	0.029	0.007	0.000	0.000	0.000	0.000	0.000	0.000	0.056
E	0.000	0.005	0.031	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.036
ESE	0.000	0.003	0.023	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.026
SE	0.000	0.009	0.007	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.015
SSE	0.000	0.000	0.014	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.014
S	0.000	0.002	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.002
SSW	0.000	0.000	0.009	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.009
SW	0.000	0.000	0.000	0.000	0.010	0.000	0.000	0.000	0.000	0.000	0.010
WSW	0.000	0.013	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.013
W	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NW	0.000	0.004	0.000	0.002	0.000	0.000	0.000	0.000	0.000	0.000	0.006
NNW	0.000	0.005	0.024	0.011	0.006	0.000	0.000	0.000	0.000	0.000	0.046
SUBTOTAL	0.000	0.103	0.294	0.221	0.039	0.011	0.000	0.000	0.000	0.000	0.668

TOTAL HOURS OF VALID OBSERVATIONS	2111.000
TOTAL HOURS OF GROUND LEVEL RELEASE	233.630
TOTAL HOURS OF STABILITY CLASS G	142.380
TOTAL HOURS OF GROUND LEVEL STABILITY CLASS G	14.110

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS  
 WIND DIRECTION MEASURED AT 10.50 METER LEVEL  
 WIND SPEED MEASURED AT 10.50 METER LEVEL  
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2013/02/06

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR  
STABILITY CLASS A (DELTA T<=-1.9 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 2 OF 2 ELEVATED RELEASE MODE

OCT 1, 2012 - DEC 31, 2012

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)						>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4			
N	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ESE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SSE	0.000	0.000	0.000	0.000	0.000	0.000	0.038	0.000	0.000	0.000	0.038
S	0.000	0.000	0.000	0.000	0.000	0.000	0.038	0.000	0.000	0.000	0.038
SSW	0.000	0.000	0.000	0.000	0.044	0.000	0.000	0.000	0.000	0.000	0.044
SW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
W	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SUBTOTAL	0.000	0.000	0.000	0.000	0.044	0.000	0.076	0.000	0.000	0.120	
TOTAL HOURS OF VALID OBSERVATIONS					2111.000						
TOTAL HOURS OF ELEVATED RELEASES					1877.370						
TOTAL HOURS OF STABILITY CLASS A					10.630						
TOTAL HOURS OF ELEVATED STABILITY CLASS A					2.530						

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 89.59 METERS  
WIND DIRECTION MEASURED AT 45.74 METER LEVEL  
WIND SPEED MEASURED AT 45.74 METER LEVEL  
EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2013/02/06

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR  
STABILITY CLASS B (-1.9 < DELTA T <=-1.7 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 2 OF 2 ELEVATED RELEASE MODE

OCT 1, 2012 - DEC 31, 2012

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)						>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4			
N	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNE	0.000	0.000	0.000	0.000	0.000	0.040	0.039	0.000	0.000	0.000	0.079
NE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ESE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SE	0.000	0.000	0.000	0.047	0.046	0.044	0.000	0.000	0.000	0.000	0.137
SSE	0.000	0.000	0.000	0.000	0.045	0.000	0.038	0.000	0.000	0.000	0.083
S	0.000	0.000	0.000	0.047	0.092	0.000	0.000	0.000	0.000	0.000	0.140
SSW	0.000	0.000	0.000	0.000	0.045	0.000	0.000	0.000	0.000	0.000	0.045
SW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
W	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SUBTOTAL	0.000	0.000	0.000	0.095	0.228	0.084	0.077	0.000	0.000	0.484	
TOTAL HOURS OF VALID OBSERVATIONS					2111.000						
TOTAL HOURS OF ELEVATED RELEASES					1877.370						
TOTAL HOURS OF STABILITY CLASS B					18.530						
TOTAL HOURS OF ELEVATED STABILITY CLASS B					10.210						

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 89.59 METERS  
WIND DIRECTION MEASURED AT 45.74 METER LEVEL  
WIND SPEED MEASURED AT 45.74 METER LEVEL  
EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2013/02/06

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR  
STABILITY CLASS C (-1.7 < DELTA T <=-1.5 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 2 OF 2 ELEVATED RELEASE MODE

OCT 1, 2012 - DEC 31, 2012

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)						>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4			
N	0.000	0.000	0.000	0.000	0.000	0.040	0.078	0.000	0.000	0.000	0.118
NNE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ESE	0.000	0.000	0.000	0.000	0.047	0.000	0.000	0.000	0.000	0.000	0.047
SE	0.000	0.000	0.000	0.237	0.138	0.000	0.039	0.000	0.000	0.000	0.414
SSE	0.000	0.000	0.000	0.047	0.092	0.040	0.000	0.000	0.000	0.000	0.180
S	0.000	0.000	0.000	0.189	0.046	0.169	0.000	0.000	0.000	0.000	0.405
SSW	0.000	0.000	0.000	0.000	0.139	0.087	0.000	0.000	0.000	0.000	0.225
SW	0.000	0.000	0.000	0.047	0.000	0.000	0.000	0.000	0.000	0.000	0.047
WSW	0.000	0.000	0.000	0.000	0.047	0.000	0.078	0.000	0.000	0.000	0.126
W	0.000	0.000	0.000	0.000	0.000	0.000	0.039	0.000	0.000	0.000	0.039
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.039	0.088	0.000	0.000	0.127
NW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.021	0.000	0.000	0.021
NNW	0.000	0.000	0.000	0.000	0.000	0.042	0.000	0.000	0.000	0.000	0.042
SUBTOTAL	0.000	0.000	0.000	0.521	0.510	0.377	0.274	0.108	0.000	1.791	
TOTAL HOURS OF VALID OBSERVATIONS					2111.000						
TOTAL HOURS OF ELEVATED RELEASES					1877.370						
TOTAL HOURS OF STABILITY CLASS C					47.060						
TOTAL HOURS OF ELEVATED STABILITY CLASS C					37.800						

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 89.59 METERS  
WIND DIRECTION MEASURED AT 45.74 METER LEVEL  
WIND SPEED MEASURED AT 45.74 METER LEVEL  
EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2013/02/06

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS D (-1.5 < DELTA T <= -0.5 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 2 OF 2 ELEVATED RELEASE MODE

OCT 1, 2012 - DEC 31, 2012

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)						>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4			
N	0.000	0.000	0.000	0.284	0.498	1.568	0.661	0.000	0.000	0.000	3.012
NNE	0.000	0.000	0.095	0.663	1.041	1.338	0.196	0.000	0.000	0.000	3.332
NE	0.000	0.047	0.095	0.284	0.365	0.590	0.039	0.000	0.000	0.000	1.421
ENE	0.000	0.000	0.047	0.142	0.181	0.253	0.000	0.000	0.000	0.000	0.623
E	0.000	0.047	0.095	0.095	0.090	0.000	0.000	0.000	0.000	0.000	0.327
ESE	0.000	0.000	0.142	0.000	0.046	0.123	0.000	0.000	0.000	0.000	0.312
SE	0.000	0.000	0.805	1.137	0.646	0.546	0.542	0.000	0.000	0.000	3.676
SSE	0.000	0.047	0.663	0.474	0.231	0.212	0.385	0.189	0.016	0.000	2.217
S	0.000	0.000	0.426	0.332	0.506	0.779	0.504	0.280	0.000	0.000	2.827
SSW	0.000	0.000	0.332	0.284	0.226	0.414	0.268	0.022	0.000	0.000	1.546
SW	0.000	0.000	0.426	0.237	0.137	0.502	0.114	0.000	0.000	0.000	1.416
WSW	0.000	0.000	0.379	0.332	0.135	0.247	0.117	0.034	0.000	0.000	1.243
W	0.000	0.095	0.237	0.332	0.630	0.584	0.232	0.099	0.020	0.000	2.228
WNW	0.000	0.047	0.047	0.284	0.458	1.001	0.541	0.710	0.024	0.000	3.112
NW	0.000	0.000	0.095	0.189	0.407	1.431	1.147	0.398	0.000	0.000	3.667
NNW	0.000	0.000	0.047	0.047	0.312	1.419	0.583	0.036	0.000	0.000	2.445
SUBTOTAL	0.000	0.284	3.932	5.116	5.910	11.007	5.327	1.769	0.061	0.000	33.406
TOTAL HOURS OF VALID OBSERVATIONS					2111.000						
TOTAL HOURS OF ELEVATED RELEASES					1877.370						
TOTAL HOURS OF STABILITY CLASS D					784.020						
TOTAL HOURS OF ELEVATED STABILITY CLASS D					705.200						

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 89.59 METERS  
 WIND DIRECTION MEASURED AT 45.74 METER LEVEL  
 WIND SPEED MEASURED AT 45.74 METER LEVEL  
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2013/02/06

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR  
STABILITY CLASS E (-0.5 < DELTA T <= 1.5 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 2 OF 2 ELEVATED RELEASE MODE

OCT 1, 2012 - DEC 31, 2012

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)						>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4			
N	0.000	0.000	0.047	0.142	0.320	0.917	0.000	0.000	0.000	1.426	
NNE	0.000	0.000	0.047	0.095	0.403	1.559	0.196	0.000	0.000	2.300	
NE	0.000	0.000	0.095	0.142	0.316	0.672	0.117	0.000	0.000	1.342	
ENE	0.000	0.000	0.095	0.332	0.137	0.252	0.117	0.000	0.000	0.933	
E	0.000	0.000	0.189	0.189	0.233	0.296	0.077	0.000	0.000	0.984	
ESE	0.000	0.047	0.237	0.379	0.419	0.420	0.038	0.037	0.000	1.577	
SE	0.000	0.000	0.047	0.663	0.647	0.991	0.461	0.061	0.009	2.880	
SSE	0.000	0.000	0.095	0.379	0.721	1.975	1.194	0.608	0.017	4.988	
S	0.000	0.000	0.095	0.379	0.597	2.487	1.460	0.512	0.000	5.530	
SSW	0.000	0.000	0.000	0.237	0.277	0.782	0.463	0.124	0.000	1.883	
SW	0.000	0.000	0.000	0.379	0.318	0.591	0.114	0.031	0.000	1.433	
WSW	0.000	0.000	0.047	0.189	0.185	0.125	0.079	0.000	0.000	0.625	
W	0.000	0.000	0.047	0.142	0.461	0.410	0.000	0.000	0.000	1.061	
WNW	0.000	0.047	0.047	0.047	0.090	0.374	0.000	0.031	0.000	0.638	
NW	0.000	0.000	0.095	0.095	0.181	0.580	0.348	0.000	0.000	1.298	
NNW	0.000	0.000	0.095	0.047	0.366	0.957	0.233	0.000	0.000	1.698	
<b>SUBTOTAL</b>	<b>0.000</b>	<b>0.095</b>	<b>1.279</b>	<b>3.837</b>	<b>5.671</b>	<b>13.387</b>	<b>4.896</b>	<b>1.405</b>	<b>0.026</b>	<b>30.596</b>	

TOTAL HOURS OF VALID OBSERVATIONS	2111.000
TOTAL HOURS OF ELEVATED RELEASES	1877.370
TOTAL HOURS OF STABILITY CLASS E	719.110
TOTAL HOURS OF ELEVATED STABILITY CLASS E	645.890

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 89.59 METERS  
 WIND DIRECTION MEASURED AT 45.74 METER LEVEL  
 WIND SPEED MEASURED AT 45.74 METER LEVEL  
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2013/02/06

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR  
STABILITY CLASS F ( 1.5 < DELTA T <= 4.0 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 2 OF 2 ELEVATED RELEASE MODE

OCT 1, 2012 - DEC 31, 2012

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)						>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4			
N	0.000	0.000	0.095	0.000	0.182	0.382	0.000	0.000	0.000	0.659	
NNE	0.000	0.000	0.142	0.142	0.134	1.160	0.156	0.000	0.000	1.734	
NE	0.000	0.000	0.047	0.142	0.321	0.169	0.000	0.000	0.000	0.680	
ENE	0.000	0.000	0.142	0.189	0.270	0.169	0.000	0.000	0.000	0.771	
E	0.000	0.000	0.047	0.047	0.185	0.042	0.000	0.000	0.000	0.322	
ESE	0.000	0.047	0.189	0.189	0.505	0.126	0.000	0.000	0.000	1.057	
SE	0.000	0.047	0.189	0.332	1.004	1.019	0.117	0.000	0.000	2.710	
SSE	0.000	0.000	0.189	0.332	1.182	1.243	0.273	0.034	0.000	3.254	
S	0.000	0.047	0.142	0.189	0.493	1.248	0.117	0.000	0.000	2.236	
SSW	0.000	0.000	0.047	0.189	0.456	0.215	0.000	0.000	0.000	0.908	
SW	0.000	0.047	0.047	0.142	0.140	0.000	0.000	0.000	0.000	0.377	
WSW	0.000	0.047	0.142	0.142	0.047	0.000	0.000	0.000	0.000	0.378	
W	0.000	0.000	0.000	0.142	0.047	0.000	0.000	0.000	0.000	0.189	
WNW	0.000	0.000	0.047	0.142	0.092	0.000	0.000	0.000	0.000	0.281	
NW	0.000	0.000	0.047	0.189	0.137	0.128	0.000	0.000	0.000	0.502	
NNW	0.000	0.000	0.142	0.000	0.132	0.128	0.000	0.000	0.000	0.402	
SUBTOTAL	0.000	0.237	1.658	2.511	5.327	6.030	0.664	0.034	0.000	16.460	
TOTAL HOURS OF VALID OBSERVATIONS					2111.000						
TOTAL HOURS OF ELEVATED RELEASES					1877.370						
TOTAL HOURS OF STABILITY CLASS F					389.270						
TOTAL HOURS OF ELEVATED STABILITY CLASS F					347.470						

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 89.59 METERS  
WIND DIRECTION MEASURED AT 45.74 METER LEVEL  
WIND SPEED MEASURED AT 45.74 METER LEVEL  
EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2013/02/06

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR  
STABILITY CLASS G (DELTA T > 4.0 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 2 OF 2 ELEVATED RELEASE MODE

OCT 1, 2012 - DEC 31, 2012

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)						>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4			
N	0.000	0.000	0.047	0.000	0.047	0.000	0.000	0.000	0.000	0.095	
NNE	0.000	0.000	0.047	0.047	0.044	0.000	0.000	0.000	0.000	0.000	0.139
NE	0.000	0.000	0.095	0.047	0.183	0.084	0.000	0.000	0.000	0.000	0.410
ENE	0.000	0.000	0.095	0.095	0.000	0.171	0.000	0.000	0.000	0.000	0.360
E	0.000	0.000	0.047	0.047	0.000	0.087	0.000	0.000	0.000	0.000	0.181
ESE	0.000	0.000	0.095	0.189	0.139	0.083	0.000	0.000	0.000	0.000	0.506
SE	0.000	0.047	0.189	0.474	0.675	0.257	0.000	0.000	0.000	0.000	1.642
SSE	0.000	0.047	0.237	0.284	0.182	0.172	0.039	0.000	0.000	0.000	0.962
S	0.000	0.047	0.047	0.047	0.000	0.041	0.000	0.000	0.000	0.000	0.183
SSW	0.000	0.142	0.047	0.000	0.134	0.043	0.000	0.000	0.000	0.000	0.367
SW	0.000	0.000	0.047	0.095	0.000	0.000	0.000	0.000	0.000	0.000	0.142
WSW	0.000	0.095	0.095	0.047	0.000	0.000	0.000	0.000	0.000	0.000	0.237
W	0.000	0.000	0.000	0.047	0.000	0.000	0.000	0.000	0.000	0.000	0.047
WNW	0.000	0.000	0.142	0.189	0.000	0.000	0.000	0.000	0.000	0.000	0.332
NW	0.000	0.000	0.237	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.237
NNW	0.000	0.000	0.142	0.095	0.000	0.000	0.000	0.000	0.000	0.000	0.237
SUBTOTAL	0.000	0.379	1.611	1.705	1.404	0.938	0.039	0.000	0.000	6.076	
TOTAL HOURS OF VALID OBSERVATIONS					2111.000						
TOTAL HOURS OF ELEVATED RELEASES					1877.370						
TOTAL HOURS OF STABILITY CLASS G					142.380						
TOTAL HOURS OF ELEVATED STABILITY CLASS G					128.270						

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 89.59 METERS  
WIND DIRECTION MEASURED AT 45.74 METER LEVEL  
WIND SPEED MEASURED AT 45.74 METER LEVEL  
EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2013/02/06

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

**BROWNS FERRY NUCLEAR PLANT**

**2012 METEOROLOGICAL DATA**

**TABLE 9A**

**JOINT FREQUENCY DISTRIBUTION IN PERCENT**

**FOR ELEVATED RELEASES**

**FIRST QUARTER**

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

### JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS A (DELTA T<=-1.9 C/100 M)

## BROWNS FERRY NUCLEAR PLANT

JAN 1, 2012 - MAR 31, 2012

WIND DIRECTION	WIND SPEED (MPH)									TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5	
N	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ESE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SSE	0.000	0.000	0.000	0.000	0.142	0.000	0.095	0.000	0.000	0.237
S	0.000	0.000	0.000	0.000	0.047	0.000	0.095	0.000	0.000	0.142
SSW	0.000	0.000	0.000	0.000	0.000	0.000	0.095	0.000	0.000	0.095
SW	0.000	0.000	0.000	0.000	0.000	0.047	0.000	0.000	0.000	0.047
WSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
W	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SUBTOTAL	0.000	0.000	0.000	0.000	0.190	0.047	0.285	0.000	0.000	0.522

TOTAL HOURS OF VALID STABILITY OBSERVATIONS	2107
TOTAL HOURS OF STABILITY CLASS A	11
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS A	11
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS	2107
TOTAL HOURS CALM	0

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 89.59 METERS  
WIND SPEED AND DIRECTION MEASURED AT 90.29 METER LEVEL

MEAN WIND SPEED = 11.66

DATE PRINTED: 2012/05/15

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS B      (-1.9 < DELTA T <=-1.7 C/100 M)

BROWNS FERRY NUCLEAR PLANT

JAN 1, 2012 - MAR 31, 2012

WIND DIRECTION	WIND SPEED (MPH)									TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5	
N	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNE	0.000	0.000	0.000	0.000	0.000	0.000	0.047	0.000	0.000	0.047
NE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ESE	0.000	0.000	0.000	0.000	0.047	0.095	0.000	0.000	0.000	0.142
SE	0.000	0.000	0.000	0.000	0.000	0.142	0.047	0.000	0.000	0.190
SSE	0.000	0.000	0.000	0.000	0.000	0.000	0.047	0.000	0.000	0.047
S	0.000	0.000	0.000	0.000	0.000	0.047	0.047	0.000	0.000	0.095
SSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SW	0.000	0.000	0.000	0.000	0.000	0.000	0.095	0.000	0.000	0.095
WSW	0.000	0.000	0.000	0.000	0.000	0.047	0.047	0.000	0.000	0.095
W	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SUBTOTAL	0.000	0.000	0.000	0.000	0.047	0.332	0.332	0.000	0.000	0.712

TOTAL HOURS OF VALID STABILITY OBSERVATIONS	2107
TOTAL HOURS OF STABILITY CLASS B	15
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS B	15
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS	2107
TOTAL HOURS CALM	0

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 89.59 METERS  
 WIND SPEED AND DIRECTION MEASURED AT 90.29 METER LEVEL

MEAN WIND SPEED = 12.10

DATE PRINTED: 2012/05/15

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS C      (-1.7 < DELTA T <=-1.5 C/100 M)

BROWNS FERRY NUCLEAR PLANT

JAN 1, 2012 - MAR 31, 2012

WIND DIRECTION	WIND SPEED (MPH)										TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5		
N	0.000	0.000	0.000	0.000	0.000	0.000	0.190	0.000	0.000	0.190	
NNE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
NE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
ESE	0.000	0.000	0.000	0.000	0.142	0.000	0.095	0.047	0.047	0.332	
SE	0.000	0.000	0.000	0.047	0.047	0.095	0.142	0.000	0.000	0.332	
SSE	0.000	0.000	0.000	0.000	0.047	0.047	0.000	0.000	0.000	0.095	
S	0.000	0.000	0.000	0.095	0.000	0.000	0.000	0.000	0.000	0.095	
SSW	0.000	0.000	0.000	0.047	0.000	0.047	0.047	0.000	0.000	0.142	
SW	0.000	0.000	0.095	0.047	0.047	0.000	0.095	0.047	0.000	0.332	
WSW	0.000	0.000	0.000	0.000	0.000	0.047	0.000	0.000	0.000	0.047	
W	0.000	0.000	0.000	0.000	0.000	0.047	0.142	0.000	0.000	0.190	
WNW	0.000	0.000	0.000	0.000	0.000	0.047	0.095	0.190	0.095	0.427	
NW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.047	0.047	0.095	
NNW	0.000	0.000	0.000	0.000	0.000	0.047	0.047	0.142	0.000	0.237	
SUBTOTAL	0.000	0.000	0.095	0.237	0.285	0.380	0.854	0.475	0.190	2.515	

TOTAL HOURS OF VALID STABILITY OBSERVATIONS	2107
TOTAL HOURS OF STABILITY CLASS C	53
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS C	53
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS	2107
TOTAL HOURS CALM	0

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 89.59 METERS  
 WIND SPEED AND DIRECTION MEASURED AT 90.29 METER LEVEL

DATE PRINTED: 2012/05/15

MEAN WIND SPEED = 14.30

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS D      (-1.5 < DELTA T <= -0.5 C/100 M)

BROWNS FERRY NUCLEAR PLANT

JAN 1, 2012 - MAR 31, 2012

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)						>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4			
N	0.000	0.000	0.047	0.190	0.190	0.854	0.380	0.570	0.047	0.000	2.278
NNE	0.000	0.000	0.142	0.142	0.285	0.997	0.380	0.332	0.000	0.000	2.278
NE	0.000	0.000	0.047	0.095	0.237	0.807	0.095	0.000	0.000	0.000	1.281
ENE	0.000	0.000	0.000	0.047	0.237	0.427	0.047	0.000	0.000	0.000	0.759
E	0.000	0.000	0.000	0.000	0.190	0.190	0.047	0.000	0.000	0.000	0.427
ESE	0.000	0.000	0.000	0.427	0.190	0.380	0.380	0.190	0.000	0.000	1.566
SE	0.000	0.000	0.095	0.332	0.190	0.142	0.237	0.570	0.047	0.047	1.614
SSE	0.000	0.000	0.142	0.332	0.570	0.427	0.095	0.427	0.095	0.095	2.088
S	0.000	0.000	0.047	0.095	0.095	0.522	0.237	0.095	0.047	0.047	1.139
SSW	0.000	0.047	0.142	0.095	0.142	0.285	0.332	0.190	0.142	0.142	1.376
SW	0.000	0.000	0.285	0.142	0.237	0.427	0.190	0.095	0.000	0.000	1.376
WSW	0.000	0.000	0.190	0.190	0.285	0.854	0.617	0.427	0.000	0.000	2.563
W	0.000	0.000	0.190	0.237	0.427	0.475	0.759	0.664	0.285	0.285	3.037
WNW	0.000	0.000	0.047	0.190	0.380	1.851	0.949	1.092	0.427	0.427	4.936
NW	0.000	0.000	0.047	0.237	0.285	0.332	0.759	0.997	0.332	0.332	2.990
NNW	0.000	0.000	0.000	0.190	0.142	0.712	1.044	0.759	0.095	0.095	2.943
SUBTOTAL	0.000	0.047	1.424	2.943	4.082	9.682	6.550	6.407	1.519	32.653	

TOTAL HOURS OF VALID STABILITY OBSERVATIONS	2107
TOTAL HOURS OF STABILITY CLASS D	688
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS D	688
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS	2107
TOTAL HOURS CALM	0

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 89.59 METERS  
WIND SPEED AND DIRECTION MEASURED AT 90.29 METER LEVEL

MEAN WIND SPEED = 12.76

DATE PRINTED: 2012/05/15

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS E      (-0.5 < DELTA T <= 1.5 C/100 M)

BROWNS FERRY NUCLEAR PLANT

JAN 1, 2012 - MAR 31, 2012

WIND DIRECTION	WIND SPEED (MPH)									TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5	
N	0.000	0.000	0.047	0.000	0.095	0.807	0.712	0.047	0.047	1.756
NNE	0.000	0.000	0.095	0.047	0.190	0.854	0.712	0.332	0.000	2.231
NE	0.000	0.000	0.000	0.000	0.380	0.617	0.902	0.142	0.000	2.041
ENE	0.000	0.000	0.000	0.142	0.095	0.522	0.190	0.000	0.000	0.949
E	0.000	0.000	0.047	0.142	0.095	0.142	0.332	0.000	0.000	0.759
ESE	0.000	0.000	0.000	0.142	0.237	0.522	0.902	0.617	0.047	2.468
SE	0.000	0.000	0.095	0.142	0.475	0.854	1.281	2.468	0.427	5.743
SSE	0.000	0.000	0.190	0.047	0.475	0.759	1.709	1.804	0.570	5.553
S	0.000	0.000	0.047	0.427	0.332	1.756	1.756	1.187	1.092	6.597
SSW	0.000	0.000	0.095	0.095	0.332	0.807	1.044	1.614	0.712	4.699
SW	0.000	0.047	0.095	0.190	0.475	1.519	0.807	0.332	0.142	3.607
WSW	0.000	0.000	0.000	0.380	0.427	0.712	0.285	0.237	0.000	2.041
W	0.000	0.000	0.047	0.047	0.047	0.854	0.237	0.190	0.047	1.471
WNW	0.000	0.047	0.000	0.190	0.142	0.427	0.190	0.095	0.000	1.092
NW	0.000	0.000	0.095	0.142	0.237	0.522	0.617	0.617	0.000	2.231
NNW	0.000	0.000	0.047	0.095	0.000	0.807	1.281	0.285	0.047	2.563
SUBTOTAL	0.000	0.095	0.902	2.231	4.034	12.482	12.957	9.967	3.132	45.800

TOTAL HOURS OF VALID STABILITY OBSERVATIONS	2107
TOTAL HOURS OF STABILITY CLASS E	965
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS E	965
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS	2107
TOTAL HOURS CALM	0

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 89.59 METERS  
 WIND SPEED AND DIRECTION MEASURED AT 90.29 METER LEVEL

MEAN WIND SPEED = 14.38

DATE PRINTED: 2012/05/15

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS F      ( 1.5 < DELTA T <= 4.0 C/100 M)

BROWNS FERRY NUCLEAR PLANT

JAN 1, 2012 - MAR 31, 2012

WIND DIRECTION	CALM	WIND SPEED (MPH)									TOTAL
		0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5		
N	0.000	0.000	0.000	0.000	0.095	0.427	0.427	0.000	0.000	0.949	
NNE	0.000	0.000	0.000	0.000	0.000	0.190	0.617	0.190	0.000	0.997	
NE	0.000	0.000	0.000	0.000	0.047	0.380	0.237	0.095	0.000	0.759	
ENE	0.000	0.000	0.047	0.095	0.047	0.047	0.095	0.000	0.000	0.332	
E	0.000	0.000	0.000	0.142	0.142	0.190	0.237	0.095	0.000	0.807	
ESE	0.000	0.000	0.000	0.000	0.095	0.047	0.190	0.000	0.000	0.332	
SE	0.000	0.000	0.047	0.047	0.047	0.237	0.617	0.332	0.332	1.661	
SSE	0.000	0.000	0.000	0.000	0.000	0.047	1.566	0.949	0.190	2.753	
S	0.000	0.047	0.047	0.047	0.237	0.617	1.661	0.380	0.000	3.037	
SSW	0.000	0.000	0.000	0.000	0.190	0.902	0.712	0.047	0.000	1.851	
SW	0.000	0.000	0.000	0.000	0.000	0.664	0.475	0.000	0.000	1.139	
WSW	0.000	0.047	0.000	0.095	0.000	0.237	0.000	0.000	0.000	0.380	
W	0.000	0.000	0.047	0.095	0.047	0.095	0.095	0.000	0.000	0.380	
WNW	0.000	0.000	0.095	0.047	0.190	0.095	0.000	0.000	0.000	0.427	
NW	0.000	0.000	0.000	0.047	0.047	0.285	0.000	0.000	0.000	0.380	
NNW	0.000	0.000	0.000	0.000	0.047	0.142	0.047	0.000	0.000	0.237	
SUBTOTAL	0.000	0.095	0.285	0.617	1.234	4.604	6.977	2.088	0.522	16.421	

TOTAL HOURS OF VALID STABILITY OBSERVATIONS	2107
TOTAL HOURS OF STABILITY CLASS F	346
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS F	346
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS	2107
TOTAL HOURS CALM	0

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 89.59 METERS  
 WIND SPEED AND DIRECTION MEASURED AT 90.29 METER LEVEL

DATE PRINTED: 2012/05/15

MEAN WIND SPEED = 13.56

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR  
STABILITY CLASS G      (DELTA T > 4.0 C/100 M)

BROWNS FERRY NUCLEAR PLANT

JAN 1, 2012 - MAR 31, 2012

WIND DIRECTION	WIND SPEED (MPH)										TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5		
N	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNE	0.000	0.000	0.000	0.000	0.000	0.000	0.047	0.000	0.000	0.000	0.047
NE	0.000	0.000	0.000	0.000	0.000	0.047	0.142	0.000	0.000	0.000	0.190
ENE	0.000	0.000	0.000	0.000	0.000	0.142	0.000	0.000	0.000	0.000	0.142
E	0.000	0.000	0.000	0.000	0.047	0.142	0.000	0.000	0.000	0.000	0.190
ESE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SSE	0.000	0.000	0.000	0.000	0.000	0.000	0.047	0.047	0.000	0.000	0.095
S	0.000	0.000	0.000	0.000	0.000	0.000	0.237	0.047	0.000	0.000	0.285
SSW	0.000	0.000	0.000	0.000	0.000	0.000	0.142	0.000	0.000	0.000	0.142
SW	0.000	0.000	0.000	0.000	0.000	0.047	0.000	0.000	0.000	0.000	0.047
WSW	0.000	0.000	0.000	0.000	0.000	0.047	0.047	0.000	0.000	0.000	0.095
W	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WNW	0.000	0.000	0.047	0.047	0.000	0.000	0.000	0.000	0.000	0.000	0.095
NW	0.000	0.000	0.000	0.000	0.047	0.000	0.000	0.000	0.000	0.000	0.047
NNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SUBTOTAL	0.000	0.000	0.047	0.047	0.095	0.427	0.664	0.095	0.000	1.376	

TOTAL HOURS OF VALID STABILITY OBSERVATIONS	2107
TOTAL HOURS OF STABILITY CLASS G	29
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS G	29
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS	2107
TOTAL HOURS CALM	0

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 89.59 METERS  
WIND SPEED AND DIRECTION MEASURED AT 90.29 METER LEVEL

MEAN WIND SPEED = 12.17

DATE PRINTED: 2012/05/15

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

**BROWNS FERRY NUCLEAR PLANT**

**2012 METEOROLOGICAL DATA**

**TABLE 9B**

**JOINT FREQUENCY DISTRIBUTION IN PERCENT**

**FOR ELEVATED RELEASES**

**SECOND QUARTER**

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS A                    (DELTA T<=-1.9 C/100 M)

BROWNS FERRY NUCLEAR PLANT

APR 1, 2012 - JUN 30, 2012

WIND DIRECTION	WIND SPEED (MPH)									TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5	
N	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNE	0.000	0.000	0.000	0.000	0.000	0.000	0.275	0.046	0.000	0.321
NE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ESE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SE	0.000	0.000	0.000	0.138	0.138	0.505	0.000	0.046	0.000	0.826
SSE	0.000	0.000	0.000	0.138	0.413	0.275	0.183	0.000	0.000	1.009
S	0.000	0.000	0.000	0.000	0.092	0.413	0.229	0.000	0.000	0.734
SSW	0.000	0.000	0.000	0.000	0.000	0.183	0.000	0.000	0.000	0.183
SW	0.000	0.000	0.000	0.046	0.046	0.000	0.000	0.000	0.000	0.092
WSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
W	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.046	0.000	0.000	0.046
NW	0.000	0.000	0.000	0.000	0.000	0.000	0.092	0.000	0.000	0.092
NNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.092	0.092
SUBTOTAL	0.000	0.000	0.000	0.321	0.688	1.376	0.826	0.092	0.092	3.394

TOTAL HOURS OF VALID STABILITY OBSERVATIONS	2180
TOTAL HOURS OF STABILITY CLASS A	74
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS A	74
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS	2180
TOTAL HOURS CALM	0

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 89.59 METERS  
 WIND SPEED AND DIRECTION MEASURED AT 90.29 METER LEVEL

MEAN WIND SPEED = 10.89

DATE PRINTED: 2012/08/20

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS B      (-1.9 < DELTA T <=-1.7 C/100 M)

BROWNS FERRY NUCLEAR PLANT

APR 1, 2012 - JUN 30, 2012

WIND DIRECTION	CALM	WIND SPEED (MPH)									TOTAL
		0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5		
N	0.000	0.000	0.000	0.000	0.000	0.138	0.046	0.046	0.000	0.229	
NNE	0.000	0.000	0.000	0.000	0.000	0.183	0.092	0.046	0.000	0.321	
NE	0.000	0.000	0.000	0.000	0.000	0.092	0.000	0.000	0.000	0.092	
ENE	0.000	0.000	0.000	0.000	0.046	0.000	0.000	0.000	0.000	0.046	
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
ESE	0.000	0.000	0.000	0.046	0.000	0.183	0.000	0.000	0.000	0.229	
SE	0.000	0.000	0.046	0.092	0.505	0.321	0.092	0.000	0.000	1.055	
SSE	0.000	0.000	0.000	0.183	0.092	0.046	0.092	0.000	0.000	0.413	
S	0.000	0.000	0.000	0.046	0.046	0.321	0.138	0.000	0.000	0.550	
SSW	0.000	0.000	0.000	0.092	0.138	0.046	0.092	0.046	0.000	0.413	
SW	0.000	0.000	0.000	0.046	0.000	0.000	0.092	0.000	0.000	0.138	
WSW	0.000	0.000	0.000	0.046	0.000	0.000	0.000	0.000	0.000	0.046	
W	0.000	0.000	0.000	0.092	0.046	0.000	0.000	0.000	0.000	0.138	
WNW	0.000	0.000	0.000	0.000	0.046	0.046	0.000	0.000	0.000	0.092	
NW	0.000	0.000	0.000	0.046	0.000	0.138	0.092	0.046	0.000	0.321	
NNW	0.000	0.000	0.000	0.000	0.000	0.046	0.138	0.046	0.046	0.275	
SUBTOTAL	0.000	0.000	0.046	0.688	0.917	1.560	0.872	0.229	0.046	4.358	

TOTAL HOURS OF VALID STABILITY OBSERVATIONS	2180
TOTAL HOURS OF STABILITY CLASS B	95
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS B	95
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS	2180
TOTAL HOURS CALM	0

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 89.59 METERS  
WIND SPEED AND DIRECTION MEASURED AT 90.29 METER LEVEL

MEAN WIND SPEED = 9.92

DATE PRINTED: 2012/08/20

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS C      (-1.7 < DELTA T <=-1.5 C/100 M)

BROWNS FERRY NUCLEAR PLANT

APR 1, 2012 - JUN 30, 2012

WIND DIRECTION	WIND SPEED (MPH)									TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5	
N	0.000	0.000	0.000	0.000	0.000	0.505	0.229	0.046	0.000	0.780
NNE	0.000	0.000	0.000	0.000	0.000	0.459	0.183	0.046	0.000	0.688
NE	0.000	0.000	0.000	0.000	0.000	0.000	0.046	0.000	0.000	0.046
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ESE	0.000	0.000	0.000	0.046	0.092	0.000	0.046	0.000	0.000	0.183
SE	0.000	0.000	0.046	0.413	0.183	0.183	0.138	0.000	0.000	0.963
SSE	0.000	0.000	0.092	0.229	0.046	0.138	0.046	0.046	0.000	0.596
S	0.000	0.000	0.000	0.183	0.046	0.046	0.183	0.000	0.000	0.459
SSW	0.000	0.000	0.092	0.046	0.000	0.229	0.000	0.000	0.000	0.367
SW	0.000	0.000	0.000	0.138	0.092	0.183	0.092	0.000	0.000	0.505
WSW	0.000	0.000	0.000	0.321	0.138	0.138	0.092	0.000	0.000	0.688
W	0.000	0.000	0.046	0.275	0.138	0.138	0.000	0.000	0.000	0.596
WNW	0.000	0.000	0.000	0.000	0.183	0.183	0.092	0.046	0.000	0.505
NW	0.000	0.000	0.000	0.000	0.046	0.046	0.138	0.229	0.000	0.459
NNW	0.000	0.000	0.000	0.046	0.000	0.092	0.550	0.046	0.000	0.734
SUBTOTAL	0.000	0.000	0.275	1.697	0.963	2.339	1.835	0.459	0.000	7.569

TOTAL HOURS OF VALID STABILITY OBSERVATIONS	2180
TOTAL HOURS OF STABILITY CLASS C	165
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS C	165
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS	2180
TOTAL HOURS CALM	0

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 89.59 METERS  
WIND SPEED AND DIRECTION MEASURED AT 90.29 METER LEVEL

MEAN WIND SPEED = 9.85

DATE PRINTED: 2012/08/20

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS D      (-1.5 < DELTA T <= -0.5 C/100 M)

BROWNS FERRY NUCLEAR PLANT

APR 1, 2012 - JUN 30, 2012

WIND DIRECTION	WIND SPEED (MPH)									TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5	
N	0.000	0.000	0.092	0.138	0.183	1.239	1.055	0.367	0.092	3.165
NNE	0.000	0.000	0.092	0.046	0.367	1.055	0.642	0.000	0.000	2.202
NE	0.000	0.046	0.046	0.092	0.046	0.321	0.046	0.000	0.000	0.596
ENE	0.000	0.000	0.046	0.000	0.092	0.275	0.000	0.000	0.000	0.413
E	0.000	0.000	0.046	0.138	0.046	0.229	0.000	0.000	0.000	0.459
ESE	0.000	0.046	0.046	0.367	0.183	0.550	0.550	0.046	0.000	1.789
SE	0.000	0.000	0.550	0.275	0.275	0.734	1.422	0.321	0.046	3.624
SSE	0.000	0.000	0.688	0.367	0.138	0.505	1.101	0.550	0.000	3.349
S	0.000	0.046	0.367	0.459	0.367	0.550	0.688	0.138	0.000	2.615
SSW	0.000	0.000	0.138	0.229	0.321	0.596	0.367	0.046	0.000	1.697
SW	0.000	0.000	0.321	0.505	0.505	0.734	0.505	0.000	0.000	2.569
WSW	0.000	0.000	0.321	0.780	0.275	0.734	0.642	0.000	0.000	2.752
W	0.000	0.046	0.183	0.688	0.459	0.917	0.321	0.000	0.000	2.615
WNW	0.000	0.000	0.000	0.275	0.550	1.835	0.459	0.046	0.000	3.165
NW	0.000	0.000	0.183	0.275	0.642	1.009	0.642	0.229	0.000	2.982
NNW	0.000	0.000	0.000	0.138	0.321	1.101	0.688	0.183	0.000	2.431
SUBTOTAL	0.000	0.183	3.119	4.771	4.771	12.385	9.128	1.927	0.138	36.422

TOTAL HOURS OF VALID STABILITY OBSERVATIONS	2180
TOTAL HOURS OF STABILITY CLASS D	794
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS D	794
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS	2180
TOTAL HOURS CALM	0

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 89.59 METERS  
WIND SPEED AND DIRECTION MEASURED AT 90.29 METER LEVEL

MEAN WIND SPEED = 9.92

DATE PRINTED: 2012/08/20

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS E      (-0.5 < DELTA T <= 1.5 C/100 M)

BROWNS FERRY NUCLEAR PLANT

APR 1, 2012 - JUN 30, 2012

WIND DIRECTION	CALM	WIND SPEED (MPH)								TOTAL
		0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5	
N	0.000	0.000	0.000	0.229	0.321	0.688	1.101	0.092	0.000	2.431
NNE	0.000	0.000	0.046	0.046	0.046	0.688	1.239	0.642	0.000	2.706
NE	0.000	0.000	0.046	0.046	0.046	0.367	0.413	0.321	0.000	1.239
ENE	0.000	0.000	0.000	0.046	0.046	0.183	0.138	0.000	0.000	0.413
E	0.000	0.000	0.092	0.000	0.046	0.321	0.046	0.000	0.000	0.505
ESE	0.000	0.000	0.046	0.183	0.092	0.734	0.229	0.000	0.000	1.284
SE	0.000	0.000	0.000	0.092	0.183	0.872	0.826	0.138	0.000	2.110
SSE	0.000	0.000	0.092	0.183	0.275	1.284	1.239	0.550	0.046	3.670
S	0.000	0.046	0.138	0.321	0.688	0.872	0.734	0.550	0.138	3.486
SSW	0.000	0.046	0.046	0.275	0.413	0.734	0.321	0.046	0.000	1.881
SW	0.000	0.000	0.000	0.229	0.505	0.780	0.550	0.000	0.000	2.064
WSW	0.000	0.000	0.229	0.550	0.275	0.413	0.046	0.000	0.000	1.514
W	0.000	0.000	0.138	0.138	0.092	0.642	0.505	0.000	0.000	1.514
WNW	0.000	0.000	0.046	0.046	0.229	0.596	0.183	0.000	0.000	1.101
NW	0.000	0.000	0.183	0.183	0.046	0.367	0.229	0.138	0.000	1.147
NNW	0.000	0.000	0.092	0.092	0.275	0.688	0.642	0.183	0.000	1.972
SUBTOTAL	0.000	0.092	1.193	2.661	3.578	10.229	8.440	2.661	0.183	29.037

TOTAL HOURS OF VALID STABILITY OBSERVATIONS	2180
TOTAL HOURS OF STABILITY CLASS E	633
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS E	633
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS	2180
TOTAL HOURS CALM	0

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 89.59 METERS  
WIND SPEED AND DIRECTION MEASURED AT 90.29 METER LEVEL

MEAN WIND SPEED = 11.32

DATE PRINTED: 2012/08/20

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS F      ( 1.5 < DELTA T <= 4.0 C/100 M)

BROWNS FERRY NUCLEAR PLANT

APR 1, 2012 - JUN 30, 2012

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)						>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4			
N	0.000	0.046	0.046	0.046	0.229	0.183	0.550	0.138	0.000	0.000	1.239
NNE	0.000	0.000	0.000	0.092	0.183	0.275	0.550	0.596	0.000	0.000	1.697
NE	0.000	0.000	0.046	0.000	0.046	0.321	0.826	0.092	0.000	0.000	1.330
ENE	0.000	0.000	0.000	0.046	0.046	0.275	0.275	0.000	0.000	0.000	0.642
E	0.000	0.046	0.000	0.138	0.092	0.275	0.046	0.000	0.000	0.000	0.596
ESE	0.000	0.000	0.046	0.046	0.229	0.138	0.183	0.000	0.000	0.000	0.642
SE	0.000	0.000	0.046	0.321	0.046	0.596	0.046	0.000	0.000	0.000	1.055
SSE	0.000	0.000	0.046	0.092	0.138	0.688	0.138	0.092	0.000	0.000	1.193
S	0.000	0.000	0.092	0.092	0.092	0.550	0.367	0.000	0.000	0.000	1.193
SSW	0.000	0.000	0.000	0.046	0.183	0.550	0.321	0.046	0.000	0.000	1.147
SW	0.000	0.000	0.138	0.183	0.229	0.183	0.046	0.000	0.000	0.000	0.780
WSW	0.000	0.000	0.138	0.092	0.046	0.046	0.046	0.000	0.000	0.000	0.367
W	0.000	0.000	0.000	0.046	0.092	0.092	0.183	0.000	0.000	0.000	0.413
WNW	0.000	0.000	0.046	0.138	0.321	0.183	0.092	0.000	0.000	0.000	0.780
NW	0.000	0.000	0.000	0.000	0.183	0.138	0.000	0.000	0.000	0.000	0.321
NNW	0.000	0.000	0.046	0.138	0.275	0.046	0.229	0.000	0.000	0.000	0.734
SUBTOTAL	0.000	0.092	0.688	1.514	2.431	4.541	3.899	0.963	0.000	14.128	

TOTAL HOURS OF VALID STABILITY OBSERVATIONS	2180
TOTAL HOURS OF STABILITY CLASS F	308
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS F	308
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS	2180
TOTAL HOURS CALM	0

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 89.59 METERS  
 WIND SPEED AND DIRECTION MEASURED AT 90.29 METER LEVEL

MEAN WIND SPEED = 10.54

DATE PRINTED: 2012/08/20

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS G                    (DELTA T > 4.0 C/100 M)

BROWNS FERRY NUCLEAR PLANT

APR 1, 2012 - JUN 30, 2012

WIND DIRECTION	WIND SPEED (MPH)									TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5	
N	0.000	0.000	0.000	0.000	0.046	0.046	0.229	0.000	0.000	0.321
NNE	0.000	0.000	0.046	0.046	0.000	0.046	0.367	0.138	0.000	0.642
NE	0.000	0.000	0.046	0.000	0.046	0.092	0.229	0.138	0.000	0.550
ENE	0.000	0.046	0.092	0.138	0.000	0.321	0.138	0.000	0.000	0.734
E	0.000	0.046	0.000	0.138	0.000	0.321	0.092	0.000	0.000	0.596
ESE	0.000	0.000	0.092	0.092	0.092	0.138	0.046	0.000	0.000	0.459
SE	0.000	0.000	0.183	0.046	0.046	0.000	0.000	0.000	0.000	0.275
SSE	0.000	0.000	0.046	0.000	0.000	0.138	0.000	0.000	0.000	0.183
S	0.000	0.000	0.092	0.000	0.000	0.046	0.046	0.000	0.000	0.183
SSW	0.000	0.000	0.000	0.046	0.046	0.046	0.046	0.000	0.000	0.183
SW	0.000	0.000	0.092	0.000	0.046	0.046	0.000	0.000	0.000	0.183
WSW	0.000	0.000	0.046	0.000	0.000	0.000	0.000	0.000	0.000	0.046
W	0.000	0.000	0.000	0.000	0.046	0.000	0.000	0.000	0.000	0.046
WNW	0.000	0.000	0.000	0.000	0.000	0.046	0.000	0.000	0.000	0.046
NW	0.000	0.000	0.000	0.000	0.046	0.046	0.000	0.000	0.000	0.092
NNW	0.000	0.000	0.046	0.046	0.321	0.092	0.046	0.000	0.000	0.550
SUBTOTAL	0.000	0.092	0.780	0.550	0.734	1.422	1.239	0.275	0.000	5.092

TOTAL HOURS OF VALID STABILITY OBSERVATIONS	2180
TOTAL HOURS OF STABILITY CLASS G	111
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS G	111
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS	2180
TOTAL HOURS CALM	0

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 89.59 METERS  
 WIND SPEED AND DIRECTION MEASURED AT 90.29 METER LEVEL

DATE PRINTED: 2012/08/20

MEAN WIND SPEED = 9.52

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

**BROWNS FERRY NUCLEAR PLANT**

**2012 METEOROLOGICAL DATA**

**TABLE 9C**

**JOINT FREQUENCY DISTRIBUTION IN PERCENT**

**FOR ELEVATED RELEASES**

**THIRD QUARTER**

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS A (DELTA T<=-1.9 C/100 M)

## BROWNS FERRY NUCLEAR PLANT

JUL 1, 2012 - SEP 30, 2012

WIND DIRECTION	WIND SPEED (MPH)										TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5		
N	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ESE	0.000	0.000	0.000	0.000	0.000	0.102	0.000	0.000	0.000	0.000	0.102
SE	0.000	0.000	0.000	0.000	0.051	0.511	0.102	0.000	0.000	0.000	0.664
SSE	0.000	0.000	0.000	0.000	0.255	0.153	0.000	0.000	0.000	0.000	0.409
S	0.000	0.000	0.000	0.051	0.000	0.204	0.051	0.000	0.000	0.000	0.306
SSW	0.000	0.000	0.000	0.000	0.000	0.409	0.153	0.000	0.000	0.000	0.562
SW	0.000	0.000	0.000	0.000	0.051	0.204	0.000	0.000	0.000	0.000	0.255
WSW	0.000	0.000	0.000	0.051	0.153	0.051	0.000	0.000	0.000	0.000	0.255
W	0.000	0.000	0.000	0.000	0.000	0.051	0.000	0.000	0.000	0.000	0.051
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SUBTOTAL	0.000	0.000	0.000	0.102	0.511	1.685	0.306	0.000	0.000	2.605	

TOTAL HOURS OF VALID STABILITY OBSERVATIONS	1958
TOTAL HOURS OF STABILITY CLASS A	51
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS A	51
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS	1958
TOTAL HOURS CALM	0

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 89.59 METERS  
WIND SPEED AND DIRECTION MEASURED AT 90.29 METER LEVEL

DATE PRINTED: 2012/11/19

MEAN WIND SPEED = 9.70

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS B      (-1.9 < DELTA T <=-1.7 C/100 M)

BROWNS FERRY NUCLEAR PLANT

JUL 1, 2012 - SEP 30, 2012

WIND DIRECTION	WIND SPEED (MPH)									TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5	
N	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ESE	0.000	0.000	0.000	0.000	0.051	0.000	0.000	0.000	0.000	0.051
SE	0.000	0.000	0.000	0.102	0.102	0.153	0.051	0.051	0.000	0.460
SSE	0.000	0.000	0.000	0.051	0.051	0.051	0.051	0.000	0.000	0.204
S	0.000	0.000	0.000	0.000	0.000	0.358	0.102	0.051	0.000	0.511
SSW	0.000	0.000	0.000	0.102	0.051	0.204	0.153	0.000	0.000	0.511
SW	0.000	0.000	0.000	0.102	0.051	0.102	0.051	0.000	0.000	0.306
WSW	0.000	0.000	0.000	0.051	0.204	0.051	0.000	0.000	0.000	0.306
W	0.000	0.000	0.000	0.000	0.102	0.460	0.000	0.000	0.000	0.562
WNW	0.000	0.000	0.000	0.000	0.000	0.102	0.102	0.000	0.000	0.204
NW	0.000	0.000	0.000	0.000	0.000	0.051	0.051	0.000	0.000	0.102
NNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SUBTOTAL	0.000	0.000	0.000	0.409	0.562	1.583	0.562	0.102	0.000	3.218

TOTAL HOURS OF VALID STABILITY OBSERVATIONS	1958
TOTAL HOURS OF STABILITY CLASS B	63
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS B	63
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS	1958
TOTAL HOURS CALM	0

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 89.59 METERS  
 WIND SPEED AND DIRECTION MEASURED AT 90.29 METER LEVEL

MEAN WIND SPEED = 9.74

DATE PRINTED: 2012/11/19

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS C      (-1.7 < DELTA T <=-1.5 C/100 M)

BROWNS FERRY NUCLEAR PLANT

JUL 1, 2012 - SEP 30, 2012

WIND DIRECTION	WIND SPEED (MPH)									TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5	
N	0.000	0.000	0.000	0.000	0.000	0.204	0.000	0.000	0.000	0.204
NNE	0.000	0.000	0.000	0.000	0.000	0.153	0.000	0.000	0.000	0.153
NE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
E	0.000	0.000	0.000	0.051	0.000	0.000	0.000	0.000	0.000	0.051
ESE	0.000	0.000	0.000	0.000	0.000	0.051	0.051	0.000	0.000	0.102
SE	0.000	0.000	0.051	0.153	0.255	0.204	0.306	0.000	0.000	0.970
SSE	0.000	0.000	0.102	0.153	0.000	0.051	0.153	0.051	0.000	0.511
S	0.000	0.000	0.000	0.255	0.000	0.409	0.204	0.000	0.000	0.868
SSW	0.000	0.000	0.000	0.204	0.051	0.153	0.102	0.051	0.000	0.562
SW	0.000	0.000	0.000	0.153	0.204	0.358	0.000	0.051	0.000	0.766
WSW	0.000	0.000	0.000	0.153	0.102	0.204	0.000	0.000	0.000	0.460
W	0.000	0.000	0.000	0.204	0.511	0.306	0.000	0.000	0.000	1.021
WNW	0.000	0.000	0.000	0.000	0.102	0.460	0.102	0.000	0.000	0.664
NW	0.000	0.000	0.000	0.000	0.051	0.000	0.204	0.000	0.000	0.255
NNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.051	0.000	0.051
SUBTOTAL	0.000	0.000	0.153	1.328	1.277	2.554	1.124	0.204	0.000	6.639

TOTAL HOURS OF VALID STABILITY OBSERVATIONS	1958
TOTAL HOURS OF STABILITY CLASS C	130
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS C	130
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS	1958
TOTAL HOURS CALM	0

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 89.59 METERS  
WIND SPEED AND DIRECTION MEASURED AT 90.29 METER LEVEL

MEAN WIND SPEED = 9.16

DATE PRINTED: 2012/11/19

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS D      (-1.5 < DELTA T <= -0.5 C/100 M)

BROWNS FERRY NUCLEAR PLANT

JUL 1, 2012 - SEP 30, 2012

WIND DIRECTION	WIND SPEED (MPH)									TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5	
N	0.000	0.000	0.153	0.204	0.664	0.613	0.000	0.000	0.000	1.634
NNE	0.000	0.000	0.102	0.204	0.051	0.562	0.051	0.051	0.000	1.021
NE	0.000	0.000	0.255	0.102	0.255	0.255	0.153	0.051	0.000	1.073
ENE	0.000	0.000	0.153	0.409	0.153	0.204	0.000	0.000	0.000	0.919
E	0.000	0.000	0.153	0.102	0.102	0.102	0.000	0.000	0.000	0.460
ESE	0.000	0.000	0.153	0.204	0.153	0.409	0.460	0.153	0.000	1.532
SE	0.000	0.051	0.204	0.511	0.460	1.175	1.124	0.817	0.000	4.341
SSE	0.000	0.000	0.409	0.613	0.409	1.685	1.430	0.358	0.000	4.903
S	0.000	0.000	0.613	0.715	0.766	2.247	1.073	0.102	0.000	5.516
SSW	0.000	0.051	0.460	0.919	1.021	2.094	0.664	0.102	0.051	5.363
SW	0.000	0.000	0.409	0.409	0.868	1.073	0.409	0.051	0.000	3.218
WSW	0.000	0.000	0.358	0.562	0.766	1.021	0.051	0.000	0.000	2.758
W	0.000	0.000	0.306	0.562	1.124	2.298	0.306	0.000	0.000	4.597
WNW	0.000	0.000	0.102	0.460	0.511	1.532	0.102	0.051	0.000	2.758
NW	0.000	0.000	0.051	0.204	0.204	0.868	0.102	0.051	0.000	1.481
NNW	0.000	0.000	0.102	0.306	0.306	0.409	0.204	0.000	0.000	1.328
SUBTOTAL	0.000	0.102	3.984	6.486	7.814	16.547	6.129	1.788	0.051	42.901

TOTAL HOURS OF VALID STABILITY OBSERVATIONS	1958
TOTAL HOURS OF STABILITY CLASS D	840
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS D	840
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS	1958
TOTAL HOURS CALM	0

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 89.59 METERS  
WIND SPEED AND DIRECTION MEASURED AT 90.29 METER LEVEL

MEAN WIND SPEED = 8.84

DATE PRINTED: 2012/11/19

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS E      (-0.5 < DELTA T <= 1.5 C/100 M)

BROWNS FERRY NUCLEAR PLANT

JUL 1, 2012 - SEP 30, 2012

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)						>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4			
N	0.000	0.000	0.051	0.153	0.255	0.306	0.153	0.000	0.000	0.000	0.919
NNE	0.000	0.000	0.153	0.153	0.306	0.562	0.715	0.051	0.000	0.000	1.941
NE	0.000	0.000	0.102	0.204	0.204	0.358	0.409	0.102	0.000	0.000	1.379
ENE	0.000	0.000	0.153	0.000	0.153	0.306	0.102	0.051	0.000	0.000	0.766
E	0.000	0.000	0.153	0.051	0.102	0.562	0.409	0.000	0.000	0.000	1.277
ESE	0.000	0.000	0.000	0.204	0.051	0.919	0.970	0.102	0.000	0.000	2.247
SE	0.000	0.000	0.051	0.358	0.409	1.532	0.460	0.000	0.000	0.000	2.809
SSE	0.000	0.000	0.204	0.409	0.664	1.328	0.204	0.051	0.000	0.000	2.860
S	0.000	0.000	0.358	0.255	0.460	0.817	0.715	0.000	0.000	0.000	2.605
SSW	0.000	0.051	0.358	0.153	0.255	0.817	0.409	0.000	0.000	0.000	2.043
SW	0.000	0.000	0.102	0.102	0.358	0.919	0.255	0.051	0.000	0.000	1.788
WSW	0.000	0.051	0.255	0.255	0.204	0.715	0.102	0.000	0.000	0.000	1.583
W	0.000	0.000	0.000	0.358	0.358	1.685	0.358	0.000	0.000	0.000	2.758
WNW	0.000	0.000	0.102	0.153	0.511	1.021	0.051	0.000	0.000	0.000	1.839
NW	0.000	0.000	0.051	0.204	0.102	0.153	0.102	0.051	0.000	0.000	0.664
NNW	0.000	0.051	0.153	0.000	0.204	0.460	0.255	0.000	0.000	0.000	1.124
SUBTOTAL	0.000	0.153	2.247	3.013	4.597	12.462	5.669	0.460	0.000	28.601	

TOTAL HOURS OF VALID STABILITY OBSERVATIONS	1958
TOTAL HOURS OF STABILITY CLASS E	560
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS E	560
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS	1958
TOTAL HOURS CALM	0

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 89.59 METERS  
 WIND SPEED AND DIRECTION MEASURED AT 90.29 METER LEVEL

MEAN WIND SPEED = 9.24

DATE PRINTED: 2012/11/19

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS F      ( 1.5 < DELTA T <= 4.0 C/100 M)

BROWNS FERRY NUCLEAR PLANT

JUL 1, 2012 - SEP 30, 2012

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)						>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4			
N	0.000	0.000	0.000	0.051	0.153	0.153	0.358	0.000	0.000	0.715	
NNE	0.000	0.000	0.000	0.051	0.000	0.306	0.562	0.306	0.000	0.000	1.226
NE	0.000	0.000	0.051	0.051	0.102	0.409	0.204	0.102	0.000	0.000	0.919
ENE	0.000	0.000	0.051	0.051	0.204	0.204	0.460	0.051	0.000	0.000	1.021
E	0.000	0.000	0.051	0.000	0.153	0.102	0.102	0.000	0.000	0.000	0.409
ESE	0.000	0.000	0.000	0.000	0.204	0.460	0.306	0.000	0.000	0.000	0.970
SE	0.000	0.000	0.102	0.358	0.255	0.970	0.409	0.000	0.000	0.000	2.094
SSE	0.000	0.000	0.153	0.102	0.204	0.511	0.051	0.000	0.000	0.000	1.021
S	0.000	0.000	0.153	0.102	0.153	0.409	0.102	0.000	0.000	0.000	0.919
SSW	0.000	0.000	0.051	0.306	0.051	0.204	0.102	0.000	0.000	0.000	0.715
SW	0.000	0.000	0.000	0.000	0.000	0.102	0.000	0.000	0.000	0.000	0.102
WSW	0.000	0.000	0.051	0.000	0.000	0.102	0.000	0.000	0.000	0.000	0.153
W	0.000	0.000	0.051	0.102	0.000	0.051	0.000	0.000	0.000	0.000	0.204
WNW	0.000	0.000	0.000	0.102	0.102	0.051	0.000	0.000	0.000	0.000	0.255
NW	0.000	0.000	0.051	0.000	0.051	0.000	0.000	0.000	0.000	0.000	0.102
NNW	0.000	0.000	0.000	0.102	0.102	0.051	0.051	0.000	0.000	0.000	0.306
SUBTOTAL	0.000	0.000	0.766	1.379	1.736	4.086	2.707	0.460	0.000	11.134	

TOTAL HOURS OF VALID STABILITY OBSERVATIONS	1958
TOTAL HOURS OF STABILITY CLASS F	218
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS F	218
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS	1958
TOTAL HOURS CALM	0

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 89.59 METERS  
 WIND SPEED AND DIRECTION MEASURED AT 90.29 METER LEVEL

MEAN WIND SPEED = 9.90

DATE PRINTED: 2012/11/19

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS G                    (DELTA T > 4.0 C/100 M)

BROWNS FERRY NUCLEAR PLANT

JUL 1, 2012 - SEP 30, 2012

WIND DIRECTION	WIND SPEED (MPH)									TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5	
N	0.000	0.051	0.153	0.000	0.000	0.000	0.000	0.000	0.000	0.204
NNE	0.000	0.000	0.051	0.102	0.000	0.051	0.204	0.051	0.000	0.460
NE	0.000	0.000	0.051	0.102	0.000	0.306	0.358	0.102	0.000	0.919
ENE	0.000	0.000	0.000	0.000	0.051	0.358	0.102	0.000	0.000	0.511
E	0.000	0.000	0.051	0.000	0.051	0.153	0.102	0.000	0.000	0.358
ESE	0.000	0.000	0.000	0.000	0.102	0.000	0.000	0.000	0.000	0.102
SE	0.000	0.051	0.051	0.000	0.051	0.000	0.000	0.000	0.000	0.153
SSE	0.000	0.000	0.153	0.051	0.051	0.000	0.000	0.000	0.000	0.255
S	0.000	0.000	0.153	0.051	0.102	0.204	0.000	0.000	0.000	0.511
SSW	0.000	0.051	0.102	0.255	0.102	0.102	0.000	0.000	0.000	0.613
SW	0.000	0.051	0.051	0.153	0.000	0.000	0.000	0.000	0.000	0.255
WSW	0.000	0.051	0.204	0.051	0.051	0.000	0.000	0.000	0.000	0.358
W	0.000	0.000	0.051	0.000	0.000	0.000	0.000	0.000	0.000	0.051
WNW	0.000	0.000	0.102	0.000	0.000	0.000	0.000	0.000	0.000	0.102
NW	0.000	0.000	0.051	0.000	0.000	0.000	0.000	0.000	0.000	0.051
NNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SUBTOTAL	0.000	0.255	1.226	0.766	0.562	1.175	0.766	0.153	0.000	4.903

TOTAL HOURS OF VALID STABILITY OBSERVATIONS	1958
TOTAL HOURS OF STABILITY CLASS G	96
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS G	96
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS	1958
TOTAL HOURS CALM	0

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 89.59 METERS  
 WIND SPEED AND DIRECTION MEASURED AT 90.29 METER LEVEL

MEAN WIND SPEED = 7.24

DATE PRINTED: 2012/11/19

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

**BROWNS FERRY NUCLEAR PLANT**

**2012 METEOROLOGICAL DATA**

**TABLE 9D**

**JOINT FREQUENCY DISTRIBUTION IN PERCENT**

**FOR ELEVATED RELEASES**

**FOURTH QUARTER**

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS A                    (DELTA T<=-1.9 C/100 M)

BROWNS FERRY NUCLEAR PLANT

OCT 1, 2012 - DEC 31, 2012

WIND DIRECTION	WIND SPEED (MPH)										TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5		
N	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ESE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SSE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.095	0.000	0.000	0.095
S	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SSW	0.000	0.000	0.000	0.000	0.000	0.047	0.000	0.000	0.000	0.000	0.047
SW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
W	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SUBTOTAL	0.000	0.000	0.000	0.000	0.000	0.047	0.000	0.095	0.000	0.142	

TOTAL HOURS OF VALID STABILITY OBSERVATIONS	2111
TOTAL HOURS OF STABILITY CLASS A	3
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS A	3
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS	2111
TOTAL HOURS CALM	0

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 89.59 METERS  
 WIND SPEED AND DIRECTION MEASURED AT 90.29 METER LEVEL

MEAN WIND SPEED = 16.60

DATE PRINTED: 2013/02/06

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS B      (-1.9 < DELTA T <=-1.7 C/100 M)

BROWNS FERRY NUCLEAR PLANT

OCT 1, 2012 - DEC 31, 2012

WIND DIRECTION	CALM	WIND SPEED (MPH)									TOTAL
		0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5		
N	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNE	0.000	0.000	0.000	0.000	0.000	0.047	0.047	0.000	0.000	0.000	0.095
NE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ESE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SE	0.000	0.000	0.000	0.000	0.095	0.047	0.000	0.000	0.000	0.000	0.142
SSE	0.000	0.000	0.000	0.047	0.047	0.000	0.047	0.000	0.000	0.000	0.142
S	0.000	0.000	0.000	0.000	0.047	0.047	0.000	0.000	0.000	0.000	0.095
SSW	0.000	0.000	0.000	0.000	0.000	0.047	0.000	0.000	0.000	0.000	0.047
SW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
W	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SUBTOTAL	0.000	0.000	0.000	0.047	0.189	0.189	0.095	0.000	0.000	0.521	

TOTAL HOURS OF VALID STABILITY OBSERVATIONS	2111
TOTAL HOURS OF STABILITY CLASS B	11
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS B	11
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS	2111
TOTAL HOURS CALM	0

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 89.59 METERS  
 WIND SPEED AND DIRECTION MEASURED AT 90.29 METER LEVEL

DATE PRINTED: 2013/02/06

MEAN WIND SPEED = 9.31

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS C      (-1.7 < DELTA T <=-1.5 C/100 M)

**BROWNS FERRY NUCLEAR PLANT**

OCT 1, 2012 - DEC 31, 2012

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)						>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4			
N	0.000	0.000	0.000	0.000	0.000	0.000	0.142	0.000	0.000	0.142	
NNE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ESE	0.000	0.000	0.000	0.000	0.047	0.095	0.000	0.000	0.000	0.000	0.142
SE	0.000	0.000	0.000	0.047	0.189	0.000	0.047	0.000	0.000	0.000	0.284
SSE	0.000	0.000	0.000	0.000	0.095	0.047	0.047	0.000	0.000	0.000	0.189
S	0.000	0.000	0.000	0.142	0.047	0.189	0.000	0.000	0.000	0.000	0.379
SSW	0.000	0.000	0.000	0.047	0.142	0.142	0.000	0.000	0.000	0.000	0.332
SW	0.000	0.000	0.047	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.047
WSW	0.000	0.000	0.000	0.000	0.047	0.000	0.095	0.047	0.000	0.000	0.189
W	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.047	0.142	0.095	0.284	
NW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNW	0.000	0.000	0.000	0.000	0.000	0.047	0.000	0.000	0.000	0.000	0.047
SUBTOTAL	0.000	0.000	0.047	0.237	0.568	0.521	0.379	0.189	0.095	2.037	

TOTAL HOURS OF VALID STABILITY OBSERVATIONS	2111
TOTAL HOURS OF STABILITY CLASS C	43
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS C	43
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS	2111
TOTAL HOURS CALM	0

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 89.59 METERS  
 WIND SPEED AND DIRECTION MEASURED AT 90.29 METER LEVEL

DATE PRINTED: 2013/02/06

MEAN WIND SPEED = 10.91

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS D      (-1.5 < DELTA T <= -0.5 C/100 M)

BROWNS FERRY NUCLEAR PLANT

OCT 1, 2012 - DEC 31, 2012

WIND DIRECTION	CALM	WIND SPEED (MPH)									TOTAL
		0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5		
N	0.000	0.000	0.000	0.237	0.379	1.374	1.516	0.047	0.000	3.553	
NNE	0.000	0.000	0.142	0.237	0.853	1.705	0.474	0.047	0.000	3.458	
NE	0.000	0.000	0.095	0.237	0.284	0.853	0.142	0.000	0.000	1.611	
ENE	0.000	0.000	0.047	0.047	0.000	0.332	0.047	0.000	0.000	0.474	
E	0.000	0.000	0.095	0.095	0.047	0.095	0.000	0.000	0.000	0.332	
ESE	0.000	0.047	0.142	0.426	0.189	0.095	0.095	0.000	0.000	0.995	
SE	0.000	0.000	0.426	0.711	0.379	0.379	0.663	0.142	0.000	2.700	
SSE	0.000	0.000	0.568	0.426	0.379	0.426	0.474	0.284	0.284	2.842	
S	0.000	0.000	0.379	0.189	0.284	1.090	0.805	0.426	0.142	3.316	
SSW	0.000	0.000	0.379	0.189	0.095	0.474	0.332	0.189	0.000	1.658	
SW	0.000	0.000	0.379	0.142	0.047	0.616	0.332	0.142	0.047	1.705	
WSW	0.095	0.189	0.284	0.000	0.332	0.237	0.142	0.047	1.326		
W	0.000	0.047	0.332	0.426	0.189	1.184	0.379	0.189	0.568	3.316	
WNW	0.000	0.000	0.095	0.142	0.237	1.326	0.568	1.374	0.853	4.595	
NW	0.000	0.000	0.095	0.095	0.426	1.042	1.279	0.853	0.095	3.884	
NNW	0.047	0.000	0.047	0.047	0.047	1.611	0.900	0.047	0.000	2.700	
SUBTOTAL	0.000	0.237	3.363	3.932	3.837	12.932	8.243	3.884	2.037	38.465	

TOTAL HOURS OF VALID STABILITY OBSERVATIONS	2111
TOTAL HOURS OF STABILITY CLASS D	812
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS D	812
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS	2111
TOTAL HOURS CALM	0

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 89.59 METERS  
 WIND SPEED AND DIRECTION MEASURED AT 90.29 METER LEVEL

MEAN WIND SPEED = 11.54

DATE PRINTED: 2013/02/06

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS E      (-0.5 < DELTA T <= 1.5 C/100 M)

BROWNS FERRY NUCLEAR PLANT

OCT 1, 2012 - DEC 31, 2012

WIND DIRECTION	CALM	WIND SPEED(MPH)									TOTAL
		0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5		
N	0.000	0.000	0.000	0.047	0.095	0.521	0.805	0.000	0.000	1.468	
NNE	0.000	0.000	0.000	0.000	0.095	1.326	1.326	0.142	0.000	2.890	
NE	0.000	0.000	0.047	0.000	0.142	0.426	0.853	0.095	0.000	1.563	
ENE	0.000	0.000	0.095	0.047	0.142	0.474	0.142	0.095	0.000	0.995	
E	0.000	0.000	0.000	0.189	0.095	0.189	0.237	0.047	0.000	0.758	
ESE	0.000	0.000	0.142	0.095	0.095	0.426	0.142	0.047	0.047	0.995	
SE	0.000	0.000	0.189	0.142	0.474	0.568	0.616	0.426	0.189	2.605	
SSE	0.000	0.000	0.000	0.000	0.332	2.842	1.611	1.090	0.616	6.490	
S	0.000	0.047	0.095	0.142	0.332	2.795	2.321	1.374	0.095	7.200	
SSW	0.000	0.000	0.047	0.000	0.189	0.947	1.042	0.379	0.047	2.653	
SW	0.000	0.000	0.000	0.047	0.142	0.521	0.711	0.142	0.000	1.563	
WSW	0.000	0.000	0.000	0.000	0.095	0.379	0.332	0.000	0.000	0.805	
W	0.000	0.000	0.047	0.047	0.095	0.568	0.237	0.000	0.000	0.995	
WNW	0.000	0.047	0.047	0.047	0.000	0.426	0.426	0.000	0.047	1.042	
NW	0.000	0.000	0.047	0.000	0.047	0.426	0.663	0.095	0.000	1.279	
NNW	0.000	0.000	0.095	0.000	0.095	0.521	0.805	0.142	0.000	1.658	
SUBTOTAL	0.000	0.095	0.853	0.805	2.463	13.359	12.269	4.074	1.042	34.960	

TOTAL HOURS OF VALID STABILITY OBSERVATIONS	2111
TOTAL HOURS OF STABILITY CLASS E	738
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS E	738
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS	2111
TOTAL HOURS CALM	0

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 89.59 METERS  
WIND SPEED AND DIRECTION MEASURED AT 90.29 METER LEVEL

DATE PRINTED: 2013/02/06

MEAN WIND SPEED = 12.90

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS F      ( 1.5 < DELTA T <= 4.0 C/100 M)

BROWNS FERRY NUCLEAR PLANT

OCT 1, 2012 - DEC 31, 2012

WIND DIRECTION	CALM	WIND SPEED (MPH)									TOTAL
		0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5		
N	0.000	0.000	0.000	0.000	0.000	0.142	0.379	0.000	0.000	0.521	
NNE	0.000	0.000	0.000	0.047	0.000	0.284	1.326	0.237	0.000	1.895	
NE	0.000	0.000	0.095	0.000	0.189	0.426	0.332	0.000	0.000	1.042	
ENE	0.000	0.000	0.000	0.095	0.000	0.379	0.189	0.000	0.000	0.663	
E	0.000	0.000	0.000	0.142	0.095	0.142	0.047	0.000	0.000	0.426	
ESE	0.000	0.000	0.047	0.000	0.284	0.189	0.000	0.000	0.000	0.521	
SE	0.000	0.000	0.095	0.189	0.284	0.521	0.095	0.000	0.000	1.184	
SSE	0.000	0.000	0.047	0.237	0.189	1.895	1.137	0.095	0.000	3.600	
S	0.000	0.000	0.000	0.142	0.189	2.463	1.374	0.000	0.000	4.169	
SSW	0.000	0.000	0.095	0.000	0.189	0.521	0.284	0.000	0.000	1.090	
SW	0.000	0.047	0.047	0.047	0.047	0.332	0.189	0.000	0.000	0.711	
WSW	0.000	0.000	0.047	0.000	0.047	0.284	0.000	0.000	0.000	0.379	
W	0.000	0.000	0.000	0.000	0.000	0.047	0.000	0.000	0.000	0.047	
WNW	0.000	0.000	0.095	0.000	0.000	0.095	0.000	0.000	0.000	0.189	
NW	0.000	0.000	0.095	0.095	0.237	0.332	0.000	0.000	0.000	0.758	
NNW	0.000	0.000	0.047	0.000	0.000	0.284	0.095	0.000	0.000	0.426	
SUBTOTAL	0.000	0.047	0.711	0.995	1.753	8.337	5.448	0.332	0.000	17.622	

TOTAL HOURS OF VALID STABILITY OBSERVATIONS	2111
TOTAL HOURS OF STABILITY CLASS F	372
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS F	372
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS	2111
TOTAL HOURS CALM	0

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 89.59 METERS  
 WIND SPEED AND DIRECTION MEASURED AT 90.29 METER LEVEL

MEAN WIND SPEED = 10.67

DATE PRINTED: 2013/02/06

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012 BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS G      (DELTA T > 4.0 C/100 M)

BROWNS FERRY NUCLEAR PLANT

OCT 1, 2012 - DEC 31, 2012

WIND DIRECTION	WIND SPEED (MPH)										TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5		
N	0.000	0.047	0.000	0.000	0.000	0.047	0.000	0.000	0.000	0.095	
NNE	0.000	0.000	0.047	0.000	0.000	0.047	0.000	0.000	0.000	0.095	
NE	0.000	0.000	0.000	0.047	0.000	0.095	0.189	0.000	0.000	0.332	
ENE	0.000	0.000	0.000	0.189	0.095	0.189	0.047	0.000	0.000	0.521	
E	0.000	0.000	0.047	0.095	0.142	0.047	0.000	0.000	0.000	0.332	
ESE	0.000	0.000	0.000	0.000	0.284	0.000	0.000	0.000	0.000	0.284	
SE	0.000	0.000	0.000	0.189	0.189	0.189	0.047	0.000	0.000	0.616	
SSE	0.000	0.000	0.000	0.189	0.237	1.090	0.189	0.000	0.000	1.705	
S	0.000	0.000	0.095	0.142	0.095	0.379	0.142	0.000	0.000	0.853	
SSW	0.000	0.047	0.047	0.047	0.000	0.000	0.047	0.000	0.000	0.189	
SW	0.000	0.047	0.047	0.000	0.000	0.095	0.095	0.000	0.000	0.284	
WSW	0.000	0.000	0.047	0.000	0.047	0.000	0.000	0.000	0.000	0.095	
W	0.000	0.095	0.047	0.000	0.047	0.095	0.000	0.000	0.000	0.284	
WNW	0.000	0.000	0.047	0.047	0.000	0.095	0.000	0.000	0.000	0.189	
NW	0.000	0.000	0.000	0.095	0.047	0.095	0.000	0.000	0.000	0.237	
NNW	0.000	0.000	0.047	0.095	0.000	0.000	0.000	0.000	0.000	0.142	
SUBTOTAL	0.000	0.237	0.474	1.137	1.184	2.463	0.758	0.000	0.000	6.253	

TOTAL HOURS OF VALID STABILITY OBSERVATIONS	2111
TOTAL HOURS OF STABILITY CLASS G	132
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS G	132
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS	2111
TOTAL HOURS CALM	0

METEOROLOGICAL FACILITY: BROWNS FERRY NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 89.59 METERS  
 WIND SPEED AND DIRECTION MEASURED AT 90.29 METER LEVEL

MEAN WIND SPEED = 7.85

DATE PRINTED: 2013/02/06

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

**2012**  
**BROWNS FERRY NUCLEAR PLANT**  
**UNITS 1, 2, AND 3**  
**EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

**ATTACHMENT 1**

**Deviations from ODCM Controls and Surveillance Requirements**

This report is to comply with Browns Ferry Nuclear Plant Offsite Dose Calculation Manual (ODCM). The ODCM requires that all deviations be reported in the Annual Radioactive Effluent Release Report.

During the reporting period, January 1, 2012 through December 31, 2012, there was one missed compensatory sample. On January 3, 2012, a potential non-representative gaseous sample was taken from the Reactor Building Effluent Monitor (2-RM-90-250) during the performance of 0-SI-4.8.B.1.A.2 (Airborne Effluent Release Rate by Manual Sampling When a Gaseous Effluent Monitor is Inoperable). This surveillance requires sampling once every 8 hours and a flow determination once every 4 hours. When the initial sample was obtained, the compensatory sampler showed sufficient flow. After sampling, Chemistry personnel were informed that the valves upstream of the compensatory sampler were closed under a clearance (WO #112244367) to replace the moisture trap. The closed valves were the Reactor Building Exhaust (2-RTV-090-0308A), Turbine Building Exhaust (2-RTV-090-306A), and Refuel Zone Exhaust (2-RTV-090-307A). Since the compensatory sampler had sufficient flow, this indicated the closed valves had potential leak through. (PER 484911)

**2012  
BROWNS FERRY NUCLEAR PLANT  
UNITS 1, 2, AND 3  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT**

**ATTACHMENT 2**

**2012 Inoperable Radiological Effluent Instrumentation Report**

This report is to comply with Browns Ferry Nuclear Plant Offsite Dose Calculation Manual (ODCM) Sections 1/2.1.1 and 1/2.1.2. The ODCM requires the exertion of best efforts to return inoperable instruments to operable status within 30 days. Failure to return such instruments to an operable status within the prescribed interval requires a description in the Annual Radioactive Effluent Release Report.

During the reporting period, January 1, 2012, through December 31, 2012, there were no radioactive gaseous effluent monitoring instruments and no liquid effluent monitoring instruments out of service for greater than 30 days.