

Official Transcript of Proceedings

NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards
ABWR Subcommittee Meeting

Docket Number: (n/a)

Location: Rockville, Maryland

Date: Wednesday, April 24, 2013

Work Order No.: NRC-4164

Pages 1-163

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1323 Rhode Island Avenue, N.W.
Washington, D.C. 20005
(202) 234-4433

1 UNITED STATES OF AMERICA

2 NUCLEAR REGULATORY COMMISSION

3 + + + + +

4 ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

5 (ACRS)

6 + + + + +

7 ADVANCED BOILING WATER REACTOR SUBCOMMITTEE

8 + + + + +

9 WEDNESDAY

10 APRIL 24, 2013

11 + + + + +

12 ROCKVILLE, MARYLAND

13 The Subcommittee met at the Nuclear
14 Regulatory Commission, Two White Flint North, Room
15 T2B1, 11545 Rockville Pike, at 8:30 a.m., Michael
16 Corradini, Chairman, presiding.

17 SUBCOMMITTEE MEMBERS:

18 MICHAEL CORRADINI, Chairman

19 J. SAM ARMIJO, Member

20 DENNIS C. BLEY, Member

21 HAROLD B. RAY, Member

22 MICHAEL T. RYAN, Member

23 STEPHEN P. SCHULTZ, Member

24 WILLIAM J. SHACK, Member

25 JOHN W. STETKAR, Member

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 ACRS CONSULTANTS PRESENT:

2 WILLIAM HINZE

3 NRC STAFF PRESENT:

4 QUYNH NGUYEN, Designated Federal Official

5 HOSUNG AHN, NRO/DSEA/RHMB

6 NILESH CHOKSHI, NRO/DSEA

7 CHRISTOPHER COOK, NRO/DSEA/RHMB

8 TEKIA GOVAN, NRO/DNRL/LB3

9 BRAD HARVEY, NRO/DSEA/RHMB

10 HENRY JONES, NRO/DSEA/RHMB

11 REBECCA KARAS, NRO/DSEA/RGS1

12 FRANKIE VEGA, NRO/DSEA/RGS1

13 GEORGE WUNDER, NRO/DNRL/LB3

14 ALSO PRESENT:

15 RICHARD BENSE, NINA

16 LYLE HIBLER, PNNL

17 PAUL JENSEN, Atkins North America

18 PATRICK LYNETT, University of Southern
19 California

20 SCOTT HEAD, NINA

21 RAJIV PRASAD, PNNL

22
23
24
25
NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

T-A-B-L-E O-F C-O-N-T-E-N-T-S

Welcome and Introduction

by Chair Corradini 4

Responses to Action Items, NINA

by Mr. Scott Head 6

Staff Overview

by Ms. Tekia Govan 17

Review of 2.3, Meteorology

by Mr. Brad Harvey 19

Open and Action Items, Hydrology

by Dr. Henry Jones 32

Non-concurrence Overview

by Ms. Tekia Govan 53

Non-concurrence Presentation

by Dr. Hosung Ahn 56

Non-Concurrence Process Issues 97

Dr. Henry Jones, NRC Dr. Rajiv Prasad, PNNL

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

P R O C E E D I N G S

8:14 a.m.

CHAIR CORRADINI: The meeting will come to order. This is a meeting of the Advanced Boiling Water Reactor or ABWR Subcommittee for the ACRS. My name is Mike Corradini. I'm chairman of the subcommittee. ACRS Members currently in attendance are Bill Shack, Mike Ryan, Sam Armijo and Harold Ray and Dennis Bley, as well as our consultant, Dr. Bill Hinze.

We also have Mr. Quynh Nguyen as our Designated Federal Official for the meeting. As announced in the Federal Register on April 8th, the subject of today's briefing is Chapter 2, Site Characteristics of the COL application submitted by Nuclear Innovation of North America or NINA for the South Texas Project Units 3 and 4 and resolution of some action items from previous briefings on the subject.

Sections 2.1 through 2.4 will be discussed today. The remaining section, 2.5, will be presented at a future meeting, to be determined, we'll get back to you on that. Last time the subcommittee was briefed on Chapter 2 was in November, was on November 30th of 2010. I'm sure

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 you have that firmly entrenched in your minds.

2 MR. HEAD: Yes, sir, we do.

3 CHAIR CORRADINI: The rules for
4 participation in today's meeting were announced in
5 the Federal Register notice for the, for an open or
6 closed meeting, however we expect this meeting will
7 be mostly open to the public. I am asking the NRC
8 staff and the applicant to verify only people with
9 required clearance and a need to know are present if
10 we enter into a closed session of the discussion.

11 We have a telephone bridge line for the
12 public and stakeholders to hear the deliberations.
13 This line will not carry any signal from this end if
14 we need to enter into a closed meeting. Also to
15 minimize disturbances, the line will be kept in the
16 listen in only mode until the end of the meeting
17 where we'll allot a few minutes for allocated or
18 we'll allot a few minutes that have been allocated
19 for public comment.

20 At that time any member of the public
21 attending this meeting in person or through the
22 bridge line can make a statement or provide comments
23 as desired. We'll check on that as we get close to
24 the end line to see if there are any folks on line.

25 As the meeting is transcribed I request

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 that participants in this meeting use the
2 microphones located throughout the room when
3 addressing the subcommittee. Participants should
4 first identify themselves and speak with sufficient
5 clarity and volume so that they can be readily
6 heard.

7 And then, as we do on airplanes, please
8 silence all cell phones, pagers, iPhones, iPads and
9 all appropriate appliances. We'll now proceed with
10 the meeting. And I call upon Mr. George Wunder of
11 NRO to begin the presentation. George.

12 MR. WUNDER: Thank you, Mr. Chairman.
13 We're delighted to be here after kind of a long wait
14 on Chapter 2. But thanks to your most thorough
15 introduction we have nothing to add.

16 CHAIR CORRADINI: So, great, I didn't
17 even have a chance to take off my glasses you were
18 so fast. So we'll turn to NINA. Scott, are you
19 going to lead us off on some, I think responses on
20 action items primarily.

21 MR. HEAD: Yes, sir, well, a couple
22 things. Our agenda for today, we do want to talk
23 about two interesting changes that have taken place
24 since the last time we met. And then we do have an
25 action item Number 65 that we want to close today,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 or excuse me to present to you today and hopefully,
2 and close that action.

3 Attendees, the team that's here, the
4 attendees, you want to go ahead and --

5 MR. BENSE: My name is Dick Bense.

6 MR. HEAD: No, I want you to move to
7 the, Dr. Bob Bailey briefed you on the ADCIRC, our
8 ADCIRC work that we had presented last time and Dr.
9 Paul Jensen had briefed you on the MCR breach work
10 from last time. The topics for discussions, I
11 should say the first topic is, next slide please.

12 Okay, first off as background, I thought
13 we would go ahead and show this slide. We've shown
14 this slide before and it portrays most of what we'll
15 be talking about today. Down at the bottom,
16 obviously, is the Gulf of Mexico with the Barrier
17 Islands.

18 You see the prominent feature to the
19 upper left is the Main Coolant Reservoir which Unit
20 1 and 2 is using right now and obviously Unit 3 and
21 4 will be using once we're licensed. It's a little
22 harder to see, but to the right of the Main Cooling
23 Reservoir is the Colorado River. The Colorado River
24 is what's used to actually fill the Main Cooling
25 Reservoir. I'd say distance from Units 3 and 4 to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 the Barrier Islands is about 15 miles.

2 CHAIR CORRADINI: So from the little
3 white patch, I was going to ask that question, from
4 the little white patch at the top to the Barrier
5 Island is 15 miles?

6 MR. HEAD: Yes, sir. The South Texas
7 and we'll show you another picture in a second with
8 respect to the location of Units 3 and 4 versus 1
9 and 2. Okay. So with respect to a couple of
10 interesting items that have transpired in the
11 intervening time frame. NRC issued Reg Guide 1.221,
12 which concerned design-basis hurricane and hurricane
13 missiles for nuclear power plants in October of
14 2011.

15 You know, based on the nature of the
16 changes, STP 3 and 4 committed to this Reg Guide and
17 that ended up was changing the maximum hurricane
18 wind speeds and more importantly the hurricane
19 generator missile spectrum was changed. We went
20 through an analysis and NRC went through a review
21 and we confirmed that the ABWR DCD buildings and the
22 site specific buildings can withstand these new
23 requirements.

24 You'll see more detail on that hopefully
25 in July, when we brief you on 3738. Okay? The next

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 interesting change is, as a result of Fukushima and
2 the lessons learned we created an Appendix 1E and
3 added it to our COLA to describe our position and
4 what we've done to address the post-Fukushima
5 recommendations.

6 As part of the discussion with the NRC
7 on the cliff edge effect or the physical margin for
8 flooding, we made some decisions regarding a number
9 of doors that allowed us to determine if the cliff
10 edge was really at 51 feet. And that information is
11 included in 1E and the results of that you see down
12 below, it's 11 feet above a design-basis flood, 12.8
13 feet above the maximum flood level from the NRC
14 briefs and 17 feet above nominal site grade.

15 At this point in time this was a paper
16 change regarding, involving some doors and so we
17 thought it was the appropriate thing to do. And
18 you'll see that in 1E when we have that briefing on
19 --

20 MEMBER ARMIJO: Scott, that MCR breach delta is
21 dependent on the size of the breach and how much
22 comes out and all that. We're going to talk about
23 that later today.

24 MR. HEAD: Yes, sir. I'm going to just
25 brief you on a follow-up item related to that and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 then the rest of the briefing will be by NRC. Okay
2 so here's the promised slide. There's 1 and 2 with
3 respect to the MCR breach ~~briefs~~.

4 This lower water you see down at the
5 bottom is the essential cooling pond and that's a
6 below grade feature. Three and 4 we located to the
7 right side back in that area and so the distance
8 between the Main Cooling Reservoir and 3 and 4 is a
9 little bit further, obviously than where 1 and 2 is
10 located right now.

11 That's a picture for perspective. This
12 is to head towards closing this follow-up item that
13 we committed to do. A picture of, another picture
14 you've seen before of the embankment. You'll see
15 this picture a couple more times today I'm sure.
16 The distance from the, from toe to toe is around 300
17 feet.

18 So with respect to the follow-up item we
19 went back and looked and said did we, were we really
20 clear last time with respect to what we were trying
21 to describe? And so with respect to the breach,
22 there's a number of things that go into the
23 calculations because the breach is an intermediate
24 step. The actual goal is the flood elevation at the
25 buildings.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 And so what's needed is a breach
2 location, picking one that's basically oriented
3 towards, you know, the either 3, Unit 3 or Unit 4.
4 The breach width is important, obviously. And the
5 timing with respect to how quick that breach opens
6 because how quick it opens also impacts how fast the
7 Main Cooling Reservoir empties.

8 As you noted in the first picture, the
9 contents of the Main Cooling Reservoir is finite.
10 It's not a lake, it's not a river. It's what's
11 there is all that will be there except for we allow
12 some rain to take place, basically a foot of rain.
13 But that's the starting point.

14 The breach width is based on the
15 Froehlich equation. That's an empirical regression
16 that has a number of features in terms of width and
17 timing. And we use that for the breach width. The
18 breach opening speed was based on MacDonald
19 Langridge equation. That's another equation that
20 has features to it that could be used.

21 And so those two features, the, or three
22 features, the location, the breach width and the
23 breach opening speed, are all placed into FLDWAV,
24 which is, actually calculates the discharge from the
25 MCR. That amount, that quantity is input in RMA-2

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 and that's used ~~the~~ to predict the actual flood
2 levels at the buildings. So this is, by the way
3 this is a new slide. We didn't include that two
4 years ago, so.

5 CHAIR CORRADINI: And just so I'm clear,
6 the upper left box, the only place where it creates
7 an issue is facing north towards the planned Unit 3
8 and 4 locations. A breach anywhere else doesn't --

9 MR. HEAD: Yes, sir, that, we believe
10 this is clearly bounding aimed right at, if anything
11 that, obviously anything that happens outside of
12 that, you know, the plants would be shut down and
13 there would be consequences and everything because
14 we would lose our cooling source. But the safety,
15 we only, we believe that the safety aspects are only
16 for anything that's headed north towards the plants.

17 On the left side you'll see, I was
18 alluding to as part of a confirmatory analysis
19 these, the breach width and the breach timing are
20 all based on empirical regression equations that are
21 developed based on previous dam breaches. The
22 BREACH model is an actual model that used
23 hydrological principles, soil mechanics and other
24 aspects to actually model a breach.

25 And we ran that as a confirmatory

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 analysis to, just like I say, to confirm, you know,
2 the results that we were getting from our, our what
3 we're calling the FLDWAV model.

4 MEMBER ARMIJO: Are these the same
5 models that were used for Units 1 and 2 when you did
6 that or were they different?

7 MR. HEAD: No, sir. Well there has
8 been, I'll say there's been some post-Fukushima work
9 on 1 and 2 that would have used FLDWAV or breach.

10 DR. JENSEN: RMA-2 and the hydrograph
11 from breach.

12 MR. HEAD: All right. But when 1 and 2
13 was licensed they used an instantaneous removal of
14 2,000 feet of the reservoir for their flood, to
15 determine their flood levels.

16 MEMBER ARMIJO: So that was just
17 arbitrary, 2,000 feet? Did you pick it out of the
18 air?

19 MR. HEAD: No, it wasn't arbitrary, at
20 least based on what I've seen. What was done is you
21 find the elevation or the breach width that creates
22 the maximum flood level. If you take away the whole
23 north embankment it goes out and so you, and so
24 there's a level that creates the worst case. And so
25 that's what 1 and 2 did back in the 80's.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER ARMIJO: Okay.

2 MR. HEAD: Okay. This is clearly a
3 different approach. So here's the slide that caused
4 some of the questions that occurred. The FLDWAV is
5 basically the STP model and you see the discharge
6 growing up to a maximum point.

7 And that maximum point is the maximum
8 breach that the Froehlich equation would say the
9 embankment would reach. The time involved to do
10 that is the time that the MacDonald equation would
11 say would occur.

12 CHAIR CORRADINI: So when you say, I
13 read this but just to make sure I got it right. For
14 all intents and purposes FLDWAV is just being driven
15 by the two correlations of size and time speed.

16 MR. HEAD: Yes, sir. That's exactly
17 correct.

18 CHAIR CORRADINI: Okay, thank you.

19 MR. HEAD: The red curve is our
20 confirmatory analysis. That is the BREACH model
21 results and I'm sure we will discuss that some more
22 today. But this is our results with the STP FLDWAV
23 model and the BREACH model. And so we went back
24 again and looked at what, you know, how we had
25 described that and next slide.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 And so here is the open item, which was
2 how does the MCR breach width, derived from the
3 Froehlich's equation used in the FLDWAV model,
4 compare with the value used in the confirmatory
5 breach model?

6 All right. So the FLDWAV model is the STP COLA
7 model and the width is 417 feet. So at that point
8 the width would be 417 feet.

9 The BREACH model, the second one down,
10 the width at the peak flow is 398 feet. Now recall
11 this is a model. So at 398 feet, it continues to
12 grow to 485 feet. But in the intervening six hours,
13 the Main Cooling Reservoir has lowered and therefore
14 at that final width it's no longer peak flow.

15 And so that's why at 398, at six hours
16 is peak flow and yet the final width is 485 feet
17 with breach since there's nothing to, you know, we
18 don't cause it to stop. It just keeps growing until
19 the physics say it stops growing.

20 Now what we've added below is one aspect
21 of the Froehlich equations. There is an equation
22 that Froehlich used that, based on the height of our
23 reservoir and the volume of our reservoir, you put
24 into a calculation and you would get 62,600 CFS
25 using the Froehlich equation.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 And I'm going to show you the results of
2 other aspects of that here in a second. So here
3 again, here is the blue and the red are from the
4 previous slides, is what we've presented before.
5 You see the maximum peak at 417, you see the breach
6 results.

7 But we've added another aspect of the
8 Froehlich equations. If you put information into
9 FLDWAV regarding the breach growth rate and time and
10 width, you'll get the green curve. And so what this
11 shows, we think, is some idea of the conservatism
12 that we have in our analysis right now.

13 CHAIR CORRADINI: So this is kind of
14 like emptying a bucket but the target that you're
15 looking at, the blue line then causes a much larger
16 max flood height than the red line?

17 MR. HEAD: Yes, sir, which is what we
18 were after. You know, and not only, it causes the
19 38.2 feet flood elevation of which then we added
20 about a 25 percent margin out at the plant to come
21 up with ultimately 40 foot flood elevation.

22 CHAIR CORRADINI: Okay.

23 MR. HEAD: So if you'll back up just a
24 couple of slides. The 417 and the 398 and the 485,
25 I think answer or that's what we believed was the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 questions with respect to the follow-up items.

2 CHAIR CORRADINI: Okay, questions from
3 the committee? Okay. Thank you for the follow-up
4 items. I think we'll now turn to staff. So a new
5 team will assemble with new tents. Tekia, are you
6 going to be our leader today?

7 MS. GOVAN: Yes.

8 CHAIR CORRADINI: Okay. So, Ms. Govan,
9 Govan?

10 MS. GOVAN: Govan.

11 CHAIR CORRADINI: Govan. I thought you
12 were French so. The other two suspects look
13 familiar. The person on the left will remain
14 nameless until identified. Clarity and volume in
15 your voice. Tekia, go ahead.

16 MS. GOVAN: Good morning. My name is
17 Tekia Govan. I am the project manager for the
18 review of Chapter 2, entitled Site Characteristics
19 as this chapter is contained in the South Texas
20 Project Units 3 and 4 COL application.

21 Today the staff is here to present the
22 findings of their review for Phase 4, which has
23 resulted in a safety evaluation report with no open
24 items. The staff review team for Chapter 2 consists
25 of George Wunder, lead PM; myself and David

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Misenhimer as chapter PM's; and the technical staff
2 from the Radiation Protection and Accident
3 Consequence branch where Michael McCoppin is branch
4 chief and the Hydrology and Meteorology branch where
5 Christopher Cook is the branch chief.

6 The staff last presented our Chapter 2
7 to the ACRS Subcommittee in 2010 where we discussed
8 our safety evaluation with open items. During that
9 meeting we discussed our findings in the areas of
10 2.1, geography and demography; 2.2, nearby
11 industrial transportation and military facilities;
12 2.3 meteorology; 2.4, hydrology; and 2.5, geology,
13 seismology and geotechnical engineering.

14 We were able to conclude our review and
15 make acceptable findings, acceptable safety findings
16 with no open items in Sections 2.1 and 2.2.
17 However, we left the 2010 ACRS meeting with open
18 items and/or ACRS action items in the areas of 2.3,
19 2.4 and 2.5. Today's presentation will focus on the
20 closure of open items and ACRS action items for
21 Sections 2.3 and 2.4.

22 Section 2.4 is notable in that the staff
23 was required to disposition a non-concurrence of the
24 safety evaluation prior to making the final, the
25 document final. The resolution of the non-

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 concurrence will be discussed in detail during the
2 second portion of this meeting.

3 As stated earlier, 2.5 will be presented
4 to the ACRS Subcommittee at a later date as it is
5 still being reviewed by the staff in connection with
6 a Fukushima recommendation 2.1. At this time I will
7 turn the presentation over to Mr. Brad Harvey, who
8 is our technical reviewer and today's presenter for
9 2.3, meteorology.

10 MR. HARVEY: Again, my name is Brad
11 Harvey. I'm the meteorological reviewer for the
12 South Texas Project, COLA. Since the ACRS
13 Subcommittee meeting on STP COLA last reviewed FSAR
14 Chapter 2.3 during its meeting on November 30, 2010,
15 the staff issued Regulatory Guide 1.221 related to
16 defining design-basis hurricane wind speeds and
17 missiles for sites located along the Gulf and
18 Atlantic coasts.

19 Reg Guide 1.221 defines a design-basis
20 hurricane as having the same 10^{-7} per year exceedance
21 frequency as a design-basis tornado. The staff
22 subsequently issued RAI 02.03.01-24, requesting that
23 the applicant identify design-basis hurricane wind
24 speed and missile spectrum for the STP site.

25 RAI 02.03.01-24, also asked the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 applicant to confirm that the ABWR standard plant
2 and the STP site-specific structure, systems and
3 components important to safety, are designed to
4 protect against the combined effects of hurricane
5 winds and missiles. The applicant's response to RAI
6 02.03.01-24, identified an STP site-specific design-
7 basis hurricane wind speed of 210 miles an hour or
8 three second gust wind speed based on the guidance
9 in Regulatory Guide 1.221.

10 To ensure that the STP Unit's 3 and 4
11 design reflects the guidance in Regulatory Guide
12 1.221, the applicant revised FSAR Tier 2, Table 2.0-
13 2 to include 210 miles an hour as a site-
14 characteristic hurricane wind speed for STP Units 3
15 and 4.

16 MEMBER SHACK: Brad, just, that Reg
17 Guide, those hurricane wind speeds are really, I
18 think based on the NUREG-7005 where you have the
19 probabilistic models now for hurricanes.

20 MR. HARVEY: That's correct.

21 MEMBER SHACK: So we use a probabilistic
22 model to deduce the winds, but we still use a
23 deterministic model to determine surge. Is that
24 where we're at?

25 DR. JONES: Well, we actually were

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 allowed to do probabilistic and also deterministic.

2 Our new ISG and the way we're going forward now
3 with the post-Fukushima. Sure, you could do
4 probabilistic. They've always had the option to do
5 probabilistic surge.

6 MEMBER SHACK: Okay, so I guess that's
7 the answer is that they could do either one.
8 They've chosen, they've done deterministic.

9 DR. JONES: Exactly.

10 CHAIR CORRADINI: Simply because it's
11 easier to do and potentially bounding at the time
12 when they did it?

13 DR. JONES: Exactly, exactly.

14 MEMBER SHACK: Well bounding is the --

15 CHAIR CORRADINI: Bounding in some sense
16 of the word. But back to I guess Bill's question,
17 it can be inconsistent based on the choice of how
18 they want to choose each of the --

19 DR. JONES: Well one thing we have to
20 remember too, what will bring your maximum winds at
21 a site is different than would bring your maximum
22 surge, two different phenomena. So you can have a
23 plant in the middle of a valley and the hurricane
24 that would bring your surge there might have light
25 winds because it's coming from a certain direction.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 So you have to keep that in mind. They're two
2 different, you know --

3 MEMBER SHACK: But you do have a
4 probabilistic models for the hurricanes that you
5 could --

6 DR. JONES: Yes, and we have them also
7 for whenever you want to do surge.

8 CHAIR CORRADINI: Okay, thank you.

9 MR. HARVEY: The staff confirmed that
10 the applicant's 202 mile-an-hour site-specific
11 design-basis hurricane wind speed derived from
12 Regulatory Guide 1.221 is correct. Therefore, the
13 staff considers RAI 02.03.01-24 to be resolved and
14 closed with regards to Chapter 2.

15 The staff is also confirming as part of
16 its review of FSAR Chapter 3, that the ABWR standard
17 plant and STP site-specific SSCs important to safety
18 are designed to be protected against hurricane winds
19 and missiles. The staff --

20 MEMBER SHACK: Again, is this the
21 limiting wind speed for the site, is it the
22 hurricane wind speed rather than the tornado?

23 MR. HARVEY: For site characteristics,
24 that's correct. I believe 200 miles an hour was the
25 tornado site characteristic value and 210 is the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 hurricane. At the 10^{-7} for your probability level.
2 The staff will report its conclusion on the issue
3 regarding protection against hurricane winds and
4 missiles in a subsequent ACRS meeting on Chapter 3.

5 I will now address ACRS Action Items 91
6 and 92, both of which concern how portions of the
7 FSAR and SER address global climate change. I will
8 start with a response to Action Item 92, which
9 concerns a generic issue of using global climate
10 change projections to evaluate the impact of natural
11 phenomenon at a site. This will be followed by a
12 response to Action Item 91, which concerns an
13 apparent inconsistency in the treatment of climate
14 change effects and characterizing the STP site.

15 In Action Item 92, the ACRS asked what
16 criteria will be used to initiate the use of global
17 climate change predictions in revising analysis of
18 the impact of natural phenomenon on the STP site?
19 The staff does not currently have a formal mechanism
20 in place for initiating the use of global climate
21 change predictions and analyzing the impact of
22 changing natural phenomenon at a COL site.

23 In developing the climatological
24 characteristics of the STP site, the staff relied on
25 General Design Criteria 2 to Appendix A to 10 CFR

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Part 50, which states structure, systems and
2 components important to safety shall be designed to
3 withstand the effects of natural phenomenon such as
4 earthquakes, tsunamis, hurricanes, floods, tornadoes
5 and seiches without loss of capacity to perform
6 their safety functions.

7 The design-basis for these SSCs shall
8 reflect in part appropriate consideration of the
9 most severe of the natural phenomenon that have been
10 historically reported for the site and surrounding
11 area with sufficient margin for the limited
12 accuracy, quantity and period of time in which the
13 historic data have been accumulated.

14 DR. HINZE: Will these be gradients that
15 you will be looking at or absolute values or
16 percentages? How do you see this developing?

17 MR. HARVEY: Well basically we've been
18 using, for instance tornadoes and hurricanes the
19 design-basis for them are 10^{-7} per year in terms of,
20 based on historic --

21 DR. HINZE: Right but in terms of the
22 change from climate change, would these be based
23 upon absolute values then?

24 MR. HARVEY: Well we haven't really --

25 DR. HINZE: Have a position on that?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. HARVEY: We don't have our position
2 yet on that.

3 DR. HINZE: I see, okay.

4 MEMBER ARMIJO: The models on these
5 climate change are simply that, models. And the
6 data don't support the models. Temperatures aren't
7 rising.

8 CHAIR CORRADINI: I'm going to limit
9 this discussion just so --

10 MEMBER ARMIJO: I just want to make sure
11 that we don't, we go at least somewhere on the
12 record there's some question about whether there's
13 any value in trying to incorporate unproven models
14 and hypotheses.

15 MR. HARVEY: Further on in my
16 presentation, I think I touched on that.

17 CHAIR CORRADINI: Keep on going.

18 MR. HARVEY: Okay. Although GDC-2
19 emphasizes the use of historic data to define the
20 design-basis, the staff acknowledges in SER Section
21 2.3S.1.4.7, on climate change, long-term climate
22 change resulting from human or natural causes may
23 introduce changes into the most severe natural
24 phenomenon reported for the site.

25 However, no conclusive evidence or

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 consensus of opinion is available on the speed or
2 nature of such changes. There is a level of
3 uncertainty in projecting future conditions because,
4 among other reasons, the assumptions regarding a
5 future level of emissions of heat trapping gases,
6 depends on projections of population, economic
7 activity and choice of energy technologies.

8 Further uncertainty is introduced in
9 attempting to downscale average global climate
10 change predictions to regional predictions of
11 changes and extreme meteorological conditions. If
12 it becomes evident that long-term climate change is
13 influencing the most severe natural phenomenon
14 reported at a site, the COL holders have a
15 continuing obligation to ensure that their plants
16 continue to operate safely. 10 CFR Part 50,
17 Appendix B, Criteria 16, entitled Corrective
18 Actions, requires licensees to promptly identify and
19 correct conditions adverse to quality.

20 Operation of the plant outside the FSAR
21 specifications constitutes a non-conforming
22 condition and a condition adverse to quality. This
23 means licensees should be identifying when ambient
24 conditions such as extreme temperatures are outside
25 design specifications and evaluate this adverse

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 condition in a timely manner.

2 The NRC inspection program includes a
3 procedure to verify a licensee's design features and
4 the implementation of procedures to protect
5 mitigating systems from adverse weather effects.
6 This procedure has been used in the past to identify
7 situations when ambient temperatures were outside
8 the FSAR specified design-basis conditions.

9 The NRC's Near-Term Task Force review of
10 insights from the Fukushima accident, recommended
11 that the staff initiate rulemaking to require
12 licensees to confirm seismic and flooding hazards
13 every 10 years, address any new and significant
14 information and if necessary update the design-basis
15 for SSCs important to safety to protect against the
16 updated hazards. This Near-Term Task Force
17 recommendation identified as recommendation 2.2, is
18 classified as a Tier 3 activity.

19 The staff intends to include other
20 natural, man-related hazards such as meteorological
21 phenomenon within the scope of this rulemaking.
22 This potential rulemaking provides an opportunity to
23 address concerns related to climate change.

24 For example, this potential new rule may
25 cause licensees and the staff to periodically review

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 recent trends and extreme meteorological conditions
2 and the latest information on global and regional
3 climate change predictions and analyzing the impact
4 of changing natural phenomenon at all plant sites.
5 Any questions regarding our response to Action Item
6 92?

7 MEMBER SCHULTZ: Well, Brad, just your
8 use of a conditional phrase. It may cause the staff
9 and licensees, that is if it is implemented is what
10 you're saying?

11 MR. HARVEY: I expect, yes.

12 MEMBER SCHULTZ: If it's implemented
13 every 10 years, it will be done.

14 MR. HARVEY: Yes, well we, the rule has
15 not, the confines of the rule have not been obvious.

16 MEMBER SCHULTZ: So that's why you
17 phrased it that way?

18 MR. HARVEY: That's correct.

19 MEMBER SCHULTZ: Thank you.

20 MR. HARVEY: Action Item 91. In Action
21 Item 91, ACRS stated that there is an inconsistency
22 in the treatment of climate change effects for
23 natural phenomenon and characterizing the STP site.
24 In particular the FSAR and SER both addressed the
25 impact of sea level rise from global climate change

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 in the next century on the potential maximum
2 tsunami.

3 But neither the FSAR or SER mentioned a
4 potential increase in wind and rain accompanying
5 future hurricanes. The FSAR and SER projections for
6 sea level rise during the next 100 years are based
7 on trends derived from historic data and do not take
8 into consideration potential increases derived from
9 projections of future changes and global or local
10 climate change.

11 This is the same approach used to
12 evaluate wind and rain accompanying future
13 hurricanes. With respect to addressing sea level
14 rise from global climate change, the applicant
15 evaluated a maximum flood level for the probable
16 maximum tsunami at the STP site assuming a long-term
17 sea level rise of 1.43 feet during the next 100
18 years as provided by NOAA's Center for Operational
19 Oceanographic Products and Services.

20 This long-term sea level rise projection
21 is based on tide gauge measurements made at nearby
22 Freeport, Texas, during the 53 year period, 1954 to
23 2006. However, future changes in sea level
24 experienced at any particular location along the
25 coast depend not only on the increase in the global

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 average sea level, but also on changes in regional
2 currents and winds, proximity to mass and melting
3 ice sheets, vertical motions of the land to
4 geological forces.

5 The long-term sea level rise projection
6 used by the applicant to identify the potential
7 maximum tsunami, is based on historic measurements
8 and does not consider future predictions and sea
9 level rise from such items as expansion of the ocean
10 volume due to warming and the melting of glaciers
11 and ice sheets.

12 Regarding the potential increase in wind
13 and rain accompanying future hurricanes, SER Section
14 2.3S.1 references the U.S. Global Change Research
15 Program as a source of information regarding the
16 impacts of climate change on the United States,
17 including the force and frequency of Atlantic
18 hurricanes. The USGCRP reports that the force and
19 frequency of Atlantic hurricanes have increased
20 substantially in recent decades, but the number of
21 North American main line hurricanes reaching land
22 does not appear to have increased in the past
23 century.

24 The USGCRP reports that likely changes
25 in the future for the United States in surrounding

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 coastal waters will include more intense hurricanes
2 with related increases in wind and rain, but not
3 necessarily an increase in the number of storms that
4 make landfall.

5 The applicant states in FSAR Section
6 2.3S.1, that the currents of all tropical cyclones
7 within a 100 nautical mile radius of the STP site
8 have been somewhat cyclical during the available
9 period of record, which is 1851 through 2006 with a
10 peak occurring in the 1940's and a secondary peak in
11 the 1880's. Therefore, quantifying potential
12 increases in wind and rain accompanying future
13 hurricanes is uncertain at best.

14 In conclusion, projected sea level rise
15 during the next 100 years is based on trends derived
16 from historic data and does not take into
17 consideration potential increases derived from
18 projections of future changes in the global or local
19 climate. This is the same approach used to evaluate
20 wind and rain accompanying future hurricanes. Any
21 questions regarding our response to Action Item 91?

22 CHAIR CORRADINI: Committee, no. Go
23 ahead.

24 MR. HARVEY: This last slide of my
25 presentation summarizes the conclusions and status

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 of SER Section 2.3. First the FSAR meets the
2 regulatory requirements to address regional and
3 local climatic information and presents appropriate
4 information on the atmospheric dispersion
5 characteristics of the site.

6 Second, all COL items were adequately
7 addressed by the applicant. And third, there are no
8 open or confirmatory items. This concludes my
9 presentation.

10 CHAIR CORRADINI: Thank you. Dr. Jones
11 is next.

12 DR. JONES: I'm Dr. Henry Jones. I'm
13 the lead hydrologist for the South Texas project.
14 And the reviewers that actually participated are Dr.
15 Nebiyu Tiruneh and Dr. Hosung Ahn.

16 I'm going to address first the open
17 items and then after that followed by the action
18 items. Open Item 02.04.4-1, this was about the Main
19 Cooling Reservoir, embankment, breach, flood
20 analysis which was briefed by the applicant earlier.

21 And it was, needed to be updated by describing the
22 process in selecting the plausible breach widths and
23 the breach time.

24 The applicant did provide the response
25 and satisfied our requirements. They described the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 use of a Dam Safety Officer, the characterization of
2 the breach, applied the BREACH model as you saw
3 earlier this morning and compared the results to
4 historical database of dam failures.

5 And based on independent confirmatory
6 analysis by the staff, we have determined that the
7 applicant's estimated breach flood discharge is
8 reasonable and conservative and the staff closed
9 this open item based on confirmatory analysis. Any
10 questions on this open item?

11 Open Item 2.4.5-1, and this has to do
12 with the storm surge which they also briefed
13 earlier. The applicant has not shown, we said that
14 they did not show that the model results accounted
15 for a conservative, plausible, probable maximum
16 hurricane scenario. And we wanted them to describe
17 in more detail how they used their model in the
18 FSAR.

19 And in response they provided additional
20 information. Through their response we actually had
21 a second audit out there where they actually
22 presented their findings. And in RAI 2.4.5-11, they
23 fully described how they used the ADCIRC model, how
24 they set it up. They actually, based on our
25 recommendation, used the probable maximum hurricane

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 scenarios that was used in the SLOSH model.

2 We wanted it to be almost similar so
3 there wouldn't be any questions about there was a
4 difference in the input and the meteorological
5 parameters. They did sensitivity runs for the storm
6 parameters using the five, you know, radius, forward
7 speed, track direction, landfall, location of the
8 storm.

9 We determined that the applicant had
10 selected the conservative scenarios and this was
11 based on the scenarios that we had used ourselves in
12 the SLOSH model and that their estimate for the PS,
13 the probable maximum at the site was conservative.
14 We determined that they had selected the appropriate
15 model, ADCIRC is the state of the art model used by
16 civil engineering firms across the United States
17 also for Katrina and the Corp of Engineers. And the
18 staff concluded that the applicant's ADCIRC
19 simulations for determining the surge at the site
20 were adequate. And we closed this open item. Any
21 questions on this one?

22 Next Open Item 2.4.10-1, this is for
23 flood protection. The applicant, we said the
24 applicant didn't provide an analysis to show whether
25 or not a hurricane storm surge could erode the toe

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 of the Main Cooling Reservoir. And we also will
2 touch on this this afternoon in MCP NCP brief too.
3 A lot of this is overlapping.

4 The action, the applicant provided the
5 staff, reviewed the responses. They described the
6 use of the ADCIRC model. And essentially what
7 happened is that due to the high resolution of the
8 ADCIRC model it was able to see the levees and the
9 rock piles there which the SLOSH or the model used
10 by Resio which was ADCIRC, it didn't have the same
11 resolution. So what happened is you wind up with a
12 level of about 29 feet, which is equal to the grade
13 level for the MCR.

14 And we determined that this would not
15 lead to a breach because it was at the same level as
16 the base of the MCR. It wouldn't be there only
17 about 80 minutes and wouldn't have the velocities.
18 Your winds are coming directly out of the south
19 throughout which actually pushes the waves and
20 current away from the northern embankment.

21 So you have no erosional forces through
22 the wave action or currents on the north face
23 whatsoever. It's just physically implausible that
24 you could do it under this scenario. So the staff
25 determined that the applicant's design and flood

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 characteristics and measures were acceptable and we
2 closed this item.

3 MEMBER SHACK: Just to go back on the
4 ADCIRC model, there was a frictional term added to
5 that right that describes the, as you're rolling
6 along the friction?

7 DR. JONES: You might have mixed it,
8 tsunami we had this kind of, when we get to our
9 tsunami we had an issue about --

10 MEMBER SHACK: That's in tsunami?

11 DR. JONES: -- frictional, that's
12 tsunami I think you're talking about. We do have
13 frictional terms in there, realistic ones. But
14 that's you know the modeling of it, that's a whole
15 different scenario. But we didn't add anything.
16 The model has realistic frictional terms to it.

17 MEMBER SHACK: But what is the realistic
18 frictional term that was used?

19 DR. JONES: No, it was Manning's
20 throughout, you know, the model you have for
21 bathymetry, you have it for over the bottom, you
22 have the topography when it comes in. I think
23 you're thinking of the tsunami action item which is
24 coming up later.

25 MEMBER SHACK: Okay, yes I --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 CHAIR CORRADINI: There was a discussion
2 about the --

3 DR. JONES: Yes, there was a discussion
4 about that where specific Manning's frictional
5 coefficients were used.

6 MEMBER SHACK: Okay, but do you have to
7 use the same frictional coefficients in the, for the
8 surge?

9 DR. JONES: Not necessarily. And the
10 model is different, it's totally different. ADCIRC,
11 you could have frictional coefficients, realistic
12 over the wide range of the whole area. Then you
13 could have different Manning's coefficients on land.

14 And we have Patrick Lynett here who did the tsunami
15 modeling.

16 He could explain to you how he used it
17 for tsunami is different in his modeling because he
18 could do a 1D. This is a 2D, 3D model ADCIRC. 1D
19 model you can specify one coefficient and send it in
20 and then specify another one and then send it in
21 because you're only in one dimension. Then you
22 could span to two dimensional which you'll see in
23 tsunami.

24 With ADCIRC multiple coefficients
25 depending on what the topography is. So you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 wouldn't have one. You would have it based on --

2 CHAIR CORRADINI: Whether there's trees
3 or rocks --

4 DR. JONES: -- trees or rocks or coral
5 reefs or buildings.

6 MEMBER SHACK: I guess I was --

7 DR. JONES: You're thinking of the
8 tsunami. I guarantee you were thinking of the
9 tsunami scenario.

10 MEMBER SHACK: But I still need a
11 friction, I still have a frictional term to describe
12 the roll up over the, to the site in the ADCIRC
13 model --

14 DR. JONES: Terms, there's multiple,
15 there's multiple terms.

16 MR. HEAD: Is it assuming that it's
17 grass? Is it scrub?

18 DR. JONES: It's based on what it
19 actually is. You actually can tune it to what is
20 actually there. There actually are coefficients.

21 CHAIR CORRADINI: I think all Bill is
22 asking is when they did the tuning, what did they
23 assume the terrain was relative --

24 DR. JONES: There's actually brush and
25 scrub there.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER SHACK: Okay and so it has to
2 remain brush and scrub for the model to remain valid
3 I guess is --

4 DR. JONES: We were trying to be as
5 realistic as possible.

6 MEMBER BLEY: He only means in 15 years.

7 DR. JONES: Well in 15 years it still
8 wouldn't change. It wouldn't change.

9 MEMBER SHACK: Did you do a sensitivity
10 run with no friction?

11 DR. JONES: That's in tsunami situation.

12 MEMBER SHACK: You don't do that in --

13 DR. JONES: We did that with the
14 tsunami.

15 MEMBER SHACK: We don't do that with
16 surge?

17 MEMBER ARMIJO: Are surge and tsunamis
18 two different things? And that's why I think one
19 surge is just a flooding, a sea level rise. Tsunami
20 is a wave and --

21 DR. JONES: It's a wind wave. You have
22 extra water being pushed to shore. Very slow
23 acting, that's why you see reporters there on the
24 shore. They can sit there with their thumbs up,
25 rising slowly. Whereas a tsunami you wouldn't have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 a reporter there. He would be gone. It's a totally
2 different phenomenon. You do it in 2D not 1D.

3 It's just like you're, you do it in 2D
4 with different coefficients are put in. You don't
5 do sensitivity analysis of frictional coefficients,
6 I mean you can. They've done studies of that.

7 MEMBER BLEY: I think the question is
8 not what do you do, but it's do you have any way to
9 look at the impact --

10 DR. JONES: Well sure. In the core.

11 MEMBER BLEY: -- of changes in the
12 future and do you do any sensitivity studies to try
13 to bound that now before the plant is there?

14 DR. JONES: We saw no changes in our
15 analysis.

16 MEMBER BLEY: You did sensitivity
17 studies for different --

18 DR. JONES: Not for the frictional
19 coefficients because there was no changes seen there
20 except for the topographic features whether you have
21 maybe, like in this case a levee there or rock or
22 buildings.

23 MEMBER SHACK: Okay, so you're arguing
24 based on experience that if you did the sensitivity
25 studies you wouldn't have seen much because

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 everything is so slow and the frictional terms are
2 relatively less important.

3 DR. JONES: Exactly.

4 MEMBER BLEY: Okay.

5 CHAIR CORRADINI: Keep on going.

6 DR. JONES: Okay, Open Item 2.4.12-1,
7 the applicant needed to clarify the potential for
8 groundwater mounding in the Lower Shallow Aquifer
9 and for a west-southwest directed pathway. We
10 issued a few RAIs to address this issue above.

11 The applicant provided responses to
12 these RAIs, including a revised groundwater modeling
13 document. The staff reviewed the responses. We
14 also performed an independent confirmatory analysis
15 and the staff review included the evaluation of an
16 improved alternative groundwater model, particle
17 tracking showing all the pathways are to east or to
18 the south east. And sensitivity cases involving
19 ranges of post-construction infiltration rates and
20 excavation backfill conductivity values.

21 And the staff concluded that these
22 alternative pathways were plausible and acceptable.

23 And we closed this open item.

24 CHAIR CORRADINI: I was trying to
25 understand, sorry to sound that I don't understand,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 but I don't understand the open item. In other
2 words, you're looking at where the groundwater is
3 and how that would impact whatever comes above it
4 and how it filters through?

5 DR. JONES: Well when you have the
6 construction, and I'm not a groundwater specialist,
7 but you have the construction, you have the pre-
8 construction, you have the fill in there. And it
9 changes the direction of where the water flow is
10 going to be. And a lot of times we send RAIs out,
11 say well look at what you're going to have after you
12 build the plant. How does it change your
13 groundwater path flow?

14 CHAIR CORRADINI: But the impact is on
15 off-site transport for radionuclides.

16 DR. JONES: Yes, that's a fill in. It
17 actually goes over into Section 13, Subsection 13.

18 CHAIR CORRADINI: I think we've, I don't
19 think we have any more questions on that.

20 (Off microphone comment)

21 DR. JONES: All right. This is for the
22 maximum groundwater level. This is also a carryover
23 the ~~MCP~~ NCP that you will see later on. The
24 applicant provided a response. We asked them to
25 clarify their basis for determining the maximum

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 groundwater level. They provided a response. We
2 reviewed the response and provided independent
3 confirmatory analysis.

4 And then we reviewed the field
5 observations 34-year record, the site characteristic
6 data. We did some modeling, post-construction
7 groundwater levels. We did a combination of field
8 observation and modeling results. And we did
9 confirmation of the groundwater depression at
10 existing STP Units 1 and 2.

11 And the staff found that the site
12 characteristics of maximum groundwater level of 28
13 feet above mean sea level is technically defensible
14 and acceptable. And that was our conclusion, that
15 was the maximum groundwater, 28 feet. And then we
16 closed it. Any questions?

17 In summary, the staff reviewed various
18 flooding mechanisms including rain, hurricanes,
19 tsunamis, surge, dam breach, et cetera to determine
20 the site-specific design, flood basic
21 characteristics and the required flood protection.
22 The applicant identified the flood caused by the
23 breach of the Main Cooling Reservoir embankment as
24 the design-basis flood.

25 The staff also reviewed the groundwater

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 area to identify characteristics of maximum
2 groundwater level and accidental release of
3 radioactive liquid effluents. The staff identified
4 four open items which we have discussed and they are
5 all closed.

6 Open Item 2.4.4-2 was made obsolete due
7 to the applicant's modification of the analytical
8 tools used to estimate erosion and deposition in the
9 area of the safety related facilities. There are no
10 confirmatory items. Any questions?

11 MALE PARTICIPANT: Why did you say there
12 were four in the slides, there's five?

13 DR. JONES: Didn't I say five, okay,
14 five, yes. Sorry about that. Any questions on
15 that? Okay, now I proceed to the action items.
16 Action Item 93, ACRS requests information on the
17 probable maximum tsunami site impact if the
18 roughness coefficient, and this is what you were
19 speaking to, coefficient is modified significantly.
20 For example, destruction of vegetation by fire.

21 No vegetation scenario modeled in 1D and
22 2D using rough, so seriously what it is, is there is
23 low friction, there's never, you never have zero
24 friction. And the low friction is like having a
25 parking lot paved over, okay. And then what you do

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 is you have moderate friction. Then you have what's
2 realistic friction for the site.

3 And then the real values you think are
4 going to be there. What you do is you do 1D
5 analysis, which is extremely conservative because,
6 you know, the world is 2D, 3D. And so you do that
7 and you do it for the three scenarios of friction.
8 And then you do a 2D run for the three scenarios of
9 the friction.

10 And what he came up with in the 1D case,
11 you know, when you have low, yes, it might reach the
12 site. But once you go to a 2D, no matter what
13 friction you use, it never reaches the site. No
14 matter what friction, low, medium, high. It doesn't
15 reach the site because of the spread and it's, you
16 know, 13 miles inland. It just doesn't reach the
17 site.

18 And so in the 1D cases once you add some
19 friction to it, it doesn't reach the site. So 1D
20 cases did not include lateral dissipation or radial
21 spreading because it's one dimensional. And we
22 assumed that the bottom with no friction, no bottom
23 loss when it was coming in and a time ~~scale~~ **scale**
24 extremely conservative.

25 If you had actually a submarine

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 landslide it would start to slide and it would be a
2 certain time that it would slide. We assumed in the
3 model, instantaneous. That's not going to happen,
4 instantaneous or a hot start. And so we got them
5 and we took the maximum submarine landslide
6 dimensions that you could.

7 Next, so what we did then is we modeled
8 it and we came to the conclusion that it was safe
9 from tsunami. Any questions on that? I mean it's
10 extremely, we've done the most conservative of any
11 group I've seen in the literature. I mean 1D with
12 low friction with the most massive submarine
13 landslide you can picture. You can't get any more
14 conservative than it.

15 MEMBER SHACK: Okay, my recollection is
16 simply that, is that even with the 2D model you had
17 to have some friction. If you put zero friction in
18 --

19 DR. JONES: There was no zero, low
20 friction.

21 MEMBER SHACK: Yes, low, well the
22 comparison is with the Levy site where in fact you
23 did the 2D model with low friction.

24 DR. JONES: We did the same thing.

25 MEMBER SHACK: You did zero friction,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 low friction.

2 DR. JONES: Pat, if you can address
3 that. MEMBER SHACK: At least I think my
4 memory is correct.

5 DR. LYNETT: When you do --

6 CHAIR CORRADINI: Please identify
7 yourself.

8 DR. LYNETT: Patrick Lynett, University
9 of Southern California. I've been working with
10 Henry in the NRC to do some of the tsunami analysis.

11 When you have onshore flow you have to have some
12 type of friction. So usually a very small value
13 like we use here for the low friction. It doesn't
14 do that much. But you have to include some measure
15 of physical friction.

16 CHAIR CORRADINI: What you have to have
17 is a no slip boundary if that's what you're really
18 saying. With some frictional just computed.

19 DR. LYNETT: Well so what happens, the
20 reason you have to include something small, so if
21 you have very mild slips like we have in a lot of
22 these places, if you have no friction at all the
23 water will just keep going and going and going and
24 going and going, pretty much forever because there's
25 nothing to dissipate it. So you have to include

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 some measure of small friction in the analysis.

2 CHAIR CORRADINI: So back to Dr. Jones'
3 analogies, so the friction you chose was a parking
4 lot friction?

5 DR. JONES: Yes. So imagine everything
6 paved over by concrete.

7 MEMBER SCHULTZ: And your phrase, excuse
8 me, the phrase it doesn't do much means there was no
9 difference in the site impact or little difference
10 in the site impact.

11 DR. LYNETT: Between which and which?

12 MEMBER SCHULTZ: Well you had said low
13 friction versus the brush case, I guess.

14 DR. LYNETT: Okay, so if we look at
15 these three different scenarios, low friction which
16 is parking lot, mid friction which is grass and high
17 friction which is brush, there is a moderate
18 difference between the low friction and the mid
19 friction. And there is a very significant
20 difference between the mid friction and the high
21 friction, which the high friction is the realistic
22 friction.

23 CHAIR CORRADINI: Keep on going. Thank
24 you.

25 DR. JONES: Action Item 94, the ACRS

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 requests information of what arrangements have been
2 made for replenishing the ultimate heat sink water.

3 There is a separate ultimate heat sink for each
4 Unit 3 and 4 that is configured with a dedicated
5 water basin and it is sized to provide cooling water
6 for 30 days.

7 On site wells provide the makeup water
8 for these basins. The Main Cooling Reservoir is the
9 secondary source of the makeup water. And as it was
10 mentioned earlier today is the Colorado River is the
11 makeup water for the MCR. So the surface and
12 groundwater sources are not safety related because
13 the basins have their own capacity 30 days supply.
14 The 30 day supply is provided by groundwater backup
15 of the MCR, which has a backup of the Colorado
16 River.

17 Action Item 95, ACRS requests
18 information on the impact of removing groundwater,
19 this is related to the previous item, to replenish
20 the ultimate heat sink. And so what we have here is
21 we're saying groundwater is used for potable and
22 sanitary supply, production of the mineralized
23 water, fire protection and makeup water for the
24 ultimate heat sink. The annual usage they haven't
25 exceeded the, for 1 and 2, and 3 and 4 would not

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 exceed this limit.

2 The STP permit has not been fully used
3 to date. And the production wells for existing
4 plants have caused a reversal somewhat of the flow
5 pattern. But the radial inflow of the wells and
6 surrounding aquifer were nothing that has a safety
7 impact. Any questions on that?

8 The estimated land-surface subsidence,
9 as you will see this again maybe in the MCP NCP
10 discussion, the estimated land-surface subsidence
11 since 1900 over the most of the county has been less
12 than one foot. Okay so from 1900 to now, less than
13 one foot. Where you do have subsident exceedance of
14 one foot is in the northwest portion of Matagorda
15 County.

16 And it's attributed to the exploration
17 of petroleum and sulfur mining. So you know,
18 there's no safety impact of subsidence at the site.

19 In addition, they have a groundwater monitoring
20 programs for 3 and 4 based on what they have at 1
21 and 2. And this will include subsidence monitoring
22 to ensure structural stability. So there's no
23 safety issue here.

24 MEMBER ARMIJO: I don't remember what
25 these basins, how they were constructed. Are they

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 the same kind of structures as the Main Cooling
2 Reservoir?

3 DR. JONES: No.

4 MEMBER ARMIJO: So what are they?

5 DR. JONES: I think they're just your
6 typical reservoir basins.

7 CHAIR CORRADINI: The applicant can
8 answer.

9 MR. HEAD: Scott Head. They're a huge
10 concrete tank, basically with cooling towers on the
11 top that contain the 30 days of supply.

12 MEMBER ARMIJO: Thank you.

13 DR. HINZE: The makeup water from the
14 subsurface is from the deep aquifer?

15 DR. JONES: From the wells?

16 DR. HINZE: Yes, which aquifer is it
17 from? Is it the deep?

18 CHAIR CORRADINI: Back to the applicant.

19 MR. HEAD: Yes, this is Scott Head
20 again. It's the deep aquifer.

21 DR. HINZE: Thank you.

22 CHAIR CORRADINI: Any other questions
23 from the committee? Okay. So we'll let part of you
24 go and we'll continue because we're going to start
25 our non-concurrence discussion. Tekia, you're going

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 to present something to us to get us properly
2 oriented. Is that correct?

3 MS. GOVAN: Right. Before we close out
4 Chapter 2, I didn't hear any ACRS action items so we
5 are to assume --

6 CHAIR CORRADINI: No, you're right. You
7 didn't hear any.

8 MS. GOVAN: -- action items that we
9 presented are closed.

10 CHAIR CORRADINI: Yes.

11 MS. GOVAN: Okay, perfect. So we'll
12 transition to the non-concurrence. Mr. or Dr. Ahn.

13 CHAIR CORRADINI: Yes, Dr. Ahn is going
14 to join us. But you have something you want to tell
15 us ahead of time, right?

16 MS. GOVAN: Yes, I do, yes.

17 CHAIR CORRADINI: Okay.

18 (Off the record comments)

19 MS. GOVAN: Okay, good morning again.
20 I'm Tekia Govan, Chapter 2 PM for the South Texas
21 Units 3 and 4 COL application. As stated in my
22 remarks earlier, Section 2.4 of this review is
23 notable in that the staff was required to
24 disposition a non-concurrence for the safety
25 evaluation prior to making the document final.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 I would like to give a brief overview of
2 the non-concurrence process prior to the presenters
3 presenting their findings for the non-concurrence.
4 The US Nuclear Regulatory Commission strives to
5 establish and maintain an environment that
6 encourages all employees and NRC contractors to
7 promptly raise concerns and differing views without
8 fear of reprisal.

9 Individuals are expected to promptly
10 raise concerns and discuss their views with their
11 immediate supervisors on a regular and ongoing
12 basis. If informal discussions do not resolve
13 concerns, individuals have various mechanisms for
14 expressing and having their concerns and differing
15 views heard and considered by management.

16 The non-concurrence process allows
17 employees to document their differing views and
18 concerns early in the decision making process, have
19 them responded to and attach them to documents
20 moving through a management approval chain. On June
21 8, 2011, Dr. Hosung Ahn submitted to his supervisor
22 Section A of the non-concurrence form stating three
23 issues with Chapter 2.4 entitled Hydrological
24 Engineering contained in the proposed South Texas
25 Project Units 3 and 4 safety evaluation report.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 The first issue was the Main Cooling
2 Reservoir breach flood analysis in SER Section
3 2.4.4. The second issue was flood analysis of
4 hurricane and MCR breach combination, in SER 2.4.5.

5 And the third issue was maximum groundwater level
6 in SER Section 2.4.12.

7 Upon the recommendation of the Office of
8 New Reactor Management, six technical experts in the
9 area of dam breach analysis and hurricane storm
10 surge were selected through the Office of Nuclear
11 Regulatory Research, to independently review the
12 applicant's FSAR, the staff's SER and the non-
13 concurrence to provide their expert opinion on the
14 issues raised by Dr. Ahn.

15 Upon completion of this review, upon
16 completion and review of the expert analysis, on
17 December 6, 2011, Dr. Ahn's supervisor provided
18 written documentation of his analysis of the non-
19 concurrence in Section B of the non-concurrence
20 form. The non-concurrence of Dr. Ahn and his
21 supervisor's recommendation which included the six
22 expert analysis, were forwarded to the division
23 management in the Division of Site Safety and
24 Environmental Analysis for resolution of the issue.

25 On October 15, 2012, the division

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 management documented their final resolution of
2 these issues in Section C of the non-concurrence
3 form. The documentation of this non-concurrence has
4 been requested by Dr. Ahn to be made publicly
5 available and can be found in ADAMS.

6 At this time I would turn to Dr.
7 Corradini, who will provide remarks regarding ACRS's
8 expectations, followed by Dr. Ahn who will present
9 his non-concurrence. Then Dr. Henry Jones and Dr.
10 Rajiv Prasad will follow with the staff's finding
11 and resolution of the non-concurrence.

12 CHAIR CORRADINI: So just to remind
13 everybody, we want to make sure we ensure equal and
14 appropriate time to hear both perspectives of the
15 non-concurrence. So I'll ask the members to focus
16 their questions primarily on the presenters and
17 their comments during the allocated time. We have
18 an hour for each. And then we can discuss it after
19 the fact. So first I'll call on Dr. Ahn for your
20 presentation.

21 DR. AHN: Good morning, everybody. My
22 name is Hosung Ahn, hydrologist in the hydrology and
23 meteorology branch. I filed this non-concurrence in
24 June 2011. And management concluded last year with
25 revising SER substantially. So I've reviewed this

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 revised SER as well as reviewed comment from the
2 external peer review and I decided I will not concur
3 the final, I mean the revised SER.

4 So this morning I am presenting why I am
5 not concurring on the revised SER. So first let's
6 cope with the site review from my original non-
7 concurrence issue. But I say that the basic issue
8 remained the same about this question and the
9 justification is slightly different from the
10 original non-concurrence.

11 MEMBER BLEY: And you said at this time
12 you do concur with the revised.

13 CHAIR CORRADINI: No, do not.

14 MEMBER BLEY: You do not, okay.

15 DR. AHN: There are three independent
16 issue. One is the, three independent issue and I do
17 not concur all three of them. So as was already
18 said there are three non-concurrence issues. I am
19 focusing my presentation on the first issue, the
20 shell damage issue because that's the most important
21 and critical issue for the safety and for the
22 structural part of Chapter 3.

23 So on that first issue, I have four main
24 concerns. There was interest on how they analyze
25 the dam breach for the MCR. They used the empirical

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 equation to predict the breach parameter. Breach
2 parameter means the breach width, breach time and
3 peak breach outflow. But peak outflow is simulated
4 by the model.

5 So empirical equation, I claim that when
6 they estimate breach width, breach time is not that
7 sensitive but breach width is the most sensitive
8 parameter. When they estimate the breach parameter
9 they used one selective equation, Froehlich
10 equation. That does not produce the conservative
11 estimate.

12 I confirm that equation with the
13 existing actual breach data from the Florida cases
14 and I found that equation underestimate the breach
15 width significantly. So I introduced that in
16 detail. So that empirical equation method is the
17 primary method. But they also used the NWS-BREACH
18 model. That's the physical model for simulating
19 breach process.

20 But it's also depending on how you
21 define the model. I found that there are three
22 issues. The first one is that STP used the low
23 value. That resulted in the underestimation of the
24 breach process as well as the flow process. Also
25 the staff used unrealistically small tailwater

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 section compared to the expected breach. So I'll
2 explain that in detail.

3 The last one is that both staff and STP
4 never considered a scouring hole. If you look at
5 the breach there are big scour hole. And I'll
6 explain that too. So let's begin with STP already
7 attributes the site layout and some structure of
8 future -- and I add some that could be related to
9 the breach analysis.

10 STP complete the MCR construction in
11 1983. And they did the filling tests. That means
12 that they filled the reservoir sequentially then
13 they measured the seepage and whether there are
14 problems or are there or not. They did filling
15 tests up to 45 feet. And they observed some sliding
16 on the system.

17 So they said that they determined
18 national normal operating level would be 45 feet.
19 Now they're going to add two more units and they're
20 going to raise their operating level to 49 feet. So
21 my concern is that with that higher water level,
22 seepage volume will increase. Then it could induce
23 the piping failure. So that's basic concern on the
24 breach analysis.

25 MEMBER ARMIJO: Where is the seepage

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 actually occurring? Where is it being detected in
2 these wells or?

3 DR. AHN: Everywhere.

4 MEMBER ARMIJO: So all around this dike
5 or levee or whatever you want to call it.

6 CHAIR CORRADINI: But I guess Sam's
7 question is the cross hash region is where they --
8 is it the yellow or the cross hash region where they
9 determine what's seeping?

10 DR. AHN: It's actually seeping on the
11 valve embankment and then it's through the
12 foundation. In the foundation there are two sand
13 layers. I will show them.

14 CHAIR CORRADINI: Okay.

15 DR. AHN: Seepage will cut through them.
16 So the location of the breach is the applicant STP
17 and I concur that the location is the closest from
18 the site. That's on the northern embankment. And
19 during the breach they have the cement block on the
20 interior side of the embankment. That cement block
21 could have fall into the bottom of the breach. That
22 could increase the roughness quotient. We call them
23 MSM.

24 That really induce more wide a breach
25 and more breach were induced. So that should be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 considered by applicant and the Staff never
2 considered that effect.

3 And when we defined the breach,
4 redefined the erosion of the embankment and when we
5 defined the scouring here we defined the erosion of
6 the foundation is defined as scouring. The bottom
7 elevation is 29 feet and below we consider that
8 scouring but STP and staff never considered the
9 scouring of the foundation.

10 So next four pages of, yes, in general
11 when we do the dam breach or levee breach analysis
12 in Chapter 2 safety analysis, we have a regulatory
13 framework of Part 50 GDC-2 that was already
14 introduced. It clearly said that we should consider
15 the most severe event with a sufficient margin. I
16 believe that STP didn't do that when they estimated,
17 especially the breach width.

18 Was the Part ~~100.208~~ 100.20(c)(2) that
19 we should use the maximum probable event for the
20 rain or wind. Why don't we use the same approach
21 for the dam breaches? That's my concern. And we
22 have the guidance in SRP, RG 1.206 and ANS 2.8,
23 that's the industry guidelines. However, the issue
24 on general dam breach problem is that we don't have
25 a detailed, technical guidance for the dam breach

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 analysis.

2 Second, we have some dam breach
3 historical data. However, especially for the larger
4 dam, you don't have sufficient data. So all of our,
5 the guessing game and we have a lot of uncertainty
6 in breach analysis due to the data gather and
7 uncertainty on those factors.

8 And applied conservatism similar to the
9 other flood causing mechanism, that's another issue.

10 For example, in rain input in the storm we use the
11 probable maximum approach it, like for the probable
12 maximum precipitation, we use the envelope approach
13 to, use what is the envelope for the record of the
14 rainfall on top of that we used the moisture
15 maximization through adding more margin on there.

16 That's what we do to PMP and also some
17 hurricanes we use the PMH approach for hurricane.
18 That is really a bounding approach. We should, my
19 opinion is that we should use the similar
20 conservatism applied to the dam breach analysis.
21 I'll explain that, explain a little bit more on
22 that.

23 CHAIR CORRADINI: Can I ask one, just
24 clarification?

25 DR. AHN: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 CHAIR CORRADINI: So when the two
2 additional units are added the mean depth would be
3 four feet larger.

4 DR. AHN: Higher.

5 CHAIR CORRADINI: Higher, sorry, higher.

6 And is that the major difference that causes your
7 concern? I'm trying to understand. I understand
8 the modeling differences. But I guess I'm, you
9 start off by saying there was a difference in the
10 operational level. So is that the source of it if
11 it stayed at 45 would there be an issue?

12 DR. AHN: They did the filling test for
13 45. But they never did a filling test for 49.

14 CHAIR CORRADINI: Okay. But if they
15 stayed at 45, would there be an issue?

16 DR. AHN: I don't think so. Yes.

17 CHAIR CORRADINI: There still would be
18 an issue. I'm trying to understand. I'm just doing
19 a relative comparison. They're at 45 now and
20 operating. And now they choose to go to 49 with the
21 two additional units. Is it the difference in
22 inventory of those four feet that caused the
23 concern?

24 DR. AHN: I think that's a concern. But
25 I need to explain this way. Applicant used the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 deterministic approach. And they just postulate
2 breach scenario without field condition or a field
3 data. No matter what operating concern, whatever,
4 they just postulate the breach scenario, then they
5 estimate the maximum flood level.

6 And they, that level exceeded the
7 design-based flood level. So they used that
8 information for structure design. That's what they
9 did. So whether operating level is higher or lower,
10 I think that doesn't matter.

11 CHAIR CORRADINI: It doesn't matter.
12 Okay.

13 DR. AHN: They just postulate the
14 scenario, breach scenario. But my concern is that
15 raising that level the potential of dam breach could
16 increase. But that information is not used in any
17 of the MRCs.

18 CHAIR CORRADINI: Okay.

19 DR. AHN: So I introduced the general
20 issue on there. And to simulate the dam breach we
21 should use, we should simulate the erosion and the
22 flow process together. The process is reservoir,
23 breach outflow and tailwater. We have no physical
24 model that could handle all of this together.

25 And the NWS-BREACH model can handle

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 reservoir and erosion process and breach outflow.
2 But it has some limitation on the tailwater routing.

3 So how applicant did that is that they used the
4 combined approach. First they used an empirical
5 equation to create the breach parameter. Breach
6 parameter, again means the breach width and breach
7 time.

8 Then they used a numerical model. Plus
9 they used a FLDWAV model to simulate breach outflow.

10 Then they used an RMA-2 model to simulate the
11 tailwater routing. Then they used the NWS-BREACH
12 model to validate their estimation. So staff used a
13 similar approach but they used the BREACH model as a
14 primary tool. Then they used the historical model
15 and entered equation to validate their estimation.

16 I used a similar approach to the STP.
17 But instead of the RMA-2 model, I used the FLO2D
18 model. That simulates tailwater spreading on the
19 tailwater. But the result are same, the basic issue
20 is that how we define the parameter and how we
21 define the empirical equation. That's the key point
22 in here.

23 So again, what empirical regression
24 equations, that's the simple regression equation to
25 predict the breach parameter. Based on the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 reservoir size. The reservoir size means the height
2 of the head of the reservoir and the storage bottom
3 of the reservoir. It's a very simple equation. But
4 it produced some bad results, some uncertainty in
5 there.

6 So next slide, I'm going to introduce
7 the, why STP's breach width estimation is not
8 conservative or why their estimate is not, why they
9 underestimate the breach width. STP breach
10 parameter estimation also relies on the first part
11 of the left side of the part. As they introduced
12 their breach is 417 feet and that's based on the
13 Froehlich, best fit equation. I emphasize best fit.

14 This is not the bounding equation.

15 And they used the MLM bounding equation
16 to get 1.7 breach timing. And using the Froehlich
17 equation they and the peak flow rate of 63,000 cfs,
18 then they used the American model for the wave. For
19 the wave they used the 417 feet breach width and the
20 1.7 hour breach time, then they simulate a breach
21 peak outflow, that's 130.

22 I used the MLM breach width equation.
23 That's, resulting in much more conservative result.

24 And based on some sort of a scouring hole, breach
25 width would be 700 feet to 1,700 feet. That's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 almost two or three times wider than what applicant
2 estimated. Using that breach width, I simulate
3 FLDWAV model and it ended up 280 kcfs. That's
4 almost two times larger than what applicant
5 estimated.

6 I also used the BREACH, NWS-BREACH model
7 with conservative roughness coefficient and
8 realistic tailwater section. That end up about 260,
9 so again two times larger than what applicant
10 estimated at peak flow.

11 So my issue is that STP's breach width
12 estimation is not conservative. I think they
13 underestimated breach. The main reason is that they
14 just keep the Froehlich best fit equation, based
15 upon region and they just ignore the MLM equation.
16 When they justify why they don't use the MLM
17 equation they said, I think one of the RAIs they
18 said that MLM equation is not for the bridge width.

19 But that's not correct.

20 I have a lot of paper. They actually
21 classify that MLM erosion volume equation, that
22 equation can be used to predict breach width. So I
23 think the applicant's justification is incorrect on
24 that. And also use of the best fit equation, that's
25 another concern and I explained that in further

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 detail.

2 So to predict a breach parameter, that
3 means breach width and breach time, there are four
4 determining equations. USBR had one equation. Von
5 Thun and Gillette has another equation. Then
6 Froehlich's one equation and MLM is another
7 equation. What guidance said, all the agent's
8 guidance all the federal agency or state guidance
9 said, what they said is that we should use all
10 equation to make engineering determination.

11 Engineering determination means what is
12 the construction condition and what is the current
13 condition of the dam already? And how an actual
14 breach could occur. So we should do that. But they
15 just picked the Froehlich equation and that's it.
16 That's what they said.

17 And also in terms of the breach peak
18 flow, there are over, more than ten equations.
19 However, the applicant used just Froehlich breach
20 equation and they ignored the other equation. The
21 other equation actually end up much higher breach
22 volume than, the peak flow volume than Froehlich
23 equation. So that's another concern on that. So on
24 the next page I made a --

25 MEMBER ARMIJO: Before you leave that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 chart, could you go back to, you also cite that the
2 breach for STP Units 1 and 2 is 2,000 feet and that
3 was determined, pretty much deterministic that they
4 just said --

5 DR. AHN: That's the same determinist
6 approach. But on the UFSA they never clearly state
7 how they end up 2,000. But they just assume the
8 2,000 and instantaneous failure.

9 MEMBER ARMIJO: And that was, did not
10 create problems for the flooding of the units.

11 DR. AHN: Yes, Units 1 and 2, they are
12 designed for these 51 feet. So I don't see any
13 problem with it.

14 MEMBER ARMIJO: So Unit 3 and 4 --

15 DR. AHN: Unit 3 and 4, their flood is
16 40 feet. That's much lower.

17 MEMBER ARMIJO: Okay. So that's a main
18 issue. So your approach would have predicted a
19 breach similar to their 2,000 feet closer.

20 DR. AHN: Actually it's less than that.
21 I said it's about 700 feet to 1700 feet, less than
22 2,000.

23 MEMBER ARMIJO: Yes, it would be less
24 than 2,000. But much greater than 417.

25 DR. AHN: That's right.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER ARMIJO: Okay. I don't
2 understand what the problem is.

3 DR. AHN: This one, UFSAR used in the
4 Victoria ESP, that's actually withdrawn. But they
5 used about 2,000, it is similar conditions, but they
6 assumed the 2,000. I don't know exactly how they
7 estimated 2,000. But they did that.

8 And the initial version of the Units 3
9 and 4 FSAR, they assume the 4,700 feet. Now they
10 change that to 417. That's our basic concern
11 raised. And for the Martin Cooling Pond in Florida,
12 that reservoir size is quite similar, about 700, I
13 mean 7,000, acre area with some similar head. But
14 actual breach was 600 feet. So that's why I say
15 this 417 feet is not conservative. And this is
16 small. Next page.

17 MEMBER SCHULTZ: Excuse me, go back
18 again please. Why are the latter two -- in your
19 notes you indicate the latter two approaches are not
20 applicable to MCR, why is that? Is that your
21 conclusion or?

22 DR. AHN: The two equation, they rely
23 only on the breach head, not the breach volume. So
24 if you use that equation it underestimate breach
25 width.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER SCHULTZ: For each of them.
2 Thank you.

3 DR. AHN: So I made a position analysis
4 for the MCR breach size to know the potential size
5 of the breach width. What I did is from the two
6 papers that Xu and Zhang and the Froehlich paper,
7 that is 2008, that's different from what I say the
8 Froehlich equations. I pulled the basic data from
9 that paper and I plot that on the graph. On x axis
10 it shows the breach volume and the y axis is the
11 breach head.

12 So if you look at that the data is
13 really scattered. That means it introduce high
14 uncertainty estimation, whatever your estimation is.

15 Then I plot the position of the MCR, MCP, Martin
16 Cooling Pond as well as Teton. The applicant chose
17 the Teton as a showcase for MCR. I believe that's
18 incorrect because Teton dam is very high. It's
19 about 270 feet high. And the storage volume is a
20 little bit higher than MCR.

21 But it reached the 419 feet breach. But
22 because that is the high then it cannot be the
23 showcase for the MCR. A better choice is the Martin
24 Cooling Pond in Florida. And staff chose there, but
25 after the, when they analyze the data it's a little

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 bit different way they did it. So what I am saying
2 is that MCR is the largest dam based on the
3 clarification of that dam even by the State of
4 Colorado or international definition.

5 MCR is the largest dam and it has a low
6 head, but high volume. So breach width could be
7 higher or wider. That's my presumption on this.
8 And that's true for the, I proved that for the
9 Martin Cooling Pond cases. And based on the size of
10 the MCR, which showcases the Martin Cooling Pond
11 breach that happened in 1979, in November. So
12 that's my observation throughout this position.

13 CHAIR CORRADINI: Can I ask one
14 clarifying question just so I remember? In the non-
15 concurrence report with the appendices, you are in
16 agreement with the other experts that it's a pipe
17 break that would be the initiating event. Am I
18 correct?

19 DR. AHN: Yes.

20 CHAIR CORRADINI: So it would be, so the
21 pipe would break, I'm still trying to understand
22 this. The pipe would break through the embankment
23 and then would cause erosion and it would just erode
24 to some size. Now we're talking about how big of a
25 size it erodes to. And that's dynamically

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 considered in both cases? In other words you start
2 with a little hole.

3 DR. AHN: Yes, starting from the small
4 piping hole.

5 CHAIR CORRADINI: But I guess the reason
6 I'm asking that question is in what I thought was
7 the assumption was it kind of rises up quickly
8 versus erodes slowly. But is the rise up quickly
9 still a dynamic erosion of a hole? That's what I'm
10 confused about.

11 DR. AHN: In the NWS-BREACH model the
12 vertical erosion and the horizontal erosion that is
13 --

14 CHAIR CORRADINI: Well, it's coming from
15 a pipe break. Okay.

16 DR. AHN: Yes, it's starting from one
17 pipe break.

18 CHAIR CORRADINI: Okay, thank you.

19 DR. AHN: Yes, Martin Cooling Pond where
20 piping started is from the foundation, not the
21 embankment itself. Similar thing could happen on MCR
22 breach.

23 CHAIR CORRADINI: Okay, so this is a
24 different initiation for the Martin Cooling Pond.
25 It initiated differently in your MCP.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 DR. AHN: Yes, you said, that's a good
2 point.

3 CHAIR CORRADINI: I just wanted to
4 understand.

5 DR. AHN: When the breach modeling, we
6 assume that piping started from the embankment. I
7 tested piping starting from the foundation and it
8 has same effect.

9 CHAIR CORRADINI: Okay.

10 DR. AHN: So in terms of the
11 conservatism, I put some historical dam breach or
12 levee breach cases because I make for the case for
13 dam breach or a levee breach because when I look at
14 the levee breach width of the breach is much wider
15 than dam breach. So those data come from the
16 different source of the data.

17 But problems on the levee breach data is
18 that we don't have extensive or comprehensive
19 database. So I used some limited report or paper.
20 But my conclusion on there is levee breach wider
21 than
22 dam. So what all the difference between the dam and
23 levee?

24 The dam has solely the foundation and it
25 has a raised embankment on the side. But levee

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 system doesn't have it. MCR doesn't have any
2 treatment -- they have some treatment on the
3 foundation. But they have no sea barrier or any
4 solely the foundation on theirs. That's why I
5 believe that MCR will breach wider. And it will --
6 scouring will happen on the MCR breach. That's my
7 opinion.

8 STP estimates breach width of 417 feet.

9 They have the scatter data, then they developed a
10 best to fit deviation equation. And they just used
11 it without the margin. So what this mean 417?

12 In an actual case about 50 percent of a
13 chance the breach width could exceed that barrier.
14 That's why I claim that this is not conservative.
15 So I said that rough STP it is, again it's for GDC-2
16 condition. And Froehlich equation does not provide
17 the bounding equation.

18 However, while Froehlich provided
19 confidence interval, offered confidence interval or
20 lower confidence interval based on the standard
21 deviation from the mean of the friction error. So
22 we can use that upper bounding equation as a, I mean
23 upper confidence interval as a bounding equation.
24 So tools are available, but applicant never used
25 them.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Next page. So here I said we have four
2 candidate equations to predict breach width and
3 breach time. First three equation, USBR and von
4 Thun and Gillette equation cannot applicable because
5 that is based only on the breach head. So the only
6 candidate is the Froehlich equation and the MLM
7 equation. Which choice is better?

8 Staff said that the Froehlich equation
9 is the better because its prediction error is
10 smaller. Froehlich equation is .43 and MLM equation
11 is .83. So Froehlich equation is better in this
12 case. I disagree with that because that Froehlich
13 prediction error is just the error in breach
14 lengths, breach width.

15 However, MLM equation prediction error
16 of .83, is the breach volume error. This is a
17 different dimension. You cannot compare one to the
18 other. Then I think that Dr. Head also commented
19 that MLM equation, actually that's for the breach
20 width. MLM equation, best fit equation, produced
21 higher R squared error compared to the bounding.

22 I think that's slightly, we cannot
23 compare one to the other. Best fit equation we can
24 define R squared. However, for the bounding
25 equation we cannot define R squared because the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 procedure are different. So that justification is
2 also, I think it not correct. CHAIR CORRADINI:

3 Can I ask you to repeat that because I read our
4 consultant's report and it was persuasive to me. So
5 I am trying to understand your explanation, your
6 counter argument. Can you just repeat it please?

7 DR. AHN: Okay. Actually two external
8 reviewer say this. Froehlich prediction equation,
9 prediction errors one of them MLM prediction
10 equation. The USBR hydrologic engineer, he actually
11 wrote his paper in 1992. He estimate the prediction
12 error for these three equation.

13 And he said that Froehlich prediction
14 equation is smaller, so it's more, it's better
15 equation for MCR breach equation. I said that's
16 incorrect because they are two different dimensions.

17 CHAIR CORRADINI: They have two
18 different what, I'm sorry?

19 DR. AHN: Dimensions.

20 CHAIR CORRADINI: Okay.

21 DR. AHN: Yes, Froehlich equation is for
22 the breach width. MLM equation is for the breach
23 erosion volume. It has much more intrinsic error
24 and it has literally higher error. So that's
25 different. That's one thing.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Then historical breach data used in the
2 MLM is much -- the range of the data is more, much,
3 much smaller than MLM equation. That's shown on
4 this, on Page 8. So we chose to verify MLM,
5 definitely this graph say that MLM equation is
6 better because the data reference, MLM is superior.

7 CHAIR CORRADINI: Okay, thank you.

8 DR. AHN: That's my argument. So based
9 on Martin Cooling Pond cases, that's the historical
10 data. I evaluate those three equations and I
11 conclude that the MLM and the, MLM equation or the
12 bounding Froehlich equation is better.

13 So for MCR because the MCR and the MCP
14 are same condition, similar condition. So that's my
15 conclusion of this specific sub-topic. And the next
16 one I'll explain the roughness coefficient.

17 CHAIR CORRADINI: We need to conclude in
18 about 30 minutes, just so, time check.

19 DR. AHN: I go fast. Roughness
20 coefficient. In the BREACH model, roughness
21 coefficient is the most important parameter, among
22 others. And Manning's equation originally developed
23 for the flow, but when we apply that then it's the
24 roughness coefficient in breach, it could have a
25 slightly different meaning.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 The issue is the STP used a non-
2 conservative n-value. However, the staff used the
3 n-value of .75, that's quite, I mean much more
4 conservative than what applicant has made. So I
5 agree with this the staff's value and I do not agree
6 with applicant's value. And I just, I explained
7 that on the next page.

8 So why the breach n-value should be
9 higher than Froehlich n-value. It's explained on
10 there. Basically the reason is that breach create
11 more flow, that create more resistance. But that's
12 why they should use the higher n-value. And the
13 State of New Jersey, they defined the probable
14 maximum n-value and they also defined the probable
15 maximum breach width.

16 But they always concentrate their
17 commentary on the higher value. The breach manual
18 provide for low n-value cases and the Staff used
19 that to justify the, justify the applicant's n-
20 value, .05 is reasonable and acceptable. But the
21 other study used really higher n-values. Sometimes
22 they used more than, greater than .1 value.

23 Next page. So I put all different
24 meanings and values from different sources. The
25 first two I already explained as applicant used .05.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Staff used the .075. And the Handbook of
2 Hydrology, that's the most widely referenced group,
3 they used n-value for China as a .04 to .1. And
4 Chow, he also reached the extensive n-value and he
5 said the n-value is .035 to .1.

6 So the high end is really high. And the
7 next two Fenton and Trieste and Jarrett paper, and
8 their n-value is really high, especially for Trieste
9 and Jarrett said the breach head barrier, the n-
10 value is much higher than, it should be two times
11 higher than what is based on the field flow
12 condition.

13 Then they should, they said you should
14 use a higher value, two times higher than that. So
15 the next one there is like .225. That's really
16 high. And the last two I estimate n-value based on
17 the Chow method. And also calibrate n-value using
18 the Martin Cooling Pond. And it's about, it's over
19 .75. So what I concluded is that the staff choosing
20 an n-value of .75 is reasonable.

21 It's not that really conservative.
22 That's my conclusion. So what I am saying is that
23 applicant's n-value of .05 is small. One expert
24 peer review said the n-value of .025 is reasonable.

25 But I disagree with that because if you use the n-

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 value of .025, breach width is less than a hundred
2 feet.

3 It's much smaller. Breach volume is
4 like less than a 100. It's also small. Even .05,
5 that's not working on this case.

6 MEMBER SCHULTZ: But your bottom line
7 conclusion is that the .075, which was used in the
8 staff SER analysis, is appropriate?

9 DR. AHN: Acceptable, yes. I agree.
10 The next one is the tailwater section. BREACH model
11 used one dimensional flow out on the breach section
12 as well as tailwater. On tailwater, the units
13 specify only one cross section. That's more than
14 limitation but is acceptable based on our tests and
15 our analysis.

16 I claim that the staff used an
17 unrealistically small cross section compared to the
18 expected breach width. Breach width is about 400 or
19 500 feet. Bottom tailwater section they used the
20 600 feet. That substantially decreased the breach
21 process. So that's the issue I raised on there.

22 And the applicant used a similar
23 approach for their sensitivity analysis. But when
24 they used a simulation of the BREACH model, they
25 used the .05 and that is not a, small breach

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 section, tailwater section is not impacted on there.

2 So my opinion, I disagree on that.

3 And the issue is the wide, the bridge
4 width because the reality of the tailwater section
5 is that it's more than one mile wide, width and it
6 has slightly upslope. So tailwater section is very
7 critical in this simulation.

8 CHAIR CORRADINI: So I don't understand
9 what a tailwater is. Are you saying it's, is that
10 your next figure? Are you going to show, okay, fine
11 thank you. Thank you.

12 DR. AHN: Next figure show what is the
13 tailwater sections. Let's look at first the bottom
14 left figure. I used the FLO2D model and applicant
15 used a similar approach using the RMA-2 model. We
16 simulate two dimensional flow on the tailwater
17 section down. The tailwater section down means the
18 downstream of the breach section. That's another
19 part of the breach section.

20 I observed that there, the tailwater
21 flow is really widely deposited. So if we use the
22 small section it creates a head, initial tailwater
23 head dramatically. If you look at the top left
24 picture, I compare the staff's tailwater section and
25 my tailwater section on the bottom and top. That is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 the imaginary section, that section, that does not
2 exist on the field.

3 But they used a small section, that
4 constrict breach process. That's what I said on
5 there. And on the top right hand corner, that
6 actually is the scale of the staff's breach section
7 and my section. I used the 3,000 breach. On the
8 side I put some barrier. But that does not effect
9 final simulation.

10 CHAIR CORRADINI: So, I'm sorry that I'm
11 still not following. It would seem to me with a
12 larger tailwater section the water would disperse
13 away from the unit. What am I missing?

14 DR. AHN: That's a good point.

15 CHAIR CORRADINI: I mean if I make it a
16 1,000 feet it's not going to go just that way. It's
17 going to go that way. So am I missing something?

18 DR. AHN: Yes, lots of people ask the
19 same question.

20 CHAIR CORRADINI: Okay.

21 DR. AHN: That tailwater is only near
22 the breach section. So if here is that small
23 tailwater section, breach for outflow of water will
24 be smaller. So if that transfers to the site, actual
25 flooding head will be lower even though tailwater

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 head near the bridge section is higher. There are
2 some compensation effect.

3 CHAIR CORRADINI: Okay. All right.

4 DR. AHN: So if I use the wider, wide
5 tailwater breach section, it create wider breach
6 width. Then it creates much more flow. That
7 transfer higher flooding at the site.

8 CHAIR CORRADINI: And your simulation is
9 what we're looking at, at the lower left? It's your
10 simulation that we're looking at the lower left?

11 DR. AHN: No, no, for the BREACH, NWS-
12 BREACH model, I used the wider breach section on
13 there. I used that outflow on my two dimensional
14 flow model, that's the lower left.

15 CHAIR CORRADINI: Fine, that's all I was
16 asking.

17 DR. AHN: Two different models.

18 CHAIR CORRADINI: Okay. Thank you.

19 DR. AHN: So my, before that, the staff
20 did the sensitivity analysis of the tailwater
21 section. However, in their sensitivity analysis
22 they used an n-value of .05 and on the blue line.
23 So what that mean? They choose the n-value of .075
24 but they did sensitivity analysis with n-value of
25 .05.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Then they concurred that tailwater
2 section is not a limiting factor. I disagree with
3 that. I did same sensitivity analysis with n-value
4 of .075. And I end up the red line. This is very
5 sensitive. Even in SER they conclude that tailwater
6 section is not contributing factor.

7 But I disagree based on my simulation.
8 Then they used the n-value of .075 in their
9 simulation and they conclude that maximum outflow
10 will be about 170. So applicant's breach scenario
11 is acceptable. If I used the n-value of .75 with
12 wider breach width, that's 3,000 feet, it end up
13 much higher outflow and flooding river. So I think
14 that's simply modeling error.

15 MEMBER SCHULTZ: Is there something in
16 the equations that explain the graph that you show,
17 the results that you show on the graphs that for an
18 n of .05 it's going to be rising and then flatten at
19 a particular?

20 DR. AHN: That's on my reanalysis
21 report. I include my sensitivity analysis paper on
22 there and clearly say that this is showing the same
23 thing as yours on there. And the the report also
24 show this graph. So all the data are there.

25 MEMBER SCHULTZ: Okay. I'll take a look

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 at that more carefully. It looks like the equations
2 provide some unusual results with that sensitivity.

3 DR. AHN: No, we use the same model and
4 same, only the difference is the Manning's value of
5 the tailwater section. So through the sensitivity
6 analysis I verified that. Next.

7 So far I explained the tailwater
8 section. We did the sensitivity analysis by STP,
9 staff and I, myself. And I plot them on there. So
10 all the basic data are on the report, on the report.

11 And I just plot this. And at Manning's n-value of
12 .075, we have a deep, deep difference between my
13 estimation and the staff's and the STP. Why that
14 happen?

15 That's because of the small tailwater
16 section. That's the clear result of the model. And
17 why is there a difference between the staff and the
18 STP? That's because they used different soil
19 property. And I tabulate that on there.

20 Next page. Scouring hole issue. I said
21 staff and STP never used a scouring hole. And in
22 the external peer review they unanimously conclude
23 that scouring hole will not occur. I disagree on
24 that. When they, when external peer review look at
25 the soil property, I think they misinterpret the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 actual soil property. So I'll explain that later.

2 But, so my issue is that scouring will
3 happen in MCR based on field data. And I explain
4 that even more.

5 CHAIR CORRADINI: Can I just say back to
6 you after reading the non-concurrence, when you say
7 scouring you mean erosion due to turbulence? When
8 you scour that means I'm, I have some sort of
9 turbulent action that's essentially taking up soil
10 and eroding.

11 DR. AHN: It's same as the breach. But
12 I defined that scouring is below the embankment and
13 breaching is on the embankment.

14 CHAIR CORRADINI: Okay, fine.

15 DR. AHN: Erosion process are the same.

16 CHAIR CORRADINI: Okay.

17 DR. AHN: Next, please. I brought some
18 Martin Cooling Pond breach case in here. They used
19 about 600 feet of the breach and in their breach
20 scouring hole is very wide and extensive. And their
21 depth is maximum 30 feet, about 30 feet, 29 feet.

22 And average is about 16 feet. That's
23 why I assume that, I assume that probably from
24 scouring holes scenarios. Zero depth, ten feet
25 depth, 15 feet depth and 20 feet depth. And that's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 the range of this, I got that value from this.

2 What scouring hole impact, I mean what's
3 the meaning of the scouring hole? It creates the
4 wider breach volume compared to just a breach
5 itself. And it produces more outflow and it induce
6 more flooding, that's the basic concern on there.
7 Next, please.

8 MEMBER ARMIJO: Without scouring you
9 would just have the initial breach of the levee or
10 the dam and it would pretty much remain the same
11 throughout the drainage, it wouldn't widen? If you
12 don't have scarring does that, a breach just --

13 DR. AHN: It's condensing. When, if you
14 simulate the breach in water without scouring hole,
15 breach width will actually be wider, about more than
16 a 1,000 feet. If we use the scouring hole, breach
17 width will be lower. But actual volume is, remain
18 the same.

19 MEMBER BLEY: So you're saying the cross
20 section stays the same.

21 DR. AHN: Cross section is same, yes.

22 MEMBER BLEY: In either case.

23 DR. AHN: Yes. So if I use the ten feet
24 scouring hole, breach outflow volume is about 270
25 something. If I use the 20 feet, actual breach

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 volume is slightly lower than that but still nearly
2 the same.

3 Next page I show the -- there are the
4 sand layers and what, how piping could occur. I'll
5 jump to the next page. And other thing that,
6 currently they have five groundwater pumping wells.

7 And they're going to add one more well. The other
8 MCR leg system.

9 If they continuously pumping groundwater
10 from there, there could be land subsidence,
11 currently they never observed. They will induce
12 significant drawdown and at the southern point it
13 could induce land subsidence and that could create
14 breaching and scouring. That's my basic opinion on
15 there.

16 This one is the soil property from the
17 UFSAR report. And I found that about a few weeks
18 ago and I include that on there. But two external
19 peer review said that scouring will not occur
20 because cohesion value, c-value, first the green
21 color is really high, a 1,000 or 2,000 pound per
22 square feet.

23 So the clay layer scouring hole will not
24 occur. However, they missed the next page on there.

25 They measure the soil property after filling the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 reservoir. What are the difference between the
2 construction end of the construction and after
3 construction? End of the construction that clay
4 layer is really compacted.

5 So the soil is really stiff and it has a
6 higher cohesion value, more than 1,000. However,
7 after filling water, clay layer is soaked and
8 saturated and c-value is dramatically reduced. Like
9 that, there are some pipe on the second, on the red
10 column, the fourth red column, I used the bar as the
11 missing data. But I checked the actual UFSAR report
12 and it's not missing value.

13 That means there is local washout on the
14 clay layer. And during the '83 to '84 they measure
15 and have a cohesion value and it's about 350 pound
16 foot, cubic feet. So --

17 MEMBER BLEY: Where are they measuring
18 this?

19 DR. AHN: Just taking sample and they
20 measure this area from the left.

21 MEMBER BLEY: Right outside of the levee
22 area.

23 DR. AHN: No, no the embankment. They
24 took samples from the --

25 MEMBER BLEY: Right through the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 embankment down.

2 DR. AHN: Embankment and the clay layer,
3 that's all foundation.

4 MEMBER BLEY: And this is down near the
5 bottom.

6 DR. AHN: Yes, exactly. They took the
7 sample and they made up a value, that's the value.

8 MEMBER BLEY: If I read your equation
9 right though, it looks like the shear strength is
10 going up in general because your fee (Φ) is going up.

11 DR. AHN: That's true.

12 MEMBER BLEY: So the shear strength is
13 getting better even though it's less compacted?

14 DR. AHN: You say blue column, I mean
15 the green column?

16 MEMBER BLEY: Your degrees.

17 DR. AHN: Degrees, yes.

18 MEMBER BLEY: The equation says the
19 shear strength is going up because that shear angle
20 is going up.

21 DR. AHN: In the BREACH model figure,
22 the angle is not that sensitive. Most sensitive
23 area is the seabed. But what external peer review
24 said is that c-value is really high. So scouring
25 will not occur. I disagree with that based on the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 data actual c-values really decreased.

2 So the staff and the STP really used
3 actually 300 feet or 400 feet in our BREACH model.
4 But external peer review, they missed this fact and
5 they said that scouring will not occur.

6 MEMBER BLEY: 1984 is the most recent
7 sample they have?

8 DR. AHN: I believe, yes.

9 MEMBER BLEY: So we don't know what it
10 is right now?

11 DR. AHN: Right now, we don't know, no.

12 Next page is, I just summarized my simulation of
13 the breach process and the final breach width and
14 the further, and I end up over about 45 feet.
15 That's five feet greater than what applicant
16 estimates. So my conclusion is that STP should use
17 the conservative equation or realistic breach
18 parameter.

19 And next, the hurricane storm surge.

20 CHAIR CORRADINI: If I might just do a,
21 I'm sorry to, but we started about an hour ago. You
22 said you want to deal with issue one. This is now
23 onto issue two. Do you want to deal with this
24 because I think we were going to need about an hour
25 for the staff too? So I wanted to ask your opinion

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 here.

2 DR. AHN: It's up to you. I can skip.

3 CHAIR CORRADINI: Well when you started
4 you said you wanted to definitely present issue one,
5 so --

6 DR. AHN: Yes, I finished the issue one.

7 CHAIR CORRADINI: Okay, okay, so we're
8 into issue two. Do you want to, you have just, as I
9 see this it's just a few slides. So you want to
10 continue please?

11 MEMBER ARMIJO: But before you do that,
12 back on slide 20 in the final analysis after all of
13 these issues that you've raised the fundamental, the
14 final difference that is on this chart that the STP
15 flood level would be six feet or should be six feet
16 higher than what they currently estimate.

17 DR. AHN: No, no. STP's flood level is
18 about 6 feet in depth. But that means plant grade
19 is 34 feet meets the river and they estimate 40
20 feet. What I estimate is about 45 feet, that's five
21 feet higher than what applicant estimated.

22 MEMBER ARMIJO: Yes, that's what, I
23 think we were saying the same thing. At least I'm
24 trying to say the same thing. So they, your 44.6
25 after all of these differences and they're at 38.8.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 DR. AHN: 38.8, but they decided 40 feet
2 including some margin.

3 MEMBER ARMIJO: So they, 40, so there's
4 about a five foot difference in flood level.

5 DR. AHN: Between them and mine, yes.
6 On hurricane storm surge issue, number two, Page 21,
7 STP storm surge, storm scenario, hurricane scenario
8 is not conservative that's what an external peer
9 review commented. However, their wind speed is
10 unrealistically high.

11 The air estimated is over 184 feet,
12 miles per hour, that's much higher than what's
13 estimate on US Army Corps of Engineer estimated.
14 However, the storm surge is much lower than what is
15 Army Corps of Engineer estimated. Their storm surge
16 is over 30 feet. But Army Corps is over and they
17 end up over 40 feet, so very big difference. Why
18 they end up different is your, I think applicant
19 should answer these questions. That's basically my
20 issue.

21 Next, please. This issue is more like
22 the processing issue. Staff identified that maximum
23 groundwater level is exceeding the DCD maximum
24 level. So that is clear departure. However, on the
25 site parameter table and departure report it never

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 addressed and subsequent structure analysis. Some
2 they incorporate this new maximum groundwater level
3 and some they are not. So that is the basic issue
4 on there. So that's my presentation.

5 CHAIR CORRADINI: Okay.

6 DR. AHN: Any questions?

7 CHAIR CORRADINI: Questions from the
8 committee?

9 MEMBER ARMIJO: A lot of questions. But
10 I, you know, basically, you know, this is a lot of
11 detail that is not our, certainly not my area. But
12 it seems that the experience with this Martin
13 Cooling Pond is very relevant to the MCR.

14 DR. AHN: Yes.

15 MEMBER ARMIJO: And there you have data
16 from a natural event and your analysis would be
17 consistent with that data, your analytical approach.

18 And if you apply that same analytical approach to
19 the cooling reservoir, you get a much bigger breach.

20 DR. AHN: That's right.

21 MEMBER ARMIJO: And so, you know, I'll
22 be asking the staff, you know, what is, what's wrong
23 with that approach? I mean we all believe in data.

24 And this is a, maybe there's better examples of
25 something similar to the Main Cooling Reservoir.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 But this looks pretty reasonable so, but it seems to
2 me that's your experimental basis, if you will, for
3 your, to support your analysis and your claims.

4 DR. AHN: If you look at the position,
5 NRC's, on Page 6, it clearly say that Martin Cooling
6 Pond could have been the best showcase for the MCR.

7 But the difference between that and MCR is that MCR
8 is like a clay and silt embankment. However, this,
9 the Martin Cooling Pond describes that, that's the
10 fine sand or the silt material. So sand material
11 has a lower corrosive strength.

12 However, I look at the Martin Cooling
13 Pond breach report and their cohesive value is even
14 higher than what STP's value. So that argument is
15 nullified.

16 MEMBER ARMIJO: Well you have your
17 backup slide, slides 36 and 37 where there's a lot
18 of similarities between those two things. But
19 there's also differences.

20 DR. AHN: That's right.

21 MEMBER ARMIJO: For example, the MCRs
22 have relief wells and sand core blankets, a variety
23 of things to control seepage that are, seem to be
24 significant. But so later, you know, that's what
25 I'll be looking for is, you know, why is the MCR not

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 a good representation of what, is not, that the MCP
2 is not representative of the MCR. What are the
3 differences that basically counter your argument?

4 DR. AHN: Somebody may argue that way.
5 But what is the better candidate? There is no case.

6 MEMBER ARMIJO: Well that's what I'm
7 saying. Is there anything better? And are there
8 any features in the MCR that say well, yes, you have
9 a good example. But what we've got is we've got
10 these wells or we've got other features that protect
11 us against these wide breaches.

12 DR. AHN: That's the positive side, but
13 there was the negative side. One negative side is
14 that the actual breach head of the Martin Cooling
15 Pond is much lower than MCR. That's the one thing.

16 CHAIR CORRADINI: Say it again, I'm
17 sorry.

18 DR. AHN: Actual breach head.

19 MALE PARTICIPANT: There's 16 and seven.

20 DR. AHN: He said 16, but if you look at
21 the table condition it's about 20.

22 (Off microphone comment)

23 MEMBER BLEY: If you get that low it's
24 likely you have a lot more head compression.

25 DR. AHN: And basically in this the 600

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 feet breach area, that's why I claim that MCR could
2 be wider than 600 feet.

3 CHAIR CORRADINI: Other questions?

4 MEMBER BLEY: I have a few. I've read
5 your analysis a while back and I don't remember the
6 details now. I'm being refreshed. I have a few
7 things that aren't quite hanging together. You
8 originally, calculation said you get a breach width
9 between 700 and 1,700 feet.

10 Then you've shown us some pictures where
11 you're using a 600 foot wide breach with scouring.
12 And I thought you had 600 foot without scouring.
13 What is the, is this picture the one that you've
14 actually based your final calculations on, 600 feet
15 wide with scouring?

16 DR. AHN: I did that.

17 MEMBER BLEY: Well you did a lot of
18 things. But the one that leads to the 45 foot, 44.8
19 feet, is that this cross section?

20 DR. AHN: No, no, this is the Martin
21 Cooling Pond cross section. This is not --

22 MEMBER BLEY: Which one is the one that
23 leads to your 44 feet? Is it the wide one that's
24 very, without scouring?

25 DR. AHN: Wide one, yes. No, no, ten

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 feet scouring hole and 1,000 feet.

2 MEMBER BLEY: And a 1,000 feet wide.
3 Okay.

4 DR. AHN: If I used the 20 feet scouring
5 hole it's over 700 feet.

6 CHAIR CORRADINI: Okay. A couple of
7 other questions just to help me out. And you did a
8 lot of calculations so I don't know if you've been
9 able to separate these things. Out of the areas
10 where you think they've been conservative, roughly
11 how important are scouring versus not accounting for
12 the uncertainties and the, you know, not setting an
13 upper bound on the equation that they used.

14 And you used something different. But
15 if they had used their equation with --

16 DR. AHN: Let's go back --

17 CHAIR CORRADINI: -- the bounding
18 calculations.

19 DR. AHN: -- to the applicant's
20 analysis. They used positive when they estimate the
21 breach parameter, they used the empirical equation.

22 On there, only issue is whether it's conservative
23 or not. When we used the breach parameter and the
24 BREACH model, we have several different factor. So
25 let's think of that later. First the empirical

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 equation. Whether they used a conservative or not,
2 I think that's the only issue.

3 CHAIR CORRADINI: And I have a little
4 trouble deciding whether it's conservative enough.
5 You know and you say they're not conservative but
6 maybe they're not conservative enough, in your
7 opinion. You think they're just actually not
8 conservative, that they're optimistic compared to
9 the real world.

10 DR. AHN: But you cannot use the best
11 fit equation because ten percent chance of a time it
12 will it will exceed, structure is there it will
13 always, actual flooding will always exceed that
14 estimate. Whether you use the one standard
15 deviation or two standard deviation the result of
16 the equation. But we should use the conservatism on
17 there, margin.

18 CHAIR CORRADINI: Other questions?
19 Okay. Why don't we take a break now and come back
20 at 10:35 and staff will come back for the, I think,
21 details on the non-concurrence review. Okay, 10:35,
22 we start again.

23 (Whereupon, the foregoing matter went
24 off the record at 10:22 a.m. and went back on the
25 record at 10:35 a.m.) CHAIR CORRADINI:

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Let's come back into session. Tekia, you're back.

2 MS. GOVAN: We're back, and we're ready
3 for the staff to present their findings for the non-
4 concurrence. At the table we have Dr. Henry Jones,
5 Dr. Rajiv Prasad, from PNNL, who is one of our
6 contractors, and Dr. Lyle Hibler also from PNNL, and
7 he's a contractor.

8 Henry Jones and Dr. Rajiv Prasad will be
9 giving the presentations, and I'll turn it over to
10 Dr. Henry Jones.

11 DR. JONES: And this is the presentation
12 of the staff NCP. Just to qualify this, in a normal
13 NCP process we usually don't have six experts weigh
14 in on this. But we thought that in this case with
15 the issues confronting us that we would have six
16 experts, three who are experts in dam breach and
17 three in the storm surge that they review our SER.

18 And actually, it has resulted in us
19 actually strengthening the SER, a lot of what we
20 learned from the panel members in this instance we
21 actually incorporated into the SER itself. And so -
22 -

23 CHAIR CORRADINI: Can I ask you a
24 question since you opened the door?

25 DR. JONES: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 CHAIR CORRADINI: So is the standard
2 review plan in need of revising based on what you've
3 gone through?

4 DR. JONES: No. We have everything that
5 we need in the SER.

6 CHAIR CORRADINI: Okay. So it's more a
7 matter of the completeness of how you looked at what
8 was there based on your review.

9 DR. JONES: Yes, you bet. All right.

10 MS. GOVAN: Completeness and clarification,
11 right?

12 DR. JONES: Yes. Okay, what we have
13 here is going to be the three issues that were
14 raised. One was the staff's MCR breach flood
15 analysis was not conservative, and the Froehlich
16 equation was not applicable, you can read that.

17 The staff's NWS BREACH, the Manning
18 values, the comparison to the Martin cooling pond.
19 The use of the NWS BREACH model was inappropriate,
20 and the staff did not consider scouring, and you've
21 heard that from Dr. Ahn.

22 And the second one was the hurricane
23 storm surge and MCR embankment breach. There
24 actually was a part where can you actually have a
25 breach of the MCR caused by storm surge, and also

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 was the NWS 23 scenarios conservative, and the
2 review of the ADCIRC model.

3 And finally, the SER, did it improperly
4 identify the maximum groundwater level, was there a
5 need for a DCD departure. And so now I'm going to
6 turn this over to Dr. Rajiv to deal with Issue 1.

7 DR. PRASAD: Good morning. My name is
8 Rajiv Prasad, and I am from PNNL as stated
9 previously. We are a contractor to the NRC for
10 performing the STP surface water and groundwater
11 reviews for the FSAR.

12 As stated before, the NRC contracted six
13 independent experts. Let's move to the next slide.

14 They contracted six independent experts to review
15 the staff's SER, the applicant's Final Safety
16 Analysis Report, and the NCP issues. Three of these
17 experts reviewed the documents related to NCP Issue
18 Number 1, which is related to the dam breach
19 described in SER Section 2.4.4.

20 Just a brief introduction about these
21 experts. Mr. Tony Wahl is a hydraulic engineer at
22 the Bureau of Reclamation. He is an expert in the
23 canal and embankment breach research. His research
24 includes uncertainty in prediction of embankment
25 breach parameters, examination of the empirical

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 methods and numerical models to predict embankment
2 breach parameters, characterization of erodibility
3 of cohesive soils, stability of the spillway
4 channels, and headcut erosions in spillway channels.

5 Expert Number 2, Dr. Baecher is a
6 professor of civil engineering at the University of
7 Maryland. He works primarily on the assessment and
8 management of risks associated with water resources
9 infrastructure, flood and coastal protection, and
10 dam safety. He's the author of four books on risk,
11 safety, and protection to civil infrastructure, and
12 is a member of the U.S. National Academy of
13 Engineering.

14 Mr. Robert Patev is a
15 regional technical specialist in the North Atlantic
16 Division of the Army Corps of Engineers New England
17 District. He is an expert in probabilistic
18 evaluation of potential loadings from hurricanes,
19 reliability analysis of hurricane protection,
20 assessment of economic and loss-of-life consequences
21 due to possible failures, and systematic integration
22 of these factors into risk assessments.

23 Three experts listed as Item Number 2
24 reviewed NCP Issue Number 2 related to the PMH storm
25 surge. Dr. Jennifer Irish is an expert in the
coastal physics response due to extreme events like

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 hurricanes. Dr. Irish has expertise in storm surge
2 dynamics, storm morphodynamics, vegetative effects,
3 coastal hazard risk assessment, and coastal
4 engineering.

5 Dr. Irish has 28 papers in peer review
6 journals, and more than 30 publications in
7 professional conferences. Dr. Irish currently leads
8 research on hurricane storm surge parameterization;
9 extreme-value and forecast statistics; vegetation,
10 breach and barrier interactions and responses to
11 storms; and impacts of climate change on coastal
12 flooding and damages.

13 Expert Number 2, Dr. Luettich, serves as
14 the director University of North Carolina's
15 Institute of Marine Sciences, and as a director of
16 UNC Center for Natural Hazards and Disasters. He is
17 the lead PI on the Department of Homeland Security
18 Center for Excellence in Natural Disasters, Coastal
19 Infrastructure and Emergency Management.

20 He is one of the principal developers of
21 the ADCIRC model and has overseen ADCIRC's
22 applications, both in hindcasts and forecast modes
23 to storm surge and inundation scenarios.

24 Expert Number 3, Dr. Resio is a
25 professor of ocean engineering and the director of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 the Taylor Engineering Research Institute at the
2 University of North Florida. Previously, Dr. Resio
3 served as the senior technologist for the U.S. Army
4 Corps of Engineers Coastal and Hydraulics Lab from
5 1994 to 2011.

6 He served as a co-leader of the post
7 Katrina interagency forensics study, and
8 subsequently became the leader of the risk analysis
9 team for the South Louisiana Hurricane Protection
10 Project. He has been developing a new technical
11 approach for hurricane risk assessment now being
12 used along all U.S. coastlines. His new approach is
13 also being extended by the NRC for new licensing
14 guidelines at coastal sites. Next slide, please.

15 Now I will describe the resolution of
16 the first NCP issue related to SER Section 2.4.4.
17 The applicant's analysis of the MCR embankment
18 breach is described in FSAR Section 2.4S.4. The
19 staff performed an independent review and evaluated
20 the empirical methods and physically based modeling
21 used by the applicant.

22 The staff's independent review included
23 confirmatory analysis, that for independent, and
24 employed both empirical methods as well as
25 physically based approaches. One of the specific

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 NCP criticisms of the applicant's selection of the
2 Froehlich empirical equation and the staff's
3 independent review and acceptance of this approach,
4 was that the Froehlich equation is not applicable to
5 breach widths exceeding 164 feet.

6 The independent review by the experts
7 concluded that Froehlich equation is indeed
8 applicable to breach widths exceeding 164 feet. The
9 independent review also concluded that Froehlich
10 equation's breach width prediction has less
11 uncertainty compared to other approaches.

12 This was one of the issues also raised
13 by Dr. Ahn in his presentation earlier. The
14 independent review also stated that Froehlich
15 equation is the most appropriate for estimation of
16 the peak discharges from a dam breach.

17 MEMBER BLEY: Can you tell us, or are
18 you going to come to it later, that the best fit
19 equation, Mr. Prasad --

20 DR. PRASAD: Yes.

21 MEMBER BLEY: -- how the uncertainty is
22 accounted for in your analyses?

23 DR. PRASAD: Well, the way we use the
24 empirical equation is to get at an estimated breach
25 width.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER BLEY: Right.

2 DR. PRASAD: Then what we do is, the
3 guidelines call for us to use the best method and
4 these are all deterministic, and then try to look at
5 what margins would be available.

6 The margins come from our sensitivity
7 analysis that we conducted on top of the best case
8 scenario. That best case scenario began in the
9 staff's independent assessment. The first thing we
10 did was to look at if the empirical equations and
11 the predictions from those were acceptable or not,
12 and if the approach would be okay. So we verified
13 that.

14 And then in our independent confirmation
15 we actually used the breach, NWS BREACH model to
16 look at sensitivity of the breach parameters, and
17 try to look at how sensitive these estimations of
18 the breach parameters are, which ultimately lead to
19 the design basis flood estimation which is the
20 quantity we want --

21 MEMBER BLEY: Since you start with the
22 best fit equation that has uncertainty, there's
23 uncertainty in the data around that, you never quite
24 account for that or try to bound it or account for,
25 you know, how far away from that best estimate fit

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 the data are. So I just don't quite understand why
2 not.

3 CHAIR CORRADINI: Can I ask Dennis's
4 question differently?

5 MEMBER BLEY: Yes.

6 CHAIR CORRADINI: Is the Froehlich model
7 or the MLM model a best estimate fit or some sort of
8 bound on it? Because the breach calculation is
9 always lower. In other words, going back to Slide
10 12 of the applicant's presentation, the red line is
11 substantially below the blue bump.

12 That tells me that the blue bump with
13 the fit is inherently conservative compared to what
14 I would compute based on some more complex model
15 where I could run the numbers and crank through the
16 what-ifs about the various model parameters. And
17 instead of getting one red line I would get a range
18 of red lines to address Dennis's issue. Am I off
19 base?

20 DR. PRASAD: Let me answer it this way.

21 CHAIR CORRADINI: Feel free.

22 DR. PRASAD: Thank you.

23 MEMBER BLEY: But before you do, just
24 one last thing. If you start with the best fit
25 experience data, you know, you haven't seen all the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 experience, so further data, some of it, will be
2 well within the bounds we've already seen and some
3 are going to be outside of that.

4 So you need some way to account for the
5 spread in the data that's already there and for what
6 we might not have seen as yet, so from that point go
7 ahead.

8 DR. PRASAD: Right. Okay, so you have
9 historical cases where they have, dams have
10 breached. So you have parameters that could be
11 ascertained or estimated the best that you can tell.

12 There's the Dam Safety Office database that lists
13 these parameters. And those parameters are
14 basically what are used by these different empirical
15 equations to come up with a predictive equation.

16 If you look in the literature, what has
17 happened when the individual investigators were
18 developing these equations was that they were
19 purposely biasing those equations. They were not
20 using the best fit, they were purposely biasing
21 these equations to actually end up on the higher
22 side of the scatter, not on the lower side.

23 That was one thing that the
24 investigators intentionally did to account for some
25 of the uncertainty. They always knew that based on

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 only those measured predictive values and just one
2 or two independent parameters that you want to base
3 your empirical equations on, that there is going to
4 be a lot more factors, like for example,
5 construction of the dam, the detailed soil, what
6 soil conditions are there, site specific scenarios,
7 like do you have conditions that are more amenable
8 to piping and stuff like that.

9 Those are not explicitly accounted for
10 by the independent variables in those equations. So
11 they always taught that any time they come up with
12 an equation, a predictive equation that should be
13 applied in practice, that they bias it on the higher
14 side.

15 MEMBER BLEY: Now does that apply to the
16 Froehlich equation?

17 DR. PRASAD: That applies to all of the
18 equations.

19 MEMBER BLEY: So the plat that we saw
20 that shows that as the best fit inside all the data
21 isn't actually the Froehlich equation?

22 DR. PRASAD: I don't know how that
23 equation was, how Dr. Ahn created that slide I'm not
24 aware of.

25 MEMBER BLEY: Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 DR. PRASAD: So I can't tell whether
2 that line that goes through, which is described as
3 the Froehlich equation, is actually the Froehlich
4 equation or not. But --

5 MEMBER BLEY: It's certainly about a
6 best fit to the --

7 DR. PRASAD: It looks like the scatter
8 is probably evenly distributed on either side, so I
9 tend with that assessment, yes. But what the
10 history tells us about development of these methods
11 is that they're biased towards the higher end. So
12 there is some account of the uncertainty, if you
13 will, or the bias towards the higher end in terms of
14 prediction.

15 Now let me go back and explain one more
16 thing. In terms of the uncertainty itself, the data
17 show a large amount of scatter. Now if you were to
18 say that I would like to use a bounding equation on
19 enveloping equation, what you're saying is that you
20 want to go in history and look at the worst case
21 scenario without actually accounting for all the
22 factors that contributed to that severe an event,
23 which may or may not be proof for your specific case
24 that you're applying it to.

25 So those are some of the things that we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 need to keep in mind. So when we apply these
2 equations there is an implicit understanding that
3 they're biased towards the higher end.

4 MEMBER ARMIJO: I'd like a couple of
5 questions. Is the Froehlich equation applied to all
6 kinds of dams whether it's a concrete dam or earth-
7 filled dam or a levy? Is it a general use or is it
8 unique to these kinds of things, dams such as the
9 cooling reservoir?

10 DR. HIBLER: My understanding is it's
11 generally.

12 MEMBER ARMIJO: Okay, that seems like it
13 would be hard to generalize with such different
14 structures. But the other thing is, the way the
15 independent analysis used the Froehlich equation,
16 did you use that same approach to predict what
17 actually happened with the Martin cooling pond, and
18 did you predict the breach with -- I'm just saying,
19 if the independent analysis said this is okay, then
20 did you validate it by saying, and it compares well
21 to the data when you use the equation our way?

22 DR. PRASAD: By independent analysis,
23 you mean the staff's independent analysis?

24 MEMBER ARMIJO: Well, either the staff's
25 independent analysis, but the independent review

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 didn't actually do any analysis, they just reviewed?

2 DR. PRASAD: My understanding is that
3 they did not do any additional analysis.

4 MEMBER ARMIJO: Okay, well, maybe --

5 DR. PRASAD: They looked at the analysis
6 that the staff presented and the NCP presented.

7 MEMBER ARMIJO: Yes.

8 MEMBER SCHULTZ: So your question, Sam's
9 question then, it focuses on the staff's analysis.

10 MEMBER ARMIJO: Yes.

11 DR. PRASAD: Okay.

12 DR. HIBLER: We didn't do a calibration
13 to the MCP.

14 DR. PRASAD: No. The way we used the
15 MCP case was when we were doing the analysis both
16 based on empirical equations as well as based on the
17 NWS BREACH physically based model, was we wanted to
18 know if these results that we were getting were
19 reasonable, were biased towards the higher end, or
20 whether we were for some reason underpredicting.

21 So one thing you do when you do
22 prediction is to go back in history and look at what
23 are the comparable cases that I can find and whether
24 there has been an instance where there is
25 significant difference between what we are seeing in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 our estimation versus what has already occurred.

2 So the Dam Safety database was actually
3 sorted based on specifically looking at a few
4 parameters of the storage reservoir itself, like for
5 volume and the head. And when you do that sorting,
6 we ended up with Martin cooling pond actually as the
7 only case that matched closely to the MCR.

8 Then we went back and looked at, at that
9 point we did not know what this Martin cooling pond
10 case was. We went back and looked at it, and lo and
11 behold, it's also an embankment constructed on
12 existing grade level which includes a cooling pond.

13 So it was pretty analogous to the way
14 the MCR behaves, but there are significant
15 differences between how the MCR was constructed
16 versus how the Martin cooling pond was constructed,
17 the way they fail, the materials in the embankment
18 they are completely different.

19 MEMBER ARMIJO: Yes, and that's what I'd
20 like to get understood, a little more detail on
21 exactly why those differences make it distinct.

22 DR. PRASAD: Right, and Dr. Ahn was also
23 showing in his slides, do you remember one slide
24 where the material embankments were mentioned, and
25 for the MCP it is sand and silt versus for the MCR

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 it is silt and clay. That's what he mentioned.
2 It's actually compacted clay, which is much more
3 cohesive and much more, well, less erodable I'd say.

4 CHAIR CORRADINI: Okay, thank you.

5 DR. PRASAD: So continuing with this
6 slide, I had already described the Froehlich we got
7 into question there. There's also this issue about
8 the Manning's n, and let me explain that a little
9 bit more in terms of what the staff's choices were
10 about Manning's n.

11 And a little bit of history at this
12 point is probably also important in the sense that
13 in the National Weather Service Breach model, which
14 is a physically based model, goes from a piping
15 initiation to collapse of that, both of that pipe,
16 collapse of that pipe with the overburden, and then
17 expanding that breach or growing that breach into a
18 regular trapezoidal section.

19 In NWS BREACH, what they do is they use
20 Manning's n in two different ways, and actually in
21 the input files there are two places where you
22 specify these Manning's n values. And these two are
23 meant to be two different Manning's n values to
24 control two different things.

25 One is the Manning's n value in the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 traditional way we understand it about channel
2 roughness. The other one is actually a surrogate
3 for the erodibility of the embankment material
4 itself.

5 And that Manning's n is actually the
6 recommendation in the breach manuals as well as in
7 literature is to pick a Manning's n value that fits
8 the bare earth medium, not to confuse it with the
9 channel flow properties.

10 CHAIR CORRADINI: Can you say that one
11 more time, please, for the uninitiated?

12 DR. PRASAD: Okay. Simply --

13 CHAIR CORRADINI: Simply's good.

14 DR. PRASAD: There are two Manning's n
15 values specified in the breach model. One is in the
16 traditional sense that we understand about the
17 channel roughness, the other one is a surrogate for
18 the erodibility of the soil.

19 The surrogate part is the value that is
20 responsible for most of the uncertainty in the
21 prediction or the sensitivity of the prediction of
22 breach parameters that you see. Now when we picked
23 our Manning's n values, we based it on the base case
24 that the applicant had started with, which is 0.05,
25 and then we went back and saw how NWS BREACH model

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 actually says you should estimate these parameters.

2 And when we did that we found that 0.05
3 was actually a very conservative value. We did a
4 sensitivity analysis on top of that both decreasing
5 that value and increasing that value. So if you
6 look in the SER there will be cases described with
7 Manning's n value at 0.025 going up to 0.075, plus
8 or minus 50 percent that we did.

9 MEMBER BLEY: And this is for the case
10 where it's used a surrogate?

11 DR. PRASAD: Yes. This is the Manning's
12 n value that is used as a surrogate. In all of
13 these instances, the Manning's n value that is for
14 the tailwater section is set at 0.06, still pretty
15 conservative in terms of what you would see in terms
16 of the channel roughness with the littering and
17 effects going on once the dam breaches and then the
18 material falls out.

19 MEMBER SCHULTZ: So in the two
20 applications, from what you've just said, there's
21 not a wide range of variability on the Manning's n
22 value, even though you need to select one for one
23 piece of the application and another for the other?

24 DR. PRASAD: Yes. With the
25 understanding that these values that we use for the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 erodibility part of it are very, very conservative.

2 That was actually demonstrated by Mr. Wahl in his
3 independent review.

4 MEMBER SCHULTZ: The values that the
5 staff has selected.

6 DR. PRASAD: That the staff has
7 selected. That the applicant selected to begin with
8 at 0.05, and the staff ran a sensitivity analysis
9 reducing and increasing that value.

10 MEMBER SCHULTZ: Was it intentional to
11 select it as very conservative or did it just turn
12 out in review that it was very conservative? Were
13 two values selected? That's my first question.

14 DR. PRASAD: It turned out to be
15 conservative in review.

16 MEMBER SCHULTZ: Okay. All right.

17 DR. PRASAD: So when we did our reviews

18 --

19 MEMBER SCHULTZ: Value was selected.

20 DR. PRASAD: Right.

21 MEMBER SCHULTZ: They were. There were
22 two different values that were used for these two --

23 DR. PRASAD: There were two different
24 values selected for independent analysis.

25 MEMBER SCHULTZ: -- approaches.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 DR. PRASAD: And they turned out to be
2 pretty conservative.

3 MEMBER ARMIJO: What is the physical
4 reason that justifies your statement that 0.075 is
5 not credible under Item C?

6 DR. PRASAD: That actually comes from --

7 DR. HIBLER: The independent reviewers,
8 that's consistent with what the independent
9 reviewers stated as well. Based on the
10 documentation and the NWS BREACH description of that
11 parameter, 0.075 is huge. It should be, you know,
12 half that value or something like that.

13 CHAIR CORRADINI: But I think what Sam's
14 after is --

15 MEMBER ARMIJO: A physical reason.

16 CHAIR CORRADINI: Yes.

17 DR. PRASAD: Well, the physical reason
18 is that, remember, these are roughness values. And
19 roughness to flow is determined by what material you
20 have over which the flow takes place. The bigger
21 the material, the higher the resistance to flow.

22 So basically if you look in the dam
23 breach manuals and the literature, there's a
24 surrogate to grain size, of medium grain size, and
25 the Manning's n value. The bigger the medium grain

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 size, the bigger the Manning's n value because you
2 expect the water to be resisted more by these bigger
3 blocks of material. MEMBER ARMIJO: But Dr.
4 Ahn, in his review he said that, you know, you have
5 this concrete soil material on the liner or whatever
6 that is, and when that breaks up it goes through the
7 breach and that's going to make it, you have to take
8 that into consideration.

9 DR. PRASAD: Sure. But that is the part
10 where we specify Manning's n in the second part with
11 the traditional channel roughness part of it.
12 That's not the erodibility part of it. The
13 erodibility part is based mainly on, I keep calling
14 it a surrogate, which is to say that we need to get
15 some measure of the stresses that are impacted on
16 those soil materials to erode them away to make the
17 opening.

18 MEMBER SHACK: I'm looking at Wahl's
19 report, and he's getting these values from what he
20 calls the Strickler equation. And now are those the
21 erodibility values?

22 DR. PRASAD: Those are the erodibility
23 values, yes.

24 MEMBER SHACK: Okay, so when he says of
25 then, of 0.04, he's talking about boulder size

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 range.

2 DR. PRASAD: That is correct.

3 MALE PARTICIPANT: Three-foot chunks.

4 CHAIR CORRADINI: This is basically
5 you're taking an erosion, at least if I understand
6 this correctly, you're taking an erosion value or
7 you're trying to estimate an erosion based on some
8 roughness value of an eroding pipe with some length
9 scale that gives you a roughness.

10 DR. PRASAD: Right. You're trying to
11 figure out if that pipe, what are the stresses --

12 CHAIR CORRADINI: On an eroding channel,
13 I should say, excuse me.

14 DR. PRASAD: Right. On that note,
15 beginning with the pipe then going into a channel,
16 what is the stresses that would be impacted on those
17 particles to basically detach them from the physical
18 embankment and move them away?

19 So that is where this notion of
20 erodibility of the embankment medium grain size
21 comes into the picture and not the boulders that are
22 actually obstructing the flow. So those are two
23 physically different concepts.

24 DR. HIBLER: Some of the standard
25 engineering practices, too, have a Manning's n be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 set as a sum of different ends of the flow features
2 or environmental features, the first part would be
3 on the grain size. How rough is the soil that the
4 flow is occurring over, and then you would add on to
5 that different terms to account for vegetation,
6 buildings, tortuosity of the channel and so on.

7 In the first case that Rajiv was talking
8 about where erodibility is concerned, that summation
9 is cut off after the first term. But when you go
10 downstream, those other terms come into play and
11 that's why there's two different values used.

12 MEMBER SHACK: And that's why it's as
13 high as 0.06 then in the tailwater is that I'm
14 talking about trees and --

15 DR. PRASAD: Yes, basically big lots of
16 say the soil cement that would come out and would
17 line the tailwater section as the flow moves out.
18 So that's the channel bottom which is going to be,
19 you have a specified Manning's n for that in the
20 breach model itself.

21 MEMBER SHACK: But I have a hard time
22 understanding why in the erodibility a large value
23 of n is conservative. I would have thought that the
24 erodibility thing, small would have been the
25 conservative way. It would erode faster.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 DR. PRASAD: Yes, I think Mr. Wahl also
2 touched on that point in his report a little bit.
3 It goes back to the stress equation that he used in
4 the NWS BREACH and how the model was set up. And
5 it's a non-linear equation and --

6 MEMBER SHACK: It's counterintuitive to
7 me.

8 DR. PRASAD: Yes. But the way the
9 equation is set up, there are multiple factors that
10 effect how that stress would come out based on how
11 you specify your Manning's n value. But that's the
12 effect you see.

13 And when you end up increasing these
14 Manning's n values, which is the erodibility part in
15 the NWS BREACH, you start seeing these embankments
16 that really lose their strength, metaphorically
17 speaking, very quickly, and then the breach sort of
18 exponentially goes as the increase of Manning's n
19 values.

20 So that's the sensitivity part that
21 you're seeing in the breach analysis. But going
22 back to the recommendation that it is actually the
23 medium grain size that you should be basing these
24 on, because that's where the stress is coming from
25 that detach those particles, that Manning's n values

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 of 0.05 is very conservative, 0.075 is not credible
2 and actually should have been in the region of about
3 0.025 to 0.04.

4 But there's also this relationship that
5 if you don't change anything and just reduce those
6 Manning's n values down, then the flow coming out
7 from NWS BREACH becomes smaller and the breach
8 becomes smaller also.

9 So in our review, the objective was to
10 basically figure out if the applicant's analysis was
11 conservative enough. And in our review we found
12 that when once we factored in all of these things,
13 that although we may not agree that that Manning's n
14 value presents the medium grain size of the
15 embankment that it is giving us a value that is
16 conservative.

17 And that's where our review stops,
18 saying that even if you pick a Manning's n value of
19 0.075 the breach width that we get is pretty
20 comparable to what they got. We got our free flow
21 not quite going up to what they did. I think they
22 were at about 130,000 cfs, and our report indicated
23 it was about 127,000 cfs. That's at Manning's n
24 value of 0.075.

25 And from that point on it was pretty

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 clear that we could not get the flow and the width
2 to go any bigger in a conservative sense. So only
3 review part after that was to basically see how you
4 specify this outflow coming out of the embankment
5 breach into a two-dimensional model which spreads it
6 out near the stipulated structures that we are
7 concerned about and how high the water gets.

8 MEMBER SHACK: Okay.

9 MEMBER SCHULTZ: Before we leave that
10 slide, can you help me resolve the statements b and
11 c, where b says it would have been useful to examine
12 the n value of 0.075 and c says 0.075 is not
13 credible?

14 DR. PRASAD: Right. This is about the
15 tailwater section. One of the things that you see
16 is the breach becomes larger and larger as you raise
17 your Manning's n value up. Our sensitivity analysis
18 began with basically its value of 0.05 for the
19 Manning's n. Now eventually to get to
20 the water surface elevation at the SSCs, we used
21 the scenario from NWS BREACH which had a Manning's n
22 value of 0.075, although the sensitivity analysis
23 for the tailwater section was done at 0.05.

24 Our position is that 0.05 being an
25 extremely conservative value for Manning's n that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 there is no reason to believe that you need to do a
2 tailwater sensitivity analysis at 0.075 which is not
3 a credible value.

4 So we did our sensitivity analysis of
5 the tailwater section at 0.05, and what that
6 demonstrated was that in NWS BREACH it's specified
7 the biggest section that you think the tailwater is
8 going to attain.

9 CHAIR CORRADINI: Tailwater is the last
10 bit of water out?

11 DR. PRASAD: Well, it's a cross section.
12 It's a cross section the way it is set up in -- do
13 you want to take that one?

14 DR. HIBLER: Sure. Downstream of the
15 breach the shape of the topography needs to be
16 specified, and the shape of that topography can
17 influence --

18 CHAIR CORRADINI: Oh, okay. Got it.
19 Thank you.

20 MEMBER SCHULTZ: I have it, thank you.

21 MEMBER SHACK: Now where do you hand
22 this off to the flooding model?

23 MEMBER ARMIJO: We get water out of
24 there.

25 DR. HIBLER: A breach simulation yields

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 discharge outflow from the breach as a function of
2 time, and that's a boundary condition to the RMA-2
3 model that --

4 MEMBER SHACK: Yes, but the tailwater
5 somehow, that's what I'm sort of looking at is that
6 if you take the, you know, changing that tailwater
7 dimension, how does that impact the flooding
8 analysis that you're going to be doing --

9 CHAIR CORRADINI: That's the size of the
10 pipe you're going to tell it to flow out of, I
11 assume.

12 DR. HIBLER: We tell it that
13 discharge is a function of time and the 2-D flow
14 model determines the shape of that, the spreading of
15 that over the realistic topography, which is the --

16 MEMBER SHACK: So it's not really so
17 much the size of the tailwater as the overall flow
18 that really is the input to the flood model?

19 DR. HIBLER: Yes.

20 CHAIR CORRADINI: Oh, I thought you had
21 to give it both the area as well as the volumetric
22 flow. You just give it the volumetric flow rate.
23 We just give it the volumetric flow rate.

24 MEMBER SHACK: But the volumetric flow
25 rate is affected then by your tailwater geometry.

DR. HIBLER: Right. And in the case for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 the 2-D flow that tailwater concept is replaced with
2 realistic topography.

3 CHAIR CORRADINI: Got it. Okay, thank
4 you. Now you can go on.

5 DR. PRASAD: Okay, next slide. So our
6 independent review found that -- okay, one note
7 about NWS BREACH. It's an old model, but that it is
8 used in standard engineering practice for dam
9 breaches if you want to use a physically based
10 approach rather than an empirical approach.

11 So these models are, well, NWS BREACH is
12 the only model that is going to be available. The
13 Agricultural Research Service and the Bureau of
14 Reclamation are partnering with universities and
15 they are trying to develop new approaches, but
16 they're still in development phase and testing
17 phases.

18 There might be one new model that has
19 become recently available, like in the last month or
20 so, but that's not really used in standard
21 engineering practice. So for our analysis and
22 review we would limit that to using what is
23 available and used widely. That's one note.

24 Just a note about the scour hole. In
25 our review, we do not do at PNNL, as the NRC's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 contractor, any geotechnical review. That said,
2 there was this concern that we needed to understand
3 the geotechnical properties of the MCR and how that
4 related to breaching.

5 And so in that case what we have done,
6 awhile ago, I think this is from two or three years
7 ago, that we have contacted some of the NRC staff in
8 the geotechnical branch to get their opinion on what
9 they felt about the construction quality of the
10 embankment, how erosion could take place, what are
11 the strength properties.

12 You saw some of the cohesive strength
13 properties that Dr. Ahn was showing you his table
14 and those properties. And the NRC staff basically
15 came up with a determination that the foundation of
16 the embankment is compacted clay, which is not
17 really amenable to a deep scour hole formation.

18 If you look at the independent
19 reviewer's comments on the scour hole, it's also
20 clear that when they base their opinions on the soil
21 properties and the geotech properties of the
22 embankment, that they feel that even if it was
23 plausible that the scour hole was formulated it
24 would not be significant. It would not be
25 significant. It would not be significantly enough

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 to change any of the conclusions that we draw in the
2 SER.

3 MEMBER BLEY: It wouldn't change the
4 levels that you see over at the --

5 DR. PRASAD: If it's not significant I
6 wouldn't expect it to change much.

7 DR. HIBLER: I would just distinguish,
8 when they said significant they weren't saying
9 significant if there was a scour hole of the
10 dimensions that's been previously described. What
11 they say is the scouring depths would not be
12 significant. So it's probably less severe than what
13 you might be envisioning.

14 MEMBER BLEY: Now Dr. Ahn told us, and I
15 didn't go back and double check the reviewers, that
16 they base that on compaction data right after
17 construction and not what was found later. Can you
18 say anything about that?

19 DR. PRASAD: Well, honestly, I don't
20 know.

21 MEMBER BLEY: That seems like that could
22 be a significant point.

23 MS. GOVAN: We have someone coming up
24 from geotechnical who can address your question.

25 MEMBER BLEY: Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

(Off the record comments)

DR. CHOKSHI: I think we'll have one of our geotechnical engineer. Originally the staff -- he died, but you explained what the --

MALE PARTICIPANT: Are you going to resurrect him or something?

MS. KARAS: This is Becky Karas. I'm chief of the geosciences and geotechnical engineering area. We've had two reviewers on this project since the beginning. The geotechnical area is a distinct discipline and there's a lot of analyses that's looked at for the subsurface of the site in general.

We had two different reviewers on this project. One of them has recently retired subsequent to performing this review, Mr. Wayne Bieganousky who had 30, 35 years-plus experience between the Army Corps and the U.S. NRC. Frankie Vega of my staff has been following the review also since the beginning. I think he can talk a little bit about the parameters --

MR. VEGA: Hi, this is Frankie Vega. For the stability analysis that was provided in Section 2.5 of the FSAR, for cohesion properties, drain cohesion properties and of constructions, a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 300-pound per square feet was used.

2 MEMBER BLEY: 300?

3 MR. VEGA: 300, yes.

4 MEMBER BLEY: Not thousands.

5 MR. VEGA: Not 3,000, no. That's the
6 drain and of construction, a cohesion that was used
7 for the stability of that as a slope stability. And
8 for the MCR, a liquifaction analysis was done too,
9 based on these types of properties.

10 MEMBER BLEY: And you concluded based on
11 those parameters that scouring was not an issue?

12 MR. VEGA: We didn't look at scouring,
13 but we looked at the slope stability itself.

14 MEMBER BLEY: What about the question --

15 MR. VEGA: For scouring, it's important
16 to say that the foundation of the soil was prepared
17 in a way that the low strength soils were removed
18 and replaced by higher strength clays. I think that
19 wasn't mentioned before.

20 MEMBER BLEY: I think that the question
21 I had asked was, your expert reviewers, at least
22 according to Dr. Ahn, when they dismissed scouring,
23 did it based on compaction of 1,000 or more psi, and
24 would it have made a difference to them if they knew
25 that the compaction wasn't that great now?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. VEGA: I'm not familiar with that
2 conclusion.

3 MEMBER BLEY: Okay, thanks.

4 DR. PRASAD: Just one point. I think
5 the SER was available to the independent reviewers.
6 And in the SER we had mentioned, plus the
7 sensitivity analysis report that we did for NWS
8 BREACH, both used cohesive strength values of 300
9 pounds per square feet or less, and those were
10 available to the independent reviewers.

11 MEMBER BLEY: Okay, thanks.

12 DR. PRASAD: Okay, one more note I'd
13 like to make about scour. We did not consider, or
14 did not determine that the foundation beneath the
15 embankment itself would be amenable to scouring.
16 But as you get beyond the dam when the flow is
17 coming out, the native soils are still the
18 uncompacted soils on the side and it's possible that
19 there could be a scour hole formation there because
20 of these flows.

21 And that scour hole was initially
22 postulated by STP, and the staff reviewed it, and we
23 also took account for the fact that the material
24 coming out of that scour hole could get deposited
25 and could result in an elevation of the water

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 surface elevation at the safety related SSCs.

2 So that was one analysis where we did
3 consider the scour hole formation, and not only a
4 scour hole formation but the effects of that on the
5 safety related structures.

6 So with that note, the technical aspects
7 of NCP Issue Number 1 were resolved because the
8 staff's literature review determined that the
9 empirical equations were applicable to the MCR. The
10 staff's NWS-BREACH modeling did not suggest that
11 tailwater cross section was a dominant factor.

12 This was what we meant when we did our
13 sensitivity analysis in development of the
14 conservative breach parameters. The staff
15 determined that the applicant's Manning's n value is
16 reasonable and conservative.

17 The staff's search of the Dam Safety
18 Office database of historical dam failures showed
19 that Martin Cooling Pond failure was the closest,
20 and as it turned out only analog. And the staff
21 used NWS BREACH model because it is accepted in
22 standard engineering practice.

23 And the staff also determined that the
24 scour hole would not form directly below the MCR
25 embankment and its foundation, but there is the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 possibility it would have formed beyond the toe of
2 the embankment and we did account for that.

3 That concludes my presentation on Issue
4 Number 1. Dr. Jones will continue with Issue --

5 MEMBER SHACK: Well, let me just, both
6 the staff and the non-concurrents seem to ~~argue~~
7 ~~agree~~ that the Martin cooling pond supports their
8 case.

9 MEMBER ARMIJO: But they came to
10 different conclusions.

11 MEMBER SHACK: And they come to
12 different conclusions. Can PNNL and the staff sort
13 of explain why they think Martin cooling pond
14 supports their view?

15 DR. HIBLER: Well, for the two
16 parameters that were searched in the DSO, Dam Safety
17 Office database, they're similar in terms of the
18 volume of water that's assumed to spill, and the
19 difference between the pool elevation, initial pool
20 elevation, and the base of the breach. And only
21 those two parameters are the, at least in those two
22 parameters the Martin cooling pond and MCR are
23 similar.

24 That database wasn't searched or
25 developed to incorporate other factors. So if the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 focus is on other factors like construction methods,
2 materials and so on, those two cases are distinct.

3 MEMBER SHACK: Okay, so the answer seems
4 to be that there really is no comparison. I mean
5 it's the right height and volume but we don't know
6 anything about the rest of it.

7 DR. PRASAD: Yes. In any empirical
8 comparison you run into those issues. What are the
9 site-specific issues that we don't know about or are
10 different that are not accounted for in a, for
11 example, integration equation.

12 MEMBER ARMIJO: The cooling pond seems
13 to me just to be telling you that it's got a lower
14 head than the MCR, about the same area, similar
15 volume. It's built different. That's where the
16 explanation has to be, but we haven't heard it other
17 than, oh, it's built different.

18 I haven't heard any real good argument
19 that says the reason we won't have a wide breach is
20 because we have relief wells or we have this feature
21 or some other feature. I haven't heard any of that
22 except yes, it's different.

23 DR. PRASAD: Yes, I think I mentioned
24 that before. And actually, Dr. Ahn presented in his
25 table about the construction being silt and clay,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 really compacted clay for the MCR embankment was
2 this silt and sand, which are more less strong
3 cohesive soils and much more erodable soils.

4 So it's not surprising in our minds that
5 it would lead to a wider embankment breach even with
6 a lower head, and also because the soils, native
7 soils there are probably different than what the MCR
8 is, MCR foundation is with the compacted clay layer
9 that you see the scouring going through the
10 foundation.

11 MEMBER ARMIJO: So is the silt clay the
12 salvation of the MCR? Is that the main difference,
13 or is it, I don't even know what relief wells are.
14 Does that help, or does a sand core blanket, those
15 features, do they help? I'm looking for a really
16 good engineering argument that says this is why the
17 MCR is superior construction to the MCP.

18 DR. HIBLER: We reviewed the report that
19 South Florida Water Management District put forth
20 after the Martin cooling pond failure occurred, and
21 there's a couple things in there. I'm not a
22 geotechnical person, but what I pulled from there
23 was the Martin cooling pond embankment was newer and
24 therefore not as, didn't develop a history of
25 performance and corrective actions that other

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 structures might have had.

2 There were some filtering of water out
3 of the Martin cooling pond that were noted on the
4 SEP, and some corrective actions that were supposed
5 to have taken place that hadn't taken place at the
6 time of the failure.

7 Now I think that the active maintenance
8 of the main cooling reservoir with its existing
9 wells and drainage blankets make it a distinct case.

10 MEMBER SHACK: I mean one of the
11 reviewers quotes that some guy who reviewed the
12 failure and, you know, he does claim that it was
13 sand and silty sand for the Martin cooling pond.
14 Then they quote some laboratory test results that
15 get three orders of magnitude in head rate advance
16 and breach widening between clay type things and
17 silty soil type things.

18 MEMBER ARMIJO: Very, very strong
19 effect.

20 MEMBER SHACK: At least from the
21 laboratory tests it's a fairly significant effect,
22 and we do seem to have some confirmation that, in
23 fact, it is sand and silty sand from someone who's
24 knowledgeable of it.

25 DR. HINZE: You have to consider the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 start of the breach as well as the expansion of the
2 breach, and that the expansion of the breach is what
3 is really being of concern here, not the start. And
4 the silt and sandy is really going to be very
5 detrimental to the MCP.

6 CHAIR CORRADINI: So to get back to
7 Sam's original question, it is the construction or
8 it is the materials of construction is one major
9 factor, and the fact that as you were saying this
10 has, essentially, I don't want to call it relief
11 wells, but I call it seepage detection.

12 DR. HINZE: And it's also the subsurface
13 that underlies the entire area. There's a lot more
14 sand in that area than there is in the MCR. That's
15 very critical.

16 CHAIR CORRADINI: Okay. Proceed.

17 DR. CHOKSHI: Before we go to the next,
18 may I make a comment?

19 CHAIR CORRADINI: Sure.

20 DR. CHOKSHI: This is Nilesh Chokshi
21 from the NRC. I just wanted to make sure that the
22 whole resolve on next slide is properly
23 characterized. We have gone through the whole non-
24 concurrence process and made a decision, and that is
25 the issue to our satisfaction. But it's not

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 resolved in the sense that non-concurring Dr. Ahn
2 agrees with what --

3 CHAIR CORRADINI: No.

4 DR. CHOKSHI: I just wanted to make it
5 clear.

6 CHAIR CORRADINI: Yes, we understand
7 that, right.

8 DR. CHOKSHI: And at this public meeting
9 I thought I'd better make it --

10 CHAIR CORRADINI: No, that's fine.
11 That's perfectly fine.

12 MS. GOVAN: And that'll be the same for
13 all of the --

14 CHAIR CORRADINI: Yes, for all the three
15 issues you're going to go over.

16 Go ahead.

17 DR. PRASAD: So that concludes Issue 1
18 presentation, and Dr. Jones will continue with Issue
19 Number 2.

20 DR. JONES: Okay, this is the Number 2,
21 hurricane storm surge and MCR embankment breach. I
22 think I can sum this up in many ways. The ADCIRC
23 model, when we first started, most of the
24 applicant's six years ago first used the 1-D and we
25 came out and said no, you need to use a 2-D. SLOSH

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 was made available by NOAA. We had the SLOSH, PNNL
2 did their analysis with SLOSH.

3 The best model out there was ADCIRC, but
4 it's, you know, very expensive to run. Many
5 simulations on that. But the applicant went beyond
6 what we called for. They actually went to using the
7 ADCIRC. They had an expert on the ADCIRC.

8 We had a second audit, actually, in
9 2009, in which we went down and they explained to us
10 in detail what they did. We gave them feedback. We
11 wanted them to use the ADCIRC, but we wanted them to
12 use the same met input from the NWS 23 that they
13 used in the staff's SLOSH, so that we can have a
14 comparison, so there wouldn't be any issues that we
15 had something different. And they ran that model.

16 But the unique thing was that they used
17 very proprietary, I guess, high, very high
18 resolution topography and bathymetry, which not only
19 that Dr. Resio didn't have for his ADCIRC model but
20 we didn't have our SLOSH model.

21 And if you know numerical modeling that
22 is critical, because if you don't see the feature
23 it's not there. So why you see the SLOSH model in
24 this case, even though it's a low resolution, it's a
25 warning model, it has the same output as the ADCIRC

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 model by Dr. Resio.

2 The only conclusion you can raise, and
3 then you see in their slides, especially when we had
4 the second audit, and also I have it in my back-up
5 slides, and you see that they have a, they can see
6 the levy which is there at Matagorda. And you can
7 see the rock piles. It's very clear.

8 And if something hits that, and that's
9 what Carla, I guess Hurricane Carla did. It hit
10 that levy back then and saved Matagorda. The
11 highest surge they had, it was 15 feet, the levy is
12 25 feet, blocked it. Never got over it.

13 So that is physically what happens.
14 That's what ADCIRC was designed to do, and that's
15 why it was used in the Katrina -- Dr. Lynett,
16 actually, though he does tsunami, actually does
17 surge too. They used that in the Katrina study, the
18 presidential study.

19 And you can see the resolution. You can
20 get down to only a few meters with ADCIRC and see
21 these features. And so the applicant by doing that
22 what they did, they wound up with 29 feet, which is
23 highly credible if you know you got the blockage
24 with the levy and stuff.

25 So what would happen if you didn't have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 the levy or the rock pile? Well, you would get that
2 39 feet that you have on the SLOSH and the Resio
3 ADCIRC. But what it proves though with Dr. Resio,
4 his research said that you get a peak.

5 Some areas where you can expand the
6 storm until you get to the point where you can't
7 expand it any more, you get no difference in your
8 surge. And you look at all his storms, 10 to the 8,
9 10 to the negative 13, probably -- this stops at
10 like 39 feet.

11 You don't get any higher, maybe 40 at
12 the most. Because what happens is that's your
13 fetch. A wave needs intensity, duration and fetch.

14 By expanding the storm wider you get a bigger
15 fetch. But after awhile you got it on, part of it's
16 on land, and you've got the outer barrier to the
17 point you're not getting any more fetch out of that.

18 Now to address Dr. Ahn about the 184,
19 basic meteorology. Delta p, isobar here, isobar
20 here. That's your delta p. If you move it wider
21 apart you get less wind because now you don't have
22 the gradient any more. Move it closer, you get
23 higher wind.

24 So in the case of the Resio ADCIRC and
25 also the case of the PNNL, they had actually wider,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 well, actually the applicant had a wider storm.
2 They actually used a wider storm than we did on the
3 staff. And Resio used a whole bunch of wider
4 storms.

5 But the thing it comes down to is that
6 bathymetry. Now 29 feet was 29 feet. That's one
7 foot above Katrina, which is the record for the
8 United States. What's 39 feet? That's one foot
9 below the world record which has only happened once,
10 in the Indian Ocean in the 1970s. Okay, that's what
11 you're talking about in rarity.

12 So conservatism, 29 feet, yes. That's
13 very conservative, one foot above what we have
14 recorded in Katrina. And he was talking about the
15 PMH. On one hand he said that it provides a
16 bounding, but on the other hand he says it's
17 questionable because it has been updated.

18 Well, the NWS 23 covers the period from
19 1871 to 1978. If you look at it, only 18.5 percent
20 of the storms occurred outside of that period. All
21 Category 4 hurricanes impacting Texas, they've never
22 seen a Category 5, and what the applicant had was a
23 Category 6 which doesn't exist. We don't have that
24 category.

25 And as it occurred within the NWS

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 reporting period, you heard the applicant report
2 that we had periods of peaks in the '70s and the
3 '40s. And so for the United States itself only 17
4 percent of all hurricanes that impacted the United
5 States occurred outside the NWS 23 reporting period,
6 and among the 12 most intense hurricanes to hit the
7 country, only three occurred outside of the NWS
8 reporting period.

9 Matter of fact, right now while we're
10 doing this review, and I have warned the applicants,
11 well, the operators, of this that we actually, in
12 most all cases the storm surge on the new reactors
13 exceeded the storm surge on the old operating
14 reactors.

15 You remember most of these were licensed
16 before '79, and NWS 23 came out in '79. So none of
17 these plants ever used NWS 23 for their design
18 basis. And they're finding it's very conservative
19 to the point that one has decided to go back and do
20 the probability storm surge and use the JPM.

21 MEMBER SHACK: Yes, but you've just
22 convinced me that NWS 23 doesn't give me anything
23 like a 10 to the minus 4 or 10 to the minus 5 storm.

24 DR. JONES: Well, actually, if you look
25 at Texas, you look at this case here. Here you have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 the SLOSH model by the staff, they got 39 feet.
2 Then you have Resio with his storms which actually
3 went up to 10 nega 13, and he had the same level.
4 So, you know, we've got the same conservatism, you
5 know, using NWS 23, and he used JPM method, the
6 joint probability method.

7 Or you could take the real database, the
8 most current database from NOAA, load it in, do your
9 Monte Carlo and you get simulated storms. And he
10 came up with the same thing. So it's always going
11 to be site by site difference. In some cases you'll
12 have --

13 MEMBER SHACK: No, but I mean he's
14 getting a different storm. He's picking up
15 something from something, I mean you can't guarantee
16 this is always going to work out that way.

17 DR. JONES: Exactly. If you go the
18 other way you actually in some cases, like they were
19 going to use ADCIRC until they actually find out
20 it's going to lower the surge which actually saved
21 them money. Went on to one applicant,
22 they said that at the beginning. They said they
23 would love to use ADCIRC because they were hoping
24 that it actually lowered the level. Sometimes it
25 might be a higher level, because it depends on what

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 feature it's going to see.

2 In the case of STP, the levy and the
3 rock pile --

4 MEMBER SHACK: But as you point out, I
5 mean ADCIRC's as good as your bathymetry.

6 DR. JONES: And that's all numerical
7 models.

8 MEMBER SHACK: Yes, that's true.

9 DR. JONES: But some have better
10 physics, and then ADCIRC has better physics than,
11 and NOAA admits that. Matter of fact, NOAA now uses
12 ADCIRC in conjunction with FEMA, okay. So NOAA
13 never objected to, they always admitted that the
14 SLOSH was only for warning purposes. You don't have
15 time to do detailed analysis when you have to
16 evacuate people.

17 ADCIRC is made for engineering purposes
18 for exactly what we're using it for, for design, and
19 that's what the applicant in this case used ADCIRC
20 to get precise detail to be precise. And actually
21 Reg Guide 1.59 says in it that the applicants can
22 use more detailed bathymetry and topography and get
23 a less conservative result.

24 We said that in the 1977 1.59, and it
25 said that, even then when we changed it we said we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 will accept less conservative results for more
2 realism. So that's part of our Regulatory Guidance.

3 Next, please.

4 DR. HINZE: How did you treat the
5 decrease in intensity over the land?

6 DR. JONES: Well, actually the applicant
7 was extreme in this. Not only did they have a 184
8 mile per hour storm, they didn't decay it.

9 DR. HINZE: Didn't decay it.

10 DR. JONES: They just hit it and just
11 kept going.

12 DR. HINZE: That's additional
13 conservatism piled onto this.

14 DR. JONES: Exactly. And so we found
15 that the independent reviewers, yes, they say, well,
16 maybe you could have used a larger storm which,
17 actually, applicant used a larger storm than the
18 staff. But when you took off the balance between
19 intensity, 184 miles per hour versus something
20 bigger, Dr. Resio says it was a wash. It was good.

21 It was sound. It was conservative. It was
22 acceptable analysis.

23 And so they suggested a review, perform
24 ADCIRC, but Dr. Resio did that. We incorporated
25 that into the SER, his results. Next, please.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER SHACK: Now the 184 is some ten-
2 minute average wind?

3 DR. JONES: Yes, at 30 feet.

4 MEMBER SHACK: Which is why it's lower
5 than the 210 gusts that you do --

6 DR. JONES: Oh, gusts. Yes, gusts is
7 different. Yes, and so it's sustained. It's
8 sustained. And they also did a stationary, fast,
9 and slow moving. And so another thing to -- the
10 bottom line is this. The applicant, back in the
11 2009 second audit said, we're going to do this.
12 We're not going to use our analysis, we're going to
13 use the staff's analysis to prove that nothing's
14 going to happen to the MCR.

15 They took our analysis, used our winds,
16 and then they said, we're going to go and do the
17 implausible. Because if you look at the storm that
18 produces the surge for all three scenarios, the wind
19 is out of the south. It goes over the MCR and blows
20 everything away from the MCR.

21 So there's no wave action, no current.
22 You're only talking about 11 feet of water, and
23 currents are not made instantaneously in the real
24 world. I mean the gulf stream is seven feet per
25 second and it takes a long time, days, hours, to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 generate currents at those speeds.

2 So there's a lot of conservatism. I
3 took the 184 miles per hour and used my
4 oceanographic experience and came up with everything
5 below what you can use to rate below clay. Never
6 made it to it. And that's assuming that you have
7 instantaneous currents. But you're never going to
8 get them because the winds are blowing physically
9 away from this area.

10 So anything that we break would be what,
11 the south side or on the east side, which would not
12 impact the plant at all. And you see my velocities
13 there, the equation I came up. And actually, even
14 on the MCR breach they came up with only, in 1.7
15 hours they only came up with six feet per second,
16 which was below the erodibility for clay in the
17 area, breach area. So if you're talking about
18 scour, you know, that falls within the range I had.

19 DR. HINZE: I'm just trying to connect
20 the dots between on Page 7G and H, and then what
21 you've just described on the following slide. Is
22 what you're describing in J and K the reanalysis
23 that the staff did in response to the applicant's
24 recommendations?

25 DR. JONES: Yes. What you did is you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 have, the literature you have, the Corps of
2 Engineers figures for what you can do to erode
3 compacted clay. And what you did is a bounding
4 analysis. You take the winds because that's what's
5 going to generate your currents. It doesn't matter
6 how deep it is. That's irrelevant.

7 You just take, say I assume that these
8 currents are going to exist from the surface, from
9 the top to 11 feet down, have 184 miles per hour.
10 What would be the surface period if it
11 instantaneously happened right there at the breach
12 which only lasts for, you know, 80 minutes, this
13 event.

14 And what you get there is a maximum
15 current of four feet per second, maybe five feet per
16 second. And that falls well within the literature
17 for not eroding compacted clay or grass line,
18 actually, for grass line. It wasn't affected at the
19 grass line. But remember, that's
20 assuming that it was aligned the way that you could
21 have erosion, and we know physically that is
22 implausible the way the hurricane is and the winds
23 that you're never going to get those currents or the
24 wave action, ever. It's not plausible.

25 Actually, to get those type of winds you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 actually had to push the surge back the other way.
2 So the bottom line is that they have a model that is
3 acceptable, that's a state-of-the-art. They used
4 the most, higher resolution than either the staff or
5 Dr. Resio.

6 That based on the literature that the
7 most likely difference is that the high resolution
8 that the ADCIRC model saw the levy at Matagorda, saw
9 the rock pile and was blocked. That you have 29
10 feet, which is equal to the MCR grade level, so
11 therefore that alone you're not going to have
12 erosion or simultaneous, the surge eroding MCR and
13 then have a combination of it breaking at that
14 point. It's one foot above Katrina. And
15 even with the staff's 39 feet there's all below the
16 MCR breach of 40, so there's no safety issue there.

17 Any questions on the Issue 2? Next.

18 And this is concerning the maximum
19 ground water level for the ABWR maximum ground water
20 level. DCD Tier 1 limit is two feet below the plant
21 grade. The non-concurrence states that the FSAR
22 site characteristic is 28 feet. This is correct.

23 The surface water departure was
24 implemented, not a ground water, but a surface water
25 departure was implemented for the two proposed units

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 in accordance with the DCD limit. A surface water
2 departure was required for the ABWR if the DBF is
3 shown to exist at a level equal to or higher than
4 one foot below plant grade, and that's of course at
5 40 feet it does that.

6 For the proposed units, the surface
7 water departure equated to 33 feet msl. The NRO
8 Division of Engineering evaluated it. They assumed
9 that these conditions, that the underground was
10 saturated at design basis flood. So they assumed
11 that that level was saturated, then on top of that
12 they put the water level for design basis flood, and
13 then they did their calculations for the
14 hydrodynamic/dynamic forces, then put it into their
15 seismic and other force design. And the
16 hydrodynamic forces were just very small compared to
17 everything else.

18 So they also evaluated the design basis
19 flood 40 and they said there were no deficiencies
20 noted. And in the summary, the non-concurrence
21 incorrectly puts the DCD term "maximum groundwater
22 level" in the wrong context, because the maximum
23 groundwater level is, you take in account all the
24 seasonal fluctuations, everything, and you get the
25 28 feet.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 The question is, could possibly a design
2 basis flood do something, but that was never
3 analyzed by either the staff or by him. That's a
4 design basis flood incident, and when they did the
5 safety analysis had no impact.

6 Well, I'll let Dr. Chokshi, if he wants
7 to add something to it.

8 DR. CHOKSHI: I'll wait for the
9 question.

10 DR. JONES: If there's a question.

11 DR. CHOKSHI: But maybe let me just, in
12 the DCD there are two water levels. The one is the
13 one that's called maximum groundwater level, and
14 there is a groundwater level associated with the
15 design basis flood.

16 The standard designs are not designed
17 for substrate flooding, so the basic of these two
18 cohorts, they're just conditioned that my design
19 basis flood is actually below ground level. So now
20 in the South Texas is you have to take a departure
21 because the design basis flood.

22 So any parameters that are associated
23 with a design basis floods are automatically, have
24 to consider is that a part of a departure. So you
25 don't need to separate departure for that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 groundwater level which is associated with the
2 design basis flood, because it automatically is a
3 part of the design basis flood.

4 That comes into the play, into the
5 engineering analysis. How do you combine my, if you
6 go to 3.8 sections, structural sections, they were
7 never designed, the load combinations associated
8 with the design basis flood. In that case is you
9 have to account for the ground saturation at all the
10 substrates, hydrostatic loads, et cetera. So
11 they're all accounted for.

12 So I think it's just a process issue. But I
13 think they are taking a departure.

14 DR. JONES: Okay. And the staff's, this
15 resolution, this is a summary. The staff's MCR
16 breach flood analysis is not conservative. As
17 discussed above, the technical issues were resolved.
18 Changes to the SER Section were made.

19 The staff added text to explain the
20 staff's review of the applicant's use of the
21 empirical methods, and the staff added text to
22 explain the tailwater sensitivity analysis. And the
23 staff's conclusions in SER Section 2.4.4 did not
24 change. So it didn't change our findings, but we
25 did add more detail.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 On Issue Number 2, a hurricane storm
2 surge and MCR embankment breach as discussed above,
3 they were resolved. We did make changes to Section
4 2.4.5 were made. The staff added text explaining
5 how the probable maximum hurricane is appropriately
6 conservative. Then we added, the staff added
7 sensitivity analysis used storms less intense but
8 larger than the probable maximum hurricane, and our
9 conclusions there did not change.

10 And in Item Number 3, management
11 concluded that all necessary departures had been
12 requested and there were no changes to the SER, and
13 there's no change to the staff's conclusion in the
14 SER Section 2.4.12. That's the end of my
15 discussion. Any questions?

16 CHAIR CORRADINI: Questions from the
17 committee? So we're at the end of this part of
18 Chapter 2 of 2.1 through 2.4. So any general
19 questions or comments from the committee?
20 Otherwise, I was going to turn to members of the
21 public either here or on the phone line, but if
22 there's something, go around the table. Bill?

23 DR. HINZE: Well, I stand by the details
24 and the conclusions I reached on my report to you.

25 CHAIR CORRADINI: Which we all have.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 DR. HINZE: I believe that the STP and
2 the staff have come up with very reasonable
3 parameters, and verging on being too conservative in
4 my view. One of the things that I think that we
5 have accomplished here is we've approved the
6 document with Dr. Ahn's NCP.

7 I think that one of the things that I
8 mentioned in the report that needs to be emphasized
9 is that the uncertainties in all these processes,
10 which have a great deal of uncertainty, were not
11 emphasized sufficiently and their impact was not
12 truly considered. And I think that that's a lesson
13 that we should take from this exercise.

14 CHAIR CORRADINI: Steve?

15 MEMBER SCHULTZ: I too appreciate the
16 discussions this morning. The applicants set the
17 stage, and I think Dr. Ahn has done an excellent job
18 of his presentation of the issues that he had
19 identified. And he's explained his concerns well to
20 the committee, just as to the staff's response and
21 the consultants they have used in preparing that
22 response have been very deliberate in their
23 reevaluation of the concerns that Dr. Ahn has
24 raised. And that the modifications to the SER have
25 been appropriately conducted and achieved.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 CHAIR CORRADINI: Dennis?

2 MEMBER BLEY: And I appreciated all the
3 discussion today and thought it was very helpful. I
4 have no real questions left except I need to pursue
5 a little on my own understanding how the uncertainty
6 was addressed in all of this. And I see conflicts
7 that I haven't been able to resolve yet, so I'm
8 going to have to dig into that a little.

9 CHAIR CORRADINI: Harold?

10 MR. RAY: Well, echoing what Bill and, I
11 guess, Dennis said here as well, I don't think it
12 should be a part of this applicant's review, but I
13 do think there ought to be some lessons learned
14 here. I don't know what they are or how exactly
15 we're going to try and derive them, but we shouldn't
16 go through this sort of an exercise only when
17 somebody raises an objection, as was done in this
18 case.

19 Even though the outcome affirms the
20 original conclusions, it's much sounder, I think,
21 than existed originally, and I'm therefore thinking
22 that there needs, I don't know whether we're talking
23 about input to the staff's review plan or Reg Guides
24 or what it is, but there's something that ought to
25 be learned from this it seems to me or derived from

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 this, not learned from it maybe, that provides us
2 the kind of review that we've gotten here now
3 without there having to have been this exercise take
4 place.

5 But like I say, it shouldn't become a
6 part of this application's review. It's something
7 we need to figure out how to do separately.

8 CHAIR CORRADINI: Sam?

9 MEMBER ARMIJO: Yes, I thought the
10 presentations were excellent both from the staff and
11 from Dr. Ahn. I do have one kind of summary
12 question is after all is said and done on the breach
13 issues, we wind up with the STP saying they're
14 designing or they'll, a flood level of 40 feet.

15 And Dr. Ahn's analyses of the various
16 analysis he did comes up with 44.6 feet, so a
17 difference of about five feet. And my question is
18 to the staff and to the applicant is, is that the
19 end of the world? I mean it really was 45 feet
20 instead of 40 feet.

21 DR. JONES: Well, 40 feet is what they
22 came up with, but we heard this morning -- and
23 someone correct me -- that they said that they're
24 going to have it waterproofed to a height of 51
25 feet.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER ARMIJO: They've just got plenty
2 of margin.

3 DR. JONES: Exactly.

4 MEMBER ARMIJO: But basically I
5 appreciated this presentation. Plowing through this
6 stuff, I think I learned a little bit, but I think I
7 didn't hear enough of in was that the engineering of
8 this MCR is a very different structure than the
9 Martin cooling pond.

10 And with some discussion of that I think
11 it would have been put to bed a lot easier, because
12 it looks like it's a very detailed engineered
13 structure and the pond was pretty much a pile of
14 dirt. And so it's not as good an example as it
15 appeared to be when you first read about it.

16 DR. JONES: Made for two different
17 purposes.

18 MEMBER ARMIJO: Yes. Thank you.

19 CHAIR CORRADINI: Mike?

20 MR. HEAD: Mr. Chairman, can I interject
21 just for a second, please?

22 CHAIR CORRADINI: Well, I was going to
23 call on you eventually, but feel free to interject
24 now to help --

25 MR. HEAD: He was at this point, and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 then since I raised it I feel like I have to -- the
2 40 feet --

3 CHAIR CORRADINI: And you are?

4 MR. HEAD: I'm Scott Head, okay.

5 CHAIR CORRADINI: Still.

6 MR. HEAD: The 40 feet is a design basis
7 number used in design basis calculations. The 51
8 feet is a flood elevation and has not been used in
9 the design basis calculation. So there is a
10 difference. It's subtle, but I think it's worth
11 knowing that we're not changing the design basis to
12 51 feet, okay. We're leaving it at 40 feet, and
13 believe that that's what it should be. But we've
14 been able, by selecting doors, in essence, raise the
15 inundation level to 51 feet.

16 MEMBER ARMIJO: Which is really the main
17 objective was to keep --

18 MR. HEAD: Well, it's certainly, in
19 light of recent events it is important.

20 MEMBER ARMIJO: Yes.

21 CHAIR CORRADINI: Well, thank you, sir.

22 I thought you had something else you were going to
23 --

24 MR. HEAD: No, that's --

25 CHAIR CORRADINI: This is -- okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER RYAN: No additional comments,
2 thank you.

3 CHAIR CORRADINI: Dr. Shack?

4 MEMBER SHACK: Well, these processes are
5 always very enlightening. You get a chance to read
6 a lot of things that are very interesting. I concur
7 with Bill. I think, you know, that there's a great
8 deal of uncertainty here that sort of is not treated
9 very well, and I'm not sure that piling conservatism
10 upon conservatism at every correlation that you use
11 is the answer.

12 But you do have to have some better
13 appreciation that, okay, you used the best fit for
14 the width. You used the conservative one for the
15 top line. You can use the conservative estimate for
16 the tailwater, and what do I really end up with?
17 And it's, you know, you're left with a little bit
18 of, it takes almost engineering judgment to decide
19 that you've really done it. And a little better
20 treatment of that and a few more sensitivity
21 studies, I think, would be helpful in putting some
22 of these things to rest.

23 But as I said, very interesting reading.
24 I'm just glad to see too that people sort of pushed
25 them out there to do some probabilistic hurricane

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 studies. I mean that NUREG was sitting there, and
2 there it was. Just when you needed it there was an
3 ADCIRC calculation 10 to the minus 13. Good for
4 research.

5 DR. JONES: That goes back to what Dr.
6 Ray was saying. We actually are addressing this.
7 We have the probabilistic hydrology workshop to
8 address the ACRS concerns to try to update in the
9 ISG that you saw, the tsunami surge.

10 We went over probabilistic and
11 uncertainties, Dr. Resio, and also, and this was
12 very helpful, I think, for the dam failure part of
13 the ongoing 50.54. I think if we hadn't have had
14 this, then I don't think we would have been as
15 prepared to deal with the issues for that. So this
16 was very helpful.

17 CHAIR CORRADINI: So before I end this,
18 are there members, people in the audience that have
19 comments?

20 DR. CHOKSHI: Dr. Corradini, may I?

21 CHAIR CORRADINI: Oh, I'm sorry.

22 DR. CHOKSHI: This is Nilesh Chokshi
23 again. I think, first of all, I think I want to say
24 that this process, I think, you know, the issues of
25 this by Dr. Ahn, I think they were significant

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 issues, and that was one of the reasons why we
2 thought we need a -- a lot of judgments are involved
3 in this process.

4 So that way we wanted also an
5 independent set of five to look at this because it
6 comes down to, you know, every step you can add
7 things, but is that appropriate? The second thing I
8 think that this may be enhanced and I think they can
9 still enhance the basis of our, you know, the
10 decisions. We will better explain to you

11 In fact, what we're having versus
12 developing the ISG for the dam analysis, and I think
13 Dr. Ahn mentioned that there is a need for guidance
14 in this area because it's in the process, and I
15 think from what I heard, and that question about
16 uncertainty -- and I think, thinking about this,
17 you've all done a good job explaining how the
18 uncertainties are there, you know, accounted for.
19 So I think we are doing, and I think this is all
20 very useful, and that this is helping us in coming
21 up with ISG which will be used for the 2.1.

22 It is a significant issues, and I think
23 we have to do it in a proper way. I don't think,
24 you know, very thoughtful because it's the way,
25 because there's so much judgment and other things

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 involved. So I think the comments I've heard, I
2 think it's pretty much along the line we are we are
3 also thinking, and I think the are the issues we
4 need to address. So thank you.

5 MEMBER SCHULTZ: Excuse me, Mike.
6 Nilesh, can you explain the schedule associated with
7 that effort in 2.1, when we'll have a chance to see
8 that?

9 DR. CHOKSHI: Yes, actually I'll let
10 Chris Cook explain more detail.

11 MR. COOK: Hi, I'm Christopher Cook.
12 I'm chief of the hydrology and meteorology branch.
13 The Interim Staff Guidance on the dam assessment
14 should have gone out into the Federal Register this
15 week for a comment period that will be going through
16 --

17 (Simultaneous speaking.)

18 MR. COOK: So approximately just a
19 little bit under 30 days as we had targeted, so it's
20 up there now.

21 For the public comment period, we're
22 going to be having a public meeting on May the 2nd.
23 We're also then, also having other meetings with
24 the Interagency Committee on Dam Safety, at the
25 federal level, talking to our federal partners and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 what have you, I believe that fell on the 9th, to
2 discuss the ISG with the different methods that were
3 used at looking at both dam failure as well as
4 routing of the flood wave once it leaves. So that's
5 all incorporated into the ISG. Like I said, it's
6 out for comment now.

7 CHAIR CORRADINI: Okay. Any other
8 comments from folks in the room? The bridge line
9 should be open. Are there comments from those
10 listening in? I think it's been unmuted. Is
11 anybody out there making noise?

12 MALE PARTICIPANT: I'm out here but I
13 have no questions.

14 CHAIR CORRADINI: All right. So let me
15 conclude by thanking the staff and the applicant. I
16 guess there's a few things, a couple of them generic
17 and one specific, I guess, that I wanted. So I
18 wanted to thank everybody for their contributions,
19 Dr. Ahn for taking the time to explain his issues,
20 and the staff for explaining how they resolved it
21 relative to the other staff conclusions as well as
22 the independent reviewers.

23 But I had three things. One is, I think
24 that Bill said it and Harold emphasized it, is that
25 if there's a lesson learned here relative to explain

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 the uncertainties or in the standard review plan in
2 this sort of area of review, I guess we'd like to
3 know about it so that we don't necessarily do this
4 every time. So that's kind of takeaway 1. Don't
5 write it down as an action item, anybody, but I
6 assume the staff will remember this because we won't
7 forget it.

8 The second thing is that I do think it's
9 important that we understand, at least in this area
10 I'm technically, I was going to use the word "at the
11 mercy," but I guess it's good to be at the mercy of
12 the consultant. But I listen to Bill a lot because
13 he's very expert in this area.

14 But I do think there is one thing that
15 I'd like to see, and I asked Quynh about this. I
16 think there is probably an RAI, it kind of goes to
17 Slide Number 12 of the applicant. I'm sure there's
18 an RAI where the breach model with one calculation
19 in the red is there, but I assume there's a series
20 of them. I'll call them sensitivity studies, so I
21 can see the spread of how the prediction looks as a
22 function of that.

23 I think that would address a lot of the
24 questions that, or at least some of the questions,
25 potentially, that Dennis was asking about what-ifs,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 and how those what-ifs relative to the detailed
2 model span out and kind of interact with what I
3 thought was the conservative blue line on top. All
4 right.

5 But I think it kind of goes back again
6 to the generic issues that we're always asking for,
7 what are the uncertainties and what drives the
8 calculation that we eventually have to make a
9 judgment on. So I think if the applicant or the
10 staff could point Quynh to the specific RAI, maybe
11 the committee can have that in the back of our
12 pockets just so we can look at it. That might help
13 Dennis.

14 With that though, I thank everybody, and
15 unless there's more questions we're adjourned.

16 (Whereupon, the foregoing matter went
17 off the record at 11:59 a.m.)
18
19
20
21
22
23
24
25

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1
2
3
4
5
6
7
8
9
10
11
12

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701


(202) 234-4433

www.nealrgross.com

South Texas Project Units 3&4

Presentation to ACRS ABWR Subcommittee:

Chapter 2 Site Characteristics



Agenda

- Introduction and Agenda
- Attendees
- Topics for Discussion:
 - COLA Changes since 11/30/2010 ACRS Meeting
 - ACRS Action Item 65
- Comments and Questions

Attendees

Scott Head	Manager, Regulatory Affairs, STP 3&4
Steve Thomas	Manager, Engineering, STP 3&4
Dick Bense	Regulatory Affairs, STP 3&4
Dr. Bob Bailey	Exponent Engineering and Scientific Consulting
Dr. Paul Jensen	Atkins Global

Chapter 2 Site Description – Summary

South Texas Project site is located near the Gulf of Mexico:



- Large site, 12,200 acres
- Main Cooling Reservoir sized for four units, 7000 acres
- Infrastructure in place
 - ✓ Road and barge access
 - ✓ Transmission corridor
- Low population density nearby
- Existing State, County and Site Emergency Plans
- Strong community support

COLA Changes since 11/30/2010 ACRS Meeting

Regulatory Guide 1.221, "Design-Basis Hurricane and Hurricane Missiles for Nuclear Power Plants," Rev. 0, October 2011, incorporated:

- Maximum hurricane wind speed for STP Site revised to meet RG 1.221.
- Hurricane generated missile spectrum revised to meet RG 1.221.

Existing design met RG 1.221 requirements:

- ABWR DCD buildings; and,
- Site specific buildings.

COLA Changes since 11/30/2010 ACRS Meeting (continued)

COLA Revision 8 added new Appendix 1E:
Response to NRC Post-Fukushima Recommendations, included:

Available Physical Margin for Flooding (i.e., the Cliff Edge):

STP 3 & 4 maintains ability to cool the core
until flood water level exceeds 51 feet MSL.


- 17 feet above nominal site grade;
- 12.8 feet above maximum flood level (MCR breach); and
- 11 feet above the design basis flood of 40 feet MSL.

Main Cooling Reservoir Embankment Breach



- MCR formed by 12.4-mile-long embankment enclosing a 7000 acre reservoir.
- Constructed above natural ground
- Minimum embankment crest elevation is 65.8 feet MSL.
Normal max operating level is 49 feet MSL.
- Toe of embankment is approximately 29 feet MSL at the north end.


Main Cooling Reservoir Embankment Breach (continued)



MCR Embankment Cross Section

(superimposed with cross section of typical Texas City Hurricane Storm Levee)


Main Cooling Reservoir Embankment Breach (continued)



Main Cooling Reservoir Embankment Breach (continued)

MCR Breach Flow:

FLDWAV (STP COLA Model using Froehlich width and MLM time)
compared to
BREACH Model (independent confirmatory analysis)



FSAR Figure 2.4S.4-13c:
Comparison of BREACH and
FLDWAV Outflow Hydrographs

Main Cooling Reservoir Embankment Breach

(ACRS Action Item 65)

How does MCR breach width derived from Froehlich's equation used in the FLDWAV model compare with value used in confirmatory BREACH Model?

	PEAK FLOW			Final
	Flow	Time	Width	Width
	(cfs)	(Hours)	(feet)	(feet)
FLDWAV-STP COLA Model	130,000	1.7	417	417
BREACH-STP	83,000	6.25	398	485
Froehlich Equations	62,600	10.6		417


Main Cooling Reservoir Embankment Breach

(ACRS Action Item 65)

FLDWAV Model (STP COLA Model using Froehlich width and MLM time)

BREACH Model (Independent Confirmation)

FLDWAV Model (Froehlich Width only)



Questions and Comments





Presentation to the ACRS Subcommittee

**South Texas Project Units 3 and 4
COL Application Review**

**STP Chapter 2
SER with no OIs
“Site Characteristics”**

April 24, 2013

ACRS Subcommittee Presentation STP Chapter 2 SER with no Ols

Staff Review Team

- **Project Managers**
 - George Wunder
 - Tekia Govan, David Misenhimer
- **Technical Staff**
 - RPAC, Chief, Michael McCoppin
 - RHMB, Chief, Christopher Cook

Summary of Staff Review

2.1 - Geography and Demography

*2.2 - Nearby Industrial, Transportation,
and Military Facilities*

2.3 - Meteorology

2.4 - Hydrology

*2.5 - Geology, Seismology, and
Geotechnical Engineering*

STP COL Chapter 2.3

Meteorology

**NRC Reviewer/Presenter:
Brad Harvey**

New RAI 02.03.01-24

Design-Basis Hurricane Winds and Missiles

- New RG 1.221 (Oct 2011)
 - Design-Basis Hurricane and Hurricane Missiles for Nuclear Power Plants
 - 10^{-7} per year exceedance frequency
- RAI 02.03.01-24
 - Applicant identified design-basis hurricane wind speed and missiles for the STP site
 - Applicant confirmed ABWR standard plant and STP site-specific SSCs are protected against hurricane winds and missiles

Action Item 92

- ACRS asked what criteria will be used to initiate use of global climate change predictions and revise analysis of impact of natural phenomena on the STP site
- GDC 2: Design basis for SSCs shall reflect appropriate consideration of the most severe of the natural phenomena that have been historically reported for the site and surrounding area, with sufficient margin for the limited accuracy, quantity, and period of time in which the historical data have been accumulated

Action Item 92 (cont'd)

- SER Section 2.3S.1.4.7: Climate Changes
 - NRC staff acknowledges that long-term climatic change resulting from human or natural causes may introduce changes into the most severe natural phenomena reported for the site
 - There is a level of uncertainty in projecting future conditions
 - If it becomes evident that long-term climatic change is influencing the most severe natural phenomena reported at a site, the COL holders have a continuing obligation to ensure that their plants continue to operate safely
- NTTF Recommendation 2.2: Program for Periodic Confirmation of Seismic and Flooding Hazards (Tier 3)
 - SECY-12-0095: The staff includes seismic, flooding, and other natural and man-related external hazards within the scope of this rulemaking
 - This rulemaking could provide a potential opportunity to address global climate change

Action Item 91

- ACRS noted an “inconsistency” in climate change effects treatment for natural phenomenon in characterizing the STP site
 - Potential maximum tsunami address sea level rise from global climate change in the next century, but no mention of the potential increase in wind and rain accompanying future hurricanes
- Both sea level rise and hurricane wind/rain data are based on either historical or deterministic data: future changes resulting from climate change are uncertain
 - Sea Level Rise: NOAA CO-OPS
 - 1.43-ft rise/100-yr projection based on locally measured trends
 - Hurricane Winds and Rain: USGCRP
 - More intense hurricanes with related increases in wind and rain likely
 - May not be an increase in the number of storms that make landfall

Summary of Review

- **Conclusions and Status of SER Section 2.3 – Meteorology**
 - FSAR met regulatory requirements
 - All COL items adequately addressed
 - No open or confirmatory items

STP COL Chapter 2.4

Hydrology

NRC Reviewers:

Dr. Henry Jones

Dr. Nebiyu Tiruneh

Dr. Hosung Ahn

Presenters:

Dr. Henry Jones

Dr. Nebiyu Tiruneh



Open Item 02.04.04-1

Open Item 02.04.04-1: The main cooling reservoir embankment breach flood analysis needed to be updated by describing the process of selecting the plausible breach widths and breach time parameters for determining the flood characteristics.

- **Staff's Review**

Action: The applicant provided and staff reviewed the responses to RAIs 02.04.02-3, 02.04.04-14 and 02.04.04-15. The applicant did the following to close the open item:

- described the use Dam Safety Office for characterization of the breach,
- applied the BREACH model, including a sensitivity analysis,
- and compared results to a historical database of dam failures.

Based on an independent confirmatory analysis, the staff determined that the applicant-estimated breach flood discharge is reasonable and conservative. The staff closed the open item based on its confirmatory analyses.



Open Item 02.04.05-1

Open Item 02.04.05-1: The applicant has not shown that the ADCIRC model results account for the most conservative plausible PMH scenario. The description and results of these models are also missing from the FSAR.

- **Staff's Review**

- **Actions:**

- STP provided additional information through the response of RAI 02.04.05-11 to more fully describe ADCIRC and to clarify the ADCIRC model set-up, PMH scenario, sensitivity runs for storm parameters (e.g., radius, forward speed, track direction, and landfall location) of storm.
 - Staff determined that the applicant has selected conservative PMH scenarios for estimating the PMSS at the STP site. The staff also determined that the applicant has selected an appropriate model supported by site-specific information. The staff concluded that the applicant's ADCIRC simulations for determining the PMSS at the STP site are adequate.
 - Staff determined that the response is acceptable, thus closed the open item.



Open Item 02.04.10-1

Open Item 02.04.10-1: The applicant did not provide an analysis to show whether or not a hurricane storm surge could erode the toe of the main cooling reservoir northern embankment during the PMSS.

- **Staff's Review:**

Action: The applicant provided and the staff reviewed the responses to RAI 02.04.05-11.

- The applicant described the use of the ADCIRC model and determined the PMSS maximum flood elevation including wave action.
- The applicant determined that the PMSS would exceed the elevation of the embankment toe but not for an length of time or with such a current to erode the toe of the embankment.
- Staff determined one scenario that could have led to a breach of the main cooling reservoir embankment. That was the storm surge could wet the toe of the embankment during the PMSS leading to erosion of toe. Staff determined that was unlikely to occur.
- Staff determined that applicant's estimate of the design basis flood characteristics and proposed flood protection measures are acceptable, thus **closed this open item.**

Open Item 02.04.12-1

Open item 02.04.12-1: The applicant needed to clarify the potential for groundwater mounding in the Lower Shallow Aquifer, and for a west-southwest directed pathway during post-construction period

- **Staff's Review**

Open Item 02.04.12-1: The staff issued RAIs 02.04.12-46, 02.04.12-48, 02.04.12-50, and 02.04.12-51 to address the above issue.

Actions:

- The applicant provided responses to the RAIs including a revised groundwater modeling document
- Staff reviewed RAI responses and performed independent confirmatory analyses. Staff's review included evaluation of:
 - An improved alternative groundwater model
 - Particle tracking showing all pathways are to east-southeast
 - Sensitivity cases involving ranges of post-construction infiltration rates and excavation backfill hydraulic conductivity values
- Staff concluded that plausible alternative pathways are analyzed, and exclusion of a west-southwest pathway in the Lower Shallow Aquifer is technically defensible
- This part of Open Item 02.04.12-1 is closed.

Open Item 02.04.12-1 (cont.)

- **Open Item 02.04.12-1:** The applicant needed to clarify the technical basis for the site characteristic of maximum groundwater level

- **Staff's Review**

Open Item 02.04.12-1: The staff issued RAI 02.04.12-49 to address the above issue.

Actions:

- The applicant provided a revised response to RAI 02.04.12-49.
- Staff reviewed the RAI response and performed an independent confirmatory analysis. Staff's review included evaluation of:
 - Field observations: 34-yr record, piezometer 602A, site characterization data
 - Modeling: post-construction groundwater levels
 - Combinations of field observations and modeling results
 - Confirmation of groundwater depression at existing STP Units 1 and 2
- Staff found that the site characteristic for maximum groundwater level of 28 ft above MSL is technically defensible and acceptable under normal and extreme conditions excluding the maximum flood level

Open Item 02.04.12-1 (cont.)

- Staff found the groundwater level could reach plant grade (34 ft MSL) during the design basis flood (maximum flood level = 40 ft above MSL).
 - This groundwater condition during the maximum flood level is included in the engineering evaluation in SER Section 3.8.
- This part of Open Item 02.04.12-1 is closed thus closing this OI completely.



Summary of Review

- The staff reviewed various flooding mechanisms (rain, hurricane, tsunami, dam breach, etc.) to determine site-specific design basis flood characteristics and required flood protection.
- The applicant identified the flood caused by a breach of the Main Cooling Reservoir embankment as the design basis flood.
- The staff also reviewed the groundwater area to identify the characteristics of the maximum groundwater level and accidental release of radioactive liquid effluents.
- The staff identified 5 open items and they are all closed.
- Open Item 02.04.04-2 was made obsolete due to applicant's modification of analytical tools used to estimate erosion and deposition in the area of the safety-related facilities.
- There are no confirmatory items.

Action Item 93

- ACRS requested information on the PMT site impact if the roughness coefficient is modified significantly. For example, destruction of the vegetation by fire.
 - “No vegetation” scenario modeled in 1D and 2D simulations using a roughness characteristic of grass/turf.
 - 1D tsunami wave front slowed significantly. Maximum water elevation 10 m at a distance of 10 km from the site. Site elevation ~ 10 m.
 - 2D tsunami wave front is 10 m at the shoreline (i.e., 1/2 of 1D case).

Conservative assumptions:

- 1D case does not include lateral dissipation (radial spreading).
- Offshore regions are assumed to be without bottom friction (no energy loss).
- Time scale of submarine landslide motion is small (i.e., instantaneous displacement of the sea surface).
- Maximum submarine landslide dimensions.

Action Item 94

- ACRS requested information on what arrangements have been made for replenishing the UHS water.
 - There is a separate UHS for each STP Unit 3 & 4 that is configured with a dedicated water basin sized to provide cooling for 30 days.
 - Onsite wells primarily provide makeup water to the UHS basins.
 - The main cooling reservoir is the secondary source of makeup water. The Colorado River is the source of makeup water for the main cooling reservoir.
 - The surface and groundwater sources are not safety-related because UHS basins of each unit as sufficient capacity to provide a 30-day cooling water supply to the UHS without the need for any makeup or blowdown.

Action Item 95

- ACRS requested information on the impact of removing ground water to replenish UHS. Would this change the local groundwater flow and lead to surface subsidence that could impact STP Units 3 & 4?
 - Groundwater will be used for the potable and sanitary supply, the production of demineralized water, fire protection, and makeup water for the UHS.
 - Annual groundwater usage at STP Units 1 and 2 is 1.59 M m³/yr (1,288 ac-ft/yr). The normal groundwater consumption rate for the STP units 3 and 4 is 1.94 M m³/yr (1,575 ac-ft/yr).
 - The STP permit limit has not been fully used to date. The estimated groundwater permit is 3.7 M m³/yr (3,000 ac-ft/yr).
 - Production wells for existing plants have caused the Deep Aquifer to exhibit a local reversal of the flow pattern. This results in a radial flow toward the production wells from the surrounding aquifer.

Action Item 95 (cont'd)

- The estimated land-surface subsidence since 1900 over most of Matagorda County to be less than 1 ft .
- Where land-surface subsidence exceeds 1 ft in northwest Matagorda County, it is attributed to groundwater withdrawals associated with
- gas/petroleum exploration and sulfur mining.
- During construction and through operation in 1993 of STP Units 1 and 2, a subsidence rate of less than 0.1 in. to about 0.2 in. per year was observed.
- Groundwater monitoring for STP Units 3 and 4 will be similar to existing reporting requirements for STP Units 1 and 2. **Considerations will include subsidence monitoring to ensure structural stability.**

**ACRS Subcommittee Presentation
SER with no Ols Chapter 2**

Questions

ACRS Subcommittee Presentation
SER with no Ols Chapter 2

Back up Slides

Backup Slide

(Action Item 91)

- Hurricane Wind Loads
 - 10^{-2} per year value of 139 mph (ASCE/SEI 7-05)
 - 10^{-7} per year value of 210 mph (RG 1.221)
- Local Intense Precipitation (PMP, HMR 51 & 52)
 - 5-minute probable max precipitation depth: 6.4 inches
 - 1-hour probable max precipitation depth: 19.8 inches
 - Maximum power block water level due to local PMP storm: 36.6 ft MSL
- Probable Maximum Surge (PMH, NOAA Tech Report NWS 23)
 - Probable maximum storm surge water level: 31.1 ft MSL



Presentation to the ACRS Subcommittee

Overview of the Non-Concurrence Process

**STP Chapter 2
SER with no Ols
“Site Characteristics”**

April 24, 2013

Overview of the Non-Concurrence Process

- The non-concurrence process (NCP)
- Documentation of the Non-Concurrence
 - The non-concurrence (Section A)
 - Issue #1: Main Cooling Reservoir (MCR) Breach Flood Analysis in SER Section 2.4.4
 - Issue #2: Flood Analysis of Hurricane and MCR Breach Combination in SER Section 2.4.5
 - Issue #3: Maximum Groundwater Level in SER Section 2.4.12
 - Supervisor's Review and Recommendation (Section B)
 - Management's Resolution of the issue (Section C)
- This non-concurrence is captured as NCP-2011-14 and can be found in ADAMS (Accession number – ML12348A249)



South Texas Project Units 3 and 4 COLA Review SER Chapter 2.4 Hydrology: **Non-Concurrence**

Presentation to the ACRS Subcommittee

Presenter: Hosung Ahn, Ph.D., P.E.

NRO/DSEA/RHMB

April 24, 2013



Hydrology Non-concurrence Issues


- #1 Main Cooling Reservoir (MCR) Levee Breach (FSAR Sec. 2.4.4)
 - 1.1 Breach width estimated by the Froehlich equation is not conservative.

The breach parameters and flows estimated by the numerical model (NWS-BREACH, or just BREACH) were underestimated by:
 - 1.2 STP used a small breach roughness value.
 - 1.3 The staff specified unrealistically small tailwater section.
 - 1.4 STP and the staff do not consider scouring of the levee foundation.
- #2 Probable Maximum Storm Surge (FSAR Sec. 2.4.5):

Conservatism of parameters and accuracy of wind and surge models used in STP's storm surge analyses are of concern.
- #3 Maximum Groundwater Level (FSAR Sec. 2.4.12):

The departure of the maximum groundwater level (ABWR DCD Tier 1 Site Parameters) is not addressed in subsequent structural analyses.

#1 Main Cooling Reservoir (MCR) Levee Breach




MCR

- Area=7000 acres; Levee length: 12.4 miles
- Construction completed in 1983
- Filling test (45 ft msl) from 1983 to 1989
- Proposed the MCR water level to 49 ft msl.

Breach & Tailwater Condition

- North levee: 4200 ft
- Elevation: 29~32 ft msl (**upslope**)
- Breach bottom roughness will be increased by broken cement blocks.


Note: msl=mean sea level



Dam/Levee Breach Flood Analysis

Regulatory Framework

- Part 50 GDC 2: 'considering the most severe events with sufficient margin.'
- Part 100.20(c)(2): 'using the maximum probable events'
- Guidance provided in SRP, RG 1.206, and ANS 2.8.



Issues in General

- No detailed **technical guide** available
- Lack of historical data, and **uncertainty**.
- Applying a **conservatism** similar to other flooding events (e.g., rain, storm, etc.)
- **No single numerical model** available to simulate erosion and flow together.

Approach: We used a combined approach.

- ✓ STP: empirical equations+ numerical models(BREACH,FLDWWAW, RMA2). (p. 24)
- ✓ The staff: numerical models (BREACH, RMA2)+ historical data.
- ✓ My re-analysis: similar to STP's, but used FLO2D

Note: Empirical regression equations are used to predict breach parameters (**width, time, peak flow**) using breach **head and storage volume**.

1.1 Breach Parameter Estimates Using Regression Equations

➤ STP's Breach Parameter Estimates:

Breach width: **417** ft by Froehlich

Breach time: 1.7 hr by MLM

Peak flow: 63 kcfs by Froehlich
83 kcfs by BREACH
130 kcfs by FLDWAV

➤ My Re-analysis:

MLM breach width: 745~1738 ft

Peak flow: 251 kcfs by 10 equations
269 kcfs by BREACH
280 kcfs by FLDWAV

➤ Non-concurrence Issues:

- STP's breach width estimate is not conservative compared to other similar cases:


- ✓ 2000 ft for STP Units 1&2
- ✓ 2034 ft for Victoria ESP
- ✓ 4757 ft for STP FSAR v. 0&1
- ✓ 600 ft on the Martin Cooling Pond breach.

- Other government guides (USBR, USACE, etc.) recommend to '**use all equations, then make an engineering judgment.**' However, STP did not use the MLM breach width equation as well as many breach peak flow equations, resulting in non-conservative parameter estimates (see my re-analysis).

Notes:

- **kcfs**=1000 cubic feet per second; **MLM**=MacDonald and Langridge-Monopolis equation (1984).
- Froehlich, MLM, USBR, and von Thun and Gillette provide both breach width and time equations, but later two are not applicable to MCR.

Position Analysis for Main Cooling Reservoir Breach



Discussions:

- By the State of Colorado dam classification, MCR is a large dam.
- MCR which has low head and large storage volume could breach widely.
- Based on the reservoir size (head and volume), suitable example for MCR is not the Teton (B=495 ft) but the Martin Cooling Pond (MCP) breach (B=600 ft).


Note: B=breach width

Historical Maximum and Envelope for Breach Widths

Record of Extreme Breach Widths:

- Dam: USBR database: 738 ft, 610ft , 551 ft ,...
Worldwide: **5800 ft** in India
- Levee: Europe (Nagy, 2006): **8000 ft**, 1300 ft, 1000 ft, ... from 39 cases
California Delta Levee: 1018 ft , 950 ft, 926 ft, from 14 cases
- STP's MCR breach width: 417 ft (**It is just a mean value for a given reservoir size without margin.**)

Note: The above data indicates that levees tend to breach wider than dams.




Conservatism

- To meet the GDC 2 requirements, STP should use a bounding breach width equation to address uncertainties in data and models.
- Froehlich (1995) does not provide bounding equations, but an upper confidence limit of a best-fit equation (Wahl, 2004) could be used alternatively.

Note: USBR=U.S. Bureau of Reclamation

Better Breach Width Equation for MCR Levee



USBR: $B=2h_w$; von Thun & G: $B=2.5h_w+C_b$

Froehlich : $B=0.1803 V_w^{0.32} h_w^{0.19}$

MLM : $B=0.0261 (V_w h_w)^{0.769} / A$

Notes: B=breach width, h_w =head (m), V_w =storage volume (m³), C_b =storage factor, A=cross section area (m²). MLM=MacDonald and Langridge-Monopolis equation (1984)

The staff asserted that Froehlich's breach width equation is better because its prediction error (0.43) is smaller than the MLM error (0.82).

My Conclusions:

- The above assertion is not valid because the two errors have different dimensions (length vs. volume).
- The MLM equation is better because the sizes of MCR and MCP data are within the range of MLM data.
- The Martin Cooling Pond (MCP) breach shows that the MLM or bounding Froehlich equations are good for MCP, thus for MCR (**see the backup slides p.37**).

1.2 Breach Bottom Roughness Coefficient (n-value)

Issue: STP used non-conservative n-value (0.05) in the BREACH model.
However, the staff chose n-value of 0.075 in the SER.

My Opinions:

- I agree with the staff, but not with the applicant.
- Breach n-value should be higher than flow n-value because eroded materials create **mud flow** with high resistance. The State of New Jersey Dam Breach Guide (2011) states that “n-value at the dam breach should be assumed to be larger than the maximum field n-value to account for uncertainties of **high energy losses**” – They used the term “**probable maximum n-value.**”
- The BREACH manual (1991) provides four low n-value examples (<0.035), while other dam breach studies used high n-values (>0.1).

Notes: 1) Manning's Equation: $V = 1.49 R^{2/3} S^{1/2} / n$, where V=velocity, R=hydraulic radius, S=slope, n=Manning's n-value, in English units.

2) n-value is the most sensitive parameter in MCR BREACH runs.

Referenced and Verified n-values Applicable to MCR

Source	Selected n	Range of n's
STP FSAR	0.05	0.025~0.08
SER & My Re-analysis	0.075	0.025~0.075
Handbook of Hydrology (Maidment, 1993): boulder)	-	0.04~0.1
Chow (1959) – for major rough stream (W>100ft)	-	0.035~0.1
Fenton, et al. (2006) – Dam Breach (p.29)	0.1	
Trieste and Jarrett (1987) - Dam Breach (p.30)		0.05~0.225
My Estimates Using the Chow Method (p.31)	0.0775	0.07~0.085
Calibrated n with the 1979 MCP Breach (p.38)	0.09	0.06~0.12

Note: Page numbers refer to backup slides.

Conclusions:

- Trieste and Jarrett (1987) concluded that verified breach n-values would be about **210% greater** than respective field n-values (Backup slide p.30).
- MCR breach n-value should consider a composite of clay, sand, and broken cement blocks (p.31).
- The n-values in bold are site-specific MCR values, thus credible.
- Therefore, the staff's selection of **n=0.075 is reasonable and conservative.**

1.3 Tailwater Section in the BREACH Model

Issues:

- The staff used an **unrealistically small** tailwater section (width of 600 ft) compared to the anticipated breach width (The same is true in FSAR Table 2.4.4-6b). Then the staff concluded that tailwater section is not critical in breach and that a small tailwater section is realistic.





My Opinions (see Ahn, 2012a):

- I disagree. The MCR breach tailwater zone is wide (>1 mile) overland plain with mild upslope to the North (4 ft to 1 mi), so that the tailwater spreads quickly and widely to the lateral directions - **A wide tailwater section is realistic.**
- My re-analysis shows that small tailwater section produces high tailwater level at the beginning of breach, resulting in reducing breach head and resulting breach width significantly. My sensitivity analysis also shows that tailwater section is very critical in breach.


Note: NWS-BREACH performs a 1-dimensional routing of breach outflow and tailwater with only one representative cross section as input – **It is a limitation of the model but acceptable.**

The Staff Used an Unrealistically Small Tailwater Section

(Staff: 600 ft at bottom, 2800 ft at top; Re-Analysis: 3000 ft)




BREACH: Tailwater Section Width vs. Breach Width



My Re-analysis Findings

- The staff/PNNL selected $n=0.075$. However, they performed a tailwater section sensitivity analysis with $n=0.05$, then concluded that the tailwater section is not a limiting factor. (SER p. 51) – This conclusion is incorrect as my re-analysis shows that tailwater section is very sensitive in breach.
- The staff obtained peak flow of 130 kcfs using BREACH with $n=0.075$ and a small tailwater section, then concluded that STP's breach estimate is acceptable – The model is flawed.
- In my re-analysis, I used a width of 3000 ft, but a tailwater width greater than 2000 ft is acceptable (see Ahn, 2012a).

Sensitivity of Two Breach Parameters (n-value and Tailwater Section)



Notes: W=tailwater bottom width;
c=cohesion of soils; ϕ =friction angle.

Discussions:

- The differences in outflows are due to width of the tailwater section and soil properties.

	W (ft)	c(lb/ft ²)	$\phi(^{\circ})$
STP	600	300	20
Staff	600	200	15
Re-an.	3000	300	20
All assumed no scour hole.			


- It is clear from the figure that the staff underestimated breach outflows by using a small tailwater section.



1.4 Scour Hole Issues

- STP and the staff did not consider the potential of foundation scouring.
- External Reviews:
 - Three reviewers concluded that a scour hole will not be formed: however they interpreted the field data incorrectly (see slide p.19).
 - Mr. Wahl asserted that the result of scour hole analysis in re-analysis must be **discounted** because the modeling and the results are not clearly documented: However he never reviewed the input and result of the model in my report.
 - Dr. Baecher stated that the staff should investigate the scouring possibility thoroughly.
- Non-concurrence Issues:
 - Scour holes are very common in levee breaches (e.g., Martin Cooling Pond, p.16). Scouring process in breach has been studied and modeled extensively.
 - The foundation of the MCR levee was **not designed to prevent piping or scouring**. Instead, UFSAR states that the foundation treatments were done by “removing trees and vegetation, scarifying and replacing the surface soil up to 9 inches with clay, then compacting.”
 - The foundation could be scoured by **piping through sand layers** in foundation or by **land subsidence** from groundwater pumping (see p. 17 & 18).
 - STP and the staff forced not to occur scouring in BREACH. However, I relaxed the constraint, resulting in a deep scour hole.


1979 Martin Cooling Pond Breach with Scour Hole




Scour Area

Levee


- Levee Breach
width: 600 ft
- Scour Hole
 - Piping started through foundation **sand layers**.
 - Width: 450 ft
 - Length: 700 ft
 - Max. depth: **29 ft**
(~16 ft on average)



Sand Layers below MCR and MCP Levees



Potential Land Subsidence from On-site Groundwater Pumping



- The south Texas area has been experiencing severe land subsidence (max. 2m).
- STP plans to pump groundwater from the Chicot Aquifer using 6 wells (5 existing +1 proposed) at a total rate of 1860 gpm.
- I estimated long-term groundwater drawdown of about 30~40 ft near the wells, which could induce land subsidence that may trigger piping and scouring.

Soil Properties Before and After the Construction of MCR

Layer	Thick- ness (ft)	End of MCR Construction		After MCR Construction			
				1975~1983		1983~1984	
		c (psf)	ϕ (°)	c (psf)	ϕ (°)	c (psf)	ϕ (°)
Embankment	36	1100	5	150	20	300	20
Clay Layer 1a	6~8	1000	-	-	20	350	17
Clay Layer 1b	4~24	2000	20	-	20	350	17
Sand Layer 2	20~30	-	30	0	30	0	35
Clay Layer 3	15~25	2000	20	-	20	350	17
Sand Layer 4	25~50	-	30	0	30	0	35
Sources: STP UFSAR Rev. 13, Section 2.5.6.1.1 & Table 2.5.6-2&5							

SER: The staff and external reviewers concluded that scour hole is not likely because c-values of the clay are high (>1000 psf).

Notes: $\tau = c + \sigma \tan(\phi)$, where τ =shear strength, σ =stress, c=cohesion, ϕ = friction angle; psf=pound per square feet

My Opinions:

- I disagree. The c-values reduced substantially after filling the MCR (**changing** the soil properties **from compacted to saturated**), but they failed to recognize this.
- I used the post-construction c-value (c=300 psf) that induces scouring of the foundation.

Re-analysis: Comparison of MCR Breach Flood Estimations

Run ID	Scour Hole (ft)	Breach Width (ft)	Model Used to Get Peak	Peak Flow (kcfs)	Peak Time (hr)	Flood Level (ft msl)
MLM-D10	10	1047	FLDWAV	309	1.9	44.6
MLM-D20	20	745	FLDWAV	280	2.1	44.1
MLM Qp & Tf	0	-		217	2.5	43.0
Avg Qp, MLM Tf	0	-		251	2.5	43.6
RUN1	0	934	BREACH	194	3.3	42.6
RUN2 (base)	10	633	BREACH	269	2.1	43.9
RUN23	15	516	BREACH	271	1.8	44.0
RUN24	20	433	BREACH	267	1.6	43.9
STP Values	0	417	FLDWAV	130	1.7	38.8

Conclusions: STP should use conservative breach equations. They should consider (1) reasonable n-value, (2) realistic tailwater section, and (3) scour hole.

Note: Qp: peak flow, Tf: breach time; Re-analysis used n of 0.075

#2 Hurricane Storm Surge Flooding

Issue: Conservatism of storm parameters and accuracy of wind and surge models used in STP's storm surge analyses are of concern.

My Comments on the Revised SER:

- The objectives of storm surge analysis are (1) to determine the level and magnitude of flooding caused by storm surge and (2) to determine site inundation for emergency plans. However, the staff's review focused only on the first objective.
- STP's probable maximum hurricane scenarios are not conservative but their wind speeds are unrealistically high (184 mph vs. 134 mph by USACE; **see backup slide p.39 & p.40**).
- The staff concluded that the STP's estimate is reasonable and conservative. However, STP's surge estimate of 29.3 ft msl is much lower than two other estimates (39.8 ft msl by USACE's ADCIRC and 39.6 ft msl by PNNL's SLOSH).

#3 Maximum Groundwater Level


Issue: The departure of the maximum groundwater level (ABWR DCD Tier 1 Site Parameters) is not addressed in subsequent structural analyses.

Maximum Groundwater Level:

- DCD requirement: 32 ft msl
- STP estimate: 28 ft msl
- Staff estimate: 34 ft msl (It is only a 2 ft departure, however it increases static water pressure significantly).

10 CFR Part 52 App. A Requirements:

The DCD Tier 1 contains **approved and certified** parameters, so any departure from Tier 1 should be reported and addressed.



My Finding: The SER states that “all departure conditions have been requested.” However I found that the departure is not addressed on:

- ✓ COLA Part 7, Departures
- ✓ FSAR Tier 1 Table 5.0 (Site Parameters)
- ✓ Flood protection and structural analyses (e.g., RAI 03.08.04-39)

BACKUP SLIDES

BACKUP 1: MCR Levee Breach Analysis

BACKUP 2: 1979 Martin Cooling Pond Breach

BACKUP 3: Hurricane Storm Surge

BACKUP 4: List of References

BACKUP 1 Approaches for MCR Breach Flood Analysis

STP's Approach

- $[V_w, H_w] \rightarrow \text{Empirical Equ's} \rightarrow [B, T_f] \rightarrow \text{FLDWAV} \rightarrow Q(t) \rightarrow \text{RMA2} \rightarrow h(t)$
- Use the **BREACH** model to validate empirical estimates of $[B, T_f]$.

Staff/PNNL's Approach

- **BREACH** ----- $\rightarrow Q(t) \rightarrow \text{RMA2} \rightarrow h(t)$
- Use **historical records** to validate BREACH estimates of $[B, T_f]$.

My Re-analysis Approach

- $[V_w, H_w] \rightarrow \text{Empirical Equ's} \rightarrow [B, T_f] \rightarrow \text{FLDWAV} \rightarrow Q(t) \rightarrow \text{FLO-2D} \rightarrow h(t)$
- **BREACH** ----- $\rightarrow Q(t) \rightarrow \text{FLO-2D} \rightarrow h(t)$

Notes

- V_w =volume, H_w =head, B & T_f =breach width and time, $Q(t)$ = breach outflow at time t , $h(t)$ =hydrograph.
- BREACH is 1-dimensional numerical breach and flow simulation model. FLDWAV is 1-D breach flow simulation model. Both RMA2 and FLO2D are 2-D flow model used to simulate MCR breach flooding.

B1 Prediction Errors for Empirical Breach Equations

Prediction Errors (Wahl, 2004)

- Assume that the errors (predicted minus observed) are a normal, independent, and identically distributed random variable.
- The mean prediction error on the best-fit regression equation is given by **two standard deviation** of prediction errors ($\sim 97.5\%$ exceedance probability).

Froehlich Breach Width (B) Error

- Denoting $V[x]$ =variance and $Cov[xy]$ = covariance of rv's (x,y), the variance of breach widths is:
$$V[B_o] = V[B_p + \epsilon_B] = V[B_p^2] + V[\epsilon_B^2] + Cov[B_p * \epsilon_B]$$
- From which, $S_\epsilon(B)$ is estimated as:
$$S_\epsilon(B) = (V[\epsilon_B^2])^{1/2}$$
$$= (V[B_o] - V[B_p^2] - Cov[B_p \epsilon_B])^{1/2}$$

MLM Breach Volume (V=AB) Error

- The variance of the MLM breach volumes is expressed as:
$$\begin{aligned} V[V_o] &= V[A_o B_o] \\ &= V[(A_p + \epsilon_A)(B_p + \epsilon_B)] \\ &= V[A_p B_p + A_p \epsilon_B + \epsilon_A B_p + \epsilon_A \epsilon_B] \\ &= V[\epsilon_B^2](\sim) + V[\epsilon_B](\sim) + Cov[\epsilon_B \cdot (\sim)](\sim) + \dots \\ &\quad (\text{e.g., 12 terms on RHS}). \end{aligned}$$
- The term $S_\epsilon(B) = [V(\epsilon_B^2)]^{1/2}$ is obtained from the last expression implicitly. However, these error terms are not defined in Wahl (2004).

Conclusions:

It is clear that the MLM breach volume error (**$S_\epsilon(V)$**) is much larger than that of the Froehlich breach width (**$S_\epsilon(B)$**) due to (1) errors in breach section area estimates and (2) the dependence between a variable and its error. However, Mr. Wahl and Dr. Baecher compared two entities erroneously.

B1 BREACH Model

- BREACH was developed by Dr. Fread in NOAA in 1993 and updated in 2000. The model is no longer supported by NOAA, but has been used widely in practice.
- BREACH simulates a coupling of breach erosion and flow processes in a 1-dimensional domain. Output of the BREACH include erosion rates (size and shape) and outflows in time.
- Because BREACH output are very sensitive to uncertain input parameters (e.g., n-value), the author of BREACH recommended using the model for an auxiliary purpose only.

BREACH Input

1. Reservoir: storage-head relation, initial pool level, bottom elevation, inflows, spills, etc.

2. Dam geometry: height, lengths, slope, core, bottom elev., spillway, etc.

3. Dam materials: grain size, porosity, weight, friction angle, cohesive strength, **n-value**, etc.

4. Tailwater: cross section, slope, n-value, etc.

5. Model: time step, convergence criteria, etc.


B1 Structure of the BREACH Model

- Breach flow: Piping orifice: $Q_o = 0.98(2g)^{0.5}Ab(H-H_p)^{0.5}$, or
Submerged broad-crested weir: $Q_o = 3B_o(H-H_c)^{1.5}$
- Tailwater flow: get Y_t from $Q_t = 1.49S^{0.5}A^{1.67}/(nP^{0.67})$
- Submergence correction: $Q_b = S_b Q_o$, $S_b = 1 - [(Y_t - H_c)/(H - H_c) - 0.67]^3$
- Erosion by the modified Meyer-Peter & Muller equation:
 $Q_s = aP(SR - \tau_c)^{1.5}$, $S = n^2 Q_b^2 / (2.21 A^2 R^{1.33})$
- Iterate the above calculations till Q_o matches Q_b .

where Q_b =breach outflow, A =breach area, $(H-H_p)$ =piping head, $(H-H_c)$ =weir head, S =slope, P =perimeter Y_t =tailwater depth, D =particle size, R =hydraulic radius, $a=27.5$, and τ_c =critical shear stress.

B1 Breach Tailwater Section and Energy Losses:

For bridge encroachment (HEC,2010, HEC-RAS Manual)



Note: HEC-RAS is an 1-dimensional steady and unsteady hydraulic simulation model used to simulate rivers/channel flows with various hydraulic structures.


- The left figure depicts a bridge encroachment in a plain view (similar to levee breaches).
- Expansion Ratio (ER): 1.4-3.6 (for $b/B=0.1$, $S=1$ ft/mile) – That is, the MCR tailwater section in BREACH should be far enough from the levee to account for tailwater spreading.
- Head Loss Coefficient:

$$h_L = h_{\text{entrance}} + h_{\text{friction}} + h_{\text{exit}}$$

Coeff. for entering = 0.3~0.6
 Coeff. for exiting = 0.5~0.8
- Similarly, STP should use high **n-value** to account for the effects entering and exiting head losses.

B1 Example of Setting Dam Breach n-values

(From Fenton et al., 2006)



B1 Example Breach n-values (Trieste and Jarrett, 1987)

Study	Field n-value	Verified n-value
Jarrett and Coasta (1985)	0.035 ~ 0.125	0.10 ~ 0.22
Blanton (1977)	0.03 ~ 0.047	0.07 ~ 0.15
Fread (1977)	0.04	0.07
Leutheusser and Chisholm (1973)	0.175	0.225
Wilson (1973)	0.02 ~ 0.03	0.05 ~ 0.07

Comments:

- In each case, author(s) obtained the verified n-values from a calibration of numerical hydrodynamic models with historical breach data.
- Trieste and Jarrett (1987) concluded that verified n-values would be about **210% greater** than the respective field n-values.
- Dr. Fread, the author of BREACH, also used $n=0.07$ in a breach study.

B1 MCR Breach n-values Estimated in the Re-analysis:


Using the Chow Method (1959): $n = n_b + n_1 + n_2 + n_3 + n_4$

Factor	Breach n-Value	Conditions Used in Re-analysis
Base n-value (n_b)	0.02	Earth (sand) bed materials
Irregularly (n_1)	0.015	Moderate/severe channel (max. 0.02)
Cross-section (n_2)	0.01~0.015	Contraction & expansion
Obstruction (n_3)	0.02~0.03	40% covered by broken cement blocks
Vegetation (n_4)	0.005	Small (max. 0.01, outer levee only)
Final n-value (sum)	0.07~0.085	Average of 0.775

Comments:

- SFWMD (1980) reports that large cement blocks (size of 6'x6'x6") were found on the bottom of the MCP breach – This is similar to a boulder channel, and thus for MCR breach.
- Substantial contraction and expansion of breach flow occur before and after water passing the breach zone, resulting in a significant head loss.
- The staff also got a tailwater n-value of 0.056 using the same Chow method,

B1 Postulating Scour Hole in Re-analysis



- STP postulated a scour hole ($W=380$ ft, $L=203$ ft, $D=20$ ft) at the downstream toe of the embankment, but not on the levee foundation – **I disagree. Scouring of the foundation is highly likely.**
- Re-analysis postulated and tested three scouring scenarios: hole depths of 0ft, 10 ft, and 20 ft below the levee. The corresponding peak breach outflows are 194 kcfs, 269 kcfs, and 267 kcfs, respectively.

B1 My Comments on Mr. Wahl's Review on the BREACH

- Value of $n=0.025$ is conservative and reasonable; $n=0.05$ is extremely conservative; and $n=0.075$ or larger is not credible.
Comment: This assertion is based on a faulty application of the Strickler's equation. Value of $n=0.025$ results in $B=183$ ft and $Q_p=30$ kcfs, which are too small for MCR.
- The Strickler equation or other methods that estimate n -values should be used.
Comment: The Strickler's equation was developed for a small immovable sand channel, thus it cannot be use for large bank materials. STP and the staff did not use this equation as BREACH uses the equation only for $n<0.001$. (Ahn, 2012a,b,c)
- BREACH should use n -value related to embankment materials only.
Comment: This statement is incorrect because bottom roughness for a composite materials is driven mainly by large size materials.
- Cement blocks would not have a bearing on n -value because breach outflow has enough dynamic energy to remove any cement block.
Comment: This assertion is against the field observation at the Martin Cooling Pond breach where broken cement blocks littered on the breach bottom (SFWMD, 1980).
- Use of Chow (1959) method to incorporate effects of obstructions, vegetation, channel variability and other factor is inappropriate.
Comment: This is not true as the Chow method is one of a few methods that can incorporate such effects, therefore the method is widely used in practice.

B1 My Comments on Dr. Patev's Review of MCR Breach




Dr. Patev focused his review on the geotechnical aspects of MCR breach, then concluded that a wide breach with scour hole is highly unlikely. However many of his assertions are speculative or not factual as:

- Seepage failure is highly unlikely because of compacted silt-clay, seepage control system (e.g., relief wells, sand chimney, berms, etc.), and low permeability (10^{-5} cm/sec). Foundation materials consist with two different clays. – **Comment: He failed to recognize sand layers in foundation, through which seepage has been observed.**
- The seepage control system has been working well. There is no evidence of continued seepage problem. There are no reports of significant water discharges or boils. – **Comment: This is not factual. STP has been observed seepage.**
- Inclusion of a scour hole is not recommended due to the foundation soils that has a cohesive share strength of 2000 psf, it is “unlikely to see erosion in the foundation” – **Comment: He missed the fact that the strength of the clay in embankment and foundation has been decreased substantially after construction (from 2000 psf to <300 psf). He also failed to recognize piping potentials through sand layer or land subsidence. Piping through the MCR foundation will easily lead a deep scour hole.**
- “MCR is like a failed dam because it lose its containment very quickly.” – **Comment: This is not true. My BREACH runs shows that breach process lasts more than a day due to a large storage volume, incurring a large breach width.**

B2 1979 Martin Cooling Pond Breach

Breach Conditions:

- Fine silt-sand in levee and foundation
- Initiated by a foundation piping failure
- Breach head is 17 ft, which is lower than that of MCR (about 22 ft).
- Actual breach head is about 12 ft due to the obstruction of tailwater flow by railroad and L-65 levee.



B2 Comparison of MCR and MCP Embankments

Area	Parameter	MCR	MCP
Geometry	Reservoir Area (ac)	7000	6600
	Breach Head (ft)	21.9	16.74
	Storage Volume (ft ³)	6.6x10 ⁹	3.0x10 ⁹
	BFF (ft ⁴)	1.44x10 ¹¹	0.5x10 ¹¹
Levee/ Foundation	Main Materials	silt-clay	silt-sand
	Cohesion (lbs/ft ²)	200	0
	Friction Angle (°)	15	38
Seepage Control	Sand Core/Blanket	Yes	No
	Abutments	Yes	Yes
	Relief Wells	774	No

Note: BFF=breach formation factor (head x storage volume).

B2 Estimation of Breach Widths using Empirical Equations

Empirical Equation	Breach Width (ft)	
	MCR	MCP
USBR	66	44
Von Thun and Gillette	235	217
Froehlich (upper bounding)	417 (1001)	306 (682)
MLM	745	537
Recorded	-	610

Comments:

- The upper bounding of the Froehlich equation is based on the best-fit estimation plus an upper 2 standard deviation of prediction errors.
- The result indicates that the bounding Froehlich breach width or MLM breach volume equations are adequate for MCP, thus for MCR.

B2 Calibration of an Optimal MCP n-value by BREACH

N-value	Qp(kcfs)	Tp (hr)	B(ft)
0.025	21	18.8	179
0.03	29	14.9	225
0.04	44	10.6	338
0.05	62	8.0	468
0.06	82	6.4	617
0.07	105	5.3	780
0.075	117	4.7	851
0.08	127	4.0	884

Notes: Qp=peak outflow, Tp=peak time,
B=average breach width.

MCP=Martin Cooling Pond in Florida

USBR=U.S. Bureau of Reclamation

Recorded MCP Breach Parameters:

- B=600 ft (610 ft by USBR)
- Qp=98 kcfs (110 kcfs by USBR)
- Tp=4 hours.

Comments:

- The calibration show that optimal MCP n-values range from 0.06 to 0.08 without scour hole, or from 0.08 to 0.12 with a scour hole.
- Therefore, **n-value of 0.075 is reasonable**, if not highly conservative, for both MCP and MCR.

BACKUP 3 Comparison of Hurricane Scenarios

Parameter	STP	NRC/PNNL	USACE
Storm Scenario	NWS 23	NWS 23	MPI
Center Pressure (mb)	887	887	880
Radius (nm)	21	21	30~42
Moving Speed (mph)	23	22	6~13
Wind & Pressure Profiles	NWS 48	NWS 48	TC96
Max. Wind Speed (mph)	184	150	134

Notes:

- **NWS**: National Weather Service of NOAA
- **MPI**: maximum possible intensity
- **TC96**: Thompson & Cardone paper in 1996
- mb=milibar; nm=nautical mile; mph=mile per hour
- Wind speed is a function of pressure gradient and radius.

B3 Surge Estimates in SER

Parameter	STP	Staff/PNNL	USACE
Wind Model Surge Models	SWAN, ADCIRC	SLOSH	WAN, STWAVE, ADCIRC
a. Initial Condition Total (ft)	4.9	6.0	9.7 (add after)
-10% high tide (ft)	3.5	2.2	2.2
- Initial rise (ft)	-	2.4	2.6
- Sea level rise (ft)	1.4	1.4	1.9
- Model uncertainty (ft)	-	-	3.0
b. Surge (ft msl)	29.3	39.6	30.1
PMSS (ft msl) (a+b)	29.3	39.6	39.8

Comments:

Dr. Resio said that STP's storm radius is small (not-conservative) but the storm intensity after landing is high (conservative) so that the STP's surge estimate of 29 ft msl is acceptable. However, he failed to recognize that STP and staff/PNNL set an **initial condition** before surge modeling, while USACE added the initial condition after surge modeling.

Note: msl=mean sea level; PMSS=probable maximum storm surge; WAN is a off-shore wave model; STWAVE is a near-shore wave model; ADCIRD and SLOAH are a storm surge model.

B3 Comments on Staff's Hurricane Surge Evaluation

The staff: Concluded that the STP's ADCIRC surge estimate which is much lower than the USACE's estimate is acceptable because STP uses a finer model grid size and the topographic features of the Matagorda levee and dredge pile.

My Opinions: I disagree with the above conclusion because:

- The STP's hurricane intensity is lower than the maximum potential intensity (MPI) of hurricanes, but their **maximum wind speed is unrealistically high**.
- The STP's ADCIRC was not validated as two external reviewers pointed out.
- Conservative surge scenario is to run the surge model without two topographic features that could be washed out by hurricane surges.
- The exceedance probabilities of storms ($10^{-7} \sim 10^{-12}$) in SER Table 2.4S.5-4 are **too low** compared to others ($10^{-4} \sim 10^{-5}$).
- STP did not account for the uncertainty in data and models.

BACKUP 4 List of References

- *Ahn, H, 2012a, Reasons for Non-Concurring the Management Decision on the Hydrology Issues for the STP COLA, NRC, (ML12312A102).
- *Ahn, H, 2012b, Comments on the Peer Review Reports to STP Levee Breach Non-Concurrence Issues, NRC (ML12311A118)
- *Ahn, H, 2012c, Mr. Wahl's MCR breach review report (the version commented by H. Ahn) (ML12311A120).
- Chow, V.T. 1959. Open Channel Hydraulics. McGraw-Hill, New York.
- Colorado, 2010, Guidelines for Dam Breach Analysis. CO.
- Fenton, et al., 2006, Peak discharge of a Pleistocene lava-dam outburst flood in Grand Canyon, Arizona, USA, Science Direct, Qtr. Res. 65, p.324-335.
- Fread, D.L., 1988 (revised in 1991), BREACH, An Erosion Model for Earthen Dam Failures, National Weather Service, NOAA, Silver Spring, MD.
- Hydraulic Engineering Center (HEC), 2010, HEC-RAS Hydraulic Reference Manual, V. 4.1, USACE, HEC.
- Maidment, D. R. 1993, Handbook of Hydrology, McGraw-Hill Inc.
- Nagy, L, 2006, Estimating Dyke Breach Length from Historical Data, Periodics Polytechnica Ser. Civ. Engr. Vol. 50, No. 2, pp125-139.
- New Jersey, 2011, Guidelines for Developing an Emergency Action Plan: Attachment E, Guidelines for Dam Breach Analysis, NJ.
- NRC, 2012, STP COLA Hydrology Non-concurrence Package, NCP-2011-014, ML12348A249).
- South Florida Water Management District, 1980, Interim Final Draft Report on Embankment Failure FPL Company Martin Plant Cooling Reservoir, WPB, FL).
- *Trieste D.J., and R.D. Jarrett, 1987, Roughness Coefficients of Large Floods, Specialty Conference on "Irrigation Systems for the 21st Century", Proc., p. 32-40, Portland, OR.(ML12311A127).
- Wahl, T., 2004, Uncertainty of Prediction of Embankment Dam Breach Parameters, J. o Hydraulic Engineering, v. 130, No. 5. ASCE

Note: (*) indicates ADAMS's internal documents.



Presentation to the ACRS Subcommittee

**South Texas Project Units 3 and 4
COL Application Review**

**NCP STP
Chapter 2.4 Hydrology**

**Presenters:
Dr. Henry Jones, NRC
Dr. Rajiv Prasad, PNNL**

April 24, 2013



Non-Concurrence Process (NCP) Issues

The NCP raised three issues:

- 1. The Staff's MCR breach flood analysis is not conservative** (SER Section 2.4.4)
 - a. The Froehlich equation is not applicable to the MCR
 - b. The Staff's NWS BREACH modeling incorrectly specified a tailwater cross-section
 - c. Manning's n values could be greater than 0.075
 - d. The Staff's comparison of MCR breach to that of Martin Cooling Pond is inappropriate
 - e. The Staff's use of NWS BREACH model is inappropriate
 - f. The Staff did not consider scouring of the MCR embankment foundation
- 2. Hurricane storm surge and MCR embankment breach** (SER Section 2.4.5)
 - a. NWS 23 PMH scenarios are not conservative
 - b. The Staff should review the applicant's ADCIRC model
- 3. The SER inappropriately identified the maximum groundwater level** (SER Section 2.4.12)
 - a. Erosion of the clay cap and stone layer could result in saturation of the soil profile
 - b. Therefore, a departure from DCD occurs



Independent Review of NCP Issues

1. Independent reviewers for dam breach related issues (SER Section 2.4.4)

1. Tony L. Wahl, PE, Hydraulic Engineer, Hydraulic Investigations and Laboratory Services Group, Bureau of Reclamation
2. Gregory B. Baecher, PhD, Professor, Civil and Environmental Engineering, University of Maryland
3. Robert C. Patev, Senior Risk Advisor, Risk Management Center, USACE

2. Independent reviewers for PMH surge issues (SER Section 2.4.5)

1. Jennifer L. Irish, PhD, PE, D.CE, Associate Professor, Virginia Polytechnic Institute and State University
2. Rick Luettich, PhD, Director of Institute of Marine Science, University of North Carolina at Chapel Hill
3. Donald P. Resio, PhD, Director Taylor Engineering Research Institute, College of Computing, Engineering and Construction, University of North Florida (previously of USACE Engineer Research Development Center Coastal and Hydraulics Laboratory)

3. No external review for groundwater level issues; NRC Staff determination (SER Section 2.4.12)



Resolution of NCP Issues

- 1. The Staff's MCR breach flood analysis is not conservative (SER Section 2.4.4)**
 - a. The independent review states that Froehlich equation is applicable to breach widths exceeding 164 ft; and concludes that Froehlich equation has less uncertainty than other approaches and maintains an appropriate amount of conservatism
 - b. The independent review states that the Staff's independent NWS-BREACH analysis specified a realistic tailwater cross section and while additional sensitivity runs at Manning's n value of 0.075 would have been useful, the Staff's conclusions would remain unaltered
 - c. The independent review finds Manning's n value of 0.05 is extremely conservative; 0.075 is not credible
 - d. The independent review states that the staff's comparison of MCR breach to Martin Cooling Pond failure is appropriate; and states that piping failure of MCR embankment would not result in a wide breach as in riverine levees; and states that piping is most likely failure mode



Resolution of NCP Issues

1. The Staff's MCR breach flood analysis is not conservative (SER Section 2.4.4) (continued)

- e. The independent review found the Staff's use of NWS-BREACH acceptable
- f. The independent review states that effects of a scouring hole formed directly under the MCR embankment are unproven; and states that geotechnical conditions at the site mitigate against scour; and states that the clays in the MCR embankment are moderately to very stiff, making erosion of the foundation highly unlikely; and recommends that a scour hole in the breach analysis be not included

As discussed, the Staff has resolved NCP Issue #1

Resolution of NCP Issues

2. Hurricane storm surge and MCR embankment breach (SER Section 2.4.5)

- a. The applicant's ADCIRC PMSS is below site grade (10.4 m [34 ft]) and is equal to the main cooling reservoir north embankment grade level (8.8 m [29 ft]), thus the main cooling reservoir embankment is safe against erosion
- b. The independent review states that PMH from NWS 23 is smaller in size compared to a few storms that have occurred in the Gulf of Mexico during the past few decades
- c. The independent review performed an estimate of expected changes to applicant-estimated PMSS water surface elevation if a storm larger than the PMH but with decaying intensity during landward approach were used based on a suite of ADCIRC runs that used rare and large hurricanes near Matagorda Bay
- d. The independent review estimated that the relative magnitudes of changes to maximum surge water surface elevation—an increase because of larger size and a decrease because of decaying intensity—would approximately cancel each other

Resolution of NCP Issues

2. Hurricane storm surge and MCR embankment breach (SER Section 2.4.5) (cont'd)

- e. The independent review concluded for the STP site that using larger, strong, but decaying storms would not change staff's conclusions in the SER The independent review agreed that ADCIRC model is appropriate
- f. The independent review agreed that the staff's review of ADCIRC model and applicant's simulations is reasonable and acceptable
- g. The independent review suggested that a recalibrated ADCIRC addressing rare and large hurricanes near Matagorda Bay by Resio should be used
- h. The independent review suggested that staff should perform ADCIRC runs to estimate surge from extremely large but moderately strong hurricanes

Resolution of NCP Issues

2. Hurricane storm surge and MCR embankment breach (SER Section 2.4.5) (cont'd)

- i. No wave/significant current action on north face of MCR – Winds from the north would oppose surge or current development.
- j. The staff calculated maximum current velocities of 1.2 m/s (4 ft/s) to 1.6 m/s (5 ft/s) for the NRC SLOSH and USACE ADCIRC storm surges. Flow duration is 80 minutes.
- k. For this duration, Hewlett et al.(1987) state that depending on the quality of the grass cover, grass-lined channels can sustain velocities of 2.7 to 4.3 m/s (9 to 14 ft/s).
- l. The predicted velocities fall below 2.7 to 4.3 m/s (9 to 14 ft/s). This suggests that the grass cover would be able to withstand this level of a hydraulic attack.

Resolution of NCP Issues

2. Hurricane storm surge and MCR embankment breach (SER Section 2.4.5) (cont'd)

- m. These ADCIRC runs were completed by the USACE under NRC contract in 2011 and modified to reflect site specific characteristics. PMSS below MCR breach flooding level using storms with exceedance probabilities of 10^{-8} to 10^{-13} .
- n. Even if the grass cover were damaged within this time frame, the clay content of the underlying zone B materials (clay with a liquid limit ≥ 30) suggests that these materials would have at least a moderate resistance to erosion.
- o. The maximum mean current velocities that are considered to be safe against erosion are 1.2 to 1.5 m/s (4 to 5 ft/s) for stiff clay soil and ordinary gravel².which falls within the staff's current velocity calculations.

As discussed, the Staff has resolved NCP Issue #2

²Fortier and Scobey, 1926; Connecticut Council for Soil and Water Conservation, 1985

Resolution of NCP Issues

3. The SER process for identifying maximum groundwater level is inappropriate (SER Section 2.4.12)

- a. For the ABWR maximum groundwater level, the DCD Tier 1 limit is two feet below plant grade. The non-concurrence states that the FSAR site characteristic is 28 ft msl for groundwater. This is correct. A surface water departure was implemented for the two proposed units in accordance to the DCD limit. A surface water departure was required for the ABWR if a DBF is shown to exist at a level equal to or higher than 1 foot below plant grade.
- b. For the proposed STP units, the surface water departure equated to 33 ft msl. The NRO Division of Engineering evaluated saturated conditions from 28 ft to 33 ft msl. They also evaluated the design basis flood impacts from 34 ft to 40 ft msl – no safety deficiencies were noted.
- c. In summary, the non-concurrence incorrectly puts the DCD term “maximum groundwater level” in the wrong context by failing recognize that his requirement is valid only during a non-design basis flood event. Regarding this third topic, no further actions are recommended.

Resolution of NCP Issues

1. The Staff's MCR breach flood analysis is not conservative (SER Section 2.4.4)

- a. As discussed above, the technical issues were resolved
- b. Changes to the SER Section 2.4.4 were made
 - i. The Staff added text to explain the Staff's review of the applicant's use of empirical methods
 - ii. The Staff added text to explain the tailwater sensitivity analysis
- c. The Staff's conclusions in SER Section 2.4.4 did not change

2. Hurricane storm surge and MCR embankment breach (SER Section 2.4.5)

- a. As discussed above, the technical issues were resolved
- b. Changes to the SER Section 2.4.5 were made
 - i. The Staff added text to explain that the PMH is appropriately conservative
 - ii. The Staff added a sensitivity analysis that used storms less intense but larger than the PMH
- c. The Staff's conclusions in SER Section 2.4.5 did not change

3. The SER inappropriately identified the maximum groundwater level (SER Section 2.4.12)


- a. DSEA management concludes that all necessary departures have been requested
- b. No changes to the SER; No change to Staff's conclusions in SER Section 2.4.12

**ACRS Subcommittee Presentation
SER with no Ols Chapter 2**

Discussion/Committee Questions


**ACRS Subcommittee Presentation
SER with no Ols Chapter 2**

Back up Slides



Chapter 2 – Site Description (Continued)

Site layout showing Main Cooling Reservoir (MCR) and locations of STP Units 1 & 2 and STP Units 3 & 4:




STP 3&4 COLA Presentation to ACRS ABWR Subcommittee 06/21/2011




Probable Maximum Storm Surge (Continued)

- PMSS potential threat to MCR Embankment (RAI 02.04.05-10)
 - SLOSH models do exceed 34 ft. In “worst case” the flood level is ≥ 34 ft for < 80 minutes. No wind waves and only moderate current.
 - There is no threat to MCR Embankment.




MCR Embankment Cross Section with superimposed cross section of Texas City Hurricane Storm Levee



TYPICAL SECTION THROUGH EMBANKMENT

SCALE: 1" = 30'

NOTE: SECTION SHOWN REPRESENTS TYPICAL SECTION. SAND DRAINAGE BLANKET AND TOE DRAIN APPLIES TO APPROXIMATELY 6% OF EMBANKMENT PERIMETER. FOR MORE DETAILS OF VARIATIONS IN THIS CROSSSECTION SEE FS.A.R. SECTION 2.5.6.



TYPICAL SECTION THROUGH DIKE


SCALE: 1" = 30'

SOUTH TEXAS PROJECT UNITS 1 & 2

COOLING RESERVOIR EMBANKMENT
AND INTERIOR DIKES TYPICAL
SECTIONS

Figure 2.4.8-3

Revision 0





Exit ground-level view




© 2013 Google
Image © 2013 TerraMetrics
Data SIO, NOAA, U.S. Navy, NGA, GEBCO

Google earth

Imagery Date: 10/28/2012 1989

Eye alt 19 m




Data SIO, NOAA, U.S. Navy, NGA, GEBCO
© 2013 INEGI
© 2013 Google

Google earth

Imagery Date: 1/25/2011 2005

Eye alt 10 m



Model Comparison – Differences

- **Grid Resolution**
- **Terrain Features (City of Matagorda Levee)**
- **Wind Model**
- **Friction Coefficients**
 - Bottom
 - Surface
- **Pressure Differential**
 - SLOSH: 133 Mb
 - ADCIRC: 123 Mb to 126 Mb

Page 75, Paragraph 4
Page 83, Paragraph 2
Page 86, Paragraphs 2 & 3
Page 88
Pages 96-97 (Conclusion)



Features





SLOSH


- Incorporating
 - SLOSH surface wind fields as wind stress
 - Overtopping of barrier systems, levees, and roads
 - Inland inundation using wet and dry
 - Sub-grid size events, flow through barrier gaps, adverse river flow, and deep passes between bodies of water via simple (1-d) hydraulic procedures
- Not incorporating
 - Upstream river flow and rain
 - Wind-generated waves
 - Astronomical tides

ADCIRC


- Incorporating
 - Overtopping of barrier systems, levees, and roads
 - Upstream river flow and Inland inundation using wet and dry
 - Astronomical tides
- Incorporating as options
 - Meteorological forcings (i.e., surface winds and pressures)
 - Wind-generated waves as the gradient of wave radiation stresses
 - Spatially variable bottom frictions
 - Surface wind roughness and canopy

Numerical Model Grids





Model will not “see” the feature (e.g. Levee)
due to low spacial resolution (e.g., SLOSH)




Model will “see” the feature (e.g., Levee)
due to high spacial resolution (e.g., ADCIRC)



Example Grid




SLOSH (emo2)



- App. 100 basin grids along the east coast of United States
- emo2: Mobile Bay (2008) v3
- App. 31,000 points

ADCIRC



- Based on EC95 mesh (nodes: app. 31,000)
- Unstructured grids (Mobile Bay to St Andrew Bay)
- App. 450,000 nodes




Example

Bathymetry/Topography




SLOSH (emo2)



- » Datum: NAVD 88
- » Bathymetry: GEODAS (GEOphysical Data System)
- » Topography: USGS (U.S. Geological Survey) topographic maps


ADCIRC



- » Datum: NAVD 88
- » Bathymetry: GEODAS + EC2001 (East Coast 2001 ADCIRC grid)
- » Topography: Bare-earth LIDAR data by county + USGS NED (National Elevation Dataset)




Topographic Data – SLOSH






Topographic Data – ADCIRC






Cross Sections AA' and BB' for SLOSH






Cross Sections AA' and BB' for ADCIRC







Cross Section A-A' for SLOSH and ADCIRC






Cross Section B-B' for SLOSH and ADCIRC






Basin: Matagorda Bay v1 <psx>

Storm: C:/slosh.pkg/sloshdsp/rexfiles/pmh3072.rex





Basin: Matagorda Bay v1 <psx>

Storm: C:/slosh.pkg/sloshdsp/rexfiles/pmh3072.rex


SLOSH Wind field
1 min avg KTS(MPH)
34(39) 65(75) 100(115)



04/24/2008
08:00:00 UTC

Stm Tide
FT NGVD-29
35
30
25
20
15
10
5
0
Tide level:
4.9(0.0) ft

Max flooding level reached in 50 minutes and remains only thirty minutes – zoom image.





Maximum Groundwater Level (Action Item 58)

ABWR DCD limit and STP Site Characteristic for max groundwater level:
“61.0 cm (2.0 feet) below grade” (Table 2.0-1)

Site Characteristic limit as function of site grade required individual evaluation and engineering judgment for each application because:

- STP site grade varies from 36.6 feet MSL at the center of the power block to 32 feet MSL at the corners of the powerblock with a nominal power block elevation of approximately 34 feet MSL.

