

**Official Transcript of Proceedings**  
**NUCLEAR REGULATORY COMMISSION**

Title: Meeting of the Advisory Committee on  
Reactor Safeguards  
ABWR Subcommittee

Docket Number: N/A

Location: Rockville, Maryland

Date: November 05, 2014

Work Order No.: NRC-1195

Pages 1-216

NEAL R. GROSS AND CO., INC.  
Court Reporters and Transcribers  
1323 Rhode Island Avenue, N.W.  
Washington, D.C. 20005  
(202) 234-4433

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION  
+ + + + +  
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS  
(ACRS)  
+ + + + +  
ABWR SUBCOMMITTEE  
+ + + + +  
WEDNESDAY  
NOVEMBER 5, 2014  
+ + + + +  
ROCKVILLE, MARYLAND  
+ + + + +

The Subcommittee met at the Nuclear  
Regulatory Commission, Two White Flint North, Room  
T2B1, 11545 Rockville Pike, at 8:30 a.m., Michael  
Corradini, Chairman, presiding.

COMMITTEE MEMBERS:

MICHAEL L. CORRADINI, Member  
RONALD F. BALLINGER, Member  
DENNIS C. BLEY, Member  
CHARLES H. BROWN, JR. Member  
HAROLD B. RAY, Member-at-Large  
STEPHEN SCHULTZ, Member  
JOHN W. STETKAR, Member

1 DANA POWERS, Member

2 DESIGNATED FEDERAL OFFICIAL:

3 MAITRI BANERJEE

4 ALSO PRESENT:

5 JIM ANGLES, NINA

6 BRET BRICKNER, NINA

7 EVANS HEACOCK, NINA

8 SCOTT HEAD, NINA

9 BILL MOOKHOEK, NINA

10 STEVE THOMAS, NINA

11 JIM TOMKINS, NINA

12

13

14 NRC STAFF:

15 LUIS BETANCOURT, NRO/DNRL

16 ATA ISTAR, NRO/DE/SEB2

17 YONG LI, NRO

18 SHEILA RAY, NRR/DE/EEEE

19 DIEGO SAENZ, NRR/DSS/SRXB

20 TOM TAI, NRO/DNRL

21

22

23

24

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

P-R-O-C-E-E-D-I-N-G-S

(8:30 a.m.)

CHAIR CORRADINI: Okay, this meeting will come to order, please. This is a meeting of the Advanced Boiling Water Reactor, ABWR, subcommittee for the ACRS. My name is Michael Corradini. I am chairman of the subcommittee.

ACRS members currently in attendance are Ron Ballinger, Dennis Bley, John Stetkar, Dana Powers and Steve Schultz. We will expect a few others to be joining us presently. We also have Ms. Maitri Banerjee as our designated federal official for the meeting.

As announced in the Federal Register on October 22, 2014, the subject of today's briefing is various sections of the COL application submitted by Nuclear Innovation North America, or NINA, for the South Texas Project's Unit 3 and 4 and the staff final safety evaluation report.

This will include Chapter 9 auxiliary systems, Section 8.2(s) that addresses the STP response to Bulletin 2012-01 to design vulnerabilities and electric power systems issued by the NRC on July 27, 2012 and STP evaluation of potential Part 21 issues by GEH containment loads potentially exceed limits with high suppression pool water level in the ABWR design.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

1           The rules for participation in today's  
2 meeting were announced in the Federal Register notice  
3 on October 22nd that stated that portions of the meeting  
4 could be closed to the public to discuss proprietary  
5 information.

6           I'll just add, parenthetically, that we  
7 don't think that will be the case. But I leave it to  
8 GEH -- I leave it to --

9           Them too. If you want to say that.

10          CHAIR CORRADINI: -- to NINA to alert us  
11 if a topic like that comes up, that we have to postpone  
12 it and close the session.

13          Yes, sir.

14          CHAIR CORRADINI: We have a telephone  
15 bridge line open for members of the public and  
16 stakeholders to hear the deliberations. To minimize  
17 disturbances, this line will be kept in a listen-in only  
18 mode until the end of the meeting where we will provide  
19 about ten minutes for public comment.

20          My understanding is there are a couple  
21 people from the public on the line that are listening,  
22 and we'll come to them at the end of the subcommittee  
23 meeting. We'll check on those members at that time to  
24 get, at the close of the end of the subcommittee  
25 meeting, to hear their comments and questions.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           As the meeting is transcribed, I request  
2 that participants in this meeting use microphones  
3 located throughout the room when addressing the  
4 subcommittee. Participants should first identify  
5 themselves and speak with sufficient clarity and volume  
6 so that that can be readily heard.

7           Also, please silence all cellphones,  
8 pagers, iPhones, iPads and all appropriate appliances.  
9 Don't be like Tom Brokaw last night on CNN. We will  
10 now proceed with the meeting, and I'll call upon Tom  
11 Tai, of NRO, to begin the presentation. Tom?

12           MR. TAI: Thank you, Chair Corradini.  
13 Good morning. My name is Tom Tai. I'm the Lead PM for  
14 South Texas. We're here to present Chapter 8 and  
15 Chapter 9.

16           Chapter 9 was a Phase 2 to Phase 4  
17 transition except 9.1 and 9.1.2. So we'll be focusing  
18 our presentation on 9.1.1 and 9.1.2 and highlight what  
19 we changed for the other sections.

20           Sam Lee, our branch chief, he's not here  
21 today, so if there's any questions of Sam then I guess  
22 I'll have to take it for him. This is the last but one  
23 subcommittee meeting for South Texas.

24           CHAIR CORRADINI: Second to last.

25           MR. TAI: Second to last. And how many --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 hopefully we'll finish it off with Fukushima, then we  
2 are done. So I'm really looking forward to that. So  
3 that you. That's all I have.

4 CHAIR CORRADINI: So, Scott, you're going  
5 to lead us through this today?

6 MR. HEAD: Yes, sir.

7 CHAIR CORRADINI: Okay, it's all yours.

8 MR. HEAD: Well, we appreciate the  
9 opportunity to brief the ACRS on these topics today.  
10 The first one, as Tom said, we're going to go over  
11 Chapter 9 and focus on the spent fuel racks.

12 Attendees, myself, Steve Thomas, will do  
13 the briefing today on this but then we'll go to Jim  
14 Engles and Jim Tompkins. Also today, from Holtec, we  
15 have with us Chuck Bullard, Bret Brickner and Tao He  
16 to assist us if there are any questions that come up  
17 in that area.

18 The agenda, we're going to go over the  
19 Chapter 9 status. We'll talk about our new fuel rack  
20 departure that we took. And then Steve will go through  
21 the spent fuel rack design analysis and we'll cover the  
22 COL items and conclude.

23 With respect to Chapter 9, we're going to  
24 cover the spent fuel rack storage or new and spent fuel  
25 storage. And a presentation back in October of 2010

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 we, in essence, covered the rest of Chapter 9. And so  
2 this really is going to be focusing, you know, our  
3 presentation, at least is going to be focusing on spent  
4 fuel racks, okay?

5 It's one of the interesting things of this  
6 review is early on, as we were going through the review,  
7 recognizing that there would be a review regarding the  
8 new fuel storage racks and the spent fuel racks, those  
9 that had refueling experience at STP asked the  
10 question, why are we licensing new fuel racks?

11 We don't use those anymore at 1 and 2 for  
12 a very good reason. It incurs an extra fuel movement  
13 that we've eliminated at 1 and 2. And for efficiency  
14 reasons, cost-savings and otherwise, why don't we go  
15 ahead and embark upon a departure to remove the new fuel  
16 racks from the licensing basis.

17 And so we've done that. And so fuel will  
18 basically move from whatever inspection it goes through  
19 into the spent fuel pool and we won't be licensing new  
20 fuel racks with the STP 3 and 4 licensing basis.

21 So that's the gist of the departure. And  
22 it was cost-savings and it's just a recognition of how  
23 we really move fuel in today's world.

24 MEMBER STETKAR: When you did that, Scott,  
25 though, it -- I guess I didn't appreciate how small the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 fuel pool is, the spent fuel pool, until I started  
2 thinking about this. Correct me if I'm wrong.

3 It said that the current capacity of the  
4 racks, the plant capacity of the racks, is 2,380 fuel  
5 assemblies, which is a little bit more than 270 percent  
6 of the reactor core --

7 MR. HEAD: Correct.

8 MEMBER STETKAR: -- which, if you refuel  
9 a third of the core at every outage, plus the third of  
10 the new fuel, plus space for one full core offload,  
11 gives you about four refueling outages before you need  
12 to start putting fuel in dry casks. Is that right?

13 MR. THOMAS: It's ten years.

14 MEMBER STETKAR: Yes, so it's after the  
15 fourth --

16 MR. THOMAS: Ten years maintaining full  
17 core discharge capability.

18 MEMBER STETKAR: Yes. Yeah, okay.

19 MR. HEAD: And that aligns with our future  
20 strategies as well and the country now are going through  
21 it. So that was acceptable to us.

22 CHAIR CORRADINI: Well put.

23 MR. HEAD: Okay.

24 MEMBER STETKAR: I just wanted to make  
25 sure I had the math right. I mean -- okay.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. HEAD: Okay, so that's the Tier 1  
2 departure that we took. And I believe the next slide  
3 we've got, I'm going to turn it over to Steve to, just  
4 to give a briefing on the spent fuel racks that were  
5 used.

6 MR. THOMAS: All right, thanks, Scott.  
7 My name's Steve Thomas. I'm the engineer/manager on  
8 STP Units 3 and 4.

9 As stated in the design certification  
10 document, Chapter 9, the spent fuel racks are procured  
11 equipment items. The racks themselves are not  
12 described in the DCD. Instead, there's a set of  
13 requirements that the supplier of the racks is required  
14 to satisfy, you know, when that equipment is designed  
15 and analyzed.

16 So although we haven't procured the  
17 hardware yet, we have selected a vendor, Holtec  
18 International, to perform the design and analysis of  
19 the spent fuel racks.

20 Holtec has been supplying spent fuel  
21 storage equipment for well over 20 years and has  
22 designed, analyzed and licensed similar equipment to  
23 what we're describing today for many utilities. In a  
24 few of the more recent spent fuel projects Holtec's  
25 projects are shown on this slide. Let's go to the next

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 slide.

2 So STP 3 and 4 spent fuel racks are proven  
3 designs, similar to many others, equipped with Metamic  
4 neutron absorber, and the racks are designed for a  
5 60-year life. Spent fuel storage racks have a minimum  
6 capacity, as mentioned earlier, just over 270 percent  
7 of the reactor core, as required by the design  
8 certification document for a total of 2,380 storage  
9 locations.

10 And the spent fuel racks are free-standing  
11 and self-supporting, also, as specified in the DCD.  
12 All the spent fuel storage racks have been designed to  
13 meet the stress limits and have been analyzed in  
14 accordance with requirements of ASME Section III,  
15 Division 1, NF.

16 And free-standing modules are stable  
17 against tipping and overturning under postulated safe  
18 shutdown earthquake events for the plant. The racks  
19 are also designed to provide natural circulation  
20 cooling through the racks, such that the coolant  
21 temperature in the rack structure itself never exceeds  
22 100 degrees Celsius.

23 Racks are designed for a maximum fuel  
24 enrichment of 5 weight percent if you account for  
25 integrated gadolinium in the fuel and 2.95 weight

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 percent enrichment without gadolinium in the fuel,  
2 maintaining a reactivity of less than 0.95, again, as  
3 required by the DCD.

4 MEMBER SCHULTZ: Steve, just one  
5 question.

6 MR. THOMAS: Yes, sir.

7 MEMBER SCHULTZ: Why is the design life of  
8 the racks 60 years? You'll have to utilize them. If  
9 the life of the plant's 60 years you'll have to utilize  
10 the racks, the spent fuel pool, for some time after the  
11 plant closes.

12 MR. THOMAS: That's a good question, but  
13 I think that probably -- first of all, of course, we're  
14 licensing the plant for 40 years, although we're  
15 designing the plant for 60-year life.

16 The surveillance coupon program extends  
17 out to 60 years. I would imagine at that time we would  
18 have to do something else with the racks which would  
19 be primarily offload the spent fuel into dry cask  
20 storage.

21 MEMBER SCHULTZ: Is there a limiting  
22 design feature associated with 60 years?

23 MR. THOMAS: Not really. Probably the  
24 criteria would be the condition of the Metamic after  
25 60 years, and that's why we have coupon surveillance

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 programs for that period of time for the design life  
2 of the racks.

3 MEMBER SCHULTZ: Thank you.

4 MR. THOMAS: Holtec performs a whole pool  
5 multi-rack dynamic analysis using a Holtec proprietary  
6 code, DYNARACK. Again, this has been used on many  
7 previous applications. One of the interesting aspects  
8 of the STP 3 and 4 spent fuel racks is the safe  
9 shutdown/earthquake that these racks have been  
10 analyzed to.

11 DCD requires a safe shutdown/earthquake  
12 with 0.3 G ground motion. The site-specific  
13 earthquake is about 0.13 G, so they are designed for  
14 the DCD requirement which is considered higher than the  
15 actual site-specific safe shutdown/earthquake.

16 Also in the ABWR, the racks are located at  
17 a relatively high location in the reactor building so  
18 the building response creates an additional seismic  
19 demand. This is probably one of the more challenging  
20 aspects of this particular design.

21 And even though the racks are a very  
22 similar design which has been used many times in the  
23 industry, a few of the features, structural features  
24 of the racks, are a little bit more substantial than  
25 what you might normally see.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 CHAIR CORRADINI: That's because of where  
2 they sit vertically?

3 MR. THOMAS: It's where they sit in the  
4 reactor building.

5 CHAIR CORRADINI: Sorry.

6 MR. THOMAS: It's --

7 CHAIR CORRADINI: I meant vertically  
8 within the --

9 MR. THOMAS: -- the elevation in the  
10 building. So these particular racks to have slightly  
11 thicker cell walls, a thicker base plate, bumper bars  
12 at the top of the racks to distribute the rack-to-rack  
13 impact loads during a seismic event, larger bearing  
14 pads to accommodate sliding displacements of the racks.

15 As I mentioned -- did I skip over a slide?  
16 I think --

17 CHAIR CORRADINI: Jim might have.

18 MR. THOMAS: Okay.

19 CHAIR CORRADINI: Maybe you could use it.

20 MR. THOMAS: Okay. So the racks are 17 by  
21 20 rows, which is a very large rack, which give them  
22 a large aspect ratio to give them more stability against  
23 tipping during an earthquake. And then we've added a  
24 fifth foot on the base plate in the center of the rack,  
25 again, to accommodate higher loads.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 CHAIR CORRADINI: But the concept is,  
2 besides the bumper bars, is that they're free to, in  
3 an event, slide around a bit?

4 MR. THOMAS: That's correct.

5 CHAIR CORRADINI: Okay.

6 MR. THOMAS: They're free, I think, six  
7 degrees of freedom and they can slide back and forth,  
8 tip and --

9 CHAIR CORRADINI: Okay.

10 MR. THOMAS: -- complete freedom of  
11 motion.

12 CHAIR CORRADINI: Thank you.

13 MR. THOMAS: There's the one I skipped  
14 over. It's showing you the layout of the rack. All  
15 seven racks are identical, 20 by 17 racks. Again,  
16 these are probably a little bit larger than the standard  
17 racks to provide a larger aspect ratio against tipping.

18 The rest of the analysis has been a pretty  
19 typical analysis in terms of criticality, thermal-  
20 hydraulic evaluation and mechanic accidents. Again,  
21 I think the more interesting aspect of this has been  
22 the seismic demand on the racks. And that has been the  
23 subject of most of the interaction between NINA and the  
24 staff.

25 So, Jim, the conclusion. So again, the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 new fuel racks have been eliminated from the design.  
2 New fuel is going to be stored in the spent fuel racks  
3 after fuel inspection. Of course, fuel is placed in  
4 the spent fuel racks before it's moved into the core  
5 anyway.

6 Spent fuel racks meet all the NRC  
7 requirements for new and spent fuel, as described in  
8 the DCD and the SRP. And all the COL items in Chapter  
9 are met on the particular design and analysis. Any  
10 questions?

11 MEMBER STETKAR: A couple. You said ten  
12 years. You really mean eight years, before you need  
13 to start rating it -- or nine or something. You can't  
14 really meet ten years time in the fuel pool.

15 MR. THOMAS: I've done the math a couple  
16 of times, and ten years is the number, I think, that  
17 I have come up with.

18 MEMBER STETKAR: Well, if I take, you  
19 know, change out a third of the core, right?

20 MR. THOMAS: I don't think it's exactly a  
21 third every time.

22 MEMBER STETKAR: It's a little bit less,  
23 isn't it?

24 MR. THOMAS: A little bit less.

25 MEMBER STETKAR: If it's a little bit less

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 you might make it with the extra spaces. I haven't done  
2 all of the spaces. So maybe you just -- maybe you just  
3 make it to ten years. So, okay. I'll give you the ten  
4 years because I didn't do the math with every single  
5 slot.

6 Question -- this doesn't have anything to  
7 do with the -- it does, a little bit -- the design of  
8 the racks. There's, in the FSAR it says the bottom of  
9 all pool gates are sufficiently high to maintain the  
10 water level over the spent fuel storage racks to provide  
11 adequate chilling and cooling.

12 I couldn't find -- I looked but I didn't  
13 look very exhaustively for elevation drawings of the  
14 fuel pools. And I know you increased the thickness on  
15 the bottom of the racks by a half an inch, so they're  
16 up a little bit higher.

17 If I drain the water in the bottom of the  
18 pool to the bottom of the gates, bottom of the slots,  
19 how much water is above the top of the fuel?

20 MR. THOMAS: I believe it's approximately  
21 four feet.

22 MEMBER STETKAR: Four feet? Okay.  
23 Thank you.

24 MR. THOMAS: Thanks.

25 MEMBER STETKAR: I asked that question of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 one client one time and the answer was minus 10  
2 centimeters because they had re-racked their pools and  
3 done things and never asked any questions, so 4 feet  
4 is a good margin. Thanks.

5 MR. HEAD: All right, Mr. Chair, that  
6 concludes our presentation.

7 CHAIR CORRADINI: Any questions? Are  
8 you going to move on, as I have, or are you going to  
9 move on to --

10 MR. HEAD: Yes, sir. I think that's the  
11 plan. We'll just stay up here and --

12 CHAIR CORRADINI: Keep on going?

13 MR. HEAD: Yes, sir.

14 CHAIR CORRADINI: Okay, then, good.

15 MR. HEAD: Okay, on topic --

16 CHAIR CORRADINI: So are --

17 MR. HEAD: I'm sorry, go ahead.

18 CHAIR CORRADINI: Onto the respond --

19 MR. HEAD: Yes, sir.

20 CHAIR CORRADINI: Okay.

21 MR. HEAD: Okay, I've got to probably pull  
22 this closer.

23 CHAIR CORRADINI: Here. Okay. Go  
24 ahead.

25 MR. HEAD: Okay. All right, yes, this

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 presentation will concern the NRC Bulletin 2012-01.  
2 Attendees are myself, Steve is up here still. Bill  
3 Mookhoek is with us today, our licensing supervisor,  
4 and, I'll just mention, Bill is a former supervisor out  
5 at 1 and 2. And you'll be seeing more of him in our  
6 discussions with respect to Fukushima.

7 Jim Tompkins is here and Evans Heacock is  
8 here. Evans has been here a couple of times, briefing  
9 ACRS. But he was here, he was here closing out the  
10 Chapter 8, ACRS meeting a number of years ago. And  
11 we'll be talking -- he'll be leading our presentation.

12 Again as background, you know electrical  
13 system, open phase, so (I) open phase solution,  
14 detection, protection and COLA changes that were  
15 required as a result of this in our solutions.

16 Just a little background, the Bulletin  
17 regarding the Byron event was issued in July of 2012  
18 between the Bulletin and further work, you know, the  
19 industry and NRC identified a couple of other loss of  
20 phase issues that have occurred.

21 One was in back of South Texas Project in  
22 2001. The industry embarked on an extensive effort in  
23 response to this issue, and that response is ongoing  
24 right now. And in terms of addressing, coming up with  
25 solutions and actually testing the solutions, the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 potential solutions that are out there.

2 That industry response is really not  
3 scheduled to be concluded until the 2016 or 2017  
4 timeframe. And so, basically, we're in a situation  
5 that, earlier this year, our review of the 3 and 4  
6 application appeared to be on a path to be concluded  
7 by September of this year.

8 And so here we were, you know, NRC was  
9 expecting us to address this issue. We felt we needed  
10 to address this issue. But we really were going to be  
11 in a position where we had to define the response before  
12 the entire industry issue has unfolded and been  
13 concluded.

14 And so the NRC defined, basically, a first  
15 that if STP could come up with a resolution to this issue  
16 that encompassed what that solution would ultimately  
17 look like, then they would move forward with our review.  
18 And that's, in essence, what we've done here today.

19 Our proposed design includes detection,  
20 control room alarm, an automatic response to the open  
21 phase of it, and I think NRC felt that it was important  
22 that that solution also be immortalized in Tech specs.  
23 And we've also done --

24 MEMBER BLEY: Good. Are you going to  
25 maybe talk more about the automatic response at all?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. HEAD: Absolutely. That will be  
2 here. But I want to preview, though, for the ACRS that  
3 this is not an automatic response to an open phase  
4 event. This is an automatic response to the symptoms  
5 of the open phase ----

6 MR. HEAD: -- that would be cinched on the  
7 4160 bus and the protection is to protect the motors.  
8 And so, and that allowed us to readily put that  
9 protection into technical specifications because it  
10 ends up being the relays that we're, that we've already  
11 gotten in Tech specs, like the under voltage,  
12 integrated voltage.

13 And so it allowed a Tech spec-related  
14 solution. It allowed an automatic response that's  
15 hitting the target, which is protecting the motors.  
16 And, at the same time, it allowed the control room to  
17 know that this issue has occurred because of the  
18 detection.

19 So it is, it really is, we think, an  
20 appropriate and, we think, I'd say appropriate response  
21 to this issue, and that's what we'll be talking about  
22 today in more detail.

23 So I'm going to turn it over to Evans. And  
24 I'll say he has briefed the ACRS before and has been  
25 responsible for a lot of the design you'll be seeing

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 today.

2 MR. HEACOCK: Thank you. Again, my name  
3 is Evans Heacock. I have presented Chapter 8, probably  
4 in 2010 timeframe. And I'm also a member of the IEEE  
5 Standards for Nuclear Power Engineering  
6 Committee/subcommittee for, just write a lot of the  
7 standards for the nuclear power industry.

8 I've also been working as the electrical  
9 lead for a number of years for STP 3 and 4, responsible  
10 for a lot of the way the electrical distribution system  
11 looks for 3 and 4.

12 I'd kind of like to go over just a high  
13 level, real quick, to refresh your memory on the Byron  
14 event. It was offsite power supply circuits were  
15 rendered inoperable by the single phase open circuit  
16 that was undetected by surveillance.

17 Again, they dropped a phase on the high  
18 side of their SATs, Station Auxiliary Transformer.  
19 The design of the electrical power system did not take  
20 into account the possibility of a loss of a single phase  
21 between a transmission network and the onsite power  
22 distribution system. From that standpoint, being able  
23 to detect a single open phase on the secondary of the  
24 plant.

25 MEMBER BLEY: Haven't -- two things.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 Since you're on the IEEE Committee -- and I don't know  
2 the answer to this. I've just been digging in to this  
3 stuff myself recently. Has protection for open phase  
4 convention, the sequence -- current sequence will  
5 reaches. Been around in other industries for a long  
6 time.

7 MR. HEACOCK: You could say that there --  
8 yes some theories --

9 MEMBER BLEY: I mean, the theory's been  
10 around for over a hundred years.

11 MR. HEACOCK: But actually, protection  
12 for single phase, negative-sequence type occurrence  
13 and voltages has been out there for a while. It has  
14 not been a item that has been -- it's not like it's a  
15 large concern because it doesn't occur very often.

16 It also depends on your distribution  
17 system of what you're trying to protect. Now if you  
18 have, as we've seen with the Byron event, if you have  
19 a lot of motors you may want to put in protection for  
20 that sort of a scheme. And if you don't have a lot of  
21 motors then you don't need to detect because it's not  
22 as severe on systems that don't have a motor, besides  
23 the standpoint that you may lose those particular  
24 loads.

25 But, yes, it's been out there. And

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 that's, when you start looking in for the protection  
2 relays, it was obvious though. That's been out there  
3 and there's been a number of papers out there.

4 MEMBER BLEY: For a long time, yeah. I  
5 knew about the papers. I didn't know how wide spread  
6 it was. And in your first bullet, were things really  
7 rendered inoperable?

8 MR. HEACOCK: I think it was --

9 MEMBER BLEY: That's part of the problem.  
10 They were rendered inoperable.

11 MR. HEACOCK: Well, actually, if you look  
12 at it from the standpoint -- and this is going like  
13 you're going based on what I understand of the Byron  
14 event and the paper is that you ended up, started --  
15 the plant started tripping motors, safety-related  
16 motors due to over current, due to the lost phase.

17 So, in that respect, yes, things were  
18 rendered inoperable because they were not able to start  
19 or have motors be able to continue to run on the  
20 distribution system.

21 MEMBER BLEY: Okay.

22 MR. HEACOCK: And also --

23 MEMBER BLEY: By the way, we're having a  
24 meeting on this in two weeks, so then the more general  
25 topic of --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 CHAIR CORRADINI: And the offsite could be  
2 considered inoperable.

3 MR. HEACOCK: Yes, that's true too.

4 CHAIR CORRADINI: The offsite circuit  
5 would be considered inoperable if --

6 MEMBER BLEY: By definition, but --

7 CHAIR CORRADINI: Yes, I knew there was  
8 something inoperable, but go ahead.

9 MR. HEACOCK: Okay. Should we go to the  
10 next slide?

11 MEMBER BROWN: Can I ask a question  
12 relative to that? The Byron event, if my memory serves  
13 me correctly. I did look at the bulletin. Now I've  
14 forgotten what I read. It was literally one of the  
15 transmission lines that went --

16 MR. HEACOCK: Yes.

17 MEMBER BROWN: -- into the plant that --

18 MR. HEACOCK: Yes.

19 MEMBER BROWN: -- came apart and,  
20 therefore, you didn't have one of the phase voltages  
21 --

22 MR. HEACOCK: Yes, I dropped a --

23 MEMBER BROWN: -- in Plants 1.

24 MR. HEACOCK: -- an insulator broke on the  
25 feed to transformer and dropped C Phase which open

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1       circuited the feed. But when that phase dropped it did  
2       not actually hit the ground and trip out the feed to  
3       it, so it stayed in there.

4               MEMBER BROWN: Okay, I got that part. Now  
5       my question is, that's a fairly clear indication. I  
6       mean, you lose AC, Phase 8 -- you know, VA/CD, AB --

7               MR. HEACOCK: Right.

8               MEMBER BROWN: -- whatever the  
9       combinations are. But I didn't see in any of these  
10      analyses or the other ones where if you had an open  
11      circuit, an open -- let me backtrack.

12              Your main power transformer is three  
13      individual transformers.

14              MR. HEACOCK: Yes, sir.

15              MEMBER BROWN: Not a multi-legged  
16      transformer.

17              MR. HEACOCK: Right.

18              MEMBER BROWN: So if you had an open phase  
19      in the transformer that transmission will, in Phase AB,  
20      BC, CA -- it's still there.

21              MR. HEACOCK: Yes.

22              MEMBER BROWN: And your, excuse me, part  
23      of your reference in your protection scheme was you had  
24      these voltage relays that are detecting --

25              MR. HEACOCK: Negative sequence.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER BROWN: -- the -- well, you --

2 MR. HEACOCK: Negative sequence.

3 MEMBER BROWN: That's all the way down the  
4 stream, but you have, at least the way I've got it, you  
5 had a voltage relay -- excuse me, voltage detection on  
6 the input to the main power transformers.

7 MR. HEACOCK: You don't necessarily have  
8 -- now most plants do not necessarily have --

9 MEMBER BROWN: You talked about it, and  
10 you already had five.

11 MEMBER STETKAR: You've committed to  
12 monitoring that voltage on the --

13 MEMBER BROWN: That's right.

14 MR. HEACOCK: It is -- it is --

15 MEMBER STETKAR: -- 45 side of those  
16 transformers, so you certainly --

17 MEMBER BROWN: And --

18 MR. HEACOCK: Yeah.

19 MEMBER BROWN: And it was used in some of  
20 your discussions relative to how you protected stuff.

21 MEMBER STETKAR: Alerting the operators.

22 MR. HEACOCK: Well, looking from a  
23 standpoint of what's going on from the three phases,  
24 yes, you can actually look at -- I don't think that's  
25 what you're referring to because --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   MEMBER STETKAR: So, Charlie, follow up on  
2 how you now get balanced three-phase voltages that will  
3 never alert you to that condition.

4                   MEMBER BROWN: Well, that's my point.

5                   MEMBER STETKAR: Right.

6                   MEMBER BROWN: I mean, if you have -- and  
7 I have anything in the other papers either where we  
8 address, literally, a transformer's primary opening up  
9 as a line separating the it with that environment.

10                  MR. HEACOCK: It would be, and I guess I'll  
11 say if from a high level. There would be no difference  
12 from a standpoint of an opening up in the transformer  
13 or dropping a line into the transformer.

14                  MEMBER BROWN: And also it depends  
15 somewhat on whether your Y Delta Y, whatever it is --

16                  MR. HEACOCK: Right.

17                  MEMBER BROWN: You all happen to have a Y  
18 input, so.

19                  MR. HEACOCK: But Y Delta for the main  
20 power transformers, yes, sir.

21                  MEMBER BROWN: Right. Now the other  
22 question, are these ground neutrals or are they  
23 ungrounded neutrals?

24                  MR. HEACOCK: On the high side, they're  
25 typically grounded.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER BROWN: Okay.

2 MR. HEACOCK: Second, since they're  
3 Delta, they do not ground.

4 MEMBER BROWN: I got that.

5 MR. HEACOCK: Yeah. On the reserve  
6 auxiliaries the primary and secondaries are grounded.  
7 The secondary has a ---

8 MEMBER BROWN: Well those are --

9 MR. HEACOCK: High resistance.

10 MEMBER BROWN: Well, the UATs are Delta on  
11 the inputs.

12 MR. HEACOCK: Correct, the Delta on that,  
13 and then are grounded on the secondaries too.

14 MEMBER BROWN: Yes, on the -- okay, so it  
15 is a grounded neutral arrangement?

16 MR. HEACOCK: Yes.

17 MEMBER BROWN: Okay. I'm just asking  
18 because there's a different response based on what you  
19 see --

20 MR. HEACOCK: Yes.

21 MEMBER BROWN: -- with or without a  
22 grounded neutral.

23 MR. HEACOCK: Right, right.

24 MEMBER BROWN: And I didn't see a specific  
25 discussion and your diagram didn't indicate whether

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 those were or not.

2 MR. HEACOCK: Yeah, I couldn't remember if  
3 I put those in there but, yes, those are grounded, all  
4 secondaries.

5 MEMBER BROWN: Okay, high resistance  
6 grounded?

7 MR. HEACOCK: No, not high resistance, a  
8 little more of a low resistance.

9 MEMBER BROWN: Low resistance grounding?  
10 Okay. What's the voltage of your main generator?

11 MR. HEACOCK: It's 27 --

12 MEMBER BROWN: 27? And your input to the  
13 -- the output of back of the main transformer?

14 MR. HEACOCK: What's that?

15 MEMBER BROWN: The main transformer,  
16 secondary is?

17 MR. HEACOCK: The main transformer?

18 MEMBER BROWN: Yeah.

19 MR. HEACOCK: The main transformer's  
20 going to be 27.

21 MEMBER BROWN: That's input.

22 MR. HEACOCK: Now the high side is 345.

23 MEMBER BROWN: The high side's 345?  
24 What's the -- oh, I'm sorry. Yeah, right. I got the  
25 26. What's the output of the UATs?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. HEACOCK: The UAT is --

2 MEMBER BROWN: One of them's 13.8?

3 MR. HEACOCK: 13.8 -- two of them are dual  
4 lining 13.8 4160 and then the last one's 4160.

5 MEMBER BROWN: Yeah, and the other one's  
6 4160. Okay. All right. I couldn't read the diagram.  
7 It was all blurred.

8 MR. HEACOCK: Sorry about that.

9 MR. THOMAS: The one today or the one we  
10 sent earlier?

11 MEMBER BROWN: No, well, it was the one  
12 that was in the package.

13 MR. THOMAS: No, no. That was a copy of  
14 -- if you look at the RAI it's clearer. There's one  
15 ----

16 MEMBER BROWN: I did look at the RAI, but  
17 I couldn't read it.

18 MR. THOMAS: Okay.

19 MEMBER BROWN: So --

20 MR. HEACOCK: Okay.

21 MEMBER BROWN: -- I blew it up. I  
22 transferred it and blew it up and it got --

23 MR. HEACOCK: Still got --

24 MEMBER BROWN: -- got blurry.

25 MR. HEACOCK: Still got worse.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. THOMAS: All right.

2 MR. HEACOCK: Okay. Let me --

3 MEMBER BROWN: Thanks. I was just  
4 trying to calibrate myself.

5 MR. HEACOCK: Sure. I'd like to go over  
6 the rest of this distribution system. We kind of  
7 explain, for those of you all that are not familiar with  
8 the STP 3 and 4 electrical distribution.

9 And what we have is, of course, we have 345  
10 kV switchyard. The 345 kV switchyard then has three  
11 separate feeds into the plant -- back feed through the  
12 main transformers that you see over on the left side.  
13 You see those three transformer sets set up that way  
14 mainly because --

15 MR. THOMAS: Doesn't want to.

16 MR. HEACOCK: Okay. I need to --

17 MR. THOMAS: All the way over there.

18 MR. HEACOCK: Here we go. Over here.  
19 Three separate transformers that make up a bank. And  
20 it's a Y Delta transformation. The other two feeds,  
21 which are going to be through RAT A and also RAT B, RAT  
22 B being the normal feed back into the Class 1-E,  
23 Division 3 Bus.

24 And the main transformer is just back feed  
25 through in the UATs, the main feed for Division 1 and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 2. This is the normal lineup for STP 3 and 4.

2 I'd also like to pretty much state that we  
3 -- the reason why we had that, that's over here, off  
4 the generator, we have a generator circuit breaker.  
5 And so that whenever we have a fault on the generator,  
6 if we have a reactor trip, the generator circuit breaker  
7 is what opens and not the feeds, the transformer -- the  
8 breaker's out in the switchyard. So we have immediate  
9 -- basically immediate power of those buses.

10 And as Charlie has -- we talked about RAT,  
11 that we do have a Y Delta for the main transformers and  
12 a YYY shell form type transformers for reserve  
13 auxiliary transformers, both RAT A and RAT B.

14 And this is the normal feed for the  
15 stations down there. And, of course, each division has  
16 its own diesel generator. One of the other things  
17 you'll see on here is that Units 3 and 4 have a  
18 combustion turbine generator that basically we do lose  
19 offsite source and it also can be as an offset source  
20 for 30 days in accordance with Tech spec, should we lose  
21 an offsite source.

22 And we also have a cross-tie between the  
23 units so that we can actually bring power in and  
24 distribute power in negative directions within STP 3  
25 and 4.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           And one of the main things that we always  
2           have to do is STP always has to have a feed through the  
3           main transformers and a feed through either RAT A or  
4           RAT B.   If we do not have the main transformers  
5           available to us then that actually will -- the we'll  
6           have to enter an LCO condition for that loss of that  
7           source.

8           RAT A and RAT B cannot be used as separate  
9           independent powers for offsite source from EGD-17.

10          CHAIR CORRADINI:   Say that slower.

11          MR. HEACOCK:   Okay.

12          MEMBER BLEY:   Say it differently.

13          CHAIR CORRADINI:   And differently.  They  
14          can be used, but in Tech specs they'll -- they won't  
15          -- you can't take credit for it.

16          MR. HEACOCK:   You cannot take credit for  
17          it.

18          MEMBER BROWN:   You don't have independent  
19          sources.  Is that --

20          MR. HEACOCK:   They're not considered  
21          independent sources.  RAT A and RAT B are not  
22          considered independent sources for an offsite system.  
23          You can use them both, yes.  But based on the space  
24          requirements we could not use them as separate sources  
25          to meet Tech specs.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 Any general questions on the distribution?

2 MEMBER BROWN: I had one little nip.  
3 What's all the other breakers are shown in one form and  
4 then there's that one with the bright red in it. Is  
5 that supposed to send a signal of some kind?

6 MR. HEACOCK: This one right here?

7 MEMBER BROWN: Yeah.

8 MR. HEACOCK: Well, where we had, when we  
9 originally drew this we actually showed the 13.8 and  
10 non-safety's and the 4160s. The 13.8 was all the  
11 bright reds, so you would have seen more. We condensed  
12 it to fill the, switch our configuration ties.

13 So really that bright red one's just  
14 showing that that's the, a tie, a breaker that's  
15 normally closed for power from the CTG if it's ever  
16 called upon to power the 13.8, the 4160 bus, that CTG-3  
17 through that transformer.

18 MEMBER BROWN: Okay. But the whole  
19 figure would have had red circuit breakers as part 13.8?

20 MR. HEACOCK: Late -- 13.8, right.

21 MEMBER BLEY: Right, red is associated  
22 with 13.8.

23 MR. HEACOCK: 13.8, right.

24 MEMBER BROWN: And green is associated  
25 with 4160.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. HEAD: 4160.

2 MEMBER BROWN: Okay.

3 MR. HEAD: In this particular drawing what  
4 we tried to -- we took that section out and put the  
5 switch yard in. So that's why we didn't have room for  
6 the whole --

7 MR. HEACOCK: Yeah, and you'll just see a  
8 little note there, says 13.8 kV loads.

9 MEMBER BROWN: And red.

10 MR. HEACOCK: And, yes. Okay? That's  
11 all.

12 CHAIR CORRADINI: Excellent.

13 MR. HEACOCK: Okay, for -- can we just --

14 MR. HEAD: That or you drive.

15 MR. HEACOCK: All right. I wondered what  
16 you were asking for. Okay, a couple of important  
17 aspects of the STP 3 and 4 design relative to an open  
18 phase condition is again, like this slide basically  
19 repeats what we just described.

20 We held it up there just so that we wouldn't  
21 -- but this is here for your reference later on. So  
22 I'm not going to go back into detail on this particular  
23 slide.

24 The STP 3 and 4 licensing approach for this  
25 is that we have defense and death type set up on this.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 We have the detection. We're doing to set up a  
2 detection of an open phase, an alarm in the control  
3 room, on all transformers on the main power  
4 transformers, reserve auxiliary A and reserve  
5 auxiliary B.

6 As part of that we'll end up, we have added  
7 Inspection, Tests, Analysis and Acceptance Criteria,  
8 ATAAC, of course, for the open phase detection alarm  
9 within our submittal. And then also, as a big part of  
10 our defense in depth on this we've added protection for  
11 the Class 1-E 4160 buses with negative sequence voltage  
12 relays.

13 These relays, upon sensing a high enough  
14 negative sequence voltage will open up the supply  
15 breakers. It'll trip each one of those supply breakers  
16 on the 4160 bus which then will cause -- the loss of  
17 voltage going into that bus will cause another relay  
18 to drop out and start the diesel generators. And the  
19 diesel generators, of course, will then pick up a load.

20 MEMBER STETKAR: When during this  
21 discussion do you want to get into technical issues of  
22 whether this will actually work?

23 MR. HEACOCK: We'll go into it --

24 MEMBER STETKAR: Well you want to finish  
25 the whole discussion and then enter into that or --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. HEACOCK: We can do it that way if  
2 you'd like. We have a couple more.

3 MEMBER STETKAR: Why don't we do that  
4 then?

5 MR. HEACOCK: We have a couple more that  
6 gives a little bit more technical information --

7 MEMBER STETKAR: Okay.

8 -- on the relays and such.

9 MEMBER STETKAR: Yeah, a little bit more  
10 technical --

11 MR. HEACOCK: Okay.

12 MR. HEAD: That was a preview, by the way.

13 MEMBER STETKAR: Yes, I understood that.

14 MEMBER STETKAR: This is here. We want to  
15 talk about whether or not the system will actually work.  
16 So I hope you're prepared to discuss that.

17 MR. HEACOCK: Yes.

18 MR. HEAD: Absolutely.

19 MR. HEACOCK: Yes. Okay, so we're open  
20 phased deficient. An alarm, like we said, we're going  
21 to put the system on the high side of the main  
22 transformers and the reserve auxiliary transformers.

23 Should a condition occur the condition  
24 will be alarmed in the control room which then the  
25 procedurals will direct the operators to the proper

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 response.

2 MEMBER BROWN: Have you worked those out  
3 yet?

4 MR. HEAD: No.

5 MR. HEACOCK: No.

6 MEMBER STETKAR: Do you have any idea how  
7 much time is available for that operator response?

8 MR. HEACOCK: I will probably defer that  
9 to our talk on our technical because --

10 CHAIR CORRADINI: Say that again? That's  
11 a first.

12 MEMBER STETKAR: No, that's fine. That's  
13 fine.

14 MR. HEAD: Well, it's sort of depends, you  
15 know, if --

16 MEMBER STETKAR: It sort of depends. I  
17 was just --

18 MR. HEAD: If all this happens and Diesel  
19 has started --

20 MEMBER STETKAR: We'll --

21 MR. HEACOCK: Yeah, I think it's all  
22 related. So when you talk about time to respond part  
23 of that protection will show.

24 MEMBER STETKAR: We'll get to it in the  
25 detail stuff.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. HEACOCK: Yeah.

2 MEMBER BROWN: Why don't we -- let's just  
3 stay here for a minute. Relative to my earlier  
4 question, if you had an open phase on the primary site  
5 of the main transformer, this particular circuit  
6 becomes inoperable. Does that -- this would not detect  
7 anything. If it was an internal open phase --

8 MR. HEACOCK: Now, wait, it still will.

9 MEMBER BROWN: On the high voltage side?

10 MR. HEACOCK: Yes, sir.

11 MEMBER BROWN: No just a minute. If I've  
12 still got, coming in -- where -- I don't where you're  
13 -- are you detecting inside the transformer?

14 MR. HEACOCK: What you're detecting for  
15 these open phase detections -- there's a couple  
16 different schemes out there. There's one developed by  
17 EPRI and there's one developed by a company called PCS  
18 2000.

19 What they're premise are looking at is the  
20 loss of phase and what it causes from a standpoint of  
21 imbalances within the circuitry that's being sensed  
22 from a current standpoint or a --

23 MEMBER STETKAR: Okay, wait a minute.  
24 Let me -- hold on. You said Current.

25 MEMBER BROWN: Now that's why I, yeah.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: He said Current.

2 MEMBER BROWN: I understand that. I  
3 understand that. And that's one of questions I've had,  
4 is why did you get -- because if you lose an internal  
5 transformer then obviously you're going to have a  
6 change in the current levels in the various phases.

7 MR. HEACOCK: Correct.

8 MEMBER BROWN: And so that it's really not  
9 just a high voltage, it's not just a loss of voltage.  
10 It's a combination voltage/current.

11 MR. HEACOCK: Current.

12 MEMBER BROWN: And their relationships  
13 and that's calculated within the --

14 MR. HEACOCK: Right, within an -- right.

15 MEMBER BROWN: Okay.

16 MR. HEACOCK: Within either one of the  
17 relays. So you're looking at --

18 MEMBER BROWN: You didn't talk about  
19 current in your RAI, at least I don't remember that,  
20 so --

21 MEMBER STETKAR: Yeah, you characterize  
22 these things as voltage relays.

23 MEMBER BROWN: That's right.

24 MEMBER STETKAR: Looking at phase  
25 differentials --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. HEACOCK: Now I think -- not these.  
2 These are not -- this would be with the ITAAC. When  
3 we look at the ITAAC. When we look at the ITACC that's  
4 a little different for the open phase detection alarm  
5 is a little different than the protection scheme. The  
6 protection scheme is voltage.

7 MEMBER BROWN: Well then you're talking  
8 about the negative sequences?

9 MR. HEACOCK: Right.

10 MR. HEAD: That's right.

11 MEMBER BROWN: And that's a downstream on  
12 the 4160?

13 MR. HEACOCK: Correct.

14 MEMBER BROWN: Yeah, I got that. I'm just  
15 trying to get back -- I'm trying, along with John and  
16 Dennis, trying to walk through this thing piecemeal,  
17 at the lead-in. And, you're right. The RAI talks  
18 about nothing except voltage relays and had, didn't say  
19 anything. And I'm sitting here thinking, hold it --

20 MR. HEACOCK: Well, let's --

21 MEMBER BROWN: This whole circuit becomes  
22 inoperative if it's an internal open circuit within the  
23 main transformer, which does not have any couplings  
24 since it's three individual transformers.

25 MR. HEACOCK: Okay, what we did not -- we

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 did not want to get into too much detail on what scheme  
2 we would use for the open phase detection.

3 MR. HEAD: That's what the ITAAC is for.  
4 That was --

5 MR. HEACOCK: Yeah.

6 MEMBER STETKAR: Well, but see in terms of  
7 understanding whether or not this provides adequate  
8 protection, it's important to understand how that  
9 relaying actually works.

10 MR. HEACOCK: Okay

11 MEMBER STETKAR: Because if it's simply  
12 measuring phase-to-phase voltages it's not going to  
13 work for all fault phases.

14 MR. HEACOCK: That's correct. It would  
15 not.

16 MEMBER STETKAR: If it's measuring  
17 voltage and current then it may very well. So getting  
18 into that level of detail without designing the actual  
19 relay itself is quite important, at least, I think, from  
20 what you're hearing, for us to understand whether it's  
21 doing to work.

22 MR. HEAD: So, John, can I ask you just,  
23 are we -- is the question we're focusing on right now  
24 the detection?

25 MR. HEACOCK: Yes.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: Yes.

2 MR. HEAD: Okay, so the detection is -- we  
3 have not selected the detection system we're going to  
4 use.

5 MEMBER STETKAR: You're waiting for the  
6 industry solution to be defined.

7 MEMBER BROWN: But, Scott, it's in your  
8 RAI. You talked of voltage relay.

9 MEMBER STETKAR: That's right.

10 MR. HEACOCK: It's only characterized as  
11 voltage.

12 MEMBER BROWN: Okay, you need to say  
13 detection, and how you did it. You talked about  
14 voltage relays. No, that -- I'm just not --

15 MEMBER STETKAR: They're not called power  
16 relays or they don't mention it?

17 (Simultaneous speaking)

18 MR. HEACOCK: And I still think we have to  
19 go back and not brush up, but we will. We were talking  
20 about the voltage relays that were primary for  
21 protection. That should have been --

22 MEMBER STETKAR: Voltage relays are  
23 mentioned in both places.

24 CHAIR CORRADINI: So before you guys start  
25 arguing about what you said or didn't say let's just

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 --

2 MEMBER STETKAR: Let's just end it.

3 CHAIR CORRADINI: -- let's just get back  
4 to what the ITAAC says. And then if you were to, at  
5 least in my mind, I think what the members are asking  
6 is if you were to try to satisfy ITAAC the principle  
7 in which you would go about it, so that they feel  
8 comfortable that it actually would succeed.

9 MEMBER STETKAR: Right.

10 CHAIR CORRADINI: So can you go back to  
11 describing what are possible ways to detect, so that  
12 we're clear about it?

13 And then also, the second part of that, for  
14 me, would be is it specified in the ITAAC enough that  
15 there's confidence that what you think, when you think  
16 you have the way to solve it, it's specified so that  
17 staff understands it and feels comfortable about it  
18 because I guess these guys didn't catch it.

19 MR. HEACOCK: Okay.

20 MEMBER BROWN: Maybe we'll feel better too

21 ----

22 (Simultaneously speaking)

23 MR. HEAD: Yes, the answer to your question  
24 is yes, the staff work -- sorry, go ahead.

25 CHAIR CORRADINI: No, go ahead, Steve.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   MEMBER STETKAR:    My comment was maybe  
2 we'll feel better about it in two weeks when we have  
3 a meeting on this in more detail.

4                   CHAIR CORRADINI:  Otherwise you guys are  
5 doing this and the preview but --

6                   MEMBER STETKAR:    But today is today.

7                   CHAIR CORRADINI:  -- we won't feel better  
8 then either.

9                   MEMBER STETKAR:    So we were hoping to get  
10 a preview of what you're doing and planning to address  
11 with us.

12                   CHAIR CORRADINI:  Well, look at it this  
13 way.  You guys are the pioneers on a number of things  
14 that I could identify about it.

15                   MR. HEAD:  Absolutely.  And we've enjoyed  
16 all of it.

17                   CHAIR CORRADINI:  That is a positive  
18 answer.

19                                       (Simultaneously speaking)

20                   MR. HEAD:  But the strategy that I talked  
21 about at the very start was, in essence, don't select  
22 this detection system right now.  Build an ITAAC so  
23 that when the industry solution is developed and  
24 defined and approved by the NRC, by the operating fleet,  
25 that will be there for us to use.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           And that' really -- remember, we said  
2 voltage or current or whatever. The ultimate issue  
3 here is that by the time we design and install this  
4 system it will have been defined and used. And the  
5 ITAAC covers that. It stipulates that it has to meet  
6 the expectations that the staff has for it.

7           So we've postponed this decision to  
8 non-safety related component, it's detection only.  
9 And I say the operating fleet has to go through their  
10 process. And that'll be there for us when we close the  
11 ITAAC.

12           So that's the theory behind why we're here  
13 right now. And that's why the protection side and the  
14 Tech spec side is so important, is that that had to be  
15 defined a little more, obviously, clearer with the  
16 actual relays, with the actual set points and the  
17 appropriate tech specs.

18           So it's a two-phase approach but one of  
19 them actually does come later. And that was per  
20 discussions, NRC, is, no, don't define that right now  
21 because that's still working through the operating  
22 fleet right now.

23           MEMBER BROWN: Well, that's all find good.  
24 I don't have a problem with that.

25           MR. HEAD: Okay.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   MEMBER BROWN:  It's, when I look at it, if  
2 I look at it and try to say, okay, I'm going to have  
3 a Tech Spec, I've got an ITAAC.  Well, that I would have  
4 expected to see -- some type of point about oh, okay,  
5 what are the modes under which I can lose that phase.

6                   Okay, is it just the loss of the line coming  
7 in?  Is it the -- you know, how many modes do I have  
8 to go through to show that I -- to result in the losses  
9 of the phase on the input side of the main power  
10 transformer.

11                  MR. HEACOCK:  Yeah.

12                  MEMBER BROWN:  Didn't stop.  So I had no  
13 problem with going that way, I don't think.  But until  
14 you started talking about hey, yeah, we're going to have  
15 -- it's not going to be just a voltage relay across the  
16 two phases.

17                  You obviously have to have some other  
18 methodology to know if there's some other mode.  But  
19 that mode, I guess, wasn't clear to me.  I don't know  
20 if anybody else saw it but I certainly didn't, relative  
21 to the approach you're taking.

22                  I don't have any problem with not defining  
23 the actual details.  It's just you've got to define the  
24 modes under which you can get to the open phase to ensure  
25 you're Tech specs or your ITAAC covers all of those in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 terms of their possibilities, that's all. Didn't see  
2 it.

3 The negative sequence detection, that one  
4 was much more clear in my own mind.

5 MR. HEACOCK: Right, right.

6 (Simultaneously speaking)

7 MEMBER BROWN: And I got that.

8 MR. HEAD: That's another one that --  
9 right, but that's only one that Tech spec applies to.

10 MEMBER BROWN: I got that. But you also  
11 don't want to lose -- I've got the idea that I've lost  
12 part of my input. I mean, there's a lot of  
13 ramifications.

14 MEMBER STETKAR: That's why I asked the  
15 earlier question about how much time is available  
16 because it did load flow studies with simulated faults,  
17 open phases out of --

18 MEMBER BROWN: We, they had light and  
19 heavy load.

20 MEMBER STETKAR: Well, and whether or not  
21 the generator was running.

22 MEMBER BROWN: Yeah.

23 MEMBER STETKAR: Or the back, just  
24 back-feeding it through the transformers. And in the  
25 case where you're just backfeeding it through the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 transformer, you never triggered the negative sequence  
2 voltage relays on the 4 kV busses. You're relying on  
3 the operator alarm to actually separate those busses  
4 manually.

5 MR. HEAD: I got you.

6 MEMBER STETKAR: And the question I had  
7 when I asked about what's a time window is, well, when  
8 are you backfeeding those busses? You're backfeeding  
9 those busses when you're in an outage.

10 MR. HEAD: Right.

11 MEMBER STETKAR: You're running RHR  
12 pumps, you have some amount of load on those busses.  
13 So then a question is, well how long can those loads  
14 operate under this condition before the motors start  
15 to get into trouble.

16 And that defines the time window for the  
17 operator need to separate to actually separate those  
18 things when they get this alarm.

19 MR. HEACOCK: Right.

20 MEMBER STETKAR: So have you thought about  
21 that?

22 MR. HEACOCK: Yes.

23 MEMBER STETKAR: I mean, is that time  
24 window minutes?

25 MR. HEAD: No, it's --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: Is I hours? Is it days?

2 What is it?

3 MR. HEAD: It's indefinite.

4 MR. HEACOCK: It's indefinite.

5 MEMBER STETKAR: Hmm?

6 MR. HEACOCK: It's indefinite.

7 MEMBER STETKAR: Indefinite? But it's a  
8 variable, I think.

9 MR. HEACOCK: Well, mainly, yes, and  
10 you're right, it's somewhat variable. We'll probably  
11 get into this, more of your discussion if we want to  
12 go the next one real quick.

13 MEMBER STETKAR: Okay.

14 MR. HEACOCK: If we go there. Go one  
15 more. Go one more.

16 CHAIR CORRADINI: So just to summarize, so  
17 at this point everybody's on the same page, that from  
18 an ITAAC standpoint, this has yet to be determined.  
19 And your approach is to essentially base it on what the  
20 entry has to do for the current operating plants, and  
21 adopt that under the assumption that you can detect it  
22 from all various modes?

23 MR. HEACOCK: Yes.

24 MEMBER STETKAR: Detection.

25 MR. HEACOCK: Detection, correct.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. HEAD: And that that process could  
2 still evolve. That was the other reason for not, you  
3 know, defining that in much detail. It could evolve,  
4 which we, maybe even hearing the, you know the evolution  
5 today there's evolution possible.

6 But by the time we close the ITAAC the  
7 industry will have had an acceptable solution for the  
8 detection portion.

9 MR. HEACOCK: Several sections.

10 MR. HEAD: sitting there all along will be  
11 out safety relate, you know, detection -- I mean, not  
12 detection but actuation and the Tech specs associated  
13 with the relays that we're going to talk about.

14 MR. HEACOCK: Well, to answer your  
15 question, I meant, again, Charlie, about --

16 MR. HEAD: Go ahead.

17 MR. HEACOCK: Because there's different  
18 schemes that will detect different types of modes. Not  
19 all of them are equal.

20 MEMBER BROWN: Okay, I just didn't see  
21 them explicitly.

22 MR. HEACOCK: No, we did not -- you're  
23 correct. We did not put those in explicitly.

24 MEMBER BROWN: Well, if they're not in  
25 there explicitly how do you expect them to be covered

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 -- if they're not explicitly covered in the ITAAC?

2 MR. HEACOCK: Well, in the ITAAC, from a  
3 standpoint of what we're trying to detect in the end  
4 is, I think we were fairly explicit. I think that  
5 detection scheme that will be ferreted out by the  
6 industry in the end will be adequate to detect what it  
7 is to detect on the various modes.

8 MEMBER BROWN: Okay. Tight-lipped,  
9 okay.

10 CHAIR CORRADINI: Noted.

11 MR. HEACOCK: Okay, for the open phase  
12 protection which we'll get into a little bit more in  
13 the conversation for Mr. Stetkar's questions is that  
14 we are adding Class 1E negative sequence voltage relays  
15 to protect the three Class 1E busses that is designed  
16 to protect the motors from overheating due to  
17 unbalanced voltage currents.

18 The relays will monitor the negative  
19 sequence voltage for each phase. And there's three  
20 relays per bus with a two out of three trip logic. And  
21 the reason for that is to help reduce various  
22 actuations.

23 MEMBER BROWN: When you say bus, let me  
24 make sure I understand. If I look at the 4160  
25 switchboard, there's obviously a Phase A, Phase B,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 Phase C. I presume that means 1 Phase relay on each  
2 phase?

3 MR. HEACOCK: These relays are 3-phase  
4 relays. So it's actually measuring between A, B and  
5 C as all of us.

6 MEMBER BROWN: Oh, so all three of them do  
7 that?

8 MR. HEACOCK: Mm-hmm.

9 MEMBER BROWN: Oh, okay. All right.

10 MR. HEACOCK: Yes, instead of an  
11 undervoltage scheme which it could be an A and a B and  
12 C.

13 MEMBER BROWN: Oh, I understand why you have to  
14 measure all of them. Otherwise you're not going to get  
15 your --

16 MR. HEACOCK: Right.

17 MEMBER BROWN: -- negative sequence  
18 calculation which is just, what, the summation of the  
19 vectors, vector sum of the voltages.

20 MR. HEACOCK: Voltages, right. Great.  
21 like it. Okay. Actually, one of the things -- this  
22 is just one of the ones where we started looking for  
23 what kind of relay we could use and it had several  
24 criteria that I wanted to look at.

25 One of them was will they exist in the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 industry due day, which we found one produced by AVD.  
2 It's a safety-related -- they actually produce these  
3 still, safety-related.

4 And these have been around since the 70s,  
5 this particular undervoltage -- excuse me, negative  
6 sequence voltage relay has been out since the 70s so,  
7 it can be produced as safety related. It can be bought  
8 safety related today.

9 And this is very similar too. You know the  
10 same company that makes all of the undervoltage relays  
11 for the safety related degraded under-voltage  
12 detection.

13 So when we started looking at this, some  
14 of the questions, what we needed to look at was where  
15 was an appropriate value to set the relay at. And we  
16 came up with looking at industry papers and a design  
17 of what STP 3 and 4 would be from the motor standpoint,  
18 loading wise is that we could tolerate a 5 percent  
19 balance continuously and without any kind of adverse  
20 consequence.

21 And then we had the design time of three  
22 seconds. And that was there to allow motors from  
23 tripping on over-current. We tried to, we're really  
24 trying to be the motor's tripping out over current, look  
25 for, you know, with this, some voltage balance so that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 operators don't have to go out and do anything manually  
2 for those motors that had tripped on over current.

3 MEMBER BLEY: And what convinces you that  
4 that's a short enough time for more severe cases?

5 MR. HEACOCK: When I look at, there's a  
6 comparison of motors and the thermal protection  
7 typically on motors today and what I, well, I went ahead  
8 and looked at since STP 3 and 4 is not procured,

9 I looked at 1 and 2 and I look at the motor,  
10 thermal damage occurs for that and looked at protection  
11 schemes. And most all those motors were 3 seconds of  
12 above.

13 MEMBER BLEY: Is that right? Okay. So  
14 you're talking about a normal overload applied to the  
15 motor based on its load. And it draws additional  
16 normal -- assuming you're in balanced operation, you're  
17 drawing more current in all three phases.

18 And I guess the three to five percent is  
19 a number I'm familiar with. See, I'm not uncomfortable  
20 with that myself. That's fairly common, I guess my  
21 understanding is but --

22 MR. HEACOCK: Yes. It's fairly common.  
23 And I would go into what we looked at from a standpoint  
24 of three to five. That's what we're suggesting, is  
25 NIMA MG1 has specifications about how much negative

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 sequence current/voltage a motor can withstand. Part  
2 of that's based on loading, motor loading.

3 MEMBER BLEY: Oh, but that -- okay, I've  
4 got a phase unbalance now coming in, okay, and because  
5 of that, the negative sequence tends to try to slow  
6 everything done. The motor, it's a reverse direction.  
7 It's not going the same direction as a positive sequence  
8 ----

9 MR. HEACOCK: Correct.

10 MEMBER BLEY: -- or a current.

11 MR. HEACOCK: To some degree.

12 MEMBER BLEY: So when you try to slow it  
13 down, you've got your load. It's going to try to draw  
14 more current, but it's going to be an unbalanced  
15 current, also.

16 MR. HEACOCK: Yes, it's something else but  
17 the bigger, the bigger part --

18 MEMBER STETKAR: It's a lot heating.

19 MR. HEACOCK: It's a bigger part.

20 MEMBER STETKAR: No, I understand that,  
21 but it's unbalanced --

22 MR. HEACOCK: Right, there is some  
23 slowing. You end with an increased slip because the  
24 motor is not able to produce the same thing that it feels  
25 to keep the motor up to speed.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   MEMBER STETKAR:    Right but it's also  
2 imbalanced which --

3                   MR. HEACOCK:    It's unbalanced.

4                   MEMBER STETKAR:    -- which makes some  
5 difference.

6                   MR. HEACOCK:    But, like he was saying,  
7 really, the biggest part is heating on a motor.

8                   MEMBER STETKAR:    Heating is a big deal.

9                   MEMBER BROWN:    I'm well aware of that.

10                  MR. HEACOCK:    Yeah, but you're right.  It  
11 does have some effect on the ability of the motor to  
12 maintain speed.  It will slow it some.

13                  And what we'll end up doing is after we've  
14 looked at, and we did a number of cases, as I stated  
15 earlier.  We did a number of ETAP (Electrical Transient  
16 Analyzer Program) analyses to see what the different  
17 values a negative sequence voltage would be on the bus  
18 with varying conditions.

19                  From a standpoint of the reserve auxiliary  
20 transformers, every time we opened a phase on the high  
21 side based on the transformers we planned to procure  
22 we ended up with a very, very high negative sequence  
23 and voltages on that -- 5, 20 percent typically.

24                  And then we also did some various studies  
25 too to look at what happens if we have a diesel generator

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 while online testing it to see what the effects were.

2           Actually, sometimes the diesel generator,  
3 depending on what the load was and what the output of  
4 the diesel was you may or not pick up, if once you start  
5 coming close to the load on your bus with your diesel  
6 it'll actually mask the open phase because it sees a  
7 lower impedance and it's not drawing from the system.

8           But once you get high enough above 20  
9 percent or so, you'll see that negative sequence come  
10 back in. So we looked at a number of different  
11 conditions.

12           The other one is the backfeed. One of the  
13 ones we looked at was the backfeed from the mains. If  
14 we were shut down and we had an open phase the negative  
15 sequence voltages were in around the 2 percent range  
16 which is way below. And we can run, definitely, in  
17 accordance with --

18           MEMBER STETKAR: That's just because of  
19 the Y Delta, right?

20           MR. HEAD: Yes.

21           MR. HEACOCK: Correct. Because that  
22 Delta recreates. Right.

23           MEMBER STETKAR: That's right.

24           MR. HEACOCK: All right, and of course all  
25 this will be looked at in the end when we look at, do

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 our final set point. And, of course, with the set point  
2 control program. We'll go back and reevaluate these  
3 with the actual distribution system.

4 And our nominal set points will be set so  
5 that we don't exceed the 5 percent, 4-1/2 percent in  
6 2.5 seconds, 2-1/2 seconds. So, John, have we answered  
7 your --

8 MEMBER STETKAR: That's the -- yeah, the  
9 discussion about the fact that, again, you haven't  
10 bought your motors yet, but the survey that you did,  
11 at least, gives my confidence that at least the way  
12 they're characterized now those relay -- if you don't  
13 get to the relay center you're basically saved. The  
14 mores will allow you --

15 MR. HEACOCK: Correct, right.

16 MR. HEAD: We'll be happy, but we'll also  
17 have detected it.

18 (Crosstalk)

19 MEMBER STETKAR: What I'm saying is, yes,  
20 you've detected the condition out here. But I was  
21 concerned about getting into a situation where you had  
22 a severe -- and severe is not well-defined term.

23 You had a severe open phase condition out  
24 there on the high side of the transformer and got into  
25 a fairly large imbalance that's still not detected by

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 the undervoltage relays that could hurt the motors and  
2 now had a time window for the operators. They needed  
3 to know that within -- pick a number. Is it seconds  
4 or minutes or whatever --

5 MR. HEACOCK: Yeah.

6 MEMBER STETKAR: -- that they actually  
7 needed to manually trip those feeds. And your  
8 discussion about at least your survey, the motors,  
9 gives me some confidence that that time window, if it  
10 exists at all, is very long.

11 MR. HEACOCK: Yes.

12 MR. HEAD: So to circle back and answer  
13 Dennis' question, we haven't written the procedures but  
14 we have walked through the different scenarios that we  
15 think would exist and the operators in the control room  
16 would face along the lines of I've got an alarm but a  
17 diesel hasn't started.

18 I'm shutdown. Okay, I need to go find out  
19 what's going on. I need to address the symptoms. I  
20 need to dispatch operators to find why am I in this  
21 situation. I need to go back to computer readouts and  
22 find out -- you know, something's going to be unveiled.

23 But because we're protecting the  
24 operators, the time requirements are not -- it's an  
25 instance.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: It's still, though, the  
2 detection of the condition, I still think is important  
3 because --

4 MR. HEACOCK: Absolutely.

5 MEMBER STETKAR: -- electrical systems  
6 tend to be a lot smarter than the people who analyze  
7 them and faults tend to be even smarter than electrical  
8 systems themselves so that, carefully thinking about  
9 that detection relaying scheme out there is really  
10 important, I think.

11 MR. HEACOCK: Yes.

12 MEMBER STETKAR: That's why I think  
13 Charlie and Dennis and I were kind of honing in on  
14 exactly what sort of notion do you have out there.

15 MR. HEACOCK: Well --

16 MEMBER STETKAR: Because it can't be a  
17 simple voltage monitor.

18 MR. HEACOCK: No, it's not. It's not a  
19 simple -- it's got to be a combination or --

20 MEMBER STETKAR: Yeah.

21 MR. HEACOCK: -- or a current by  
22 themselves. And EPRI has come up with something  
23 totally different than PCS-2000.

24 MEMBER BLEY: Yes, and I guess we'll  
25 probably hear more about that in two weeks. But --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. HEAD: Yeah, well somebody's over here  
2 so I'm going to say something. No, I'm saying I want  
3 to introduce Bill Mookhoek. He wanted to, I think,  
4 expand on something I said or correct it. One or the  
5 other.

6 MR. MOOKHOEK: Again, my name's Bill  
7 Mookhoek. I'm the Licensing Supervisor and kind of the  
8 Operations input right now for STP 3 and 4. One of the  
9 things we looked at, and it concerned me, is when we  
10 looked at the bulletin and the way it was written, it  
11 was focused at the high side of the transformers.

12 And when we looked at protection, I mean,  
13 you get a problem on the low side of UAT, your detection  
14 system may not pick it up. That's why we put protection  
15 down where it needed to be to protect the equipment.

16 Now one of the things we looked at is what  
17 happens if those relays on the E-bus actuate, strip off  
18 the load, start the diesel, but I haven't had an alarm?  
19 Again, that's indication for an operator that he's got  
20 an abnormal condition and he needs to go look.

21 So detection on the high side is not  
22 complete and, you know, the final word on anything  
23 because we'll have the relays on the E-busses which will  
24 also generate alarms if they actuate as well as the  
25 detection on the main power transformers and the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 reserved auxiliary transformers.

2 MEMBER STETKAR: Well, the only problem  
3 is, from an operational perspective, you've got those  
4 relays picked up, you aren't -- you have no idea.

5 MR. MOOKHOEK: You don't know why.

6 MR. HEAD: You don't know why. All you  
7 know is you have it. But at least I have a diesel supply  
8 in the bus and loads.

9 MR. MOOKHOEK: Yeah.

10 MR. HEAD: And now I've got time to react  
11 to what was the condition because the plant, at that  
12 point, is protected.

13 MR. MOOKHOEK: The plant is protected from  
14 licensing safety related basis. It's not all clear  
15 what's going on on the 13.8 kV supply to your reactor  
16 cooling pumps and your, whatever else is fed from that,  
17 those buses, right.

18 MEMBER STETKAR: Right.

19 MR. MOOKHOEK: You think the water pumps  
20 picked up? I don't remember. 13.8?

21 MR. HEAD: Those are 13.8, three water  
22 pumps, 13.8, plus they have --

23 MR. MOOKHOEK: First water pumps, feed  
24 water pumps --

25 MR. HEAD: Yes, sir.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. MOOKHOEK: Reactor -- reactor  
2 internal pumps.

3 MR HEAD: Internal pumps, yeah.

4 MEMBER STETKAR: Reactor internal pumps,  
5 those things, smaller motors.

6 (Cross talk)

7 MR. MOOKHOEK: But that was one of the  
8 reasons we looked at putting stuff down on the E-busses  
9 because it protected all the way from E-Bus out to the  
10 grid.

11 MR. HEAD: Just also remember some of the  
12 buses, like the feed water pumps are going to have a  
13 variable speed drive on them. And also with the  
14 reactor internal pumps too. So they won't have quite  
15 the same effect.

16 MEMBER STETKAR: Yeah, those will --

17 MR. HEAD: So they're going to be somewhat  
18 isolated from the event. They'll still have this  
19 effect on increased currents possibly, but no current  
20 shifts kicking in.

21 MEMBER STETKAR: But thinking about it,  
22 from --

23 (Laughter)

24 MEMBER STETKAR: -- an operational  
25 perspective there still could be some strange things

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 going on out on the 13.8 kV side --

2 MR. MOOKHOEK: Absolutely.

3 MEMBER STETKAR: -- that, you know, you  
4 get a BUS shed and a diesel start and strange things  
5 happening on the 13.8 kV side, it isn't necessarily a  
6 good day in the control room, right.

7 And I think you're right. Monitoring on,  
8 whether it's the low side of the UATs or at least  
9 somewhere in that circuitry would certainly be  
10 beneficial to the operators. But --

11 MR. MOOKHOEK : Well, when you take a look  
12 at what happened on STP Unit 2, I mean, that condition  
13 had one of the breakers out in the switch yard, one pole  
14 didn't close.

15 But you had a diesel -- you had the main  
16 generator timing out on negative sequence which is a  
17 long time delay. But you had that going on. You wound  
18 up starting to lose circ water pumps which caused them  
19 to manually trip the plant.

20 But in our case, the way we're designed,  
21 we would also be -- may or may not get a trip on the  
22 E-bus and shift to the diesel. But we would still  
23 expect that those, the generator would still be timing  
24 on a negative sequence.

25 MR. MOOKHOEK: The generator would see the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 negative sequence.

2 MR. HEACOCK: Yes. But you can have --

3 MR. MOOKHOEK: But then the generator  
4 breaker's going to open up --

5 MR. HEACOCK: Yes.

6 MR. MOOKHOEK: -- and you're still going  
7 to have the fault though.

8 MR. HEACOCK: You may still have a fault  
9 but at that point you'll wind up recreating voltages  
10 because you don't have loads. The loads are going to  
11 break.

12 (Simultaneously speaking)

13 MR. MOOKHOEK: All that gets worked out.  
14 But I'm not saying it's going to be the panacea but at  
15 least there's enough indications there to tell an  
16 operator something's wrong. But there is protection  
17 there for the equipment you have to have for safe  
18 shutdown.

19 MEMBER BLEY: Right. Well, I take it  
20 we're not just talking procedures. We're talking  
21 maybe a new training module.

22 UNISON: Oh, absolutely.

23 MEMBER BLEY: It's just this tricky stuff.

24 MR. MOOKHOEK: The training has occurred  
25 in the industry do far based on just the Byron event.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 I mean, your people --

2 MEMBER BLEY: Yes, but if you only focus  
3 on that it's you guys, say. You're missing a whole  
4 variety of other odd conditions that can be, let go.

5 MR. HEAD: But there are loss of phases  
6 that will end up in reactors trips and a lot of stuff  
7 going on. I have a diesel running now that's  
8 protecting the safety layer loads. And so that's the  
9 essence of --

10 MEMBER STETKAR: Yes, my other point, as  
11 far as the operators are concerned, there is a lot of  
12 other stuff.

13 MR. HEACOCK: Yes.

14 MEMBER STETKAR: There could be a lot of  
15 other stuff.

16 MR. HEAD: From a timing standpoint, I  
17 have a diesel running, protecting my motors.

18 I'll get to that after I've got the plant  
19 stable, I've got the turbine building in a condition  
20 I want it, and then I'll go investigate why my diesel  
21 started. It may give me a hint, early on, why I'm in  
22 that condition. But that's stable. That's an  
23 expected condition that I can go take care of, you know,  
24 in an appropriate time frame.

25 MR. HEACOCK: This is to kind of, also

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 give you a little bit of reason why the motor's tripped.  
2 The motor on Unit 2, the circ water, did not trip on  
3 an over current. It tripped on negative sequence  
4 current imbalance.

5 This actually was a current balance relay  
6 that tripped that motor out, those particular motors.  
7 When one went, then the other, and that was because of  
8 voltage imbalances which starting drawing a current,  
9 higher currents on two of the phases compared to the  
10 third.

11 MEMBER STETKAR: But that was a particular  
12 motor protection relay for --

13 MR. HEACOCK: Right.

14 MEMBER STETKAR: -- because it's a big  
15 motor.

16 MR. HEACOCK: It's a big -- that's right.  
17 It's a large investment and you want to protect it.  
18 Right.

19 MEMBER BLEY: Here's a just something to  
20 think about --

21 MR. HEACOCK: Sure.

22 MEMBER BLEY: -- there's a little point of  
23 difference between what you were saying, Scott, and  
24 what the gentleman -- I forgot your name. But you were  
25 saying --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. MOOKHOEK: Bill Mookhoek. It won't  
2 be the first time.

3 MEMBER BLEY: Well, you got your diesel  
4 running and everything looks good, but when the loads  
5 go away it looks good up above. So you might be ready  
6 to, well, hell, let's put it back where we got it.

7 MR. HEACOCK: No.

8 MEMBER BLEY: No, no, we'd never do that.

9 (Crosstalk)

10 MR. MOOKHOEK: I point you to Brunswick  
11 when they had their fire -- or, I'm sorry, Robinson,  
12 when they had their fire. When they tried to reconnect  
13 stuff.

14 MEMBER BLEY: People get smart, you know.

15 MR. HEAD: I expect not only our  
16 procedures but our -- I mean, that alarm is in place  
17 there will be steps that you have to take.

18 MEMBER BLEY: Oh, no. Not if you have  
19 this alarm --

20 MR. HEAD: Right.

21 MEMBER BLEY: -- and you know what was  
22 going on. That's different than looking up and saying  
23 hey the voltages look okay.

24 MR. MOOKHOEK: But that's the message  
25 about that alarm, had better --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER BLEY: Be clear.

2 MR. MOOKHOEK: It had better be clear and  
3 perhaps because of your configuration which is  
4 different than Byron, just focusing on the particular  
5 high side of a particular transformer might not be the  
6 appropriate alarm scheme for South Texas. I think  
7 that's a bit of the message also.

8 MR. HEACOCK: Okay.

9 MR. MOOKHOEK: What the solution for one  
10 particular plant, fixing that particular problem might  
11 not necessarily be the solution for every one.

12 MEMBER BLEY: That is correct.

13 MR. HEACOCK: Correct. That's correct.  
14 It varies. STP 3 and 4 design is different than a lot.

15 MR. MOOKHOEK: Yes.

16 MEMBER BLEY: Yes.

17 MR. HEAD: So have we given you at least  
18 the perspective that this meeting in two weeks will be  
19 successful?

20 (Laughter)

21 MEMBER STETKAR: Two weeks is broader. I  
22 understand better -- I understand, Charlie, and I think  
23 we understand better the fact that the detection  
24 relaying out there on the 345 kV side is not simple  
25 voltage reading.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           And I was reading the same thing. I saw  
2 voltage, voltage, voltage. As we were discussing, I'm  
3 reading back through the words now and more carefully  
4 seeing where I was -- where I see voltage relaying and  
5 it -- I can't guarantee it but it seems to be more  
6 carefully associated with the 4kV busses.

7           MEMBER BROWN: The only place I saw that  
8 kind of negative sequence approach, not in the input,  
9 primary side of the main transformer, it was just  
10 strictly a reference to voltage and totally -- I said,  
11 I don't know how in the world can you do this. You're  
12 losing part of the message.

13           And, you've answered, the point and said  
14 you're going to do it -- you're not going to ignore the  
15 other pieces.

16           MEMBER STETKAR: Right, I was going say,  
17 you have to some how figure out current.

18           MR. HEAD: Yeah, you have to find that.  
19 That's a big inventory and that's what PCS is actually,  
20 their design is looking at current. They're looking  
21 at balance both from a loaded and a transformer that's  
22 unloaded eventually can detect based on current, open  
23 phase.

24           MR. MOOKHOEK: Okay.

25           MR. HEAD: And the same with EPRI, EPRI

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 design does the same thing but a little differently.

2 MEMBER BROWN: Does -- this may be a dumb  
3 question because I'm just, I don't work these 345  
4 babies, never have. But on the input side of these  
5 grids have a lot of -- your shifting reactive current  
6 around all the time.

7 MR. HEAD: Yes.

8 MEMBER BROWN: And does the -- I mean,  
9 when you measure current you're measuring current.

10 MR. HEAD: Right. It's reactive.

11 MEMBER BROWN: That's the sum -- it's  
12 written but do a vector sum, that's what you get when  
13 you read it out. But reactive current can really  
14 provide a disturbance if you've got an unbalance in the  
15 line layout of what you're getting.

16 MR. HEAD: Right.

17 MEMBER BROWN: Is there -- can stuff come  
18 from the grid that reflects in, that screws up this from  
19 a reactive standpoint? Your real load's going to be  
20 your real load, okay. It is what it is.

21 MR. HEAD: Right. And it's measuring a  
22 summation that is there. Most of it's going to be  
23 saying it's looking at, are all my phases still loaded,  
24 even somewhat --

25 MEMBER BROWN: But does it look for a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 balance in that current?

2 MR. HEAD: No, it's not looking for a  
3 balance. It's looking for all three phases. And also  
4 it could be referenced to a neutral, seeing, looking  
5 at which one of these current, these phases loaded  
6 similarly or, and do I have, and what's my neutral  
7 current's looking like too. So they --

8 MEMBER BROWN: Primary ground -- I asked  
9 you if the secondaries ground. You said yes. Does the  
10 -- I presume the primary --

11 MR. HEAD: The primary on the mains --

12 CHAIR CORRADINI: Primary on the mains.

13 MEMBER BROWN: The primary grounds also,  
14 right?

15 MR. HEAD: On the mains, no, because it's  
16 a Delta.

17 MEMBER BROWN: Right.

18 MR. HEAD: But on the reserve auxiliaries

19 CHAIR CORRADINI: Oh, you're right -- I'm  
20 sorry.

21 MR. HEAD: Yeah, reserve auxiliaries have  
22 it. But most of those have reference to the high side.  
23 And those are grounded. Those are solidly grounded on  
24 the high side.

25 MEMBER BROWN: Okay.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. HEAD: All right?

2 MEMBER BROWN: Well, I don't whether it's  
3 all right or not, I just --

4 (Laughter)

5 If it's okay, let's move on, yes.

6 CHAIR CORRADINI: Okay, let's move on.

7 MEMBER BLEY: Has this been factored into  
8 your PRA?

9 MR. HEAD: Let's go to COLA changes, okay,  
10 and I'll answer that. The open phase detection alarm  
11 has been added to our COLA Section 8.2, Offsite Power  
12 Systems.

13 The negative sequence relays have been  
14 added to the 8.3 Onsite Power Systems. The relays have  
15 been added to the Tech specs and they come with the same  
16 surveillances that other relays like that would come  
17 with in terms of periodicity and type of test.

18 There's a site specific ITAAC for the open  
19 phase detection and alarms that is in the COLA. And  
20 no other changes to the COLA is required at this time.

21 CHAIR CORRADINI: They're reading their  
22 RAI. I'm just trying to catch them up a bit.

23 MR. HEAD: Okay. All right, so there are  
24 no other COLA, no other changes to the COLA are required  
25 at this time. So, no, this has not been -- we have done

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 sensitivity studies with respect to these relays, okay.

2 The do not rise to the level of requiring  
3 the PRA to be changed or either from a, you know, 10  
4 percent aspect. If you think about it logically,  
5 that's what you would expect. These are sitting there  
6 and then what they would cause is a diesel actuation.

7 So they really don't have an impact. But  
8 we did look at that too, for us to be able to submit  
9 to COLA we had to assess that.

10 We also did a sensitivity analysis, PRA  
11 analysis. To answer the question that was, is  
12 bothering us from the initial event is there were some  
13 conditional probabilities with respect to the Byron  
14 event.

15 And we really felt it was important for us  
16 to be able either for the public, with NRC, or ACRS to  
17 recognize that ABWR, with the design we have described  
18 today, is not going to be in the same situation from  
19 a conditional core damage probability standpoint. So  
20 we did a study to conclude that or to understand that  
21 ourselves,

22 MEMBER BLEY: We've heard some arguments  
23 that, gee, the chance that these things go wrong and  
24 separate you from power when they shouldn't increases  
25 the risk substantially. So we wouldn't really want to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 do this sort of modification.

2 MR. HEAD: On the 4160?

3 MEMBER BLEY: Yeah.

4 MEMBER STETKAR: But you just switched it  
5 to diesel, so.

6 MEMBER BROWN: Yeah, you just kind of  
7 switched to diesel. So there's no adverse consequence  
8 per se. So that --

9 MEMBER STETKAR: Scott --

10 MEMBER BROWN: I'm sorry.

11 MEMBER STETKAR: As I read through the RAIs  
12 I don't think -- correct me if I'm wrong -- the sense  
13 that I got was that there was an initial attempt to try  
14 to quantify this in the PRA.

15 And the staff started asking a lot of  
16 questions and you basically negotiated a  
17 semi-quantitative, mostly qualitative conclusion --  
18 semi-quantitative being the fact that there, you've  
19 identified five events.

20 And you argue that it's roughly a thousand  
21 reactor years' worth of experience. And so,  
22 therefore, the frequency is 5 times 10 to the minus 3,  
23 that you would get an open phase condition. And the  
24 worst impact of that would be shedding of the loads and  
25 starting the diesels, which is small compared to the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 normal loss of offsite power, if you will. Is that a  
2 more appropriate characterization of the extent of the  
3 risk assessment?

4 MR. HEAD: That's the way it ended up.  
5 Yes, sir.

6 MEMBER STETKAR: Okay.

7 MR. HEAD: When we first PRA update -- or  
8 not update -- when we provided that insight in one of  
9 our RAI responses we felt it was important that this  
10 design be reflected and understood from a PRA  
11 standpoint.

12 We really didn't mean for it to go into an  
13 in-depth review. I mean, we had the sensitivity  
14 information. We needed to make the Rev.11 change.  
15 But we did want to make a statement about this design  
16 is not the same that -- you know, this is the event to  
17 one of our reactors, the design.

18 And that's what we wanted to -- but we  
19 didn't really want to embark upon a detailed review and  
20 so we did back off to a quantitative -- or qualitative  
21 discussion which we could have made initially, okay.

22 And it speaks to what Evans has talked  
23 about today that between the offsite sources, the  
24 backup systems we have -- RCIC, the CTG -- had all that  
25 available to us, we ought to recognize that impact.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   MEMBER STETKAR:        The reason that I  
2 started down the path on challenging the time window  
3 for operator response was specifically focused on a  
4 question about whether or not the vulnerability during  
5 plant shutdown, when you are relying only on RHR,  
6 whether that had been carefully thought.

7                   Because a lot of the other  
8 semi-quantitative, semi-qualitative arguments are all  
9 focused on power operations, the redundancy in terms  
10 of high pressure cooling mechanisms, independence from  
11 AC power, alternating AC power sources for things that  
12 do depend on AC power.

13                   And I started to think about, well, okay,  
14 all of those arguments make a lot of sense. And then  
15 is there a much higher vulnerability when the plant is  
16 on shutdown cooling, you know, RHR cooling.

17                   And I think your discussions about the  
18 ability of the motors to withstand conditions above the  
19 negative sequence voltage relay settings is what has  
20 to build confidence for those, for that kind of  
21 configuration, so.

22                   MR. HEAD: And I guess I would add that  
23 there --

24                   MEMBER STETKAR: And I didn't see any  
25 discussions in the shutdown stuff in the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 semi-quantitative/qualitative stuff.

2 MR. HEAD: But obviously during shutdown  
3 your time frames are different.

4 MEMBER STETKAR: That's true.

5 MR. HEAD: And in this case we would expect  
6 the alarm and we're going to react to it. That may  
7 mean, ultimately, we'll switch to another rack or  
8 something that, to make sure that --

9 MEMBER STETKAR: No, sure. Yes, there  
10 are options but also during shutdown you may have stuff,  
11 more stuff out of service.

12 MR. HEAD: Sure.

13 MEMBER STETKAR: I mean, the other rack  
14 might not be there.

15 MR. HEAD: And I'm sure that, having gone  
16 through all the shutdown safety that 1 and 2 goes  
17 through, that this is now added to that as something  
18 that you have to be aware of, and certainly would be,  
19 at 3 and 4.

20 MEMBER STETKAR: Good.

21 MR. HEAD: So did I answer your PRA  
22 question?

23 MEMBER STETKAR: I'm sorry.

24 MR. HEAD: Okay, then I think that -- did  
25 I? I think that's our, probably our conclusion. Open

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 phase detection alarm, enhanced the already robust  
2 design that described today.

3 We have an ITAAC that will ensure the open  
4 phase detection, however that evolves. An alarm meets  
5 design requirements and then we have Tech specs  
6 surveillance that ensure these relays are there as  
7 other relays are in the, covered by text books.

8 CHAIR CORRADINI: Other questions from  
9 the Committee? Okay, thank you very much.

10 MR. HEAD: Thank you.

11 MR. HEACOCK: Thank you.

12 CHAIR CORRADINI: We're a bit ahead of  
13 time. So I guess it would be best to take a break  
14 because we're next scheduled for an hour with the staff  
15 discussing. So let's take a break now and we'll come  
16 back at 10 o'clock.

17 (Whereupon, the above-entitled matter  
18 went off the record at 9:49:58 a.m. and resumed at  
19 10:02:40 a.m.)

20 CHAIR CORRADINI: Okay, why don't we get  
21 started? Okay, so the staff is going to begin with the  
22 Chapter 9. Luis, are you --

23 MR. BETANCOURT: Yeah.

24 CHAIR CORRADINI: -- going to kick us off?

25 MR. BETANCOURT: Yes.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 CHAIR CORRADINI: Okay, go ahead.

2 MR. BETANCOURT: Thank you so much. Good  
3 morning. My name is Luis Betancourt. I am the Chapter  
4 PM for Chapter 9 auxiliary systems.

5 Today the staff presentation will be to  
6 discuss the phase four SER for STP. Today at my side  
7 I have two other technical reviewers who will be  
8 presenting with me today.

9 I have Diego Saenz who will be providing  
10 the criticality evaluation of the spent fuel racks as  
11 well as Ata Istar who will be presenting the structural  
12 and seismic evaluation.

13 This slide provides a list of the staff  
14 reviewers that contributed to the safety evaluation  
15 subsections 9.1.1 and 9.1.2 on the new spent fuel racks.  
16 We've got people from structural, SRSB, materials as  
17 well as a consultant from the National Lab.

18 As NINA provided in their presentation  
19 earlier today, back in 2010 staff provided our  
20 presentation to the ACRS of Chapter 9, sections 9.1.1  
21 and 9.1.2 which relates to new and spent fuel racks  
22 which were still under evaluation. So today's  
23 presentation will be focused on 9.1.1 and 9.1.2.

24 This slide provides a highlight of how the  
25 confirmatory items as well as open items that resulted

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 from the phase two review where all 32 items,  
2 confirmatory items, have been confirmed and closed, as  
3 well as the 3 open items have been all resolved and  
4 closed.

5 Some of the significant changes that  
6 happened since Revision 2, we added in the SER Sections  
7 9.1.1 and 9.1.2. And there have been some provisions  
8 that were primarily to document the closure of the open  
9 items, confirmatory items as well as the, to address  
10 some of the Agency comments.

11 Now to talk about 9.1.1. In this Tier 1  
12 departure, the applicant eliminates the use of the new  
13 fuel vault and specifies that the new fuel will be  
14 stored in the spent fuel storage racks.

15 However the DCD still requires the COL  
16 applicant to satisfy COL items 9.1 which relates to the  
17 criticality analysis and the fuel storage, 9.2 which  
18 relates to the impact analysis on new fuel storage and  
19 9.5 which relates to the new fuel inspection standard.

20 The staff found the COL 9.5 is satisfied  
21 because the staff actually requested an RAI, for the  
22 applicant to provide additional information on the New  
23 Fuel Inspection Stand Seismic Capability Evaluation.  
24 The staff found that it was acceptable because it's  
25 actually the fuel stand will be anchored at the top and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 at the bottom of the fuel pool. And the other COL items  
2 will be addressed in the spent fuel racks.

3 In order to provide supplementary  
4 information in the FSAR the applicant provided a Holtec  
5 report, HI-2135462 to provide the assigned information  
6 including criticality, thermal-hydraulic analysis,  
7 seismic and mechanical assistance in order to address  
8 the following COL items.

9 Diego will be talking today about COL items  
10 9.1 and 9.3. Ata will be talking about COL items 9.2,  
11 9.7 and 9.4. 9.5 was related to -- or 9.8. 9.8  
12 requires the applicant to provide a thermal-hydraulic  
13 analysis that evaluates the spent fuel racks designed  
14 to provide sufficient flow of air and to prevent  
15 nucleate boiling.

16 The applicant used a methodology that has  
17 been used and approved by the staff in other  
18 applications so the staff found it acceptable. So with  
19 that I conclude my part of the presentation and I will  
20 hand, give to Ata.

21 MR. ISTAR: Thank you very much. And prior  
22 to starting to my presentation I would like to recognize  
23 Samir Chakrabarti, who's the lead for this --

24 CHAIR CORRADINI: You have to speak up  
25 please.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. ISTAR: -- who is the lead for --

2 CHAIR CORRADINI: Talk into the  
3 microphone. Just don't hit it with anything because  
4 it explodes in our recorder's ears and makes his life  
5 difficult.

6 MR. ISTAR: I'm sorry. Once again, good  
7 morning. Before I start my presentation I would like  
8 to recognize Samir Chakrabarti who, as the lead for this  
9 project won't be able to be here and make the  
10 presentation. I'm taking his place and he's, luckily  
11 on vacation.

12 And I would like to also recognize other  
13 members -- Yong Li, sitting on my left, who's another  
14 structural engineer that basically performed the  
15 mechanical accident evaluations, and Richard Morenta,  
16 who's the consultant from BNL.

17 And also I'd like to recognize the NINA and  
18 Holtec members who provided responses to our questions  
19 in a very, very timely manner, especially Scott and  
20 Chuck. I do thank you for that.

21 And going back to Slide 8 which serves as  
22 the background and review scope, the applicant provided  
23 the Holtec report which is HI-2135462.

24 Right now it's Version 2 of that report which  
25 provides structural design information and the seismic

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 structural analysis and mechanical accident evaluation  
2 of freestanding spent fuel racks for ABWR fuel at South  
3 Texas Project.

4 Staff review includes seismic structural  
5 analysis and design as well as mechanical accident and,  
6 of course, methodology and assumptions used for the  
7 spent fuel racks. Next page, please.

8 The applicable regulations and guidance  
9 for this review includes 10 CFR 50, Appendix A, General  
10 Design Criteria No. 2 and NUREG 0800 SRP 3.8.4, Appendix  
11 D. Next page, please.

12 Highlights of the staff review, the staff  
13 reviewed Sections 1, 2, 3, 6 and 7, of the Holtec report,  
14 basically the 1, 2, 3, 6 provides the design codes and  
15 standards, drawings, allowable levels, materials,  
16 structural, seismic evaluations. And Section 7  
17 provides the mechanical accident evaluations for the  
18 freestanding spent fuel racks.

19 And staff issued 34 RAIs, basically they  
20 are additional information, clarifications and some  
21 issues that I'll be discussing on the next slide. And  
22 I will elaborate further on those.

23 And there were some clerical issues such  
24 as units were not consistent throughout the report,  
25 that which was taken care of later on by Holtec.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   Interactions with the applicant include  
2 three onsite audits and public conference calls over  
3 a six-month period. And staff identified several  
4 issues pertaining to the analysis and design which  
5 subsequently resolved. Next page, please.

6                   The major structural reviews which I will  
7 go through one by one, some of them. And starting with  
8 the first one, modeling of a fuel assembly, the  
9 applicant or the Holtec staff used a proprietary  
10 program, a computer program called DYNARACK to model  
11 the spent fuel pools.

12                   As you know, they're a 17 by 20 array spent  
13 fuel racks and there are 7 of them in the spent fuel  
14 pool. And this is a proprietary code that, during the  
15 review of the DYNARACK model, the staff identified that  
16 the lump masses for the fuel assembly was at the -- five  
17 lump masses were modeled vertically and they're equally  
18 spaced.

19                   And it was not, the staff was not clear  
20 whether those uncoupled masses were acting properly  
21 during the dynamic events. So the objective of the  
22 dynamic model is to adequately capture the dynamic  
23 characteristics of the free-standing spent fuel racks  
24 under seismic loading conditions and whether these  
25 uncoupled modeling would provide the additional impact

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 loads within the fuel racks.

2 So the applicant agreed to put additional  
3 stiffness values within the masses which, I think there  
4 are -- 56 horizontal springs in octagonal directions  
5 were added to the model.

6 And there were a series of runs made from  
7 very flexible spring constants all the way to very, very  
8 rigid constants. I think there were 13 runs made. And  
9 finally there is, a graph was drawn, Load versus Spring  
10 Constants, changing spring constants, and there were  
11 variation on the impact loads.

12 And additional rattling forces were  
13 identified and applied in the structure. That  
14 resolved the issue that satisfied the staff's concern.

15 The second one is the rack-to-rack impact  
16 load estimation. Rack-to-rack impact load, again, it  
17 was in the DYNARACK model and there were two springs  
18 at the perimeters of the fuel racks.

19 And the staff had a concern about that  
20 stiffness is used rack-to-rack impact, whether the  
21 applicant underestimated the spring constant. And,  
22 consequently, the loads will be, will not be, come up  
23 with conservatively.

24 So the applicant agreed to perform a  
25 sensitivity analysis, increasing the spring values 20

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 percent and 50 percent and provided a graph showing  
2 that, as the spring constant goes higher, the loads were  
3 kind of numbing early, you know, in a diminishing way.

4 So the applicant used a higher load that  
5 was determined from this sensitivity analysis to  
6 qualify the racks. And that was kind of a modeling  
7 issue from the DYNARACK models.

8 The third one is calculating shear stress  
9 factor which is a design issue during the review of  
10 design calculation of the rack. The staff find out  
11 that a cross-section of the overall cells was used to  
12 calculate the shear stresses, but the -- which is the  
13 entire cross-sectional area.

14 But it's effect, I think the staff pointed  
15 out that effective shear area needs to be used, and the  
16 applicant agreed upon that and revised the calculations  
17 accordingly. And during this revision the welds at the  
18 base were, needed to be increased somewhat.

19 And the fourth one, buckling evaluation,  
20 which is, again, a modeling issue. During the design  
21 calculation the applicant performed a compressive --  
22 had a model, ANSYS model, which applied compressive  
23 loads on the cells to determine the stresses and  
24 buckling of the cells.

25 And the staff had a concern that whether

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 the height were chosen to be 4.8 inches is good enough  
2 to characterize that buckling behavior there.

3 So, referring back to this Theory of Elasticity  
4 book, which was written by Timoshenko and Goodier, and  
5 there was a section related to this similar condition  
6 which is simply support at both ends and had height and  
7 base ratio calculation and a graph showing that what  
8 would be the ultimate height for this condition.

9 So the applicant agreed to use that  
10 approach and calculated that height from 4.8 inches to  
11 be raised up to 10 inches. So we made it better and  
12 compressive strength, buckling issue with higher  
13 height still met the allowable stress values. But the  
14 buckling had better results out of its ANSYS run.

15 And going back to sizing the bearing plate,  
16 to commit a direct displacement, this is another issue  
17 that the staff was, a design issue that staff was not  
18 able to find out any discussion or calculation related  
19 to the bearing pad that the pedestals are sitting on.

20 And distributed loads throughout, that  
21 bearing pad hit evenly, so that issue was brought up  
22 to the attention of the applicant and out of this  
23 discussion from 2-inch thickness of the pad it was  
24 increased to 2-1/2 inches to make sure that enough  
25 rigidity was there and the distribution of the loads

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 from the pedestals are evenly distributed on the  
2 concrete pad. And also from this the pads' dimensions  
3 were increased as well.

4 And, No. 6, Analysis, Methodology of  
5 Mechanical Accident, originally the applicant  
6 performed the energy balance methodology on three  
7 different mechanical accident conditions.

8 Those are basically two deep-drop cases  
9 and one shallow-drop cases. Shallow-drop cases at the  
10 edge of the rack and two deep-drop cases, one at the  
11 pedestal and one is away from the pedestal onto the  
12 base.

13 So looking at the hand-calculations and  
14 balance method the staff was not convinced that that  
15 will be the worst drop. And the applicant agreed to  
16 perform a timely analysis for those conditions. And  
17 they've performed for those three cases. And  
18 comparing to the results against energy balance against  
19 LL Stein, LL Stein had a higher stress value.

20 So this is kind of a methodology of a  
21 mechanical accident that resulted between the staff and  
22 the applicant.

23 And lastly, a postulation of scenarios.  
24 And as I told you earlier, the deep-drop cases, one of  
25 the deep-drop cases were performed at the center of the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 rack which this whole design had five pedestals.

2 And the applicant kind of ignored the --one  
3 of them were in the middle and four of them were at the  
4 corners -- ignored the one in the center and performed  
5 the drop-cases based on, at the center of the pad which  
6 is not a realistic condition.

7 So the staff asked them to perform a  
8 deep-drop case away from the pads at the edge of the  
9 fuel rack. And even that provided higher stress  
10 values. And that will be the realistic condition for  
11 the South Texas Project, ABWR design.

12 And the applicant, again, revised the  
13 drop-case scenarios accordingly and it's finally  
14 accepted. And last page, please, Sheet 3.

15 CHAIR CORRADINI: Ata, before you move on  
16 --

17 MR. ISTAR: Yes? Sorry.

18 CHAIR CORRADINI: Thanks for your  
19 thorough discussion, especially on each of these areas.  
20 The question I have, I think it may be apparent, but  
21 was this the first staff review of the DYNARACK  
22 methodology?

23 It seems as if you've identified a number  
24 of different analysis features that I would have  
25 thought may have been addressed in previous reviews.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. ISTAR: Well, the applicant made a  
2 very good presentation about the DYNARACK.

3 And it was, just to give you a little bit,  
4 background on that, DYNARACK has been used for quite  
5 a bit of time. I can't remember, but it has been used  
6 with other fuel rack analyses and has been accepted by  
7 the NRC staff in the past.

8 CHAIR CORRADINI: That's what I had  
9 thought. But I was --

10 MR. ISTAR: Yes, but --

11 CHAIR CORRADINI: -- trying to understand  
12 ----

13 MR. ISTAR: We were --

14 CHAIR CORRADINI: -- the methodology, the  
15 development to here.

16 MR. ISTAR: Yes, exactly. We really  
17 wanted to look into this, more detail and the behavior  
18 of the fuel racks during a seismic event needs to be  
19 correct.

20 So how we can improve those things, and I  
21 think one of the issues was the coupled masses on the  
22 fuel rack was modeled. And we want to make sure that  
23 that elasticity of the fuel racks are really -- they're  
24 all moving in the same path and the same impact loads  
25 are applied along the fuel racks.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           So that's one issue that will be identified  
2 as a concern. And of course we had a higher rattling  
3 force based on that but still meet allowable of the  
4 requirements for that.

5           But, again, going back to the other  
6 analysis, whether those considered this kind of issue  
7 or not. I don't know. But this is what we identified  
8 and as well as in the rack-to-rack impact, that spring  
9 values. We believe that they made it lower than what  
10 it's supposed to be.

11           As you know, as the spring values go higher  
12 the impact loads will go higher.

13           CHAIR CORRADINI: Exactly. And is it  
14 right to conclude that the purpose of, the major purpose  
15 of your onsite audits was to get into the calculations  
16 ---

17           MR. ISTAR: Yes.

18           CHAIR CORRADINI: -- to make sure you had  
19 the opportunity to dig into what had been done and have  
20 an opportunity to review it and make your detailed  
21 comments and evaluations?

22           MR. ISTAR: Exactly. Exactly as I said  
23 earlier and I would like to thank again to the staff  
24 of Holtec, they were open to that. And the originator  
25 of the program, he made us numerous presentations

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 during the audit on specific issues that we asked him,  
2 which really helped the audit. Presentations really  
3 helped us to understand the details of the program.

4 CHAIR CORRADINI: Thank you. Thank you.

5 MR. ISTAR: And finally, in summary, I  
6 would like to conclude that the information provided  
7 by the application is adequate and acceptable to  
8 determine the structural, free-standing fuel storage  
9 racks in accordance with the NRC guidance and  
10 regulations. I thank you.

11 MR. BETANCOURT: Questions? Okay.

12 MR. SAENZ: Okay. I'd first like to  
13 highlight some of the requirements for criticality that  
14 are applicable to this design or most applicable to this  
15 design. First is the 50.68(b)(4) requirement that  
16 requires for spent fuel pools that do not credit soluble  
17 Boron, the K effective that spent fuel rack loaded with  
18 the maximum fuel assembly reactivity must not exceed  
19 0.95 at 95 percent probability, 95 percent confidence  
20 level.

21 There's also a Tech specs requirement  
22 4.3.1.1 that requires the standard cold core geometry,  
23 K infinity, be maintained at or below 1.35.

24 And there's administrative requirements that for  
25 fresh fuel without gadolinia has a maximum of fuel U-235

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 enrichment of 2.95 and for fuel (with gadolinia) up to  
2 5 percent Uranium-235 enrichment there are lattice  
3 design limits on the number of gad rods, the gad rod  
4 locations and the gad rod loading. Next slide.

5 So to highlight a few features of the  
6 design, there's no new fuel racks, as was already  
7 mentioned in the applicant's presentation. There's  
8 only spent fuel racks. There's seven 17 by 20 storage  
9 racks. The new and spent fuel can be stored in any  
10 location within the spent fuel storage racks.

11 And then there's the fuel lattice  
12 requirements are such that even for fuel with gadolinia  
13 it is most reactive fresh so the applicant did some  
14 sensitivity studies to confirm that and also the NRC  
15 staff did a confirmatory analysis to confirm that.

16 The applicant used Metamic as the fixed  
17 neutron absorbing material. Are there any questions on  
18 that? Okay.

19  
20 So to summarize, the Staff find that the  
21 STP spent fuel rack design protects against criticality  
22 with the use of a geometrically safe configuration  
23 given appropriate analysis methodology was used,  
24 appropriate abnormal conditions were analyzed, and  
25 margin exists between the regulatory limit and the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 maximum calculated K effective, which the maximum  
2 calculated K effective including abnormal conditions,  
3 and biases, and uncertainties was .9167, so that had  
4 margin to the regulatory requirement of .95.

5 MEMBER BALLINGER: In one of the documents  
6 you talked about a surveillance program that involves  
7 corrosion coupons and measuring neutron attenuation.  
8 How is that going to be done? --- the corrosion part  
9 I understand, but the neutron attenuation, I didn't see  
10 anything discussing method.

11 MR. SAENZ: Okay. So, those details of the  
12 coupon program were done by two different reviewers.  
13 They're in the room. I don't know if they'd like to  
14 address this specifically.

15 CHAIRMAN CORRADINI: They don't look very  
16 willing. Please identify yourself.

17 MR. YESHNIK: Andrew Yeshnik. Can you hear  
18 me?

19 CHAIRMAN CORRADINI: A little closer.

20 MR. YESHNIK: I'm Andrew Yeshnik from the  
21 Materials and Chemical Engineering Branch, and the  
22 coupon program does have neutron attenuation testing  
23 as is in the Holtec reports, and it should follow the  
24 QA program that Holtec has, so it should be accounted  
25 for.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   MEMBER BALLINGER: That doesn't answer my  
2 question. How are they going to measure the neutron  
3 attenuation?

4                   MR. SASTRE: My name is Eduardo Sastre. I'm  
5 the reviewer for neutron absorbers.

6                   CHAIRMAN CORRADINI: Talk a little bit  
7 slower.

8                   MR. SASTRE: My name is Eduardo Sastre. I'm  
9 the reviewer for neutron absorbers. So, your question  
10 is what tests are they going to perform in the neutron  
11 absorbers?

12                   MEMBER BALLINGER: Yes, what method. Yes.

13                   MR. SASTRE: I don't think we covered which  
14 specific test. Our requirement was that they were going  
15 to test it.

16                   MEMBER BALLINGER: Okay. Can we get an  
17 answer to that?

18                   CHAIRMAN CORRADINI: Holtec might know.

19                   MEMBER BALLINGER: Yes, I just read the  
20 Holtec report. It doesn't say how they're going to do  
21 it.

22                   CHAIRMAN CORRADINI: So as I suspected, you  
23 may have to go get that answer off ---- there we are.  
24 Sorry. Sorry.

25                   MR. RICKNER: I'm at the bottom. My name is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 Bret Rickner from Holtec International. I'm a  
2 criticality analysis expert for the last 10 years. The  
3 coupons are tested initially when they're batched, and  
4 they do neutron attenuation measurements. They also do  
5 chemical analysis and weight measures, so whatever  
6 tests were done initially when they batched the coupons  
7 they repeat those tests because they have to compare  
8 it to the baseline.

9 MEMBER BALLINGER: Okay.

10 MR. RICKNER: Typically, we stick them in  
11 a reactor beam.

12 MEMBER BALLINGER: Okay, so that's what I'm  
13 asking. How ----

14 MR. RICKNER: That's the neutron  
15 attenuation part.

16 MEMBER BALLINGER: Okay. Okay, got it.

17 CHAIRMAN CORRADINI: Thank you.

18 MEMBER BALLINGER: Thank you.

19 MR. BETANCOURT: Any more questions?

20 CHAIRMAN CORRADINI: Any other questions?

21 Okay. This team is off, the next team comes. Bring on  
22 the electrical engineers, or electrical engineer.  
23 Excuse me.

24 MR. BETANCOURT: Let's start with the form  
25 presentation. Good morning, again. My name is Luis

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 Betancourt. I am the Chapter PM and for Section 8.2S  
2 which evaluates the applicant's solution regarding the  
3 NRC Bulletin 2012-1. I want to make a side note. Section  
4 8.2 was there because we wanted to avoid any further  
5 editing to Chapter 8 which has already gone through the  
6 ACRS and is now Chapter 8.2S. However, on the staff  
7 evaluation we needed to include the evaluation of the  
8 tech specs related to the sequence relay, so because  
9 of that we needed to amend Chapter 16, so Chapter 16  
10 we took it from Phase 6 and now it's back in Phase 4.

11  
12 With that being said, as part of the Staff  
13 Review Team we got our engineers over here, we have  
14 Danny Martinez who also participated in the review. We  
15 have people from the tech specs which are in the back,  
16 as well. There were some questions about regarding PRA  
17 so we've got Marie Pohida to answer those questions.  
18 And we also have I&C Staff who evaluated the set point  
19 methodology. So with that being said, I will now give  
20 it to Sheila.

21 MS. RAY: Good morning. My name is Sheila  
22 Ray. I'm in the NRR Electrical Engineering Branch. So,  
23 this first slide talks about the Byron open phase event.  
24 I think we've covered that sufficiently, but I do want  
25 to highlight that manual actions were necessary, and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 this issue has a potential for common cause failure,  
2 so we did evaluate for the new reactors and the  
3 operating fleet. Next slide, please.

4 This slide provides some information on  
5 our history. There was a special inspection at Byron.  
6 We issued an information notice followed by a bulletin,  
7 and based on the responses we issued a summary report.

8 Furthermore, in October of 2013, NEI  
9 provided an NSIAC approved industry initiative to  
10 address the issue. And then Staff issued two RAIs to  
11 the applicant. Next slide.

12 So, the Staff position for the active  
13 plants consists --- it's a three pronged approach, as  
14 you heard from the applicant. It's automatic detection,  
15 alarm in the control room, and automatic mitigation.  
16 And, furthermore, we ask the applicant to provide  
17 training for plant personnel and procedures. Next  
18 slide.

19 So, to begin with the detect and alarm  
20 piece of it. So, as I stated before, the Staff position  
21 requires automatic detection, and alarm in the control  
22 room. And NINA has indicated that there's automatic  
23 detection on all three phases of the main power  
24 transformer and the reserve auxiliary transformers.

25 MEMBER STETKAR: Sheila, does --- I know

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 that the Staff is reacting to the event that happened  
2 at Byron. Does the proposed detection scheme for the  
3 high side of the main power transformer and the high  
4 sides of the reserve auxiliary transformers in this  
5 particular plant specific design solve the real issue?

6 MS. RAY: In terms of detecting and alarming  
7 for the open phase?

8 MEMBER STETKAR: That's correct. That's  
9 what I'm ----

10 MS. RAY: Yes, we believe so.

11 MEMBER STETKAR: You believe that. So, any  
12 potential over ---- open phase in the power supplies  
13 to the safety buses will be detected and alarmed.

14 MS. RAY: Well, let me add two more points.  
15 There is a tech spec for approval offsite sources, and  
16 that gives us some reasonable assurance. And also ---

17 MEMBER STETKAR: Let me ask you, will an  
18 open phase on the high side of the unit auxiliary  
19 transformer be detected and alarmed in this particular  
20 design?

21 MS. RAY: So ----

22 MEMBER STETKAR: It's a yes or a no.

23 MS. RAY: Yes.

24 MEMBER STETKAR: It will? Okay.

25 MS. RAY: So, I haven't seen the analyses

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 on these because as the applicant has stated, we are  
2 ---- we don't know the full details of the design for  
3 the detect and alarm, but ----

4 MEMBER STETKAR: Well, excuse me. They said  
5 that they are going to monitor on the high side of the  
6 main power transformer, and I know where that is. I  
7 could see that, it's out here. I'm asking you whether  
8 or not this design will detect and alarm an open phase  
9 on the high side of a unit auxiliary transformer, which  
10 is peculiar to this design? Did you look at that and  
11 did you think about it in your review of the detection  
12 for this design?

13 MS. RAY: Not particularly that exact  
14 scenario.

15 MEMBER STETKAR: Okay. Why not?

16 MS. RAY: Because we felt that the detection  
17 and alarm on the high side of the ---- you're detecting  
18 at the source.

19 MEMBER STETKAR: No, I'm detecting at the  
20 high side of a unit auxiliary transformer, which is the  
21 supply to the safety bus. It is a different design from  
22 the Byron plant. I am asking you whether ----- did you  
23 think about whether or not the proposed design will  
24 detect an open phase on the high side of a unit auxiliary  
25 transformer, and if not, why not?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MS. RAY: No, we did not.

2 MEMBER STETKAR: Okay. Why not?

3 MS. RAY: Is there ----- maybe I would like  
4 to refer to -----

5 CHAIRMAN CORRADINI: Yes, you can call for  
6 a life line.

7 MR. GOEL: This is Vijay Goel. Because  
8 basically we are concerned about the overhead  
9 conductors, and the high side of the isophase bus.

10  
11 MEMBER STETKAR: I will go back to ---- let  
12 me be the class clown for the moment. I'll go back to  
13 my previous statement that electrical systems are a lot  
14 smarter than the people who analyze them, and  
15 electrical faults are a lot smarter than anything you  
16 can assume about them. So, if you didn't anticipate a  
17 fault, I can say I can anticipate a fault on the high  
18 side of a unit auxiliary transformer. Now Charlie, I'll  
19 end up being the technical guy.

20 MEMBER BROWN: If you look at what --- I'll  
21 just springboard back to the RAI and the other  
22 discussions, the technical information that was  
23 provided. The way I view it, it's only --- they only  
24 did the main power, and they only take the negative  
25 sequence. And in my understanding, and NINA can correct

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 me if I'm wrong, anything that occurred upstream of the  
2 4160 volt say at the unit auxiliary transformers would  
3 be protected based on the negative --- that's --- I'm  
4 looking for heads shaking up and down. They presumed  
5 that they didn't have to do anything on the primary or  
6 the UATs because they had the negative sequence  
7 protection system on all three phases, on all the 4160  
8 volt buses. And did I phrase that properly?

9 MR. HEAD: Yes, you did.

10 MEMBER BROWN: Okay. So, I'm not saying it's  
11 right or wrong, but I don't ---- right now I didn't have  
12 a basis for saying it wouldn't work.

13  
14 MEMBER STETKAR: Yes, I don't know whether  
15 it would or not. I have ---- you'd have to think about  
16 it. But what I'm probing the Staff is, did they think  
17 about that and ask whether or not the existing ---- the  
18 combination of the alarm ---- the detection and  
19 alarming ---

20 (Background noise)

21 MEMBER BROWN: Excuse me, pardon the  
22 interruption.

23 MEMBER STETKAR: --- kV level, and the  
24 protection scheme down at the 4 kV level, whether that  
25 combination would, indeed, solve problems of open

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 phases at the 27 kV level.

2 MEMBER BROWN: The difference the way I view  
3 it is where the fault occurs on the primary of the UAT.  
4 If it's an open line talking relative to the bus that  
5 he's referring to, that gives you one response. But this  
6 is a delta primary side, not a Y side which you end up  
7 in some circumstances with an open delta transformer  
8 configuration which still provides voltage downstream.

9 Now you get phase shift differences in the  
10 currents that you get, the voltage coming in is what  
11 it is, but they didn't talk about that.

12 MEMBER STETKAR: Right.

13 MEMBER BROWN: So, I just don't know whether  
14 ---- how that would work.

15 MEMBER STETKAR: And I don't know either.  
16 I mean, I haven't thought through it. I'm asking whether  
17 the Staff ----

18  
19 MR. HEACOCK: Yes, I'm Evans Heacock. Let  
20 me weigh in on your question of detection on the UAT.  
21 No, we did not look at detection on the UAT. However,  
22 as Charlie has stated, if you have an open phase on the  
23 high side of the UAT that will manifest itself as larger  
24 negative sequence voltages down on the 4160 buses  
25 themselves. And the protection ----

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER BROWN: Yes, but you still haven't  
2 ---- you have an open delta configuration. You're going  
3 to get power transfer to all three phases on the Y side.

4 MR. HEACOCK: Not the same.

5 MEMBER BROWN: It's going to be unbalanced.  
6 I'm not arguing about that.

7 MR. HEACOCK: Now, the delta on the high  
8 side gives you a little difference than a delta on the  
9 secondary with a Y delta. If you lose one phase on the  
10 high side, you lose multiple phases ---- your two  
11 phases actually go low, you end up with a lower voltage  
12 on two phases on the secondary ----

13 MEMBER BROWN: Yes, but it's not zero.

14 MR. HEACOCK: No, it's not zero.

15 MEMBER BROWN: Okay.

16 MR. HEACOCK: I'm just saying it's lower.  
17 And that's actually -----

18 MEMBER BROWN: I don't disagree with that.

19 MR. HEACOCK: Yes, you've got your voltage,  
20 you've got your under voltage would actually see that,  
21 and also the negative sequence.

22 MEMBER BROWN: Okay. Now, the phase  
23 difference would remain the same, 120 degree phase  
24 difference. Now, the currents would be different.

25 MR. HEACOCK: Currents ---- well, you're

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 --- I've got do summations in my head. There are some  
2 that will give you a phase difference. And on that  
3 particular one, I'd have to go back and think. I can't  
4 remember off the top of my head. I think you have some  
5 phase difference but it's not significant. But you do  
6 have ----- you still end up with negative sequences  
7 because your voltage ----

8 MEMBER BROWN: I don't disagree with that.  
9 You're in a ---- you've now got an unbalanced current  
10 situation so you will get negative sequence currents.

11 MR. HEACOCK: Yes, that's what I'm saying,  
12 you do have negative sequence ----

13 (Simultaneous speech)

14 MEMBER STETKAR: Because they're only  
15 picking up voltages. You should -----

16 MEMBER BROWN: That's -----

17 MR. HEACOCK: Yes, you can have an increase  
18 on negative sequence.

19 MR. HEAD: So, Evans, would you repeat the  
20 undervoltage aspect of that? You say --, it will be more  
21 than --. Don't we believe that we would actually have  
22 an undervoltage actuation? You can't hear me right now?  
23 Okay, I'm sorry. Don't you believe we'd have an  
24 undervoltage actuation?

25 MR. HEACOCK: Yes. From the standpoint of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 what Scott was asking, yes, that's what I was stating  
2 earlier. You would end up with two phases that were low,  
3 and that the undervoltage scheme for STP 3 and 4 would  
4 actuate.

5 MEMBER BROWN: I have to go back and try to  
6 do the math, how far it would be. Open deltas are funny  
7 things. I mean, you can support roughly 50 ---- if you  
8 do the classic analysis and you have an open delta  
9 situation occur, you can supply roughly 57 percent or  
10 so of the load that you normally would have seen  
11 otherwise if you had all three transformers. And it's  
12 not two thirds, in other words, because of the  
13 differences that you get phase wise. So, I mean, it's  
14 just not clear to me how big those voltage differences  
15 would be based on the way you're utilizing the -----  
16 how your criteria for set points. I just -----

17 MR. HEACOCK: Right.

18 MEMBER BROWN: Because you didn't do an  
19 analysis ---- nobody ---- there was no analysis for  
20 that.

21 MEMBER STETKAR: You've actually looked at  
22 it though, Evans?

23 MR. HEACOCK: I have looked at a ---- when  
24 you have an open phase on the high side of a delta Y  
25 transformer, the high side being delta which we're

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 talking about -----

2 MEMBER STETKAR: Yes. That's right, yes.

3 MR. HEACOCK: I have looked at those, yes.

4 MEMBER STETKAR: You have.

5 MR. HEACOCK: Yes.

6 MEMBER STETKAR: And you do get -----

7 MR. HEACOCK: Low voltages on two phases on  
8 the secondary.

9 MEMBER BROWN: But not an open in the bus  
10 but, I mean, an open in the actual transformer itself.

11 MR. HEACOCK: Yes, it could be anywhere.

12 MEMBER BROWN: Okay.

13 MR. HEACOCK: Anywhere that disconnects the  
14 signal phase.

15 MEMBER BROWN: All right. I've got to think  
16 about that.

17 MEMBER STETKAR: Have to think about it.

18 MEMBER BROWN: Yes. All right. The answer  
19 is you've done ---- right now the right answer, not the  
20 right answer, the answer you're giving is we do it on  
21 the high side of the main power, we do it on the negative  
22 sequence, anything that happens in between the output  
23 of the main power transformer and the 4160 volt bus is  
24 covered by -----

25 MEMBER STETKAR: The 4160 volt bus, that's

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 get back to the earlier question, the 13.8kV feeds and  
2 the 27, you know, would the operators know what's going  
3 on, but ----

4 MEMBER BROWN: Exactly.

5 MEMBER STETKAR: ---- the more important  
6 part of my probe is how carefully did the Staff actually  
7 think about the electrical system at this plant when  
8 you wrote the RAIs, because the ----- just because the  
9 issue was prompted by a particular fault at a particular  
10 plant with that plant design, you know, are you trying  
11 to fit every plant in the world to do that such that  
12 if everybody in the world simply monitors the high side  
13 of what they call their main power transformer, that's  
14 going to solve everybody's problems. And it sounds like  
15 that's the approach you took.

16 MS. RAY: That is the approach the Staff has  
17 taken.

18 MEMBER STETKAR: Okay. And that's certainly  
19 not an adequate approach in the grand scheme of Staff  
20 reviews of these designs. On the record, in my personal  
21 opinion.

22 CHAIRMAN CORRADINI: But just to put that  
23 in context, what NINA is proposing given that the  
24 detection scheme has to be designed and is common  
25 amongst current operating plants and new plants, given

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 that, what they're proposing in terms of detection  
2 looks reasonable. You're worried about the whole review  
3 process.

4 MEMBER STETKAR: I'm worried about the fact  
5 that this particular design because the ---- if I can  
6 go from 345, the Y delta, delta Y, as I get down to the  
7 safety buses, perhaps this particular design with the  
8 detection out on the Y side of the 345, and if indeed  
9 an open phase on the delta side of the 27 ---- of the  
10 UATs, if that's protected against by the protection  
11 relaying then the detect at the 345 with the ultimate  
12 protection at the 4kV may indeed solve the problem for  
13 this particular design.

14 CHAIRMAN CORRADINI: But you're more  
15 worried about the generic review on all possibilities.

16 MEMBER STETKAR: Exactly. And if the  
17 staff haven't probed that, if they're failing open on  
18 this particular design, it's not clear how carefully  
19 they're thinking about the overall issue.

20 CHAIR CORRADINI: From the report, and the  
21 applicant has looked at this, but, absent the --

22 MEMBER STETKAR: No, but, from, no, from  
23 our oral presentation today, they said they've thought  
24 about it.

25 CHAIR CORRADINI: Yes.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: Nobody --

2 MEMBER BROWN: But they didn't do any --  
3 they didn't do --

4 MEMBER STETKAR: I understand that.

5 MEMBER BROWN: -- an analysis where they  
6 determined what the negative sequence currents are.

7 MEMBER STETKAR: Right.

8 MEMBER BROWN: Well, what the negative  
9 sequence voltages are, and whether they would be  
10 covered for that UAT --

11 MEMBER STETKAR: By the relays.

12 MEMBER BROWN: -- by the relays, and the  
13 4160 volt bus.

14 CHAIRMAN CORRADINI: Okay, just since we  
15 have this nice discourse amongst each other, I want to  
16 make sure. NINA, so did you guys hear what Charlie just  
17 said?

18 MEMBER BROWN: No, they were chatting.

19 MR. HEAD: Yes, sir, but I didn't absorb  
20 it.

21 CHAIRMAN CORRADINI: Okay, can you repeat  
22 it? Because he's characterizing what you did. I want  
23 to make sure that's the appropriate characterization.  
24 Can you repeat it Charlie?

25 MEMBER BROWN: Okay. Alarm on the main

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 power input, negative sequence relays on the 4160 volt  
2 bus. There's no open circuit detection relative to the  
3 UATs input.

4 You didn't do any analyses for an open  
5 circuit on the UATs to see what the negative sequence  
6 voltages would be, and if the voltage, you know, your  
7 negative sequence sensors would take care of that.

8 There's another part of this question now  
9 that is --

10 MEMBER STETKAR: Equipment lightly  
11 loaded, heavily loaded, unless there's --

12 MEMBER BROWN: -- for the lightly loaded  
13 -- so, but you've thought about the thing, but you  
14 didn't analyze it. That's, that was what I got out of  
15 the comment a few minutes ago. I'm not saying it's  
16 right or wrong.

17 I'm just saying it doesn't, there's a  
18 disconnect right at the input on the primary side of  
19 relays.

20 MR. HEAD: The negative phase sequence  
21 relays, they are there for whatever. However it  
22 occurred.

23 MEMBER BROWN: The point is whether --  
24 okay.

25 MR. HEAD: No matter how it occurs, they

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 are there and will protect the motors.

2 MEMBER BROWN: But is the response  
3 different at that point relative to it is on the main  
4 power transformers?

5 MR. HEAD: I guess what I'm --

6 MEMBER BROWN: I just don't know.

7 MR. HEAD: -- the scenario I'm hearing is  
8 the possibility that we've addressed a maybe, I'll call  
9 it the switchyard phenomena, but there's some internal  
10 failures that you're -- the motors are protected with  
11 the 4160s, but maybe this detection scheme that the  
12 industry is headed towards won't detect those.

13 MEMBER BROWN: Something in between.

14 MR. HEAD: Something in between, and I  
15 think the intro was that that's not as likely a failure  
16 as you have from a cable or, you know --

17 MEMBER BROWN: On a bus standpoint, he  
18 just said that they, because a bus is not like a cable  
19 coming in from a transformer.

20 MR. HEAD: Exactly. And so, you know,  
21 that --

22 MEMBER BROWN: But I'm thinking of the  
23 transformer. A transformer failure, itself,  
24 internal, as opposed to a bus failure.

25 MR. HEAD: And I have to agree, sort of.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER BROWN: I agree with the bus.

2 MR. HEAD: Okay. I think those sort of  
3 failures have ways of being identified other than this  
4 alarm, because obviously, the alarm isn't, but through  
5 the entire scenario, the motors are protected,  
6 regardless of how it happens.

7 CHAIRMAN CORRADINI: That's your ultimate  
8 objective.

9 MR. HEAD: Yeah.

10 CHAIRMAN CORRADINI: That's what I want to  
11 make sure.

12 MR. HEAD: Yes, sir. That is our ultimate  
13 objective.

14 MEMBER BROWN: Are all the 13.8 loads  
15 protected, as well?

16 MR. HEACOCK: No.

17 MR. HEAD: No.

18 MEMBER BROWN: No? So you haven't, I  
19 noticed that. That you had not worried about those.

20 MR. HEACOCK: Well --

21 MR. HEAD: Because they're nonsafety now.  
22 (Simultaneously Speaking)

23 MEMBER BROWN: There was nothing done  
24 relative to those, other than the open phase on the  
25 input to the main power transformer.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. HEAD: Right, there's --

2 MEMBER BROWN: The alarm.

3 MR. HEAD: No, sir. There is, at this  
4 point in time, not a business case for us to do that.

5 MEMBER BROWN: That's fine. Okay, I got  
6 the answer.

7 MR. HEAD: Okay, and Evans is going to also  
8 clarify some.

9 MR. HEACOCK: This is Evans Heacock, and  
10 I just want to, on the 13.8 motors, yes, those are  
11 considered actually part of our protection scheme would  
12 be, include a current unbalance relay, similar again  
13 to what we have for (Units) one and two to protect those  
14 motors for this particular event.

15 MEMBER STETKAR: That's what we say for  
16 the circ water pump motors --

17 MEMBER BROWN: Okay.

18 MR. HEACOCK: Okay.

19 MEMBER STETKAR: -- for the event that  
20 actually happened there, they were protected, because  
21 they're big --

22 MEMBER BROWN: Because you have a current  
23 unbalance set up.

24 MEMBER STETKAR: Yeah, and they worked.

25 (Simultaneously Speaking)

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER BROWN: A different protection  
2 scheme.

3 MR. HEACOCK: A different protection  
4 scheme, correct.

5 MEMBER BROWN: All right.

6 MR. HEACOCK: But there's one in place.  
7 There will be.

8 MEMBER BROWN: Okay.

9 MEMBER STETKAR: But it's a --

10 MEMBER BROWN: But it's not --

11 MEMBER RAY: -- it's at the individual  
12 load level for the --

13 MR. HEACOCK: Right.

14 MEMBER STETKAR: -- big motors rather than  
15 shedding the whole bus --

16 MR. HEACOCK: Correct.

17 MEMBER STETKAR: Yeah.

18 CHAIRMAN CORRADINI: Okay, I got that. I  
19 think their staff has another point to make.

20 MS. MARTINEZ: Yes, just a quick  
21 clarification. My name is Tania Martinez-Navedo from  
22 the electrical engineering branch. The staff position  
23 in the slide focuses particularly on the failure that  
24 occurred and was defined in the real time. So it was  
25 the loss of an off-site power line.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           And that's the reason why it was focused  
2           on detection on the high side, rather than inside, in  
3           the circ pumps of the plant.

4           CHAIRMAN CORRADINI:  Yeah, I think we've  
5           got that.  I think what the members are saying is, since  
6           you're going through all this effort, you might as well  
7           be somewhat comprehensive to make sure that it's not  
8           just what you saw, but what could occur in other ways.

9           MEMBER STETKAR:  When the next one happens  
10          that is not that particular failure in that particular  
11          design, we'll have another bulletin and we'll have  
12          another --

13          MEMBER BROWN:  But even, I believe, after  
14          the bulletin was issued for that one event, staff  
15          uncovered about four or five additional events over the  
16          last ten years that were not the same.

17          CHAIRMAN CORRADINI:  Okay.  Thank you.  
18          Okay, Sheila, we're right on track.

19          MS. RAY:  And I just also wanted to mention  
20          that there is an ITAAC for the alarm detection scheme.

21          CHAIRMAN CORRADINI:  That, I think we  
22          wrung out of the applicant earlier.  Thank you.

23          MS. RAY:  I think we've covered this one.  
24          So the next piece is the mitigation scheme, which, as  
25          we've talked about, is the negative sequence relays.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 And this is for protection of the Class 1E 4160 volt  
2 loads. All right, so next slide.

3 So the staff finds the mitigation scheme  
4 acceptable, since it protects the Class 1E loads and  
5 we've audited the simulations and analyses to show the  
6 detection scheme will work and identify an open phase  
7 and protect the loads.

8 Furthermore, there is a tech spec for the  
9 negative sequence relays that the applicant has  
10 discussed. So next slide. This is regarding the  
11 training and the procedures.

12 The applicant will be developing training  
13 as well as procedures for maintenance and testing for  
14 the monitoring system. Next slide. And the staff  
15 finds this acceptable, since training will be  
16 developed.

17 And also, there will be maintenance and  
18 testing procedures, as well as calibration and  
19 troubleshooting procedures. So next slide. Sorry.

20 CHAIRMAN CORRADINI: Oh, don't worry  
21 about it.

22 MS. RAY: That was me.

23 MEMBER BROWN: They'll just get you.

24 CHAIRMAN CORRADINI: You do that once  
25 more, and he goes nuts.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MS. RAY: I'll do my best.

2 CHAIRMAN CORRADINI: That's right.  
3 We've made a request for a generic action item to get  
4 rid of these microphones, but it proceeds through the  
5 NRC evaluation process.

6 MS. RAY: I understand.

7 CHAIRMAN CORRADINI: I could be dead.

8 MALE PARTICIPANT: But in that way, we  
9 know that he's woke up, so.

10 MEMBER STETKAR: Does it need to go  
11 through ACRS?

12 CHAIRMAN CORRADINI: Huh?

13 MEMBER STETKAR: Does it need to go  
14 through ACRS?

15 CHAIRMAN CORRADINI: God help us all.  
16 Anything that's initiated here dies. Go ahead, sorry.

17 MS. RAY: This slide is a bit repetitive  
18 from the applicant. They have discussed FSAR updates  
19 as well as the tech spec on the negative sequence  
20 relays. And furthermore, as I mentioned, there is a  
21 specific ITAAC to verify the detection alarm scheme.

22 Next slide. So in summary, the applicant  
23 has provided information for a scheme to detect alarm  
24 and automatically respond to an open phase event. And  
25 the staff finds this issue acceptable. Questions,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 comments.

2 CHAIRMAN CORRADINI: Additional  
3 questions for Sheila? Okay, thank you very much.

4 MS. RAY: Thank you.

5 CHAIRMAN CORRADINI: We'll move on to --

6 MEMBER BROWN: Part 21.

7 CHAIRMAN CORRADINI: -- Part 21. NINA'S  
8 back up. I can at least finish you off.

9 MR. HEAD: Ready?

10 CHAIRMAN CORRADINI: Ready.

11 MR. HEAD: So, yes. I appreciate the  
12 opportunity. We were asked to discuss this issue  
13 that's been recently identified regarding suppression  
14 pool water level. And, move on to the next slide.  
15 And, you know, obviously Steve Thomas, and Jim, and  
16 myself will lead this presentation.

17 Just from a background standpoint, in  
18 March of this year, GEH identified a potential Part 21  
19 associated with the assumptions used to calculate ABWR  
20 hydrodynamic loads.

21 In essence, the suppression pool level  
22 used for the development of the hydrodynamic loads  
23 might not have been conservative. The analysis, the  
24 original analysis was done at the tech spec high set  
25 point level.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   However, following a feed water line  
2 break, that level was increased, and that increased  
3 level was not originally, was not considered in the  
4 original analysis.

5                   The original potential Part 21  
6 documentation indicated that the access tunnel was the  
7 issue, the structure that was most likely to be  
8 impacted.

9                   And then I'll just note that here, the  
10 final GEH report concluded that there was no  
11 substantial safety hazard and no impact on the tech  
12 spec, and was not reportable.

13                   Just some technical background. During a  
14 LOCA, the suppression pool is subject to the following  
15 hydrodynamic loads, many of which we've discussed with  
16 ACRS in previous meetings.

17                   Pool swell, condensation oscillation, and  
18 chugging. Pool swell is really an air phenomena, and  
19 the impact of this higher pool level would really be  
20 seen more in the condensation oscillation and chugging  
21 loads related loads.

22                   These loads can impact the suppression  
23 pool walls and the structures. And the suppression  
24 pool water level increased, level increases the extent  
25 of the hydrodynamic pressure loads on the suppression

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 pool walls and submerged structures.

2 CHAIRMAN CORRADINI: Since we're not  
3 talking electrical, and this kind of stuff, I kind of  
4 understand a little bit of this, can I ask --

5 MR. HEAD: Yes, sir.

6 CHAIRMAN CORRADINI: -- so the  
7 identification of this as a, I'll use the word mistake,  
8 was a change in elevation of what amount? Less than  
9 a foot, I remember.

10 MR. HEAD: No, sir. It ends up about  
11 three feet.

12 CHAIRMAN CORRADINI: Oh, I thought it was  
13 a foot.

14 MR. HEACOCK: No, it's --

15 MEMBER BROWN: A meter.

16 MR. HEACOCK: -- maybe a meter.

17 CHAIRMAN CORRADINI: A meter. Okay. So  
18 it was one of something. I said the wrong measure.  
19 And this is just a miscalculation, or a --

20 MR. HEACOCK: An assumption.

21 MR. HEAD: It's an assumption. When the  
22 analysis was done, and here's the water level you'd be  
23 starting with.

24 CHAIRMAN CORRADINI: Right.

25 MR. HEAD: Okay? Well it turns out, while

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 chugging and condensation oscillation loads are still  
2 occurring, the water level may have increased another  
3 three feet or a meter.

4 CHAIRMAN CORRADINI: Oh, okay.

5 MR. HEAD: And so you have additional  
6 water that's either hitting stuff, you know, impacting  
7 the walls or impacting the --

8 CHAIRMAN CORRADINI: Okay.

9 MR. HEAD: -- tunnel. So that's the  
10 phenomena that's going on.

11 CHAIRMAN CORRADINI: Remind me one other  
12 thing. The initial nominal water level is what?

13 MR. HEAD: 7.1 meters.

14 CHAIRMAN CORRADINI: Okay.

15 MR. HEAD: That's the high expect level.

16 CHAIRMAN CORRADINI: Or the initial water  
17 level inside of it?

18 MR. HEAD: Right, in the tech spec.

19 CHAIRMAN CORRADINI: Tech spec, all  
20 right, 7.1.

21 MR. HEAD: But due to the accident  
22 analysis, it could be higher than --

23 CHAIRMAN CORRADINI: Right.

24 MR. HEAD: -- after --

25 CHAIRMAN CORRADINI: Right.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 (Simultaneously Speaking)

2 MR. HEAD: After the feed water line  
3 break, obviously the water is --

4 CHAIRMAN CORRADINI: Okay.

5 MR. HEAD: -- going to go down in the  
6 suppression pool area.

7 CHAIRMAN CORRADINI: Thank you.

8 MR. HEAD: So after this, after the  
9 initial report, NINA requested Toshiba to evaluate the  
10 impact of this assumption for STP 3&4. And Toshiba  
11 performed a conservative analysis that concluded that  
12 the increase of about one meter that it does increase  
13 for about one meter for the feed water line break LOCA.

14 And their conclusions are, which we've  
15 received obviously, is that the most, for the most  
16 limiting load combination, there is no significant  
17 effect on the containment structure.

18 It's a one, less than a one percent  
19 increase in stress. Okay, you can go to the next one.  
20 This is it. With respect to the access tunnel, which  
21 was mentioned in the initial GE report and discussed  
22 in a subsequent report, we noted that it's not analyzed  
23 in the DCD, and will be designed later as part of the  
24 detail design of the plant.

25 We did ask Toshiba, though, with respect

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 to the Japanese plants and the tunnels that exist over  
2 there what would the impact be with respect to them,  
3 and also, it's a gain of less than one percent increase  
4 in stress loading on those tunnels. Our actions --

5 CHAIRMAN CORRADINI: So --

6 MR. HEAD: Sir, go ahead.

7 CHAIRMAN CORRADINI: -- can I ask you this  
8 -- different question. Maybe you're not prepared for  
9 it, but I'm just trying to think. I'm just, I want to  
10 rid myself of phases and --

11 MEMBER BROWN: I'm going to do a vector up  
12 here and we'll --

13 MR. HEAD: That, I can do.

14 MEMBER STETKAR: You'll notice, by the  
15 way, Mike, that we did not use a human being's name,  
16 and the jargon of the, Joe's correlation in any of that  
17 discussion. It was strictly focused on technical  
18 things.

19 CHAIRMAN CORRADINI: Well, when it's  
20 linear and easily analyzed, I guess so. Okay, so what  
21 I didn't understand though is the one percent, a 15  
22 percent change in the level is causing a one percent  
23 change in the various loads.

24 That would imply to me, though, that in the  
25 chugging phase, a lot of the structure is still above,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 that could be impacted is still above where the water  
2 is hitting. I'm trying to understand if this is like  
3 the washing machine, I've got a chugging action, why  
4 I only have a one percent effect.

5 MR. HEAD: Well, because chugging, or  
6 condensation oscillation, is not the only load you  
7 assume on the containment.

8 CHAIRMAN CORRADINI: So it's a small part  
9 of the load, regardless?

10 MR. HEACOCK: Yes.

11 MR. HEAD: It's a small part of the load,  
12 regardless.

13 CHAIRMAN CORRADINI: Okay, fine.

14 MR. HEAD: Okay? And so the one percent  
15 for the containment, that's what we were pretty much  
16 expecting, given it's really just additional mass that  
17 you're adding to the seismic analysis. And all the  
18 other loads --

19 CHAIRMAN CORRADINI: Mm-hmm.

20 MR. HEAD: -- all those combinations are  
21 already there.

22 CHAIRMAN CORRADINI: Okay.

23 MR. HEAD: It's essentially ten percent of  
24 seven percent of the total load combination. It's  
25 actually about .7 percent increase.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN CORRADINI: Say it again, I'm  
2 sorry?

3 MR. THOMAS: For a chugging contribution  
4 --

5 CHAIRMAN CORRADINI: Oh.

6 MR. THOMAS: -- to the total load is seven  
7 percent and it increases by ten percent.

8 CHAIRMAN CORRADINI: Okay, got it.

9 MR. THOMAS: So you've got a ten percent  
10 increase of seven percent.

11 CHAIRMAN CORRADINI: Okay, fine.

12 MR. HEAD: So our action is, we submitted  
13 the letter to NRC in early September after the GE report  
14 came out. And we wanted obviously to review it and make  
15 sure we understood what they had done. And we, in our  
16 report, we concluded, in our letter, we concluded that  
17 it's not a significant safety issue.

18 The NRC audited the Toshiba evaluation in  
19 September. That was done per NINA's request to, you  
20 know, understand the work that was done there. And to  
21 basically close this issue out from a regulatory  
22 perspective, we offered a site-specific ITAAC that was  
23 developed, that will ensure that this issue is  
24 addressed when we do the final, you know, plant design,  
25 and if this aspect is discovered.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   And in conclusion, we agreed that there is  
2 not a significant safety issue, determined there is not  
3 a significant safety issue. And we believe our results  
4 are consistent with the GEH evaluation.

5                   CHAIRMAN CORRADINI: Questions by the  
6 Committee? Okay. Thanks. We'll have staff come up.  
7 Go ahead, you guys can load it up there.

8                   MR. TAI: Okay. Well, slides to lose.  
9 Good morning, this is Tom Tai, again. Yong Li is our  
10 co-reviewer for this Part 21 issue with Samir. Samir  
11 is vacationing, so he is having a good time. And Henry  
12 will be joining us shortly.

13                   In first slide is a little background that  
14 you, STP already showed to you that GE submitted a  
15 potential Part 21 evaluation in terms of 10 CFR 21, 21A.  
16 That they identified problem that they think is a  
17 concern so they can look into it.

18                   And essentially, it's a tech spec high  
19 water level of 7.1 meters. They think it should be  
20 higher, because of the flow down, so that would bring  
21 it up to about eight meters.

22                   And they think the access tunnel is  
23 probably the most vulnerable structure, so to speak,  
24 for this particular analysis. And in the final report,  
25 in -- are these our slides?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN CORRADINI: Yes, that's what I  
2 wanted to say. Those aren't --

3 MR. TAI: Are these our slides?

4 CHAIRMAN CORRADINI: Nope, they're not.

5 MR. TAI: Oh, of course.

6 MS. BANERJEE: These are NINA's slides.

7 CHAIRMAN CORRADINI: NINA's slides.

8 MS. BANERJEE: Part 21 ACRS presentation?

9 MR. TAI: And then I press --

10 MEMBER BROWN: Okay, there you go.

11 CHAIRMAN CORRADINI: There you go.

12 That's it.

13 MR. TAI: I knew it was familiar, but I  
14 didn't know it was --

15 CHAIRMAN CORRADINI: You must have  
16 realized how low-budget an organization we are.

17 (Simultaneously Speaking)

18 CHAIRMAN CORRADINI: Hit the slide show  
19 so, hit the slide show button.

20 MR. TAI: Okay.

21 MALE PARTICIPANT: F5.

22 CHAIRMAN CORRADINI: Great.

23 MR. TAI: Okay. There you go. Now I  
24 recognize myself. In August, they find a, GE finally  
25 sent us the results of the final evaluations. And they

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 concluded that it is not a reportable, and there is no  
2 change of tech spec.

3 And STP or NINA followed up on September  
4 15, and they gave us their own evaluation with help from  
5 Toshiba, using some of the input from the Japanese ABWR  
6 plant, and they draw the same conclusion.

7 I want to bring this one up in here for  
8 stakeholders, because I want to make sure that we have  
9 talked about the COL application, and I'll get to that  
10 later on. GEH is still the original ABWR design  
11 applicant. But that design was certified in 1997.

12 I'm sure you guys had a lot of discussion  
13 with AP1000, Vogtle, and Summer. I just want to bring  
14 this up. So we are asking STP to address this question,  
15 not the ABWR designs for it. Toshiba is the, one of  
16 the EPC teams for NINA to support the COL application,  
17 and in the future constructions.

18 And I want to emphasize that, because we  
19 had a lot of discussion about ultimate vendor  
20 qualification about five years ago. That doesn't make  
21 them the owner of ABWR. All that does, all that did  
22 was to make sure they are qualified to go buy the design  
23 for ABWR.

24 And we are who we are. Our review, when  
25 we first got that notice from GE, almost, like, the day

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 after, we've been engaging STP to find out what the,  
2 so that they are aware of that.

3 And we follow them just to find out what  
4 has been, what is going on and what are they doing. So  
5 it was a pretty well-coordinated effort. And of  
6 course, we don't hear anything for about six weeks.

7 And when we finally got the results from,  
8 or when we expect the results from NINA in September,  
9 we have a meeting on September 9 just to go through some  
10 of the preliminary findings that they had.

11 And when they finally submitted to us, I  
12 think it was September 15, we did the audit on September  
13 19 on the report that they gave us. We accept the  
14 technical presentations. We have some observations,  
15 but they are more like editorial quality type.

16 Because they reported it, if there is not  
17 supposed to be a design supposed to submit to us  
18 internally. And at the end, we agree with NINA that  
19 this is not reportable. But we had a lot of internal  
20 discussion.

21 How do you approve a COL application when  
22 you know there is an imperfection in the analysis that  
23 they are going to do eventually? So the ITAAC itself  
24 will help us out to cover that.

25 The ITAAC is basically a, I will call that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 an extension of an existing TON-ITAAC in the DCD in  
2 Table 2.14.1 item 14. What that one does, when you do  
3 the containment analysis to, using a spill condition,  
4 all the internal structures need to meet the design load  
5 in section 2.14.1.

6 That is the DCD ITAAC. The ITAAC that NINA  
7 is proposing, to put into site specific, table 3.0, that  
8 one basically said that consider a high suppression  
9 pool level because of low down.

10 So we're not imposing any additional load  
11 in on the applicant, but it will be a good reminder five  
12 years, ten years from now, whenever that is, that when  
13 you do the analysis, you won't forget. But that's what  
14 I had in mind.

15 CHAIRMAN CORRADINI: So let me make sure  
16 I understand. So you're, let me summarize. The  
17 analysis done by NINA, there's not an issue. The ITAAC  
18 is there to record it in what fashion? So that any  
19 downstream analysis by the COL applicant is not  
20 forgotten?

21 MR. TAI: When you do the final analysis  
22 for the containment, based on the as-built, you will  
23 use the suppression pool level. The right --

24 CHAIRMAN CORRADINI: So the ITAAC is just  
25 a placeholder to remind everybody?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. TAI: That's correct.

2 CHAIRMAN CORRADINI: Okay.

3 MR. TAI: Which is not different than DCD  
4 ITAAC. Because DCD -- or that you had to do containment  
5 analysis to make sure as-built design is consistent.

6 MEMBER SCHULTZ: Using the as-built as  
7 finally designed.

8 CHAIRMAN CORRADINI: Okay. All right.

9 MS. BANERJEE: So your design of that  
10 thing up there --

11 MR. TAI: The access tunnel. That thing,  
12 yeah.

13 MS. BANERJEE: Tunnel.

14 MR. TAI: Conclusion. NINA and Toshiba  
15 decide, or conclude, that this one concerned assumption  
16 is not a reportable under Part 21, and we agreed. And  
17 like we mentioned earlier, because of this concerns  
18 that, you know, when you have this potential Part 21,  
19 or changes or imperfection, even there is no safety  
20 impact, I think it is our duty to make sure that you  
21 don't carry over that kind of a problem downstream.

22 So the ITAAC takes care of that in the third  
23 bullet. And because we are adding an ITAAC, or because  
24 they are adding an ITAAC and we accept that, we have  
25 to make some changes to capture that new item in the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 FSAR, in the SER, I'm sorry.

2 The SER that I expect, that we're revising  
3 is part, Chapter Six and Chapter 3.8.4. Referring to  
4 the ITAAC is what we plan to do. The last bullet is  
5 not, has nothing to do with COL, because this issue is  
6 too, weighing very heavy on our mind, management  
7 especially.

8 So we have two applications from, one from  
9 GE, one from Toshiba for the renewal of the ABWR. That  
10 is in-house and we're probably starting the review  
11 sometime maybe next year or the year after.

12 CHAIRMAN CORRADINI: Say it again, I'm  
13 sorry? A bit slower.

14 MR. TAI: There is AWBR renewal projects.

15 CHAIRMAN CORRADINI: Oh.

16 MR. TAI: There are two new projects, one  
17 by Toshiba, one by GEH. And they are in-house already  
18 for --

19 CHAIRMAN CORRADINI: To renew the  
20 certification?

21 MR. TAI: To renew certification, which  
22 expired in, what, 2012? So we will, our tech staff is  
23 planning on asking them, what you do about this type  
24 of questions. I think for some of them, it's already  
25 done, but --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 (Simultaneously Speaking)

2 MR. TAI: -- but it doesn't mistake an  
3 ABWR. That would fix it. And that's all the  
4 conversation I have. Any questions?

5 CHAIRMAN CORRADINI: Questions by the  
6 Committee? Okay. Let's do this. I think this would  
7 be the appropriate time -- thank you very much, Tom.

8 MR. TAI: Thank you.

9 CHAIRMAN CORRADINI: Okay? I think this  
10 is the appropriate time to take the public comments,  
11 because there are a couple people on the line.

12 MS. BANERJEE: Yeah, let me go check.

13 CHAIRMAN CORRADINI: Is there anybody in  
14 the audience that wanted to make a comment? They  
15 declined. So we'll turn on the -- to allow for, so if  
16 anybody's out there on the line, can you please at least  
17 acknowledge you're there so we know that the line is  
18 open?

19 (Simultaneously Speaking)

20 MALE PARTICIPANT: It's not open yet.

21 MEMBER BROWN: You can't hear any snap,  
22 crackle and pop noise, crispy sounds. That's a  
23 detailed electrical comment.

24 CHAIRMAN CORRADINI: Snap crackle and  
25 pop, Rice Krispies sounds.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MALE PARTICIPANT: It has nobody's name  
2 associated with it as a correlation. So therefore, you  
3 can't get full professorship.

4 CHAIRMAN CORRADINI: Folks are out there,  
5 wait a minute, I don't think we have a line open yet.

6 MS. BANERJEE: Someone is opening the line.

7 MALE PARTICIPANT: Okay, we hear  
8 something.

9 CHAIRMAN CORRADINI: There it is. Is  
10 anybody out there?

11 MR. SHARP: Hi, yes, this is Phil Sharp  
12 GE Hitachi, we heard the presentation there on the Part  
13 21, and at least I have no public comments.

14 CHAIRMAN CORRADINI: Okay, thank you,  
15 Phil. Good to hear from you. Anybody else on the  
16 line?

17 MS. LIANGE: Jilly Liange, GE San Jose. I  
18 have no comments.

19 CHAIRMAN CORRADINI: Okay. Member of the  
20 public? Okay. Hearing nothing, that means we have  
21 nobody on the line from the public making a comment.  
22 We can close the line. And let me go around the room  
23 to the Committee members. We'll start with Ron.

24 MEMBER BALLINGER: Nothing.

25 CHAIRMAN CORRADINI: Any comments?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER BALLINGER: No, thank you.

2 CHAIRMAN CORRADINI: Charlie? Member  
3 Brown?

4 MEMBER BROWN: Nope. I've already  
5 exhausted my comments. I won't amplify it.

6 MEMBER BLEY: Nothing additional from me,  
7 thank you.

8 MEMBER STETKAR: Nothing more.

9 CHAIRMAN CORRADINI: Dr. Powers?

10 MEMBER POWERS: I support everything  
11 Charlie had to say.

12 MEMBER SCHULTZ: No further comment.

13 CHAIRMAN CORRADINI: Okay. Let me not  
14 comment about today. I just wanted to thank NINA and  
15 their support from Holtec about discussing Chapter  
16 Nine. And the very interesting open phase discussion  
17 for Chapter Eight supplement.

18 I wanted to remind the members that this  
19 is the second to the last Subcommittee meeting, which  
20 has spanned four and a half years of fun. And about  
21 15 Subcommittee meetings, as far as my count has gone.

22 And so the last one, which will primarily  
23 deal with Fukushima issues and primarily mitigating  
24 strategies, which will be December the 3rd in the  
25 afternoon, is where we're going to wrap up anything,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 everything.

2 So I wanted to at least alert the members,  
3 we're trying to come up with an internal memo to remind  
4 everybody, since I know you have a crisp memory, but  
5 I don't, what occurred over the last four and a half  
6 years, and the things that will eventually roll into  
7 --

8 MEMBER POWERS: You are amazingly  
9 inefficient, aren't you?

10 CHAIRMAN CORRADINI: Thank you. That's  
11 on the record, too. So I wanted to summarize all the  
12 pieces of the puzzle, so to speak, so that when we come  
13 into the, when we have a final presentation to the full  
14 Committee, at least we all have the various issues that  
15 we will potentially raise or discuss in the final  
16 letter.

17 That, I'll try to have to the members prior  
18 to the December 3rd meeting, so at least you have it  
19 to read. Because I know you wanted something to read.

20 MEMBER BROWN: So December 3rd  
21 Subcommittee meeting?

22 CHAIRMAN CORRADINI: Subcommittee  
23 meeting, excuse me. December 3rd Subcommittee  
24 meeting. Okay? I really don't have anything else.

25 MEMBER SCHULTZ: I just have one comment,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 since you've announced their next meeting on December  
2 3rd for NINA's benefit is that the Fukushima  
3 Subcommittee will be having a day and a half meeting,  
4 and our Subcommittee week in November on mitigating  
5 strategies.

6 CHAIRMAN CORRADINI: And thank you,  
7 because you've actually reminded me of something else.  
8 We had one question relative to NINA and how they did  
9 their seismic analysis, and the associated certainty.  
10 And there'll be a generic meeting on Monday, the 17th,  
11 in the afternoon. Morning? I can't remember.

12 MEMBER SCHULTZ: Morning, I believe.

13 CHAIRMAN CORRADINI: Morning, that will  
14 talk about the seismic uncertainty analysis, and I  
15 would encourage the folks that are of interest to attend  
16 that, so that we're all on the same page as to where  
17 we're going.

18 Because we had questions of the staff in  
19 terms of their uncertainty analysis that was much more  
20 generic, which could apply to the analysis that NINA  
21 has done. On top of the Thursday, Friday meeting you  
22 just mentioned, Steve.

23 MR. THOMAS: Right.

24 MEMBER BROWN: And the other Mondays, it's  
25 the open phase one, from one to five, B2B8-9, 8-9.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   CHAIRMAN CORRADINI: Yeah, so it's just,  
2                   it's a jammed full week of fun and stuff. Okay?  
3                   Anything else? Otherwise, we'll adjourn, and thank  
4                   you all very much.

5                   (Whereupon, the above-entitled matter  
6                   went off the record at 11:19 a.m.)

7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23


**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

# South Texas Project Units 3 & 4

## Chapter 9, Sections 9.1.1 and 9.1.2

### New Fuel and Spent Fuel Storage



# Attendees

Scott Head	Manager, Regulatory Affairs, NINA
Steve Thomas	Manager, Engineering, NINA
Bill Mookhoek	Licensing Supervisor, NINA
Jim Agles	Licensing Engineer, NINA
Jim Tomkins	Licensing Engineer, NINA
Chuck Bullard	Holtec International
Bret Brickner	Holtec International
Tao He	Holtec International

# Agenda

- Chapter 9 ACRS Status
- New Fuel Rack Departure
- Spent Fuel Rack Design and Analysis
- COL Items
- Conclusions

# Chapter 9

- Today's presentation will cover Chapter 9, Subsections 9.1.1 and 9.1.2, New and Spent Fuel Storage
- ACRS Presentation on October 20, 2010, addressed the following:
  - Subsections:
    - 9.1.3, Fuel Pool Cooling and Cleanup
    - 9.1.4, Light Load Handling System (Related to Refueling)
    - 9.1.5, Overhead Heavy Load Handling Systems
  - Section 9.2, Water Systems
  - Section 9.3, Process Auxiliaries
  - Section 9.4, HVAC
  - Section 9.5, Other Auxiliary Systems

# ABWR DCD requirement for New Fuel Storage Racks eliminated:

- Tier 1 Departure:  
STP DEP T 2.5-1:  
**Elimination of New Fuel Storage Racks from New Fuel Vault**
  - Completely eliminates new fuel storage racks and use of new fuel storage vault for fuel storage.
  - Following receipt inspection, new fuel will be stored in the spent fuel storage racks in the spent fuel pool.
  - Eliminates unnecessary fuel handling step.
  - COL Items for new fuel storage are met by the spent fuel racks.

# Spent Fuel Rack Vendor: Holtec International


## Responsible for SFR Design and Analysis

- Holtec International has been the primary vendor for SFR Design and Analysis during the last 15 years:
- SFR Projects recently completed by Holtec:
  - Palisades Plant (PWR, NRC Approval 2013)
  - US AP1000 Design Certification (PWR, NRC Approval 2012)
  - Beaver Valley Unit 2 (PWR, NRC Approval 2011)
  - Nine Mile Point Units 1 & 2 (BWR, NRC Approval 2007)
  - Cooper (BWR, NRC Approval 2007)
  - Clinton (BWR, NRC Approval 2007)

# Spent Fuel Rack Design:

- New and spent fuel stored in the stainless steel-lined concrete spent fuel pool
- Seven (7) rack modules
  - Each module is 20 x 17 cells and has space for 340 cells
  - Total storage capacity is 2,380 fuel assemblies
  - More than 270 percent of the reactor core as required by DCD
- Rack modules are freestanding
- Each storage cell includes neutron absorbing material Metamic™ (B<sub>4</sub>C)
  - Metamic™ enclosed in stainless steel sheathing, which holds a single Metamic™ panel
  - Surveillance of sample coupons for 60 year life of plant

# Spent Fuel Rack Layout:



# Spent Fuel Rack Analysis:

Holtec Report No. HI-2135462:

“Licensing Report for South Texas Project Units 3 and 4 ABWR Spent Fuel Racks,” Rev 2

HI-2135462 incorporated by Reference into STP 3 & 4 FSAR:

Satisfies COL Items for New and Spent Fuel:

- Criticality Safety Evaluation (COL Items 9.1 and 9.3)
- Thermal-Hydraulic Evaluation (COL Item 9.8)
- Structural/Seismic Evaluation (COL Items 9.2 and 9.7)
- Mechanical Accident Evaluation (COL Item 9.4)

# Conclusions

- New Fuel Storage Racks Eliminated from Design
- New fuel will be stored in Spent Fuel Racks
- Spent Fuel Racks meet all NRC requirements for new and spent fuel
- All COL Items addressed


# Chapter 9, Section 9.1: Fuel Storage Handling

## Questions and Comments



# South Texas Project Units 3 & 4

## Response to NRC Bulletin 2012-01



# Attendees

- Scott Head, Regulatory Affairs Manager, NINA
- Steve Thomas, Engineering Manager, NINA
- Bill Mookhoek, Licensing Supervisor, NINA
- Jim Tomkins, Licensing, NINA
- Evans Heacock, Electrical Engineering, NINA

# Agenda

- Background
- STP 3&4 Electrical System
- STP 3&4 Open Phase Solution
- Open Phase Detection
- Open Phase Protection
- COLA Changes
- Conclusions


# Background

- Bulletin issued July 27, 2012 as a result of event at Byron 2
- Open phase events since 2001 at South Texas 2, Beaver Valley 1, James Fitzpatrick, Nine-Mile Point 1, and a two-phase event at Forsmark
- Industry response
- STP 3&4 approach includes:
  - Detection
  - Control Room Alarm
  - Automatic response to the open phase event
  - Technical Specifications

# Byron Open Phase Event

- Offsite power supply circuits were rendered inoperable by single-phase open circuit that was undetected by surveillances
- Design of electric power system did not take into account possibility of loss of a single phase between the transmission network and the onsite power distribution system

# STP 3&4 Electrical System



# Important Aspects of STP 3&4 Design Relative to an Open Phase Condition

- Three separate offsite connections - Main Power Transformer (MPT) and two Reserve Auxiliary Transformers (RAT) for each unit
- No automatic bus transfer schemes
- Each unit has a Combustion Turbine Generator (CTG)
- Can cross-tie to other unit

# STP 3&4 Licensing Approach for Open Phase Condition

1. Detection of Open Phase (and Control Room Alarm) on the high-voltage side of MPT, RAT-A, and RAT-B
  - Inspections, Tests, Analyses and Acceptance Criteria (ITAAC) for Open Phase Detection and Alarm
2. Protection of Class 1E 4.16 kV busses with Negative Sequence Voltage Relays
  - Actuation opens bus supply breakers
  - Undervoltage (UV) relays actuate causing Emergency Diesel Generator (EDG) start and pick up of load
  - Negative Sequence Voltage Relays are added to Technical Specifications (TS)

# Open Phase Detection and Alarm


- Detection on the high-voltage side of the MPT and both RATs
- Alarm in Main Control Room
- Procedures will direct the operator response

# Open Phase Protection

- Class 1E Negative Sequence Voltage Relays provide protection for the three Class 1E 4.16 kV busses
- Designed to protect motors from overheating due to unbalanced voltage and current
- Relays monitor negative sequence voltage for each phase
  - 3 relays for each bus
  - 2 out of 3 logic

# Open Phase Protection *(continued)*

## Negative Sequence Voltage Relay



# Open Phase Protection *(continued)*

- Design Negative sequence voltage of 5.0%
  - Value at which motors can operate continuously with no adverse consequences
- Design time delay of 3.0 seconds
  - Ensures that relays do not actuate as a result of normal system transients
- Final setpoint and time delay values will be in accordance with Setpoint Control Program
  - Current nominal setpoint values are 4.5% and 2.5 seconds

# COLA Changes

- Open Phase Detection and Alarm added to FSAR Section 8.2 (Offsite Power Systems)
- Negative Sequence Voltage Relays added to FSAR Section 8.3 (Onsite Power Systems)
- Negative Sequence Voltage Relays added to TS 3.3.1.4, ESF Actuation Instrumentation
  - Same surveillances as UV and Degraded Voltage Relays
- Site-specific ITAAC for the Open Phase Detection and Alarm
- No other changes to COLA

# Conclusions

- Addition of open phase detection/alarm and Class 1E 4.16 kV protection enhance an already robust design
- ITAAC will ensure the open phase detection and alarm meet design requirements
- TS surveillances will ensure negative sequence relays remain reliable for their protective function



# **Presentation to the ACRS Subcommittee**

**South Texas Units 3 and 4 COL Application Review**

**SER Phase 4 Chapter 9  
“Auxiliary Systems”**

November 5, 2014

- **Technical Staff**

- ◆ Diego Saenz, SRSB (Presenter)
- ◆ Ata Istar, SEB2 (Presenter)
- ◆ Samir Chakrabarti, SEB2 (Lead)
- ◆ Huan Li, SEB2
- ◆ Eduardo Sastre, MCB
- ◆ Andrew Yeshnik, MCB
- ◆ Raul Hernández, SPSB
- ◆ Richard Morante (Consultant, BNL)

- **Project Management**

- ◆ Tom Tai, Lead PM
- ◆ Luis Betancourt, Chapter PM

# Background

- ACRS presentation on October 20, 2010:
  - ◆ Phase 2: All Chapter 9 except Sections 9.1.1 and 9.1.2, New and Spent Fuel Storage.
  - ◆ Confirmatory Items / Open Items.
- Today's presentation is focused on Sections 9.1.1 and 9.1.2, New and Spent Fuel Storage.

# Staff's Phase 2 Review

SRP Section		Number of Open Items or Confirmatory Items	Status
9.1	Fuel Storage and Handling	3 CI 1 OI	All Confirmed and Closed Closed
9.2	Water Systems	16 CI	All Confirmed and Closed
9.3	Process Auxiliaries	3 CI	All Confirmed and Closed
9.4	Air Conditioning, Heating, Cooling, and Ventilation Systems	1 OI	Closed
9.5	Other Auxiliary Systems	10 CI 1 OI	All Confirmed and Closed Closed
Totals		32 CI 3 OI	All Confirmed and Closed All Closed

## **Chapter 9 Sections with Significant Revisions Since Phase 2**

- Added evaluation of Sections 9.1.1 and 9.1.2.
- Most of the revisions in Chapter 9 were:
  - ◆ To document the closure of the open items.
  - ◆ To document the closure of the confirmatory items.
  - ◆ To address OGC comments.

### Tier 1 Departure

- STP DEP T 2.5-1: Elimination of New Fuel Storage Racks from New Fuel Vault.
  - ◆ This departure eliminates the new fuel storage racks from the new fuel vault, and specifies that new fuel will be stored in the spent fuel storage pool.
  - ◆ ABWR DCD requires the COL applicant to satisfy COL Information Items 9.1, 9.2, and 9.5 for the design of new fuel storage.
- Staff's Finding:
  - ◆ COL Item 9.5 is satisfied (Section 9.1.1).
  - ◆ Other COL items are addressed by SFRs (Section 9.1.2).

# **Technical Topic of Interest:**

## **Sections 9.1.1 and 9.1.2 – New and Spent Fuel Storage**

- Holtec Report No. HI-2135462, “Licensing Report for South Texas Project Units 3 and 4 ABWR Spent Fuel Racks,” provides design details of the fuel racks including criticality, thermal-hydraulic, seismic, and mechanical accident evaluations.

### COL Items

- COL Items 9.1 and 9.3 – Criticality Evaluation
- COL Items 9.2 and 9.7 – Structural/Seismic Evaluation
- COL Item 9.4 – Mechanical Accident Evaluation
- COL Item 9.5 – New Fuel Inspection Stand Seismic Capability Evaluation
- COL Item 9.8 – Thermal-Hydraulic Evaluation

# **Structural/Seismic Review: COL Information Items 9.2, 9.4, and 9.7**

## Background and Review Scope

- Holtec Report No. HI-2135462, “Licensing Report for South Texas Project Units 3 and 4 ABWR Spent Fuel Racks,” provides structural design information for spent fuel racks including seismic/structural analysis (COL Items 9.2 and 9.7) and mechanical accident evaluation (COL Item 9.4).

## Staff review focused on:

- Seismic/Structural analysis and design of racks including methodology and assumptions used.
- Evaluation of racks for mechanical accidents.

# **Structural/Seismic Review: COL Information Items 9.2, 9.4, and 9.7**

## Applicable Regulations/Guidance

- 10 CFR Part 50, Appendix A, GDC 2, “Design bases for protection against natural phenomena.”
- NUREG-0800 (SRP 3.8.4, Appendix D, “Guidance on Spent Fuel Pool Racks”).

# **Structural/Seismic Review:** **COL Information Items 9.2, 9.4, and 9.7**

## Highlights of Staff Review

- The staff reviewed Sections 1, 2, 3, 6, and 7 of the Holtec report providing details of structural analysis/design and mechanical accident evaluation of the racks.
- Staff issued 34 RAIs.
- Interaction with the applicant included 3 on-site audits and weekly public conference calls over a six-month period.
- Staff identified several issues pertaining to analysis and design, which were subsequently resolved.

# **Structural/Seismic Review: COL Information Items 9.2, 9.4, and 9.7**

## Major Structural Review Issues:

- Modeling of Fuel Assembly
- Rack-to-Rack Impact Load Estimation
- Calculation of Shear Stress Factors for the Rack
- Buckling Evaluation of fuel rack structure
- Sizing of Bearing Pads to Accommodate Rack Loads and Displacements
- Analysis Methodology for Mechanical Accidents
- Postulation of Drop Scenarios

# **Structural/Seismic Review: COL Information Items 9.2, 9.4, and 9.7**

## Summary

- Staff reviewed structural analysis and design of STP spent fuel storage racks, and concludes that information provided by the applicant is adequate and acceptable for determination of structural adequacy of fuel storage racks in accordance with NRC regulations and guidance in SRP 3.8.4, Appendix D, of NUREG-0800.

# **Criticality Review:**

## **COL Information Items 9.1 and 9.3**

### Requirements for Criticality

- 50.68(b)(4) regulatory requirement of  $K_{\text{eff}} \leq 0.95$  at 95/95.
- TS 4.3.1.1 requirement of  $K_{\infty} \leq 1.35$  in SCCG
- Administrative requirements:
  - ♦ Fresh fuel without Gd has an upper limit of 2.95% on U-235 enrichment.
  - ♦ Fresh fuel with Gd has a U-235 enrichment limit of 5.0% and a lattice design limit on the number of Gd rods, the Gd rod locations, and the Gd rod loading.

# **Criticality Review:**

## **COL Information Items 9.1 and 9.3**

### Overview of Design

- No New Fuel Racks, only SFRs.
- Seven 17 x 20 storage racks.
- New and spent fuel can be stored in any SFR location.
- Fuel lattice requirements are such that even fuel with Gd is most reactive fresh.
- Metamic<sup>®</sup> is used as fixed neutron absorber material.

# **Criticality Review:**

## **COL Information Items 9.1 and 9.3**

### Summary

- The staff find that the STP SFR design protects against criticality with the use of geometrically safe configurations given:
  - ♦ Appropriate analysis methodology was used.
  - ♦ Appropriate abnormal conditions were analyzed.
  - ♦ Margin exists between the regulatory limit and the maximum calculated  $K_{\text{eff}}$ .

# Conclusions

- No open technical issues in Chapter 9 review.
- Tier 1 Departure – STP DEP T 2.5-1:
  - COL Items addressed by SFRs (Subsection 9.1.2).
  - Meets all applicable regulations.
- Revision 11 of the FSAR received on 10/21/2014.
- One confirmatory item to finalize the staff's review of SFRs:
  - ♦ FSAR updates on subsections 9.1.2.1.4 and 9.1.6.8.

# Acronyms

- ACRS – Advisory Committee on Reactor Safeguards
- COL – Combined License
- CI – Confirmatory Item
- CFR – Code of Federal Regulations
- COLA – Combined License Application
- DCD – Design Control Document
- DEP – Departure
- FSAR – Final Safety Analysis Report
- Gd – Gadolinium
- GDC – General Design Criteria
- HVAC – Heating, Ventilation, Air Condition
- MCB – Materials and Chemical Branch
- NRC – United States Nuclear Regulatory Commission
- OGC – Office of General Counsel
- OI – Open Item
- PM – Project Manager
- RAI – Request for Additional Information
- SEB2 – Structural Engineering Branch 2
- SER – Safety Evaluation Report
- SFR – Spent Fuel Racks
- SRSB – Reactor Systems, Nuclear Performance & Code Review Branch
- SRP – Standard Review Plan
- SPSB – Plant Systems Branch
- STP – South Texas Project
- TS – Technical Specifications

# **Backup Slides**

# Fuel Assembly Lattices




Figure 4.5.1  
 Fuel Assembly Lattices  
 (a) Lattice 0; (b) Lattice 4a (4.0 wt%  $Gd_2O_3$ ); (c) Lattice 4n (8.0 wt%  $Gd_2O_3$ );  
 (d) Lattice 4o (7.75 wt%  $Gd_2O_3$ )



United States Nuclear Regulatory Commission

*Protecting People and the Environment*

# **Presentation to the ACRS Subcommittee**

**South Texas Project, Units 3 and 4**

**Section 8.2S and amended Chapter 16**

**NRC Bulletin 2012-01: Design Vulnerability in Electric  
Power System**

November 5, 2014

# Staff Review Team

- **Technical Staff**
  - Sheila Ray, NRR/DE/EEEEB
  - Tania Martinez-Navedo, NRR/DE/EEEEB
  - Craig Harbuck, NRO/DSRA/SPSB
  - Hien Le, NRO/DSRA/SPSB
  - Odunayo Ayegbusi, NRO/DSRA/SPRA
  - Marie Pohida, NRO/DSRA/SPRA
  - Wendell Morton, NRO/DE/ICE2
  - Joseph Ashcraft, NRO/DE/ICE2
  
- **Project Management**
  - Luis Betancourt, Chapter PM, NRO/DNRL/LB2
  - Tom Tai, Lead PM, NRO/DNRL/LB2

# **Byron Open Phase Event**

- Occurred January 30, 2012, at Byron Unit 2.
- Not immediately detected.
- Both offsite and onsite electrical power systems were not able to perform their intended safety function.
- Manual actions were necessary to restore ESF safety functions.
- Presented a potential common cause failure event.
- Therefore, needed to be addressed across the entire reactor fleet.

# **NRC Staff Actions**

- Special Inspection at Byron [ML12087A213]
- Information Notice 2012-03 [ML120480170]
- Bulletin 2012-01 [ML12074A115]
- Summary Report including recommended actions [ML13052A711]
- NEI provided NSIAC approved industry initiative to address open phase conditions (Oct 2013) [ML13333A147]
- Staff issued RAI 08.02-25 and 08.02-26 to STP COL applicant

# **Staff Position for Active Plants**

- Automatic detection of single/double loss of phase events with/without a high impedance fault across all operating modes of the plant.
- Alarm in the control room.
- Automatic mitigation/response to the open phase event.
- Training of plant personnel (operations, maintenance) and provide procedures.

# **STP 3 & 4 – Design Solution**

- **Staff Position:**
  - Automatic detection of single/double loss of phase events with/without a high impedance fault across all operating modes of the plant.
  - Alarm in the control room.
- **STP Units 3 and 4:**
  - Automatic detection of open phase and ground faults on high-voltage side of MPT, RAT-A, RAT-B (all three phases of each transformer).
  - Alarm in Control Room.

# Staff Evaluation

- Detection to be located on the high voltage side of the transformer(s) that feed offsite power into the plant's electrical distribution system.
  - Given the challenges of identifying and taking sufficient measures of an open phase condition, the staff's position is that detection must occur on the high voltage side of the credited offsite power circuit (i.e. at the source).
- The STP Units 3 and 4, detection and alarm scheme provides indication of the open phase condition under all loading and operating configurations.
- The staff finds this acceptable.

# **STP 3 & 4 – Design Solution**

- **Staff Position:**
  - Automatic mitigation/response to the open phase event.
  - Protective devices should automatically initiate the disconnection of the offsite power sources whenever the setpoints and time delay limits have been exceeded.
- **STP Units 3 and 4:**
  - Protection of Class 1E 4.16 kV busses with negative sequence voltage relays.
    - Actuation open supply breakers, UV relays actuate to start EDG and pick up load.

# Staff Evaluation

- The staff finds the mitigation scheme acceptable since the negative sequence relay setpoints can identify open phase circuit conditions and actuate to protect the loads on the Class 1E buses, as shown in simulations and analyses.

# **STP 3 & 4 – Design Solution**

- **Staff Position:**
  - Training of plant personnel (operations, maintenance) and provide procedures.
- **STP Units 3 and 4:**
  - Training, as well as, maintenance and testing procedures associated with the monitoring system will be developed in accordance with FSAR Subsections 13.2 and 13.5.

# Staff Evaluation

- Training will be developed for the operation and maintenance of the monitoring system to detect an offsite power system open phase circuit condition.
- Furthermore, maintenance and testing procedures will be developed and include calibration and troubleshooting procedures to ensure the monitoring system functions as expected.
- The staff finds this acceptable.

# Confirmatory Items

- FSAR updates on:
  - Section 8.2.1.24: Open phase detection and alarm,
  - Section 8.3.1, 8.3.1.1.6.3, and 8.3.1.1.7: Negative sequence relays
  - Section 16.4.6.4: TS SRs
- TS SRs (PTS 3.3.1.4) on negative sequence relays
- Site specific ITAAC in Table 3.0-29, Part 9, Section 3.0 to verify detection and alarm components are installed as designed

# Summary

- NRC staff has required the new reactor design plants to address the vulnerability identified in Bulletin 2012-01.
- STP Units 3 and 4, has provided information on a scheme to detect, alarm, and automatically respond to a single-phase open circuit condition on credited offsite power circuits.
- NRC staff finds this issue acceptably resolved.

# Questions

# Acronyms


- COL – Combined Operating License
- EDG – Emergency Diesel Generator
- ESF – Engineered Safety Feature
- FSAR – Final Safety Analysis Report
- ITAAC – Inspections, Tests, Analyses, and Acceptance Criteria
- kV – kilovolt
- MPT – Main Power Transformer
- NEI – Nuclear Energy Institute
- NSIAC – Nuclear Strategic Issues Advisory Committee
- PTS – Plant-Specific Technical Specifications
- RAI – Request for Additional Information
- RAT – Reserve Auxiliary Transformer
- SR – Surveillance Requirement
- STP – South Texas Project
- TS – Technical Specifications
- UV - undervoltage

# **Back-up Slides**

# **Staff Position for Passive Plants**

- Detection of single/double loss of phase events with/without a high impedance fault across all operating modes of the plant
- Alarm in the control room
- Training of plant personnel (operations, maintenance) and provide procedures

# South Texas Project Units 3 & 4 ABWR Suppression Pool Water Level Assumption Issue



# Licensing Background

- On 3/31/2014, GEH identified a potential Part 21 associated with an assumption used to calculate ABWR hydrodynamic loads
- Suppression Pool (S/P) level used for development of hydrodynamic loads
  - Technical Specifications (TS) High S/P Level
  - S/P TS high level could be exceeded for Feedwater Line Break Large Break LOCA
- Access tunnel is internal structure most likely to be impacted
- Final GEH report concluded no substantial safety hazard, no impact on the TS, and not reportable

# Technical Background

- During a LOCA, the S/P is subjected to the following hydrodynamic loads in addition to other loads:
  - Pool Swell
  - Condensation Oscillation
  - Chugging
- These hydrodynamic loads can impact the S/P walls and submerged structures in the S/P
- Higher S/P level increases the extent of hydrodynamic pressure loads on the S/P walls and submerged structures

# NINA Actions

- After GEH initial report, Toshiba evaluated the impact of this assumption for STP 3&4
- Toshiba performed a conservative analysis that concluded:
  - S/P level increase is about 1 meter above TS high value for the FWLB LOCA
  - For the most limiting load combination, no significant effect on the containment structure (<1%)

# NINA Actions *(continued)*

- Access Tunnel
  - Not analyzed in the DCD
  - Will be designed later as part of detailed design
  - Evaluation of Japanese ABWR access tunnels determined load increase is small (<1%)

# NINA Actions *(continued)*

- NINA submitted a letter to NRC in early September concluding this is not a significant safety issue
- NRC audited the Toshiba evaluation in September
- A site-specific ITAAC was developed to ensure that the as-built design of the S/P submerged structures and S/P walls consider the effects of suppression pool water level increase

# Conclusions

- NINA determined this is not a significant safety issue
- NINA results are consistent with GEH evaluation



United States Nuclear Regulatory Commission

---

*Protecting People and the Environment*

# **Presentation to the ACRS Subcommittee**

**South Texas Project Units 3 and 4  
Hydrodynamic Loads  
Interim Part 21 Evaluation**

November 5, 2014



# Staff Review Team

- Technical Staff
  - Harry Wagage (NRO/SRSB/SCVB)
  - Samir Chakrabarti (NRO/DE/SEB2)
  - Huan Li (NRO/DE/SEB2)
  
- Project Manager
  - Tom Tai (NRO/DNRL/LB2)

# Background

- **GEH's Interim Part 21 Evaluation**
  - On March 31, 2014, GEH submitted a 60-Day interim report notification on an analysis in the ABWR design
    - A potential increase in hydrodynamic loads on containment structures during a postulated LOCA
      - ABWR hydrodynamic load analysis used SP HWL in TS as initial condition
      - Should consider suppression pool level with RPV depressurization during a postulated LOCA
  - On August 29, 2014, GEH submitted final evaluation results concluding there is no significant safety hazard and no exceedance on TS Safety Limit, thus not reportable
  - On September 15, 2014, NINA submitted STP's evaluation with the same conclusion as GEH's

# Stakeholders

- GEH – Original ABWR Design Certification applicant. Revision 4 of the ABWR Design Control Document (DCD) was certified by the NRC in 1997.
- NINA – STP Units 3 and 4 COL applicant.
- Toshiba – Part of the EPC consortium supporting the design and construction of STP Units 3 and 4.
- NRC – Currently reviewing the STP Units 3 and 4 COL application.

# Staff Review

- Engaged weekly telephone conference for update and assessed potential impact on completed review and ongoing review
- Held public meeting on September 9, 2014, to discuss preliminary assessment by NINA/Toshiba on this issue
- Audited NINA/Toshiba's evaluation on September 19, 2014
- Several audit observations on clarity and quality but no audit finding
- Agreed to a site-specific ITAAC (in parallel to DCD ITAAC in Table 2.14.1, Item 14) to ensure the proper SP water level is used in detailed analysis

# Conclusions

- NINA/Toshiba finds the non-conservative initial condition in the ABWR analysis does not result in a significant safety issue and is not reportable under Part 21 and the staff agrees
- Appropriate input data will be used to predict the STP hydrodynamic loads even though there was no safety impact
- Proposed site-specific ITAAC will ensure that the containment walls and submerged structures can withstand the design basis loads considering the effects of a higher SP water level on the hydrodynamic loads during a postulated LBLOCA
- The appropriate section(s) in the STP safety evaluation report will be revised to document the addition of this site-specific ITAAC
- GEH and Toshiba renewal projects will take necessary actions to address this issue