

Official Transcript of Proceedings
NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards
 ABWR Subcommittee

Docket Number: (n/a)

Location: Rockville, Maryland

Date: Wednesday, December 3, 2014

Work Order No.: NRC-1262

Pages 1-270

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1323 Rhode Island Avenue, N.W.
Washington, D.C. 20005
(202) 234-4433

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION
+ + + + +
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS
(ACRS)
+ + + + +
ABWR SUBCOMMITTEE
+ + + + +
WEDNESDAY
DECEMBER 3, 2014
+ + + + +
ROCKVILLE, MARYLAND
+ + + + +

The Subcommittee met at the Nuclear Regulatory Commission, Two White Flint North, Room T2B1, 11545 Rockville Pike, at 1:30 p.m., Michael L. Corradini, Chairman, presiding.

COMMITTEE MEMBERS:

MICHAEL L. CORRADINI, Subcommittee Chairman
RONALD G. BALLINGER, Member
DENNIS C. BLEY, Member
CHARLES H. BROWN, JR. Member
DANA A. POWERS, Member

1 HAROLD B. RAY, Member
2 JOY L. REMPE, Member
3 PETER C. RICCARDELLA, Member
4 MICHAEL T. RYAN, Member
5 JOHN W. STETKAR, Member

6

7 DESIGNATED FEDERAL OFFICIAL:

8 MAITRI BANERJEE

9 QUYNH NGUYEN

10

11 ALSO PRESENT:

12 DENNIS ANDRUKAT, NRO

13 LUIS BETANCOURT, NRO

14 ERIC BOWMAN, NRR

15 ROCKY FOSTER, NRO

16 JAMES M. GILMER, NRO

17 EVANS HEACOCK, NINA

18 SCOTT HEAD, NINA

19 TIM HIRST, Hirst Engineering

20 CHANG LI, NRO

21 SAMUEL LEE, NRO

22 TANIA MARTINEZ-NAVEDO, NRR

23 BILL MOOKHOEK, NINA

24 THOMAS SCARBROUGH, NRO

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

DINESH TANEJA, NRO
STEVE THOMAS, NINA
JIM TOMKINS, NINA
HANRY WAGAGE, NRO

1	T A B L E O F C O N T E N T S	
2	Opening Remarks - Michael Corradini, ACRS	5
3	NRO/NINA Introductions - NINA	7
4	NINA Presentation COLA FSAR 1E 2.4, Mitigating	
5	Strategies for Beyond Design-Basis	
6	Events	10
7	Break	103
8	Staff Presentation ASER Section 22.2, Mitigation	
9	Strategies	103
10	ACRS Action Item #64, Fire-Induced Spurious Signals	
11	from DI&C Cabinet with Fiberoptic Cables ...	152
12	Miscellaneous Outstanding Issues - NRO	176
13	Subcommittee Discussion and Closing Remarks -	
14	Michael Corradini, ACRS	202
15	Meeting Adjourned	206
16		
17		
18		
19		
20		
21		
22		
23		
24		
25		

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

P R O C E E D I N G S

1:30 p.m.

CHAIRMAN CORRADINI: Okay. Why don't we begin. This meeting will come to order. This is a meeting of the Advance Boiling Water Reactor, ABWR, Subcommittee for the ACRS. My name is Mike Corradini. I am chair of the Subcommittee.

ACRS members currently in attendance are Pete Riccardella, Harold Ray, Dana Powers, Dennis Bley, John Stetkar, Mike Ryan, Charlie Brown, Joy Rempe and Ryan Ballinger. We also have Mr. Quynn Nguyen as our designated federal official for the meeting.

As announced in the Federal Register on November 26, 2014, the subject of today's briefing is the COL application submitted by Nuclear Innovation of North America, or NINA, for the South Texas Project, Units 3 and 4 and the staff's final Safety Evaluation Report related to the requirements resulting from the Fukushima Near Term Task Force Recommendation 4.2, Mitigating Strategies.

The briefing will also include the NRO staff responding to a question from the Committee members regarding the possibility of spurious signals from digital I&C cabinets with fiberoptic cables under heat from a nearby fire.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

1 The rules for participation in today's
2 meeting were announced in the Federal Register Notice
3 on November 26th that stated that portions of the
4 meeting could be closed to the public to discuss
5 proprietary information.

6 However, since then the staff has informed
7 us that the entire meeting could be open to the public
8 I should say would be open to the public.

9 We have a telephone bridge line for the
10 public and stakeholders to hear the deliberations. To
11 minimize disturbances, the line will be kept in the
12 listen-only mode until the end of the meeting when we
13 will provide 10 minutes for public comment.

14 At that time, any member of the public
15 attending the meeting in person or through the bridge
16 line can make a statement or provide comments as
17 desired.

18 We'll check on that as we get closer to the
19 end of the meeting to see if there are any members of
20 the public on the line.

21 As the meeting is transcribed, I request
22 that the participants in this meeting use the
23 microphones located throughout the room when
24 addressing the Subcommittee.

25 Participants should first identify

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 themselves and speak with sufficient clarity and volume
2 so that they can be readily heard.

3 And then, please silence all cell phones,
4 pagers, iPhones, iPads, Kindles, Fires and all
5 appropriate appliances, washers and dryers.

6 We will now proceed with the meeting.
7 I'll call upon Rocky Foster. Is Rocky --, there you
8 are. Sorry, Rocky. I didn't see you hiding over
9 there.

10 NRO can begin their presentation.

11 MR. LEE: I'll pinch hit for Rocky. My name
12 is Sam Lee. I'm the Chief of Licensing, Branch 2 in
13 Office of New Reactors.

14 I just wanted to take the opportunity to
15 appreciate the Committee for this time and opportunity
16 to brief you on mitigating strategies.

17 I just wanted to make a note here that this
18 is the last of the scheduled ACRS briefings for our
19 South Texas Project COLA 3 and 4. So, we look forward
20 to this opportunity and I'll turn it over to the
21 applicant.

22 MEMBER POWERS: There is a very optimistic
23 individual over there.

24 (Laughter.)

25 MR. LEE: I did say last of the scheduled

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 meetings.

2 MEMBER POWERS: Oh, I see.

3 CHAIRMAN CORRADINI: So, I should have
4 interjected earlier with one comment that given the
5 fact this is the last planned subcommittee meeting,
6 we'll in the wrap-up here probably not only discuss our
7 comments relative to the subjects of today, but also
8 make sure we're on track for a potential committee
9 letter in February.

10 Scott, I think you're going to start us
11 off.

12 MR. HEAD: Yes, sir. Just I would like to
13 add one thing to your discussion. You said the staff
14 is going to brief you on the Open Item 64.

15 I think we would like an opportunity to
16 offer a briefing on that topic.

17 CHAIRMAN CORRADINI: Oh, yes. I'm sorry.
18 That is my mistake. You're on the schedule as well as
19 the staff. Go ahead.

20 MR. HEAD: All right. And I also
21 appreciate the opportunity to brief the ACRS today on
22 Recommendation 4.2.

23 Attendees today, myself and obviously
24 Steve Thomas, the engineering managers, briefed you on
25 a number of topics before.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Bill Mookhoek, our licensing supervisor,
2 has been here at our meetings before. He will be --
3 his main focus today will be FLEX.

4 And as a former shift supervisor at Units
5 1 and 2, the operational aspect of all that, I think
6 it will be a worthwhile discussion today that we have
7 regarding that.

8 Jim Tomkins, Dick Scheide and Evans
9 Heacock, Evans has briefed you on a number of topics
10 with respect to electrical aspects of the design and
11 obviously is available to discuss that with respect to
12 this topics, too.

13 So, our agenda, I'm going to just slide
14 back around on the regulatory framework. And then
15 Steve is going to go into the, you know, basically the
16 DCD features that mitigate a station blackout, the ones
17 that -- the features that were there that came with the
18 certified design.

19 And he'll also go into the enhancements to
20 address the NRC Fukushima recommendations that we've
21 committed to in the COLA.

22 And then Bill, as I alluded to, will go
23 through the FLEX plan, sequence of events and how we're
24 addressing the FLEX requirements. Short discussion on
25 supporting analysis, the summary and conclusions. So,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that's the agenda for the day.

2 Just as background, actions have been
3 identified in response to the Fukushima event. We have
4 embarked on doing that.

5 Four actions apply to new reactors. We
6 briefed the ACRS on the -- on 2.1, 7.1 and 9.3 early
7 in the year.

8 All these actions are laid out in our
9 Appendix 1E in the COLA to describe, you know, how we're
10 reacting to all of those, which references a FLEX plan.
11 And today we're going to be covering 4.2.

12 If no questions for me with that
13 background, I'm going to turn it over to Steve Thomas.

14 MR. THOMAS: Okay. Thanks, Scott.

15 As Scott mentioned, before Fukushima and
16 before FLEX, station blackout was a major design
17 consideration in the development of the certified
18 design for the ABWR.

19 ABWR incorporates major installed
20 capability for station blackout mitigation. Those
21 components are highlighted here.

22 We have a combustion turbine generator --

23 MEMBER STETKAR: Let me -- I was going to
24 ask Scott, but I might as well get this off my chest
25 early.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. THOMAS: Okay.

2 MEMBER STETKAR: All of the Fukushima
3 mitigation strategies are ostensibly designed to
4 address beyond design-basis external events.

5 For South Texas, is a 0.2 g peak ground
6 acceleration beyond design-basis earthquake, or a 0.4
7 g earthquake beyond design-basis?

8 Because you guys have two design bases.
9 You've got the certified DCD design-basis peak ground
10 acceleration of 0.3 g, and then you have your so-called
11 site-specific design-basis of 0.13 g.

12 And I know what equipment is qualified to
13 each. So, depending on how I ask questions over the
14 next three-and-a-half hours, I need to understand what
15 for you is a beyond design-basis earthquake.

16 MR. THOMAS: Want me to answer that?

17 MEMBER STETKAR: Yes.

18 (Laughter.)

19 MEMBER STETKAR: Somebody answer that.

20 MR. THOMAS: I think most of the equipment
21 we're going to be talking about is going to be protected
22 against the site-specific conditions, which would be
23 the .13 g earthquake.

24 There are exceptions on here. Mainly, the
25 reactor core isolation cooling system and any of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 components in the Reactor Building are going to be
2 qualified to the 0.3 g, but the non-safety-related
3 equipment that we're going to be crediting in the FLEX
4 plan will be qualified to the site-specific earthquake.

5 MEMBER STETKAR: Your diesel generators are
6 qualified to 0.3 g, right?

7 MR. THOMAS: Yes, sir.

8 MEMBER STETKAR: Okay. So, we're talking
9 about an earthquake that leaves essentially all of the
10 certified design equipment intact because it's
11 qualified for well above your site-specific, and, yet,
12 leaves you with a station blackout where you require
13 the stuff that's qualified for 0.13 g.

14 MR. THOMAS: That would be the presumption.

15 MEMBER STETKAR: Okay. Thank you.

16 CHAIRMAN CORRADINI: Besides the fact that
17 it sounds inconsistent.

18 MEMBER STETKAR: Yes, but I just wanted to
19 get it on the record that it doesn't --

20 CHAIRMAN CORRADINI: Are you going to come
21 back to this? Because I have questions, too.

22 MEMBER STETKAR: Well, no, because
23 depending on which -- I got the answer that I want,
24 because depending on which questions I ask --

25 MR. HEAD: That answer works. I mean,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that's an appropriate, I mean, we've had two design
2 bases, you know, depending on the different structures
3 or features, and that's the way the plan --

4 MEMBER STETKAR: To me, quite honestly, it
5 doesn't make any sense, but that's okay.

6 (Laughter.)

7 MR. HEAD: When you're making a decision in
8 South Texas for a 0.3 g earthquake, there is some
9 benefit to a --

10 MEMBER STETKAR: I'm sorry. For a 0.3 g
11 earthquake, there's a fairly high likelihood that all
12 of your stuff that's qualified for 0.13 g doesn't
13 survive.

14 MR. HEAD: I understand.

15 MEMBER STETKAR: About a 40 percent chance
16 that it doesn't survive.

17 MR. HEAD: But when you're making those
18 original decisions, a 0.13 g earthquake is still very
19 conservative, as we've demonstrated in our previous
20 discussions.

21 MEMBER STETKAR: It's not my question.
22 This is for beyond design-basis earthquakes. I don't
23 think I'll comment on that any further.

24 MR. HEAD: Okay.

25 MEMBER POWERS: Well, I'll comment a little

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 bit. I mean, it's also true that at a 0.6 g there's
2 very low likelihood that the 0.3 g stuff --

3 MEMBER STETKAR: That's --

4 MEMBER POWERS: -- will survive.

5 MEMBER STETKAR: -- absolutely true,
6 Dana, which is -- but I'm trying to get calibrated where
7 the lower bound of what I'm thinking about is.

8 MEMBER POWERS: Well, it seems to me I would
9 think about the more probable lower bound. What kind
10 of earthquake are you likely to have?

11 MEMBER STETKAR: I've got the exceedance
12 frequencies and I know what those are also.

13 MR. THOMAS: Thank you, Member Powers.
14 That was my comment as well.

15 (Laughter.)

16 MEMBER POWERS: You can pay me right after
17 the meeting.

18 MR. THOMAS: Okay.

19 CHAIRMAN CORRADINI: We'll go on, because
20 I had similar questions about the different levels.
21 But go ahead. I'm sorry.

22 MR. THOMAS: So, the ABWR in its inception
23 for the certified design did consider station blackout
24 as a major design consideration. And there was
25 specific equipment designed for and installed in the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 plant to mitigate station blackout.

2 Those are listed here on the slide. I'll
3 read them quickly. There's the combustion turbine
4 generator.

5 We're going to mention the combustion
6 turbine generator a couple times in this presentation.
7 I guess I want to make it clear from the outset that
8 we are not taking credit for the combustion turbine
9 generator in our mitigating strategy plan.

10 It will be there. It's a significant
11 piece of equipment for the site, significant piece of
12 risk equipment at the site, but we are not taking credit
13 for it in our FLEX strategy.

14 CHAIRMAN CORRADINI: You're not, okay.
15 So, now we're into the questions I didn't understand
16 from NEI.

17 You're not, or by staff guidance you can't?

18 MR. THOMAS: The NEI guidance at this point,
19 requires you to assume that all installed AC power is
20 unavailable --

21 CHAIRMAN CORRADINI: Okay.

22 MR. THOMAS: -- in the FLEX scenario.

23 CHAIRMAN CORRADINI: Okay. So, it's more
24 a matter of -- okay. Then you can't.

25 MR. THOMAS: Under that guidance, that's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 true.

2 CHAIRMAN CORRADINI: Under the postulated
3 scenario.

4 MR. THOMAS: Maybe if we put wheels on it,
5 we could take credit for it. But since it's installed,
6 under those guidelines we cannot.

7 CHAIRMAN CORRADINI: Got it.

8 MR. THOMAS: And do not.

9 CHAIRMAN CORRADINI: Okay.

10 MR. THOMAS: The AC-independent water
11 addition system, again, part of the original certified
12 design.

13 This is essentially the diesel-powered
14 fire pump and portions of the fire protection system
15 to provide an alternate injection capability.

16 Reactor core isolation cooling, standard
17 piece of equipment for the boiling water reactor. Give
18 significant credit for this.

19 We have a somewhat unique reactor core
20 isolation cooling turbine pump which I'll talk about
21 a little bit later in the presentation.

22 Containment overpressurization system,
23 COPS, part of the atmospheric control system,
24 protection for the containment is basically the passive
25 hardened vent system that you may have heard in some

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 other discussions.

2 And we have substantial battery capacity.
3 Four divisions of Class 1E batteries in the ABWR that
4 we use in the FLEX strategy.

5 These provide us with substantial
6 capability. I will point out, however, that these
7 components were installed in the design, incorporated
8 into the design before the Fukushima event, before NEI
9 12-06, but the NEI guidance created additional
10 requirements in order to take credit for installed
11 equipment in the plant.

12 And, therefore, we have made some
13 enhancements to these components, which I'll discuss
14 on the next several slides.

15 Again, I'm mentioning the combustion
16 turbine generators that we don't take credit for.
17 These were previously in the certified design flood
18 protected components for the site flood.

19 We have in our application, committed to
20 qualify these for the design-basis hurricane and
21 tornado missiles that they might be subjected to. So,
22 we're additionally providing additional qualification
23 criteria for these components to protect them from
24 external events.

25 The ACIWA system was seismically qualified

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 in the certified design. And likewise, we are taking
2 additional measures to flood protect these things and
3 protect them from missiles and other severe weather
4 external events.

5 MEMBER STETKAR: Steve, I couldn't find it
6 easily. Good acronym, ACIWA. Is ACIWA qualified to
7 0.13 g, or 0.3 g, because it's not safety related.

8 MR. THOMAS: It is not. It will be
9 qualified to the site-specific earthquake.

10 MEMBER STETKAR: 0.13 g, okay.

11 MR. THOMAS: Yes.

12 MEMBER STETKAR: Thanks.

13 MR. THOMAS: The ACIWA includes fire water
14 storage tanks. Those will also be qualified for
15 site-specific floods, missiles and external hazard
16 events.

17 In the original design, only one of those
18 tanks was protected, was seismically qualified. In
19 our FLEX strategy, we are qualifying and protecting
20 both of the fire water storage tanks for the system.

21 ACIWA will also be able to take suction
22 from the ultimate heat sink, which is a very large
23 inventory of available water, through the use of some
24 connections that we are adding for that purpose.

25 CHAIRMAN CORRADINI: But just to clarify,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 it can be taking credit based on the rules of the game
2 with B

3 MR. THOMAS: The inventory can be taking
4 credit. If the inventory is protected, then you can
5 take credit for that inventory water.

6 You cannot take credit for any of the
7 active components, pumps, fans and things like that.

8 CHAIRMAN CORRADINI: Okay.

9 MEMBER STETKAR: It's also, though, the
10 building and things are only protected to 0.13 g.

11 MR. THOMAS: Right.

12 MEMBER STETKAR: That is correct.

13 CHAIRMAN CORRADINI: Keep on going.

14 MR. THOMAS: We have made some additional
15 enhancements to the spent fuel pool cooling system.
16 Primarily in the original design, RHR Train Charlie,
17 Train C, was a little bit -- did not have the same
18 capabilities as A and B in terms of providing makeup
19 to the spent fuel pool. So, we have made all three of
20 those trains the same.

21 ACIWA ties into RHR Train C. And so,
22 therefore, we can provide spent fuel pool makeup and
23 other functions with RHR Train C the same as A and B.

24 MEMBER STETKAR: Steve, can you actually
25 physically -- I got lost and I know the flow capacity

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 of the pump.

2 Can you physically connect it to both units
3 simultaneously?

4 MR. THOMAS: Yes.

5 MEMBER STETKAR: You can, okay. Thank you.

6 MR. THOMAS: There is substantial onsite
7 storage of diesel fuel and water supplies. We have
8 combined at both units about 1.7 million gallons of
9 diesel fuel. The issue would be getting it in the right
10 place, and we'll discuss that a little bit later.

11 Likewise, in counting the substantial
12 volume in both of the alternate heat sink basins, we
13 have about 35 million gallons of water available.
14 Again, we need to get that to the right place, which
15 we will discuss in a little bit more detail later.

16 The condensate storage tank is a major
17 supply of water for the reactor core isolation cooling
18 system. In the original design, the condensate
19 storage tank was non-safety-related, not qualified.

20 We have committed to protect that
21 structure for flood and external events such as tornado
22 and hurricane missiles.

23 We're providing battery connections
24 between the different battery banks, primarily between
25 Battery Bank 2 and 3, which would give us the capability

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 of accessing the battery -- stored battery power in all
2 four trains of the Class 1E batteries.

3 We'll see later on that we really only need
4 one of those trains to accomplish our coping strategy.
5 So, we have substantial margin, which we'll talk about
6 a little bit later. We have added a plant radiation
7 monitor powered by 1E power to the plant stack.

8 Okay. We're adding permanent connections
9 to allow offsite diesel generators to be connected in
10 Phase III. This is a little bit confusing. I want to
11 make sure that you didn't read this three phase.

12 The generators are three phased, but they
13 will be utilized in Phase III --

14 MEMBER STETKAR: Do you know how many
15 single-phase 480 volt stuff that you --

16 (Laughter.)

17 MR. THOMAS: I just want to make sure it is
18 we're talking about utilizing these in Phase III of the
19 mitigation strategy.

20 Internal radio communications are going to
21 be powered by non-Class 1E batteries during the first
22 36 hours of the event.

23 We have other communications capabilities
24 that we'll talk about if for some reason those are not
25 available, but they are located in a Seismic Category

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 structure and will be seismically mounted.

2 MEMBER STETKAR: Steve, while I've got you
3 on this slide, why did you decide to only bring in 480
4 volt diesels and not 4 kV diesels?

5 Because with 4 kV diesels, I can get a whole
6 lot of pumps that my operators are more used to using
7 like residual heat removal available. With 480 volt,
8 I can repower battery chargers and keep my single train
9 of mitigation going.

10 So, I was curious why not -- as long as
11 you're air lifting stuff in, why not air lift big
12 diesels in that you have a lot more flexibility with.

13 MR. THOMAS: Because primarily the
14 strategy, as you mentioned, is to recharge the
15 batteries.

16 MEMBER STETKAR: Yes, but that's recharging
17 the batteries presuming, according to the NEI rules,
18 presuming that your one and only one set of equipment
19 can never fail and runs infinitely.

20 With a big-guy diesel, I can power a whole
21 bunch of things that give me many more options as an
22 operator. And as long as I'm flying them in there, why
23 not fly in a big diesel and hook it up?

24 MR. THOMAS: Couple of reasons. First of
25 all, I think that when you look at the time durations

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 of our coping strategy at the point where this equipment
2 is going to be connected, we're going to be in a
3 situation where the plant is in a relatively stable
4 condition and could operate under those conditions
5 indefinitely.

6 MEMBER STETKAR: If everything works.

7 MR. THOMAS: If everything works.

8 MR. MOOKHOEK: May I?

9 MEMBER STETKAR: Yes. Go ahead.

10 MR. MOOKHOEK: Bill Mookhoek. I'm the
11 licensing supervisor. I had a large part in writing
12 the FLEX plan.

13 Really, the reason we went with the 480
14 volt diesels is they would be easier to transport.
15 They get the load centers, the 480 volt load centers
16 on a Class 1E system, two of those energized. And it
17 would allow us to energize not only the battery
18 chargers, but also a ventilation system and other MCCs,
19 et cetera, that we may want to.

20 Now, we may --

21 MEMBER STETKAR: And just for the record,
22 you can also do that if I repower the 4 kV buses.

23 MR. MOOKHOEK: Correct.

24 MEMBER STETKAR: Okay.

25 MR. MOOKHOEK: Playing the 4160 is a little

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 bit different than playing with 480 volt, but --

2 (Laughter.)

3 MEMBER STETKAR: Not if the bus is dead.

4 The bus is dead.

5 MR. MOOKHOEK: I agree.

6 MEMBER STETKAR: It's hooking up cables
7 into plug-in connectors.

8 MR. MOOKHOEK: I agree, but we were trying
9 to -- I was trying to keep it simple.

10 MEMBER STETKAR: Yeah, but my point is that
11 you're actually presuming that things work that can
12 make it more complex for the operators than giving them
13 greater -- I'll use that term "flexibility." Giving
14 them greater flexibility by providing 4 kV power where
15 you have a lot more equipment available to the
16 operators. Other alternatives that they don't have at
17 only the 480 volt plus level.

18 MEMBER BLEY: We had a discussion like this
19 with some of the folks involved in originating the
20 strategies.

21 And I guess on the one hand I can understand
22 you got to start somewhere and having a fixed event is
23 a place to start, but the concept was one of flexibility
24 to deal with other things rather than that one specific
25 thing.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And I think we're losing that in various
2 places as this gets implemented, but go ahead.

3 MR. MOOKHOEK: And part of the other piece
4 was do we really believe that the CTGs are going to be
5 available?

6 The only reason we can't credit them is
7 because of the guidance.

8 MEMBER STETKAR: Fukushima really believed
9 that they weren't going to have anything high than three
10 meters, okay. This is -- CTGs are qualified for 0.13
11 g.

12 MR. MOOKHOEK: Correct.

13 MEMBER STETKAR: Okay.

14 MR. MOOKHOEK: And the guidance --

15 MEMBER STETKAR: You really believe that,
16 but maybe they won't.

17 MR. MOOKHOEK: The guidance we were working
18 on allowed us to credit the CTGs as robust simply
19 because they're transported over ground.

20 Are we going to think about doing 4160 as
21 we finish the plant design and modify and update this
22 plant? Yes, I'm sure we will.

23 MEMBER STETKAR: Except for the fact that
24 you're getting NRC approval of your strategy with this
25 snapshot in time.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. MOOKHOEK: Correct.

2 MEMBER STETKAR: And I'm going to ask the
3 NRC the same question about did they ask about
4 flexibility, or did they simply stovepipe into a
5 pre-defined notion of what this scenario shall be.

6 MR. MOOKHOEK: Well, I think you'll see that
7 we also have replacements for -- and backup equipment
8 for the ACIWA system. So, we do have additional pumps
9 in the plan that can replace that diesel-driven fire
10 pump.

11 MEMBER STETKAR: Not formally, though.
12 You don't take credit for them in the formal plan that's
13 been --

14 MR. MOOKHOEK: Because the guidance tells
15 me I don't have to assume that there's another failure,
16 that there are two other diesel-driven pumps per unit
17 which are in 1E.

18 MEMBER STETKAR: Right.

19 MR. HEAD: And you're hearing Bill, I think,
20 you know, somewhat hidden, this is a -- there's more
21 to the story here than just a decision of 480 versus
22 4160.

23 There are a lot of other capabilities that
24 we have with respect to this issue and this event that
25 went into this decision.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: My simple question is,
2 though, forget about the event and the guidance and my
3 assumption.

4 Why wouldn't I, why would I not bring in
5 a 4 kV diesel generator to provide me more flexibility?
6 Why would I not do that?

7 And it's not because it's higher voltage,
8 because these guys are not connecting 4 kV power live.
9 And it's heavier, but I'm telling you other people are
10 flying in 4 kV diesel generators.

11 So, FedEx and big trucks are available to
12 get the big diesels there. So, it's not bulk. It's
13 not, you know.

14 MR. HEAD: But we were --

15 MEMBER STETKAR: So, why would I not do
16 that?

17 MR. HEAD: We were making this decision in
18 the context of everything else that's available to us.

19 CHAIRMAN CORRADINI: Okay. Go ahead,
20 Steve.

21 MR. THOMAS: Okay. I think I'm ready for
22 the next slide. What I'd like to do is talk about each
23 of these components briefly.

24 The combustion turbine generator. Again,
25 we're not taking credit for this. Again, it's a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 significant piece of equipment.

2 Each unit has a combustion turbine
3 generator rated at 20 megawatts. These are completely
4 independent from the standby diesel generator systems,
5 electrically, fuel, physically separated.

6 Each diesel generator is capable of
7 supplying all three of the Class 1E buses in that unit,
8 or one Class 1E bus if there's only one of the two
9 combustion turbine generators available, can be
10 cross-connected to the other unit and you can power one
11 of the Class 1E 4160 buses in each unit from a single
12 combustion turbine generator.

13 They are, by their nature, seismically
14 robust. We haven't gone through the rigorous process
15 of demonstrating that yet, but there are similar size
16 components that are available for emergency transport
17 over the air and highway systems and, I mean, it's
18 basically a jet engine.

19 So, the component itself is seismically
20 robust and we have committed to protect this in a
21 structure from design-basis hurricanes, tornado
22 missiles. And as I mentioned earlier, it's already in
23 the certified design protected from the design-basis
24 flood.

25 The AC-independent water addition system,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 it's a diesel powered system. It's a common installed
2 diesel fire pump with the two units.

3 In addition to this pump, there is one fire
4 truck per unit which can be substituted for the ACIWA
5 pump. And for each unit, there is a trailer-mounted
6 diesel power pump available for backup for the ACIWA
7 pump.

8 The ACIWA system connects to the RHR
9 system. And in that capacity, it is capable of
10 providing injection to the core, capable of providing
11 drywell and wetwell spray, which we do not acquire in
12 our FLEX strategy, and is also capable of providing
13 spent fuel pool makeup.

14 MEMBER BLEY: When you say you're not
15 required, you're still going to put in the connection
16 points so you can hook it up, or not?

17 MR. THOMAS: Yes, it's there in the existing
18 design.

19 MEMBER BLEY: It is, okay.

20 MR. THOMAS: It is. The pump has a
21 sufficient capacity to provide the required flow rates
22 for both units and provide makeup to both spent fuel
23 pools.

24 The two fire water storage tanks again
25 which we have qualified both of those for protection

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 against the design-basis external events, have a
2 combined capacity of greater than 600,000 gallons.

3 The fuel tank supply to there we have
4 committed to provide at least 36 hours of operation for
5 the system. And it's protected from the site-specific
6 seismic, missiles, floods and external events.

7 CHAIRMAN CORRADINI: And this is used after
8 you use RCIC to bring it down to a pressure that is --

9 MR. THOMAS: That's correct.

10 CHAIRMAN CORRADINI: Okay.

11 MEMBER STETKAR: Well, it cools you down and
12 you still have to actively depressurize.

13 CHAIRMAN CORRADINI: Right. But still
14 this is not in support of RCIC operation. This is after
15 RCIC has cooled you down and --

16 MR. THOMAS: After the period of RCIC
17 operation.

18 MEMBER STETKAR: That's what I was going to
19 ask. What happens if RCIC doesn't work?

20 MR. THOMAS: I'm sorry?

21 MEMBER STETKAR: What happens if RCIC
22 doesn't work?

23 MR. THOMAS: Then we depressurize and use
24 the system.

25 MEMBER STETKAR: Does it have enough flow

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 rate at time -- pick a number -- 20 minutes or so?

2 MR. THOMAS: Yes, it does.

3 MEMBER STETKAR: Okay.

4 MR. TOMKINS: And if it happened at T equals
5 zero, it's close.

6 CHAIRMAN CORRADINI: So, the backup plan,
7 that's what I was trying to understand. The backup
8 plan here is that if RCIC fails to take you down or it
9 fails in some portion of that, you would immediately
10 depressurize and go to this.

11 MR. THOMAS: Yes.

12 MR. TOMKINS: Yes.

13 MR. HEAD: RCIC is a pretty simple system.

14 MR. THOMAS: But under that scenario,
15 that's what we would do.

16 CHAIRMAN CORRADINI: I think if I heard
17 correctly, you're going to get to the scenarios in a
18 minute. So, I'll wait.

19 MR. THOMAS: Yes.

20 CHAIRMAN CORRADINI: I had a couple other
21 questions, but I'll wait.

22 MR. THOMAS: Yes. Okay. The RCIC system
23 is really the keystone of the system. As I mentioned
24 earlier, did have the opportunity recently to go to
25 Scotland and talk to the manufacturer of this

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 component. And I was impressed with it before, and I'm
2 probably more impressed now.

3 CHAIRMAN CORRADINI: Who is the
4 manufacturer?

5 MR. THOMAS: Clyde Union.

6 CHAIRMAN CORRADINI: Okay. So, it's not
7 Dresser.

8 MR. THOMAS: It's not a Dresser component,
9 no.

10 CHAIRMAN CORRADINI: Okay.

11 MR. THOMAS: It is a very simple and rugged
12 machine. It's a mono-block. It's a single shaft with
13 the turbine on one end and the pump on the other end.
14 It's self-lubricated, water-lubricated by the process
15 flow.

16 It supplies water to the core over the full
17 spectrum of reactor vessel pressures. Takes suction
18 initially from the condensate storage tank or the
19 suppression pool.

20 In our analysis, we credited 250,000
21 gallons of the over 500,000 gallons capacity of the
22 condensate storage tank.

23 And since the RCIC is part of the emergency
24 core cooling system, it is safety-related and is
25 protected from all design-basis external events. In

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 this case, 0.3 g.

2 (Comments off record.)

3 CHAIRMAN CORRADINI: So, can I ask a
4 question in this regard? Maybe it's in the writeup and
5 I don't remember it.

6 Why did you only pick half the inventory
7 as credited? I didn't understand that.

8 MR. THOMAS: The level in the condensate
9 storage tank will fluctuate some.

10 CHAIRMAN CORRADINI: Oh, okay. So, it's
11 just where it might be at any given point in time, okay.

12 MR. THOMAS: There are some unavailable
13 volumes at the top and at the bottom. And then there's
14 an operating band in the middle. So, we were not able
15 to take full credit for that.

16 Although it's in all likelihood that there
17 will be more than 250,000 gallons there, we only
18 credited the 250,000 gallons.

19 CHAIRMAN CORRADINI: Okay. Thank you.

20 MR. HEAD: For example, if there was a
21 hurricane in the Gulf, that would be 500,000 gallons.
22 It's part of the site procedures to fill up the tanks.

23 CHAIRMAN CORRADINI: Thank you.

24 MR. THOMAS: Okay. The containment
25 overpressurization system is the hardened passive vent

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 system for the ABWR.

2 The rupture disk for this system, it's a
3 completely passive system. Operates at about 90 psig.
4 And this ensures containment integrity.

5 And then of course when you start venting
6 the containment, that provides containment cooling
7 capability.

8 These components are located inside the
9 Reactor Building. And as such, they would be designed
10 to the 0.3 g criteria for the components in the Reactor
11 Building.

12 MEMBER STETKAR: I don't read ahead fast
13 enough. So, tell me when you get into the scenarios.
14 I track power supplies for the COPS isolation valves
15 and I know they fell open on loss of power. They fell
16 open on -- they're only shown as they have an air supply
17 to them; is that correct?

18 They're from air, not --

19 MR. THOMAS: I think it's nitrogen, but yes.

20 MEMBER STETKAR: Well, I couldn't track it
21 down. So, when you say you think, that's going to be
22 part of my question is I couldn't find a connection from
23 the nitrogen bottles that you connect to the SRVs, which
24 I'll get to later --

25 MR. THOMAS: Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: -- into the COPS isolation
2 valves. My question is, in a practical sense if you
3 do not -- I understand how you'll have power to the
4 solenoids. But if you don't have pneumatic pressure,
5 you may not be able to reclose those valves.

6 I don't know whether you want -- there are
7 statements in there saying, well, once we've stabilized
8 the plant, we'll go reclose the COPS line and control
9 ourselves otherwise.

10 Can the operators actually do that if they
11 don't have instrument air?

12 MR. MOOKHOEK: Part of the equipment we're
13 bringing in for Phase III is a portable instrument air
14 compressor.

15 So, we will tie in an instrument air
16 compressor not only for these vales, but for any of the
17 other AOVs that we need to operate.

18 MEMBER STETKAR: Thank you. That helps.
19 Thank you.

20 MEMBER POWERS: You ought to check to see
21 if that's air or nitrogen.

22 MEMBER STETKAR: Yeah, I couldn't find --
23 I tried -- the problem is the instrument air drawing
24 is just so stubs going out. And I couldn't find a
25 connection on -- the nitrogen drawings are more

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 complete. I couldn't find a connection.

2 MR. THOMAS: Yeah, I looked at that once and
3 I'm not going to make a positive statement like the last
4 time.

5 MEMBER STETKAR: It could come off a tie-in
6 on the nitrogen side that just shows as an arrow, but
7 there are some check valves that prevent the nitrogen
8 bottles feeding backwards into that part of the line.

9 MR. THOMAS: I don't think it would come off
10 of the nitrogen bottles. That's specifically for ADS,
11 but it may come off the non-safety-related nitrogen
12 system.

13 MEMBER STETKAR: Yeah.

14 MR. THOMAS: That's what I'd have to check.

15 MEMBER STETKAR: Yes, okay. Anyway, the
16 air compressors are good enough for me. Thanks.

17 MR. THOMAS: Okay. I mentioned earlier we
18 do have four divisions of Class 1E batteries capable
19 of more than 12,000 amp-hours.

20 We're also using non-Class 1E batteries
21 for some of the communications requirements and have
22 an 8,000 amp-hour capacity.

23 We do require load shedding, which Bill is
24 going to discuss in considerable detail, which can
25 extend the Division 1 battery alone to get us entirely

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 through Phase I of the event for 40 hours.

2 Now, that's a significant point circled
3 out on mine that combined capacity for Division I, II
4 and III Class 1E batteries gives us about 72 hours
5 capacity.

6 Our Phase I coping capability for 36 hours,
7 we can handle with only one division of these batteries.
8 So, we have a substantial margin on battery capacity,
9 which is a significant advantage.

10 CHAIRMAN CORRADINI: So, you're counting on
11 this shedding to take you to whenever offsite stuff
12 happens, because you jump from Phase I to Phase III.

13 MR. THOMAS: Correct.

14 CHAIRMAN CORRADINI: Okay. So, let's say
15 something goes wrong. IS the RCIC system designed and
16 operators trained such that they can run RCIC manually?

17 MR. THOMAS: Absolutely. RCIC system can
18 be operated entirely without external services. All
19 it needs is steam and a suction supply of water.

20 MEMBER STETKAR: Part of that I was going
21 to wait until Bill came up, but you're stealing --

22 CHAIRMAN CORRADINI: I'm allowed to ask a
23 question.

24 MEMBER STETKAR: No, that's -- part of the
25 -- as I go through the scenarios, it says that an

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 operator will be dispatched to the RCIC room.

2 Is that required?

3 MR. THOMAS: If somebody --

4 MEMBER STETKAR: I'm eventually going to
5 get to a point where I'm counting bodies. So, I'm
6 starting to take an inventory of bodies.

7 MR. MOOKHOEK: In this case, I would say
8 it's normal practice, but as a operations supervisor
9 the answer to that would be yes.

10 MEMBER STETKAR: Okay.

11 MR. MOOKHOEK: That's a vital piece of
12 equipment. I want someone there.

13 MEMBER STETKAR: So, I'll put a body over
14 in the RCIC room.

15 MR. MOOKHOEK: Put a body there.

16 MEMBER STETKAR: Okay.

17 MR. MOOKHOEK: He may not be there the
18 whole time, he may be running back and forth between
19 the shutdown panel and RCIC room, but --

20 MEMBER STETKAR: The shutdown panel has
21 absolutely no control or indication for RCIC though;
22 is that right?

23 MR. MOOKHOEK: That is correct.

24 MEMBER STETKAR: Okay.

25 MR. HEAD: Except water level.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN CORRADINI: Except what?

2 MR. HEAD: Water level.

3 MR. MOOKHOEK: It has water level in the CST
4 and the suppression pool.

5 MEMBER STETKAR: Yes, but I man --

6 MR. MOOKHOEK: But as far as RCIC itself
7 goes, there's no flow rate, there's no indication of
8 valve positions. That's all local.

9 MEMBER STETKAR: Okay. Thanks.

10 MR. THOMAS: Next slide. I mentioned
11 earlier that the AC-independent water addition system
12 was capable of providing makeup to the spent fuel pool
13 via the RHR piping. That is the preferred method.

14 MEMBER BROWN: Can I ask a -- go back to the
15 power supply for a minute. In most of the documents
16 that were submitted, there is a letter from the IEEE
17 Standards Group, which you all referenced, as well as
18 NRC referenced in their audits.

19 And that talked about the curves and -- the
20 graphs that they, you know, charts they provided. And
21 they were based on like a 1.215 nominal voltage. And
22 then they talked about going down to 1.75 volts per cell
23 in the extended period that could be utilized out to
24 that.

25 And that's, what, 1.215 to 1.75, there's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 -- what am I missing? I lost the bubble a little bit
2 between those two numbers.

3 MR. THOMAS: I'm going to ask Evans Heacock
4 to address your question.

5 MR. HEACOCK: This is Evans Heacock. Your
6 question about cells --

7 MEMBER BROWN: Yes.

8 MR. HEACOCK: Cell voltage.

9 MEMBER BROWN: Yes.

10 MR. HEACOCK: Typically your open cell
11 voltage will be about 1.25, like you said. And then
12 --

13 MEMBER BROWN: Right. 1.2 --

14 MR. HEACOCK: Yeah, 1.2.

15 MEMBER BROWN: 1.215, or 1.25? The PES
16 documents are based on -- their tables are based on a
17 1.215 specific gravity.

18 MR. HEACOCK: Yes. Specific gravity, yes.

19 MEMBER BROWN: Okay.

20 MR. HEACOCK: But the volts to the cell --

21 MEMBER BROWN: The voltage would be --

22 MR. HEACOCK: Yes, it gives you a different
23 open --

24 MEMBER BROWN: -- 2.5?

25 MR. HEACOCK: Not that high. It won't be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 2.5.

2 MEMBER BROWN: Okay. I didn't think so.

3 MR. HEACOCK: It's a little lower than than
4 two volts per cell when you first have the event when
5 you take it off charge and go to the open cell.

6 MEMBER BROWN: Yes.

7 MR. HEACOCK: But it will drain down. It
8 will drain the batteries down to a voltage of about 105.
9 Just a little above 105 volts. About 106 to --

10 MEMBER BROWN: From 200 --

11 MR. HEACOCK: From nominal of 125 for the
12 safety-related battery --

13 MEMBER BROWN: Okay. About a 17 or 18
14 percent reduction then, roughly. I guess my question
15 goes do you have to feed invertors to develop the power
16 for these.

17 MR. HEACOCK: Right.

18 MEMBER BROWN: And I presume your invertors
19 cover that --

20 MR. HEACOCK: Correct.

21 MEMBER BROWN: -- full range and --

22 MR. HEACOCK: The invertors built these
23 days typically go down to about a hundred volts before
24 they'll shut down.

25 MEMBER BROWN: Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. HEACOCK: That's what's going to --

2 MEMBER BROWN: When you say typically, I
3 mean --

4 (Speaking over each other.)

5 MR. HEACOCK: That's part of the overall
6 analysis that will be covered when you look at what your
7 overall voltage profile is going to be for a
8 distribution system.

9 And they'll have to be -- ensure that these
10 will be covered down to 105 to 106 at the battery,
11 because your voltage drops from your distribution panel
12 all the way out to your inverter included.

13 MEMBER BROWN: Okay. So, that's the kind
14 of number you used in doing the --

15 MR. HEACOCK: Yes.

16 MEMBER BROWN: -- discharge and the load
17 analysis as you shift cells.

18 MR. HEACOCK: Correct.

19 MEMBER BROWN: Okay. Thank you.

20 CHAIRMAN CORRADINI: Okay. Go ahead, Jim.

21 MEMBER BROWN: Let me ask one other
22 question.

23 CHAIRMAN CORRADINI: Okay.

24 MEMBER BROWN: Sorry. You say it's typical
25 that they typically for the 125 volt input capacity

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 rating to the invertors, that they will work down to
2 105, roughly.

3 Did somebody verify that by test or
4 something like that for what you all are getting? Are
5 your all's custom, or are these standard off-the-shelf
6 invertors, or what?

7 MR. HEACOCK: Well, at the -- okay. For --
8 and I'll give you some of what I've dealt with in the
9 industry.

10 We have procured a number of invertors for
11 different sites. STP included, 1 and 2. When we
12 procured new invertors there, they were operable down
13 to a hundred to 102 volts as an input to the invertor
14 itself.

15 MEMBER BROWN: Okay. And you all confirmed
16 that.

17 MR. HEACOCK: Yes.

18 MEMBER BROWN: The actual testing or
19 operation --

20 MR. HEACOCK: Yes, actual, live test.

21 MEMBER BROWN: Live test, okay. All right.
22 That's -- so, you've got experience.

23 MR. HEACOCK: Yes.

24 MEMBER BROWN: You've confirmed that.

25 MR. HEACOCK: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BROWN: Okay. That's all I was
2 looking for.

3 MR. HEACOCK: Okay.

4 MEMBER BROWN: Thank you.

5 MR. HEACOCK: Okay.

6 MR. THOMAS: Okay. I did mention that
7 ACIWA is the preferred makeup method to the spent fuel
8 pool via the RHR system.

9 We do have two external standpipes that can
10 provide makeup and spray to the spent fuel pool. These
11 were added as part of the loss of large area effort,
12 but they are there. They are on opposite building --
13 opposite sides of the Reactor Building. And those
14 would be available for temporary hookups if for some
15 reason we could not provide makeup with the RHR slant
16 final portion of the system.

17 Just to summarize, the ABWR was really
18 designed for a station blackout with or without the CTG
19 before the Fukushima event and before FLEX strategies
20 came along.

21 We fully expect the CTGs are going to be
22 available to provide power to mitigate this event using
23 the normal ECCS systems. However, we do not take
24 credit for them in our FLEX strategy.

25 We have made additional enhancements to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the components that we've discussed today in order to
2 satisfy the additional requirements imposed by NEI
3 12-06 required to take credit for installed equipment.

4 And even without crediting the combustion
5 turbine generators, ACIWA, RCIC and COPS can mitigate
6 the extended loss of AC power events.

7 CHAIRMAN CORRADINI: So, can I say it
8 differently just so that I think I get it, but in
9 difference to my colleague?

10 So, the DCD design safety-related
11 equipment can take something that is not site-specific,
12 but just turns out to be much more robust.

13 But given the current rules of the
14 strategy, you can't take credit for that because it's
15 installed equipment and, therefore, it can't be
16 credited.

17 MEMBER STETKAR: Electrical, but they can
18 take credit for other stuff like --

19 CHAIRMAN CORRADINI: Right.

20 MEMBER STETKAR: -- RCIC.

21 CHAIRMAN CORRADINI: Right. I
22 understand. Thank you very much, but have I got it
23 about right?

24 MR. THOMAS: You were speaking about the
25 combustion turbine generator.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN CORRADINI: When I read 1E, I got
2 a little confused. And then I tried to go backwards
3 and I just got more confused, but I think I get it now.

4 Have I said it approximately right?

5 MR. THOMAS: Yes, sir.

6 CHAIRMAN CORRADINI: Okay.

7 MEMBER BLEY: I have another question on
8 this. These are the rules you are following to design
9 the strategy.

10 Are you following those same rules when you
11 write the procedures for carrying out the strategies,
12 or do you let the people use everything that works?

13 MR. MOOKHOEK: I'll go into it here in a
14 minute.

15 MEMBER BLEY: Okay.

16 MR. MOOKHOEK: We wrote this plan as what
17 will I have to have at minimum to show protection for
18 indefinite protection for the core and fuel. And
19 that's what we came up with.

20 So, there is a lot more capability that
21 isn't addressed in the plan, but the plan basically
22 gives us our minimums.

23 MEMBER REMPE: So, maybe this is the time
24 to bring up this question. If I look at the plan,
25 there's instrumentation you've identified. And I'm

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 curious is that the minimum instrumentation that you
2 need and did you use your existing ~~spurious~~ severe
3 accident management guidance, or did you come up with
4 a new guidance to identify that minimum set? And then
5 were some changes made to make that instrumentation
6 work with us?

7 MR. THOMAS: All right. You want me to
8 answer that?

9 PARTICIPANT: Sure.

10 MR. THOMAS: I'll try. The
11 instrumentation we're taking credit for is basically
12 the installed instrumentation that's provided in the
13 original design at the remote shutdown system panels.

14 So, we did not enhance that
15 instrumentation. It's there. It provides more than
16 the minimum of what we need, but it does provide the
17 minimum of what we need in order to assess the plant
18 conditions and control the systems necessary to take
19 us through our FLEX strategy.

20 MR. MOOKHOEK: And the other important part
21 about it, that's essentially the safe shutdown
22 instrumentation for fire in the control room. It's an
23 analog system instead of a computer-driven system.

24 And because of our plan where we're going
25 to turn off the computer system because of the load on

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the batteries and the heat generation in the area, we
2 rely on that installed analog system.

3 MEMBER REMPE: Thank you.

4 MR. THOMAS: Does that answer your
5 question?

6 MEMBER REMPE: Yes.

7 MR. THOMAS: That concludes my portion of
8 the presentation. Right now I'm going to turn it over
9 to Bill Mookhoek to walk through our FLEX strategy.

10 Bill, as he mentioned, was eminently
11 involved in developing the implementation of the
12 strategy primarily using installed equipment.

13 And so, Bill, I'll let you go ahead.

14 MR. MOOKHOEK: Since this is really the
15 first time, I'll talk to you a little bit on my
16 background.

17 I joined STP in 1983 as part of the initial
18 manning for operations after 12 years in the Navy with
19 nuclear submarines.

20 I served in operations until '95. And I
21 spent four, five years as shift supervisor on shift in
22 Unit 1. So, I was there for the initial startup,
23 testing program and operation and several of the major
24 events that we had there in that period of time.

25 At that point, I shifted over, did some

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 time in licensed operator training and then went to
2 licensing.

3 I had the opportunity to come over and be
4 the licensing supervisor for the application for 3 and
5 4 and worked on a new reactor, which was very
6 interesting.

7 But I am a PWR guy and moved over to a BWR
8 and they almost convinced me to boiling reactors. Not
9 a bad thing.

10 (Laughter.)

11 CHAIRMAN CORRADINI: You would never
12 convince me.

13 (Laughter.)

14 MR. MOOKHOEK: That's one of the things the
15 Navy always taught you. Never ~~boiler~~ boil a reactor.

16 MEMBER BROWN: As long as you have a
17 hardware watchdog timer, it will come up.

18 MR. MOOKHOEK: All right.

19 CHAIRMAN CORRADINI: Let's move on.

20 MR. MOOKHOEK: When we started looking at
21 what did we have to do to answer the staff questions
22 on the orders that were going out to the operating
23 fleet, this was at a time when there was -- NEI 12-06
24 was really just being developed in draft. It had just
25 been submitted to the NRC for approval and we started

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 putting our plan together.

2 So, we used 12-06 as the guidance. The big
3 point in that, as I said before, is you assume that you
4 lost all of your onsite AC power generation equipment
5 and that the ultimate heat sink was unavailable as well
6 essentially because it had no power.

7 So, our goal was to because of the
8 capabilities of the ABWR, was to use installed
9 equipment as much as possible.

10 Phase I on the NEI guidance is strictly
11 installed equipment. You survive on your own. Phase
12 II was you have portable equipment on site that you
13 could connect and bridge the gap between the onsite
14 installed equipment and the offsite equipment showing
15 up.

16 As we went through and did the analysis and
17 looked at what our capabilities were, it became
18 apparent that we didn't need a Phase II, because our
19 Phase I usage with the installed equipment could bridge
20 that gap itself and get us to the 36 hours. We expect
21 to have the first equipment on site in 32 hours. So,
22 we really don't have a Phase II, per se.

23 We do use some portable equipment we have
24 on site mainly for transferring fuel from either the
25 diesel generator fuel oil storage tanks, or the major

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 fuel oil storage tank for the CTG into the ACIWA fuel
2 oil storage tank. Other than that, we really don't
3 need much else.

4 We specify having an air compressor
5 brought in with the FLEX diesels, but we also have
6 onsite as part of our portable equipment additional
7 pumps, diesel-driven pumps that can replace the ACIWA
8 pump, power supplies, small generators and ventilation
9 fans that we will use.

10 The plan doesn't specify where
11 specifically that defense-in-depth equipment goes, but
12 we felt it was necessary to have the flexibility for
13 operations to go do what they need to do based on
14 anything that may happen.

15 So, our Phase I is 36 hours. Phase III
16 directly follows that with no Phase II. And, again,
17 the offsite equipment we're assuming shows up at the
18 staging hours within 24 hours of request.

19 We ask for that conservatively within two
20 hours of the event initiation. That means it should
21 be there ready for use in 32 hours.

22 MEMBER STETKAR: Bill, what triggers -- you
23 said we ask for that conservatively, and I never know
24 what "conservatively" means, within two hours of the
25 event.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 What actually triggers people to call up
2 the center and say, help me, I need the equipment?

3 MR. MOOKHOEK: It will be definitely driven
4 by procedures. The emergency operating procedures
5 will have a kick-out at 30 minutes to tell you to go
6 initiate the procedures for an extended loss of AC
7 power, which gets you into the FLEX plan.

8 That procedure, part of that and the fact
9 that you also have an ERO organization, you're in the
10 emergency plan. So, it will be built into the plant
11 procedures at this time both in the control room and
12 with the ERO staff.

13 CHAIRMAN CORRADINI: But what physical - -
14 I think what he's asking is what physical plant status
15 would --

16 MEMBER STETKAR: I would hope it would be
17 in procedures.

18 CHAIRMAN CORRADINI: That would be -- you
19 would look at and say, you know, this has happened, this
20 has happened, this has happened. I better go do X.

21 MR. MOOKHOEK: Right.

22 CHAIRMAN CORRADINI: What is the physical
23 state -- what physical states would have to be there
24 to ask for outside assistance?

25 MR. MOOKHOEK: All the diesels failed, both

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CTGs failed for a period of 30 minutes with no
2 expectation to restore power. At that point, you kick
3 out to the new procedure.

4 MR. HEAD: That's covered in some slides
5 here.

6 CHAIRMAN CORRADINI: Oh, yes. If you're
7 coming, then you can hold us off. That's fine. Okay.

8 MR. MOOKHOEK: As we looked through the
9 external events, it became -- for South Texas because
10 of the fact that we deal with hurricanes normally, we
11 would have shut the plant down for a hurricane before
12 hurricane-force winds get on site.

13 We also preemptively start and load a
14 diesel generator before we get hurricane-force winds
15 on site.

16 It's an event we see coming and we are well
17 prepared for it. We have additional people on site.

18 We don't get a big enough flood with
19 hurricanes or storm surges to impact the plant
20 significantly.

21 Seismic, we have done all the current
22 guidance seismic analysis for the plant. So, we didn't
23 have to go redo any analysis for seismic or for
24 hurricane missiles, tornado missiles. That was all
25 done with the current guidance.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Our limiting event that we chose for this
2 was a breach of the main cooling reservoir embankment,
3 because it is the event that puts the most water on the
4 site for the longest period of time.

5 CHAIRMAN CORRADINI: This has also been
6 your -- well, this is your main event from the severe
7 accident standpoint.

8 MR. MOOKHOEK: Design-basis flood. It is
9 our design-basis flood.

10 MEMBER STETKAR: Why didn't you select --
11 you said this is your limiting beyond design-basis
12 external event.

13 Why didn't you pick a 0.5 g earthquake as
14 your limiting beyond design-basis external event? For
15 reference, it has about a factor of 10. It's about a
16 factor of 10 less likely than your 0.13 g earthquake
17 in frequency according to your site-specific seismic
18 hazard -- mean seismic hazard at an absolute frequency,
19 for Dr. Powers' benefit, of about 1E to the minus six
20 per year.

21 So, when you're talking about limiting
22 beyond design-basis events, I start to get curious
23 about how you determine what's limiting, not probably
24 the biggest flood you can get.

25 MR. MOOKHOEK: I mean, I guess the answer

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 to that question is what would be the criteria for
2 selecting a -- any earthquake bigger than what your
3 maximum design-basis earthquake is.

4 MEMBER STETKAR: Well, I'm sorry. The
5 maximum design-basis earthquake from the certified
6 design could be conceived to be 0.3 g.

7 MEMBER RICCARDELLA: Wait. Wait. Wait.
8 Not in Texas. No. The 0.13 g as I understand it, is
9 the currently reevaluated seismic hazard at the site
10 by the CEUS and by Recommendation 2.1.

11 MEMBER STETKAR: That's absolutely
12 correct.

13 MEMBER RICCARDELLA: The 0.3 g just happens
14 to be what the standard design can tolerate.

15 MEMBER STETKAR: That is also absolutely
16 correct.

17 MR. MOOKHOEK: We had to start somewhere.
18 I don't know how to --

19 MEMBER STETKAR: The point is you do need
20 to start somewhere, but statements like "this is my
21 limiting beyond design-basis event," implies that
22 you've thought about everything and nothing can be
23 worse than this. And that's not true.

24 MEMBER POWERS: I mean, that would never be
25 what they would imply.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: It wouldn't be, because
2 you need to --

3 MEMBER POWERS: Well, I mean, they can sit
4 down and say my limiting event is the asteroid Ceres
5 slamming into my planet there. That would be a
6 limiting event, by your logic.

7 MEMBER STETKAR: No, my logic is that when
8 one makes absolute statements like this, one is
9 presuming --

10 MEMBER POWERS: You are --

11 MEMBER STETKAR: Wait, Dana. Let me
12 finish. One is presuming to have done some sort of
13 frequency screening.

14 And my question is, has that frequency
15 screening been done? Because this has been selected
16 deterministically as the limiting event.

17 I don't know what the frequency of this
18 event is compared to the frequency of a 0.5 g
19 earthquake.

20 I know what the frequency of the 0.5 g
21 earthquake is. And indeed if the frequency of this
22 flood giving me much worse conditions is much higher
23 than the frequency of that 0.5 g earthquake, I'm willing
24 to accept the notion that for all practical purposes
25 they can accept this.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER POWERS: So, for the practical
2 purposes, the difficulty is we don't have the
3 equivalent of geologists going out and looking at paleo
4 floods. We just can't do it because all the evidence
5 gets wiped out after about a thousand years.

6 And so, 10 to the minus third is like --
7 (Speaking over each other.)

8 MEMBER POWERS: I mean, this seems like a
9 reasonable, probable limiting event whereas you're
10 hypothesizing an earthquake that seems beyond the pale
11 for anything that anybody else has to look at.

12 MR. HEAD: John, I understand your point.
13 This is added here because the flood impacts the time
14 that operators can do different things on the station.

15 Okay. It has an impact that we needed --
16 we felt like we needed to address and is embedded in
17 our FLEX plan.

18 If there's a bigger seismic event, I don't
19 know what we would do other than expect a lot of this
20 stuff, even the bigger seismic event to work, but that's
21 the reason it's in here. It's with respect to the FLEX
22 plan that we added this word in there.

23 It's basically saying the main coolant
24 reservoir in this flood is the -- has the limiting
25 impact in terms of what operators can do.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: See, I have no problem
2 saying we designed our strategies for this event,
3 period.

4 MR. HEAD: Okay.

5 MR. MOOKHOEK: Okay.

6 MEMBER STETKAR: I have no problem with that
7 notion in the same sense that we have design-basis
8 events that we design -- you have to design for
9 something. But to characterize things as saying this
10 is the limiting beyond design-basis event --

11 MR. HEAD: We designed it for this FLEX
12 plan. We used the MCR --

13 MEMBER STETKAR: And no problem with that.

14 MR. HEAD: And it's --

15 MR. MOOKHOEK: From our viewpoint, it's the
16 most challenging.

17 CHAIRMAN CORRADINI: But can I just -- I'm
18 watching you guys have at each other and it's
19 entertainment.

20 However, I want to make sure I get back to
21 something that Dana said, which I make sure that John
22 -- because I think you guys are both on the same page,
23 but I want to make sure I understand it because this
24 I don't get, is that really your biggest issue is they
25 can't -- since I can't estimate the frequency of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 flooding event, then you can't claim that it's
2 limiting, because I don't know the frequency.

3 And, Dennis, point back to you is that
4 given just the way hydrologists do that, it's not
5 possible at this point technically. That's what I
6 heard him say to you.

7 MEMBER STETKAR: That's true. On the other
8 hand as Dennis mentioned, this is not a notion of
9 probable maximum precipitation. This is a manmade
10 design facility that there is evidence for estimating
11 frequencies of failure.

12 And they've done that in their PRA. So,
13 if they could do that in their PRA, why can't, you know,
14 they have that information.

15 MR. HEAD: Well, just back on the
16 presentations on that, even this flood is very
17 conservative.

18 We had to generate an incredible growth gap
19 to --

20 CHAIRMAN CORRADINI: Yes, I was just going
21 to say I thought we went through that.

22 MR. HEAD: Right.

23 CHAIRMAN CORRADINI: And we all agreed that
24 they were on the slightly conservative side on if it
25 failed and how much it grew, how fast it grew and how

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 it essentially ran up to the plant site, if I'm
2 remembering correctly.

3 MR. HEAD: We grew it as fast as we could
4 to the maximum extent that was reasonable to assume.

5 MEMBER BLEY: The big old doors are closed;
6 is that right?

7 MR. HEAD: Doors are closed and, like I
8 said, as part of our, you know, part of the thinking
9 is that, you know, even this flood does give you time
10 to recognize that it's coming.

11 Okay. You will be shutting the plant down
12 as this is happening. Okay. Because you're going to
13 lose your cooling. So, you'll be shutting the plant
14 down.

15 And so, we weren't trying to say something
16 exotic or global with the limiting external event. It
17 was just something we included in our thinking, because
18 there is water on the site and we won't be able to do
19 a number of things while the water is on the site.

20 So, we need to be --

21 MEMBER BLEY: And I think, you know, if it
22 were phrased that way in terms of it affects the people
23 more than others --

24 MR. THOMAS: Yes. I think that after
25 having listened to this discussion, I think I would

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 prefer to use Bill's terminology.

2 We felt this was the most challenging event
3 in terms of our ability to move around the site to get
4 equipment around the site. For example, it would be
5 very difficult to access portable storage equipment
6 while you've got six feet of water at the site and move
7 it someplace where you need it.

8 That was the thinking in putting this
9 bullet on the slide, not to indicate that it was somehow
10 an overarching ultimate criteria.

11 So, I understand your point. I'm happy to
12 change the word "limiting" on this if it makes it a more
13 appropriate comment.

14 MR. MOOKHOEK: Okay. Poor choice of words
15 on my part, but that's --

16 CHAIRMAN CORRADINI: That's okay. I
17 learned something. Nicely done. Let's go.

18 MR. MOOKHOEK: In our plan, we assume that
19 the extended loss of AC power, or the ELAP, occurs at
20 time zero. But as Scott said, there is some lead-in
21 time. The events don't happen instantaneously.

22 And this actually requires the failure of
23 all six ESF diesel generators, both CTGs and six offsite
24 power sources. So, it's a pretty significant process.

25 MEMBER BLEY: It is, but here's where that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 earlier discussion about flexibility and the like comes
2 in.

3 If you really think about this scenario --

4 MR. THOMAS: Which we have.

5 MEMBER BLEY: This scenario is very
6 unlikely to occur by those eight things just failing.
7 It's almost certain -- the probability that there's
8 more stuff going on than just these things breaking is
9 much higher than the probability that nothing else is
10 going on and these things are breaking.

11 So, when we focus what we're doing strongly
12 assuming that nothing else is there is troublesome --
13 now, I think eventually when you get to doing your SAMGs
14 and dealing with this equipment and maybe trying to
15 integrate it in, you have to deal with those kinds of
16 issues, but it's a bit of an artificial piece.

17 And when we limit the flexibility of FLEX
18 to meet this, that artificial scenario, it's just kind
19 of a --

20 MR. HEAD: I think maybe limiting the
21 flexibility of FLEX is in that context. We think our
22 capabilities are much more than FLEX. And Steve has
23 gone over that.

24 And as Bill has alluded to, we would not
25 limit ourselves to FLEX, okay. It's what we needed

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 as part of a licensing strategy, but there are more
2 pumps, there's more capabilities and there's more to
3 the context, I think, with respect to what would cause
4 that to happen.

5 Okay. We believe the most significant or
6 most likely way it would ever happen would be induced
7 by a hurricane. All four units would suffer through
8 a hurricane. But to look at that as just --

9 MEMBER BLEY: I wouldn't argue with you on
10 that one, yes.

11 MR. HEAD: I'm sorry?

12 MEMBER BLEY: I said I would not argue with
13 that.

14 MR. HEAD: Okay. And so, the planning as
15 I alluded to, the filling of tanks, the preparation for
16 it, the reactor is shut down, that would be a different
17 event than just this all failing immediately and but
18 we think we can accommodate easily both.

19 So, I hope -- I don't know if that's
20 answering your question or maybe just adding to the
21 discussion, but -- so, anyway, go ahead.

22 MEMBER BLEY: It adds to the discussion.
23 Since I interrupted, you're going to get to that bullet
24 about load shedding.

25 MR. HEAD: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BLEY: Earlier you mentioned that
2 one of the things you do is kill power to the computer
3 to save those batteries.

4 How do you get real confidence that turning
5 off the power to your computer doesn't lead to some
6 weird stuff happening around the plant that you weren't
7 expecting?

8 I mean, any control systems I've played
9 with and tried to keep power and things like that, it's
10 not -- you're introducing an event on that system that,
11 you know, if you just look on paper, maybe you say I'm
12 pretty convinced, but weird stuff often happens when
13 you pull power. And especially to a system that's
14 controlling stuff.

15 And I'm just -- how do you have confidence
16 that we're not introducing something that's going to
17 be more troublesome than where we started?

18 MR. THOMAS: The presumption is there's no
19 other power in the plant for weird stuff to happen. I
20 mean, you could have all kinds of perhaps signals being
21 generated, but there's no power-operated equipment in
22 the plant.

23 The plant is dead. And the only thing
24 that's powering those computers are the invertors from
25 the batteries.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. MOOKHOEK: And we do look at what's
2 going to happen especially with the RCIC system. We
3 turn the computers off. The automatic control in RCIC
4 goes away. It no longer auto starts and stops. It's
5 going to be totally manual.

6 And if the pump is running when we turn off
7 the computers, it's going to continue. If it's not
8 running, it won't start. We'll have to either turn it
9 -- throttle it down if it's still running, or we'll have
10 to restart it. And the plan recognizes that.

11 The rest of the computer system, as Steve
12 was talking, there's no AC power out there for it to
13 actually start and stop things.

14 MEMBER BLEY: The reason I got real quiet,
15 I'm thinking about what you said. And we came into this
16 on no AC power, but I'm wondering if you have -- if you
17 have no emergency power, but you have other AC power,
18 might we initiate this? And then you might have some
19 power that would do the -- I don't know the answer. I
20 hope you've looked at that sort of thing and --

21 MEMBER STETKAR: Let me try something else
22 that might help.

23 MEMBER BLEY: Yes, go ahead.

24 MEMBER STETKAR: In two slides we're going
25 to get to everything is fine and dandy and we send people

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 back into the control room and we power the thing back
2 up. What happens then? What does it do to you and how
3 do we know when we bring it back up again?

4 Because it now responds to stuff that we're
5 not sure what signals it's going to respond to unless
6 we're really, really careful about things.

7 MR. HEAD: Correct.

8 MEMBER STETKAR: Because it can perhaps put
9 you on a -- it suddenly realizes that, oh, darn, I had
10 a high temperature alarm from the RCIC exhaust and I'm
11 going to shut down RCIC, and it does.

12 MR. HEAD: Well, I think the TSC, the
13 Technical Support Center, with any other assistance
14 including the procedures that we already have in place,
15 because, I mean, we could lose power to this at any time
16 much less ELAP.

17 I mean, so we -- we're going to have to have
18 that embedded in our design and embedded in our
19 procedures, but I think that would be a very careful
20 moment for the plant to say, okay, we're going to start
21 reenergizing this. What would happen?

22 And I think we would have a significant,
23 you know, support from an onsite Technical Support
24 Center or otherwise before we embarked upon that to say
25 everything is stable and everything is fine before we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 --

2 MEMBER BLEY: You need to think hard about
3 it. I think back to the Robinson fire. And you got
4 to the end of that -- and I actually got to go visit
5 and talk to people who were involved in it.

6 And when they got to that and as you read
7 about it and they reset their 86 relay, they didn't just
8 do it. They talked to everybody there including people
9 who were in training.

10 And it turns out in their training plan and
11 what everybody knew in the plant, was the only thing
12 that would do is reset the permissives and that nothing
13 would happen.

14 And sure enough when they closed it, the
15 breakers tried to reclose and that's when they got the
16 second fire.

17 They've gone back and changed their
18 training program and corrected drawings so it's all
19 there. That's the kind of thing I'm trying -- when you
20 get in a place like this and you, you know, if nothing
21 happened when you lost power, but when you bring power
22 back, really weird stuff can happen.

23 You got to be -- it strikes me that what
24 you really need is for people to understand that and
25 be ready for it, because you're not going to get it nail

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 it perfectly. Something is going to surprise you when
2 you do that. And it's not the kind of thing you're
3 going to go do to test and see what happens.

4 MR. THOMAS: That is an extremely unusual
5 circumstance. I agree with --

6 MEMBER POWERS: And it raises this whole
7 issue of I take an event that gets progressively more
8 and more extreme, but their intermediate states are
9 actually more operationally complex, you know.

10 When you have a dead plant, that's an
11 interesting thing electrically. It's a partially
12 active plant that could be a lot more troublesome from
13 an operational point of view.

14 And then, so we did a kind of a perturbed
15 view of the world that when we keep pushing the more
16 and more limiting catastrophes all the time -- I worry
17 about that and I presume you have to take care of that
18 via your procedures and --

19 MR. HEAD: I would say in Hour 40 if we're
20 on ACIWA and we now believe that we have offsite or we've
21 gotten a diesel to work that we would have a restart
22 team that would have gone through all that process and
23 ensure, for example, that that would not impact ACIWA,
24 okay, because we don't want to lose it as we reenergize,
25 and it would be a progressive process that you would

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 verify that things are happening that --

2 MEMBER POWERS: Well, we have experience
3 with this in other plants where they do a self-induced
4 station blackout and fire. And they have to do it very
5 carefully. No question about it.

6 MEMBER BLEY: If we're quiet, you should
7 probably keep going.

8 (Laughter.)

9 MEMBER POWERS: Don't wait for us to dream
10 up something else.

11 MR. MOOKHOEK: When the event occurs, we're
12 going to enter the emergency operator procedures on
13 loss of AC power. We will have all three emergency
14 buses, switchgears deenergized.

15 That's going to kick us into a site area
16 emergency and the ERO system will man -- will get --
17 the procedures will be written such that at 30 minutes
18 if we haven't restored any power and we have no
19 prognosis on being able to restore power, we're going
20 to kick out into this FLEX plan the ELAP procedures.

21 What that procedure will tell us to do is
22 to commence a load shed -- deep load shed on the Class
23 1E batteries and to shift command and control from the
24 control room to the remote shutdown system in the
25 Reactor Building.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 I envision that we will send one reactor
2 operator, one senior reactor operator to the remote
3 shutdown system.

4 We will have two non-licensed plant
5 operators doing the load sheds. And we will have a
6 third plant operator going to the RCIC room to
7 coordinate and manually operate RCIC.

8 With the load shed completed, that's going
9 to give us greater than 40 hours of battery time on the
10 Division 1 battery.

11 MEMBER BLEY: I can't remember. Do Units
12 3 and 4 share any operators?

13 MR. MOOKHOEK: They will probably share a
14 yard operator.

15 MEMBER BLEY: But that's about it?

16 MR. MOOKHOEK: That's it. Other than that
17 there's going to be two senior reactor operators, three
18 reactor operators and five or six plant operators.

19 Now, with the loss of AC power, the Turbine
20 Building is going to be in significant, shall I say,
21 straits. And the flood levels will actually prevent
22 folks from getting in there. So, I envision the entire
23 staff will be in the Reactor Building/Control Building
24 complex.

25 MEMBER BLEY: Okay. So, they're going to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 have to abandon the Turbine Building. I didn't realize
2 that.

3 MR. MOOKHOEK: Yes, it's --

4 MEMBER BLEY: I don't remember the layouts
5 completely. So, I'm --

6 MR. MOOKHOEK: The flood level is 38.8 feet.

7 MEMBER BLEY: Okay.

8 MR. MOOKHOEK: And grade is 34 feet in the
9 Turbine Building. So, this could be a fair amount of
10 water.

11 MR. HEAD: For a relatively short period of
12 time.

13 MEMBER BLEY: How long is that?

14 MR. HEAD: Well, it's 20 hours, but that
15 peak immediately -- almost immediately starts coming
16 down.

17 MEMBER BLEY: All right.

18 MR. MOOKHOEK: And the Turbine Building is
19 actually further away.

20 The computer system and the reason we do
21 the load shed is because of the computer system. It
22 is the biggest load drain on the batteries. The
23 invertors run the computer system. And not only that,
24 but we've lost all the ventilation.

25 The digital instrumentation and control

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 system incorporates a lot of displays which generate
2 a lot of heat. So, we want them off.

3 RCIC will provide the initial core
4 cooling. Initially it's lined up to take a suction on
5 the condensate storage tank.

6 After you get to the high level alarm in
7 the suppression pool, it will automatically shift to
8 the suppression pool with suction.

9 We envision -- the MAAP runs show us it will
10 happen in a couple of minutes.

11 MEMBER BLEY: Did you have to add analog
12 instrumentation, or is that already --

13 MR. MOOKHOEK: No, that's part of the ABWR
14 design. It had a train of analog because the initial
15 digital systems, they wanted a backup for them.

16 MR. THOMAS: Basically for the fire in the
17 control room remote shutdown capability.

18 MR. MOOKHOEK: That was one of the reasons
19 it was turn off the computers, go to RSS. It's analog.
20 It's predictable.

21 Again, as I said, we'll operate RCIC
22 manually after a load shed. And I said within two hours
23 we'll ask for offsite assistance. That will be line
24 items in the procedure.

25 CHAIRMAN CORRADINI: So, you operate RCIC

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 manually after the -- so, the thinking process is you
2 get away from any need for DC power control for RCIC.

3 You would go to the local operator to
4 operate the system. That's what I didn't understand.
5 I want to make sure.

6 MR. MOOKHOEK: Well, DC control for the RCIC
7 is -- it's actually the computer that will actuate DC
8 devices. That goes away.

9 CHAIRMAN CORRADINI: Okay.

10 MR. MOOKHOEK: And the controls, we will
11 have local hand switches for the valves for RCIC.

12 CHAIRMAN CORRADINI: So, how does it trip
13 off? What if somebody didn't operate it properly? It
14 trips off on overspeed, I assume?

15 MR. MOOKHOEK: That's it.

16 CHAIRMAN CORRADINI: And so, the operator
17 would sit there and then reestablish it.

18 MR. MOOKHOEK: In fact --

19 MEMBER STETKAR: No, I think he --

20 CHAIRMAN CORRADINI: I'm trying to figure
21 out -- well, I have a couple questions, but you go ahead.
22 I didn't mean to interrupt.

23 MR. MOOKHOEK: Yes, all those other trips
24 on RCIC are all driven out of the computer system. So,
25 when we turn the computer system off, those additional

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 trips on the RCIC pump go away.

2 It initially, I mean, it will trip, it will
3 turn off at Level 8. That's what it's designed -- it
4 cycles between Level 2 and Level 8. That control will
5 be gone once we turn the computers off.

6 Now, as you stated, overspeed will still
7 be valid. It's a mechanical overspeed.

8 MEMBER BLEY: Is it still that kind of
9 clunky system?

10 MR. MOOKHOEK: Well, this --

11 MEMBER BLEY: I think they've changed it in
12 the last 20 years.

13 MR. MOOKHOEK: Well, this is not Dresser.

14 MEMBER BLEY: Okay.

15 MR. MOOKHOEK: Again, this is Clyde Union.

16 MEMBER BLEY: The one you were talking
17 about, okay.

18 MR. MOOKHOEK: It doesn't have any
19 electrical to it. It doesn't have any oil. And, in
20 fact, the manufacturer starts and stops it with the
21 overspeed trip. They leave the valves open.

22 (Comments off record.)

23 MR. MOOKHOEK: But, yes, they trip it
24 locally manually and then just reset the switch.

25 MEMBER BLEY: Very simple machine.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 (Comments off record.)

2 MR. MOOKHOEK: So, within two hours we're
3 asking for offsite assistance. The SAFER teams will
4 be notified. That should start getting equipment
5 loaded and ready to us, sent to us.

6 We stay on RCIC on the suppression pool
7 until the suppression pool temperature gets to about
8 250 degrees.

9 The manufacturer says that pump will run
10 fine at 250. In fact, maybe even more. But at 250,
11 we'll shift suction back to the CST at about 10 hours.

12 That eliminates the temperature issue from
13 the pump and puts us on RCIC with the CST volume until
14 we run out of that volume.

15 We expect COPS, the rupture disk, to
16 actuate at about 20 hours, which will start venting
17 containment.

18 Expect the offsite equipment --

19 CHAIRMAN CORRADINI: I guess I didn't
20 understand -- can I go back to that one? That's the
21 one I didn't understand -- oh, you switch off the CST
22 at 10 hours.

23 This is because we're at the -- may I just
24 ask, this is you at the 250,000 gallons so that you've
25 run out and now you're doing recycle?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. MOOKHOEK: We're 250 degrees in the
2 suppression pool.

3 MEMBER STETKAR: It's temperature rating on
4 the bearings for the RCIC turbine.

5 MR. MOOKHOEK: For the pump.

6 MR. TOMKINS: At 10 hours, we haven't used
7 the CST nearly at all.

8 MEMBER STETKAR: Right.

9 MR. TOMKINS: It's pretty much full.

10 MEMBER STETKAR: You had two minutes on the
11 CST at time zero to two minutes. Then it gets too hot
12 for the temperature. I think it's the bearings, isn't
13 it?

14 MR. MOOKHOEK: Yes, it is. And we shift to
15 the CST. We expect to stay on the CST for, what, 40
16 hours.

17 MR. TOMKINS: 36.

18 CHAIRMAN CORRADINI: Oh, I'm sorry. I have
19 it backwards in my head. Excuse me. Okay. I'm
20 sorry.

21 MR. MOOKHOEK: You good?

22 CHAIRMAN CORRADINI: I'm good.

23 MEMBER STETKAR: Let me ask you a couple of
24 questions. Let me get the easy one out of the way
25 first.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 When you go back to the CST, you got about
2 15 pounds overpressure in the suppression pool at that
3 time. So, the RCIC suction line is pressurized to
4 about 15 pounds.

5 There's a check valve in the line. You're
6 an operator. You know the check valves aren't always
7 a hundred percent tight.

8 There's a check valve in the line that's
9 basically going to put 15 pounds on the disk of the CST
10 suction valve that I'm now asking an operator to open
11 manually.

12 Can they do that, the 15 pounds DP across
13 it? Have you thought about it? I mean, if the check
14 valve is absolutely perfect and it doesn't leak, that's
15 okay.

16 Otherwise I got to shut RCIC down, let the
17 system depressurize and restart it. Now, you have no
18 problems doing that if it works.

19 MR. MOOKHOEK: Not knowing the kind of
20 valves we're talking about right at this point, it could
21 go either way.

22 MEMBER STETKAR: Okay. You have no problem
23 shutting RCIC down and restarting.

24 MR. MOOKHOEK: No.

25 MEMBER POWERS: Remember, RCIC doesn't have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 to be running continuously at that point in time. So,
2 you couldn't -- one option would be to shut it down.
3 Hit the switch.

4 CHAIRMAN CORRADINI: Can I take you back to
5 that? So, you switch RCIC from the CST to the wetwell
6 earlier. And then you switch it back to the CST at 10
7 hours.

8 MR. MOOKHOEK: Correct.

9 MEMBER STETKAR: It switches automatically
10 now. Auto on high wetwell level, your terminology,
11 switches RCIC. It does it before the operator. So,
12 they didn't do it.

13 CHAIRMAN CORRADINI: And that's
14 approximately how many hours in?

15 MR. MOOKHOEK: No, two minutes.

16 CHAIRMAN CORRADINI: Oh.

17 MR. MOOKHOEK: A few minutes.

18 CHAIRMAN CORRADINI: So, it's a very -- it's
19 a very small change in level.

20 MR. MOOKHOEK: Yes.

21 CHAIRMAN CORRADINI: Okay. Got it.

22 MR. TOMKINS: 7.1 to 7.2 or something.

23 CHAIRMAN CORRADINI: About two inches.

24 That's a lot of water though.

25 MR. MOOKHOEK: It happens -- we originally

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 thought that it would take longer. But once we did the
2 MAAP runs, we found it surprised us that it actually
3 changed that fast.

4 So, we run the first part of it on the
5 suppression pool. Then we shift to the CST,
6 essentially, for the longer duration time.

7 CHAIRMAN CORRADINI: Okay. Got it. Thank
8 you.

9 MEMBER STETKAR: I went back and there were
10 a lot of references back and forth to Section 19E of
11 the ABWR DCD, the certified stuff.

12 Section 19E, for reference, is the station
13 blackout without CTG. So, it sounds a lot like this
14 at least as far as RCIC is concerned.

15 The question I had, I'm not a thermal
16 hydraulics guy. So, please listen, Dr. Corradini,
17 sir.

18 In the Section 19 analyses, it said that
19 the CST -- the RCIC would be realigned to the CST about
20 four and a half hours, 4.4 hours into the event. And
21 that the COPS ruptured disks would open about 32 hours
22 into the event.

23 And now, I'm having problems with heat
24 balances because if the temperature gets too high
25 within four and a half hours in the Chapter 19 analyses,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 why do I operate 10 hours before the temperature gets
2 up to 250 here?

3 So, that's like six hours more. But here,
4 my COPS rupture disk opens about 12 hours earlier than
5 the other one.

6 I don't understand what's going on with the
7 heat. Are they completely different analyses?

8 MR. MOOKHOEK: We noticed that, too.
9 Number one, the analysis for the DCD was done with the
10 Terry turbine. They used a different pump in Chapter
11 19.

12 MEMBER STETKAR: And different temperature
13 as far as switchover or -- I assume it was different
14 flow rates.

15 MR. MOOKHOEK: Well, the pump itself and,
16 in fact, (coughing) it assumes that RCIC fails in eight
17 hours. But that was because of --

18 MEMBER STETKAR: Yes, but this is -- I'm not
19 -- okay.

20 MR. MOOKHOEK: Yes, but the pump limit, the
21 limitations on that pump with it being oil cooled,
22 temperature-wise I believe it was -- it couldn't --

23 MEMBER STETKAR: It couldn't get up to 250?

24 MR. MOOKHOEK: Right.

25 MEMBER STETKAR: Okay. That explains the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 shorter -- that explains the shorter time on that, but
2 what about the COPS? Because that's --

3 MR. MOOKHOEK: It surprised us. When we --

4 MEMBER STETKAR: That's just energy.

5 MR. MOOKHOEK: Yes. When we went through
6 and did the MAAP run, in fact, we had -- Toshiba did
7 the analysis for us. And then Jim wound up doing a
8 confirmatory on his own. So, the two separate folks,
9 they came up with 20 hours.

10 MEMBER STETKAR: Came out with the 20 hours?

11 MR. MOOKHOEK: Yes.

12 MR. TOMKINS: I think one thing that may,
13 but I can't prove it, because there isn't enough detail
14 in the DCD to look, but I think that DCD analysis that
15 was done by GE, they had sprays.

16 MR. MOOKHOEK: They used sprays.

17 MR. TOMKINS: They used sprays.

18 MEMBER STETKAR: Oh.

19 MR. TOMKINS: That's how they kept the
20 pressure down. They didn't say it.

21 MEMBER STETKAR: Yes, they certainly didn't
22 say it.

23 MR. TOMKINS: If you look at some of the
24 level increases, it's consistent with sprays.

25 MEMBER STETKAR: I didn't look at -- I don't

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 even actually remember if level was in there. Was it?
2 I was looking for levels.

3 MR. TOMKINS: There wasn't level, but
4 there's mass.

5 MEMBER STETKAR: Yes, okay.

6 CHAIRMAN CORRADINI: So, you're getting
7 there from a combination of heating the wetwell up and
8 essentially just adding more incompressible fluid to
9 the system to pump out the pressure until it started
10 opening at 20 hours.

11 MR. MOOKHOEK: Essentially, we don't cool
12 down the air space, yes.

13 CHAIRMAN CORRADINI: I'm sorry?

14 MR. MOOKHOEK: We don't cool down. We
15 don't spray.

16 MEMBER STETKAR: You're saying you believe
17 they were spraying it.

18 MR. TOMKINS: It's our suspicion.

19 MEMBER STETKAR: That's a big difference.

20 MR. TOMKINS: It is a big difference.

21 MR. MOOKHOEK: But in our case, having COPS
22 go earlier is better.

23 MEMBER STETKAR: Oh, yes. I'm just -- what
24 I'm trying to understand is what uncertainties there
25 are in these times, because times are kind of important

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 on this.

2 And if it's uncertainties because of one
3 person doing an analysis under some assumptions and
4 another person doing nominally, you know, the same
5 analysis under somewhat different assumptions, if you
6 get, you know, the difference of 20 hours versus 30,
7 whatever it was, 36 or 32 hours, you're saying that you
8 believe that there was something fundamentally
9 different going on in that other --

10 MR. THOMAS: We did not try to match that
11 analysis.

12 MEMBER STETKAR: Yes.

13 MR. THOMAS: We prepare our own inputs and
14 own model for that analysis.

15 MEMBER STETKAR: Okay. Okay.

16 CHAIRMAN CORRADINI: Keep on going.

17 MEMBER STETKAR: That's a good story.

18 CHAIRMAN CORRADINI: Keep on going.

19 MR. MOOKHOEK: So, again, we expect COPS to
20 operate at about 20 hours to start cooling containment.
21 The design-basis flood dissipates to below grade level
22 at 20 hours. So, at 20 hours we have access around the
23 power bar.

24 We expect the offsite equipment to be at
25 the staging area in 26 hours. 24 hours is what they

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 guarantee. It may be a little sooner, it may be a
2 little, you know, before that.

3 We have not yet selected the staging area.
4 We expect it to be in Bay City. We --

5 MEMBER BLEY: We're just a little -- you got
6 to keep them out until the water is gone.

7 MR. MOOKHOEK: Correct.

8 PARTICIPANT: For that one scenario.

9 MR. MOOKHOEK: For this scenario, we need
10 to keep them out until the water is gone. We allowed
11 six hours to get that equipment from Bay City to the plant
12 and essentially hook it up.

13 Once we have it hooked up, we'll actually
14 start those generators. We'll power two of the class
15 load centers. We'll start ventilation, which will
16 start battery exhaust fans. And then we'll start
17 battery chargers.

18 Once the battery chargers are back on, we
19 can go through a process to restart the computer system.

20 Again, none of these procedures have been
21 written yet. The detail is not there as to how we would
22 go do that. But having been through a deenergization
23 of a Class 1E bus for a couple of reasons, it is a
24 deliberate action on how you bring that power back.
25 And I would expect that's the way you would do it.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Again, at this point we still have no AC
2 power. We're working on DC power. So, we wouldn't
3 expect a lot of actuation, shall I say, because there's
4 still no AC power.

5 Once we ever get AC power back, that's
6 going to be, again, very challenging and deliberate as
7 to how you --

8 MEMBER STETKAR: You have 480 volt AC power.

9 MR. MOOKHOEK: On the load centers only.
10 So, we're picking up those load centers and the MCCs.

11 MEMBER STETKAR: And some MCCs, which have
12 vales in it that will move.

13 MR. MOOKHOEK: Right. Yes.

14 MEMBER STETKAR: Or could move.

15 MR. MOOKHOEK: Could move. Like I said,
16 none of those procedures, those implementing
17 procedures have been written.

18 MEMBER STETKAR: Yes.

19 MR. MOOKHOEK: Once we get the battery
20 chargers up and running, one of the next major things
21 would be, you know, I've got ventilation. Now, we'll
22 operate it in smoke purge. There's still no cooling
23 other than smoke purge and straight through
24 ventilation. We'll look at shift in command and
25 control back to the main control room.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 At any time during the event we can
2 initiate makeup to the spent fuel pool with ACIWA. It
3 will actually be running initially. That diesel fire
4 pump will start on the loss of AC power and it will just
5 be sitting there recirc'ing the fire water storage
6 tank.

7 We will be doing the valve lineups to shift
8 to ACIWA earlier in the event than it's actually needed.

9 Next slide. So, at the time we get the
10 offsite -- get into Phase III, we'd still be on RCIC.
11 We expect to shift to ACIWA when necessary and we
12 deplete the water in the CST.

13 Will restore normal AC service. That will
14 be one of the major things that the maintenance crews
15 will be working on is to get a diesel back or get one
16 of the CTGs back.

17 Again, we talked a little bit about ACIWA.
18 It's got a minimum of 36 hours of fuel supply, but
19 there's several diesel fuel oil storage tanks in close
20 proximity to the fire protection system and each one
21 of those tanks holds thousands of gallons of fuel. And
22 we have a portable pump and generator staged in two of
23 the diesel rooms to transfer fuel oil to the ACIWA.

24 For extremely long duration if we still
25 don't have any issue or have any success in getting AC

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 power back, we can actually -- we will be putting in
2 a permanently mounted subsurface crosstie between the
3 fire protection system and the Unit 3 ultimate heat sink
4 basin.

5 So, we want to be able to shift that ACIWA
6 pump to that 16 million gallons of water that's sitting
7 in the ultimate heat sink if necessary.

8 We also obviously since the site will be
9 accessible at that time, we would have the capability
10 of bringing in tanker trucks as an alternate.

11 We will keep the spent fuel pool filled as
12 needed. Once we get normal AC power, we will be able
13 to restore normal cooling functions and reestablish the
14 normal ECCS systems.

15 Next slide. This event had time critical
16 steps. And I'll save time. "Critical" is kind of
17 tongue in cheek, because there's a lot of margin here,
18 but we're going to write the procedure such that in 30
19 minutes they declare the ELAP and go into the event.

20 That gives us 30 minutes to do the load shed
21 and to shift command and control to the RSS system.

22 MEMBER STETKAR: So, there's going to be
23 a lot of people running around the plant in that
24 30-minute time period.

25 MR. MOOKHOEK: Yes and no, yes. The nice

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 thing about the ABWR is the way it's designed, the RSS
2 has its transfer switches right there. We can enable
3 its equipment right there.

4 The load shed on the batteries essentially
5 turns off the computer systems. So, what I used to
6 experience with a PWR on an analog system running around
7 and turning all those switches, we really don't have
8 to do a lot of that with this design.

9 MEMBER STETKAR: When I say that, you know,
10 it's a bit -- but you're basically relocating your
11 license crew and the supervisors to the RSS.

12 MR. MOOKHOEK: Supervisor and a reactor
13 operator.

14 MEMBER STETKAR: Yes. At the same time,
15 sending out a couple of local operators to do the load
16 shed, and another guy to go to the RCIC Room.

17 MR. MOOKHOEK: Correct.

18 Next, please. In developing this plan, we
19 did use MAAP runs. We actually also went to the
20 simulator in Charlotte. Toshiba does have an ABWR
21 simulator.

22 We went over and to the best extent
23 possible, we had to override and pull some things, but
24 we tried to run this scenario. And we were able --
25 successful enough in doing that to realize that from

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 an operator's standpoint, this is not a very
2 challenging event.

3 This is slow-moving. It takes a fair
4 amount of time to pressurize and depressurize and to
5 fill and blow-down. So --

6 MEMBER STETKAR: But I'll come back to Dr.
7 Bley's statement that that's fine standing around a
8 simulator where the ceiling hasn't fallen in or, you
9 know, half the site is washed away.

10 MR. MOOKHOEK: I agree.

11 MEMBER STETKAR: These events aren't going
12 to happen that way where it's a fairly non-interesting
13 event.

14 MR. MOOKHOEK: There will be a lot going on
15 and there will be a lot of stress, but the thing that
16 surprised me is that it doesn't occur really quickly.
17 The BWR gives you -- it's kind of forgiving in that event
18 more so than a PWR.

19 MR. THOMAS: We were concerned with how
20 fast is an operator going to have to start RCIC? How
21 fast is the depressurization? How fast is the vessel
22 going to be blowing down? How fast is it going to pump
23 up? Are we going to be scurrying around?

24 And, quite frankly, I don't want to
25 oversimplify this thing, but it was kind of like

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 watching grass grow on the simulator.

2 It's a very slow event in terms of how
3 quickly do you need to put people in a place to respond
4 to it. There's adequate time to perform these actions.
5 And that was our purpose in going to the simulator to
6 check the timing on some of the operator events.

7 MEMBER POWERS: When you look at these
8 analysis deals, I'm thinking particularly in MAAP, this
9 isn't a very challenging MAAP, very hard, because it's
10 mostly moving liquid backwards and forwards, but still
11 it kind of has its own peculiarities.

12 Did you perturb it a little bit to see, for
13 instance, you said I'm going to stay on the CST for a
14 couple of minutes and then I'm going to switch to the
15 sump, you know? How confidently does MAAP give you
16 that number of a couple of minutes?

17 Is it two minutes plus or minus 30 seconds,
18 or two minutes or five minutes kind of range sort of
19 thing?

20 MR. THOMAS: I would say we ask questions
21 about the folks who did the MAAP analysis on those
22 things that we felt were crucial to the analysis.

23 MEMBER POWERS: Yes.

24 MR. THOMAS: And, quite frankly, we didn't
25 find anything in there that was particularly alarming

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 in terms of what if it's this or what if it's that. Does
2 it make any difference into how we build the scenario?

3 We challenged it in that regard. But in
4 terms of doing iterative runs to test it for different
5 results, we didn't do too many of the --

6 MEMBER POWERS: But it's not -- it's not
7 pressing the -- it's not pushing the part of the code
8 that's uncertain, because it's just moving hot water.

9 MR. HEAD: Do you really think that two
10 minutes is important? That little swap are really
11 almost irrelevant.

12 MEMBER POWERS: I'm using that just as an
13 example --

14 MR. HEAD: I understand.

15 MEMBER POWERS: -- of, you know, when you
16 rely -- any time you're relying on a computer code like
17 MAAP, I mean, it's a systems level code. It has a swap
18 and it's better at predicting trends than it is --

19 MR. THOMAS: We did a few hand calculations
20 to check some things that we thought, you know, does
21 this give us the right answer?

22 MEMBER POWERS: Yes.

23 MR. THOMAS: Do we -- it seemed reasonable,
24 but we did not run a bunch of iterations to challenge
25 that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER POWERS: I mean, it's not clear.
2 You get into the hard wired part of MAAP on this. If
3 anything, it's just moving hot water.

4 Similarly on your simulator runs, did you
5 perturb your scenario at all?

6 MR. THOMAS: Yes. I had fun with that.

7 MEMBER POWERS: Well, it's not fun. It's,
8 again, when you take this thing and say everything is
9 dead, now what do I do? Okay. Well, that's one
10 scenario.

11 Now, what if only half of it is dead?
12 That's a very different scenario there. And that's the
13 scenario that can lead to operator confusion.

14 MR. THOMAS: Right.

15 MR. HEAD: We were kind of limited on the
16 simulator capabilities. It didn't have the full plant
17 model.

18 MEMBER POWERS: Yes. I mean, that's the
19 kind of stuff you're going to have to think about when
20 you write your procedures.

21 MR. HEAD: Well, we will have a full
22 plant-specific simulator at that time, too, that we
23 will do that.

24 MEMBER POWERS: Right. Only some fraction
25 of it is dead. That's the hard, I mean, just coming

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 up with all those different possibilities.

2 MR. THOMAS: And by "some fraction," you
3 mean some fraction of the -- from the electrical
4 capability?

5 MEMBER POWERS: Well, some fraction of X.

6 MR. THOMAS: Some intermediate event.

7 MEMBER POWERS: Something not quite as bad
8 as bad.

9 MR. HEAD: Right. But at some point in time
10 you have to say, okay, am I in ELAP or not? That's a
11 very important --

12 MEMBER BLEY: And that's kind of where Dana
13 is. Can we get in a spot where it's hard to decide?
14 Are there some sequences of failures?

15 MR. HEAD: I don't think so.

16 MEMBER BLEY: The general one we think about
17 is pretty clean, but --

18 MR. HEAD: I don't think so. I mean, it's,
19 you know, that will be a significant moment if all three
20 diesels and your CTG and another CTG are not working.
21 I think the decision will be pretty clear.

22 If a diesel is working --

23 MEMBER POWERS: Then everything --

24 MEMBER BLEY: In another world, all of them
25 are working except one, and one is working, but the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 breakers aren't quite working right and you can't get
2 the power where you want it, you know, that will look
3 different.

4 MR. HEAD: It will.

5 MEMBER BLEY: And you might not want to go
6 here.

7 MR. HEAD: We wouldn't go here under those
8 circumstances. It would go somewhere else.

9 MEMBER BLEY: Well, back to where Dana was
10 on the MAAP and the simulator. The simulator and MAAP
11 kind of look alike in this scenario?

12 MR. THOMAS: They did. We looked at some
13 of the timing of the blow-down and depressurization and
14 refill events and they were certainly compatible.

15 MEMBER POWERS: We kind of expected it.
16 We're just moving hot water.

17 MR. MOOKHOEK: Next slide.

18 PARTICIPANT: If it's not chemistry, it's
19 not interesting.

20 PARTICIPANT: People doing things.

21 MR. MOOKHOEK: People in front of the
22 simulator. We were in dire straits there. Scott was
23 running it.

24 (Laughter.)

25 (Comments off the record.)

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: You're getting close to
2 the end here. So, let me ask you one thing. Getting
3 the -- blowing the thing down so you can get ACIWA
4 working is pretty important to the basic strategy.

5 You hook up nitrogen bottles to --
6 everything I've read as the SRVs on the drawing, it's
7 specifically to eight of the 18 valves that are ADS
8 valves, right? Those are the only ones you can --

9 MR. MOOKHOEK: Two banks of four.

10 MEMBER STETKAR: Two banks of four, but only
11 the ADS valves.

12 MR. MOOKHOEK: Yes.

13 MEMBER STETKAR: Okay. The operators then
14 know that they're the only ones. I guess they would
15 try to open the other ones and they wouldn't work, but
16 --

17 MR. MOOKHOEK: And the way we ran the
18 scenario, we just opened one valve.

19 MEMBER STETKAR: Okay.

20 MR. MOOKHOEK: And one valve does it. It
21 will depressurize us to the point where ACIWA works and
22 it will keep us depressurized.

23 MEMBER STETKAR: You got to hold it open?

24 MR. THOMAS: I don't think they have control
25 functions from the RSS for anything other than the ADS

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 valves. Those are the only valves they can operate.

2 MEMBER STETKAR: But nothing --

3 MR. THOMAS: Those are the only ones that
4 are over on the RSS.

5 MEMBER STETKAR: Okay. Thanks.

6 MR. TOMKINS: There are three on the RSS.

7 MEMBER STETKAR: Only three?

8 MR. TOMKINS: Three on each. There's an A
9 Panel and --

10 MEMBER STETKAR: Okay. Thank you.

11 MR. MOOKHOEK: So, we think that the -- go
12 back one. We think we maintained the key safety
13 functions that 12-06 asked us to do with core cooling,
14 containment and spent fuel pool cooling.

15 And, again, as I said earlier, the plan we
16 wrote doesn't credit or address a lot of the
17 defense-in-depth that we've also added; the additional
18 pumps, the additional water, et cetera.

19 Okay. Next one. We believe we are
20 self-sufficient for more than 36 hours, Phase I. In
21 fact, we've got enough fuel and battery capacity to go
22 out to 72 hours if we had to.

23 But in the plan, we haven't really credited
24 anything other than the Division I battery even though
25 we have the capability to cross-tying all four. That's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 it.

2 CHAIRMAN CORRADINI: Questions from the
3 Committee.

4 MEMBER BROWN: How long does it take to shed
5 loads?

6 MR. MOOKHOEK: Less than 30 minutes.

7 MEMBER BROWN: Okay.

8 MR. MOOKHOEK: You've got --

9 MEMBER BROWN: How many people do you need
10 to do that to do it in less than 30 minutes?

11 MR. MOOKHOEK: Two.

12 MEMBER BROWN: Two, okay.

13 MR. MOOKHOEK: The majority of it is right
14 in the battery rooms in the Control Building. There
15 is another panel out in -- so, for Division III and IV
16 we're basic -- we're going to just open the battery
17 breakers to shed those loads. For Division II and
18 Division I, we will also shed specific loads.

19 So, we'll kill the computers off of those
20 invertors, but then there will also be a couple other
21 switches that we'll have to turn out in the Reactor
22 Building.

23 So, that's why I say two guys. One to do
24 the Control Building, one to do the Reactor Building.

25 CHAIRMAN CORRADINI: Other questions,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Pete.

2 MEMBER RICCARDELLA: I guess I question the
3 logic of this whole evolution. I mean, if you had an
4 operating plant with the standard complement of
5 emergency diesels and they said, well, to address this
6 event I'm going to go out and I'm going to install a
7 combustion turbine generator that's qualified to all
8 the newly-defined NTTF 2.0 external hazards, wouldn't
9 we consider that an effective mitigation strategy?

10 And, yet, here STP has that already and
11 they have to ignore it. I think it stems from that
12 basic NEI 12-06 assumption of a non-mechanistic loss
13 of all AC power.

14 MR. MOOKHOEK: Correct.

15 MEMBER RAY: Well, it may stem from the
16 Agency's statement originally.

17 MEMBER RICCARDELLA: I guess maybe was
18 12-06 developed for operating plants, or it's applied
19 to both operating plants and new --

20 CHAIRMAN CORRADINI: By guidance it's
21 applied to both.

22 MEMBER RICCARDELLA: Huh?

23 CHAIRMAN CORRADINI: By guidance it's
24 applied to both.

25 PARTICIPANT: But it was developed for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 operating plants.

2 MR. HEAD: That's why, you know, basically
3 our presentation was split the way it was. You heard
4 the first half of what ABWR - STP ABWR is capable,
5 including the CTG.

6 But as part of our licensing process, we
7 needed to address FLEX as written. And we think we've
8 done that, too.

9 MR. THOMAS: It goes to the last bullet is
10 defense-in-depth. I'm not going to argue with 12-06.
11 It sets the rules and we follow those guidelines. But
12 as I mentioned, CTG is an incredibly significant
13 component in the plant.

14 We have enhanced its capabilities even
15 though we're not taking credit for it. And that
16 provides us, I believe, sufficient and considerable
17 defense-in-depth against --

18 MEMBER RICCARDELLA: Put it on wheels?

19 (Laughter.)

20 MR. THOMAS: I did not pay him to make that
21 remark.

22 (Comments off record.)

23 CHAIRMAN CORRADINI: Other questions?

24 (No response.)

25 CHAIRMAN CORRADINI: Okay. So, let's take

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 a break --

2 MR. HEAD: Can I ask a question, I guess.
3 I'm sorry.

4 CHAIRMAN CORRADINI: You're welcome to ask
5 a question.

6 MR. HEAD: Do we need to have -- was there
7 any follow-on questions on the 480 volt/4160 now that
8 we've seen the whole --

9 MEMBER STETKAR: Yeah, it still bothers me,
10 but that's just me.

11 MR. HEAD: Okay. All right.

12 MEMBER RAY: Yeah, I didn't know you were
13 going to cut it off. I was going to make a comment if
14 it came to me.

15 CHAIRMAN CORRADINI: Well, I'm not going
16 around the table. I'm just asking if you have
17 questions at this point before we take a break.

18 MEMBER RAY: Well, I want to say something
19 about that topic though.

20 CHAIRMAN CORRADINI: Okay.

21 MEMBER RAY: Many, many years ago long
22 before any of this stuff that we're talking about today,
23 we wound up deciding we wanted to have the ability to
24 cross-connect two units electrically and there was a
25 big controversy in the Agency about precipitating a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 fault so that you've lost both units instead of just
2 one. But leaving that aside, the debate went to 4160
3 versus 480 volt.

4 And we wound up by John suggesting
5 connecting -- cross-connecting with 4160. It's a
6 manual cross-connect so that it wasn't -- it had to be
7 manually implemented with cables on reels because
8 people were so concerned about creating a two-unit
9 fault sequence.

10 But there was an awful lot of feeling that
11 it ought to have been a 480 instead of 4160 because of
12 the concern with energizing a cross-connection that you
13 make up like that to a dead set of 4160 volt buses. The
14 feeling was 480 should carry you through the event and
15 it was much less risky.

16 Like I said, we went ahead and did it at
17 4160 anyway, but it is an issue that people have
18 discussed before.

19 And I don't think it's -- I was thinking
20 about it since John made his comments. I don't think
21 it's something that you don't want to reflect on
22 carefully, because we had a big debate about it and
23 decided to do it at 4160 because of the reasons that
24 he said, which is we could power pumps that we couldn't
25 operate at 480.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 But it didn't experience a lot of debate
2 because people thought, no, no, no, you don't want to
3 energize a manual connection at 4160 into a dead plant.
4 So, for what it's worth, it's been discussed before.

5 CHAIRMAN CORRADINI: Other questions.

6 (No response.)

7 CHAIRMAN CORRADINI: Okay. We will now
8 take a break until 3:35.

9 (Whereupon, the proceedings went off the
10 record at 3:22 p.m. for a brief recess and went back
11 on the record at 3:35 p.m.)

12 CHAIRMAN CORRADINI: Okay. Let's get
13 started. Mr. Foster is going to lead us through this.

14 MR. FOSTER: Yes, sir.

15 CHAIRMAN CORRADINI: Okay.

16 MR. FOSTER: Hello. My name is Rocky
17 Foster. I'm the project manager for South Texas
18 Project COL Fukushima mitigative strategies submittal
19 and staff review.

20 Let me first start off by saying I'd like
21 to thank the Subcommittee for this opportunity to
22 present the staff's review on this topic.

23 I do speak very quickly and I do move the
24 slides very quickly, but I want to allow you -- allow
25 the Subcommittee at any time to stop me and ask your

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 questions.

2 A lot of the material that's in these
3 slides we've already gone through with the south Texas
4 presentation.

5 So, I don't want to slow you up in that
6 process, but I want to provide you with ample time to
7 ask any questions that you may feel you need to ask.

8 Okay. So, with that, like I said, I'm the
9 project manager. Tom Tai is our lead project manager
10 for South Texas. He is on leave right now.

11 And our technical review staff, we've got
12 about seven or eight different branches that were
13 involved in the review process. So, we have a lot of
14 different groups having to weigh in to look at and
15 review what they gave us.

16 Again, this is NTF Recommendation 4.2 for
17 mitigative strategies. We'll go through our
18 background slides using the sequence of events and
19 things that happen. The SECY paper documents went
20 before the Commission, back and forth to the industry.

21 I'd like to bring your attention to
22 SECY-12-0025. And in that SECY paper, the orders were
23 proposed, but also the RAIs that were associated with
24 the different Tier 1 recommendations were put out for
25 the staff then to issue to the applicant.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Also within that paper was NRO's position
2 of what they were applying for the orders to our COL
3 and our design certification reviews.

4 CHAIRMAN CORRADINI: You've all of a sudden
5 became magnified and amplified, sir.

6 MR. FOSTER: We've just gotten bigger.

7 CHAIRMAN CORRADINI: I guess so.

8 (Comments off record.)

9 MR. FOSTER: So, back in the spring of about
10 2012 we started issuing the initial RAIs in NINA. Then
11 came back June 25th of 2012 and started responding.
12 And we've already presented Recommendation 2.1, 7.1
13 and 9.3 to the ACRS April 9th of this year.

14 Now, also as I go through the slides, I will
15 summarize and bring up significant points. But if you
16 want to get into further discussion, please stop me at
17 any time.

18 Okay. What the staff used to review the
19 submittal, the response that the applicant gave us, we
20 used the NEI Order EA-12-049. This was the guidance
21 of the ISG-2012-01 endorse which is NEI 12-06.

22 Basically, the order states that you've
23 got to mitigate an extended loss of AC power and loss
24 of normal access to the ultimate heat sink and provide
25 adequate capabilities for core cooling, containment

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 function and spent fuel pool cooling.

2 The order specifies a three-phased
3 approach using installed equipment, portable onsite
4 equipment and then offsite resources. And it
5 specifies the equipment through the life of the
6 mitigative strategies must be reasonably protected
7 from external events.

8 These are the different review areas that
9 the staff looked at and that we asked questions for.
10 The phased approach, ~~at different~~ core cooling,
11 containment functions, ~~cooling~~, spent fuel pool
12 cooling, power supplies, water/fuel **supplies**,
13 ventilation, basically a whole laundry list that we
14 could think of things.

15 And then we also used our licensing
16 condition to make sure that we -- the applicant -- or
17 the licensee then would address certain aspects that
18 could not be done during the licensing.

19 A phased approach. We had a follow-up RAI
20 to one of our initial RAIs on mitigative strategies in
21 which South Texas responded that they propose a
22 two-phased which they have discussed already with you.

23 Phase I basically going out to the 36-hour
24 point using installed equipment. And offsite
25 resources coming in for the Phase III approach at 36

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 hours.

2 36 hours is significant time according to
3 the NEI guidance document, which requires the 24 hours.
4 Also, we found out, too, that the onsite portable
5 equipment that are available provides the
6 defense-in-depth for South Texas' approach towards
7 mitigative strategies.

8 And they have a -- you get a full laundry
9 list of the installed equipment that they use for credit
10 for the mitigative strategies. Okay. So, as far as
11 -- the staff does find the proposed approach
12 acceptable.

13 Core cooling. If an ELAP occurs during
14 Modes 1, 2 or 3, as you know, RCIC automatically starts.
15 It's originally lined up with the condensate storage
16 tank within two minutes it automatically stops over to
17 the suppression pool depending on high level alarm for
18 it.

19 We did multiple audits looking at the MAAP
20 codes. Those started back in August of 2012. We had
21 five or six audits on different applications for the
22 application itself.

23 MAAP code, we did come up with a
24 justification that it did extend the RCIC operations
25 from the eight hours that were in the design cert to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the 36 hours that was in the mitigative strategies FLEX
2 plan.

3 And that Phase III core cooling then can
4 be swapped over to the -- I call it the aqua system,
5 but I guess they call it the ACIWA system.

6 I'm from South Dakota. So, it's a little
7 bit different in terminology. But, yes, basically
8 when RCIC starts losing steam power, you've got to do
9 -- okay, what are you going to do for core cooling? And
10 that's when the ACIWA system comes into play.

11 If the ELAP occurs during Mode 4 or 5, you
12 don't have any steam power. So, automatically the loss
13 of AC, ACIWA system starts up, you can use your ACIWA
14 system to provide your core cooling at that time.

15 Okay. But also, too, you may do
16 depressurization of the reactor pressure vessel using
17 the SRVs as in Mode 4.

18 South Texas Group described the RCIC
19 system pump, which is a steam-driven turbine pump with
20 a mono-block totally self-lubricated, 250 degree
21 limited bearing temperature. And the long-term
22 cooling is required by ACIWA system. And, again, we
23 did use the MAAP codes -- or they used the MAAP codes,
24 which we audited and came to the acceptable conclusion
25 they have given to us.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN CORRADINI: Just I'm sure you've
2 discussed this before, but I don't remember. When you
3 say "audit," you look at the calculations, or perform
4 side calculations? How did you do the audit?

5 Just looked through the input? Look at
6 the results?

7 MR. FOSTER: Yes. We did not -- as far as
8 I know, we did not use calculations ourself. We looked
9 at their calculations that we looked up, up at the
10 Westinghouse Reading Room up in Twinbrook.

11 And, Mr. Gilmer, can you expand on that,
12 please?

13 MR. GILMER: Jim Gilmer, NRO Reactor
14 Systems. Yes, we did do a detailed look at the Toshiba
15 calculation.

16 And in addition, we used the research
17 developed MELCOR model to do our own --

18 CHAIRMAN CORRADINI: Okay. So, you did do
19 site calculations with MELCOR.

20 MR. GILMER: Yes.

21 CHAIRMAN CORRADINI: Okay. That's what I
22 was trying to understand.

23 MR. GILMER: And they're very much in
24 agreement.

25 CHAIRMAN CORRADINI: Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. GILMER: Except we got a little
2 different from the two minutes for the switchover, but
3 insignificant as far as the overall timeline.

4 CHAIRMAN CORRADINI: Okay. I was just
5 curious how you did the audit. Thank you.

6 MR. FOSTER: Thank you. Any other
7 questions?

8 MEMBER POWERS: You'd pretty much be
9 surprised if there were any differences. This is, like
10 I say, flow of hot water.

11 MR. FOSTER: For containment function and
12 ventilation, containment function is controlled or
13 maintained by the use of the COPS system.

14 It's a hardened passive vent system with
15 ruptured disks. They actuate at 90 psig. Vents in the
16 suppression pool to the plant stack. And then it has
17 a radiation monitor that's powered by the Class 1Es up
18 in the plant stack area.

19 COPS remains available throughout Phase I
20 through III and is located in the Reactor Building.
21 Provides containment cooling while ensuring
22 containment structure integrity.

23 CHAIRMAN CORRADINI: You can ask a
24 question.

25 MEMBER STETKAR: Thank you. Back on Slide

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 8, what is the staff's definition of "indefinite"?

2 MR. LI: Our review covers, say, for
3 example, we looked at water supply. It extends to
4 however long the events lasting. So, we in long term
5 we use ultimate --

6 MEMBER STETKAR: I'm sorry?

7 MR. LI: -- heat sink water source which
8 covers up to 30 days. And then after that, we will be
9 able to use the well water which may bring in water from
10 outside. So, that extends to -- well, however the
11 events that ends up to.

12 MR. FOSTER: Member Stetkar, I think you
13 have to look as to how we phrase the actual statement
14 itself. It approaches about the offsite equipment for
15 an indefinite duration.

16 So, if we bring offsite equipment in, it's
17 going to last. You're going to use it to get to your
18 final end point of when you're going to recover from
19 the plant or whatever the next step you're going to have
20 to deal with it.

21 MEMBER STETKAR: The statement was, in
22 particular the design -- this is quoted from the SER:
23 "In particular, the design includes permanent piping
24 to allow the ACIWA system to take suction from the water
25 volumes in the UHS basins and is discussed later in this

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 SER. The calculation confirms that core cooling can
2 indeed be maintained indefinitely in this scenario.
3 Accordingly, the staff concludes that core cooling can
4 be maintained indefinitely." That's a quote.

5 Now, if "indefinitely" means 30 days,
6 that's okay. In my term, indefinitely has a different
7 definition. But if it's 30 days, that's okay. I'm
8 just trying to find out what it actually means.

9 MR. LI: If it's last more than 30 days, that
10 water still be able to --

11 MEMBER STETKAR: Yes, but your conclusion
12 doesn't say that.

13 MR. LI: I think in --

14 MEMBER STETKAR: Your conclusion says
15 that it could be aligned to the UHS, which I know has
16 a 30-day capacity.

17 MR. FOSTER: That's right. UHS --

18 MEMBER STETKAR: 30 days is indefinitely,
19 because what you said is additional activities beyond
20 the UHS.

21 My point is people throw terms around like
22 limiting, bounding, indefinite, beyond design-basis
23 without really being very accurate in about what those
24 terms mean.

25 And why is it important? It's important

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 because the American public reads these things and
2 might have different conclusions about your evaluation
3 of the safety, because they might understand those
4 words differently than what this says.

5 So, if your conclusion is that indeed with
6 the things you looked at they can maintain core cooling
7 for as long as 30 days with no additional actions, it
8 ought to say that. It ought not to say indefinitely,
9 which might be determined by some as many, many, many
10 years.

11 MR. FOSTER: Well, I think if you have
12 enough tanker trucks and enough fuel oil, you could go
13 many, many, many years. I mean, that's what we're --

14 MEMBER STETKAR: But your analysis --

15 MR. FOSTER: You haven't put a --

16 MEMBER STETKAR: Your analysis didn't say
17 they can bring in additional tanker trucks to make up
18 to the UHS. It says it can be --

19 MR. LI: I believe in --

20 MEMBER STETKAR: You might believe it. The
21 analysis simply says they can use the UHS inventory to
22 maintain core cooling indefinitely.

23 MR. LI: I believe in the SER we did clarify
24 that.

25 MEMBER STETKAR: Did you? Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. LI: It goes beyond the 30 days. The
2 ultimate heat sink water inventory will be able to
3 support up to 30 days. Beyond 30 days use well water
4 and they use the water that you can take from off site.

5 MEMBER STETKAR: I didn't find it in the
6 SER. So --

7 MR. LI: I believe in the SER we have that
8 statement.

9 MEMBER STETKAR: Okay. Thank you. Sorry.

10 CHAIRMAN CORRADINI: That's okay. Now, go
11 back to where you were.

12 MR. FOSTER: Okay. Ventilation. We
13 looked at certain areas that were very critical during
14 the operation.

15 MEMBER POWERS: On Page 32, it says the UHS
16 basin can be filled as needed via a stored well water
17 system or tanker truck.

18 Is that what he's talking about?

19 MEMBER STETKAR: I think that's what he's
20 talking about.

21 MEMBER POWERS: A permanent piping
22 connection to allow suction from the water volume will
23 be installed. That's the last two sentences of that
24 -- it's on Page 32 of 22.2.

25 MEMBER STETKAR: Okay. I'll look it up.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Thanks.

2 MEMBER POWERS: Uh-huh.

3 MR. FOSTER: Okay. To continue on, so
4 ventilation we were concerned about the different
5 conditions in certain areas of the plant to the
6 operations.

7 One was the RCIC Room where the integrated
8 plan actually states that to help with the
9 environmental condition in the room itself, they will
10 go ahead and open up the doorways -- stairwell doorways
11 and also an overhead hatch which will allow for natural
12 circulation. We weighed that against the reference
13 DCD Chapter 3, Appendix 3I.

14 And we also looked at the remote shutdown
15 system room for Phase I and the main control room for
16 Phase III for the heatup analysis. And part of that
17 habitability was that they would also open up stairwell
18 doorways to allow for natural circulation.

19 We weighed that against Table 2D of
20 NUREG/CR-6146, Local Control Stations: Human
21 Engineering Insights.

22 Spent fuel cooling. In spent fuel
23 cooling, they basically -- the approach is to -- the
24 pool has a level of water at a 23-foot point and is
25 allowed, basically, for heat removal to take it down

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 to 10 foot.

2 This is during the first 36 hours of ELAP.
3 They will monitor the spent fuel water level. And
4 then, as you know, they'll use the ACIWA system to use
5 any makeup if the level gets too low or to bring it up
6 to the operating level that they want to have it at.

7 Likes to be maintained at least 10 foot
8 above the top of the fuel racks. And provide makeup
9 water for the system, water for the spent fuel pool.
10 And Phase III -- also go ahead and provide the makeup
11 water to it.

12 Okay. I'll turn this over to you now,
13 Chang.

14 MR. LI: To support the function of RCIC,
15 ACIWA, spent fuel pool cooling, assuming
16 simultaneously ELAP and normal assets to ultimate heat
17 sink, we review that required water sources such as from
18 condensate storage tank, fire water storage tank,
19 ultimate heat sinks. We review the pumps and the
20 valves and associated power and fuel supplies, the
21 piping connections and the reasonable protections for
22 the equipment being relied on for mitigation
23 strategies.

24 So, following that process, I would look
25 in Phase I as applicant already presented. They use

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 their suppression pool, condensate storage tank and
2 then goes into Phase III, use the water from ACIWA
3 system, taking water from fire water storage tank
4 initially.

5 And in the long term, it used water from
6 ultimate heat sink. The ultimate heat sink can be
7 filled as needed via restored well water system or
8 linked truck. That's what we would clarify there.

9 A permanent piping connection to allow the
10 ACIWA system to take suction from the water volume in
11 the ultimate heat sinks will be installed.

12 In the review process, we ask how that
13 connection is being able to connect from ultimate heat
14 sink to the ACIWA systems.

15 They answer the questions and explain that
16 they installed a piping system which is robust,
17 according to what their commitment.

18 And the connections that in the RHR systems
19 provides piping valves that connect ACIWA piping was
20 the RHR Loop C pump discharge piping. Many valve
21 permit any water from the fire water storage tank to
22 the RHR systems.

23 The single ACIWA plan can provide enough
24 flow to maintain the vessel level in both units and
25 still have sufficient approach to provide makeup for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 both spent fuel pool.

2 And we ask them -- well, I think they
3 addressed it in their submittal in terms of their backup
4 pumps as provided. And they have connections outside
5 the Reactor Building. And those backup pumps hook up
6 to the ACIWA to fire truck pumps are trailer-mounted
7 pump.

8 The ACIWA pump is designed with the minimum
9 of 36-hour fuel supplies. And I think they have the
10 pumps and generator that take water from fuel oil
11 systems.

12 The Phase III operator when you transfer
13 diesel fuel, that's using the -- those underground EDG
14 fuel which will protect it from external events that
15 need to be protected.

16 And in the review process, we did ask about
17 the water piping I mentioned before. And we revised
18 the FSAR to reflect this clarification.

19 And then by using all those information,
20 we think they have sufficiently addressed the water
21 supplies, the fuel supplies, the pumps and the valves
22 and all the capabilities and we believe it's sufficient
23 to support these functions, the three safety functions
24 for core cooling, containment and spent fuel pool
25 cooling.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 The Order specifies the equipment being
2 relied on, for example, how those pumps, valves must
3 be protected from external B reasonably protected from
4 external events.

5 And according to NEI 12-06 guidance, these
6 must be designed to be robust. According to NEI
7 guidance that's robust with respect to the seismic,
8 flood, high winds and associated missiles.

9 And the review of the mitigation equipment
10 and protection levels for the external events is set
11 to at the design-basis level. I understand you have
12 lots of questions on that.

13 MEMBER STETKAR: And, yet, these are
14 specifically for things that are worse than that,
15 whatever that is.

16 MR. LI: Well, that --

17 MEMBER STETKAR: Specifically, these are
18 for events that are, by definition, worse than the
19 design-basis level. Protecting them to the
20 design-basis for events that are worse than the
21 design-basis has never made sense to me.

22 MR. FOSTER: Well, then you've got to pull
23 back from that and say, okay, well, how far beyond
24 design-basis do we put that marker at?

25 MEMBER STETKAR: That's a different

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 question. And that's the point of what ought to be
2 being discussed, in my opinion, subcommittee meeting,
3 between the staff and the industry.

4 What level of margin do we need? Level of
5 margin is defined differently for different hazards,
6 perhaps.

7 MR. FOSTER: True. How bad of an
8 earthquake are we looking at, or how big of a flood are
9 we looking at, or -- correct.

10 MEMBER STETKAR: Can you do it
11 probabilistically? That's a different question. The
12 first question is defining the fact that "robust" means
13 I am designed to the event for which, by definition,
14 I will exceed, doesn't make any sense.

15 MR. LI: Yes, this position at the time
16 where we start reviewing the -- would take the position
17 that's established in the rulemaking --

18 MEMBER STETKAR: You took the industry's
19 position in something that they wrote, is what you took.

20 MR. LI: I think the rulemaking --

21 MEMBER STETKAR: You agreed with the words
22 in NEI 12-06 and said, yeah, that's okay.

23 MR. FOSTER: The Agency did take that
24 position, yes, sir.

25 CHAIRMAN CORRADINI: You've walked into

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 generic land. You just happen to be the ones up that
2 we can beat on.

3 MR. FOSTER: If you step back from the
4 situation, okay --

5 MEMBER STETKAR: That's what I'm trying to
6 do, by the way.

7 MR. LI: We understand.

8 MR. FOSTER: With mitigative strategies
9 itself, you can design to certain levels. And you can
10 do this probably fully informed, right?

11 We know with these advance reactors we do
12 have built in margins. They all do in all different
13 areas, okay. That's proof from the studies and the
14 calculations they've done and whatever.

15 But with FLEX, if you can't -- if you don't
16 come to a final definition of how bad the situation is,
17 you can put programs in place to address it using
18 different strategies then.

19 Some equipment will survive. If that's
20 installed, that's great. You have backups to it. You
21 have flexibility of where you have global onsite
22 equipment at. And then provisions in place for offsite
23 resources to get there to assist you to final build a
24 combat of the situation you've got.

25 CHAIRMAN CORRADINI: I think we're just

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 trying to evoke some discussion, because I think at
2 least for this particular case given the fact they've
3 stuck a plant on a site that's a tad more robust than
4 the site requires, gives me a lot of confidence and I'm
5 not concerned about this plant at this site.

6 On the other hand, I think where John is
7 going with this, it's just kind of interesting that at
8 0.13 it all stops. It's not 0.15. It's whatever.

9 MEMBER STETKAR: Yes.

10 CHAIRMAN CORRADINI: I'm doing this so that
11 I can get Pete to say something. Pete.

12 MEMBER RICCARDELLA: If you design to 0.13
13 or a spectrum that goes through a peak ground
14 acceleration of 0.13, you clearly have margin for
15 larger earthquakes.

16 MEMBER STETKAR: And that's my whole point
17 is how much margin for --

18 MEMBER RICCARDELLA: In fact, I mean, if you
19 look at the CEUS plants and the new response spectra
20 that have come out, you've got plants that are a factor
21 of two or three times B have response spectra that are
22 two, and in some cases three times what the original
23 SSE was for the plant. And what are they going to do?

24 I don't think they're going to change
25 equipment. They're going to go back and they're going

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 to do a margin analysis or they're going to do a seismic
2 PRA.

3 MEMBER STETKAR: Nothing wrong with doing
4 that, but I don't see people doing it.

5 MEMBER RICCARDELLA: So, I mean, the fact
6 that they design to the newly-defined site hazard, to
7 me, tells me that they've got the ability to evaluate
8 this equipment to show that while in reality if I really
9 need it, it can take --

10 MEMBER STETKAR: On the other hand if I take
11 this particular site, if I design to 0.13 g, typically
12 what we see a lot of, and there's variability, is that
13 the HCLF capacity when I look at fragilities, is
14 typically around where you design where typical comes
15 out. At least I've seen that.

16 MEMBER RICCARDELLA: What capacity?

17 MEMBER STETKAR: HCLF, high-confidence low
18 probability of failure. One percent probability of
19 failure is -- if you look at typical margins that are
20 built into things, people when they've done the
21 analyses, tend to come out and say, yeah, I mean, it
22 might be higher than -- might be 0.15. Might be 0.17.

23 The median capacity in a -- if I look at
24 the typical uncertainties is about anywhere from
25 two-and-a-half to three times higher than the HCLF

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 capacity.

2 So, if I'm looking at a 0.15 g HCLF
3 capacity, I'm looking at about a 0.4-ish, 0.45 g median
4 capacity, which means there's a 50 percent chance that
5 the thing fails at that capacity.

6 Now, what's my margin? Well, if I were to
7 get a 0.5 g earthquake, there's a 50 percent chance that
8 the stuff designed for 0.13 g would fail.

9 There's a much lower chance that the stuff
10 designed for 0.3 g would fail, but I can't take credit
11 for that stuff. I can take credit for the stuff that
12 has a much higher likelihood of failure.

13 MR. FOSTER: Okay. I think --

14 MEMBER STETKAR: And that's the notion of
15 how much confidence do I have in the margins for the
16 stuff that's on the site.

17 The stuff you're flying -- the stuff that's
18 not on wheels, you know. Use the term "on wheels."
19 The installed equipment. Whether that installed
20 equipment is something like RCIC, is part of the
21 original plant design, or the switchgear that you're
22 plugging stuff into, or whether the installed equipment
23 is -- well, ACIWA is part of the original plant design
24 here, but other installed, fixed equipment that might
25 be part of a strategy, not on this plant.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. FOSTER: Okay. Can we allow Mr. Bowman
2 a chance to speak and maybe provide some insight on
3 12-06?

4 CHAIRMAN CORRADINI: We'd welcome it.

5 MR. BOWMAN: Thank you. I'm Eric Bowman.
6 I'm a special advisor in the Lessons Learned Division
7 in the Office of Nuclear Reactor Regulation.

8 Some of the background on why the levels
9 were set at the design-basis level is really related
10 to the direction we got from the Commission in
11 particular in the SRM to COMSECY -- or to SECY-11-0093
12 in which the Commission told us to pursue the NTF
13 Recommendation 1, which had included the establishment
14 of an extended beyond design-basis limit independently
15 of all the other recommendations, including
16 Recommendation 4.2 which resulted in the Order
17 EA-12-049.

18 Tomorrow the full committee will be
19 hearing a presentation on the integration of the
20 reevaluation of at least the flooding hazard under
21 Recommendation 2.1 activities with the Recommendation
22 4.2 EA-12-049 activities and the associated rulemaking
23 in which we'll be looking at seeking Commission
24 affirmation that the end result should be setting the
25 level of protection for the FLEX equipment and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 mitigating strategies to the reevaluated hazards.

2 But we were constrained by the direction
3 that we were provided by the Commission as to what we
4 could do for setting the necessary hazard levels.

5 MEMBER STETKAR: I happen to be reading that
6 SRM right now and I don't actually see --

7 MR. BOWMAN: It's the last paragraph that
8 says, pursue Recommendation 1 separately. And you
9 have to go to SECY-11-0093 itself to see -- Step 1.1
10 of Recommendation 1 was the one that recommended that
11 the Commission draft a policy statement for an
12 integrated risk-informed defense-in-depth policy
13 including specifically extended beyond design-basis
14 regulations.

15 MEMBER STETKAR: Okay. Thanks. It's on
16 the record. It's a stretch to me, but that's okay.

17 MR. FOSTER: Any other questions?

18 MEMBER STETKAR: No.

19 MR. FOSTER: Okay. We'll continue on then.

20 CHAIRMAN CORRADINI: Okay. We got out two
21 cents in.

22 MR. FOSTER: Yes, sir.

23 MR. LI: We review the -- verify that the
24 installed RCIC, ACIWA and the seismic qualified and
25 compare with robust structures with adequate

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 protection against --

2 MEMBER RAY: You said "adequate." I don't
3 think you meant that, did you?

4 MR. LI: "Adequate protection" is the
5 wording that's put --

6 MEMBER RAY: I know. I'm just looking at
7 the screen up here. Do you mean to say adequate
8 protections? It says "reasonable protection" up
9 there.

10 MR. LI: Reasonable protection, yes.
11 Sorry.

12 MEMBER RAY: That's an important
13 difference.

14 MR. LI: Yes. Reasonable protection.

15 And we verify that those ACIWA valves,
16 those connections in RHR loops and the batteries are
17 in the units. That's either Seismic Category 1
18 structures are the enhancement that the applicant
19 committed to view to be robust.

20 MEMBER STETKAR: Can you guys do me a favor
21 when you write the final SER, to avoid the confusing
22 term "Seismic Category 1"? Because in the first
23 bullet, it is 0.3 g Seismic Category 1. And then in
24 the third bullet it's 0.13 g Seismic Category 1.

25 That's just -- it's very, very confusing

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 to someone who reads this. If I were to read this
2 looking at the bullets, I would presume that the UHS
3 is designed to precisely the same seismic acceleration
4 as the Reactor Building, and that's simply not true.

5 MR. FOSTER: Okay.

6 MEMBER STETKAR: So, either always use the
7 term "site-specific" when you're talking about the
8 site-specific, but just don't throw around -- and it's
9 not just done on this slide. It is done actually in
10 the SER.

11 The justification is this is a Seismic
12 Category 1 structure. These are Seismic Category 1
13 equipment. There's two different Seismic Category 1s
14 for this plant.

15 MR. LI: Thank you. That was a good
16 comment. Going to change that.

17 And ultimate heat sink is Seismic Category
18 1. That's in the design. Based on all these
19 verifications confirmed, the staff finds the equipment
20 being relied on for the mitigation would be reasonably
21 protected from external events.

22 (Comments off record.)

23 MR. FOSTER: Okay. The power supplies for
24 the submittal as NINA presented earlier, we have four
25 Class 1E 125 DBC divisions, one battery per division.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 One non-Class 1E 120 volt DC battery, and another one
2 non-Class 1E 250 volt DC battery.

3 Phase I, the only power source that they
4 take credit for are the DC power stations, not the CTGs
5 as was earlier discussed. And with the use of load
6 shedding, their initial approach on this was that the
7 battery life will last for at least 36 hours.

8 This load shed the battery divisions to
9 maintain core cooling, containment and spent fuel pool
10 cooling.

11 Phase III, they'll bring in the offsite
12 resources which we already discussed the differences
13 on the different generator system they could bring in.

14 Their approach is the 480 volt 1500 kW
15 diesel generator will be brought in. And that's
16 sufficient enough to power the loads they need for Phase
17 III.

18 In Phase I, the only power source, as they
19 said, the only things that are available are the Class
20 1 120 volt DC batteries. The staff reviews the battery
21 size calculations to confirm the adequacy of power
22 supplies.

23 We performed five different audits to
24 support this portion of the review. They confirmed the
25 battery sizing was performed in accordance with the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 IEEE Reg Guide 1.212.

2 The battery duty cycle, the loads of
3 corresponding timeline. They ensured the minimal
4 battery valve voltage is met. The environmental
5 conditions of the battery room, and the list goes on
6 and on, on different things in the area that we looked
7 at.

8 What it comes down to is they assured the
9 batteries could support a duty cycle greater than the
10 eight-hour qualifications.

11 MEMBER BROWN: Why is it only eight if you
12 need 36?

13 MR. FOSTER: I'll defer that to staff.

14 MEMBER BROWN: She's leaving.

15 (Laughter.)

16 MS. MARTINEZ-NAVEDO: Yes. My name is
17 Tania Martinez from the Electrical Engineering Branch.
18 The eight-hour mark is the actual duty cycle for a
19 battery. And it's the basis for 485 battery sites in
20 calculation. That's the example.

21 Not to say that the sizing calculation
22 method can be used for extended duty cycles, but the
23 operational experience for the U.S. is based on the
24 eight-hour duty cycle.

25 That's why that eight-hour duty cycle

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 number is used, but the calculation method can be used
2 for longer duty cycles.

3 MEMBER BROWN: I know, but they're taking
4 credit for 36 hours.

5 MS. MARTINEZ-NAVEDO: Correct.

6 MEMBER BROWN: And you say all you audited
7 for was to make sure they would make greater than eight
8 hours, which seemed to be a little bit inconsistent.

9 The second thing, I looked at your audit
10 reports and in there you said, you know, I looked at
11 even the June, whatever, 2014 and it said you reviewed
12 all their stuff.

13 Did you all independently do the
14 calculation against the IEEE standard for how they came
15 to their conclusions with their battery profile -- or
16 with their load profile?

17 MS. MARTINEZ-NAVEDO: We audited their
18 calculation and it's basically -- it's a tabulated
19 version of the calculation that follows Appendix A of
20 485.

21 We did go line by line because you have to
22 break the duty cycle by the loads, depending on the
23 timeline. So, we did go one by one to verify that the
24 duty cycle or the battery capacity could cover the
25 length of the duty cycle and the demands of the loads.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So, we didn't do the calculation
2 ourselves, but we did look at all of the numbers in their
3 tabulated calculation.

4 MEMBER BROWN: Okay. There's two parts in
5 their FSAR. Section 1.18.4 is their discussion of the
6 loading considerations.

7 They say as discussed in 2.4, the ability
8 of the division of one safety-related battery was
9 evaluated to support the required loads, et cetera, et
10 cetera.

11 And then they go through a bunch of
12 paragraphs, but they never say 36 hours anyplace in the
13 FSAR that they needed a sizing, they needed to size the
14 batteries in the extended period for -- I don't find
15 36 hours anywhere in here other than one specific
16 reference to non-Class 1E batteries to power radio
17 communications for 36 hours.

18 MR. FOSTER: In Part 2, Chapter 1, Appendix
19 1E.

20 MEMBER BROWN: 1E, yeah. So, you know, I
21 thought their FSAR would have provided a metric for
22 saying since we credit all these, then whatever we do
23 with our batteries -- somewhere in here the 1E batteries
24 should be specified as being able to be covered for 36
25 hours. It's kind of a loose end.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 I went back and looked at Section 2.4.
2 Didn't say anything there.

3 MR. FOSTER: The integrated plant itself.

4 MEMBER BROWN: I looked at the FSAR.

5 MR. FOSTER: Well, the --

6 MEMBER BROWN: The FSAR they modified,
7 they revised the FSAR to cover the need for extended
8 life on the batteries, but they don't talk about what
9 the extended life is -- should be. That's my only
10 point.

11 MS. MARTINEZ-NAVEDO: Yes. And just to
12 clarify, we did --

13 MEMBER BROWN: I understand. I just
14 wondered how fine tuned you went down through the ~~voting~~
15 ~~auditing~~.

16 MS. MARTINEZ-NAVEDO: Okay.

17 MEMBER BROWN: The reason for that is
18 personal experience where we had a contractor who said
19 that they followed an IEEE standard, they calculated
20 X, Y and Z, came to a conclusion.

21 When myself as an independent contractor
22 went back and looked at it, they neglected to use three
23 of the correction factors that were within the IEEE
24 standard, because they didn't think they were relevant.
25 And they ended up with the wrong answer.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So, that's why I ask how detailed your
2 question was. And I'm not familiar with that IEEE
3 standard that much, because I don't have a copy of it.
4 That's why I asked for a level of detail. So, thank
5 you.

6 MS. MARTINEZ-NAVEDO: Okay.

7 MEMBER BROWN: Other than that, it was just
8 a disconnect. The FSAR SR seems to be silent relative
9 -- at least in the 1E, relative to the Class 1E
10 batteries. I couldn't find it.

11 MR. MOOKHOEK: Bill Mookhoek. We actually
12 incorporated by reference the FLEX plan. We consider
13 that as part of the FSAR.

14 MEMBER BROWN: Is that in the FSAR?

15 MR. MOOKHOEK: Yes. Yes, it is.

16 MEMBER BROWN: Where?

17 MR. MOOKHOEK: In Section 4.2, we actually

18 B

19 MEMBER BROWN: 1E 4.2?

20 MR. MOOKHOEK: That's correct -- or 2.4.

21 MEMBER BROWN: 2.4?

22 MR. MOOKHOEK: 2.4 for the FLEX plan.

23 MEMBER BROWN: Okay. I looked at that. I
24 didn't pick that up.

25 MR. MOOKHOEK: And it actually says that the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 detailed scenario, the integrated plan is described in
2 that separate document.

3 MEMBER BROWN: That should be at the
4 beginning?

5 MR. MOOKHOEK: It's -- I don't have a -- it's
6 in one of the paragraphs.

7 MEMBER BROWN: 2.4.

8 (Comments off record.)

9 MR. MOOKHOEK: It's probably after --

10 MEMBER BROWN: I'll look. Go ahead. Go
11 ahead. I know how to look.

12 MR. MOOKHOEK: That was our intention.
13 That plan is actually going to be covered as part of
14 the FSAR and under the same change process.

15 MEMBER BROWN: So, I ought to be able to
16 keyword "incorporated by reference" and find --

17 MR. MOOKHOEK: I don't think we used the
18 word "incorporated by reference." We used "described
19 in the FLEX integrated plan.

20 MEMBER BROWN: Okay. All right. Go
21 ahead.

22 MR. FOSTER: Thank you, sir. Now, we'll
23 turn it over to Mr. Tom Scarbrough for the mechanical
24 part of the review.

25 MR. SCARBROUGH: Thank you. I'm Tom

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Scarbrough. I'm in the Mechanical Branch. We looked
2 at several aspects of their FLEX plan, their pumps and
3 valves, which ones are safety-related,
4 non-safety-related. We asked a series of RAIs that
5 we've done for Vogtle and, you know, other ESBWR, Fermi.

6 What we're doing here was in the first RAI,
7 which was RAI 01.05-24, we asked about the performance
8 requirements for the safety-related,
9 non-safety-related and portable equipment.

10 And the response from NINA, they indicated
11 that safety-related pumps, valves and snubbers used in
12 the mitigative strategy are permanently installed
13 equipment and not relied on to perform functions beyond
14 those credited in design-basis, except for the RCIC
15 suction where they are going to allow the suppression
16 pool temperature to increase up to 250 degrees
17 Fahrenheit, which is the qualification for the RCIC
18 pump bearing. So, that's a limitation that is
19 different than what the original was.

20 So, that's the type of thing we ask for when
21 we ask about is there anything -- even though it's
22 safety-related, there may be some scenarios or aspects
23 of the FLEX response that goes beyond what was currently
24 reviewed and approved as part of the original DCD or
25 FSAR.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So, we have a confirmative item which will
2 track the revision of the RCIC piping expansion
3 calculations for the FSAR for that.

4 For the non-safety-related equipment, the
5 strategy, they are permanently installed and are not
6 relied to perform any functions beyond those already
7 specified in the DCD or the FSAR.

8 Now, for the pumps, there's two portable
9 pumps that are used to transfer the fuel oil from the
10 ACIWA, the ACIWA system, the fuel oil storage tanks up
11 to the B from the diesel fuel oil storage tanks so they
12 can have fuel oil for those -- for the equipment. So,
13 that was the performance requirements in terms of what
14 we evaluated in that respect.

15 And then once we found out where the
16 performance requirements were, we would ask about each
17 type of equipment in terms of how we would qualify
18 tests, you know, what would your process be for that.

19 And so, for RAI 25 we asked about, okay,
20 for safety-related equipment, this will be the RCIC.
21 What's your qualification process? What, you know,
22 what process are you going to use?

23 And they specified that it's indicated in
24 the DCD and the FSAR, for example, Appendix B, the IST
25 Program, all of those have to be followed for that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Now, we did find that the RCIC net positive
2 suction head margin was acceptable, but they did have
3 increased suppression pool temperature and containment
4 overpressure to be able to reach a RCIC margin -- head
5 margin.

6 And so, we explored that and we asked
7 about, okay, what's your basis for those assumptions
8 that the RCIC net positive suction head was going to
9 be acceptable?

10 And they ended up with like about 8.4 feet
11 of minimum net positive suction head margin at eight
12 hours. And so, we're saying, okay, that's kind of
13 close. What's your assumptions for there where you
14 came up with that?

15 The net positive suction head required is
16 based on full RCIC flow. And after eight hours, it's
17 going to be dropped down quite a bit. So, there's some
18 margin there.

19 The friction head loss that they assumed
20 was more at nominal temperature and with the increase
21 in the suppression pool up to, you know, up toward 200
22 degrees or so, you're going to have a higher
23 temperature, you're going to have a -- less friction
24 head loss there. So, you have some required NPSH
25 margin there.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And then for the RCIC pump vendor, they
2 indicated that the pump vendor, their assumption of 23
3 feet assumed net positive suction head required, this
4 pump, as we talked about, has a better performance than
5 that. So, we'll probably have some margin there.

6 So, there was some margin with their net
7 positive suction head. Even though it was 8.4 feet,
8 we consider it to be reasonable.

9 Nevertheless, we had them adjust their
10 FLEX plan in case they did start to observe some
11 cavitation in their RCIC pump that they could shift
12 back to -- from the suppression pool to the condensate
13 storage tank early if they needed to because they're
14 going to switch anyway about 10 hours.

15 And so, the minimum net positive suction
16 head occurs about eight hours. So, it would have a
17 switch a little early if they got to a point where, as
18 we heard earlier today, they have someone in the RCIC
19 room monitoring those pumps. And if there's a problem,
20 then they'll switch early.

21 So, they do have the process to if they lose
22 RCIC entirely, they can reduce reactor pressure and
23 then shift all the way over to the ACIWA system. So,
24 they can do that as well.

25 So, that was some of our questions

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 regarding the qualification for the RCIC in light of
2 the fact it is going to have somewhat different
3 performance than during sort of the standard
4 safety-related that was accepted in the DCD.

5 For non-safety-related equipment, the
6 ACIWA system is part of the fire protection system which
7 has its own additional requirements. And all of the
8 requirements are described in DCD.

9 We looked over the sections in the DCD
10 related to this. The testing is performed in
11 accordance with the fire protection program, the
12 maintenance rule program. It's part of their -- the
13 D-RAP, Design Reliability Assurance Program, and the
14 maintenance rule.

15 It's also seismic qualified and we'll need
16 to make sure we -- make sure that's clear in the SER
17 which level of g it is, but we'll make sure that's clear.
18 It's also in robust structures.

19 The fire protection system also includes
20 pre-operational testing per Chapter 14. There's pump
21 and valve testing specified for that equipment.

22 And then as part of the QA program, there's
23 a special section of the South Texas 3 and 4 QA program
24 which deals with non-safety-related equipment.
25 That's high importance and this would fall into that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So, those are some of the aspects that we
2 looked at in terms of the capability of that
3 non-safety-related equipment.

4 And then for the portable equipment, as we
5 mentioned, the only portable equipment are those two
6 120 volt pumps that are used to transfer fuel oil.

7 They're going to be commercial grade, but
8 we explored with them through this RAI how that process
9 is going to be accomplished for this equipment.

10 In their procedures, there are specific
11 requirements that they develop a determination of the
12 critical characteristics for the commercial grade
13 item, make sure it's suitable.

14 So, it's very similar to what's done for
15 safety-related commercial grade dedication. And
16 there's a quality evaluation that's performed as part
17 of that as part of the operational program. So, that
18 was the performance capability evaluation for the
19 portable equipment.

20 And then we asked them about the
21 operational programs, because there is some discussion
22 of that. And we wanted to see sort of where this all
23 fit into the program. And they would develop a
24 separate program for their FLEX equipment, or
25 incorporate it into their programs that are already

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 listed in Section 13.4S.

2 And there's a number of them there. For
3 example, the fire protection, maintenance rule, motor
4 operated valve program, initial test program and those
5 are all specified.

6 And then lastly, there is a plan license
7 condition which will have the administrative program
8 for the configuration control, the maintenance, the
9 testing of the equipment for all of this mitigation
10 strategy.

11 So, based on that, we agreed that the basis
12 for this equipment has been demonstrated and there's
13 going to be a license condition. And also, there will
14 be inspections conducted as part of the ones that are
15 related to ITAAC or ones that are related to the normal
16 - - the operational program in the inspection procedure
17 for function design qualification and in-service
18 testing of pumps and valves and restraints.

19 There are provisions in there for
20 equipment that's RTNSS and for safety-related and RCIC
21 would be in there. So, we'll have an opportunity to
22 verify that they follow through on these procedures and
23 these processes for qualifying this equipment and
24 establishing testing for them.

25 MEMBER STETKAR: One thing I stumbled

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 across was -- and maybe not you, because it's not
2 necessarily mechanical equipment, but I'll throw it out
3 anyway, a question about equipment qualification in the
4 drywell.

5 And in the SER, it said that MAAP analysis
6 results in the calculation report that the maximum
7 drywell temperature during an ELAP condition is 332
8 degrees Fahrenheit, 167 degrees C, which is below the
9 equipment design temperature of 339.8 degrees
10 Fahrenheit, 171 degrees C.

11 That doesn't sound like a very big margin
12 for a fairly large temperature increase. So, I was
13 curious about what the uncertainties are in those two
14 estimates and where I might get in trouble if indeed
15 the actual temperature inside the drywell is
16 underestimated by that MAAP calculation.

17 MR. SCARBROUGH: Well, in terms of their
18 qualification, there will be design specifications
19 which provide what are the qualification limits. And
20 then they will have to go through a process to
21 demonstrate that equipment.

22 I'm not sure which if it's ~~(coughing)~~, but
23 they will have to have a program to validate to
24 qualification of that equipment for that limit.
25 That's a margin built into that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: Okay. Well, that's what
2 I'm trying to explore, because you went through a good
3 process talking about qualification of, if I can call
4 it that, confidence that I'd have adequate net positive
5 suction head for the RCIC pump because of all the things
6 we discussed a few slides ago about different designs
7 and reduced flow rate, things like this.

8 I didn't see any similar discussion here.
9 It just said, well, they ran a MAAP analysis and I came
10 out 7.8 degrees lower in that MAAP analysis than some
11 other temperature that's designed -- a qualification
12 temperature, so I'm okay.

13 MR. SCARBROUGH: Right. I'm not sure --

14 MEMBER STETKAR: Without any discussion of
15 uncertainties or why I'm confident that --

16 MR. SCARBROUGH: Right.

17 MEMBER STETKAR: -- that one MAAP analysis
18 temperature isn't underestimated by, you know, 20
19 degrees --

20 MR. SCARBROUGH: Yes, I understand.

21 MEMBER STETKAR: -- out of 350.

22 MR. SCARBROUGH: Yes, I didn't do the
23 review, but I would imagine that the staff that looked
24 at that, would have looked at the uncertainties in that
25 analysis, you know, based on their use of that program,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that code.

2 MEMBER STETKAR: I don't know what
3 equipment. I mean, it's mentioned in the SER about
4 drywell penetration seals, for example, you know, are
5 qualified to that 339.8.

6 MR. SCARBROUGH: Right.

7 MEMBER STETKAR: I don't know what happens
8 when we get up in that range on those penetration seals.

9 MR. SCARBROUGH: I'm sure they have margin
10 in terms of the -- because you wouldn't want to qualify
11 something that was so close to the limit that if you
12 ended up down the road that you had an adjustment of
13 that calculation that all of the sudden you found a lot
14 of equipment that's unqualified.

15 And we've had this discussion with
16 licensees regarding motor operated valves in terms of
17 building in margins so that in case down the road you
18 ended up with an adjustment, a slight adjustment in your
19 design-basis, you don't end up with inoperable valves
20 all of a sudden because you can't justify that small
21 increase. So, I would expect that they have margin
22 there.

23 CHAIRMAN CORRADINI: Can I ask a different
24 question -- or at least related question? So, before
25 when we asked about an audit, MELCOR calculations were

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 done as part of the audit.

2 So, in this case, did staff just look at
3 the MAAP calculation, or did they do something to
4 convince themselves that this was good enough?

5 MR. SCARBROUGH: I wasn't part of that
6 audit.

7 CHAIRMAN CORRADINI: Is Mr. Gilmer there?

8 MR. FOSTER: Different staff member.
9 Different branch.

10 MR. WAGAGE: My name is Hanry Wagage. I'm
11 from Containment and Ventilation Branch. We looked at
12 the MAAP calculation. We looked at the input and we
13 looked at the results that were reasonable.

14 And we found that there was some margin,
15 but we were convinced that there was some margin in the
16 calculation because of the input chosen and we assumed
17 that their results were consistent.

18 MEMBER REMPE: So, you are convinced
19 there's margin because they used conservative input,
20 but did you compare the results with what like
21 temperature is for the seals like Mr. Stetkar was
22 mentioning?

23 Did you look at how it would affect
24 equipment, seals, instrumentation that are placed in
25 the drywell?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. WAGAGE: We did note -- compare the --
2 actually, there was the limitation of the temperature
3 limit. We compared the limit that was below the
4 limiter.

5 MEMBER REMPE: I couldn't hear. I'm sorry.
6 You looked at the limit for the seals themselves?

7 MR. WAGAGE: Equipment qualification
8 template. It was below the equipment qualification
9 template.

10 MEMBER REMPE: For the seals.

11 MR. WAGAGE: Yes.

12 MEMBER REMPE: Okay.

13 CHAIRMAN CORRADINI: Okay. Let's keep on
14 going. You guys are close.

15 MR. SCARBROUGH: Okay. I'll turn it back
16 over to Rocky.

17 MR. FOSTER: Okay. Our final slide on
18 licensing conditions, this is a license action that
19 we're doing. And we know that this is not a final
20 design or the final build.

21 We're at a point where additional work will
22 have to be done on this process and on the plant itself
23 to come to full ~~tuition~~ **fruition** on it.

24 And so, we put licensing conditions in
25 place to make sure that the licensee at that time would

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 then have to fulfill -- come forward with this
2 information.

3 In our license conditions, we looked at
4 completing the entire FLEX integration plan because
5 right now it takes that long and they have to address
6 by plant procedures the guidance, the strategy, the
7 installation of any type of FLEX equipment, if they do,
8 the training programs and the administrative controls,
9 the configuration control maintenance and testing.

10 And then we've got to provide a full
11 implementation guidance and strategies for procedures,
12 training, the acquisition, staging the equipment,
13 installation of equipment and the configuration
14 control provisions, procedures for maintenance and
15 testing.

16 They also want them to perform
17 habitability analysis for the RCIC room, for the RSS
18 room and for the main control room for the different
19 phases that we spoke about earlier.

20 Updated design calculations for the Class
21 1E battery discharge with FLEX as-built plant design.
22 Complete an integrated system validation of ELAP
23 timeline which is 30 minutes. You heard about the ELAP
24 declaration. We want to see the basis for that and we
25 ask for it to be proceduralized. And the maintenance

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 to the guidance to the strategies programs.

2 Questions.

3 CHAIRMAN CORRADINI: So, I'm going to make
4 a suggestion. Unless we have burning questions now,
5 we're going to lose some of South Texas and we need to
6 go on to the fire-induced spurious signals and we'll
7 lose some experts.

8 So, if we want questions of these staff,
9 they're going to stay. So, we can drag them back up.
10 Is that acceptable to you, Mr. Brown?

11 MEMBER BROWN: Well, I mean, they're not
12 necessary because I'm just going to go back and respond
13 to the comment about the mitigating --

14 CHAIRMAN CORRADINI: Okay. But if we might
15 go on to fire-induced --

16 MEMBER BROWN: That's fine.

17 CHAIRMAN CORRADINI: Anything burning?

18 MEMBER RAY: Let me say one thing quickly.

19 CHAIRMAN CORRADINI: Yes.

20 MEMBER RAY: I had a very short discussion
21 about reasonable protection when the words "adequate
22 protection" were used. I just want to be clear about
23 it.

24 Reasonable protection is the protection
25 afforded to the equipment. Adequate protection has to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 do with the protection of the public health and safety.
2 Completely different subjects and I thought it was
3 important that we not mix up those two. They get
4 confused often enough.

5 MR. FOSTER: Yes, we agree.

6 CHAIRMAN CORRADINI: Okay. So, thank you.
7 We'll let you exit off stage left and we'll bring on
8 South Texas to talk about fire-induced spurious safety,
9 but don't go anywhere.

10 (Pause.)

11 (Comments off record.)

12 MEMBER BROWN: While they're doing that,
13 can I ask you, Bill --

14 MR. MOOKHOEK: Yes, sir.

15 MEMBER BROWN: -- on a response you said
16 the mitigating -- that you had referenced kind of
17 incorporated by reference, the only thing I could find
18 was in Section 2.4 where you all specifically state in
19 1E that to support the implementation of the FLEX plan,
20 the following system design requirements will be
21 incorporated in the STP 3 and 4 final design.

22 And then it goes through a shopping list
23 of about a dozen items. Class 1E batteries are not even
24 mentioned.

25 MR. MOOKHOEK: Correct.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BROWN: Only non-1E batteries.
2 They are important, but not the Class 1E batteries.

3 MR. MOOKHOEK: In a follow-on paragraph, we
4 say that the FLEX integrated plan describes the
5 strategies and the methods to provide core cooling, et
6 cetera.

7 MEMBER BROWN: Okay. Would you just let us
8 know, tell Maitri or somebody if I'm not around, where
9 that is?

10 CHAIRMAN CORRADINI: Yes, help us find it
11 so that --

12 MEMBER BROWN: If that's there, that's
13 fine.

14 MR. MOOKHOEK: Okay.

15 CHAIRMAN CORRADINI: Scott, you're up.

16 MR. HEAD: Okay, and thank you very much for
17 this. We will be losing a couple of our critical
18 players here in a few moments. And I apologize to the
19 staff for whatever this might be doing to your evening
20 plans.

21 We wanted to give our perspective on ACRS
22 Action Item 64, which is fire-induced spurious signals
23 from DC cabinets -- I mean digital I&C control cabinets
24 with fiberoptic cables.

25 So, to do this, we're going to start this

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 off with this diagram that comes from a, you know, it's
2 derived from a Tier 1 figure and it will be our starting
3 point for the discussion.

4 And the blue is what we've added at this
5 point to show the different locations of some of the
6 important features.

7 And Tim Hirst with Hirst Engineering is
8 with us here today. He's basically responsible for the
9 overall coordination of our digital I&C control
10 architecture and the design.

11 And if we have any detailed questions on
12 this, then Tim is certainly going to weigh in. And
13 Evans you've heard from today.

14 So, we've broken this up in terms of what's
15 local out in the field in terms of sensors to the left
16 of the drawing, in the control room, and then in local.

17 And the important aspects of this are, I
18 think, is that you see in the control room the SLF, basic
19 digital logical processing information takes place.
20 And we have fiberoptic cables, the dotted lines that
21 are going out to the SLF RDLC that's out in local.
22 That's out in the switchgear room or other areas in the
23 plant where the signals are being sent out from the
24 control room to control that equipment.

25 And I guess a couple of aspects of this that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 are important is that, you know, we don't, you know,
2 we believe that based on the design of the architecture
3 and the way the signals are encoded that it's very, very
4 unlikely for a spurious actuation to
5 be generated within the digital control system. And
6 that's reflected in some of the DCD language.

7 MEMBER STETKAR: Let me stop you right
8 there, because you've just used a term that says very,
9 very unlikely that I'm willing to be pretty happy with
10 if you were doing a risk-informed fire protection
11 program, which you're not.

12 You're doing a deterministic fire
13 protection --

14 MR. HEAD: Right.

15 MEMBER STETKAR: -- program which says you
16 shall assume that those signals occur. So, just let's
17 --

18 MR. HEAD: And B

19 MEMBER STETKAR: It doesn't say that
20 they're unlikely. It says, I have to assume that they
21 occur and I can demonstrate that I'm protected against
22 them.

23 MR. HEAD: Okay. And so, we're going to
24 address the -- where the spurious actuation signals are
25 assessed per the NEI guidance on the next figure, which

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 is the same figure that is -- but now it incorporates
2 where we believe, in fact, where the NEI 00-01 applies
3 with respect to spurious actuations.

4 And it's basically out in the field where
5 wire occurs and spurious actuations can occur due to
6 fires with respect to actual cabling or wire.

7 So, the NEI guidances we've committed to
8 applies to your local instrumentation or local
9 equipment out as you see on the right side of the figure
10 there.

11 With respect to -- I'll say, the DCD says
12 essentially zero, okay. It's still possible we
13 recognize that.

14 And so, you have to ask, well, what happens
15 in the control room if a fire is caught or you have a
16 fire that takes place or a cabinet is heated?

17 Well, there's a number of things that will
18 take place. One, if a cabinet is heated or is
19 undergoing some sort of situation where maybe the lines
20 or the vents are plugged or something, we will get
21 alarms in the control room.

22 And so, we will be able to assess that, even
23 deenergize the cabinet if necessary because there's
24 issues with that, or if we actually see something
25 happening.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: Scott --

2 MR. HEAD: Yes, sir.

3 MEMBER STETKAR: -- let me interrupt you
4 again.

5 MR. HEAD: Uh-huh.

6 MEMBER STETKAR: You're talking about a
7 scenario that I can quantify in a risk-informed
8 approach.

9 MR. HEAD: Right.

10 MEMBER STETKAR: That is not part of the
11 deterministic evaluation of fire damage.
12 Deterministic evaluation of fire damage says you assume
13 that the spurious actions occur and indeed the plant
14 has adequate margin to still be able to achieve safe
15 shutdown.

16 It does not say I have this thing where the
17 operators have some likelihood of deenergizing it
18 before or after some spurious actuations. That's not
19 part of the deterministic analysis.

20 MR. HEAD: Okay. Well, I'm just saying
21 that's not what happens in the control room. That's
22 not what --

23 MEMBER STETKAR: You're right. You're
24 absolutely right, but you don't get to -- you don't get
25 to take credit for the probabilistic approach to life

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 in saying, well, because I -- in truth, it's probably
2 not going to happen that way, and also say that I don't
3 want to do the analyses to support that.

4 MR. HEAD: Well, there is no analysis that
5 we don't want to do. What the certified design says
6 and has approved was the creation of those spurious
7 signals is low enough to be acceptable for --

8 MEMBER STETKAR: Low enough to be
9 acceptable. What's low enough to be acceptable?

10 MR. HEAD: We think in this case --

11 MEMBER STETKAR: Why can't you -- let me
12 play the opposite side. Why can't you presume that all
13 of the spurious signals come out of there and show that
14 you can --

15 MR. HEAD: We do that on the right side,
16 okay. On the right side of this, those signals
17 immediately are going to end up being in cabling. And
18 we will have all the spurious actuations take place,
19 but on the right side in basically a division level.

20 MEMBER STETKAR: You use words like "all."

21 MR. HEAD: Sorry.

22 MEMBER STETKAR: And those --

23 MR. HEAD: I try not to do that.

24 MEMBER STETKAR: -- and on the right side.

25 And having done enough fire analyses, it depends on how

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the stuff on the right side of this figure is
2 distributed in compartments throughout the plant
3 compared to how the stuff between the two dotted lines
4 is distributed in other compartments throughout the
5 plant.

6 And if I have very well-separated
7 divisionalized stuff that's called "local" here, I have
8 different effects when I burn that room than I do if
9 I burn the room between the dotted lines. So, you can't
10 draw those analogies when you say "all."

11 MR HEAD: Well --

12 MEMBER STETKAR: Because they're different
13 alls.

14 MR. HEAD: So, let me say that our east
15 division is its own fire area. That's, you know,
16 that's the way the plant is designed. And it really
17 won't matter where the wire is.

18 We believe that the wire will be in its
19 division and its room that's in the, you know, the fire
20 area, but it really won't matter.

21 The NEI guidance will cover it, cover the
22 wire and says, if you have wire, then you need to see
23 what happens if there is a fire.

24 MEMBER STETKAR: And I'm not talking about
25 wire. I'm talking about spurious signals that come out

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 of cabinets in through transmission pathways that are
2 intact.

3 Now, in some cases those transmission
4 pathways might be copper, in other cases those
5 transmission pathways might be fiberoptic cables, but
6 it's heating up cabinets that cause spurious signals.

7 MR. HEAD: Okay. So, we'll circle back
8 then and then address the digital aspect of those
9 spurious signals because that is --

10 MEMBER STETKAR: Now, NEI 00-01 doesn't
11 address that. In fact, it doesn't even address
12 cabinets, because it's all focused on the traditional
13 bugaboo of hot shorts in wires that are formed out of
14 copper conductors that may or may not have grounds on
15 them and all that kind of stuff. It never thought about
16 digital systems.

17 MR. HEAD: Or it did and found it
18 unnecessary to make that an issue because digital --
19 spurious signals due to fire are probably orders of
20 magnitude less than, you know, than other issues that
21 have existed for digital equipment.

22 Spurious actuation, you know, sun spots,
23 electromagnetic fields, you know, something else would
24 be in the digital world much more likely than a
25 fire-induced spurious actuation.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And so, that's maybe why it's not in the
2 NEI guidance right now is that it is not a threat that
3 -- represented by spurious actuations due to fire for
4 copper.

5 And so, I'm going to ask Tim to go ahead
6 and use that as a lead-in.

7 MR. HIRST: In reality, any spurious event
8 that you could get out of the SLF ends up becoming an
9 item that happens in the local actuation area.

10 The way the design is set up, there are
11 three independent divisional electrical switchgear
12 motor control centers. The final voting is done in
13 those rooms where that equipment is. So, it's all in
14 one spot.

15 The final connection from the mode unit to
16 the switchgear is copper. So, therefore, as part of
17 the analysis of the rooms and the actual controls on
18 the switchgear and MCC will end up verifying every one
19 of these spurious actions that can happen in its event
20 or its impact on the plant.

21 MEMBER STETKAR: But you again have fallen
22 back into places where copper exists. And I'm saying
23 I don't care about that. I care about spurious signals
24 coming out of cabinets.

25 I don't care whether it's copper or

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 fiberoptic cable, because you immediately said you've
2 gone back and looked at every place in those rooms where
3 copper wire comes, that nice solid line, those over
4 there, and I'll give you that. You looked at that.
5 Great. You didn't look at something called SLF.

6 MR. HIRST: SLF is the final voting on an
7 actuation.

8 MEMBER STETKAR: The SLF between the two
9 dotted lines, not the SLF RDLC.

10 MR. HIRST: Correct. The voting, the two
11 out of four voting is in the SLF.

12 MEMBER STETKAR: All right. You didn't
13 look at spurious signals coming out of that if they --
14 if that is in a cabinet that then goes to several
15 distributed locations where you have the local
16 controls, you did not look at the effects of spurious
17 signals coming out of the central SLF to all those
18 distributed locations.

19 You looked at the distributed locations
20 one by one, right?

21 MR. HIRST: Well, the SLF is only an
22 actuation piece, okay. So, therefore, it's very
23 limited on where it goes.

24 MEMBER STETKAR: Which SLF?

25 MR. HIRST: All of them. I mean, the SLF

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 is designated there where you do your two out of four
2 voting. That drives the SLF RDLC.

3 MEMBER STETKAR: That SLF is probably a
4 card, right?

5 MR. HIRST: No, it's an entire -- multiplex
6 processors, yes.

7 MEMBER STETKAR: You have several of those
8 mounted in the same cabinet.

9 MR. HIRST: They're actually in multiple
10 cabinets in the electrical switchgear rooms.

11 MEMBER STETKAR: Okay. The analogy is if
12 I have an old analog-driven plan that has Division A
13 having all relays and copper things and it's all in
14 Division A room and I burn up that Division A room
15 deterministically now, I have to look at multiple
16 spurious actuations coming out of that Division A room.

17 MR. HIRST: Right.

18 MEMBER STETKAR: Why don't I have to look
19 at multiple spurious actuations coming out of the
20 Division A room here that contains multiple SLF --
21 multiple cabinets that contain little digital SLF
22 processors.

23 MR. HIRST: Now, if you're doing it strictly
24 from a black and white situation that I can't take any
25 -- I don't know what to say -- credit, any credit for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the levels of redundancy and double-checking on this
2 because it is a digital system, there's no digital
3 faults coming out of SLF that would be any different
4 than the fault I would have in the electrical room
5 because that's a direct one-to-one relationship.

6 MEMBER STETKAR: And I guess I'm still not
7 communicating effectively enough. Let me ask the
8 question differently.

9 Do all of the SLFs that are listed shown
10 on this drawing as two out of four, a single division,
11 call it Division 1 --

12 MR. HIRST: Yes.

13 MEMBER STETKAR: -- go to local SLFs in a
14 single room?

15 MR. HIRST: Yes.

16 MEMBER STETKAR: One and only one room in
17 the plant.

18 MR. HIRST: There's one in the Reactor
19 Building. I'm trying to think. Is that the only one?

20 (Comments off record.)

21 MR. HIRST: Oh, all right. And the remote
22 shutdown room.

23 MEMBER STETKAR: So, there's more than one.

24 MR. HEACOCK: Yes. It will be isolated in
25 the fire areas.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. HIRST: There are two set of fire areas.

2 MR. HEACOCK: Yes, it will be more than one.
3 You can have multiple RDLCS.

4 MEMBER STETKAR: You can have multiple in
5 different isolated compartments.

6 MR. HEACOCK: Fire areas.

7 MEMBER STETKAR: Fire areas.

8 MR. HEACOCK: Right.

9 MEMBER STETKAR: So, therefore, if I burn
10 one of those isolated fire areas and affect all of the
11 SLF RDLCS in that fire area, I will have potentially
12 a different effect on the plant than if I burn what I'll
13 call the central SLF which communicates now with
14 several different fire areas.

15 Is that true, or am I misunderstanding
16 something?

17 MR. HIRST: I don't see how it could be any
18 different. Because the only thing coming out of the
19 SLF, well, basically are open, close, stop, start.
20 That's all it's telling the command to come out unless
21 you're trying to say that a message turns all the stuff
22 off or all the stuff on because of that message.

23 But you have the same issue with fire in
24 a given room. Show the same thing. So, that's what
25 I'm saying. There's no difference there.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 (Comments off record.)

2 MEMBER STETKAR: What I'm saying is, and
3 unfortunately I have to use visceral aids here, is this
4 is what I'm calling the central SLF. The SLF two out
5 of four.

6 MR. HIRST: Right. Right.

7 MEMBER STETKAR: And if that communicates
8 to -- I'll keep it simple -- two SLF RDLs that are
9 located in different fire zones, each of which controls
10 stops, starts, open, close different sets of equipment,
11 then if I have a fire here in my blue one, I effect all
12 of the equipment that comes out of the blue thing.

13 If I have a fire here in the white one, I
14 affect all of the equipment that comes out of the white
15 one.

16 If I have a fire here in the central one,
17 I affect both blue and white. So, I can't say that I've
18 assessed the effects of fires that affect the central
19 thing simply because I've looked at the blue and I've
20 separately looked at the white. That's what I'm trying
21 to get at.

22 Now, if the blue and the white are all in
23 the same fire zone, I can buy your argument. But if
24 they're in separate -- two or more separate fire zones,
25 I don't get it.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 (Comments off record.)

2 MR. THOMAS: This is Steve Thomas. I just
3 wanted to point out that the blue and the white are all
4 divisional. So, you're looking at a piece of
5 divisional equipment in the control room and divisional
6 equipment in the plan.

7 For example, might be an RHR pump, valve
8 and associated electrical equipment that supplies
9 those components, but they're all divisional.

10 MEMBER STETKAR: See, I understand that. I
11 actually understand that. What I don't see is the
12 analysis that says suppose I burn up that division the
13 worst way that I can burn up the division, and get the
14 worst set of spurious signals out of that division, and
15 I do that for each of the three divisions thinking about
16 them carefully. Do I still have adequate remaining
17 equipment to safely shut down the plant?

18 Now, the answer to that question may be
19 yes, but I haven't seen anybody ask that question yet.

20 MR. HEACOCK: I think -- this is Evans. I
21 think what we're trying to say is that, yes, the
22 question has been asked and answered in high level
23 9.5.1.1.7 with the statement that is shown there.

24 And that's being -- part of that's going
25 to be is that, yes, we understand there's a digital

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 communication system and platform that sends out
2 signals. They could be spurious signals.

3 We also have on the remote end and each one
4 of the switchgear rooms where a lot of this actuation
5 is going to take place, you have all your power and --

6 MEMBER STETKAR: A lot of it, but not -- if
7 you say a lot of -- if it's not all, that's --

8 MR. HEACOCK: Hang on a second. Hang on a
9 second. They go through to say that from a review from
10 a spurious actuation, our really rebounding case is
11 going to be what's in the larger area which control for
12 these items going to be a Division 1 or Division 2 or
13 Division 3 switchgear room which can control valves,
14 control the pumps, all the pumps and all the valves in
15 there for the plant itself since that's where you're
16 going to send the signal to start and stop MCC
17 contactors, 4160 switchgear breakers from that
18 particular point.

19 As we said, one of the other locations not
20 going to be in that same will be remote shutdown. You
21 have an interface there. And you'll have some control
22 for ADS. And they're not all valves, but you'll have
23 some.

24 So, you don't have them all the same. But
25 when you're looking at what your worst case is going

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 to be, your worst case is going to be in that switchgear
2 room from a spurious actuation that would really bound
3 any kind of spurious signal that would be valid, should
4 be a valid-type signal that could get through and cause
5 spurious actuation somewhere else.

6 You have a lot more switchgear, a lot more
7 equipment in that one area than what your computer
8 system in a faulted, somewhat faulted state, not a truly
9 faulted state, sending out erroneous signals that would
10 cause multiple spurious actuations.

11 MR. HIRST: I mean, there's the act of
12 communication. SLF RDLC. After RDLC, all -- there's
13 actually two redundant sets of communication.

14 MEMBER STETKAR: Not always, as I
15 understand it. Sometimes there's only one, but go on.

16 MR. HIRST: For the lower level functions.

17 MEMBER STETKAR: Yes.

18 MR. HIRST: For all your main functions that
19 are significant events.

20 MR. THOMAS: There are always two redundant
21 communication paths as shown. Sometimes there are two
22 redundant SLFs.

23 MR. HIRST: Right. Yes. But there's
24 always -- those are always redundant.

25 MR. THOMAS: Those two communication paths

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 are --

2 MEMBER STETKAR: Sometimes it's too
3 redundant.

4 MR. THOMAS: Yes.

5 MEMBER STETKAR: SLF RDLCs. One for a
6 valve, one for a pump, et cetera.

7 MR. THOMAS: Exactly.

8 MR. HIRST: Once they've got to RDLC, they
9 are individual chassis, individual processors that
10 validate the signals. So, there's no way that you can
11 -- wrong words?

12 MEMBER STETKAR: Right. That's the wrong
13 word.

14 (Laughter.)

15 MR. HIRST: I don't see a valid method for
16 a package, a message package coming out of different
17 CPUs and different chassis going to different CPUs,
18 different chassis all to the equivalent in order to
19 cause a spurious action.

20 MR. HEAD: To be accepted.

21 MR. HIRST: To be accepted.

22 MR. HEAD: Accepted at the SLF RDLC as a
23 valid signal. And both of them be identically --

24 MR. HIRST: Because the entire system was
25 designed to eliminate spurious events whether fire in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 my RFI, surges, shorts, people unplugging things, you
2 name it.

3 And that's what makes this system
4 different. The base design from the beginning was
5 dealing with avoiding spurious actuation in the
6 equipment. And that's all final voted and verified at
7 the SLF RDLC.

8 MR. HEAD: Which is one of the reasons I
9 think the NEI guidance has not addressed the digital
10 world because of this process that we've just talked
11 about.

12 And that's why, you know, my staff and
13 we've talked about and said, you know, 9.5.1.1.7 has
14 language in it that is, you know, potentially
15 controversial, but it is -- we stand behind it and it
16 is what we think is the reason we believe the
17 probability of this event coming from the control room
18 is, whatever we want to call it, small.

19 MEMBER STETKAR: And, Scott, I'm not
20 arguing with that statement. I believe that
21 statement.

22 MR. HEAD: Okay.

23 MEMBER STETKAR: It's small if you were to
24 do a probabilistic analysis. You're not, though. You
25 have hung your hat --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. HEAD: We --

2 MEMBER STETKAR: -- on the fact that
3 you're going to follow the deterministic guidelines for
4 licensing the fire protection program on this plant.

5 MR. HEAD: Right.

6 MEMBER STETKAR: The deterministic
7 guidelines don't say that you're allowed to say this
8 is not very probable or it's very likely that this other
9 thing will occur. They say you must assume that it
10 occurs.

11 I think that's silly, but indeed that's the
12 world that you have decided to adopt for your fire
13 protection program.

14 MR. HEAD: So, we've decided to adopt what's
15 on the diagram here. The NEI guidance will apply to
16 the right side of the local where there's basically
17 copper.

18 We don't believe the NEI guidance tells you
19 what you should do or how you should do anything in the
20 digital world.

21 MEMBER STETKAR: You're right. It
22 doesn't. It's silent on it.

23 MR. HEAD: And we think it's silent for a
24 reason. For the reason we've talked about. The
25 creation of those signals, the absorption of those

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 signals on the right side and redundant signals is small
2 enough, the probability is small enough for the issues
3 that are more real in the digital world than fire.

4 There are things that can happen in the
5 digital side that are more significant, more global
6 than a fire.

7 CHAIRMAN CORRADINI: I'm looking at you,
8 John, because I can't ask any questions on this.

9 MEMBER STETKAR: Well, I don't have
10 anything more to say. I think we're -- this is where
11 we are.

12 MR. HEAD: I'll just offer that the last
13 page of this presentation is what's, you know, there's
14 two major points on there that the RDLC utilizes
15 diagnostics -- we've alluded to that -- to verify the
16 validity of each redundant message. And that's, I say,
17 the messages have to be received and tested and verified
18 that they are valid. And then there has to be two of
19 them.

20 And while, you know, maybe that's a
21 probabilistic argument. It almost looks
22 deterministic to me. It's more deterministic than
23 some of what --

24 CHAIRMAN CORRADINI: Can I say something
25 back to you --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. HEAD: Sure.

2 CHAIRMAN CORRADINI: -- because I really
3 don't really get a lot of this, but I've got my colleague
4 here who wants to get it.

5 All right. If I go back to the picture,
6 what you're basically saying is that in a deterministic
7 way, it's impossible based on the design to have a
8 spurious actuation.

9 MR. HEAD: No, we're saying essentially
10 zero, but not zero.

11 CHAIRMAN CORRADINI: Okay. But -- okay.
12 Fine.

13 MR. HEAD: Okay.

14 MEMBER STETKAR: And my point is in the
15 analog world with relays and copper, the people say,
16 well, it's essentially impossible to get a large number
17 of spurious operations also. And, yet,
18 deterministically you're required to assume that they
19 will occur when you do deterministic fire analysis.

20 MR. HEAD: Not in the control room.

21 MEMBER STETKAR: In the control room,
22 people typically say I can go to a remote shutdown
23 facility and shut the plant down.

24 MR. HEAD: And that's what we're saying,
25 too. That's what we're saying, too.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: However, I've seen
2 designs where because of the way things are wired
3 together or wired, for some sets of multiple spurious
4 actuations you can't mitigate them from a remote
5 shutdown facility.

6 All I'm trying to do is explore how
7 carefully your fire assessment for every location in
8 the plant, every compartment, control room being one
9 of them, has looked at what can possibly happen and how
10 well you're protected against it in a deterministic
11 sense, because that's the world that you've established
12 for your fire protection programs.

13 MR. HIRST: I almost look at it as our
14 deterministic argument is the fact that every command
15 we send down to the RDLC, you must get multiple
16 commands.

17 Those commands must match exactly. And if
18 they don't, it doesn't do anything. And to me, that's
19 really our key issue.

20 MR. HEAD: That sounds deterministic to me.
21 That's my --

22 MR. HIRST: Because we specifically and
23 purposely put those multiple communications signals on
24 separate controllers, separate cables and then
25 compared them again so that we knew for sure

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 deterministically that before we did anything else,
2 it's got to match.

3 MEMBER STETKAR: And I get it. You know,
4 it's five after 5:00. We can throw words back and forth
5 at each other and it's just me speaking right now.

6 We have a subcommittee here of seven, eight
7 people. Everybody has heard this exchange.

8 CHAIRMAN CORRADINI: We need the staff to
9 come up and talk to us.

10 MEMBER STETKAR: We need the staff to come
11 up and talk.

12 MR. HEAD: And thank you for letting us
13 accommodate our schedule.

14 CHAIRMAN CORRADINI: Thank you. Okay.
15 Staff is up. Scott, you're staying. We're losing
16 your expert, but you're staying.

17 (Comments off record.)

18 CHAIRMAN CORRADINI: Okay. Dennis, is it
19 you?

20 MR. ANDRUKAT: Yes, sir.

21 CHAIRMAN CORRADINI: Okay. Have at it.

22 MR. ANDRUKAT: Well, not quite.

23 (Comments off record.)

24 MR. BETANCOURT: Okay. So, let's go to the
25 handout since we don't have the presentation review in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 front of us. Good afternoon. Thank you for having us
2 here today.

3 My name is Luis Betancourt. I am the PM
4 with the STP COLA. Today I have over here also with
5 me Dennis Andrukat, the fire protection engineer for
6 this action item.

7 Today we are going to be discussing how the
8 staff is addressing this action item, fire-induced
9 multiple spurious actuations in a digital cabinet.

10 This action item came up out of the Chapter
11 9 presentation of the STP COLA back in October 2010.
12 The members asked us to work together with NRC fire,
13 as well as NINA on this topic.

14 So, you look on the second slide. This is
15 the staff review as well as Dennis Andrukat's
16 assessments on the fire protection. I will now turn
17 it over to Dennis and Slide Number 3.

18 MR. ANDRUKAT: Okay. So, the background,
19 as we know, four years ago, Dr. Stetkar, you brought
20 up this question about the adverse effects due to a
21 fire.

22 MEMBER STETKAR: That was four years ago?

23 MR. ANDRUKAT: Yes. The staff still
24 maintains that there's reasonable assurance that a fire
25 will not prevent the ability to achieve and maintain

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 safe shutdown even given the digital question.

2 If we move to Slide 4, I believe we talked
3 about this a little bit with NINA's presentation. The
4 hard wire portion of this is going to follow NEI 00-01.
5 And also is going to follow Revision 2 of Reg Guide
6 1.189, which is the fire protection for nuclear power
7 plants guidance document for those portions that relate
8 to spurious operation.

9 Moving forward to the I&C architecture
10 portion, in addition to the presentation that NINA has
11 given, the staff finds it reasonable given the
12 architecture, given the robust features such as
13 diversity, redundancy, reliability and some additional
14 layers of protection, we still find it reasonable that
15 you're still going to have one train of safe shutdown
16 equipment to achieve and maintain safe shutdown.

17 CHAIRMAN CORRADINI: So, can I ask a
18 question --

19 MR. ANDRUKAT: Yes.

20 CHAIRMAN CORRADINI: -- since I think
21 you're done.

22 MR. ANDRUKAT: Yes. I mean, I have some
23 layers in page Number 5.

24 CHAIRMAN CORRADINI: Right. But what I'm
25 hearing you say since I've heard Mr. Stetkar a lot, what

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 I'm hearing you say is you accept their
2 probabilistic/deterministic argument.

3 MR. ANDRUKAT: We don't accept it as a
4 probabilistic --

5 CHAIRMAN CORRADINI: Well, you can define
6 it however you want, but what I'm hearing in simple
7 vernacular is they're saying it's so low as to not be
8 possible. And you're saying, yeah.

9 MR. ANDRUKAT: In addition -- well, by
10 itself I don't think we can say that.

11 CHAIRMAN CORRADINI: So --

12 MR. ANDRUKAT: So, we have these additional
13 layers of protection. We also sit there and say, if
14 I can throw out some scenarios that we were talking
15 about with the RDLCS, for example, the RDLCS are
16 separated by division in the switchgear room. The
17 input to that is digital. The output is hard wires.

18 The NEI guidance -- and that's the entire
19 division in one fire area. And then you have one fire
20 area per division.

21 That NEI guidance will account for
22 spurious actuations for each of those components. I
23 don't know if that makes sense.

24 CHAIRMAN CORRADINI: Yes. Go on.

25 MR. ANDRUKAT: Okay. So, at least in the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 switchgear room we're accounting for that's one
2 division and it will not affect other divisions.

3 So, we still have two other divisions at
4 this point that are free from fire damage that can
5 achieve and maintain their ability to safely shut down.

6 If we backup to the control room where the
7 DTFs and the SLFs are, you can have what we were thinking
8 of. Two basic scenarios.

9 One, how they describe in basic terms in
10 the DCD and FSAR if you have a fire or smoke, they're
11 going to consider -- we're going to render the entire
12 room, the entire fire area -- the entire fire area is
13 the main control room and the two computer rooms, if
14 you will.

15 Okay. They're going to render that
16 inoperable, uninhabitable. They're going to transfer
17 and run to the remote shutdown station.

18 MEMBER STETKAR: Sure.

19 MR. ANDRUKAT: Okay. In that case, you
20 have isolated the issue as far as we're concerned. The
21 other --

22 MEMBER STETKAR: You've isolated the issue
23 after you got there. The problem is the issue may have
24 done things to you in the interim before you got there
25 and isolated it. So, valves could have been

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 repositioned.

2 MR. ANDRUKAT: Correct.

3 MEMBER STETKAR: And valves that you cannot
4 control from a remote shutdown room, because you only
5 have a limited amount of controls there.

6 MR. ANDRUKAT: You have a limited amount of
7 controls. You have the -- correct. You do have up
8 front, you have the necessary controls at each remote
9 shutdown station if you didn't have an event, correct.
10 Right.

11 MEMBER STETKAR: That's right.

12 MR. ANDRUKAT: But you still have the
13 ability to -- so, you're bringing a timing thing into
14 this, if you will.

15 If you're going to have a digital failure
16 before you're transferring the switch, before you're
17 isolating the control room --

18 MEMBER STETKAR: Now, I had a fire.
19 Remember this is --

20 MR. ANDRUKAT: You had a fire-induced --

21 MEMBER STETKAR: I had a fire.

22 MR. ANDRUKAT: A fire-induced spurious
23 signal. Multiple spurious signals before you
24 transferred.

25 Within a division, I believe we're still

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 covered. You still have an analysis on a single
2 division, an entire division from RDLCS that's covered
3 by the methodology. If you spuriously actuate those
4 components, you have analysis.

5 MEMBER STETKAR: Provided -- and, again,
6 I'll bring you back to this notion of spatial
7 distribution. Provided that all of those RDLCS live
8 in the same space.

9 MR. ANDRUKAT: Correct.

10 MEMBER STETKAR: If they live --

11 MR. ANDRUKAT: And that's our
12 understanding.

13 MEMBER STETKAR: -- in different spaces,
14 then I get back to my white and blue and central, you
15 know, visual aids here.

16 MR. ANDRUKAT: And our understanding is
17 they are all in the switchgear room.

18 MEMBER STETKAR: That's good news.

19 MR. ANDRUKAT: Within the control room, you
20 know, you still have the three separate divisions per
21 cabinet. They're not mixing -- and STP can correct me
22 if I'm wrong -- they're not mixing divisions within
23 cabinets.

24 MEMBER STETKAR: Right.

25 MR. ANDRUKAT: If you're in a situation that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 you're not abandoning the control room, you know, now
2 you're kind of in what-if space. But this is where I
3 think the reasonable assurance of, I'll say, coping
4 strategies where we have trained operators, we have
5 procedures inside the control room that will try to find
6 the source, try to put out the fire, whatever they have
7 to do to mitigate that situation without -- before they
8 can abandon the control room, you know.

9 I don't know if it's reasonable or not to
10 sit there and say that that would spread past more than
11 a cabinet or more than a division.

12 MEMBER STETKAR: The deterministic stuff
13 just says you burn up everything --

14 MR. ANDRUKAT: But if you're in a
15 deterministic space --

16 MEMBER BLEY: That's true for Appendix R
17 kind of stuff, deterministic fire, but it's not true
18 for other deterministic aspects of regulation.

19 We've always had in the deterministic
20 side, this idea of beyond reasonable not being there.
21 We don't look at spurious, I mean, a sudden reactor
22 vessel failure all by itself. We don't look at
23 concurrent Chapter 15 events happening at the same
24 time.

25 So, there's a range of things for which

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 there's been a reasonable -- it's never been completely
2 defined, but it's pretty remote.

3 I'm not sure where that fits with --

4 MEMBER STETKAR: I'm not sure either,
5 because -- I'm just not sure. I'm not sure.

6 MR. ANDRUKAT: And usually for control
7 rooms, though, I mean, you're relying on remote -- an
8 independent -- something that's electrically and
9 physically separated, hence the remote shutdown panel,
10 and a transfer switch.

11 In our guidance documents, that's what we
12 rely on for the control room, you know, which is a little
13 bit, you know, control room analyses are quite
14 different than the fire hazard fire safety shutdown
15 analysis you would do for any other fire area. And
16 there's some leniencies similar to containment. You
17 have some leniencies based on you can't separate all
18 four divisions in those two areas. So, there's a
19 different strategy.

20 MEMBER STETKAR: Dennis, let me see if, you
21 know, badgering people, are the -- I think I've
22 established at least from your perspective that the
23 RDLCs, at least your understanding is that they are
24 located in three, and only three, switchgear rooms in
25 the plant. In other words, they're not distributed

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 throughout the Reactor Building, for example, in, you
2 know, six or eight or 10 different locations.

3 MR. ANDRUKAT: Correct.

4 MEMBER STETKAR: Okay.

5 MR. ANDRUKAT: At least -- and STP can step
6 in. And I also want to add we're not necessarily
7 preventing all spurious actuations. We are only
8 concerned with the spurious actuations that prevent the
9 ability to achieve and maintain safe shutdown.

10 MEMBER STETKAR: True.

11 MR. ANDRUKAT: If you have an RDLC that's
12 somewhere else, that spurious actuation just makes a
13 mess somewhere else, but doesn't affect a Fire 3
14 Division from achieving, say, you know --

15 MEMBER STETKAR: Let me give you an example
16 only because this is something that pops into mind for
17 pressurized water reactors.

18 I've looked at plants where spurious
19 signals in non-safety-related systems throw the plant
20 into a trajectory not necessarily preventing safe
21 shutdown, because it's a very, very plant-specific
22 analysis, but throw it into a trajectory that you would
23 not necessarily think about only looking at your
24 safety-related divisionalized stuff.

25 MR. ANDRUKAT: Correct.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: And some of those
2 trajectories we've actually found are not
3 well-protected because of the presumptions about --
4 especially in a plant like this where you have fours
5 and threes, you know, it's not a perfectly symmetric
6 --

7 MR. ANDRUKAT: Correct.

8 MEMBER STETKAR: -- four-train plant or
9 two-train plant.

10 MR. ANDRUKAT: Right.

11 MEMBER STETKAR: We found cases where some
12 of those trajectories wind up in very funny situations.
13 They're rare, but they're not zero. And why I'm trying
14 to pursue this is to see how carefully anyone has
15 thought about that.

16 MR. ANDRUKAT: Okay.

17 MEMBER STETKAR: Now, the other thing is do
18 we know that all of the SLFs on this drawing here are
19 located in the control room, or are they located in
20 other rooms that are outside of the control room, but
21 what might be defined from the purposes of ventilation
22 or other reasons, called the control room envelope.

23 CHAIRMAN CORRADINI: We're asking STP this,
24 right?

25 MEMBER STETKAR: Yes. Are they actually in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the control room where the operators live?

2 MR. HIRST: They are part of the control
3 room fire zone. There are two relay rooms.

4 MEMBER STETKAR: That's what I was looking
5 for.

6 MR. HIRST: Yes, but they are all there in
7 one place.

8 MEMBER STETKAR: Well, no. Are they -- if
9 I'm sitting here, I'm an operator and I have these nice
10 little terminals and this is where I live and it's a
11 room. It's got walls. It's got floors.

12 MR. HIRST: Uh-huh.

13 MEMBER STETKAR: Are the cabinets that
14 contain those processors within this space, or are they
15 in another room?

16 MR. HIRST: They're in two rooms. One in
17 the front, and one in the back of the physical boards.

18 MEMBER STETKAR: But they're separate
19 rooms.

20 MR. HIRST: Yes.

21 MEMBER STETKAR: Okay. Do they
22 communicate with the space where I live?

23 MR. HIRST: Yes.

24 MEMBER STETKAR: How do they communicate?

25 MR. HIRST: It's -- well, cable and HVAC,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 because it's a false floor of the whole area.

2 MEMBER STETKAR: But it communicates
3 through the false floor.

4 MR. HIRST: Yes.

5 MEMBER STETKAR: Okay.

6 MEMBER RYAN: So, you have one room.

7 MEMBER STETKAR: No, not necessarily.

8 MR. HIRST: One fire zone.

9 MEMBER STETKAR: But that's my whole point.
10 Fire zones are defined for fire protection, for
11 ventilation, for safety-related isolation. Fires
12 don't necessarily -- it's when you get into defining
13 compartments for fire analysis.

14 Fires -- a single fire zone might involve
15 multiple compartments, or a single compartment might
16 involve multiple fire zones, because fire zones are
17 defined for different purposes.

18 MR. ANDRUKAT: Zones don't necessarily mean
19 walls, for example.

20 MEMBER STETKAR: Right.

21 MR. ANDRUKAT: Or fire barriers.

22 MEMBER STETKAR: So --

23 MR. ANDRUKAT: Fire areas will tell you
24 fire-rated barriers.

25 MEMBER STETKAR: So, when you make -- the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 reason I was trying to get a little more precise is if
2 indeed the cabinets were located within the same
3 confines of where I live, it's a little different
4 situation. That is the traditional control room fire
5 analysis.

6 MR. HIRST: They are essentially in the area
7 where the operator lives. And each one of the cabinets
8 has got a temperature monitoring. Now, as soon as it
9 feels heat, you're going to get alarms.

10 Now, at that point, the operator is going
11 to open the door and say, what's going on here? It's
12 when the cabinet gets hot.

13 MEMBER STETKAR: Are there -- since I have
14 three divisions, these other rooms, are there six of
15 them? Are there three of them? There are two of them;
16 am I correct?

17 MR. HIRST: There are two relay rooms.

18 MEMBER STETKAR: Relay rooms. Two relay,
19 but I have three divisions of things and four sets of
20 input signals.

21 MR. HIRST: So, four divisions and call it
22 three trains.

23 MEMBER STETKAR: Four divisions, three
24 trains, okay. We'll use that terminology.

25 MR. HIRST: And two of them, they're split

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 between the two rooms. Two in one. That's the way the
2 --

3 PARTICIPANT: Two in one area on one side
4 of the control.

5 MR. HIRST: East side and west side in our
6 plant.

7 MR. HEACOCK: The way the divisions are
8 separated they have the control room in the center, two
9 on one side, two on the other.

10 MEMBER STETKAR: Those are divisions.
11 What about my trains, though?

12 MR. HEACOCK: Well, the trains are in a
13 different area altogether. So, the way the signals are
14 carried --

15 MR. HIRST: Okay. Wait a minute. As far
16 as the SLFs go, the (coughing) train level SLFs are
17 associated with Division 1, Division 2 and Division 3.

18 MR. HEACOCK: Right.

19 MR. HIRST: So, therefore, they're in that
20 equipment area in their own cabinet. Now, once they
21 leave the control room, they go to separate chassis all
22 going to the electrical trains.

23 MEMBER STETKAR: Let's see if I can bring
24 you back to the picture that we're looking at here so
25 that I can try to understand this.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 I'm focusing on the thing -- right there.
2 Thank you. I'm focusing on the thing that's called SLF
3 2/4 typical of three divisions. Where are the cabinets
4 for those things?

5 MR. HEACOCK: Those are in the control room.

6 MEMBER STETKAR: Physically where?

7 MR. HEACOCK: Where he was pointing to.

8 MEMBER STETKAR: And when I say "control
9 room," I mean physically where I come to work and sit
10 down at my terminal every day in that -- in the confines
11 of that enclosure.

12 MR. HEACOCK: No.

13 MEMBER STETKAR: No. So, I'm hearing yes
14 and no.

15 MR. HEACOCK: The division -- these are the
16 SLFs for the divisions where they'll communicate where
17 they'll send the signals out. Those are on the other
18 side of the control room in separate, little areas, but
19 still part of --

20 MR. HIRST: Part of the control room. We
21 consider that part -- that's the control room envelope.

22 (Comments off record.)

23 MR. HIRST: These four divisions here and
24 we have three of ~~each~~ ~~eight~~. Okay. These are in
25 either end of the control room envelope in that east

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 and west area.

2 MEMBER STETKAR: Now, let's go on now the
3 analogy that we are all sitting in the control room
4 because we all have terminals here. And out that door,
5 because that happens to be an open door, could the
6 cabinets be in that annex room out that door?

7 MR. HIRST: Yes.

8 MEMBER STETKAR: Yes, okay.

9 MR. HIRST: They are.

10 MEMBER STETKAR: They are. A different
11 compartment.

12 MR. HIRST: Yes.

13 MEMBER STETKAR: A different room. Now,
14 how many of those rooms are there? Two?

15 MR. HIRST: There's two.

16 MEMBER STETKAR: Two. One of those rooms
17 contains two of those three divisions? No, I'm sorry.
18 There's only three of these things. There's four of
19 those.

20 MR. HIRST: One has got one, and the other
21 one has got two.

22 MEMBER STETKAR: Good. Thank you.

23 MR. HIRST: Uh-huh.

24 MEMBER STETKAR: So that if I have a fire
25 in one room, I have a different effect than if I have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 a fire in the other room, because one room can affect
2 two of the three divisions, and one can affect one of
3 the three divisions.

4 MR. ANDRUKAT: Correct.

5 MEMBER STETKAR: Okay. Thank you.

6 CHAIRMAN CORRADINI: Are you done?

7 MEMBER STETKAR: I'm done.

8 CHAIRMAN CORRADINI: I don't mean to seem
9 uneducated, but now that we're done I'm not sure where
10 that leads us.

11 Because what I'm hearing from the staff is,
12 and I just want to paraphrase so I don't come off base,
13 is the staff feels confident with the design that
14 deterministically, I'll use their terminology, there
15 is enough redundancy and backup that they don't see
16 spurious signals propagating to the area where we have
17 -- I thought.

18 Say it again, because that's what I read
19 in your four slides.

20 MR. ANDRUKAT: So, not speaking to the
21 redundancy, there's still reasonable assurance you
22 have divisional separation.

23 We have divisional separation outside the
24 control room. We just talked about a little bit of
25 divisional separation within the control room. The

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 control room is analyzed a little bit differently.

2 In addition, there is electrical -- not
3 just physical separation, electrical separation,
4 because again the bottom line is I just need one
5 division.

6 MEMBER STETKAR: Dennis, I'll come back and
7 we need to stop this because it's 5:30 and we have other
8 things to do, but I'll now get a little more specific
9 because I understand the spatial configuration a little
10 better.

11 So, I'll come back to my previous
12 discussion about the fact that one of those rooms
13 outside the door contains two of the three divisions.
14 The other room contains one of the three divisions.

15 MR. ANDRUKAT: Correct.

16 MEMBER STETKAR: Good? If I have a fire in
17 the room that contains the two divisions, do I have
18 assurance that given the worst combination of multiple
19 spurious operations from those two divisions, I can
20 still safely shut down the plant with the remaining
21 division.

22 MR. ANDRUKAT: Yes.

23 MEMBER STETKAR: And looking at all
24 combinations, you know, the multiple spurious signals.

25 MR. ANDRUKAT: To my knowledge, yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: Okay.

2 CHAIRMAN CORRADINI: Are there questions
3 from the other members of the Committee?

4 (No response.)

5 CHAIRMAN CORRADINI: Okay. So, Scott, now
6 that you've hung on, can you join or come up front? I
7 want to make sure we go around, because this is our last
8 -- I'm sorry. Excuse me. We have other open items.
9 Excuse me. I apologize. I forgot.

10 MR. HEAD: I think I'm closing all of those.

11 CHAIRMAN CORRADINI: So, Luis.

12 MR. BETANCOURT: So, I guess we can
13 actually touch upon that separately, or I can actually
14 go through it very quickly. It's up to you.

15 CHAIRMAN CORRADINI: I would prefer you
16 touch on it now.

17 MR. BETANCOURT: Okay. So, as part of the
18 discussion, one of the members asked us regarding the
19 STP design and there was the transformer.

20 MEMBER STETKAR: So, as far as -- and we had
21 a really good presentation in the last subcommittee
22 meeting --

23 MR. BETANCOURT: Correct.

24 MEMBER STETKAR: -- about the philosophy.
25 So, I, you know, I personally am fine with the issue

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 of open phase.

2 MR. BETANCOURT: We just wanted to.

3 MEMBER STETKAR: And that's fine.

4 MR. BETANCOURT: With that, that concludes
5 my presentation.

6 CHAIRMAN CORRADINI: Okay. That's it?

7 MR. BETANCOURT: That's it.

8 (Comments off record.)

9 CHAIRMAN CORRADINI: We're going to be
10 fairly flexible, Scott.

11 MR. HEAD: Okay. One last item was
12 regarding the CEUS issues. And there was questions
13 regarding our analysis.

14 CHAIRMAN CORRADINI: And we had a
15 memorandum from the Committee about your discussion
16 point.

17 MR. HEAD: Right. And I believe the
18 discussions you heard from the industry basically has
19 subsumed our issue. And I believe -- I was hoping that
20 we'd get on the record that that issue is closed with
21 respect to STP.

22 MEMBER STETKAR: Yes. And as far as since
23 I raised the question again, as far as I'm personally
24 concerned, you've done -- you followed the industry
25 guidance.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. HEAD: Yes, sir.

2 MEMBER STETKAR: So, any questions that we
3 have that are with the industry guidance. It's a
4 generic.

5 MR. HEAD: The last meeting we had regarding
6 spent fuel racks, you had asked -- Member Stetkar asked
7 a question about the fuel, top of active fuel versus
8 the gate elevation.

9 MEMBER STETKAR: Yes.

10 MR. HEAD: And Steve Thomas said it's four
11 feet. And we committed to go back and look at that.
12 And we went back and looked and it's in fact 32 inches
13 above the top of active fuel, and 10 inches above the
14 top of the rack.

15 So, the issue is covered, but it was not
16 --

17 MEMBER STETKAR: That's just clarification
18 for the record.

19 MR. HEAD: And I guess I want to correct or
20 at least -- I'm sorry.

21 CHAIRMAN CORRADINI: No, you have the
22 floor. I'm not going to stop you. You're doing well.

23 MR. HEAD: Regarding, you know, regarding
24 the SLF RDLs, okay, we have not --

25 (Laughter.)

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. HEAD: So, we have not designed the
2 plant. And so, for us to assert that they're all in
3 the same place is possibly premature, okay, but very
4 likely, but still premature.

5 My point would be still is that's
6 irrelevant.

7 MEMBER STETKAR: Well, okay. On the
8 flipside, you haven't designed the plant yet. And
9 quite honestly, some of the reasons that I'm
10 emphasizing this is that when you finally get to design
11 the plant, meaning the layout, spatial layout of stuff
12 in the plant, it could be very useful for you to think
13 about the types of things I'm trying to emphasize.
14 Because I have seen examples of people with all good
15 intentions designing backfits on -- "backfit" is a bad
16 term -- modifications to plants where they haven't
17 thought carefully about those spatial separation
18 things.

19 They've thought very carefully about
20 piping, electrical -- separation, electrical
21 isolation, but done things like put things in the same
22 cabinet so they didn't benefit, for example, from the
23 effects of fires or routed cables through the same area
24 where they were particularly sensitive to fires for
25 cables.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So, part of this at an early phase thinking
2 about, well, I've got two divisions out in that room,
3 have I carefully thought about how those can affect me,
4 or maybe when I finally build the plant, do I want to
5 segregate those with a wall between them, now is the
6 time to kind of ask those questions before you actually
7 design the plant and say, oh, gee, maybe I would have
8 done it differently had I thought about it.

9 MR. HEAD: And see, I think we're -- if we
10 were in an analog world, we might accept that premise.
11 Okay. In the digital world and the diagnostics that
12 are involved in these signals, we really don't accept
13 that premise that that is an issue because we believe
14 --

15 MEMBER STETKAR: I hear you.

16 MR. HEAD: And if we don't accept it, I think
17 as I go back, I think that's why the NEI guidance has
18 not been involved to that period of time is because it
19 is -- it does represent a step forward from the analog
20 world that would have been next door from an older plant
21 or in the room next door in my older plant.

22 So, Mr. Chair, what I really was trying to
23 say is I would hate -- I'd hate to say that the
24 definitive statements about the plant design are known,
25 okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN CORRADINI: They're too premature
2 to be known.

3 MR. HEAD: They're just too -- we know where
4 the remote shutdown panel is, we know where each
5 division is, but for us to absolutely cert that right
6 now before is not true -- or is not known at this point.

7 CHAIRMAN CORRADINI: Okay.

8 MR. HEAD: So, I don't want that on the
9 record that we know all that.

10 CHAIRMAN CORRADINI: That's fine. Okay.
11 So, we've completed 64, Mr. Head.

12 MR. HEAD: I'm sorry. I was going to go
13 back to the -- we had a couple of things we wanted to
14 correct from the Fukushima discussion, but I don't know
15 where we are because I don't think the staff is finished
16 with their Fukushima discussion.

17 CHAIRMAN CORRADINI: No, I thought they
18 were.

19 MR. HEAD: Okay. Sorry. There was a
20 question about ACIWA feeding both units, which it can.
21 But if RCIC were to fail immediately, then feeding both
22 units would not be --

23 MEMBER STETKAR: You cannot feed both units
24 form T zero.

25 MR. HEAD: Right. With the one pump. But

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 what we would do is get one of the other pumps and hook
2 it up to the fire water.

3 MEMBER STETKAR: They have a couple hundred
4 gpm capacity? Are they 500, I mean basically
5 diesel-driven.

6 MR. HEAD: Right. I think they are -- the
7 fire pump -- the fire truck is equivalent to ACIWA, I
8 believe.

9 MEMBER STETKAR: Is it?

10 MR. HEAD: Yes.

11 MEMBER STETKAR: You can buy fire trucks
12 with sort of distinct capacities.

13 MR. HEAD: ACIWA is actually 900 if --

14 MEMBER STETKAR: ACIWA is 900 if you get it
15 down to, you know, let's run out.

16 MR. HEAD: I think we answered the question
17 globally, but the one would only feed -- only have
18 enough flow for one unit. That was our correction we
19 wanted to offer. At least a verification.

20 CHAIRMAN CORRADINI: Okay. Anything else?

21 (No response.)

22 CHAIRMAN CORRADINI: Okay. So, at this
23 point, nobody go anywhere. What I'd like to do is open
24 the phone lines and ask if there is anybody on the phone
25 lines.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Would you, Quynn, do that? We'll have
2 public comments. And as we're waiting for that --

3 MR. NGUYEN: Phone line is open.

4 CHAIRMAN CORRADINI: Phone line is open.
5 Is anybody on the line? Make a noise.

6 (Pause.)

7 CHAIRMAN CORRADINI: We'll close the phone
8 lines. Is there anybody in the audience that wants to
9 make a comment?

10 (No response.)

11 CHAIRMAN CORRADINI: Okay. So, now we're
12 at the point where we'll go around. And we'll start
13 with Pete.

14 MEMBER RICCARDELLA: No comments.

15 CHAIRMAN CORRADINI: But let me broaden it
16 and let me -- the broaden it goes like this is that this
17 is our last scheduled subcommittee meeting. So, it's
18 not simply these topics. It's these topics and
19 anything else that precedes it, because we're planning
20 to write a letter on STP COL in February. Thank you
21 very much. In February.

22 MEMBER RICCARDELLA: I still have no
23 comments.

24 CHAIRMAN CORRADINI: Okay. Fine. Dana.

25 MEMBER POWERS: I anxiously look forward to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 this.

2 CHAIRMAN CORRADINI: I'm glad somebody is
3 anxious.

4 (Laughter.)

5 MEMBER POWERS: Well, I think it will be an
6 EPR letter.

7 CHAIRMAN CORRADINI: Okay.

8 MEMBER POWERS: No pressure, Mike.

9 (Laughter.)

10 (Comments off record.)

11 MEMBER POWERS: I said a template. It's
12 not going to be possible to copy STP and EPR.

13 CHAIRMAN CORRADINI: Okay.

14 MEMBER BLEY: Nothing more.

15 MEMBER STETKAR: Nothing more from me.

16 CHAIRMAN CORRADINI: Thank you.

17 (Laughter.)

18 CHAIRMAN CORRADINI: I'm thanking you.

19 MEMBER STETKAR: You're welcome.

20 MEMBER RYAN: All set. Thanks.

21 MEMBER REMPE: No comments.

22 CHAIRMAN CORRADINI: All right. Okay.

23 So, let me at least for the Committee and you guys are
24 here, so you can hear it, my plan really is in terms
25 of drafting something that we have -- we've done draft

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 now -- I guess it's been five years. A wonderful five
2 years in this.

3 So, what I'm planning to do at least for
4 the letter is try to focus on Fukushima actions and the
5 particulars about the site relative to site-related
6 activities.

7 There are two or three issues. Charlie is
8 not here now. There is two or three issues in terms
9 of the turbine overspeed, the mono-block, some of these
10 things that probably at least in my mind they are not
11 issues, but I'm going to send a note out to the -- we
12 have a draft note. I'm sending it out to the Committee
13 just so that they're clear about those, but we'll
14 probably focus on the site issues and the
15 Fukushima-related activities for the letter.

16 Because I think -- personally I think it's
17 a reasonably good design at a reasonably good site, but
18 that's just me.

19 MEMBER POWERS: I have to say that I really
20 appreciate it and the rationale you did, because this
21 is the one that poses the biggest hassle for the people
22 on the site doing anything about it.

23 I think that's something that needs to be
24 done, rather than continuously escalating the
25 probability of more and more intense ground motions.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 What is the accident that poses the biggest challenge
2 and the people coping with it? People and equipment
3 coping with it.

4 I appreciated your rationale there and I
5 think it would be useful to articulate that rationale
6 before the full committee.

7 CHAIRMAN CORRADINI: So, no pressure. But
8 I think from the standpoint of presentation to the full
9 committee assuming the Committee members are okay with
10 the idea about how we'd approach it, I think focusing
11 on the site, focusing on things related to site events
12 such as the MCR, okay.

13 And then the Fukushima-related issues and
14 how you dealt with them would be the appropriate thing
15 to talk about in front of the full committee, unless
16 the members feel differently. Okay.

17 MR. HEAD: And any of the stuff that we had
18 covered before the previous letter --

19 CHAIRMAN CORRADINI: I don't think --
20 personally, I don't think it rises to the need to --

21 MR. HEAD: Okay.

22 CHAIRMAN CORRADINI: -- bring it up.

23 MR. HEAD; All right.

24 CHAIRMAN CORRADINI: But again, I just one
25 of 13. Just one of the baker's dozen.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. HEAD : AS I recall, we have one hour
2 or two normally for that?

3 CHAIRMAN CORRADINI: Well, that's
4 negotiable with the leadership.

5 MR. HEAD: That's true.

6 CHAIRMAN CORRADINI: I mean, probably an
7 hour and a half. Probably a couple hours.

8 MEMBER POWERS: Do not presume that members
9 who have not attended the Subcommittee meeting have a
10 good memory of what your site is.

11 CHAIRMAN CORRADINI: Don't presume any of
12 the members have any memory. But I do think, though,
13 you want to focus on these sorts of issues.

14 All right. With that, we're adjourned.

15 (Whereupon, at 5:44 o'clock p.m. the
16 meeting was adjourned.)


NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

South Texas Project Units 3 & 4

Mitigating Strategies for Beyond Design Basis External Events

(Recommendation 4.2)



Attendees

- Scott Head, Regulatory Affairs Manager, NINA
- Steve Thomas, Engineering Manager, NINA
- Bill Mookhoek, Licensing Supervisor, NINA
- Jim Tomkins, Licensing, NINA
- Richard Scheide, Licensing, NINA
- Evans Heacock, Electrical Engineering, NINA

Agenda

- Regulatory Framework
- DCD Features that Mitigate a Station Blackout
- Enhancements to Address NRC Fukushima Recommendations
- FLEX Plan Sequence of Events
- Supporting Analyses
- Summary
- Conclusions

Regulatory Framework

- SECY-12-0025 identified actions in response to Fukushima event
- Four actions apply to new reactors
 - 2.1 – Seismic and Flooding Re-evaluations
 - 4.2 – Mitigating Strategies for Beyond Design Basis Events
 - 7.1 – Spent Fuel Pool Instrumentation
 - 9.3 – Enhanced Emergency Plan Staffing and Communication
- STP 3&4 response to these actions is in FSAR Appendix 1E
- Previously discussed 2.1, 7.1, and 9.3 with ACRS
- Presentation today will cover 4.2

DCD Features that Mitigate a Station Blackout (SBO)

- Combustion Turbine Generator (CTG)
- AC-Independent Water Addition (ACIWA)
- Reactor Core Isolation Cooling (RCIC)
- Containment Overpressure Protection (COPS)
- Substantial Battery Capability

STP 3&4 ABWR Enhancements

- CTGs qualified for design basis hurricane and tornado missiles (already flood protected)
- ACIWA system and fuel tank qualified for site flood and severe weather events (already seismically qualified)
- ACIWA Fire Water Storage Tanks (FWSTs) qualified for site-specific seismic, missile, flood, high wind and other site severe weather events
- ACIWA able to use Ultimate Heat Sink (UHS) water inventory

STP 3&4 ABWR Enhancements *(continued)*

- Alternate Spent Fuel Pool (SFP) Makeup and Sprays
- Substantial onsite diesel fuel oil and water supplies
 - Over 1,700,000 gallons of diesel fuel oil
 - Over 35,000,000 gallons of water

STP 3&4 Enhancements (*continued*)

- Condensate Storage Tank (CST) designed for site-specific seismic, missile, flood, high wind and other site-specific severe weather hazards
- Battery connections installed and cables staged to allow cross-connection between the divisions
- One plant stack radiation monitor powered by Class 1E power

STP 3&4 Enhancements (*continued*)

- Permanent connections to allow the Phase III 480V 1500 kW diesels to be connected from outside the Reactor Building to supply Engineered Safety Feature (ESF) loads
- Internal plant radio communications powered by non-Class 1E batteries for 36 hours. These batteries are seismically mounted in the Control Building.

Combustion Turbine Generator

- One 20 MW CTG for each unit
- Diverse and independent from the Standby Emergency Diesel Generators (EDGs)
- Capable of supplying all three Class 1E busses
- Cross-connects to the other unit
- Seismically robust
- Protected from design basis hurricane, tornado missiles, and flood

AC-Independent Water Addition

- Diesel powered system
 - Installed diesel powered fire pump (common)
 - Fire truck (one per unit)
 - Trailer mounted portable pump (one per unit)
- Injects via Residual Heat Removal (RHR) piping to provide:
 - Core cooling
 - Drywell and Wetwell Spray
 - Spent Fuel Pool (SFP) Makeup

AC-Independent Water Addition

(continued)

- Sufficient flow rate for both units and both SFPs
- Dedicated onsite water storage of > 600,000 gallons
- Diesel fuel tank supports 36 hours of operation
- Protected from site-specific seismic, missiles, floods, high wind and other site-specific weather

Reactor Core Isolation Cooling

- Advanced steam-driven turbine/pump system
 - Mono-block, totally self-lubricated design
- Supplies water to the core over the full spectrum of Reactor Pressure Vessel (RPV) pressures
- Suction from Suppression Pool (S/P) or CST
 - CST has capacity of > 500,000 gallons (250,000 gallons credited)
- RCIC is part of Emergency Core Cooling System (ECCS) and is protected from all design basis external events

Containment Overpressure Protection System

- Hardened passive vent system
- Rupture disk actuates at 90 psig
- Ensures containment structural integrity and provides containment cooling
- COPS components located inside the Reactor Building

Substantial Battery Capability

- Four (4) Divisions of Class 1E batteries
- Class 1E batteries capable of more than 12,000 amp-hours
- Non-Class 1E 250V battery capable of more than 8,000 amp-hours
- Shedding of non-essential loads can extend Division I battery life to more than 40 hours

Alternate Spent Fuel Pool Makeup

- ACIWA is the preferred method of makeup to SFP via RHR piping
- Two external standpipes that can provide makeup and spray to the SFP were added to design as part of Mitigative Strategies for the Loss of Large Area of the Facility Effort

Summary of STP 3&4 Key Features

- ABWR was designed for an SBO with or without the CTG
- CTGs would be expected to provide power to mitigate this event using ECCS systems
- Additional enhancements to the design have been made for STP 3&4
- Even without crediting the CTGs; ACIWA, RCIC, and COPS can mitigate the extended loss of AC power

STP 3&4 FLEX Plan

- Based on industry guidance in NEI 12-06
 - Phase I – Installed equipment
 - Phase II – Portable equipment
 - Phase III – Offsite equipment
- STP 3&4 Phase I is 36 hours in length
- Phase III directly follows Phase I (no Phase II required)
- Offsite equipment arrives at the staging area within 24 hours of request, ready for use at 32 hours
- Beyond design basis limiting external event is a flood caused by a breach of the Main Cooling Reservoir

STP 3&4 FLEX Plan – Sequence of Events

- Extended Loss of AC Power (ELAP) and Loss of Normal Access to the Ultimate Heat Sink occurs at $t = 0$
 - All 6 offsite power connections, all 6 EDGs, and 2 CTGs not available
- Operators declare ELAP in 30 minutes
- Command and control relocated to Remote Shutdown System (RSS) room in 1 hour
- Perform load shed within 1 hour to extend Division I battery life to > 40 hours
 - Computer system is most significant battery load
- RCIC provides initial core cooling with suction from CST

STP 3&4 FLEX Plan – Sequence of Events *(continued)*

- RCIC suction switches to S/P due to Hi S/P level within a few minutes
- RCIC operated manually after load shed
- Request for offsite supplies at ~ 2 hours
- As S/P approaches 250 degrees F, RCIC suction switched to CST at ~ 10 hours
- COPS expected to actuate at ~ 20 hours
- Design Basis Flood has dissipated at ~ 20 hours
- Offsite equipment arrives at offsite staging area at 26 hours
- Offsite equipment in place and operational at 32 hours

STP 3&4 FLEX Plan – Sequence of Events *(continued)*

- Phase III starts in 36 hours
- When CST nears depletion (> 36 hours), core cooling transitioned to ACIWA
 - RPV depressurized using Safety Relief Valves (SRVs)
 - RCIC secured
- Ventilation restored in smoke purge mode
- Batteries being charged at 36 hours
- Command and control returned to Main Control Room
- ACIWA makeup to SFP initiated

STP 3&4 FLEX Plan – Sequence of Events *(continued)*

Long Term Actions:

- Restore normal AC service via EDGs or CTGs
- Restore DC loads
- Replenish ACIWA fuel oil supplies
- Connect UHS water supply to ACIWA
- Fill SFP as needed
- Restore normal core cooling functions
- Re-establish normal ventilation and cooling
- Restore AC service via offsite power

STP 3&4 FLEX Plan – Sequence of Events *(continued)*

Time critical steps :

- Declare ELAP in 30 minutes
- Relocate command and control to RSS room in 1 hour
- Perform load shed within 1 hour

Supporting Analyses

- Core and containment thermal-hydraulic analysis performed using MAAP Version 4.0.7
- Simulator scenarios performed to validate event timing and plan feasibility
- Electrical calculation performed to validate battery capability
- SFP heat-up calculations performed to determine when SFP replenishment is needed
- These analyses collectively demonstrate the FLEX Plan is viable:
 - Core, containment, and spent fuel cooling requirements met

ABWR Simulator



STP 3&4 FLEX Plan – Summary

Key safety functions maintained:

- Core Cooling
 - RCIC (0-36 hours)
 - ACIWA (beyond 36 hours)
- Containment Cooling via COPS
- Spent Fuel Cooling
 - No makeup needed for more than 36 hours
 - ACIWA
- Defense-in-depth

Conclusions

STP 3&4 ABWR has robust capability to mitigate a beyond design basis external event

- Plant is self-sufficient for more than 36 hours
- Core, containment, and spent fuel cooling maintained

Presentation to the ACRS Subcommittee

South Texas Project Units 3 and 4
COL Application Review

SER Phase 4 Chapter 22.2
Requirements Resulting From Fukushima Near-
Term Task Force Recommendation 4.2
“Mitigative Strategies”

December 3, 2014

Staff Review Team Chapter 22.2

- **Project Managers**

- Tom Tai, DNRL/LB2, Lead Project Manager
- Rocky D. Foster, DNRL/LB2, Project Manager

- **Technical Staff Review Team**

- Chang Li, SPSB, Senior Reactor Systems Engineer
- Thomas Scarbrough, MEB, Senior Mechanical Engineer
- Sheila Ray, NRR/EEEB, Senior Electrical Engineer
- James Gilmer, SRSB, Reactor Systems Engineer
- Nan Chien, SCVB, Reactor Systems Engineer
- Harry Wagage, SCVB, Senior Reactor Systems Engineer
- Sunwoo Park, Structural Engineer

Technical Topic

Chapter 22.2

- Chapter 22.2 Near-Term Task Force (NTTF)
 Recommendation 4.2
 Mitigative Strategies

Background

- March 11, 2011, Great Tohoku Earthquake and Tsunami in Japan
- July 12, 2011, SECY-11-0093 included twelve NTTF recommendations
- September 9, 2011, SECY-11-0124 addressed NTTF recommendations that could provide near term safety improvement
- October 3, 2011, SECY-11-0137 prioritized the NTTF recommendations
- February 17, 2012, SECY-12-0025 proposed orders and requests for additional information (RAIs) to be issued

Background (cont'd)

- March 12, 2012: Orders EA-12-049 and EA-12-051 issued
- Beginning in 2012, NRC staff issued RAIs to NINA for STP 3 & 4 actions on NTTF Recommendations 2.1, 4.2, 7.1, and 9.3
- June 25, 2012: In response to RAIs, NINA added Appendix 1E, “Response to NRC Post-Fukushima Recommendations,” to the STP 3 & 4 FSAR
- April 9, 2014: NTTF Recommendations 2.1, 7.1 and 9.3 presented to ACRS

Review Approach

- The NRC staff reviewed the STP submittal consistent with NRC Order EA-12-049 using guidance in JLD-ISG-2012-01, which endorsed NEI 12-06, with exceptions and clarifications.
- The Order states that mitigation strategies must be capable of mitigating a simultaneous extended loss of all ac power (ELAP) and a loss of normal access to the ultimate heat sink (LUHS), and must provide adequate capabilities to address challenges to core cooling, containment function, and SFP cooling for all modes of operation at all of the operating units on a site.
- The Order specifies a three-phase approach using installed equipment and resources for the initial phase, portable onsite and offsite equipment and resources for the transition phase and final phase respectively.
- The Order specifies that the equipment being relied on for mitigation strategies must be reasonably protected from external events.

Review Areas

- Phased approach and acceptance criteria,
- Core cooling,
- Containment function,
- SFP cooling,
- Power supply,
- Water and fuel supplies,
- Ventilation (control room habitability and equipment cooling),
- Instrumentation and emergency lighting,
- FLEX equipment and offsite resources.
- Evaluation of external hazards,
- Protection of equipment (structure),
- Mechanical equipment capability and programmatic controls.
- Multiple units at the site;
- Programmatic controls, including equipment maintenance and availability testing, procedures and training,
- Use of license conditions.

Phased Approach

In response to RAI 01.05-5, the applicant provided the “STP 3&4 ABWR FLEX Integrated Plan”, which proposed a two-phase approach:

- Initially cope by relying on installed plant equipment for 36 hours (Phase 1).
- Obtain additional capability and redundancy from offsite equipment for an indefinite duration (Phase 3).

Phased Approach (cont'd)

- The duration of 36 hours is sufficiently long compared to the duration of 24 hours in the guidance of NEI 12-06 for the combination of initial phase and transition phases. Onsite portable equipment are available for defense-in-depth purpose, but are not relied upon to perform the functional requirements.
- The functional requirements of core cooling using reactor core isolation cooling (RCIC) and AC-Independent Water Addition (ACIWA) systems, containment function using containment overpressure protection system (COPS), and SFP cooling using ACIWA can be satisfied by installed equipment. In Phase 3, portable pumps are used to support ACIWA system and FLEX diesel generators to provide power supplies.
- The proposed two-phase approach, which provides adequate capabilities to address the functional requirements of core cooling, containment and SFP cooling, serves the same purpose as the three-phase approach in Order EA-12-049.
- The staff finds the proposed approach acceptable.

Core Cooling

- If ELAP occurs when in Modes 1, 2 or 3, the RCIC pump starts automatically on low Reactor Pressure Vessel (RPV) level signal.
 - RCIC suction initially aligned to Condensate Storage Tank (CST), but automatically switches to Suppression Pool (SP) on High SP level signal
 - ABWR DCD credits RCIC operation for Station Black-Out (SBO) for up to 8 hours
 - MAAP code analysis justify extended RCIC operation to at least 36 hours with manual control
 - Phase 3 core cooling is provided by ACIWA system
- If ELAP occurs when in Modes 4 or 5, the ACIWA system can be used to maintain core cooling due to lack of steam pressure (depressurization of RPV by a safety relief valve is needed in Mode 4)

Core Cooling (cont'd)

- RCIC system is an advanced steam-driven turbine/pump system with a mono-block, totally self-lubricated design
- RCIC pump has a 250 F bearing design temperature limit
- Long-term cooling by ACIWA with water make-up and fuel supplied by Phase 3 equipment
- MAAP code calculation audit of August 20, 2014
 - Staff agrees that MAAP is an appropriate code for this analysis
 - Applicant made conservative assumptions regarding CST inventory

Containment Function/Ventilation

- Containment function is maintained by the use of the COPS
- COPS is a hardened passive vent system with rupture disk that actuates at 90 psig
- COPS vents from the suppression pool through the plant stack which has a radiation monitor powered by Class 1E power
- COPS remains available throughout Phase 1 and Phase 3
- COPS is located in Reactor Building and provides containment cooling while ensuring containment structural integrity

Containment Function/Ventilation

- RCIC Room Temperature Analysis
 - Phase 1
 - Environmental Qualification – RCIC room door/overhead hatch & stairwell door opened to allow for natural circulation
 - Reference DCD Chapter 3, Appendix 3I
- Remote Shutdown System (RSS) Room (Phase 1) and Main Control Room (Phase 3) Heat-Up Analysis
 - Habitability – Stairwell door opened to allow for natural circulation
 - Table D-2 of NUREG/CR-6146, “Local Control Stations: Human Engineering Issues and Insights”

SFP Cooling

Proposed Strategy

- Allowing the water in the SFP to boil from 23 feet above the top of the fuel racks to 10 feet above the top of the fuel rack, during the first 36 hours into ELAP,
- Monitoring SFP water level,
- Using installed equipment, ACIWA system, and water from Firewater Storage Tank (FWST) or Ultimate Heat Sink (UHS), to make up the water as needed to maintain the SFP water level 10 feet above the top of the fuel rack after 36 hours into ELAP.

SFP Cooling (cont'd)

Staff Review

- SFP water will be maintained 10 feet above the top of the fuel rack, which has sufficient margin to prevent fuel damage.
- ACIWA can provide water makeup for an extended period of time without ac power.
- As indicated in response to RAI 01.05-22, the applicant clarifies the ACIWA realignment. In Phase 3, SFP water makeup, if needed, is provided by manually opening valves F14C and F15C (Loop C double isolation between residual heat removal (RHR) Loop C and the fuel pool cooling). The connection at RHR Loop C is in the reactor building. The installed ACIWA pump provides flow to the RHR system piping and then to the SFP.
- The staff finds the proposed approach acceptable.

Water and Fuel Supplies

Proposed Strategies

- In Phase 1, RCIC takes water from the SP or CST, which is sufficient for the 36-hour Phase 1 period for core cooling. No water supply is needed for the containment function or SFP cooling during Phase 1.
- In Phase 3, ACIWA system takes water from one of the two FWSTs for core and SFP cooling. Once the water in the FWSTs is depleted, operator will shift the ACIWA suction to UHS, which has a water volume of approximately 16 million gallons. The UHS basin can be filled as needed via a restored well water system or tanker truck.
- A permanent piping connection to allow the ACIWA system to take suction from the water volume in the UHS basins will be installed.
- The RHR system provides the piping and valves that connect the ACIWA piping with the RHR Loop C pump discharge piping. Manual valves permit adding water from the FWSTs to the RHR system.

Water and Fuel Supplies (cont'd)

Proposed Strategies (cont'd)

- A single ACIWA pump can provide enough flow to maintain the vessel level for both units and still have sufficient flow to provide makeup for both SFPs.
- A backup to the pump is provided by a connection on the outside of the reactor building, which allows hookup of the ACIWA to a fire truck pump or trailer mounted pump.
- The ACIWA pump is designed with a minimum of 36-hour fuel supply.
- In Phase 3, operators will need to transfer diesel fuel oil, as necessary, from one of the three underground EDG fuel oil storage tanks to the ACIWA fuel oil storage tank using a staged portable pump and a small portable diesel generator.

Water and Fuel Supplies (cont'd)

Staff Review

- In the response to RAI 01.05-32 , the applicant clarified that the permanent piping to allow the ACIWA system to take suction from the water volumes in the UHS basins will be seismically designed. This piping will be robust, sub-surface, and protected from site hazards.
- The response proposes to revise FSAR Appendix 1E, Section 1E.2.4 to reflect this clarification.
- In Attachment 3 of the “FLEX Integrated Plan,” all the pumps and valves with power sources being used for the mitigation strategies are identified.
- The staff finds that the applicant has demonstrated sufficient capability regarding water and fuel supplies and pumping mechanisms for Phase 1 and Phase 3 mitigation strategies.

Reasonable Protection

- Order EA-12-049 specifies that the equipment being relied on for mitigation strategies must be reasonably protected from external events.
- According to NEI 12-06, this equipment should be designed to be robust and housed in robust buildings. Robust is defined as meeting the current plant design basis for the applicable external hazards with respect to seismic events, flood, and high winds and associated missiles.
- The review of the mitigation equipment and the protection levels for external events is set at a design basis level.
- The installed RCIC, ACIWA, and COPS are seismically qualified and are contained within robust structures that provide adequate protection against the applicable extreme hazards for the site.

Reasonable Protection (cont'd)

- ACIWA valves connecting to the RHR loop C are contained in the reactor building and the battery rooms are in the control building. Both buildings are Seismic Category I structures designed to withstand the effects of design basis external hazards.
- Onsite portable equipment including portable diesel generators and diesel-powered pumps and associated hoses and fittings is stored either in Seismic Category I structures or structures that are designed to withstand the effects of applicable external events.
- UHS is a Seismic Category I structure.
- The staff finds that the equipment being relied on for mitigation strategies will be reasonably protected from external events, consistent with the provisions of Order 12-049.

NTTF Recommendation 4.2

“Mitigative Strategies”

Power Supplies

- STP DC Power Systems
 - 4 Class 1E 125 VDC divisions – one battery per division
 - 1 non-Class 1E 125 VDC battery
 - 1 non-Class 1E 250 VDC battery

- Phase 1 – only available power sources are Class 1E 125 VDC station batteries
 - 36 hours via load shedding
 - Ensure battery divisions can provide power to the corresponding loads to maintain core cooling, containment, and SFP cooling

- Phase 3 – 2 FLEX 480 V, 1500kW diesel generators
 - Sufficient capacity to power the loads
 - Electrical isolation is maintained between the safety-related system and the FLEX power supplies

NTTF Recommendation 4.2

“Mitigative Strategies”

Power Supplies

- Phase 1 – only available power sources are Class 1E 125 VDC station batteries
 - Staff reviewed battery sizing calculation and confirmed the adequacy of the power supply
 - Staff performed 5 audits to support this portion of the review
 - Confirm battery sizing was performed (i.e. methodology) in accordance with IEEE Std. 485 and RG 1.212
 - Review battery duty cycle – loads and corresponding timeline
 - Ensure minimum battery voltage is met
 - Review environmental conditions of battery room
 - License condition to ensure battery calculation will be finalized based on as-built equipment characteristics
 - Ensure batteries can support duty cycles greater than 8 hour qualification

NTTF Recommendation 4.2

“Mitigative Strategies”

Mechanical

As indicated in response to RAI 01.05-24:

- All safety-related pumps, valves, and snubbers used in mitigation strategy are permanently installed equipment, and not relied on to perform functions beyond those credited in the design basis (except RCIC suction from SP will be allowed to increase to 250 F qualification temperature of RCIC pump bearings).
- All nonsafety-related pumps, valves, and snubbers used in mitigation strategy are permanently installed equipment, and not relied on to perform functions beyond those specified in ABWR DCD and STP 3 & 4 FSAR.
- Portable pumps used in mitigation strategy are two portable pumps used to transfer fuel oil to ACIWA fuel oil storage tank from diesel generator fuel oil storage tanks.

NTTF Recommendation 4.2

“Mitigative Strategies”

Mechanical

As indicated in response to RAI 01.05-25:

- Design, manufacture, testing, installation, and surveillance to provide assurance of seismic, environmental, and functional capability of safety-related pumps, valves, and snubbers used in mitigation strategy for an ELAP are specified in ABWR DCD and STP 3 & 4 FSAR.
- RCIC net positive suction head (NPSH) margin with increased SP temperature and containment overpressure acceptable based on conservative NPSH assumptions until suction shifted to CST when SP temperature reaches 250 F.
- Plant operators will monitor RCIC pump operation for adequate NPSH and will shift RCIC suction to CST if cavitation indicated.
- If RCIC becomes unavailable, plant operators will shift reactor vessel injection to the ACIWA system.

NTTF Recommendation 4.2

“Mitigative Strategies”

Mechanical

As indicated in response to RAI 01.05-26:

- All nonsafety-related pumps, valves, and snubbers used as part of mitigation strategy are part of ACIWA portion of the Fire Protection System (FPS).
- Design, manufacture, testing, installation, and surveillance requirements in ABWR DCD and STP 3 & 4 FSAR.
- Testing performed in accordance with Fire Protection Program and Maintenance Rule Program.
- ACIWA and FPS included in Design Reliability Assurance Program (D-RAP) and Maintenance Rule scope.
- FLEX Integrated Plan specifies ACIWA system is seismically qualified and contained within robust structures.
- ABWR DCD Chapter 14 specifies FPS preoperational testing.
- STP 3 & 4 Reliability Assurance Program and QA Program specify quality requirements for these components.

NTTF Recommendation 4.2

“Mitigative Strategies”

Mechanical

As indicated in response to RAI 01.05-27:

- Only portable equipment for ELAP mitigation strategy are two 120V pumps used to transfer fuel oil to ACIWA fuel oil tank from diesel generator fuel oil storage tanks.
- Portable pumps will be procured as commercial grade in accordance with STP 3 & 4 Quality Assurance Program.
- Detailed procedures will be developed for determination of critical characteristics to ensure commercial grade item is suitable for intended use.
- Quality evaluation will be performed during implementation of Operational Programs indicated in FSAR Section 13.4S.

NTTF Recommendation 4.2

“Mitigative Strategies”

Mechanical

As indicated in response to RAI 01.05-28:

- Specific operational programs listed in FSAR Section 13.4S will provide assurance of the functional capability of the pumps, valves, and snubbers used in mitigation strategy.
- Applicable operational programs include, for example, Fire Protection Program, Maintenance Rule, Motor-Operated Valve Testing Program, and Initial Test Program.
- Planned license condition will verify administrative program for configuration control, maintenance, and testing of equipment used in mitigation strategy with requirements for preventative maintenance, and testing procedures and frequencies.

NTTF Recommendation 4.2

“Mitigative Strategies”

License Condition

- Complete FLEX Integration Plan to maintain core cooling, containment, and SFP cooling capabilities during a simultaneous ELAP and LUHS:
 - Plant procedures
 - Guidance & strategies
 - Installation of FLEX equipment
 - Training program
 - Administrative control for configuration control, maintenance & testing
- Fully implement guidance & strategies for:
 - Procedures
 - Training
 - Acquisition, staging or installation of equipment & consumables
 - Configuration controls, provisions & procedures for maintenance & testing
- Perform a habitability analysis of the RCIC room, RSS room and the Main Control Room
- Update the design calculation for the Class 1E battery discharge to reflect “as-built” plant design
- Complete an integrated system validation of the ELAP timeline
- Maintenance of the guidance & strategies program

NTTF Recommendation 4.2

“Mitigative Strategies”


Discussion/Committee Questions

ACRS Action Item 64


**Fire Induced Spurious Signals from
DI&C Cabinets with Fiber Optic Cables**

12/3/2014

ESF Logic and Controls System (ELCS) Block Diagram



ESF Logic and Controls System (ELCS) Block Diagram



FSAR 9.5.1.1.7 Spurious Control Actions

- As stated above, the [ESF] systems are separated by fire areas on a divisional basis.
- The ESF Logic and Control System (ELCS) utilizes redundant fiber optic links to communicate ESF system level actuation status to the Remote Digital Logic Controllers (RDLCs), which control the remote input/output functions and the actuation of the electromechanical components.
- The RDLC utilizes diagnostics to **verify the validity** of each redundant message.
- The **redundant messages** received by the RDLC must **match** for component actuation to occur.
- The probability of spurious messages occurring on each of the redundant links that both pass the communication diagnostics and that also match between the two redundant links is essentially zero.



Presentation to the ACRS Subcommittee

South Texas Units 3 and 4 COL Application Review

Action Item #64: Fire-Induced Spurious Actuations in DI&C

December 3, 2014

Staff Review Team

- **Technical Staff**
 - ◆ Dennis Andrukat, SPSB (Presenter)
 - ◆ Dinesh Taneja, ICE2
 - ◆ Joe Ashcraft, ICE2
 - ◆ Wendell Morton, ICE2

- **Project Management**
 - ◆ Tom Tai, Lead PM
 - ◆ Luis Betancourt, Chapter PM

Fire Protection Review: Action Item #64

Background

- October 20, 2010 – ACRS Subcommittee
 - ◆ ACRS raised the concern regarding adverse effects due to fire on digital equipment

Conclusion

- NRC staff finds reasonable assurance that a fire will not prevent the ability to achieve and maintain safe shutdown.

Fire Protection Review: Action Item #64

Evaluation

- Applicant will follow NEI 00-01 and RG 1.189 for the hardwire portions of the electrical and I&C systems
- The staff finds the I&C architecture contains robust features (e.g., diversity, redundancy, reliability)

Fire Protection Review: Action Item #64

Evaluation

- Additional Layers of Protection:
 - ◆ Hardwire portions can be bounding
 - ◆ Each safety division physically and electrically isolated
 - ◆ Voting logic also helps maintain this isolation

Acronyms

- ACRS – Advisory Committee on Reactor Safeguards
- COL – Combined License
- DI&C – Digital Instrumentation and Control
- I&C – Instrumentation and Control
- ICE2 – Instrumentation, Controls and Electronics Engineering Branch 2
- NEI – Nuclear Energy Institute
- NRC – Nuclear Regulatory Commission
- PM – Project Manager
- RG – Regulatory Guide
- SPSB – Plant Systems Branch