

**Official Transcript of Proceedings**  
**NUCLEAR REGULATORY COMMISSION**

Title:                   Advisory Committee on Reactor Safeguards  
                              General Atomics Licensing Subcommittee

Docket Number:       (n/a)

Location:               teleconference

Date:                    Tuesday, May 2, 2023

Work Order No.:       NRC-2387

Pages 1-109

**NEAL R. GROSS AND CO., INC.**  
**Court Reporters and Transcribers**  
1716 14th Street, N.W.  
Washington, D.C. 20009  
(202) 234-4433

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S  
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, as reported herein, is a record of the discussions recorded at the meeting.

This transcript has not been reviewed, corrected, and edited, and it may contain inaccuracies.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

UNITED STATES OF AMERICA

NUCLEAR REGULATORY COMMISSION

+ + + + +

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

(ACRS)

+ + + + +

GENERAL ATOMICS DESIGN SUBCOMMITTEE

+ + + + +

TUESDAY

MAY 2, 2023

+ + + + +

The Subcommittee met via Teleconference,  
at 12:30 p.m. EDT, Vicki M. Bier, Chair, presiding.

COMMITTEE MEMBERS:

- VICKI M. BIER, Chair
- RONALD G. BALLINGER, Member
- CHARLES H. BROWN, JR., Member
- VESNA B. DIMITRIJEVIC, Member
- GREGORY H. HALNON, Member
- WALTER L. KIRCHNER, Member
- JOSE MARCH-LEUBA, Member
- DAVID A. PETTI, Member
- JOY L. REMPE, Member

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

ACRS CONSULTANTS :

DENNIS BLEY

STEPHEN SCHULTZ

DESIGNATED FEDERAL OFFICIAL :

WEIDONG WANG

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

AGENDA

<u>Item</u>	<u>Page</u>
ACRS Chairman Introductory Remarks . . . . .	4
NRC Staff Introductory Remarks . . . . .	7
GA-EMS Introductory Remarks . . . . .	9
Overview of GA-EMS FMR Design . . . . .	11
FMR Principal Design Criteria Topical Report - GA-EMS . . . . .	56
Draft Safety Evaluation for the FMR Principal Design Criteria Topical Report - NRC Staff . . . . .	68
Public Comments . . . . .	108

P-R-O-C-E-E-D-I-N-G-S

12:30 p.m.

CHAIR BIER: This meeting will now come to order. This is a meeting of the General Atomics Licensing Subcommittee of the Advisory Committee on Reactor Safeguards.

I am Vicki Bier, chairman of today's Subcommittee meeting. Here as members in attendance are David Petti, Charles Brown. Jose is here. Joy Rempe, Matt Sunseri, Ron Ballinger. Walt Kirchner I think will be back in a minute, probably. Greg Halnon is here.

Vesna, are you online? I can't really see.

MEMBER DIMITRIJEVIC: Yes, I am.

CHAIR BIER: Yes.

MEMBER DIMITRIJEVIC: Hi.

CHAIR BIER: Great. Thank you. And how about our consultants, Dennis Bley and Steve Schultz?

DR. BLEY: Dennis here.

CHAIR BIER: And it looks like Steve is also here. Apologies. I have to keep taking my glasses on and off for different distances. Okay.

Weidong Wang of the ACRS staff is the Designated Federal Official for this meeting.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1           During today's meeting the Subcommittee  
2 will review the staff's draft safety evaluation on the  
3 General Atomics Fast Modular Reactor principal design  
4 criteria. The Subcommittee will hear presentations by  
5 and hold discussions with the NRC staff, General  
6 Atomics' representatives, and other interested persons  
7 regarding this matter.

8           Parts of the presentations by the  
9 applicant and the NRC staff may be closed in order to  
10 discuss information that is proprietary to the  
11 licensees and its contractors pursuant to 5 USC 552  
12 (b) (C) (iv).

13           Attendance in the meeting that deals with  
14 such information will be limited to the NRC staff and  
15 its consultants, General Atomics, and those  
16 individuals and organizations who have entered into an  
17 appropriate confidentiality agreement with them.  
18 Consequently, we will need to confirm that we have  
19 only eligible observers and participants in any closed  
20 part of today's meeting.

21           The rules for participation in all ACRS  
22 meetings, including today's, were announced in the  
23 Federal Register on June 13, 2019.

24           The ACRS was established by the Atomic  
25 Energy Act and is governed by the Federal Advisory

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 Committee Act.

2 For background, the ACRS is intended to be  
3 independent of the NRC staff. ACRS issues publicly  
4 available letter reports that provide the Commission  
5 our independent technical reviews of NRC staff  
6 evaluations of the safety of proposed reactor  
7 facilities.

8 It is required by the Atomic Energy Act  
9 that ACRS participate in the reviews of submittals for  
10 new reactor licenses. As part of our review, we  
11 consider not only the staff's safety evaluations but  
12 also the original submittals by the applicant.

13 As part of our review process, ACRS  
14 members will ask questions and at times make  
15 statements. However, these statements are individual  
16 member opinions and should not be construed as ACRS  
17 findings or opinions. ACRS opinions are only as  
18 documented in our written letter reports.

19 The ACRS section of the U.S. NRC public  
20 website provides our charters, bylaws, agendas, letter  
21 reports, and full transcripts of all full and  
22 subcommittee meetings, including the slides presented.  
23 The meeting notice and agenda for this meeting were  
24 also posted there.

25 So far we have received no written

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 statements or requests to make an oral statement from  
2 members of the public.

3 The Subcommittee will gather information,  
4 analyze relevant issues and facts, and formulate  
5 proposed positions and actions as appropriate for  
6 deliberation by the full Committee.

7 A transcript of today's meeting is being  
8 kept and will be made available.

9 Today's meeting is being held in person  
10 and over Microsoft Teams for ACRS staff and members,  
11 NRC staff, and the applicant. There is also a  
12 telephone bridge line and a Microsoft Teams link  
13 allowing participation of the public.

14 When addressing the Subcommittee,  
15 participants should first identify themselves and  
16 speak with sufficient clarity and volume so that they  
17 may be readily heard. When not speaking, we request  
18 that participants mute your computer microphone or  
19 phone by pressing star 6.

20 We will now proceed with the meeting. And  
21 I'd like to start by calling up the NRR staff. And I  
22 believe that will be, sorry, Candace De Messieres.  
23 Sorry if I mispronounced that. Thank you.

24 MS. DE MESSIERES: Thank you, Chair Rempe  
25 and also Member Bier for the opportunity to present to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 the Committee today.

2 So I'm Candace De Messieres, Chief of the  
3 Advanced Reactor Technical Branch 2 in the Division of  
4 Advanced Reactors and Non-Power Production and  
5 Utilization Facilities, or DANU, in the Office of  
6 Nuclear Reactor Regulation.

7 Later in this meeting after the General  
8 Atomics design overview, the NRC staff will provide  
9 you with a summary of our review of the General  
10 Atomics Electromagnetic Systems, or GA-EMS, Fast  
11 Modular Reactor Principal Design Criteria Topical  
12 Report.

13 Like the light water-based general design  
14 criteria contained in Part 50, Appendix A, the PDC  
15 established the necessary design, fabrication,  
16 construction, testing, and performance requirements  
17 for structures, systems, and components that are  
18 important to safety. Accordingly, generation of  
19 adequate PDC is a foundational step on the path to  
20 licensing.

21 In our review of the GA-EMS PDC Topical  
22 Report, the NRC staff leveraged the information in  
23 Regulatory Guide 1.232 that was reviewed by the ACRS  
24 in 2018 and provides guidance for developing generic  
25 advanced reactor design criteria, or ARDC, for

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 technology specific sodium-cooled fast reactor and  
2 modular high temperature gas-cooled reactor PDC.

3 The staff also drew on its experience  
4 reviewing PDC for other advanced non-light water  
5 reactors, such as the Kairos Power fluoride salt-  
6 cooled high temperature reactor.

7 Thank you again for the opportunity to  
8 present to the Committee. And we look forward to  
9 hearing your insights and feedback later in the  
10 meeting. Thank you.

11 CHAIR BIER: Okay. I believe it is now  
12 time for the General Atomics introductory remarks by  
13 -- I'm not sure if that's -- oh, sorry, that's Aaron  
14 Majors I believe. And I don't know if you're in the  
15 room or online.

16 MR. MAJORS: I am online. Everyone hear  
17 me clearly?

18 CHAIR BIER: Yes.

19 MR. MAJORS: Thank you so much. I just  
20 want to start by saying thank you for taking the time  
21 out to have this review, very needed. And we're  
22 looking forward to hearing from the outcome of this  
23 meeting.

24 I'd like to say just a couple quotes that  
25 are apropos for safety. These authors are unknown.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 But no safety, know pain, but if you know safety, you  
2 have no pain. Also, safety doesn't happen by  
3 accident.

4 And those are the safety moments that we  
5 live by here at General Atomics. General Atomics has  
6 a long history of developing extremely safe reactors.  
7 And this history began with the TRIGA research in  
8 reactors and has evolved into high temperature gas-  
9 cooled reactors is where we are today with our Fast  
10 Modular Reactor, which is an answer to a growing  
11 market and the need for small, easily deployable  
12 reactors that provide great stability through rapid  
13 load following.

14 And so our main objective is the  
15 achievement of proper operating conditions and the  
16 prevention or mitigation of accident consequences to  
17 protect our workers, the public, and the environment  
18 from radiation hazards.

19 So we're really happy to be here and  
20 looking forward to the outcome. Thank you.

21 CHAIR BIER: Okay. Thank you. We're  
22 happy to have you here.

23 So now the first part of the presentation  
24 is the overview of the General Atomics Fast Modular  
25 Reactor design. And I believe the presenter for that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 is going to be John Bolin. Is that correct?

2 MR. BOLIN: That's correct.

3 CHAIR BIER: Excellent. Welcome.

4 MR. BOLIN: Okay. Let's see. Is this  
5 displaying as just a single slide?

6 CHAIR BIER: Yes. We now see your slides.

7 MR. BOLIN: Okay. All right. So this is  
8 going to be an overview of the conceptual design to  
9 date. And I'll continue. And I am the safety and  
10 licensing lead here at GA-EMS for the Fast Modular  
11 Reactor.

12 So, before I go on to this goal, I wanted  
13 to introduce our team. We have a very distinguished  
14 team of collaborators, including a strategic  
15 partnership with Framatome, on this Fast Modular  
16 Reactor design. We have worked with Framatome in the  
17 past on the gas turbine-modular helium reactor and  
18 worked together and competed against each other on the  
19 next generation nuclear plant.

20 We also have on our team EPRI. And EPRI  
21 has, as part of their team, they have enlisted to help  
22 Vanderbilt University.

23 We also have two other universities that  
24 are collaborating with us, the University of  
25 Wisconsin-Madison, under the leadership of Mike

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 Corradini, and the University of Texas at Arlington.  
2 And they're focused on the turbine machine design.

3 We also have the expertise of three  
4 national labs, Idaho National Lab, with both their  
5 BISON and ATR and TREAT expertise. And we also have  
6 Argonne National Lab, with their fast reactor fuel  
7 design expertise, and Sandia National Lab, with their  
8 MELCOR modeling expertise.

9 So the goal is to develop a Fast Modular  
10 Reactor. It's 44 megawatts electric. And, you know,  
11 it's intended for flexible power generation and easily  
12 dispatchable and carbon free. And we're targeting  
13 commercial operations by 2035.

14 The team is developing key design  
15 attributes. It is a fast spectrum reactor. We use  
16 helium inert gas as coolant. We have pellet loaded  
17 fuel rods. We are emphasizing site flexibility and  
18 small passive heat removal systems that will result in  
19 safe, maintainable, and cost effective nuclear power  
20 generation.

21 The FMR project officially started on 15th  
22 of December of 2021. It's a three-year program under  
23 the ARDP, Advanced Reactor Concepts 2020 Program.

24 MEMBER REMPE: Hey, John. This is Joy.  
25 You know how ACRS members always are rude and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 interrupt people. I don't know if --

2 MR. BOLIN: And I was going to say you  
3 guys can ask me questions any time.

4 MEMBER REMPE: Things haven't changed over  
5 years. But anyway, I don't know if you're too close  
6 to the mic or there's some tapping sounds. But it's  
7 hard to sometimes hear what you're saying. Do you  
8 have an idea what it could be? And maybe --

9 MR. BOLIN: It might be my coffee flask is  
10 jiggling a little bit. So maybe that's --

11 MEMBER REMPE: Okay. That would help.  
12 Thank you. Sorry to interrupt. But it was getting  
13 distracting. Thanks.

14 MR. BOLIN: Okay. All right. We'll see  
15 if that's improved.

16 MEMBER REMPE: That is better. Thanks.

17 MR. BOLIN: Okay. I'll go on to the Next  
18 slide. So the project objectives, you know, their  
19 focus is to enable future deployment, development and  
20 deployment. And so we're particularly interested in  
21 verification of key metrics in fuel, safety, and  
22 operational performance.

23 So, as stated here, we will look at the  
24 technical feasibilities. I mean, basically the  
25 conceptual design effort is to prove the technical

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 feasibility of the design, looking at high burn-up  
2 fuel operation, passive safety features, and rapid  
3 grid adaptability or load following.

4 The project obviously includes pre-  
5 application licensing activities with the NRC. That  
6 was a key desire of the DOE in their FOA. And the  
7 project will also conclude with an initial cost  
8 evaluation.

9 Like I said, the two focuses are on  
10 verification, both experimental and numerical  
11 verification. The experimental verification, we do  
12 have a fuel fabrication campaign that will result in  
13 a high burn-up irradiation test at, and transient test  
14 at ATR and TREAT to begin the qualification of the  
15 fuel design. And we'll go into that a little more in  
16 the later slides.

17 We also have scaled tests of the reactor  
18 vessel cooling system using the facility that  
19 University of Wisconsin-Madison has to further verify  
20 the passive cooling capability. In this case, the  
21 RVCS test facility that they have is actually between  
22 half scale and full scale of our RVCS design. So it  
23 will be a very interesting test.

24 We're also doing numerical verification.  
25 Part of this is the accident analysis work being done

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 both, or being done at UW-M. They are developing a  
2 MELCOR model. So that will support the design work  
3 and pre-application licensing.

4 We are also doing, with Sandia, a MELCOR  
5 model to simulate the FMR plant and to demonstrate  
6 rapid load following capability, also load rejection  
7 and basically a variety of operational transients.

8 Any questions so far? Okay.

9 Okay. This is the, this goes over our  
10 effort to design the FMR core to improve safety  
11 margin. Some of the things to note on this slide is  
12 the core power density. Oh, and I should -- and so,  
13 in this slide, I'm comparing numbers for the Fast  
14 Modular Reactor, the gas turbine-modular helium  
15 reactor, also designed by General Atomics, and the  
16 AP1000 PWR.

17 So, I mean, the first state, of course, is  
18 the output. The reactor output is quite low. It's  
19 100 megawatts thermal, you know, 6 times lower than  
20 the GT-MHR and much lower than the AP1000.

21 The power density is almost 15 megawatts  
22 per meter cubed. That's higher than the GT-MHR but  
23 much less than the AP1000.

24 The heat generated in the fuel, actually  
25 our number is similar to AP1000. Most of the heat

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 does get deposited in the fuel, of course. Pressure  
2 is 7 megapascals.

3 The other thing to note, it's not  
4 explicitly mentioned here. So the outlet temperature  
5 is not, you have to calculate the outlet temperature  
6 based on these numbers. So the FMR has an outlet  
7 temperature of 800 degrees C, while the GT-MHR had an  
8 outlet temperature of 850 degrees C. So we cut back  
9 the outlet temperature a little bit to improve safety  
10 margin.

11 The other thing to note, of course, is  
12 the, similar to the power density, the fuel rod  
13 average linear power is quite low, much lower than the  
14 AP1000.

15 And the other thing is the fuel height.

16 DR. BLEY: John?

17 MR. BOLIN: Yes.

18 DR. BLEY: This is Dennis Bley.

19 MR. BOLIN: Yes, Dennis.

20 DR. BLEY: I'm remembering back a long  
21 time ago, probably from the '70s. Excuse me. You had  
22 a fast reactor design way back then. And if you lost  
23 force circulation, you had about 45 seconds I think,  
24 if my memory is right, to get it back to prevent  
25 significant damage. How does this reactor look if you

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 lose force circulation?

2 MR. BOLIN: Well, there's two things that  
3 are in our favor. First off, we are using SiGA  
4 silicon carbide composite cladding. In fact, the  
5 whole fuel assembly is a ceramic composite cladding or  
6 ceramic composite material. And so it has a much  
7 higher temperature capability. But also we have  
8 greatly reduced the power density compared to the, I  
9 think you're referring to the gas-cooled fast breeder  
10 reactor --

11 DR. BLEY: That's probably true.

12 MR. BOLIN: -- back in the '70s. So the  
13 power density is much less.

14 And so, while I'm not going to present the  
15 accident results, the passive safety, we have  
16 engineered that so that we can safely cope with a loss  
17 of force circulation, loss of force cooling.

18 DR. BLEY: Okay. Thanks. I look forward  
19 to seeing more about that later.

20 MR. BOLIN: Sure. And like I said, so the  
21 cladding material is a SiGA silicon carbide composite.  
22 And we'll go into that a little bit more.

23 And the core height is also quite small  
24 compared to the other two designs shown here. It's  
25 only 1.8 meters in height. And this is the active

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 height. This is the fuel zone of the fuel assembly.

2 Okay. Any questions before I move on?

3 MEMBER PETTI: John, this is Dave Petti.

4 Are you going --

5 MR. BOLIN: Hi, Dave.

6 MEMBER PETTI: Hi. Are you going to show  
7 us some pictures of what a fuel assembly looks like?

8 MR. BOLIN: Yes, definitely.

9 MEMBER PETTI: Okay. Then I will wait.  
10 Thanks.

11 MR. BOLIN: Okay. In fact, it's, part of  
12 it is on the next slide here.

13 So the fuel design, it leverages both UO2  
14 legacy fuel development and SiGA cladding development.  
15 So we purposefully chose high density UO2 that's been  
16 proven in LWRs and tested in fast reactors in order to  
17 minimize the fuel development timeframe.

18 The silicon carbide composite cladding,  
19 SiGA, it's undergoing testing and maturation to the  
20 DOE accident tolerant fuel program. And in fact, SiGA  
21 cladding is being irradiated presently in ATR.

22 The fuel design uses, actually uses the  
23 ATF-LWR dimensions, you know, so that the cladding is  
24 the same size as that being developed for ATF. But it  
25 does have, the fuel design does have a large plenum

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 similar to what you find in the legacy liquid metal  
2 fast reactor fuel designs --

3 MEMBER REMPE: John. Oh, I'm sorry. Go  
4 ahead.

5 MR. BOLIN: Yes.

6 MEMBER REMPE: Okay. Did you finish your  
7 last sentence? I didn't mean to cut you off.

8 MR. BOLIN: Yes. Go ahead.

9 MEMBER REMPE: Okay. Well, I was curious  
10 if you could talk a little bit more about the end cap  
11 welding. There's an image shown here (audio  
12 interference) an end cap on with this SiGA material.  
13 And apparently you've made it through leak testing and  
14 pressure testing.

15 And how long has it been in the ATR? And  
16 how long is it scheduled to be in the ATR? Are they  
17 -- is it going through any PALM cycles in the ATR so  
18 it's sort of having some ramp testing?

19 MR. BOLIN: I don't know the details of  
20 that. I mean, we have made a lot of progress in the  
21 end cap welding. And these are sealed rodlets that  
22 have been hermetically tested and meet the hermeticity  
23 requirements. And they will go through a few cycles  
24 I believe. I don't know if it will go through a PALM  
25 or not. And I don't know the details of that.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MR. MAJORS: It's six cycles that our  
2 specimens will be in ATR.

3 MR. BOLIN: This is, I think she's  
4 particularly, Joy is particularly asking about --  
5 that's -- and Aaron is correct. So the ATF, I don't  
6 know about the ATF cladding that's being irradiated.  
7 The FMR cladding will also be, go through, like Aaron  
8 said, it will go through up to six cycles.

9 MEMBER REMPE: But you've not started that  
10 test yet --

11 MR. BOLIN: That hasn't started yet.

12 MEMBER REMPE: Okay.

13 MR. BOLIN: I'm going to --

14 MR. MAJORS: It starts in December.

15 MEMBER REMPE: Oh, okay. So it starts  
16 this December. And what is the peak temperature that  
17 this end cap weld has survived to date?

18 MR. BOLIN: I don't know the answer to  
19 that.

20 MEMBER REMPE: Okay. I just am curious.  
21 I mean, it's not necessary for this PDR report, but,  
22 or PDC report, but I just am --

23 MR. BOLIN: Yes.

24 MEMBER REMPE: -- curious on how far,  
25 because I know that was an issue for a lot of years.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MEMBER PETTI: John, just a question on  
2 the diameter of the UO<sub>2</sub>, because you mentioned about  
3 fast and thermal. Is it the size of a thermal UO<sub>2</sub> or  
4 a fast reactor UO<sub>2</sub> or somewhere in between?

5 MR. BOLIN: Well, I believe the fast  
6 reactor UO<sub>2</sub> was extremely small.

7 MEMBER PETTI: Right.

8 MR. BOLIN: So it's not like that. But --

9 MEMBER PETTI: Okay.

10 MR. BOLIN: -- density obviously is much  
11 less in the liquid metal fast reactor similarly. So  
12 the UO<sub>2</sub> pellet diameter is a little bit smaller than  
13 a standard UO<sub>2</sub> pellet, because we do have a somewhat  
14 larger gap between the pellet and the cladding --

15 MEMBER KIRCHNER: John, this is Walt  
16 Kirchner.

17 MR. BOLIN: It's basically the same as an  
18 LWR pellet.

19 MEMBER KIRCHNER: John, this is Walt  
20 Kirchner. So I'm thinking back to the prior work that  
21 GA did in this particular area. If I remember  
22 correctly, you were looking at uranium carbide pellets  
23 or platelets or different --

24 MR. BOLIN: Correct.

25 MEMBER KIRCHNER: -- designs, not UO<sub>2</sub>.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 For this reactor with a longer lifetime, what is the,  
2 what's the effective full power years of the UO2 in  
3 terms of burn-up?

4 MR. BOLIN: I think I will cover that.  
5 But it's 100 megawatt days per --

6 MEMBER KIRCHNER: Metric ton?

7 MR. BOLIN: Yes.

8 MEMBER KIRCHNER: That's pretty high  
9 compared to the UO2 that's used, because --

10 MR. BOLIN: Currently licensed, correct.  
11 It's higher than what's currently licensed. Fast  
12 reactor oxide fuel tests get to that burn-up and  
13 higher. But --

14 MEMBER KIRCHNER: Doesn't it center quite  
15 a bit? I thought that's why you were looking at  
16 uranium carbide and not UO2 previously.

17 MR. BOLIN: Well, the reason we were  
18 looking at uranium carbide, and we still are pursuing  
19 that reactor design, the centering is going to be much  
20 lower than you might expect because the UO2, peak UO2  
21 fuel temperature is much lower than LWRs. So, and  
22 I'll show you that. I think I show you that later.  
23 I might be getting my presentations mixed up.

24 But, you know, it's probably about, well,  
25 no, we'll see that, about 1,200 degrees C is the peak

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 fuel temperature.

2 MEMBER KIRCHNER: And then the grid  
3 material for the X bundle is what?

4 MR. BOLIN: Silicon carbide composite.

5 MEMBER KIRCHNER: Silicon carbide as well.

6 MR. BOLIN: Yes.

7 MEMBER KIRCHNER: Thank you.

8 MR. BOLIN: And the support tube is also  
9 silicon carbide. And you can see a picture of silicon  
10 carbide composite cladding and in the X-ray tomography  
11 of a cladding tube, and then as Joy mentioned, the end  
12 cap welding, which we think we have perfected. So,  
13 and it's ready for testing.

14 MEMBER PETTI: John, the grid plate is  
15 also silicon carbide?

16 MR. BOLIN: Yes.

17 MEMBER PETTI: Thank you.

18 MR. BOLIN: Okay. This goes into more  
19 detail, a little bit more detail of the different  
20 steps we've gone through to prepare for the ATR and  
21 TREAT irradiation capsules. Like I said, we've  
22 enlisted Argonne's help in looking at the BISON fuel  
23 model, looking at fission gas release and swelling.  
24 And all those eventual fuel failure mechanisms are  
25 also part of their modeling efforts.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1           And so that's informed our fuel design and  
2 analysis and, in particular, the analysis of these  
3 test rodlets. We are looking at both standard size  
4 rodlets and reduced diameter rodlets.

5           And like I said, we're going to do both  
6 ATR irradiation for up to six cycles. And we've also  
7 designed the rodlets with different size gaps to look  
8 at performance, you know, both standard fuel rod  
9 performance and performance where there would be  
10 pellet clad interaction in possible failure. So  
11 that's a design into the analysis and the  
12 experimentation. So --

13           MEMBER PETTI: So, John --

14           MR. BOLIN: Yes.

15           MEMBER PETTI: -- just a question on the  
16 clad. If this gets proprietary, let me know. But,  
17 you know, the last time I looked at SiC-SiC cladding  
18 for ATF, there were some seminal papers out of Oak  
19 Ridge that, given the delta T across the clad, you get  
20 some pretty serious tensile stress built up because of  
21 differential or irradiation swelling across it. I  
22 would imagine the lower power density helps you with  
23 that --

24           MR. BOLIN: Correct.

25           MEMBER PETTI: -- delta T. So, but, you

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 know, they've gone to things like liners and stuff.  
2 This is just SiC-SiC, nothing special?

3 MR. BOLIN: It's the standard ATF silicon  
4 carbide composite cladding. So it has the monolithic  
5 outside layer and the composite woven silicon carbide  
6 fiber, infiltrated silicon carbide in the inner layer.

7 And you're correct. Certainly the, you  
8 know, our power density is much lower than light water  
9 reactors. So the thermal gradients are much lower.  
10 Also, operating at a higher temperature is actually,  
11 for silicon carbide is actually a benefit, too. So  
12 swelling --

13 MEMBER PETTI: Sure.

14 MR. BOLIN: -- swelling and irradiation  
15 damage is less at higher temperatures. So we have  
16 both of those factors in our favor.

17 MEMBER PETTI: Thanks.

18 MEMBER REMPE: Out of curiosity -- I'm  
19 sorry. Is someone else -- do you want to go first?

20 DR. SCHULTZ: That was me, Steve, Joy.  
21 You go ahead.

22 MEMBER REMPE: Oh, well, I was just --

23 DR. SCHULTZ: I'll come in next.

24 MEMBER REMPE: Okay. I was curious about  
25 the instrumentation and what you're trying to validate

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 with these, or verify with these tests. Are you, is  
2 it just temperature or are you -- and then post-  
3 irradiation examinations or are you going to try and  
4 do any other type of measurements online that --

5 MR. BOLIN: No, no other --

6 MEMBER REMPE: -- tests?

7 MR. BOLIN: No other measurements online.  
8 But we will look at, post-irradiation examination  
9 we'll look at fuel physical changes and fission gas  
10 release. So that will be looked at.

11 Actually, it's in that box right there.  
12 The PIE will look at fission gas release and fuel and  
13 cladding deformation. And particularly in the cases  
14 where we have reduced gap between the fuel and the  
15 cladding, you know, there's a possibility of cladding  
16 fracture that also needs to be looked at.

17 MEMBER REMPE: Will you have temperature  
18 instrumentation in the tests themselves?

19 MR. BOLIN: The fuel itself will not be  
20 temperature monitored, no.

21 MEMBER REMPE: Okay. And just to caution  
22 --

23 MR. BOLIN: At least not in the ATR  
24 capsule. I don't believe it's in the ATR capsule.  
25 The TREAT capsule may have instrumentation for that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 transient test.

2 MEMBER REMPE: In ATR sometimes small  
3 geometry changes that are within specifications can  
4 lead to interesting changes in temperatures that you  
5 don't expect. It's just a caution.

6 Anyway, Steve, go ahead.

7 DR. SCHULTZ: My question was related,  
8 John. And that is, in the testing, are you going to  
9 achieve those temperatures that you anticipate in the,  
10 for the reactor design parameters? The first  
11 question.

12 MR. BOLIN: Yes. In fact, we will have  
13 higher fuel temperatures than FMR will experience.  
14 We'll have higher temperatures.

15 DR. SCHULTZ: Good. And for the six  
16 cycles of operation, what burn-up do you expect to  
17 achieve in the fuel test?

18 MR. BOLIN: We will get close to 100  
19 megawatt days for burn-up.

20 DR. SCHULTZ: Good. Thank you.

21 MR. BOLIN: It's a very, unfortunately I  
22 think, but it is a very accelerated test.

23 DR. SCHULTZ: It certainly appears that  
24 way. Thank you.

25 MR. BOLIN: Yes.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1           This just goes over the FMR test rodlets.  
2           And like I said, they are being fabricated. Actually,  
3           the rodlets have been fabricated. And they are going  
4           to be loaded with UO2 pellets actually next week. And  
5           then they'll be, the final end cap will be welded on  
6           and shipped to INL for insertion into ATR at the end  
7           of the year. So the fuel pellet processing is  
8           basically standard UO2 fuel pellet processing.

9           The other steps are part of the silicon  
10          carbide composite cladding fabrication. The silicon  
11          carbide fiber is braided together, then infiltrated  
12          with silicon carbide, and then both infiltration and  
13          then deposition of an outside silicon carbide layer.  
14          Pellets are then loaded. And then the final end cap  
15          is sealed. So this is obviously a key accomplishment  
16          of our conceptual design effort is to actually make  
17          these fuel rods and to have them tested.

18          We were particularly, it was particularly  
19          important to us to not just do a paper study on  
20          conceptual design, but to actually do, like we  
21          mentioned earlier, experimental verification of the  
22          design.

23          The other, of course, part of our defense  
24          in depth is the vessel system. We have a, the vessel  
25          is sized, you know, for normal operation AOO

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 conditions. The design code, the ASME design code, of  
2 course, is used. That is Section 3, Division 5, the  
3 2021 edition.

4 Right now the thickness is adequate for  
5 300,000 hours or 35 effective full power years based  
6 upon the code. The code data does suggest very little  
7 change out to, because of the temperatures that we're  
8 at, very little change out to 60 years. And so a  
9 future code revision should not have an impact on our  
10 vessel design.

11 But we're also, one of the key problems  
12 with gas-cooled reactors, helium gas-cooled reactors  
13 is, of course, helium leakage. And so we pay  
14 particular attention to using seal welds at all joints  
15 to minimize helium leakage.

16 And another interesting thing is that a  
17 lot of accidents and even load following, you know,  
18 involve flow reductions. As we'll go over on the next  
19 slide, we'll see, I'll discuss about the flow  
20 reductions through normal operation. But all these  
21 events, because we're using a Brayton cycle, the  
22 pressure load on the vessel decreases during these  
23 flow reductions.

24 MEMBER MARCH-LEUBA: John, this is Jose  
25 March-Leuba. Just a layman question, you mentioned

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 earlier an exit gas temperature of 800 degrees C.

2 MR. BOLIN: Correct.

3 MEMBER MARCH-LEUBA: What materials are  
4 you using for the hot leg and the vessel? And what  
5 temperatures do they have to survive?

6 MR. BOLIN: Well, so, like the GT-MHR, we  
7 do have a cross vessel that connects the reactor  
8 vessel to the power conversion unit. And so it has,  
9 the hot gas in on the inside of this cross vessel.  
10 There's an insulated layer on the inside of this cross  
11 vessel that then protects.

12 And then we have cold helium. Cold is a  
13 relative term, you know. It's 509 degrees C on the  
14 outside of this duct. And, you know, the layer that  
15 connects to the cross vessel sees that 509 degrees C.  
16 So all of the vessel materials are 509 degrees C or  
17 lower.

18 MEMBER MARCH-LEUBA: The gas is the one  
19 that has 7 megapascals. Somebody has to contain the  
20 helium. I hope you have thought through this. I  
21 don't know anything about this, but --

22 MR. BOLIN: It certainly is something we  
23 have dealt with on numerous, particularly the GT-MHR  
24 gas-cooled reactor design has looked at this  
25 extensively.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 MEMBER MARCH-LEUBA: Yeah, and another  
2 question I know even more about. You don't mention  
3 anything about reactivity control. How do you plan to  
4 control reactivity?

5 MR. BOLIN: We have both control rods, I  
6 think boron carbide control rods and shutdown rods.  
7 They will have also silicon carbide cladding.

8 MEMBER MARCH-LEUBA: But they're not shown  
9 here in the picture, right? I don't see --

10 MR. BOLIN: No, no. Just the upper drive  
11 mechanisms are shown there.

12 MEMBER MARCH-LEUBA: Yeah, one important  
13 concern when you go for the final certification will  
14 be, priming along is the control rod has to be a  
15 design, has to have a design temperature that is  
16 higher than the fuel. In other words, you should not  
17 have an accident when you can meld a control rod and  
18 leave the fuel intact, because that would be bad.

19 MR. BOLIN: Yes.

20 MEMBER MARCH-LEUBA: So you're saying your  
21 design --

22 MR. BOLIN: That's why we are using  
23 silicon carbide cladding for the control rods. I  
24 don't know. Yeah.

25 MEMBER MARCH-LEUBA: And you said boron

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 carbide inside?

2 MR. BOLIN: Yes.

3 MEMBER MARCH-LEUBA: Okay.

4 MR. BOLIN: I guess my final comment was  
5 that the conceptual design has been completed on the  
6 reactor vessel internals. We're still working on the  
7 details of the power conversion system, which I'm  
8 going to discuss on the Next slide. And also this  
9 shows the arrangement of neutron shields around the  
10 core, of course. And there is a core shroud that  
11 protects the vessel top head from the high temperature  
12 gas exiting the core. So that's also an insulated  
13 layer that protects the top head.

14 Cold helium coming into the reactor goes  
15 all the way around the vessel and down the outside  
16 core barrel and into the lower portion of the vessel  
17 head and then up through the core.

18 MEMBER PETTI: John?

19 MR. BOLIN: Yes?

20 MEMBER PETTI: Just a question on your  
21 outer reflector. Is it stainless steel like in sodium  
22 systems? Or I know you guys had a design once with  
23 beryllium carbide as an outer reflector.

24 MR. BOLIN: No, we're using -- zirconium  
25 silicide is our reflector that's adjacent to the fuel.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 It is zirconium silicide. It's a product that we're  
2 developing that we think it is a better reflector. I  
3 mean, it's not as good as stainless steel, but,  
4 fortunately, it has higher temperature capability.  
5 And it helps to minimize, then, fuel rod peakings  
6 along the reflector edge.

7 MEMBER KIRCHNER: And the upper and lower  
8 reflectors, are they the same or --

9 MR. BOLIN: The reflector that is right  
10 next to the fuel is always going to be zirconium  
11 silicide. Now, the outside reflector, outside of the  
12 zirconium silicide, we'll be using graphite, and I  
13 think, also, on the bottom.

14 MEMBER KIRCHNER: Upper and lower  
15 reflectors are graphite?

16 MR. BOLIN: Well, below -- like I said,  
17 there's always a zirconium silicide layer immediately  
18 next to the fuel, the core. So, both the upper and  
19 lower part is, first, zirconium silicide, and then,  
20 graphite. In the core, I don't think that's the case,  
21 but in the outer reflector that's the case. And the  
22 lower reflector, that definitely is the case, yes.

23 MEMBER PETTI: But the inner reflector  
24 has, like, an annulus of graphite?

25 MR. BOLIN: Yes -- no, no. The inner

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 reflector is always zirconium silicide.

2 MEMBER BALLINGER: This is Ron Ballinger.

3 I understand 300,000 hours, but I don't  
4 understand 540,000 hours. You say, "Code revision."  
5 Is this talking about Division 5 again?

6 MR. BOLIN: Yes, but, right now, the  
7 material, 316 stainless steel, is only allowed up to  
8 300,000 hours.

9 MEMBER BALLINGER: Right.

10 MR. BOLIN: And so, future ASME Code  
11 revision is intended to extend that to 540,000 hours.

12 MEMBER BALLINGER: And that's in process?

13 MR. BOLIN: Yes. And the data, of course,  
14 already exist and shows very little change between  
15 300,000 hours and 540,000 hours. So, it's not  
16 expected to have any design impact.

17 MEMBER PETTI: What's the vessel material  
18 again?

19 MR. BOLIN: 316 stainless steel.

20 MEMBER PETTI: Okay.

21 MR. BOLIN: Okay. So, the next slide goes  
22 over a little bit on the power conversion system.  
23 This is fairly standard for gas turbine design. It is  
24 a direct Brayton cycle. I know it's maybe hard to  
25 see. And I don't go into the details on the core

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 side.

2 So, exit temperature from the reactor goes  
3 to the turbine, where, obviously, it goes down in  
4 temperature and pressure. It goes through the  
5 recuperator. So, the turbine outlet temperature is,  
6 basically, directing the reactor inlet temperature.  
7 So, there's a heat exchange between these two fluid  
8 streams.

9 From the recuperator, it goes to a pre-  
10 cooler that cools the helium before going to the low  
11 pressure compressor. And we have an intercooler in  
12 this design. So, from the low pressure compressor,  
13 you go to the intercooler. So, the heat that is added  
14 during the compression process in the low pressure  
15 compressor is removed by the intercooler, and that,  
16 then, goes to the high pressure compressor, and then,  
17 goes to the recuperator, and then, to the reactor.

18 So, this provides a high efficiency. And  
19 like we said, it's the net -- the electrical output  
20 from the generator is 44 megawatts electric.

21 The other interesting thing that enables  
22 rapid load following is that we are using a GA  
23 product, a current magnet motor generator. It is a  
24 variable frequency generator. So, it can change its  
25 rotational speed as needed. So, we can change the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 flow rate to the reactor by controlling the frequency  
2 and speed of the current magnet motor generator.

3 It goes through an AC/DC-AC frequency  
4 converter to get to the grid frequency. And, of  
5 course, that goes to the grid.

6 And so, this combination allows us to  
7 change the speed of the generator, change the speed of  
8 the turbine machinery, and thereby change the flow  
9 rate through the core. But, at the same time, while  
10 we're doing that, we're maintaining the frequency  
11 that's being fed to the grid.

12 And so, it promotes both rapid load  
13 following -- we're shooting for 20 percent per minute  
14 load following changes, but, also, it promotes grid  
15 stability. So, those are two things that we see as  
16 being important to the market in the future, and  
17 particularly, as the electric market gets more and  
18 more intermittent renewable energy sources.

19 MEMBER MARCH-LEUBA: And this is Jose  
20 again.

21 With those power rates 20 percent per  
22 minute, have you analyzed what happens to the UO2  
23 pellets?

24 MR. BOLIN: So, that is going to be part  
25 of our modeling that is still ongoing.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MEMBER MARCH-LEUBA: Yes, because in the  
2 life of the reactors, if you ramp up like that, you  
3 will blow up the zirconium.

4 MR. BOLIN: Well, you know, the --

5 MEMBER MARCH-LEUBA: Yeah.

6 MR. BOLIN: Yeah. And, I mean, there's  
7 two things that are in our favor: lower power density  
8 and the silicon carbide is quite strong. And although  
9 sometimes it's viewed as a negative, the fact that  
10 it's not very ductile also means it keeps its shape,  
11 even if the pressure inside is increasing.

12 MEMBER REMPE: John, I just assumed that  
13 the TREAT test would encompass that. That's not going  
14 to -- you're not going to try to run the presentient  
15 (phonetic) test to such changes?

16 MR. BOLIN: The TREAT test is a  
17 reactivity-initiated accident. So, it is doing that,  
18 a reactivity-initiated accident simulation, not a load  
19 following test.

20 MEMBER REMPE: But the ramp and the change  
21 in power, wouldn't that --

22 MR. BOLIN: It should bound any reactivity  
23 -- it should bound any load following change.

24 MEMBER REMPE: Yes, I would think it  
25 would. Either that or -- it seems like you would want

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 to test that before you start doing load following in  
2 the reactor.

3 MEMBER BALLINGER: This is a very  
4 different paradigm. I mean, we've got to stop  
5 thinking about zirconium cladding, because the  
6 zirconium, that's what the load following problem was  
7 for in light water reactors. It was for zirconium  
8 cladding. It only takes 10 or 20 degrees C to crack  
9 the UO2 at delta T. So, it's really the silicon  
10 carbide that's got to take it, and it's very rigid  
11 compared to zirconium, and there's no environment.

12 So, it's a different way of having to  
13 think of it. It requires a heck of a lot more data  
14 and experiments, but it's a very different fuel  
15 system.

16 MEMBER REMPE: Yes, but I just think I  
17 would rather test it out of the reactor.

18 MEMBER BALLINGER: I'll agree with you.

19 (Laughter.)

20 MEMBER REMPE: Yes, ahead of time.

21 MEMBER BALLINGER: Yes.

22 MEMBER REMPE: And I would find some way  
23 of doing it.

24 MEMBER BALLINGER: Yes.

25 MEMBER REMPE: But it's not included in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 your plans?

2 Also, there's a lot of feedback, and I  
3 don't know -- John, again, there's something with your  
4 system, it looks like, according to the computers here  
5 in the room.

6 MR. BOLIN: Oh, well, I mean, it could be  
7 the fan in my laptop. So, I'm not sure I could  
8 control that.

9 MEMBER REMPE: We did have that happen  
10 with one of our members. Don't turn off your  
11 computer. But, anyway, it started up recently, yes,  
12 but anyway, you're going to have to have your managers  
13 buy you a better computer.

14 (Laughter.)

15 MEMBER REMPE: But, anyway, yes, so you do  
16 not have any plans to try and -- you're just going to  
17 do it by analysis?

18 MR. BOLIN: Just do it by analysis for  
19 now, yes.

20 CHAIR BIER: While we're paused here, I  
21 also to check and see if Aaron had any comments or  
22 clarifications that he wanted to add. Because  
23 anything in the chat does not make it into the  
24 transcript and the public meeting.

25 I guess maybe not right now.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MEMBER KIRCHNER: So, John, this is Walt  
2 Kirchner.

3 So, on this one, you're probably not going  
4 to try and put a bottoming Rankine cycle on this?

5 MR. BOLIN: No.

6 MEMBER KIRCHNER: No? Okay.

7 MR. BOLIN: The temperature coming out the  
8 recuperator is on the order of between 150 and 200  
9 degrees C. So, there's not much left to take out.

10 MEMBER KIRCHNER: Okay. Right.

11 MR. MAJORS: Chairman? Chairman, my  
12 apologies, I was on mute talking. I'm sorry.

13 CHAIR BIER: Okay, go ahead, Aaron.

14 MR. MAJORS: I was just following up.  
15 Someone had asked the question about the peak  
16 temperature survival for the end caps. And I just  
17 wanted to add -- I didn't get a chance to interject  
18 because you guys were rapid-firing questions, which is  
19 great. We're trying to transcribe all these questions  
20 as well for our technical team. But I just wanted to  
21 add some points of reference.

22 So, our high-temperature gas application  
23 for joining our end caps is sufficient for normal  
24 operating and accident performance. So, our end caps  
25 are stable up to 1900 degrees Celsius for inert

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 environments and 1750 for steam.

2 MEMBER REMPE: Thank you.

3 CHAIR BIER: Any other questions or  
4 comments for Aaron?

5 MEMBER KIRCHNER: Could you share who your  
6 fuel vendor is, or is that TBD?

7 MR. MAJORS: Fuel vendor is TBD.

8 MEMBER KIRCHNER: TBD? So, it's not one  
9 of the fly rod manufacturers? I'm thinking of Orvis,  
10 Sage, Winston. This is a joke. The technology that  
11 you're describing is what's used to make graphite fly  
12 rods for the cladding.

13 MEMBER BROWN: They'll use Loomis.

14 MEMBER KIRCHNER: Loomis? Okay.

15 (Laughter.)

16 MEMBER REMPE: And so, maybe this was in  
17 the reading material that I've forgotten, but this  
18 variable frequency generator, has anyone used it? Has  
19 it been built? What's its status?

20 MR. BOLIN: This is a proven product at  
21 GA-EMS. We have built an 8-megawatt version of both  
22 the current magnet motor generator -- and the  
23 frequency converter, we build that in modular fashion.  
24 So, we have, I believe -- and, Aaron, you can correct  
25 me -- I think we have 1-megawatt electric modules that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 we have built. And so, they're assembled in a modular  
2 fashion.

3 And so, for the 44-megawatt, we will be  
4 scaling both the current magnet motor generator up and  
5 the frequency converter up. But we have already  
6 proven the design at a reduced scale.

7 MEMBER REMPE: Okay. Thank you.

8 MR. BOLIN: And also on this slide, I  
9 wanted to address -- we purposefully chose to use dry  
10 cooling, even though that does have an efficiency  
11 penalty. But that, clearly, will reduce the impact on  
12 water resources and expands our siting options,  
13 particularly, if you consider that a lot of the solar  
14 and wind generation is going to be in possibly dry  
15 areas of the West. So, that was a deliberate  
16 selection on our part.

17 MR. FAIBISH: John, can I chime in? This  
18 is Ron Faibish with General Atomics. Can I chime in  
19 on something about silicon carbide?

20 MR. BOLIN: Sure.

21 MR. FAIBISH: I just wanted to add --  
22 there were a lot of questions about the cladding. And  
23 we have had campaigns at HFIR in Oak Ridge on  
24 irradiation and prototypical conditions of 800 degrees  
25 C of (audio interference) and outlets.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1           So, variability was both shown -- and this  
2 was, actually, a campaign back for EM-Squared back  
3 when we were actively pursuing that design. The  
4 outlet temperature of 800 degrees C is very  
5 applicable, obviously, for FMR.

6           And also, in addition to that, as John  
7 mentioned, there is a campaign starting at ATL to do  
8 additional testings. So, that's up and coming.

9           But I just wanted you to know that silicon  
10 carbide has been exposed to irradiation and to high-  
11 temperature conditions and showing good results. And  
12 I think we're going to get more information to you, as  
13 needed, from previous tests. So, I just wanted to  
14 chime in on that.

15           Thanks, John.

16           MR. BOLIN: Thank you, Ron. Okay. Let's  
17 move on. Well, let's see.

18           And, obviously, in a defense-in-depth, you  
19 know, the third barrier we have is the containment.  
20 Now, this is, unlike a lot of gas-cooled reactors,  
21 this is, actually, a leak-tight containment. It is  
22 below grade, like most gas-cooled reactors have been  
23 below grade, but it is a leak-tight containment.

24           This was a deliberate selection to prove  
25 safety and siting. Obviously, it also has an impact,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 then, on fuel development and qualification.

2           Clearly, with TRISO fuel, there's a high  
3 standard that TRISO fuel has to meet. And by having  
4 a containment, we provide that extra defense for  
5 potential fuel failures during severe accidents.

6           This also shows the arrangement of the  
7 reactor. I don't know how I can get a pointer on  
8 this. Let's see. There we go. Can you see that?  
9 Yes, you can.

10           So, obviously -- maybe not obvious -- this  
11 was the arrangement that was presented in the  
12 proposal. So, it doesn't reflect concept design work  
13 to date, but here is the reactor vessel. And around  
14 the reactor vessel is the reactor vessel cooling  
15 system, which we'll cover in the Next slide. And  
16 then, in another compartment is the power conversion  
17 unit, the power conversion vessel. We also have --  
18 which will also be covered in the next slide -- the  
19 maintenance cooling system. So, that is an active  
20 forced cooling system that is provided in case the  
21 power conversion system is unavailable. It is non-  
22 safety-related. Well, I'm getting ahead of myself.

23           And also, above --

24           MEMBER PETTI: John, functionally, it's  
25 like the shutdown cooling system in a HTGR?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MR. BOLIN: Correct. Correct.

2 MEMBER PETTI: Thanks.

3 MR. BOLIN: Functionally, it's like the  
4 shutdown cooling system.

5 It is also like the direct reactor  
6 auxiliary cooling system of liquid metal reactors, and  
7 EM-Squared had that kind of a system, a forced cooling  
8 system.

9 And up above here, we have RVCS water  
10 tanks, which I'll also discuss in the Next slide. So,  
11 this is just a general arrangement of the structure,  
12 the below-grade structure, of the containment. And  
13 it's a Category 1 structure.

14 The need for containment heat removal,  
15 cleanup, and venting, those are still under  
16 investigation. It is something addressed as a  
17 possibility in the PDCs as something that might be  
18 necessary, but it's still under investigation.

19 Obviously, below-grade containment is  
20 intended to also make us less vulnerable to airplane  
21 crashes.

22 MEMBER PETTI: John, I wanted to go back  
23 for a minute to the Brayton cycle.

24 MR. BOLIN: Go back to that slide?

25 MEMBER PETTI: No, no, just a question on

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 it.

2 On the bigger machines, there was always  
3 a lot of development to get it to work, but at these  
4 smaller sizes, I know that you can get such components  
5 for gas systems. What's the status for helium  
6 systems? Are they commercially available or?

7 MR. BOLIN: No, they're not commercially  
8 available. We have not identified a manufacturer.  
9 Clearly, there are a variety of turbine manufacturers  
10 that we could choose from, but no one is building  
11 helium turbine machinery. Obviously, there are air-  
12 driven --

13 MEMBER PETTI: Right.

14 MR. BOLIN: -- turbine machines, but no  
15 helium ones.

16 MEMBER PETTI: Thanks.

17 MR. BOLIN: Sure. Okay. So, like I  
18 alluded to, we have residual heat is being removed by  
19 both active and passive systems. Really, the first  
20 line of defense is the power conversion system itself.  
21 We are, in particular, designing the system so that,  
22 if there is a grid disruption, that the power  
23 conversion system will ramp down and provide house  
24 loads and cool the reactor at house loads.

25 But if the power diversion system is the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 source of the problem, then the maintenance cooling  
2 system is available to remove core residual heat after  
3 reactor shutdown. And so, like we said, it is similar  
4 in function to the shutdown cooling system.  
5 Basically, it's taking hot helium out of the reactor,  
6 bringing it over helium-to-water heat exchanger, and  
7 then, circulating that back into the reactor, and  
8 basically, cooling the core. Details are still being  
9 worked on.

10 And so, that water is cooled in a cooling  
11 tower by forced air. So, all that system is intended  
12 to be not safety-related.

13 The safety-related system is the RVCS,  
14 although it has, actually, also has a non-safety-  
15 related component to it. So, the RVCS, the Reactor  
16 Vessel Cooling System, has two loops. The panel of  
17 two loops surrounding the reactor has alternating  
18 tubes of one loop or the other loop.

19 The water in the RVCS circulates naturally  
20 by buoyancy-driven flow. The water goes into a tank.  
21 So, this tank -- there's two tanks. Like I say,  
22 everything is redundant. There's also two of these  
23 cooling towers, and both of these cooling towers have  
24 a -- there's a heat exchanger in the RVCS tank that is  
25 cooled by this cooling tower. So, it keeps the water

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 in the tank cold during normal operation -- both  
2 tanks. Like I said, there's another cooling tower  
3 with heat exchangers that's cooling this tank.

4 In an accident where we lose power, you  
5 know, for the safety-related portion of the system,  
6 the cooling tower is not safety-related. The pump for  
7 this water is not safety-related. So, this whole  
8 cooling system of the tank is not safety-related. So,  
9 during an accident where we lose all non-safety-  
10 related systems, then the RVCS loses heat by boiling  
11 off water from the water tank. And the water tank is  
12 sized so that we have seven days of boil-off with just  
13 one loop. And obviously, if we have both loops that  
14 are functioning, then we have, you know, much longer  
15 capacity to cool the reactor and vessel system.

16 Also, like many gas-cooled reactors, we  
17 have an annular core arrangement that promotes passive  
18 heat removal from the core through the reflector.  
19 This, actually, like I said, this shows the zirconium  
20 silicide reflector -- is this green. The blue is also  
21 zirconium silicide. The central zone is also  
22 zirconium silicide. And there is a graphite outer  
23 layer outside of the zirconium silicide.

24 And there's three, yes, three fuel zones.  
25 We have a three-batch core. And every 15 or more

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 years, we have a refueling and we replace one-third of  
2 the core.

3 Let's see. I think that's all I need to  
4 say about this slide. Any questions on this slide?

5 MEMBER KIRCHNER: So, John, this is Walt  
6 Kirchner again.

7 MR. BOLIN: Yes?

8 MEMBER KIRCHNER: So, on this MCS, then,  
9 you said that's not a safety-grade system. So, you  
10 must have isolation valves to and from the helium  
11 circuit?

12 MR. BOLIN: It is a --

13 MEMBER KIRCHNER: Because you have a water  
14 heat exchanger there.

15 MR. BOLIN: We have isolation valves on  
16 the waterlines, definitely. But the MCS is in the  
17 containment. So, we have a --

18 MEMBER KIRCHNER: So, you're designing for  
19 the potential that you would have a break in that line  
20 --

21 MR. BOLIN: We'd have a break in --

22 MEMBER KIRCHNER: -- and the containment  
23 would have the pressure rating --

24 MR. BOLIN: Correct.

25 MEMBER KIRCHNER: -- to withstand that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1       blowdown?   Okay.

2                   MR. BOLIN:   Correct.   So, the MCS is one  
3       of our sources of primary coolant breaks.   Now, there  
4       is a flow shutoff valve downstream -- it will probably  
5       be downstream of the circulator.   Because, otherwise,  
6       we'll get natural circulation through this maintenance  
7       cooling system.   So, we have a flow shutoff valve for  
8       normal operation.

9                   MEMBER KIRCHNER:   Thank you.

10                   MR. BOLIN:   Okay.   This is my last slide.  
11       Or, no, it's not my last slide.   Okay.

12                   So, one of the things that has been a  
13       concern with gas-cooled reactors is bypass flow.   And  
14       also, related to that is flow-induced oscillations.  
15       I know that there is a PDC on power oscillations.

16                   The coolant itself, of course, it doesn't  
17       have a reactivity effect, but movement of core and  
18       reflector structures can have some reactivity effect.  
19       In particular, the bypass flow, you know, because the  
20       -- I don't know if it was clear, but the fuel assembly  
21       is relatively open.   So, it's kind of an open bundle.  
22       It does have brackets on the corners, but, basically,  
23       as the flow comes up through the fuel assembly, it can  
24       redistribute among the various fuel assemblies.

25                   But, also, because it's open, it can also

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 feed bypass flow paths. So, as you see here, around  
2 the outer fuel assemblies, and also, all throughout  
3 the inner fuel assemblies, there are gaps between  
4 these blocks. And so, because of the open fuel  
5 assembly, we can get bypass flow going from the fuel  
6 area into the central zone and into the other  
7 reflector zone. And, in fact, this outer green zone  
8 also has gaps in it, because it's going to be in  
9 pieces.

10 And so, all these gaps contribute to  
11 bypass flow. It has a benefit, though. These bypass  
12 flow paths also improve heat transfer during loss-of-  
13 forced-cooling accidents. So, while our predominant  
14 heat transfer method is by radiation heat transfer  
15 from the fuel assemblies to the reflector, we also get  
16 a natural circulation from the upper plenum down  
17 through the outer reflector bypass flow paths, and  
18 then, into the fuel and back up, into the fuel here  
19 and back up.

20 So, the bypass flow has a negative effect  
21 during normal operation because it reduces the amount  
22 of flow through the core, but it has a positive effect  
23 during loss-of-forced-cooling accidents because it  
24 aids in the natural circulation of helium through the  
25 core.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 Any questions on this?

2 MEMBER KIRCHNER: Can you give us, John --  
3 this is Walt Kirchner -- just some estimate of steady  
4 state? What's the centerline temperature in your peak  
5 rod bundle, roughly? You know, compared to LWR, the  
6 cooling is not as efficient as a forced-water  
7 circulation system. So, I'm imagining that your delta  
8 T that's building up with the UO2 pellet on the order  
9 of diameter of an LWR fuel rod would have a centerline  
10 temperature that's running significantly higher. Is  
11 your power density so low --

12 MR. BOLIN: Let's go back --

13 MEMBER KIRCHNER: -- versus your surface  
14 area, that the centerline uranium oxide temperatures  
15 are low?

16 MR. BOLIN: Well, let's go back to the  
17 chart I had.

18 So, yes, you can see here that the fuel  
19 rod linear power is about -- it's not quite 10 times  
20 lower, but it's close, almost 10 times lower linear  
21 power than an LWR. So, the delta T in the fuel is,  
22 correspondingly, 10 times lower. And so, our peak  
23 fuel temperatures are running around, I think around  
24 1200 degrees C.

25 MEMBER KIRCHNER: Okay. It doesn't quite

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 scale like that. I'm sorry.

2 MR. BOLIN: Well, it doesn't quite --

3 MEMBER KIRCHNER: You've got a helium  
4 coolant and --

5 MR. BOLIN: The helium -- the cladding  
6 temperature is a lot higher.

7 MEMBER KIRCHNER: Yes.

8 MR. BOLIN: Yes, the cladding temperature  
9 is -- obviously, the cladding temperature is higher  
10 than the helium that's cooling it. But, if the  
11 cladding temperature is around 800 degrees C, we have,  
12 like I said, a much lower fuel delta T, and it,  
13 correspondingly, lowers our peak fuel temperature.

14 MEMBER KIRCHNER: It would be useful to  
15 have simple graphs at least for steady-state full-  
16 power conditions -- what your centerline UO2  
17 temperature; what your cladding temperature is; what  
18 the coolant is.

19 MR. BOLIN: Yes, I have that.

20 MEMBER KIRCHNER: And then, for a loss of  
21 -- I think Dennis asked earlier -- for a loss of  
22 forced circulation, where this was a real issue for  
23 some of the fast reactors, gas-cooled fast reactor  
24 designs, what kind of temperature excursion you would  
25 see in a loss-of-flow condition?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MR. BOLIN: Yes, I think that is a subject  
2 that is best addressed later, I mean in a subsequent  
3 discussion maybe. I actually do have some slides on  
4 that, but it is for a different meeting. So, I didn't  
5 put it in this package.

6 So, for accident conditions, we are --

7 MEMBER KIRCHNER: These comparisons that  
8 you're showing aren't very useful, actually.

9 MR. BOLIN: Well, yes, I mean, they're --

10 MEMBER KIRCHNER: Because I think you get  
11 my point. I mean, it's a rather complicated thermal  
12 hydraulic set of conditions that doesn't extrapolate  
13 well from gas to water.

14 MR. BOLIN: Correct.

15 MEMBER KIRCHNER: It depends on how much  
16 surface area you have; what your ilium flow velocity  
17 is --

18 MR. BOLIN: So, the surface --

19 MEMBER KIRCHNER: -- a whole number of  
20 things. So, when you just do this apples-and-oranges  
21 comparison, it's not terribly useful. It would be  
22 much more for your benefit in making your case to show  
23 what the actual operating conditions are for the fuel  
24 and the cladding, and how the system responds in a  
25 loss-of-flow condition.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 MEMBER MARCH-LEUBA: Yes, this is Jose.

2 Eventually, you're going to have to choose  
3 your licensing basis events and run all the Chapter 15  
4 analyses and figure out what your temperatures are  
5 everywhere. But, before I invest money in the design,  
6 I assume you have run some preliminary calculations  
7 for what you consider to be the limiting event.

8 MR. BOLIN: Correct, we have.

9 MEMBER MARCH-LEUBA: And I would expect  
10 that likely to be loss of pressure and when you lose  
11 your gas.

12 MR. BOLIN: Correct.

13 MEMBER MARCH-LEUBA: And then, you started  
14 cooling off by radiation. What temperatures you reach  
15 -- are you going to be okay?

16 MR. BOLIN: Correct, we are. We've  
17 designed it for that accident.

18 And as far as the surface area is  
19 concerned, remember, our fuel rods have the same  
20 geometry as the light water reactor fuel rods. So,  
21 our fuel rod surface area is the same as the light  
22 water reactor.

23 But that's about, you know, in the future,  
24 you will need to present both normal operation and  
25 accident condition fuel performance.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1           So, we have -- and I know the NRC project  
2 management is also going to go over this -- but we  
3 have made a lot of progress in pre-application  
4 licensing with the NRC. We have prepared a Regulatory  
5 Engagement Plan, you know, that outlines our licensing  
6 strategy for this conceptual period.

7           Obviously, the subject of this discussion  
8 is the principal design criteria. We submitted that;  
9 got some requests for additional information, and we  
10 responded to those and revised the Topical Report.  
11 And that's the subject of this meeting, is the NRC's  
12 Safety Evaluation on that Topical Report.

13           We have also submitted a QA program  
14 description Topical Report. We got some feedback  
15 early on, and then, made changes to that document.  
16 And that's undergoing review now.

17           And we've also submitted a Fuel  
18 Qualification Plan Technical Report. It's still a  
19 fairly early document. It's like a white paper. It's  
20 not a Topical Report.

21           And then, we have other documents that are  
22 planned: a Source Term Methodology, LBE selection,  
23 PRA, and safety classification.

24           CHAIR BIER: A quick question here.  
25 You're expecting that the safety classification

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 decisions will be made based on the PRA or they are  
2 two separate processes?

3 MR. BOLIN: Well, we will not have a  
4 complete PRA at the end of this conceptual design  
5 period. But the safety classification will be  
6 informed by the preliminary risk assessment work that  
7 is being done by, actually, being done by Vanderbilt  
8 University -- and also, historical PRA work that we've  
9 done on gas-cooled reactors in the past. So, it will  
10 be risk-informed safety classification. And the LBE  
11 selection will also be risk-informed, but not based on  
12 a complete PRA.

13 CHAIR BIER: Okay. Thanks.

14 MEMBER KIRCHNER: John, this is Walt  
15 Kirchner.

16 MR. BOLIN: Yes?

17 MEMBER KIRCHNER: I started to digress or  
18 regress. Your basic reactivity control in terms of  
19 accident conditions is based on leakage? In other  
20 words, the diameter of your core and power level were  
21 chosen or are pretty much indirectly determined  
22 depending on leakage?

23 You've gone away from reflector control to  
24 control rod controls. So, in an offsite condition,  
25 what's the primary shutdown mechanism for this? Is it

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 Doppler and leakage? Could you give us just a feeling  
2 for your core design philosophy in terms of reactivity  
3 control?

4 MR. BOLIN: Well, while Doppler is a  
5 factor that can lessen the reactivity control  
6 requirements, we are still primarily relying on  
7 control rods and shutdown rods. So, we have control  
8 rods that will be, you know, partially inserted into  
9 the core for power adjustment, but we also have  
10 shutdown rods that will be fully removed from the core  
11 that will be used for shutdown, out-of-steam shutdown  
12 rods.

13 So, leakage and Doppler and reactivity  
14 coefficients, those will all play a factor, but we're  
15 still primarily relying on control rods and shutdown  
16 rods.

17 MEMBER KIRCHNER: I'm thinking to offsite  
18 conditions.

19 MR. BOLIN: Yes.

20 MEMBER KIRCHNER: So, our fast sodium  
21 reactors, typically, are relying on leakage -- that  
22 determines the maximum size of the core -- and  
23 expansion.

24 MR. BOLIN: Yes, we're not relying on  
25 expansion or --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MEMBER KIRCHNER: Right.

2 MR. BOLIN: Like I said, leakage is not --  
3 I mean, it's there, but we're not relying on leakage.

4 MEMBER KIRCHNER: Are your reflectors,  
5 your radial reflectors, positive or neutral? Or  
6 negative?

7 MR. BOLIN: I don't know the answer to  
8 that.

9 MEMBER KIRCHNER: It's just something to  
10 think about.

11 MR. BOLIN: Okay.

12 MEMBER KIRCHNER: We'll ask in a future  
13 engagement.

14 MR. BOLIN: Yes.

15 MEMBER KIRCHNER: Thank you.

16 MEMBER PETTI: So, John, then, what  
17 determines the size? Why is it 110 megawatts? Was  
18 there some accident that limited, you know --

19 MR. BOLIN: Definitely. It definitely was  
20 the depressurized loss-of-forced-cooling accident that  
21 determined the size. And, in fact, we originally were  
22 looking at 50 megawatts electric and 120 megawatts  
23 thermal. And we ended up reducing the power to 100  
24 megawatts thermal for the depressurized loss-of-  
25 forced-cooling transient.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MEMBER PETTI: And is it a vessel  
2 temperature or a peak silicon carbide temperature?

3 MR. BOLIN: It was peak silicon carbide  
4 temperature.

5 MEMBER MARCH-LEUBA: Am I to assume from  
6 what you said that your safety margin is 20 percent?  
7 I mean, you cannot handle 50 megawatts electric, but  
8 you can handle 40? I mean, that's very limited for an  
9 advanced reactor.

10 Yes, I'm just putting it in the record.  
11 You don't have to answer it. But we're used to seeing  
12 reactors that you can shoot them with a shotgun and  
13 nothing happens to it.

14 MR. BOLIN: Yes.

15 MEMBER MARCH-LEUBA: Are you telling me  
16 that you want to go out to 20 percent power operate  
17 and make it?

18 All right. Don't answer. I'll put the  
19 bad things on the record, but you don't have to --

20 MR. BOLIN: I would say that the analysis  
21 has improved during the conceptual design period, but  
22 we have decided to stick with the 100 megawatts rather  
23 than try to minimize our margin.

24 And silicon carbide has different --

25 MEMBER KIRCHNER: Just to calibrate us,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 John, what do you use as a benchmark for your silicon  
2 carbide structure as a thermal, like a thermal limit,  
3 to determine, you know, it remains intact in a loss-  
4 of-depressurization and loss-of-forced-circulation  
5 event?

6 Because that's, typically, you know, if  
7 you go back to the HTGR business that you all were  
8 involved in, you know, sizing of the core was kind of  
9 an inverse calculation of temperature of the vessel  
10 and temperature of the TRISO particle fuel.

11 What limits here? If it's silicon  
12 carbide, can you calibrate us? What temperature is  
13 that?

14 MR. BOLIN: The temperature limit we have  
15 been using is 1800 degrees C. So, we want our silicon  
16 carbide to be below 1800 degrees C.

17 MEMBER MARCH-LEUBA: And that's because of  
18 the welding on the top of the rod?

19 MR. BOLIN: No. No.

20 MEMBER MARCH-LEUBA: So, I thought that  
21 was the number that we were given earlier.

22 MR. BOLIN: The cladding itself. No, it  
23 doesn't, it doesn't --

24 MEMBER PETTI: Decomposition? Because I  
25 always thought decomposition was a little higher than

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 -- around 2000.

2 MR. BOLIN: Yes, decomposition is higher  
3 than that.

4 MEMBER PETTI: Yes.

5 MR. BOLIN: It's higher than that.

6 MEMBER PETTI: So, it's just a composite  
7 --

8 MR. BOLIN: It is degradation. I mean,  
9 there's degradation of the cladding at 1800 C. And  
10 so, we want to stay below that point. And we are.

11 MEMBER REMPE: I am confused because,  
12 earlier, Aaron said that the peak temperatures for the  
13 end caps for air are -- or I guess for helium -- was  
14 1900 C?

15 MR. BOLIN: Correct.

16 MEMBER REMPE: So, what are the -- aren't  
17 the end caps made of silicon carbide, too?

18 MR. BOLIN: Yes. Yes.

19 MEMBER REMPE: Was it 1800 or 1900?

20 MR. BOLIN: Eighteen hundred was just the  
21 number we were using as a design --

22 MEMBER REMPE: So, you have margin, is  
23 what you're saying?

24 MR. BOLIN: Yes. Yes.

25 MEMBER REMPE: Unless there's not any

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 steam in there.

2 MR. BOLIN: Right.

3 DR. SCHULTZ: John, this is Steve Schultz.  
4 Just thinking about some operational considerations.  
5 You mentioned the fuel cycle approach was going to be  
6 such that the fuel assemblies would be in reactor for  
7 a fairly extended period of operation. Any concerns  
8 about the fuel assembly dimensional stability over  
9 those long periods of time to high burnups as well?  
10 In other words, are you going to have any problems  
11 after many, many years moving assemblies when you do  
12 your fuel management at infrequent intervals?

13 MR. BOLIN: Well, we will be moving fuel  
14 assemblies every -- so, when we refuel every 15 years,  
15 all the fuel assemblies get moved.

16 DR. SCHULTZ: We hope.

17 MR. BOLIN: Well, yes. And like I said,  
18 15 years, we will have design gaps around the fuel  
19 assemblies. And like I said, silicon carbide is very  
20 rigid material. So, no deformation is --

21 DR. SCHULTZ: So, the accommodation is  
22 there in the design --

23 MR. BOLIN: There is some --

24 DR. SCHULTZ: -- for that type of an  
25 approach?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MR. BOLIN: Correct. Correct.

2 MEMBER PETTI: How many dpa's, John,  
3 about?

4 MR. BOLIN: Well, on average, it is 77.

5 MEMBER PETTI: And peak?

6 MR. BOLIN: No. And peak is about 100.  
7 So, pretty aggressive. But it's been done before.

8 MEMBER PETTI: Yes. No, I'm not too  
9 worried about it. There's data that shows that it's  
10 okay. I'm more worried about how you qualify a 15-  
11 year fuel cycle in ATR, which is like super-  
12 accelerated for light water reactors. It's kind of  
13 off the charts for this fuel.

14 MR. BOLIN: It's a subject of a  
15 presentation I'm giving on Thursday.

16 MEMBER PETTI: Oh, good. I'm glad you've  
17 got the answer.

18 DR. SCHULTZ: I am, too. That sounds  
19 good.

20 MR. BOLIN: It's at INL. So, if you're in  
21 the neighborhood --

22 DR. SCHULTZ: Well, thank you, John.

23 MEMBER REMPE: Back in D.C., though, a  
24 question. Since this is your last slide, what are you  
25 guys going to do for fuel ultimate storage? Is it

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 going to be onsite? Are there any special concerns  
2 about how you're going to store it onsite, and then,  
3 ultimately, if we ever have a repository, transferring  
4 it to the repository? Or at least --

5 MR. BOLIN: So --

6 MEMBER REMPE: Go ahead.

7 MR. BOLIN: So, we're still working on  
8 that. We're going to store onsite within the reactor  
9 building, similar to other gas-cooled reactor designs.  
10 At least have a core's worth -- I think core and a  
11 reload worth of storage onsite in a spent fuel storage  
12 area. Because I don't want to say -- I don't know if  
13 it's going to be a pool, a vault, or storage wells.  
14 That's still being worked out.

15 Eventually, I think we'll use dry storage  
16 on the outside of the reactor building, similar to  
17 like what light water reactors are doing now. We may  
18 be able to move fuel into dry storage casks fairly  
19 early because of our low power density. So, that's  
20 still being investigated.

21 I do have to show my last slide just to  
22 acknowledge that this work was supported by the  
23 Department of Energy, Office of Nuclear Energy, under  
24 that contract for advanced reactor concepts.

25 So, let's see.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 CHAIR BIER: So, we are remarkably close  
2 to being on time. You did a good job anticipating how  
3 many questions and comments you would get, I guess.

4 MR. BOLIN: Yes.

5 CHAIR BIER: If there are no more  
6 questions on this presentation, this is probably a  
7 good time to take a break, as scheduled, and be back,  
8 I guess, at maybe 3:30, instead of 3:25. Is that okay  
9 with people? I'm sorry, 2:30. I'm looking at the  
10 wrong computer and doing the conversion in my mind of  
11 time zones. You're right.

12 We're ahead of schedule. So, let's take  
13 a break until 2:30, and then resume. Is that  
14 agreeable to everybody?

15 (Whereupon, the above-entitled matter went  
16 off the record at 2:12 p.m. and resumed at 2:32 p.m.)

17 CHAIR BIER: All right. Sorry for the  
18 brief delay. Are people ready to move forward?

19 John, I believe you are up after the  
20 break, also, for the principal design criteria, is  
21 that correct?

22 MR. BOLIN: Correct. Can you hear me?

23 CHAIR BIER: Yes.

24 MR. BOLIN: And is my audio better?

25 CHAIR BIER: Well, it sounds fine so far.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 Okay.

2 MR. BOLIN: Okay. Because I have donned  
3 a set of headphones and microphones. Hopefully,  
4 that's going to --

5 CHAIR BIER: That will probably help, yes.

6 MR. BOLIN: -- cut back on ambient noise.

7 CHAIR BIER: Thank you. We appreciate it.  
8 And so far, you are not sharing your slides. I  
9 believe you're planning to.

10 MR. BOLIN: No, I've not started sharing.

11 CHAIR BIER: Okay.

12 MR. BOLIN: Yes.

13 CHAIR BIER: That's fine.

14 MR. BOLIN: Yes. Let me pull up that  
15 presentation.

16 CHAIR BIER: By the way, I thought your  
17 slides were quite readable, which is nice. Sometimes  
18 they're minuscule eye charts, but these were pretty  
19 good. Thank you.

20 MR. BOLIN: There might have been a few  
21 tests, eye tests, on there.

22 Okay. Let's see here. Okay. How is  
23 that?

24 CHAIR BIER: It looks good. Thank you.

25 MR. BOLIN: Okay. This is an overview of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 the Principal Design Criteria for the Fast Modular  
2 Reactor. Okay. There.

3 So, we did use the NRC guidance in  
4 adapting and developing our Principal Design Criteria.  
5 The Reg Guide 1.232, as you're aware, developed PDCs  
6 for non-light water reactors by modifying and  
7 supplementing 10 CFR 50, Appendix A, General Design  
8 Criteria. And they did that in three categories:  
9 sodium-cooled fast reactor, modular high-temperature  
10 gas-cooled reactor, and then, a design-neutral  
11 advanced reactor design criteria.

12 So, we used the ARDC and the MHTGR-DC as  
13 starting points, and then, in our Topical Report, we  
14 modified the NRC rationale for adaptation of the GDC  
15 to our application for the FMR-DCs.

16 So, I'll just quickly go over some of the  
17 key things about the FMR-DCs, and I've organized it in  
18 the major categories of the design criteria.

19 So, the first category is overall  
20 requirements, FMR-DC 1 through 5.

21 So, FMR-DC 1 is the same as the GDC.

22 Likewise, FMR-DC 2 is also the same as  
23 GDC.

24 FMR-DC 3 is the same as the ARDC.

25 FMR-DC 4 made a slight change to the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MHTGR-DC. We changed missiles. We expanded it or  
2 made it more specific to include missiles originating  
3 both inside and outside the reactor helium pressure  
4 boundary. And we did that to explicitly cover any  
5 missiles generated by the turbine machinery.

6 And then FMR-DC 5 is the same as the GDC.

7 The next category is multiple barriers,  
8 FMR-DC 10 through 19. The FMR-DC 10 on reactor  
9 design, the fuel design, as we went over previously,  
10 the fuel design using SiGA cladding, it functions  
11 similarly to light water reactors in that, you know,  
12 that there's kind of a classic cladding function.

13 And so, we chose to use the SAFDL  
14 terminology, both here and in other FMR-DCs. So,  
15 where we may have been using a MHTGR-DC, we,  
16 basically, chose to use the SAFDL terminology instead  
17 of the -- I don't know how you pronounce it -- SARRDL  
18 terminology.

19 Okay. Then, FMR-DCs 11, 13 through 15, 17  
20 through 18, those are the same as the ARDCs and MHTGR-  
21 DCs, but with minor terminology changes. So, they're,  
22 essentially, the same as those.

23 FMR-DC 12, the suppression of reactor  
24 power oscillations, the word "structures" was added to  
25 address reflectors, but the word "coolant" was

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 deleted.

2 So, as mentioned, the helium coolant  
3 itself is neutronically neutral or inert or  
4 transparent. And so, helium density flow changes, in  
5 and of itself, don't cause a reactivity change, but --

6 MEMBER MARCH-LEUBA: This is Jose.

7 But, conceivably, you could have something  
8 like u-tube momentarily-type oscillation of the  
9 coolant between the reflector and the core, for  
10 example. I don't know if you're supposed to go into  
11 that. And that will, even though the helium is (audio  
12 interference), it changes the temperature and has some  
13 Doppler feedback. I don't suspect, I mean, it's even  
14 remotely a problem, but you should analyze it.

15 MEMBER KIRCHNER: John, before you answer,  
16 let me add on.

17 So, you have a fast reactor here, and you  
18 have a reflector in the middle of it. Now, that's an  
19 adaptation from the HTGR world. That's to push the  
20 power out and to allow your passive heat rejection  
21 system to take care of decay heat and manage the  
22 vessel wall temperature, and a number of other  
23 factors.

24 But, for a fast reactor now, does that  
25 reflector decouple one part of the reactor from

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 another? In other words, do you have a tightly-  
2 coupled neutronic design or is this loose now -- I  
3 use that word loosely -- in terms of how the core  
4 might behave with regard to power oscillations?  
5 Because you're now running in a fast spectrum, not a  
6 thermal spectrum.

7 MR. BOLIN: So, I think the coolant, in  
8 and of itself, is not a source of power oscillation.  
9 But the flow is a possible source of power  
10 oscillation. So, I think that's why structures were  
11 added to address whether flow could cause the  
12 reflectors to move, and therefore, cause a reactivity-  
13 generated power oscillation.

14 Now, that flow through the reflectors can  
15 affect both position and temperature. So, I think  
16 we're covered by that.

17 Since it is a fast-spectrum reactor, it  
18 should be fairly tightly-coupled, and these  
19 reflectors, like I said, this is zirconium silicide.  
20 So, it's a fairly heavy reflector. So, it doesn't  
21 moderate like a lot of reflectors tend to do, you  
22 know, graphite or water, or whatnot.

23 So, the coupling, I think the coupling is  
24 tight, but we're still looking at whether there's  
25 really any significant oscillation or reactivity

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 feedback from the reflectors. Of course,  
2 historically, Fort Saint Vrain had a power oscillation  
3 issue with the fuel columns and their moving around.  
4 So, I think that's why we don't want to totally ignore  
5 the structures.

6 Okay? Then, the last DC in this category  
7 is containment design. And we are using the same as  
8 the SFR-DC because the FMR uses, like we discussed  
9 earlier, a low-leakage pressure-retaining containment.  
10 So, more in line with the SFR-DC and, certainly, not  
11 the vented confinement of the MHTGR.

12 The reactivity control is FMR-DC 20  
13 through 29.

14 FMR-DC 20 through 24 are the same as the  
15 GDCs.

16 FMR-DC 25 is the same as ARDC with minor  
17 terminology changes.

18 And then, FMR-DC 26, just like the ARDC  
19 and MHTGR-DC, it combines GDC 26 and GDC 27.

20 FMR-DC 28 is the same as MHTGR-DC.

21 And FMR-DC 29 is the same as GDC.

22 Fluid systems, FMR-DC 30 through 46.

23 30 through 33 are the same as MHTGR-DC.

24 The FMR-DC 34, residual heat removal, it's  
25 similar to MHTGR-DC, but we wanted to make sure that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 it covered both the active, non-safety-related and  
2 passive safety-related systems available to remove  
3 residual heat. Also, similar to MHTGR-DC, it  
4 incorporates the requirements in GDC 35.

5 And then, FMR-DC 36 and 37 are the same as  
6 MHTGR-DC.

7 38 through 41 are the same as the ARDC.

8 DC-42 is the same as GDC.

9 DC-43, 45, and 46 are the same as ARDC.

10 And FMR-DC 44 is the same as MHTGR-DC.

11 So, all of these PDC selections are driven  
12 by the design choices that we've made in the design.

13 And I believe this is the last slide of  
14 DCs. It is reactor containment.

15 So, 50 through 53 are the same as ARDC.

16 54 is the same as SFR-DC.

17 And 55 through 57, they're the same as  
18 ARDC, but with minor terminology changes.

19 And then, the next category is fuel and  
20 radioactivity control.

21 60, 62, and 63 are the same as GDC.

22 And 61 is the same as ARDC.

23 And the same acknowledgment as the  
24 previous presentation. It's supported by the U.S.  
25 DOE, Office of Nuclear Energy, under that contract.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 So, that was that.

2 CHAIR BIER: So, this is Vicki Bier. I  
3 have a couple of very general, high-level questions.

4 One, could you discuss briefly, of the  
5 modifications you described, which ones were kind of  
6 the most crucial for safety versus just matching the  
7 terminology to what's in your design?

8 MR. BOLIN: Well, let's see here.

9 MEMBER MARCH-LEUBA: How about DC 4 with  
10 the missiles?

11 MR. BOLIN: Yes, that probably is the most  
12 unique challenge from the FMR, is the missiles.  
13 Because that, obviously, adds -- I mean, not that it  
14 wouldn't have been considered, anyway, but it  
15 certainly adds a design focus. I mean, not that we  
16 would have ignored it, but, yes.

17 CHAIR BIER: Sure. One other, again,  
18 high-level question. I know that the Reg Guide says  
19 that it is possible for the applicants to identify  
20 entirely new PDCs for unique features of the design  
21 that are not adequately covered by the kind of  
22 templates in the Reg Guide. And did you find any  
23 situations where you were at least pondering that or  
24 thought it might be worthwhile? Or do you think  
25 you're close enough to the samples in the Reg Guide,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 that you were able to cover what you needed there?

2 MR. BOLIN: I think, because the staff  
3 covered the two different, very different, advanced  
4 reactors -- the sodium fast reactor and the MHTGR --  
5 that I don't think there were -- we did not identify  
6 any gaps in design criteria that we -- we did not  
7 identify any gaps.

8 CHAIR BIER: Okay. So, in other words,  
9 the reason why what you have looks a lot like the  
10 samples in the Reg Guide is really just because the  
11 Reg Guide is pretty thorough and comprehensive, not  
12 because you were just going through kind of a checkbox  
13 process of "pick one from each column" kind of thing?

14 MR. BOLIN: Correct. Correct.

15 CHAIR BIER: Okay.

16 MR. BOLIN: I mean, I think the Reg Guide  
17 was extremely useful in this process.

18 MEMBER REMPE: Well, thinking about the  
19 historical approaches that GA has developed, where you  
20 start with the critical safety functions, are you  
21 doing that or applying that approach with this design?  
22 Is it just, you know, control radionuclide release --

23 MR. BOLIN: It's the same critical safety  
24 functions, correct.

25 MEMBER REMPE: So, there's nothing that's

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 unique or different, then, when you think about this  
2 design? I mean, sometimes chemical reactions comes in  
3 with higher priority, but you just didn't see anything  
4 else?

5 MR. BOLIN: No. I mean, obviously, we  
6 still have some graphite. So, we do have graphite  
7 concerns. But we don't have -- the graphite is not in  
8 the high-temperature parts of the core.

9 We still have water ingress concerns, but  
10 we don't have high-temperature, high-pressure steam.  
11 So, a lot of our safety concerns from MHTGR are quite  
12 a bit lessened.

13 MEMBER MARCH-LEUBA: This is Jose.

14 How about the very long cycle time, the  
15 15-years recycle/reload, and the implications that you  
16 may have on misalignment of fuel, clipping, phase-in,  
17 moving, vibrations? And 15 is a long time before you  
18 open and look inside to see what's going on.

19 MR. BOLIN: Yes.

20 MEMBER MARCH-LEUBA: I mean, does that  
21 affect something?

22 MR. BOLIN: Certainly, we do expect to  
23 have to shut down more frequently than every 15 years  
24 for other maintenance and inspection reasons.

25 MEMBER MARCH-LEUBA: Yes, but do you

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 expect to open the core? You'll probably be fixing  
2 some pump outside of the core plenum.

3 MR. BOLIN: Well, that hasn't been  
4 decided, whether --

5 MEMBER MARCH-LEUBA: Yes. And if I  
6 incorrectly wanted to --

7 MR. BOLIN: And, you know, for the first-  
8 of-a-kind prototype, it might be you might do some  
9 fuel inspection.

10 MEMBER MARCH-LEUBA: I'm just trying to  
11 think what is different. If I read correctly your  
12 cartoons, the control rods are sitting outside, or the  
13 shutdown rods for sure are sitting outside the vessel,  
14 and they have to go through sealed?

15 MR. BOLIN: Well, the control rod drive  
16 mechanism and connecting rod are out -- well, they're  
17 not -- technically, that's still part of the vessel.  
18 It's still part of the helium reactor pressure  
19 boundary.

20 MEMBER MARCH-LEUBA: Then, enclosed? I'm  
21 just wondering if there is some design criteria that  
22 applies to those special configurations.

23 MR. BOLIN: Well --

24 MEMBER MARCH-LEUBA: It certainly feels --  
25 let me put it this way; I'm the bad guy here -- it

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 simply feels that you took all the GDCs that were in  
2 the design guide and went through to see if they  
3 applied to you, instead of thinking about your design  
4 and see what's missing. It's something very human to  
5 do, and that's something we all do.

6 So, on the review, I'll be asking the  
7 staff, when they're here, if they thought, what's  
8 missing?

9 MR. BOLIN: Okay.

10 MEMBER MARCH-LEUBA: It's very easy, when  
11 somebody gives you a paper, to correct the English,  
12 but what's important is, what paragraph is missing in  
13 that article? The same thing here.

14 MR. BOLIN: All right.

15 CHAIR BIER: For operational reasons, are  
16 you anticipating that there would be periodic  
17 shutdowns for reasons other than refueling, or that  
18 it's just going to run flat-out and just adjust power  
19 levels?

20 MR. BOLIN: I mean, it hasn't been worked  
21 out specifically, but there is discussion of whether  
22 we would want to shut down every five years for an  
23 inspection, particularly, you know, power conversion  
24 unit inspection and/or generator or control rod drive  
25 motors, or a variety of things we might want to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 inspect every five years. At least, particularly, we  
2 have to consider increased inspection frequency for a  
3 first-of-a-kind plant. So, that's being discussed.

4 MEMBER PETTI: Wouldn't Section 11  
5 require, like, the vessel to be inspected?

6 MR. BOLIN: Yes, vessel inspection is  
7 another example.

8 MEMBER HALNON: Yes, and don't  
9 underestimate the power of the insurance agency.

10 MR. BOLIN: Well, yes. We tend to ignore  
11 that until the very end.

12 CHAIR BIER: Are there other questions or  
13 comments for John, or any other points that John wants  
14 to add, before we transition to the staff?

15 (No response.)

16 CHAIR BIER: I guess one other question  
17 that I have, I noticed that there was a Rev 1 of the  
18 PDCs, which I guess was in response to the RAIs from  
19 the staff; that some things got adjusted? Again, are  
20 there any there that are noteworthy enough that you  
21 want to call them out or discuss the value of those  
22 changes?

23 MR. BOLIN: Well, it's interesting that a  
24 lot of the changes were -- we had actually prepared  
25 our DCs based on a draft of the Reg Guide. And then,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 the Reg Guide changed. And so, there were  
2 inconsistencies between our DCs and the Reg Guide.  
3 So, a lot of the corrections were just making those  
4 corrections to the revised Reg Guide.

5 CHAIR BIER: Okay. If there are no  
6 further questions and comments, then, I guess we can  
7 transition to staff. And I'm not sure if the primary  
8 presenter is Reed Anzalone or Samuel Cuadrado. Which  
9 of --

10 MR. ANZALONE: It's going to be me.

11 CHAIR BIER: Okay. Thank you.

12 So, I guess, John, you can stop sharing  
13 your slides, then. Thank you very much for the  
14 presentation.

15 MR. BOLIN: Thank you.

16 MR. ANZALONE: Okay. Thanks. So, thank  
17 you, everyone, for having us here today.

18 My name is Reed Anzalone. I'm a Senior  
19 Nuclear Engineer in NRR's Division of Advanced  
20 Reactors and Non-Power Production and Utilization  
21 Facilities. I'm joined today by our Project Manager,  
22 Sam Cuadrado, who is also with me in DANU.

23 So, I was the lead technical reviewer for  
24 this effort, and I was assisted by Sheila Ray in our  
25 Division of Engineering and External Hazards, who's

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 here on the phone. She covered the electrical PDCs,  
2 and Steve Jones, who is with me in DANU, covered the  
3 containment PDCs, who wasn't able to make it. So, if  
4 there are questions about those, I can address them.

5 Next slide, please.

6 So, quick agenda, and you'll see that a  
7 lot of this should look very, very, very, very  
8 familiar from the presentations that we just had from  
9 General Atomics. I was laughing the whole time during  
10 John's presentation because there is almost a one-to-  
11 one correspondence between the topics covered. So, I  
12 may go quickly through some of these. And, of course,  
13 if you have questions, feel free to interrupt.

14 MEMBER MARCH-LEUBA: Is that the 100  
15 percent rule to coordinate with the other presenter?

16 MR. ANZALONE: No. In fact, we --

17 MEMBER MARCH-LEUBA: In fact, the  
18 desirable?

19 (Laughter.)

20 MR. ANZALONE: We only got the slides  
21 yesterday. So, I was happy to see that they matched  
22 very well.

23 So, Sam will be talking a little bit about  
24 the pre-application engagement. Then, it will go back  
25 to me, and I'll talk about the Topical Report

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 timeline. That's really just going to be for  
2 reference, for anyone who might want to go back and  
3 look at the correspondence that we had.

4 I'll touch a little bit on some of the  
5 design features that we already talked about; talk a  
6 little bit about the PDC guidance that's out there;  
7 the PDC development approach that General Atomics  
8 provided to us in their Topical Report, and then, I'll  
9 go into the Fast Modular Reactor design criteria  
10 themselves, including kind of highlighting the key  
11 design choices and the effects that those had on the  
12 PDCs. And hopefully, I can address the question that  
13 you raised. And then, I'll just briefly touch on the  
14 Safety Evaluation and conclusions.

15 So, Next slide. MR. CUADRADO DE JESUS:  
16 Now, good afternoon. Sam Cuadrado.

17 So, this is a brief overview of the pre-  
18 application engagement with General Atomics. You saw  
19 a similar slide when John Bolin was doing the  
20 presentation.

21 We got the pre-application letter  
22 engagement plan last year in March. Accordingly,  
23 we're reviewing a couple of documents, which include  
24 this one that we see, the Topical Report which is the  
25 topic of this meeting.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1           We have a few qualifications in the  
2 Topical Report. Basically, it's only that we are  
3 providing feedback in the form of a white paper. And  
4 last month, we received the Quality Assurance Program  
5 Topical Report. That's currently going through the  
6 review process.

7           We expect a few more documents, a few more  
8 submittals this year, and a couple more next year.  
9 This year, for the summer, we've got the mechanistic  
10 source term. By the end of the year, we should be  
11 getting the licensing basis event white paper. And  
12 for the spring of next year, the safety approach on  
13 the PRA and safety classification white papers.

14           So, back to Reed on this.

15           MR. ANZALONE: All right. Next slide.  
16 So, just quickly on the review timeline, really, all  
17 I wanted to highlight here was that we did ask a round  
18 of RAIs and we got prompt responses, and then,  
19 subsequently, General Atomics rev'd the Topical Report  
20 to incorporate those responses. And then we issued  
21 the Draft SA in March.

22           Next slide. Well, go ahead.

23           MEMBER BALLINGER: I have a question. I  
24 see that the Fuel Qualification Plan Technical Report,  
25 it says, "under review." Do we know when we're going

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 to get that?

2 MR. CUADRADO DE JESUS: Yes. That is for  
3 a white paper there. It was just some feedback. So,  
4 they provided some "asks," some questions for us to  
5 provide them feedback. I placed that information for  
6 you guys to get access to it. But we plan to provide  
7 feedback to them by November of this year.

8 MEMBER BALLINGER: So, we have access to  
9 this?

10 MR. CUADRADO DE JESUS: You have access to  
11 the request, yes, to the Technical Report.

12 MS. DE MESSIERES: This is Candace de  
13 Messieres.

14 I just wanted to clarify that this is a  
15 Technical Report, not a Topical Report.

16 MR. CUADRADO DE JESUS: Yes, yes, yes.

17 MS. DE MESSIERES: So, I just wanted to  
18 make sure that that was clear.

19 MR. CUADRADO DE JESUS: Yes, but you can  
20 see the Technical Report and the questions that they  
21 want us to answer, to provide feedback. It's in  
22 SharePoint for you guys.

23 MEMBER MARCH-LEUBA: But it has been  
24 provided on the docket? I mean, we can see it?

25 MR. CUADRADO DE JESUS: Yes, it's on the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 docket.

2 MEMBER MARCH-LEUBA: But, typically,  
3 Technical Reports are part of the SAR.

4 MEMBER HALNON: Yes, we, typically, don't  
5 -- we separate white papers from Technical Reports.  
6 This has both. Is it a white paper or is it an  
7 actually approved -- since they don't have a QA  
8 program yet, it can't be a Technical Report that they  
9 would reference.

10 MR. ANZALONE: No, it's a white paper.

11 MEMBER HALNON: Okay.

12 MR. ANZALONE: It's just called a  
13 Technical Report.

14 MEMBER HALNON: Yes, that's the title.

15 (Laughter.)

16 MR. CUADRADO DE JESUS: Yes, but it's on  
17 the docket, so you guys can see it.

18 MR. ANZALONE: So, it's not going to be,  
19 you know -- it doesn't get that stamp of finality  
20 that's --

21 MEMBER HALNON: It won't be referenced out  
22 of the SAR --

23 MR. ANZALONE: No.

24 MEMBER HALNON: -- whenever that comes.

25 CHAIR BIER: Just for completeness or

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 clarification, Weidong, if I understand correctly,  
2 this is not in the SharePoint for this meeting, but  
3 it's available through NRC, is that correct?

4 MR. WANG: Correct. That is, the staff  
5 has created a SharePoint, but I think that Sam has --

6 MR. CUADRADO DE JESUS: Yes, in  
7 SharePoint, there's a folder related to General  
8 Atomics.

9 MEMBER HALNON: So, on your next slide,  
10 Rev 2 was transmitted. They make it Rev 1.

11 MR. ANZALONE: I think it should be Rev 1.  
12 Sorry.

13 Okay. Next slide. So, just talking a  
14 little bit about the design features, I know we've  
15 just, literally, had a presentation from them. I just  
16 wanted to kind of go through the things that we  
17 thought were particularly noteworthy in our review.

18 So, one is, obviously, the core  
19 arrangement, which is different from the other gas-  
20 cooled reactors that we've seen recently at the NRC,  
21 which, you know, they're using, essentially, what  
22 looks like an LWR core with the fuel rods and UO2  
23 cladding, the silicon carbide. But the arrangement is  
24 a little bit more like a fast reactor core with a  
25 tight space in between the rods and triangular

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 tension, the hexagonal assemblies.

2 And when you compare that -- so, I was  
3 thinking about things in terms of the basis for what's  
4 in Reg Guide 1.232. So, that's the MHTGR, which was  
5 a prismatic block gas-cooled reactor using TRISO fuel.  
6 So, obviously, pretty different there.

7 The other thing that's big that you can  
8 see on this slide is the gas turbine. I think that's  
9 been covered pretty well.

10 And then, the MHTGR used steam generators  
11 rather than having the power conversion system  
12 directly on the primary circuit.

13 Next slide. The thing that I'll highlight  
14 here, you see the containment. John talked a little  
15 bit about that. So, there is an actual containment  
16 building versus like a functional containment or  
17 confinement approach.

18 And the other thing is the RVCS cooling  
19 system, which is a little different from the passive  
20 cooling system that was in the MHTGR design.

21 Yes, that's everything I wanted to cover  
22 on this slide.

23 So, then, the key design features, and on  
24 a future slide, I'll kind of talk about how these feed  
25 into the PDCs. So, it just sort of sums up everything

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 that I covered in the last couple of slides. I don't  
2 think I need to really talk any more about this.

3 Next slide. MEMBER KIRCHNER: Can you  
4 just pull your microphone up? Maybe we can hear it  
5 better. Yes, great.

6 MR. ANZALONE: All right. Sorry. Thanks.  
7 Oh, that is much louder.

8 MEMBER MARCH-LEUBA: There's people on the  
9 other side of the phone line that would love to see  
10 how this works.

11 MR. ANZALONE: Yes. Thanks. That's much  
12 better.

13 So, just a little bit of what we used for  
14 guidance in evaluating PDCs and you know the kind of  
15 conclusions that we're trying to reach. So, both of  
16 these quotes are from Part 50, Appendix A.

17 And that first one, the first statement  
18 there is kind of the conclusion that we're trying to  
19 reach: that the Principal Design Criteria established  
20 the necessary design, fabrication, construction,  
21 testing, and performance requirements.

22 And then, the second statement there talks  
23 about this is the guidance that Part 50, Appendix A,  
24 gives in establishing PDCs. So, the GDCs in Appendix  
25 A aren't directly applicable to non-light water

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 reactors, but they are considered to be guidance in  
2 establishing PDCs for non-light water reactors.

3 Next slide. And then, also, we have Reg  
4 Guide 1.232, which we talked about a little bit. That  
5 was issued in April of 2018. I think most of the  
6 members were on the Committee when it was issued.

7 And it documents three sets of acceptable  
8 PDCs. So, there's the advanced reactor DCs, which are  
9 supposed to be generic and technology-inclusive, and  
10 there's an asterisk there because it's technology-  
11 inclusive for certain technologies that we had in mind  
12 when we were writing them. I don't think that you  
13 could make one that is, you know, wholly generic that  
14 would be of value really.

15 Then, there is the sodium-cooled fast  
16 reactor DC, which really, I think, were made with the  
17 PRISM reactor in mind, and the MHTGR-DCs, which were  
18 made with the MHTGR which is a TRISO-fueled, helium-  
19 cooled, as I mentioned, prismatic block, graphite-  
20 moderated, high-temperature gas reactor.

21 So, that slide --

22 CHAIR BIER: Before you move on, when  
23 these design criteria were developed, did you envision  
24 in advance that people might be mixing and matching,  
25 based on what fits their circumstance?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MR. ANZALONE: Yes. And actually, there's  
2 one -- one of the points coming up, especially PDC 16  
3 talks about containment design criteria. That  
4 explicitly in it says, "We envisioned that people  
5 would pick the one that best suits their design here."  
6 So, I think that was, clearly, a consideration.

7 And the thing that I want to kind of point  
8 out -- and this gets a little bit at Jose's question  
9 -- the FMR kind of neatly straddles all of these  
10 categories. It falls kind of in between all of them.  
11 So, I don't think that there's any real aspect of the  
12 design that is so exotic that it wouldn't be well-  
13 encompassed by these design criteria.

14 And then, that is something that we  
15 thought about, as we were going through and doing the  
16 review, is, you know, are these adequate? And the  
17 answer that we keep coming back to was, yes, it looks  
18 like this covers what it needs to.

19 MEMBER MARCH-LEUBA: And an impracticality  
20 -- if that's a word -- when we do the full Chapter 15-  
21 type analysis and Chapter 19, it will mean something.  
22 It will pop up there.

23 MR. ANZALONE: Mm-hmm. And one thing that  
24 I think is interesting about this particular review is  
25 that they came to us with these PDCs very, very early

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 in the project. I mean, this was the second thing  
2 that was submitted after the Regulatory Engagement  
3 Plan. So, really, it's the PDCs came, and then, the  
4 design -- I mean, it got to a certain level of  
5 maturity to be able to establish what the PDCs ought  
6 to be, but, ultimately, they will have to design the  
7 reactor to meet these PDCs.

8 MEMBER HALNON: But is it, I mean, written  
9 generically enough to create a fourth category in  
10 regards to the Reg Guide?

11 (Laughter.)

12 MEMBER HALNON: I mean, when I went  
13 through it, it seemed like there were pretty generic,  
14 directly written to advanced reactors of this type.

15 MR. ANZALONE: So, I don't know that  
16 that's really necessarily worth doing. Because I  
17 think there's this vision that people would kind of  
18 mix and match. The vast majority -- and I have a  
19 summary slide as a backup slide -- the vast majority  
20 are just straight from the ARDC with minor  
21 modifications here and there.

22 MEMBER HALNON: Okay.

23 MR. ANZALONE: So, I think it's, you know,  
24 within the envelope of stuff that we would expect  
25 people to do with this Reg Guide.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 CHAIR BIER: And presumably, any future  
2 designs may also have their own unique tweaks and not  
3 fit exactly with --

4 MEMBER HALNON: But when I got done  
5 reading it, one of the things that just popped into my  
6 mind, it just felt like the fourth category was just  
7 written, but I understand what you're saying. They're  
8 close enough to all these other things.

9 MR. ANZALONE: Yes.

10 MEMBER HALNON: There's nothing really  
11 unique or brand-new in there that would warrant a  
12 special --

13 MEMBER MARCH-LEUBA: If anything worries  
14 me along this design, it's the high temperature. But  
15 they'll eventually know how to do it.

16 MR. ANZALONE: All right. Next slide.  
17 And General Atomics covered this in their  
18 presentation, but the concept that was conveyed to us  
19 in the Topical Report was that they would start with  
20 the Advanced Reactor Design Criteria. Then, if that  
21 wasn't fully applicable, they would go look at the  
22 other ones for direct adoption, and then, take the one  
23 that was the most applicable and adapt or refine it to  
24 match with the design.

25 Okay. Next slide. So, then, talking

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 about the key design feature effects on the Principal  
2 Design Criteria. So, the fuel and the core really  
3 kind of lead to the use of SAFDLs rather than SARRDLs,  
4 which John mentioned in his presentation. And that  
5 also, I think, goes along with the Containment  
6 Principal Design Criteria that they ended up using and  
7 the containment design. We generally kind of think of  
8 those as going together. SAFDLs go with functional  
9 containment; SARRDLs go with leak-tight containment or  
10 controlled leakage.

11 The neutron spectrum fast, I think the big  
12 takeaway there that we wanted to make sure was  
13 included was to consider the effect of structures on  
14 reactivity feedback, which, otherwise, I think the  
15 ARDC includes this, but the GDC, if that were to be  
16 adopted directly, does not.

17 And actually, that was an RAI that we  
18 asked. Because, originally, what was in the Topical  
19 Report didn't include structures in that PDC, and we  
20 wanted to make sure that that was in there.

21 The helium coolant, so for that, the big  
22 thing there was -- they're all out of order on my  
23 paper here -- that affects a whole bunch of the  
24 Principal Design Criteria. The big effect is to  
25 remove considerations related to coolant inventory

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 control, and that's consistent with the modular high-  
2 temperature gas reactor design criteria. And that  
3 means there's no PDC 35, which relates to emergency  
4 core cooling systems. And the emphasis is placed on  
5 the residual heat removal systems.

6 And then there's also they decided to  
7 change, to be consistent, the reactor helium pressure  
8 boundary, instead of reactor coolant pressure boundary  
9 or reactor coolant boundary in the PDCs.

10 There wasn't any particular effect for the  
11 gas turbine on the primary coolant. DC 4 has the  
12 consideration of missiles generated from either inside  
13 or outside the containment. That was actually  
14 included originally in the MHTGR-DC 4. So, I wanted  
15 to note that there.

16 The residual heat removal -- and John  
17 mentioned this on his slides -- so, they adopted the  
18 MHTGR passive residual heat removal PDCs, but, then,  
19 they adapted them to remove passive, so that it would  
20 encompass both their passive system and the active  
21 non-safety-related system.

22 And that seemed appropriate to us to do.  
23 You know, it just made it broader, so that it covers  
24 a wider scope of systems; whereas, the MHTGR-DC really  
25 just, specifically, covers the passive residual heat

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 removal systems.

2 And then, for containment, I already  
3 mentioned that they got the leak-tight containment  
4 building, and they adopted the standard containment  
5 PDCs.

6 Next slide. So, I've, basically, already  
7 covered most of these in what I just said, but we can  
8 quickly go through this.

9 So, I listed out all of the design  
10 criteria, and then, highlighted ones that I think are  
11 worth mentioning, either because they had to make a  
12 particular choice about where they went with it or  
13 they've modified it in an interesting way.

14 So, I just finished talking about PDC 4.  
15 It's noteworthy because they wanted to include  
16 missiles generated inside the reactor helium pressure  
17 boundary.

18 Next slide. So, 10, we've got the --

19 MEMBER BROWN: Can I ask you a question  
20 about the missiles?

21 MR. ANZALONE: Sure.

22 MEMBER BROWN: They show in their prior  
23 generation a gas turbine-driven, you know, the heated  
24 helium-driven TGs. Is that a very high speed? Is  
25 that a very, very high-speed? I mean, all plants have

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 a missile issue relative to their turbine generator  
2 sets you have to consider. So, this looked like a  
3 high-speed one, which would make it more critical in  
4 terms of covering it. Is that the reason for the  
5 emphasis here?

6 MR. ANZALONE: No. I think the reason is  
7 just that, like, it is noteworthy that they have a  
8 power conversion system that is inside containment.

9 MEMBER BROWN: Oh, okay. All right.

10 MR. ANZALONE: And it's part of the  
11 reactor coolant boundary.

12 MEMBER KIRCHNER: It's part of the primary  
13 cooling boundary.

14 MEMBER BROWN: Yes. Okay. So, that part  
15 I missed. I missed that it was inside the coolant,  
16 the primary boundary.

17 MR. ANZALONE: Yes.

18 MEMBER BROWN: My brain fried on it.

19 (Laughter.)

20 MEMBER BROWN: Thank you.

21 MR. ANZALONE: Go ahead.

22 So, I already mentioned the use of SAFDLs  
23 rather than SARRDLs. I will also mention that  
24 Criterion 10 uses, talks about heat removal, rather  
25 than coolant. So, I think the effect that you were

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 talking about of, you know, potentially, oscillatory  
2 coolant behavior -- I think that talking about heat  
3 removal is appropriate there.

4 The same thing with we talked about power  
5 oscillations. Coolant isn't mentioned there, but it  
6 talks about the core. And so, I think that's  
7 appropriately considered, enveloped by that design  
8 criterion. And it does have structures in there in  
9 talking about power oscillations.

10 So, if there's an effect of the  
11 reflectors, that's covered under that design  
12 criterion. Whether that effect is caused by the  
13 behavior of coolant affecting the structures or it's  
14 something in the inherent behavior of the structures.

15 MEMBER MARCH-LEUBA: Yes, I sense some  
16 real thinking that you worry about the structures  
17 because of mechanical vibrations or displacement;  
18 whereas, it could be a temperature oscillation. I  
19 find it very unlikely that will happen, but --

20 MR. ANZALONE: Yes.

21 MEMBER MARCH-LEUBA: -- you have to  
22 consider that it will happen.

23 MR. ANZALONE: No, but, I mean, actually,  
24 I will say, part of the reason that we asked about  
25 structures was, you know, knowing fast reactors and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 that they're, basically, a coupled system, we felt  
2 like that was important to include. We didn't know at  
3 the time when we asked that question that all of the  
4 structures are going to be made out of silicon  
5 carbide. And so, they don't really move very much  
6 during power maneuver.

7 MEMBER MARCH-LEUBA: But you have those  
8 unusual bowing effects. It's an oscillation  
9 configuration, a crucial thing.

10 MR. ANZALONE: But we think it's covered  
11 by just making sure that structures are considered in  
12 there.

13 MEMBER MARCH-LEUBA: Okay.

14 MR. ANZALONE: Thirteen, that was one  
15 where they used the helium pressure boundary instead  
16 of the reactor coolant boundary. And I know it's  
17 instrumentation and control, but, really, the main  
18 distinguishing feature between all the different DCs  
19 was what the coolant system looked like.

20 Containment design. John already covered  
21 that, I think in sufficient detail.

22 And electric power systems, they used the  
23 MHTGR design criterion, but they modified it to go  
24 with SAFDLs instead of SARRDLs. That's appropriate to  
25 be consistent with the other DCs.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MEMBER MARCH-LEUBA: Do we envision  
2 safety-grade power? Or there is nothing that needs to  
3 be driven?

4 MR. ANZALONE: I can't remember off the  
5 top of my head. I'm going to phone a friend.

6 (Laughter.)

7 MR. ANZALONE: To Sheila, do you think you  
8 can answer that question? Or John?

9 MR. BOLIN: John can answer it.

10 We don't see a need for Class 1E backup  
11 electrical generation.

12 Does that --

13 MEMBER MARCH-LEUBA: Yes. But you usually  
14 have a couple of batteries for the control room,  
15 right?

16 MR. BOLIN: Correct. Correct. We'll have  
17 --

18 MEMBER MARCH-LEUBA: Non-safety grade?

19 MR. BOLIN: Or, you know, there will be  
20 containment isolation valves, other isolation valves  
21 that might need to function. Whether they're  
22 electrical, by battery, or some other means is still  
23 to be determined.

24 MR. ANZALONE: Next slide. So, 26. I  
25 want to highlight here we have had some challenges

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 with some applicants in PDC 26. I'm not going to go  
2 into that in detail here. But here, they adopted the  
3 PDC, the language in advanced reactor design criteria.

4 As is, with one modification, to be  
5 consistent with the GDC, they included the effects of  
6 xenon. We don't think that xenon is going to be  
7 particularly important in a fast reactor, but there  
8 wasn't any reason not to include it.

9 MR. BOLIN: And I'll second that. We have  
10 recently found that also to be the case, that xenon is  
11 really not of any -- it has no impact to speak of.

12 MR. ANZALONE: But it's included in the  
13 design criterion.

14 MR. BOLIN: But it's there. It's there.

15 MR. ANZALONE: So, if somehow it's found  
16 to have an effect, it's covered. More broad is  
17 actually okay.

18 So, consistent with the all of the sets of  
19 design criteria in the Reg Guide, got rid of PDC 27  
20 and incorporated it into 26.

21 MEMBER MARCH-LEUBA: Now that I see, I'm  
22 asking not PDC, but criteria limits. Is there an  
23 issue with rod ejection here? We have 7 megapascal.  
24 Will that be a licensing basis event?

25 MR. ANZALONE: I would think so.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MEMBER MARCH-LEUBA: Okay.

2 MR. ANZALONE: We haven't looked at the --  
3 we haven't gotten in the level of detail of  
4 understanding the control rod design or the control  
5 rod drive systems.

6 MEMBER MARCH-LEUBA: It's likely my lack  
7 of familiarity with fast reactors, but even events on  
8 fast reactors bothers me a lot.

9 MEMBER KIRCHNER: It's a high-pressure  
10 envelope and the control rod mechanism is part of the  
11 envelope, inside the envelope. So, it's the same as  
12 a PWR when it comes to rod ejection.

13 MEMBER MARCH-LEUBA: Mm-hmm.

14 MR. ANZALONE: But that is a distinction  
15 to sodium fast reactors which are not high-pressure.

16 For the reactivity limits, they went with  
17 the modular high-temperature gas reactor design  
18 criterion because it fit the best with the coolant  
19 system design that they have. Again, that was the  
20 biggest distinguishing feature between all of them.

21 Next slide. So, getting into fuel  
22 systems, I think John already -- I think we covered  
23 this. So, 33 and 35 were removed, and that's  
24 consistent with the modular high-temperature gas  
25 reactor design criteria, and like I said, reflects a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 focus away from coolant inventory control and towards  
2 residual heat removal. And then, those residual heat  
3 removal PDCs were adjusted to not specifically mention  
4 passive systems.

5 Next slide. There wasn't anything, in  
6 particular, that I wanted to highlight about these,  
7 but I saw that, on John's slides, he mentioned that  
8 containment heat removal, cleanups, and events were  
9 things that they were considering. We think that  
10 those are encompassed by these design criteria, the  
11 way that they're written.

12 Next slide. So, here, 54 I think is  
13 interesting because they referenced the sodium fast  
14 reactor design criteria. They made a change to it to  
15 remove reactor, to signify that there are more  
16 structures inside. So, normally, it says, "reactor  
17 containment," but they want to say, hey, we've got a  
18 lot inside containment, aside from just the reactor.  
19 The power conversion system is inside containment.  
20 So, it just says, "containment," rather than "reactor  
21 containment."

22 But, aside from that, the interesting  
23 thing about SFR-DC 54 is that it talks about not  
24 necessarily having to isolate systems that penetrate  
25 containment where you wouldn't expect a release path.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 And that's key for them to be able to have the water  
2 tanks for the RVCS outside of containment with lines  
3 that go into containment. And because you wouldn't  
4 expect a release pathway to go through those pipes,  
5 that's acceptable. And that's consistent with the  
6 SFR-DC.

7 MEMBER MARCH-LEUBA: And with 55, the  
8 helium pressure boundary doesn't cross containment,  
9 does it?

10 MR. ANZALONE: No, it does not.

11 MEMBER MARCH-LEUBA: I mean, there might  
12 be some feedline.

13 MR. ANZALONE: Yes.

14 MEMBER MARCH-LEUBA: But that wouldn't  
15 enter part of the pressure containment?

16 MR. BOLIN: I will correct. There is a  
17 system that has helium in it that is connected to the  
18 pressure boundary that does cross the containment  
19 boundary, and that's the helium purification system.

20 MR. ANZALONE: Right.

21 MEMBER MARCH-LEUBA: Yes, but that would  
22 be a small line.

23 MR. ANZALONE: Yes.

24 MR. BOLIN: It will be a small line, and  
25 it certainly will have isolation valves on it.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MR. ANZALONE: Well, and that's what the  
2 design criterion says, that you need to do this when  
3 you have reactor helium systems penetrating it.

4 MR. BOLIN: And we will do that.

5 MR. ANZALONE: And then, the next slide.  
6 So, nothing particular with these. They all adopted  
7 the advanced reactor design criterion as written.

8 Next slide. So, I just wanted to talk  
9 briefly about the conclusions and the Safety  
10 Evaluation. So, we think that they, appropriately,  
11 considered the Reg Guide and developed a sufficient  
12 set of PDCs that were appropriate for establishing the  
13 requirements for the FRM design. And like I said,  
14 they came early. So, these will be criteria that  
15 we'll open to, as they continue interactions with us.

16 And what the SE says is that they  
17 establish the necessary design, fabrication,  
18 construction, et cetera, that 10 CRF 50, Appendix 50,  
19 kind of establishes as the requirement for Principal  
20 Design Criteria.

21 And then, I wanted to make note that the  
22 Topical Report can be used by future applicants for  
23 the FRM, but the way that we do Topical Reports, you  
24 know, you have to justify the applicability of the  
25 Topical Report when you come in and you use it. And

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 so, there isn't a specific limitation and condition  
2 that says it has to be like this reactor. But we  
3 expect that, if somebody were to use this Topical  
4 Report and reference it, they would have to justify  
5 that if it was substantially different in any way, why  
6 it was okay to use this design.

7 MEMBER MARCH-LEUBA: By "somebody," do you  
8 mean like a different company?

9 MR. ANZALONE: Well, presumably -- so,  
10 it's for the FRM design. So, I don't know -- some  
11 other company bought that design from General Atomics  
12 or if they spun off a subsidiary or --

13 MEMBER MARCH-LEUBA: Doesn't GA own the  
14 intellectual property on the Topical Report? I mean,  
15 nobody can use it without GA's permission. Well, it's  
16 static.

17 MR. ANZALONE: And that's my last slide.  
18 I have some backup slides that go over some of these  
19 in more detail.

20 CHAIR BIER: So, again, a different  
21 version of the same question that I asked John earlier  
22 with regard to the RAIs. How many of those subsequent  
23 changes to Rev 1 were because the Reg Guide itself  
24 changed? How many were kind of minor editorial  
25 improvements? And were there any that you thought

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 were really (audio interference)?

2 MR. ANZALONE: I don't think there were  
3 any that specifically -- so, the one that I mentioned  
4 earlier, which was including structures in the power  
5 oscillations, that was an RAI, and that was, we think,  
6 important to capture something that was missing.

7 I think most of the rest of them were,  
8 hey, you said you're using this design criterion from  
9 the Reg Guide, but the words that you're using don't  
10 match up. And that could reflect what John said, that  
11 they were using the draft version of the Reg Guide.  
12 I think that covers pretty much all the RAIs between  
13 those two.

14 CHAIR BIER: Are there any other questions  
15 for Reed and Sam? Sorry. Yes, are there other  
16 questions for Reed and Sam? Are there in the room or  
17 online?

18 MEMBER KIRCHNER: I'd just make an  
19 observation or two.

20 I mean, you asked both the applicant and  
21 the staff -- my take, the major thing that's different  
22 here is that, you know, this concept is straddling the  
23 MHTGR and the fast, as has been pointed out, the fast  
24 reactor PDCs and the MHTGR. So, the MHTGR, as we  
25 know, is a functional containment approach -- SARRDLs,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 if I got the acronym right, where this is SAFDLs and  
2 a containment.

3 And I think the main issue that I see  
4 coming is where the systems straddle the containment  
5 boundary for this reactor. So, you've got quasi-  
6 passive systems, if I could call them that. The MHTGR  
7 was meant to be a passive decay heat removal. Here,  
8 you've got a combination of passive/active/quasi-  
9 active systems, maybe depending on what design  
10 approaches we see presented, but you would really hear  
11 about containment bypass, which is not in the MHTGR  
12 designs. That, essentially, is confinement and  
13 reliance, mainly, on the functional containment. So,  
14 I think that's interesting from my vantage point,  
15 looking at how they picked and choose, and how you  
16 reviewed their use of the Reg Guide.

17 That would be the two areas I would zero-  
18 in on for this particular design. And it begs the  
19 question, like Charlie was asking, you know, which  
20 systems are active in terms of which ones might need  
21 electric power, or will they fail safe, so to speak,  
22 without power?

23 MEMBER PETTI: Well, it just seems to me  
24 that there's sort of a body of knowledge of MHTGR and  
25 there's a body of knowledge to fast sodium systems.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 And this kind of sort of puts them together. There's  
2 an intersection, if you will. So, when one thinks  
3 about accident response, you know, there may be  
4 something there that, when you look at them in  
5 accident space, something new comes up that you  
6 wouldn't necessarily see looking at them each  
7 separately. So, it's just something that, when you  
8 get into the details, you have to be looking for.

9 CHAIR BIER: Additional questions or  
10 comments from members or consultants? Anybody on the  
11 line?

12 If not, then we are going to take comments  
13 from the public somewhat earlier than is indicated on  
14 the agenda.

15 We'll wait another 30 seconds or so, in  
16 case anybody is trying to unmute.

17 (No response.)

18 CHAIR BIER: Okay. It sounds like we have  
19 no public comments for today.

20 So, at this point, we have time for member  
21 discussion. And I forget if that should be public or  
22 not public.

23 MEMBER REMPE: We can go off the record  
24 until regular order. But hope someone will show up  
25 tomorrow at 8:30 for us.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 CHAIR BIER: Okay, you got that message,  
2 Court Reporter? I don't believe there is a need for  
3 a closed session. So we will see you at 8:30 in the  
4 morning tomorrow, or whoever it is. Thank you.

5 (Whereupon, the above-entitled matter went  
6 off the record at 3:39 p.m.)

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25



# General Atomics Electromagnetic Systems

## Fast Modular Reactor Conceptual Design

May 2, 2023

Presented To: Advisory Committee on Reactor Safeguards

Prepared By: John Bolin (GA-EMS)





# Fast Modular Reactor (FMR) Distinguished Design Team Goal

***The goal is to advance General Atomics Electromagnetic Systems (GA-EMS) Fast Modular Reactor 44 MWe (FMR) for flexible and dispatchable carbon-free electricity generation, targeting commercial operations by 2035.***

- The Team will develop and verify key-design attributes such as fast-spectrum neutron, inert helium gas coolant, pellet-loaded fuel rod, site-flexible, small and passive heat removal systems, that will result in a safe, maintainable, and cost-effective nuclear power generation.
- The FMR project was officially awarded on 15 December 2021 as a three-year program under Advanced Reactor Demonstration Program (ARDP)/Advanced Reactor Concepts-20 (ARC-20).

**GA-EMS is working with a distinguished team to this effort with a strategic partner in Framatome (FRA) as well as collaboration with Electric Power Research Institute (EPRI), Idaho National Laboratory (INL), Argonne National Laboratory (ANL), Sandia National Laboratories (SNL), University of Wisconsin-Madison (UWM), and University of Texas-Arlington (UTA).**

# Project Objectives That Enable Future Development and Deployment

*The project objective is the FMR conceptual design with verifications of key metrics in fuel, safety, and operational performance.*

- The project will verify the technical feasibilities of high-burnup fuel operation, passive safety features, and rapid grid adaptability.
- The project includes pre-application licensing activities with Nuclear Regulatory Commission (NRC).
- The project will conduct an initial cost evaluation.

## **Experimental verification:**

- (i) Fuel fabrication campaign, high-burnup irradiation tests and transient tests to qualify the fuel design.
- (ii) Scaled tests of the Reactor Vessel Cooling System (RVCS) to verify the passive cooling capability.

## **Numerical verification:**

- (i) Accident analysis to support the design work and the pre-application licensing.
- (ii) FMR plant simulator to demonstrate the rapid load-following capability.




# FMR Core Designed to Improve Safety Margin

	FMR	GT-MHR	AP1000
Reactor core heat output, MWt	100	600	3400
Reactor core power density, MW/m <sup>3</sup>	14.97	6.6	109.7
Heat generated in fuel, %	-	-	97.4
Nominal system pressure, MPa	7	7.07	15.5
Coolant total flow rate, kg/s	66	320	14,301
Coolant nominal inlet temperature, °C	509	491	279.4
Coolant temperature rise in core, °C	291	359	27.4
Fuel rod average linear power, kW/m	<b>2.34</b>	<b>0.39<sup>a)</sup></b>	<b>18.8</b>
Heat flux hot channel factor, F <sub>Q</sub>	<b>1.52</b>	-	<b>2.6</b>
Fuel assembly geometry	Hexagonal	Hexagonal <sup>b)</sup>	Square <sup>c)</sup>
Number of fuel assemblies	198	102 <sup>d)</sup>	157
Fuel rods per assembly	120	210 <sup>a)</sup>	264
Fuel material	UO <sub>2</sub>	UC <sub>0.5</sub> O <sub>1.5</sub>	UO <sub>2</sub>
Cladding material	SiGA	SiC <sup>e)</sup>	ZIRLO
Core active height (cm)	180	793	426.72


a) Stack of fuel compacts, b) Solid block with coolant channels inside, c) 17×17, d) Fuel blocks, e) TRISO fuel particle coating

# Fuel Leverages UO<sub>2</sub> Legacy and SiGA™ Cladding Development

- High density UO<sub>2</sub> proven in LWRs and tested in fast reactors
- Silicon carbide composite cladding (SiGA) undergoing testing and maturation through DOE Accident Tolerant Fuel (ATF) program
- Fuel design uses ATF-LWR dimensions with large plenum like legacy liquid metal fast reactors




Cladding tube




Endcap welding

# Numerical and Experimental Verification of Fuel Design




ATR Irradiation Capsule



TREAT  
Transient  
Capsule


# FMR Test Rodlets Fabricated Using ATF Established Procedures

## Fuel Rod Fabrication Process




# Vessel System Designed to Minimize Helium Leakage

- **Conceptual sizing calculation for normal and AOO conditions**
  - Design code is Section III, Division 5, 2021 Ed.
  - Thickness is adequate for operation up to 300,000 hours (~34 EFPY), will be extended to 540,000 hours (~60+ EFPY) (code revision)
  - Proven use of seal welds at joints to minimize helium leakage
- **Flow reductions during accident conditions reduces pressure loads**
- **Conceptual design complete on reactor vessel internals**




# Power Conversion System (PCS) based on a Direct Brayton-Cycle



- **Dry Cooling Tower**

- Reduces impact on water resources and expands siting options




**High-Efficiency Cycle that supports fast maneuvering capability**



# Containment Improves Safety and Siting



1. Reactor vessel
2. Reactor vessel cooling panel
3. Power conversion unit
4. Generator
5. Recirculator
6. Maintenance cooling system
7. Water tank
8. Containment
9. Containment liner
10. Maintenance caps
11. Concrete
12. Ground level




- The Containment System (Category I Structure, SSE-qualified) includes below-grade, leak-tight Containment Vessel (multi-barrier, defense-in-depth)
- Need for containment heat removal, cleanup, and venting under investigation


Below grade containment that is less vulnerable  
to airplane crashes

# Residual Heat Removed By Active and Passive Systems

- Reactor Vessel Cooling System (2-loops)
- Maintenance Cooling System
- Annular core arrangement promotes passive heat removal






- Central zone
- Zone 1 = 1x burned
- Zone 2 = Fresh
- Zone 3 = 2x burned
- $Zr_3Si_2$
- Graphite
- Neutron absorber



# Core Bypass Flow Effects Normal Operation and Accidents


- Core bypass flows through central and radial reflectors improves heat transfer during loss of forced cooling accidents



# Progress in Pre-Application Licensing with NRC

**GA-EMS has issued four documents and submitted them to NRC and DOE.**

- Revision of the PDC document was issued following NRC's RAIs.
- The QA document was also revised following NRC's recommendations.



# Acknowledgements

**This work was supported by the U.S. Department of Energy - Office of Nuclear Energy under Contract Number DE-NE0009052 for Advanced Reactor Concepts-20 (ARC-20).**






# General Atomics Electromagnetic Systems

## Fast Modular Reactor Principal Design Criteria

May 2, 2023

Presented To: Advisory Committee on Reactor Safeguards

Prepared By: John Bolin (GA-EMS)



# Principal Design Criteria Adapted From NRC Guidance

- **Regulatory Guide (RG) 1.232 established guidance for developing PDC for non-light-water reactors by modifying / supplementing 10 CFR 50, Appendix A, General Design Criteria (GDC) in three categories:**
  - Sodium-cooled fast reactors (SFR-DC)
  - Modular high-temperature gas-cooled reactors (MHTGR-DC)
  - Design-neutral advanced reactors (ARDC)
- **ARDC and MHTGR-DC used as starting point**
- **NRC rationale for adaptation of GDC modified for application to FMR-DC**

# I. Overall Requirements – FMR DC 1 – 5

- **FMR-DC 1: Quality standards and records: Same as GDC**
- **FMR-DC 2: Design bases for protection against natural phenomena: Same as GDC**
- **FMR-DC 3: Fire protection: Same as ARDC**
- **FMR-DC 4: Environmental and dynamic effects design bases: Modified from MHTGR-DC**
  - “missiles” changed to “missiles originating both inside and outside the reactor helium pressure boundary” to cover turbomachinery
- **FMR-DC 5: Sharing of structures, systems, and components: Same as GDC**



## II. Multiple Barriers – FMR-DC 10 – 19

- **FMR-DC 10: Reactor design: Fuel design using SiGA cladding functions like LWRs so SAFDL terminology used here and in other FMR-DCs**
- **FMR-DC 11, 13 - 15, 17 - 18: Same as ARDC and MHTGR-DC with minor terminology changes**
- **FMR-DC 12: Suppression of reactor power oscillations: The word “structures” added to address reflectors. The word “coolant” was deleted.**
- **FMR-DC 16: Containment design: Same as SFR-DC because FMR uses low-leakage, pressure-retaining containment**

### III. Reactivity Control – FMR-DC 20 – 29

- **FMR-DC 20 - 24: Same as GDC**
- **FMR-DC 25: Protection system requirements for reactivity control malfunctions: Same as ARDC with minor terminology changes**
- **FMR-DC 26: Reactivity control systems: Combines GDC 26 and GDC 27 same as ARDC and MHTGR-DC**
- **FMR-DC 28: Reactivity limits: Same as MHTGR-DC**
- **FMR-DC 29: Protection against anticipated operational occurrences: Same as GDC**

## IV. Fluid Systems – FMR-DC 30 – 46

- **FMR-DC 30 – 33: Same as MHTGR-DC**
- **FMR-DC 34: Residual heat removal: Similar to MHTGR-DC. Both active non-safety-related and passive safety-related systems available to remove residual heat. Incorporates requirements in GDC 35.**
- **FMR-DC 36 and 37: Same as MHTGR-DC**
- **FMR-DC 38 – 41: Same as ARDC**
- **FMR-DC 42: Inspection of containment atmosphere cleanup systems: Same as GDC**
- **FMR-DC 43, 45, 46: Same as ARDC**
- **FMR-DC 44: Same as MHTGR-DC**

# V. Reactor Containment and VI. Fuel and Radioactivity Control

## V. Reactor Containment – FMR-DC 50-57

- FMR-DC 50 – 53: Same as ARDC
- FMR-DC 54: Same as SFR-DC
- FMR-DC 55 - 57: Same as ARDC with minor terminology changes

## VI. Fuel and Radioactivity Control – FMR-DC 60 – 64

- FMR-DC 60, 62, 63: Same as GDC
- FMR-DC 61: Same as ARDC

# Acknowledgements

**This work was supported by the U.S. Department of Energy - Office of Nuclear Energy under Contract Number DE-NE0009052 for Advanced Reactor Concepts-20 (ARC-20).**

# General Atomics – Electromagnetic Systems Fast Modular Reactor Principal Design Criteria

Samuel Cuadrado de Jesus, NRR/DANU

Reed Anzalone, NRR/DANU

Sheila Ray, NRR/DEX

Steve Jones, NRR/DANU

# Agenda

- General Atomics – Electromagnetic Systems (GA-EMS) Fast Modular Reactor (FMR) pre-application engagement
- GA-EMS FMR principal design criteria (PDC) topical report (TR) review timeline
- GA-EMS FMR design features
- PDC guidance
  - General Design Criteria (GDC)
  - Regulatory Guide (RG) 1.232
- GA-EMS PDC development approach
- Fast modular reactor design criteria (FMR-DC)
  - Impacts of key design choices on PDCs
  - FMR-DC overview
- Safety evaluation (SE) conclusions

# GA-EMS FMR Pre-Application Engagement

## Documents Submitted

Submittal	Document	Review Status
03/2022	Pre-Application Regulatory Engagement Plan	N/A
06/2022	PDC TR	Draft SE issued
02/2023	Fuel Qualification Plan Technical Report	Under review (white paper)
04/2023	Quality Assurance Program TR	Pending acceptance determination

## Documents Expected

Submittal	Document
06/2023	Mechanistic Source Term Technical Report
12/2023	LBE Selection White Paper
05/2024	Safety Approach and Mini-PRA White Paper
05/2024	Safety Classification White Paper

\*FMR demonstration expected by 2030 and deployment by mid-2030s



# GA-EMS FMR PDC TR Review Timeline

- Submitted 06/06/22 (ML22154A555)
- Accepted 07/07/22 (ML22181B173)
- Requests for Additional Information (RAIs) issued 10/5/22 (ML22321A310)
- RAI response received 11/7/22 (ML22311A472)
- Revision 2 of TR transmitted 01/05/23 (ML23005A292)
- Draft SE issued 03/17/23 (ML23076A196)

# GA-EMS FMR Design Features





Figure 2. FMR Primary Coolant Flow and Power Generation

# GA-EMS FMR Design Features



Source: TR, ML22154A556

# GA-EMS FMR Key Design Features

Feature	Design
Fuel	UO <sub>2</sub> pellets in silicon carbide fuel pins
Core arrangement	Pins in triangular pitch arranged into hexagonal bundles
Neutron spectrum	Fast
Coolant	Helium
Power conversion system	Gas turbine on primary coolant
Residual heat removal	Reactor vessel cooling system (water-fed, gravity-driven passive system)
Containment	Leak-tight containment building

# PDC Guidance – 10 CFR 50 Appendix A GDC

“The principal design criteria establish the necessary design, fabrication, construction, testing, and performance requirements for structures, systems, and components important to safety; that is, structures, systems, and components that provide reasonable assurance that the facility can be operated without undue risk to the health and safety of the public.”

“These General Design Criteria establish minimum requirements for the principal design criteria for water-cooled nuclear power plants similar in design and location to plants for which construction permits have been issued by the Commission. **The General Design Criteria are also considered to be generally applicable to other types of nuclear power units and are intended to provide guidance in establishing the principal design criteria for such other units.**”

# PDC Guidance – RG 1.232, “Guidance for Developing Principal Design Criteria for Non-Light-Water Reactors”

- Issued April 2018 (ACRS letter March 2018)
- Documents three sets of acceptable PDCs:
  - Advanced reactor DC (ARDC) – generic, technology inclusive\*
  - Sodium-cooled fast reactor DC (SFR-DC) – sodium-cooled fast reactors (e.g., PRISM)
  - Modular high temperature gas-cooled reactor DC (MHTGR-DC) – TRISO-fueled, helium-cooled, graphite-moderated HTGR

\* For sodium/lead/gas-cooled fast reactors, modular high temperature gas reactors, fluoride high-temperature reactors, and molten salt reactors

# GA-EMS Approach to PDC Development

- Start with ARDC, considering underlying safety basis
- If ARDC not fully applicable, assess SFR-DC and MHTGR-DC for direct adoption
- If SFR-DC or MHTGR-DC not directly applicable, apply DC that is most representative of FMR
- Adapt or refine selected DC

# Key Design Feature Effects on PDCs

Feature	Design	Effect on PDCs
Fuel	UO <sub>2</sub> pellets in silicon carbide fuel pins	Use of specified acceptable fuel design limits (SAFDLs) instead of specified acceptable system radionuclide release design limits (SARRDLs)
Core arrangement	Pins in triangular pitch arranged into hexagonal bundles	
Neutron spectrum	Fast	Consider effect of structures on reactivity feedback
Coolant	Helium	Removal of coolant inventory control considerations consistent with MHTGR; use of reactor helium pressure boundary in lieu of reactor coolant pressure boundary
Power conversion system	Gas turbine on primary coolant	No particular effect
Residual heat removal	Reactor vessel cooling system (water-fed, gravity-driven passive system)	Adoption of MHTGR passive residual heat removal PDCs
Containment	Leak-tight containment building	Adoption of containment PDCs



# FMR-DC – I. Overall Requirements

Criterion	Title	Basis PDC	Modified?
1	Quality standards and records.	ARDC	N
2	Design bases for protection against natural phenomena.	ARDC	N
3	Fire protection.	ARDC	N
4	Environmental and dynamic effects design bases.	MHTGR-DC	N
5	Sharing of structures, systems, and components	ARDC	N

# FMR-DC – II. Multiple Barriers

Criterion	Title	Basis PDC	Modified?
10	Reactor design.	ARDC	Y - uses "heat removal" instead of "coolant"
11	Reactor inherent protection.	ARDC	N
12	Suppression of reactor power oscillations.	ARDC	Y - removes "coolant"
13	Instrumentation and control.	ARDC	Y - uses "helium pressure boundary" instead of "reactor coolant boundary"
14	Reactor helium pressure boundary.	MHTGR-DC	N
15	Reactor helium pressure boundary design.	MHTGR-DC	N
16	Containment design.	SFR-DC	N
17	Electric power systems.	MHTGR-DC	Y - uses SAFDLs instead of SARRDLs
18	Inspection and testing of electric power systems.	ARDC	N
19	Control room.	MHTGR-DC	N

# FMR-DC – III. Reactivity Control

Criterion	Title	Basis PDC	Modified?
20	Protection system functions	ARDC	N
21	Protection system testability and reliability.	ARDC	N
22	Protection system independence.	ARDC	N
23	Protection system failure modes.	ARDC	N
24	Separation of protection and control systems.	ARDC	N
25	Protection system requirements for reactivity control malfunctions.	ARDC	N
26	Reactivity control systems.	ARDC	Y - includes effects of xenon
27	[None - incorporated into 26 consistent with RG 1.232]	N/A	N/A
28	Reactivity limits.	MHTGR-DC	N
29	Protection against anticipated operational occurrences.	ARDC	N

# FMR-DC – IV. Fluid Systems (1)

Criterion	Title	Basis PDC	Modified?
30	Quality of reactor helium pressure boundary.	MHTGR-DC	N
31	Fracture prevention of reactor helium pressure boundary.	MHTGR-DC	N
32	Inspection of reactor helium pressure boundary	MHTGR-DC	N
33	[None - not applicable consistent with MHTGR-DC]	N/A	N/A
34	Residual heat removal.	MHTGR-DC	Y - includes both passive and active systems
35	[None - not applicable consistent with MHTGR-DC]	N/A	N/A
36	Inspection of passive residual heat removal system.	MHTGR-DC	N
37	Testing of residual heat removal system.	MHTGR-DC	Y - includes both passive and active systems
38	Containment heat removal.	ARDC	N
39	Inspection of containment heat removal system.	ARDC	N

# FMR-DC – IV. Fluid Systems (2)

Criterion	Title	Basis PDC	Modified?
40	Testing of containment heat removal system.	ARDC	N
41	Containment atmosphere cleanup.	ARDC	N
42	Inspection of containment atmosphere cleanup systems.	ARDC	N
43	Testing of containment atmosphere cleanup systems.	ARDC	N
44	Structural and equipment cooling.	ARDC	N
45	Inspection of structural and equipment cooling systems.	ARDC	N
46	Testing of structural and equipment cooling systems.	ARDC	N

# FMR-DC – V. Reactor Containment

Criterion	Title	Basis PDC	Modified?
50	Containment design basis.	ARDC	N
51	Fracture prevention of containment pressure boundary.	ARDC	N
52	Capability for containment leakage rate testing.	ARDC	N
53	Provisions for containment testing and inspection.	ARDC	N
54	Piping systems penetrating containment.	SFR-DC	Y - removes "reactor"
55	Reactor helium pressure boundary penetrating containment.	ARDC	Y - uses "helium pressure boundary" instead of "reactor coolant boundary"
56	Containment isolation.	ARDC	N
57	Closed system isolation valves.	ARDC	Y - uses "helium pressure boundary" instead of "reactor coolant boundary"

# FMR-DC – VI. Fuel and Reactivity Control

Criterion	Title	Basis PDC	Modified?
60	Control of releases of radioactive materials to the environment.	ARDC	N
61	Fuel storage and handling and radioactivity control.	ARDC	N
62	Prevention of criticality in fuel storage and handling.	ARDC	N
63	Monitoring fuel and waste storage.	ARDC	N
64	Monitoring radioactivity releases.	ARDC	N

# Safety Evaluation Conclusions

- GA-EMS appropriately considered RG 1.232 and developed a sufficient set of PDCs appropriate for establishing requirements for the FMR design.
- PDCs establish the necessary design, fabrication, construction, testing, and performance design criteria for safety-significant SSCs to provide reasonable assurance that an FMR could be operated without undue risk to the health and safety of the public. (10 CFR 50 App A)
- This TR can be used by future FMR applicants, but if the reactor design differs from that discussed in the TR use of the PDCs in the TR must be justified.



# FMR-DC Summary

- Directly adopted from RG 1.232
  - From ARDC: FMR-DC 1, 2, 3, 5, 11, 18, 20, 21, 22, 23, 24, 25, 29, 38, 39, 40, 41, 42, 43, 44, 45, 46, 50, 51, 52, 53, 60, 61, 62, 63, 64
  - From SFR-DC: FMR-DC 16
  - From MHTGR-DC: FMR-DC 4, 14, 15, 19, 28, 30, 31, 32, 36
- Modified from RG 1.232
  - FMR-DC 10 (ARDC 10), 12 (ARDC 12), 13 (ARDC 13), 17 (MHTGR-DC 17), 26 (ARDC 26), 34 (MHTGR-DC 34), 37 (MHTGR-DC 37), 54 (SFR-DC 54), 55 (ARDC 55), 57 (ARDC 57)

# FMR-DC Modified from RG 1.232

ARDC 10	FMR-DC 10
<p><i>Reactor design.</i></p> <p>The reactor core and associated coolant, control, and protection systems shall be designed with appropriate margin to assure that specified acceptable fuel design limits are not exceeded during any condition of normal operation, including the effects of anticipated operational occurrences.</p>	<p><i>Reactor design.</i></p> <p>The reactor core and associated <del>coolant</del> <b>heat removal</b>, control, and protection systems shall be designed with appropriate margin to assure that specified acceptable fuel design limits are not exceeded during any condition of normal operation, including the effects of anticipated operational occurrences.</p>

Basis: Helium inventory control is not necessary to meet SAFDLs due to reactor system design; consistent with MHTGR-DC (which use SARRDLs instead) and other FMR-DC

# FMR-DC Modified from RG 1.232

ARDC 12	FMR-DC 12
<p data-bbox="173 439 980 485"><i>Suppression of reactor power oscillations.</i></p> <p data-bbox="173 554 945 996">The reactor core; associated structures; and associated coolant, control, and protection systems shall be designed to ensure that power oscillations that can result in conditions exceeding specified acceptable fuel design limits are not possible or can be reliably and readily detected and suppressed.</p>	<p data-bbox="1021 439 1829 485"><i>Suppression of reactor power oscillations.</i></p> <p data-bbox="1021 554 1819 996">The reactor core<del>;</del>, associated structures<del>;</del>, and associated <del>coolant,</del> control<del>,</del> and protection systems shall be designed to ensure that power oscillations that can result in conditions exceeding specified acceptable fuel design limits are not possible or can be reliably and readily detected and suppressed.</p>

Basis: Helium coolant does not have a significant effect on reactivity for the FMR

# FMR-DC Modified from RG 1.232

ARDC 13	FMR-DC 13
<p><i>Instrumentation and control.</i></p> <p>Instrumentation shall be provided to monitor variables and systems over their anticipated ranges for normal operation, for anticipated operational occurrences, and for accident conditions, as appropriate to ensure adequate safety, including those variables and systems that can affect the fission process, the integrity of the reactor core, the reactor coolant boundary, and the containment and its associated systems. Appropriate controls shall be provided to maintain these variables and systems within prescribed operating ranges.</p>	<p><i>Instrumentation and control.</i></p> <p>Instrumentation shall be provided to monitor variables and systems over their anticipated ranges for normal operation, for anticipated operational occurrences, and for accident conditions, as appropriate, to ensure adequate safety, including those variables and systems that can affect the fission process, and the integrity of the reactor core, the reactor <del>coolant</del> helium pressure boundary, and the containment and <del>its</del> associated systems. Appropriate controls shall be provided to maintain these variables and systems within prescribed operating ranges.</p>

Basis: More appropriate to say “reactor helium pressure boundary” than “reactor coolant boundary” for FMR, consistent with MHTGR-DC and other FMR-DC

# FMR-DC Modified from RG 1.232

ARDC 26	FMR-DC 26
<p><i>Reactivity control systems.</i></p> <p>A minimum of two reactivity control systems or means shall provide:</p> <p>(1) A means of inserting negative reactivity at a sufficient rate and amount to assure, with appropriate margin for malfunctions, that the design limits for the fission product barriers are not exceeded and safe shutdown is achieved and maintained during normal operation, including anticipated operational occurrences.</p> <p>(2) A means which is independent and diverse from the other(s), shall be capable of controlling the rate of reactivity changes resulting from planned, normal power changes to assure that the design limits for the fission product barriers are not exceeded.</p> <p>(3) A means of inserting negative reactivity at a sufficient rate and amount to assure, with appropriate margin for malfunctions, that the capability to cool the core is maintained and a means of shutting down the reactor and maintaining, at a minimum, a safe shutdown condition following a postulated accident.</p> <p>(4) A means for holding the reactor shutdown under conditions which allow for interventions such as fuel loading, inspection and repair shall be provided.</p>	<p><i>Reactivity control systems.</i></p> <p>A minimum of two reactivity control systems or means shall provide:</p> <p>(1) A means of inserting negative reactivity at a sufficient rate and amount to assure, with appropriate margin for malfunctions, that the design limits for the fission product barriers are not exceeded and safe shutdown is achieved and maintained during normal operation, including anticipated operational occurrences.</p> <p>(2) A means which is independent and diverse from the other(s), shall be capable of controlling the rate of reactivity changes resulting from planned, normal power changes (including xenon burnout) to assure that the design limits for the fission product barriers are not exceeded.</p> <p>(3) A means of inserting negative reactivity at a sufficient rate and amount to assure, with appropriate margin for malfunctions, that the capability to cool the core is maintained and a means of shutting down the reactor and maintaining, at a minimum, a safe shutdown condition following a postulated accident.</p> <p>(4) A means for holding the reactor shutdown under conditions which allow for interventions such as fuel loading, inspection and repair shall be provided.</p>

Basis: GDC 26 includes explicit consideration of Xe burnout; while Xe is not expected to be a significant reactivity contributor in the FMR it is not incorrect to explicitly include it

# FMR-DC Modified from RG 1.232

MHTGR-DC 34	FMR-DC 34
<p>Passive residual heat removal.</p> <p>A passive system to remove residual heat shall be provided. For normal operations and anticipated operational occurrences, the system safety function shall be to transfer fission product decay heat and other residual heat from the reactor core to an ultimate heat sink at a rate such that specified acceptable system radionuclide release design limits and the design conditions of the reactor helium pressure boundary are not exceeded.</p> <p>During postulated accidents, the system safety function shall provide effective cooling.</p> <p>Suitable redundancy in components and features and suitable interconnections, leak detection, and isolation capabilities shall be provided to ensure the system safety function can be accomplished, assuming a single failure.</p>	<p><del>Passive</del> Residual heat removal.</p> <p><del>A passive</del> System(s) to remove residual heat shall be provided. For normal operations and anticipated operational occurrences, the system safety function shall be to transfer fission product decay heat and other residual heat from the reactor core to an ultimate heat sink at a rate such that specified acceptable <del>system radionuclide release</del> fuel design limits and the design conditions of the reactor helium pressure boundary are not exceeded.</p> <p>During postulated accidents, the system safety function shall provide effective core cooling.</p> <p>Suitable redundancy in components and features and suitable interconnections, leak detection, and isolation capabilities shall be provided to ensure the system safety function can be accomplished, assuming a single failure.</p>

Basis: The MHTGR included a passive residual heat removal (RHR) system because of the low core power density. FMR has multiple RHR systems including active non-safety-related systems and passive safety-related systems, and the DC should be broad enough to apply to all of them.

# FMR-DC Modified from RG 1.232

MHTGR-DC 37	FMR-DC 37
<p><i>Testing of passive residual heat removal system.</i></p> <p>The passive residual heat removal system shall be designed to permit appropriate periodic functional testing to ensure (1) the structural and leaktight integrity of its components, (2) the operability and performance of the system components, and (3) the operability of the system as a whole and, under conditions as close to design as practical, the performance of the full operational sequence that brings the system into operation, including associated systems, for AOO or postulated accident decay heat removal to the ultimate heat sink and, if applicable, any system(s) necessary to transition from active normal operation to passive mode.</p>	<p><i>Testing of <del>passive</del>-residual heat removal system.</i></p> <p>The <del>passive</del>-residual heat removal system(s) shall be designed to permit appropriate periodic functional testing to ensure (1) the structural and leak-tight integrity of its components, (2) the operability and performance of the system components, and (3) the operability of the system as a whole and, under conditions as close to design as practical, the performance of the full operational sequence that brings the system into operation, including associated systems, for AOO or postulated accident decay heat removal to the ultimate heat sink and, if applicable, any system(s) necessary to transition from active normal operation to passive mode.</p>

Basis: The MHTGR included a passive residual heat removal (RHR) system because of the low core power density. FMR has multiple RHR systems including active non-safety-related systems and passive safety-related systems, and the DC should be broad enough to apply to all of them (same as FMR-DC 34).

# FMR-DC Modified from RG 1.232

SFR-DC 54	FMR-DC 54
<p><i>Piping systems penetrating containment.</i></p> <p>Piping systems penetrating the reactor containment structure shall be provided with leak detection, isolation, and containment capabilities that have redundancy, reliability, and performance capabilities necessary to perform the containment safety function and that reflect the importance to safety of preventing radioactivity releases from containment through these piping systems. Such piping systems shall be designed with the capability to verify, by testing, the operational readiness of any isolation valves and associated apparatus periodically and to confirm that valve leakage is within acceptable limits.</p>	<p><i>Piping systems penetrating containment.</i></p> <p>Piping systems penetrating the <del>reactor</del> containment structure shall be provided with leak detection, isolation, and containment capabilities that have redundancy, reliability, and performance capabilities necessary to perform the containment safety function and that reflect the importance to safety of preventing radioactivity releases from containment through these piping systems. Such piping systems shall be designed with the capability to verify, by testing, the operational readiness of any isolation valves and associated apparatus periodically and to confirm that valve leakage is within acceptable limits.</p>

Basis: There are other major SSCs other than just the reactor within containment (e.g., the power conversion system) so it is appropriate to remove the word “reactor”



# FMR-DC Modified from RG 1.232

ARDC 55	FMR-DC 55
<p><i>Reactor coolant boundary penetrating containment.</i></p> <p>Each line that is part of the reactor coolant boundary and that penetrates the containment structure shall be provided with containment isolation valves, as follows, unless it can be demonstrated that the containment isolation provisions for a specific class of lines, such as instrument lines, are acceptable on some other defined basis:</p> <p>...</p>	<p><i>Reactor <del>coolant</del>helium pressure boundary penetrating containment.</i></p> <p>Each line that is part of the reactor <del>coolant</del>helium pressure boundary and that penetrates the reactor containment structure shall be provided with containment isolation valves as follows, unless it can be demonstrated that the containment isolation provisions for a specific class of lines, such as instrument lines, are acceptable on some other defined basis:</p> <p>...</p>

Basis: More appropriate to say “reactor helium pressure boundary” than “reactor coolant boundary” for FMR, consistent with MHTGR-DC and other FMR-DC

# FMR-DC Modified from RG 1.232

ARDC 57	FMR-DC 57
<p><i>Closed system isolation valves.</i></p> <p>Each line that penetrates the containment structure and is neither part of the reactor coolant boundary nor connected directly to the containment atmosphere shall have at least one containment isolation valve, unless it can be demonstrated that the containment safety function can be met without an isolation valve and assuming failure of a single active component. The isolation valve, if required, shall be either automatic, or locked closed, or capable of remote manual operation. This valve shall be outside containment and located as close to the containment as practical. A simple check valve may not be used as the automatic isolation valve.</p>	<p><i>Closed system isolation valves.</i></p> <p>Each line that penetrates the containment structure and is neither part of the reactor <del>coolant</del> helium pressure boundary nor connected directly to the containment atmosphere shall have at least one containment isolation valve unless it can be demonstrated that the containment safety function can be met without an isolation valve and assuming failure of a single active component. The isolation valve, if required, shall be either automatic, or locked closed, or capable of remote manual operation. This valve shall be outside containment and located as close to the containment as practical. A simple check valve may not be used as the automatic isolation valve.</p>

Basis: More appropriate to say “reactor helium pressure boundary” than “reactor coolant boundary” for FMR, consistent with MHTGR-DC and other FMR-DC