

Official Transcript of Proceedings
NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards

Docket Number: (n/a)

Location: teleconference

Date: Wednesday, June 7, 2023

Work Order No.: NRC-2423

Pages 1-46

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1716 14th Street, N.W.
Washington, D.C. 20009
(202) 234-4433

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, as reported herein, is a record of the discussions recorded at the meeting.

This transcript has not been reviewed, corrected, and edited, and it may contain inaccuracies.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

+ + + + +

706TH MEETING

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

(ACRS)

+ + + + +

OPEN SESSION

+ + + + +

WEDNESDAY

JUNE 7, 2023

+ + + + +

The Advisory Committee met via hybrid In-
Person and Video-Teleconference, at 1:00 p.m. EDT, Joy
L. Rempe, Chairman, presiding.

COMMITTEE MEMBERS:

- JOY L. REMPE, Chairman
- WALTER L. KIRCHNER, Vice Chairman
- DAVID A. PETTI, Member-at-Large
- RONALD G. BALLINGER, Member
- CHARLES H. BROWN, JR., Member
- VICKI M. BIER, Member
- VESNA B. DIMITRIJEVIC, Member
- GREGORY H. HALNON, Member

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

JOSE MARCH-LEUBA, Member

MATTHEW W. SUNSERI, Member

DESIGNATED FEDERAL OFFICIAL:

WEIDONG WANG

ALSO PRESENT:

REED ANZALONE, NRR

JOHN BOLIN, GA-EMS

SAMUEL CUADRADO DE JESUS, NRR

STEVE JONES, NRR

SCOTT MOORE, Executive Director, ACRS

ANDREW PROFFITT, NRR

A G E N D A

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

Opening Remarks by the ACRS Chairman

1.1) Opening Statement

1.2) Agenda and Items of Current Interest

General Atomics (GA) Fast Modular Reactor Principal

Design Criteria

2.1) Remarks from Subcommittee Chair . . . 7

2.2) Presentations and Discussions with GA
representatives and NRC staff 9

P-R-O-C-E-E-D-I-N-G-S

1:05 p.m.

CHAIR REMPE: So it is past 1:00 p.m. And I apologize, but there was a technical difficulty in the room. And the ACRS meeting will now come to order. This is the first day of the 706th meeting of the Advisory Committee on Reactor Safeguards.

And I am Joy Rempe, Chairman of the ACRS. Other members are Ron Ballinger, Vicki Bier, Charles Brown, Vesna Dimitrijevic, Greg Halnon, Walt Kirchner, Jose March-Leuba, Dave Petti, and Matt Sunseri. We do have a quorum. And today the committee is meeting in person and virtually.

The ACRS was established by the Atomic Energy Act, and is governed by the Federal Advisory Committee Act. The ACRS section of the U.S. NRC public website provides information about the history of this committee and documents, such as our Charter, bylaws, Federal Register notices for meetings, letter reports, and transcripts of all full and sub-committee meetings, including all slides presented at the meetings.

The committee provides its advice on safety matters to the Commission through its publicly available letter reports. The Federal Register notice

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 announcing this meeting was published on May 12th,
2 2023. This announcement provided a meeting agenda as
3 well as instructions for interested parties to submit
4 written documents or request opportunity to address
5 the committee. The DFO for today's meeting is Weidong
6 Wang.

7 The communications channel has been opened
8 to allow members of public to monitor open portions of
9 the meeting. Members of the public may use the MS
10 Teams link to view slides and other discussion
11 materials during these open sessions. The MS Teams
12 link information was placed in the Federal Register
13 notice and agenda on the ACRS public website.

14 We received no written comments or
15 requests to make oral statements from members of the
16 public regarding today's session. Periodically the
17 meeting will be opened to accept comments from
18 participants listening to our meeting. Written
19 comments may be forwarded to Mr. Weidong Wang, today's
20 DFO.

21 During today's meeting, the committee will
22 consider the General Atomics Fast Modular Sensible
23 Design Criteria topical report. Note that portions of
24 the GA session may be closed as stated in the agenda.

25 A transcript of the open portions of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 meeting is being kept, and it's requested that
2 speakers identify themselves and speak with sufficient
3 clarity and volume so they may be readily heard.
4 Participants should mute themselves when they're not
5 speaking.

6 Before we begin today's session, I do have
7 two topics of interest. First, we'd like to welcome
8 Paris Bradley, a summer hire, who's pursuing a
9 Master's Degree in Nuclear Science and Engineering at
10 the Colorado School of Mines.

11 And second, I'd like to ask members to
12 join me in congratulating Member Petti for his
13 reappointment to ACRS for a second term.

14 I'd also like to thank Scott and Alisha's
15 organization for their efforts to get this package
16 together so that we could have this renomination
17 occur.

18 And at this time, I'd like to ask some of
19 the other members if they have any opening remarks.
20 Hearing none, I'd like to ask --

21 MR. MOORE: Chairman?

22 CHAIR REMPE: Oh, they do --

23 MR. MOORE: Yeah. I'm not a member but
24 Executive Director, Scott Moore. I'd also like to let
25 the members know, and recognize we have a new member

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 and, excuse me, we have a new staff member in PMDA.
2 Tyesha Bush joined us about three weeks ago. And
3 she's working with a future incoming member right now.
4 But, yeah.

5 CHAIR REMPE: Thank you, Scott. I did
6 meet Tyesha today, and we're glad to have her onboard.
7 She's already been very helpful to us.

8 MR. MOORE: Thanks.

9 CHAIR REMPE: So at time then, not hearing
10 anyone else with an opening remark, I'd like to ask
11 Member Bier to lead us through our first topic. Well,
12 I think I'll ask Member Bier to start, and then she
13 will call on them. Okay. Thank you.

14 MEMBER BIER: All right. I'm Vicki Bier,
15 I'm Chair of the General Atomics Subcommittee for
16 ACRS. And we had an overview of these issues in May
17 of this year, last month. And I'm pleased to be
18 hearing from both the NRC staff and GA again here full
19 committee this week.

20 And Andrew Proffitt from Nuclear Reactor
21 Regulations will be giving the NRC's introductory
22 remarks.

23 MR. PROFFITT: Yeah, thank you, Member
24 Bier. This is Andrew Proffitt from the NRC staff,
25 acting chief of the Advanced Reactor Licensing Branch,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 and I'll give a brief overview of the presentation
2 today.

3 So we're currently engaged with General
4 Atomics Electromagnetic Systems in pre-application
5 activities related to an expected application for
6 their 50 megawatt electric fast modular reactor
7 design.

8 Currently we have two topical reports and
9 one white paper under review. The PDC topical report
10 we're here to talk about today, we're also reviewing
11 a Quality Assurance Program topical report and a fuel
12 qualification plan white paper.

13 We're expecting several more over the next
14 year related to white papers related to mechanistic
15 source term, licensing basis event selection, safety
16 approach and PRA, and safety classification.

17 So GA has undertaken these activities in
18 pursuit of a FMR demonstration by 2030 and deployment
19 in the mid-2030s. The staff's looking forward to
20 continued interactions with the committee on these
21 topics as we move forward on this application, and
22 other advanced reactor applications, and appreciate
23 the opportunity to be here. Thank you, Member Bier.

24 MEMBER BIER: Okay. Yes?

25 VICE CHAIR KIRCHNER: Andrew is it your

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 anticipation that these white papers will eventually
2 evolve into TRs to support their subsequent
3 application?

4 MR. PROFFITT: Many times they do, and
5 specifically on these topics. These are some of the
6 more complicated topics we deal with in pre-
7 application. And we certainly encourage them to turn
8 into topical reports. I mean, that's not a
9 requirement, but we do have, right now, a draft white
10 paper out on pre-application engagement that outlines
11 a lot of the topics we'd like to see in the topical
12 report space.

13 And we commit that if applicants or
14 potential applicants meet those, what we lay out in
15 that draft white paper, that we'll accelerate their
16 review when they do come into play.

17 VICE CHAIR KIRCHNER: Thank you.

18 MEMBER BIER: Any other questions or
19 comments at this stage?

20 Okay. If not, I am happy to turn this
21 over to John Bolin, a senior staff engineer at GA, who
22 will be giving the GA presentation virtually. So you
23 can go ahead whenever you're ready, John.

24 MR. BOLIN: Okay, thank you. So I'm going
25 to give everyone an overview of the Fast Modular

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Reactor Conceptual Design. We are midway through a
2 conceptual design effort, a cooperative agreement with
3 the Department of Energy.

4 Let's see, I'm trying to see how to
5 advance my slides. Okay. This slide covers some of
6 the major parameters of the fast modular reactor and
7 compares those with the gas turbine modular heating
8 reactor and the Westinghouse AP1000.

9 The main thing to note is the small
10 thermal output, 100 megawatts thermal. We have a
11 relatively small core power density, and in particular
12 we have a fuel rod linear power that is about eight
13 times lower than the AP1000. And we also have a
14 relatively flat axial and radial power distribution
15 that limits our hot channel power factor to 1.52.

16 The design, and we'll go over this in a
17 little more detail, the design uses a high density UO2
18 fuel in a silicon carbide composite cladding. And
19 we'll go over that in subsequent slides.

20 So like I mentioned, the fuel is one of
21 the key components, one of the first barriers to
22 fission product release. And the fuel leverages UO2
23 legacy development and also SiGA, sodium carbide
24 composite cladding development.

25 So we are using high density UO2 that's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 been proven in light water reactors and also tested in
2 fast reactors. The silicon carbide composite cladding
3 that we will be using in our fuel is undergoing
4 testing and maturation through the DOE Accident
5 Tolerant Fuel Program, and that includes current
6 testing that's going on in ATR.

7 The fuel design uses the ATF-LWR
8 dimensions, but unlike a light water reactor fuel rod,
9 we have a large plenum. Approximately one-third of
10 the fuel link is a plenum, similar to the legacy
11 liquid metal fast reactor fuel design. And so here we
12 see images of the fuel assembly, it's a hexagonal fuel
13 assembly, and then pictures of the silicon carbide
14 composite cladding.

15 We have manufactured test rodlets that
16 will be inserted in ATR. And I'll go over that in a
17 little more detail in the next slide. And we have an
18 X-ray image of the cladding tube. And then the endcap
19 is sealed at the end of the cladding tube.

20 This goes into a little more detail on the
21 fuel, since the fuel is a critical component and, like
22 I said, one of the first barriers to fission product
23 release. We are working with both Argonne and Idaho
24 in developing the fuel and in also testing the fuel.

25 We have manufactured both standard and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 compact rodlets. And compact rodlets have a higher
2 enrichment but a reduced size compared to the standard
3 rodlets. And so with the compact rodlets we can do
4 accelerated irradiation in ATR and get to a full burn
5 up.

6 ANL is working with us on a BISON model
7 and is analyzing both the standard reactor and also
8 the rodlets. And of course INL is assembling, will be
9 assembling our rodlets into a capsule that will be
10 inserted into ATR and go through between three to six
11 cycles of ATR radiation. And afterwards, we'll have
12 a post-radiation examination.

13 This image goes through some of the
14 procedures associated with fuel fabrication. And we
15 are using established ATF fabrication procedures. The
16 left side is pretty much standard UO₂, high density
17 UO₂ fabrication. And then on the right side is the
18 fabrication steps for sodium carbide composite
19 cladding, including the final joining and sealing of
20 the endcap.

21 Should I pause for questions, or should I
22 save questions to the end?

23 CHAIR REMPE: I think we'll continue to
24 interrupt you as we have in other times, but since you
25 have paused, I have a question.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Maybe it's not crossed your radar, but
2 your use of the DOE codes, is that going to -- have
3 you thought forward if, at some point when you have
4 this reactor and you're going to be trying to market
5 around the world, have you thought about will that
6 cause any complications with transmitting those codes
7 for the future owner operators of the plant to use it?
8 Or is that something that hasn't crossed your radar
9 yet?

10 MR. BOLIN: That has not crossed our radar
11 yet. In particular, I think you're referring to
12 BISON, of course?

13 CHAIR REMPE: Well, yeah. And we've had
14 other applicants come in and, at some point, some of
15 these codes are not going to be, you know, how will
16 one get them to something where you can transmit it
17 and sell it to the owners and operators? And, you
18 know, is it exportable? Those kinds of questions that
19 I assume it's too early to be thinking about that.

20 MR. BOLIN: We haven't thought about that.
21 And whether BISON would be part of that package, I
22 don't know.

23 Okay. So now I want to go through some of
24 the other major components of the design, particularly
25 components that are part of the defense in depth. So

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 the vessel system is part of, of course, the primary
2 coolant pressure boundary. And we have done
3 conceptual sizing for both normal operations and AOO
4 conditions.

5 We are basing it on the ASME Code, Section
6 III, Division 5. And the thickness is adequate for
7 operation up to 300,000 hours. And we plan on
8 extending that with the subsequent code revision to
9 540,000 hours, almost 60 years of effective full power
10 operation. And we'll be using COL at joints to
11 minimize heating leakage, because heating leakage is
12 an economic penalty for us.

13 One interesting thing to note is when we
14 do have accident conditions, or even reduced load
15 conditions, that actually reduces the pressure load on
16 the vessel system, so that's an added benefit. And so
17 far, we are complete on the conceptual design of the
18 reactor vessel internals.

19 This image also shows the general flow
20 path through the reactor. We do have a cross vessel
21 connecting the reactor vessel to the power conversion
22 unit. So hot helium exits through the top of the
23 core, through that cross vessel, returns through the
24 outer portion of that, and goes down to the bottom of
25 the core, and then flows up through the fuel

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 assemblies.

2 I should also note that we do have a
3 zirconium silicide reflector adjacent to the core that
4 minimizes, of course, neutron leakage, but it also
5 minimizes the reduction in neutron spectrum so that we
6 remain a fast spectrum reactor, and without much
7 thermalization of the neutrons that might physically
8 be found in other kinds of reflectors.

9 An important part of our design is the
10 power conversion system. And this power conversion
11 system is a direct Brayton cycle, inter-cooled. So we
12 see here in this image more on the flow path through
13 the reactor, but also through the power conversion
14 system.

15 Because it's inter-cooled, the hot helium
16 first goes to the turbine, then goes to a recuperator,
17 pre-cooler, a low pressure compressor, an inter-
18 cooler, and then a high pressure compressor, then back
19 through the recuperator, and then back to the reactor.

20 So we have a permanent magnet motor
21 generator that allows us to operate our reactor
22 asynchronously so we can vary the speed and flow rate
23 through the reactor and quickly adjust the power and
24 flow rate to match the grid demand. So that allows us
25 to be able to provide grid stability and load

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 following services to the grid.

2 We also are using a dry cooling tower as
3 our standard ultimate heat sink for our power
4 conversion system. And that, of course, reduces
5 impact on water resources and expands our citing
6 options.

7 And then the final barrier to fission
8 product release is the containment. And unlike
9 standard modular heating reactors, we actually have a
10 leak-tight containment vessel. It is below grade,
11 similar to all other modular heating reactors. So
12 below grade obviously makes us less vulnerable to
13 airplane crashes, and it's leak-tight so that we can
14 tolerate some fuel failure during extreme accidents
15 and still meet strict offsite dose limits.

16 We're still investigating whether we need
17 containment heat removal, containment fission product
18 cleanup, and venting post-accident. Those things are
19 probably maybe needed for expediting post-accident
20 recovery, but we are still looking to see whether
21 that's actually required to meet dose limits. So they
22 may not be safety related at all.

23 VICE CHAIR KIRCHNER: John, this is Walt
24 Kirchner.

25 MR. BOLIN: Yes.

1 VICE CHAIR KIRCHNER: Can you just give us
2 an idea of your containment design pressure?

3 MR. BOLIN: We are looking at a design
4 pressure of normally about 0.6 megapascals but with an
5 upper limit of 0.7 megapascals, or seven atmospheres.

6 So with the intention of being within
7 standard light water reactor containment design
8 capabilities, that was our purpose in setting those
9 pressures.

10 VICE CHAIR KIRCHNER: Yeah, thank you. So
11 your helium inventory is such that you don't get a
12 much higher pressure --

13 MR. BOLIN: Correct, correct.

14 VICE CHAIR KIRCHNER: -- for the major
15 rupture of the --

16 (Simultaneous speaking.)

17 MR. BOLIN: So with a depressurization
18 event, we will be within those design pressures,
19 correct.

20 So one of the key safety systems is, of
21 course, residual heat removal, safety functions. And
22 we are doing that by both active and passive. So was
23 there another question?

24 Okay. So we're doing that by both active
25 and passive systems. The main passive system is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 reactor vessel cooling systems, so that would be a
2 safety related system. But it has both safety related
3 and non-safety related components to it.

4 The RVCS water tanks provide a seven-day
5 supply of cooling, even if only one of them is
6 available, provide a seven-day supply. Those tanks
7 are kept cool by a forced circulation system and a
8 water tower, or water cooling tower.

9 The RVCS loop, there's two of them. So
10 there is a redundancy in those loops. They operate
11 passively by natural circulation, a buoyancy driven
12 flow to the water tank. There is also a maintenance
13 cooling system.

14 It's an active system that is primarily
15 there for maintenance cooling but is also available if
16 the power conversion system fails and is not able to
17 provide force convection cooling. But that
18 maintenance cooling system is a not safety related
19 system. So it has typically, I mean, it's sort of a
20 typical configuration of a helium to water heat
21 exchanger, and every circulator that circulates hot
22 helium through the heat exchanger and then back to the
23 core.

24 We also have arranged the core in an
25 annular configuration, and that promotes also passive

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 heat removal to the vessel and then from the vessel to
2 the reactor vessel cooling system panels.

3 MEMBER HALNON: John, can you point to
4 what would be safety related in this RVCS?

5 MR. BOLIN: Let's see?

6 MEMBER HALNON: Well, for example, the
7 water towers, are they safety or non-safety?

8 MR. BOLIN: The water towers would not be
9 safety related --

10 MEMBER HALNON: Yeah, because that's kind
11 of a keep cool system type of thing.

12 MR. BOLIN: That's to keep it cool. And
13 obviously it's electric powered. And also the pump
14 that pumps the water from the RVCS -- so in the RVCS
15 tank there is a heat exchanger, a water to water heat
16 exchanger that has a pump that pumps water through
17 that heat exchanger, and out to the towers, and back.
18 So all those electrical systems are not safety
19 related.

20 The tank is safety related, and obviously
21 the pipes feeding RVCS --

22 MEMBER HALNON: The tanks will have some
23 temperature limit on it based for pre-existing
24 conditions to keep it. And that's why you have the
25 keep cool system.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. BOLIN: Well, and the passive heat
2 removal relies on boil off of that water to remove
3 heat from the RVCS system.

4 MEMBER HALNON: Okay. So I think I get
5 it. Thanks.

6 VICE CHAIR KIRCHNER: Just a follow on to
7 Greg's question, on the recirculator, is there an
8 isolation valve or some --

9 (Simultaneous speaking.)

10 VICE CHAIR KIRCHNER: -- where do you draw
11 the line on the safety related part of the primary
12 coolant pressure boundary?

13 MR. BOLIN: The pressure boundary of the
14 maintenance cooling system would be safety related.
15 But the function of the maintenance cooling system,
16 the heat exchanger and the circulator themselves, are
17 not safety related. So there is no isolation valves
18 in the maintenance cooling system. There will be a
19 flow shutoff valve so that we don't have flow through
20 the maintenance cooling system during normal
21 operation. But otherwise, I think that answers your
22 question, doesn't it?

23 VICE CHAIR KIRCHNER: Yes, it does. Yeah,
24 I just was checking on the pressure boundary.

25 MR. BOLIN: Yes. So the maintenance

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 cooling system is located in the containment. And the
2 pressure boundary itself would be safety related.

3 And that concludes my presentation. I
4 just want to acknowledge that this, like I said, this
5 is supported by the U.S. Department of Energy under
6 their Advanced Reactor Concepts 2020 program.

7 CHAIR REMPE: John?

8 MR. BOLIN: Yes?

9 CHAIR REMPE: I know that the staff's
10 going to talk about what you've selected for your
11 principal design criteria. During the subcommittee
12 meeting, I mentioned about the critical safety
13 functions.

14 But again, as we go through a lot of these
15 new applications coming in, I think it's good for us
16 to understand how you came up with the principal
17 design criteria and if you started with looking at
18 what the critical safety functions were, and then kind
19 of linking them to the principal design criteria, to
20 make sure that you'd identified enough principal
21 design criteria.

22 And could you talk a little bit about the
23 process that you followed?

24 MR. BOLIN: So we did leverage our past
25 work on both GT-MHR and the energy multiplier module.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 We had looked at the energy multiplier module. It has
2 a lot of similarities to the FMR design.

3 And the critical safety functions there
4 are where we started. The functions of controlling
5 heat generation, removing heat, and preventing
6 chemical attack on the fuel. And so those are the
7 critical functions that we started with.

8 And in developing the principal design
9 criteria, and in developing the design itself, you
10 know, we made every effort to incorporate defense-in-
11 depth into our design. That's why, in particular, we
12 do have a leak-tight containment as our ultimate
13 barrier to fission product release.

14 CHAIR REMPE: Thank you, that helps.

15 MEMBER BIER: Any other questions or
16 comments for John before we hear from the staff on the
17 principal design criteria?

18 MEMBER PETTI: I just had one, John. Did
19 you map your criteria to the safety functions? I know
20 there's a lot of criteria. It would be interesting to
21 know how many of them are related to heat removal, how
22 many are related to controlled chemical attack --

23 MR. BOLIN: We did not explicitly map the
24 PDCs to the safety functions. I mean, that's an
25 exercise we could do, but we did not do that during

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 our development process.

2 MEMBER PETTI: Okay.

3 MEMBER BIER: Okay. With that then, I
4 think we are ready to hear from staff. And, Reed, you
5 will present the staff's NCR?

6 MR. ANZALONE: That's right. Let me get
7 a second to set up here.

8 MEMBER BIER: Oh, absolutely. Take your
9 time. Thank you.

10 MR. ANZALONE: One of my key lessons from
11 last time is that I need to get a lot closer to the
12 microphone.

13 MEMBER BIER: Yes, absolutely. And I
14 think we're still amazingly ahead of schedule, so
15 we're good.

16 MR. ANZALONE: Okay. So first of all, I
17 want to thank the committee for having me here today
18 and for your time on this important topic. My name is
19 Reed Anazalone. I'm a senior nuclear engineer in the
20 Office of Nuclear Reactor Regulation, Division of
21 Advanced Reactors and Non-Power Production and
22 Utilization Facilities, Advanced Reactor Technical
23 Branch 2.

24 My colleagues who helped on this report
25 were Sam Cuadrado, sitting on the side over there who

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 was the project manager, Sheila Ray, who handled the
2 electrical related PDCs, and Steve Jones who handled
3 the containment PDCs.

4 I wanted to kind of reflect after John's
5 presentation on how this was the very first thing that
6 General Atomics submitted to us after the regulatory
7 engagement plan. And so, you know, we think that this
8 was an appropriately early engagement on PDCs.

9 And we hope that the PDCs will really
10 drive the design in the direction that considers, you
11 know, safety as one of the critical aspects and really
12 will help to establish the design of the facility
13 going forward. So we think they got enough of the
14 design done to be able to establish what the PDCs
15 ought to be and go on from there.

16 I have to figure out how to advance the
17 slides.

18 So for my presentation today, I'll be
19 talking a little bit about the requirements and
20 guidance that exists for principal design criteria.
21 I'll briefly touch on the development approach that
22 General Atomics presented to us in the topical report.

23 And then I'll go into the fast modular
24 reactor design criteria themselves. And I'll talk a
25 little bit about what the design choices we perceived

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 General Atomics made and how those affected the
2 principal design criteria. And then I'll go through
3 a brief overview of the design criteria themselves.
4 Then I'll talk about the safety evaluation conclusions
5 briefly.

6 So the guidance for -- first of all, talk
7 about the requirements for PDCs, which isn't on this
8 slide. And I believe that General Atomics is pursuing
9 a Part 50 pathway for this initial license. And so
10 they have a requirement to submit principal design
11 criteria under 5034.

12 And then Appendix A establishes, in this
13 first excerpt, which I won't read, what the PDCs are
14 required to do, what the scope has to be. It has to
15 establish the design fabrication, construction
16 testing, and performance requirements for SSCs that
17 are important to safety.

18 And then it also, for non-light water
19 reactors, or reactors that are different from the
20 water-cooled nuclear power plants similar in design
21 and location to plants which construction permits have
22 been issued, provides guidance in establishing what
23 the PDCs ought to look like.

24 But the staff also issued more specific
25 guidance in developing principal design criteria for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 non-light water reactors. This was issued in April of
2 2018. I think this is one of the earlier applications
3 that we're actually seeing of this reg guide.

4 The reg guide documents three acceptable
5 sets of principal design criteria. There is a
6 generic, technology inclusive set of PDCs called the
7 Advance Reactor Design Criteria, or ARDCs, and it's
8 technology inclusive.

9 And I have a caveat there that it's
10 technology inclusive for the certain types of
11 technologies that it was designed to be inclusive for,
12 for sodium, lead, or gas-cooled fast reactors, modular
13 high temperature gas reactors, or high temperature gas
14 reactors -- there is a set of sodium fast reactors
15 that you see which was really based on the PRISM
16 design. And there's a set of modular high temperature
17 gas-cooled reactor design criteria which were based on
18 a TRISO fueled, helium cooled, graphite moderated by
19 a temperature gas reactor.

20 So the FMR design kind of fits between the
21 SFR and mHTGR designs that were considered here. And
22 as you'll see when I go through their design criteria,
23 they mostly picked the advanced reactor design
24 criteria, and then picked some mHTGR or SFR design
25 criteria as the basis for their PDCs.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 And I will highlight here that mixing and
2 matching was explicitly considered in the development
3 of this reg guide and endorsed by the reg guide. And
4 there is an explicit quote that I'll read. "The
5 applicants may use this reg guide to develop all or
6 part of the PDC and are free to choose among the ARDC
7 as an RDC, or mHTGR-DC, to develop each PDC after
8 considering the underlying safety basis for the
9 criterion and evaluating the rationale for the
10 adaptation described in the reg guide."

11 And so that's something that was
12 explicitly thought about as we were building this reg
13 guide in the first place.

14 So General Atomics' approach to PDC
15 development was generally to start with the advance
16 reactor design criterion, consider the underlying
17 safety basis. If the advance reactor design criterion
18 wasn't fully applicable, they would then assess the
19 more specific design criteria to see if they were
20 acceptable to be adopted directly.

21 If they weren't directly applicable, they
22 would find which one was most representative of the
23 FMR design, and then they would adapt or refine
24 whichever design criterion they went with as
25 necessary. And we thought this was an acceptable

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 approach.

2 And we were, while I did say on the last
3 slide that, you know, the design kind of sits in a
4 relatively comfortable space between the different
5 sets of criteria that already listed, we did try to be
6 mindful of whether additional criteria would be
7 appropriate. And generally speaking, I think we were
8 happy with where things were.

9 So now I'll spend a bunch more time on
10 this slide talking about the effects of certain key
11 design features on the principal design criteria. I
12 didn't want to go through a detailed design overview,
13 because John just did that for us.

14 So for the fuel they use, as John just
15 mentioned, the uranium dioxide pellets and silicon
16 carbide fuel pins, these are put into a triangular
17 pitch and arranged into the hexagonal bundles that is
18 typical of fast reactor design.

19 And this fuel design which, when you think
20 about that coupled with the use of a leak-tight
21 containment building, lends itself to the use of
22 specified acceptable fuel design limits in the
23 principal design criteria as currently exists for LWRs
24 in general, Design Criteria 10.

25 Rather than the specified acceptable

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 system radionuclide release design limits, I think I
2 got that right, that are, or SARDLs which I will say
3 from now on, because it's much easier to say, that are
4 in Reg Guide 1.232 for the modular high temperature
5 gas reactor design criteria.

6 And we felt that that was appropriate for
7 the fuel and core arrangement that they were
8 considering rather than, you know, TRISO fuel, HTGR.
9 And this affects the Criterion 10 and several other
10 design criteria that reference back to Criterion 10.

11 The fast modular reactor is a fast
12 reactor. So, as when you compared a thermal spectrum
13 reactor, the core is more tightly coupled and more
14 tightly coupled with the surrounding structure. So we
15 wanted to make sure that the effects of structures on
16 reactivity feedback would be considered. That's
17 reflected in Design Criterion 11 and 12.

18 They use the helium coolant which affects
19 quite a large number of principal design criteria.
20 And consistent with the modular high temperature gas
21 reactor design criteria, in the FMR design criteria
22 they moved the emphasis kind of more from inventory
23 control to ensuring that there's adequate residual
24 heat removal.

25 There's no PDC 35 which is the ECCS design

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 criterion. Also, throughout DC they've removed, uh,
2 the term reactor coolant pressure boundary and
3 replaced it with reactor helium pressure boundary.
4 And some of their design criteria in this area related
5 to the coolant adopt the modular high temperature gas
6 reactor design criterion directly, while others adapt
7 the advance reactor design criterion to fit the
8 design.

9 The power conversion system is a direct
10 Brayton cycle. They use the gas turbine that runs
11 directly on the primary coolant so the turbine itself
12 is therefore inside the reactor helium pressure
13 boundary. And the overall power conversion system
14 forms a portion of the reactor helium pressure
15 boundary.

16 And that has to be considered in the
17 environmental dynamic effects design basis. And
18 General Atomics did that appropriately. They adopted
19 a modular high temperature gas reactor, Design
20 Criterion 4, which included those considerations in
21 it.

22 The residual heat removal system, which
23 was one of the last things John talked about, lends
24 itself to using the MSGGR design criterion for
25 passive residual heat removal, though I will note

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 that there were a couple of tweaks there that I'll
2 get to once I actually go through the criteria
3 themselves.

4 And finally, the use of a leak-tight
5 containment implies the use of all the regular
6 containment principle design criteria. And for the
7 containment design criterion itself, DC-16, the sodium
8 fast reactor design criterion was used as the basis.
9 And I'll talk about that in a little bit.

10 All right. So now I'm going to walk
11 through the actual criteria themselves. So in this
12 first set of requirements, the one that really stands
13 out here is Criterion 4 which, as I just mentioned,
14 means that the effects -- that they used the modular
15 high temperature gas reactor design criteria which
16 explicitly considers the effects of turbine missiles
17 originating both inside and outside the reactor helium
18 pressure boundary, which is very important considering
19 the turbine is inside the reactor helium pressure
20 boundary and wouldn't necessarily be considered
21 otherwise.

22 In this block there's a bunch that I'm
23 going to touch on. Criterion 10 is where they
24 introduce the specified acceptable fuel design limits
25 rather than SARDLs which, as I mentioned earlier, is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 appropriate for their fuel system in containment
2 design.

3 It also replaces coolant in the design
4 criterion with heat removal which is consistent with
5 the modular high temperature gas reactor and other gas
6 cooled reactors which argue that helium inventory
7 control, specifically during a transient, isn't needed
8 to meet the SAFDLs provided that heat removal is
9 maintained.

10 Criterion 12 is based on the advanced
11 reactor design criterion rather than the modular high
12 temperature gas reactor design criterion because, as
13 I mentioned before, structures have to be captured in
14 the criterion due to the long mean free path of fast
15 neutrons.

16 Also in adopting this criterion they've
17 removed effects of coolant, because the coolant itself
18 has a negligible impact on reactivity feedback. And
19 that's consistent with the justification, and
20 rationale, and the language in the modular high
21 temperature gas reactor design criteria.

22 Criterion 16 is based on the sodium fast
23 reactor Design Criteria 16 which includes the use of
24 a low leakage pressure retaining containment concept.
25 And I know I mentioned earlier that, in general, the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 reg guide endorses mixing and matching of design
2 criteria. But this was explicitly discussed in the
3 containment design basis criteria where it said, you
4 know, we would expect that developers would use the
5 criterion that best fits their containment design.

6 VICE CHAIR KIRCHNER: Reed, in this
7 particular instance I would have thought they would
8 have fallen back on the PDCs. This is a higher
9 pressure containment.

10 And the sodium reactors are -- the
11 containment there is to deal with leakage and fires,
12 really, not pressure. Although you could have a
13 pressure event if you mixed the water with the sodium
14 because of a leak somewhere in the system and such.
15 But I would have expected they, as I said, might have
16 fallen back on the GDCs with regard to containment.

17 Also when you come to the later GDCs on
18 containment testing for leak-tight integrity, Appendix
19 J, etcetera.

20 MR. ANZALONE: Yeah. So thanks for
21 bringing that up. I think there's a bunch of
22 discussion in the reg guide about, you know, what is
23 appropriate. And there were a bunch of Commission
24 considerations, back starting in the '90s, about what
25 would be appropriate for advanced reactor designs.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 And I think the general consensus, if I
2 remember correctly, was that the prescription of a,
3 quote, unquote, "essentially leak-tight containment,"
4 which was what was in the GDC, was too stringent of a
5 requirement for advanced reactor designs as opposed to
6 the low leakage containment. And I thought that that
7 was generically applicable.

8 And then the last one on this slide, I'm
9 going to talk about is Criterion 17 which is the same
10 as the modular high temperature gas reactor design
11 criteria. And that's appropriate, but they've tweaked
12 that to refer to SAFDLs instead of SARDLs.

13 MEMBER HALNON: Why would that be reversed
14 from the previous. I thought the SARDLs was what they
15 should be using.

16 MR. ANZALONE: No, they're using SAFDL.

17 MEMBER HALNON: They're using SAFDL?

18 MR. ANZALONE: Yeah. So they made it
19 consistent throughout.

20 MEMBER HALNON: Okay. So SARDLs are more
21 for the -- I think what you said there is the
22 subcommittee was --

23 MR. ANZALONE: They're generally
24 associated with TRISO fuel and --

25 (Simultaneous speaking.)

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. ANZALONE: -- contained.

2 MEMBER HALNON: Okay. Thanks.

3 MR. ANZALONE: Any other questions?

4 Sorry, I moved on.

5 Okay. Here I'm just going to, and I
6 mentioned this during the subcommittee meeting, FMR-DC
7 26, we've had some challenges with PDC 26 with some
8 applicants, but here General Atomics adopted the
9 language in the AR-DC-26 as is, which we were pleased
10 about, with one minor exception that they explicitly
11 consider the effects of xenon as is originally
12 included in the GDC.

13 And while we thought that xenon effects
14 would likely be small for a fast reactor, during the
15 subcommittee meeting General Atomics mentioned that
16 they were indeed, they checked and found that they
17 were small or negligible. We felt like it was
18 conservative to include them. It doesn't hurt.

19 And then consistent with Reg Guide 1.232,
20 the requirements of, or the design criteria in GDC 27
21 were incorporated into PDC 26. And that was done by
22 General Atomics as well. So there is no Criterion 27.

23 And then for 28, even though the subject
24 is reactivity limits, the most significant differences
25 between the different sets of design criteria had to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 do with the coolant design. So General Atomics
2 adopted the mHTGR-DC which fits the best for them
3 there.

4 Fluid systems, and I kind of covered this
5 in my overview, consistent with the modular high
6 temperature gas reactor design criteria, there are no
7 Criteria 33 or 35. Consistent with, you know, that
8 removal of focus from inventory control to heat
9 removal, or the residual heat removal criterion in 34,
10 they adopted the modular high temperature gas reactor
11 design criteria which, again, we thought was
12 appropriate.

13 But they tweaked the title of it, and one
14 or two of the words, to reflect that there are, rather
15 than just a passive residual heat removal system,
16 which was what was written into the Reg Guide 1.232
17 criterion, they wanted to encompass both the passive
18 and active residual heat removal mechanisms that they
19 had. And we felt like that was appropriate to include
20 all of them within the scope. And that's reflected in
21 37 as well.

22 Next slide. These are all related to
23 containment, and they just adopted the advanced
24 reactor design criteria which we thought was
25 appropriate.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 More related to containment, so for 54,
2 the sodium fast reactor design criterion was chosen,
3 because it replaces the phrase, having redundancy,
4 reliability, and performance capabilities that reflect
5 the importance to safety of isolating these piping
6 systems in advanced reactor design Criterion 54 with
7 -- that have redundancy, reliability, and performance
8 capabilities necessary to perform the containment
9 safety function and that reflect the importance to
10 safety of preventing radioactivity releases from
11 containment through these piping systems.

12 So the intent of this change as described
13 in the topical report is to accommodate designs that
14 are capable of demonstrating that containment
15 isolation valves aren't necessary for certain piping
16 penetrations that don't have a credible release path
17 to the atmosphere.

18 In the FMR design this includes the RVCS
19 and intermediate power conversion system heat removal
20 loops which could be designed to achieve the
21 containment function without isolation valves. But if
22 isolation valves, it turns out, are necessary, the
23 design criterion still requires them to be included.

24 The other change here, which I have
25 mentioned on the slide, is that FMR-DC 54 refers to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 containment rather than "reactor containment," quote,
2 unquote, to reflect the presence of major SSCs
3 containing radioactivity inside containment. So in
4 this case, that's the power conversion system. And no
5 comments on the ones related to fuel and reactivity
6 control. They're all what you would expect to see.

7 So finally, the conclusions from our
8 safety evaluation, we determined that General Atomics
9 appropriately considered the reg guide and developed
10 a sufficient set of principle design criteria that
11 were appropriate for establishing requirements for the
12 FMR design.

13 The PDCs themselves do meet that
14 requirement of 10 CFR 50, Appendix A, to establish the
15 necessary design fabrication, construction testing,
16 and performance design criteria for safety-significant
17 SSCs.

18 And as I mentioned, you know, there were
19 a couple instances in which they expanded to ensure
20 that all the safety significant, rather than just
21 safety related, SSCs would be captured, and that the
22 topical report could be used by future fast modular
23 reactor applicants. But if the reactor design differs
24 from that discussed in the topical report, use of the
25 PDCs must be justified.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 And that's just sort of part of the nature
2 of how topical reports work in licensing space. You
3 need to be able to say that the topical report is
4 applicable. And that's the end of my presentation.

5 MEMBER BIER: Okay. Thank you. First of
6 all, I appreciate that you kind of hit the high points
7 and focused on the areas where there was something
8 important or unique in the PDC and made it very
9 efficient that way.

10 At this point, are there questions or
11 comments for Reed?

12 MEMBER HALNON: Did you have any RAIs
13 outside of the, you know, just minor questions?

14 MR. ANZALONE: So there were a couple of
15 RAIs. I think most were related to, like, what I
16 would consider to be errors in the PDCs, you know,
17 grammatical errors --

18 MEMBER HALNON: Okay.

19 MR. ANZALONE: -- things like that. But
20 there was at least one. So we asked about the
21 inclusion of structures in PDC 12. So originally that
22 wasn't in there. We felt like it was important to
23 make sure that that was included so that the effect of
24 structures on reactivity feedback would be considered.
25 And they did duly add that back in.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MEMBER HALNON: Okay. Thanks.

2 MEMBER PETTI: So, Reed, how did you show
3 completeness of the set, given this is, you know, a
4 technology -- is between the couple technologies that
5 have been looked at a lot. So that's always the
6 question in the back of my mind, you know, is there
7 something that's been missed?

8 MR. ANZALONE: Yeah, that's a good
9 question. And it is, it's difficult to answer.
10 Because I think it's something that we had in the back
11 of our minds as trying to make sure that it was
12 complete.

13 I think I will say that we did probably
14 rely mostly on the fact that the criteria in the reg
15 guide kind of encompassed, and I mentioned this at the
16 subcommittee meeting, encompassed the scope of what we
17 would expect to be considered for the design, you
18 know.

19 So we're interpolating between designs
20 effectively, right, between the sodium fast reactor
21 and modular high temperature gas reactor designs. So
22 I would say that's probably the true answer to the
23 question. But there was some interrogation, you know,
24 internally. Okay, have we captured everything? And
25 I think that we did.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 I will say if we are early enough in the
2 design phase that if it turns out there is something
3 that we somehow didn't include, it should come out
4 later.

5 MEMBER PETTI: It's the same question I
6 asked. So General Atomics, I mean, if you map it to
7 the safety functions, and you think you've got all the
8 safety functions which, I think, the LMP approach
9 covers most of -- all the safety functions you would
10 think of at a high level. It's sort of another way to
11 check, but it's a cross check.

12 MR. ANZALONE: Yeah. Another project that
13 I'm working on is using LMP, and it is very focused on
14 identifying and then appropriately ensuring that
15 you're considering those safety functions. So I agree
16 that that would certainly capture anything that might
17 have been missed.

18 Though, I mean, really the safety
19 functions for this are not too different from what you
20 would expect to see, again, from either the modular
21 high temperature gas reactor or the sodium cooled fast
22 reactor. So I don't see -- and I think, again, this
23 was something that I said at the subcommittee meeting,
24 you know, it's not really exotic. So I don't see that
25 there's some area, obviously at least, that we would

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 have missed.

2 MEMBER BIER: Yeah.

3 MR. ANZALONE: Of course, if it was
4 obvious, then we would have considered it.

5 (Laughter.)

6 MEMBER BIER: Just following up on Dave's
7 point, I don't think, you know, I'm not aware of a
8 specific concern here. But in principle with this
9 kind of mix and match thing, you can have interaction
10 effects where a feature from one design doesn't marry
11 happily with some --

12 MR. ANZALONE: Yeah. And certainly that's
13 something we were very focused on during the review,
14 is that if they were mixing and matching, was it
15 appropriate to do so, and did they make sure with
16 their mixing and matching that they were consistent.
17 And that I can say very confidently, yes, we did make
18 sure that that wasn't an issue.

19 CHAIR REMPE: Oh, I'm kind of going from
20 Part 53 discussions, and it's not focused on this
21 application. But I thought with Framework B there was
22 discussion that well, yeah, it might be easier if one
23 used the LMP approach. But we're going -- if people
24 want to do a bottoms up approach, we'll let them, but
25 we'll group things.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Now, sounds like General Atomics sort of
2 did start with the critical safety functions, as we
3 asked them earlier today. But are you guys grouping
4 them like we've heard that might occur? I mean, this
5 was done -- we don't have Part 53 in place yet, but is
6 that kind of what staff's going to be doing as the try
7 and deal with a lot of these more different designs
8 that may come in?

9 MR. ANZALONE: I don't know that I have a
10 great answer to that question, because I haven't
11 started thinking about it in terms of people who
12 aren't pursuing an LMP type framework. Because
13 General Atomics is planning to use LMP. The other
14 reactor designs that I'm working with are using LMP.
15 So I don't know that I personally have an answer --

16 CHAIR REMPE: I just was --

17 MR. ANZALONE: -- to that question.

18 CHAIR REMPE: Yeah.

19 VICE CHAIR KIRCHNER: My fall back answer
20 on your behalf would be that the GDCs are organized
21 according to safety functions, right?

22 MR. ANZALONE: Yeah. Yeah, they are.

23 VICE CHAIR KIRCHNER: It's not explicit as
24 LMP approach, but the categories that they're binned
25 in makes sense from a safety function standpoint.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. ANZALONE: Right. And when John was
2 asked that question, what came in my head was, well,
3 they kind of tell you what the safety function they're
4 related to is in the title or at least the heading of
5 the sections.

6 So that's part of the answer. But don't
7 feel like that's the whole answer to your question.

8 CHAIR REMPE: Too early to really have an
9 answer. I'm just --

10 MR. ANZALONE: Yeah.

11 CHAIR REMPE: -- thinking ahead on how
12 we're going to deal with it.

13 MR. ANZALONE: It's a good question though
14 for framework lead.

15 CHAIR REMPE: And we had time in the schedule to
16 explore it, so thank you.

17 MEMBER PETTI: I think though it is worth
18 a letter at least touching on this, that the staff was
19 very focused on the mix and match and making sure that
20 something wasn't missed. Because we're going to see
21 more mix and match, I'm sure.

22 MEMBER BIER: I noticed you mentioned no
23 individual feature was that exotic. It's more the mix
24 and match that could create issues.

25 Additional questions or comments for Reed?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MEMBER DIMITRIJEVIC: I just want to point
2 out that in the reg guide actually the both sodium
3 and, you know, module that have extended GDCs, you
4 know, to additional ones in the '70s. Here, I mean,
5 it seems like they're just, you know, keeping it
6 simple to the basics.

7 MR. ANZALONE: Yeah. And I can comment on
8 that a little bit. So the extended ones for the
9 modular high temperature gas reactor relate to sort of
10 the characteristics of the reactor building that need
11 to be there when you use a functional containment.
12 And the ones for the sodium fast reactor relate
13 specifically to sodium and what nasty things that can
14 do when it interacts with the atmosphere.

15 So neither of those are really
16 considerations here since they're not using a
17 functional containment approach, and they don't have
18 sodium coolant.

19 MEMBER DIMITRIJEVIC: Well, that's very
20 true. I just want to say maybe, you know, when they
21 really go to the detailed design they will find some
22 features not covered. I mean, we cannot really
23 guarantee completeness about they have, you know, they
24 have not made the radical changes and they have not
25 extended. It's sort of basic application.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MEMBER BIER: Are there questions or
2 comments?

3 Yes? Yes?

4 So if there are no questions in the room
5 or from the members online, then I think it's time
6 for any public comments on the GA principal design.

7 And I guess it's Star 6 to unmute yourself
8 if you're on the phone.

9 And hearing none, I think we can close
10 public comments.

11 CHAIR REMPE: Great. So at this time
12 we're going to go off the record. And this is it for
13 the court reporter for this meeting, okay.

14 (Whereupon, the above-entitled matter went
15 off the record at 2:07 p.m.)

16

17

18

19

20

21

22

23

24

25

General Atomics – Electromagnetic Systems Fast Modular Reactor Principal Design Criteria

Reed Anzalone, NRR/DANU

Samuel Cuadrado de Jesus, NRR/DANU

Sheila Ray, NRR/DEX

Steve Jones, NRR/DANU

Agenda

- PDC guidance
 - General Design Criteria (GDC)
 - Regulatory Guide (RG) 1.232
- GA-EMS PDC development approach
- Fast modular reactor design criteria (FMR-DC)
 - Impacts of key design choices on PDCs
 - FMR-DC overview
- Safety evaluation (SE) conclusions

PDC Guidance – 10 CFR 50 Appendix A GDC

“The principal design criteria establish the necessary design, fabrication, construction, testing, and performance requirements for structures, systems, and components important to safety; that is, structures, systems, and components that provide reasonable assurance that the facility can be operated without undue risk to the health and safety of the public.”

“These General Design Criteria establish minimum requirements for the principal design criteria for water-cooled nuclear power plants similar in design and location to plants for which construction permits have been issued by the Commission. **The General Design Criteria are also considered to be generally applicable to other types of nuclear power units and are intended to provide guidance in establishing the principal design criteria for such other units.**”

PDC Guidance – RG 1.232, “Guidance for Developing Principal Design Criteria for Non-Light-Water Reactors”

- Issued April 2018 (ACRS letter March 2018)
- Documents three sets of acceptable PDCs:
 - Advanced reactor DC (ARDC) – generic, technology inclusive*
 - Sodium-cooled fast reactor DC (SFR-DC) – sodium-cooled fast reactors (e.g., PRISM)
 - Modular high temperature gas-cooled reactor DC (MHTGR-DC) – TRISO-fueled, helium-cooled, graphite-moderated HTGR

* For sodium/lead/gas-cooled fast reactors, modular high temperature gas reactors, fluoride high-temperature reactors, and molten salt reactors

GA-EMS Approach to PDC Development

- Start with ARDC, considering underlying safety basis
- If ARDC not fully applicable, assess SFR-DC and MHTGR-DC for direct adoption
- If SFR-DC or MHTGR-DC not directly applicable, apply DC that is most representative of FMR
- Adapt or refine selected DC

Key Design Feature Effects on PDCs

Feature	Design	Effect on PDCs
Fuel	UO ₂ pellets in silicon carbide fuel pins	Use of specified acceptable fuel design limits (SAFDLs) instead of specified acceptable system radionuclide release design limits (SARRDLs)
Core arrangement	Pins in triangular pitch arranged into hexagonal bundles	
Neutron spectrum	Fast	Consider effect of structures on reactivity feedback
Coolant	Helium	Removal of coolant inventory control considerations consistent with MHTGR; use of reactor helium pressure boundary in lieu of reactor coolant pressure boundary
Power conversion system	Gas turbine on primary coolant	Consider in environmental and dynamic effects design basis
Residual heat removal	Reactor vessel cooling system (water-fed, gravity-driven passive system)	Adoption of MHTGR passive residual heat removal PDCs
Containment	Leak-tight containment building	Adoption of containment PDCs

FMR-DC – I. Overall Requirements

Criterion	Title	Basis PDC	Modified?
1	Quality standards and records.	ARDC	N
2	Design bases for protection against natural phenomena.	ARDC	N
3	Fire protection.	ARDC	N
4	Environmental and dynamic effects design bases.	MHTGR-DC	N
5	Sharing of structures, systems, and components	ARDC	N

FMR-DC – II. Multiple Barriers

Criterion	Title	Basis PDC	Modified?
10	Reactor design.	ARDC	Y - uses "heat removal" instead of "coolant"
11	Reactor inherent protection.	ARDC	N
12	Suppression of reactor power oscillations.	ARDC	Y - removes "coolant"
13	Instrumentation and control.	ARDC	Y - uses "helium pressure boundary" instead of "reactor coolant boundary"
14	Reactor helium pressure boundary.	MHTGR-DC	N
15	Reactor helium pressure boundary design.	MHTGR-DC	N
16	Containment design.	SFR-DC	N
17	Electric power systems.	MHTGR-DC	Y - uses SAFDLs instead of SARRDLs
18	Inspection and testing of electric power systems.	ARDC	N
19	Control room.	MHTGR-DC	N

FMR-DC – III. Reactivity Control

Criterion	Title	Basis PDC	Modified?
20	Protection system functions	ARDC	N
21	Protection system testability and reliability.	ARDC	N
22	Protection system independence.	ARDC	N
23	Protection system failure modes.	ARDC	N
24	Separation of protection and control systems.	ARDC	N
25	Protection system requirements for reactivity control malfunctions.	ARDC	N
26	Reactivity control systems.	ARDC	Y - includes effects of xenon
27	[None - incorporated into 26 consistent with RG 1.232]	N/A	N/A
28	Reactivity limits.	MHTGR-DC	N
29	Protection against anticipated operational occurrences.	ARDC	N

FMR-DC – IV. Fluid Systems (1)

Criterion	Title	Basis PDC	Modified?
30	Quality of reactor helium pressure boundary.	MHTGR-DC	N
31	Fracture prevention of reactor helium pressure boundary.	MHTGR-DC	N
32	Inspection of reactor helium pressure boundary	MHTGR-DC	N
33	[None - not applicable consistent with MHTGR-DC]	N/A	N/A
34	Residual heat removal.	MHTGR-DC	Y - includes both passive and active systems
35	[None - not applicable consistent with MHTGR-DC]	N/A	N/A
36	Inspection of passive residual heat removal system.	MHTGR-DC	N
37	Testing of residual heat removal system.	MHTGR-DC	Y - includes both passive and active systems
38	Containment heat removal.	ARDC	N
39	Inspection of containment heat removal system.	ARDC	N

FMR-DC – IV. Fluid Systems (2)

Criterion	Title	Basis PDC	Modified?
40	Testing of containment heat removal system.	ARDC	N
41	Containment atmosphere cleanup.	ARDC	N
42	Inspection of containment atmosphere cleanup systems.	ARDC	N
43	Testing of containment atmosphere cleanup systems.	ARDC	N
44	Structural and equipment cooling.	ARDC	N
45	Inspection of structural and equipment cooling systems.	ARDC	N
46	Testing of structural and equipment cooling systems.	ARDC	N

FMR-DC – V. Reactor Containment

Criterion	Title	Basis PDC	Modified?
50	Containment design basis.	ARDC	N
51	Fracture prevention of containment pressure boundary.	ARDC	N
52	Capability for containment leakage rate testing.	ARDC	N
53	Provisions for containment testing and inspection.	ARDC	N
54	Piping systems penetrating containment.	SFR-DC	Y - removes "reactor"
55	Reactor helium pressure boundary penetrating containment.	ARDC	Y - uses "helium pressure boundary" instead of "reactor coolant boundary"
56	Containment isolation.	ARDC	N
57	Closed system isolation valves.	ARDC	Y - uses "helium pressure boundary" instead of "reactor coolant boundary"

FMR-DC – VI. Fuel and Reactivity Control

Criterion	Title	Basis PDC	Modified?
60	Control of releases of radioactive materials to the environment.	ARDC	N
61	Fuel storage and handling and radioactivity control.	ARDC	N
62	Prevention of criticality in fuel storage and handling.	ARDC	N
63	Monitoring fuel and waste storage.	ARDC	N
64	Monitoring radioactivity releases.	ARDC	N

Safety Evaluation Conclusions

- GA-EMS appropriately considered RG 1.232 and developed a sufficient set of PDCs appropriate for establishing requirements for the FMR design.
- PDCs establish the necessary design, fabrication, construction, testing, and performance design criteria for safety-significant SSCs to provide reasonable assurance that an FMR could be operated without undue risk to the health and safety of the public. (10 CFR 50 App A)
- This TR can be used by future FMR applicants, but if the reactor design differs from that discussed in the TR use of the PDCs in the TR must be justified.

GA-EMS FMR Design Features





Figure 2. FMR Primary Coolant Flow and Power Generation

Source: REP, ML22087A510

GA-EMS FMR Design Features



Source: TR, ML22154A556

FMR-DC Summary

- Directly adopted from RG 1.232
 - From ARDC: FMR-DC 1, 2, 3, 5, 11, 18, 20, 21, 22, 23, 24, 25, 29, 38, 39, 40, 41, 42, 43, 44, 45, 46, 50, 51, 52, 53, 60, 61, 62, 63, 64
 - From SFR-DC: FMR-DC 16
 - From MHTGR-DC: FMR-DC 4, 14, 15, 19, 28, 30, 31, 32, 36
- Modified from RG 1.232
 - FMR-DC 10 (ARDC 10), 12 (ARDC 12), 13 (ARDC 13), 17 (MHTGR-DC 17), 26 (ARDC 26), 34 (MHTGR-DC 34), 37 (MHTGR-DC 37), 54 (SFR-DC 54), 55 (ARDC 55), 57 (ARDC 57)

FMR-DC Modified from RG 1.232

ARDC 10	FMR-DC 10
<p data-bbox="193 446 486 489"><i>Reactor design.</i></p> <p data-bbox="193 562 1001 1001">The reactor core and associated coolant, control, and protection systems shall be designed with appropriate margin to assure that specified acceptable fuel design limits are not exceeded during any condition of normal operation, including the effects of anticipated operational occurrences.</p>	<p data-bbox="1034 446 1319 489"><i>Reactor design.</i></p> <p data-bbox="1034 562 1857 1001">The reactor core and associated coolant heat removal, control, and protection systems shall be designed with appropriate margin to assure that specified acceptable fuel design limits are not exceeded during any condition of normal operation, including the effects of anticipated operational occurrences.</p>

Basis: Helium inventory control is not necessary to meet SAFDLs due to reactor system design; consistent with MHTGR-DC (which use SARRDLs instead) and other FMR-DC

FMR-DC Modified from RG 1.232

ARDC 12	FMR-DC 12
<p data-bbox="173 439 980 485"><i>Suppression of reactor power oscillations.</i></p> <p data-bbox="173 554 945 996">The reactor core; associated structures; and associated coolant, control, and protection systems shall be designed to ensure that power oscillations that can result in conditions exceeding specified acceptable fuel design limits are not possible or can be reliably and readily detected and suppressed.</p>	<p data-bbox="1021 439 1829 485"><i>Suppression of reactor power oscillations.</i></p> <p data-bbox="1021 554 1819 996">The reactor core;, associated structures;, and associated coolant, control, and protection systems shall be designed to ensure that power oscillations that can result in conditions exceeding specified acceptable fuel design limits are not possible or can be reliably and readily detected and suppressed.</p>

Basis: Helium coolant does not have a significant effect on reactivity for the FMR

FMR-DC Modified from RG 1.232

ARDC 13	FMR-DC 13
<p><i>Instrumentation and control.</i></p> <p>Instrumentation shall be provided to monitor variables and systems over their anticipated ranges for normal operation, for anticipated operational occurrences, and for accident conditions, as appropriate to ensure adequate safety, including those variables and systems that can affect the fission process, the integrity of the reactor core, the reactor coolant boundary, and the containment and its associated systems. Appropriate controls shall be provided to maintain these variables and systems within prescribed operating ranges.</p>	<p><i>Instrumentation and control.</i></p> <p>Instrumentation shall be provided to monitor variables and systems over their anticipated ranges for normal operation, for anticipated operational occurrences, and for accident conditions, as appropriate, to ensure adequate safety, including those variables and systems that can affect the fission process, and the integrity of the reactor core, the reactor coolant helium pressure boundary, and the containment and its associated systems. Appropriate controls shall be provided to maintain these variables and systems within prescribed operating ranges.</p>

Basis: More appropriate to say “reactor helium pressure boundary” than “reactor coolant boundary” for FMR, consistent with MHTGR-DC and other FMR-DC

FMR-DC Modified from RG 1.232

ARDC 26	FMR-DC 26
<p><i>Reactivity control systems.</i></p> <p>A minimum of two reactivity control systems or means shall provide:</p> <p>(1) A means of inserting negative reactivity at a sufficient rate and amount to assure, with appropriate margin for malfunctions, that the design limits for the fission product barriers are not exceeded and safe shutdown is achieved and maintained during normal operation, including anticipated operational occurrences.</p> <p>(2) A means which is independent and diverse from the other(s), shall be capable of controlling the rate of reactivity changes resulting from planned, normal power changes to assure that the design limits for the fission product barriers are not exceeded.</p> <p>(3) A means of inserting negative reactivity at a sufficient rate and amount to assure, with appropriate margin for malfunctions, that the capability to cool the core is maintained and a means of shutting down the reactor and maintaining, at a minimum, a safe shutdown condition following a postulated accident.</p> <p>(4) A means for holding the reactor shutdown under conditions which allow for interventions such as fuel loading, inspection and repair shall be provided.</p>	<p><i>Reactivity control systems.</i></p> <p>A minimum of two reactivity control systems or means shall provide:</p> <p>(1) A means of inserting negative reactivity at a sufficient rate and amount to assure, with appropriate margin for malfunctions, that the design limits for the fission product barriers are not exceeded and safe shutdown is achieved and maintained during normal operation, including anticipated operational occurrences.</p> <p>(2) A means which is independent and diverse from the other(s), shall be capable of controlling the rate of reactivity changes resulting from planned, normal power changes (including xenon burnout) to assure that the design limits for the fission product barriers are not exceeded.</p> <p>(3) A means of inserting negative reactivity at a sufficient rate and amount to assure, with appropriate margin for malfunctions, that the capability to cool the core is maintained and a means of shutting down the reactor and maintaining, at a minimum, a safe shutdown condition following a postulated accident.</p> <p>(4) A means for holding the reactor shutdown under conditions which allow for interventions such as fuel loading, inspection and repair shall be provided.</p>

Basis: GDC 26 includes explicit consideration of Xe burnout; while Xe is not expected to be a significant reactivity contributor in the FMR it is not incorrect to explicitly include it

FMR-DC Modified from RG 1.232

MHTGR-DC 34	FMR-DC 34
<p>Passive residual heat removal.</p> <p>A passive system to remove residual heat shall be provided. For normal operations and anticipated operational occurrences, the system safety function shall be to transfer fission product decay heat and other residual heat from the reactor core to an ultimate heat sink at a rate such that specified acceptable system radionuclide release design limits and the design conditions of the reactor helium pressure boundary are not exceeded.</p> <p>During postulated accidents, the system safety function shall provide effective cooling.</p> <p>Suitable redundancy in components and features and suitable interconnections, leak detection, and isolation capabilities shall be provided to ensure the system safety function can be accomplished, assuming a single failure.</p>	<p>Passive Residual heat removal.</p> <p>A passive System(s) to remove residual heat shall be provided. For normal operations and anticipated operational occurrences, the system safety function shall be to transfer fission product decay heat and other residual heat from the reactor core to an ultimate heat sink at a rate such that specified acceptable system radionuclide release fuel design limits and the design conditions of the reactor helium pressure boundary are not exceeded.</p> <p>During postulated accidents, the system safety function shall provide effective core cooling.</p> <p>Suitable redundancy in components and features and suitable interconnections, leak detection, and isolation capabilities shall be provided to ensure the system safety function can be accomplished, assuming a single failure.</p>

Basis: The MHTGR included a passive residual heat removal (RHR) system because of the low core power density. FMR has multiple RHR systems including active non-safety-related systems and passive safety-related systems, and the DC should be broad enough to apply to all of them.

FMR-DC Modified from RG 1.232

MHTGR-DC 37	FMR-DC 37
<p><i>Testing of passive residual heat removal system.</i></p> <p>The passive residual heat removal system shall be designed to permit appropriate periodic functional testing to ensure (1) the structural and leaktight integrity of its components, (2) the operability and performance of the system components, and (3) the operability of the system as a whole and, under conditions as close to design as practical, the performance of the full operational sequence that brings the system into operation, including associated systems, for AOO or postulated accident decay heat removal to the ultimate heat sink and, if applicable, any system(s) necessary to transition from active normal operation to passive mode.</p>	<p><i>Testing of passive-residual heat removal system.</i></p> <p>The passive-residual heat removal system(s) shall be designed to permit appropriate periodic functional testing to ensure (1) the structural and leak-tight integrity of its components, (2) the operability and performance of the system components, and (3) the operability of the system as a whole and, under conditions as close to design as practical, the performance of the full operational sequence that brings the system into operation, including associated systems, for AOO or postulated accident decay heat removal to the ultimate heat sink and, if applicable, any system(s) necessary to transition from active normal operation to passive mode.</p>

Basis: The MHTGR included a passive residual heat removal (RHR) system because of the low core power density. FMR has multiple RHR systems including active non-safety-related systems and passive safety-related systems, and the DC should be broad enough to apply to all of them (same as FMR-DC 34).

FMR-DC Modified from RG 1.232

SFR-DC 54	FMR-DC 54
<p><i>Piping systems penetrating containment.</i></p> <p>Piping systems penetrating the reactor containment structure shall be provided with leak detection, isolation, and containment capabilities that have redundancy, reliability, and performance capabilities necessary to perform the containment safety function and that reflect the importance to safety of preventing radioactivity releases from containment through these piping systems. Such piping systems shall be designed with the capability to verify, by testing, the operational readiness of any isolation valves and associated apparatus periodically and to confirm that valve leakage is within acceptable limits.</p>	<p><i>Piping systems penetrating containment.</i></p> <p>Piping systems penetrating the reactor containment structure shall be provided with leak detection, isolation, and containment capabilities that have redundancy, reliability, and performance capabilities necessary to perform the containment safety function and that reflect the importance to safety of preventing radioactivity releases from containment through these piping systems. Such piping systems shall be designed with the capability to verify, by testing, the operational readiness of any isolation valves and associated apparatus periodically and to confirm that valve leakage is within acceptable limits.</p>

Basis: There are other major SSCs other than just the reactor within containment (e.g., the power conversion system) so it is appropriate to remove the word “reactor”

FMR-DC Modified from RG 1.232

ARDC 55	FMR-DC 55
<p><i>Reactor coolant boundary penetrating containment.</i></p> <p>Each line that is part of the reactor coolant boundary and that penetrates the containment structure shall be provided with containment isolation valves, as follows, unless it can be demonstrated that the containment isolation provisions for a specific class of lines, such as instrument lines, are acceptable on some other defined basis:</p> <p>...</p>	<p><i>Reactor coolanthelium pressure boundary penetrating containment.</i></p> <p>Each line that is part of the reactor coolanthelium pressure boundary and that penetrates the reactor containment structure shall be provided with containment isolation valves as follows, unless it can be demonstrated that the containment isolation provisions for a specific class of lines, such as instrument lines, are acceptable on some other defined basis:</p> <p>...</p>

Basis: More appropriate to say “reactor helium pressure boundary” than “reactor coolant boundary” for FMR, consistent with MHTGR-DC and other FMR-DC

FMR-DC Modified from RG 1.232

ARDC 57	FMR-DC 57
<p><i>Closed system isolation valves.</i></p> <p>Each line that penetrates the containment structure and is neither part of the reactor coolant boundary nor connected directly to the containment atmosphere shall have at least one containment isolation valve, unless it can be demonstrated that the containment safety function can be met without an isolation valve and assuming failure of a single active component. The isolation valve, if required, shall be either automatic, or locked closed, or capable of remote manual operation. This valve shall be outside containment and located as close to the containment as practical. A simple check valve may not be used as the automatic isolation valve.</p>	<p><i>Closed system isolation valves.</i></p> <p>Each line that penetrates the containment structure and is neither part of the reactor coolant helium pressure boundary nor connected directly to the containment atmosphere shall have at least one containment isolation valve unless it can be demonstrated that the containment safety function can be met without an isolation valve and assuming failure of a single active component. The isolation valve, if required, shall be either automatic, or locked closed, or capable of remote manual operation. This valve shall be outside containment and located as close to the containment as practical. A simple check valve may not be used as the automatic isolation valve.</p>

Basis: More appropriate to say “reactor helium pressure boundary” than “reactor coolant boundary” for FMR, consistent with MHTGR-DC and other FMR-DC




General Atomics Electromagnetic Systems

Fast Modular Reactor Conceptual Design

June 7, 2023

Presented To: Advisory Committee on Reactor Safeguards

Prepared By: John Bolin (GA-EMS)






FMR Core Designed to Improve Safety Margin

	FMR	GT-MHR	AP1000
Reactor core heat output, MWt	100	600	3400
Reactor core power density, MW/m ³	14.97	6.6	109.7
Heat generated in fuel, %	-	-	97.4
Nominal system pressure, MPa	7	7.07	15.5
Coolant total flow rate, kg/s	66	320	14,301
Coolant nominal inlet temperature, °C	509	491	279.4
Coolant temperature rise in core, °C	291	359	27.4
Fuel rod average linear power, kW/m	2.34	0.39^{a)}	18.8
Heat flux hot channel factor, F _Q	1.52	-	2.6
Fuel assembly geometry	Hexagonal	Hexagonal ^{b)}	Square ^{c)}
Number of fuel assemblies	198	102 ^{d)}	157
Fuel rods per assembly	120	210 ^{a)}	264
Fuel material	UO ₂	UC _{0.5} O _{1.5}	UO ₂
Cladding material	SiGA	SiC ^{e)}	ZIRLO
Core active height (cm)	180	793	426.72


a) Stack of fuel compacts, b) Solid block with coolant channels inside, c) 17×17, d) Fuel blocks, e) TRISO fuel particle coating

Fuel Leverages UO₂ Legacy and SiGA™ Cladding Development

- High density UO₂ proven in LWRs and tested in fast reactors
- Silicon carbide composite cladding (SiGA) undergoing testing and maturation through DOE Accident Tolerant Fuel (ATF) program
- Fuel design uses ATF-LWR dimensions with large plenum like legacy liquid metal fast reactors




Cladding tube




Endcap welding

Numerical and Experimental Verification of Fuel Design




ATR Irradiation Capsule



TREAT
Transient
Capsule


FMR Test Rodlets Fabricated Using ATF Established Procedures

Fuel Rod Fabrication Process




Vessel System Designed to Minimize Helium Leakage

- **Conceptual sizing calculation for normal and AOO conditions**
 - Design code is Section III, Division 5, 2021 Ed.
 - Thickness is adequate for operation up to 300,000 hours (~34 EFPY), will be extended to 540,000 hours (~60+ EFPY) (code revision)
 - Proven use of seal welds at joints to minimize helium leakage
- **Flow reductions during accident conditions reduces pressure loads**
- **Conceptual design complete on reactor vessel internals**




Power Conversion System (PCS) based on a Direct Brayton-Cycle



- **Dry Cooling Tower**

- Reduces impact on water resources and expands siting options




High-Efficiency Cycle that supports fast maneuvering capability

Containment Improves Safety and Siting



1. Reactor vessel
2. Reactor vessel cooling panel
3. Power conversion unit
4. Generator
5. Recirculator
6. Maintenance cooling system
7. Water tank
8. Containment
9. Containment liner
10. Maintenance caps
11. Concrete
12. Ground level





- The Containment System (Category I Structure, SSE-qualified) includes below-grade, leak-tight Containment Vessel (multi-barrier, defense-in-depth)
- Need for containment heat removal, cleanup, and venting under investigation

Below grade containment is less vulnerable to airplane crashes

Residual Heat Removed By Active and Passive Systems

- Reactor Vessel Cooling System (RVCS)
- Maintenance Cooling System
- Annular core arrangement promotes passive heat removal



FMR core and RVCS design guarantees long-term heat removal during severe accidents

Acknowledgements

This work was supported by the U.S. Department of Energy - Office of Nuclear Energy under Contract Number DE-NE0009052 for Advanced Reactor Concepts-20 (ARC-20).