

PG&E Letter DCL-24-033

10 CFR 21.21

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001Docket No. 50-275, OL-DPR-80
Docket No. 50-323, OL-DPR-82
Diablo Canyon Power Plant, Units 1 and 2
10 CFR Part 21 Interim Report

Dear Commissioners and Staff:

In accordance with the requirements of 10 CFR 21.21(a)(2), Pacific Gas and Electric Company (PG&E) hereby submits this interim report for Diablo Canyon Power Plant (DCPP). This interim report is being submitted as a result of PG&E's determination that a 10 CFR Part 21 evaluation is needed and will not be completed within 60 days of discovery. This issue did not adversely affect plant safety or operations.

In October 2023, during snubber functional testing being conducted during the DCPP Unit 1 Twenty-Fourth Refueling Outage, PG&E identified that three pipe system mechanical snubbers, of similar design and manufacturer, did not perform as expected during the tension portion of the as-found functional activation test. These snubbers were purchased in 2015 from ASC Engineered Solutions. Subsequently, PG&E has determined that the observed issue constitutes a deviation, as defined by 10 CFR 21.3.

The snubbers have been removed and are awaiting further evaluation into the cause of the activation test results by ASC Engineered Solutions.

PG&E makes no new or revised regulatory commitments (as defined by NEI 99-04) in this report. Corrective actions associated with this issue and the evaluation process are being tracked in the DCPP Corrective Action Program.

Sincerely,



Adam S. Peck

April 3, 2024

Date

dqmg/51214999

cc: Diablo Distribution
Mahdi O. Hayes, NRC Senior Resident Inspector
Sampson S. Lee, NRR Senior Project Manager
John D. Monninger, NRC Region IV Administrator