

# **RIC 2002**

## **Session W14**

### **License Renewal**

---

**Charles A. Casto, Director**  
**Division of Reactor Safety**  
**Region II**  
**U.S. Nuclear Regulatory Commission**  
**March 6, 2002**



# License Renewal Inspections

---

- Inspection Objectives
  - Verify license renewal program implemented within requirements
  - Verify material condition of systems, structures and components
  - Verify information and documentation
  - Verify implementation of license renewal integrated plant assessment and aging management program

# License Renewal Inspections

---

- Insights from inspection activities
  - Some scope omissions
  - Few material condition problems
  - Documentation errors usually minor
  - Aging management program structures established

# License Renewal Inspections

---

- Positive insights
  - Incorporated corrective actions into aging management reports, changes to application or documents
  - Material condition
  - Documentation from scoping and screening process of good quality and detailed
  - Procedures proposed for expansion of existing programs and creation of new aging management systems

# License Renewal Inspections

---

- Conclusion
  - Overall, inspections have shown that the applicants are implementing the license renewal process in accordance with the Rule.