

EXHIBIT B

**UPDATED FINAL SAFETY ANALYSIS REPORT
SUPPLEMENT**

APPLICATION FOR RENEWED OPERATING LICENSES

for

OCONEE NUCLEAR STATION, UNITS 1, 2, AND 3

OCONEE NUCLEAR STATION
UFSAR SUPPLEMENT FOR LICENSE RENEWAL

1. INTRODUCTION

As the current operating license holder for Oconee Nuclear Station (Oconee), Duke Energy Corporation (Duke) has prepared an Application for Renewed Operating Licenses for Oconee Nuclear Station, Units 1, 2, and 3 (Application). The complete application includes sufficient information for the NRC to complete their technical and environmental reviews and provides the basis for the NRC to make the findings required by §54.29. [Footnote 1]

Exhibit B of the Application contains the UFSAR Supplement required by §54.21(d).

§54.21(d) An FSAR Supplement

The FSAR supplement for the facility must contain a summary description of the programs and activities for managing the effects of aging and the evaluation of time-limited aging analyses for the period of extended operation determined by paragraphs (a) and (c) of this section, respectively.

Exhibit A of the Application (OLRP-1001) contains the technical information required by §§54.21(a) and (c). Chapter 4 of OLRP-1001 provides descriptions of the programs and activities that manage the effects of aging for the period of extended operation and Chapter 5 of OLRP-1001 contains the evaluations of the time-limited aging analyses for the period of extended operation. Both of these chapters have been used to prepare the program and activity descriptions that are contained in the attached *UFSAR Supplement for License Renewal*.

Available guidance has been considered in the preparation of the *UFSAR Supplement for License Renewal*. This guidance includes NEI 95-10, Revision 0 [Reference B-1] and the Statement of Considerations for the Final Part 54 Rule [Reference B-2]. In addition, several ongoing industry activities are focused on the enhancing the scope and content of existing safety analysis reports. Generally, the existing guidance is qualitative and subject to wide variations of interpretation. The attached *UFSAR Supplement for License Renewal* is considered reasonable in light of the guidance currently available and the existing Oconee UFSAR [Reference B-3].

-
1. Exhibit A of the Application contains the technical information for license renewal, as required by §§54.21(a) and (c), Exhibit B contains the UFSAR Supplement, as required by §54.21(d), Exhibit C contains the changes for the technical specifications, as required by §54.22 and Exhibit D contains the Environmental Information, as required by §54.23.
-

OCONEE NUCLEAR STATION
UFSAR SUPPLEMENT FOR LICENSE RENEWAL

The attached *UFSAR Supplement for License Renewal* will be incorporated into Oconee UFSAR following issuance of the renewed operating licenses for Oconee Nuclear Station, Units 1, 2 and 3. Upon inclusion of the *UFSAR Supplement for License Renewal* in the Oconee Updated Final Safety Analysis Report, changes to the descriptions of programs and activities will be made in accordance with the change process in effect at the time of any such change.

As an aid to the reader, Table 18-1 provides a summary listing of the programs, activities and time-limited aging analyses (TLAA) (topics) required for license renewal that are contained in the Oconee Nuclear Station *UFSAR Supplement for License Renewal*. The first column of Table 18-1 provides an alphabetical listing of these topics. The second column of Table 18-1 indicates whether the topic is a Program/Activity or TLAA. Programs and Activities are described in Chapter 4 of OLRP-1001 (Exhibit A of the Application). Topics that are considered to be currently existing programs, will continue through the life of the plant and are well documented.

Topics which are considered to be activities are of three types:

- (1) Individual inspections which currently exist and will continue through the life of the plant (e.g., plant inspections and surveillances);
- (2) Component replacements specifically identified within the Application as required for license renewal of Oconee; and
- (3) New one-time inspections specifically identified within the Application as required for license renewal of Oconee.

TLAA are described in Chapter 5 of OLRP-1001 (Exhibit A of the Application).

The third column of Table 18-1 identifies where the description of the Program, Activity, or TLAA will be located in the Oconee UFSAR. In some instances, a specification contained in the Oconee Improved Technical Specifications (ITS) pertains to a Program, Activity, or TLAA. In these instances, the ITS location is provided in the fourth column of Table 18-1.

OCONEE NUCLEAR STATION
UFSAR SUPPLEMENT FOR LICENSE RENEWAL

2. REFERENCES

- B-1. NEI 95-10, Revision 0, *Industry Guideline for Implementing the Requirements of 10 CFR Part 54 - The License Renewal Rule*, Nuclear Energy Institute, March 1996.
- B-2. 10 CFR Parts 2, 51, and 54, *Nuclear Power Plant License Renewal; Revisions*, 60 *Federal Register* 22461, May 8, 1995.
- B-3. *Oconee Nuclear Station, Final Safety Analysis Report*, through December 1996 Revision submitted by M. S. Tuckman (Duke) letter dated June 30, 1997 to Document Control Desk (NRC), Oconee Nuclear Station, Docket Nos. 50-269, -270, and -287.

Oconee Nuclear Station
UFSAR Supplement For License Renewal
Proposed Changes

BEGIN

UFSAR

SUPPLEMENT

Oconee Nuclear Station
UFSAR Supplement For License Renewal

Chapter 3 Changes

Revise existing text in UFSAR Section 3.2.2.2 to read as follows:

3.2.2.2 System Piping Classifications

Oconee has a number of systems that were designed to USAS B31.7 Class II and Class III and to USAS B31.1.0 requirements [Reference Table 3-1]. Piping analyses for these systems include stress range reduction factors to provide conservatism in the design to account for thermal cyclic operations. Thermal fatigue of mechanical systems designed to USAS B31.7 Class II and Class III and to USAS B31.1 is considered to be a time-limited aging analysis because all six of the criteria contained in §54.3 are satisfied.

For license renewal, the existing analysis addressing thermal fatigue of the mechanical components within the scope of license renewal is considered to be valid for the period of extended operation.

Add the following References:

Application for Renewed Operating Licenses for Oconee Nuclear Station, Units 1, 2, and 3, submitted by M. S. Tuckman (Duke) letter dated July 6, 1998 to Document Control Desk (NRC), Docket Nos. 50-269, -270, and -287.

[Insert specifics of NRC approval document as a reference, when available.]

Oconee Nuclear Station UFSAR Supplement For License Renewal

Chapter 3 Changes

Revise existing text in UFSAR Section 3.8.1.5.2 to read as follows:

3.8.1.5.2 Prestress Losses

Loss of prestress in the post-tensioning system is due to material strain occurring under constant stress. Loss of prestress over time is accounted for in the design and is a time-limited aging analysis requiring review for license renewal.

In accordance with ACI 318-63 the design of the Oconee Containment post-tensioning system provides for prestress losses caused by the following:

- Elastic shortening of concrete
- Creep of concrete
- Shrinkage of concrete
- Relaxation of prestressing steel stress
- Frictional loss due to curvature in the tendons and contact with tendon conduit.

No allowance is provided for seating of the anchor since no slippage occurs in the anchor during transfer of the tendon load into the structure.

By assuming an appropriate initial stress from tensile loading and using appropriate prestress loss parameters, the magnitude of the design losses and the final effective prestress at the end of 40 years for typical dome, vertical, and hoop tendons was calculated at the time of initial licensing.

In 1996, Oconee provided a description of the methodology for determining the most accurate minimum required lift-off force for each tendon group for NRC review. Based upon the results of the evaluation of the submitted information and commitments made by Duke, the NRC staff has determined that the integrity of the Oconee Containment is adequate to support continued operation.

Containment post-tensioning system surveillance will be performed in accordance with Oconee Improved Technical Specification SR 3.6.1.2. Acceptance criteria for tendon surveillance are given in terms of Prescribed Lower Limits and Minimum Required Values. Oconee Selected Licensee Commitment, Oconee UFSAR, SLC 16.6.2 provides the required prescribed lower limits and minimum required values in Appendix 16.6-2, Figures 1, 2, and 3. These figures contain the dome, hoop and vertical tendon prescribed lower limits and minimum required values, respectively, for all three Oconee units. The figures

Oconee Nuclear Station
UFSAR Supplement For License Renewal

Chapter 3 Changes

have been developed using the guidance contained in Regulatory Guide 1.35. Each prescribed lower limit line has been extended to 60 years of plant operation and remains above the minimum required values for all three tendon groups.

Add the following References:

Application for Renewed Operating Licenses for Oconee Nuclear Station, Units 1, 2, and 3, submitted by M. S. Tuckman (Duke) letter dated July 6, 1998 to Document Control Desk (NRC), Docket Nos. 50-269, -270, and -287.

[Insert specifics of NRC approval document as a reference, when available.]

Oconee Nuclear Station
UFSAR Supplement For License Renewal

Chapter 3 Changes

Revise existing text concerning fatigue loads in UFSAR Section 3.8.1.5.3 to read as follows:

3.8.1.5.3 Liner Plate

The interior surface of the Containment is lined with welded steel plate to provide an essentially leak tight barrier. At all penetrations, the liner plate is thickened to reduce stress concentrations. Design criteria are applied to the liner to assure that the specified leak rate is not exceeded under design basis accident conditions. The following fatigue loads were considered in the design of the liner plate and are considered to be time-limited aging analyses for the purposes of license renewal:

- (a) Thermal cycling due to annual outdoor temperature variations. The number of cycles for this loading is 40 cycles for the plant life of 40 years.
- (b) Thermal cycling due to Reactor Building interior temperature varying during the startup and shutdown of the Reactor Coolant System. The number of cycles for this loading is assumed to be 500 cycles.
- (c) Thermal cycling due to the loss-of-coolant accident will be assumed to be one cycle.
- (d) Thermal load cycles in the piping systems are somewhat isolated from the liner plate penetrations by concentric sleeves between the pipe and the liner plate. The attachment sleeve is designed in accordance with ASME Section III considerations. All penetrations are reviewed for a conservative number of cycles to be expected during the plant life.

Each of the above four time-limited aging analyses have been evaluated for continued operation for up to 60 years. For item (a), an increase in the number of thermal cycles due to annual outdoor temperature variations from 40 to 60 cycles is considered to be insignificant in comparison to the assumed 500 thermal cycles due to Containment interior temperature varying during heatup and cooldown of the Reactor Coolant System. Thus, this time-limited aging analysis is considered to be valid for the period of extended operation as it is enveloped with item (b) above.

For item (b), with respect to the assumed 500 thermal cycles due to startup and shutdown of the Reactor Coolant System, a more limiting number of thermal cycles is contained in the Oconee UFSAR, Section 5.2 for actual plant operation. Oconee UFSAR , Table 5.2

Oconee Nuclear Station UFSAR Supplement For License Renewal

Chapter 3 Changes

indicates a design limit of 360 heatup cycles and 360 cooldown cycles for the Reactor Coolant System. The projected number of cycles for each Oconee unit through 60 years of operation has been determined to be less than the original 360 cycle design limits. This time-limited aging analysis is considered to be valid for the period of extended operation because actual operating cycle values fall well within the assumed 500 thermal cycles due to startup and shutdown of the Reactor Coolant System.

For item (c), the assumed value for thermal cycling due to loss-of-coolant accident remains valid. None have occurred and none are expected to occur. This time-limited aging analysis is considered to be valid for the period of extended operation.

Finally for item (d), the design of the Containment penetrations has been reviewed. The design meets the general requirements of ASME Section III for thermal cycling. The only high temperature lines penetrating the Containment wall and liner plate are the feedwater and main steam lines. The design number of thermal load cycles in these two systems is bounded by the number of design heatup and cooldown cycles of the Reactor Coolant System. The projected number of cycles for each Oconee unit through 60 years of operation has been determined to be less than these original design limits. Thus, based on a review of the existing fatigue analysis, this time-limited aging analysis is considered to be valid for the period of extended operation.

Periodic Type A Integrated Leak rate tests are additional major sources of load changes. These Type A loads are considered within the set of design loads whose cumulative total was assumed to be 500 cycles. Seven Type A tests have been performed per unit to date (June 1998). The frequency of performing Type A tests has recently been revised to once every ten years. Four more tests may be performed per unit through the period of extended operation. The additional load cycles on the liner due to Type A testing are considered to be insignificant.

Oconee Nuclear Station
UFSAR Supplement For License Renewal

Chapter 3 Changes

Add the following References:

Application for Renewed Operating Licenses for Oconee Nuclear Station, Units 1, 2, and 3, submitted by M. S. Tuckman (Duke) letter dated July 6, 1998 to Document Control Desk (NRC), Docket Nos. 50-269, -270, and -287.

[Insert specifics of NRC approval document as a reference, when available.]

Oconee Nuclear Station
UFSAR Supplement For License Renewal

Chapter 3 Changes

Revise existing text in UFSAR Section 3.11, to read as follows:

(Text that has been added is underlined; text that has been revised is ~~strikethrough~~)

3.11 ENVIRONMENTAL DESIGN OF MECHANICAL AND ELECTRICAL EQUIPMENT

3.11.1 EQUIPMENT IDENTIFICATION AND ENVIRONMENTAL CONDITIONS

Duke has a program in place for environmental qualification of safety-related electrical equipment inclusive of equipment required to achieve a safe shutdown. Environmental effects resulting from the postulated design basis accidents documented in Chapter 15, "Accident Analyses" have been considered in the qualification of electrical equipment which is covered by this program. This program has been reviewed and approved by NRC (Reference 2).

3.11.1.1 Equipment Identification

Safety-related electrical equipment that is required to perform a safety function(s) in a postulated harsh environment is identified in Duke Power Company's response to NRC IE Bulletin 79-01B (Reference 1).

Safety-related mechanical equipment including design information is identified in Section 3.2.2, "System Quality Group Classification."

3.11.1.2 Environmental Conditions

The postulated harsh environmental conditions resulting from a LOCA or HELB inside the Reactor Building and a HELB outside the Reactor Building are identified and discussed in Duke Power Company's response to NRC IE Bulletin 79-01B (Reference 1).

The environmental parameters that compose the overall worst-case containment environment are as follows:

Containment Temperature: Time history as shown in Figure 15-71 for the Design Basis Accident (DBA), a 5.0 ft² hot leg break.

Oconee Nuclear Station UFSAR Supplement For License Renewal

Chapter 3 Changes

Containment Pressure: Time history as shown in Figure 15-56 for the largest (14.1 ft²) hot leg break.

Relative Humidity: 100%

Radiation: Total integrated radiation dose for the equipment location includes the 40 year normal operating dose plus the appropriate accident dose based on equipment operability requirements. The bases for determining the containment radiation environment are discussed in Chapter 12, "Radiation Protection."

Chemical Spray: Boric acid spray resulting from mixing in the containment sump with borated water from the borated water storage tank. Refer to Section 6.2.2, "Containment Heat Removal Systems" for additional information on chemical spray.

3.11.2 QUALIFICATION TEST AND ANALYSIS

Safety-related equipment identified in Section 3.11.1.1, "Equipment Identification" is qualified by test and/or analysis. The method of qualification for this Class 1E equipment is identified in Duke Power Company's response to NRC IE Bulletin 79-01B (Reference 1).

3.11.3 QUALIFICATION TEST RESULTS

The results of the qualification tests and/or analyses for the electrical equipment identified in Section 3.11.1.1, "Equipment Identification" are presented in the qualification documentation references identified in Duke Power Company's response to NRC IE Bulletin 79-01B (Reference 1). Additionally, a summary of the qualification results is also presented in the bulletin response.

3.11.4 EVALUATION FOR LICENSE RENEWAL

Some qualification analyses for safety-related equipment identified in Section 3.11.1.1 were found to be a time-limited aging analyses for license renewal. Evaluations were performed for applicable electrical equipment with the results submitted in Reference 3.

~~3.11.4~~ 3.11.5 LOSS OF VENTILATION

The control area air conditioning and ventilation systems (Section 9.4.1, "Control Room Ventilation") are conservatively designed to provide a suitable environment for the control

Oconee Nuclear Station UFSAR Supplement For License Renewal

Chapter 3 Changes

and electrical equipment. In addition, redundant air conditioning and ventilation equipment is provided, as summarized below, to assure that no single failure of an active component within these systems will prevent proper control area environmental control.

1. Two 100 percent capacity supply fans with filter banks and chilled water coils.
2. Two 100 percent capacity chillers.
3. Two 50 percent capacity outside air booster fans.

The Station Blackout scenario involves a four hour loss of ventilation to the control area. Assuming the non-essential loads are manually stripped within the first 30 minutes of the event, and the initial ambient temperatures outlined in the Selected Licensee Commitments Manual, Section 16.8.1 are not exceeded, analysis has shown that the following temperatures would not be exceeded:

| | |
|----------------------------|-------|
| Control rooms | 120°F |
| Cable rooms | 137°F |
| Electrical equipment rooms | 115°F |
| I&C Battery rooms | 107°F |

The above temperatures are within the specifications of the control room habitability requirements of 10CFR 50.63, and within the operating temperature limits of the equipment required to operate during the scenario.

~~3.11.5~~ 3.11.6 ESTIMATED CHEMICAL AND RADIATION ENVIRONMENT

The estimated chemical and radiation environments at Oconee are discussed in Duke Power Company's response to NRC IE Bulletin 79.01B (Reference 1). Additional information regarding chemical and radiation conditions is presented in Section 6.5, "Fission Product Removal and Control Systems" and in Chapter 12, "Radiation Protection," respectively.

~~3.11.6~~ 3.11.7 REFERENCES

1. Oconee Nuclear Station Response to IE Bulletin 79-OIB, as revised, including Response to NRC Equipment Qualification Safety Evaluation Report.

Oconee Nuclear Station
UFSAR Supplement For License Renewal

Chapter 3 Changes

2. Letter from J. F. Stolz (NRC) to H. B. Tucker (Duke) dated March 20, 1985.
Subject: Safety Evaluation Report on Environmental Qualification of Electrical Equipment Important to Safety.

3. Application for Renewed Operating Licenses for Oconee Nuclear Station, Units 1, 2, and 3, submitted by M. S. Tuckman (Duke) letter dated July 6, 1998 to Document Control Desk (NRC), Docket Nos. 50-269, -270, and -287.

[Insert specifics of NRC approval document as a reference, when available.]

Oconee Nuclear Station
UFSAR Supplement For License Renewal

Chapter 3 Changes

Insert new UFSAR Section 3.12 to read as follows:

3.12 Coatings Program

The Oconee *Coatings Program* was established prior to initial licensing of the station and has been in effect continuously since then. Over the years, enhancements and refinements have been made to improve the effectiveness of the program. The purpose of the Oconee *Coatings Program* is to protect the underlying structure or component from detrimental effects of the environment to which it is exposed during normal operation and to reduce personnel exposure to as low as reasonably achievable in areas subject to radiation and contamination. Table 3-12 provides a tabulation of the original, maintenance and new coating systems used in primary Containment. The elements of the Oconee *Coatings Program* are documented in a Nuclear Generation Department Directive.

Add the following References:

Application for Renewed Operating Licenses for Oconee Nuclear Station, Units 1, 2, and 3, submitted by M. S. Tuckman (Duke) letter dated July 6, 1998 to Document Control Desk (NRC), Docket Nos. 50-269, -270, and -287.

[Insert specifics of NRC approval document as a reference, when available.]

Oconee Nuclear Station UFSAR Supplement For License Renewal

Chapter 3 Changes

Insert new UFSAR Section 3.13 to read as follows:

3.13 Cranes and Control of Heavy Loads

The load cycle limit of the Oconee Polar Cranes has been identified as a time-limited aging analysis by reviewing correspondence on the Oconee dockets associated with the control of heavy loads. In 1981, NRC issued Generic Letter 81-07 and NUREG-0612 [Reference 3.13-1]. NRC issued a letter [Reference 3.13-2] requesting additional information which Duke responded to by letter [Reference 3.13-3]. One of the concerns expressed in NUREG-0612 was the potential for fatigue of the crane due to frequent loadings at or near design conditions. Cranes at Oconee are not generally subjected to frequent loads at or near design conditions. The topic of lift cycles of cranes at or near rated load is considered to be a time-limited aging analysis for Oconee because the analysis meet all of the criteria contained in §54.3.

The NRC evaluated the written Duke response to NUREG-0612 and in its evaluation [Reference 3.13-4] stated that since the number of cycles is far below the 20,000 loading cycles specified by CMAA-70 [Reference 3.13-5], fatigue is not a concern at Oconee. Duke notes that even for operation of the Oconee polar cranes through 60 years, the estimated number of heavy load cycles of the polar crane is still below 20,000 loading cycles.

Subsequent to the above NUREG-0612 review, Oconee installed an Independent Spent Fuel Storage Installation (ISFSI) which became operational in 1990. The operation of the ISFSI resulted in additional lifts by the spent fuel pool cranes near their rated lifting capacity.

For license renewal, the existing analyses addressing heavy load lifts of both the polar cranes and the spent fuel pool cranes are considered to be valid for the period of extended operation [Reference 3.13-6]

Oconee Nuclear Station
UFSAR Supplement For License Renewal

Chapter 3 Changes

References for Section 3.13

- 3.13-1. Generic Letter 81-07, *NUREG-0612, Control of Heavy Loads*, NRC, February 3, 1981.
- 3.13-2. J. F. Stolz (NRC) to W. O. Parker (Duke) letter dated February 18, 1982, Oconee Nuclear Station, Docket Numbers 50-269, 50-270, 50-287.
- 3.13-3. W. O. Parker (Duke) letter to Document Control Desk (NRC) dated October 8, 1982, Oconee Nuclear Station, Docket Numbers 50-269, 50-270, 50-287.
- 3.13-4. J. F. Stolz (NRC) letter H. B. Tucker (Duke) dated April 20, 1983, Oconee Nuclear Station, Docket Numbers 50-269, 50-270, 50-287.
- 3.13-5. Crane Manufacturers Association of America (CMAA) Specification #70, *Specifications for Electric Overhead Traveling Cranes*, Revised 1975.
- 3.13-6. *Application for Renewed Operating Licenses for Oconee Nuclear Station, Units 1, 2, and 3*, submitted by M. S. Tuckman (Duke) letter dated July 6, 1998 to Document Control Desk (NRC), Docket Nos. 50-269, -270, and -287.

[Insert specifics of NRC approval document as a reference, when available.]

Oconee Nuclear Station
UFSAR Supplement For License Renewal

Chapter 4 Changes

Revise existing text in UFSAR Section 4.5.1.2 to read as follows:

4.5.1 Reactor Internals

4.5.1.2 Design Bases

Duke actively participated in a B&W Owners Group effort that developed a series of technical reports whose purpose was to demonstrate that the aging effects for reactor coolant system components are adequately managed for the period of extended operation for license renewal. One of the B&W Owners Group topical reports that was submitted and is currently under NRC review is BAW-2248 [Reference 4-1] which addresses the reactor vessel internals. Time-limited aging analyses applicable to the Oconee reactor vessel internals are addressed within BAW-2248.

Time-limited aging analyses that are applicable to the Oconee reactor vessel internals include: (1) flow-induced vibration endurance limit assumptions; (2) transient cycle count assumptions for the replacement bolting; and (3) reduction in fracture toughness.

Oconee Nuclear Station
UFSAR Supplement For License Renewal

Chapter 4 Changes

REFERENCES FOR CHAPTER 4

- 4-1. *Demonstration of the Management of Aging Effects for the Reactor Vessel Internals*, BAW-2248, The B&W Owners Group Generic License Renewal Program, July 1997.
- 4-2. *Application for Renewed Operating Licenses for Oconee Nuclear Station, Units 1, 2, and 3*, submitted by M. S. Tuckman (Duke) letter dated July 6, 1998 to Document Control Desk (NRC), Docket Nos. 50-269, -270, and -287.

[Insert specifics of NRC approval document as a reference, when available.]

Oconee Nuclear Station
UFSAR Supplement For License Renewal

Chapter 5 Changes

Revise existing text in UFSAR Section 5.2.1.4 to read as follows:

5.2.1.4 Cyclic Loads

Oconee Technical Specification 5.5.6 establishes the requirement to provide controls to track the number of UFSAR Section 5.2.1.4 cyclic and transient occurrences to assure that components are maintained within design limits. The Transient Cycle Monitoring Program is implemented by written procedures as required by Oconee Technical Specification 5.4. The evaluation of the thermal transient cycle count assumptions used in Oconee mechanical system thermal fatigue analyses considered the following specific topic areas:

- (1) Reactor Coolant System components within the B&W scope of supply;
- (2) Reactor Coolant System components within the Bechtel scope of supply;
- (3) IE Bulletin 88-11, Pressurizer Surge Line Stratification;
- (4) IE Bulletin 88-08, Thermal Stresses in Piping Connected to the Reactor Coolant System.
- (5) ASME Section XI - Analysis of Inservice Inspection Indications;
- (6) Non-Reactor Coolant System mechanical components;

For license renewal, continuation of the Oconee *Thermal Fatigue Management Program* into the period of extended operation will provide reasonable assurance that the analyses will remain valid or that appropriate action is taken in a timely manner to assure continued validity of the design.

Add the following References:

Application for Renewed Operating Licenses for Oconee Nuclear Station, Units 1, 2, and 3, submitted by M. S. Tuckman (Duke) letter dated July 6, 1998 to Document Control Desk (NRC), Docket Nos. 50-269, -270, and -287.

[Insert specifics of NRC approval document as a reference, when available.]

Oconee Nuclear Station
UFSAR Supplement For License Renewal

Chapter 5 Changes

Revise appropriate portions of text in UFSAR Section 5.2.3.3 to include the following:

5.2.3.3 Reactor Vessel

Replace existing text in Section 5.2.3.3.6 with the following:

5.2.3.3.6 Pressurized Thermal Shock

Section 50.61(b)(1) provides rules for protection against pressurized thermal shock events for pressurized water reactors. Licensees are required to perform an assessment of the projected values of reference temperature whenever there is a significant change in projected values of RT_{PTS} , or upon request for a change in the expiration date for the operation of the facility. For license renewal, RT_{PTS} values are calculated for 48 EFPY for Oconee Units 1, 2, and 3.

Section 50.61(c) provides two methods for determining RT_{PTS} : (Position 1) for material that does not have surveillance data available, and (Position 2) for material that does have surveillance data. Availability of surveillance data is not the only measure of whether Position 2 [Footnote 1] may be used; the data must also meet tests of sufficiency and credibility.

RT_{PTS} is the sum of the initial reference temperature (IRT_{NDT}), the shift in reference temperature caused by neutron irradiation (ΔRT_{NDT}), and a margin term (M) to account for uncertainties.

IRT_{NDT} is determined using the method of Section III of the ASME Boiler & Pressure Vessel Code. That is, IRT_{NDT} is the greater of the drop weight nil-ductility transition temperature or the temperature that is 60 °F below that at which the material exhibits Charpy test values of 50 ft-lbs and 35 mils lateral expansion. For a material for which test data is unavailable, generic values may be used if there are sufficient test results for that class of material. For Linde 80 weld material with the exception of WF-70, the IRT_{NDT} is taken to be the currently NRC accepted values of -7 °F or -5 °F. For WF-70, the IRT_{NDT} is similarly taken to be a measured value, -26.5 °F, in accordance with the discussion and results presented in BAW-2202 [Footnote 2][Reference 5-1]. For forgings and plate material, measured values are used where appropriate data is available. Where not

-
1. The term "Position" is taken from Regulatory Guide 1.99, the methodology of which was incorporated into 10 CFR 50.61.
 2. BAW-2202 is an FTI topical report submitted to the NRC for their acceptance on September 29, 1993. The NRC's acceptance for use at the Zion plants was published in the Federal Register, Vol. 59, No. 40, Pages 9782-9785, March 1, 1994.
-

Oconee Nuclear Station UFSAR Supplement For License Renewal

Chapter 5 Changes

available, the generic value of +3 °F is used for forgings and +1 °F is used for plate material [Reference 5-2].

For Position 1 material (surveillance data not available), ΔRT_{NDT} is defined as the product of the chemistry factor (**CF**) and the fluence factor (**ff**). **CF** is a function of the material's copper and nickel content expressed as weight percent. "Best estimate" copper and nickel contents are used which is the mean of measured values for the material. For Oconee, best estimate values were obtained from the following FTI reports: BAW-1820, BAW-2121P, BAW-2166, and BAW-2222 [Footnote 1][References 5-3, 5-4, 5-5, and 5-6]. The value of **CF** is directly obtained from tables in §50.61. **ff** is a calculated value [Footnote 2] using end-of-license (EOL) peak fluence at the inner surface at the material's location. Fluence values were obtained by extrapolation to 48 EFPY of the current 32 EFPY values for each Oconee unit.

For beltline welds and plate materials for which surveillance data is available, evaluations were performed in accordance with Regulatory Guide 1.99, Revision 2, Position 2. The applicable chemistry factors, margin, and RT_{PTS} at 48 EFPY are summarized in Tables 5-1 through 5-3.

For Position 2 material (surveillance data available), the discussion above for Position 1 applies except for determination of **CF**, which in this instance is a material-specific value calculated as follows:

- (1) Multiply each ΔRT_{NDT} value by its corresponding **ff**.
- (2) Sum these products.
- (3) Divide this sum by the sum of the squares of the **ffs**.

The **margin** term (**M**) is generally determined as follows:

$$M = 2(\sigma_I^2 + \sigma_\Delta^2)^{0.5}$$

-
1. BAW-1820 and BAW-2121P were provided to the NRC for their information. BAW-2166 and BAW-2222 were provided to the NRC as part of the Generic Letter 92-01 program.
 2. $ff = f^{(0.28-0.1*\log f)}$, where $f = \text{fluence} * 10^{-19}$ (n/cm², E>1MeV).
-

Oconee Nuclear Station UFSAR Supplement For License Renewal

Chapter 5 Changes

where σ_I is the standard deviation for IRT_{NDT}

and σ_Δ is the standard deviation for ΔRT_{NDT} .

For Position 1, $\sigma_I = 0$ if measured values are used. If generic values are used, σ_I is the standard deviation of the set of values used to obtain the mean value. For ΔRT_{NDT} , $\sigma_\Delta = 28^\circ\text{F}$ for welds and 17°F for base metal (plate and forgings), except that σ_Δ need not exceed one-half of the mean value of ΔRT_{NDT} . For Position 2, the same method for determining the σ values are used except that the σ_Δ values are halved (14°F for welds and 8.5°F for base metal).

Section 50.61(b)(2) establishes screening criteria for RT_{PTS} : 270°F for plates, forgings, and axial welds and 300°F for circumferential welds. The values for RT_{PTS} at 48 EFPY are provided in Tables 5-1, 5-2, and 5-3 for Units 1, 2, and 3, respectively. The RT_{PTS} values reported herein are based on updated 48 EFPY fluence projections using the evaluation based methodology described in BAW-2251 [Reference 5-7, Appendix D] and BAW-2241P [Reference 5-8].

The projected RT_{PTS} values for Units 1 and 3 are within the established screening criteria for 48 EFPY. For Unit 1, the limiting weld is SA-1073 with a projected value of RT_{PTS} at 48 EFPY of 230.3°F (screening limit of 270°F). For Unit 3, the limiting weld is WF-67 with a projected value of RT_{PTS} at 48 EFPY of 253.5°F (screening limit of 300°F).

For Unit 2, the projected RT_{PTS} value for 48 EFPY is 300.1°F which is 0.1°F above the established screening criteria or 300°F for circumferential welds. Section 50.61(b)(3) requires that licensees implement flux reduction programs that are reasonably practical to avoid exceeding the screening criteria set forth in §50.61(b)(2).

Duke commits to the following activities in order to avoid exceeding these screening criteria at Oconee:

- (1) Duke will continue our practice of using low leakage core designs;
- (2) Duke will continue our involvement in various industry activities that provide new information or new analysis techniques associated with the reactor vessel beltline region. These activities include, but are not limited to, the development of the master curve technique which will establish a generic initial value of RT_{NDT} of -27°F Linde 80 welds (WF 25, the limiting weld for Unit 2 is a Linde 80 weld);

Oconee Nuclear Station
UFSAR Supplement For License Renewal

Chapter 5 Changes

- (3) Duke will provide projected values of RT_{PTS} at 48 EFPY for each Oconee unit as follows:
- (a) in 2013 (which is 40 years of operation or approximately 33 EFPY)
 - (b) in 2023 (which is 50 years of operation or approximately 41 EFPY)

[Reference 5-9]

Oconee Nuclear Station UFSAR Supplement For License Renewal

Chapter 5 Changes

Insert New Section 5.2.3.3.X

5.2.3.3.X Charpy Upper-Shelf Energy

Appendix G of 10 CFR 50 requires that reactor vessel beltline materials “have Charpy upper-shelf energy ... of no less than 75 ft-lb initially and must maintain Charpy upper-shelf energy throughout the life of the vessel of no less than 50 ft-lb” The B&WOG positions on upper shelf energy for 32 EFPY are documented in the responses to Generic Letter 92-01, as reported in BAW-2166 and BAW-2222 and, the low upper shelf toughness analyses documented in BAW-2275 [Reference 5-10], which is included in BAW-2251 as Appendix B.

Regulatory Guide 1.99, Revision 2 provides two methods for determining Charpy upper-shelf energy (C_V USE): Position 1 for material that does not have surveillance data available and Position 2 for material that does have surveillance data. For Position 1, the percent drop in C_V USE, for a stated copper content and neutron fluence, is determined by reference to Figure 2 of Regulatory Guide 1.99, Revision 2. This percentage drop is applied to the initial C_V USE to obtain the adjusted C_V USE. For Position 2, the percent drop in C_V USE is determined by plotting the available data on Figure 2 and fitting the data with a line drawn parallel to the existing lines that upper bounds all the plotted points.

The 48 EFPY C_V USE values were determined for the reactor vessel beltline materials for each Oconee Unit are reported in Tables 5-4 through 5-6. The T/4 fluence values reported in these tables were calculated in accordance with the ratio of inner surface to T/4 values (i.e. neutron fluence lead factors at T/4) determined in the latest Reactor Vessel Surveillance Program report. [Footnote 1] As shown in these tables, the C_V USE is maintained above 50 ft-lb for base metal (plates and forgings), however, for Oconee the C_V USE for weld metal drops below the required 50 ft-lb level at 48 EFPY. Appendix G of 10 CFR 50 provides for this by allowing operation with lower values of C_V USE if “it is demonstrated ... that the lower values of Charpy upper-shelf energy will provide margins of safety against fracture equivalent to those required by Appendix G of Section XI of the ASME Code.”

This equivalent margin analysis was performed for 48 EFPY and is reported in BAW-2275 for service levels A, B, C, and D. The analysis used very conservative material models and load

-
1. The current projected 48 EFPY fluence values for Unit 1 welds are slightly greater than that reported in BAW-2251, Table 4-4. A calculation has been performed which shows that the weld metals of Oconee Unit 1 continue to satisfy the acceptance criteria of Appendix K of Section XI of the ASME Code. The current projected 48 EFPY fluence values for Units 2 and 3 are less than those values presented in BAW-2251, Tables 4-5 and 4-6. The values reported in these two tables of BAW-2251 are conservatively bounding.
-

Oconee Nuclear Station UFSAR Supplement For License Renewal

Chapter 5 Changes

combinations, i. e., treating thermal gradient stress as a primary stress. For service levels A and B, the analytical results demonstrate that there is sufficient margin beyond that required by the acceptance criteria of Appendix K of the ASME Code (1995 Edition). For service levels C and D, the most limiting transient was evaluated, and again the analytical results demonstrate that there is sufficient margin beyond that required by the acceptance criteria of Appendix K of the ASME Code. The evaluations for all service levels conclusively demonstrate the adequacy of margin of safety against fracture for the reactor vessels within the scope of this report for 48 EFPY [Reference 5-9].

Oconee Nuclear Station UFSAR Supplement For License Renewal

Chapter 5 Changes

Insert New Section 5.2.3.3.Y

5.2.3.3Y Intergranular Separation in HAZ of Low Alloy Steel under Austenitic SS Weld Cladding

Intergranular separations in low alloy steel heat-affected zones under austenitic stainless steel weld claddings were detected in SA-508, Class 2 reactor vessel forgings manufactured to a coarse grain practice, and clad by high-heat-input submerged arc processes. BAW-10013 contains a fracture mechanics analysis that demonstrates the critical crack size required to initiate fast fracture is several orders of magnitude greater than the assumed maximum flaw size plus predicted flaw growth due to design fatigue cycles. The flaw growth analysis was performed for a 40-year cyclic loading, and an end-of-life assessment of radiation embrittlement (i.e., fluence at 32 EFPY) was used to determine fracture toughness properties. The report concluded that the intergranular separations found in B&W vessels would not lead to vessel failure. This conclusion was accepted by the Atomic Energy Commission. [Footnote 1] To cover the period of extended operation, an analysis was performed using current ASME Code requirements; this analysis is fully described in BAW-2274 [Reference 5-11] which is contained in BAW-2251 as Appendix C.

In May 1973, the Atomic Energy Commission issued Regulatory Guide 1.43, "Control of Stainless Steel Weld Cladding of Low-Alloy Steel Components," [Reference 5-12]. The guide states that underclad cracking "has been reported only in forgings and plate material of SA-508 Class 2 composition made to coarse grain practice when clad using high-deposition-rate welding processes identified as 'high-heat-input' processes such as the submerged-arc wide-strip and the submerged-arc 6-wire processes. Cracking was not observed in clad SA-508 Class 2 materials clad by 'low-heat-input' processes controlled to minimize heating of the base metal. Further, cracking was not observed in clad SA-533 Grade B Class 1 plate material, which is produced to fine grain practice.

Characteristically, the cracking occurs only in the grain-coarsened region of the base-metal heat-affected zone at the weld bead overlap." The guide also notes that the maximum observed dimensions of these subsurface cracks is 0.165-inch deep by 0.5-inch long.

The BAW-10013 fracture mechanics analysis is a flaw evaluation performed before the ASME Code requirements for flaw evaluation, the K_{Ia} curve for ferritic steels as indexed against RT_{NDT} , and the ASME Code fatigue crack growth curves for carbon and low alloy ferritic steels were available. The revised analysis uses current fracture toughness information, applied stress intensity factor solutions, and fatigue crack growth correlations

1. R. C. DeYoung (USAEC) to J. F. Mally (B&W), letter transmitting topical report evaluation, October 11, 1972.

Oconee Nuclear Station UFSAR Supplement For License Renewal

Chapter 5 Changes

for SA-508 Class 2 material. The objective of the analysis is to determine the acceptability of the postulated flaws for 48 EFPY using ASME Code, Section XI, (1995 Edition), IWB-3612 acceptance criteria.

The revised analysis was applied to three relevant regions of the reactor vessel: the beltline, the nozzle belt, and the closure head/head flange. The analysis conservatively considered 360 cycles of 100°F/hr normal heatup and cooldown transients. For the power maneuvering transients, the range in applied stress intensity factors for the closure head region were assumed to be the same as that determined for the beltline region. This assumption is considered conservative since the closure head region is subject to a low flow condition while the beltline region is subject to a forced flow condition.

An initial flaw size of 0.353-inch deep by 2.12-inch long (6:1 aspect ratio) was conservatively assumed for each of the three regions. The flaw was further assumed to be an axially oriented, semi-elliptical surface flaw in contrast to the observed flaws which are subsurface with a maximum size of 0.165-inch deep by 0.5-inch long.

The maximum crack growth and applied stress intensity factor for the normal and upset conditions were found to occur in the nozzle belt region. The maximum crack growth, considering all the normal and upset condition transients for 48 EFPY, was determined to be 0.180-inch, which results in a final flaw depth of 0.533-inch. The maximum applied stress intensity factor for the normal and upset condition results in a fracture toughness margin of 3.6 which is greater than the IWB-3612 acceptance criterion of 3.16.

The maximum applied stress intensity factor for the emergency and faulted conditions occurs in the closure head to head flange region and the fracture toughness margin was determined to be 2.24, which is greater than the IWB-3612 acceptance criterion of 1.41. It is therefore concluded that the postulated intergranular separations in the Oconee Unit 1, 2, and 3 reactor vessel 508 Class 2 forgings are acceptable for continued safe operation through the period of extended operation [Reference 5-9].

Oconee Nuclear Station
UFSAR Supplement For License Renewal

Chapter 5 Changes

Revise existing text in UFSAR Section 5.4.4.2 to read as follows:

5.4.4.2 Flywheel Design Consideration

The reactor coolant pump motors are large, vertical, squirrel cage, induction motors. The motors have flywheels to increase rotational-inertia, thus prolonging pump coastdown and assuring a more gradual loss of main coolant flow to the core in the event that pump power is lost. The flywheel is mounted on the upper end of the rotor, below the upper radial bearing and inside the motor frame. The assumed operation of the reactor coolant pumps was 500 motor starts over forty years. The aging effect of concern is fatigue crack initiation in the flywheel bore key way from stresses due to starting the motor. Therefore, this topic is considered to be a time-limited aging analysis for license renewal.

The flywheels have been designed for 10,000 starts that provide a safety factor of 20 over the original operation assumptions. Reaching 10,000 starts in 60 years would require on average a pump start every 2.1 days. This conservative design is considered to be valid for the period of extended operation [Reference 5-9].

Oconee Nuclear Station
UFSAR Supplement For License Renewal

Chapter 5 Changes

References for Chapter 5

- 5-1. BAW-2202, *Fracture Toughness Characterization of WF-70 Weld Metal*, B&W Nuclear Service Company, Lynchburg, VA, September 1993.
- 5-2. BAW-10046A, Revision 2, *Methods of Compliance With Fracture Toughness and Operational Requirements of 10 CFR 50, Appendix G*, B&W Nuclear Power Division/Alliance Research Center, June 1986.
- 5-3. BAW-1820, *177-Fuel Assembly Reactor Vessel and Surveillance Program Materials Information*, B&W Nuclear Power Division, Lynchburg, VA, December 1984.
- 5-4. BAW-2121P, *Chemical Composition of B&W Fabricated Reactor Vessel Beltline Welds*, B&W Nuclear Technologies, Inc., Lynchburg, VA, April 1991.
- 5-5. BAW-2166, *Response to Generic Letter 92-01*, B&W Nuclear Service Company, Lynchburg, VA, June 1992.
- 5-6. BAW-2222, *Response to Closure Letters to Generic Letter 92-01, Revision 1*, B&W Nuclear Technologies, Lynchburg, VA, June 1994.
- 5-7. BAW-2251, *Demonstration of the Management of Aging Effects for the Reactor Vessel*, The B&W Owners Group Generic License Renewal Program, June 1996.
- 5-8. BAW-2241P, *Fluence and Uncertainty Methodologies*, April 1997 (under NRC review as of June 1998).
- 5-9. *Application for Renewed Operating Licenses for Oconee Nuclear Station, Units 1, 2, and 3*, submitted by M. S. Tuckman (Duke) letter dated July 6, 1998 to Document Control Desk (NRC), Docket Nos. 50-269, -270, and -287.
- 5-10. BAW-2275, T. Wiger and D. Killian, *Low Upper-Shelf Toughness Fracture Mechanics Analysis of B&W Designed Reactor Vessels for 48 EFPY*, Framatome Technologies, Inc. Lynchburg, VA.

Oconee Nuclear Station
UFSAR Supplement For License Renewal

Chapter 5 Changes

-
- 5-11. BAW-2274, A. Nana, *Fracture Mechanics Analysis of Postulated Underclad Cracks in B&W Designed Reactor Vessels for 48 EFPY*, Framatome Technologies, Inc. Lynchburg, VA.
- 5-12. U.S. Atomic Energy commission, *Control of Stainless Steel Weld Cladding of Low-Alloy Steel Components*, Regulatory Guide 1.43, May 1973.

Oconee Nuclear Station
UFSAR Supplement For License Renewal

Chapter 5 Changes

Table 5-1 Evaluation of Reactor Vessel Pressurized Thermal Shock Toughness Properties at 48 EFPY - Oconee Unit 1

| Material Description | | | | Chemical Composition | | Initial RT _{NDT} | Chemistry Factor | Fluence, n/cm ² Inside Surface | ΔRT _{NDT} , F at 48 EFPY | Margin | RT _{PTS} , F at 48 EFPY | Screening Criteria |
|---|--------------|-------------|----------------|----------------------|--------|---------------------------|------------------|---|-----------------------------------|--------|----------------------------------|--------------------|
| Reactor Vessel Bellline Region Location | Matl. Ident. | Heat Number | Type | Cu wt% | Ni wt% | | | | | | | |
| 10 CFR 50.61 (Tables) | | | | | | | | | | | | |
| Lower Nozzle Belt Forging | AHR 54 | ZV-2861 | A 508 Cl. 2 | 0.16 | 0.65 | +3 | 119.3 | 1.11E+18 | 52.2 | 70.7 | 126.0 | 270 |
| Intermediate Shell Plate | C2197-2 | C2197-2 | SA-302 Gr. BM* | 0.15 | 0.50 | +1 | 104.5 | 1.18E+19 | 109.3 | 63.6 | 174.0 | 270 |
| Upper Shell Plate | C3265-1 | C3265-1 | SA-302 Gr. BM* | 0.10 | 0.50 | +1 | 65.0 | 1.31E+19 | 69.9 | 63.6 | 134.5 | 270 |
| Upper Shell Plate | C3278-1 | C3278-1 | SA-302 Gr. BM* | 0.12 | 0.60 | +1 | 83.0 | 1.31E+19 | 89.2 | 63.6 | 153.9 | 270 |
| Lower Shell Plate | C2800-1 | C2800-1 | SA-302 Gr. BM* | 0.11 | 0.63 | +1 | 74.5 | 1.31E+19 | 80.0 | 63.6 | 144.7 | 270 |
| Lower Shell Plate | C2800-2 | C2800-2 | SA-302 Gr. BM* | 0.11 | 0.63 | +1 | 74.5 | 1.31E+19 | 80.0 | 63.6 | 144.7 | 270 |
| LNB to IS Circ. Weld (100%) | SA-1135 | 61782 | ASA/Linde 80 | 0.23 | 0.52 | -5 | 157.4 | 1.11E+18 | 69.0 | 68.5 | 132.4 | 300 |
| IS Longit. Weld (Both 100%) | SA-1073 | 1P0962 | ASA/Linde 80 | 0.21 | 0.64 | -5 | 170.6 | 9.24E+18 | 166.8 | 68.5 | [230.3] | 270 |
| IS to US Circ. Weld (ID 61%) | SA-1229 | 71249 | ASA/Linde 80 | 0.23 | 0.59 | +10 | 167.6 | 1.19E+19 | 175.7 | 56.0 | 241.7 | 300 |
| US Longit. Weld (Both 100%) | SA-1493 | 8T1762 | ASA/Linde 80 | 0.19 | 0.55 | -5 | 149.3 | 1.12E+19 | 154.0 | 68.5 | 217.4 | 270 |
| US to LS Circ. Weld (100%) | SA-1585 | 72445 | ASA/Linde 80 | 0.22 | 0.54 | -5 | 158.0 | 1.27E+19 | 168.5 | 68.5 | 232.0 | 300 |
| LS Longit. Weld (100%) | SA-1426 | 8T1762 | ASA/Linde 80 | 0.19 | 0.55 | -5 | 149.3 | 1.08E+19 | 152.5 | 68.5 | 215.9 | 270 |
| LS Longit. Weld (100%) | SA-1430 | 8T1762 | ASA/Linde 80 | 0.19 | 0.55 | -5 | 149.3 | 1.08E+19 | 152.5 | 68.5 | 215.9 | 270 |
| 10 CFR 50.61 (Surveillance Data) | | | | | | | | | | | | |
| LNB to IS Circ. Weld (100%) | SA-1135 | 61782 | ASA/Linde 80 | 0.23 | 0.52 | -5 | 133.0 | 1.11E+18 | 58.3 | 48.3 | 101.6 | 300 |
| US to LS Circ. Weld (100%) | SA-1585 | 72445 | ASA/Linde 80 | 0.22 | 0.54 | -5 | 151.8 | 1.27E+19 | 161.9 | 48.3 | 205.2 | 300 |

Oconee Nuclear Station
UFSAR Supplement For License Renewal

Chapter 5 Changes

Table 5-2 Evaluation of Reactor Vessel Pressurized Thermal Shock Toughness Properties at 48 EFPY - Oconee Unit 2

| Material Description | | | | Chemical Composition | | Initial RT _{NDT} | Chemistry Factor | Fluence, n/cm ² Inside Surface | ΔRT _{NDT} , F at 48 EFPY | Margin | RT _{PTS} , F at 48 EFPY | Screening Criteria |
|---|--------------|-------------|--------------|----------------------|--------|---------------------------|------------------|---|-----------------------------------|--------|----------------------------------|--------------------|
| Reactor Vessel Bellline Region Location | Matl. Ident. | Heat Number | Type | Cu wt% | Ni wt% | | | | | | | |
| 10 CFR 50.61 (Tables) | | | | | | | | | | | | |
| Lower Nozzle Belt Forging | AMX 77 | 123T382 | A 508 Cl. 2 | 0.13 | 0.76 | +3 | 95.0 | 1.19E+19 | 99.6 | 70.7 | 173.3 | 270 |
| Upper Shell Forging | AAW 163 | 3P2359 | A 508 Cl. 2 | 0.04 | 0.75 | +20 | 26.0 | 1.28E+19 | 27.8 | 27.8 | 75.6 | 270 |
| Lower Shell Forging | AWG 164 | 4P1885 | A 508 Cl. 2 | 0.02 | 0.80 | +20 | 20.0 | 1.27E+19 | 21.3 | 21.3 | 62.7 | 270 |
| LNB to US Circ. Weld (100%) | WF-154 | 406L44 | ASA/Linde 80 | 0.28 | 0.59 | -5 | 185.7 | 1.19E+19 | 194.7 | 68.5 | 258.1 | 300 |
| US to LS Circ. Weld (100%) | WF-25 | 299L44 | ASA/Linde 80 | 0.34 | 0.68 | -5 | 220.6 | 1.23E+19 | 233.3 | 68.5 | 296.8 | 300 |
| 10 CFR 50.61 (Surveillance Data) | | | | | | | | | | | | |
| Upper Shell Forging | AAW 163 | 3P2359 | A 508 Cl. 2 | 0.04 | 0.75 | +20 | 8.9 | 1.28E+19 | 9.5 | 9.5 | 39.0 | 270 |
| US to LS Circ. Weld (100%) | WF-25 | 299L44 | ASA/Linde 80 | 0.34 | 0.68 | -5 | 223.7 | 1.23E+19 | 236.6 | 68.5 | [300.1] | 300 |

Oconee Nuclear Station
UFSAR Supplement For License Renewal

Chapter 5 Changes

Table 5-3 Evaluation of Reactor Vessel Pressurized Thermal Shock Toughness Properties at 48 EFPY - Oconee Unit 3

| Material Description | | | | Chemical Composition | | Initial RT _{NDT} | Chemistry Factor | Fluence, n/cm ² Inside Surface | ΔRT _{NDT} , F at 48 EFPY | Margin | RT _{PTS} , F at 48 EFPY | Screening Criteria |
|---|--------------|-------------|--------------|----------------------|--------|---------------------------|------------------|---|-----------------------------------|--------|----------------------------------|--------------------|
| Reactor Vessel Bellline Region Location | Matl. Ident. | Heat Number | Type | Cu wt% | Ni wt% | | | | | | | |
| 10 CFR 50.61 (Tables) | | | | | | | | | | | | |
| Lower Nozzle Belt Forging | 4680 | 4680 | A 508 Cl. 2 | 0.13 | 0.91 | +3 | 96.0 | 1.14E+19 | 99.5 | 70.7 | 173.2 | 270 |
| Upper Shell Forging | AWS 192 | 522314 | A 508 Cl. 2 | 0.01 | 0.73 | +40 | 20.0 | 1.26E+19 | 21.3 | 21.3 | 82.6 | 270 |
| Lower Shell Forging | ANK 191 | 522194 | A 508 Cl. 2 | 0.02 | 0.76 | +40 | 20.0 | 1.26E+19 | 21.3 | 21.3 | 82.6 | 270 |
| LNB to US Circ. Weld (100%) | WF-200 | 821T44 | ASA/Linde 80 | 0.25 | 0.63 | -5 | 181.0 | 1.14E+19 | 187.6 | 68.5 | 251.0 | 300 |
| US to LS Circ. Weld (ID 75%) | WF-67 | 72442 | ASA/Linde 80 | 0.26 | 0.60 | -5 | 180.0 | 1.22E+19 | 190.0 | 68.5 | [253.5] | 300 |
| 10 CFR 50.61 (Surveillance Data) | | | | | | | | | | | | |
| Upper Shell Forging | AWS 192 | 522314 | A 508 Cl. 2 | 0.01 | 0.73 | +40 | 47.4 | 1.26E+19 | 50.5 | 34.0 | 124.5 | 270 |
| Lower Shell Forging | ANK 191 | 522194 | A 508 Cl. 2 | 0.02 | 0.76 | +40 | 32.5 | 1.26E+19 | 34.6 | 17.0 | 91.6 | 270 |

Oconee Nuclear Station
UFSAR Supplement For License Renewal

Chapter 5 Changes

Table 5-4 Evaluation of Reactor Vessel Extended Life (48EFPY) Charpy V-Notch Upper-Shelf Energy - Oconee Unit 1

| Material Description | | | | Copper Composition w/o | Initial CvUSE, ft-lbs | 48 EFY Fluence T/4 Location, n/cm ² | Estimated 48 EFY CvUSE at T/4 | 48 EFY % Drop at T/4 |
|---|--------------|-------------|----------------|------------------------|-----------------------|--|-------------------------------|----------------------|
| Reactor Vessel Beltline Region Location | Matl. Ident. | Heat Number | Type | | | | | |
| Regulatory Guide 1.99, Revision 2, Position 1 | | | | | | | | |
| Lower Nozzle Belt Forging | AHR-54 | ZV-2861 | A508 Cl.2 | 0.16 | 109 | 9.18E+17 | 94 | 14 |
| Intermediate Shell Plate | C2197-2 | C2197-2 | SA-302 Gr. B M | 0.15 | 81 | 6.22E+18 | 63 | 22 |
| Upper Shell Plate | C3265-1 | C3265-1 | SA-302 Gr. B M | 0.10 | 108 | 7.06E+18 | 90 | 17 |
| Upper Shell Plate | C3278-1 | C3278-1 | SA-302 Gr. B M | 0.12 | 81 | 7.06E+18 | 66 | 19 |
| Lower Shell Plate | C2800-1 | C2800-1 | SA-302 Gr. B M | 0.11 | 81 | 6.78E+18 | 66 | 18 |
| Lower Shell Plate | C2800-2 | C2800-2 | SA-302 Gr. B M | 0.11 | 119 | 6.78E+18 | 98 | 18 |
| LNB to IS Circ. Weld (100%) | SA-1135 | 61782 | ASA/Linde 80 | 0.25 | 70 | 9.18E+17 | 55 | 22 |
| IS Longit. Weld (Both 100%) | SA-1073 | 1P0962 | ASA/Linde 80 | 0.21 | 70 | 4.91E+18 | 50 | 29 |
| IS to US Circ. Weld (61% ID) | SA-1229 | 71249 | ASA/Linde 80 | 0.26 | 70 | 6.22E+18 | 45 | 36 |
| IS to US Circ. Weld (39% OD) | WF-25 | 299L44 | ASA/Linde 80 | 0.35 | 70 | ---- | -- | -- |
| US Longit. Weld (Both 100%) | SA-1493 | 8T1762 | ASA/Linde 80 | 0.20 | 70 | 5.66E+18 | 49 | 30 |
| US to LS Circ. Weld (100%) | SA-1585 | 72445 | ASA/Linde 80 | 0.21 | 70 | 6.78E+18 | 48 | 32 |
| LS Longit. Weld (100%) | SA-1430 | 8T1762 | ASA/Linde 80 | 0.20 | 70 | 5.71E+18 | 49 | 30 |
| LS Longit. Weld (100%) | SA-1426 | 8T1762 | ASA/Linde 80 | 0.20 | 70 | 5.71E+18 | 49 | 30 |
| LS to Dutch. Circ. Weld (100%) | WF-9 | 72445 | ASA/Linde 80 | 0.21 | 70 | 3.95E+16 | 64 | 9 |
| Regulatory Guide 1.99, Revision 2, Position 2 | | | | | | | | |
| Upper Shell Plate | C3265-1 | C3265-1 | SA-302 Gr. B M | 0.10 | 108 | 7.06E+18 | 91 | 16 |
| LNB to IS Circ. Weld (100%) | SA-1135 | 61782 | ASA/Linde 80 | 0.25 | 70 | 9.18E+17 | 53 | 24 |
| IS to US Circ. Weld (61% ID) | SA-1229 | 71249 | ASA/Linde 80 | 0.26 | 70 | 6.22E+18 | 47 | 33 |
| IS to US Circ. Weld (39% OD) | WF-25 | 299L44 | ASA/Linde 80 | 0.35 | 70 | ---- | -- | -- |
| US to LS Circ. Weld (100%) | SA-1585 | 72445 | ASA/Linde 80 | 0.21 | 70 | 6.78E+18 | 48 | 31 |
| LS to Dutch. Circ. Weld (100%) | WF-9 | 72445 | ASA/Linde 80 | 0.21 | 70 | 3.95E+16 | 64 | 9 |

Oconee Nuclear Station
UFSAR Supplement For License Renewal

Chapter 5 Changes

Table 5-5 Evaluation of Reactor Vessel Extended Life (48 EFPY) Charpy V-Notch Upper-Shelf Energy - Oconee Unit 2

| Material Description | | | | Copper Composition w/o | Initial CvUSE, ft-lbs | 48 EFPY Fluence T/4 Location, n/cm ² | Estimated 48 EFPY CvUSE at T/4 | 48 EFPY % Drop at T/4 |
|---|--------------|-------------|--------------|------------------------|-----------------------|---|--------------------------------|-----------------------|
| Reactor Vessel Beltline Region Location | Matl. Ident. | Heat Number | Type | | | | | |
| Regulatory Guide 1.99, Revision 2, Position 1 | | | | | | | | |
| Lower Nozzle Belt Forging | AMX-77 | 123T382 | A508 Cl.2 | 0.06 | 109 | 6.83E+18 | 94 | 14 |
| Upper Shell Forging | AAW-163 | 3P2359 | A508 Cl.2 | 0.04 | 133 | 7.78E+18 | 117 | 12 |
| Lower Shell Forging | AWG-164 | 4P1885 | A508 Cl.2 | 0.02 | 138 | 7.45E+18 | 124 | 10 |
| LNB to US Circ. Weld (100%) | WF-154 | 406L44 | ASA/Linde 80 | 0.31 | 70 | 6.83E+18 | 42 | 40 |
| US to LS Circ. Weld (100%) | WF-25 | 299L44 | ASA/Linde 80 | 0.35 | 70 | 7.45E+18 | 41 | 41 |
| LS to Dutch. Circ. Weld (100%) | WF-112 | 406L44 | ASA/Linde 80 | 0.31 | 70 | 4.36E+16 | 62 | 12 |
| Regulatory Guide 1.99, Revision 2, Position 2 | | | | | | | | |
| Upper Shell Forging | AAW-163 | 3P2359 | A508 Cl.2 | 0.04 | 133 | 7.78E+18 | 116 | 13 |
| NB to US Circ. Weld (100%) | WF-154 | 406L44 | ASA/Linde 80 | 0.31 | 70 | 6.83E+18 | 45 | 36 |
| US to LS Circ. Weld (100%) | WF-25 | 299L44 | ASA/Linde 80 | 0.35 | 70 | 7.45E+18 | 44 | 37 |
| LS to Dutch. Circ. Weld (100%) | WF-112 | 406L44 | ASA/Linde 80 | 0.31 | 70 | 4.36E+16 | 62 | 11 |

Oconee Nuclear Station
UFSAR Supplement For License Renewal

Chapter 5 Changes

Table 5-6 Evaluation of Reactor Vessel Extended Life (48 EFPY) Charpy V-Notch Upper-Shelf Energy - Oconee Unit 3

| Material Description | | | | Copper Composition w/o | Initial CvUSE, ft-lbs | 48 EFPY Fluence T/4 Location, n/cm ² | Estimated 48 EFPY CvUSE at T/4 | 48 EFPY % Drop at T/4 |
|---|--------------|-------------|--------------|------------------------|-----------------------|---|--------------------------------|-----------------------|
| Reactor Vessel Beltline Region Location | Matl. Ident. | Heat Number | Type | | | | | |
| Regulatory Guide 1.99, Revision 2, Position 1 | | | | | | | | |
| Lower Nozzle Belt Forging | 4680 | 4680 | A508 Cl.2 | 0.13 | 109 | 6.66E+18 | 87 | 20 |
| Upper Shell Forging | AWS-192 | 522314 | A508 Cl.2 | 0.01 | 112 | 7.56E+18 | 102 | 9 |
| Lower Shell Forging | ANK-191 | 522194 | A508 Cl.2 | 0.02 | 144 | 7.28E+18 | 130 | 10 |
| LNB to US Circ. Weld (100%) | WF-200 | 821T44 | ASA/Linde 80 | 0.24 | 70 | 6.66E+18 | 46 | 35 |
| US to LS Circ. Weld (75% ID) | WF-67 | 72442 | ASA/Linde 80 | 0.24 | 70 | 7.28E+18 | 46 | 35 |
| US to LS Circ. Weld (25% OD) | WF-70 | 72105 | ASA/Linde 80 | 0.35 | 70 | ---- | -- | -- |
| LS to Dutch. Circ. Weld (100%) | WF-169-1 | 8T1554 | ASA/Linde 80 | 0.18 | 70 | 4.23E+16 | 64 | 9 |
| Regulatory Guide 1.99, Revision 2, Position 2 | | | | | | | | |
| Upper Shell Forging | AWS-192 | 522314 | A508 Cl.2 | 0.01 | 112 | 7.56E+18 | 95 | 15 |
| Lower Shell Forging | ANK-191 | 522194 | A508 Cl.2 | 0.02 | 144 | 7.28E+18 | 111 | 23 |
| NB to US Circ. Weld (100%) | WF-200 | 821T44 | ASA/Linde 80 | 0.24 | 70 | 6.66E+18 | 55 | 21 |
| US to LS Circ. Weld (25% OD) | WF-70 | 72105 | ASA/Linde 80 | 0.35 | 70 | ---- | -- | -- |

Oconee Nuclear Station UFSAR Supplement For License Renewal

Chapter 9 Changes

Insert new UFSAR Section 9.1.2.5 to read as follows:

9.1.2.5 Boraflex

The spent fuel storage racks contain Boraflex, which is the trade name for a silicon polymer that contains a specified amount of Boron 10 that is used as the neutron absorber to assure that the design basis for criticality control is met through the service life of the racks. The Boraflex is affixed to each of the four exterior sides of the fuel storage cell by means of stainless steel wrappers. Boraflex is used in spent fuel storage racks for the nonproductive absorption of neutrons such that the NRC established acceptance criterion of k_{eff} no greater than 0.95 is maintained.

In the NRC Safety Evaluations approving the use of these racks, the NRC concluded that 'tests under irradiation and at elevated temperatures in borated water indicate that the Boraflex material will not undergo significant degradation during the expected service life of 40 years.' Based on the above information, Duke has conservatively determined that the aging of Boraflex meets the criteria of §54.3 and should be considered as a time-limited aging analysis for the purposes of license renewal.

Oconee has had in place a Boraflex Monitoring Program since the installation of the high density spent fuel storage racks containing Boraflex. This program contains several elements including testing, monitoring, and analysis of the criticality design. Actions are taken as necessary to assure that the NRC established acceptance criterion of k_{eff} no greater than 0.95 is maintained.

The *Spent Fuel Rack Boraflex Monitoring Program* monitors the Boraflex to assure that the required 5% criticality margin is maintained for the lifetime of the spent fuel storage racks. The program includes:

- (1) Periodic neutron attenuation testing of a representative sample of actual Boraflex panel enclosures to established appropriate acceptance criteria;
- (2) Periodic sampling and analysis for silica in the spent fuel cooling water and the trending of results obtained;
- (3) Corrective actions to be taken in the event the Boraflex is no longer capable of maintaining the required subcriticality margin.

Data collection and analysis of Boraflex condition is implemented through Nuclear Generation Department administrative and workplace procedures.

Oconee Nuclear Station
UFSAR Supplement For License Renewal

Chapter 9 Changes

Insert Reference:

- 9-1** *Application for Renewed Operating Licenses for Oconee Nuclear Station, Units 1, 2, and 3, submitted by M. S. Tuckman (Duke) letter dated July 6, 1998 to Document Control Desk (NRC), Docket Nos. 50-269, -270, and -287.*

Oconee Nuclear Station
UFSAR Supplement For License Renewal

Chapter 16 Changes

Revise Figures 1, 2, and 3 of SLC 16.6.2 as follows:

16.6. COMMITMENTS RELATED TO ENGINEERED SAFETY FEATURES (NON-ESF SYSTEMS)

16.6.2 REACTOR BUILDING POST-TENSIONING SYSTEM

See next three pages.

Insert reference:


Application for Renewed Operating Licenses for Oconee Nuclear Station, Units 1, 2, and 3, submitted by M. S. Tuckman (Duke) letter dated July 6, 1998 to Document Control Desk (NRC), Docket Nos. 50-269, -270, and -287.

Oconee Nuclear Station
UFSAR Supplement For License Renewal

Chapter 16 Changes

Appendix 16.6-2
Figure 1
Units 1, 2, and 3

Estimated 60 Year Prescribed Lower Limit
Dome Tendons




Oconee Nuclear Station
UFSAR Supplement For License Renewal

Chapter 16 Changes

Appendix 16.6-2
Figure 2
Units 1, 2, and 3


Estimated 60 Year Prescribed Lower Limit
Hoop Tendons



Oconee Nuclear Station
UFSAR Supplement For License Renewal

Chapter 16 Changes

Appendix 16.6-2
Figure 3
Units 1, 2, and 3



Oconee Nuclear Station
UFSAR Supplement For License Renewal

New Chapter 18

Insert new UFSAR Chapter 18 to read as follows:

18. AGING MANAGEMENT PROGRAMS AND ACTIVITIES

As the current operating license holder for Oconee Nuclear Station, Duke Energy Corporation prepared an Application for Renewed Operating Licenses for Oconee Nuclear Station, Units 1, 2, and 3 (Application) [Reference 18-1]. The complete application included sufficient information for the NRC to complete their technical and environmental reviews and provided the basis for the NRC to make the findings required by §54.29 [Reference 18-2]. Pursuant to the requirements of §54.21(d), the FSAR supplement for the facility must contain a summary description of the programs and activities for managing the effects of aging and the evaluation of time-limited aging analyses for the period of extended operation determined by §54.21 (a) and (c), respectively. Chapter 18 of the Oconee UFSAR fulfills this requirement.

As an aid to the reader, Table 18-1 provides a summary listing of the programs, activities and time-limited aging analyses (TLAA) (topics) required for license renewal that are contained in the Oconee Nuclear Station *UFSAR Supplement for License Renewal*. The first column of Table 18-1 provides an alphabetical listing of these topics. The second column of Table 18-1 indicates whether the topic is a Program/Activity or TLAA. Programs and Activities have been described in Chapter 4 of OLRP-1001 (Exhibit A of the Application.) Topics that are considered to be programs currently exist, will continue through the life of the plant and are well documented.

Topics which are considered to be activities are of three types:

- (1) Individual inspections which currently exist and will continue through the life of the plant;
- (2) Component replacements specifically identified within the Application as required for license renewal of Oconee; and
- (3) New one-time inspections specifically identified within the Application as required for license renewal of Oconee.

TLAA have been described in Chapter 5 of OLRP-1001 (Exhibit A of the Application.)

The third column of Table 18-1 identifies where the description of the Program, Activity, or TLAA is located in the Oconee UFSAR. In some instances, a specification contained in the Oconee Improved Technical Specifications (ITS) pertains to a Program, Activity, or TLAA. In these instances, the ITS location is provided in the fourth column of Table 18-1.

Oconee Nuclear Station
UFSAR Supplement For License Renewal

New Chapter 18

**Table 18-1 Summary Listing of the Changes Contained in the
UFSAR Supplement for License Renewal**

| <i>Topic</i> | <i>Program / Activity or TLAA</i> | <i>UFSAR Location</i> | <i>ITS Location</i> |
|---|---|---------------------------|---|
| New Programs and Activities: <ul style="list-style-type: none"> • Alloy 600 Aging Management Program • Cast Iron Selective Leaching Inspection • Galvanic Susceptibility Inspection • Keowee Air and Gas Systems Inspection • Keowee Oil Sampling Program • Once Through Steam Generator Upper Lateral Support Inspection • Pressurizer Examinations • Preventive Maintenance Activity Assessment • Reactor Building Spray System Inspection • Reactor Coolant Pump Motor Oil Collection System Inspection • Reactor Vessel Internals Aging Management Program • Small Bore Piping Inspection • Treated Water Systems Stainless Steel Inspection | Program/ Activity | 18.1 | |
| Battery Rack Inspections | Program/ Activity | | SR 3.8.1.13, SR 3.8.3.2, SR 3.10.1.10 |
| Boric Acid Wastage Surveillance Program | Program/ Activity | 18.2 | |
| Chemistry Control Program | Program/ Activity | 18.3 | |

Oconee Nuclear Station
UFSAR Supplement For License Renewal

New Chapter 18

**Table 18-1 Summary Listing of the Changes Contained in the
UFSAR Supplement for License Renewal
(continued)**

| <i>Topic</i> | <i>Program / Activity or TLAA</i> | <i>UFSAR Location</i> | <i>ITS Location</i> |
|---|---|---------------------------|-------------------------|
| Coatings Program | Program/ Activity | 3.12 | |
| Containment Inservice Inspection Plan | Program/ Activity | 18.4 | |
| Containment Leak Rate Testing Program | Program/ Activity | | 5.5.2 |
| Containment Liner Plate and Penetrations | TLAA | 3.8.1.5.3 | |
| Containment Post-Tensioning System | TLAA | 3.8.1.5.2, 16.6.2 | |
| Control Rod Drive Mechanism Nozzle and Other Vessel Closure Penetrations Inspection Program | Program/ Activity | 18.5 | |
| Crane Inspection Program | Program/ Activity | 18.6 | |
| Duke Power Five-Year Underwater Inspection of Hydroelectric Dams and Appurtenances | Program/ Activity | 18.7 | |
| Duke Quality Assurance Program | Program/ Activity | 17 | |
| Environmental Qualification of Electrical Equipment | TLAA | 3.11 | |
| Elevated Water Storage Tank Inspection | Program/ Activity | 18.8 | |
| Federal Energy Regulatory Commission (FERC) Five Year Inspections | Program/ Activity | 18.9 | |

Oconee Nuclear Station
UFSAR Supplement For License Renewal

New Chapter 18

**Table 18-1 Summary Listing of the Changes Contained in the
UFSAR Supplement for License Renewal
(continued)**

| <i>Topic</i> | <i>Program / Activity or TLAA</i> | <i>UFSAR Location</i> | <i>ITS Location</i> |
|--|---|---|-------------------------|
| Fire Protection Program | Program/ Activity | 16.9.1, 16.9.2, 16.9.4, 16.9.5 | |
| Heat Exchanger Performance Testing Activities | Program/ Activity | 18.10 | |
| Inservice Inspection Plan | Program/ Activity | 18.11 | |
| Inspection Program for Civil Engineering Structures and Components | Program/ Activity | 18.12 | |
| Penstock Inspection | Program/ Activity | 18.13 | |
| Piping Erosion/Corrosion Program | Program/ Activity | 18.14 | |
| Program to Inspect High Pressure Injection Connections to the Reactor Coolant System | Program/ Activity | 18.15 | |
| Non-Class 1 Piping | TLAA | 3.2.2.2 | |
| Polar Crane | TLAA | 3.13 | |
| Reactor Coolant Pump Flywheel | TLAA | | 5.5.8 |
| Reactor Coolant System Operational Leakage Monitoring | Program/ Activity | | 3.4.13 |
| Reactor Coolant System and Class 1 Components | TLAA | 5.2.1.4 | |

Oconee Nuclear Station
UFSAR Supplement For License Renewal

New Chapter 18

**Table 18-1 Summary Listing of the Changes Contained in the
UFSAR Supplement for License Renewal
(continued)**

| <i>Topic</i> | <i>Program / Activity or TLAA</i> | <i>UFSAR Location</i> | <i>ITS Location</i> |
|---|---|--------------------------------------|-------------------------|
| Reactor Vessel | TLAA | 5.2.3.3.4, 5.2.3.3.6, 5.2.3.13 | |
| Reactor Vessel Integrity Program | Program/ Activity | 18.16 | |
| Reactor Vessel Internals | TLAA | 4.5.1.2 | |
| Service Water Piping Corrosion Program | Program/ Activity | 18.17 | |
| Spent Fuel Rack Boraflex | TLAA | 9.1.2.5 | |
| Steam Generator Tube Surveillance Program | Program/ Activity | | 5.5.10 |
| System Performance Testing Activities | Program/ Activity | 18.18 | |
| Tendon - Secondary Shield Wall - Surveillance Program | Program/ Activity | 18.19 | |
| 230 kV Keowee Transmission Line Inspections | Program/ Activity | 18.20 | |

Oconee Nuclear Station
UFSAR Supplement For License Renewal

New Chapter 18

18.1 NEW PROGRAMS AND ACTIVITIES

The *Oconee Integrated Plant Assessment* for license renewal identified several new programs and activities that currently do not exist, nevertheless are necessary to continue operation of Oconee during the additional 20-years beyond the initial license term. Section 18.1 describes these activities and programs. They are commitments that will be implemented following issuance of the renewed operating licenses for Oconee Nuclear Station.

These commitments will be met prior to the expiration of the initial facility operating license for Oconee Unit 1 (DPR-38), which currently expires at midnight February 6, 2013; of the initial facility operating license for Oconee Unit 2 (DPR-47), which currently expires at midnight October 6, 2013; and of the initial facility operating license for Oconee Unit 3 (DPR-55), which currently expires at midnight July 19, 2014.

Oconee Nuclear Station UFSAR Supplement For License Renewal

New Chapter 18

18.1.1 ALLOY 600 AGING MANAGEMENT PROGRAM

Purpose - The purpose of the Oconee *Alloy 600 Aging Management Program* will be to manage cracking due to PWSCC of Alloy 600 and Alloy 82/182 locations, including the Alloy 82/182 cladding in the hot leg flowmeter element, for the period of extended operation.

Scope - The results of the *Alloy 600 Aging Management Program* will be applicable to the Alloy component 600 material and Alloy 82/182 weld material in the Oconee Reactor Coolant System, including the hot leg flowmeter element. [Footnote 1]

Aging Effects - The applicable aging effect for the scope of the *Alloy 600 Aging Management Program* is primary water stress corrosion cracking (PWSCC) of Alloy 600 components and Alloy 82/182 weld metal in the Reactor Coolant System at Oconee.

Method - The exact inspection method will be dependent on the geometry of the inspection locations. Inspection methods will involve a combination of surface and volumetric examinations which may include eddy current testing, ultrasonic testing, and radiography.

1. Renewal Applicant Action Item in the NRC SER concerning the "Demonstration of the Management of Aging Effects for the Reactor Coolant System Piping," BAW-2243A states that:

"The BWOG defers the development of details of (1) the inspection of the Alloy 82/182 clad hot leg segment and plant selection for that inspection, and (2) the sample inspection of small bore RCS piping, to the renewal applicant referencing this topical report. The renewal applicant will have to provide details of these ... inspection programs in its renewal application for staff review and approval."

Renewal Applicant Action Item 5 in the NRC SER concerning the "Demonstration of the Management of Aging Effects for the Pressurizer," BAW-2244A states that:

"Since the B&WOG defers the development of details of the sample volumetric inspection program of small-bore nozzles and safe ends to the renewal applicant referencing this topical report, the renewal applicant will have to provide details of the additional sample inspection program in its renewal application for staff review and approval."

[Reference Chapter 2.4 of OLRP-1001, Table 2.4-2].

The *Alloy 600 Aging Management Program* is intended to address these Renewal Applicant Action Items regardless of whether or not the hot leg segment is included in the inspection locations selected.

Oconee Nuclear Station UFSAR Supplement For License Renewal

New Chapter 18

Sample Size - To determine the initial inspection locations, the Oconee *Alloy 600 Aging Management Program* will, first, complete a susceptibility study of Alloy 600 components and Alloy 82/182 weld locations in the Reactor Coolant System. Upon completion and validation of this susceptibility study, the top three or four locations will have detailed inspection plans developed and implemented to monitor the condition of these locations. Monitoring the most susceptible locations will bound the Alloy 600 component locations and the Alloy 82/182 weld locations that are not inspected.

Industry Code or Standards - ASME Section XI, 1989 Edition, including mandatory Appendices VII and VIII (Appendix VIII in accordance with 1989 Addenda).

Frequency - The frequency will be based on findings of the initial inspections. An analysis will be completed at each of the selected locations that will determine crack propagation rates. The time for an indication to grow from a newly initiated indication to a through wall crack will determine the inspection frequency.

Acceptance Criteria or Standard - Acceptance criteria for identified flaws will be based on crack propagation rates, which vary from location to location based on the calculated residual and operating stresses for the particular location using approved fracture mechanics techniques. In past inspections, after measuring the depth of the indications, small cracks have been allowed to remain in service without immediate repair when the calculated crack growth rate plus the measured depth of the indication predicted no through wall leak (or other acceptance criteria agreed to by the NRC) will occur prior to corrective action being taken or the crack otherwise being dispositioned.

Corrective Action - Corrective actions will be developed and implemented on a case-by-case basis at Oconee depending on the nature of the inspection findings. A complete, full replacement or a repair in accordance with ASME Section XI may be appropriate for some locations. Taking no immediate action on the indication and monitoring with further inspections may also be appropriate.

Both the sample size and number of locations will be re-evaluated following the completion of each inspection with documentation of these re-evaluations completed on an annual basis once the inspections begin. Additional inspection locations may be added to the list based on a qualitative assessment of risk.

Specific corrective actions will be implemented in accordance with the *Duke Quality Assurance Program*.

Oconee Nuclear Station UFSAR Supplement For License Renewal

New Chapter 18

Timing of New Program or Activity - Following issuance of a renewed operating licenses for Oconee Nuclear Station, this inspection will be completed by February 6, 2103 (the end of the initial license term for Oconee Unit 1).

Administrative Controls - The *Alloy 600 Aging Management Program* will be implemented by plant procedures in accordance with the *Duke Quality Assurance Program*.

Regulatory Basis - BAW-2243A, [Reference 18-3] and BAW-2244A, Action Item 5 [Reference 18-4] [Footnote 1].

1. Renewal Applicant Action Item in the NRC SER concerning the “Demonstration of the Management of Aging Effects for the Reactor Coolant System Piping,” BAW-2243A states that:

“The BWOG defers the development of details of (1) the inspection of the Alloy 82/182 clad hot leg segment and plant selection for that inspection, and (2) the sample inspection of small bore RCS piping, to the renewal applicant referencing this topical report. The renewal applicant will have to provide details of these ... inspection programs in its renewal application for staff review and approval.”

Renewal Applicant Action Item 5 in the NRC SER concerning the “Demonstration of the Management of Aging Effects for the Pressurizer,” BAW-2244A states that:

“Since the B&WOG defers the development of details of the sample volumetric inspection program of small-bore nozzles and safe ends to the renewal applicant referencing this topical report, the renewal applicant will have to provide details of the additional sample inspection program in its renewal application for staff review and approval.”

[Reference Chapter 2.4 of OLRP-1001, Table 2.4-2].

The *Alloy 600 Aging Management Program* is intended to address these Renewal Applicant Action Items regardless of whether or not the hot leg segment is included in the inspection locations selected.

Oconee Nuclear Station UFSAR Supplement For License Renewal

New Chapter 18

18.1.2 CAST IRON SELECTIVE LEACHING INSPECTION

Purpose - The purpose of the *Cast Iron Selective Leaching Inspection* will be to characterize loss of material due to selective leaching for cast iron components in Oconee raw water, treated water, and underground environments.

Scope - The results of this inspection will be applicable to the cast iron components falling within the scope of license renewal. These components include pump casings in several systems along with piping, valves and other components. As identified in Sections 3.5.3 through 3.5.14, the Oconee raw and treated water systems containing cast iron components potentially susceptible to loss of material due to selective leaching are the Auxiliary Service Water System, the Condensate System, the Condenser Circulating Water System, the Service Water System (Keowee), and the High Pressure Service Water System.

Aging Effects - The inspection will determine the existence of loss of material due to selective leaching, a form of galvanic corrosion and assess the likelihood of the impact of this aging effect on the component intended function. Selective leaching is the dissolution of iron at the metal surface that leaves a weakened network of graphite and iron corrosion products.

Method - The *Cast Iron Selective Leaching Inspection* will inspect a select set of cast iron pump casings to determine whether selective leaching of the iron has been occurring at Oconee and whether loss of material due to selective leaching will be an aging effect of concern for the period of extended operation. A Brinnell Hardness check will be performed on the inside surface of a select set of cast iron pump casings to determine if this phenomenon is occurring. The results of the *Cast Iron Selective Leaching Inspection* will be applicable to all cast iron components within license renewal scope and installed in applicable environments.

Sample Size - Five pump casings will be inspected for evidence of selective leaching, one from each of the following systems on-site:

- Auxiliary Service Water System
- Condensate System
- High Pressure Service Water System
- Service Water System (Keowee)
- Condensate System (one inspection location on any of the three Oconee Units.)

Oconee Nuclear Station
UFSAR Supplement For License Renewal

New Chapter 18

Industry Codes or Standards - No specific codes or standards exist to address this inspection.

Frequency - The *Cast Iron Selective Leaching Inspection* is a one-time inspection.

Acceptance Criteria or Standard - No unacceptable indication of loss of material due to selective leaching as determined by engineering analysis. Component wall thickness acceptability will be judged in accordance with the Oconee component design code of record.

Corrective Action - Any unacceptable loss of material due to selective leaching requires an engineering analysis be performed to determine potential impact on component intended function.

Specific corrective actions will be implemented in accordance with the *Duke Quality Assurance Program*.

Timing of New Program or Activity - Following issuance of renewed operating licenses for Oconee Nuclear Station, this inspection will be completed by February 6, 2013 (the end of the initial license of Oconee Unit 1).

Administrative Controls - The *Cast Iron Selective Leaching Inspection* will be implemented by plant procedures in accordance with the *Duke Quality Assurance Program*.

Regulatory Basis - This one-time inspection activity has no current regulatory basis.

Oconee Nuclear Station UFSAR Supplement For License Renewal

New Chapter 18

18.1.3 GALVANIC SUSCEPTIBILITY INSPECTION

Purpose - The purpose of the *Galvanic Susceptibility Inspection* will be to characterize the loss of material by galvanic corrosion in carbon steel - stainless steel couples in the Oconee raw water systems.

Scope - The results of this inspection will be applicable to all galvanic couples with the focus on the carbon steel - stainless steel couples in the Oconee raw water systems falling within the scope of license renewal.

Aging Effects - The inspection will determine the existence of loss of material due to galvanic corrosion and assess the likelihood of the impact of this aging effect on the component intended function.

Method - A volumetric examination at the junction of the carbon steel - stainless steel components is needed to determine material loss from the more anodic carbon steel. At the time of Application, a destructive examination of the more susceptible locations chosen to be the sentinel population would be an acceptable examination method. Other volumetric techniques may also be effective with the exact method of examination to be selected at the time of inspection.

Sample Size - A sentinel population of the more susceptible locations on all three Oconee units, Keowee, and Standby Shutdown Facility will be selected for this inspection from the following raw water systems within the scope of license renewal.

- Auxiliary Service Water System
- Condensate System (raw water portions of the Condensate Cooler and Main Condenser within the scope of license renewal)
- Condenser Circulating Water System
- High Pressure Service Water System
- Low Pressure Injection (raw water portion of the Decay Heat Removal Cooler)
- Low Pressure Service Water System
- Service Water System (Keowee)
- Turbine Generator Cooling Water System (Keowee)
- Turbine Sump Pump System (Keowee)
- Standby Shutdown Facility Auxiliary Service Water System

Oconee Nuclear Station UFSAR Supplement For License Renewal

New Chapter 18

Areas of low to stagnant flow in Oconee raw water systems which contain carbon steel - stainless steel couples are the most susceptible locations. Engineering practice at Duke has been to use stainless steel as a replacement material in raw water systems for several years. Since engineering practice will continue to use stainless steel as an acceptable substitute material, the size of the sentinel population will be dependent on the number of susceptible locations at the time of the inspection.

Industry Codes or Standards - No code or standard exists to guide or govern this inspection. Component wall thickness acceptability will be judged in accordance with the Oconee component design code of record.

Frequency - The *Galvanic Susceptibility Inspection* is a one-time inspection.

Acceptance Criteria or Standard - No unacceptable indication of loss of material due to galvanic corrosion as determined by engineering analysis.

Corrective Action - Any unacceptable loss due of material due to galvanic corrosion requires that an engineering analysis be performed to determine potential impact on component intended function.

Specific corrective actions will be implemented in accordance with the *Duke Quality Assurance Program*.

Timing of New Program or Activity - Following issuance of renewed operating licenses for Oconee Nuclear Station, this inspection will be completed by February 6, 2013 (the end of the initial license of Oconee Unit 1).

Administrative Controls - The *Galvanic Susceptibility Inspection* will be implemented by plant procedures in accordance with the *Duke Quality Assurance Program*.

Regulatory Basis - This inspection has no current regulatory basis.

Oconee Nuclear Station UFSAR Supplement For License Renewal

New Chapter 18

18.1.4 KEOWEE AIR AND GAS SYSTEMS INSPECTION

Purpose - The purpose of the *Keowee Air and Gas Systems Inspection* will be to characterize the loss of material due to general corrosion of the carbon steel components within the Carbon Dioxide, Depressing Air, and Governor Air Systems at Keowee that may be exposed to condensation.

Scope - The results of this inspection will be applicable to the carbon steel components within the license renewal portion of the Carbon Dioxide, Depressing Air, and Governor Air Systems on each unit at Keowee.

Aging Effects - The inspection will determine the existence of loss of material due to general corrosion of carbon steel components in the Carbon Dioxide, Depressing Air, and Governor Air Systems. The inspection will assess the likelihood of the impact of this aging effect on the component intended function.

Method - An inspection of select portions of the each system will determine whether loss of material due to general corrosion will be an aging effect of concern for the period of extended operation. The results *Keowee Air and Gas Systems Inspection* will determine the need for additional programmatic oversight to manage this aging effect.

For the Carbon Dioxide System, the discharge piping low elevation point will be determined. A volumetric examination will be conducted on a portion of carbon steel pipe in and around this low point of the Carbon Dioxide System.

For the Depressing Air System, a volumetric examination will be conducted on a portion of piping between the control valves and the Keowee unit turbine head cover.

For the Governor Air System, a visual examination of the bottom half of the interior surface of the air receiver tanks will determine the presence of corrosion. The visual examination will also serve to characterize any instance of corrosion. Piping between the air receiver tank and the governor oil pressure tank will receive a volumetric examination.

Sample Size - For the Carbon Dioxide System, the inspection will include four feet of pipe around the system low elevation point (two feet upstream and downstream).

For the Depressing Air System, the inspection will include one of the two four-foot sections of piping between the control valves and the Keowee unit headcover.

Oconee Nuclear Station
UFSAR Supplement For License Renewal

New Chapter 18

For the Governor Air System, the inspection will include the lower half of each Air Receiver Tank and one of the two four-foot sections of the piping between the air receiver tanks and the governor oil pressure tanks.

Industry Code or Standards - No code or standard exists to guide or govern this inspection.

Frequency - The *Keowee Air and Gas Systems Inspection* is a one-time inspection.

Acceptance Criteria or Standard - No unacceptable indication of loss of material due to corrosion as determined by engineering analysis. Component wall thickness acceptability will be judged in accordance with the component design code of record.

Corrective Action - Any unacceptable indication of loss of material due to corrosion will require that an engineering analysis be performed to determine proper corrective action.

Specific corrective actions will be implemented in accordance with the *Duke Quality Assurance Program*.

Timing of New Program or Activity - Following issuance of renewed operating licenses for Oconee Nuclear Station, this inspection will be completed by February 6, 2013 (the end of the initial license of Oconee Unit 1).

Administrative Controls - The *Governor Air System Inspection* will be implemented by plant procedures in accordance with the *Duke Quality Assurance Program*.

Regulatory Basis - This inspection has no current regulatory basis.

Oconee Nuclear Station
UFSAR Supplement For License Renewal

New Chapter 18

18.1.5 KEOWEE OIL SAMPLING PROGRAM

Purpose - The purpose of the *Keowee Oil Sampling Program* will be to monitor and control the water contamination levels in the Governor Oil System to preclude loss of material for the carbon steel and stainless steel components in the scope of license renewal. In addition, the *Keowee Oil Sampling Program* will manage loss of material of the stainless steel subcomponents in the Turbine Guide Bearing Oil System by monitoring the Turbine Guide Bearing Oil System for water contamination.

Scope - The scope of the *Keowee Oil Sampling Program* includes all carbon steel and stainless steel components within the scope of license renewal in the Governor Oil System and the turbine guide bearing oil coolers, the only stainless steel component of concern in the Turbine Guide Bearing Oil System. This program will contain elements which cover all four Keowee oil systems and, as such, is intended to cover a broader scope than is being credited for license renewal.

Aging Effects - Water contamination in the Governor Oil System can expose the carbon steel and stainless steel components to conditions conducive to loss of material due to various forms of corrosion. Water contamination in the Turbine Guide Bearing Oil System is evidence of leakage of the Turbine Guide Bearing Oil Cooler from loss of material due to microbiologically influenced corrosion. Monitoring and controlling water contamination precludes this applicable aging effect in the Governor Oil System and manages this applicable aging effect in the Turbine Guide Bearing Oil Coolers.

Method - The *Keowee Oil Sampling Program* will require that the Governor Oil System Sump and Turbine Guide Bearing Oil System reservoirs be sampled for the presence of water contamination.

Sample Size - This criteria is not applicable, since relevant conditions are being monitored and not system hardware.

Industry Codes or Standards - ASTM D95-83, *Water in Petroleum and Bitumens*, provides guidance for the testing of the oil sample.

Frequency - Oil samples will be taken and analyzed every six months. Results of the analysis will be monitored and trended.

Oconee Nuclear Station
UFSAR Supplement For License Renewal

New Chapter 18

Acceptance Criteria or Standard - No water contamination in excess of 0.1% water by volume will be the limit for water contamination in the Governor Oil System and Turbine Guide Bearing Oil System.

Corrective Action - If water contamination levels exceed the acceptance criteria, the accountable engineer will be notified and the source of the water contamination will be located and corrected. The contaminated oil will be sent to the plant oil purifier to remove the water and returned to the system.

Specific corrective actions will be made in accordance with the *Duke Quality Assurance Program*.

Timing of New Program or Activity - Following issuance of a renewed operating license for Oconee Nuclear Station, the *Keowee Oil Sampling Program* will be implemented by February 6, 2013 (the end of the initial license term for Oconee Unit 1).

Administrative Control - The *Keowee Oil Sampling Program* will be implemented by plant procedures in accordance with the *Duke Quality Assurance Program*.

Regulatory Basis - This program has no current regulatory basis.

Oconee Nuclear Station
UFSAR Supplement For License Renewal

New Chapter 18

18.1.6 ONCE THROUGH STEAM GENERATOR UPPER LATERAL SUPPORT INSPECTION

Purpose - The purpose of the *OTSG Upper Lateral Support Inspection* is to determine whether cracking of the OTSG upper lateral support lubrite pads has occurred and to validate that the condition of the lubrite pads is acceptable for the period of extended operation.

Scope - The results of this inspection will be applicable to all thirty lubrite pads installed at Oconee (ten per unit).

Aging Effects - The applicable aging effect is cracking of the lubrite pads by gamma irradiation.

Method - A visual inspection of the accessible surfaces of a sample population of lubrite pads will be performed to determine if the pads are cracking.

Sample Size - The sample size will be five lubrite pads on one OTSG upper lateral support.

Industry Codes or Standards - No code or standard exists to guide or govern this inspection.

Frequency - The *OTSG Upper Lateral Support Inspection* is a one-time inspection.

Acceptance Criteria or Standard - No cracks in the lubrite pads.

Corrective Action - If the sample lubrite pads are cracked, then the affected pads must be replaced and the remaining 25 lubrite pads must be inspected. Lubrite pads that are cracked will be replaced with new pads.

Timing of New Program or Activity - Following issuance of renewed operating licenses for Oconee Nuclear Station, this inspection will be completed by February 6, 2013 (the end of the initial license of Oconee Unit 1).

Administrative Controls - The *OTSG Upper Lateral Support Inspection* will be implemented in accordance with written procedures as required by the *Duke Quality Assurance Program*.

Regulatory Basis - This one-time inspection has no current regulatory basis.

Oconee Nuclear Station
UFSAR Supplement For License Renewal

New Chapter 18

18.1.7 PRESSURIZER EXAMINATIONS

18.1.7.1 Pressurizer Cladding, Internal Spray Line, and Spray Head Examination

The *Pressurizer Cladding, Internal Spray Line, and Spray Head Examination* will have the following attributes.

Purpose - The purpose of the *Pressurizer Cladding, Internal Spray Line, and Spray Head Examination* will be to assess the condition of the pressurizer cladding, internal spray line, and spray head.

Scope - The scope of this activity will include the cladding and attachment welds to the cladding of all three pressurizers at the Oconee units and to the internal spray line and spray head of all three pressurizers at the Oconee units, including the fasteners that connect the spray line and spray head to the internal surface of the pressurizer.

Aging Effects - The aging effects of concern are cracking of cladding by thermal fatigue, which may propagate to the underlying ferritic steel. Cracking of the internal spray line by fatigue and cracking of the spray head due to reduction of fracture toughness are also aging effects.

Method - Visual examination (VT-3) of the clad inside surfaces of the pressurizer (100% coverage of the accessible surface) including attachment welds to the pressurizer will be performed. Historical data (Haddam Neck) indicates cracking may occur adjacent to the heater bundles, if at all. Therefore, the examination will focus on cladding adjacent to the heater bundles. In addition, visual inspections have been shown to be adequate for detecting cracks in cladding at Haddam Neck; cracking that extended to underlying ferritic steel was found due to the observance of rust.

Visual examination (VT-3) of the internal spray line and spray head, including the fasteners that are used to attach the spray line to the internal surface of the pressurizer will also be performed.

Sample Size - The examination will be performed on the cladding (100% coverage of the accessible surface), spray head, and internal spray line of one pressurizer at Oconee.

Industry Code or Standards - ASME Section XI, 1989 Edition, including mandatory Appendices VII and VIII (Appendix VIII in accordance with 1989 Addenda).

Oconee Nuclear Station
UFSAR Supplement For License Renewal

New Chapter 18

Frequency - The *Pressurizer Cladding, Internal Spray Line, and Spray Head Examination* is a one-time inspection.

Acceptance Criteria or Standard - Acceptance standards for visual examinations will be in accordance with ASME Section XI VT-3 examinations.

Corrective Action - If cracks are detected in the cladding that extend to the underlying ferritic steel, acceptance standards for Examination Categories B-B and B-D may be applicable to subsequent volumetric examination of ferritic steel.

If cracks are detected in the internal spray piping, acceptance standards for Examination Category B-J may be applied. If cracks are detected in the spray head, engineering analysis will determine corrective actions that could include replacement of the spray head.

The need for subsequent examinations will be determined after the results of the initial examination are available.

Specific corrective actions will be implemented in accordance with the *Duke Quality Assurance Program*.

Timing of New Program or Activity - Following issuance of renewed operating licenses for Oconee Nuclear Station, this inspection will be completed by February 6, 2013 (the end of the initial license of Oconee Unit 1).

Administrative Controls - Inspections and engineering evaluations will be performed in accordance with the *Duke Quality Assurance Program*.

Regulatory Basis - Renewal Applicant Action Item 4.2 (1) in the Safety Evaluation for BAW-2244A (See Table 2.4-3 of OLRP-1001).

Oconee Nuclear Station
UFSAR Supplement For License Renewal

New Chapter 18

18.1.7.2 Pressurizer Heater Bundle Penetration Welds Examination

The *Pressurizer Heater Bundle Penetration Welds Examination* will have the following attributes.

Purpose - This purpose of the *Pressurizer Heater Bundle Penetration Welds Examination* will be to assess the condition of the pressurizer heater penetration welds.

Scope - The results of this examination will be applicable to the heater sheath-to-sleeve or heater sheath-to-diaphragm plate penetration welds for the pressurizer heater bundles. Each pressurizer contains three heater bundles.

Aging Effects - The aging effect of concern is cracking at heater bundle penetration welds which may lead to coolant leakage.

Method - For the heater bundle that is removed, a surface examination of sixteen peripheral welds on one bundle will be performed. A visual examination (VT-3 or equivalent) of the remaining welds of the heater bundle will be performed. [Footnote 1]

Sample Size - The examination will include sixteen peripheral heater penetration welds on one heater bundle in one of the Oconee units, whichever heater bundle is removed first.

Industry Code or Standards - ASME Section XI, 1989 Edition, including mandatory Appendices VII and VIII (Appendix VIII in accordance with 1989 Addenda).

Frequency - The *Pressurizer Heater Bundle Penetration Welds Examination* is a one-time inspection.

Acceptance Criteria or Standard - Acceptance standards for surface examinations and visual examination (VT-3) will be in accordance with ASME Section XI.

Corrective Action - If the results of the inspection are not acceptable, then the results may be used as a baseline inspection for establishing a longer term programmatic action covering all Oconee pressurizer heater bundles.

-
1. The Oconee *Inservice Inspection Plan* for the 5th inservice inspection interval will include pressurizer heater bundle welds under Examination Category B-E or equivalent. (See Section 18.11)
-

Oconee Nuclear Station
UFSAR Supplement For License Renewal

New Chapter 18

Specific corrective actions will be implemented in accordance with the *Duke Quality Assurance Program*.

Timing of New Program or Activity - The surface examinations of the sixteen peripheral heater penetration welds will be performed upon removal of a pressurizer heater bundle.

Administrative Controls - Inspections and engineering evaluations will be performed in accordance with the *Duke Quality Assurance Program*.

Regulatory Basis - Renewal Applicant Action Item 4.2 (2) in the Safety Evaluation for BAW-2244A (See Table 2.4-3 of OLRP-1001).

Oconee Nuclear Station UFSAR Supplement For License Renewal

New Chapter 18

18.1.8 PREVENTIVE MAINTENANCE ACTIVITY ASSESSMENT

Purpose - The purpose of the *Preventive Maintenance Activity Assessment* will be to assess the effectiveness of existing plant maintenance activities identified in Table 18-2.

Scope - The *Preventive Maintenance Activity Assessment* will include an assessment of the effectiveness of the maintenance activities listed in Table 18-2.

Aging Effects - The applicable aging effects that have been identified for license renewal are listed in Table 18-2.

Method - The *Preventive Maintenance Activity Assessment* will be conducted in accordance with the requirements for performing self-assessments as described in Chapter 17.3.3, *Self Assessments*, of the *Duke Quality Assurance Program Topical Report*.

Sample Size - Each of the above maintenance activities will be assessed.

Industry Codes or Standards - No code or standard exist to guide or govern this assessment.

Frequency - The *Preventive Maintenance Activity Assessment* is a one-time assessment.

Acceptance Criteria or Standard - The *Duke Quality Assurance Program*.

Corrective Action - The maintenance activities identified in Table 18-2 are effective in managing the aging effects and that the component intended functions are being maintained under all current licensing basis conditions for the period of extended operation. If the *Preventive Maintenance Activity Assessment* determines that enhancements to one or more of the maintenance activities listed in Table 18-2 are required, then corrective actions will be implemented.

Specific corrective actions will be implemented in accordance with the *Duke Quality Assurance Program*.

Timing of New Program or Activity - Following issuance of renewed operating licenses for Oconee Nuclear Station, this inspection will be completed by February 6, 2013 (the end of the initial license of Oconee Unit 1).

Administrative Controls - The *Preventive Maintenance Activity Assessment* will be

Oconee Nuclear Station
UFSAR Supplement For License Renewal

New Chapter 18

implemented by plant procedures in accordance with the *Duke Quality Assurance Program*.

Regulatory Basis - 10 CFR §50.65, *Requirements for monitoring the effectiveness of maintenance at nuclear power plants*.

Oconee Nuclear Station
UFSAR Supplement For License Renewal

New Chapter 18

Table 18-2 Preventive Maintenance Activities

| Preventive Maintenance Activity | Aging Effect |
|---|---|
| Auxiliary Service Water Piping Inspection | Fouling due to macro-organisms and silting has been identified as an applicable aging effect for specific portions of the Auxiliary Service Water System piping that can not be periodically tested. |
| Borated Water Storage Tank Internal Coatings Inspection | Loss of material due to general and localized corrosion has been identified as an applicable aging effect for the carbon steel borated water storage tank in the Low Pressure Injection System. |
| Component Cooler Tubing Examination | Loss of material due to general and pitting corrosion of the brass tubes exposed to raw water has been identified as an applicable aging effect for the component cooler tubing in the Component Cooling System. |
| Condensate Cooler Tubing Examination | Loss of material due to pitting corrosion of the stainless steel tubes exposed to raw water has been identified as an applicable aging effect for the condensate coolers in the Condensate System. |
| Condenser Circulating Water System Internal Coatings Inspection | Condenser Circulating Water System Internal Coatings - Loss of material due to general and localized corrosion has been identified as applicable aging effect for the underground Condenser Circulating Water System piping. |
| Decay Heat Cooler Tubing Examination | Loss of material due to pitting corrosion and microbiologically influenced corrosion of the stainless steel tubes exposed to raw water has been identified as an applicable aging effect for the decay heat coolers in the Low Pressure Injection System. |
| Main Condenser Tubing Examination | Loss of material due to pitting corrosion and microbiologically influenced corrosion of the stainless steel tubes exposed to raw water has been identified as an applicable aging effect for the main condenser in the Condensate System. |
| Reactor Building Cooling Unit Tubing Inspection | Loss of material due to general and localized corrosion of the tube side exposed to raw water and localized corrosion due to galvanic corrosion and boric acid wastage of the copper alloy tubing has been identified as applicable aging effects for the cooling units in the Reactor Building Cooling System. |
| Standby Shutdown Facility Diesel Fuel Oil Tank Inspection | Loss of material due to general and localized corrosion of the carbon steel Standby Shutdown Facility Fuel Oil Tank has been identified as applicable aging effects for the external surfaces. |
| Turbine Generator Cooling Water System Strainer Inspection | Loss of material due to general and localized corrosion has been identified as an applicable aging effect for the carbon steel strainers in the Turbine Generator Cooling Water System. |

Oconee Nuclear Station
UFSAR Supplement For License Renewal

New Chapter 18

18.1.9 REACTOR BUILDING SPRAY SYSTEM INSPECTION

Purpose - The purpose of *Reactor Building Spray System Inspection* will be to characterize the loss of material due to pitting corrosion and cracking due to stress corrosion of stainless steel components within the Reactor Building Spray System periodically exposed to an borated water environment that is not monitored.

Scope - The results of this inspection will be applicable to stainless steel piping and components downstream of the containment isolation valves BS-1 and BS-2 toward their respective spray headers, a total of two lines per Oconee unit. Because the piping is open to the Reactor Building environment, unmonitored conditions exist in any borated water which may be entrapped downstream of these valves.

Aging Effects - The inspection will determine the existence of loss of material due to pitting corrosion and cracking due to stress corrosion of stainless steel piping due to the periodic presence of borated water in the Reactor Building Spray piping open to the Reactor Building environment. The inspection will assess the likelihood of the impact of these aging effects on the component intended function.

Method - An inspection of a select set of stainless steel piping locations will determine whether loss of material due to pitting corrosion and cracking due to stress corrosion have been occurring and whether further programmatic aging management will be required to manage these effects for license renewal. The length of susceptible piping will be determined. A volumetric examination of a length of the susceptible piping locations will be conducted for this inspection. This examination will include a stainless steel weld and heat affected zone, if available, since this is a more likely location for stress corrosion cracking to occur.

Sample Size - The inspection will include one of the six susceptible locations. The inspection locations are the piping between valves BS-1 and BS-2 and the normally open drain valves BS-15 and BS-20. If no parameters are known that would distinguish the susceptible locations, one location of the six available locations will be examined.

Industry Code or Standards - No code or standard exists to guide or govern this inspection. Component wall thickness acceptability will be judged in accordance with the Oconee component design code of record.

Frequency - The *Reactor Building Spray System Inspection* is a one-time inspection.

Oconee Nuclear Station
UFSAR Supplement For License Renewal

New Chapter 18

Acceptance Criteria or Standard - No unacceptable indication of loss of material due to pitting corrosion or cracking due to stress corrosion as determined by engineering analysis.

Corrective Action - Any unacceptable indication of loss of material due to pitting corrosion or cracking or cracking due to stress corrosion will require that an engineering analysis be performed to determine proper corrective action.

Specific corrective actions will be implemented in accordance with the *Duke Quality Assurance Program*.

Timing of New Program or Activity - Following issuance of renewed operating licenses for Oconee Nuclear Station, this inspection will be completed by February 6, 2013 (the end of the initial license of Oconee Unit 1).

Administrative Controls - The *Reactor Building Spray System Inspection* will be implemented by plant procedures in accordance with the *Duke Quality Assurance Program*.

Regulatory Basis - This one-time inspection activity has no current regulatory basis.

Oconee Nuclear Station
UFSAR Supplement For License Renewal

New Chapter 18

18.1.10 REACTOR COOLANT PUMP MOTOR OIL COLLECTION SYSTEM INSPECTION

Purpose - The purpose of the *Reactor Coolant Pump Motor Oil Collection System Inspection* will be to characterize the loss of material due to general and localized corrosion of the carbon steel, copper alloy and stainless steel components in the Reactor Coolant Pump Motor Oil Collection System that may periodically be exposed to water.

Scope - The results of this inspection will be applicable to the components in the system, particularly the lower portions of the system, with the potential to be exposed to water. Each Oconee unit has four Reactor Coolant Pump Oil Collection Tanks for a total population of twelve at Oconee.

Aging Effects - The inspection will determine the existence of loss of material due to general and galvanic corrosion for the carbon steel component materials and pitting and crevice corrosion for the carbon steel, copper alloys and stainless steel component materials as a result of periodic exposure to water.

Method - An inspection of several of the Reactor Coolant Pump Motor Oil Collection System Tanks will determine whether loss of material due to general and localized corrosion will be an aging effect of concern for the period of extended operation. The evidence gained from the tank examinations will be indicative of the condition of all materials in the lower portion of the system.

A visual examination on the bottom half of the interior surface of the tank will be performed to determine the presence of corrosion. The visual examination will also serve to characterize any instances of corrosion, both general and localized. A volumetric examination will then be conducted on any problematic areas to determine the condition of the lower portions of the tank which is a leading indicator of the other susceptible components.

Sample Size - The inspection will include one of the twelve Reactor Coolant Pump Motor Oil Collection System Tanks.

Industry Code or Standards - No code or standard exists to guide or govern this inspection.

Frequency - The *Reactor Coolant Pump Motor Oil Collection System Inspection* is a one-time inspection.

Oconee Nuclear Station
UFSAR Supplement For License Renewal

New Chapter 18

Acceptance Criteria - No unacceptable indication of loss of material due to various forms of corrosion as determined by engineering analysis. Component wall thickness acceptability will be judged in accordance with the Oconee component design code of record.

Corrective Action - Any unacceptable indication of loss of material due to various forms of corrosion will require that an engineering analysis be performed to determine proper corrective action.

Timing of New Program or Activity - Following issuance of renewed operating licenses for Oconee Nuclear Station, this inspection will be completed by February 6, 2013 (the end of the initial license of Oconee Unit 1).

Administrative Controls - The *Reactor Coolant Pump Motor Oil Collection System Inspection* will be implemented by plant procedures in accordance with the *Duke Quality Assurance Program*.

Regulatory Basis - This one-time inspection activity has no current regulatory basis.

Oconee Nuclear Station
UFSAR Supplement For License Renewal

New Chapter 18

18.1.11 REACTOR VESSEL INTERNALS AGING MANAGEMENT PROGRAM

Duke proposes an Oconee *Reactor Vessel Internals Aging Management Program* which may include the following activities:

- (a) Continue the characterization of the potential aging effects that have been identified in BAW-2248, *Demonstration of the Management of Aging Effects for the Reactor Vessel Internals* [Reference 18-5]. The scope of the characterization includes, but is not limited to, the development of key program elements to address the following aging effects: cracking, reduction of fracture toughness, and loss of closure integrity.
- (b) After the characterization of aging effects and prior to midnight February 6, 2013, Duke will develop an appropriate monitoring and inspection program, with attributes as defined in Section 4.2. This monitoring and inspection program will provide additional assurance that the reactor vessel internals will remain functional through the period of extended operation.

Oconee Nuclear Station UFSAR Supplement For License Renewal

New Chapter 18

18.1.12 SMALL BORE PIPING INSPECTION

Purpose - The purpose of the *Small Bore Piping Inspection* will be to validate that service-induced weld cracking is not occurring in the small bore Reactor Coolant System piping that does not receive a volumetric examination under ASME Section XI.

Scope - The scope of *Small Bore Piping Inspection* includes the Oconee ISI [Footnote 1] Class A piping welds in lines less than 4 inch NPS [Footnote 2] including pipe, fittings, and branch connections.

Aging Effects - The aging effect being investigated is cracking of piping welds which may not be fully managed by the current ASME Section XI examinations. For Duke, these inspections are driven by the consequences of small bore piping failures rather than a lack of confidence in the current inservice inspection techniques to manage aging. In many instances, small bore piping cannot be isolated from the Reactor Coolant System and a leak could lead to a SBLOCA [Footnote 3] and plant shutdown.

Method - Selected inspection locations will receive either a destructive or non-destructive examination that permits inspection of the inside surface of the piping.

Sample Size - Pipe, fittings, and branch connections over the entire small bore size range will be considered for inspection. The total population of welds will be determined by summing the number of welds found in scope. To determine the inspection locations from this total population of welds, risk-informed approaches will be used to identify locations most susceptible to cracking. Susceptibility will be determined either qualitatively (i.e., based on site and industry experience, evaluation of current ASME Section XI inspection requirements and results, and any applicable regulatory initiatives) or quantitatively, or both. The consequences of weld failure, without respect to susceptibility, also will be evaluated to identify the most safety significant piping welds. After the evaluation of susceptibility and consequences, a list of potential inspection locations will be developed. Actual inspection locations will be selected based on physical accessibility, exposure levels, and the likelihood of meaningful results if a non-destructive technique is employed.

Industry Code or Standards - No code or standard exists to guide or govern this inspection. ASME Section XI provides rules for this piping, but not for volumetric or

-
1. ISI = Inservice Inspection
 2. NPS = Nominal Pipe Size
 3. SBLOCA = Small Break Loss of Coolant Accident
-

Oconee Nuclear Station UFSAR Supplement For License Renewal

New Chapter 18

destructive examination. If destructive examination is employed, the Section XI rules for Repair and Replacement will be used to return piping to its original condition.

Frequency - The *Small Bore Piping Inspection* is a one-time inspection.

Acceptance Criteria or Standard - No unacceptable indication of cracking of piping welds as determined by engineering analysis.

Corrective Action - Any unacceptable indication of cracking of piping welds requires an engineering analysis be performed to determine proper corrective action.

Specific corrective actions will be implemented in accordance with the *Duke Quality Assurance Program*.

Timing of New Program or Activity - Following issuance of a renewed operating licenses for Oconee Nuclear Station, this inspection will be completed by February 6, 2103 (the end of the initial license term for Oconee Unit 1).

Administrative Controls - The *Small Bore Piping Inspection* will be implemented by plant procedures in accordance with the *Duke Quality Assurance Program*.

Regulatory Basis - Renewal Applicant Action Item in the NRC SER concerning the "Demonstration of the Management of Aging Effects for the Reactor Coolant System Piping," BAW-2243A:

"... The BWOG defers the development of details of ... (2) the sample inspection of small bore RCS piping, to the renewal applicant referencing this topical report. The renewal applicant will have to provide details of these ... inspection programs in its renewal application for staff review and approval."

Oconee Nuclear Station UFSAR Supplement For License Renewal

New Chapter 18

18.1.13 TREATED WATER SYSTEMS STAINLESS STEEL INSPECTION

Purpose - The purpose of the *Treated Water Systems Stainless Steel Inspection* will be to characterize the loss of material due to pitting corrosion and cracking due to stress corrosion of stainless steel components that could be occurring within several Oconee treated water systems.

Scope - The results of this inspection will be applicable to the stainless steel piping and valves in portions of several Oconee treated water systems which are exposed to treated or potable water falling under separate guidelines from the *Chemistry Control Program* and the state of South Carolina. The stainless steel components may experience aging that is not monitored by current plant programs. The focus on this inspection will be on a representative sample from each of the three treated water groups. The results of the inspections in each group will be an indicator of the condition of all of the stainless steel components in the systems within that group. The systems containing the stainless steel piping and valves under consideration are:

- Chemical Addition System (caustic addition portion containing demineralized water)
- Component Cooling System (the stainless steel Containment penetration portion on Unit 2 only containing demineralized water)
- Demineralized Water System (Containment penetration portion containing demineralized water)
- Filtered Water System (Containment penetration portion containing filtered water)
- Liquid Waste Disposal System (Containment penetration portion containing demineralized water)
- SSF Drinking Water System (containing potable water)
- SSF Sanitary Lift System (containing potable water)

Aging Effects - The inspection will determine the existence of loss of material due to pitting corrosion and cracking due to stress corrosion of stainless steel piping and valves.

Method- A volumetric examination of a length of the susceptible piping locations will be conducted for this inspection. This examination will include a stainless steel weld and heat affected zone since this is a more likely location for stress corrosion cracking to occur. In addition to the volumetric examination, a visual examination of the interior of a valve will be conducted to determine the presence of pitting corrosion.

Sample Size- Portions of stainless steel piping and valves, as applicable, for each of the three groups of system components will be inspected.

Oconee Nuclear Station UFSAR Supplement For License Renewal

New Chapter 18

If in the Filtered Water System no parameters exist that would distinguish among the three Containment penetrations, one of the three Containment penetrations will be inspected. A stainless steel weld at one Containment isolation valve along with piping and weld between the isolation valve and the Containment penetration schedule transition point will be volumetrically examined in the 6-inches nominal pipe size stainless steel piping. In addition, one valve will be disassembled for an internal visual examination.

If in the Demineralized Water System no parameters exist that would distinguish among the four Containment penetrations, one of the three, 4-inches nominal pipe size, Containment penetrations will be inspected. A stainless steel weld at one Containment isolation valve along with piping and weld between the isolation valve and the containment penetration schedule transition point will be volumetrically examined. In addition, one valve will be disassembled for an internal visual examination.

In the SSF Drinking Water System, a one-foot section of 1-inch nominal pipe size piping will be volumetrically examined upstream of valve PDW-72. In addition, one valve will be disassembled in the license renewal portion of this system for an internal visual inspection.

Industry Code and Standards - No code or standard exists to guide or govern this inspection. Component wall thickness acceptability will be judged in accordance with the Oconee component design code of record.

Frequency - The *Treated Water Systems Stainless Steel Inspection* is a one-time inspection.

Acceptance Criteria or Standards - No unacceptable indication of loss of material due to pitting corrosion or cracking due to stress corrosion as determined by engineering analysis.

Corrective Action - Any unacceptable loss of material due to of pitting corrosion or stress corrosion cracking requires an engineering analysis be performed to determine potential impact on component intended function.

Specific corrective actions will be implemented in accordance with the Duke *Quality Assurance Program*.

Oconee Nuclear Station
UFSAR Supplement For License Renewal

New Chapter 18

Timing of New Program or Activity - Following issuance of renewed operating license for Oconee Nuclear Station, this inspection will be completed by February 6, 2013 (the end of the initial license term for Oconee Unit 1).

Administrative Controls - The *Treated Water Systems Stainless Steel Inspection* will be implemented by plant procedures in accordance with the *Duke Quality Assurance Program*.

Regulatory Basis - This one-time inspection activity has no current regulatory basis

Oconee Nuclear Station
UFSAR Supplement For License Renewal

New Chapter 18

18.2 BORIC ACID WASTAGE SURVEILLANCE PROGRAM

Purpose - The purpose of the *Boric Acid Wastage Surveillance Program* is to provide reasonable assurance that leaks of boric acid are promptly identified and corrected and that loss of material due to boric acid corrosion is evaluated. This program focuses on small leaks which generally occur below technical specification limits for operational leakage.

Scope - The results of the program are applicable to mechanical components and structural components fabricated from carbon steel and low alloy steel that are located in proximity to borated systems. This program addresses equipment both inside and outside the Reactor Building. Bolted closures such as manways and flanged connections of systems containing dissolved boric acid are also included.

Aging Effects - The condition evaluated during the *Boric Acid Wastage Surveillance Program* is loss of material from components due to boric acid corrosion of the carbon steel and low alloy steel.

Method - Visual inspections are performed on external surfaces in accordance with plant procedures.

Industry Code or Standard - ASME Section XI and Generic Letter 88-05 [Reference 18-6].

Frequency - Inspections are performed each time the Reactor Building is entered (not to exceed intervals associated with refueling outages and ISI inspections).

Acceptance Criteria or Standard - The *Boric Acid Wastage Surveillance Program* includes the following acceptance criteria:

- (1) Free from leakage from non-insulated components
- (2) Free from leakage in excess of permissible levels defined by the owner on devices with leak limiting devices
- (3) Free from leakage from insulated or inaccessible components
- (4) Free from areas of general corrosion of a component resulting from leakage
- (5) Free from discoloration or accumulated residues on surfaces or components, insulation, or floor areas that may indicate borated water leakage.

Oconee Nuclear Station
UFSAR Supplement For License Renewal

New Chapter 18

Corrective Action - When the programmatic activities described as the *Boric Acid Wastage Surveillance Program* lead to detection of an unacceptable condition, the following corrective actions are required:

- (1) Locate leak source and areas of general corrosion.
- (2) Evaluate pressure-retaining components suffering more than 10% wall loss for continued service or replacement.
- (3) Evaluate other affected components such as supports and other structural members for continued service, repair or replacement.

Items which do not meet the acceptance criteria will be repaired or replaced in accordance with the *Duke Quality Assurance Program*.

Administrative Controls - Implemented through Nuclear Generation Department administrative and workplace procedures.

Regulatory Basis - ASME Section XI, Examination Category B-P, *All Pressure Retaining Components*, Examination Category C-H, *All Pressure Retaining Components*; Examination Category D-A, *Systems in Support of Reactor Shutdown Function*; Examination Category D-B, *Systems in Support of Emergency Core Cooling, Containment Heat Removal, Atmospheric Cleanup, and Reactor Residual Heat Removal* and Examination Category D-C, *Systems in Support of Residual Heat Removal from Spent Fuel Storage Pool*; Duke commitments in response to NRC Generic Letter 88-05 [Reference 18-7].

Oconee Nuclear Station
UFSAR Supplement For License Renewal

New Chapter 18

18.3 CHEMISTRY CONTROL PROGRAM

The primary objective of the Oconee *Chemistry Control Program* is to protect the integrity, reliability, and availability of plant equipment and components by minimizing corrosion in fluid systems. To ensure the best protection is provided, reactor coolant water quality specifications are based upon the current revision of the EPRI PWR Primary Water Chemistry Guidelines and vendor recommendations as appropriate [UFSAR Section 5.2.1.7]. Secondary chemistry specifications are based upon the recommendations in the current revision of the EPRI PWR Secondary Water Chemistry Guidelines.

For component cooling water, Oconee utilizes a modified chromate-phosphate treatment recommended by Babcock & Wilcox Co., the Oconee nuclear steam supply system vendor, as the basis for the chemistry control specifications for the component cooling system. For the SSF diesel jacket water cooling system, Oconee utilizes the industry-standard diesel jacket water cooling treatment method (sodium nitrite/borax/tolytriazole).

The Oconee SSF Fuel Oil surveillances are governed by Oconee Technical Specifications [ITS SR 3.10.1.8 and ITS 5.5.14].

Oconee Nuclear Station
UFSAR Supplement For License Renewal

New Chapter 18

18.4 CONTAINMENT INSERVICE INSPECTION PLAN

The Oconee *Containment Inservice Inspection Plan* implements the requirements of 10 CFR §50.55a (61 Federal Register 41303, dated August 8, 1996) and the 1992 Edition with the 1992 Addenda of Subsection IWE, “Requirements for Class MC and Metallic Liners of Class CC Components of Light-Water Cooled Power Plants,” and Subsection IWL, “Requirements for Class CC Concrete Components of Light-Water Cooled Power Plants.” The examinations are performed to the extent practicable within the limitations of design, geometry and materials of construction of the component. When examination requirements are determined to be impractical, relief requests are prepared and submitted in accordance with the requirements of §50.55a(g)(5)(iv) for NRC review and approval pursuant to §50.55a(g)(6).

The *Containment Inservice Inspection Plan* for each inservice inspection interval of the license renewal term will :

- (1) Implement the examination requirements of either:
 - (a) §50.55a (61 Federal Register 41303, dated August 8, 1996) and the 1992 Edition with the 1992 Addenda of Subsection IWE, “Requirements for Class MC and Metallic Liners of Class CC Components of Light-Water Cooled Power Plants,” and Subsection IWL, “Requirements for Class CC Concrete Components of Light-Water Cooled Power Plants” with the limitation listed in paragraph (b)(2)(vi) and the modifications listed in paragraphs (b)(2)(ix) and (b)(2)(x) of §50.55a, or
 - (b) the edition of the ASME Section XI Code required by §50.55a(b) prior to the start of the 120-month inservice inspection interval, or
 - (c) another edition of ASME Section XI provided an appropriate evaluation is performed;

Comply with §50.55a (g)(4)(ii), except that if an examination required by the Code or Addenda is determined to be impractical, a relief request will be submitted to the Commission in accordance with §50.55a(5)(iv), for Commission evaluation.

Oconee Nuclear Station
UFSAR Supplement For License Renewal

New Chapter 18

18.5 CONTROL ROD DRIVE MECHANISM NOZZLE AND OTHER VESSEL PENETRATIONS INSPECTION PROGRAM

Purpose - The purpose of the *CRDM Nozzle and Other Vessel Closure Penetrations Inspection Program* is to verify the assumptions made in the BWOOG safety evaluation of the susceptibility and consequence of PWSCC in B&W-designed CRDM nozzles by gathering additional inspection information in order to better characterize PWSCC.

Scope - The scope of the program includes reactor vessel closure head CRDM nozzles for all three units and the Oconee Unit 1 thermocouple penetrations.

Aging Effects - The applicable aging effect is PWSCC of Alloy 600 nozzles with partial penetration welds that cause high circumferential residual stresses on the inner diameter of the nozzles opposite the welds.

Method - The current program requires the re-inspection of from two to twelve Oconee Unit 2 CRDM nozzles from the top of the head in 1999. Eddy Current inspection will be utilized for detection. eddy current, ultrasonic, and liquid penetrate will be used for sizing.

Industry Code or Standard - No code or standard exists to guide or govern this inspection.

Frequency - The inspection frequency is dependent on plant-specific, B&WOG, and industry-wide inspection results. The next Oconee Unit 2 inspections are planned for 1999. Future inspections will be established upon review of the next set of inspection results.

Acceptance Criteria or Standard - Axial flaws detected during inspection will be analyzed and evaluated using the NUMARC acceptance criteria which were approved by the NRC in their Safety Evaluation dated November 19, 1993. Circumferential flaws will be analyzed and addressed with the NRC on a case-by-case basis [Reference 18-8].

Corrective Action - Flaws that cannot be justified for continued service by analysis will be repaired in accordance with ASME Section XI. Flaws that can be justified for continued service become a time-limited aging analysis and are addressed by the Oconee *Thermal Fatigue Management Program* (see Section 5.4 of OLRP-1001). Specific corrective actions will be implemented in accordance with the *Duke Quality Assurance Program*.

Oconee Nuclear Station
UFSAR Supplement For License Renewal

New Chapter 18

Administrative Controls - *CRDM Nozzle and Other Vessel Closure Penetrations Inspection Program* will be implemented by plant procedures in accordance with the *Duke Quality Assurance Program*.

Regulatory Basis - Duke response to NRC Generic Letter 97-01 [Reference 18-9].

Oconee Nuclear Station
UFSAR Supplement For License Renewal

New Chapter 18

18.6 CRANE INSPECTION PROGRAM

Purpose - The purpose of the *Crane Inspection Program* is to provide periodic inspections and preventive maintenance on Oconee cranes and hoists. A subset of the many inspection activities performed under the auspices of the *Crane Inspection Program* is the inspection of the structural components.

Scope - Structural components associated with the following cranes and hoists are included in the *Crane Inspection Program* for license renewal:

| Building | Crane |
|---------------------------|--|
| Auxiliary Building | Spent Fuel Bay Crane |
| | Spent Fuel Pool Fuel Handling Crane |
| | Hoists located over safety-related equipment |
| Keowee | 270 Ton Crane |
| | Intake Hoist |
| | Hoists located over safety-related equipment |
| Reactor Building | Polar Crane |
| | 2 Ton CRDM Service Crane |
| | Main Fuel Handling Bridge |
| | Equipment Hatch Hoist |
| | Hoists located over safety-related equipment |
| Turbine Building | Pump Aisle Crane |
| | Turbine Aisle Crane |
| | Turbine Aisle Auxiliary Crane |
| | Heater Bay Crane |
| | Hoists located over safety-related equipment |
| Standby Shutdown Facility | Hoists located over safety-related equipment |

A list of hoists located over safety-related equipment is maintained at Oconee.

Aging Effects - The applicable aging effect is loss of material due to corrosion of the steel components.

Method - The program requires visual inspections of cranes and hoists within the scope.

Industry Code or Standard - ANSI B30.2.0 [Reference 18-10] for cranes and ANSI B30.16 [Reference 18-11] for hoists.

Oconee Nuclear Station
UFSAR Supplement For License Renewal

New Chapter 18

Frequency - Each crane and hoist is subject to several inspections. The inspection frequencies for the cranes are based on the guidance provided by ANSI B30.2.0. The inspection frequencies for hoists are based on guidance provided by ANSI B30.16. Oconee experience supports the established frequency as being timely and effective.

Acceptance Criteria or Standard - No unacceptable visual indication of loss of material as determined by the accountable engineer.

Corrective Action - Items which do not meet the acceptance criteria are repaired or replaced. Specific corrective actions will be implemented in accordance with the *Duke Quality Assurance Program*.

Administrative Controls - The *Crane Inspection Program* is implemented by written procedure in accordance with the *Duke Quality Assurance Program*.

Regulatory Basis - 29 CFR Chapter XVII, §1910.179 [Reference 18-12].

Oconee Nuclear Station
UFSAR Supplement For License Renewal

New Chapter 18

18.7 DUKE POWER FIVE-YEAR UNDERWATER INSPECTION OF HYDROELECTRIC DAMS AND APPURTENANCES

Purpose - The purpose of the *Duke Power Five Year Underwater Inspection of Hydroelectric Dams and Appurtenances* is to inspect the structural integrity of the Keowee intake structure, spillway, and powerhouse.

Scope - The scope of the *Duke Power Five Year Underwater Inspection of Hydroelectric Dams and Appurtenances* includes:

- Keowee Intake - trashracks, support steel and concrete
- Spillway - concrete
- Powerhouse - concrete

Aging Effects - The applicable aging effects include loss of material due to corrosion for steel components and loss of material, cracking, and change in material properties of concrete components.

Method - The program requires visual examinations of external surfaces.

Industry Code or Standard - No code or standard exists to guide or govern this inspection.

Frequency - Inspections are performed once every five years. The inspection frequency is consistent with the periodicity of inspections performed by FERC for maintaining other components of the structures (See *FERC Five Year Inspections* Section 18.9).

Acceptance Criteria or Standard - No unacceptable visual indication of loss of material, cracking, or change in material properties as determined by the accountable engineer.

Corrective Action - Areas which do not meet the acceptance criteria are evaluated by the accountable engineer. If repair or replacement is required, then specific corrective actions will be implemented in accordance with the *Duke Quality Assurance Program*.

Administrative Controls - This program currently is performed in accordance with written guidance developed by the responsible Duke Power department.

Regulatory Basis - 18 CFR Part R, *Water Power Project Works Safety*.

Oconee Nuclear Station
UFSAR Supplement For License Renewal

New Chapter 18

18.8 ELEVATED WATER STORAGE TANK INSPECTION

Purpose - The purpose of the *Elevated Water Storage Tank Civil Inspection* is to provide a visual examination of the interior and exterior surfaces of the tank and associated components to ensure their structural integrity.

Scope - The scope of the program includes the interior and exterior surfaces of the Elevated Water Storage Tank and associated components.

Aging Effects - The applicable aging effect is loss of material due to corrosion.

Method - The program requires visual examinations of internal and external surfaces in accordance with station procedures.

Industry Code or Standard - NFPA 25, *Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems*.

Frequency - Inspections are performed once every five years.

Acceptance Criteria or Standard - No unacceptable visual indication of loss of material due to corrosion as determined by the accountable engineer.

Corrective Action - Items that do not meet the acceptance criteria are evaluated for continued service, monitored, or corrected. Specific corrective actions will be implemented in accordance with the *Duke Quality Assurance Program*.

Administrative Controls - The *Elevated Water Storage Tank Inspections* are implemented by plant procedures in accordance with the *Duke Quality Assurance Program*.

Regulatory Basis - This program has no current regulatory basis.

Oconee Nuclear Station
UFSAR Supplement For License Renewal

New Chapter 18

18.9 FEDERAL ENERGY REGULATORY COMMISSION (FERC) FIVE YEAR INSPECTIONS

Inspections of the Keowee River Dam; Little River Dam; Little River Dikes A, B, C, and D; Oconee Intake Canal Dike; Keowee Spillway and Left Abutment, Keowee Intake and Powerhouse are performed in accordance with the requirements contained in 18 CFR Part 12, *Water Power Projects and Project Works Safety* [Reference 18-13].

Oconee Nuclear Station
UFSAR Supplement For License Renewal

New Chapter 18

18.10 HEAT EXCHANGER PERFORMANCE TESTING ACTIVITIES

The following heat exchangers in the scope of license renewal have heat transfer as a component intended function that could be impacted by fouling. Each of these heat exchangers has raw water from the Low Pressure Service Water System: the decay heat removal cooler in the Low Pressure Injection System, the Reactor Building cooling units in the Reactor Building Cooling System, and the Standby Shutdown Facility heat exchangers in the Standby Shutdown Facility Auxiliary Service Water and Heating, Ventilation, and Air Conditioning Systems. Performance testing for these heat exchangers will provide assurance that the components are capable of adequate heat transfer required to meet system and accident load demands. Performance testing will also serve to manage loss of material for the applicable Standby Shutdown Facility heat exchangers.

Periodic testing is completed for these heat exchangers at frequencies ranging from twice per day for the Standby Shutdown Facility heat exchangers to each refueling outage for the decay heat removal cooler and the Reactor Building cooling units. Heat removal capacity is determined and compared to test acceptance criteria established by the accountable engineer and to previous test results for the decay heat removal coolers and the Reactor Building cooling units. For the Standby Shutdown Facility heat exchangers, heat removal capacity is verified by monitoring component and system performance parameters and comparing them to acceptance criteria. If the heat exchangers fail to perform adequately, then corrective actions such as cleaning are undertaken. Specific corrective actions are implemented in accordance with the *Duke Quality Assurance Program*.

The *Heat Exchanger Performance Testing Activities* are implemented by plant procedures in accordance with the *Duke Quality Assurance Program*. The activities credited here for license renewal for the Decay Heat Removal Coolers and the Reactor Building Cooling Units are consistent with the Oconee commitments made in response to Generic Letter 89-13 [References 18-14, 18-15, 18-16 , 18-17, and 18-18].

The continued implementation of the *Heat Exchanger Performance Testing Activities* provides reasonable assurance that the heat exchangers will continue to perform their intended function consistent with the current licensing basis for the period of extended operation.

Oconee Nuclear Station UFSAR Supplement For License Renewal

New Chapter 18

18.11 INSERVICE INSPECTION PLAN

The Oconee *Inservice Inspection Plan*, implements the requirements of 10 CFR §50.55a (57FR47983) and the 1989 Edition of the ASME Section XI, no addenda. The examinations are performed to the extent practicable within the limitations of design, geometry and materials of construction of the component. When examination requirements are determined to be impractical, relief requests are prepared and submitted in accordance with the requirements of §50.55a(g)(5)(iv) for NRC review and approval pursuant to §50.55a(g)(6).

The period of extended operation for Oconee will contain the 5th and 6th ten-year inservice inspection intervals. The Oconee *Inservice Inspection Plan* for each of these two inservice inspection intervals will:

- (1) Include compliance with Appendix VII, Qualification of Nondestructive Examination Personnel for Ultrasonic Examination;
- (2) Include compliance with Appendix VIII, Performance Demonstration for Ultrasonic Examination Systems;
- (3) Implement the Subsection IWB examination requirements of either (a) the 1989 Edition of ASME Section XI, or (b) the edition of the ASME Section XI Code required by §50.55a(b), or (c) another edition of ASME Section XI provided an appropriate evaluation is performed;
- (4) Comply with §50.55a (g)(4)(ii) except that if an examination required by the Code or Addenda is determined to be impractical, then a relief request will be submitted to the Commission in accordance with the requirements contained in §50.55a(5)(iv), for Commission evaluation; and
- (5) Include examination of pressurizer heater bundle welds in accordance with Examination Category B-E (or equivalent) (see UFSAR Section 18.1.7.2)

The Oconee *Inservice Inspection Plan* is a separately maintained document which has been approved by NRC for the Third Ten-Year Interval [Reference 18-19]. Current regulations require the submittal of each Ten-Year Interval Inservice Inspection Plan to the NRC for approval. Oconee will be in full compliance with Appendices VII and VIII prior to entering the period of extended operation.

Oconee Nuclear Station
UFSAR Supplement For License Renewal

New Chapter 18

In addition for CASS Class 1 components, when conditions are detected during these inservice inspections that exceed the allowable limits of ASME Section XI, engineering evaluations of either detected or postulated flaws shall be carried out using material properties and acceptance criteria applicable to the evaluation procedures presented in IWB-3640. More favorable material properties and acceptance criteria may be used, if justified, on a case-by-case basis [Reference 18-1, Volume III, Exhibit A, Chapter 4].

Oconee Nuclear Station
UFSAR Supplement For License Renewal

New Chapter 18

18.12 INSPECTION PROGRAM FOR CIVIL ENGINEERING STRUCTURES AND COMPONENTS

The *Inspection Program for Civil Engineering Structures and Components* is intended to meet the requirements of 10 CFR §50.65, *Requirements for monitoring the effectiveness of maintenance at nuclear power plants* (the Maintenance Rule). This program:

- (1) monitors and assesses civil structures and components and their condition in order to provide reasonable assurance that they are capable of performing their intended functions in accordance with the current licensing basis; and
- (2) includes nuclear safety-related structures which enclose, support, or protect nuclear safety-related systems and components and non-safety related structures whose failure may prevent a nuclear safety-related system or component from fulfilling its intended function.

NEI 96-03, *Industry Guideline for Monitoring the Condition of Structures at Nuclear Power Plants*, (draft) has been used as guidance in the preparation of the *Inspection Program for Civil Engineering Structures and Components*.

For license renewal, the program will be enhanced to include any components identified in Tables 3.4-1, 3.5-1 through 3.5-12, and 3.7-1 through 3.7-8 of Reference 18-1 that currently are not identified specifically in the program.

Oconee Nuclear Station
UFSAR Supplement For License Renewal

New Chapter 18

18.13 PENSTOCK INSPECTION

Purpose - The purpose of the *Penstock Inspection* is to ensure that the structural integrity of the Keowee Penstock will be maintained.

Scope - The scope of the *Penstock Inspection* includes both the steel lined and unreinforced concrete lined sections of the Keowee Penstock.

Aging Effects - The applicable aging effects include loss of material, cracking, and change in material properties for the unreinforced concrete lined section and loss of material for the steel lined section of the Keowee Penstock.

Method - The *Penstock Inspection* requires visual examination of the interior surface of the Keowee Penstock.

Sample Size - Not applicable for an existing program.

Industry Code or Standard - No code or standard exists to guide or govern this inspection.

Frequency - Inspections are performed each time the Keowee Penstock is dewatered during outages, which is at least every five years.

Acceptance Criteria or Standard - No unacceptable visual indication of aging effects as identified by the accountable engineer.

Corrective Action - Areas which do not meet the acceptance criteria are evaluated by the accountable engineer for continued service or corrected by repair or replacement.

Specific corrective actions are implemented in accordance with the *Duke Quality Assurance Program*.

Administrative Controls - This program is performed in accordance with written guidance developed by the responsible Duke Power department.

Regulatory Basis - 18 CFR Part 12, *Water Power Projects and Project Works Safety*.

Oconee Nuclear Station
UFSAR Supplement For License Renewal

New Chapter 18

18.14 PIPING EROSION/CORROSION PROGRAM

Purpose - The purpose of the *Piping Erosion/Corrosion Program* is to manage loss of material for the component locations in the Feedwater System and Main Steam System that have been identified as being susceptible to erosion/corrosion.

Scope - The portion of the overall program credited for license renewal includes the components in the Feedwater System between the main control valves, bypass block valves, and the steam generator, and a small section of piping downstream of the Emergency Feedwater pump turbine steam supply control valve.

Aging Effects - The aging effect of concern is loss of material of carbon steel components due to erosion/corrosion under certain relevant conditions. Relevant conditions include physical parameters such as fluid temperature, fluid (steam) quality, fluid velocity, fluid pH, mechanical component geometry and piping configuration. An analytical review process is used to determine susceptible locations based on these types of relevant conditions.

Method - The focus of the program is on the carbon steel components in the more susceptible locations within these systems. Over seventy total inspection locations exist for the three units' Feedwater Systems and ten separate inspection locations exist for the three units' Main Steam Systems. Inspection methods for susceptible component locations include use of volumetric examinations using ultrasonic testing and radiography. Also visual examination is used when access to interior surfaces is allowed by component design.

Industry Codes and Standards - No code or standard exists to guide or govern this inspection. However, the program follows the basic guidelines or recommendations provided by EPRI Document NSAC-202L. Component wall thickness acceptability is judged in accordance with the Oconee component design code of record.

Frequency - Inspection frequency varies for each location, depending on previous inspection results, calculated rate of material loss, analytical model review, changes in operating or chemistry conditions, pertinent industry events, and plant operating experiences.

Acceptance Criteria - Using inspection results and including a safety margin, the projected component wall thickness at the time of the next plant outage must be greater than the allowable minimum wall thickness under the component design code of record.

Oconee Nuclear Station
UFSAR Supplement For License Renewal

New Chapter 18

Corrective Action - If the calculated component wall thickness at the time of the next outage is projected to be less than the allowable minimum wall thickness with safety margin under the component design code of record, then the component will be repaired or replaced prior to system start-up. The as-inspected component can also be justified for continued service through additional detailed engineering analysis.

Specific corrective action will be in accordance with the *Duke Quality Assurance Program*.

Administrative Control - The *Piping Erosion/Corrosion Program* is implemented by engineering specification in accordance with the *Duke Quality Assurance Program*.

Regulatory Basis - Duke response to Bulletin 87-01 [References 18-20 and 18-21] and Duke response to Generic Letter 89-08 [References 18-22 and 18-23].

Oconee Nuclear Station
UFSAR Supplement For License Renewal

New Chapter 18

18.15 PROGRAM TO INSPECT THE HIGH PRESSURE INJECTION CONNECTIONS TO THE REACTOR COOLANT SYSTEM

Purpose - The purpose of the *Program to Inspect the High Pressure Injection Connections to the Reactor Coolant System* is to manage the displacement of the HPI thermal sleeves or cracking of the thermal sleeves and associated piping welds in the normal and emergency HPI portions of the Reactor Coolant System branch lines. This program satisfies the requirements of previous Oconee inspection commitments to the NRC for Generic Letter 85-20 [Reference 18-24] and IE Bulletin 88-08 [Reference 18-25], as well as some key ASME Section XI requirements and simplifies the programmatic oversight of these risk-significant welds in the Reactor Coolant System.

Scope - The scope of this program includes the HPI nozzles on the reactor coolant loops and attached Reactor Coolant System piping. The program also applies to the thermal sleeves within the nozzles. It encompasses all Oconee System Piping Class A (not ISI Class A) HPI piping and components with the additions of some welds within Oconee System Piping Class B boundaries (still within ISI Class A scope) being examined in accordance with IE Bulletin 88-08 commitments.

Aging Effects - Two aging effects are addressed by this program. The first aging effect is the cracking of the base metal or weld metal which could result in a non-isolable Reactor Coolant System Piping.

The second aging effect is the initiation and growth of gaps between the protective thermal sleeve and the nozzle safe end.

Method - This program includes the inspection techniques for these locations defined from ASME Section XI, Subsection IWB defined in the Oconee *Inservice Inspection Plan*. Additional augmented inspections are done using ultrasonic (UT) and dye-penetrant (PT) inspections of the components of the nozzles and piping to detect cracks, and radiographic (RT) inspections to verify no gaps are growing between the thermal sleeve and the safe end.

Industry Code or Standard - ASME Section XI for the detection and engineering evaluation of flaws in the welds.

Frequency - The frequency of actions under this program are component location-specific. The frequencies are established for each component location by considering the ASME Section XI inspection frequencies in IWB-2400 as well as the

Oconee Nuclear Station
UFSAR Supplement For License Renewal

New Chapter 18

frequencies established by Duke regulatory commitments for Generic Letter 85-20 and IE Bulletin 88-08.

Acceptance Criteria or Standard - No flaws in welds and base metal in accordance with ASME Section XI acceptance criteria. No flaws in the nozzle inner radius base metal (which is not required to be inspected under ASME Section XI criteria but which is being inspected under Generic Letter 85-20 commitments) in accordance with standards established as a part of the Duke commitment to Generic Letter 85-20).

No increase in size of the gaps between the thermal sleeve and safe end.

Corrective Action - Flaws in weld or base metal which cannot be accepted based on either the geometry screening or the Fracture Mechanics Analysis methods of ASME Section XI are corrected by repair or replacement activities. Unacceptable gaps detected by sleeve RT are corrected by repair or replacement activities. Specific corrective actions will be implemented in accordance with the *Duke Quality Assurance Program*.

Administrative Controls - The *Program to Inspect the High Pressure Injection Connections to the Reactor Coolant System* is implemented by plant procedures and controlled in accordance with the *Duke Quality Assurance Program*.

Oconee Nuclear Station
UFSAR Supplement For License Renewal

New Chapter 18

Regulatory Basis - Specific Duke-NRC communications with regard to NRC Generic Letter 85-20, IE Bulletin 88-08 and Oconee *Inservice Inspection Plan* provide the regulatory basis for this program. They are:

- W. R. McCollum, Jr., (Duke) letter dated August 6, 1997 to Document Control Desk (NRC), Oconee Nuclear Station, Units 1, 2, and 3, Docket Nos. 50-269, -270, and -287, *Inservice Inspection Plan, Third Ten-Year Inservice Inspection Interval, Generic Letter 85-20 Supplemental Information*.
- W. R. McCollum, Jr., (Duke) letter dated September 10, 1997 to Document control Desk (NRC), Oconee Nuclear Station, Units 1, 2, and 3, Docket Nos. 50-269, -270, and -287, *Inservice Inspection Plan, Third Ten-Year Inservice Inspection Interval, Generic Letter 85-20 Supplemental Information*.
- H. B. Tucker (Duke) letter dated December 29, 1989 to Document Control Desk (NRC), Oconee Nuclear Station, Units 1, 2, and 3, Docket Nos. 50-269, -270, -287, *Thermal Stresses in Piping Connected to Reactor Coolant System (NRC Bulletin 88-08)*.

Oconee Nuclear Station
UFSAR Supplement For License Renewal

New Chapter 18

18.16 REACTOR VESSEL INTEGRITY PROGRAM

The Oconee *Reactor Vessel Integrity Program* consists of the following five interrelated subprograms:

- (1) Master Integrated Reactor Vessel Surveillance Program,
- (2) Cavity Dosimetry Program,
- (3) Fluence and Uncertainty Calculations,
- (4) Pressure Temperature Limits, and
- (5) Monitoring Effective Full Power Years.

The Master Integrated Reactor Vessel Surveillance Program is an NRC approved B&WOG program [Reference 18-26] that complies with requirements for an integrated surveillance program in accordance with §50.60, Appendix H. Cavity dosimetry is used as a continuous monitoring device to ensure that the calculated values of reactor vessel fluence are accurate. Reactor vessel fluence and uncertainty calculations are used as input to calculate pressure temperature limits and end-of-life reference temperatures. Pressure temperature limit curves determine the operating region during normal heatup, normal cooldown, and inservice leak and hydrostatic test transients. The calculation of reactor vessel effective full power years is used to ensure that the pressure temperature limits and end-of-life reference temperatures are not violated. These subprograms are described in the following sections.

18.16.1 MASTER INTEGRATED REACTOR VESSEL SURVEILLANCE PROGRAM

Duke is a participant in the B&WOG Master Integrated Reactor Vessel Surveillance Program (MIRVP). The MIRVP meets the requirements of Appendix H of 10 CFR Part 50, with regard to integrated surveillance programs (paragraph III.C) and is also an NRC accepted program. In addition, the MIRVP addresses reference temperature shift concerns and pressurized thermal shock in accordance with §50.61. A description of the MIRVP is provided in BAW-1543A, Revision 2, [Reference 18-27] and in BAW 2251 [Reference 18-28] The attributes of the MIRVP are provided in the following:

Purpose - The purpose of the MIRVP is to provide a method to monitor reactor pressure vessel materials containing Linde 80 high copper beltline welds for determining the reduction of material toughness by neutron irradiation embrittlement.

Scope - The scope of the MIRVP includes beltline plate and weld material for the beltline region of the Oconee reactor vessels.

Oconee Nuclear Station UFSAR Supplement For License Renewal

New Chapter 18

Aging Effects - The applicable aging effect is the reduction of material toughness by neutron irradiation embrittlement.

Method - Fracture toughness specimens are irradiated within two operating B&W reactor vessels (i.e., Davis-Besse and Crystal River-3) and the participating Westinghouse reactor vessels. The specimens are irradiated in capsules that are located near the reactor vessel inside wall, thus enabling reactor vessel materials to become irradiated out to and beyond anticipated license renewal fluence levels. The fracture toughness specimens are tested in accordance with applicable ASTM standards as identified in Section 5.0 of BAW-1543A, Revision 2 [Reference 18-27].

Industry Code or Standard - ASTM E 185 [Reference 18-29]; Regulatory Guide 1.99, Revision 2 [Reference 18-30]; ASTM standards as identified in Section 5.0 of BAW-1543A, Revision 2 [Reference 18-27], and BAW-1543, Revision 4, Supplement 2 [Reference 18-31];

Frequency - The capsule withdrawal schedules are presented in BAW-1543, Revision 4, Supplement 2 [Reference 18-31]. The MIRVP schedule may be altered due to unscheduled downtimes or extended outages at the host plants. In addition, certain surveillance capsules may receive additional irradiation to fully satisfy license renewal fluence requirements.

Acceptance Criteria or Standard - Fracture toughness specimens removed from the surveillance capsules will be laboratory tested to ensure reactor vessel fracture toughness properties exhibit upper shelf energy greater than 50 ft-lbs. If the Charpy upper-shelf energy drops below 50 ft-lbs, then it must be demonstrated that margins of safety against fracture are equivalent to those of Appendix G of ASME Section XI. In addition, calculations of reference temperature for pressurized thermal shock (RT_{PTS}) must be below the screening criteria of 270°F for plates, forgings, and longitudinal welds and 300°F for circumferential welds, respectively. If the projected reference temperature exceeds the screening criteria, licensees are required to submit an analysis and schedule for such flux reduction programs as are reasonably practicable to avoid exceeding the screening criteria. If no reasonably practicable flux reduction program will avoid exceeding the screening criteria, licensees shall submit a safety analysis to determine what actions are necessary to prevent potential failure of the reactor vessel if continued operation beyond the screening criteria is allowed.

Corrective Action - Not applicable because this program is collecting irradiated materials data.

Oconee Nuclear Station
UFSAR Supplement For License Renewal

New Chapter 18

Administrative Controls - Fracture toughness specimens are being tested and analyzed using procedures and specifications developed and maintained in accordance with the *Duke Quality Assurance Program*.

Regulatory Basis - §50.60, *Acceptance criteria for fracture prevention measures for lightwater nuclear power reactors for normal operation*; §50.61, *Fracture Toughness requirements for protection against pressurized thermal shock*; Appendix G to Part 50, *Fracture Toughness Requirements*; Appendix H to Part 50, *Reactor Vessel Material Surveillance Program Requirements*; and Oconee Improved Technical Specification 3.4.3, *Reactor Coolant System Pressure and Temperature (P/T) Limits*.

Oconee Nuclear Station UFSAR Supplement For License Renewal

New Chapter 18

18.16.2 CAVITY DOSIMETRY PROGRAM

The *Cavity Dosimetry Program* is an Oconee on-site method to continuously monitor the reactor vessel beltline region fluence for determining the reduction of material toughness due to neutron irradiation embrittlement.

Purpose - The purpose of the *Cavity Dosimetry Program* is to provide an improved methodology to more accurately estimate reactor vessel accumulated neutron fluence for the reactor vessel limiting beltline welds. Cavity dosimetry measurements are used to verify the accuracy of fluence calculations and to determine fluence uncertainty values.

Scope - All three Oconee reactor vessels are included in the cavity dosimetry program; however, only the Oconee Unit 2 reactor vessel has installed cavity dosimetry. The Oconee Unit 1 and Oconee Unit 3 reactor vessel fluence uncertainty values are based on Oconee Unit 2 cavity dosimetry results due to similar design, fabrication, operation, and fuel loading patterns.

Aging Effects - The reduction of material toughness by irradiation embrittlement.

Method - Dosimeters (i.e., U_{238} , Np_{237} , Ni, Cu, etc.) are irradiated in the cavity region outside of the Oconee Unit 2 reactor vessel. Cavity dosimetry was irradiated at Oconee Unit 2 for cycle 9, cycle 10, combined cycles 11-12, combined cycles 13-14, and combined cycles 15-16. At present, cavity dosimetry is being irradiated at Oconee Unit 2 for combined cycles 17-18.

The cavity dosimeters are measured to determine the activity resulting from the fast fluence irradiation. In addition, calculations of the dosimetry activities are performed using operational data. The calculations are compared to the measurements to verify the accuracy and the uncertainty in the calculated fluence.

Industry Code or Standard - Regulatory Guide 1.99, Revision 2 [Reference 18-30]; ASTM E 185 [Reference 18-29]; Draft Regulatory Guide - 1053 [Reference 18-32]; BAW-2241P [Reference 18-33].

Frequency - At present, cavity dosimetry is changed out on an every-other-cycle basis. Future trends indicate extending the frequency to an every-third-cycle exchange period or longer. The cavity dosimetry exchange schedule may be altered due to changes in fuel type, fuel loading pattern, or power rating of Oconee Unit 2.

Oconee Nuclear Station
UFSAR Supplement For License Renewal

New Chapter 18

Acceptance Criteria or Standard - Dosimetry removed from the cavity dosimetry holder is laboratory tested to count the amount of neutron irradiation damage to the dosimetry specimens. Computer analyses are used to calculate the dosimeter activities and associated fluence. Following computer analyses, the calculated accumulated fast fluence will be determined. The results of the fluence uncertainty values should be within the NRC-suggested limit of $\pm 20\%$.

Corrective Action - As additional cavity dosimetry is withdrawn and tested, cavity dosimetry exchange frequency may be adjusted, as appropriate. If the comparison of calculations to measurements of the Unit 2 multiple dosimeters fail to meet $+20\%$, measurements and calculations will be reviewed to locate the discrepancy.

Administrative Controls - Cavity dosimetry is being tested and analyzed using procedures and specifications developed and maintained in accordance with the *Duke Quality Assurance Program*.

Regulatory Basis - §50.60, *Acceptance criteria for fracture prevention measures for lightwater nuclear power reactors for normal operation*; Appendix H to Part 50, *Reactor Vessel Material Surveillance Program Requirements*; and Oconee Improved Technical Specification 3.4.3, *Reactor Coolant System Pressure and Temperature (P/T) Limits*.

Oconee Nuclear Station UFSAR Supplement For License Renewal

New Chapter 18

18.16.3 FLUENCE AND UNCERTAINTY CALCULATIONS

The reactor vessel *Fluence And Uncertainty Calculations* are used as inputs to the pressure temperature limit curves and pressurized thermal shock calculations. Updating fluence and uncertainty calculations is essential to maintaining an accurate prediction of the actual reactor vessel accumulated neutron fast fluence value.

Purpose - The purpose of the reactor vessel *Fluence And Uncertainty Calculations* is to provide an accurate prediction of the actual reactor vessel accumulated neutron fast fluence value.

Scope - The *Fluence And Uncertainty Calculations* includes all three of the Oconee reactor vessels.

Aging Effect - The reduction of material toughness by neutron irradiation embrittlement.

Method - The cavity dosimetry program yields irradiated dosimeters that are analyzed based on Oconee specific geometry models (i.e., Mark-B8 fuel, reactor vessel, capsule holder, concrete structures), macroscopic cross sections, cycle-specific sources using the DORT and GIP computer codes, and a reference set of microscopic cross sections (BUGLE-93). Specific attention is made to target fluence values for limiting reactor vessel beltline circumferential weld locations. Recently updated fluence and uncertainty calculations were based on cavity dosimetry irradiated at Oconee Unit 2 for cycle 9, cycle 10, combined cycles 11-12, and combined cycles 13-14. Future revised calculations will be based on cavity dosimetry currently being irradiated at Oconee Unit 2 for combined cycles 15-16.

Industry Code or Standard - Regulatory Guide 1.99, Revision 2 [Reference 18-30]; ASTM E 185 [Reference 18-29]; Draft RG-1053 [Reference 18-32], BAW-2241P [Reference 18-33].

Frequency - Fluence and uncertainty calculations are expected to follow each cavity dosimetry analysis for the next few years. The frequency of updating fluence and uncertainty calculations may change as additional data are obtained. Future decisions concerning the frequency of withdrawal of dosimetry will be based on changes in fuel type or fuel loading pattern.

Oconee Nuclear Station
UFSAR Supplement For License Renewal

New Chapter 18

Acceptance Criteria or Standard - The results of the fluence uncertainty values are to be within the NRC-suggested limit of $\pm 20\%$. Calculated fluence values for fluence levels above 1.0MeV are compared with measurement values to determine if calculations contain any errors. This methodology represents a continuous validation process to ensure that no biases have been introduced, and that the uncertainties remain comparable to the reference benchmarks.

Corrective Action - As additional cavity dosimetry is withdrawn and tested, fluence and uncertainty calculations will be revised and updated accordingly. If comparisons of dosimetry calculations to measurements are not within acceptance standards, then the calculations will be revised. Specific corrective actions will be implemented in accordance with the *Duke Quality Assurance Program*.

Administrative Controls - The *Fluence And Uncertainty Calculations* are developed and maintained in accordance with the *Duke Quality Assurance Program*.

Regulatory Basis - Appendix H to Part 50, *Reactor Vessel Material Surveillance Program Requirements*; and Oconee Improved Technical Specification 3.4.3, *Reactor Coolant System Pressure and Temperature (P/T) Limits*.

Oconee Nuclear Station UFSAR Supplement For License Renewal

New Chapter 18

18.16.4 PRESSURE TEMPERATURE LIMIT CURVES

Pressure Temperature Limit Curves determine the operating region during normal heatup, normal cooldown, and inservice leak and hydrostatic test transients. Periodically they are updated based on revised accumulated fluence values, additional effective full power years, and to incorporate methodology or regulatory changes.

Purpose - The purpose of the *Pressure Temperature Limit Curves* is to establish the normal operating limits for the Reactor Coolant System.

Scope - The scope of the *Pressure Temperature Limit Curves* includes all three of the Oconee reactor vessels.

Aging Effects - The reduction of material toughness by neutron irradiation embrittlement.

Method - Pressure temperature curves are generated assuming a postulated 1/4T surface flaw in accordance with ASME Section XI, Appendix G [Reference 18-34]. Bounding input heatup and cooldown transients are used to develop the pressure temperature curves. Current Oconee Unit-1, -2, and -3 *Pressure Temperature Limit Curves* are valid for 21, 19, and 21 EFPY, respectively. In 1998, updated Oconee *Pressure Temperature Limit Curves* are being extended to at least 26 EFPY for all three units.

Industry Code or Standard - ASME Section XI, Appendix G, 1989 Edition [Reference 18-34]; ASME Code Case N-514 [Reference 18-35]; Regulatory Guide 1.99, Revision 2 [Reference 18-30].

Frequency - *Pressure Temperature Limit Curves* are valid for a period of time expressed in Effective Full Power Years (EFPY). The curves are required to be updated prior to exceeding this time period.

Acceptance Criteria or Standard - NRC approved *Pressure Temperature Limit Curves* must be in place for continued plant operation.

Corrective Action - Oconee Improved Technical Specifications, *ITS 3.4.3, RCS Pressure and Temperature (P/T) Limits*, require valid pressure-temperature limits prior to and during plant operations. Actions to be taken if the pressure-temperature limits are not valid are specified in Oconee Improved Technical Specifications 3.4.3.

Oconee Nuclear Station
UFSAR Supplement For License Renewal

New Chapter 18

Administrative Controls - The *RCS Pressure and Temperature (P/T) Limits* are developed and maintained in accordance with the *Duke Quality Assurance Program*.

Regulatory Basis - Oconee Improved Technical Specification ITS 3.4.3, *Reactor Coolant System Pressure and Temperature (P/T) Limits*.

Oconee Nuclear Station UFSAR Supplement For License Renewal

New Chapter 18

18.16.5 EFFECTIVE FULL POWER YEARS

Effective Full Power Years provide a measurement of the age of the reactor vessel and is required input for verifying pressure temperature limit curves and pressurized thermal shock validity periods. The values for *Effective Full Power Years* are established from the calculation of Effective Full Power Hours and Effective Full Power Days.

Purpose - The purpose *Effective Full Power Years* is to accurately monitor and tabulate the accumulated operating time and cycles experienced by the reactor vessel and other Reactor Coolant System components.

Scope - The scope of the *Effective Full Power Years* activity includes all three of the Oconee reactor vessels.

Aging Effect - The reduction of material toughness by neutron irradiation embrittlement.

Method - The effective full power days of plant operation are based on reactor vessel incore power readings. The Nuclear Applications Software, which runs on the operator aid computer, collects incore instrument data. Site reactor engineers determine effective full power days values by comparing the burnup to the thermal power calculated burnup. All data is collected continuously for all three Oconee units.

Industry Code or Standard - None.

Frequency - Each unit is continuously computer monitored and updated weekly by site reactor engineers to determine the effective full power days of Reactor Coolant System operation during the previous seven day period.

Acceptance Criteria or Standard - For a given fuel cycle, the updated effective full power days calculation based on the power history must be within ± 0.25 EFPD of the operator aid computer generated value.

Corrective Action - As additional effective full power hour and effective full power day values become available, effective full power year calculations are revised and updated accordingly. Specific corrective actions will be implemented in accordance with the *Duke Quality Assurance Program*.

Administrative Controls - The *Effective Full Power Years* activity are implemented by Oconee workplace procedures developed and maintained in accordance with the *Duke Quality Assurance Program*.

Oconee Nuclear Station
UFSAR Supplement For License Renewal

New Chapter 18

Regulatory Basis - Oconee Improved Technical Specification 3.4.3, *Reactor Coolant System Pressure and Temperature (P/T) Limits*.

Oconee Nuclear Station
UFSAR Supplement For License Renewal

New Chapter 18

18.17 SERVICE WATER PIPING CORROSION PROGRAM

Purpose - The *Service Water Piping Corrosion Program* will manage loss of material due to general and localized corrosion for components in the Auxiliary Service Water System, the Condenser Circulating Water System, the High Pressure Service Water System, the Low Pressure Injection System (for the raw water side of the Decay Heat Cooler), the Low Pressure Service Water System, the SSF Auxiliary Service Water System, the Keowee Service Water System, the Turbine Generator Cooling Water System, and the Turbine Sump Pump System.

Scope - The scope of the program credited for license renewal includes all bronze, carbon steel, cast iron and stainless steel components in the license renewal portions of the systems listed in the Purpose. The program focuses on the carbon steel piping components exposed to raw water which are more susceptible to general corrosion and which serve as a leading indicator of the general material condition of the system components. At the time of the Application, no inspection locations were identified for any of the Keowee systems since they remain bounded by the overall program results.

For license renewal, the program will be enhanced to include piping inspection locations at Keowee, focused on bronze and brass piping.

Over 30 different carbon steel piping component inspection locations have been established throughout the applicable systems based on the understanding that fluid flow rates are a prime contributor to the conditions conducive to corrosion. Inspection locations are spread among the four flow regimes: (1) stagnant, (2) intermittent, (3) low flow or approximately three feet per second or less, and (4) normal flow or flow greater than three feet per second based on system operations.

Aging Effects - The aging effects of concern are loss of material due to general corrosion of bronze, carbon steel, and cast iron components and loss of material due to localized corrosion for bronze, carbon steel, cast iron and stainless steel that may reveal itself in the raw water systems within the scope of license renewal.

Method - Inspection methods for susceptible component locations include use of volumetric examinations using ultrasonic testing. Also, visual examination is used as a general characterization tool in conjunction with ultrasonic testing when access to interior surfaces is allowed such as during plant modifications.

Oconee Nuclear Station UFSAR Supplement For License Renewal

New Chapter 18

Industry Codes and Standards - No code or standard exists to guide or govern this inspection. However, the program follows the basic guidelines or recommendations provided by EPRI Document NSAC-202L. Component wall thickness acceptability is judged in accordance with the component design code of record.

Frequency - Because the corrosion phenomena is slow-acting, inspection frequency varies for each location with a periodicity on the order of five to ten years. The first inspections were performed in the early 1990s. The frequency of re-inspection depends on previous inspection results, calculated rate of material loss, piping analysis review, pertinent industry events and plant operating experiences. Most locations received one re-inspection at the time of application.

Acceptance Criteria - No inspection locations falling below the minimum pipe wall thickness values for the inspection locations as defined in the program. These minimum values have been determined based on design pressure or structural loading using the piping design code of record and then applying additional conservatism.

Corrective Action - Inspection locations that fall below the acceptance criteria are repaired or replaced prior to the system returning to service unless an engineering analysis allows further operation. In the cases where a component may be allowed to continue in service, a re-inspection interval is established in the program.

Specific corrective actions will be implemented in accordance with the *Duke Quality Assurance Program*.

Administrative Control - The *Service Water Piping Corrosion Program* is implemented by engineering specification in accordance with the *Duke Quality Assurance Program*.

Regulatory Basis - The *Service Water Piping Corrosion Program* is a formalization of a portion of the commitments made in response to GL 89-13, primarily those associated with component pressure boundary maintenance [References 18-14, 18-15, 18-16, 18-17 and 18-18].

Oconee Nuclear Station
UFSAR Supplement For License Renewal

New Chapter 18

18.18 SYSTEM PERFORMANCE TESTING ACTIVITIES

The following raw water systems have been identified as containing smaller diameter piping that could be effected by fouling and will be managed by *System Performance Testing Activities*: Auxiliary Service Water System, Low Pressure Service Water System, SSF Auxiliary Service Water System, Turbine Generator Cooling Water System, and Turbine Sump Pump System. Performance testing for these systems will provide assurance that the components are capable of delivering adequate flow at a sufficient pressure as required to meet system and accident load demands. Performance testing will also provide the means to manage the loss of material in the Standby Shutdown Facility Auxiliary Service Water System air ejector and orifices as loss of material will be directly revealed by system performance.

Periodic testing and inspections are completed for the above systems at a range of frequencies. Periodic testing frequencies range from quarterly to every third refueling outage, depending on the system. The Turbine Generator Cooling Water System is tested at design conditions every time the Keowee units operate. The Keowee units operate at about a ten percent capacity factor. Visual inspections of the Auxiliary Service Water System are conducted every five years.

Flow capacity is determined and compared to test acceptance criteria established by engineering and to previous test results. The results of visual inspections are evaluated by engineering. If the results of the flow tests and inspections do not meet acceptance criteria, then corrective actions, which could require piping replacement, are undertaken. Specific corrective actions are implemented in accordance with the *Duke Quality Assurance Program*.

The *System Performance Testing Activities* are implemented by plant procedures in accordance with the *Duke Quality Assurance Program*. The activities credited here for license renewal are consistent with the Oconee commitments made in response to Generic Letter 89-13 [References 18-14, 18-15 18-16, 18-17 and 18-18].

The continued implementation of the *System Performance Testing Activities* provides reasonable assurance that the aging effects will be managed such that mechanical components will continue to perform their intended functions consistent with the current licensing basis for the period of extended operation.

Oconee Nuclear Station
UFSAR Supplement For License Renewal

New Chapter 18

18.19 TENDON - SECONDARY SHIELD WALL - SURVEILLANCE PROGRAM

Purpose - The purpose of the *Tendon - Secondary Shield Wall - Surveillance Program* is to inspect the Secondary Shield Wall Post-Tension Tendon System to ensure that the quality and structural performance of the secondary shield wall is consistent with the licensing basis.

Scope - The scope of this program includes the tendon wires and tendon anchorage hardware, including bearing plates, anchorheads, bushing, buttonheads, and shims of the Units 1, 2, and 3 Secondary Shield Wall Tendons.

Aging Effects - The applicable aging effects include loss of material due to corrosion and cracking of tendon anchorage; wire force relaxation; loss of material due to corrosion and breakage of wires; loss of material due to corrosion and cracking of bearing plate; cracked, split, and broken buttonheads; cracking and loss of material due to corrosion of shims.

Method - This program requires a visual examination of in-scope components and lift-off testing of the tendon system.

Industry Code or Standard - No code or standard exists to guide or govern this program.

Frequency - All vertical tendon caps are visually inspected each refueling outage. A random sample of tendons (including vertical) are inspected every other refueling outage and lift-off tests are performed on a selected number of tendons. All accessible tendon anchorages are visually inspected every fourth refueling outage. The inspection sample size and the frequency of performance of the inspections were initially based on the judgment of experienced engineers. The frequency and extent of the inspections are acceptable because they are more stringent than those used for reactor building containment tendon inspections required by ASME, Section XI, Subsection IWL which has been endorsed by the NRC.

Acceptance Criteria or Standard - No unacceptable visual indication of moisture, discoloration, foreign matter, rust, corrosion, splits or cracks in the buttonheads, broken or missing wires, and other obvious damage as identified by the accountable engineer. Lift-off forces are measured and compared to established acceptance criteria. Oconee operating experience tends to confirm that visual inspections and lift-off tests of these tendons are appropriate.

Oconee Nuclear Station
UFSAR Supplement For License Renewal

New Chapter 18

Corrective Action - Areas which do not meet the acceptance criteria are evaluated for continued service or corrected by replacement. Specific corrective actions are implemented in accordance with the *Duke Quality Assurance Program*.

Administrative Controls - The *Tendon - Secondary Shield Wall - Surveillance Program* is implemented by written procedures in accordance with the *Duke Quality Assurance Program*.

Regulatory Basis - This program has no current regulatory basis.

Oconee Nuclear Station
UFSAR Supplement For License Renewal

New Chapter 18

18.20 230 kV KEOWEE TRANSMISSION LINE INSPECTION

Purpose - The purpose of the *230 kV Keowee Transmission Line Inspection* is to maintain the structural integrity of the 230 kV Keowee transmission line structures.

Scope - The *230 kV Keowee Transmission Line Inspection* include steel towers, concrete foundations, and hardware within the 230 kV Keowee transmission line.

Aging Effects - The applicable aging effects of concern include loss of material due to corrosion of the steel structures and loss of material due to spalling or scaling for concrete components.

Method - The inspection requires a visual examination of the towers.

Industry Code or Standard - National Electric Safety Code, Part 2 *Safety Rules for Overhead Lines*; Rule 214 *Inspection and Tests of Lines and Equipment*.

Frequency - The inspections are performed once every five years.

Acceptance Criteria or Standard - No unacceptable visual indication of aging effects as evaluated by the inspector.

Corrective Action - Areas which do not meet the acceptance criteria are evaluated for continued service or corrected by repair or replacement. Specific corrective actions are implemented in accordance with the *Duke Quality Assurance Program*.

Administrative Controls - The *230 kV Keowee Transmission Line Inspection* is contracted through the Oconee site engineering group with Duke Power's Power Delivery Group. The inspection is addressed within the Oconee preventive maintenance program.

Regulatory Basis - National Electric Safety Code, Part 2, *Safety Rules for Overhead Lines*, Rule 214 *Inspection and Tests of Lines and Equipment*.

Oconee Nuclear Station
UFSAR Supplement For License Renewal

New Chapter 18

18.21 REFERENCES

- 18-1. *Application for Renewed Operating Licenses for Oconee Nuclear Station, Units 1, 2, and 3*, submitted by M. S. Tuckman (Duke) letter dated July 6, 1988 to Document Control Desk (NRC), Docket Nos. 50-269, -270, and -287.
- 18-2. [Insert specifics of NRC approval document as a reference, when available.]
- 18-3. BAW-2243A, *Demonstration of the Management of Aging Effects for the Reactor Coolant System Piping*, The B&W Owners Group Generic License Renewal Program, June 1996.
- 18-4. BAW-2244A, *Demonstration of the Management of Aging Effects for the Pressurizer*, The B&W Owners Group Generic License Renewal Program, December 1997.
- 18-5. BAW-2248, *Demonstration of the Management of Aging Effects for the Reactor Vessel Internals*, The B&W Owners Group Generic License Renewal Program, July 1997.
- 18-6. Generic Letter 88-05, *Boric Acid Corrosion of Carbon Steel Reactor Pressure Boundary Components in PWR Plants*, dated March 17, 1988.
- 18-7. H. B. Tucker (Duke) letter dated August 1, 1988 to Document Control Desk (NRC), *Response to Generic Letter 88-05, Boric Acid Corrosion of Carbon Steel Reactor Pressure Boundary Components in PWR Plants*, Oconee Nuclear Station, Docket Nos. 50-269, -270, and -287.
- 18-8. W. T. Russell (NRC) letter dated November 19, 1993 to W. H. Rasin (NUMARC, now NEI).
- 18-9. M. S. Tuckman (Duke) letter dated July 30, 1997 to Document Control Desk (NRC), Oconee Nuclear Station - Response to Generic Letter 97-01: *Degradation of Control Rod Drive Mechanism Nozzle and Other Vessel Closure Head Penetrations*, Docket Nos. 50-269, -270, and -287.
-

Oconee Nuclear Station
UFSAR Supplement For License Renewal

New Chapter 18

- 18-10. ANSI B30.2.0, "Overhead and Gantry Cranes", American National Standard, Section 2-2, *Safety Standards for Cableways, Cranes, Derricks, Hoists, Hooks, Jacks and Slings*, The American Society of Mechanical Engineers, New York.
- 18-11. ANSI B30.16, "Overhead Hoists (Underhung)", The American Society of Mechanical Engineers, New York.
- 18-12. 29 CFR Chapter XVII, §1910.179, *Occupational Safety and Health Administration, Overhead and Gantry Cranes*.
- 18-13. 18 CFR Part 12 - *Safety of Water Power Projects and Project Works*, 59 FR 54815, Nov. 2, 1994.
- 18-14. H.B. Tucker (Duke) letter dated January 26, 1990 to the Document Control Desk (NRC), *Response to NRC Generic Letter 89-13, Service Water System Problems Affecting Safety-Related Equipment*, Oconee Nuclear Station, Units 1, 2, and 3, Docket Nos. 50-269, -270, and -287.
- 18-15. H.B. Tucker (Duke) letter dated May 31, 1990 to the Document Control Desk (NRC), *Supplemental Response to NRC Generic Letter 89-13, Service Water System Problems Affecting Safety Related Equipment*, Oconee Nuclear Station, Units 1, 2, and 3, Docket Nos. 50-269, -270, and -287.
- 18-16. J.W. Hampton (Duke) letter dated December 10, 1992 to the Document Control Desk (NRC), *Confirmation of Implementation of Recommended Action Related to Generic Letter 89-13*, Oconee Nuclear Station, Units 1, 2, and 3, Docket Nos. 50-269, -270, and -287.
- 18-17. J.W. Hampton (Duke) letter dated September 1, 1994 to the Document Control Desk (NRC), *Follow Up to a Deviation Notice in NRC Inspection Report 93-25 to Revise Response to 89-13*, Oconee Nuclear Station, Units 1, 2, and 3, Docket Nos. 50-269, -270, and -287.
- 18-18. J.W. Hampton (Duke) letter dated April 4, 1995 to Document Control Desk (NRC), *Supplemental Response #3 to Generic Letter 89-13*, Oconee Nuclear Station, Units 1, 2, and 3, Docket Nos. 50-269, -270, and -287.
-

Oconee Nuclear Station
UFSAR Supplement For License Renewal

New Chapter 18

- 18-19. H. N. Berkow (NRC) letter dated November 15, 1995 to J. W. Hampton (Duke), *Inservice Inspection Program for Third Ten-Year Interval, Oconee Nuclear Station, Units 1, 2, and 3*, (TAC Nos. M88484, M888484, and M88486).
- 18-20. IE Bulletin 87-01, *Thinning of Pipe Walls in Nuclear Power Plants*.
- 18-21. H. B. Tucker (Duke) letter dated September 14, 1987 to Document Control Desk (NRC), Response to IE Bulletin 87-01, Oconee Nuclear Station, Units 1, 2, and 3, Docket Nos. 50-269, -270, and -287.
- 18-22. Generic Letter 89-08, *Erosion/Corrosion-Induced Pipe Wall Thinning*.
- 18-23. H. B. Tucker (Duke) letter dated July 21, 1989, Response to Generic Letter 89 08, Oconee Nuclear Station, Units 1, 2, and 3, Docket Nos. 50-269, -270, and -287.
- 18-24. Generic Letter 85-20, *Resolution of Generic Issue 69: High Pressure Injection/Make-up Nozzle Cracking in Babcock and Wilcox Plants*.
- 18-25. IE Bulletin 88-08, *Thermal Stresses in Piping Connected to the Reactor Coolant System*.
- 18-26. D. B. Matthews (NRC) letter dated July 11, 1997 to J. H. Taylor (FTI), Babcock & Wilcox Owners Group (B&WOG) Reactor Vessel Working Group Report BAW-1543, Revision 4, Supplement 2, *Supplement to the Master Integrated Reactor Vessel Surveillance Program*, TAC No. M98089.
- 18-27. BAW-1543A, Revision 2, *Integrated Reactor Vessel Surveillance Program*, B&W Owners Group Materials Committee, May 1985.
- 18-28. BAW-2251, *Demonstration of the Management of Aging Effects for the Reactor Vessel*, The B&W Owners Group Generic License Renewal Program, June 1996.
- 18-29. ASTM E 185, *Standard Practice for Conducting Surveillance Test for Light-Water Cooled Nuclear Power Reactor Vessels*.
-

Oconee Nuclear Station
UFSAR Supplement For License Renewal

New Chapter 18

- 18-30. Regulatory Guide 1.99, Revision 2, NRC, *Radiation Embrittlement of Reactor Vessel Material*, May 1998.
- 18-31. BAW-1543, Revision 4, Supplement 2, *Supplement to the Master Integrated Reactor Vessel Surveillance Program*, Babcock & Wilcox Owners Group (B&WOG) Reactor Vessel Working Group.
- 18-32. Draft Regulatory Guide - 1053, *Calculational and Dosimetry Method for Determining Pressure Vessel Neutron Fluence*, June 1996.
- 18-33. BAW-2241P, *Fluence and Uncertainty Methodologies*, April 1997 (under NRC review as of June 1998).
- 18-34. ASME Section XI, Appendix G for Nuclear Power Plants, Division 1, *Protection Against Non-Ductile Failure*.
- 18-35. ASME Code Case N-514, *Low Temperature Overpressure Protection*, Section XI, Division 1.