Official Transcript of Proceedings

NUCLEAR REGULATORY COMMISSION

Title:	Advisory Committee on Reactor Safeguards 535th Meeting
Docket Number:	(not applicable)
Location:	Rockville, Maryland
Date:	Thursday, September 7, 2006

Work Order No.: NRC-1237

Pages 1-279

NEAL R. GROSS AND CO., INC. Court Reporters and Transcribers 1323 Rhode Island Avenue, N.W. Washington, D.C. 20005 (202) 234-4433

	1
1	UNITED STATES OF AMERICA
2	NUCLEAR REGULATORY COMMISSION
3	+ + + +
4	ADVISORY COMMITTEE ON REACTOR SAFEGUARDS (ACRS)
5	535^{TH} MEETING
б	+ + + +
7	THURSDAY, SEPTEMBER 7, 2006
8	+ + + +
9	The meeting was convened in Room T-2B3 of
10	Two White Flint North, 11545 Rockville Pike,
11	Rockville, Maryland, at 8:30 a.m., Dr. Graham B.
12	Wallis, Chairman, presiding.
13	MEMBERS PRESENT:
14	GRAHAM B. WALLIS Chairman
15	WILLIAM J. SHACK Vice Chairman
16	SAID ABDEL-KHALIK ACRS Member
17	GEORGE E. APOSTOLAKIS ACRS Member
18	J. SAM ARMIJO ACRS Member
19	MARIO V. BONACA ACRS Member
20	MICHAEL CORRADINI ACRS Member
21	THOMAS S. KRESS ACRS Member
22	OTTO L. MAYNARD ACRS Member
23	DANA A. POWERS ACRS Member
24	WILLIAM J. SHACK ACRS Member
25	JOHN D. SIEBER ACRS Member-At-Large

1	NRC STAFF PRESENT:
2	JAKE ZIMMERMAN
3	FRANK GILLESPIE
4	P.T. KUO
5	DAN MERZKE
6	PETER WEN
7	PATRICIA LOUGHEED
8	MATT MITCHELL
9	FRANK GILLESPIE
10	CHRISTIAN ARAGUAS
11	PAUL PRESCOTT
12	BOB WEISMAN
13	DR. MICHAEL RYAN
14	BILL ROLAND
15	GEARY MIZUNO
16	MICHELE LAUR
17	JASON SCHAPEROW
18	FAROUK ELTAWILA
19	CHARLES TANKLER
20	CHRIS HUNTER
21	TOM MARTIN
22	GEORGE TARTAL
23	MERAJ RAHIMI
24	
25	

		3
1	ALSO PRESENT:	
2	PAT BURKE	
3	JOHN GRUBB	
4	JOE PAIRITZ	
5	RAY DENNIS	
6	RON SIEPEL	
7	JIM ROOTES	
8	MIKE ALEKSEY	
9	DAVE POTTER	
10	STEVE KRAFT	
11	ALBERT MACHIELS	
12	DON DUBE	
13		
14		
15		
16		
17		
18		
19		
20		
21		
22		
23		
24		
25		
	I contract of the second s	

	4
1	C-O-N-T-E-N-T-S
2	AGENDA ITEM PAGE
3	Opening Remarks by ACRS Chairman 4
4	Final Review of the License Renewal
5	Application for the Monticello
6	Nuclear Generating Plant 6
7	Lessons Learned from the Review of the
8	Early Site Permit Applications 47
9	Criticality Accident Requirements 90
10	State of the Art Consequence Analysis 208
11	Adjourn
12	
13	
14	
15	
16	
17	
18	
19	
20	
21	
22	
23	
24	
25	

	5
1	P-R-O-C-E-E-D-I-N-G-S
2	8:32 A.M.
3	CHAIRMAN WALLIS: Good morning. The
4	meeting will now come to order. This is the first day
5	of the 535^{th} meeting of the Advisory Committee on
6	Reactor Safeguards. During today's meeting the
7	Committee will consider the following; The Final
8	Review of the License Renewal Application for the
9	Monticello Nuclear Generating Plant; Lessons Learned
10	from the Review of the Early Site Permit Applications;
11	Draft Final Revision to 10 CFR 5068, Criticality
12	Accident Requirements; State of the Art Consequence
13	Analysis; the EDO Response to the ACRS Report on the
14	Review of Ongoing Security Related Activities and the
15	Preparation of ACRS Reports.
16	A portion of the meeting will be closed to
17	discuss safeguards and security matters. This meeting
18	is being conducted in accordance with the provisions
19	of the Federal Advisory Committee Act. Dr. John T.
20	Larkins is the designated Federal Official for the
21	initial portion of the meeting. We have received no
22	written comments or requests for time to make oral
23	statements from members of the public regarding
24	today's sessions. A transcript of portions of the
25	meeting is being kept and it is requested that

(202) 234-4433

	6
1	speakers use one of the microphones, identify
2	themselves and speak with sufficient clarity and
3	volume so that they can be readily heard. This
4	identifying yourself does not apply to members of the
5	ACRS or the new members. Just speak up, they know who
6	you are.
7	I'd like to welcome Michael Corradini and
8	Said Abdel-Khalik who are now official members of the
9	ACRS. Please welcome them.
10	(Applause)
11	CHAIRMAN WALLIS: Dr. Richard Savio, who's
12	been with the ACRS for more than 30 years, will be
13	retiring on September 30 th , 2006. During his tenure
14	on the ACRS staff he provided technical support on
15	numerous matters, including development of safety goal
16	policy, review of construction permit and operating
17	license applications for several plants and safety
18	research program report and the ACRS/ACNW self-
19	assessment. I don't think Dr. Savio is here, but on
20	behalf of the committee, I'd like to thank him for his
21	contributions and wish him good luck in his future
22	endeavors.
23	We're also going to say goodbye to Noble
24	Green, who's been Administrative Secretary to the
25	Executive Director for the past three years. He's
1	I contract of the second se

(202) 234-4433

	7
1	accepted a position as an Administrative Support
2	Specialist in the Information Management Branch of
3	NRR. He started his new job on September the 1^{st} . I
4	don't think he's here either. Is Noble here, but I
5	will note that he has provided excellent
6	administrative support to both the ACRS Staff and the
7	Committee members and on behalf of the Committee, I'd
8	like to thank him for his support and wish him much
9	success in his new endeavors.
10	Now, we're going to get down to business.
11	And the first item on the agenda is the Final Review
12	of the License Operating License Renewal
13	Application for the Monticello Nuclear Generating
14	Plant. My colleague Mario Bonaca will lead us through
15	this one. Mario.
16	MEMBER BONACA: Thank you, Mr. Chairman.
17	Good morning. We're here to review the Monticello
18	Nuclear Generating Plant License Renewal Application.
19	The Subcommittee on License Renewal met on May 30^{th} to
20	review this application. We found an application that
21	was over 95 percent consistent with GALL. That meant
22	that this required a very small number of RAIs, and
23	clarifications. We find an application also that had
24	no open items in the interim review the we performed
25	on May 30^{th} and now we're going to see review the
	1 I I I I I I I I I I I I I I I I I I I

(202) 234-4433

	8
1	results of the finals SER and with that, I'll turn to
2	the NRC staff, I guess, Mr. Zimmerman?
3	MR. ZIMMERMAN: Yes, thank you, Dr.
4	Bonaca. Good morning. My name is Jake Zimmerman.
5	I'm the Branch Chief for License Renewal Branch B.
6	With me today is Frank Gillespie, the Director for the
7	Division of License Renewal, also Dr. P.T. Kuo, who is
8	the Deputy Director for the Division of License
9	Renewal. To my right is Mr. Dan Merzke. Dan will be
10	leading the staff's presentation this morning. We
11	also have Mr. Peter Wen, who was the Audit Team Leader
12	for the Aging Management Program on site audits. We
13	also have Ms. Patricia Lougheed, who is the Region 3
14	Team Leader, so is also available to answer questions.
15	We also have a lot of staff in the
16	audience here to support any questions that may come
17	up. We've got a lot of excellent support from the
18	staff and we certainly appreciate their efforts. The
19	staff has conducted a detailed and thorough review of
20	this application that was submitted in March of 2005.
21	Throughout this review we I'd like to acknowledge
22	the Monticello staff. They provided excellent support
23	to us throughout our audits, our inspections, our
24	responses to request for additional information. As
25	Dr. Bonaca indicated, this application wound up being
	1

(202) 234-4433

	9
1	about 95 percent consistent with GALL.
2	Monticello submitted their application
3	based on the draft Rev 1 version of the GALL report
4	which was issued in January of 2005. During our
5	review, we had to reconcile any differences that
6	occurred when the final version was done in September
7	of 2005 and they worked with us and the staff to
8	reconcile those differences and that really helped out
9	with our review. As Dr. Bonaca indicated, we issued
10	the initial SER back in April of 2006. There were no
11	open or confirmatory items. As a result of that, we
12	were able to accelerate the schedule and we appreciate
13	the ACRS accommodating us in accelerating the
14	schedule, both for the subcommittee and now again for
15	the full committee for this application that was under
16	review.
17	With that, I'll turn it over to Mr. Pat
18	Burke, who is the Manager of Projects to lead the
19	Applicant's presentation.
20	MR. BURKE: Thank you, Jake, and thank you
21	members of the ACRS full committee for allowing us to
22	speak on behalf of the Monticello Nuclear Generating
23	Plant for the license renewal application. We have a
24	short presentation today and we'll start with
25	introduction to the folks that we brought here to
I	I contraction of the second seco

(202) 234-4433

	10
1	support the meeting. Today we have
2	MEMBER APOSTOLAKIS: Are you speaking on
3	behalf of them? What did you mean by that? You're
4	NRC, right?
5	MR. BURKE: No, I am the licensee.
6	CHAIRMAN WALLIS: No, George, when it
7	comes in color and with pictures, it's the licensee.
8	(Laughter)
9	MR. BURKE: So the folks I'm going to
10	introduce now are all members of the Monticello
11	Nuclear Generating Plant. I'll start with Mr. John
12	Grubb, who is our Director of Engineering. Again, I
13	am Patrick Burke, the Manager of Projects up at
14	Monticello. Joe Pairitz is the License Renewal
15	Project Manager; Ray Dennis, who is in the gallery
16	back here, is our License Renewal Civil and Structural
17	Lead. We also have Ron Siepel, who is our Electrical
18	Lead as well as Jim Rootes, who is our Programs Lead.
19	Mike Aleksey is our Time Limiting and Aging Analysis
20	Coordinator. Dave Potter is the Engineering
21	Supervisor of Inspections and Materials and then from
22	other sites within the NMC today, we have Gene
23	Eckholt, who is a Perry Island (phonetic) Licensing
24	Lead and Bob Vincent who is the Palisades Project
25	Manager and they're observing today.

(202) 234-4433

	11
1	We've got a short agenda. We're going to
2	start with a description of the Monticello Nuclear
3	Generating Plant just to refresh your memory on what
4	Monticello. Major plant we're going to go over
5	some major plant enhancements. I'm going to talk a
6	little bit about the project application and
7	background, how we got to where we are today and then
8	Joe will be discussing some of the ACRS subcommittee
9	follow-up items specifically the shroud neutron
10	fluence and dry well shell integrity discussions and
11	we'll close with commitment tracking and
12	implementation status.
13	At this point, I'd like to turn it over to
14	Mr. John Grubb.
15	MR. GRUBB: All right, thank you, Pat, and
16	again, Committee, we appreciate the opportunity to
17	speak with you this morning about the Monticello
18	license application. What we have here is just an
19	aerial view of the Monticello Station. The plant is
20	located roughly 30 miles northwest of Minneapolis.
21	It's on the banks of the Mississippi River. You see
22	the intake here, the discharge back from the
23	Mississippi River, Substation, Reactor Building,
24	Turbine Building, Cooling Towers, a pretty compact
25	site.
	1

(202) 234-4433

	12
1	The Plant is owned by Northern States
2	Power Company which is a subsidiary of Xcel Energy and
3	the plant is operated by the Nuclear Management
4	Company. We have an onsite staff of approximately 420
5	employees. The plant is a single-unit General
6	Electric BWR-3 with a Mark 1 containment. Our
7	preliminary license was issued in September of 1970
8	and commercial operation began in June of 1971. The
9	plant's licensed thermal power is 1,775 megawatts.
10	Net electrical output is approximately 600 megawatts
11	electric. The plant does operate on two-year fuel
12	cycles.
13	Currently our material condition is
14	outstanding, it's very, very good. On day 512 of our
15	current operating cycle, the plant has run
16	continuously since the last refueling outage. We've
17	had no operational transients during this cycle.
18	We've had no significant equipment challenges during
19	this cycle. Additionally, the plant has had superb
20	fuel reliability throughout the last 20 years. With
21	that, I'd like to turn it back to
22	MEMBER POWERS: None of those items you
23	mentioned speak to the issue of material condition.
24	The fact that it's run doesn't mean that the materials
25	are in good shape.
	1

(202) 234-4433

	13
1	MR. GRUBB: Yeah, we'll discuss the
2	material condition in the rest of the presentation.
3	This is kind of an overview.
4	MR. BURKE: The next part we want to talk
5	about is some of the plant enhancements that we've
6	done to support material condition for the long term
7	operation of the facility. We have a couple of
8	examples of major components and evolutions that we've
9	taken over the years. In 1984 we did replace all the
10	recirculation piping with material that's resistant to
11	intergranular stress corrosion cracking. Those
12	replacements included risers, supply headers, suction
13	piping and safe-ends. That replacement significantly
14	reduced the number of welds. We also incorporated
15	induction heat stress improvements and electro-
16	polishing applied to the new pipe.
17	In 1986 we did replace the core spray
18	safe-ends, again with material of resistant to
19	intergranular stress corrosion cracking. Those
20	replacements have been successful and we have not seen
21	intergranular stress corrosion cracking on those new
22	pipes.
23	MEMBER POWERS: It's my understanding,
24	correct me if I'm wrong, that there's a significant
25	induction period or the development of evidence on

(202) 234-4433

	14
1	intergranular stress corrosion cracking. Have you
2	gone long enough to I mean, the fact that you
3	didn't observe it doesn't mean you won't.
4	MR. BURKE: Right. It's been 20 plus
5	years. We do continue to inspect it. We have not
6	seen it yet. We do not Dave, do you want to add to
7	that?
8	MR. POTTER: Yes. My name is Dave Potter.
9	The recirc piping, all the welds that are in the
10	recirc piping are categorized as Category A welds
11	according to I believe it's Generic Letter 88-01 and
12	10 percent of those welds by our current inspection
13	methods are still included within our risk informed
14	ISI program so we'll be periodically inspecting both
15	the suction and discharge piping on the recirc system.
16	MR. BURKE: Okay, in 1989 we did implement
17	a moderate hydrogen water chemistry and we have
18	observed fully protection for the vessel internals as
19	a result of that. In 1997 we replaced the emergency
20	core cooling system suction strainers with strainers
21	that have significantly larger surface area for debris
22	loading. In `98 we did a fair amount of work on the
23	condensate pumps and motors. In the last outage, we
24	did replace the recirc pump motor and the pump
25	internal rotating assembly internals which was a major
	1

(202) 234-4433

1 evolution and we are, as of 2005, we are in the two-2 year fuel cycles. Some life cycle management projects 3 that we have in various stages going forward include 4 replacement of feedwater heaters. We are planning to 5 do the 12 recirc pump motor and internals during the We are replacing service water pumps 6 2007 outage. 7 this fall. We have transformers and generator rewinds 8 on the plans. Next I'd like to talk a little bit about 9 the project application and background. 10 When we first 11 started the project, we assembled a core team of site 12 They were site-based. Of those there were employees. about seven folks that we assembled. Four of those 13 14 seven folks had previous SROs or SRO certifications, 15 so it was an experienced staff, multi-disciplined. We onsite staff 16 did supplement that with onsite These contractors did come from various 17 contractors. other sites with license renewal experience. 18 We 19 retained that throughout the audits and team 20 inspections still retain and them to support 21 implementation activities. As mentioned in the 22 opening remarks, we feel that that did provide 23 continuity throughout the review process and gave us 24 good review and good support of those review а 25 activities.

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

1 We contracted with General Electric to 2 perform the reactor pressure vessel and internals time limiting aging analysis. They also performed the 3 4 vessel and internals aging management reviews. And we 5 did have significant site involvement in our aging 6 management reviews and aging management program 7 development through reviews by the system engineers 8 and the program owners. If there's no questions on 9 that part of it, I'd like to turn it over at this 10 point to Joe Pairitz to talk about the ACRS follow-up 11 items. 12 Good morning, I'm Joe MR. PAIRITZ: I'm the License Renewal Project Manager and 13 Pairitz. 14 also the Mechanical Lead for the Monticello Project. 15 I'm going to start off by summarizing our responses to two follow-up items that we had from our May 30 th 16 17 subcommittee meeting, the first concerning shroud There's approximately a factor of 14 18 neutron fluence. 19 difference between the value that was calculated for 20 license renewal and the original 32 effective full 21 power year number that was assumed. So we'll talk 22 about that. Secondly, I'll talk about the dry well 23 24 shell integrity, specifically the location of the sand

pocket drains with respect to the excavation that was

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

25

(202) 234-4433

Í	17
1	done in the late `80s in support of Generic Letter 87-
2	05. Also I'll talk about the configuration of the
3	sand pocket area.
4	CHAIRMAN WALLIS: Did you have any
5	significant corrosion in that area?
6	MR. PAIRITZ: No, we have not found any
7	degradation on the shell.
8	CHAIRMAN WALLIS: I'm trying to remember
9	which one you are. No, you didn't, okay.
10	MR. PAIRITZ: I'll talk about that a
11	little more in detail. Moving back to the shroud
12	neutron fluence question, I'm going to provide an
13	explanation for the relative magnitude difference
14	between the 54 EFPY and 32 EFPY values. For license
15	renewal, we calculated the maximum shroud fluence at
16	3.84 times 10^{21} neutrons per centimeter squared. This
17	was done using the guidance in Reg Guide 1.190. The
18	previous 32 EFPY shroud fluence was 2.7 times 10^{20}
19	neutrons per centimeter squared. That number came
20	from the General Electric Document APED-5460 entitled
21	"Design and Performance of General Electric Oil and
22	Water Reactor Jet Pumps".
23	So after our May 30^{th} meeting, we went
24	back to find out why this factor of 14 was large
25	because it can't just be explained by power increases
1	I contraction of the second seco

(202) 234-4433

	18
1	or time. And what we found was, is that the major
2	contributor to that large 14 factor is the water gap
3	geometry. Monticello has approximately a 1.8 inch
4	minimum water gap. The APED-5460 documents, for their
5	number, they used a 6.7 inch minimum water gap. So
6	that would account for approximately 75 percent of
7	that difference right there. Any questions on that?
8	MEMBER POWERS: Well, there's 25 percent
9	missing, right?
10	MR. PAIRITZ: Right, and that would be
11	accounted for by the difference in the original number
12	assuming we had a 1670 megawatt thermal license power
13	limit, we increase that, then the additional time from
14	32 to 54 EFPY, but the vast majority of it is due to
15	the water gap and that's what we discovered. It took
16	a couple of days and we responded.
17	CHAIRMAN WALLIS: So you were going for
18	several years with a figure which was incorrect
19	presumably.
20	MR. PAIRITZ: Well, it wasn't incorrect.
21	It was the APED-5460 document just listed I would
22	call it a generic number and said, "This is it".
23	CHAIRMAN WALLIS: But it obviously wasn't,
24	it didn't apply to your plant because you have a
25	smaller gap.
	1

(202) 234-4433

	19
1	MR. PAIRITZ: Right, it was yeah, it
2	was based more on a bigger BRW, in fact.
3	With that I'll move onto the dry well
4	shell integrity. Just to give you a brief overview of
5	the Monticello Mark 1 primary containment. I'll use
6	the cursor here, it might be easier than the laser
7	pointer. We have the reactor pressure vessel located
8	here. We have the inverted lightbulb shape of the dry
9	well shell around the reactor pressure vessel. We
10	have the vent tubes that lead to the pressure
11	suppression chamber otherwise known as the torus. The
12	areas that I'm going to concentrate on this morning,
13	we're going to talk about the refueling bellows up
14	here towards the top. We're going to talk about this
15	air gap between the reactor building concrete and the
16	reactor shell, the exterior of the shell, or the dry
17	well shell, pardon me.
18	And then we'll talk specifically about the
19	sand pocket area down here. Monticello has some
20	design features that prevent water from accumulating
21	next to the exterior of the dry well shell if water
22	were to be introduced that area.
23	CHAIRMAN WALLIS: The best thing is to
24	prevent the water getting there in the first place.
25	MR. PAIRITZ: That is exactly right. And
1	I contract of the second se

(202) 234-4433

we'll start from the top and go down. I'm going to start with the refueling bellows and then we'll go 2 down to the air gap and then down to the sand pocket 3 4 region and I'll show you the design features that are there to prevent water from -- really from being there in the first place. 6

7 In the refueling bellows area, just to 8 give you some perspective here, this is the outside of 9 the reactor pressure vessel shell. We have the first set of bellows here that is between the vessel shell 10 and the dry well. We come across, here's the dry well 11 12 shell right here. The bellows that we're most concerned about here are the second set of bellows. 13 14 If there were any leakage from these bellows, that 15 leakage would be caught but this trough down here and then go into this eight-inch pipe. This eight-inch 16 17 pipe does have a flow switch on it, set at three gallons per minute, which does give an alarm in the 18 19 control room also. Now, this other drain listed here, 20 that's how we drain down from normal refueling 21 activities when this reactor cavity is flooded up. 22 That is a normal drain path and it does travel through 23 the inside of the eight-inch pipes. We have a pipe 24 within a pipe.

During normal operation this is normally

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

25

1

5

	21
1	all dry here. The only time this sees water is when
2	we're flooded up for refueling operations. Right here
3	you have the beginning of the air gap region and we'll
4	talk about that next. We have done some testing on
5	these outer bellows in the past in the late `80s. We
6	did some visual inspections, we did some UT's and
7	there was no significant degradation there.
8	CHAIRMAN WALLIS: That air gap connects to
9	what? Is it it must be a vent or something.
10	MR. PAIRITZ: Oh, the air gap, I'll go
11	back to the bear with me a moment here. The air
12	gap is right here, actually.
13	CHAIRMAN WALLIS: It goes all the way
14	around.
15	MR. PAIRITZ: Right, and if we go to the
16	next slide, the next slide here, here's this air gap
17	region here going up all the way to the top of the
18	shell. Now, if water were to come in that region,
19	there are four four-inch drain pipes at the bottom
20	that would drain that water away but again, if we look
21	at the way the refueling bellows is set up, any
22	leakage should go into this trough and into this
23	eight-inch pipe. You shouldn't get any water in the
24	air gap.
25	CHAIRMAN WALLIS: I was thinking of the
	1

(202) 234-4433

	22
1	air expanding and contracting, and the temperature
2	changes. There must be some vent or something which
3	you also keep dry. There must be
4	MR. PAIRITZ: Yeah, there well, the
5	drainpipes. Let's go to the yeah, we'll go to the
6	next picture. The drain pipes at the bottom are open
7	to the atmosphere at the bottom so you can get some
8	air through there.
9	CHAIRMAN WALLIS: Okay, so air comes in
10	and out of there.
11	MR. PAIRITZ: Correct. Now, these four
12	four-inch drain pipes are open. They empty right onto
13	the floor of the reactor building basement or the
14	torus room, so it's first of all, it's obvious if
15	you have any water and then they're open so that
16	CHAIRMAN WALLIS: The air that's saturated
17	out there, comes it and it's hotter inside so it
18	doesn't condense.
19	MR. PAIRITZ: Right, during normal
20	operation the dry well shell is well above ambient
21	temperature. So the air gap region, if water were to
22	get in that region, which would be a big feat in
23	itself, then it would be drained away by these four-
24	inch drain pipes. We've never seen water come out of
25	any of these four four-inch drain pipes. In the sand
	I

(202) 234-4433

1 pocket region, we have an 18-gauge sheet metal cover 2 over the top of the sand pocket region. It is sealed 3 to the reactor building concrete and with the drywall 4 shell. So that is a significant water-tight barrier 5 that is in place. Not every Mark 1 containment has We do have that cover, however. For some 6 the cover. 7 reason, if water did get into the sand pocket region, we have four two-inch drain lines that drain the sand 8 9 pocket region also. Again, we've never -- these drain 10 right into the reactor building basement, again, and we have never seen water come out of those drains, and 11 we do check these drains, both the air gap drains and 12 the sand pocket drains. 13 14 We check them for obstructions before we flood-up for refueling activities and then we check 15 them while we're flooded up to insure that there is no 16 17 leakage coming from those drains. CHAIRMAN WALLIS: The function of the sand 18 19 pocket is what? MR. PAIRITZ: Well, it's called a cushion. 20 CHAIRMAN WALLIS: Yeah, it seems like a 21 22 cushion for this bulb to rest on? 23 MR. PAIRITZ: Right, so for any kind of --24 you know, if you were to have a blow-down or seismic 25 event, it's a cushioning type function. I've heard it

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

	24
1	refer to before as the sand cushion in General
2	Electric documentation.
3	CHAIRMAN WALLIS: It makes more sense than
4	a sand pocket, yeah.
5	MR. PAIRITZ: Right. So we've talked
6	about the design features that we have in place. I'll
7	talk a couple minutes about the excavation of the
8	drywall floor that was done in 1987. And I'm also
9	going to talk about a little bit more well, right
10	now about the UT's that were done for Generic Letter
11	87-05 and the drywall shell. It not only included the
12	sand pocket area and the place that we excavated but
13	we did do UT inspections at other elevations, higher
14	up that would be equivalent to the air gap region and
15	we did not find any degradation in those areas. We
16	have no evidence of any corrosion going on in those
17	areas.
18	One of the questions that specifically
19	came up in our subcommittee meeting was the location
20	of the sand pocket drains compared to where we
21	excavated. These red arrows here represent the sand
22	pocket drains, four of them at those approximate
23	locations. In 1987 we did excavate at this location
24	225 degrees azimuth. It's approximately between these
25	two drains here, so that would be a good place to look

(202) 234-4433

1 if you're trying to find out if any water existed or 2 if there was any corrosion there. Go to the next picture so we can look at this. What we did is the 3 4 excavated region here was 31 inches deep. It was 18 5 inches wide. It exposed the full length of the sand pocket area at that location, 225 degrees azimuth. 6 7 We did UT's there. We did not see any degradation. The other thing I want to point out is 8 9 just the geometry of the sand pocket region itself and I'm going to go back to this other slide. 10 We had a question of whether there was sloping to these drains. 11 12 We reviewed our documentation. We can't find anything to say that there was a slope, but I know that at the 13 14 time this was constructed, Bechtel was the architect 15 engineering. They had general construction specifications that would have required some slope on 16 17 drainage paths. So I think at the best case it's sloped. I think at the worst case, it's level, but 18 19 either way that's okay for us because I want to show 20 that the -- back to this picture -- there is a radial 21 slope on that sand pocket region down to the drain. 22 So if there is any water accumulating here, it would 23 be in the drain area first. 24 And in order for the water to get up to

the top, or get to the area of the shell, the drain

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

25

(202) 234-4433

1 line would have to be overflowing. There's a little 2 stand pipe on the end of this drain and it's at the 3 same elevation as the inlet here. So in order to have 4 water up at the interface between the shell and the 5 sand pocket, we'd have to have water overflowing into the reactor building basement and we would see that. 6 7 CHAIRMAN WALLIS: I suppose it wicks up 8 through the sand, doesn't it? 9 That's another purpose of MR. PAIRITZ: 10 the sand also. It should help absorb moisture if there were moisture. 11 12 MEMBER POWERS: Isn't he asking an inferred question? 13 I mean, you say it has to 14 overflow. Doesn't capillary action just take it up 15 the wall and make wet when not even you're 16 overflowing? 17 CHAIRMAN WALLIS: Yeah, it wicks up through the sand. 18 19 MR. PAIRITZ: Yeah, you would see it in 20 the sand, but I mean, you couldn't -- it still 21 wouldn't be in contact with the dry well shell. 22 CHAIRMAN WALLIS: But there would be 23 moisture there, yes, there would. 24 MEMBER ARMIJO: How hot is that area? 25 MR. PAIRITZ: Well, let's go back to a

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

	27
1	picture we can look at here. You know, the shell here
2	you know, the average dry well temperature is about
3	135 degrees when we're running. So you're going to
4	get some conduction down into this area. I can't tell
5	you off the top of my head what the actual temperature
6	would be here but it stands to reason that at least in
7	this area were that we're going to get some conduction
8	and some heat from that area.
9	CHAIRMAN WALLIS: So damp sand which is
10	part water, part air is probably worse than pure water
11	or pure air. I mean, you've got both constituents
12	there.
13	MR. PAIRITZ: We shouldn't have any water
14	there.
15	CHAIRMAN WALLIS: So the question about
16	wicking and capillary action is not really relevant.
17	I don't think you have a problem here but that's
18	something you ought to think about.
19	MR. PAIRITZ: Yes.
20	CHAIRMAN WALLIS: Just thinking about
21	levels doesn't really answer the question about
22	whether there's moisture on the surface isn't
23	MR. PAIRITZ: Correct, we're thinking of,
24	you know
25	CHAIRMAN WALLIS: there's a whole

(202) 234-4433

	28
1	theory of
2	MR. PAIRITZ: gross failure that would
3	allow water into a region, no. Now, moisture from
4	humidity in the air or something like that
5	CHAIRMAN WALLIS: The dirt that your
6	houseplants are in is damp, but it's not wet.
7	MR. PAIRITZ: Correct.
8	CHAIRMAN WALLIS: It's still corrosive.
9	MR. PAIRITZ: Okay, so we talked about the
10	design features. We talked about the excavation of
11	the floor. I'm now going to spend a few minutes
12	talking about commitment tracking and our
13	implementation status.
14	MEMBER BONACA: Before you move on
15	MR. PAIRITZ: Yes.
16	MEMBER BONACA: Your refueling ceiling is
17	within the scope of license renewal, right?
18	MR. PAIRITZ: That is correct.
19	MEMBER BONACA: So, I mean, you're
20	monitoring water leakage during the outages.
21	MR. PAIRITZ: Right, we do have that flow
22	switch, so that would be an indication that three
23	gallons per
24	MEMBER BONACA: So that's an option that
25	GALL gives you, right?
l	I contraction of the second

```
(202) 234-4433
```

	29
1	MR. PAIRITZ: Pardon me?
2	MEMBER BONACA: That's an option that GALL
3	will give you.
4	MR. PAIRITZ: Right, you could put your
5	refueling ceiling. Ours is in and we do plan on
6	MEMBER BONACA: So the fact that you don't
7	have UT doesn't mean you're not meeting the
8	expectation of inspections.
9	MR. PAIRITZ: That's correct.
10	MEMBER BONACA: You're doing inspections
11	of that type. Thank you.
12	MR. PAIRITZ: Going back to commitment
13	tracking and implementation status; Monticello made 60
14	commitments to enhance the aging management at
15	Monticello. These commitments are described in our
16	license renewal updated safety analysis report
17	supplement. They will be in our USAR. All the
18	commitments are entered into the Monticello corrective
19	action program. Each commitment has an owner and a
20	due date. And as far as implementation status goes,
21	we do have an implementation schedule in place. We
22	are currently working on implementation activities.
23	We have due dates and assigned personnel. We have
24	inspections scheduled for our 2007 and 2009 outages in
25	the area for the one-time inspections and selective

(202) 234-4433

1 leaching inspections. So we feel we're making 2 progress in that area and that we will meet our 3 commitments. 4 Most of our aging management programs 5 already exist, just require some minor revision to meet the requirements of license renewal. 6 Right now, 7 we're looking forward to getting our renewed license and meeting our commitments and proceeding into the 8 period of extended operations. With that, I'll ask 9 10 for any further questions. MEMBER ARMIJO: When you did your UT in, 11 1987, what did you find as far as 12 I quess, the thickness of the shell? 13 14 MR. PAIRITZ: We could not differentiate 15 between what we found and the original thickness of the material when it was new was what it came down to, 16 with the tolerances of the new material that fell into 17 18 that region. 19 MEMBER BONACA: If I remember it was still in excess of nominal. 20 21 MR. PAIRITZ: Correct. 22 MEMBER ARMIJO: Do you have any planned 23 inspection of that region at all during the period of 24 extended operation? 25 MR. PAIRITZ: Not UT inspection. As part

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

	31
1	of the IWE program, we do visual inspections on the
2	interior of the dry well. I don't know if you want to
3	go
4	MEMBER ARMIJO: Just a question.
5	MR. PAIRITZ: There is a draft ISG out
6	there right now, too, which gives some direction in
7	that area. They recommend they direct you to do
8	UT's if you believe that you may have water in an
9	inaccessible area with the exterior of the shell or if
10	you have evidence of water. So we will follow the ISG
11	in that area.
12	MEMBER SIEBER: But on the inside of the
13	containment where the sand pocket is, that's covered
14	with concrete.
15	MR. PAIRITZ: That's correct.
16	MEMBER SIEBER: So there's nothing to see.
17	MR. PAIRITZ: Not much excavated the
18	floor. If we had sand pocket drainage, you know, if
19	we saw leakage from out sand pocket drains, then that
20	would be reason to go dig up the floor.
21	CHAIRMAN WALLIS: Are those drains or sand
22	pocket have a standpipe, you say? Is there something
23	there that is kept full of water so that air doesn't
24	get
25	MR. PAIRITZ: No, it's full of sand,
	I contraction of the second

(202) 234-4433

	32
1	actually.
2	CHAIRMAN WALLIS: Full of sand. I was
3	just thinking, suppose you got water in there, the
4	corrosion would soon eat up all the oxygen in the sand
5	and then unless you've got air coming in, corrosion
6	presumably would stop.
7	MR. PAIRITZ: Right.
8	MEMBER POWERS: Hopefully.
9	MR. PAIRITZ: Then it becomes the question
10	of the porosity of the sand and how much air it would
11	allow in.
12	CHAIRMAN WALLIS: Right, it takes an
13	ingress of air as well as water.
14	MEMBER SIEBER: Sounds like thesis
15	material.
16	CHAIRMAN WALLIS: Well, this is
17	undoubtedly a topic we'll come back to with other
18	BWRs.
19	MEMBER BONACA: Yeah, and remember we
20	in some cases we have recommended UT's because they
21	have experienced water leakage and so I believe a
22	preferred way of the NRC has been to monitor water
23	leakage and, in fact, monitor the bellows and the
24	seals and then to prevent the leakage at all.
25	MR. PAIRITZ: I think a thing to remember

(202) 234-4433

	33
1	also is on this diagram, you know, there are many
2	barriers that would have to fail in order to get water
3	into the sand pocket region, at least from the upper
4	areas like through the refueling bellows. I mean, the
5	sheet metal cover on top of the sand pocket is a
6	water-tight barrier. You've got the air gap drains.
7	We had that trough at the top of the drain line from
8	the refueling bellows. There are many barriers in
9	place to prevent water from ever getting to that
10	point.
11	MEMBER ARMIJO: You can't inspect that
12	joint sealing compound. That region in there really
13	is not
14	MR. PAIRITZ: That's in concrete also.
15	MEMBER ARMIJO: Yeah, it's really
16	inaccessible, so you can't really count on it that
17	it's a seal.
18	MR. PAIRITZ: All we can say is that it
19	was installed that way and it is a galvanized sheet
20	metal surface and the joint sealing compound was used
21	to insure that that was a water tight barrier when it
22	was installed.
23	MEMBER MAYNARD: Where does the eight-inch
24	pipe drain to?
25	MR. PAIRITZ: Yeah, let me go to that
1	

(202) 234-4433

	34
1	again. This eight-inch pipe here, it goes to our rad
2	waste system.
3	MEMBER MAYNARD: And is that the one that
4	has the alarm on it?
5	MR. PAIRITZ: That's correct.
б	MEMBER MAYNARD: Do you have any other way
7	okay, I guess any water that gets into there,
8	couldn't get around the shell. That's going to drain
9	away with
10	MR. PAIRITZ: Well, we have to overflow
11	this trough in order to get any water into the air gap
12	region.
13	MEMBER MAYNARD: Yeah, okay.
14	MR. PAIRITZ: So you'd have a gross
15	failure of that bellows in order to get water over
16	into the air gap. So not only would the alarm go off
17	but you'd probably see level dropping in the reactor
18	cavity so that would be
19	MEMBER MAYNARD: But the alarm set point
20	is for a sizable leak.
21	MR. PAIRITZ: Right, three gallons per
22	minute.
23	MEMBER MAYNARD: And I'm wondering about
24	a leak below that level as to what indication you
25	would have of that if it all goes down that eight-inch
	1

```
(202) 234-4433
```

	35
1	pipe.
2	MR. PAIRITZ: The only thing we would have
3	to monitor that would be our level of the reactor
4	cavity.
5	MEMBER MAYNARD: Yeah.
6	MR. PAIRITZ: But like I said, we did do
7	inspections on these bellows in the late `80s both
8	visual and UT and found them to be in fine shape, no
9	degradation detectable.
10	MEMBER BONACA: Any other questions? If
11	not, thank you and we'll hear from the staff now.
12	MR. PAIRITZ: Thank you very much.
13	MR. ZIMMERMAN: Dan Merzke will lead the
14	staff's presentation on the license renewal
15	application for Monticello. All right, regarding the
16	ISG, I just wanted to let the Committee know that we
17	are in the process of finalizing the ISG on the dry
18	well shell. We did receive some comments from
19	industry and we've worked through those comments and
20	we plan to issue the final ISG this fall. Probably
21	late September, early October that ISG will be coming
22	out.
23	MR. MERZKE: All right, good morning. My
24	name is Dan Merzke. I'm the Project Manager for the
25	staff review of the Monticello Nuclear Generating
l.	

(202) 234-4433
Plant license renewal application. As Jake mentioned earlier today, joining me today is Patricia Lougheed who is the Inspection Team Leader from Region 3, Peter Wen, who is the Audit Team Leader and the rest of the technical staff who were involved in the review of this application.

7 Today, I'll cover a brief overview of the review, cover some highlights of the review and 8 9 briefly touch on the review of the time limited aging analyses and follow that up with the staff conclusion. 10 Most of this you've already heard today already. 11 The 12 application was submitted by letter to the agency dated March 16th, 2005 by the Nuclear Management 13 14 Company. Monticello is a General Electric BWR 3 Model with a Mark 1 steel containment. The plant is rated 15 16 1775 megawatts thermal with a 600 megawatt at electrical capacity and that includes a 6.3 percent 17 power uprate which was approved by the NRC in 1998. 18

19 The current operating license expires 20 September 8th, 2010 and the plant is located about 30 21 miles northwest of Minneapolis, Minnesota. The staff 22 conducted their GALL audits in June and July of 2005. 23 The region based their inspections in January and 24 February of this year, two weeks on site per each. 25 The initial safety evaluation report by the staff was

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

3

4

5

6

issued on April 26 th of 2006 with no open or confirmatory items. As you heard before, the staff issued a total of 113 formal RAIs during their review which was a somewhat lower than normal review. Part of this is based on the fact that the application was about 95 percent consistent with GALL Revision 1 which was issued in September of 2005.

The final Safety Evaluation Report was 8 issued July 28th with a total of 60 commitments and 9 three license conditions. The commitments will be 10 implemented prior to the prior of extended operations. 11 12 The three license conditions are to include the updated safety analysis report supplement and the next 13 14 update of the USAR following issuance of the renewed 15 license and to complete the list of commitments that are listed in Appendix A of the SER in accordance with 16 the schedule that's in Appendix A. 17

finally, for the reactor vessel 18 And 19 surveillance program, all capsules must be maintained 20 for future reinsertion into the reactor pressure 21 vessel. And any changes to the capsule withdrawal 22 schedule must be submitted to the NRC for review and 23 approval. During the review, the staff concluded that 24 the Applicant's scoping methodology met the 25 requirements of 10 CFR 54 and the scoping and

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

3

4

5

6

7

(202) 234-4433

1 screening results included all system structures and 2 components within the scope of license renewal and 3 subject to aging management review. During the 4 scoping and screening methodology audit, the audit 5 team reviewed the currently licensing basis for floor control measures and determined that storage steel 6 7 plates and floor hatches that were designed to be installed for flood control were not included within 8 9 the scope of license renewal. The Applicant initially did not include components stored in the warehouse 10 within the scope of license renewal. 11

12 After further evaluation and extent of condition review, Applicant 13 the brought these 14 components into the scope of license renewal. Walkdowns conducted during the license renewal inspections 15 resulted in a length of steam piping in a steam trap 16 in the emergency diesel generator room being brought 17 into scope as well as floor drains in the sodium 18 19 hypochlorite building which penetrated the flooring to 20 intake structure. And those were the only the 21 components that the staff found were not in scope 22 originally.

The Applicant is committed to following the BWRVIP guidelines through the period of extended operations as outlined in Commitment Number 57. The

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	39
1	examples include BWRVIP-139 for steam drier
2	inspections and BWRVIP-26 for top guide inspections.
3	In addition to the guidelines set forth in BWRVIP-26,
4	the Applicant also committed to perform additional top
5	guide inspections in the high fluence region.
6	CHAIRMAN WALLIS: While you're mentioning
7	steam driers, is this one of those which has not had
8	problems with the steam drier?
9	MR. MERZKE: That is correct.
10	CHAIRMAN WALLIS: Has there been any
11	observed cracking?
12	MEMBER BONACA: There is some cracking.
13	MR. MERZKE: There is some minor cracking
14	as I recall, found in the 2005 outage but, Dave, do
15	you want to mention
16	MR. POTTER: Yeah, I'm Dave Potter from
17	Monticello. We found what I would call what I
18	would characterize as four minor indications on the
19	steam drier and there are believed three of them
20	are believed to be original fabrication induced flaws.
21	MR. MERZKE: Concerning aging management
22	of the dry well, the Applicant credits the primary
23	containment in-service inspection program which the
24	staff determined is consistent with GALL AMP ASME
25	Section 11, Subsection IWE. Around the time the

(202) 234-4433

40 1 initial SER was issued, the staff issues proposed 2 license renewal ISG 2006-01 regarding the inaccessible areas of BWR Mark 1 steel containment dry wells. 3 In a letter dated June 23rd, 2006, the Applicant amended 4 5 its primary containment in-service inspection program to incorporate the points outlined in the proposed 6 7 license renewal ISG. In response to the ISG, that Applicant verified that ultrasonic testing performed 8 in the sand pocket region in 1986 and 1987 detected no 9 degradation. 10 In addition, the Applicant verified that 11 12 no water or moisture has been identified in the air gap or sand pocket region and that leakage monitoring 13 14 is performed for all drains in accordance with plant 15 Drains are verified open and no leakage procedures. 16 detected every refueling outage. If leakage is the 17 detected, Applicant will perform auqmented inspections consistent with the quidance in ASME 18 19 Section 11, Subsection IWE 1240. MEMBER APOSTOLAKIS: What do they involve. 20 21 MR. MERZKE: Which would include UT 22 inspections. 23 MEMBER APOSTOLAKIS: Thank you. The staff found that 24 MR. MERZKE: 25 Applicant's program for managing aging effects of the

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1 dry well acceptable. Concerning aging management of 2 in-scope inaccessible concrete, the Applicant stated 3 and the staff verified that the below grade 4 environment is non-aggressive. Periodic testing of 5 the groundwater will be performed as part of the structure's monitoring program. 6 7 As part of our review of the Applicant's time limited aging analysis, the following table 8

9 summarizes the upper shelf energy for the limiting 10 belt line components. Acceptance criteria for upper 11 shelf energy is greater than 50 foot pounds. The 12 Applicant has demonstrated and the staff has verified 13 that the upper shelf energy for the limiting belt line 14 components at Monticello will exceed 50-foot pounds at 15 the end of the period of extended operations.

16 VICE CHAIR SHACK: Now, is this computed 17 on Rev 2 of 199 or the upcoming Rev 3?

18 MR. MERZKE: Matt Mitchell is going to19 take this for component integrity.

20 MR. MITCHELL: Yeah, Matt Mitchell, Chief 21 of the Vessels and Materials Integrity branch. This 22 is definitely computed in accordance with Rev 2, which 23 is our current review basis and review standard for 24 all things related to Appendix G issues. So this is 25 using those correlations.

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	42
1	VICE CHAIR SHACK: Now, what happens when
2	you change the basis? You have to do a back-fit now
3	to have them do an analysis?
4	MR. MITCHELL: Well, with respect to any
5	future changes to Regulatory Guide 199, Rev 2 going to
6	Rev 3, which I'm sure that the ACRS is aware is sort
7	of an in-process activity, the staff is going to have
8	to evaluate what type of follow-up actions we may feel
9	necessary to take when that new revision is issued.
10	If you go back to the last time that we revised Reg
11	Guide 1.99, the staff issued a companion generic
12	letter which requested that licensees re-evaluate
13	their vessel integrity analysis in accordance with the
14	revised regulatory guide. At this time, barring any
15	other precedent, I would suggest that that may be, in
16	fact, the course we intend to take for a future
17	revision of the reg guide.
18	MR. MERZKE: Thanks, Matt. It seems kind
19	of short but to summarize on the basis of its
20	evaluation of the license renewal application, the NRC
21	staff has concluded that the requirements of 10 CFR
22	5426A have been met. Does anybody have any further
23	questions?
24	MEMBER BONACA: I would like to add that
25	during the subcommittee meeting we had presentations
	1

(202) 234-4433

	43
1	from the inspectors and they pointed out they were
2	very positive regarding this site. I don't know if
3	there are any comments that
4	MR. MERZKE: Patricia, she has no further
5	comments. I participated in the inspections and we
6	did a 100 percent review of all the aging management
7	programs on site and I think Patricia would agree, the
8	material condition of the plant was at least above
9	average.
10	CHAIRMAN WALLIS: Well, thank you.
11	MR. MERZKE: We don't like to give out top
12	grades to anybody.
13	MEMBER POWERS: I see.
14	MEMBER ARMIJO: I had a quick question.
15	The what are your criteria, what constitutes
16	leakage? Is it prolonged leakage? Is it large
17	quantities of leakage? To trigger excavation and UT,
18	you know, there's got to be some potential damage to
19	the shell. So and that's not going to happen with one
20	leak event unless it's prolonged, undetected, you
21	know, what are your criteria there?
22	MR. MERZKE: I believe the criteria, and
23	Hans can probably speak to this better than I can but
24	the criteria probably that would be followed would be
25	the ASME Section 11 IWE 1240 criteria. I think it
I	

(202) 234-4433

44 1 specifies in there and I'm reaching back, that there 2 has to be some sort of excess leakage and Hans maybe 3 might --4 MR. GILLESPIE: Let me address that. This 5 is Frank Gillespie. This is exactly the point of the IHG we put out and what the IHG says is it tries to 6 7 equate any evidence of moisture seen coming from those drains and the ISG basically says any leakage to the 8 same thing as identified corrosion which is seen in 9 the visual inspection from the inside. 10 And the IWE already requires ultrasonics if you see enhanced 11 12 corrosion problems on the inside and there was no equivalent kind of criteria for the outside. 13 14 So the ISG that the staff issued basically 15 equates any moisture that's visible coming from those drains to actually seeing any kind of corrosion on the 16 17 inside and the ISG attempts to equate those two and then uses exactly the same criteria as the 18 IWE 19 relative to ultrasonic testing being required. 20 MEMBER ARMIJO: So one event that had some 21 leakage detected in one or more drains let's say even 22 for a period of a couple of days, that would trigger 23 a UT inspection and excavation? 24 MR. GILLESPIE: Not necessarily an 25 excavation but a UT inspection. That's the way the

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	45
1	ISG is written right now.
2	MR. MERZKE: It would depend on if the
3	Applicant believed that the moisture leakage entered
4	the dry well or the sand pocket region. I think
5	that's the area that would need to be excavated.
6	MR. GILLESPIE: Now, you need to look at
7	the uniqueness of this design because this plant does
8	have that seal and the galvanized material over the
9	sand pocket and what we're going to be doing is coming
10	to the Committee or the subcommittee next month on
11	Oyster Creek who removed the sand from the sand pocket
12	because they didn't have the seal to allow the
13	leakage, if there is any, to drain directly through.
14	MEMBER ARMIJO: Yeah, but, you know, this
15	corrosion takes time. It doesn't happen
16	instantaneously and I just wanted to know if you had
17	a time
18	MR. GILLESPIE: I think what you're seeing
19	is the ISG is very conservatively written. We've got
20	a licensee who, for 30 years of operation has seen no
21	leakage and if we see leakage in one of these
22	operations it's going to be a point for discussion.
23	So the ISG sets a very, very high standard on
24	something no one expects to happen and the intent,
25	quite honestly, encourages keeping that seal in good

(202) 234-4433

	46
1	shape, keeping it dry and that's
2	MEMBER BONACA: I would expect you would
3	allow an engineering evaluation of the leakage and the
4	actions taken to prevent further leakage. I mean
5	MR. GILLESPIE: Yeah, I'm not saying we
6	wouldn't allow it. I'm saying the way the ISG is
7	written right now, it's a very conservative ISG and
8	basically equates water in that gap that's detected
9	with seeing enhanced corrosion on the inside with the
10	visual inspection. It just equates those two. It
11	puts an equal sign to them.
12	MEMBER BONACA: Yeah. Any further
13	questions to members? If not, I mean, I would like to
14	be recognized, Mr. Chairman, for giving it back to you
15	with 40 minutes and I didn't do much about that.
16	CHAIRMAN WALLIS: Thank you very much. We
17	aren't allowed to start the next item until the time
18	scheduled which is 10:15. What I've asked Mike Junge
19	to do is to hand out to you a draft letter, if that's
20	okay with you, Mario, hand out to the Committee the
21	draft letter you prepared on this matter and ask the
22	Committee during the break which is going to be almost
23	an hour, to read it and if you have any comments, give
24	them to Mario, so that we can get ahead of the game on
25	this letter and maybe finish it very quickly if you're
	I contract of the second s

(202) 234-4433

	47
1	in agreement with it, this evening. So we're going to
2	do that. It's the same one that you sent. You
3	haven't changed it from the draft? What's the status
4	of this letter?
5	MALE PARTICIPANT: They're making copies
6	of it.
7	CHAIRMAN WALLIS: We'll take a break until
8	10:15 and look for this letter, if you don't have a
9	copy.
10	MEMBER MAYNARD: Mr. Chairman, I would
11	just like to compliment both the staff and the
12	licensee. I think they directly addressed
13	CHAIRMAN WALLIS: Quiet, quiet.
14	MEMBER MAYNARD: they directly
15	addressed questions that had come up in the
16	subcommittee meeting. They took them head on and
17	brought them to the Committee. So I'd like to
18	compliment both the staff and the licensee for that.
19	CHAIRMAN WALLIS: Thank you very much.
20	All right, now we're going to take a break now. 10:15,
21	come back here at 10:15.
22	(A brief recess was taken at 9:26 a.m.)
23	(On the record at 10:18 a.m.)
24	CHAIRMAN WALLIS: Please come back into
25	session. The next item on the agenda is the Lessons

(202) 234-4433

	48
1	Learned from the Review of the Early Site Permit
2	Applications. I turn to my distinguished colleague
3	Dana Powers, to lead us through this one.
4	MEMBER POWERS: Thank you, Mr. Chairman.
5	We, as you are aware, have reviewed three early site
6	permits and found the process to be generally a smooth
7	one. Generally, we have written reports as we're
8	required by law to do, on the safety portions of these
9	applications in which we have complimented both the
10	staff and the Applicant on the quality of their
11	application and the safety evaluation report.
12	We have, on occasions, noted places where
13	the application and the report could be improved.
14	We've raised some issues, perhaps, to be addressed in
15	the future but by and large, we've found it a very
16	positive experience. Nevertheless, we felt it would
17	be opportune since this was a first of a kind
18	application of this revised regulation, to have a
19	lessons learned session to see if there were things of
20	a generic nature that might be improved. This is
21	especially so since we knew well that the early site
22	permit process is a subset of the process that would
23	be associated with a combined license and anticipated
24	that there might well be combined licenses showing up
25	in the near future.

(202) 234-4433

	49
1	At any rate, we scheduled and held such a
2	lessons learned session yesterday. Many of you
3	attended, are familiar with it. The staff made a
4	presentation which will be reproduced and enhanced and
5	augmented here. I'll also note that each of the
6	applicants made a presentation and the staff shall try
7	to indicate those portions of the points made by the
8	applicants that they feel they need to address. We
9	reviewed a variety of different issues and whatnot.
10	I think one of the findings that we came away from it
11	is recognition that an application consists of two
12	parts; those that deal with safety and those that deal
13	with environment and we focused strictly on the safety
14	ones and many came away feeling that the safety is in
15	better shape than the environment. I don't know.
16	But with that introduction, I'll ask the
17	staff to discuss their lessons learned and what they
18	drew from our review.
19	MR. ARAGUAS: Good morning, my name is
20	Chris Araguas and as I mentioned yesterday, I work in
21	NRR and I'm one of the newer members of the Early Site
22	Permit Review Team. As Dana mentioned yesterday, we
23	went through the staff identified lessons learned
24	and I plan to go over those in a little bit less
25	detail today to the extent that that's acceptable to
	I

(202) 234-4433

1 the ACRS. Following that, we will attempt to discuss 2 lessons learned that were identified by the the 3 applicants and will attempt, to the extent possible, 4 to address either what the staff is doing now or what 5 it plans to do in the future. Before I move onto what the lessons 6 7 learned, I find it's important to go over what the staff is currently doing in terms of updates. 8 In 9 light of the lessons learned that we've identified during the ESP process, we are currently undergoing an 10 update to the standard review plan as well as updating 11 12 the guidance for COL applicants in terms of what's required for a COL application. Regarding the 13 14 guidance out there for ESPs now, which is the RS002, 15 the plan is actually to capture any deficiencies that

were identified with that document and capture that in 16 So the SRP will be the guidance for the tech 17 the SRP. staff in terms of reviewing ESP applications, COL 18 19 applications and design certifications.

20 As far as the RS002, what the staff plans 21 to do, it's not going to go away completely but what 22 it will do is within the document, it will contain a 23 matrix identifying the applicable SRP sections that are required for an ESP application review. 24 So with 25 that I'll move onto the staff lessons learned. The

> **NEAL R. GROSS** COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1 first lesson learned that we identified was a need to 2 establish criteria in terms of how to identify a site characteristic and a controlling plant parameter 3 4 envelope value included in ESP. During the review 5 there was some confusion as to what exactly should be included in the permit and as a result, the staff has 6 7 actually been able to characterize what the criteria is for site characteristic and what a controlling PPE 8 9 should look like.

10 These criteria were presented in a May 5th. 11 2005 NEI meeting as well as previous ACRS meetings to support the ESP reviews. 12 The staff recognized the importance of having these definitions 13 14 and criteria embedded within staff review quidance and 15 therefore, is making sure to capture these definitions and criteria in the SRP update as well as the RS002. 16 The second staff lesson learned was regarding permit 17 conditions and COL action items. 18 The staff recognized 19 that there was a need to put out criteria for how to 20 identify a permit condition and a COL action item for 21 the staff. During the reviews, we did come up with 22 that criteria and prior to issuing the -- any of the 23 FSERs, the staff did a scrub-through of making sure 24 that it correctly identified what a permit condition 25 was, what it should look like, and making sure that it

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

	52
1	correctly identified the COL action items. The
2	follow-up to that is these criteria will also be put
3	into the SRP update as well as the RS002.
4	MEMBER POWERS: There's no we had
5	reviewed those as a committee and found then
6	praiseworthy, thought it was a good measure on your
7	part.
8	MR. ARAGUAS: Thank you. The third lesson
9	learned and this was a combination between comment and
10	lesson learned, and that was the Commission's
11	expectations for high quality applications. The
12	comment really we wanted to put out to industry and
13	for future reviews is that we're expecting that any
14	RSP or COL application that comes in certainly will
15	have done a review of what was done at the SP stage in
16	terms of the RAIs that the staff issued, how those
17	RAIs were addressed, the open items that came out and
18	then any other safety issues that came out of the ESP
19	so that they're aware or able to incorporate this into
20	their applications that may be coming in, that way to
21	support a more efficient review of any future ESP and
22	COL applications.
23	The lesson learned here is that the staff
24	recognizes that it too has a role in industry being
25	able to support the submittal of these high quality
	1

(202) 234-4433

(202) 234-4433

applications and therefore, as a result the staff has, as I mentioned before, taken on and endeavored to provide these updates to reg guides that are supporting new reactor licensing, updating the Reg Guide 1.70 in the form of DG-1145 and completing the proposed Part 53 rulemaking.

7 The fourth lesson learned that I wanted to mention was a combination of several different areas 8 9 where the staff identified where it needed to update 10 its review quidance to capture what we felt was -well, to capture the first of a kind review process, 11 issues identifying that first of 12 a kind review And the first item that I have listed and 13 process. 14 I've already gone through, I don't know if there's any more discussion that needs to be had on that, but that 15 was basically that the staff needed to capture the 16 criteria for site characteristics, controlling PBEs, 17 COL action items and permit conditions in appropriate 18 19 review guidance.

The second item we had listed down was the performance based methodology for seismic hazards. And I'm just briefly going to go over where this comment comes from or this lesson learned, is this came out of the Clinton ESP application review where Clinton submitted a new performance based methodology

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

3

4

5

6

1 the staff had not previously reviewed and in light of 2 this, the staff encountered some delays as far as how 3 long they would take to complete its review having to 4 look at a new methodology. The end result was that 5 the staff found that this methodology was acceptable. It realized that we don't want to encounter these 6 7 kinds of future delays down the road for another potential ESP or COL applicant that's going to 8 reference this performance based methodology. So the 9 staff has taken on the approach of developing an 10 update to Reg Guide 1.165 in the form of DG-1146 which 11 12 will capture this performance based methodology. The next item I had was the major features 13 14 of the emergency plan and there was certainly a lot of 15 discussion yesterday in regards to what the staff is currently doing and hopefully, I'll be able to capture 16 17 all of those items. During the previous three ESP applications, several questions were raised regarding 18 19 the major features option. Three questions that 20 seemed to be a common theme were regarding the level 21 of review being conducted under the major features 22 option for applicants that reference an approved 23 emergency plan for an existing nuclear power plant co-24 located to the site. Another was regarding the 25 definition of major features.

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

1 And the last item was the level of _ _ 2 regarding the level of finality that an applicant receives under the major features option. 3 To address 4 the first comment, the staff recognizes the need for 5 updating the existing review guidance in NUREG-0654, Revision 1, Supplement 2, which is the guidance for 6 7 major features. Currently Supplement 2 calls for the review of a description of proposed emergency plans 8 9 for the major features option. The Review Guidance in Supplement 2 should be revised to provide additional 10 11 quidance relating the level of information to 12 necessary for each of the 14 planning standards. To the the review ___ to the extent 13 extent that 14 information in existing approved plans is referenced, 15 the staff level review of the plans is limited to the following three criteria. 16 Is the information up to date; is the information applicable to the proposed 17 site and does it reflect the use of the proposed site 18 19 for possible construction of a new reactor? 20 Although the staff recognizes the need to 21 update NUREG 0654 Revision 1, Supplement 2, since the 22 staff has not been indicated by industry that any 23 future ESP applicants would be coming in with major

24 features, it feels that this is a low priority work 25 item and therefore, wouldn't be addressed in the near

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

	56
1	future. I think th staff is more focused on
2	addressing the appropriate guidance for COL
3	applications. And one thing I wanted to note is that
4	currently in house we do have the Vogel (phonetic) ESP
5	application which has come in not referencing not
6	doing a major features approach but doing a complete
7	and integrated emergency plan approach with ITAC which
8	is what the staff feels and what industry has conveyed
9	to the staff is the more appropriate approach during
10	the ESP stage.
11	Regarding the definition of major features
12	of the emergency plan, major features is currently
13	identified in NUREG 0654 Revision 1 to Supplement 2
14	and the way the definition reads, is that major
15	features include the exact sizes of EPZs and planning
16	standards in evaluation criteria located in Section 5
17	of Supplement 2. As part of the proposed Part 52, the
18	staff plans to provide language clearly defining the
19	major features of emergency plans.
20	The third item that we wanted to discuss
21	was the level of finality at the ESP stage regarding
22	the major features option. The staff has also
23	proposed additional language in 10 CFR 52.18 that
24	specifies that the review of major features of the
25	emergency plan will be against 10 CFR 50.47 and
	1

(202) 234-4433

(202) 234-4433

Appendix E of Part 50 which are the basic emergency planning requirements that are directly associated 3 with a reasonable assurance determination. As a part 4 of this rulemaking, the staff has intended to not only clarify what major features are but expand on the information that would be allowed for review and 6 approval of major features.

The next item I had that the staff felt it 8 needs to address was the applicability of 10 CFR Part 9 This was an issue that was 10 21 to ESP applicants. 11 raised early on in the review process where somebody 12 raised the question in regards to what's the -- you know, is 10 CFR Part 21 applicable to ESP pre-13 14 applicants. Is it applicable to an ESP applicant and 15 is it applicable to an ESP holder? As a result of that comment, in a June 22nd, 2004 letter, the staff 16 reporting 17 clarified its position on 10 CFR requirements regarding an ESP pre-applicant, 18 ESP 19 applicant and ESP holder. And as far as the pre-20 applicant is concerned, 10 CFR Part 21 reporting 21 requirements are not directly applicable in the sense 22 that the pre-applicant does not have any obligation 23 under the regulations during the pre-application phase to comply with 10 CFR Part 21. 24

For both the ESP applicant and the ESP

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

25

1

2

5

7

	58
1	holder, the staff stated that 10 CFR Part 21 reporting
2	requirements do apply. Because site characteristics
3	form the part of the basis for design and because the
4	design forms part of the basis for the license, the
5	staff feels that it is appropriate to require an ESP
6	applicant and ESP holder to apply a 10 CFR Part 21
7	reporting program. In order to verify an applicant's
8	program, established just finished writing
9	CHAIRMAN WALLIS: Just tell the new folks
10	here what 10 CFR Part 21 is all about since you keep
11	referring to it, but you haven't said what it is.
12	MR. ARAGUAS: Sure. Paul, can you go into
13	a little bit of detail of what's required under Part
14	21 in terms of the reporting requirements for an
15	applicant?
16	MR. PRESCOTT: This is Paul Prescott of
17	the Quality in Vendor Branch. What that refers to is
18	reporting of defects. In other words, if they were to
19	find design inputs that had been calculated wrong or
20	had been applied incorrectly, and could effect safety
21	related FSCs at a future date of construction that
22	they would have to report that to the NRC.
23	MEMBER CORRANDINI: Thank you.
24	MR. ARAGUAS: The next item I had was
25	MEMBER POWERS: Wait, before you go on
	1

(202) 234-4433

(202) 234-4433

	59
1	from there, it seemed to me that the applicant
2	yesterday conceded the applicability but asked for
3	guidance on the implementation of both 21 and Appendix
4	B, which for our new members is the appendix to 10 CFR
5	Part 50, which is a quality assurance requirement.
б	Did you react to that?
7	MR. ARAGUAS: Yes, we did and one of the
8	comments they made to me was that the staff attempted
9	to capture this and the SRP updates but there was a
10	lot of push-back from industry regarding that and
11	there was no requirement to have a Part 21 program, at
12	least its description, in the application. So the
13	staff, right now is relying on its inspection program
14	and feels that it's documented there in terms of what
15	the staff would be looking for, for this type of
16	program.
17	MEMBER POWERS: I guess I would have
18	resisted the push-back because it seems to me I'm
19	scratching memory a little bit but that the defect in
20	the quality assurance explicitly asked for in the Part
21	52. I'm scratching memory. I have I can't quote
22	you chapter and verse on this.
23	MR. ARAGUAS: Paul, did you want to
24	address this a little bit further?
25	MR. PRESCOTT: Paul Prescott again. Per
I	1

(202) 234-4433

	60
1	50.34 that lays out what the requirements are for what
2	needs to be in an application and you have to describe
3	your quality assurance program per 50.34, but there is
4	no requirement that your Part 21 program be described
5	for that.
6	MR. ARAGUAS: Does that satisfy your
7	question?
8	The next lesson learned that I have listed
9	here is the applicability of Appendix B to 10 CFR Part
10	50 to ESP applicants and that's regarding a quality
11	assurance program. Current regulations in 10 CFR Part
12	52 do not require that a 10 CFR 50 Appendix B quality
13	assurance program be implemented in support of an ESP
14	application. However, the staff determined that ESP
15	activities associated with the site safety must be
16	controlled by quality assurance measures sufficient to
17	provide a reasonable assurance that future safety-
18	related systems, structures and components of a
19	nuclear power plant or plants that might be
20	constructed on the site will perform adequately.
21	Implementation of this guidance for the first three
22	ESP applications proved challenging and the staff
23	believes that future ESP reviews will be significantly
24	improved by the addition of an explicit QA requirement
25	for ESP applications.

(202) 234-4433

1 The staff believes that the level of 2 quality used to control activities related to safety related SSEs should be equivalent in ESP and COL 3 4 phases. The staff's position is that applicants must 5 apply quality controls to each ESP activity associated with the generation of design information for safety 6 7 related SSEs that meet the criteria for Appendix B. The reasoning for this similar to the reasoning 8 provided for Part 21 implementation is that the site 9 characteristics approved at the ESP stage will form 10 11 the part of the basis of the design which, in turn, 12 will form part of the basis for the license. To avoid any future -- any problems in the 13 14 future, the staff is proposing to modify 10 CFR 15 50.55F, Appendix B and 52.17 to make these ΟA requirements applicable to ESPs. 16 The staff is also capturing this proposed change in the rule in SRPs and 17 the SRP updates. 18 19 MEMBER APOSTOLAKIS: Give me an example of 20 this. 21 MR. ARAGUAS: An example of --22 MEMBER APOSTOLAKIS: That you have to 23 worry about Appendix B because the future safety 24 systems --25 Bore holes. MEMBER POWERS:

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

	62
1	MEMBER APOSTOLAKIS: Huh?
2	MEMBER POWERS: Bore holes.
3	MEMBER SIEBER: Or your seismic stuff.
4	MEMBER APOSTOLAKIS: Or my seismic stuff?
5	MEMBER SIEBER: Yeah, you're going to
6	build a foundation for the plant, including safety
7	related buildings based on what you determined the
8	seismic site characteristics are. You make a mistake
9	there, you have an impact on the qualification,
10	seismic qualification of the structures.
11	MEMBER APOSTOLAKIS: Well, is it Appendix
12	B that will be preventing me from making a mistake?
13	MEMBER SIEBER: That's one of the tools.
14	VICE CHAIR SHACK: You have a quality
15	control program to
16	MEMBER SIEBER: To make sure you do it
17	right. And if you don't do it right
18	MEMBER APOSTOLAKIS: Well, if you're going
19	to force Appendix B on them, they will not evaluate
20	and review their calculations. I mean, that's absurd.
21	MEMBER SIEBER: You could say that about
22	any activity in a nuclear power plant.
23	MEMBER POWERS: Yeah, you could say that
24	about anything, George. I mean, we've created
25	Appendix B to create a discipline.

(202) 234-4433

	63
1	MEMBER SIEBER: What Appendix B does is
2	provide documentation that the work was done in
3	accordance with the plan.
4	MEMBER POWERS: Well, it also provides
5	mechanism for how you handle deficiencies and things
6	like that.
7	MEMBER SIEBER: It makes the processes
8	dependable.
9	CHAIRMAN WALLIS: It gives a message to
10	the agency that those things that are going on are
11	being done right.
12	MEMBER APOSTOLAKIS: When they do the
13	evaluation of the site and the NRC staff reviews it,
14	I'm sure there is documentation. So it's stretching
15	it a little bit, isn't it?
16	MEMBER POWERS: Well, I think you're
17	railing up against Appendix B and that's subject for
18	a separate discussion and I will regale you enormously
19	with my views on Appendix B.
20	MEMBER APOSTOLAKIS: No, I understand,
21	Appendix B is very useful for a plant itself, but to
22	say that in the early site permit stage they have to
23	make sure they don't make mistakes, I mean
24	VICE CHAIR SHACK: Well, but I mean, it's
25	like any of your data that goes into your design.

(202) 234-4433

	64
1	MEMBER SIEBER: Right, it's all
2	fundamental stuff.
3	MEMBER APOSTOLAKIS: If you guys are happy
4	with that, I yield.
5	MEMBER SIEBER: And if there is no
6	documentation as Appendix B requires, the NRC wants
7	assurance that everything has been done properly,
8	there is no way to enforce the fact that the licensee
9	should have prepared documentation unless you apply
10	Appendix B or something like it.
11	MEMBER APOSTOLAKIS: I mean, they are
12	reviewing the application, so anyway it seems to me
13	that should be documented. But anyway
14	MEMBER POWERS: Well, I mean, I want to
15	distinguish here between feelings about Appendix B and
16	the applicability of that appendix to the early site
17	permit. I think we can have a long discussion about
18	the merits and demerits of Appendix B. Set those
19	aside, accept Appendix B, now is it applicable here
20	and I think the applicability is to activities at the
21	site is clear.
22	CHAIRMAN WALLIS: Now we can move onto a
23	physical consideration instead of being ensnared in
24	all the bureaucracy?
25	MR. ARAGUAS: Okay.
	1

	65
1	MEMBER POWERS: A harsh view.
2	CHAIRMAN WALLIS: Well, I mean, all these
3	references are about different parts of the
4	regulations must be really something for someone who
5	is coming here for the first time, that's
6	MEMBER SIEBER: I think we have an
7	additional comment over here.
8	MR. WEISMAN: This is Bob Weisman on NOGC
9	and it appears to me that the Committee is under the
10	impression that Appendix B applies to the current
11	early site permits, but it doesn't. Appendix B does
12	not apply to the current early site permits. What the
13	staff has done is it has inquired into the reliability
14	and integrity of the information that supports the
15	permit and come to a conclusion that really equivalent
16	in substance to Appendix B but Appendix B does not now
17	apply. I will note that the proposed rule Part 52
18	issued on March 13^{th} , 2006 includes a provision that
19	would apply Appendix B to early site permits, but you
20	know, we don't know what form the final rule is going
21	to take.
22	MEMBER APOSTOLAKIS: I have one last
23	question. If you apply Appendix B, okay, the next guy
24	who comes requesting early site permit what would you
25	do different from the other people?
1	I contraction of the second

(202) 234-4433

	66
1	MR. WEISMAN: I think for that I would
2	probably have to turn to Mr. Prescott.
3	MEMBER APOSTOLAKIS: Then why don't you do
4	that?
5	MR. WEISMAN: Okay.
6	MR. PRESCOTT: This is Paul Prescott.
7	MEMBER APOSTOLAKIS: Turn around a little
8	bit so we can see you.
9	MR. PRESCOTT: Sure.
10	MEMBER APOSTOLAKIS: Thank you very much.
11	MR. PRESCOTT: There was initially it
12	was interpreted, legally interpreted that Appendix B
13	did not apply to ESP applicants. So we felt that in
14	order to provide reasonable assurance that the data
15	that the data that the staff was receiving for review
16	was adequate, we worked in hand with OGC to come up
17	with okay, something that's equivalent in substance to
18	Appendix B. And so what we essentially drafted was a
19	standard review plan 1711 which outlined the general
20	requirements of quality assurance that should be
21	applied to activities related to the ESP application
22	which we also performed in an implementation
23	inspection to insure that they were doing these
24	controls.
25	The difference here is that the only thing
l	1

(202) 234-4433

ĺ	67
1	that was applied was the essence of Appendix B. So if
2	you read Appendix B in 10 CFR, that's what was
3	applied. What is different is in the way the current
4	plants operate and in the way the future applications
5	will be reviewed is that Appendix B will be applied
6	but Appendix B, when we talk about Appendix B in
7	quality assurance space, that includes the
8	interpretations that the staff and the industry have
9	come up with over time to include that enhances or it
10	goes into greater detail to explain how to properly
11	implement Appendix B. And this would include such
12	guidance as industry standard and QA1 and included in
13	the past the daughter standards that were born from
14	ANSI 45.2 series of standards that explained how to
15	implement, properly implement Appendix B and that's
16	the difference.
17	MEMBER MAYNARD: George, let me take a
18	shot at this. In reality there will probably be very
19	little difference as far as what's actually done and
20	performed for most of the licensees that are coming in
21	for early site permits have been operating plants and
22	they've kind of ingrained the methodology and the way
23	they do business anyway. There may be a few more
24	audits of what's been done by imposing the Appendix B
25	program as opposed to not having it. Audits may be a
	I contraction of the second seco

(202) 234-4433

(202) 234-4433

	68
1	little more formal.
2	Documentation, that way it's handled, and
3	record keeping requirements may be a little bit
4	different but the actual physical work, physical
5	calculations will probably be very little maybe a
6	little bit more rigor in assuring qualification of
7	some of the vendors and some of the people doing the
8	work, but I believe that would be the differences.
9	MEMBER APOSTOLAKIS: Okay, thank you.
10	CHAIRMAN WALLIS: Please continue, Chris.
11	MR. ARAGUAS: Okay. The last item that
12	the staff identified as lessons learned was the issue
13	that came up from the Clinton review, which was
14	establish a criteria for computing the probable
15	maximum flood. During the proprietary review period
16	for the final safety evaluation report on the Clinton
17	ESP application, Exelon discovered a discrepancy
18	between its calculated probable maximum flood
19	elevation and what the staff had included as the
20	probable maximum flood in the final safety evaluation
21	report. After several discussions with Exelon and
22	after performing several independent analysis, the
23	staff concluded that the revised analysis
24	conservatively estimated the probable maximum flood
25	elevation at the Clinton ESP site.

(202) 234-4433

1 As a result of this issue, there was two 2 lessons learned the staff identified. The first was that it is not the job of the staff to do a bounding 3 4 type analysis in the review and ESP and then use the staff's value as a value used to characterize the ESP 5 site. The second lesson learned was that that staff 6 7 recognizes it needs to update the guidance and data computing the probable maximum 8 used for flood 9 elevations for future ESP and COL applicants. As part of this ongoing SRP updates, the staff has planned to 10 revise the staff review procedure and acceptance 11 12 criteria for calculating the probable maximum flood elevation. 13

14 That concludes the staff's identified 15 lessons learned covered in yesterday's that we subcommittee meeting. What I'm going to attempt to do 16 here is discuss briefly some of the lessons learned 17 that were projected to the staff from the ACRS and 18 19 attempted disposition what the staff is doing now, or what it felt was the lesson learned. 20

The first was regarding the review of the staff's analysis of the hazards posed on the proposed site by explosions and transportation accidents on the Mississippi River that was done for the Grand Gulf ESP application. During the December 8 th, 2005 ACRS

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

70 1 meeting on this area ESP application, the staff's --2 and the staff's FSER, the ACRS identified a concern on the evaluation conducted for the potential hazards 3 4 along the Mississippi River that could impact the 5 site. In light of the ACRS' concern, the staff determined that the Applicant needed to clarify how it 6 7 was in compliance with 10 CFR Part 100. This was an area where the staff should 8 9 have requested additional information along the lines 10 of а quantitative analysis as opposed to the qualitative analysis that provided 11 was by the 12 In this case, the ACRS did a great job in Applicant. identifying a concern that needed to be addressed 13 14 further by the staff and the Applicant. As a part of 15 this, the staff does not feel this was an indication of poor or outdated review quidance and therefore, 16 feels that the guidance in RS002 and the future 17 quidance and SRP updates will -- is sufficient for the 18 19 review of site hazards. 20 MEMBER POWERS: I think we agree with you 21 on that. 22 MR. ARAGUAS: The second lesson learned that was identified was for the staff to review the 23

change for the next 20 years. In each of the previous

development of study -- and the study of climate

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

24

25

1 early site permit reviews, the ACRS identified a 2 concern with how the staff was addressing climate 3 change that may complicate the prediction of future 4 weather extremes based on historical records. As a 5 result of yesterday's ACRS meetings, the staff recognizes this concern and will consider how this 6 7 might be captured in staff guidance specifically the SRP updates with a review of future ESP and COLs. 8 9 Regarding what that would look like, I don't think the staff has a clear picture of how but I certainly will 10 attempt to. 11

12 I mean, I don't think we MEMBER POWERS: disagree with your disposition of the issues. 13 We 14 disagree with what you've written in RS002 and maybe the appropriate way to handle it is in a guidance 15 16 statement. I think the agency generically has an I don't think it's your responsibility. 17 issue here. I mean, that's the contention you've made and I think 18 19 we agree with you on that. And I think it's difficult 20 for you to disposition the issue in finality, but it 21 is your guidance but you need to just modify some of 22 the words.

23 MR. ARAGUAS: Okay. Now I'm going to move 24 onto some of the industry identified lessons learned 25 and what the staff is currently doing to address those

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433
1 comments that were made. Regarding the first two, I 2 want to address those two at the same time. That's 3 the plant parameter envelope approach and the major 4 features option that seemed to be discussed quite a 5 bit vesterday. The staff recognizes the challenges associated with both the PPE approach and the major 6 7 features option but at this time, it's the staff's understanding that any future ESP applicant will be 8 9 application with а specific submitting an ESP 10 technology in mind and will be submitting complete and integrated emergency plans with ITEC (phonetic). 11 As a result of this understanding, the 12 staff is really focused on addressing the guidance 13 14 that is out there for COL applicants so that it does 15 not encounter these same problems it's encountered Aside from the fact that the 16 during the SP reviews. staff needs to update its guidance with respect to the 17 PPE approach and the major features option, the staff 18 19 also feels that some of the challenges arose due to 20 the fact that industry was initially just testing out 21 the Part 52 licensing process. Had a design been 22 selected it would have made for a more efficient 23 review.

24 The next item that was discussed yesterday 25 was permit content and the fact that industry felt

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

72

	73
1	that it had not seen what the draft permit or what its
2	actual permit would look like. The staff understands
3	the industry's interest in seeing what the actual
4	early site permit will look like
5	CHAIRMAN WALLIS: Interesting, they're
6	applying for something but they don't know what it is.
7	MR. ARAGUAS: And I'll get to that. We
8	understand their interest in seeing what the permit
9	looks like and as far as the safety side is concerned,
10	we feel that Appendix A is a good representation for
11	the terms and conditions that will be placed on the
12	permit. It is unlikely that the language will change
13	as identified in Appendix A unless the ASLB identifies
14	some fundamental mistake with the language being
15	proposed. This has been relayed to industry and they
16	are aware that, in fact, those conditions in Appendix
17	A will go in the permit.
18	As far as the environmental portion of the
19	permit, we realize that the staff has been silent on
20	this issue but in light of the ASLB hearings to take
21	place in the next few months, following these hearings
22	we will with certainty know what the permit will look
23	like. An aside to this as the staff mentioned
24	yesterday, on June 22^{nd} , 2004, the staff did send out
25	a permit template to each of the applicants to provide
	I

(202) 234-4433

1 feedback on. So they are aware of what the permit 2 will potentially look like and it shouldn't be any 3 surprise to them the type of information, the level of 4 detail that will be captured.

5 The next item that we had that was brought up was the -- was regarding seismic methodology, and 6 7 this was regarding the high frequency issue. The 8 staff is very much aware of this issue and has engaged 9 industry on this issue. And currently the staff is reviewing a topical report that was submitted by NEI 10 and EVRI (phonetic) and has issued RAIs on the topical 11 12 and is not awaiting response to the RAIs.

Another item that was raised was regarding 13 14 the quality assurance program, specifically internet 15 Right now the staff has been requiring that an data. applicant's technical reviewer within the technical 16 discipline document his or her review of the internet 17 data and we also require the information be in a hard 18 19 copy form to insure that we know specifically what 20 data is -- what the data is they reviewed since data 21 could potentially change with time. The plan right 22 now is to incorporate this information in the SRP 23 updates.

Another item that was discussed was regarding electronic submittal guidance. The staff is

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	75
1	certainly aware of this issue.
2	MEMBER POWERS: Let me come back to the
3	internet data a little bit.
4	MR. ARAGUAS: Sure.
5	MEMBER POWERS: Let me predicate my
6	remarks by saying there's no problem with the current
7	applications. They've everything has been dealt
8	with appropriately and conservatively. I'm worried
9	more in the future. I may not even be worried about
10	early site permits or COLs but engineering and safety
11	analysis in general. The problem I see is that
12	internet data only available via the internet could be
13	defaced and the or changed by third parties
14	unbeknownst to any user or reviewer. And that's the
15	I mean, that's the reality is that you can get into
16	these sites and you can do things to them.
17	MR. ARAGUAS: Right.
18	MEMBER POWERS: The gentleman to my right
19	probably can do it. I can't but and how do you
20	assure integrity of data that may have languished
21	there for years before it actually gets used by
22	someone is the issue that has to be confronted.
23	MR. ARAGUAS: Right.
24	MEMBER POWERS: And I don't think it's
25	your responsibility. I think it's just something in
I	

(202) 234-4433

	76
1	the future.
2	MR. ARAGUAS: Okay.
3	MEMBER CORRANDINI: Can I ask, just to
4	understand Dana, so you're saying there is real data.
5	It's stored somewhere but in the transmission through
6	the internet it's modified?
7	MEMBER POWERS: Oh, no, Mike, somebody
8	goes in an hacks the site.
9	MEMBER CORRANDINI: Okay.
10	CHAIRMAN WALLIS: Maliciously modified.
11	Is that the idea?
12	MEMBER POWERS: That's the problem and the
13	problem is that there are going to be changes over the
14	next 20 years and the availability of information is
15	just going to be different. I mean, there's a
16	paradigm where as now, and appropriately so, most
17	people you can use the internet to go and say, "Ah,
18	somewhere there's this volume that I can go look at,
19	put my hands on and look up this number". Okay, I
20	might not actually do that but I know that it exists.
21	In the future, that volume won't exist.
22	The only thing that will exist is an electronic page
23	and so how do you assure the integrity of that
24	electronic page?
25	MEMBER CORRANDINI: So let me just ask my
	I

(202) 234-4433

	77
1	question differently then. So right now, there has
2	probably been a reference that's untouchable.
3	MEMBER POWERS: There's something
4	untouchable. For instance, somebody uses data from
5	the National Weather Service, okay. He got it off the
6	internet but he knows he can go to the National
7	Weather Service and say, "I want to assure that this
8	data I got off the internet is in fact, truly
9	represents what you claimed it to be", and sure
10	enough, they can do something. It may well be going
11	to their separate computer files and say, "Yeah,
12	that's exactly the number we said it was", and there's
13	some assurance. In the future, you may not be able to
14	do that.
15	Okay, it's forward looking. I don't know
16	that these gentlemen have any responsibility for this.
17	I think the agency has a responsibility to think about
18	this issue because based on what I see, electronic
19	libraries are the way to the future. That actually
20	going in and being able to pick up a printed volume is
21	going to become an anachronism. And what I have seen,
22	it's really marvelous for the stuff, but it's I can
23	see it fraught with difficulty because there are a lot
24	of people out there that like to tear down
25	institution, and destroy things just for the fun of
	I

(202) 234-4433

	78
1	it.
2	MEMBER CORRANDINI: One last question,
3	just for my own edification; so right now there's no
4	requirement by the licensee to have a reference
5	what I'll call, I'll use the word "hard reference" on
6	engineering specifications.
7	MEMBER POWERS: Oh, I think there is.
8	MEMBER CORRANDINI: But that's why I'm
9	still going back to your worry. Your worry is that
10	somehow you'll get to that in the future because there
11	will never be the hard reference will disappear?
12	Is that your
13	MEMBER POWERS: Yeah, there just won't be
14	any.
15	MEMBER CORRANDINI: Okay.
16	MEMBER POWERS: There will never be one.
17	I mean, we will have valuable data obtained through
18	great labor, the only place it exists is
19	electronically. And we're going to use it, I mean, it
20	will be silly not to use it. Now, what do you do?
21	How do you insure the integrity of it? I don't know
22	the answer to that but I know that we've got to think
23	about it.
24	MEMBER CORRANDINI: Right, thank you.
25	MR. ARAGUAS: That's a good point. As I
	1

(202) 234-4433

1 started to mention, one of the issues that was raised 2 yesterday by industry was the electronic submittal guidance and this has been a challenge for guite some 3 4 time now. The staff is very much aware of this issue 5 and has certainly engaged industry over the course of the last two years not specifically on this issue but 6 7 in several meetings has raised this issue. Currently 8 the staff is coordinating with the Office of 9 Information Services to develop a program to be able 10 to up -- not a program but to update the guidance so that it makes it easier for an applicant to submit 11 information on the docket. 12 The next item that was raised --13 14 MEMBER MAYNARD: Kind of a caution on 15 that; one of the -- in that consideration, one of the 16 things that causes problems is when you update to later versions and if the NRC doesn't, the industry 17 does or vice versa, that's where you run into a lot of 18 19 problems where you -- what you're submitting may not 20 be compatible with what the NRC can receive or vice 21 And I think it needs to be taken into account, versa. 22 you know, how are different versions handled and are 23 And do the specifications say you know, they locked. 24 pdf and this version only or whatever. 25 I think that it's not only what types of

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

79

	80
1	programs but also what versions that have to be taken
2	into account.
3	MR. ARAGUAS: That's a good comment. The
4	next item that was raised yesterday which seemed to be
5	a common theme amongst the three also was the NRC
6	guidance documents in place during the time of the ESP
7	review. We understand this was a challenge because
8	the RS-002 didn't come out until it was too late.
9	CHAIRMAN WALLIS: Are you talking about
10	time or length here?
11	MR. ARAGUAS: Excuse me?
12	CHAIRMAN WALLIS: Are you talking about
13	time or length?
14	MR. ARAGUAS: Regarding?
15	CHAIRMAN WALLIS: Because these are are
16	you talking about the length or the time?
17	MR. ARAGUAS: The time.
18	CHAIRMAN WALLIS: The time, okay.
19	MR. ARAGUAS: The point that I wanted to
20	capture regarding the NRC guidance documents is the
21	staff recognizes this was a problem and therefore, as
22	you can see and as I've mentioned already the staff
23	has undergone a significant effort in terms of getting
24	the SRPs up to date, putting out guidance for COL
25	applications, putting out the proposed rule and this
1	I Contraction of the second

(202) 234-4433

	81
1	is all going on in a timely fashion to support the
2	COL, the preparation of the COL applications. The
3	other comment that I wanted to point out is this is
4	all being done with the support of industry. They are
5	certainly very much involved in this process and
6	certainly shaping how these documents will look.
7	MEMBER POWERS: The conclusion I came out
8	of this is that all parties learned a lot from ESP and
9	it's applicable to the COL and the staff deserves high
10	praise for the reacting to it now. And none of this
11	surprised me given the nature of the early site
12	permits which in my mind certainly snuck up on me. It
13	may not have snuck up on the staff and whatnot, but it
14	certainly got sprung on me very early. I mean, I know
15	I scrambled to catch up on reviewing first RS-002 and
16	then recognizing that I didn't know a lot of the
17	background and scrambling there.
18	MR. ARAGUAS: Right. The last item that
19	I had that was identified by industry and as I was
20	corrected, it's the early site permit review time and
21	why, in fact, it's taken the staff so long to get out
22	an early site permit. The points that I wanted to
23	make on this were the staff recognizes that because
24	these were first of a kind reviews, it could not
25	anticipate some of the issues that arose causing
	1 I I I I I I I I I I I I I I I I I I I

(202) 234-4433

(202) 234-4433

delays. For example, one was an issue that came on the environmental side and that was the mass amounts of public comments that were received when the staff issued its Draft Environmental Impact Statement. I don't think the staff ever anticipated this level of participation and therefore, was not prepared to handle addressing all these public comments.

8 Another issue that I wanted to point out 9 that more lies on the applicants was the fact that the staff had built in a review process to review these 10 ESPs in series and this came out of a I don't want to 11 say commitment, but an understanding from industry 12 that these applications would be very, very similar in 13 14 terms of how they would look and, in fact, when they 15 came in the door, were not similar at all and the 16 problem with that is that you really couldn't gain any 17 efficiencies in trying to review these applications in a series. And I think the staff was attempting to 18 19 take this approach because of the lack of resources in 20 terms of the reviewers to review these applications. So that I think was one of the challenges 21 22 the staff saw on the part of industry. Another was 23 the fact that -- and this was raised yesterday, 24 regarding the submittal of new methodologies. The 25 staff schedules, as they stand now, are built on a

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

3

4

5

6

7

(202) 234-4433

82

83 1 level of understanding that there's no surprises. 2 What we get we've seen. And that's not to say that we won't review it 3 as we have with Clinton. The 4 understanding is that if you want the staff to meet a 5 certain schedule, there shouldn't be any surprises. And in the case of Clinton, as I mentioned, it was 6 7 really up until the day that we got the application 8 that we were made aware of this new performance based 9 methodology for determining that the safe shutdown 10 earthquake ground motion. Another issue that we wanted to raise was 11 not so much the fact that RAIs were received late but 12 that there was not timely responses to the RAIs. 13 Ι 14 think this is something that has been thrown around industry and that they've committed as far as these 15 future ESPs and COLs to getting responses in at least 16 within 30 days to support the staff's shortened review 17 And I think the point of this that I bring 18 times. 19 here is not necessarily to put the onus on industry 20 but it was a combination of both staff and industry 21 problems throughout the review that I think have been 22 correctly identified now in the process of developing 23 shorter review times for any upcoming ESPs and

24 especially with the early site permit application that 25 we have in house and that's for the Vogel site.

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	84
1	Currently the staff has put together a 21-
2	month review schedule and that's to issue the FSCR and
3	the FEIS and that's taking into account that there's
4	these expectations that have been clearly indicated to
5	the applicants that they submit high quality
6	applications and that they don't attempt to submit
7	applications with new proposed methodologies for the
8	staff to review. As I mentioned again, we don't
9	discourage that from the standpoint if they want us to
10	review it, we will but expect schedule delays.
11	And I think that's all I have in terms of
12	what was captured yesterday. Any other questions?
13	MEMBER MAYNARD: I think I would agree
14	with you that both parties, the NRC staff and the
15	licensee, have some improvements that they could make
16	on time for the review, different areas there. I
17	would caution you, you seem to put probably most of it
18	on the industry. It's not going to help you guys
19	improve your process if you don't take a little bit
20	harder look at within the agency as to how these
21	things are being handled and managed there, because I
22	think the industry would have maybe some different
23	views on some of the things that you brought up there,
24	but I still think that three years is too long for
25	this type of review on something that is a really
	II

(202) 234-4433

a fairly small part compared to the overall licensing process that's going to be coming up soon.

3 So I think that there's still some lessons 4 to be learned there and I would focus more on what the 5 staff can be doing internally to change their processes and what -- and one of the areas that I 6 7 haven't seen -- some of the things that generated RAIs and some inconsistencies in applications, I think, 8 9 some of the guides that's being developed as we went 10 along and some of the interpretations. Also some of the guidance documents and some of the regulations had 11 12 some wording in it that made it somewhat difficult, took some time to get around that. 13 Those are some 14 areas to be taking a look at as to in some cases it's 15 better to change the guidance document or the branch technical position than it is to spend a lot of time 16 17 trying to figure out a way to get around that. So I think there's opportunities there. 18

19 MR. ARAGUAS: Correct. And I think the 20 staff agrees with you and I think that the gist of my 21 presentation or the staff's presentation was mainly 22 identifying the issues that the staff had in terms of 23 its not having sufficient guidance out there. And so 24 we recognize that there are a lot of problems in terms 25 of where the staff certainly contributed to schedule

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

(202) 234-4433

85

ĺ	86
1	delays and I think those have been captured here. I
2	just my point was to also capture that it's a
3	combination. As you said, it was both parties and
4	just to point out one fact how industry contributed to
5	that problem as I felt that the staff had already
6	acknowledged what its problems are and how it plans to
7	address those.
8	MEMBER POWERS: Any other comments?
9	MEMBER ABDEL-KHALIK: I guess I'm
10	concerned about the internet data issue. This seems
11	like a generic problem and the issue then is how does
12	one assure the fidelity of the data and consistency
13	with the primary source? Is the concern that over
14	time the primary source of the data will disappear and
15	we will only have what's available?
16	MEMBER POWERS: What's certain is the
17	internet is becoming the primary source. There would
18	be no there will be nowhere, anywhere a hard
19	document that you can put your hand on.
20	MEMBER ABDEL-KHALIK: Well, it doesn't
21	have to be a hard document. It can be an electronic
22	document, but nevertheless, it's still a primary
23	source that's verifiable by the originator of the
24	data.
25	MEMBER POWERS: Well, it may be the

(202) 234-4433

	87
1	solution
2	MR. ARAGUAS: Can you provide some
3	clarification?
4	MEMBER POWERS: Yeah, you may have
5	identified a solution but it's
6	MEMBER SIEBER: It's not there now.
7	MR. ARAGUAS: Paul, could you shed some
8	light on what our concern is in terms of internet
9	data?
10	MR. PRESCOTT: This is Paul Prescott. The
11	concern started with us right with the first
12	applicant, Dominion, and again, keep in mind, we're
13	focused from a quality assurance standpoint, not from
14	a technical standpoint of the information that the
15	data is supplying to whatever technical reviewer is
16	going to look at it from the staff and however the
17	licensee is going to use it. What we were looking
18	for, we essentially outlined.
19	Our concern was some of the concerns that
20	were expressed by you, could the data have been
21	tampered with because the internet is not fool-proof.
22	Another concern was from a legal standpoint that ESPs
23	are considered something that goes through hearing
24	space and so what are the current legal requirements
25	that are placed on internet data used in legal

(202) 234-4433

	88
1	proceedings. And what we found is that at least for
2	most of the for most of the internet data that we
3	were concerned about from a safety standpoint, most of
4	that data could be certified by the outfit that was
5	supplying it.
6	Like a lot of the governments like NOAA
7	and the Census Bureau, they will actually certify that
8	their data is authentic, thank you, is authentic and
9	what Dominion did and a number of the other ones was
10	that the data that could be certified they actually
11	went through the process to get it certified and
12	insure the integrity of the data.

13 Now, there was some concerns with --14 especially with population data for local population, 15 density requirements, like county data. Our concern 16 there was that at least -- that somebody technically 17 competent in that area review the data to insure that 18 it appeared at least to be adequate because we had concerns that data like that could easily be corrupted 19 from various outside sources. So -- and so these were 20 21 the controls that at least from a quality assurance 22 standpoint that we put in place for us to have some 23 level of confidence that what the staff was getting was good information. 24

MEMBER POWERS: And again, I don't think

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

25

	89
1	there's any problem with these applications at all.
2	I mean, I think everybody was very conservative. The
3	internet is still moving to this process. I foresee
4	in 20 years it becoming a bit difficult.
5	Any other comments you'd like to make? I
6	think Chris has done a marvelous job of summarizing
7	the major points.
8	MR. ARAGUAS: Thank you.
9	MEMBER POWERS: And I think the staff's
10	reacted appropriately to this lesson. What the ESP
11	provides is a predicate to the COL process which has
12	as Maynard just pointed out, is only Chapter 2 of
13	the COL process. So we have a lot to do in the COL
14	but I think this has been a worthwhile exercise. I
15	also note that the industry, too, feels that the early
16	site permit was a useful introduction to what the COL
17	is going to look like and, yes, there are going to be
18	challenges in getting this to be as timely as we'd
19	like and whatnot. If there are not other comments,
20	I'll turn it back to the Chairman.
21	CHAIRMAN WALLIS: Thank you very much. We
22	seem to again have gained a great deal of time, which
23	amounts in this case to a half an hour and we're not
24	allowed to proceed with the next item on the agenda.
25	So we will take a break until 12:45 and you will have
	1

(202) 234-4433

	90
1	an opportunity to review this Monticello draft.
2	We also have I believe, a draft on the EDO
3	response on the security matter which you have to
4	treat a little bit more carefully, but if you're
5	interested in that matter, you can contact Eric
6	Thornsberry and look at it ahead of time. I think
7	those are the only drafts which are available at the
8	moment.
9	MEMBER BONACA: Just a comment on that is
10	that it's a rough first draft because we need to hear
11	a response but I think that the elements are all
12	there. All it needs is a concluding statement at the
13	end.
14	CHAIRMAN WALLIS: So we'll take a break
15	until 12:45.
16	(Whereupon at 11:17 a.m. a luncheon recess
17	was taken until 12:45 p.m.)
18	CHAIRMAN WALLIS: On the record. So
19	please come back in session, the afternoon session, of
20	the first day. The next item on the agenda is the
21	draft final revision to 10 CFR 50.68, Criticality
22	Accident Requirements. I invite my colleague, Sam
23	Armijo, to get us going on this one.
24	MEMBER ARMIJO: Thank you, Mr. Chairman.
25	The Committee will consider a proposed final rule to
	1

(202) 234-4433

	91
1	amend 10 CFR 50.68 so that the requirements governing
2	criticality control for spent fuel pool storage racks
3	do not apply to the fuel within a spent fuel
4	transportation package or a storage cask when these
5	packages are in the spent fuel pool. The Committee
6	was given the package at the last meeting. We didn't
7	have time to really consider it or meet as a
8	subcommittee. So the decision was made to have it
9	presented at this meeting. The presenters will be Tom
10	Martin of NRR and there will be comments from Mr.
11	Kraft of NEI. I believe he is here. So Tom.
12	MR. MARTIN: I would like to turn it over
13	to Mr. George Tartal, the Project Manager, to begin
14	the presentation.
15	MR. TARTAL: Thank you. This ACRS
16	briefing is on NRR's rulemaking activity to amend 10
17	CFR 50.68 titled Criticality Accident Requirements.
18	I'm George Tartal. I'm the Project Manager for this
19	rulemaking activity. I work in the Regulatory
20	Analysis, Policy and Rulemaking branch in the division
21	of the Policy and Rulemaking in NRR. As you heard a
22	moment ago, Tom Martin here is one of my co-
23	presenters. He's the Division Director, Division of
24	Safety Systems in NRR and to my far right is Meraj
25	Rahimi who is the Senior Project Manager from the
	1

(202) 234-4433

(202) 234-4433

	92
1	Licensing section of the Spent Fuel Project Office in
2	NMSS. Together we'll be presenting on various slides
3	throughout the presentation sort of as a team approach
4	as we did in developing the rulemaking package.
5	These first few slides will give a brief
б	overview of the topics we'll be discussing in more
7	detail during today's presentation. Criticality
8	accidents are prevented or controlled in accordance
9	with Parts 50 or 70 for fuel in a spent fuel pool,
10	Part 71 for fuel in a transportation package and Part
11	72 for fuel in a dry storage cask. These are
12	CHAIRMAN WALLIS: I would hope that most
13	of the time they're prevented.
14	MR. TARTAL: It depends on which
15	regulation you're talking about. We'll go into those
16	in a little more detail shortly, so bear with me. So
17	these are the current regulations regarding fuel
18	criticality.
19	Now in 2003, a question arose regarding
20	which regulation or regulations apply to fuel being
21	loaded into a dry storage cask while the cask is
22	submerged in a spent fuel pool. The NRC determined
23	that licensees must meet the requirements of Part 50
24	and Part 72 when loading casks in a spent fuel pool
25	and this determination was documented in the form of

(202) 234-4433

	93
1	a RIS in March of 2005. The NRC did not intend to
2	create overlapping requirements between Part 50 and
3	Part 72. That wasn't the intent when 50.68 was
4	written in 1998. However, this is the current state
5	of criticality accident requirements for fuel within
6	a cask in a spent fuel pool.
7	Now in order to comply with the Part 50
8	requirements
9	MEMBER APOSTOLAKIS: I think just an
10	explanation.
11	MR. TARTAL: Yes.
12	MEMBER APOSTOLAKIS: When you are asking
13	people to meet both requirements, what was the
14	thinking? That they are complimentary? How can you
15	say you did not intend to create overlapping
16	requirements?
17	MR. TARTAL: Well, when 50.68 was written
18	back in 1998 it was written as an alternate means of
19	meeting Part 70. An alternate means of meeting Part
20	70, that's right. So the intent wasn't to overlap
21	between 50 and 72 when we wrote the rule.
22	MEMBER APOSTOLAKIS: Okay.
23	MR. TARTAL: So to
24	CHAIRMAN WALLIS: So presumably it's not
25	critical by either analysis.
ļ	1

(202) 234-4433

94
MEMBER APOSTOLAKIS: That's correct.
MR. TARTAL: Yes.
CHAIRMAN WALLIS: Okay. So it doesn't
really matter which one you use.
MR. TARTAL: Different assumptions.
MEMBER APOSTOLAKIS: Right. Different
assumptions.
CHAIRMAN WALLIS: But the answer is the
same. Right?
MEMBER SIEBER: Hopefully.
MR. TARTAL: Yes.
MEMBER APOSTOLAKIS: What do you mean the
answer? There is no answer. If you meet, if you
satisfy these requirements, then you are subcritical.
MEMBER ARMIJO: Right. That's the answer.
MEMBER APOSTOLAKIS: Yes. No, no. It
doesn't tell you how much.
MEMBER ARMIJO: Go ahead. Keep going.
MR. TARTAL: So to comply with the Part 50
requirements, licensees basically have two options.
One is to perform an additional criticality analysis
and amend their tech specs or they could (2) receive
an exemption from 50.68. So those are the current
options for licensees, either meet the regulation or
be exempt from it.

(202) 234-4433

	95
1	MEMBER KRESS: Generally, the fuel in the
2	cask is denser in the sense that the rods are closer
3	together, more of them.
4	MR. TARTAL: Yes.
5	MEMBER KRESS: Than rods in a pool. So
6	that's where you get a kind of a different
7	MR. MARTIN: It would be a different
8	pitch, a different analysis that would be required if
9	there There would be a separate analysis that has
10	been done for the fuel in the cask that's separate
11	from the analysis of the pool because of the
12	configuration, the geometry change.
13	MR. TARTAL: Our position is that this
14	additional criticality analysis is unnecessary to
15	protect public and health and safety since the
16	required analyses for fuel in the spent fuel pool
17	under Part 50 and for fuel in a dry storage cask under
18	Part 72 are adequate to ensure safe movement of the
19	fuel.
20	CHAIRMAN WALLIS: So putting the cask in
21	the fuel doesn't make any difference to the
22	criticality of the fuel within the cask.
23	MR. TARTAL: The point is there are
24	regulations covering the cask whether it's in the pool
25	or out of the pool.

(202) 234-4433

	96
1	CHAIRMAN WALLIS: The leakage and all
2	that.
3	MEMBER KRESS: But when the criticality
4	analysis for just the cask. They assume it's
5	surrounded by water?
6	CHAIRMAN WALLIS: Yes, they find out that
7	leakage is a reflection
8	MR. TARTAL: We'll get into that.
9	MEMBER KRESS: Okay.
10	MEMBER APOSTOLAKIS: They are considering
11	all their scenarios.
12	MEMBER ARMIJO: There are different
13	assumptions that can be applied when it's dry.
14	Transportation casks can be flooded, but apparently
15	the dry storage casks can not be flooded. So these
16	are very You know there are a lot of variations in
17	here that kind of confuse.
18	MR. MARTIN: An assumption as part of the
19	dry storage cask is not that it would be permitted to
20	be flooded with pure water. An assumption as part of
21	the spent fuel pool is that the spent fuel pool should
22	tolerate a dilution event so that the fuel will still
23	remain subcritical even if
24	MEMBER SIEBER: Pure water.
25	MR. MARTIN: you have pure water in the
1	

(202) 234-4433

	97
1	spent fuel. You lose boron in the spent fuel pool.
2	So for the period of time that you have a dry storage
3	cask in the spent fuel pool where the dry storage cask
4	has an assumption of you either dry with no moderator
5	or full of boron, those casks haven't been analyzed to
6	ensure that they can remain subcritical with
7	MEMBER SIEBER: Pure water.
8	MR. MARTIN: pure water.
9	CHAIRMAN WALLIS: So there is something
10	different about putting it in the pool.
11	MR. MARTIN: There is something.
12	CHAIRMAN WALLIS: Could it get pure water
13	in it in the pool?
14	MR. MARTIN: Pardon me?
15	CHAIRMAN WALLIS: Could it get pure water
16	in it? Could the cask have pure water?
17	MR. TARTAL: We're going to get into that.
18	MR. MARTIN: There are a couple of
19	scenarios that you could get into that and that's at
20	the crux of the issue.
21	CHAIRMAN WALLIS: You're going to address
22	that. Okay. So that is the crux.
23	MR. MARTIN: And we're going to get into
24	that, some assumptions.
25	CHAIRMAN WALLIS: I'm bothered by your
I	1 I I I I I I I I I I I I I I I I I I I

(202) 234-4433

1 assumptions. I guess you're considering different 2 situations rather than making some answers or 3 assumptions. You're considering different situations, 4 different situations where there is or is not water 5 and there is or is not boron. Those to me are different situations. Assumptions are things you do 6 7 to get on with the analysis. There are different 8 MEMBER ARMIJO: 9 situations and different assumptions. 10 CHAIRMAN WALLIS: I see. I quess this will all become clear. 11 And the regulations are 12 TARTAL: MR. different as well. So we'll get into that shortly. 13 14 MEMBER CORRADINI: Just to clarify since 15 I'm a bit new to this. So your point is that what is 16 going to be suggested for the elimination that it's 17 unnecessary that you're getting to, the last bullet you had just said. 18 19 MR. TARTAL: Yes. 20 MEMBER CORRADINI: So you're going to get to how you're going to resolve this unnecessary 21 requirement. 22 23 MR. TARTAL: We're going to describe the 24 technical basis for the rulemaking and how we came to 25 that conclusion.

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

98

99
CHAIRMAN WALLIS: And you're going to be
convincing.
MR. TARTAL: We hope so. The cost to
licensees to comply with this is considerable and by
considerable, we're talking on the order of several
hundred thousand dollars per request as we heard from
the industry.
CHAIRMAN WALLIS: You don't just put
something into a computer and get an answer?
MEMBER APOSTOLAKIS: For heaven's sake,
let them speak.
CHAIRMAN WALLIS: It costs hundreds of
thousand dollars to do an analysis?
MR. TARTAL: You have to submit it for
review as well at the cost to the licensee.
CHAIRMAN WALLIS: Ah, that's the cost.
Okay.
MR. TARTAL: There are a lot of things
involved in this cost.
CHAIRMAN WALLIS: Okay.
MEMBER ARMIJO: Is the exemption as
expensive as the analysis?
MR. TARTAL: It's still on that order. I
don't remember the exact numbers. I believe we put
the numbers into the rulemaking package. I don't

```
(202) 234-4433
```

	100
1	remember them off the top of my head.
2	MR. MARTIN: But we would prefer not to
3	regulate by exemption.
4	MEMBER ARMIJO: Of course.
5	(Several conversations at once.)
6	MR. MARTIN: And this is a situation where
7	we would require exemptions in many, many cases. So
8	rather than have a continual process of exemptions,
9	it's apparent that we have to change the regulation.
10	MR. TARTAL: So the solution here is to
11	change the regulation and that's the subject of our
12	presentation to the Committee today. The purpose of
13	the rulemaking is to reduce regulatory burden by
14	regulating the criticality fuel loaded in a package or
15	cask exclusively under Part 71 or Part 72 and the
16	rulemaking clarifies the boundary between Part 50 and
17	Part 71 or 72 for criticality accident considerations.
18	CHAIRMAN WALLIS: So this is reducing
19	burden while preserving public safety.
20	MR. TARTAL: Yes. So I'm going to turn
21	the presentation over to Tom Martin.
22	MR. MARTIN: Slide No. 5, as an overview,
23	the regulations that relate to criticality controls
24	for storage of fuel are 10 CFR 50.68 and General
25	Design Criteria, the GDC 62 and 63. The regulatory
	I contract of the second se

(202) 234-4433

101 1 framework established by these regulations emphasizes 2 the prevention of an accidental criticality and the 3 capability to detect one should it occur. General 4 Design Criteria provide high level expectations for 5 design of fuel storage systems. 50.68 provides specific limitations on the reliance of soluble boron 6 7 for criticality control. 8 Criticality safety requirements. 9 50.68(b)(4) requires that the analysis demonstrates that subcriticality is maintained in an unborated 10 In general, specifically in 10 CFR 50.68 11 condition. requires that K-effective be maintained less than 0.95 12 with boron and less than one without boron. 13 Having 14 soluble boron --15 CHAIRMAN WALLIS: Less than one by how much? 16 17 MR. MARTIN: Pardon me? 18 CHAIRMAN WALLIS: Less than one by how 19 much? 20 MR. MARTIN: Less than one, as long as if 21 you take credit for boron in the pool. 22 CHAIRMAN WALLIS: 0.9 recurring is 23 acceptable? 24 MR. MARTIN: If you -- There's a 95/95 25 requirement on 0.95 K-effective with boron, however

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	102
1	the regulation is it just says less than one
2	CHAIRMAN WALLIS: That's all it says.
3	MR. MARTIN: under accidental
4	conditions. There is nothing less than
5	CHAIRMAN WALLIS: There is no margin of
6	uncertainty or anything? One is okay.
7	MR. TARTAL: There is the 95/95 on it.
8	MR. MARTIN: It's still at 95/95 on less
9	than one.
10	CHAIRMAN WALLIS: On less than one.
11	MR. TARTAL: Yes.
12	CHAIRMAN WALLIS: So there's a finite
13	probability of being more than one.
14	MR. MARTIN: and k-effective must
15	remain below one at 95 percent probability/95 percent
16	confidence level.
17	CHAIRMAN WALLIS: So there is a finite
18	probability of it being more than one. Right? That
19	would seem to me there's a finite probability of it
20	being more than one.
21	MEMBER POWERS: That's what it means.
22	CHAIRMAN WALLIS: Yes.
23	MEMBER POWERS: Not for long though.
24	CHAIRMAN WALLIS: Not very much.
25	(Off the record comments.)
1	

(202) 234-4433

	103
1	MEMBER KRESS: Yes, it will take of that.
2	MR. MARTIN: Generally, the water in the
3	spent fuel pool is borated to around 2300 bpm boron
4	and to go from that level of boron to
5	CHAIRMAN WALLIS: To one. Takes some
6	doing.
7	MR. MARTIN: to no boron, it would be
8	a very big challenge to do.
9	CHAIRMAN WALLIS: Right.
10	MR. MARTIN: Okay. Let's go to the next
11	slide please.
12	MEMBER ARMIJO: Before you leave that,
13	what are the additional controls you have for fresh
14	fuel?
15	MR. MARTIN: Fresh fuel is generally
16	stored dry. However, when it is placed in the fuel
17	before it goes into the vessel, it's controlled in
18	terms of the locations in the spent fuel pool to
19	ensure that the
20	MEMBER ARMIJO: So the fresh fuel is
21	spread out in the pool.
22	MR. MARTIN: So the fresh fuel is spread
23	out amongst the other assemblies in the pool.
24	Correct. Meraj.
25	(Off the record comments.)
1	1

(202) 234-4433

104 1 MR. RAHIMI: What I would like to do just 2 briefly transportation storage is qo over the 3 criticality safety requirements. Transportation 4 criticality safety requirements are under Part 71, 5 specifically Part 71.55 and 71.59. They provide, transportation 6 establish, the requirements for 7 packages under normal and accident condition for 8 single and an array of packages. 9 CHAIRMAN WALLIS: Does this apply to 10 fabricated fuel or to -- No, it applies to new fuel 11 too. 12 Yes, those are --MR. RAHIMI: CHAIRMAN WALLIS: For fabricated fuel. 13 It's not the ingredients. It's not the transportation 14 15 of the uranium or enriched uranium. It's fabricated fuel it applies to. 16 It could be. 17 MR. RAHIMI: Those criticality safety requirements is for transporting 18 19 any kind of the fuel, pellets, fuel assembly, fuel rods, fissile material. 20 21 CHAIRMAN WALLIS: So material not even 22 fabricated. Okay. 23 MR. RAHIMI: Right. CHAIRMAN WALLIS: 24 Thank you. 25 The requirements in there MR. RAHIMI:

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	105
1	under Part 71.55 and 17.59, they are for non-site
2	specific. Those are general requirements for general
3	cask design, that they have to satisfy those
4	requirements and under Part 71, there is, the
5	criteria, a little bit more specific with respect to
6	presence of moderator in the containment system of the
7	package. Specifically under 71.55(b), it does state
8	that if water were to enter the containment system
9	between fuel assembly, it means between the fuel
10	assembly, that with fresh water, fresh water
11	intrusion, the package must remain subcritical.
12	CHAIRMAN WALLIS: Presumably it's all
13	light water.
14	MR. RAHIMI: Yes. Well, no. Actually we
15	They are required to look at the variation of water
16	density as a function of hydrogen. Yes, they look at
17	the range of "the most optimum moderation." Those are
18	the words. So it could be the heavy water. It could
19	be light water.
20	(Off the record comments.)
21	PARTICIPANT: light water, not
22	detorium.
23	MR. RAHIMI: Not detorium (PH) no.
24	PARTICIPANT: No.
25	MR. RAHIMI: So with that respect, 71.55
l	1

(202) 234-4433

	106
1	is kind of consistent with the Part 50.68 specific
2	requirements that the scenario they have under boron
3	dilution meaning fresh water that remains subcritical.
4	So with respect to transportation packages, there is
5	no problem. But we're including those transportation
6	packages in the rulemaking in order to define clearly
7	that when the transportation packages or storage casks
8	are in the pool, the requirements for those under Part
9	71/72, they apply to the casks, the fuel in the casks.
10	MEMBER ARMIJO: Under this regulation,
11	does the transportation Does a rule allow a credit
12	for burn-up on spent fuel for the transportation cask?
13	MR. RAHIMI: Okay. The rule is not
14	specific, but in the implementation of the regulation
15	the staff considers what's the most creditable
16	conditions and historically in the implementation of
17	Part 71, we have allowed, at this point, we allow
18	actonite only credit but not all the fission products.
19	We would allow that if the applicant comes in with the
20	data and proves in terms of benchmarking that they
21	know the isotopic content of the fuel, they know very
22	well, they have quantified all the uncertainty with
23	respect to cross-section of these isotopes, neutron
24	cross-section of these isotopes, so it depends on the
25	supporting data, we would give credit, burn-up credit.
1	I contract of the second se

(202) 234-4433

107 1 CHAIRMAN WALLIS: Now you say it's 2 subcritical if water leaks in and fills the cask. 3 Right? 4 MR. RAHIMI: Yes. 5 CHAIRMAN WALLIS: Doesn't it make a difference if there's water outside the cask too? 6 It 7 makes a slight difference but it could be significant 8 if you're talking about less than one or not. 9 MR. RAHIMI: Under our --(Court Reporter comment.) 10 MEMBER SIEBER: It makes a little 11 12 difference. CHAIRMAN WALLIS: It makes a little tiny 13 14 difference, doesn't it? 15 MR. RAHIMI: Yes. CHAIRMAN WALLIS: It's a reflection from 16 outside. 17 18 Right. MR. RAHIMI: 19 CHAIRMAN WALLIS: But is that part of the 20 rule or not? 21 The regulation says --MR. RAHIMI: Yes. 22 CHAIRMAN WALLIS: It is. So it's 23 submerged in water, too. 24 MR. RAHIMI: Yes, the regulation says 25 "reflection by water, water intrusion" all scenarios.

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433
	108
1	CHAIRMAN WALLIS: Everything.
2	MR. RAHIMI: Everything they have to
3	consider. So what's the most reactive configuration.
4	Now moving on to the next slide, now Part
5	72 regulation.
6	CHAIRMAN WALLIS: Presumably including
7	being next to the next cask.
8	MR. RAHIMI: I'm sorry.
9	CHAIRMAN WALLIS: Presumably being
10	adjacent to another cask, too.
11	MR. RAHIMI: That's right. Actually under
12	71.59 is array of packages they need to look at and an
13	array could be more reactive than a single package.
14	So they are supposed to look at all connecting
15	configurations and under Part 71 with respect to the
16	criteria is the 0.95 k-effective. That's the limit we
17	set.
18	MEMBER APOSTOLAKIS: Under which? I
19	thought it was 50.68 that has that.
20	MR. RAHIMI: No, I'm talking about Part
21	71/72 what the criticality safety requirements are
22	under Parts 71/72. But you're right. Under 50.68
23	they have one scenario that if you lose all the boron
24	in the pool, all you have to show is that you're just
25	below one. But they still have that 0.95 limit with

(202) 234-4433

	109
1	the boron that they take credit for.
2	MEMBER APOSTOLAKIS: That's in 68.
3	MR. RAHIMI: That's correct. That's in
4	68.
5	MEMBER APOSTOLAKIS: If I look at 72, am
б	I going to see anything like that?
7	MR. RAHIMI: No, you're not going to see
8	that.
9	MEMBER APOSTOLAKIS: No. That's what I
10	was saying.
11	MR. RAHIMI: You're not going to see it.
12	Under 72, again 72, the criteria is That's the next
13	one. Yes. The criteria are not very specific. They
14	are more general criteria, the criticality safety
15	requirements under Part 72. But you will see it has
16	to take two unlikely independent changes before
17	criticality can occur. Those are the criticality
18	safety requirements under Part 72.
19	CHAIRMAN WALLIS: It changes its geometry
20	that they are
21	MR. RAHIMI: In addition, yes.
22	CHAIRMAN WALLIS: drops that the fuel
23	doesn't move in any way.
24	MR. RAHIMI: Right. Under Part 72, there
25	are scenarios that they look at tip-over, cask tip-

	110
1	over. Those are part of the scenarios they look at,
2	but under Part 71, they look at the 30-foot drop. So
3	under Part 71 transportation, there are very stringent
4	requirements in terms of fire, drop, puncture. But
5	you go to the Part 72, what you have in terms of the
6	configuration or change in configuration, you have the
7	cask tip-over.
8	So this Part 72, the criticality safety
9	requirements, those are the general requirements.
10	CHAIRMAN WALLIS: What these margins
11	require which take of it being less than one to some
12	degree, isn't it?
13	MR. RAHIMI: Yes.
14	CHAIRMAN WALLIS: The margins require.
15	MR. RAHIMI: Yes, under Part 72, our
16	margin is five percent.
17	CHAIRMAN WALLIS: Right.
18	MR. RAHIMI: Our design criteria is 0.95.
19	CHAIRMAN WALLIS: But it gets you away
20	from being on the edge. Right?
21	MR. RAHIMI: Yes. Our subcriticality, you
22	know, limit is 0.95. It cannot be more than 0.95
23	including all the uncertainty biases.
24	MEMBER APOSTOLAKIS: This sub-bullet two
25	"unlikely independent changes before criticality can

```
(202) 234-4433
```

	111
1	occur," can you elaborate a little bit on that?
2	MR. RAHIMI: Sure. Under Part 72, it's a
3	double contingency principle. I mean that's what it
4	stems from and it says, basically what it means, that
5	the design has to be in such a way that it shouldn't
6	go critical with the first event, unlikely event. It
7	has to take a second unlikely event in order for it to
8	go critical, meaning what you design for, let's say,
9	during loading in the pool, for example. One of the
10	first The requirement is in the text like for the
11	72 cask, there has to be a minimum boron concentration
12	level in the pool before they can commence loading and
13	unloading. And that is one of the events, let's say,
14	and normally they take two independent measurements to
15	satisfy sort of this double contingency that indeed if
16	the first person messed up on the first measurement,
17	you know, it was the boron concentration was lower
18	than it was supposed to be
19	MEMBER APOSTOLAKIS: No, but I thought it
20	meant something else.
21	MR. RAHIMI: Okay.
22	MEMBER APOSTOLAKIS: That the boron
23	concentrate has to be greater than a number.
24	MR. RAHIMI: That's correct.
25	MEMBER APOSTOLAKIS: And that if it goes

(202) 234-4433

	112
1	below, that's one of the unlikely event and something
2	else.
3	MR. RAHIMI: That's right.
4	MEMBER APOSTOLAKIS: But you're saying no.
5	You're monitoring it with two different independent
6	means, that boron concentrate.
7	MR. RAHIMI: Right.
8	MEMBER APOSTOLAKIS: And these independent
9	monitoring activities must fail. Is that what you
10	mean?
11	MR. RAHIMI: In addition to this, yes, we
12	have a criticality monitoring requirement under Part
13	72.
14	MEMBER APOSTOLAKIS: No, but what are the
15	two independent changes? That's what I don't
16	understand because this is so fuzzy.
17	CHAIRMAN WALLIS: I think he hasn't gotten
18	to it yet.
19	MR. RAHIMI: Right. Well, no. This is a
20	slide to discuss. This is the
21	CHAIRMAN WALLIS: The two different
22	measurements aren't the independent changes.
23	(Several speaking at once.)
24	PARTICIPANT: The geometry change.
25	MEMBER BONACA: Now I'm thinking that
	1

(202) 234-4433

	113
1	there are two, I'm really anxious to hear about this
2	example.
3	MEMBER APOSTOLAKIS: Yes, I'm looking for
4	an example too.
5	MEMBER BONACA: I suppose
6	CHAIRMAN WALLIS: What is the other
7	independent change?
8	MR. RAHIMI: If you lose I mean
9	historically what we've been relying on again is those
10	two measurements of the boron concentrate.
11	CHAIRMAN WALLIS: Those are the two
12	independent changes.
13	MEMBER APOSTOLAKIS: Yes. That's not what
14	I understood.
15	CHAIRMAN WALLIS: That's not what I
16	understood either. No.
17	MEMBER APOSTOLAKIS: I thought if there is
18	for some reason the bottom concentration becomes too
19	low, something else also must happen for the
20	criticality to be achieved. You're saying no, no,
21	that event by itself can lead to criticality but I
22	have two independent means of making sure that it will
23	not happen.
24	PARTICIPANT: Right.
25	MEMBER APOSTOLAKIS: And the whole thing
I	

(202) 234-4433

	114
1	comes from the fact that the word "change" is not well
2	defined.
3	MEMBER BONACA: That's right.
4	MEMBER ARMIJO: In contrast to the
5	transportation cask for moving spent fuel, the
6	transportation cask will remain subcritical even if
7	it's flooded with pure water
8	MR. RAHIMI: That's correct.
9	MEMBER ARMIJO: and surrounded with
10	pure water. So it has enough poison built into the
11	structure that it's going to be okay no matter what.
12	MR. RAHIMI: That's correct.
13	MEMBER SIEBER: In case it falls into the
14	river.
15	MEMBER ARMIJO: Right. Now the dry
16	storage cask, does it not have the same amount of
17	structural boron in there to achieve the same goal in
18	fresh water?
19	MR. MARTIN: It's not analyzed for that.
20	MR. RAHIMI: Right. It's not analyzed for
21	that but although at the same time, this fuel that
22	we're talking about that these are the burned fuel and
23	we're not relying on the fact that the fuel is burned,
24	they assume the fuel is fresh under storage even.
25	That boron concentrate that is needed, it is for the
1	

(202) 234-4433

	115
1	fresh fuel configuration. So you have that other
2	factor that we don't take into account. The fact that
3	the fuel is burned but we may assume the fuel is fresh
4	and
5	CHAIRMAN WALLIS: A big difference.
6	MR. RAHIMI: Yes, and the boron
7	concentrate is based on that.
8	MEMBER APOSTOLAKIS: Okay. So you want a
9	k-effective less than 0.5.
10	MR. RAHIMI: 0.95. Oh, what I'm saying,
11	no. I said that typically when they're on the pad,
12	they're dry. You look at the k-effective. There is
13	substantial margin. The only time when it's submerged
14	in the pool, that's when you sort of approach into it.
15	MEMBER SIEBER: Submerged in any place.
16	MR. RAHIMI: I mean that number, I'm just
17	giving typically just That's what the k-effective
18	is when it's dry.
19	MEMBER APOSTOLAKIS: Okay.
20	MR. RAHIMI: When it's sitting on the pad.
21	MEMBER APOSTOLAKIS: Okay. So all these
22	things are valid.
23	MR. RAHIMI: Okay. So again
24	MEMBER APOSTOLAKIS: This was This
25	document was
	1

	116
1	PARTICIPANT: You just keep going.
2	MEMBER APOSTOLAKIS: I should respect my
3	own advice. Okay. Go on.
4	MR. RAHIMI: Okay. So when the loading of
5	the storage casks for transportation packages, again
6	I mean the regulative language for transportation, we
7	use package and package is really the cask and the
8	content, we call it package, when it's submerged in
9	the pool actually that is when the reactivity is
10	increased due to the moderation and that's when the
11	margins are decreased. And normally, these casks,
12	these storage casks or transportation packages, they
13	are licensed, you know, based on generic analysis,
14	generic information about the fuel and I guess as I
15	alluded earlier that the burn-up credit is available
16	to an applicant if they want to take credit for it
17	provided they have the supporting benchmarking,
18	meaning they can quantify all the biases and
19	uncertainties that are associated with burn-up credit
20	in a cask environment, not at the reactor core, in the
21	cask environment because it's a total different
22	environment or a different temperature from the
23	reactor core, the cross-section function of
24	temperatures. So it is different.
25	So under those conditions since
	1 I I I I I I I I I I I I I I I I I I I

(202) 234-4433

1 historically the vendors, you know, I guess they found 2 cumbersome to have all that data. The it most 3 straightforward path was credit for the boron that was 4 in the pool that they could satisfy. They said these 5 are the storage only casks. They said we're not going Therefore, we shouldn't 6 to use them for transport. 7 assume fresh water in there. So there is boron. As 8 long as we put а minimum boron concentration 9 requirement as far as tech spec for Part 72, we have satisfied the criticality safety requirement for Part 10 And historically, we've allowed that for the 11 72. vendors to rely on the boron because we believe that 12 the boron dilution scenario during cask loading, the 13 14 likelihood is low. 15 MEMBER ARMIJO: But you also know that 16 there's burn-up on that fuel. 17 MR. RAHIMI: That's correct. 18 MEMBER ARMIJO: You're not taking credit 19 Do you have any -- So you have a real for it. 20 advantage, but you're not taking account of that or 21 crediting that in your analysis. 22 That's right. MR. RAHIMI: It goes back. 23 It's more like a defense in depth that I know is, 24 boron is in there. 25 If I -- I quess I'm MEMBER CORRADINI:

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

117

1 new to this again, but I'm confused and I'm getting 2 more confused. So is there somewhere that I can look, 3 not now but later, that I would have a little chart 4 that said in the pool on the transportation system in 5 the dry cask the initial conditions that are real and then must be assumed by the licensee. Because as you 6 7 explain it, the assumptions are different in every different situation. 8 9 Right. PARTICIPANT: CORRADINI: 10 MEMBER And they're not consistent and I don't -- I'm not -- Maybe I'm just 11 I'm not catching it. 12 too new to this. So is there somewhere where this is laid out in some simple or at 13 14 least on one page way so that --MEMBER ARMIJO: Michael. I want to 15 16 apologize. There is as a matter of fact, but it may 17 not be accurate. It was so murky for me that I made a little Excel spreadsheet for each of these things 18 19 and when the time comes, I'll just pass it around so we can kind of have all our facts in front of us. 20 21 MEMBER CORRADINI: Okay. 22 This is my problem too. CHAIRMAN WALLIS: 23 What's the difference? I said it a long time ago. 24 What's the difference between there's a real situation 25 you're analyzing and the assumptions you're making

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

118

119 1 which sometimes make it more conservative and so on. 2 To separate those two is sometimes difficult. If I may, can I just chime in 3 DR. RYAN: 4 with a second to the question? One of the things that 5 strikes me is when you're loading fuel in a pool cask or in a pool in a cask, the strategies that you're 6 7 using that cask for might be completely different than 8 the strategies you use for transportation. So for that reason, the loading could be completely different 9 and I'm sitting here listening to the discussion 10 trying to think about what's the range of criticality 11 12 loading that could occur in transportation versus in the pool in the same cask. So I think I'm asking the 13 14 same question a slightly different way, but I'm a 15 little bit stuck too. 16 MR. MARTIN: From my perspective, the 17 biggest concern is with the Part 72 issue on the dry storage cask that is not analyzed to be filled with 18 19 pure water and then the likelihood when you're in the 20 spent fuel pool for the spent fuel pool to become pure 21 water and we're going --CHAIRMAN WALLIS: 22 I hope I'm never in the 23 spent fuel pool. 24 MR. MARTIN: Pardon me? 25 CHAIRMAN WALLIS: You said when you're in

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	120
1	the spent fuel pool.
2	MR. MARTIN: When the cask is.
3	(Several speaking at once.)
4	MR. MARTIN: When the dry storage cask is
5	in the spent fuel pool and then for that to turn into
6	fresh water and what's the likelihood of that and even
7	if that were to happen, would the fuel become critical
8	because it's burned up? Now we have There have
9	been a variety of analyses that have been done so far
10	and I have some notes here indicating for relative
11	initial percent uranium-235, say roughly, an initial
12	fuel load of about four percent uranium-235 burned up
13	at around 42,000 gigawatts days per metric ton, the
14	expectation would be that that would not
15	MEMBER POWERS: 42,000 gigawatt days per
16	ton?
17	MR. MARTIN: Per initial
18	MEMBER POWERS: That's a bunch.
19	MR. MARTIN: I'm sorry. 42,000 megawatt
20	DAIS per metric ton. The expectation would be, or 42
21	gigawatt days per metric ton, the expectation would be
22	that that fuel would be subcritical.
23	CHAIRMAN WALLIS: There might be cases
24	where you would unload earlier for some reason.
25	MR. MARTIN: There might be cases where

(202) 234-4433

121 1 you would unload for some reason and there could be 2 under a worse scenario a cell of relatively fresh fuel 3 that could occur. 4 MEMBER SIEBER: Yes, damage. 5 MR. MARTIN: It's possible but unlikely. 6 MEMBER SIEBER: If you get damage, you 7 might have to move that fuel around or ship it 8 someplace. 9 MR. MARTIN: Move that fuel around, ship 10 it someplace or put it, zone it even within the cask to ensure you could maintain an optimum configuration 11 to minimize the reactivity. 12 13 MR. RAHIMI: Okay. Yes. I'm sorry. Did 14 you have a question? 15 MEMBER APOSTOLAKIS: Just one last 16 question. 17 MR. RAHIMI: Sure. MEMBER APOSTOLAKIS: The issue of burn-up 18 19 arises only in the context of 50.68. Is that correct? 20 PARTICIPANT: No, in 71 also. 21 MR. RAHIMI: Burn-up credit. Burn-up credit is 22 MEMBER APOSTOLAKIS: 23 only in 68. 24 MR. RAHIMI: Burn-up credits is under 25 Yes, that's one of the assumptions that you 50.68.

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	122
1	use up burn-up credit under 50.68.
2	MEMBER APOSTOLAKIS: Okay. So you don't
3	get credit for it.
4	MR. RAHIMI: The credit on the Part 71/72
5	is available but not to the extent that it is
6	available under Part 50.68.
7	MEMBER APOSTOLAKIS: But that's not what
8	the documents says though. That's why I'm confused.
9	MR. RAHIMI: Well, I will go later on to
10	talk about burn-up credit, the differences with the
11	50.68 and 71/72 with respect to burn-up credit.
12	MEMBER APOSTOLAKIS: 10 CFR 72 was in part
13	predicated on the assumption that spent fuel without
14	any burn-up would remain subcritical when stored dry
15	in a cask and remains subcritical when placed in a
16	cask in a spent pool fuel at the commensurate power
17	reactor.
18	MR. RAHIMI: Yes.
19	MEMBER APOSTOLAKIS: Implementation of
20	Part 72 relies on soluble boron rather than on burn-up
21	to assure subcriticality.
22	MR. RAHIMI: That's correct. Yes.
23	MEMBER APOSTOLAKIS: I have digested that.
24	Now you're changing it.
25	MR. RAHIMI: No. What you just digested
	1 I I I I I I I I I I I I I I I I I I I

(202) 234-4433

	123
1	was correct under Part 72. Yes, they assume the fuel
2	is fresh.
3	MEMBER APOSTOLAKIS: Okay. And the way
4	you're going to modify the Rule 68 you will add a
5	paragraph C that will say this rule doesn't apply to
6	casks in the pool.
7	MR. RAHIMI: Yes.
8	MEMBER APOSTOLAKIS: Therefore, they
9	cannot, they will not address the issue of burn-up.
10	They will satisfy 72.
11	MR. RAHIMI: Yes.
12	MEMBER APOSTOLAKIS: Now you mentioned
13	that they may want to do it, but then that would be -
14	that would deviate from whatever the practice is and
15	you guys would have to review the whole thing from the
16	beginning. Right?
17	MR. RAHIMI: In partial. Right now, the
18	licensing basis for granting those Part 72 licenses is
19	boron, soluble boron, credit.
20	MEMBER APOSTOLAKIS: You rely on boron?
21	MR. RAHIMI: Yes.
22	MEMBER APOSTOLAKIS: Okay. Now I'm back
23	to understanding.
24	MR. RAHIMI: Okay.
25	CHAIRMAN WALLIS: The only way you get rid

ĺ	124
1	of the boron would be some sort of catastrophic flood
2	or something.
3	MR. MARTIN: Well, we'll get into that.
4	That's right. There's basically a slow scenario and
5	a fast scenario and catastrophic flood is possibly
6	from a seismic event or a
7	CHAIRMAN WALLIS: Or a dam breaks or
8	something. You know there are ways which you can
9	flood everything with a lot of water.
10	MR. RAHIMI: Okay. So I would like to end
11	this slide by saying that at the end for the Part 72
12	licenses that the reliance on solid boron is made to
13	maintain subcriticality and these are normally for
14	early storage casks that was licensed, they didn't
15	have poison plates, or newer casks that they are high
16	capacity, high density casks like a 32 P. But if you
17	look at normally what has been loaded, there are 24
18	PWRs. They have flux draft design in there and
19	normally they haven't needed to rely on the solid
20	boron in the pool. So those are the instances you
21	were talking about.
22	I guess at this point I'll turn it over to
23	Tom.
24	MR. MARTIN: Okay. Back into the reactor
25	implementation arena. In March 2005, NRR issued
	I

(202) 234-4433

	125
1	Regulatory Information Summary, RIS 2005-05 to alert
2	licensees of our position that criticality
3	requirements of both 10 CFR 50.68 and Part 72 apply
4	while fuel is located in the spent fuel that's within
5	the boundary of the spent fuel pool.
6	Before this time, licensees had not been
7	applying these considerations, both of the
8	requirements of 50.68 and of the Part 71/72
9	requirements. This was intended to clarify the
10	regulatory position and the interpretation that we got
11	on 10 CFR 50.68 that while the cask is within the
12	pool, the regulations of both 50.68 and Part 71 and 72
13	applied. This then affected the licensees such that
14	they would have to analyze the fuel, conduct an
15	additional criticality analysis and either request an
16	exemption of their technical specification, request an
17	exemption of their license or amend their license to
18	modify it to be in conformance with the requirements.
19	CHAIRMAN WALLIS: They do have to perform
20	some sort of criticality analysis, don't they?
21	MR. MARTIN: Yes, they would have had to
22	perform an additional criticality analysis.
23	CHAIRMAN WALLIS: Using different
24	assumptions.
25	MR. MARTIN: Using different assumptions

(202) 234-4433

	126
1	for the
2	CHAIRMAN WALLIS: In regulatory space,
3	they're not really a criticality analysis of what's
4	really there. They're doing something with various
5	assumptions. That's different. I guess that's what's
6	different.
7	MR. RAHIMI: Yes, under Part 50.
8	CHAIRMAN WALLIS: If they were doing a
9	criticality analysis of what's really there, it would
10	always be the same presumably.
11	MR. MARTIN: Right.
12	PARTICIPANT: Or no
13	MR. MARTIN: I have to apologize. I was
14	
15	MEMBER APOSTOLAKIS: It's a worst case
16	analysis, isn't it? That's what it is. You're
17	assuming you have fresh fuel. You have unborated
18	water. Prove that it is subcritical.
19	CHAIRMAN WALLIS: There are assumptions
20	that are different in the two cases.
21	MEMBER APOSTOLAKIS: Yes, the assumptions,
22	but the analysis
23	CHAIRMAN WALLIS: But the reality
24	MR. MARTIN: They were doing a realistic
25	analysis.

	127
1	MEMBER APOSTOLAKIS: Realistic analysis.
2	The assumptions
3	MR. MARTIN: They were doing a realistic
4	analysis to show that they would be subcritical under
5	the actual conditions if you have pure water in the
6	dry storage sitting in the spent fuel pool. Mr.
7	Kraft, is that correct?
8	MR. KRAFT: I'm sorry. I'm having
9	difficulty with the ins and outs of the conversations.
10	(Off the record discussion.)
11	MR. KRAFT: I apologize. I'm having
12	difficulty following the ins and outs of the
13	conversation.
14	CHAIRMAN WALLIS: You're the expert, are
15	you?
16	MR. KRAFT: No sir. I have experts with
17	me, but I will tell, Dr. Wallis, that I think you put
18	your finger right on the nub that there are different
19	methodologies for calculating the same thing.
20	MR. MARTIN: Right.
21	CHAIRMAN WALLIS: You're forced to make
22	different assumptions.
23	MR. KRAFT: Not just that there are
24	different assumptions.
25	CHAIRMAN WALLIS: But the situation is the
	•

(202) 234-4433

	128
1	same. Right? The physical situation is the same.
2	MR. KRAFT: Well, the situations can be
3	different. They're in a cask. You're in a pool.
4	Those are different
5	CHAIRMAN WALLIS: Once you define the
6	situation, it's clear what it is.
7	MR. KRAFT: Yes. And how you calculate
8	CHAIRMAN WALLIS: Then you use different
9	methods of analysis. Is that it?
10	MR. KRAFT: Well, our view is that how you
11	calculate The radionuclide doesn't care where it
12	is. It's going to decay the same way. The difference
13	is what geometry and what assumptions you're making
14	for that geometry. That's okay.
15	CHAIRMAN WALLIS: What assumptions you're
16	required to make. That's the difference.
17	MR. KRAFT: But if you dig into what NRC
18	requires that you to do or does in their own analyses,
19	they have different methodologies that apply in
20	different geometric settings. Am I wrong about that,
21	Meraj?
22	MR. RAHIMI: No, you're correct in terms
23	of, yes, under Part 72 that the licensees would rely
24	on the boron. The situation is the same, I mean, the
25	configuration instead of burn-up credit. When you go
1	I contraction of the second seco

(202) 234-4433

	129
1	to the Part
2	CHAIRMAN WALLIS: Methodology, that to me
3	means a different method, I mean, two group theory or
4	something or other different or seven group theory or
5	
6	MR. RAHIMI: No, but what Steve means by
7	"methodology," (1) taking into account the burn-up of
8	the fuel. The other method does not.
9	CHAIRMAN WALLIS: Methodology to me means
10	the way you analyze. We're not talking about that.
11	MR. RAHIMI: No.
12	CHAIRMAN WALLIS: We're talking about the
13	assumptions, the variations, of the analysis.
14	MR. RAHIMI: The assumptions, correct.
15	We're talking about different assumptions under Part
16	50.68
17	CHAIRMAN WALLIS: Which are in the
18	direction of being conservative. So it's different
19	conservatisms you're talking about.
20	MR. RAHIMI: That's correct.
21	MR. MARTIN: And the problem
22	CHAIRMAN WALLIS: Is that right, Sam?
23	MEMBER ARMIJO: The frustration to me is
24	and I'm frustrated because there's reality. The fuel
25	has a certain amount of burn-up whether it's in the
1	

(202) 234-4433

	130
1	cask, in the pool or in a transportation package. But
2	sometimes you can use it and sometimes you can't. But
3	it's real. It's still there and so the problem I'm
4	having is, and I agree it's bad to do two analyses for
5	very different conditions to apply to the same
6	physical thing, but there is something very confusing
7	about
8	What we're supposed to do is assure safety
9	and then the other part of the argument is assure that
10	you mean requirements. Regulatory requirements are
11	not the same thing. So how do we assure safety and
12	the way to assure safety is to work with
13	CHAIRMAN WALLIS: If either the
14	requirements assures safety, I don't care which one
15	you use.
16	MEMBER ARMIJO: Well, maybe and maybe not.
17	But yes.
18	MR. ROLAND: Can I say something for a
19	minute? My name is Bill Roland. I'm the Deputy
20	Director for the Spent Fuel Project Office for
21	Inspection and Licensing. What I know Meraj and NRR
22	is going to eventually get to is the difference in the
23	way we do the analysis in that for a specific reactor
24	we use the specific fuel design and the specific data
25	that they provide. The Spent Fuel Project Office,
	1

(202) 234-4433

	131
1	these casks are generically approved so that there's
2	more bounding analyses that has to be performed as a
3	result of that and I know Meraj later on has that on
4	his slide. So we're going to get there.
5	CHAIRMAN WALLIS: Get to that.
б	MR. RAHIMI: Yes.
7	CHAIRMAN WALLIS: Everything will become
8	clear in the last act.
9	MR. RAHIMI: I hope so.
10	CHAIRMAN WALLIS: It will all be certain.
11	MR. ROLAND: We hope, Dr. Wallis. No
12	doubt if it isn't, you'll help us. You'll point that
13	out. Thank you.
14	MEMBER SIEBER: The point is they're
15	trying to simplify the regulation.
16	MR. RAHIMI: Yes. Correct. Simplify the
17	application.
18	MEMBER APOSTOLAKIS: And clarify.
19	MEMBER SIEBER: We have certainly
20	established the need for simplification.
21	MR. RAHIMI: Yes.
22	(Laughter.)
23	MR. MARTIN: I apologize. As a My
24	staff person who was intended to give this
25	presentation today was called for jury duty and I was
	1

```
(202) 234-4433
```

	132
1	thrown into the breach at the last moment to give this
2	presentation.
3	MEMBER SIEBER: I bet you that's true.
4	MR. MARTIN: But it was all clear to me
5	beforehand.
6	PARTICIPANT: Before talking to us.
7	MEMBER SIEBER: I would be too.
8	MR. MARTIN: As far as the conclusion on
9	this slide, at the time we issued this regulatory
10	information summary, we were clarifying NRC
11	expectations and we made it clear that licensees must
12	comply with the requirements of both 10 CFR 50.68 and
13	the requirements of 10 CFR 71 and 72 which then
14	resulted in licensees having to do additional
15	analyses.
16	MEMBER SIEBER: Right.
17	MR. MARTIN: And either requesting an
18	exemption of the regulations or requesting an
19	amendment and that became quite much more labor
20	intensive and expensive for both the NRC and the
21	industry than we had anticipated.
22	CHAIRMAN WALLIS: But it's a kind of
23	defense in depth. If you have public safety assured
24	by two different independent methods that's a kind of
25	defense in depth.

(202) 234-4433

	133
1	MEMBER APOSTOLAKIS: No. That's one of
2	the major problems of the structure of this defense in
3	depth. There is no end. You can spend millions of
4	dollars and
5	CHAIRMAN WALLIS: But here we only have
6	two.
7	MEMBER APOSTOLAKIS: I think they are
8	doing fine, Graham. They are just not explaining it
9	very well.
10	MEMBER ARMIJO: I think they're doing what
11	is.
12	MEMBER APOSTOLAKIS: Let's get into the
13	scenarios.
14	CHAIRMAN WALLIS: Let's move on.
15	MR. MARTIN: So the purpose and scope of
16	the rulemaking.
17	VICE CHAIR SHACK: Let me just go back to
18	this for one second. If the purpose wasn't to make
19	them do both analyses, why did you issue the RIS in
20	the first place?
21	MEMBER APOSTOLAKIS: That's exactly the
22	question.
23	MR. MARTIN: We At the time the RIS was
24	issued, we did not appreciate the extent of the burden
25	that this would create.
	1 I I I I I I I I I I I I I I I I I I I

(202) 234-4433

	134
1	VICE CHAIR SHACK: I see. So you did
2	intend for them to do both analyses.
3	MR. MARTIN: We did intend for them to do
4	the additional analyses, however, we did not
5	appreciate that the burden was going to be as
6	extensive.
7	CHAIRMAN WALLIS: Why did you ask them to
8	do it in the first place? I mean there must be some
9	reason why you wanted them to do independent of
10	burden. You thought it was a good idea.
11	MR. RAHIMI: No because technically, they
12	would have been out of compliance according to the
13	rule when you introduce something in the pool.
14	CHAIRMAN WALLIS: So you were saying that
15	they would have been out of compliance.
16	MR. RAHIMI: Yes, they would have been out
17	of compliance.
18	MR. MARTIN: And previously what's not
19	clear to the staff
20	CHAIRMAN WALLIS: You're clarifying the
21	situation.
22	MR. MARTIN: around the six/seven years
23	ago that there was this overlap in the regulations
24	that did exist and then
25	CHAIRMAN WALLIS: Okay. So you were just
	1

(202) 234-4433

	135
1	clarifying the compliance requirements. You weren't
2	
3	MR. MARTIN: a careful reading of the
4	regulations by someone around five or six years
5	identified that these conditions existed and that they
6	really had to comply
7	CHAIRMAN WALLIS: Both rules applied.
8	MR. MARTIN: to both the requirements,
9	the criticality and criticality analyses requirements
10	of 50.68 and the Part 71/72 and our initial impression
11	was in order to be in compliance with the regulations
12	and, as I might add, an unintended consequence of the
13	regulations at first we did not feel that this was
14	going to create a significant burden.
15	CHAIRMAN WALLIS: The cask comes along and
16	it obeys some regulation and then it crosses some
17	border and it shows its cask to all and it satisfies
18	some other regulation. That's what you want?
19	MR. MARTIN: Yes.
20	MEMBER SIEBER: Right. Two different
21	offices.
22	MEMBER APOSTOLAKIS: So it's getting out
23	of the reactor arena. Right?
24	MEMBER SIEBER: Well, cost is.
25	MR. MARTIN: We're not here to discuss the
I	1

(202) 234-4433

	136
1	reason this came to past, but we're trying But
2	we're here to try to straighten it out.
3	MEMBER APOSTOLAKIS: But the ACRS did not
4	review it.
5	PARTICIPANT: Okay.
6	MEMBER APOSTOLAKIS: But we're trying to
7	help.
8	(Several speaking at once.)
9	MR. MARTIN: I know you're trying to help
10	and we appreciate that.
11	Okay. The purpose and scope of the
12	rulemaking. To reduce the regulatory burden imposed
13	by compliance with both 50.68 and Part 71 and 72 as
14	applicable.
15	MEMBER APOSTOLAKIS: This is the key.
16	MR. MARTIN: Our intention is that the
17	requirements of 50.68 would not apply to the fuel that
18	has entered the physical boundary of the cask or
19	package located in the spent fuel pool.
20	CHAIRMAN WALLIS: What happens when it's
21	halfway in?
22	MR. MARTIN: The requirements of Part 71
23	or 72 would apply.
24	CHAIRMAN WALLIS: Both apply. Okay. So
25	do you have to do an analysis when it's halfway in.
	1 I I I I I I I I I I I I I I I I I I I

```
(202) 234-4433
```

	137
1	MR. MARTIN: The requirements of Part 68
2	would not apply.
3	MEMBER APOSTOLAKIS: They are different.
4	This is like establishing boundaries between the ACRS
5	and ACNW.
6	(Laughter.)
7	MR. MARTIN: For example, if a licensee is
8	moving a fuel assembly from a spent fuel pool storage
9	rack into the cask 50.68 would apply to the fuel
10	assembly until the bottom portion of the fuel assembly
11	crossed the boundary of the cask, the plane made up by
12	the top surface of the cask.
13	CHAIRMAN WALLIS: Ah.
14	MEMBER SIEBER: There you go.
15	CHAIRMAN WALLIS: So it's if any part of
16	it has entered the physical boundary. Right?
17	MR. MARTIN: Correct.
18	CHAIRMAN WALLIS: Okay. Thank you.
19	MR. MARTIN: Okay.
20	MEMBER APOSTOLAKIS: Now I have a
21	complaint about the technical evaluation before you
22	even jump into it.
23	MR. MARTIN: Okay. Would you like to
24	express your complaint before I talk or after I talk?
25	MEMBER APOSTOLAKIS: I would like to

(202) 234-4433

	138
1	express my complaint. You describe in this document
2	several scenarios and one has to do mental acrobatics
3	to follow you. You know at this day and age an event
4	tree would go a long way towards explaining what
5	you're trying to do. Show the scenarios for heaven's
6	sake and then discuss. Now I have to figure it out
7	myself. I have to draw the scenario myself. I mean
8	this is really a case where this simple tool would
9	have helped a lot. You know what an event tree is,
10	don't you?
11	MR. MARTIN: Yes. And I
12	MEMBER POWERS: George will tell you.
13	MR. MARTIN: I'm not sure the members of
14	the general public if we publish this in the Federal
15	Register would be able to follow an event tree as
16	opposed to the mental acrobatics of the
17	MEMBER APOSTOLAKIS: They would follow it.
18	MR. MARTIN: But I can appreciate your
19	comment and I
20	MEMBER APOSTOLAKIS: It's so simple to
21	show the scenarios. Now it's very difficult to
22	remember how much scenario two and three they share or
23	they are different and so on.
24	MR. MARTIN: Well, let me try to lay it
25	out for you in general.
1	I

(202) 234-4433

(202) 234-4433

	139
1	MEMBER APOSTOLAKIS: Okay.
2	MR. MARTIN: Just to talk you through it.
3	If we start with the probability of a cask being in
4	the pool which could be as generally licensees fill
5	three casks per year and there could be a period of
6	about three days where the fuel is in the cask with
7	the head off the cask and that would probably be
8	generous. We do not We do object from a standpoint
9	of the regulator to licensees having any intent to
10	leave the cask in the pool for any period of time
11	because our consideration is that this would not
12	comply with the design basis of the racking of their
13	spent fuel pool and it would become We would not
14	permit this to become part of the permanent storage in
15	their spent fuel pool, but rather a device that was
16	intended to transit the fuel pool.
17	So you have to start from the standpoint
18	of the probability of this cask being in the pool with
19	the spent fuel which if you're talking average loading
20	of three casks per year in about three days you're
21	talking about nine days out of the year where you
22	potentially have this vulnerability and that's order
23	of magnitude 10^{-2} or around 2 X 10^{-2} .
24	MEMBER APOSTOLAKIS: Why do you say three?
25	In the document it's five. Have you updated that or
1	I

(202) 234-4433

	140
1	what? Historical data suggests that approximately
2	five storage casks are loaded on an annual basis.
3	MR. MARTIN: Right. We -
4	MEMBER APOSTOLAKIS: It's still 10 $^{-2}$. I
5	mean it doesn't change the probability.
6	MR. RAHIMI: Right. For the technical
7	basis, we made conservative assumptions. What Tom is
8	giving you is a more realistic scenario.
9	MR. MARTIN: It may be more realistic.
10	I'm giving you something more realistic as opposed to
11	a conservative assumption that might be discussed in
12	the document you have in front of you.
13	MEMBER APOSTOLAKIS: It still doesn't
14	matter I don't think, but okay.
15	MR. MARTIN: So you have to have a
16	probability of the cask in the pool with the fuel
17	loaded in the cask. Then you have to have a potential
18	for a boron dilution event to cause fuel damage and
19	here we discuss a possibility of a slow boron dilution
20	event due to injection from unborated water or a rapid
21	spent fuel pool drain-down.
22	Following the fast dilution event, the
23	fast drain-down event, then you would have to dilute
24	the pool after that because if you just drain down the
25	spent fuel pool very quickly, you had a fast drain-
l	I contraction of the second seco

(202) 234-4433

	141
1	down, the fuel that was the most secure in the spent
2	fuel pool would be the fuel in the cask. The fuel
3	that would be more vulnerable would be the fuel that
4	was in the racks. So what you would be concerned with
5	would be as far as the fuel in the cask itself not as
6	much the drain-down but any subsequent dilution and
7	operators would if there was a capability of refueling
8	the spent fuel pool, first of all, they would choose
9	to fill it with borated water and if they had to spray
10	the pool, this is again a beyond-design-basis event
11	that comes with, it's part of other considerations,
12	but there might be a possibility of sprays being
13	diverted to spray the fuel in the spent fuel pool and
14	then the possibility would exist of the water, the
15	pool, I'm sorry, the water to drain into the cask such
16	that the water in the cask would then become dilute
17	which if that's the only If you had a fast drain-
18	down and now you have water in the cask and the water
19	that's left in the cask would still be borated water,
20	then you would have to have a dilution through
21	Shetlay's Principle or some sort of osmosis of moving
22	this material in or out of the cask that would become
23	diluted or there are some casks that have a small
24	drain valve on the bottom. So there is a possibility
25	that the water would slowly drain out of the bottom of
	I

(202) 234-4433

(202) 234-4433

142
the cask and then be refilled with fresh water, again,
not a very likely event.
And then even if the water were to drain
out of the pool and the water in the cask were to
become diluted, there would have to be the possibility
that the fuel remaining in the cask could become
critical. And then even if it became critical, we
could look at the consequences which might be minimal
relative to the consequences of everything else that's
happening around this event.
The other event that we could discuss
would be a slow dilution event and with slow dilution
events there is
MEMBER APOSTOLAKIS: "Slow" means hours.
MR. MARTIN: Slow could mean hours. It
could mean a hose stuck into the pool or stuck into
the cask or some other That's probably about the
only way that something like this could happen or if
there was a loss of control of the equipment to
monitor the fuel in the spent fuel pool and there was
somehow pure fresh water injected into the spent fuel
pool.
MEMBER APOSTOLAKIS: But I mean you're
done with the seismic evaluation to drain-down.
MR. MARTIN: If you have any questions,

(202) 234-4433

	143
1	yes. Do you have any more questions on that?
2	MEMBER APOSTOLAKIS: So there was a study
3	done
4	MR. MARTIN: Go ahead.
5	MEMBER APOSTOLAKIS: There was a study
6	done reported in Inurrich (PH) that the peak ground
7	acceleration that would start creating damage to the
8	spent fuel pool is 0.5 g. Right? That's pretty high.
9	That's very high. I'm just commenting on that.
10	MR. MARTIN: For a ground acceleration,
11	correct. So the order of magnitude
12	MEMBER APOSTOLAKIS: So essentially what
13	you're saying is the probability of getting that kind
14	of BGA is so low that the whole event is unlikely.
15	MR. MARTIN: Well, if I'm looking just
16	in round figures. The probability that the cask is
17	going to be in the pool in a configuration that would
18	be vulnerable is on the order of magnitude of maybe
19	10^{-1} to 10^{-2} , around 10^{-2} more likely, maybe a little
20	bit greater than that. So somewhere between 10 $^{-1}$ to
21	10^{-2} likelihood that the cask will even be in the pool
22	in that configuration.
23	MEMBER APOSTOLAKIS: Right.
24	MR. MARTIN: Then you would have to have
25	for the fast drain-down a seismic event. The

(202) 234-4433
	144
1	probability of the seismic event would be somewhere
2	around the order of magnitude of 10^{-5} .
3	MEMBER APOSTOLAKIS: Because of that
4	acceleration which is very high.
5	MR. MARTIN: Yes. You would have to have
6	beyond-design-basis seismic event that would cause a
7	rapid drain-down in the spent fuel pool and then you
8	would have to have You could have in that the
9	probability that the fuel would even go critical were
10	it
11	CHAIRMAN WALLIS: Seismic event associated
12	with a dam failure which would flood the pool.
13	MEMBER ARMIJO: No, you would be trying to
14	reflood the pool.
15	CHAIRMAN WALLIS: You would try, but you
16	might reflood with unborated water.
17	MEMBER ARMIJO: Right.
18	CHAIRMAN WALLIS: I'm saying the dam
19	failure would if some of these pools are below grade.
20	But again, it's a huge unlikelihood. I'm just trying
21	to think of ways in which you could get water going
22	into the pool, undesirable water from somewhere.
23	MR. MARTIN: Right.
24	CHAIRMAN WALLIS: And it could be from the
25	environment.

(202) 234-4433

	145
1	MR. MARTIN: It could be.
2	CHAIRMAN WALLIS: Extreme case. Right.
3	MR. MARTIN: Generally speaking, plants
4	are designed for significant environmental events and
5	I don't know of any plant that's significantly
6	vulnerable to a dam break that would create such a
7	problem in the spent fuel pool.
8	MEMBER MAYNARD: But in any event
9	regardless of what consequences you want to assume,
10	the fuel that's actually in the cask during this would
11	probably be better protected and in better shape than
12	the fuel that you have in the rest of the spent fuel
13	pool.
14	MR. MARTIN: That's correct and actually
15	you could throw in probably another, at least, an
16	order of magnitude that even the fuel in the cask will
17	not go critical because it's spent fuel.
18	MEMBER ARMIJO: And that's where I have a
19	problem. I think the real issue is could you have a
20	local boron dilution separate from the pool and there
21	are ways that might happen. I mentioned that to the
22	staff earlier.
23	CHAIRMAN WALLIS: But it's hard to imagine
24	how though. Someone would almost have to
25	MEMBER ARMIJO: I don't think we want to

(202) 234-4433

	146
1	discuss it here.
2	CHAIRMAN WALLIS: just wilfully insert
3	the hose.
4	MEMBER ARMIJO: Well, you just discussed
5	it.
6	MR. MARTIN: There are certain ways that
7	that could That might be one possible scenario.
8	But even if someone decided that they wanted through
9	sabotage do something like that the refueling deck is
10	a controlled personnel access area as a vital area of
11	the plant. The people that load and unload the spent
12	fuel pool are licensed operators. The senior person
13	in the refueling area is a senior licensed operator.
14	There are While the cask is in the pool, there are
15	measures in place to control the boron concentration.
16	There are samples that are taken every They have to
17	be taken at least every 72 hours and they are normally
18	taken more frequently than that. So I would say every
19	24 to 72 hours there are two samples taken of the
20	boron. There is a level monitoring of the spent pool
21	fuel so that if there's any significant change of the
22	level either up or down, there's an expectation that
23	that would be picked up. The operators in the on
24	the refueling deck are very conscious of the radiation
25	levels and the level of the spent fuel pool and it's

(202) 234-4433

	147
1	very likely that they would pick up anything any more
2	than a very minor change of the
3	CHAIRMAN WALLIS: You're on the next slide
4	really.
5	MEMBER MAYNARD: You also don't have
6	faucets and hoses of fresh water sources available,
7	laying around, in these areas either.
8	MEMBER ARMIJO: I think that was
9	identified in one of those scenarios you analyzed as
10	a potential for diluting the entire pool. It was
11	mentioned in the analysis. I think the question I
12	would like answered is if you have a dry storage cask
13	in the pool with spent fuel in it and you fill that,
14	displace the borated water locally with pure water,
15	would it still be safe if you took credit for burn-up
16	and the structure. Would it still be safe? And if
17	that was the case I think then I think you're home
18	free. Well, if it's not the case then I think it's
19	MR. MARTIN: We believe in many cases that
20	it would be safe. However, we haven't analyzed for
21	all these cases and that becomes part of the crux of
22	the problem which is the tie-in through the technical
23	specifications and the license for each plant and the
24	analysis, the additional analysis, that would have to
25	be done.

(202) 234-4433

	148
1	The results that I've had and I'm sorry.
2	I did give you one incorrect number, I should have
3	consulted my notes, on an enrichment for an analysis
4	that we had done to show that initial enrichment of
5	uranium-235 with a four weight percent initial
6	enrichment, a burn-up of about 32 gigawatt days per
7	metric ton would be about the cutoff for an
8	expectation for assuring subcriticality and we would
9	expect that fuel that was enriched under normal
10	circumstances certainly to four weight percent would
11	be burned at a higher rate than 33 gigawatt days per
12	metric ton.
13	CHAIRMAN WALLIS: Does that answer your
14	question, Sam?
15	MEMBER ARMIJO: Yes, I think it does but
16	you know you need to take credit for the burn-up for
17	that to be subcritical.
18	MR. MARTIN: If we were to take credit for
19	the burn-up fully in every case, we think it would be
20	in almost every case we would say we would be okay.
21	Even with no boron, it would be likely that we would
22	maintain conditions subcritical. However, the
23	regulations as they're written right now don't You
24	know we're trying to establish separation between 71
25	and 72 and Part 68 so that we don't get into this gray
	1 I I I I I I I I I I I I I I I I I I I

(202) 234-4433

149 1 area where we're applying both sets of regulations. 2 MR. RAHIMI: Let me add that the question 3 you asked, yes, under Part 50.68, yes, those are the 4 assumptions that they take credit for burn-up and the 5 reason again which I'll go into it later why we don't yet under Part 71/72 when it's outside of the pool, 6 7 they don't have to quantify all the uncertainty to a 8 great detail because they always have the boron as a 9 So given that, they always satisfy with backup. 10 taking into account burn-up credit in the pool. Fresh water, they are subcritical. 11 12 Do you know what's ARMIJO: MEMBER difficult to realize is that you have burn-up credit 13 14 for one physical entity, a fuel bundle, and that burn-15 up credit isn't attached to it when it's put into a 16 dry storage cask. You know maybe you can discount it. 17 Maybe you can saying, I'm not going to give you full burn-up credit. I'll give you 75 percent burn-up 18 19 But there's still a burn-up credit. credit." There 20 has to be some solution where reality can go with the 21 item. 22 You're right. MR. RAHIMI: I mean that's 23 exactly what he's done. Under Part 71/72, we're 24 saving, "You're coming to cask environment, 25 transportation environment. We know the actonite yes

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	150
1	is there. Yes, you cannot quantify all the fission
2	product, cross section. You don't have chemical
3	assay." Those are the areas that right now that the
4	applicants are trying, we're encouraging them, to get
5	data for transportation and come in with the
6	application.
7	But actonite only burn-up credit, yes, we
8	have ISGA Rev 2. It tells the cask vendors to go
9	ahead and take credit for the actonites. Those we
10	have data we're sure. We know about the cross section
11	of all those actonites.
12	MEMBER ARMIJO: And they could do it for
13	the dry storage cask as well?
14	MR. RAHIMI: They could If they want to
15	choose to, yes, they could do it.
16	MEMBER ARMIJO: Wouldn't need any more
17	data. Right?
18	MR. RAHIMI: Yes, actonite only, but
19	unfortunately with the actonite only credit they
20	cannot make it where they put 32 assemblies in a
21	canister. They want to put maximum amount of fuel
22	assembly in that canister.
23	MEMBER ARMIJO: With actonite credit 32
24	assemblies in a canister and you displace the borated
25	water with fresh water by some mechanism, it will go
	1

(202) 234-4433

	151
1	critical.
2	MR. RAHIMI: Yes. If you take partial
3	credit, yes, partial credit for burn-up credit in
4	there and
5	MEMBER ARMIJO: Right, but if you take
6	full credit, it probably wouldn't if you had 32,000
7	megawatts.
8	MR. RAHIMI: It probably wouldn't
9	That's right. That's why under 50.68 they've analyzed
10	with the full burn-up credit, getting rid of all the
11	boron in there, they are separated below one. But on
12	the other side in the cask, our criteria is 0.95. As
13	I will go into it because the environment is
14	different, the cask isn't an open environment, it's
15	not even a controlled environment, we need to be a
16	little bit more careful.
17	MEMBER CORRADINI: So if I just could
18	If you're going to get to this later.
19	MR. RAHIMI: Yes.
20	MEMBER CORRADINI: Because you just about
21	got to the slide I thought would be at the beginning
22	of the presentation, Slide 16, which essentially gives
23	the assumptions and initial conditions. So I don't
24	want to take you there if you're going to go there,
25	but you kind of almost got there with all this

(202) 234-4433

	152
1	discussion.
2	MR. RAHIMI: Yes.
3	MEMBER CORRADINI: So shall we wait?
4	CHAIRMAN WALLIS: I think he's already
5	discussed this slide.
6	MR. MARTIN: Well, I've already been
7	through the slow boration and the rapid drain-down,
8	I'm sorry, the slow boron dilution and the rapid
9	drain-down. The attention at least from my standpoint
10	was to go through just a very brief summary and then
11	turn it over to Meraj for a more in-depth discussion
12	of the differences between the analyses between Part
13	50 and then Part 71/72.
14	CHAIRMAN WALLIS: That's what we were
15	trying to figure out all along.
16	MR. MARTIN: Which is what you've been
17	trying to figure out.
18	MEMBER APOSTOLAKIS: I think Mike is right
19	though. The last slide does that well, doesn't it?
20	MEMBER CORRADINI: So if I could
21	MEMBER APOSTOLAKIS: Let's go to 16.
22	MEMBER CORRADINI: So if I could just ask
23	the question with that slide in front of us.
24	MR. RAHIMI: Okay.
25	MEMBER CORRADINI: You said something in
	1

(202) 234-4433

response to Mr. Armijo that I wanted to at least have you repeat because I heard it but maybe I misheard it. You're saying that you know with some certainty what are the actonites are but you don't know what the fission product is and that's why the reason you don't give it credit. That's what I thought I heard you say.

That is correct. 8 MR. RAHIMI: They have 9 not -- We have not seen, you know, that the licensees 10 have not quantified or that the cask designers have not quantified the uncertainties associated with 11 12 fission product cross section in a cask environment. So let me say it back

MEMBER CORRADINI:

14 to you because I used to -- I teach some days and I 15 tell my students that the thing we have the highest certainty of is decay heat and all the various fission 16 17 products and transuranics that are produced in decay heat and you're telling me that I have large enough 18 19 uncertainty that I can't take credit for the fission. 20 That's the reason.

I can understand if you're saying I don't 21 22 take credit and that's a safety margin. That I get. 23 But if you're saying I don't take credit because I am 24 uncertain I don't get it. So can you explain to me 25 what I'm missing?

> **NEAL R. GROSS** COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

3

4

5

6

7

13

	154
1	MR. RAHIMI: Okay. I didn't say that you
2	cannot take credit. You need I mean is the neutron
3	cross section. There is not decay heat in the
4	criticality that we're interested in as you well know
5	that these istopes, solarium, cesium, rhodium, all
6	these isotopes which they have a poisonous effect,
7	they absorb neutrons, we want to make sure that the
8	designer has a good handle on the cross section of
9	these isotopes and historically
10	MEMBER ARMIJO: But, Meraj, we start up
11	reactors every day knowing the reactivity of those
12	bundles and we can hit the reactivity point with high
13	confidence. So we must know something.
14	MR. RAHIMI: You are absolutely right.
15	You do it either
16	MEMBER ARMIJO: What happens when you take
17	the fuel out of the reactor? Does it lose fission
18	products?
19	MR. RAHIMI: Right. Well, you look in the
20	reactor core over the years, yes, all those codes have
21	been really fine-tuned, have been confirmed, through
22	restart and the first unreload you look at that.
23	They're not right on the nose. You know they're off.
24	They treat those fission products as lump fission
25	products. They don't even go isotope by isotope.
	1

(202) 234-4433

	155
1	They assign some lump
2	CHAIRMAN WALLIS: Are these bundles
3	different or so on? It's pretty complicated. Each
4	bundle is different. Each bundle has a different
5	history.
6	MR. RAHIMI: That's right. Operating
7	history.
8	MR. MARTIN: Different history. Different
9	initial
10	MR. RAHIMI: Each is different. That's
11	correct.
12	MR. MARTIN: Different fuel vendors.
13	MR. RAHIMI: So you're absolutely right.
14	In the reactor environment over the years, you have
15	these codes. You fine-tune it. You lump it. Yes,
16	you have a handle. But now all of a sudden, you're
17	taking that fuel assembly. You're putting in a cask
18	environment that's in the cold condition, room
19	temperature cross section which really you haven't
20	benchmarked and suddenly you're asking the question
21	"You need to tell me very accurately when this thing
22	is flooded, it's out on the road, it is subcritical."
23	I mean you have to have confidence in this.
24	CHAIRMAN WALLIS: Can we get This slide
25	looks very good to me. I mean you have these two

(202) 234-4433

	156
1	different rules and you're going to say you only need
2	one of them. So you're going to make a comparison and
3	you're going to tell us why one is better than the
4	other or why one is sufficient without the other. Are
5	you going to tell us all that?
б	MR. RAHIMI: Yes.
7	CHAIRMAN WALLIS: If that's your argument,
8	that's all you really need to do.
9	MR. RAHIMI: Okay.
10	MR. MARTIN: I think from my standpoint,
11	from the NRR's standpoint, we've established that if
12	we separate the requirements at the point where the
13	assemble goes into the cask versus it's in the spent
14	fuel pool, that the risk associated with events when
15	the cask is inside the pool is sufficiently low that
16	it does not warrant the additional burden on licensees
17	to have to do this additional analysis and modify
18	their license with all the trappings that is
19	associated with that, both their expense and our
20	expense.
21	CHAIRMAN WALLIS: So it's based on a risk
22	analysis.
23	MR. MARTIN: That's become Well, I
24	wouldn't
25	PARTICIPANT: A probability analysis.
	1

(202) 234-4433

	157
1	MR. MARTIN: A probability analysis
2	basically of the
3	CHAIRMAN WALLIS: Where is the probability
4	analysis?
5	MR. MARTIN: Well, I
6	MEMBER KRESS: It's qualitative.
7	CHAIRMAN WALLIS: I don't like qualitative
8	probability.
9	PARTICIPANT: It's a mixture.
10	MEMBER KRESS: It's qualitative but you
11	add a little bit of quantification. Let me ask you a
12	question. If they did this analysis, the ones that
13	were reducing the burden law, is there a chance that
14	part of the pool would go critical or do we know that?
15	That's saying that you don't but you're ruling it on
16	probability
17	MR. MARTIN: I'm not personally familiar
18	with those analyses and I'm not personally familiar
19	with the results of those analyses. However, in the
20	cases where licensees have changed the license or
21	gotten exemptions, the analyses have shown that they
22	would not go critical with pure water. Otherwise, it
23	would have been unacceptable.
24	MEMBER KRESS: So No matter what you're
25	not going critical even though you don't know that for
	I

(202) 234-4433

	158
1	sure unless you do the analysis.
2	MR. MARTIN: Well, our expectation is that
3	you would not go critical. However, there are low
4	probability situations
5	MEMBER KRESS: Where you might.
6	MR. MARTIN: Pardon me?
7	MEMBER KRESS: Where you might go
8	critical.
9	MR. MARTIN: Where you might go critical.
10	There are situations where let's say a licensee
11	decides, has a leaking fuel pin, a leaking fuel rod.
12	MEMBER KRESS: So it's fresh fuel on the
13	rod.
14	MR. MARTIN: And they take a Maybe they
15	have a bad batch of fresh fuel and they take two or
16	three assemblies out and they put them in the cask in
17	the same location right next to each other. There is
18	a possibility that they could have a cell that would
19	then possibly go critical.
20	MEMBER KRESS: Okay.
21	MR. MARTIN: Once again, an unlikely
22	situation. You would have to have the bad fuel. You
23	would have to have a couple of assemblies that were
24	bad. You'd have to put them in the cask next to each
25	other. You'd have to Pardon me?
I	1

(202) 234-4433

	159
1	MEMBER SIEBER: You would have to have
2	mistakes made by people.
3	MR. MARTIN: You would have to have
4	mistakes made. You would not put those next to each
5	other in the cask. You would then have to have the
6	low probability event.
7	CHAIRMAN WALLIS: What you should do then
8	is have an event train or probabilistic analysis and
9	have something convincing. All this talk doesn't
10	really convince me about anything yet.
11	MEMBER APOSTOLAKIS: Very hard to follow.
12	CHAIRMAN WALLIS: Right. Very hard to
13	follow.
14	MEMBER APOSTOLAKIS: I don't find anything
15	wrong but it's very hard to follow.
16	MEMBER KRESS: It's a qualitative risk
17	assessment.
18	MEMBER APOSTOLAKIS: Anyway
19	MEMBER SIEBER: Which is the way
20	regulations are.
21	MEMBER APOSTOLAKIS: You are on a path of,
22	what do you call it, direct rule?
23	MR. MARTIN: Direct final.
24	MEMBER APOSTOLAKIS: Direct final. What
25	is it you will publish because the public hasn't seen

```
(202) 234-4433
```

	160
1	this yet, has it?
2	(Several speaking at once.)
3	MR. MARTIN: It is
4	MEMBER APOSTOLAKIS: No.
5	MR. MARTIN: It's not on the website.
6	MEMBER APOSTOLAKIS: So what will be I
7	mean you're going after public comments soon? Is this
8	document that says RIN3150, is this going to go to
9	become public?
10	MR. TARTAL: That's going to be part of
11	the rulemaking package that we'll submit next month if
12	all goes as planned.
13	MEMBER APOSTOLAKIS: Okay, and there is
14	still time to draw a couple of event trees and make it
15	clear?
16	MR. TARTAL: Depending on your comments,
17	we will consider your comments as part of the final
18	package that goes out to the public.
19	MEMBER APOSTOLAKIS: You have been with
20	this agency a long time, haven't you?
21	MR. TARTAL: Not very long but I'm a fast
22	learner.
23	MEMBER APOSTOLAKIS: We'll consider it.
24	CHAIRMAN WALLIS: So this goes out for
25	public comment. We have another crack at it when it
	1

```
(202) 234-4433
```

	161
1	comes back again.
2	MR. MARTIN: Actually we are on a path
3	with this rule such that if it goes out for public
4	comment and we get no significant public comments the
5	rule would go into effect. If when it goes out for
6	public comment we get some significant public
7	comments, then the rule would become, basically it
8	would become, a proposed rulemaking and we would
9	modify the rule, address the public comments and then
10	go proceed with the final rule.
11	MEMBER SIEBER: Right.
12	MEMBER CORRADINI: So just to Since I
13	started this thing to go to Slide 16, the rule though
14	essentially in essence is on Slide 11 which
15	essentially you define a physical boundary where if
16	something passes one thing is applicable, Section 50,
17	and you slide over to the other thing and Section 71
18	or 72 are applicable. Do I have that correct?
19	MR. TARTAL: Yes.
20	MEMBER CORRADINI: That is the rule in
21	essence.
22	MR. TARTAL: Yes, that's the intent of the
23	rule.
24	MEMBER CORRADINI: Or rule change or
25	whatever?

(202) 234-4433

	162
1	MR. TARTAL: Yes.
2	MEMBER CORRADINI: All right. Thank you.
3	CHAIRMAN WALLIS: And your argument is
4	that the public risk entailed by this change is small.
5	MR. MARTIN: Very small.
6	CHAIRMAN WALLIS: You haven't given us an
7	indication of how small it is. You've just talked
8	about it.
9	MEMBER KRESS: Even if they went critical
10	in a cell, the public is not at risk. Believe me.
11	CHAIRMAN WALLIS: No, but it's a bad thing
12	to have a critical event.
13	MEMBER KRESS: Yes, there would be all
14	sorts of issues raised.
15	MEMBER SIEBER: It would get in the
16	newspapers.
17	MEMBER MAYNARD: But I don't see where
18	this has any impact on changing the risk to the public
19	in that by making this change or not making this
20	change. The only thing it's going to effect is
21	paperwork and analysis.
22	CHAIRMAN WALLIS: Some risk to the workers
23	in the plant.
24	MEMBER KRESS: Yes. There is some risk,
25	but you're not quite There is some situation it may
I	1

```
(202) 234-4433
```

1

2 MEMBER MAYNARD: But I think what we're 3 talking about is that the licensee is not going to go 4 modify their pool or modify the cask. They're going 5 to be reanalyzing, doing an analysis, and perhaps going for an exemption. But I see where the real 6 7 problem is which is by trying to require compliance regulations different 8 with two different with 9 assumptions and things it may put you in violation of your current license, although it's not creating any 10 11 real new safety issue.

MEMBER ARMIJO: But if exemptions have been granted over the past few years, this has already been going on. Right? People haven't been doing the analysis and have been doing it. So it's actually been happening. So maybe we're shutting the barn door a little late.

But I read your documents several times 18 19 and it looks like you address a whole number of 20 scenarios. Some of them are so unlikely that I didn't 21 even know why you bothered to analyze. The only thing 22 I asked was related to a deliberate action by someone 23 and you answered my question. It could happen. There 24 could be a criticality, but it's very unlikely and I 25 think that's where George could following a more

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

	164
1	probabilistic approach quantify where we are.
2	MR. MARTIN: Let me also add that if
3	somebody deliberately did this their fingerprints
4	would be all over it.
5	MEMBER ARMIJO: Yes, but it's too late.
6	MR. MARTIN: But it would take a long time
7	to It's too late, but it would have to happen over
8	a period of hours and it's likely that it would be
9	detected before it would happen. It's not the kind of
10	thing that if somebody was smart enough to want to
11	sabotage a plant this is not something that somebody
12	would try to do.
13	MEMBER APOSTOLAKIS: You said that even
14	At some point I believe you said that even if an
15	assembly goes critical, you said nothing much happens
16	or I mean what's going to happen.
17	MR. MARTIN: Let's say this assembly goes
18	critical, for those of you that are familiar with
19	swimming pool reactors at Nico (PH) Power Plants and
20	I went to my graduate school at University of Virginia
21	and we had a two megawatt swimming pool reactor which
22	was critical in water that was more shallow than what
23	we would expect to experience in a spent fuel pool and
24	under these conditions as you got to the point where
25	you would dilute the water, the density would change
	I

(202) 234-4433

ĺ	165
1	and it would shut down. So it would become critical
2	over a relatively slow period of time. Once it became
3	critical, it would heat up. The density would change
4	and it would shut down. And then it would heat up
5	again.
6	CHAIRMAN WALLIS: Density boil?
7	MR. MARTIN: There could be some nuclear
8	boiling and there could be some warming up of the
9	water and there could be some evaporation. But once
10	it boiled and evaporated, then it would shut down.
11	MEMBER KRESS: And the only problem is you
12	wouldn't want to be standing right close to it.
13	PARTICIPANT: That would be bad.
14	MR. MARTIN: And there are If that were
15	to happen, the effect of the several hundred other
16	assemblies would have already killed you long before
17	the criticality from the
18	CHAIRMAN WALLIS: I mean you have all this
19	water level above the pool. If you're looking in, you
20	still wouldn't be affected, would you? It's a
21	swimming pool reactor.
22	MR. MARTIN: Right. That's correct.
23	CHAIRMAN WALLIS: You would have to go
24	into the pool.
25	MR. MARTIN: You would have to go into the
I	1 I I I I I I I I I I I I I I I I I I I

(202) 234-4433

	166
1	pool to be
2	CHAIRMAN WALLIS: That would be crazy.
3	MEMBER APOSTOLAKIS: Is it possibly you
4	would have some melting?
5	MR. MARTIN: No. I
6	MR. ROLAND: No, and we also have
7	criticality alarms too.
8	MR. MARTIN: There are criticality alarms.
9	The criticality alarms would be Yes, you have
10	criticality alarms. Are there any comments from the
11	I have experts, criticality experts, at the back
12	wall there. Any other comments, Tony or Rob or Kent?
13	MEMBER ABDEL-KHALIK: Excuse me. Has
14	there been a situation where a cask has been filled
15	and then after the process has been completed they've
16	decided that they have to drain it because something
17	happened?
18	MEMBER SIEBER: Yes.
19	MR. MARTIN: There is a Well, let me
20	turn it over to the Spent Fuel Program Office to
21	answer that question. That would be
22	MR. RAHIMI: Yes, during loading and
23	unloading casks, you know, they routinely encounter
24	problems.
25	MEMBER ABDEL-KHALIK: Okay.
	1

(202) 234-4433

	167
1	MR. RAHIMI: You know, in terms of the
2	things they did not anticipate, but are you asking the
3	question
4	MEMBER ABDEL-KHALIK: Well, I'm sort of
5	asking a series of questions.
6	MR. RAHIMI: Okay.
7	MEMBER ABDEL-KHALIK: You load the cask
8	and you're going through the drying process and then
9	you find out that something is wrong and you have to
10	refill the cask. Is it possible that you can refill
11	the cask while it's in the pool during a situation
12	like this after they had initiated the dry-out process
13	that you can actually fill it with unborated water?
14	MR. MARTIN: In order for that to happen,
15	let me just interject here, you have to have There
16	would have to be two samples made of the boron
17	concentration and they would both have to be faulty
18	for that to happen.
19	MR. RAHIMI: Yes, the subsequent
20	refilling, let's say, after they drain the cask, they
21	dry the cask. They found they have to go back. They
22	have to refill it because they have to take some fuel
23	assemblies out. It's the same sequence. They have to
24	take boron measurement, solvent boron measurement, as
25	part of the operating procedure for those casks during

(202) 234-4433

	168
1	refilling, drawing or unloading. If you look at the
2	unloading casks, you know, it's almost the same thing
3	you described that they have to fill the cask. But
4	the boron measurements will be made prior to refilling
5	the casks with the pool water which is borated water.
б	MEMBER ABDEL-KHALIK: So the procedures
7	for refilling a cask in an event of this sort, that
8	totally precludes this possibility.
9	MR. RAHIMI: That's right. Under We go
10	chapter When we're having a safety analysis report
11	at DC there's an operating procedure if at somehow in
12	the midstream they have to go back, they have to
13	follow the operating procedure.
14	MR. MARTIN: I wouldn't To say totally
15	preclude, I would be reluctant to say they would
16	totally preclude anything. However, there would have
17	to be two independent samples made by two and they
18	would have to be independent and independently
19	analyzed and they would have to both be faulty and
20	there would have to be something, you know, you would
21	have to be sitting in the spent fuel pool and discover
22	"Oh, this is not borated to 2300 ppm boron. There is
23	no boron in there. How could this have happened?"
24	Not very likely because there is also routine
25	requirements to sample the boron in the spent fuel
	1

(202) 234-4433

pool beyond the requirements to sample before you conduct cask activities in the spent fuel pool.

There are also situations that are out 3 4 there right now in terms of my belief and the 5 situation that we've created by having this problem with this regulation where licensees might have to do 6 7 the very thing that you just mentioned. Let's say there's something they discover that there's a problem 8 9 or they want to, they need to unload one of these 10 casks for some emergency purpose and they should have the basis to do and they take one of these casks that 11 were loaded in the year 1999, 2000, 2001 before they 12 were doing this, before this issue came up, before we 13 14 discovered that there was this overlapping requirement 15 and they say we have to get this fuel out of here on 16 some sort of an emergency basis. They theoretically 17 would either have to request an exemption of the regulations or request an amendment to the regulations 18 19 in order to do that under emergency basis and that 20 wouldn't make sense and it's very unlikely, you know, 21 under circumstances that we would find an the 22 expeditious way for them to conduct that activity.

But the fact that we have these overlapping regulations that are not really consistent with each other in terms of providing a consistent and

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

(202) 234-4433

169

1 appropriate reasonable assurance of safety and 2 certainly we're expecting -- And reasonable assurance 3 of criticality is certainly another level of 4 assurance. When we're talking reasonable assurance 5 and we're not going to have criticality, that has to 6 be vert reasonable. 7 CHAIRMAN WALLIS: So you have two overlapping relations each of which is good, each of 8 9 which is adequate and you've picked the best one or the one with the least effort or whatever. 10 How did you pick one versus the other one? Both of them, each 11 one of them, is adequate. I understand. 12 Right? You're not saying that one of them is inadequate. 13 14 MR. MARTIN: Right. 15 CHAIRMAN WALLIS: You're saying we're going to pick one instead of two. 16 17 MR. RAHIMI: The rulemaking is --We picked this one because 18 MR. MARTIN: 19 when the fuel goes inside the cask, we believe that 20 regulations pertaining the to the control of criticality inside the cask are reasonable 21 and 22 adequate to assure that that fuel is protected. 23 These are the generic CHAIRMAN WALLIS: 24 ones, are they? 25 MR. MARTIN: Correct. And we also believe

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

170

1 that when the fuel is the bottom of the spent fuel 2 pool the regulations pertaining to the criticality and 3 the spent fuel pool are also reasonable and adequate. 4 However, when you combine those two, you then are 5 forced to analyze the fuel in the cask as though it's it's part of the spent fuel pool. And once you 6 7 analyze the fuel in the cask as though it's part of 8 the spent fuel pool assuming that the spent fuel pool is at a density that would occur in the cask which is 9 not realistic and you would have to assume that the 10 same accident sequences that apply to the spent fuel 11 pool apply to the cask which is not reasonable because 12 the cask is only in the spent fuel pool for a very 13 14 short period of time, that's not a reasonable assumption. When the licensees are forced to do the 15 analyses that would support both 50.68 and Part 72, 16 then it's not a reasonable situation. 17 You're saying there's 18 CHAIRMAN WALLIS: 19 something artificial about doing the Part 50 analysis, 20 something really artificial. You said they would 21 force an analysis which is inappropriate on this cask. 22 Well, you're assuming a MR. MARTIN:

23 deboration in the cask that is much more likely to
24 occur. A deboration inside the cask is much less
25 likely to occur.

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

171

	172
1	CHAIRMAN WALLIS: Part 50 analysis is
2	inappropriate. Then you convince us Are you going
3	to convince us that the Part 71/72 is adequate?
4	MR. MARTIN: Correct.
5	CHAIRMAN WALLIS: Is that what you're
6	going to do?
7	MR. MARTIN: And the Part 71/72 has an
8	assumption, takes credit for boron, and then once you
9	drain the boron out
10	CHAIRMAN WALLIS: It's adequate.
11	MR. MARTIN: Yes. There is reasonable
12	assurance.
13	CHAIRMAN WALLIS: That's all we need to
14	know if you have one which is adequate.
15	MR. MARTIN: There is reasonable assurance
16	the public health and safety will be maintained
17	through what we're proposing.
18	CHAIRMAN WALLIS: It hasn't been
19	demonstrated to us by any kind of technical analysis
20	at all.
21	MEMBER APOSTOLAKIS: The issue is whether
22	to do both.
23	CHAIRMAN WALLIS: No, no.
24	MEMBER APOSTOLAKIS: Either one is
25	acceptable.

	173
1	CHAIRMAN WALLIS: All we need to know is
2	if one is adequate.
3	MEMBER APOSTOLAKIS: Either one is
4	adequate. We're not questioning that.
5	VICE CHAIR SHACK: We've gone through a
6	qualitative statement of probabilities. You know you
7	have a probability because of the time. You have the
8	probability of the dilution event. You have the
9	probability that even if you had the dilution event
10	that you'd have a fuel configuration that is in fact
11	could go critical.
12	MR. MARTIN: Right.
13	VICE CHAIR SHACK: Now we don't know any
14	of those probabilities all that rigorously, but I
15	think that they are 10^{-2} , 10^{-5} and 10^{-1} as a ball park
16	kind of number and that gets you to a pretty unlikely
17	event.
18	MR. MARTIN: The numbers that we were
19	coming up with
20	MEMBER KRESS: Let's couple that with the
21	consequences of probably, no, never mind. So it's a
22	qualitative risk assessment that looks like
23	MEMBER APOSTOLAKIS: Let's not call it
24	that. Let's accept the event and not call it that.
25	MEMBER KRESS: Well, it's a bit

(202) 234-4433

	174
1	quantitative.
2	MEMBER APOSTOLAKIS: is qualitative.
3	MR. MARTIN: But when we get to the
4	distinction of the fast drain-down and the slow drain-
5	down it's a little more difficult for us to quantify
6	the risk on the slow drain-down because as Mr. Armijo
7	pointed out I mean there's some It's more difficult
8	to get your hands around the probability for these
9	things to happen. However, we do know that there are
10	controls on the refueling deck, that we have
11	instrumentation, that we have radiation
12	instrumentation, that we have security controls, that
13	there's key cards and there's access controls for
14	everybody that goes up there, that there's limited
15	opportunity, both window of opportunity and equipment
16	opportunity to conduct the kind of sabotage type event
17	that might take to render this, to create this problem
18	and even if that did happen, it's not likely it would
19	have any consequences. So even if somebody was smart
20	enough to beat the system and those controls, if they
21	were smart enough to do that, they would probably be
22	smart enough to know that there would be no
23	consequences associated with them having done that.
24	VICE CHAIR SHACK: Inadvertent slow
25	dilution is also because you're taking your samples.

(202) 234-4433

	175
1	MR. MARTIN: And the inadvertent slow
2	dilution would be mitigated through the training of
3	the operators, having the license operators conduct
4	the activity, having the dual samples performed at 24
5	to 72 hour frequency, licensees conducting this
6	activity with license operators, get the fuel cask in
7	the pool to get it loaded and then they take it out
8	and it happens. The operators are generally trying to
9	do that as quickly and as safety as they can because
10	they have other things to do besides take their time
11	loading fuel casks. So there's a minimum window of
12	opportunity for those kinds of problems to occur in
13	that activity.
14	MEMBER SIEBER: But the cask is open and
15	sits upright in the pool.
16	MR. MARTIN: Right.
17	MEMBER SIEBER: If you have a slow
18	dilution in the pool, the cask is like a cup and you
19	don't get the dilution in the cask
20	MR. MARTIN: The boron, the borated water
21	is denser than the pure water so
22	MEMBER SIEBER: It's going to stay there.
23	MR. MARTIN: it's more likely that
24	that's going to be the safest point for the fuel.
25	MEMBER SIEBER: And the safety in that

(202) 234-4433

176 1 configuration, safety posture is improved. 2 MR. MARTIN: And when we looked at the 3 impact on the industry, the impact on the NRC and the 4 fact that there was minimal health and safety to the 5 public involved in this activity, we decided that we ought to correct this situation as quickly as possible 6 7 and that's why we went down the path of proceeding with the direct final rule. 8 CHAIRMAN WALLIS: What kind of letter are 9 we going to write? I think if we state qualitative in 10 our letter and simple said that we see no reason to 11 12 stop you doing this that would be fine. But if we started to say we've seen a convincing analysis that 13 14 everything is okay, I think we would be on much more 15 shaky ground. 16 MEMBER SIEBER: Don't say that. 17 CHAIRMAN WALLIS: And we --18 MEMBER KRESS: Don't say that. 19 CHAIRMAN WALLIS: I was wondering what 20 we're going to say in our letter. 21 MEMBER APOSTOLAKIS: What is it that 22 you're asking us to do? 23 As part of our process for MR. MARTIN: 24 this kind of rulemaking activity, it was appropriate 25 for us to bring this to your attention. Perhaps there

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

```
(202) 234-4433
```

177 1 was something although we were quite convinced from a technical standpoint that proceeding with the direct 2 3 final rulemaking was the most expeditious way to 4 correct this problem. You know we thought it was 5 prudent to bring to your attention so if there was anything that we hadn't considered, I know as a result 6 7 of Mr. Armijo's questions --8 MEMBER ARMIJO: It's Armijo. 9 MR. MARTIN: Armijo. 10 MEMBER ARMIJO: Right. MR. MARTIN: We addressed, we provided 11 some additional consideration for what might happen on 12 this slow dilution event. 13 14 MEMBER APOSTOLAKIS: But basically --15 MR. MARTIN: What it hasn't changed --16 CHAIRMAN WALLIS: But what you want is a letter from us. 17 MEMBER APOSTOLAKIS: What is it that you 18 19 want? You want --20 CHAIRMAN WALLIS: You want us to approve your action. Right? 21 22 That would be nice. MR. MARTIN: 23 (Laughter.) 24 CHAIRMAN WALLIS: That's what you want. 25 That's what you're asking.

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

	178
1	MEMBER APOSTOLAKIS: But approves what?
2	CHAIRMAN WALLIS: Approves what?
3	MR. MARTIN: That you have no objection.
4	MEMBER KRESS: They're going to follow
5	with rulemaking.
6	MR. MARTIN: That you have no objection to
7	the rulemaking proposed.
8	MEMBER KRESS: They intend to make rules
9	to do exclude this double thing.
10	MEMBER APOSTOLAKIS: What would you do if
11	a member agreed with us but had a problem with the way
12	it's presented.
13	MEMBER KRESS: We would write a letter.
14	MEMBER APOSTOLAKIS: next time they do
15	better.
16	CHAIRMAN WALLIS: Say come back with a
17	more convincing case.
18	(Several speaking at once.)
19	MEMBER KRESS: The question we have to ask
20	ourselves since we haven't seen a full quantitative
21	risk assessment for the sets of scenarios where the
22	cask is in the pool and can have all these things, we
23	haven't seen that. We've heard qualitative arguments
24	about how improbable that is. The question we have to
25	ask ourselves is would it be reasonable for us to ask

(202) 234-4433

	179
1	for a full risk assessment with quantitative. I don't
2	think so because I don't even think it can be done
3	right now.
4	MEMBER APOSTOLAKIS: No.
5	MEMBER KRESS: And then the next question
6	is well has their qualitative argument been sufficient
7	for us to make the judgment that they can go ahead
8	with this rulemaking and there not be any particular
9	change in the risk to the public. It's like a 14174.
10	They're going to reduce burden and they're going to
11	probably increase the risk a little bit but it's going
12	to be so small about these qualitative arguments which
13	I buy that we ought to be able to say go right ahead
14	with this and we're okay with it. I don't think we're
15	At least that would be my view of what the letter
16	ought to be.
17	MEMBER SIEBER: This is not a risk
18	informed
19	MEMBER APOSTOLAKIS: I agree one hundred
20	percent.
21	MEMBER KRESS: It is in a sense when we
22	think about it. We risk inform all of our
23	CHAIRMAN WALLIS: I think the question
24	comes
25	MEMBER SIEBER: You consider risk but it's
	1

(202) 234-4433
	180
1	not risk informed.
2	CHAIRMAN WALLIS: The question is so what
3	sort of standard are we going to maintain and when we
4	have these presentations in terms of well we'll buy a
5	farm.
6	MEMBER KRESS: We've always
7	CHAIRMAN WALLIS: How much evidence do we
8	need to see, what they're going to
9	MEMBER KRESS: We've always said the
10	qualitative risk assessments can be done.
11	CHAIRMAN WALLIS: Well, that gets you into
12	a pretty murky area.
13	MEMBER KRESS: Yes. We have to make
14	judgments then.
15	MEMBER APOSTOLAKIS: It has to be
16	convincing.
17	MEMBER KRESS: Yes.
18	MEMBER APOSTOLAKIS: That's the standard.
19	MEMBER KRESS: And the question is are we
20	convinced that this qualitative risk assessment is
21	good enough.
22	CHAIRMAN WALLIS: I ask myself I may be
23	willing to go along with this but if I sign a letter
24	and then some Commissioner calls me up into his office
25	and says "Well, what makes you make me of me to give
1	

(202) 234-4433

	181
1	him your arguments?" Then I may have some difficulty.
2	MEMBER CORRADINI: So if I could ask a
3	question. Could I ask a question though because I
4	guess what the sense is is that there's maybe more to
5	do? So is it fair to say that step one is you've
6	uncovered a duplication of effort and you're going to
7	clear it up? That's my simple interpretation of what
8	it is. You've uncovered a duplication effort and
9	you're going to clear it up.
10	MR. MARTIN: That's a fair overview
11	assessment, yes.
12	MEMBER CORRADINI: But would it be fair to
13	also go one step further and say using Slide 16 that
14	there are some other things that would give one pause
15	as to the consistency and overall overreaching way in
16	which this is done that further investigation might be
17	warranted by the staff? I mean to me, only to me, I'd
18	like to actually unravel where some things count and
19	where some things don't count and understand the
20	uncertainty of why you do that.
21	I understand that somebody said behind us
22	which now makes sense to me that one is plant specific
23	and one is generic and that could be the underlying
24	reason that you make this sort of kind of judgment
25	call. But I do think after saying that you've
	1

(202) 234-4433

uncovered duplication that it seems reasonable to do it this way, but the staff is going to go further and kind of make things a little bit more clear, concise, risk informed would be --

5 MR. MARTIN: If I might add here from an NRR/NMSS standpoint, I'm looking at this from an NRR 6 7 standpoint in terms of how it's being implemented and 8 how it's impacted on licensees and how the spent fuel 9 pool operations. He's looking at the spent fuel transportation/storage type kind of operations. 10 Ι haven't chosen to really delve into the fission 11 12 product burn-up credit issue because it's somewhat irrelevant from my standpoint. It does create an 13 14 additional conservatism when it comes to the analysis 15 of the criticality of the dry cask that then falls, 16 somehow gets swept and then it does create an additional amount of conservatism. 17

If this fission product credit was able to 18 19 be taken, there might be some overall simplification 20 and this might even become less of a problem because 21 you would say this stuff could never go critical. But 22 then there would even be the situations that were 23 brought up before where you might be taking out the 24 fresh fuel and putting that in. So that's a red 25 herring, the issue of the fission product credit.

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	183
1	From my standpoint, it's a red herring.
2	When I look at the likelihood of the
3	scenarios, the possibility of the leakage drain-down,
4	the recriticality, the deboration, that becomes
5	significantly improbable and the issue of the fission
6	product credit that although it might allow licensees
7	to put higher burn-up fuel in the cask in the long run
8	is a cask gloating issue. It's something that I think
9	should be dealt separately in a separate context and
10	really has no doesn't have a significant bearing
11	for me on this rulemaking. I don't believe it has a
12	significant bearing for the licensees either.
13	MEMBER ARMIJO: Okay. Well, I disagree.
14	I think burn-up is there. It's real.
15	MEMBER CORRADINI: Yes.
16	MEMBER ARMIJO: So whether you take credit
17	for it or not is I think you should take credit for
18	it. I think you should be more consistent across your
19	regulations of taking burn-up credit whether you want
20	to discount it for one configuration or another to
21	some extent if you don't have the detailed data that
22	you think you need. But you can count on the burn-up
23	because that's spent fuel and all these other
24	procedural things that you're relying on to protect
25	you I don't think they are as reliable as the burn-up.
I	

(202) 234-4433

	184
1	So I kind of take a different view.
2	MR. RAHIMI: Let me then
3	MEMBER ARMIJO: I think that's your
4	protection really.
5	MR. RAHIMI: Let me then go and really
6	talk about the differences. This one is You know
7	there are differences in different and let me
8	explain why, our position, the reason for the
9	position.
10	MEMBER ARMIJO: And I believe you and I
11	accept that. But if you had a burn-up credit for an
12	assembly in the pool, now you put it in a cask, can't
13	you discount it by some factor that you know based on
14	your judgement or analysis that this is going to get
15	90 percent of the burn-up credit that we know is there
16	in the pool and at least you put real data into your
17	analysis rather than procedural controls to protect
18	the public?
19	MEMBER SIEBER: And if you don't need the
20	burn-up credit, why go to all the expense?
21	MEMBER ARMIJO: But the point is you do
22	need it.
23	MEMBER SIEBER: I don't think so.
24	MR. RAHIMI: If you use burn-up credit,
25	then you don't need to rely on boron, solvent boron,
	1

(202) 234-4433

	185
1	in the pool.
2	MEMBER SIEBER: That's right.
3	MR. RAHIMI: I mean that's the
4	MEMBER CORRADINI: So these dilution
5	events become less significant?
6	MEMBER APOSTOLAKIS: Which brings you back
7	to 50.68.
8	(Several speaking at once.)
9	MR. RAHIMI: Yes. It brings you back to
10	
11	MEMBER POWERS: If you have burn-up
12	credit, you put more fuel in the cask.
13	MR. RAHIMI: Yes, it does bring you back.
14	CHAIRMAN WALLIS: Now I guess that's
15	another consequence. I mean if you change this rule
16	is there a probability then that the licensees will
17	change their procedures in response which will lead
18	them closer to
19	MEMBER CORRADINI: No.
20	MEMBER APOSTOLAKIS: No, they are
21	requesting it.
22	MEMBER CORRADINI: I guess my feeling with
23	the uncovering of the duplication and now they've
24	separated it by the movement of the thing from Point
25	A into Point B they've essentially eliminated the
	1

(202) 234-4433

	186
1	duplication. I'm just kind of listening to the
2	discussion after all this time that even on top of
3	that there is room to be understood as to why these
4	things are different. Now if there are reasons,
5	that's fine. I heard what you're saying. If it's a
6	red herring, fine.
7	But if that's the case, is there an
8	analysis you can point me to that will shut me up so
9	that I would stop asking that? I mean that's what I
10	think Mr. Armijo is asking.
11	MR. RAHIMI: I guess that's why that I
12	wanted to go in addition to rulemaking. This doesn't
13	really separate from the rulemaking.
14	MEMBER CORRADINI: Okay. Go ahead.
15	That's fine.
16	MR. RAHIMI: The only reason that I want
17	to go over this because some interests were expressed
18	that they would like to hear about the burn-up credit
19	in general, why the difference.
20	MR. MARTIN: This rulemaking will not
21	affect the loading in the spent fuel pool. It will
22	absolutely permit no additional
23	MEMBER CORRADINI: Won't affect what they
24	do.
25	MR. MARTIN: It won't affect what they do
I	I contraction of the second

(202) 234-4433

	187
1	and this will also not affect the licensing basis of
2	the cask because the cask is still licensed to stay
3	subcritical either with boron or dry and that's not
4	going to change as a result of this. So I wouldn't
5	anticipate that this is not the kind of thing there's
6	a tail end of this or another part of this story
7	that's going to create a problem.
8	CHAIRMAN WALLIS: Can we get to the end of
9	it? Do you have
10	MR. MARTIN: I think we've
11	CHAIRMAN WALLIS: Do you have any ways to
12	clarify things?
13	MR. MARTIN: No, I think we've essentially
14	exhausted our discussion of this. I know the industry
15	has requested a certain amount of time and I think it
16	might be interesting for you to hear
17	MEMBER ABDEL-KHALIK: Can I just ask one
18	simple question? Would a generic analysis performed
19	under Part 71/72 always be bounding for all plant
20	specific scenarios?
21	MR. RAHIMI: No, it won't be always
22	bounding. There is Also we have a site specific
23	license. If there is something unique about the site,
24	you know, they can apply what they call a site
25	specific license that it was not included in that
	I contract of the second se

(202) 234-4433

	188
1	general license for the cask and normally when there
2	is something different it's the site. There is
3	something unique about that site.
4	Like Diablo Canyon, for example, they have
5	a site specific storage license as opposed to using a
б	general license, you know, taking a cask with the
7	specific compliance off the shelf and using that.
8	Because of their seismic events, you know what that
9	cast was designed for. The answer to your question,
10	if there are some unique things about the site, then
11	they would go through the site specific license route.
12	MEMBER ABDEL-KHALIK: Thank you.
13	MR. RAHIMI: I guess I do want to ask if
14	you want me to continue and describe the differences
15	or you believe you've heard enough. You know we can
16	stop right here.
17	MEMBER ARMIJO: I think we've heard it.
18	MEMBER APOSTOLAKIS: Yes, we've heard.
19	MEMBER ARMIJO: Anybody?
20	MEMBER APOSTOLAKIS: Let's hear from the
21	industry.
22	MEMBER ARMIJO: Yes. Thank you.
23	MEMBER APOSTOLAKIS: Don't go away though.
24	(Off the record comments.)
25	CHAIRMAN WALLIS: This is probably going
	I

(202) 234-4433

	189
1	to say it's okay and I don't think they're going to
2	give you this clarifying analysis that we've been
3	asking for but maybe they will.
4	PARTICIPANT: Let's see what they say.
5	MEMBER APOSTOLAKIS: I think most of it is
6	in Michael's presentation.
7	MEMBER ARMIJO: Mr. Kraft.
8	(Off the record comments.)
9	CHAIRMAN WALLIS: Please go up front.
10	Tell us who you are and make a presentation.
11	MEMBER APOSTOLAKIS: Why you are here.
12	Why do you think you want to address us?
13	MR. KRAFT: We don't have any slides so
14	we're not going to want the screen here. Thanks very
15	much. I appreciate the opportunity to be included in
16	this discussion. My name is Steven Kraft. I'm the
17	Senior Director of Used Field Management at NEI. I'm
18	joined at the table here with Brian Gutherman who is
19	a consultant to NEI and NEI members on these matters
20	and Dr. Albert Makios well known from ***2:32:56
21	Research Institute and there are four individuals in
22	the room in the back here who are representing
23	utilities who use this technology. So if there are
24	questions about utility site specific, we may ask one
25	of the folks over there.

(202) 234-4433

I think it was very interesting listening to the give and take with the staff. It was -- We were sitting here debating whether or not we actually wanted to come up here because you kind of covered all the issues and there's not a whole lot left to say. But anticipating you might have some questions, we of course, I have Brian and Albert along with us here.

You know I think -- I don't know who it 8 9 was that said it, but I think it's fair to say that we live in a very practical application driven world and 10 you all are going to have your conversations with the 11 staff and you're going to grill them the way you 12 grilled them and I think this sort of Socratic method 13 14 you use improves the understanding and sharpens 15 everyone's ability to think and do the analysis and I'm sure Tom and Meraj and George will go back and 16 think about what you have to say and I think that it 17 ultimately leads to improvement and that's what it's 18 19 So we appreciate what you're doing here. all about.

We take a very different point of view and we're not going to sit here and try to argue with you about whether you know you have this analysis and that analysis. Our approach was is the erode of risk after we loaded 750 casks with no indication of any problems whatsoever in this area and all of a sudden we had to

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

3

4

5

6

7

	191
1	make a change with the way we were doing business.
2	And that didn't bother us a whole lot. We understood
3	that sometimes you have overlapping regulations, but
4	a number of our utilities who are members of NEI
5	pointed out to us and some of them are in the room
6	that it was costing them upwards of \$0.5 million each
7	to do this not to mention eating up valuable
8	engineering and licensing personnel time when there
9	are many other issues that really deserve attention.
10	CHAIRMAN WALLIS: Like just doing the
11	extra analysis and presenting it to the NRC and going
12	through all that.
13	MR. KRAFT: Yes, and so we approached it
14	not by the sort of detailed, in-the-pool kind of
15	consequence analysis that you all are talking about.
16	We approached it on the basis of the following. It
17	was safe then. It's safe now. What's the problem?
18	And I think So we sent
19	MEMBER APOSTOLAKIS: Why do you say it was
20	safe then?
21	MR. KRAFT: Well, two things. First of
22	all, NRC approves the use of these casks under Part
23	72. You get a certificate and it says you can use it
24	under those circumstances. So somewhere along the
25	way, NRC had made a determination it was safe to load
l	I contract of the second se

(202) 234-4433

(202) 234-4433

	192
1	those casks in the pool (1). And then (2) our
2	experience now over 800 casks suggests to us that
3	there's not a problem, that we can do it. As Tom
4	points out, the casks are not in the pool long periods
5	of time. The goal is to load them and get them out.
6	That sort of thing.
7	So we strongly support the need to change
8	10 CFR 50.68.
9	CHAIRMAN WALLIS: Safety is not based on
10	only what happened, but on what might happen.
11	MR. KRAFT: We completely agree and that's
12	what we take comfort in the fact that NRC has done an
13	analysis that says if you meet the requirements of
14	Part 72 and which includes loading the cask then
15	you're going to be safe. Again to us, it's a bright
16	line test. You either are or you aren't. We have to
17	operate huge facilities. Okay, we're not going to sit
18	around every day and dither over whether we got, you
19	know, we're on the margin. We're going to operate
20	safely. It's a bright line test. We're going to
21	remain on the safe side of that bright line.
22	CHAIRMAN WALLIS: But in answer to my
23	colleague's question about how you know it was safe
24	before, it's safe before because it met a regulation,
25	not because you did some analysis to show it was safe.

(202) 234-4433

	193
1	MEMBER APOSTOLAKIS: That's why I shut up.
2	The fact that you have 750 loads does not mean they
3	were safe. But you met 72, then it's okay.
4	MR. KRAFT: That's right. But having 750
5	loads having met 72 gives us gives us some measure of
6	the fact that we're safe and we can do it safely. The
7	sorts of analyses that you're demanding of NRC staff
8	is appropriate if you demand that of the NRC staff.
9	MEMBER APOSTOLAKIS: Right. I agree.
10	That's fine.
11	MEMBER MAYNARD: I don't believe that the
12	industry just relies totally on the regulations for it
13	being safe. They do their own analyses. The vendors
14	for these casks and the utilities themselves do
15	analysis and they won't be submitting something that
16	they didn't believe was safe also. So I don't think
17	they are just relying on the fact that if it meets the
18	regulations it must be safe. The utilities and the
19	vendors have also done analysis, criticality analysis,
20	and stuff.
21	CHAIRMAN WALLIS: Are you going to tell us
22	about it?
23	MR. MACHIELS: Yes, exactly.
24	MR. KRAFT: Do you want to respond to
25	that, Albert?
	1

(202) 234-4433

	194
1	MR. MACHIELS: Yes, I would like maybe
2	just to divert just a moment but Dr. Rahimi was asked
3	a lot of questions about burn-up credit, why it was
4	used in one context and not in the other context. The
5	whole issue is validation essentially. When you rely
6	on the Part 50 and you take into account burn-up
7	credit and the methodology that you use, you have
8	actually a lot of validation for those methodologies.
9	You rely on the extensive feedback from running the
10	reactor, criticality, depletion and so on. So the
11	method that you use that gives you a number whether
12	it's 0.5, 0.9 or 0.95, it's actually validated by a
13	real experience and clearly in the context of
14	establishing a case why you can load safely is that
15	you go through a calculation which entails not only
16	using a methodology but having means to validate that
17	your methodology is appropriate and giving you the
18	right results.
19	Now when we go into Part 72, you notice
20	that there's a change in philosophy there and the
21	practice then is that you have virtually lost
22	corporate memory about your spent fuel. You go from
23	essentially a first principle, how much uranium-235,

238, 236, 238, plutonium-239 and so on, fission 24 products, and you go on the one specific isotope by 25

> **NEAL R. GROSS** COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

	195
1	one specific isotope.
2	MEMBER ARMIJO: But why is that? Why do
3	you assume or why does anyone assume you've lost
4	corporate memory and all that? I mean you still
5	MR. MACHIELS: I am the wrong person to
6	answer that. You really have to go back to the NRC
7	and go for historical reasons why they chose that
8	approach. You could in principle have that approach
9	or another approach could be which is not in the
10	regulations right now is that you could leave that to
11	the utilities actually to the You have the dual
12	purpose. But that's where the discontinuation is here
13	and so on one case you have a true validation by
14	looking at the way you run your reactor, the extent of
15	the experience that you have with that.
16	The other one you have to go and now
17	analyze spent fuel element from miscellaneous
18	reactors, see how much isotopic concentration you have
19	from a given species and then you have to look at the
20	value of the worse of those fission products for a
21	given spectra and these type of things. So you need
22	a tremendous amount of good data so get the validation
23	in order to support any burn-up credit methodology in
24	that context. And so that's the issue there.
25	Now there are reasons why the industry
	1

(202) 234-4433

	196
1	obviously likes burn-up credit and one of them is risk
2	based is that if you have burn-up credit instead of
3	shipping 24 assemblies at a time, you ship 32
4	assemblies at a time. You reduce the number of
5	shipments by a factor of 25 percent. We all know that
6	there are real risks in tracking along the highway and
7	if you'll compare the incremental risk one way and the
8	decrease in the risk in the highway system, you will
9	find that burn-up credit should probably be the method
10	that you would have to use in order to maximize the
11	load of your shipment and minimize the number of
12	shipments.
13	But anyway, I'm diverging here. Okay.
14	But I'm saying there is a basis. This is not simply
15	because we have 750 loadings and no accident that we
16	deduce it's safe. But there is a systematic analysis
17	which have been performed with appropriate
18	benchmarking and you can see in one case why in one
19	case we can use burn-up credit in a fairly
20	straightforward manner and the other case because of
21	a different selection at the start we are really, if
22	you want to, we have to get an extensive amount of
23	data in order to be able to validate the approach.
24	I believe that, you know, the weak point
25	is really in some ways the regulations themselves. As
	1 I I I I I I I I I I I I I I I I I I I

(202) 234-4433

1 pointed out by the NRC, there is no distinction. You talk about fissile materials and clearly if you ship 2 plutonium or fresh fuel, it's a different animal as if 3 4 you ship spent fuel. And when you ship plutonium or 5 fresh fuel, you deal only with a limited number of nucleids. So you can afford to go systematically 6 7 through a methodology which says these are the biases of the methodology that I should take into account. 8 These are the uncertainties I should take into 9 10 account. When you talk about spent fuel, you talk 11 12 about an animal which is dead most of the time from a reactivity point of view, but there is about a 13 14 gazillion isotopes it and obviously if you want to 15 take into account not only the actonites but the minor actonites as well as up to about 15 fission products 16 17 and systematically you have to come up with a bias and the uncertainties that apply to those and add those in 18 19 a systematic manner so that you stay conservative. 20 You basically eat in to your reality and that's why 21 the reliance on reactor is so good because the reactor 22 in a way give you change of reactivity in a more 23 global manner. They follow some fission products 24 individually but also they have some groupings of 25 fission products. So you can see there the tension if

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

197

	198
1	you want to between the two parts.
2	MEMBER SIEBER: And it's non-homogenous.
3	Spent fuel assembly is with variations.
4	MR. MACHIELS: Right. There's a profile.
5	There's an actual profile.
6	MEMBER SIEBER: In all directions. So the
7	problem is not simple.
8	MEMBER CORRADINI: So let me ask you a
9	different question to turn it around. So is the
10	industry actively pursuing a conscious effort to use
11	burn-up credit and make a proposal that that's the way
12	to actually reduce overall risk?
13	MR. MACHIELS: There are two vendors which
14	have an application in front of the NRC. The NRC is
15	evaluating that. There is a joint research project
16	involving DOE, NRC Research and EPRI in chance of
17	obtaining additional data and so there is certainly an
18	effort to get to that.
19	MR. KRAFT: Absolutely. I think that in
20	the long run, I think that you're going to need to
21	have to take the higher burn-up fuels. You're going
22	to have to take into account burn-up credit and things
23	like that.
24	MEMBER APOSTOLAKIS: So Part 72 then
25	imposes unnecessary burden. Is that what you're

(202) 234-4433

	199
1	saying?
2	MR. MACHIELS: Well, the Part 72 takes the
3	most simple situation. It says let's assume that your
4	fuel is fresh and let's go from there.
5	MR. KRAFT: It's only two ways. As
6	enrichments go up, I think that you're going to see
7	that it could be that. I think initially it wasn't.
8	The uncovering of the conflict between two regulations
9	I think brought it really to a head in terms of
10	current regulatory application. That burn-up credit
11	is something that would be beneficial and I think we
12	can project into the future that for the Yucca
13	Mountain project. When DOE starts coming to NRC to
14	get certificates, or the vendors are, certificates for
15	the multi-purpose canister, there's going to probably
16	you need to get burn-up credit for some of the
17	criticality control requirements that they're looking
18	for. So I think that there's going to be a need to
19	have this develop and documented and through the
20	research program that Albert described.
21	DR. RYAN: Just a question from Mike Ryan.
22	I think that's where the ACNW's interest really is
23	because we're tasked to look at the package
24	performance study and some of those issues related to
25	Yucca Mountain.
	1

(202) 234-4433

	200
1	MR. ROLAND: This is Bill Roland. Just
2	one comment. Mr. Armijo said it probably as precise
3	as I think somebody could say it. He said how could
4	you take the fuel credit for burn-up and I think you
5	said some factor.
6	MEMBER ARMIJO: Yes, discounted if you
7	have some uncertainty.
8	MR. ROLAND: And that's precisely the
9	problem. We need to know what the technical basis for
10	that factor is and that's why we're looking for
11	additional data so that we just don't have some
12	factor. We have a factor that has technical basis.
13	MEMBER ARMIJO: But wouldn't it be better
14	to put a big fat factor and do something soon than
15	study it for 50 years and never get there.
16	MR. ROLAND: And it's my understanding
17	that when you make that factor big and fat it ends up
18	not being particularly useful.
19	MEMBER ARMIJO: I'm talking about
20	MEMBER APOSTOLAKIS: Sam, are you arguing
21	that they should be going the other way?
22	MEMBER ARMIJO: No, I'm saying that they
23	should take the burn-up credit as validated by the
24	reactor experience, attach that number
25	MR. ROLAND: He wants the modified Part
	1

(202) 234-4433

	201
1	72.
2	MEMBER APOSTOLAKIS: That's what I'm
3	saying. You're going the other way. You want to keep
4	68.
5	MEMBER ARMIJO: I'll give you the option
6	of using it if you want.
7	MEMBER APOSTOLAKIS: Oh, option.
8	MEMBER ARMIJO: Yes, you don't have to use
9	it, but you know it's there to some extent. Right?
10	So it's just the issue of how much it's physically
11	there, the burn-up is there.
12	MEMBER APOSTOLAKIS: But the industry
13	doesn't care. Why do you care? I mean I'm serious.
14	MR. KRAFT: We do care though.
15	MEMBER APOSTOLAKIS: So you say you have
16	studies going on.
17	MR. KRAFT: Wait. Hang on a second.
18	50.68 applies only to loading in a pool. Okay. Then
19	that's what's on point for discussion here. But in
20	many other areas, the need for burn-up credit is going
21	to become very important as we get to higher burn-up,
22	higher enrichment, higher burn-up fuels.
23	PARTICIPANT: George, it's reality.
24	MR. KRAFT: As we get the disposal at
25	Yucca Mountain.

(202) 234-4433

	202
1	MEMBER APOSTOLAKIS: I understand that,
2	but
3	CHAIRMAN WALLIS: Isn't there a
4	MEMBER APOSTOLAKIS: No, the reality today
5	is the proposal by the staff to modify 50.68.
6	MR. KRAFT: I don't disagree with that.
7	MEMBER APOSTOLAKIS: And there is a
8	reality out there which is another reality. So the
9	question is do we disagree with the staff. Are we
10	going to agree, disagree, whatever? Now what you're
11	addressing it seems to me, Sam, is a broader issue.
12	MR. KRAFT: Right.
13	MEMBER APOSTOLAKIS: Which probably
14	belongs to another meeting.
15	MR. KRAFT: Yes, there is a very broad
16	There is a much broader issue that that.
17	MEMBER APOSTOLAKIS: Yes and these
18	gentlemen, I think you told us that the industry is
19	already looking into this.
20	MR. KRAFT: Yes we are.
21	MEMBER APOSTOLAKIS: So probably you will
22	come back with some sort of request of the staff at
23	some point. I don't know.
24	MR. KRAFT: Yes.
25	MEMBER APOSTOLAKIS: I mean whatever you
	1

(202) 234-4433

	203
1	do that's in the future.
2	MR. KRAFT: You're exactly right. We have
3	again not really on point to this discussion, but we
4	have an inventory of issues on dry cask and
5	transportation casks that we maintain with the staff
6	that we meet periodically and we work to resolve. Our
7	goal is to close issues so the regulatory uncertainty,
8	if that's the right word I could use, gets closed up.
9	One of them is burn-up credit. There are any number
10	of others. Monetary exclusion is another big one and
11	we are working with the staff and the industry to get
12	those issues dealt with and this is one of them.
13	MEMBER APOSTOLAKIS: We'll probably have
14	a chance to address this at some time in the future.
15	MR. KRAFT: The future, you will
16	certainly.
17	MEMBER APOSTOLAKIS: But I think Mr.
18	Michiels' views have been noted.
19	CHAIRMAN WALLIS: We are simply to revise
20	on this decision to pick one of them and not have
21	duplication.
22	MEMBER APOSTOLAKIS: It's a very limited
23	decision.
24	MR. KRAFT: And I agree with that.
25	CHAIRMAN WALLIS: It's very simple in

(202) 234-4433

	204
1	essence decision.
2	MR. KRAFT: While you're thinking about
3	whether you're going to agree or disagree with the
4	staff, there's one more point from a regulatory
5	implementation standpoint. We read the proposal. It
6	was made available to the public about 3:00 p.m.
7	yesterday afternoon and so we've kind of been reading
8	it and we haven't exactly studied all the details of
9	it and general counsel still wants to read this thing
10	in great detail. It is not clear to us what happens
11	to those handful of licensees who have already
12	modified their licenses. Where having borne the
13	burden, they are now being required to go back and
14	rebear the burden to undo what they have done and that
15	make absolutely no sense and whether or not the
16	current language that was made available to the public
17	
18	CHAIRMAN WALLIS: They've done it twice.
19	They've done it with both. Do they now have to go
20	back and forget that they've done it?
21	MR. KRAFT: That's exactly the question,
22	Dr. Wallis.
23	CHAIRMAN WALLIS: But if they've done
24	both, it doesn't matter.
25	MEMBER APOSTOLAKIS: They should tear up
	1

(202) 234-4433

	205
1	the pages.
2	MR. KRAFT: We don't really know, but what
3	is intended by, it's not described very clearly, but
4	you know it's a confused situation. When we read the
5	words, we're not exactly certain how they get applied.
6	We think NRC is going to be smart about it but it's
7	not clear.
8	MEMBER APOSTOLAKIS: Can we have the staff
9	tell us?
10	CHAIRMAN WALLIS: And we have the public
11	comments to come back. We'll have the public
12	comments.
13	MR. MARTIN: This is Tom Martin. I am
14	just now finding out that there might be some degree
15	of unfairness associated with licensees that have
16	already taken the steps before and modified their
17	regulations, not modified the regulations, modified
18	their technical specifications to provide
19	consideration of this. I'll have to You know we'll
20	have to discuss this with NEI and if we can make a
21	minor adjustment in the rulemaking that would be
22	appropriate that could be considered. This has not
23	been released as a direct final rule and it's still on
24	the table.
25	MR. MIZUNO: This is Gary Mizuno, Office

(202) 234-4433

	206
1	of General Counsel for NRC. If I understand the
2	industry correctly, they are saying that they have
3	modified, some licensees have modified, their analyses
4	and provided perhaps an exemption.
5	MR. KRAFT: No, these are people who have
6	actually submitted LARs, got them approved and now
7	have modified tech specs.
8	MR. MIZUNO: Okay. They have modified
9	tech specs. Okay. The tech specs I believe are
10	consistent with the proposed rule were it to go final
11	or if it becomes a direct final rule, if it becomes
12	final.
13	MR. KRAFT: That would require your having
14	a conversation with our general counsels to convince
15	them that that's the case because at the moment
16	they're not convinced.
17	MR. MIZUNO: Okay, but I've certainly
18	thought about and the concept was that this was not
19	going to impose any kind of backfitting upon licensees
20	because it was basically one that permitted licensees
21	to either stay with their existing system, whatever it
22	may be but this was a relaxation, a voluntary
23	relaxation. So licensees had their freedom even if
24	they were approved for something else to revert back
25	to something else. But there was nothing in

(202) 234-4433

	207
1	particular about the rule that required them to change
2	from where they were.
3	CHAIRMAN WALLIS: Are we about ready to
4	wrap this up?
5	MEMBER ARMIJO: I think we are. Are you
6	finished?
7	MR. KRAFT: Yes we are. Thank you.
8	CHAIRMAN WALLIS: Ready to wrap it up?
9	MEMBER ARMIJO: We're ready.
10	CHAIRMAN WALLIS: If you're ready, then
11	can we do it? May we do it?
12	MEMBER ARMIJO: Do it, yes. Just I think
13	
14	CHAIRMAN WALLIS: Thank you very much.
15	MEMBER ARMIJO: Thank you.
16	CHAIRMAN WALLIS: I thank the NRC. Now,
17	Sam, I think you need some input from the Committee
18	but would you be happy to take it when we meet to
19	discuss things at the end of the day rather than now.
20	MEMBER ARMIJO: If you want to move the
21	schedule. Are we still
22	CHAIRMAN WALLIS: I think we may need to
23	mull it over. Yes, I would like to take a break. I'd
24	like to take a break.
25	MEMBER ARMIJO: Let's take a break.
	I contract of the second se

(202) 234-4433

	208
1	CHAIRMAN WALLIS: Okay. We'll take a
2	break for 15 minutes or actually Yes, we'll take a
3	break for 15 minutes to It's seven minutes past.
4	Can you remember seven minutes past? Ten minutes
5	past. Ten past three. Off the record.
6	(Whereupon, at 2:53 p.m., the above
7	entitled matter recessed and reconvened at 3:12 p.m.
8	the same day.)
9	CHAIRMAN WALLIS: On the record. Please
10	come back into session. In case there's any doubt
11	this is an open meeting and the subject is the State
12	of the Art Consequence Analysis and I'll turn it over
13	to Mario Bonaca.
14	MEMBER POWERS: Mr. Bonaca, before you
15	start, I believe that Sandia National Laboratories has
16	some involvement in this of an indeterminant nature
17	and because of that, I am going to seriously recuse
18	myself from commenting, participating or otherwise
19	engaging on this subject.
20	MEMBER BONACA: Recusing yourself. Very
21	good.
22	CHAIRMAN WALLIS: Are we going to lose a
23	quorum because of that?
24	(Laughter.)
25	MEMBER BONACA: That said, just let me say

(202) 234-4433

1 the purpose of the meeting is to discuss the staff's 2 performing state-of-the-art plan for reactor analysis. Just for the purpose of 3 consequence 4 background, the 1992 NRC and Sandia National Lab NUREG 5 CR22.38 more commonly known as the Sandia Offsite Study, used several known conservative assumptions and 6 7 bounding analysis to demonstrate results that met 8 overall risk goals. At the time this analyses were 9 sufficient to meet the purposes.

But the results in terms of predicted offsite early fatalities latent cancer for severe accident scenarios have often been quoted. And despite widely accepted arguments that these results rely on conservative inputs and bounding analysis the results continue to be quoted and circulated in public forums.

The Commission has directed the staff to 17 develop a plan and then has approved a plan to 18 19 evaluate and update as appropriate analytical methods and models for a realistic evaluation of severe 20 21 accident progression and offsite consequences, (2) to 22 state-of-the-art develop reactor consequence 23 assessments and (3) to develop an integrated and 24 predictive computer based tool to assist decision 25 making in the event of severe reactor accident.

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1 The Commission also directed the staff to 2 work with the CRS on technical issues and therefore 3 it's important to us to listen to our role. 4 perspective role. During the meeting, the staff will 5 discuss their plans with us to establish a basis for our ongoing interaction on these topics. We are not 6 7 expected to write a letter I believe out of this 8 meeting and so at this point, I will turn over the 9 presentation to you.

10 MS. LAUR: Thank you. Thank you for your 11 time this afternoon. I'm Michele Laur with the Office 12 We have Chris Hunter and Jason Schaperow of Research. who will also present and answer questions today. 13 We 14 want to thank you for the time to talk about this 15 particular project in a public venue. This afternoon we're going to cover a number of topics. 16 We want to give you a general overview of the project, but more 17 importantly we would like to give you some progress to 18 19 date and some of the activities that we're going to be 20 pursuing as our next step.

As Mario mentioned, there have been some studies done in the past that did serve their purpose at that time, but there have been changes at the plants. We've learned a great deal of good information with regard to accident progression and

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	211
1	core melt phenomenology. So the Commission determined
2	that there was a need to kind of revisit the subject
3	if you will. So in December of 2005, a SECY was
4	written that included the staff's plan to conduct this
5	analysis and then in April of this year, the
6	Commission SRM was released that directed the staff to
7	perform this more realistic evaluation of severe
8	accident progression and offsite consequences.
9	Now the focus of this study is to look at
10	a spectrum of scenarios that are most likely to happen
11	and produce subsequent offsite consequences using a
12	risk informed rather than a risk based approach.
13	MEMBER KRESS: Can I ask a question about
14	that one?
15	MS. LAUR: Surely.
16	MEMBER KRESS: You know when we do a full
17	PRA analysis, Level 3, we add up the endpoints.
18	MS. LAUR: Yes.
19	MEMBER KRESS: Which includes basically
20	all of the sequences that we stick in there that have
21	endpoints that are important. Now what you're saying
22	is that you're going to somehow curtail those
23	endpoints and pick out only certain ones and not add
24	in the others.
25	MS. LAUR: We are going to address that in
1	

(202) 234-4433

	212
1	a slide and if we could hold that question until then.
2	MEMBER KRESS: Okay.
3	MS. LAUR: Because we'll step through it
4	very carefully for you.
5	MEMBER KRESS: Okay. Thank you.
6	MS. LAUR: All right. Thank you very
7	much.
8	CHAIRMAN WALLIS: My question is risk
9	informed usually applies to regulation. You make risk
10	informed regulation.
11	MS. LAUR: That's correct.
12	CHAIRMAN WALLIS: And the evaluation of an
13	action of progression is a technical analysis. It has
14	nothing to do with risk informed or not. And as my
15	colleague points out, you only bring in risk when you
16	perhaps exclude certain things that you decide not to
17	look at.
18	MS. LAUR: We will step through the
19	process we're using and discuss it in greater detail
20	for you.
21	CHAIRMAN WALLIS: Maybe using this risk
22	informed approach is just some kind of litany you go
23	through to try to get a blessing.
24	(Laugher.)
25	MS. LAUR: You're very intuitive, aren't

(202) 234-4433

	213
1	you?
2	MEMBER KRESS: You can't believe the
3	numbers. Right?
4	MS. LAUR: As we all know, numbers should
5	be looked at as trends, but we'll get into it in
6	detail. Thanks. As you may know, this project really
7	has two major parts to it. The first is the
8	consequence analysis and for the consequence analysis
9	we will be using the most realistic modeling software
10	that we have to look at the systems and transport and
11	eventually the release pathways. We will incorporate
12	the most up-to-date emergency preparedness modeling
13	assumptions. So we are working very closely with
14	folks in NSER so that we factor that in appropriately.
15	We're going to try to account for plant improvements
16	that have come about because of recent studies that
17	have been ongoing here at NRC and elsewhere.
18	We want to account for recent mitigation
19	strategies that might either delay core damage or at
20	least reduce the impacts of the offsite consequences
21	and then that second part of this project is this
22	faster than real time decision making tool that we're
23	not going to focus on today but I will tell you again
24	we're working with folks in NSER and also people in
25	our OPS Center who are the ultimate endusers of that

(202) 234-4433

	214
1	product so that when it is developed it will be useful
2	to the folks that need it.
3	CHAIRMAN WALLIS: Real time tool, you mean
4	a computer simulation which goes faster than the
5	event?
6	MS. LAUR: Yes.
7	MEMBER KRESS: When you do this
8	assessment, have you got up-to-date data on the
9	meteorological conditions and the population around
10	these areas and the changes in the general types of
11	land that are around there? Do you have up-to-date
12	data on that?
13	MS. LAUR: We are going to be using the
14	most up-to-date data we can get. In fact, we're
15	holding a public meeting tomorrow where we're going to
16	focus primarily on the data needs for this particular
17	project, met data, precipitation data, emergency
18	preparedness information, evacuation, sheltering. All
19	of these are important bits of information that we
20	want to incorporate that really makes this the state-
21	of-the-art type project because we hope to wrap that
22	information in as well as the information that's been
23	gained over the last 20 years on how cores actually
24	melt. So that's really where the state-of-the-art
25	part comes into this analysis.

(202) 234-4433

	215
1	You may ask yourself why bother to do this
2	project. What could be the end uses of it? This is
3	a list of some
4	MEMBER KRESS: I'm not going to ask myself
5	that.
6	MS. LAUR: You might not?
7	MEMBER KRESS: No.
8	MS. LAUR: I ask myself.
9	MEMBER KRESS: I've been calling for it
10	for ever since I've been on this committee.
11	MS. LAUR: Thank you.
12	CHAIRMAN WALLIS: What do you use it for?
13	MEMBER KRESS: I have lots of things I use
14	it for.
15	MEMBER APOSTOLAKIS: Is this a Level 3
16	PRA?
17	MEMBER KRESS: Yes sir.
18	MEMBER APOSTOLAKIS: Obviously you don't
19	like what they're doing.
20	MEMBER KRESS: You can tell. I don't like
21	this program at all.
22	MEMBER APOSTOLAKIS: Why did you decide to
23	do this? Has the question been asked?
24	MEMBER KRESS: Yes.
25	MS. LAUR: Yes. It was
	1
	216
----	--
1	MEMBER APOSTOLAKIS: Because he does a
2	good
3	MS. LAUR: He got one vote. So some of
4	the potential uses that have been identified in the
5	SECY for this particular project are listed here. I'd
6	like to highlight that for example we hope to gain
7	some insights that might be useful in the licensing
8	and site reviews for new reactors that are on new
9	sites. While we won't use this information to
10	supercede the regulations for siting, they can help us
11	to make better decisions in that process.
12	We also hope that the analysis will help
13	us to test our emergency preparedness plans to make
14	sure that what we have in place does make sense and is
15	of the greatest benefit.
16	CHAIRMAN WALLIS: Can I ask you a
17	question?
18	MS. LAUR: Surely.
19	CHAIRMAN WALLIS: What you're doing here
20	is all plant specific.
21	MS. LAUR: Yes it is.
22	CHAIRMAN WALLIS: So are you going to
23	provide a tool for doing it or are you going to do it
24	for each plant?
25	MS. LAUR: What we plan to do is that the
	I

(202) 234-4433

	217
1	Melcor part of the analysis which will give us the
2	actual source terms we don't actually have a plant
3	deck for every plant. So we will be using the plant
4	decks we have and making some changes to them as
5	necessary, also doing some sensitivity analysis to see
6	which of the parameters are more important to more
7	accurately model. When we get to the consequence
8	analysis which is the MACCS analysis, that will be
9	done on a plant specific basis for every plant.
10	CHAIRMAN WALLIS: For every plant?
11	MS. LAUR: For every plant.
12	CHAIRMAN WALLIS: Are you going to publish
13	a document which gives us for every plant, gives the
14	results for every plant?
15	MS. LAUR: We will be publishing a
16	document to cover the entire analysis. There could be
17	the potential that some insights gained through this
18	would not be something that would be put out publicly
19	and we'll determine that at
20	MEMBER CORRADINI: So if I remember back
21	`82 wasn't this I'm trying to think of Dave
22	Aldridge. There was a study done, a NUREG, that had
23	it on a plant specific basis essentially a source
24	stream analysis. Am I remembering correctly?
25	MS. LAUR: The 1982
I	1

(202) 234-4433

	218
1	MEMBER KRESS: Sandia Siting Study.
2	MS. LAUR: Sandia Siting Study, that's
3	correct.
4	MEMBER CORRADINI: So it's essentially an
5	update to the Sandia Study of `82?
6	MR. SCHAPEROW: Actually the Sandia Siting
7	Study had only one source term, well it had five
8	source terms, but one was really the severe accident
9	source term with early containment failure.
10	MEMBER CORRADINI: But then they placed it
11	at all the reactor sites.
12	MR. SCHAPEROW: That's correct.
13	MEMBER CORRADINI: That's what I remember
14	to be the case.
15	MS. LAUR: Right, but this will
16	MR. SCHAPEROW: They did crack
17	calculations for each site.
18	MEMBER CORRADINI: Right.
19	COURT REPORTER: Sir, would you identify
20	yourself please?
21	MR. SCHAPEROW: Jason Schaperow of the NRC
22	staff.
23	MEMBER APOSTOLAKIS: So is it possible
24	then at some point in the future your results will be
25	part of the SPAR models if you are doing it on a site
	1 I I I I I I I I I I I I I I I I I I I

```
(202) 234-4433
```

	219
1	specific basis?
2	MS. LAUR: We're actually using the SPAR
3	models that we have in-house right now to help us
4	determine which scenarios to select and as we move
5	beyond looking at internal events to inform us in our
6	scenario selection we will be trying to use the
7	external event SPAR models that have been developed
8	here to help inform us on that decision.
9	MEMBER APOSTOLAKIS: Yes, but then when
10	you get your results, are you going to feed back into
11	the SPAR model your Level 3 results?
12	MR. ELTAWILA: Professor Farouk Eltawila
13	from the staff. We are developing a model from the
14	SPAR right now, a simplified model that can be used
15	the resident inspector. Where this type of analysis
16	that Michele is talking about and using the Melcor
17	code and things like that might be a very complicated
18	analysis. We are going to decide on whether we are
19	going to incorporate the insight that's coming from
20	that study into the SPAR model. But right now, there
21	is a plan to develop a Level 4 SPAR model.
22	MEMBER KRESS: Let me ask you a technical
23	question. I don't know if you get to it or not. When
24	you do the consequence analysis, let's talk about
25	latent effects. Are you going to truncate somewhere
	1 I I I I I I I I I I I I I I I I I I I

(202) 234-4433

	220
1	like 50 miles or 100 miles or 150 miles and are you
2	going to use the linear no-threshold? I don't know if
3	I just want to get the basis.
4	MR. SCHAPEROW: Yes, our initial thinking
5	was to present both results with a linear no-threshold
6	going out to great distances and also to present
7	results with a series of different threshold doses up
8	to 5 rem per year.
9	MEMBER KRESS: Okay. So you'll do sort of
10	a sensitivity.
11	MR. SCHAPEROW: Yes, that was our initial
12	thinking. Now we had an expert review meeting two
13	weeks ago out in Albuquerque to go over the modeling
14	and the MACCS code and some of the main assumptions
15	we're going to use in it and this issue of course came
16	up and we had different views from different people on
17	the panel as to what might be an appropriate distance
18	for truncating. So I guess it's fair to say you're
19	right. That's a tough issue.
20	CHAIRMAN WALLIS: Are you going to
21	truncate the distance and if you have a very hot plume
22	of the Chernobyl type, as you know, it goes a long
23	way.
24	MEMBER KRESS: But that will get put in
25	the distance traveled. But you know you can either do
	1

(202) 234-4433

	221
1	something about the threshold or you can do something
2	about the distance and they are equivalent to each
3	other. But it's hard to say which is which. But I
4	would just make it easy. Don't mess with the
5	threshold. Mess with the distance.
6	MEMBER APOSTOLAKIS: I thought it was 50
7	miles, isn't it?
8	MEMBER KRESS: They used to stop at 50.
9	MR. SCHAPEROW: Sometimes 150.
10	MEMBER KRESS: That's arbitrary.
11	Sometimes they go to 150.
12	MEMBER CORRADINI: Can I ask, Tom, why do
13	it on distance and not dose?
14	MEMBER KRESS: You would do the dose but
15	I would say just if you're using the linear no-
16	threshold theory on the dose consequences.
17	MEMBER CORRADINI: Yes.
18	MEMBER KRESS: You're essentially
19	truncated it if you truncate the distance. So it's
20	easier to truncate a distance than it is to try to
21	figure out what the threshold is.
22	MEMBER CORRADINI: You're just saying from
23	a practical matter.
24	MEMBER KRESS: From a practical sense.
25	But that can go either way.
l	1 I I I I I I I I I I I I I I I I I I I

	222
1	CHAIRMAN WALLIS: But you're saying that
2	Chernobyl had no effects beyond 150 miles.
3	MEMBER KRESS: We're not going to have
4	Chernobyl in our sequences.
5	CHAIRMAN WALLIS: But presumably at
6	Chernobyl like sequences are a possibility. It's been
7	analyzed
8	MEMBER KRESS: No, that's not even going
9	to be in the PRA.
10	CHAIRMAN WALLIS: It's not going to be in
11	the PRA.
12	MEMBER KRESS: No.
13	CHAIRMAN WALLIS: It's impossible.
14	MEMBER KRESS: Yes.
15	CHAIRMAN WALLIS: All right. Thank you.
16	MEMBER KRESS: It's one of the truncated
17	sequences and we don't
18	MEMBER SIEBER: Very reassuring.
19	CHAIRMAN WALLIS: It's truncated. That's
20	why it's impossible.
21	MEMBER BONACA: Okay. Let's Go ahead,
22	Ms. Laur.
23	(Off the record comments.)
24	MS. LAUR: Thank you. Some of the other
25	reasons why we want to move forward with this study

```
(202) 234-4433
```

	223
1	that one might ask themselves even though Tom might
2	not ask himself is that there have been some
3	improvements in PRA modeling. As we know plants have
4	evolved and improved over time. We've had some plant
5	design changes based on a number of initiatives. It
6	started here at NRC such as the station blackout rule.
7	One of the things that came out of that was an
8	improved alternative AC power source.
9	Some of the things in the Level 2/Level 3
10	area that have improved and give us a reason for doing
11	this study is that since 1982 there have been a number
12	of international and national studies that have been
13	done on phenomenology that give us a much better idea
14	of how core melt will progress. Also there have been
15	improvements in the Melcor software product that we
16	have that we're going to take advantage of during this
17	study. Computing speeds have given us the opportunity
18	to look at more sequences than we might have done in
19	the past. The net effect is that we hope to have a
20	much more realistic study for ourselves and for our
21	stakeholders.
22	We have a lot to do. We have three years
23	to do it. This gives you a little idea of the plan as
24	far as what sites we plan to look at first. In the
25	first year, we hope to evaluate the Westinghouse large

(202) 234-4433

IJ

(202) 234-4433

	224
1	dry, the GE Mark I and the GE Mark III plants. We
2	will follow up with the Mark IIs, the Ice Condenser
3	and the sub-atmospheric in year two and in year three
4	we hope to look at BMW and CE plants. We also plan to
5	use year three to go back and refine different parts
6	of the study if we find that is necessary.
7	This is, and I'd like to point this out,
8	a joint effort between Research NSER and NRR and we
9	are using Sandia as our contractor for assisting us
10	with this analysis.
11	MEMBER APOSTOLAKIS: Is the industry doing
12	anything? Are they helping you? Opposing you? Don't
13	care?
14	MS. LAUR: I've had some conversations
15	with industry. We will have a public meeting tomorrow
16	where we will have members of industry attending. We
17	hope to engage them on a frequent basis throughout
18	this project. So far in the conversations I've had
19	they are very interested in being a part of this
20	project. We hope that they will help us to get some
21	of the information that we need that we don't have in-
22	house.
23	We've already kind of talked about some of
24	that information already. The MET data, we have some
25	of that already. Some of that data is available to us
	1

(202) 234-4433

	225
1	because of license renewals, but data such as the
2	precipitation data is not something that is required
3	by the NRC. So we hope that we will get assistance
4	from the industry to get that kind of information.
5	There are some recent procedures that are being
6	developed by EPRI and others to help deal with post
7	accident activity and we hope to tie into that source
8	as well to get that kind of information so that we can
9	update our HRA to the extent necessary on this
10	project. So, yes, we are engaging industry.
11	MEMBER CORRADINI: Now let me ask Can
12	I ask a different question along the same lines? Have
13	they done the equivalent of a Level 3 on one of these
14	sorts of plants that you could actually do a one-to-
15	one comparison based on tool as well as assumptions?
16	MS. LAUR: I don't think so. That's
17	certainly something that we can investigate.
18	MEMBER KRESS: There have been some Level
19	3s in the environmental impact statements.
20	MEMBER APOSTOLAKIS: Level 3 is Indian
21	Point. There is a full Level 3.
22	MEMBER KRESS: Yes.
23	MEMBER APOSTOLAKIS: Seabrook.
24	MEMBER KRESS: Seabrook has one.
25	MEMBER APOSTOLAKIS: The other one, the
1	1

(202) 234-4433

	226
1	big one. South Texas project. So there are four or
2	five. The Indian Point is very old, but the others
3	MS. LAUR: There are some.
4	MEMBER CORRADINI: All done by their
5	consultants.
6	MEMBER APOSTOLAKIS: Yes. Well, the
7	utility process.
8	MEMBER CORRADINI: I'm getting the point
9	which I'm guessing what their tool is in relation to
10	this and I'm also curious about many times you don't
11	want to roll it too much, but I'm curious about the
12	modeling assumptions as well as the net result and so
13	I would expect they're using what they use in their
14	IPES.
15	MS. LAUR: I would guess that.
16	MEMBER CORRADINI: So it would be an
17	interesting comparison if you had some sort of
18	connection at a couple of places. That's just what I
19	was wondering.
20	MS. LAUR: That's a good point.
21	MEMBER KRESS: Let me ask you another
22	question. When you get around to doing the site
23	specific evaluations, what are you going to about
24	sites that have three plants on it, three different
25	units? Or two? Multiple sites? Multiple units?
	1 I I I I I I I I I I I I I I I I I I I

(202) 234-4433

227 MR. SCHAPEROW: We'll have to consider 1 2 those separate consequence calculations. 3 MEMBER KRESS: Then add them up. Add up 4 the risks. 5 MR. SCHAPEROW: The assumption that they would both be having --6 7 MEMBER KRESS: You're going to get a site 8 risk rather than a plant risk is what I'm asking 9 because you have to add up the risks of each plant on 10 the site to get the total risk for that site. MEMBER CORRADINI: But would it be 11 Why would it be additive? 12 additive? MEMBER KRESS: It's additive. 13 14 MR. SCHAPEROW: If your metric is risk. 15 I think our metric here is going to be offsite prompt fatalities, offsite latent fatalities. 16 17 MEMBER APOSTOLAKIS: And some probability of distribution. You're not going to just say --18 19 MEMBER KRESS: You're definitely going to 20 qo to a risk. 21 MEMBER APOSTOLAKIS: You have to have a 22 probability distribution. 23 MEMBER KRESS: Yes. I mean it's useless 24 without it. I mean you're going to go back to 740 if 25 you just use the consequences. You're going to add

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	228
1	the probabilities in.
2	MEMBER APOSTOLAKIS: Are you producing
3	risk curves? That's really the question. You know
4	like the reactor safety study. Frequency versus acute
5	fatality.
6	MEMBER KRESS: Yes.
7	MEMBER APOSTOLAKIS: I mean how else can
8	you do it. Otherwise, you go back to 740.
9	MEMBER KRESS: Complimentary. Yesm,
10	otherwise you're doing 740. You don't want to do
11	that. That was a mistake.
12	MEMBER APOSTOLAKIS: What will your result
13	look like?
14	MEMBER CORRADINI: They're not really
15	talking to you. They're talking to each other.
16	MS. LAUR: Okay. Go right ahead.
17	MEMBER APOSTOLAKIS: No, I'm asking you.
18	MEMBER KRESS: Cumulative complimentary
19	distribution functions.
20	MEMBER APOSTOLAKIS: Yes.
21	MEMBER KRESS: For things like fatalities
22	and
23	CHAIRMAN WALLIS: Frequency consequences
24	curves.
25	MEMBER APOSTOLAKIS: Yes, exactly. FM

	229
1	curves.
2	MEMBER KRESS: That's what PRAs put out.
3	CHAIRMAN WALLIS: Is that what you're
4	going to produce? They're talking
5	MEMBER KRESS: No, that's what PRAs put
6	out.
7	MR. ELTAWILA: We are not going to produce
8	frequency consequence curves. We are going to produce
9	results for the dominant scenario. We're going to
10	identify the number of early fatalities and the number
11	of cancer fatalities. So this RD will be the product
12	our work.
13	MEMBER APOSTOLAKIS: Farouk, what do you
14	mean by the number of early fatalities? I mean there
15	will be a distribution for those. Right? You can't
16	just say it's five. There's a probability for
17	MR. ELTAWILA: You're going to have to add
18	for all the scenarios. Yes.
19	CHAIRMAN WALLIS: So integrate.
20	MEMBER APOSTOLAKIS: So you will not deal
21	with uncertainty at all?
22	MR. ELTAWILA: Do you want to take this?
23	MR. TANKLER: Yes. Let me I'll just
24	jump in here. A different kind of risk. Charles
25	Tankler from the NRC staff. The current thinking is

(202) 234-4433

1 that the complimentary cumulative distribution 2 function curves don't really add a lot to this 3 portrayal because we end up then focusing on 99.9th percentile for 10^{-6} events. So we end on focusing all 4 our energy and attention on what then becomes a 10 $^{-9}$ 5 outcome. So the focus of the study is to focus on the 6 7 more probable but dominant events. So repeating that same process that was done in the `82 study which -8 9 MEMBER CORRADINI: Is that how they 10 portrayed it too? MR. TANKLER: Yes. 11 12 MEMBER CORRADINI: I remember the curves. So we generate lots of 13 MR. TANKLER: 14 numbers and the only number that gets a lot of attention is the 99.9th percentile for a 10^{-6} or so 15 event and there's a serious concern how well we 16 examine the tales of some of those distributions was 17 Now we are proposing to look at the 18 not clear. 19 uncertainty in the predictions of consequences. 20 MEMBER CORRADINI: So there will be, if I 21 might just clarify, so there will be a point estimate 22 for a particular scenario and with that point estimate 23 would be an uncertainty in the consequence direction and an uncertainty in the probability direction. 24 25 There would be an MR. TANKLER:

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

230

	231
1	uncertainty in the consequence direction. Okay. Now
2	whether or not we consider 75^{th} percentiles or even go
3	to 90 th percentiles that's still something that's
4	under discussion. But there's very little appetite
5	for looking at 99.9th percentiles on
6	MEMBER APOSTOLAKIS: But nobody is saying
7	you should do that.
8	MR. TANKLER: But that was the nature of
9	the CCDF curves from the `82 study.
10	MEMBER APOSTOLAKIS: No.
11	MEMBER KRESS: Well, they can be means.
12	MR. TANKLER: I mean that may not have
13	been what learned members of this committee focused
14	on. But it was what many people thought
15	MEMBER CORRADINI: Maybe we weren't that
16	learned.
17	MR. TANKLER: Well, it was many people
18	ended on focusing on. So there is The thrust of
19	this is to look at the likely outcomes from the more
20	probable events. We will, we intend, to look at
21	uncertainty in an integrated way. We intend to use
22	our tools in a manner in which we have some experience
23	to integrate the uncertainty through the calculation,
24	both the MACCS calculation and the Melcor calculation
25	so we can capture the uncertainty of both the source

(202) 234-4433

	232
1	term and the consequence calculation. But we have not
2	yet determined as yet whether or not how far out on
3	the distribution the portrayal of results, how far out
4	we think that portrayal is meaningful is the best way
5	of saying it.
6	CHAIRMAN WALLIS: I think it would help
7	If you make this presentation again, it would help to
8	give us a sketch of the kind of outputs you expect to
9	get out of this thing and how you would present them.
10	It would be very helpful.
11	VICE CHAIR SHACK: Why not a mean output
12	if you're going to put out a number?
13	MR. TANKLER: Yes. A mean, if you look at
14	the 1982 study, one of the companion documents had a
15	compilation of tables where they list the mean value.
16	Now the summary document also had CCDF curves. So we
17	would reasonably expect that we would report mean
18	values and those mean values will be influenced by the
19	tails of the distributions. But the extent to which
20	we attach significance to the tail and out far out on
21	the tail the distribution that remains to be seen and
22	how far we are confident that that number deserves
23	that sort of attention.
24	MEMBER APOSTOLAKIS: What is the purpose
25	of the meeting today?

(202) 234-4433

	233
1	CHAIRMAN WALLIS: Informative.
2	MEMBER KRESS: We're getting briefed I
3	think.
4	MEMBER APOSTOLAKIS: So we're not writing
5	anything.
6	CHAIRMAN WALLIS: No.
7	MEMBER KRESS: We can always write one.
8	MEMBER CORRADINI: We can always write
9	one.
10	CHAIRMAN WALLIS: It's informative. Let
11	us
12	MEMBER APOSTOLAKIS: But the thing is what
13	I'm trying to avoid is sometime in the future the
14	committee is asked to express or to state its views on
15	the finished product under this program we have of
16	research quality. We may surprise the staff then. So
17	I would rather have a detailed subcommittee meeting
18	where you guys will tell what you plan to do and you
19	hear from us what we think you should be doing and
20	come up to some sort of understanding.
21	MR. ELTAWILA: That's very high This
22	meeting is intended to be at a very high level just to
23	introduce the subject. We are planning to have
24	frequent and more-than-you-need meetings to discuss
25	all the aspects of the program at a subcommittee

(202) 234-4433

	234
1	meeting. We want everybody to go out with us that we
2	are all in it together.
3	MEMBER APOSTOLAKIS: I am serious because
4	this is very important. I mean you keep referring to
5	this `82 study which I don't think I have seen but I
6	have seen the 11.50 studies which are from `89 and
7	they report frequency consequence curves. So this
8	would be nice to update those.
9	CHAIRMAN WALLIS: Which subcommittee is it
10	that's going to do this?
11	MEMBER APOSTOLAKIS: I think it's Tom's,
12	the Joint.
13	MEMBER KRESS: I think it's a Joint
14	because of PRA and
15	CHAIRMAN WALLIS: So you probably have
16	several meetings throughout the year to get updates.
17	MEMBER KRESS: This is a PRA subcommittee
18	I think.
19	MEMBER APOSTOLAKIS: Which subcommittee is
20	today yours? You are not running today's.
21	(Several conversations at once.)
22	MEMBER BONACA: We have done this under
23	the Security and Safeguard Subcommittee because we got
24	the first briefing in the subcommittee and then we
25	decided to make it public. So therefore, this is a
	1 I I I I I I I I I I I I I I I I I I I

(202) 234-4433

	235
1	summary of what we've heard already before in Security
2	and Safeguard. Now you're probably unaware in the
3	SRM, the Commission specifically directed the staff to
4	work with the ACRS on this issue. So we have a role
5	to play and so your comments certainly are important.
6	MEMBER APOSTOLAKIS: All I'm saying is
7	that it would be nice for the committee to express its
8	views on what you plan to do before you actually spend
9	a lot of time trying to do it and Mr. Eltawila agreed.
10	Okay. I think.
11	MR. ELTAWILA: Yes.
12	MEMBER BONACA: But I think it's important
13	The locale for that is to have a subcommittee
14	meeting soon enough where we get to the working level.
15	MEMBER APOSTOLAKIS: And the subcommittee
16	meeting is not part of the security thing.
17	CHAIRMAN WALLIS: We'll schedule it for
18	the near future.
19	MEMBER APOSTOLAKIS: Is that okay with
20	you?
21	MR. ELTAWILA: We already and I think
22	Michele is going to provide you with a plan of what we
23	are planning to do and then you can ask for the
24	meeting what topics you want us to cover in the next
25	meeting and we'll be here definitely.
1	I

(202) 234-4433

	236
1	MEMBER APOSTOLAKIS: Very good.
2	MS. LAUR: Thank you.
3	MEMBER APOSTOLAKIS: Exciting.
4	MR. ELTAWILA: It's an exciting time.
5	MEMBER APOSTOLAKIS: At both levels.
6	Right?
7	MS. LAUR: Okay. As I alluded to the
8	first step in this process is to identify the proper
9	scenarios that we're going to look at and Chris is
10	going to step through this for you.
11	MR. HUNTER: Hi. I'm Chris Hunter, Office
12	of Research. This slide is just a basic flow diagram
13	for how we're going to pick our scenarios and just to
14	go over a definition of scenario in terms of this
15	project it's either an individual sequence or a group
16	of sequences that have some similar system
17	unavailabilities or availabilities and similar times
18	to core damage.
19	CHAIRMAN WALLIS: I'd pick the first item,
20	screen initiating events. Do you mean events with a
21	probability of less than 10^{-7} ?
22	MR. HUNTER: Initiating events with a
23	CHAIRMAN WALLIS: Just don't have a CDF by
24	themselves. Initiating events don't have a CDF.
25	MEMBER APOSTOLAKIS: Do you mean

(202) 234-4433

	237
1	sequences?
2	MR. HUNTER: No, that would be the
3	cumulative sum of initiating sequences, the sum. So
4	for example, say a medium loca, all the medium loca
5	sequences, have a core damage frequency.
6	CHAIRMAN WALLIS: With the same initiating
7	event.
8	MR. HUNTER: Correct.
9	CHAIRMAN WALLIS: Okay. I see.
10	MR. HUNTER: So for the lower frequency
11	initiating events a lot of them scream out and it
12	depends on the type of plant we're looking what
13	scenarios we're going to see.
14	MEMBER APOSTOLAKIS: Because you expect
15	the CDF to be on the order of 10^{-5} or so.
16	MR. HUNTER: Actually a lot of our core
17	damage frequencies you get a lot of E^{-6} , some lower to
18	mid E^{-5} for overall core damage frequency, correct,
19	for in the SPAR models.
20	MEMBER APOSTOLAKIS: For existing
21	reactors. Right?
22	MR. HUNTER: Correct.
23	MEMBER CORRADINI: Can you remind me what
24	a SPAR model is?
25	MR. HUNTER: A SPAR model is an internal
	1

(202) 234-4433

	238
1	PRA. It's simplified. It stands for Standardized
2	Plan Analysis Risk Model, but it's essentially the
3	NRC's internal model for internal events and we have
4	them per site or per plant. Sometimes if the plants
5	are mirror images of each other it will be just be,
б	say it's Byron, Byron 1 and 2 will have one SPAR
7	model. But plants that have a little bit differences
8	like Indian Point 2 and 3 they will have separate
9	models.
10	MEMBER CORRADINI: So if I might just ask
11	in a follow-on question. So then I assume, so I'll
12	pick one in my states. So Kewanee has a SPAR model.
13	MR. HUNTER: Correct.
14	MEMBER CORRADINI: And they probably have
15	their own internal PRA too for internal events.
16	MR. HUNTER: Correct.
17	MEMBER CORRADINI: So how do these things
18	compare? That's what would be my first question about
19	before I start throwing things out and keeping things
20	in. How does the one calculation compare to the other
21	calculation?
22	MR. HUNTER: Right now, we're actually
23	going through a secondary enhancement of the SPAR
24	models where we're actually comparing the top, the
25	dominant, cuts between a licensee PRA and the SPAR
	1

(202) 234-4433

	239
1	model. Now are we finished with that? No, but the
2	licensees' PRAs have been benchmarked before previous.
3	As the SPAR models have matured over the past decade,
4	there has been comparisons because that's how
5	initially started up the SPAR models. So are they
6	matched identically? Absolutely not. However they
7	are in order of magnitude and they definitely are
8	similar and just to remind you this is for internal
9	events only.
10	CHAIRMAN WALLIS: Don.
11	MR. DUBE: Yes, if I could answer that
12	question directly. We compared the current CDF for
13	internal events SPAR model versus the licensee's PRA
14	and at present time 80 percent of the plants are
15	within a factor of two plus or minus, up or down.
16	MEMBER CORRADINI: In terms of the
17	cumulative.
18	MR. DUBE: Internal events core damage
19	frequency.
20	MEMBER CORRADINI: Okay.
21	MR. DUBE: So they are pretty close and
22	they are converging.
23	CHAIRMAN WALLIS: It doesn't mean to say
24	that the screening works out if the integral works
25	out. I know that plants often which look almost
I	

(202) 234-4433

	240
1	identical have different dominant sequences.
2	MR. DUBE: Well, I'm getting a high level
3	comparison, but we do do
4	CHAIRMAN WALLIS: Are you matching the
5	dominant sequences success rate as you go along?
6	MR. DUBE: Yes, as we enhance the models
7	we are comparing cut set by cut set level and we have
8	criteria if the cut sets differ by a certain amount
9	then we kind of flag them out.
10	MEMBER APOSTOLAKIS: Okay. We've had a
11	presentation by the Idaho people.
12	CHAIRMAN WALLIS: There's far more is
13	pretty good as the answer.
14	MR. HUNTER: Especially for the purposes
15	of this when we're looking at the dominant core damage
16	frequency contributors. But basically the first block
17	is really just to screen out some of the lower core
18	damage frequency initiating events and sequences so we
19	can look at the more dominant contributors and we
20	purposefully are dropping at least an order of
21	magnitude or two below just to prevent because at the
22	end we are actually grouping sequences together to
23	form a scenario and we don't want to cut anything out
24	prematurely before we actually group them together.
25	The second thing is
	1 I I I I I I I I I I I I I I I I I I I

(202) 234-4433

	241
1	CHAIRMAN WALLIS: Does this tend to screen
2	out large break locas?
3	MR. HUNTER: Yes, it does. For all
4	plants, large break locas.
5	MEMBER APOSTOLAKIS: This has already been
6	done. You're not going to do that. I mean the SPAR
7	model tells you what the dominant sequences are.
8	MR. HUNTER: Correct, but we're also going
9	in them and we're also grouping sequences together to
10	form a scenario because sometimes you get similar
11	sequences. Maybe they're different initiators because
12	they break transients a little bit differently,
13	whether it's a loss of main feed water or just a
14	general transient or a small loca. Sometimes you get
15	similar sequences that essentially would provide
16	essentially the same accident scenario. So we're
17	grouping those together essentially just summing up
18	the core damage frequencies after we look into the cut
19	sets to figure out exactly what's actually unavailable
20	and the times of core damage.
21	MEMBER APOSTOLAKIS: I don't want to
22	belabor the point, but it seems to me they have
23	already done it. But anyway
24	MR. HUNTER: They have done it, but it's
25	not pieced together with how we need it. So you have

(202) 234-4433

	242
1	to go in to do this. It takes a couple hours each
2	model just to go in to do this. Okay. Next we do is
3	we go into the dominant cut sets. So we have a
4	sequence list basically after the first block of the
5	dominant sequences. Typically it's between 20 and 30
6	and then we look at the dominant cut sets and we look
7	at what
8	CHAIRMAN WALLIS: I'm sorry. I have a
9	fundamental question. If you're screening out
10	everything based on CDF, CDF has nothing to do with
11	release to the public and it's LERF (PH) that releases
12	to the public. So it may be that the biggest things
13	are the biggest influence on release from containment,
14	things screened out.
15	MR. HUNTER: Right. We are basing this
16	off of frequency and that was the guidance provided by
17	the Commission. However, in saying that, we are an
18	order of magnitude below the actual threshold based on
19	core damage frequency instead of release frequency.
20	CHAIRMAN WALLIS: All these core damage
21	frequencies seem unlikely. Not very important core
22	damage doesn't lead to failure of containment and
23	there's no hurt to the public. Whereas, the things
24	you're screening out are the ones which are likely to
25	lead to containment failure.
	1

(202) 234-4433

	243
1	MEMBER CORRADINI: Just to become a
2	positive sort, if you get much below 10 ⁻⁸ you're
3	starting to approach geological events.
4	MEMBER KRESS: And when you screen out on
5	CDF you are also screening our LERF because LERF has
6	CDF as part of it.
7	MEMBER APOSTOLAKIS: No, I think
8	CHAIRMAN WALLIS: But it's certain events,
9	certain kinds of CDFs which lead to LERF. Right?
10	MEMBER APOSTOLAKIS: Graham is right. The
11	screening should be made on the basis of LERF, large
12	release.
13	MEMBER SIEBER: Yes.
14	MEMBER KRESS: I can do that by making the
15	CDF screen lower.
16	MEMBER APOSTOLAKIS: Yes.
17	MEMBER KRESS: But your screening, you're
18	basically screening on LERF at that level.
19	(Several speaking at once.)
20	MEMBER CORRADINI: At 10 ⁻⁸ .
21	MEMBER KRESS: Yes.
22	CHAIRMAN WALLIS: Location should be based
23	on LERF not on CDF.
24	MEMBER APOSTOLAKIS: It principally should
25	be based on LERF.

	244
1	VICE CHAIR SHACK: If you assume that the
2	conditional probability is one and you're 10^{-8} .
3	MEMBER KRESS: That's what I was saying.
4	Yes. Then you're screening on LERF.
5	VICE CHAIR SHACK: You're screening on
6	LERF.
7	MEMBER KRESS: Yes.
8	CHAIRMAN WALLIS: But not necessarily. It
9	seems to me that the things that you put in may not
10	lead to containment failure.
11	MEMBER CORRADINI: But I think what
12	they're saying though is at level of frequency it's so
13	bad that the probability of failure is one.
14	CHAIRMAN WALLIS: But then you end up with
15	an answer which is zero which doesn't really tell the
16	public anything.
17	MR. HUNTER: We're not going to do offsite
18	consequences for scenarios that don't produce a
19	release.
20	CHAIRMAN WALLIS: It might be a good idea
21	to make the connection with LERF at this point when
22	you're doing this and explain why this is okay.
23	MEMBER KRESS: That's almost obvious but
24	go ahead.
25	CHAIRMAN WALLIS: Well it's not obvious to

(202) 234-4433

	245
1	me.
2	MEMBER KRESS: Okay.
3	(Several speaking at once.)
4	MEMBER CORRADINI: But your worry is a
5	probability of one. Just assume that. It ain't going
6	to get any higher than one.
7	MEMBER KRESS: It could get close to one
8	for BWRs.
9	MEMBER CORRADINI: But what your worry is
10	is that above a sum probability what they might have
11	thrown out there is some sheltering by the containment
12	and you might have some ordering that would be
13	different than you would have it just on probability
14	if I understood your question because the containment
15	is some sort of filter where Bill's point is it's
16	not there anymore.
17	MEMBER APOSTOLAKIS: The dominant
18	contributors as to LERF are not necessarily the same
19	dominant contributors you see here.
20	CHAIRMAN WALLIS: Right. That's the
21	point.
22	MEMBER APOSTOLAKIS: That's really what it
23	is.
24	CHAIRMAN WALLIS: The dominant
25	contributors to individual risk are not necessarily

(202) 234-4433

	246
1	the same.
2	CHAIRMAN WALLIS: But the whole point of
3	the study is to look at the consequences to the
4	public.
5	MEMBER APOSTOLAKIS: And this is
6	conceptual, so you should really be doing it on LERF.
7	MR. HUNTER: Right. Our original guidance
8	was actually to look at all releases, to not base the
9	actual frequency on LERF. Now we're trying to lower
10	the thresholds of where we screen at.
11	CHAIRMAN WALLIS: But my message, the
12	question might be asked again.
13	MR. HUNTER: Understood.
14	CHAIRMAN WALLIS: Next time it might be
15	more serious.
16	MR. HUNTER: Understood. A threat.
17	MEMBER BONACA: We have need to move on.
18	MR. HUNTER: Let me just go over quickly
19	here. Once we have these sequences we're going to
20	group them together like I discussed earlier and then
21	basically what we're going to do is we're actually
22	going to evaluate the scenarios that either have a
23	core damage frequency cumulative based on whether they
24	are a group of scenarios or individual sequence.
25	We're going to look at the status of containment
	I contract of the second s

(202) 234-4433

1 cooling systems especially for the PWRs. We're going 2 to look at equipment recovery because station blackout 3 is a heavy contributor, the potential to recover the 4 diesels after core damage but prior to release and 5 other mitigation measures and we're also going to, we actually lower the screen threshold an order of 6 7 magnitude on the containment bypass scenarios just because they're going to have higher consequence type 8 9 So this just covers internal events. things. We also want to look at the IPEEEs to look 10 at what the dominant external scenarios are. 11 We're 12 also looking at there's 11 completed external event SPAR models that we're also looking and we're also 13 14 going to look at the IPEs when we don't have enhanced 15 SPAR models that are not available and the enhanced 16 SPAR models are the ones that have undergone the 17 recent benchmarking as the licensee PRA that Don just talked about. Then from that, we're going to actually 18 19 pick our scenarios that we're going to look at for 20 this study. 21 MEMBER CORRADINI: So just to summarize, 22 then the final boxes you're not going to have 1,000 or 23 maybe even 100. You may have a handful. 24 MR. HUNTER: Correct. 25 MEMBER CORRADINI: Okay.

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

247

	248
1	MEMBER APOSTOLAKIS: Hold on. You are
2	moving. Wait.
3	MR. HUNTER: I'm sorry.
4	MEMBER APOSTOLAKIS: Now the scenario
5	evaluation you say equipment, recovery and other
6	mitigation measures.
7	MR. HUNTER: Right.
8	MEMBER APOSTOLAKIS: Aren't these
9	inherently time dependent events?
10	MR. HUNTER: Correct. We're going to have
11	to look at each scenario differently.
12	MEMBER APOSTOLAKIS: Yes, and I'm sorry.
13	Go ahead.
14	MR. HUNTER: And in each plant differently
15	depending on whether we use a plant specific or group
16	specific approach when we're looking at them.
17	MEMBER APOSTOLAKIS: Right, and you will
18	need some probability that certain recovery actions
19	will be completed by a certain time.
20	MR. HUNTER: Correct. We're going to have
21	heavy HRA implications
22	MEMBER APOSTOLAKIS: And the agency HRA's
23	model does not consider time explicitly. You're in
24	trouble. You will have to switch to the EPRI HCR ORE
25	which you don't have.
	I

```
(202) 234-4433
```

	249
1	MR. HUNTER: Well, the current SPAR HRA
2	model does use time as a factor.
3	MEMBER APOSTOLAKIS: No. You'd better not
4	say that.
5	MR. HUNTER: No.
6	CHAIRMAN WALLIS: Do we want to get into
7	SPAR HRA now?
8	MEMBER APOSTOLAKIS: We are trying to
9	review it and nobody comes here to talk to us about
10	it. You will have a big problem there because the
11	available model to the agency does not consider time
12	explicitly.
13	MR. HUNTER: I don't know all the factors
14	into the HRA.
15	MEMBER APOSTOLAKIS: I do.
16	MR. HUNTER: I understand.
17	MEMBER APOSTOLAKIS: ATHENA does not.
18	SPAR HRA does not.
19	CHAIRMAN WALLIS: That's a take-away for
20	you.
21	MR. HUNTER: I will communicate that to
22	the folks that need to know that.
23	MEMBER APOSTOLAKIS: Good. The HRA folks.
24	MR. HUNTER: But yes. Correct. We have
25	HRA tasked to look at how we're going to go about
	I contraction of the second seco

```
(202) 234-4433
```

	250
1	this. We're actually going into a couple pilot plants
2	and actually look at their SAMGs and EDMGs to look at
3	what's proceduralized to try to determine what kind of
4	credit is appropriate for these type of actions.
5	MEMBER APOSTOLAKIS: We looked at the, we
6	not here, it was some other we, EPRI calculator. It's
7	actually not as bad as people say it is. It's
8	actually pretty good.
9	MEMBER BONACA: What people say it? I
10	thought it was good.
11	MEMBER APOSTOLAKIS: It's actually pretty
12	good. So something needs to happen there because I
13	don't think the agency has access to it.
14	MR. HUNTER: All right. This slide just
15	shows a couple technical issues that we're dealing
16	with as we speak. The first is the external event
17	scenarios. As you may be well aware, the IPEEE,
18	they're not full. They're not to the IPE quality.
19	Most of it is screening analysis. At least, 60 to 70
20	percent of the plants don't have seismic PRAs. They
21	are just screenings. So we're just trying to
22	determine how we're going to deal with the data
23	conservatisms and the limitations of the IPEEEs
24	because we don't want to just because our SPAR
25	models are relatively mature and the data has been

(202) 234-4433

251 1 updated throughout the years where we have 15 year old 2 data. CHAIRMAN WALLIS: Now does fire come into 3 4 this? 5 MR. HUNTER: Excuse me? 6 CHAIRMAN WALLIS: Does fire? 7 MR. HUNTER: Correct. Fire, seismic, 8 severe weather, flooding. 9 CHAIRMAN WALLIS: We know that fire 10 apparently with the assumptions that go into it can be as significant as the internal event. 11 Yes, and that's what we're 12 MR. HUNTER: trying to deal with is we have some plants with 13 14 internal events overall core damage frequency in the 15 EMIS6 but fire is in the EMIS5 range. So we're just 16 trying to determine is that EMIS5 number really 17 accurate because they weren't originally designed to do this. It was a screening methodology that they did 18 19 that and you're talking about old data and there's 20 been plant improvement since then. So the numbers 21 aren't probably accurate as of now. 22 But also just and the second bullet is an 23 aside bullet, just how we're going to treat the 24 external event numbers compared to --25 CHAIRMAN WALLIS: I'm trying to be

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433
	252
1	realistic. The whole point of this point is to be
2	more realistic than previous studies.
3	MR. HUNTER: Correct.
4	CHAIRMAN WALLIS: And then you need to be
5	more realistic about fires.
6	MEMBER APOSTOLAKIS: There is this major
7	EPRI/NRC project on fires.
8	MS. LAUR: That's right. 805.
9	MEMBER APOSTOLAKIS: You'll probably use
10	it.
11	MR. HUNTER: The last bullet just has to
12	do with the mitigation of release frequency
13	calculations and when we're talking about the HRAs,
14	the evaluation, the mitigation recovery actions for
15	scenario screening and to the Melcor but because of
16	the timing. And that sort of thing is going to be a
17	very important input to the Melcor calculations.
18	MEMBER APOSTOLAKIS: So when you are
19	discussing all this you are planning to do things
20	here, do you have other groups within the agency
21	participate? Like the HRA people, are they aware you
22	are doing this?
23	MR. HUNTER: Yes. The HRA, we have HR
24	people with Sandia and inside the NRC are aiding us.
25	So they're actually starting to get involved into our
1	I contraction of the second seco

(202) 234-4433

ĺ	253
1	scenario section. We're not exactly right there yet,
2	but we're almost there for our first group of plants.
3	So they are heavily involved now and we're going to
4	moving forward working together to determine these
5	type of things because it's going to affect both the
6	Melcor calculations and the actual, because we're
7	going to have to eventually calculate the release
8	frequency of these scenarios because we only have the
9	core damage frequency.
10	MEMBER APOSTOLAKIS: So you plan to do
11	this in three years for all the units? This is
12	incredible to me.
13	MR. HUNTER: Right.
14	MEMBER BONACA: This is just one piece of
15	it because there is additional work that they haven't
16	described yet like development of the tool.
17	CHAIRMAN WALLIS: George, if you can
18	graduate a student in three years, they can do this
19	work in three years.
20	MEMBER APOSTOLAKIS: No really. I mean
21	you are revisiting the PRA, Level 3 PRA, and you're
22	saying in three years not only are we going to
23	implement the new tools but we're going to apply it to
24	every unit and I think that's just not realistic.
25	MR. SCHAPEROW: The source term estimates
	1

(202) 234-4433

	254
1	are going to be made I guess first of all, from the
2	Level 1 work we're going to basically pick a, we're
3	going to end up with a couple of scenarios for each
4	plant design which we've identified about seven or
5	eight plant designs. For each of those plant designs,
6	we're going to be doing a source term estimate for
7	those designs.
8	MEMBER APOSTOLAKIS: Are you going to use
9	11.50 at all?
10	MR. SCHAPEROW: No.
11	MEMBER APOSTOLAKIS: Why not?
12	MR. HUNTER: What we plan to do as part of
13	1150 is we're actually going to look at the scenarios
14	that 1150 analyzed and determined why aren't those
15	scenarios above our threshold and we would either
16	determine if we should be including them or we have a
17	solid basis for not including them. For example, that
18	ATLAS is not really showing up as a high dominant
19	contributor in the SPAR models. So that would be one
20	example of a scenario where we'd either determine that
21	it wasn't the frequency of the ATLAS event is a lot
22	lower since NUREG 1150 or we would determine that
23	maybe our calculations are off or something to go back
24	or maybe our modeling of those type of events are
25	wrong. And we're going to use NUREG 1150 as a guide

(202) 234-4433

	255
1	for our scenarios, but it's also for the reporting to
2	justify why we don't analyze certain scenarios.
3	MEMBER BONACA: Now NUREG CR 2239, the
4	Siting Study, used a different approach and goal just
5	to certain scenarios. You know one of the clear
6	objectives is the one of encouraging the use of this
7	new information for the public rather than the Sandia
8	Site Study. But if the results are comparable, how
9	you may state your case, I mean, these are just
10	individual scenarios you're addressing. You're saying
11	they are dominant.
12	MR. ELTAWILA: I think that part of our
13	job and we would like your help in that about how to
14	communicate this information to the public. One of
15	our jobs is to try to, as Chris indicated, we look at
16	NUREG 1150 and we are going to look at the Sandia
17	Siting Study and we have excluded any scenario. We
18	have to provide the basis why we exclude that
19	scenario, scientific basis, improvement in plant
20	performance, improvement in emergency management,
21	improvement of the tools and data and so on. So we
22	will have to provide this information and that will be
23	part of our deliverable to the Commission.
24	MEMBER BONACA: That's what I was
25	thinking. I mean this is a significant task that you
	1

(202) 234-4433

	256
1	have to fulfill for all these plants.
2	MEMBER APOSTOLAKIS: Yes, I don't think it
3	can be done in three years.
4	CHAIRMAN WALLIS: Ask them to show us. We
5	all know. We're going to have subcommittee meetings.
6	We're going to see the progress and we'll be able to
7	tell whether it's realistic or not after six months or
8	so.
9	MR. ELTAWILA: Okay.
10	CHAIRMAN WALLIS: At least it's a good
11	thing to try to do.
12	MEMBER SIEBER: Are you going to do
13	anything with shutdown operations?
14	MR. HUNTER: Currently, no. The maturity
15	of our low power shutdown SPAR models is pretty
16	They are being created as we speak. We don't have a
17	lot of information on it. Right now, we are just
18	looking at at-power conditions.
19	MR. SCHAPEROW: This slide lists a few of
20	the accident progression issues that we will be
21	handling in this project. We'll be dealing with.
22	There are other ones. I just picked a couple to just
23	kind of give an overview of what kinds of issues we'll
24	be handling.
25	CHAIRMAN WALLIS: Haven't they improved
	1

(202) 234-4433

ĺ	257
1	seals to the point where this is much less likely now?
2	MR. SCHAPEROW: My understanding is that
3	the Westinghouse plants basically all have the newer
4	seal packages in them maybe with the exception of one
5	pump at one plant. But this issue involves very high
6	temperatures. I mean during core melt you get
7	extremely high gas temperatures in the RCS. So I
8	think there still is an open issue on that and we're
9	going to have to look into that.
10	And again the issue deals with very high
11	temperatures, maybe a high seal leak rate at some
12	point on the order of 100/200 GMP type of leak rates.
13	This is important because if you were in a boil off
14	scenario you're now at a loca and you're starting to
15	lose inventory quickly. It can also affect the timing
16	of lower head failure and as well as the challenge to
17	the hot leg, the high temperature challenge to the hot
18	leg, surge line and steam generator tubes.
19	For the BWR scenarios that don't have DC
20	power so that the relief valve is basically operating
21	on the spring, the relief valves will open and close
22	to relieve pressure. If the relief valve does stick
23	open at some point possibly due to very high
24	temperatures during the core melt, very high
25	temperature gases, then it can seize in the open
	I

(202) 234-4433

	258
1	position and depressurize the RCS.
2	And this would turn high pressure scenario
3	again into a low pressure scenario. The problem with
4	this is though is the low pressure in the RCS you
5	basically would lose a lot of your convective heat
6	transfer away from the core, the melting core. So you
7	would make a quicker lower head failure. It may speed
8	it up by a couple of hours.
9	And the third point I have here is we were
10	going to be
11	VICE CHAIR SHACK: What scenarios wouldn't
12	a BWR depressurize and be dumping water in?
13	MR. SCHAPEROW: I'm sorry. Can you
14	VICE CHAIR SHACK: Wouldn't the BWR always
15	be depressurized unless the depressurization system
16	fails?
17	MR. SCHAPEROW: Yes. The idea here is you
18	don't have DC power. In some of the sequences we've
19	examined, we don't have power. We don't have DC
20	power. So we don't have We can't operate that
21	valve. It just opens when the pressure gets high and
22	the spring opens it.
23	Finally on containment failure, we are
24	going to consider the data from the Sandia tests on
25	containment failure to try to get a better handle on

(202) 234-4433

1 the size and the location of the containment failure 2 because this is of course a direct impact on source 3 term. If the containment fails a lot earlier, then 4 your release is going to be a lot earlier. If the 5 containment happens to start leaking in the aux building, then the release is going to start later and 6 7 it's going to have to go through the aux building 8 before it gets out which is a potential reduction in 9 the release. 10 MEMBER CORRADINI: Can I ask a question here? 11 12 MR. SCHAPEROW: Sure. So do you have any 13 MEMBER CORRADINI: 14 indication that if you carried this out as an 15 experiment on one type of reactor containment location set compared to what was done 25 years there is a 16 17 significant difference? Do you have any empirical data that you would actually find a difference? 18 19 MR. ELTAWILA: Professor Eltawila. The 20 answer is yes. We have an information. We have done 21 analysis which shows that for the type of plants that 22 you are talking about and the containment there have 23 been significant improvement in the consequences of 24 some of the severe accidents. To give you an example, 25 cite you an example, you know that we took to

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

259

260 advantage for the work that was done about steam explosion. You don't have alpha mode (PH) explosion which was a major contributor to the early fatalities in the 1980s. Right now, we can take advantage of that and say containment will not fail as a result of alpha mode failure of containment. So you can see a difference and we can quantify that difference. MEMBER KRESS: Along that same line with all your screening and truncations and the picking grouping scenarios and ending up with a small number and leaving out parts like IPEEE and not seeing HR correctly, you're going to end up with all sorts of questions. One way to address those would be to take one of the plants and do a full PRA, put everything in it and see what difference you get. Is that part of the plan? It wouldn't take too much effort to do at least one or maybe four. It depends on what kind of _ _ VICE CHAIR SHACK: Maybe five. MEMBER CORRADINI: I think what Tom is asking is kind of where I was going to is that then --

22 What I'm worried about is because I think what you're 23 doing, personally I think what you're doing is 24 important, but you could open yourself up from 25 criticism because they say you selectively picked the

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

	261
1	things that make it look better than it really is and
2	what Tom is asking is have you done something like an
3	orthogonal analysis that says "No, when I did a
4	complete analysis, then I got still some sort of
5	improvement." I think that's what you're after.
6	MEMBER KRESS: Yes, that's exactly it.
7	CHAIRMAN WALLIS: Then you might also see
8	the LERF contributors.
9	MEMBER KRESS: Yes.
10	MEMBER APOSTOLAKIS: Or at least identify
11	the main contributors.
12	MS. LAUR: Now we are going to keep the
13	information as we progress through and look at the
14	scenarios. That information isn't lost and as we go
15	through and starting doing the first number of plants
16	there could be insights that we gain that cause us to
17	go back and rethink the approach. But we have to get
18	it started and see what is the information telling us.
19	VICE CHAIR SHACK: I mean you do have
20	1150, too. I mean if you're not directly using 1150
21	it's certainly a much better basis of comparison than
22	the siting study.
23	MS. LAUR: That's correct.
24	MR. NOUBRAKHSH: Just for your
25	information, PNL did limited studies using insights
l	I

(202) 234-4433

	262
1	from NUREG 1150 and did some sensitivity of important
2	sighting parameters.
3	CHAIRMAN WALLIS: And would you please
4	give your name?
5	MR. NOUBRAKHSH: And this is NUREG CR 6295
6	and actually we looked at dominant accident
7	progression beings and we looked at the timing, not
8	CDF because sometimes And then we compared the
9	release frequency actually a dominant sequence at
10	different frequencies, dominant sequences matched the
11	frequency sequence curve scale blindly. We picked up
12	the scenarios and then later it was matched, kind of
13	very similar to
14	MEMBER APOSTOLAKIS: What did you
15	conclude, Hossein?
16	MR. NOUBRAKHSH: The conclusion was first
17	of all the sourcing as Farouk said the things have
18	changed as far as frequency of releases so that the
19	risk is going to be changed essentially compared to
20	Sandia Siting Studies. But what I wanted to say is in
21	order to add this to uncertainties we picked up the
22	mean values of the source and from NUREG 1150 because
23	some of these source terms are seven order of
24	magnitude and using a Melcor justification for single
25	value may be difficult.

(202) 234-4433

	263
1	MEMBER KRESS: What was that NUREG number
2	again?
3	MR. NOUBRAKHSH: 6295.
4	MEMBER APOSTOLAKIS: Is the motivation
5	behind
6	CHAIRMAN WALLIS: Hossein, you have to
7	give your name when you speak.
8	MR. NOUBRAKHSH: Hossein Noubrakhsh, ACRS
9	staff.
10	CHAIRMAN WALLIS: Hossein Noubrakhsh, did
11	you get that?
12	MEMBER APOSTOLAKIS: So is the motivation
13	behind the SRM the fact as I recall the Sandia study
14	of `82 has been misused and abused by outside groups?
15	MS. LAUR: That's part of the motivation
16	and so that's why the focus is what it is. The `82
17	study had a value at that time. One could view it as
18	kind of a bounding analysis, worst case kind of
19	analysis.
20	MEMBER APOSTOLAKIS: Okay.
21	MS. LAUR: What we hope to achieve here is
22	to give ourselves and the public a better
23	understanding of what their offsite consequences would
24	be for realistic type scenarios.
25	MEMBER APOSTOLAKIS: So motivation was not
1	I contract of the second se

```
(202) 234-4433
```

	264
1	to improve on the PRA or getting the Level 3 results.
2	MS. LAUR: No.
3	MEMBER APOSTOLAKIS: Although you are, you
4	will.
5	MS. LAUR: Right. That's the correct
6	understanding of the motivation.
7	MEMBER APOSTOLAKIS: Because after all,
8	Dr. Kress was right. That's what really matters to
9	the public. Right? The results of the Level 3.
10	CHAIRMAN WALLIS: Of course.
11	MEMBER APOSTOLAKIS: Not the core damage
12	frequency.
13	CHAIRMAN WALLIS: Of course.
14	MEMBER APOSTOLAKIS: This gentleman wants
15	to say something.
16	MR. CANAVAN: Ken Canavan, EPRI. Just two
17	quick comments. The first one is HRA calculator is an
18	excellent tool.
19	(Laughter.)
20	MR. CANAVAN: If you have any questions,
21	come see us.
22	MEMBER APOSTOLAKIS: Why don't you give it
23	to the agency?
24	MR. CANAVAN: I believe that we were
25	discussing how to do that at some point.
	I contract of the second se

```
(202) 234-4433
```

	265
1	MEMBER APOSTOLAKIS: I am convinced that
2	the HRA people, they don't know what the other side is
3	doing. In other words, you have people here working
4	on HRA models and they really don't know the details
5	of what you guys are doing and vice versa. We had a
6	subcommittee meeting in December and it was confirmed.
7	MEMBER BONACA: Reached that conclusion by
8	now.
9	MEMBER APOSTOLAKIS: And I reached that
10	conclusion because I spent time learning what they are
11	doing and I'm now very positive.
12	CHAIRMAN WALLIS: While you can have a
13	subcommittee, George
14	MEMBER APOSTOLAKIS: I am wrong. I admit
15	it.
16	(Laughter.)
17	MEMBER APOSTOLAKIS: What do you do?
18	CHAIRMAN WALLIS: You can have a
19	subcommittee meeting where they're both in the same
20	room and they have to talk to each other.
21	MEMBER APOSTOLAKIS: They talk but they
22	don't listen.
23	(Laughter.)
24	MEMBER BONACA: This poor gentleman here
25	is trying to tell us something and it
	1

```
(202) 234-4433
```

Í	266
1	MEMBER APOSTOLAKIS: Well, why should we
2	let him? If he wants to.
3	MR. CANAVAN: My second comment was along
4	the same lines as perhaps the HRA which was a lot of
5	this information for example from the Level 1 current
6	PRAs of the existing units have plant damage dates
7	which are binned accident classes. So a lot of this
8	screening work that you're talking already sort of
9	exists, at least at the sites and I know we're meeting
10	tomorrow. So maybe we'll be discussing some more of
11	this.
12	But the other part, scenario grouping, so
13	much of this is probably already available from a
14	willing site if they are willing to donate it and the
15	second part, so boxes on the left-hand side of your
16	diagram are probably complete at many sites and then
17	the next part was on the containment of failure modes
18	and characteristic size and locations. A lot of
19	sites, almost all, have a Level 2 or at least a LERF
20	analysis which would indicate for those plant damage
21	dates what failure modes and locations were analyzed.
22	So that information is available as well again from a
23	willing site.
24	MEMBER APOSTOLAKIS: So maybe it can be
25	done in three years. That's what you're saying.

(202) 234-4433

	267
1	MR. CANAVAN: So maybe it can be done in
2	three years if you don't redo it.
3	MEMBER APOSTOLAKIS: You mean if the ACRS
4	doesn't redo it?
5	MR. CANAVAN: No, I mean if the staff
6	doesn't redo it into independently.
7	MS. LAUR: As I indicated in the
8	beginning, we are very interested in engaging with to
9	work together and get the information that's necessary
10	so that we can move this project successfully forward.
11	CHAIRMAN WALLIS: I'm really waiting to
12	I've heard this presentation before. This is what
13	you're going to do.
14	MS. LAUR: Right.
15	CHAIRMAN WALLIS: What would really be the
16	test is when you start to get results and can show
17	them.
18	MS. LAUR: That's right.
19	CHAIRMAN WALLIS: So we're really looking
20	forward to that.
21	MS. LAUR: We actually have
22	MEMBER APOSTOLAKIS: Same thing on the
23	methodology. That's when we should give you more.
24	MS. LAUR: We actually have some progress
25	that we'll share with you shortly.

```
(202) 234-4433
```

	268
1	MEMBER APOSTOLAKIS: Good. You have what?
2	MS. LAUR: Progress that a little bit of
3	progress, not results, just some progress.
4	MEMBER APOSTOLAKIS: Great.
5	MR. SCHAPEROW: To form the consequence
6	analysis, we are going to use the source terms that
7	we're going to generate through Melcor analysis. We
8	use source terms for each plant group. Again this is
9	a departure from the earlier Sandia Siting Study.
10	They had one source term for everybody. So for
11	example, for the Westinghouse four-loop and three-loop
12	plants, we're probably going to consider that one
13	plant group and we'll analyze that. We'll pick one
14	plant. We'll model that in lots of detail and we'll
15	estimate source terms for the dominant sequences.
16	To do the consequence analysis we need to
17	consider site specific factors because we're going to
18	be doing an analysis for each plant. So we're going
19	to do an evaluation for each plant and what the
20	emergency response is going to be.
21	MEMBER CORRADINI: Can I ask about it?
22	You just said something that sounds like a little
23	thing but you're going to scale it on thermal power I
24	assume at least.
25	MR. SCHAPEROW: Correct.
	I contract of the second s

(202) 234-4433

	269
1	MEMBER CORRADINI: Okay. Fine.
2	MR. SCHAPEROW: thermal power, actually
3	some plants have much lower. I think some of the
4	older Mark 1s have only half the thermal power of the
5	newer ones. So that's important.
6	MEMBER SIEBER: That's today.
7	MR. SCHAPEROW: Also we need to consider
8	burn-up. Are we going to do one halfway through the
9	fuel cycle, the beginning of the cycle and so on?
10	We'll consider these issues certainly.
11	CHAIRMAN WALLIS: So they are all scaled
12	by the same CDF although some of them have many more
13	inventory. Right?
14	MEMBER SIEBER: Right.
15	MEMBER KRESS: I don't know how you scale
16	the thermal power because you're actually looking for
17	a source term to be a fraction of the inventory and
18	you can't just say the inventory's ratio to the power
19	and you can't say this fraction is ratio to the power.
20	I don't know exactly how you I understand that the
21	smaller reactor have different inventories and will
22	have different source terms, but it would be tough to
23	make that scaling definitive I think.
24	MEMBER SIEBER: They ought to really be
25	scaling by core volume.

(202) 234-4433

	270
1	MR. SCHAPEROW: The site specific factors
2	that we're going to be considering include emergency
3	response. We'll be looking at each site to see what
4	we feel, to estimate what their evacuation time and
5	speed is going to be. We're going to be using the
6	latest population distribution numbers we have which
7	is 2000 Census data.
8	CHAIRMAN WALLIS: What do you do about how
9	well the emergency response actually works? I know
10	how it's supposed to work.
11	MS. LAUR: We have folks
12	CHAIRMAN WALLIS: Do you have any good
13	idea about how well it's going to work?
14	MR. SCHAPEROW: Yes. One of the members
15	of our team is an emergency preparedness specialist.
16	He's probably better to address that than I can and
17	unfortunately he's not here today. So I would like to
18	punt on that for now.
19	MEMBER APOSTOLAKIS: But PRAs in general,
20	my impression is that failure to evacuate is not taken
21	into account. It's an outside input. Right?
22	MEMBER SIEBER: Every plant has an
23	evacuation
24	MEMBER APOSTOLAKIS: It's an input to the
25	analysis and so in so much time so many people have

(202) 234-4433

	271
1	been evacuated. There is no uncertainty.
2	MEMBER KRESS: And that's site specific.
3	MEMBER APOSTOLAKIS: Yes, but I mean it's
4	deterministic.
5	MEMBER KRESS: Yes.
6	MR. SCHAPEROW: I can tell you what I read
7	recently. There was some analysis published for
8	Indian Point which showed that after an hour people
9	started evacuating and then after like nine hours
10	everybody is going to be out of the zone and it's kind
11	of curve.
12	CHAIRMAN WALLIS: This is one of the
13	biggest public concerns.
14	(Several speaking at once.)
15	MR. SCHAPEROW: Yes.
16	CHAIRMAN WALLIS: This is one of the
17	biggest public concerns you hear at public meetings is
18	that the emergency response plan isn't very reflective
19	of what will actually happen. I think that if you're
20	going to respond to public concerns you may need to
21	put some effort into making emergency response
22	evaluation realistic. I don't know how you're going
23	to do it but it is a public concern that we hear
24	about.
25	MEMBER APOSTOLAKIS: I don't know what it
1	

(202) 234-4433

ĺ	272
1	means to make it realistic. I mean it's intended to
2	be realistic. You can do some sensitivity analysis
3	what if we don't evaluate 1,000 and we evaluate 900.
4	MEMBER KRESS: I think the results you're
5	going to get for the consequences will be very
6	sensitive to the assumptions on evaluation. I mean
7	that's one of the more sensitive.
8	CHAIRMAN WALLIS: We went to Vermont
9	Yankee and there were people who stood up in the
10	audience and said "I'm not going to leave."
11	MEMBER SIEBER: Yes.
12	MEMBER CORRADINI: Sounds like somebody
13	from Vermont.
14	MS. LAUR: And we recognize
15	MEMBER APOSTOLAKIS: I'm not going to
16	leave. Protect me.
17	MS. LAUR: We recognize this is a very
18	important part of this analysis and that's why we do
19	have an expert both on our side of the house and on
20	the Sandia so that we try to accurately model
21	evacuation.
22	MR. SCHAPEROW: The other two other site
23	specific factors we're going to including are weather
24	data and shielding factors and that's about it.
25	VICE CHAIR SHACK: And you're going to
	1

(202) 234-4433

	273
1	compute all sorts of consequences. Right? Land
2	contamination, everything that comes out of MACCS.
3	Right?
4	MEMBER SIEBER: No.
5	MR. SCHAPEROW: Well, we do intend to look
6	at prompt fatalities. We're going to compute latent
7	and cancer fatalities. The issue of land
8	contamination is one we're going to have to look into
9	a little more.
10	MR. ELTAWILA: We are not planning at this
11	time to look at land contamination.
12	MEMBER KRESS: But that's the dominant
13	consequence.
14	CHAIRMAN WALLIS: You're just following
15	the QHOs, aren't you?
16	MR. ELTAWILA: Following the QHOs.
17	VICE CHAIR SHACK: It's part of your reg
18	analysis we look at all these costs. I mean when I do
19	a SAMA I look at everything. Why not do it here?
20	MEMBER KRESS: But you're going to use
21	MACCS for this thing. It's just like a little tiny
22	increment to get these land consequence and the total
23	number of deaths out of it. I mean I don't understand
24	why you don't go ahead and get that because the extra
25	effort is just minuscule.
	1

(202) 234-4433

	274
1	MEMBER APOSTOLAKIS: Maybe the Commission
2	is not interested.
3	MEMBER KRESS: I understand.
4	MEMBER BONACA: I guess the focus is the
5	siting study and there was no equivalent calculation
6	done for that. I agree that they could pull out the
7	data, but I think it probably would focus the results
8	of the study totally in a different direction than
9	what is intended by the Commission.
10	MEMBER KRESS: I don't know what they
11	intended.
12	MS. LAUR: Just in case there's any
13	concern that there won't be a lot of interaction
14	between ourselves and you and others this slide just
15	lets you know that there is lots of opportunity to
16	help us along the way. We are having frequent
17	meetings with our steering committee. We have
18	representatives from all three.
19	MEMBER APOSTOLAKIS: Steering committee is
20	internal?
21	MS. LAUR: The steering committee is
22	internal. We have a representative from Research,
23	ENSER and NRR. It's Jim Wiggins. Let's see. It was
24	Bill Orchard, but Bill Deal will be replacing him and
25	Gary Hollahan.
	1

(202) 234-4433

MEMBER APOSTOLAKIS: How will you be getting industry input throughout the meetings? MS. LAUR: The industry input will be through public meetings that we're going to start with tomorrow, workshops as well. So there's going to be a lot of interaction both internally and externally to get the information we need. MR. SCHAPEROW: We've already had a little

275

9 bit of initial input as we've had some meetings to 10 look at the code modeling. We've had both laboratory and in industry experts there to go through the 11 12 modeling.

MEMBER APOSTOLAKIS: 13 But as you progress 14 and you derive results for individual units, are you 15 going to go back to the licensee and see whether they 16 agree or disagree or whatever? That's what the SPAR 17 models did. Right? They went back and they said "Okay, here is the model we have for your unit. 18 What 19 do you guys think?" And they pulled out their PRA and 20 there was some give and take and there was some 21 consensus at the end.

22 MS. LAUR: You know we haven't really 23 thought through exactly what point in the project 24 we're going to engage all the stakeholders. But we do 25 through the process to engage all the plan

> **NEAL R. GROSS** COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

3

4

5

6

7

8

276 1 stakeholders, not just industry, but any public that's interested in this project. 2 I understand the 3 MEMBER APOSTOLAKIS: 4 public meetings. I mean somebody comes in there and 5 listens and expressed views. What I'm talking about is a much more serious interaction where you tell the 6 7 quy "Look. This is what we're getting for your plant. 8 What do you think?" And you give those people some 9 time to review what you have done so that they will 10 pass judgment. I mean I have participated in numerous review committees and some they send you three volumes 11 the day before and others you have plenty of time to 12 review them and do a good job. 13 14 MS. LAUR: I mean we envision that we will have that level of interaction. 15 You will. 16 MEMBER APOSTOLAKIS: Tt's 17 inevitable because the industry will be up in arms if you start surprising them. 18 19 MS. LAUR: It's always better to include 20 people up front. 21 MEMBER APOSTOLAKIS: There you are. 22 That's a truism. 23 CHAIRMAN WALLIS: While you're planning 24 all these meetings make sure you leave time to do the

NEAL R. GROSS

25 work.

(202) 234-4433

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701 (202) 234-4433

	277
1	(Laughter.)
2	MS. LAUR: Tell me about it.
3	MEMBER APOSTOLAKIS: No, I'm sure the
4	industry will be very much interested in this and you
5	certainly don't want to surprise anybody.
6	MS. LAUR: I know we're running out of
7	time here. Just to give you a flavor of where we are
8	on the project some of this is pre-decisional. That's
9	why you don't see the sub-bullets. But we have picked
10	the first six plants that we're going to analyze.
11	That information is being sent up through our
12	management chain to make sure that it's acceptable and
13	as soon as that has occurred, we will be glad to share
14	that information with you.
15	We have identified what we believe to be
16	the scenarios of interest for the initial runs for the
17	GE 4, BWR, Mark 1s and the Westinghouse four-loop
18	large drives and as Jason shared with you, we had a
19	week long meeting in Albuquerque where we had experts
20	come and talk to us regarding the use of the Melcore
21	and MACCS codes as to the appropriateness for this
22	project and what enhancements might be useful.
23	MEMBER APOSTOLAKIS: So you actually have
24	something to show us.
25	MS. LAUR: Yes. As far as next steps,
	1

(202) 234-4433

1 clearly we want to get started on the analysis and so 2 we are moving forward to try to begin the Melcore runs 3 on those first six plants. While we have chosen the 4 scenarios for those plants, it was based on the internal events SPAR model. 5 So we are quickly 6 investigating what the external events, what the 7 impacts would be on the selection for the scenarios. We're also looking at those post accident operator 8 9 actions and determining how they will impact the scenario selection. 10

Also any credit that might be given for available equipment that could be used to delay core melt and offsite consequences, we're investigating that and how it will influence the analysis and we're taking those recommendations that came out of that week long meeting in Albuquerque and trying to look at how we might revise the Melcor analysis.

We're going to continue on in the process. While we're starting the Melcor runs on those first six plants, we will then begin looking at the SPAR models for the other plants to try to determine what scenarios would be appropriate for those plants and then hopefully we will begin the MACCS runs on the first six plants shortly thereafter.

As George has pointed out, we have a lot

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

25

	279
1	to do in three years and we will be engaging you and
2	others as we go through this process.
3	MEMBER APOSTOLAKIS: It seems to me we
4	should have a subcommittee meeting soon.
5	CHAIRMAN WALLIS: Yes. Thank you very
6	much.
7	MS. LAUR: Thank you.
8	MEMBER KRESS: Very good, Michele.
9	MEMBER APOSTOLAKIS: Very good.
10	MEMBER BONACA: Any more questions? If
11	not, then
12	MEMBER APOSTOLAKIS: In ten years,
13	everybody will be doing Level 3 PRAs.
14	CHAIRMAN WALLIS: I would like to move
15	onto the next item on the agenda. The next part of
16	the meeting is going to be closed. I want to make
17	sure that those who have no business being here are
18	not here. Discuss security matters. I'm afraid the
19	new members have to leave, the four new members we
20	have this year. Off the record to go to a closed
21	session.
22	(Whereupon, at 4:29 p.m., the above
23	entitled matter recessed.)
24	
25	
	I contraction of the second