

July 30, 1997

SECY-97-168

FOR: The Commissioners

FROM: L. Joseph Callan /s/  
Executive Director for Operations

SUBJECT: ISSUANCE FOR PUBLIC COMMENT OF PROPOSED RULEMAKING  
PACKAGE  
FOR SHUTDOWN AND FUEL STORAGE POOL OPERATION

PURPOSE:

This paper informs the Commission of the staff's intent to re-issue for public comment a proposed rulemaking package addressing shutdown and fuel storage pool operations at nuclear power plants.

BACKGROUND:

In SECY-94-176, the staff sought Commission approval to issue for public comment a proposed rule for shutdown and low-power operation at nuclear power plants. The Commission approved the request in the staff requirements memorandum dated September 12, 1994, and the proposed rule was published in the Federal Register in October 1994. The numerous comments received were considered along with Commission guidance regarding the use of a risk-informed, performance-based approach for new regulations. As a result, the staff made significant changes to the proposed rule and regulatory analysis. In addition, the staff's studies of spent fuel storage pool operations led to a decision to encompass spent fuel storage pool operations in the revised rule. Therefore, the staff intends to again issue the rulemaking package for public comment.

DISCUSSION:

The staff's revised regulatory analysis considered important safety functions and the controls currently in place to ensure these functions. For low-power operation, hot shutdown, and the transition period from hot to cold shutdown, the revised analysis concludes that for these periods important safety functions are protected by existing requirements in standard technical

specifications. Accordingly, the revised proposed rule no longer addresses these modes.

CONTACT: Timothy Collins, NRR  
415-2897

For the balance of shutdown operations (cold shutdown and refueling modes), the regulatory analysis shows that the proposed rule provides a substantial increase in the overall protection to public health and safety, and that the costs of the proposed rule are justified in view of the increased protection afforded by the backfit. The analysis found that current controls have evolved through a series of NRC and industry actions initiated for the most part through NRC generic communications. Although these initiatives have been successful in achieving the acceptable level of risk that now exists at U.S. nuclear power plants, the analysis showed that a significant level of safety is dependent upon measures that are not traceable to specific underlying regulations, and that could, therefore, be withdrawn by licensees without prior staff approval. The practical effect of rule implementation is, therefore, not to raise the current level of safety, but rather to ensure that at least the current level of safety will be maintained. This action is considered necessary to preclude a withdrawal from current practice in light of continuing economic pressure to increase plant availability through shortened outages.

The Committee to Review Generic Requirements (CRGR) reviewed the revised proposed rule, statement of considerations, regulatory guide, and regulatory analysis and sent its comments to the staff on June 12, 1997. The staff incorporated CRGR comments in the enclosed rulemaking package. The staff briefed the Advisory Committee on Reactor Safeguards (ACRS) on the status of the rulemaking package in May 1996. The ACRS sent its comments to the staff on June 4, 1996, indicating the ACRS plan to comment again on the proposed final rule after reconciliation of public comments. The staff plans to develop inspection and enforcement guidance for the proposed rule during the public comment period.

#### SUMMARY OF THE RULE:

The proposed rule consists of three parts: (1) shutdown operations, (2)

fire protection, and (3) spent fuel storage pool operations. The overall objective of the rule is to establish a clear, flexible, risk-informed, and enforceable regulatory framework for assuring that cold shutdown, refueling, and fuel (storage) pool operations continue to be conducted in a safe manner. Although a shutdown probabilistic risk assessment (PRA) is not required, the rule is written in a fashion that allows licensees to enhance operational flexibility by the use of state-of-the-art PRA methods as a complement to traditional deterministic analyses provided that defense-in-depth considerations are also addressed.

### Shutdown Operations

The shutdown operations section of the rule has been structured with the specific objectives of: (1) reducing the frequency of events that can lead to loss of the decay heat removal function, (2) assuring that mitigative equipment is available for those events that do occur, (3) providing a measure of performance through monitoring of parameters that represent necessary safety functions, and (4) facilitating inspection and enforcement activities.

These goals are to be achieved through a combination of procedural, monitoring, and mitigation capability requirements.

The proposed rule would require licensees to establish and implement procedures for training, quality assurance, and corrective actions to ensure that the safety functions of decay heat removal, inventory control, and pressure control are maintained and monitored, and that mitigation capability is provided.

The procedures would be described in the administrative controls section of the technical specifications. This would establish a clear regulatory requirement while allowing licensees flexibility in terms of implementing these programs.

The proposed rule would also require licensees to monitor safety function performance and prescribes limits for each safety function. Licensees would choose the specific parameters, parameter limits and instrumentation to be used to demonstrate compliance with the safety function limits. These details would have to be maintained available for inspection in a

licensee-controlled document. The criteria and methods used for selecting the parameters and parameter limits, however, would have to be described in the administrative controls section of the technical specifications.

The proposed rule further requires that mitigative equipment be maintained available to ensure core cooling and decay heat removal, and to protect against the uncontrolled release of fission products in the event of loss of the operating decay heat removal system. The specific equipment to be credited at any time in the outage would be under licensee control, but would need to be documented and available for inspection. Criteria and methods for selecting equipment would have to be described in the administrative controls section of the technical specifications.

#### Fire Protection

This part of the rule is intended to extend the fire protection provisions already provided during power operation to shutdown operation. The proposed rule would require licensees to implement measures to minimize the frequency of fires during shutdown operations. It would also require that the decay heat removal function be maintained free of fire damage, or that fire damage be limited by promptly detecting, controlling, and extinguishing fires that do occur. It would further require that contingency plans be developed to ensure adequate core cooling and restoration of decay heat removal following a fire. The provisions necessary for implementation would have to be documented in the licensee's fire protection plan.

#### Fuel Storage Pool Operations

The objective of the fuel storage pool portion of the rulemaking is to establish clearly defined regulatory controls for current operational practices in spent fuel storage pools and to facilitate inspection and enforcement.

In the portion of the rule that deals with fuel storage pool operations, licensees would be required to: (1) document in their facility's safety analysis report the current design bases for removing decay heat from the pool, and (2) ensure that operational limits derived from those bases are incorporated into operating procedures.

## Conforming Changes

In addition, conforming changes would be made to other regulations in support of the shutdown operation requirements of 50.67. The most significant of these are: (1) adding the structures, systems, and components necessary for compliance with the shutdown operation requirements of 50.67 to the maintenance rule ( 50.65) and the license renewal rule (10 CFR Part 54), (2) providing for notification and submitting reports to the NRC, in accordance with 50.72 and 50.73, of any event that results in actuation of the mitigation equipment, and (3) adding a definition of shutdown operations to 50.2, which makes it clear that normal operation includes shutdown operation.

The proposed rule is provided in Attachment 1, the statement of considerations in Attachment 2, the regulatory analysis in Attachment 3, and the regulatory guide in Attachment 4.

## Coordination

The Office of the General Counsel has no legal objection to this Commission paper.

## RECOMMENDATION:

The staff recommends that the Commission note that the staff will proceed to have the proposed rule and the associated statement of consideration published in the Federal Register unless otherwise instructed by the Commission.

L. Joseph Callan

Executive Director

for Operations

## Attachments:

1. Shutdown and Fuel Storage Pool Operations at

- Nuclear Power Plants
2. Statement of Considerations
  3. Regulatory Analysis for the Proposed Regulation 50.67
  4. Draft Regulatory Guide DG-1066

[7590-01-P]

NUCLEAR REGULATORY COMMISSION

10 CFR Parts 50 and 54

RIN 3150-AE97

Shutdown and Fuel Storage Pool Operations at Nuclear Power Plants

AGENCY: Nuclear Regulatory Commission

ACTION: Proposed rule

SUMMARY: The Nuclear Regulatory Commission (NRC) is proposing to amend its regulations pertaining to the operation of commercial nuclear power plants for shutdown operation and fuel storage pool operation. The proposed rule would require licensees to establish parameter limits for certain safety functions defined in the proposed rule, monitor those parameters, and take necessary actions to ensure that the parameter limits are not exceeded; maintain available a mitigation capability to provide core cooling, decay heat removal and protection against loss of fission products following loss or interruption of decay heat removal during shutdown operation; amend the required fire protection plan to add provisions for fire protection measures defined in the proposed rule, and report actuations of shutdown mitigation equipment to the NRC. With regard to fuel storage pool operation, the proposed rule would require licensees to update the final safety analysis report (FSAR) to document key safety analysis parameters and assumptions defining the design bases for the fuel pool decay heat removal function and to translate the key parameters into operating procedures.

DATES: The comment period expires [insert date 75 days after publication in the Federal Register]. Comments received after that date will be considered if it is practical to consider them, but the Commission is able to assure

consideration only for comments received on or before that date.

ADDRESSES: Submit comments to: Secretary, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, Attention: Docketing and Service Branch. Deliver comments to: 11555 Rockville, Pike, Rockville, Maryland between 7:30 a.m. and 4:15 p.m. on Federal workdays.

Copies of comments received may be examined and copied for a fee at the NRC Public Document Room, 2120 L Street, NW. (Lower Level), Washington, DC 20037. For information on electronic access and submittal, please see the discussion under Electronic Access in the Supplementary Information section.

FOR FURTHER INFORMATION CONTACT: Mr. Timothy Collins, Section Chief, Reactor Systems Branch, Division of Systems Safety and Analysis, Office of Nuclear Reactor Regulation, Mail Stop O-8E23, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, Telephone: 301-415-2897, e-mail: TEC@nrc.gov.

SUPPLEMENTARY INFORMATION:

- I. Objective
- II. Background
- III. Basis for Shutdown Operations Requirements
- IV. Basis for Fuel Storage Pool operation Requirements
- V. Section-by-Section Analysis of Rule Requirements
- VI. Comments on the Initially Proposed Rule
- VII. Request for Public Comments
- VIII. Availability of Documents
- IX. Electronic Access
- X. Criminal Penalties
- XI. Finding of No Significant Environmental Impact
- XII. Paperwork Reduction Act Statement
- XIII. Regulatory Analysis
- XIV. Regulatory Flexibility Certification
- XV. Backfit Analysis

I. Objective

The objective of the proposed rule is to establish a clear regulatory framework for ensuring that cold shutdown, refueling outages, and fuel pool operations continue to be conducted in a safe manner. To accomplish this objective for cold shutdown and refueling operations, licensees would be required to modify the administrative controls section of their technical specifications in accordance with the requirements of the rule, and

establish procedures for performance monitoring and other activities important to safety. To accomplish this objective for fuel pool operation, licensees would be required to document factors important to safety in the FSAR and incorporate these safety factors in fuel pool operating procedures.

## II. Background

On October 19, 1994 (59 FR 52707), the Commission published a proposed rule that promulgated requirements for low-power and shutdown operations. In that Federal Register notice, the Commission described a series of serious events that occurred during shutdown operations. Subsequently, other such events have also occurred. During 1995 and 1996, the NRC held several public meetings to ensure that the NRC would have the benefit of an interchange of views on the subject of shutdown risk.

## III. Basis for Shutdown Operations Requirements

On the basis of the extensive written public comments and the discussions at the public meetings, the Commission has decided to substantially revise the proposed rule and the supporting regulatory analysis, and republish these documents for public comment. The scope of this rulemaking was changed to include fuel pool operation and to exclude low-power and transition modes. Fuel pool operation were included because of the need for the Commission to clarify its expectations for documentation and to ensure a clear basis for enforceability and inspectability in this related area. Low-power and transition modes were excluded because analysis shows that important safety functions are protected by existing standard technical specifications in these modes.

In a revised regulatory analysis, the Commission has reviewed the safety functions important to shutdown operation and the controls currently in place to ensure these functions. The current controls have evolved through a series of NRC and industry actions generally initiated through NRC generic communications. These initiatives have been successful in achieving the acceptable level of risk that now exists at U.S. power plants. However, the

Commission has also reviewed the existing body of regulations to establish the underlying regulatory requirement to sustain these practices in place. The Commission's regulatory analysis shows that a significant safety benefit relies upon measures for which a clear legal requirement does not exist.

Accordingly, the regulatory analysis shows that the proposed rule would provide a substantial increase in the overall protection to public health and safety, and that the costs of the proposed rule are justified in view of the increased protection afforded by the backfit. However, the practical effect of rule implementation is not to raise the current level of safety, but rather to ensure that the current level of safety being achieved through voluntary actions of nuclear power plant licensees will be maintained by all licensees in the future. This action is considered necessary to ensure a regulatory "floor" for all licensees, and preclude a withdrawal from current practice in light of continuing economic pressure to increase plant availability through shortened outages.

The NRC estimated the benefit of implementing the proposed rule less the cost of such implementation. The analysis was performed in accordance with the Commission's guidance for regulatory analysis described in NUREG/BR-0058, "Regulatory Analysis Guidelines of the U.S. Nuclear Regulatory Commission," Revision 2, Final Report, November 1995, and SECY-95-028, "Issuance of Regulatory Analysis Guidelines of the U.S. Nuclear Regulatory Commission," February 7, 1995. Accordingly, a base case was constructed that represented the protection afforded strictly by legally enforceable requirements, i.e., current regulations, technical specifications, license conditions, and orders. The base case did not credit any measures that are voluntary or that can be unilaterally changed by the licensee, such as licensee commitments made in response to generic letters and bulletins. When comparing this base case to the rule case, the Commission found the net value was \$153 billion for the

pressurized-water reactors (PWRs) and \$5.1 billion for the boiling-water reactors (BWRs). This was a base-case to rule-case analysis reflecting industry-wide values in 1997 dollars.

Sensitivity analysis showed little quantitative value when comparing the voluntary case (based on the assumption that current voluntary practices remain in effect) to the rule case. This is because of the substantial measures generally adopted by industry in response to generic communications. These measures include NUMARC 91-06, Nuclear Management and Resources Council, "Guidelines for Industry Actions to Assess Shutdown Management," December 1991. However, there are significant non-quantifiable benefits when comparing the rule case to the voluntary case. These non-quantifiable benefits include the enforceability and inspectability that are facilitated by the revised proposed rule's requirements for procedures for training, quality assurance, and corrective actions. Thus, this rule would establish a clear regulatory basis to preclude licensees from retreating from current levels of safety.

#### IV. Basis for Fuel Storage Pool Operation Requirements

The revised proposed rule also contains requirements that address fuel storage pool operation. These requirements were not included in the 1994 version of the rule that was published for comment. The NRC decided to include fuel storage pool operation in this rulemaking because the NRC has found that design-basis assumptions have not been fully documented in the FSAR and have not been captured in procedures in a number of instances. To address these problems, the NRC has prepared a new section (10 CFR 50.67(b)) on fuel storage pool operation that would require licensees to describe in the updated final safety analysis report (UFSAR) the assumptions and parameter values used in safety analyses performed by the licensee as reference bounds for design to demonstrate adequate decay heat removal for the fuel storage pool. Licensees would also be required to translate these assumptions and parameter values into operational limits in appropriate procedures.

The regulatory analysis for fuel storage pool operation shows no quantifiable risk benefit because risk is already believed to be very low.

The primary benefits of this section are non-quantifiable. These non-quantifiable benefits include improved enforceability and inspectability, and clarification of the Commission's expectations. The Commission believes this is a significant qualitative benefit in addressing the perceived need for improved regulatory controls in this area, which justifies the associated cost.

#### V. Section-by-Section Analysis of Rule Requirements

1. Shutdown Operations, 50.67(a) of the proposed rule would apply to holders of operating licenses and combined licenses for commercial light-water nuclear power plants. The proposed rule is not applicable to commercial nuclear power plants that have been permanently shut down with fuel permanently removed from the reactor vessel.

a. Shutdown Operations Procedures, 50.67(a)(1) of the proposed regulation would require holders of operating licenses and combined licenses for a light-water reactor nuclear power plant to establish and implement procedures for complying with the requirements of paragraph (a) of the proposed rule. Procedures must address training, quality assurance, and corrective action for complying with the requirements of proposed 50.67(a). Thus, procedures must be developed for establishing, monitoring, and complying with the parameter limits required by 50.67(a)(2)(i); activities undertaken to ensure that the safety function limits would be met; and to ensure that the mitigation capabilities required by 50.67(a)(3) would be maintained. The Commission interprets this section to require that procedures must address all activities that can reasonably affect the reliability and availability of the decay heat removal function. The criteria for determining the adequacy of the procedures, and the methods for establishing, modifying, and superseding the procedures would be set forth in the administrative controls section of the technical specifications. The Commission does not intend the changes to the procedures themselves to be subject to prior NRC review and approval. Instead, the Commission intends the licensee to be free to change the procedures (subject to NRC audit and inspection), as long as the criteria for determining the adequacy of the procedures are satisfied and the licensee complies with the methodology for changing the procedures.

b. Performance Monitoring, 50.67(a)(2) of the proposed rule would require each licensee to establish parameter limits for its plant that would ensure compliance with the three safety function limits specified in this paragraph, monitor the parameters during shutdown operation, and comply with the parameter limits. The licensee need not monitor the parameters and comply with the parameter limits during those periods when the licensee has removed all of the fuel from the reactor vessel. The safety function limits have been selected by the Commission in order to ensure the safety functions of decay heat removal, reactor coolant system (RCS) inventory control, and the pressure boundary control of the RCS and connected systems. Some licensees may propose direct methods of measuring the parameters, using either existing or newly installed instrumentation. Other licensees may propose indirect methods. Analogous to 50.67(a)(1), the parameters, parameter limits, and the monitoring requirements (including the nature and frequency of monitoring of the parameters) must be specified in a licensee-controlled document that is identified in (but will not be deemed to be "incorporation by reference" into) the administrative controls section of technical specifications. Therefore, licensee changes to the parameters, parameter limits and monitoring requirements in this licensee-controlled document do not require prior NRC review and approval. However, the criteria and method for licensee selection of the parameters, parameter limits, and the nature and frequency of monitoring must be set forth in the administrative controls section of the technical specifications. This would provide the necessary assurance and regulatory control that licensee changes will be acceptable, while maximizing the licensee's flexibility to quickly make changes during an outage to respond to changing conditions and circumstances.

The Commission regards a failure to comply with the parameter limits established for performance monitoring of parameters in 50.67(a)(2) as a serious matter and intends to revise its enforcement guidelines to reflect the seriousness of such non-compliance. Any failure to comply with the parameter limits must be reported to the NRC in a licensee event report (LER) pursuant

to 50.73(a)(2)(i)(B), which requires an LER for "[a]ny operation or condition prohibited by the plant's Technical Specifications." Furthermore, if the failure to comply with the parameter limits results or should have resulted in an actuation of a mitigation system, the event, along with its details, is reportable pursuant to 50.72(b)(1)(vii) and 50.73(a)(2)(xi). Mitigation system failure or actuation (by automatic or manual means) would still require reports if there were a need for the actuation as evidenced by exceeding a parameter limit established in the administrative controls section of the technical specifications.

c. Mitigation Capability, 50.67(a)(3). This provision would ensure that a backup capability exists if needed to maintain the reactor in a safe condition in the event of the loss of the operating decay heat removal system. This paragraph would require each licensee to propose in the administrative controls section of the technical specifications for shutdown operation criteria and methods for selecting structures, systems, and components to cover the following three functions after the loss or interruption of the operating decay heat removal path: adequate core cooling (inventory control), decay heat removal, and sufficient protection against the uncontrolled release of fission products. Each mitigation capability must remain functional following the occurrence of an event that could interrupt or degrade the operating decay heat removal path. Thus, the decay heat removal path element of the mitigation capability would be in addition to the decay heat removal path that is in operation at any time.

A licensee-controlled document would contain the outage-specific details about which pumps, systems, and other equipment will be used to satisfy the mitigation capability during different portions of the outage. The document must be identified in (but not be "incorporated by reference" into) the administrative controls section of technical specifications. The licensee could change the outage-specific details without NRC approval as long as the approved process specified in the administrative controls section of the technical specifications is followed.

For decay heat removal, licensees would be required to provide a

heat  
removal path to meet 50.67(a)(3) in addition to the operating decay  
heat  
removal path. The availability of both trains of normal decay heat  
removal  
(or residual heat removal as it is sometimes referred to) would satisfy  
the  
requirement for both an operating and an additional decay heat removal  
path.

The Commission expects licensees to propose criteria such that:

(1) The selected path for the decay heat removal system will have support  
systems, onsite power, and cooling water available for a path to the  
ultimate  
heat sink; or

(2) A passive capability of such capacity that a sufficient length of  
time is  
available to reestablish a decay heat removal path before exceeding the  
safety  
function limits specified in the rule.

For adequate core cooling, licensees would be required  
to provide a means  
for maintaining the fuel cladding in a wetted condition following a core  
uncovery event, and maintaining the reactor in a subcritical condition.  
The  
Commission expects licensees to propose such criteria in the  
administrative  
controls section of their technical specifications that the selected path  
would be a subsystem of the safety injection or emergency core cooling  
system  
and would be designed to withstand the safe-shutdown earthquake, thus  
protecting the reactor from seismic events. In order to meet the  
Commission's  
expectations, the non-passive equipment in the selected path should be  
comprised of structures, systems, and components in addition to those  
used for  
the decay heat removal paths. In order for a safety injection or  
emergency  
core cooling system to be functional, the licensee shall ensure that  
support  
systems are functional.

In addition to decay heat removal and inventory control, licensees  
shall  
provide sufficient protection against the uncontrolled release of fission  
products. During different portions of an outage, this could be  
accomplished  
with either an intact full-pressure primary containment or a  
risk-comparable  
alternative mitigation capability. For purposes of this rulemaking, the  
Commission defines an intact containment as one in which:

(1) The personnel hatch is capable of being readily closed;

(2) All other containment penetrations are closed with a single barrier or are capable of being remote-manual closed from the control room; and

(3) The differential pressure capability is comparable to that of an integral containment.

Confirmation of leak rate characteristics does not apply. Most BWRs do not have such a containment during refueling operations and, as a practical matter, PWRs will at times have their containment open or of reduced capability during portions of an outage. Consequently, licensees are required to propose criteria for inclusion in the administrative controls section of their technical specifications for the selection of alternatives to an intact primary containment. The Commission does not expect licensees to perform shutdown probabilistic risk assessments (PRAs). However, the Commission expects licensees to develop criteria based upon risk insights that account for factors such as independence, diversity, ongoing work activities and plant state, and the defense-in-depth aspect of mitigation ordinarily provided by a containment.

The licensee need not maintain available the mitigation capability to provide adequate core cooling, decay heat removal, and sufficient protection against the uncontrolled release of fission products as required by paragraph (a)(3) of the proposed rule during those periods when the licensee has removed all of the fuel from the reactor vessel.

d. Fire Protection, 50.67(a)(4). This provision would require licensees to minimize the frequency of fires during shutdown operation and their potential consequences in those areas in which a fire could impair the decay heat removal system in operation. Thus, the Commission expects licensees to control combustible materials used during an outage, control interruption of fire barriers, and control potential sources of ignition in all areas in which fire could impair the decay heat removal function. Licensees would also be required to limit the levels of fire damage by promptly detecting, controlling, and extinguishing fires, and to develop and implement contingency plans for maintaining the fuel cladding wetted and for

restoring a heat removal path in the event of a fire in those areas that interrupts or degrades heat removal to an ultimate heat sink. Some licensees may find it necessary to install fire protection equipment for use in areas essential for removing decay heat or for adding water to the vessel. The reason for this fire protection provision is that the potentially short time to core damage would make it difficult to restore a fire-damaged system to service. The reason for the requirement to have contingency plans is based on the need to have a reliable source of water readily available to maintain the wetted fuel cladding. Licensees may need to have the reactor sump available or to replenish the tank used for safety injection. As with the preceding provisions, the licensee would also be required to ensure the availability of support systems, including emergency onsite power sources for the safety injection or emergency core cooling system used for this function. Lastly, this provision would also require licensees to describe these measures in their fire protection plan. However, licensees need not actually implement the shutdown fire protection measures described in the plan for those periods when the licensee has removed all of the fuel from the reactor vessel.

2. Fuel Storage Pool Operation, 50.67(b). This provision would require holders of operating licenses and combined licenses for a light-water reactor nuclear power plant, and licenses authorizing storage or movement of fuel in a fuel storage pool at a light-water reactor nuclear power plant to document their design basis for fuel storage pool operation. This provision would not be applicable to commercial nuclear power plants that have been permanently shut down with fuel transferred to a storage facility other than the fuel storage pool, the refueling cavity, or connected water-filled cavities. Licensees would be required to describe in the UFSAR the assumptions and parameter values used in safety analyses performed by the licensee as reference bounds for the design to demonstrate adequate decay heat removal for the fuel storage pool and to translate these assumptions and parameter values into operational limits in appropriate procedures.

3. Implementation. 50.67(c) would require licensees to develop and submit for NRC review and approval a modification of the administrative controls section of the technical specifications required by paragraph

(a),  
"Shutdown Operation Procedures," within 6 months after a final rule is published. Model technical specifications are included as an appendix in the regulatory guide associated with this rule. 50.67(c)(2) would require the fire protection plan required by 50.48 to be updated by describing the various positions within the licensee's organization that are responsible for complying with 50.67(a)(4), of this section, the authorities that are delegated to each of these positions to implement these responsibilities, and the specific features necessary for complying with 50.67(a)(4). This documentation is intended to be sufficiently detailed to be enforceable and inspectable. 50.67(c)(3) would require licensees to update their final safety analysis report (FSAR) to reflect the requirements of 50.67(b) in the first scheduled FSAR update cycle that begins 6 months after the rule is published in final form. 50.67(c)(4) would require licensees to revise the procedures for fuel pool storage within 12 months after the rule is published in final form.

4. Definitions, 50.2. This provision would define "shutdown operation" consistent with the mode definitions found in individual plant technical specifications.

5. Maintenance Rule, 50.65(b)(2)(iv). This provision would require non-safety-related structures, systems, and components necessary for compliance with 50.67 to be covered by the monitoring program of the maintenance rule. Safety-related structures, systems, and components necessary for compliance with 50.67 are already covered by the maintenance rule.

6. FSAR Rule, 50.34(b). This paragraph would clarify that future applications for operating licenses and combined licenses must include the design assumptions and parameters used as reference bounds for design to demonstrate adequate decay heat removal for the fuel storage pool. The Commission believes that an explicit requirement to include the fuel storage pool design assumptions and parameters in the FSAR will end any ambiguity with respect to the necessity for inclusion of such information in the FSAR pursuant to 50.34.

7. Immediate Notification Requirement, 50.72(b)(1)(vii), and Licensee Event Report System, 50.73(a)(2)(xi). These provisions would require the 1-

hour reports via the emergency notification system and licensee event reports.

Real actuations of a shutdown mitigation system, failures of a mitigation system to respond, and failures to actuate a mitigation system manually when it should have been manually actuated would all be reportable.

8. License Renewal, 54.4(a)(3). This provision would reflect a change in scope consistent with 50.67 so that non-safety related structures, systems, and components necessary for compliance with 50.67 would be included within the scope of the license renewal rule. Safety related structures, systems, and components necessary for compliance with 50.67 are already within the scope of license renewal in accordance with 54.4(a)(1).

#### VI. Comments on the 1994 Proposed Rule

The period for commenting on the 1994 proposed rule closed on February 3, 1995. There were 1023 comments received from 49 different commenters. Comments were received on the proposed rule, the regulatory analysis, and the regulatory guide. All comments were considered in formulating the revised proposed rule, regulatory analyses, and regulatory guide.

The 49 sources of comment consisted of two licensed operators, five utility owners' groups, 39 utilities, the Nuclear Energy Institute (NEI), Engineering Planning and Management, Inc., and one public interest group. The five utility owners' groups were the Combustion Engineering Owners Group (CEOG), the Boiling Water Reactor Owners Group (BWROG), the Westinghouse Owners Group (WOG), the Babcock and Wilcox Owners Group (BWOOG), and the Nuclear Utility Backfitting and Reform Group (NUBARG), which was represented by Winston and Strawn.

Among the 1023 comments were the following four letters received before the proposed rule was published: (1) letter from Thomas E. Tipton (NUMARC) to William T. Russell (NRC), dated January 11, 1994; (2) letter from Raymond Burski (CEOG) to William T. Russell (NRC), dated April 8, 1994; (3) letter from William H. Rasin (NEI) to Edward L. Jordan (NRC), dated March 28, 1994; and (4) letter from William Bray (NEI) to Chairman Ivan Selin (NRC), dated May 25, 1994. Several of the comments on the prepublication rule were reiterated by the same commenters in separate letters after the initial proposed

rule was  
issued.

About 379 comments addressed the regulatory analysis. There were 82 comments that addressed the regulatory guide. Most commenters stated that there was no need for the proposed rule because no consideration had been given to significant industry changes to improve safety. Many commenters stated that the regulatory analysis was based on outdated information and contained assumptions that did not accurately portray risk, implementation cost, or safety benefit. Many commenters also stated that the regulatory guide was a restatement of the proposed rule and did not contain sufficient guidance or clarification.

In response to the public comments, the staff rewrote the 1994 proposed rule, the associated regulatory guide, and the regulatory analysis to more clearly reflect NRC regulatory requirements and to provide more flexibility to licensees in meeting these requirements (i.e., a rule with some performance elements). Because of the substantial revision to the 1994 proposed rule and because the revised proposed rule is being reissued for public comment, the Commission has determined that a detailed analysis of the public comments and responses to the comments on the 1994 proposed rule would not be useful.

#### VII. Request for Public Comments

Comments on the revised proposed rule, the draft regulatory guide, and the regulatory analysis may be submitted to the Secretary, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, Attention: Docketing and Service Branch. Please refer to the next section, "Availability of Documents," for information on obtaining copies of these documents. In addition, the Commission requests public comments on the following issues:

Issue 1. The Commission has developed the requirements in 50.67(a)(3) based upon its understanding of the designs for representative boiling-water reactor (BWR) and pressurized-water reactor (PWR) plants. However, there may be specific plants whose approved designs are such that compliance with the requirements of 50.67(a)(3) may represent a substantial cost, or may be impractical. For example, some plants do not have containments during shutdown and may need to take credit for an alternative means of achieving

comparable levels of safety. Licensees whose plants have been licensed with plant designs that would require substantial modification to comply with the requirements of 50.67(a)(3) of the proposed rule, or for which compliance would be impractical, are asked to identify their design bases with a concise explanation of why compliance with the requirements of 50.67(a)(3) would be impractical or would otherwise result in inordinate costs. In this regard, licensees are also asked to present alternatives that achieve the same level of risk reduction.

Issue 2. The Commission is interested in detailed comments relating to the cost, operational burden, and safety benefit to be derived from the proposed rule. Comments that discuss alternative approaches to achieving safety with the least burden are desired.

Issue 3. The Commission is interested in obtaining additional information on the risk of shutdown and low-power operation and insights on whether the Commission should engage in a more detailed quantitative examination of risk during shutdown and low-power operation at representative nuclear power plants. Would such a study be warranted in order to specify limits on the tolerable durations of plant configurations that pose very high risks? How could the rule be structured to better reflect the risk insights and strategies commonly used to develop software tools now in use by the industry for outage planning, such as the Electric Power Research Institutes's ORAM (Outage Risk Assessment and Management).

Issue 4. The Commission is interested in determining how licensees could best structure the administrative controls section of their technical specifications to achieve the objectives of the rulemaking. Should the technical specifications required by this rulemaking be placed in a separate section of plant technical specifications that addresses only shutdown operation?

#### VIII. Availability of Documents

Copies of NRC documents, including the regulatory guide and regulatory

analysis, are available for public inspection and copying for a fee at the NRC Public Document Room (PDR) at 2120 L Street, NW. (Lower Level), Washington, DC 20037.

Copies of NRC reports in the NUREG series may be purchased from the Superintendent of Documents, U.S. Government Printing Office, by calling 202-275-2060 or by writing to the Superintendent of Documents, U.S. Government Printing Office, Mail Stop SSOP, Washington, DC 20402-9328. Copies are also available from the National Technical Information Service, 5825 Port Royal Road, Springfield, VA 22161.

Copies of the regulatory analysis and of the proposed regulatory guide are available from the Superintendent of Documents. Prospective commenters may also request single copies from Mr. Kulin Desai, Reactor Systems Engineer, Reactor Systems Branch, Division of Systems Safety and Analysis, Office of Nuclear Reactor Regulation, Mail Stop O-8E23, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, Telephone: 301-415-2835; e-mail: KDD@nrc.gov.

#### IX. Electronic Access

Comments may be submitted electronically, in either ASCII text or Word Perfect format (version 5.1), by calling the NRC Electronic Bulletin Board on FedWorld. The bulletin board may be accessed using a personal computer, a modem, and one of the commonly available communications software packages, or directly via Internet. Some of the documents related to this rulemaking are also available for downloading and viewing on the bulletin board.

If using a personal computer and modem, the NRC subsystem on FedWorld can be accessed directly by dialing the toll-free number: 1-800-303-9672. Communications software parameters should be set as follows: parity to none, data bits to 8, and stop bits to 1 (N,8,1). Using ANSI or VT-100 terminal emulation, the NRC rulemaking subsystems can then be accessed by selecting the "Rules Menu" option from the "NRC Main Menu." For further information

about options available for NRC at FedWorld, consult the "Help/Information Center" from the "NRC Main Menu." Users will find the "FedWorld Online User's Guides" particularly helpful. Many NRC subsystems and databases also have a "Help/Information Center" option that is tailored to the particular subsystem.

The NRC subsystem on FedWorld can also be accessed by a direct-dial phone number for the main FedWorld BBS: 703-321-8020; Telnet via Internet: fedworld.gov (192.239.93.3); File Transfer Protocol (FTP) via Internet:ftp:fedworld.gov (192.239.92.205); and World Wide Web using: http://www.fedworld.gov (this is the Uniform Resource Locator (URL)).

If using a method other than the toll-free number to contact FedWorld, access the NRC subsystem from the main FedWorld menu by selecting "F " Regulatory, Government Administration and State Systems," then selecting "A " Regulatory Information Mall." At that point, a menu will be displayed that has an option "A - U.S. Nuclear Regulatory Commission" that will take you to the NRC Online Main Menu. You can also go directly to the NRC Online area by typing "/go nrc" at a FedWorld command line. If you access NRC from FedWorld's Main Menu, then you may return to FedWorld by selecting the "Return to FedWorld" option from the NRC Online Main Menu. However, if you access NRC at FedWorld by using NRC's toll-free number, then you will have full access to all NRC systems, but you will not have access to the main FedWorld system. For more information on NRC bulletin boards, call Mr. Arthur Davis, Office of Information Resources Management, Systems Development and Integration Branch, U.S. Nuclear Regulatory Commission, Telephone: 301-415-5780; e-mail: AXD3@nrc.gov.

## X. Criminal Penalties

For purposes of Section 223 of the Atomic Energy Act of 1954, as amended (AEA), the Commission proposes to issue the proposed rule under one or more of sections 161b, 161i, or 161o of the AEA. Willful violations of the proposed rule are subject to criminal enforcement.

## XI. Finding of No Significant Environmental Impact

The Commission has determined under the National Environmental Policy Act of 1969, as amended, and the Commission's regulations in Subpart A of 10 CFR Part 51, that this proposed rule, if adopted, will not have a significant impact on the environment. The actions resulting from this proposed rule, if adopted, would reduce the core-damage frequency and risks during shutdown operation. Therefore, the Commission concludes that there will be no significant impact on the environment from this proposed rule. This discussion constitutes the environmental assessment and finding of no significant impact for this proposed rule.

### XIII. Paperwork Reduction Act Statement

This proposed rule amends information collection requirements that are subject to the Paperwork Reduction Act of 1995 (44 U.S.C. 3501 et seq.). This rule has been submitted to the Office of Management and Budget (OMB) for review and approval of the information collection requirements.

The public reporting burden for this collection of information is estimated to average 3000 hours per response, including the time for reviewing instructions, searching existing data sources, gathering and maintaining the data needed, and completing and reviewing the collection of information. The U.S. Nuclear Regulatory Commission is seeking public comment on the potential impact of the collection of information contained in the proposed rule and on the following issues:

1. Is the proposed collection of information necessary for the proper performance of the functions of the NRC, including whether the information will have practical utility?
2. Is the estimate of burden accurate?
3. Is there a way to enhance the quality, utility, and clarity of the information to be collected?
4. How can the burden of the collection of information be minimized, including the use of automated collection techniques?

Send comments on any aspect of this proposed collection of information, including suggestions for reducing the burden, to the Information and Records Management Branch (T-6F33), Office of Information Resources Management, U.S.

Nuclear Regulatory Commission, Washington, DC 20555-0001, or by the Internet electronic mail at BJS1@nrc.gov; and to the Desk Officer, Office of Information and Regulatory Affairs, NEOB-10202 (3150-0011), Office of Management and Budget, Washington, DC 20503.

Comments to OMB on the collections of information or on the preceding issues should be submitted by [insert date 30 days after publication in the Federal Register]. Comments received after this date will be considered if it is practical to do so, but assurance of consideration cannot be given to comments received after this date.

#### Public Protection Notification

The NRC may not conduct or sponsor, and a person is not required to respond to, a collection of information unless it displays a currently valid OMB control number.

#### XIII. Regulatory Analysis

The NRC has prepared a regulatory analysis for this rule that examines the costs and benefits of the rule and alternatives considered: "Regulatory Analysis for the Proposed 50.67 Shutdown and Fuel Storage Pool Operation at Nuclear Power Plants," United States Nuclear Regulatory Commission, July 24, 1997.

The proposed rule's general requirements for shutdown operation are quantitatively analyzed in the main section of the regulatory analysis. The requirements applicable to fuel storage pool operation and for fire protection during shutdown are qualitatively analyzed in Appendix A and Appendix B, respectively. The regulatory analysis for the general shutdown operations requirements establishes that shutdown operation is important and that the proposed rule would significantly reduce risk to public health and safety, and it will accomplish this in a cost-beneficial manner, as evidenced by the large net values for both PWRs and BWRs.

The regulatory analysis for the fuel storage pool concludes that the proposed requirements would result in a substantial increase in protection to public health and safety due to improved enforceability and inspectability of

the design basis for the fuel storage pool, assuming that fuel storage pool operating procedures are consistent with design parameters and assumptions.

The regulatory analysis for the fire protection requirements during shutdown operation concludes that the proposed fire protection requirements would result in a substantial decrease in risk due to fires during shutdown operations and that the cost of implementation of about \$1 million per plant would be justified in light of the substantial increase in protection. Copies of the regulatory analysis are available as stated in Section VIII, "Availability of Documents."

#### XIV. Regulatory Flexibility Certification

In accordance with the Regulatory Flexibility Act of 1980 (5 U.S.C. 605(b)), the Commission certifies that this proposed rule, if promulgated, will not have a significant economic impact on a substantial number of small entities. This proposed rule would affect only the licensing and operation of nuclear power plants. The companies that own these plants do not fall within the scope of the definition of "small entities" as specified in the Regulatory Flexibility Act or the Small Business Size Standards in regulations issued by the Small Business Administration at 13 CFR Part 121.

#### XV. Backfit Analysis

The Commission's backfit analysis for this rulemaking is found in Section 1.4 of the regulatory analysis and Section 2.0 of 10 CFR Part 50, Appendix A. Refer to Section VIII, "Availability of Documents," of this notice for information on obtaining copies of these documents. The backfit analysis concludes that the proposed rule's would result in a substantial increase in protection to public health and safety and that the associated costs are justified in light of this increased protection.

#### List of Subjects

10 CFR Part 50

Antitrust, Classified information, Criminal penalties, Intergovernmental relations, Nuclear power plants and reactors, Radiation protection,

Reactor  
siting criteria, Reporting and recordkeeping requirements.

10 CFR Part 54

Administrative practice and procedure, Age-related degradation, Backfitting, Classified information, Criminal penalties, Environmental protection, Incorporation by reference, Nuclear power plants and reactors, Reporting and record keeping requirements.

For the reasons given in this statement of consideration and under the authority of the Atomic Energy Act of 1954, as amended; the Energy Reorganization Act of 1974, as amended; and 5 U.S.C. 553; the NRC is proposing to adopt the following amendments to 10 CFR Parts 50 and 54.

PART 50 " DOMESTIC LICENSING OF PRODUCTION AND UTILIZATION FACILITIES

1. The authority citation for Part 50 continues to read as follows:

AUTHORITY: Secs. 102, 103, 104, 105, 161, 182, 183, 186, 189, 68 Stat. 936, 937, 938, 948, 953, 954, 955, 956, as amended, Sec. 234, 83 Stat. 1244, as amended (42 U.S.C. 2132, 2133, 2134, 2135, 2201, 2232, 2233, 2236, 2239, 2282); Secs. 201, as amended, 202, 206, 88 Stat. 1242, as amended, 1244, 1246 (42 U.S.C. 5841, 5842, 5846), E.O. 12829, 3 CFR, 1993 Comp., p. 570; E.O. 12958, as amended, 3 CFR, Comp., p.333; E.O. 12968, 3 CFR, 1995 Comp., p. 391.

Sec. 50.7 also issued under Pub. L. 95-601, Sec. 10, 92 Stat. 2951 as amended by Pub. L. 102-486, Sec. 2902, 106 Stat 3123 (42 U.S.C. 5851). Sec. 50.10 also issued under Secs. 101, 185, 68 Stat. 936, 955, as amended (42 U.S.C. 2131, 2235); Sec. 102, Pub. L. 91-190, 83 Stat. 853 (42 U.S.C. 4332). Secs. 50.13, 50.54(dd), and 50.103 also issued under Sec. 108, 68 Stat. 939, as amended (42 U.S.C. 2138). Secs. 50.23, 50.35, 50.55, and 50.56 also issued under Sec. 185, 68 Stat. 955 (42 U.S.C. 2235). Secs. 50.33a, 50.55a and Appendix Q also issued under Sec. 102, Pub. L. 91-190, 83 Stat. 853 (42 U.S.C. 4332). Secs. 50.34 and 50.54 also issued under Sec. 204, 88 Stat. 1245 (42 U.S.C. 5844). Secs. 50.58, 50.91, and 50.92 also issued under Pub. L. 97-415, 96 Stat. 2073 (42 U.S.C. 2239). Sec. 50.78 also issued under Sec. 122, 68

Stat. 939 (42 U.S.C. 2152). Secs. 50.80-50.81 also issued under Sec. 184, 68 Stat. 954, as amended (42 U.S.C. 2234). Appendix F also issued under Sec. 187, 68 Stat. 955 (42 U.S.C. 2237).

2. In 50.8, paragraph (b) is revised to read as follows:

50.8 Information collection requirements: OMB approval

\*\*\*\* \*

(b) The approved information collection requirements contained in this part appear in 50.30, 50.33, 50.33a, 50.34, 50.34a, 50.35, 50.36, 50.36a, , 50.36b, 50.44, 50.46, 50.47, 50.48, 50.49, 50.54, 50.55, 50.55a, 50.59, 50.60, 50.61, 50.62, 50.63, 50.64, 50.65, 50.66, 50.67, 50.71, 50.72, 50.73, 50.74, 50.75, 50.80, 50.82, 50.90, 50.91, 50.120 and appendices A, B, E, G, H, I, J, K, M, N, O, Q, R, and S to this part.

\*\*\*\* \*

3. Section 50.2 is revised by adding in alphabetical order the definition for Shutdown operation as follows:

50.2 Definition

\*\*\*\* \*

Shutdown operation means the reactor coolant system (RCS) is in Cold Shutdown or Refueling (as defined in a plant s technical specifications) and one or more fuel assemblies are located in the reactor vessel or in the refueling cavity. Shutdown operation is a part of normal operation.

\*\*\*\* \*

4. Section 50.34 is revised to read as follows:

50.34 Contents of applications; technical information

\*\*\*\*\*

(b)

\*\*\*

(12) The assumptions and parameter values used in safety analyses required by

50.67(b) as reference bounds for design to demonstrate adequate decay heat removal for the fuel storage pool.

\*\*\*\* \*

5. Section 50.65(b) is revised to insert a new subparagraph (b)(2)(iv) as follows:

50.65 Requirements for monitoring the effectiveness of maintenance a nuclear power plants.

\*\*\*\* \*

- (b) \*\*\*
- (2) \*\*\*
- (iv) necessary for compliance with 50.67 of this part.

\*\*\*\* \*

6. A new 50.67 is added to read as follows:

50.67 Shutdown and Fuel Storage Pool Operations at Nuclear Power Plants

(a) Shutdown Operations. Holders of operating licenses and combined licenses for a light-water reactor nuclear power plant, except those plants that have been permanently shut down with fuel permanently removed from the reactor vessel, shall comply with the following requirements except when all fuel has been transferred out of the reactor vessel:

(1) Shutdown Operation Procedures. Licensees shall establish and implement procedures (including procedures for training, and quality assurance and corrective action measures) for the activities for complying with the requirements of paragraph (a) of this section. Except for those procedures necessary for complying with paragraph (a)(4) of this section, the criteria for determining the adequacy of the procedures and the method for establishing, modifying, and superseding the procedures must be described in the administrative controls section of technical specifications.

(2) Performance Monitoring.

(i) Licensees shall establish, monitor, and comply with parameter limits during shutdown operation. The parameter limits must ensure compliance with the following safety function limits:

(A) Decay heat removal such that the water temperature above the reactor core is less than the saturation temperature.

(B) Reactor Coolant System (RCS) inventory control such that the RCS water level is sufficient for reliable operation of the normal means of decay heat removal.

(C) RCS and connected systems pressure control such that the design pressure and Low Temperature Overpressure Protection (LTOP) settings are not exceeded.

(ii) The parameters, parameter limits, and monitoring requirements (including the nature and frequency of monitoring) must be identified and described in a licensee-controlled document that is identified in the administrative controls section of the technical specifications. The criteria and method for licensee selection of the parameters, the parameter limits, and the nature and frequency of monitoring must be described in the administrative controls section of technical specifications.

(3) Mitigation Capability. Licensees shall maintain available a mitigation capability to provide adequate core cooling, decay heat removal, and sufficient protection against the uncontrolled release of fission products following the loss or interruption of decay heat removal during shutdown operation. The structures, systems, and components for complying with this section must be identified in a licensee-controlled document that is identified in the administrative controls section of the technical specifications. The criteria and method for licensee selection of the structures, systems, and components necessary for complying with this section must be described in the administrative controls section of technical specifications.

(4) Fire Protection.

(i) Licensees shall:

(A) Minimize the frequency of fires during shutdown operation;

(B) Maintain the decay heat removal function free of fire damage or limit the levels of fire damage by promptly detecting, controlling, and extinguishing fires that do occur, and

(C) Develop and implement a contingency plan for maintaining adequate core cooling and in a timely fashion restoring decay heat removal in the event of a fire in those areas that interrupts or degrades heat removal to an ultimate heat sink.

(ii) The provisions necessary for complying with this paragraph (including the contingency plan) must be described in the fire protection plan required by 10 CFR 50.48.

(b) Fuel Storage Pool Operation. Holders of licenses authorizing storage or movement of fuel in a fuel storage pool refueling cavity or connected

water-filled cavity at a light-water reactor nuclear power plant shall describe in the updated final safety analysis report the assumptions and parameter values used in safety analyses performed by the licensee as reference bounds for design to demonstrate adequate decay heat removal for the fuel storage pool and ensure that the procedures for the fuel storage pool contain operational limits that incorporate the assumptions and parameter values in the updated final safety analysis report.

(c) Implementation. Each licensee shall:

(1) Develop and submit for NRC review and approval technical specifications required by paragraph (a) of this section by [INSERT EFFECTIVE DATE OF FINAL RULE PLUS 6 MONTHS];

(2) Update the fire protection plan required by 50.48 of this part by [INSERT EFFECTIVE DATE OF FINAL RULE PLUS 12 MONTHS] by describing the various positions within the licensee's organization that are responsible for complying with paragraph (a)(4) of this section, the authorities that are delegated to each of these positions to implement these responsibilities, and the specific features necessary for complying with paragraph (a)(4); and

(3) Revise their updated final safety analysis report as required by paragraph (b) of this section at the next scheduled revision following [INSERT EFFECTIVE DATE OF FINAL RULE PLUS 6 MONTHS];

(4) Revise the procedures for the fuel storage pool as required by paragraph (b) of this section by [INSERT EFFECTIVE DATE OF FINAL RULE PLUS 12 MONTHS].

\*\*\*\*\* \*

7. Section 50.72 is revised to insert a new subparagraph (b)(1)(vii) as follows:

50.72 Immediate notification requirements for operating nuclear power reactors.

\*\*\*\*\* \*

(b) \*\*\*  
(1) \*\*\*  
(vii) Any event that results or should have resulted in the actuation of the mitigation capability required by 50.67(a)(3).

\*\*\*\*\* \*

8. Section 50.73 is revised to insert a new subparagraph (a)(2)(xi) as follows:

50.73 Licensee event report system

(a) \*\*\*

(2) \*\*\*

(xi) Any event that results or should have resulted in the actuation of the mitigation capability required by 50.67(a)(3).

\*\*\*\* \*

PART 54 -- REQUIREMENTS FOR RENEWAL OF OPERATING LICENSES FOR NUCLEAR POWER PLANTS

9. The authority citation for Part 54 continues to read as follows:

AUTHORITY: Secs. 102, 103, 104, 161, 181, 182, 183, 186, 189, 68 Stat. 936, 937, 938, 948, 953, 954, 955, as amended, sec. 234, 83 Stat. 1244, as amended (42 U.S.C. 2132, 2133, 2134, 2135, 2201, 2232, 2233, 2236, 2239, 2282); secs 201, 202, 206, 88 Stat. 1242, 1244, as amended (42 U.S.C. 5841, 5842), E.O. 12829, 3 CFR 1993 Comp., p. 570; E.O. 12958, as amended, 3 CFR, 1995 Comp., p. 333; E.O. 12968, 3 CFR, 1995 Comp., p. 391.

10. Section 54.4 is revised to read as follows:

54.4 Scope

(a) \*\*\*

(3) All systems, structures, and components relied on in safety analyses or plant evaluations to perform a function that demonstrates compliance with the Commission's regulations for fire protection (10 CFR 50.48), environmental qualification (10 CFR 50.49), pressurized thermal shock (10 CFR 50.61), anticipated transients without scram (10 CFR 50.62), station blackout (10 CFR 50.63), and shutdown and fuel storage pool operations (10 CFR 50.67).

\*\* \* \* \*

Dated at Rockville, Maryland, this \_\_\_th day of September 1997.

For the Nuclear Regulatory Commission.

John C. Hoyle,

Secretary of the Commission.

50.67

Shutdown and Fuel Storage Pool Operations at Nuclear Power  
Plants

1. A new 50.67 is added to read as follows:

50.67 Shutdown and Fuel Storage Pool Operations at Nuclear Power  
Plants

(a) Shutdown Operations. Holders of operating licenses and combined licenses for a light-water reactor nuclear power plant, except those plants that have been permanently shut down with fuel permanently removed from the reactor vessel, shall comply with the following requirements except when all fuel has been transferred out of the reactor vessel:

(1) Shutdown Operation Procedures. Licensees shall establish and implement procedures (including procedures for training, and quality assurance and corrective action measures) for the activities for complying with the requirements of paragraph (a) of this section. Except for those procedures necessary for complying with paragraph (a)(4) of this section, the criteria for determining the adequacy of the procedures and the method for establishing, modifying, and superseding the procedures must be described in the administrative controls section of technical specifications.

(2) Performance Monitoring.

(i) Licensees shall establish, monitor, and comply with parameter limits during shutdown operation. The parameter limits must ensure compliance with the following safety function limits:

(A) Decay heat removal such that the water temperature above the reactor core is less than the saturation temperature.

(B) Reactor Coolant System (RCS) inventory control such that the RCS water level is sufficient for reliable operation of the normal means of decay heat removal.

(C) RCS and connected systems pressure control such that the design pressure and Low Temperature Overpressure Protection (LTOP) settings are not exceeded.

(ii) The parameters, parameter limits, and monitoring requirements

(including the nature and frequency of monitoring) must be identified and described in a licensee-controlled document that is identified in the administrative controls section of the technical specifications. The criteria and method for licensee selection of the parameters, the parameter limits, and the nature and frequency of monitoring must be described in the administrative controls section of technical specifications.

(3) Mitigation Capability. Licensees shall maintain available a mitigation capability to provide adequate core cooling, decay heat removal, and sufficient protection against the uncontrolled release of fission products following the loss or interruption of decay heat removal during shutdown operation. The structures, systems, and components for complying with this section must be identified in a licensee-controlled document that is identified in the administrative controls section of the technical specifications. The criteria and method for licensee selection of the structures, systems, and components necessary for complying with this section must be described in the administrative controls section of technical specifications.

(4) Fire Protection.

(i) Licensees shall:

(A) Minimize the frequency of fires during shutdown operation;

(B) Maintain the decay heat removal function free of fire damage or limit the levels of fire damage by promptly detecting, controlling, and extinguishing fires that do occur, and

(C) Develop and implement a contingency plan for maintaining adequate core cooling and in a timely fashion restoring decay heat removal in the event of a fire in those areas that interrupts or degrades heat removal to an ultimate heat sink.

(ii) The provisions necessary for complying with this paragraph (including the contingency plan) must be described in the fire protection plan required by 10 CFR 50.48.

(b) Fuel Storage Pool Operation. Holders of licenses authorizing storage or movement of fuel in a fuel storage pool refueling cavity or connected water-filled cavity at a light-water reactor nuclear power plant shall describe in the updated final safety analysis report the assumptions and

parameter values used in safety analyses performed by the licensee as reference bounds for design to demonstrate adequate decay heat removal for the fuel storage pool and ensure that the procedures for the fuel storage pool contain operational limits that incorporate the assumptions and parameter values in the updated final safety analysis report.

(c) Implementation. Each licensee shall:

(1) Develop and submit for NRC review and approval technical specifications required by paragraph (a) of this section by [INSERT EFFECTIVE DATE OF FINAL RULE PLUS 6 MONTHS];

(2) Update the fire protection plan required by 50.48 of this part by [INSERT EFFECTIVE DATE OF FINAL RULE PLUS 12 MONTHS] by describing the various positions within the licensee's organization that are responsible for complying with paragraph (a)(4) of this section, the authorities that are delegated to each of these positions to implement these responsibilities, and the specific features necessary for complying with paragraph (a)(4); and

(3) Revise their updated final safety analysis report as required by paragraph (b) of this section at the next scheduled revision following [INSERT EFFECTIVE DATE OF FINAL RULE PLUS 6 MONTHS];

(4) Revise the procedures for the fuel storage pool as required by paragraph (b) of this section by [INSERT EFFECTIVE DATE OF FINAL RULE PLUS 12 MONTHS].

#### CONFORMING CHANGES TO OTHER REGULATIONS

2. Section 50.2 is revised by adding in alphabetical order the definition for Shutdown operation as follows:

##### 50.2 Definition

\*\*\*\* \*

Shutdown operation means the reactor coolant system (RCS) is in Cold Shutdown or Refueling (as defined in a plant's technical specifications) and one or more fuel assemblies are located in the reactor vessel or in the refueling cavity. Shutdown operation is a part of normal operation.

\*\*\*\* \*

3. Section 50.34 is revised to read as follows:

50.34 Contents of applications; technical information

\*\*\*\* \*

(b)

\*\*\*

(12) The assumptions and parameter values used in safety analyses required by paragraph 50.67(b) as reference bounds for design to demonstrate adequate decay heat removal for the fuel storage pool.

\*\*\*\* \*

4. Section 50.65(b) is revised to insert a new subparagraph (b)(2)(iv) as follows:

50.65 Requirements for monitoring the effectiveness of maintenance a nuclear power plants.

\*\*\*\* \*

(b)

\*\*\*

(2)

\*\*\*

(iv) necessary for compliance with 50.67 of this part.

\*\*\*\* \*

5. Section 50.72 is revised to insert a new subparagraph (b)(1)(vii) as follows:

50.72 Immediate notification requirements for operating nuclear power reactors.

\*\*\*\* \*

(b)

\*\*\*

(1)

\*\*\*

(vii) Any event that results or should have resulted in the actuation of the mitigation capability required by 50.67(a)(3).

\*\*\*\* \*

6. Section 50.73 is revised to insert a new subparagraph (a)(2)(xi) as follows:

50.73 Licensee event report system

\*\*\*\* \*

(2)

\*\*\*

(xi) Any event that results or should have resulted in the actuation of the mitigation capability required by 50.67(a)(3).

\*\*\*\* \*

7. Section 54.4 is revised to read as follows:

54.4 Scope

(a)

\*\*\*

(3) All systems, structures, and components relied on in safety analyses or plant evaluations to perform a function that demonstrates compliance with the Commission's regulations for fire protection (10 CFR 50.48), environmental qualification (10 CFR 50.49), pressurized thermal shock (10 CFR 50.61), anticipated transients without scram (10 CFR 50.62), station blackout (10 CFR 50.63) and shutdown and fuel storage pool operations (10 CFR 50.67).

AE97-1

United States Nuclear Regulatory

Commission

Regulatory Analysis for the Proposed  
Regulation 50.67, "Shutdown and Fuel  
Storage Pool Operations at Nuclear Power  
Plants"

July 24, 1997

Table of Contents  
Section  
Page

1	INTRODUCTION
1	1.1 Objective and Problem
1	1.2 Background and History of Events
2	1.3 Cases Used for Analysis
5	1.4 Backfit Rule
6	
2	IDENTIFICATION AND PRELIMINARY ANALYSIS OF ALTERNATE APPROACHES
10	2.1 Take No Action
10	2.2 Issue an Information Notice
10	2.3 Issue a Generic Letter or Bulletin
10	2.4 Implement the Rule Published in 59 FR 52707
10	2.5 Rewrite the Maintenance Rule ( 50.65)
11	2.6 Modify and Prepare Technical Specifications Without Rulemaking
11	2.7 Implement a Risk-Informed Rule With Performance Elements
11	2.8 Implement a Rule Applicable Solely to PWRs
11	2.9 Implement a Rule Applicable to PWRs During Midloop or Reduced Inventory
11	
3	ESTIMATION AND EVALUATION OF VALUES AND IMPACTS
11	3.1 Probabilistic Risk Assessment
12	3.2 Estimation of Values
14	3.3 Estimation of Impacts
15	3.4 Evaluation of Values and Impacts
15	3.4.1 Avoided Public Health Risk (V1)
16	3.4.2 Avoided Occupational Health Risk (V2)
18	

18 3.4.3 Avoided Offsite Damage to Property (V3)  
19 3.4.4 Avoided Onsite Power Replacement and Cleanup (V4)  
19 3.4.5 Routine Occupational Health Risk (V5)  
20 3.4.6 Costs or Savings to NRC (I1)  
21 3.4.7 Direct Costs or Savings to Licensees (I2)

4 DISCUSSION OF RESULTS

24 4.1 Net Value  
26 4.2 Attributes for Each Case  
26 4.3 Non-Quantifiable or Poorly Quantifiable Attributes  
27 4.4 Key Assumptions  
27 4.4.1 Base Case  
27 4.4.2 Voluntary Action Case  
27 4.4.3 Rule Case  
28

5 RATIONALE FOR SELECTING THE PROPOSED ACTION

29 5.1 Relationship to Other NRC Programs and Requirements  
29 5.2 Statement of Proposed Generic Requirement  
30 5.3 Statement Regarding Nature of Proposed Requirement  
34

6 IMPLEMENTATION

34

7 REFERENCES

34

Appendix A: Regulatory Analysis "Fuel Storage Pool Operation"  
A-1

Appendix B: Regulatory Analysis Supplement "Fire Protection for Shutdown  
Operation"  
B-1

Regulatory Analysis for the Proposed Regulation 50.67, "Shutdown and  
Fuel Storage Pool Operations at Nuclear Power Plants"

## 1 INTRODUCTION

This regulatory analysis assesses the proposed rule in accordance with the United States Nuclear Regulatory Commission's (NRC's) regulations, 10 CFR 50.109, "Backfitting," and the guidance in SECY-95-028 and NUREG/BR-0058. This analysis has three separate sections. The first section discusses shutdown operations exclusive of proposed fire protection requirements. The second section, which is Appendix A to this regulatory analysis, discusses the fuel pool regulatory analysis. The third section, which is Appendix B, discusses the fire protection regulatory analysis. Because of the degree of quantitative assessment associated with the first section, it is separate from the regulatory analysis for those aspects of the proposed rule regarding the fuel storage pool and fire protection during shutdown operations. For fire protection, a detailed quantification is not practical because of the many plant-specific dependencies.

### 1.1 Objective and Problem

The objective of the proposed rule is to establish a clear regulatory framework for assuring that cold shutdown, refueling outages and fuel pool operations continue to be conducted in a safe manner. To accomplish this objective for cold shutdown and refueling operations, licensees shall modify their administrative controls section of the technical specifications in accordance with the requirements of the rule, and have procedures for performance monitoring and other activities important to safety. To accomplish this objective for fuel pool operation, licensees shall appropriately document factors important to safety in the FSAR and operating procedures.

Existing regulatory controls for shutdown operations have evolved through a series of NRC and industry actions generally initiated as a result of NRC generic communications. Such measures have been successful in achieving the acceptable level of safety which exists at plants today. However, to prevent licensees from retreating from these voluntary measures to the minimum requirements of existing regulations, a comprehensive and coherent codification has been proposed to address a wide range of considerations.

These include quality assurance for cold shutdown equipment, inventory and pressure control during shutdown operations, availability of mitigation equipment, fire protection and containment. The staff's review found that much of the equipment used during cold shutdown is not safety-related or is not required to be in a safety-related configuration and therefore is not subject to the QA requirements of 10 CFR Appendix B. PWRs are not currently required to have an ECCS injection capability during cold shutdown or refueling. BWRs are not required to maintain pressure control capability during cold shutdown. This is risk significant because if the vessel were to pressurize in an accident, pressure relief is necessary to permit low pressure injection. Although backup decay heat removal systems are required during cold shutdown, the associated support systems necessary for mitigative decay heat removal capability are not required. Containment is not required during cold shutdown and thus control of the release of fission products following an accident is unaddressed. Fire protection during cold shutdown is largely unaddressed despite initiating frequencies comparable to power operation. The risk from fire is the product of several factors besides initiating frequency and virtually all of these factors are under significant regulatory control during operation but not cold shutdown. In addition, many BWRs rely on inerted containment to address fire in containment during power operation but inerting is not available during cold shutdown and refueling.

## 1.2 Background and History of Events

Over the past several years, the NRC has become increasingly concerned about the potential for loss of the residual heat removal (RHR) capability during shutdown periods. Several serious incidents involving loss of RHR prompted the NRC to reexamine the entire scope of shutdown operation.

In 1980 an event occurred involving loss of both RHR trains at Davis-Besse. This resulted when one RHR pump failed while the second pump was already out of service. After reviewing this event, the NRC concluded that control of RHR availability was inadequate and issued Generic Letters 80-42 and 80-53. These

generic letters proposed technical specifications that require the availability of two RHR pumps for many shutdown conditions.

In 1986 one of the San Onofre units lost RHR during a particularly sensitive shutdown condition referred to as "midloop operations." (During midloop operations, the water in the reactor coolant system (RCS) is partially drained to allow access to the steam generators and other components.) A few months later, on April 10, 1987, Diablo Canyon lost RHR despite licensee knowledge of the San Onofre event and despite precautions taken by the Diablo Canyon licensee to preclude a similar event. At Diablo Canyon, the water was drained too low and the RHR pumps failed because of air in their intake lines. After reviewing the event, NRC issued Generic Letter 87-12, which established that aspects of the Diablo Canyon event were generic to operation of all pressurized water reactors (PWRs). After further assessment of the technical issues, and applying probabilistic risk assessment (PRA) techniques, the NRC concluded that the risk of some shutdown operations should be reduced. The NRC then issued Generic Letter 88-17, which focused on PWR reduced inventory operation (water level lower than 3 feet below the reactor vessel flange). It covered many shutdown concerns, including instrumentation, controls, procedures, understanding, and training.

In response to Generic Letter 88-17, all licensees operating PWRs improved reduced inventory operation and other aspects of shutdown operation. Inspections found that licensees often failed to adequately address containment closure and water level measurements. Among other weaknesses were inadequacies in procedures, understanding of thermal-hydraulic behavior, understanding of accident behavior, and other instrumentation.

The loss during shutdown of all vital ac power at the Alvin W. Vogtle, Jr., nuclear plant on March 20, 1990, was judged to have particularly serious implications, and the NRC sent an incident investigation team to the plant. The team's report (NUREG-1410) identified weaknesses in the licensee's response to GL 88-17, the need for improvements, the need for risk management of shutdown operations, and the need for overall management of shutdown operations. Discussions with representatives of foreign regulatory organizations (French, Japanese, and Swedish authorities) reinforced NRC staff

concerns that the core-damage probability for shutdown operations can be a substantial fraction of the total core-damage probability. Consequently, the staff initiated a study of shutdown and low-power operations at U.S. commercial nuclear power plants.

The NRC staff reviewed shutdown operating experience at nuclear power plants by studying licensee event reports (LERs), reports prepared by the Office for Analysis and Evaluation of Operational Data (AEOD), and various inspection reports such as NUREG-1410 (the loss of all vital ac power event at Vogtle in 1990). The NRC staff also reviewed events at foreign nuclear power plants using information found in the foreign events file maintained for AEOD at the Oak Ridge National Laboratory. The staff visited 11 plant sites to broaden its understanding of shutdown operations, outage planning, outage management, and startup and shutdown activities. The NRC staff performed thermal-hydraulic and risk assessment scoping analyses to gain insights about the relative importance of events and phenomena.

Industry also began to respond to increasing concerns regarding shutdown operations following the loss-of-RHR event at Diablo Canyon in 1987 (NUREG-1269). Following issuance of GL 87-12 (1987) and GL 88-17 (1988), the initial emphasis was on PWRs. The entire industry actively addressed shutdown operations problems following the Vogtle event (NUREG-1410), furnished support to NRC fact-finding and information exchange visits to U.S. nuclear power plants, and supported an industry initiative (NUMARC 91-06) that was implemented, at least in part, by the end of 1992 at every operating U.S. nuclear power plant. The industry has addressed outage planning and control with such programs as workshops, Institute of Nuclear Power Operations inspections, Electric Power Research Institute support, enhanced training, and improved procedures. The NUMARC 91-06 initiative established high-level guidelines for self-assessment of shutdown operations that address many of the areas that need improvement. Further, industry's defense-in-depth concept for safety functions and outage strategy contained in NUMARC 91-06 represent good self-improvements in the shutdown operations area.

The NRC published the results of its evaluation in NUREG-1449 "Shutdown and

Low-Power Operation at Commercial Nuclear Power Plants in the United States"

(September 1993). It reported that public health and safety were protected during shutdown operation, but that substantial safety improvements were justifiable. In particular, the study concluded that although shutdown risks have been reduced at many plants through improvements to outage programs, the improvements are unevenly and inconsistently applied across the industry and significant precursor events continue to occur. The report noted that a significant lack of controls, including lack of regulatory controls, allows plants to enter circumstances likely to challenge safety functions with minimal mitigation equipment available and containment capability not established. It was also noted that current NRC requirements in the area of fire protection (i.e., 10 CFR Part 50, Appendix R) do not apply to shutdown conditions, even though significant maintenance activities, which can increase the potential for fire, do occur during shutdown. The report recommended that licensees perform fire hazard analyses with a focus on RHR systems. Technical specifications for residual heat removal, emergency core cooling, and containment systems were judged to be of insufficient detail to address the number and risk significance of RCS configurations during shutdown. Careful outage planning and well-trained and well-equipped operators were found to play a significant role in accident mitigation for shutdown events, but training and procedures for use of effective passive methods of decay heat removal were lacking. The NRC has also completed probabilistic risk studies of shutdown operation at the Surry and Grand Gulf plants; these concluded that operations during shutdown significantly contribute to overall plant risk. Furthermore, these studies indicate that risk per unit time during normal shutdown activities can be higher than during power operation.

The NRC updated the NUREG-1449 events information by means of a preliminary survey and assessment based upon readily available information for 1993, 1994, and the first five months of 1995 (Michel Labatut and Mohammed Shuaibi, "Review of Recent Shutdown Events," NRC Memorandum to R. C. Jones, Chief of Reactor Systems Branch, Office of Nuclear Reactor Regulation, August 14, 1995). It identified 426 events originating during shutdown operations

and 60 events that occurred during power operation that would have challenged the safety of the plant had they occurred during shutdown. It found 187 events in 1993, 152 in 1994, and 147 in the first five months of 1995. Of the 486 events, 64 were judged to be of concern or to be significant.

Events reported involved RHR, design problems and unanalyzed conditions, offsite power, external events, refueling, reactor vessel water level problems, containment, and reactivity control. Safety-related equipment accounted for 117 events and emergency safeguard features and reactor protection systems accounted for another 95. NRC dispatched augmented inspection teams (AITs) to investigate shutdown events in 1991 at Diablo Canyon, in 1992 at Prairie Island and three times at Oconee, and once at Oyster Creek in 1993. There have also been other serious events at Oyster Creek in 1993, at Hope Creek in 1995, and at Haddam Neck in 1996.

In SECY-94-176 (July 1994), the staff asked the Commission to approve a proposed rule. The proposed rule was published for comment in 59 FR 52707 (October 1994). It would have required power reactor licensees to do the following:

- ù Assure that uncontrolled changes will not occur in reactivity, reactor coolant inventory, and loss of subcooling in the RCS when subcooled conditions are normally being maintained.

- ù Assure that containment integrity is maintained or can be reestablished to prevent releases in excess of regulatory limits.
- ù Establish controls in technical specifications limiting conditions for operation and surveillance requirements or in plant procedures required by technical specifications administrative controls for equipment that the licensee identifies as necessary to ensure maintenance of the safety functions.

- ù Evaluate realistically the effect of fires stemming from activities conducted during cold shutdown, determine whether such fires could realistically prevent accomplishment of the normal RHR capability, and if they could, either present measures to prevent loss of normal RHR or establish a contingency plan to ensure that an alternate RHR capability exists.

ù For licensees of PWRs only, install instrumentation for monitoring water level in the RCS during midloop operation.

The NRC received 1023 comments on the proposed rule (that are discussed in more detail in Section VIII of the Statement of Considerations.) Most commenters said (1) the proposed rule was unnecessary, was prescriptive, would unnecessarily complicate outages, and would lengthen many outages by 1 or 2 weeks; (2) the regulatory analysis was inaccurate and incomplete; and (3) the regulatory guide was incomplete and offered little guidance. The only unqualified support came from a public interest group. The NRC found many comments valid and it consequently reevaluated all aspects of the rulemaking effort.

The NRC held several public meetings during 1995 and 1996 to ensure that a revised shutdown rule could be effectively implemented and to encourage the Nuclear Energy Institute (NEI) to develop an implementation guide that the NRC could reference in a regulatory guide. The NRC's dialogue with the industry was effective in obtaining information useful to the development of a draft shutdown rule. However, following the NRC's decision in June 1996 that extending coverage of the rule to the fuel storage pool, and containing language regarding internal and external events, NEI decided not to develop an implementation guidance document.

### 1.3 Cases Used for Analysis

A quantitative analysis was performed using PRA techniques for the shutdown operations portion of the rule exclusive of fire protection requirements. This analysis has three cases: the base case, the voluntary case, and the rule case.

The base case represents the level of protection afforded strictly by legally-enforceable requirements, i.e. current regulations, technical specifications, license conditions and orders. It does not credit any measures that are voluntary or that can be unilaterally changed by the licensee, such as licensee commitments made in response to generic letters and bulletins. It is

the case against which costs and benefits are measured in assessing the value of proposed new requirements.

The voluntary case is representative of the level of protection for plants as they would be if operated with a reasonable implementation of voluntary measures based on guidance from NUMARC 91-06. These voluntary measures go beyond those strictly required by the regulations, technical specifications, license conditions and orders. Because of the voluntary nature of these measures, the Commission expects that there would be a range in the level of implementation of these measure among nuclear power plant licensees. The difference between the base case and the voluntary case is a measure of the actual risk reduction in plants, assuming effective voluntary measures are maintained in the future.

The rule case represents the level of protection which would be afforded by all plants complying with the requirements of the proposed rule. The difference between the base case and the rule case shows the enforceable risk reduction that would be achieved as a result of the proposed rule and it is the case against which benefits are measured in assessing the value of new requirements.

#### 1.4 Backfit Rule

Section 50.109(a)(3) requires that there be a substantial increase in the overall protection of public health and safety or common defense and security to be derived from the backfit and that the direct and indirect costs of implementation for that facility are justified in view of this increased protection. Section 50.109(c) lists nine items that will be considered in satisfying 50.109(a)(3). Each is addressed below.

(1) Statement of the specific objectives that the proposed backfit is designed to achieve.

The objective of the proposed rule is to establish a clear regulatory framework for assuring that cold shutdown and refueling outages continue to be conducted in a safe manner. To accomplish this objective, licensees shall modify their administrative controls section of the technical specifications in accordance with the requirements of the rule, and have procedures for performance monitoring and other activities important to safety.

(2) General description of the activity that would be required by the licensee or applicant in order to complete the backfit  
To meet the shutdown operations requirements of 50.67, licensees would be required to: (a) monitor and comply with parameters for the reactor coolant system water temperature, level, and pressure; (b) provide mitigation capability for events that result in a loss of decay heat removal; and (c) implement procedures for training, quality assurance, and corrective actions to ensure the parameters are monitored and complied with and that the mitigation capability is provided.

In addition, conforming changes would be made to other regulations in support of the shutdown operations requirements of 50.67. These changes require licensees to (a) consider a new definition of shutdown operations in 50.2 as meaning the reactor coolant system (RCS) is in Cold Shutdown or Refueling (as defined in a plant's technical specifications) and one or more fuel assemblies are located in the reactor vessel or in the refueling cavity and that shutdown operation is a part of normal operation, (b) include the structures, systems, and components necessary for compliance with the shutdown operation requirements of 50.67 into the maintenance rule (50.65), (c) include in safety analyses for the license renewal rule (54.4) the structures, systems, and components relied on to perform a function that demonstrates compliance with 50.67, (d) provide notification and submit reports to the NRC in accordance with 50.72 and 50.73 of any event that results in or should have resulted in the actuation of the mitigation capability.

(3) Potential change in the risk to the public from the accidental offsite release of radioactive material. Release rates for PWRs are predicted to be reduced from the base case value of  $2E-2$ /reactor-year to  $1E-6$ . For boiling water reactor BWRs, the release rates are predicted to be reduced from  $1E-3$ /reactor-year to  $4E-6$ /reactor-year. The NRC analysis assumed a 35-day refueling outage each 18 months of operation and addressed initial entry into cold shutdown until the refueling cavity was filled. This addressed 9 days of the 35 days of the outage for the PWRs

and 6

days of the outage for BWRs. This approach was based upon plant-specific shutdown PRA results which indicated that these were the most risk-significant periods. The NRC then added an additional 10 to 20 percent to the calculated risk values for these periods to approximate the entire refueling outage. Only event initiators that result in the loss of RHR were considered. The contributions from seismic events, fires, and internal floods were not modeled in the quantitative risk assessment due to their highly plant-specific nature. Inclusion of these events would increase the risk benefits of the rule. Existing requirements were considered to provide protection for reactivity events and low temperature overpressure (LTOP) events and for hot shutdown conditions. The total risk contribution from all non-refueling outages was assumed to be equal to the refueling outage contribution.

(4) Potential impact on radiological exposure of facility employees. The reduction in dose from event cleanup (i.e., the frequency of events x the cleanup dose per event x remaining reactor-years) is estimated to be 17,000 person-Sv. Nearly all of this comes from improvements in PWR operation; less than 5 percent is attributable to BWR improvements. The occupational exposure increase from instrumentation improvements is estimated to be less than 30 person-Sv and is negligible. Thus, the total expected impact on radiological exposure of facility employees is a reduction of about 17,000 person-Sv. No estimate was made of immediate dose to workers on site at the time of a serious accident.

(5) Installation and continuing costs associated with the backfit, including the cost of facility downtime or cost of construction delay. The NRC separated industry costs into initial costs (one-time) and continuing costs (recurrent) as specified in Table 3. For analysis purposes, all licensees were assumed to incur costs based on "average" PWRs or BWRs. All costs are given in 1997 dollars and the operating costs are discounted at an annual rate of 7 percent. Labor cost rates were developed using NUREG/CR-4627, updated to 1997 dollars by assuming an annual rate of inflation of 5

percent.

The following industry costs were considered in the regulatory analysis:

- ù developing procedures and implementation of quality assurance to control shutdown operations and maintenance of those procedures
- ù providing operator training to minimize the frequency of events that interrupt or degrade shutdown cooling and training to ensure effective operator response to events that occur
- ù providing instrumentation to monitor and comply with the parameters and to monitor significant changes in the reactor coolant system parameters.
- ù reporting shutdown operations events that occur to the NRC in accordance with 10 CFR 50.72 and 50.73
- ù providing a mitigation capability following loss of decay heat removal events
- ù updating FSAR and technical specifications, and developing an understanding of system behavior

The NRC estimated there would be no cost impact from any extension in outage time. The mitigation requirements are judged to be sufficiently flexible that with deliberate and careful licensee planning, the rule can be satisfied with no increase in the duration of outages on an industry-wide basis. The total industry cost is estimated to be \$180 M in going from the base case to the rule case and \$137 M in going from the voluntary case to the rule case. These costs are estimated for the industry over the lifetime of all plants. Each plant would therefore need to spend only about \$1.8 M over the lifetime of the plant. These costs are similar for both cases because of the administrative burden associated with bringing a voluntary program under regulatory enforceable purview.

(6) The potential safety impact of changes in plant or operational complexity, including the relationship to proposed and existing regulatory requirements.

The rule is focused on a disciplined and safety-conscious approach to shutdown operations. Additional complexity is assumed to be added to the planning stages of an outage due to the rule. Well-planned and well-controlled

work

practices are important contributors to the benefits of the rule. The regulatory analysis assumes that these practices reduce the frequency of initiating events, and ensure the availability of systems for mitigating events. Therefore, although initial outage planning may be more complex, safety during the actual outage is expected to be enhanced.

Other proposed or existing regulatory requirements which address shutdown operation include the following:

ù The maintenance rule ( 50.65) focuses on assuring the reliability of equipment to fulfill its intended safety function. In conjunction with the proposed shutdown rule, changes are being proposed to the maintenance rule to include SSCs selected by the licensee for decay heat removal and event mitigation.

ù The reporting requirements ( 50.72 and 50.73) will be revised to have licensee's report events that result in or should have resulted in the actuation of the mitigation capability.

ù The requirements governing the content of the FSAR ( 50.34) will be revised to have licensees incorporate information related to fuel pool operations.

ù The shutdown rule requires revision of individual plant technical specifications.

ù The emergency preparedness regulations ( 50.47(b)(4) and Appendix E to 10 CFR Part 50) are applicable in all modes of operation. However guidance documents for developing emergency action levels (EALs) that meet the regulations do not adequately address shutdown operation. A regulatory guide containing guidance on EALs for the shutdown mode of operation is being developed.

ù License renewal ( 54.4(a)(3)) will reflect a change in scope consistent with 50.67 such that non-safety related structures, systems and components necessary for compliance with 50.67 are included within the scope of the license renewal rule. Safety related structures, systems and components necessary for compliance with 50.67 are already within the scope of license renewal in accordance with 54.4(a)(1).

(7) The estimated resource burden on the NRC associated with the

proposed

backfit and the availability of such resources.

NRC costs were estimated per site or, when a total was determined, it was divided according to the number of sites when assigning costs among PWRs and

BWRs. Headquarters and regional staff training as well as inspection and review time were included. The total estimated staff cost for all plants is

\$1.5 M. This cost is a negligible contributor to the value-impact analysis.

Staff resources are available for this work. Resources were estimated for the

following activities:

- ù resident inspector time to verify compliance with new requirements
- ù reviewing technical specifications and licensee bases for claiming compliance with the new regulation
- ù training resident inspectors
- ù training regional staff
- ù training headquarters project managers
- ù preparing temporary instructions and training material
- ù conducting training
- ù regional inspector time to verify compliance with new requirements
- ù headquarters inspector time to verify compliance with new requirements
- ù headquarters event receipt/response/analysis

(8) The potential impact of differences in facility type, design, or age on

the relevancy and practicality of the proposed backfit.

Facility type and design are significant factors in the backfit analysis. PWRs have a considerably higher net value and value-impact ratio than BWRs.

This is due largely to the lower estimated-core damage frequency (CDF) for

BWRs in the base case analysis and the assumption that the containment is open

for both reactor types in the base case. The lower CDF in BWRs is attributable to the greater number of required water addition sources in the

base case and the absence of a "mid-loop" operating state. Differences between PWR vendor designs and differences within a vendor type are not expected to make a significant difference in the analyses.

(9) Whether the proposed backfit is interim or final and, if interim, the

justification for imposing the proposed backfit on an interim basis.

The proposed backfit is final.

## 2 IDENTIFICATION AND PRELIMINARY ANALYSIS OF ALTERNATE APPROACHES

### 2.1 Take No Action

The "no action" option has been rejected on the basis of the regulatory

analysis and also for the following reasons:

ù Existing regulations do not provide an enforceable basis for effective regulation of shutdown operation.

ù Measures assumed for the voluntary case are unevenly applied across the industry, as evidenced by the number of events with serious implications that continue to occur, and increasing economic pressure in the absence of explicit regulations may result in a relaxation of current voluntary measures.

## 2.2 Issue an Information Notice

Shutdown operation encompasses a broader scope than can be addressed in an information notice, and there is no enforcement basis provided by an information notice.

## 2.3 Issue a Generic Letter or Bulletin

Generic letters and bulletins have been successful in improving shutdown operations. These approaches, however, do not establish a satisfactory enforcement basis since licensees can, in general, unilaterally change commitments made in response to these generic letters and bulletins; generic letters and bulletins may not achieve the same level of attention as provided to implement a technical specification (TS) or a rule.

## 2.4 Implement the Rule Published in 59 FR 52707

The 59 FR 52707 rule addressed many of the same areas covered by the presently proposed rule. However, consideration of public comments and Commission policy regarding the use of a performance-based approach guided by risk insights have led to a restructuring of the rule.

## 2.5 Rewrite the Maintenance Rule ( 50.65)

Industry representatives have suggested rewriting the maintenance rule ( 50.65), its regulatory guide, and industry documentation that is referenced in the regulatory guide. Although the maintenance rule and the associated guidance cover both power and shutdown operation, much of its effectiveness depends upon the definition of functional requirements that are clear for power operation and not well defined for shutdown operation. Rewriting the maintenance rule so that it had clear functional requirements for

shutdown  
operation would effectively produce a rule similar to that now proposed  
as  
50.67.

## 2.6 Modify and Prepare Technical Specifications Without Rulemaking

The staff's regulatory analysis shows that shutdown operation can be a significant contributor to overall risk and therefore the public should be given the opportunity to participate in the process of developing these requirements. Rulemaking is the preferred method of offering the public this opportunity to participate.

## 2.7 Implement a Risk-Informed Rule With Performance Elements

Rewriting the rule and regulatory guide using a risk-informed approach with performance elements wherever practical is the alternative selected.

## 2.8 Implement a Rule Applicable Solely to PWRs

The estimated probability of core damage is greater for PWRs than for BWRs. However, since PWRs generally have a more robust containment than can be economically provided for BWRs during much of shutdown operation, this greater probability of core damage does not translate into a greater probability of release of radioactive material. This regulatory analysis shows that the combination of core damage probability and containment characteristics results in similar release probabilities for the PWRs and BWRs, and it justifies a rule that applies to both. Consequently, a rule that excluded BWRs was rejected in favor of an industry-wide action.

## 2.9 Implement a Rule Applicable to PWRs During Midloop or Reduced Inventory

The perceived probability of core damage is greater during these aspects of operation than at other times during shutdown operation of PWRs. Overall, the regulatory analysis and defense-in-depth considerations justify a rule that covers all phases of shutdown operation when in the cold shutdown and refueling modes. Consequently, a rule limited to this narrow aspect of shutdown operation was rejected. Further, the rule is justified for both BWRs and PWRs during the cold shutdown and refueling modes.

## 3 ESTIMATION AND EVALUATION OF VALUES AND IMPACTS

### 3.1 Probabilistic Risk Assessment

A reference PRA was developed for the PWRs and another was developed for the BWRs. The NRC assumed that plant operations can be described on average by considering a four-loop Westinghouse PWR with a large, dry containment and a BWR-4 with a Mark I containment. Each represents the largest fraction of plants in its category.

The following accident initiators were considered:

- ù loss of offsite power causing loss of RHR
- ù loss of inventory (LOI) causing loss of RHR
- ù direct loss of the operating train of the RHR system
- ù loss of level (LOL) control causing loss of RHR (PWRs only)

Event trees were developed on the basis of the four initiators to describe the base case, voluntary case and the rule case. Each tree describes accident sequences leading to core damage and the consequential release of radioactive material. Core damage was taken as exceeding a clad temperature of 1200 °F.

The release of radioactive material following a core damage event was further considered in the analysis only if the release was unmitigated. An unmitigated release was assumed to be a significant fraction of the release that would occur during and following an accident in which (1) most of the core melted, (2) the reactor coolant system pressure boundary was breached or there was a large opening in the reactor coolant system (vessel head or primary side manways removed) and (3) a containment equipment hatch cover was removed that provided a direct release to the environment outside the plant. Releases via such paths as a BWR suppression pool would be reduced by a significant factor would represent success with respect to the prevention of unmitigated releases.

Logic trees were developed for certain major events, including the injection and ac power systems, to provide data for the event tree quantification.

The NRC assumed a 35-day refueling outage each 18 months of operation. It examined typical outage schedules and several shutdown operation PRAs,

which establish that most of the shutdown operation risk occurs before flooding the refueling cavity. Before initiating RHR, little risk was identified, few RCS configurations changed, and standard technical specifications (STSS) provided coverage equivalent to that provided for power operation as long as equipment was not removed from service in anticipation of entering modes in which it was not required. Consequently, the NRC judged that it could capture the more risk-significant portions of a refueling outage by analyzing two phases: from RHR initiation until reaching 200 °F with the RCS closed, and from that point until the refueling cavity was filled. This addressed 9 days of the 35 days of the outage for the PWRs and 6 days of the outage for BWRs. Analyses then established that the risk prior to entering cold shutdown was small. Consequently, the NRC's analyses, and the rule, were limited to the cold-shutdown and refueling modes. The NRC then added an assumed 10-20 percent to the calculated risk to approximate the entire refueling outage. Since this addition is small, there is little perturbation of the results and conclusions.

Nonrefueling outages also make up a significant fraction of shutdown operations. Nonrefueling outages consist of both scheduled outages and unscheduled outages, and can vary widely from a few hours in hot standby to many days in cold shutdown. The latter may or may not include extended periods with the containment and the RCS open, and may sometimes include extended midloop operation in PWRs. The NRC judged that, for purposes of the regulatory analysis, it could estimate the risk of non-refueling outage operation by assuming that the refueling outage results could be applied to nonrefueling outages. The judgment was based on consideration of the fact that the decay heat removal function is the primary concern in either case.

The NRC assumed nuclear power plants would be operated at power for 87 percent of the time. This time is compared in Table 1 to outage information provided in Nucleonics Week (August 22, 1996) for refueling outages at 34 U.S. plants during the spring of 1996.

A number of event categories were not directly included in the PRA because of plant-specific considerations. These include fire, internal flood, seismic, and weather-related impacts (although loss-of-offsite-power data were compiled for the total of all causes). The proposed rule covers fire through a separate analysis. Seismic considerations are implicitly addressed through the Commission's expectation that licensees will implement the rule's requirement to have a mitigation capability by using an emergency core cooling system or safety injection system that are designed to withstand the safe-shutdown earthquake.

The base case PRA did not explicitly account for licensees who voluntarily documented commitments in their FSARs in response to Generic Letters. Although these commitments have occasionally been so documented, this is a relatively unusual occurrence. When it has been done, it is usually enforceable as a design commitment and not as an availability or operational commitment. Therefore, consistent with the agency guidance on regulatory analysis, such commitments have not been included in the base case.

### 3.2 Estimation of Values

Values are the changes due to implementing the proposed rule in public and occupational radiation exposure with their associated monetary equivalent and changes in property damage. The NRC used the following values:

V1avoided public health risk (person-Sv or the monetary equivalent to dose in 1997 dollars)

V2avoided occupational exposure risk associated with accident management and cleanup (person-Sv or the monetary equivalent to dose in 1997 dollars)

V3avoided offsite property damage risk (1997 dollars)

V4avoided onsite financial risk due to cleanup and power replacement costs (1997 dollars)

V5change in routine occupational exposure due

to the implementation of the  
increases or decreases (person-Sv or the monetary equivalent to dose  
in  
1997 dollars)

The first four are positive with respect to decreases in the frequency of  
consequences of accidents. The fifth may be a positive (beneficial) or  
negative perturbation associated with a decrease or increase,  
respectively,  
in the routine occupational exposure to implement the changes.

The shutdown dose consequence to the public within a 50-mile radius for  
an  
unmitigated release from the Surry plant at the Surry site is taken as  
104  
person-Sv (106 person-rem) (NUREG/CR-6144). This value has been  
estimated  
using the MELCOR and MACCS codes assuming a severe accident following an  
event  
during mid-loop operations. The dose consequences as presented in  
NUREG/CR-  
6144 ranges from  $3 \times 10^3$  to  $2 \times 10^4$  person-Sv. Little information is  
available  
of a comparable quality for shutdown operation at other plants.  
Consequently,  
the NRC assumed that the Surry result could be applied to other plants as  
follows:

ù by multiplying the Surry result by each plant's full-power level  
divided  
by the Surry full-power level to account for radionuclide inventory

ù by multiplying the preceding result for each plant by the respective  
plant release characteristics for a full-power accident  
(NUREG/CR-2239)  
divided by the Surry release characteristics for a full-power  
accident to  
account for individual siting characteristics

Other assumptions included:

ù Plant-specific information (applicable to Surry) was used for loss of  
offsite power.

ù Each plant's remaining life (from 1997) was individually accounted  
for  
and core-damage accidents were assumed equally probable from 1997 to  
the  
end of the 40-year plant life for each plant.

ù A 5-percent inflation value and a 7-percent discount value were used  
to  
adjust dollar values that were determined or assumed for years other  
than

1997.

### 3.3 Estimation of Impacts

Impacts are the costs and savings for the changes evaluated in the regulatory analysis. The NRC used the following:

I1cost to the NRC covering training, inspection, review, and monitoring associated with the changes (positive impact) (1997 dollars)

I2direct cost to the licensee to implement the changes and perturbation in operating cost (positive or negative impact) (1997 dollars)

The assumptions applicable to impact estimation are the same as those discussed in Section 3.2 for value estimation.

### 3.4 Evaluation of Values and Impacts

Values and impacts were combined to form the following equation, which represents the net value of a proposed regulatory action in 1997 dollars:

$$NV = V1 + V2 + V3 + V4 + V5 - (I1 + I2)$$

The value attributes V1, V2, and V5 are converted from person-Sv to 1997 dollars by assuming \$200 K per person-Sv (COMSECY-95-033).

The corresponding impact/value ratio is defined as follows:

$$I/V = (I1 + I2)/(V1 + V2 + V3 + V4 + V5)$$

This regulatory analysis is based upon 73 PWRs and 37 BWRs that are assumed located on 49 and 31 sites, respectively. Essentially identical nuclear steam supply systems (NSSSs) were assumed to be located at the same site. Those that differ in design were treated as though they were located at different sites for all purposes except for assessing the effect of an accident at one site on the operation of other NSSSs at the same site. Thus, for most purposes, two sites are associated with Millstone: one for the BWR and one for the two PWRs. Similarly, one site is associated with Oconee and one with Palo Verde, sites that each contain three PWRs.

#### 3.4.1 Avoided Public Health Risk (V1)

For any given plant  $i$ , the estimate of V1 is obtained:

V1iB-R = avoided public health risk (1997 dollars) in moving from the

base case  
to the rule case for plant i

This was calculated by first obtaining the incremental change in containment release frequencies via the PRA discussed in Section 3.1. Consider the PWRs and a comparison of the base case to the rule case as an example. The PRA provides the following:

$f_{RC-1} = f_{RC-1PWRB-R} \cdot f_{RC-1}$  = reduction in frequency of an open containment type release (RC-1) for a PWR moving from the base case to the rule case

Plant-specific source terms associated with shutdown accidents are generally not available. Brookhaven National Laboratory recently estimated the shutdown-related dose consequences to the public within 50 miles for an open containment type release for Surry as 106 person-rem (NUREG/CR-6144). As previously discussed, the NRC applied the Surry estimate to each individual plant by adjusting it for power level (radionuclide inventory) and location (siting). Thus, for nuclear power plant i, one has the following:

$P_i$  = thermal power (MWt) associated with nuclear plant i

$SSF_i$  = site scaling factor to account for the conditional latent cancer fatalities from a reference plant (i) (NUREG/CR-2239).

Now  $p_d(RC-1i)$ , the conditional public dose (person-Sv) associated with RC-1-type releases for plant i, can be obtained from the following equation:

where:

$p_d(RC-1Surry)$  is 1.0 ' 104 person-Sv (1.0 ' 106 person-rem),

is the source term scaling factor, and

is the site scaling factor.

The annual per-plant reduction in public dose consequences (person-Sv) for RC-1 type releases is:

One can convert the annual per-plant reduction in public dose to a monetary equivalent (1997 dollars) by assuming \$200 K for a person-Sv (\$2000 for a person-rem):

The avoided public health risk associated with moving from the base case to the rule case for the RC-1-type release for plant  $i$ , expressed in monetary equivalent value, is:

where:

$r$  = real discount rate (fraction)  
 $t_i$  = years remaining until end of plant  $i$  life.

The total avoided public health risk for plant  $i$  associated with moving from the base case to the rule case for all RC type releases is:

Summing over all plants in a class, e.g., all PWRs, yields:

where  $I$  = total number of PWRs.

The approach for BWRs is similar but as a group, BWRs yield the different resultant values because of the differences in number of BWRs, their lower CDF in the base case and site specific differences.

#### 3.4.2 Avoided Occupational Health Risk (V2)

Estimation of avoided onsite consequences depends on CDF and accompanying containment effectiveness. The occupational exposure consists of immediate and long-term components.

The number of personnel on site during an outage typically ranges from a few hundred to a thousand and, as reported in NUREG-1410, evacuation is not assured. The potential exists for an immediate high dose to onsite personnel. Despite this, the NRC has not included this potential effect in the impact/value assessment because of the large uncertainty involving personnel movements.

Long-term occupational exposure occurs when cleanup and recovery take place beyond work immediately associated with the accident. The value used as an estimate for this exposure was based on a study of decommissioning a reference light-water reactor following a major loss-of-coolant accident in which the emergency core cooling system was delayed in starting (NUREG/CR-2601). All fuel cladding was assumed to rupture with significant fuel melting and core damage. It was also assumed that the containment building was extensively contaminated, and that the auxiliary building was contaminated too. The estimated occupational radiation dose from cleanup and recovery was 200 person-Sv. The postulated shutdown accident assumes significant contamination of the auxiliary building and other buildings, as well as the surrounding plant area, because the containment is assumed to be open, in contrast to the case discussed in NUREG/CR-2601 in which the containment was closed. For purposes of impact/value analysis, the NRC assumed that the 200 person-Sv value was appropriate for the Surry plant discussed in NUREG/CR-2601 and consistent with a closed containment. The NRC then assumed exposures of 600 person-Sv for the more serious conditions that would exist without containment for those releases. Values at all other plants were adjusted relative to these values based on each plant's power level. The conversion to 1997 dollars assumes \$200 K/person-Sv.

### 3.4.3 Avoided Offsite Damage to Property (V3)

Offsite property loss is one of the major value categories for calculating avoided risk. In severe accidents, property damage off site can exceed the damage on site. Public property damage costs, V3, were calculated using an analysis similar to that for V1 as described in Section 3.4.1.

Scaled results for property damage costs, given a radionuclide release from

the containment, were obtained from NUREG/CR-2723. This study reported offsite property costs for accidents at 91 U.S. sites with licensed reactors or construction permits. These values were updated to 1997 dollars using an annual inflation rate of 5 percent. A public property damage cost of \$800 M per unmitigated release for Surry at the Surry site was used and the value adjusted for each other plant was based on that particular plant's power level and site characteristics.

These offsite property damage costs were discounted at a 7-percent rate for each year after 1997, when the risk reductions were assumed to begin.

#### 3.4.4 Avoided Onsite Power Replacement and Cleanup (V4)

Replacement power costs were derived by first assuming the replacement power costs determined in NUREG/CR-4627, and then adjusting these figures, established in 1988, to 1997 dollars by assuming a 5-percent annual inflation rate. For the damaged plant, the time for replacement power is the remaining life of the plant with costs adjusted to 1997 dollars assuming a 7-percent annual discount rate. For sites with more than one unit, it was assumed that the undamaged unit(s) would be shut down for 2 years after the accident, and thus replacement power would also be needed for the undamaged unit(s). No allowance was taken for cleaning up of such undamaged units.

Cost estimates for cleanup were obtained from a study that estimated the cost of a major loss-of-coolant accident in which emergency core cooling was assumed to be delayed (NUREG/CR-2601). In that study, it was assumed that the cleanup activities would take 10 years and the cost would be \$373 M per event. No distinction was made between BWRs and PWRs. The onsite consequences were limited to the containment and auxiliary buildings. Thus, as discussed for V2 (Section 3.4.2), this value was assumed. Consequently, this value was tripled for a case with no containment. In addition, the "\$373 M" was adjusted for 5-percent annual rate of inflation, bringing it from its 1983 value to \$73.8 M/yr as a 1997 estimate.

The total cleanup costs were discounted at a 7-percent rate for each year after 1997, when the CDF reductions were assumed to begin. Cleanup costs were added to the power replacement cost to get total costs. The total yearly cleanup and power replacement costs, given core damage, were then expressed in 1997 dollars.

Avoided property damage cost, V4, due to cleanup and power replacement given a core-damage accident, was calculated by adding the cost of replacement power to the cost of cleanup.

#### 3.4.5 Routine Occupational Health Risk (V5)

For routine occupational health risk (V5), an exposure of 3 person-rem during instrumentation installation per unit and 0.5 person-rem per unit per outage thereafter was assumed. Consistent with the rest of the regulatory analysis, a refueling outage and a maintenance outage were assumed each 18 months [(12 months/yr)/(18 months) \* (2 outages) = 1.333 outages/yr]. For the per-outage value, the conversion to 1997 dollars, assuming \$200 K/person-Sv and a 7-percent discount rate, is the same as described under Section 3.4.1 for V1. For the one-time installation exposure, the 1997 value is \$6000 per unit.

#### 3.4.6 Costs or Savings to NRC (I1)

NRC costs were estimated on a per-site basis or, when a total was determined, it was divided according to the number of sites when assigning costs between PWRs and BWRs. A cost of \$56/hr was used since the rule was assumed not to change overhead associated with the NRC offices and general support, and such support was assumed covered by existing NRC work. The following outage activity elements were identified:

ù resident inspector time to verify compliance with new requirements:  
(10 staff-day/site) \* (8 hr/day) (\$56/hr) = \$4480/site

ù review technical specifications: (20 staff-day/site) \* (8 hr/day) \* (\$56/hr) = \$8960/site

ù training resident inspectors: (5 staff-day/site) \* (8 hr/day) \* (\$56/hr)

= \$2240/site

ù training regional staff: (10 staff-day/region) ' (4 region) ' (8 hr/day)  
' (\$56/hr) = \$17,920

ù training headquarters project managers: (2 staff-day/staff) ' (75 staff)  
' (8 hr/day) ' (\$56/hr) = \$67,200

ù preparing temporary instructions and training material: (30 staff-day) '  
(8 hr/day) ' (\$56/hr) = \$13,440

ù conducting training: (40 staff-day) ' (8 hr/day) ' (\$56/hr) = \$17,920

ù regional inspector time to verify compliance with new requirements:  
(5 staff-day/site) ' (8 hr/day) ' (\$56/hr) = \$2240/site

ù headquarters inspector time to verify compliance with new requirements:  
(2 staff-day/site) ' (8 hr/day) ' (\$56/hr) = \$896/site

ù headquarters event receipt/response/analysis (20 staff-days/year) '  
(8 hr/day) ' (\$56/hr) = \$8,960

The total cost of these ten activities for all PWRs is PWRI(1)rule = \$0.96 M.

For all BWRs, it is BWRI(1)rule = \$0.54 M. These costs are summarized in Table

2.

Table 2. Base Case to Rule Case

ACTIVITY	NRC Costs for (47 sites)	50.67 PWRs COST \$K	BWRs COST \$K (26 sites)	TOTAL COST \$K
Resident Inspector Time to Verify	210.5	116.5	327	
Review Technical Specifications	421.1	232.9	654	
Training Resident Inspectors	105.3	58.2	163.5	
Training Regional Staff	9.0	9.0	18	
Training HQ Project Managers	43.3	23.9	67.2	
Preparing TI's and Training Material	6.7	6.7	13.4	
Conducting Training	9.0	9.0	18	
Regional Inspector Time to Verify	105.3	58.2	163.5	
HQ Inspector Time to Verify	42.1	23.3	65.4	
HQ Event Receipt/Response/Analysis	5.8	3.2	9.0	
Total NRC costs (\$K)	958.1	540.9	1,499.0	

### 3.4.7 Direct Costs or Savings to Licensees (I2)

The NRC separated industry costs into two subcategories: implementation or one-time costs, and operating or continuing costs.

The nature of these costs (i.e., implementation, operating, or both) was also investigated. For analysis purposes, all licensees were assumed to incur costs based on "average" PWRs or BWRs. Implementation of the rule is judged to be less costly for the BWRs since there is less work to be done and the estimates are provided accordingly. All costs are given in 1997 dollars and all operating costs are discounted at an annual rate of 7 percent. Labor cost rates were developed using NUREG/CR-4627, updated to 1997 dollars by assuming an annual rate of inflation of 5 percent. In each of the following calculations, the base case to rule case is calculated first, then an adjustment is made according to NRC staff estimates of the extent to which industry has already voluntarily complied with rule " thus developing an estimate of the costs for voluntary case to rule case.

The following industry costs were calculated:

ù TS update " PWRs: (28 new pages/NSSS) ' (\$5000/page) ' (73 NSSSs) = \$10.2 M base case and voluntary case; BWRs: (24 new pages/NSSS) ' (\$5000/page) ' (37 NSSSs) = \$4.4 M base case and voluntary case

ù develop system behavior understanding " PWRs: \$3 M; BWRs: \$0.5 M

ù develop and/or modify operations and maintenance procedures " PWRs: (3 owners groups) ' (200 pages/owners group) ' (\$3000/page)= \$1.8 M plus (200 pages/site) ' (47 sites) (\$1500/page) = \$14.1 M base case which totals \$15.9 M and 50 percent is estimated for voluntary case =\$8.0 M; BWRs: (1 owners group) ' (35 pages/owners group) (\$3000/page) = \$0.1 M plus (35 pages/site) ' (26 sites) ' (\$1500/page) = \$1.4 M base case which totals \$1.5 M and 50 percent is estimated for voluntary case =\$0.8 M. The difference in the number of pages between PWRs and BWRs represents more extensive procedure modification for the PWRs.

ù new plans for operating in compliance with the new rule requirements " PWRs: (20 staff-weeks/site) ' (47 sites) ' (40 hr/wk) ' (\$100/hr) = \$3.8

M base case and voluntary case; BWRs: (8 staff-weeks/site) ' (26 sites) ' (40 hr/wk) (\$100/hr) = \$0.8 M base case and voluntary case

ù provide instrumentation " A number of PWR licensees have installed level instrumentation systems that are assumed to meet the requirements.

The

NRC assumed that 45 PWRs do not have the necessary level instruments. The NRC also assumed that little work was needed to provide

temperature

instrumentation for PWRs. All BWRs were assumed to need improved temperature instrumentation. PWRs: (45 NSSSs) ' (\$300,000/unit) =

\$13.5

M base case and \$5.2M voluntary case; BWRs: (37NSSSs) ' (\$300,000/unit) =

\$11.1 M base case and voluntary case

ù develop or modify (or both) QA procedures " PWRs: (3 owners groups) ' (150 pages/owners group) ' (\$3000/page)= \$1.4 M plus (300 pages/site)

(47 sites) (\$1500/page) = \$21.2 M which totals \$22.6 M for the base case

and voluntary case; BWRs: (1 owners group) ' (150 pages/owners group) (\$3000/page) = \$.5 M plus (300 pages/site) ' (26 sites) ' (\$1500/page) =

\$11.7 M which totals \$12.2 M for the base case and voluntary case.

Industry costs are incurred over the remaining life of each NSSS and are individually converted to a present value via  $[1-\exp(-rt_i)]/r$ , where  $r$  = discount rate (7 percent) and  $t_i$  = remaining life of plant "i."

The

present values are:

ù operator training " PWRs: (1 staff-mo) ' (4.3 wk/mo) ' (40 hr/wk) ' (\$100/hr) '  $[1-\exp(-rt_i)]/r$  = \$14 M base case and 50 percent is estimated for voluntary case = \$7.0 M; BWRs: (1 staff-wk) ' (40 hr/wk)

(\$100/hr) '  $[1-\exp(-rt_i)]/r$  = \$1.7 M base case and 50 percent is estimated for voluntary case = \$.9 M

ù instrumentation per NSSS " PWRs: (\$2000) '  $[1-\exp(-rt_i)]/r$  = \$1.6

M

base case and voluntary case; BWRs: (\$2000) '  $[1-\exp(-rt_i)]/r$  =

\$0.8 M

base case and voluntary case where the NRC assumed \$2000 of

maintenance

cost per NSSS unit per year.

ù procedures maintenance " PWRs: (20 pages/yr) ' (\$1500)  $[1-\exp(-rt_i)]/r$  = \$24.4 M base case and 50 percent is estimated voluntary case = 12.2 M; BWRs : (20 pages/yr) ' (\$1500))  $[1-\exp(-rt_i)]/r$  = \$12.0 M

base

case and 50 percent is estimated for voluntary case = \$6.0 M

ù quality assurance " PWRs: (1 staff-mo) ' (4.3 wk/mo) ' (40 hr/wk) ' (\$100/hr) '  $[1-\exp(-rt_i)]/r$  = \$14 M base case and voluntary case;

BWRs: (1 staff-mo) ' (4.3 wk/mo) ' (40 hr/wk) ' (\$100/hr) '
   
 $[1 - \exp(-rti)]/r = \$6.9 \text{ M}$  base case and voluntary case
   
 ù event reporting " PWRs: (1 staff-wk) ' (40 hr/wk) ' (\$100/hr) '
   
 $[1 - \exp(-rti)]/r = \$3.3 \text{ M}$  base case and voluntary case; BWRs: (1 staff-wk) '
   
 (40 hr/wk) ' (\$100/hr) '  $[1 - \exp(-rti)]/r = \$1.7 \text{ M}$  base case and
   
 voluntary case
   
 Total industry implementation cost is summarized in Table 3 for the base
   
 case
   
 and the voluntary case.

Table 3. Base Case to Rule Case and Voluntary Case to Rule Case
   
 (Industry Costs for 50.67)

TASK (\$M)	Base Case to Rule Case (\$M)	Voluntary Case to Rule Case (\$M)
PWRs		
BWRs		
Total		
Tech Spec Update	10.24	4.61
Develop System Behavior	3.00	53.53
New Operations/Maint Procedures	15.91	517.48
New Plans	3.80	84.63
Provide Instrumentation	13.51	1124.65
New QA Procedures	22.61	234.82
Subtotal (Initial Costs)	69.03	599.55
Operator Training	14.01	715.77
Instrumentation Maintenance	1.60	82.41
Procedures Maintenance	24.41	2.03
Quality Assurance	14.06	920.91
Event Reporting	3.31	75.03
Subtotal (Present Value Continuing Costs)	57.32	3180.43
Total Cost to Industry	126.35	36179.99

#### 4 DISCUSSION OF RESULTS

Comparisons of the base cases, voluntary cases, and rule cases for both
   
 PWRs
   
 and BWRs are summarized in Table 4. The base case represents shutdown
   
 risk
   
 crediting only equipment required by regulation (assumed in Standard TS).
   
 The
   
 voluntary action case includes equipment required by regulation and
   
 equipment
   
 voluntarily added by the licensee based on NRC and industry guidance.
   
 The
   
 rule case represents shutdown risk crediting equipment as described in
   
 the
   
 Statement of Considerations and the Regulatory Guide for 50.67.
   
 Details of

these cases are provided in subsequent sections. Results of an impact/value analysis that was performed simultaneously with the PRA are summarized in Table 5. The net values are positive and the impact/value ratios are less than 1, showing that the rule is justified.

Table 4. Probabilistic Risk Assessment

Results

Regulatory Analysis  
Alternative

Core damage Frequency  
events/reactor-year  
Frequency of Unmitigated  
reactor-year

Release per

PWRBWRPWRBWR  
Potential Regulatory  
Minimum (Base Case):

	2E-2			
		1E-3		
			2E-2	
				1E-3

Estimate of Industry Practice  
per NUMARC 91-06  
(Voluntary Case):

	8E-5 to 2E-6			
		1E-5 to 6E-7		
			2E-5 to 2E-7	
				8E-6 to 6E-7

Proposed  
Requirements  
(Rule Case):  
(S/D only)  
Comparable  
Equipment

Intact  
Containment

	1E-5			
	8E-5			
		4E-6		
		8E-6		
			1E-6	

1E-6

4E-6

4E-6

Table 5. Impact/Value Summary

Item	PWR	BWR
Net Value, \$M153,000 5,100		
Impact/Value (dimensionless)	0.001	0.01

The Regulatory Analysis results show that the most significant risk reduction in moving from the base case to the rule case is achieved in several increments. The most significant reduction in risk is derived from the introduction of an ECCS injection path for PWRs and a RCS venting capability for BWRs (SRV operability). The PWR ECCS injection path and BWR RCS venting capability are not currently required to be available by TS in cold shutdown and refueling. The second most significant reduction in risk results from the introduction of procedures as required by 50.67(a)(1) including those for training, quality assurance, and corrective actions. This portion of the rule is credited with a reduction in the frequency of initiating events and an increase in the probability of restoring a RHR system if it is lost. The third most significant incremental reduction in risk results from the introduction of either a containment that is expected to reduce the release frequency significantly or a risk-comparable mitigation capability.

In terms of relative cost, the requirement for maintaining mitigation capability available is less than the procedural elements or the rule. This is because equipment such as the ECCSs is already installed and can be readily aligned with no additional equipment acquisition. The largest cost associated with the shutdown operations portion of the rule (excluding fire protection) is that associated with the development of procedures for training, quality assurance, and corrective actions. In addition to reducing risk, these procedures have the unquantifiable benefit of enforceability; it permits the NRC to inspect and enforce safe operation during shutdown and refueling. However, the overall cost for rule implementation is modest, averaging about \$1.8 M per plant over the remaining lifetime of the plant.

In summary, the rule case significantly reduces risk from the base case. The rule permits the NRC to inspect and enforce safe operation practices before an event occurs. The rule reduces risk from plants that are below average in safety. The rule also ensures a minimum level of safety by greatly reducing risk from what it would be if plants chose to comply with little more than what is required by present regulation. Nevertheless, little reduction in overall risk is achieved by the rule for the licensee who has adopted effective voluntary practices that reduce risk for shutdown operation.

#### 4.1 Net Value

The important risk measures are the CDFs and the corresponding release frequencies. The release frequencies drive the public value attributes V1 and V3, which are the most important attributes in the net value equation. The CDFs drive the onsite risk value attributes V2 and V4.

Estimated net values are shown in Table 6. Both the PWR and BWR net values are positive when the base case is compared to the rule case, indicating that it is worthwhile, from an impact and value perspective, to proceed with the proposed rule.

Table 6. Value Impact Analysis

Attribute	PWR \$M	BWR \$M
V1, avoided public exposure	91,900	2,920
V2, avoided worker exposure	5,700	238
V3, avoided offsite property damage	36,800	1,160
V4, avoided cleanup & power replacement	18,800	855
V5, routine worker exposure	-1.5	-0.8
I1, Cost to NRC	0.96	0.5
I2, Cost to licensee	104.34	2.8
NV, Net value	153,100.5	129
Impact-value ratio	0.001	0.01

#### 4.2 Attributes for Each Case

The results for the seven attributes (5 values and 2 impacts), that together yield the net values, are summarized in Table 6. The avoided public

health

risk (V1) is the dominant value. (It is sufficiently large that the net value, PWRNVB, would still be positive if all the other values (V2, V3, V4, and

V5) were zero.) However, V3, avoided offsite property damage, and V4, avoided

onsite costs, also are important contributors. Avoided occupational exposure

associated with accident management and cleanup (V2) contributes a small amount. Routine occupational exposure from implementation of new requirements

(V5) is a negative value but almost negligible. The dominant impact is direct

licensee cost to implement the new requirements and changes in operating costs

(I2). The cost to the NRC (I1) is essentially negligible.

#### 4.3 Non-Quantifiable or Poorly Quantifiable Attributes

Section 50.67(a)(1) will result in some benefits that are quantifiable and

some that are not quantifiable. These non-quantifiable benefits include the

improved enforceability and inspectability that are facilitated by the procedures for training, quality assurance, and corrective actions to ensure

compliance with the requirements of rule. The requirement of 50.67 to develop TS also facilitates the inspectability and enforceability of the rule.

These non-quantifiable benefits permit the NRC to reduce the number of significant events, particularly those that may occur at plants with practices

that are well below average in terms of safety and, thus, more susceptible to

identification through inspection and remediation through enforcement.

#### 4.4 Key Assumptions

##### 4.4.1 Base Case

For the base case, the Regulatory Analysis Guidelines (NUREG/BR-0058, Rev. 2)

specify that no credit may be given for voluntary actions taken by licensees.

Therefore, with respect to equipment availability, the base case only credits

equipment that is required to be operable by Standard Technical Specifications

(STS).

The base case estimates credit:

- ù one onsite power source

- ù one offsite power source

- ù 2 trains of RHR (which also meet BWR Mode 5 ECCS LCOs) and support

- equipment
- ù PORV operability (PWR LTOP TS)
- ù RHR automatic isolation on Level III (BWRs)
- ù operator recovery actions

Since the following equipment is not required by TS to be available, the base case does not credit:

- ù containment
- ù PWR ECCS capability
- ù BWR RCS venting capability (SRV operability)

#### 4.4.2 Voluntary Action Case

As recommended in NUREG/BR-0058, a voluntary action case was performed that credits voluntary initiatives. This case credited equipment required by TS and equipment recommended to be available based on guidance from GL 88-17 and NUMARC 91-06. For PWRs, GL 88-17 recommended the following to be implemented during reduced inventory operations: containment closure procedures, two means of adding inventory to the RCS in addition to the two RHR pumps, level and temperature instrumentation. NUMARC 91-06 provided high level guidance to BWR and PWR licensees on how to control outage risk.

For both PWRs and BWRs, two voluntary action cases were performed representing different interpretations of NUMARC 91-06 and GL 88-17. The higher CDF voluntary case represents a minimal implementation of both guidance documents, in terms of the amount of extra equipment and additional sources of water being made available. The low CDF voluntary case represents a more in-depth implementation of both guidance. Both PWR and BWR cases include improved initiating event frequencies and improved operator recovery actions. These two cases are not meant to bound current plant operations but are intended to be examples of reasonable interpretations of the referenced guidance.

The higher CDF voluntary case for BWRs credits equipment credited in the base case plus, two operable SRVs, an additional low pressure injection pump, and a long term source of water. The lower CDF voluntary case includes the equipment described in the high voluntary action case plus an additional EDG

(or equivalent onsite power source), high pressure service water, fire water, and core spray. For PWRs, the higher CDF voluntary action case includes the equipment credited in the base case, plus 1 ECCS injection pump, gravity feed, and an "available" containment. The lower CDF PWR voluntary action case adds: an additional EDG (or equivalent power source), a second ECCS pump, containment spray pumps (to supplement the RHR pumps), steam generator heat removal, and a recirculation capability. (An "available containment" is defined as one that can be closed by remote or local manual actions before containment conditions become intolerable.)

#### 4.4.3 Rule Case

The rule case only credits equipment as outlined in the Statement of Considerations and the Regulatory Guide for 50.67. The following equipment was credited:

- ù 2 RHR trains, including support equipment
- ù 1 emergency core cooling system (ECCS) pump and support equipment (one of the RHR pumps for BWRs)
- ù 1 emergency diesel generator
- ù 1 source of offsite power
- ù equipment comparable in mitigation capability to an intact containment
- ù indication of temperature immediately above core inside the reactor vessel (RV)
- ù accurate RV water level indication
- ù pressure control capability (2 SRVs for BWRs or 2 PORVs for PWRs)
- ù level III isolation capability for BWRs
- ù a long term source of water or a recirculation capability
- ù reduced initiating event frequencies and improved operator recovery actions.

Since it is the staff's expectation that the licensee will have an intact containment or an additional mitigative capability that is comparable to an intact containment, two risk estimates are provided in Table 4. For BWRs, the additional mitigative capability that is comparable to an intact containment includes fire water. For PWRs, the additional mitigative capability includes an "available containment", an additional injection source, an additional EDG (or equivalent onsite power source), steam generator heat removal, and gravity feed.

## 5 RATIONALE FOR SELECTING THE PROPOSED ACTION

As discussed in this regulatory analysis, a quantitative value-impact analysis using PRA techniques shows large positive net values for the prescribed "base case to rule case" comparison for both PWRs and BWRs, despite a bias built into the analysis that undercalculates the worth of the rule. This bias was principally the omission of certain external events from the calculations. In addition, the non-quantifiable attributes of the proposed rulemaking are substantial; they include the ability to inspect and enforce elements of safe operation during the shutdown condition.

### 5.1 Relationship to Other NRC Programs and Requirements

Modifications are expected in plant-specific TSs and in the STSSs documented in NUREG-1430, NUREG-1431, NUREG-1432, NUREG-1433, and NUREG-1434 (Standard TSs for NSSSSs [and associated plants] applicable to Babcock & Wilcox, Westinghouse, Combustion Engineering, General Electric BWR/4 designs, and General Electric BWR/6 designs, respectively). Some of these changes have been addressed in this regulatory analysis and in associated rulemaking documentation.

The rule will result in inspection activities that are broadly covered by the NRC's Five-Year Plan. Headquarters, regional, and resident inspector personnel will be trained in the rule's features and its implications. Workshops will be conducted to update licensee and vendor personnel and to explain NRC's expectations. Inspection depth will be tailored to the adequacy of licensee implementation and the observed effectiveness on event frequency and mitigation.

The decision to proceed with rulemaking is consistent with NRC's safety goal screening criteria. Guidance on what constitutes a substantial increase in the overall protection of public health and safety appears in Table 7 (taken from NUREG/BR-0058).

By the agency's procedures, the staff is required to assume that in the base case, licensees follow no more than what is required by the regulations and

technical specifications. The difference between the base case and the rule case is used as a decision criterion. The CDF reduction in moving from the base case to the rule case of 10<sup>-3</sup> to 10<sup>-2</sup> per reactor-year in combination with a containment that is not required to be closed, meets the criteria of Table 7 to proceed, and the NRC consequently developed the PRA and the proposed rulemaking.

## 5.2 Statement of Proposed Generic Requirement

The following proposed rule will be published in the Federal Register for comment:

### PART 50 " DOMESTIC LICENSING OF PRODUCTION AND UTILIZATION FACILITIES

1. The authority citation for Part 50 continues to read as follows:

AUTHORITY: Secs. 102, 103, 104, 105, 161, 182, 183, 186, 189, 68 Stat. 936, 937, 938, 948, 953, 954, 955, 956, as amended, Sec. 234, 83 Stat. 1244, as amended (42 U.S.C. 2132, 2133, 2134, 2135, 2201, 2232, 2233, 2236, 2239, 2282); Secs. 201, as amended, 202, 206, 88 Stat. 1242, as amended, 1244, 1246 (42 U.S.C. 5841, 5842, 5846), E.O. 12829, 3 CFR, 1993 Comp., p. 570; E.O. 12958, as amended, 3 CFR, Comp., p.333; E.O. 12968, 3 CFR, 1995 Comp., p. 391.

Sec. 50.7 also issued under Pub. L. 95-601, Sec. 10, 92 Stat. 2951 as amended by Pub. L. 102-486, Sec. 2902, 106 Stat 3123 (42 U.S.C. 5851). Sec. 50.10 also issued under Secs. 101, 185, 68 Stat. 936, 955, as amended (42 U.S.C. 2131, 2235); Sec. 102, Pub. L. 91-190, 83 Stat. 853 (42 U.S.C. 4332). Secs. 50.13, 50.54(dd), and 50.103 also issued under Sec. 108, 68 Stat. 939, as amended (42 U.S.C. 2138). Secs. 50.23, 50.35, 50.55, and 50.56 also issued under Sec. 185, 68 Stat. 955 (42 U.S.C. 2235). Secs. 50.33a, 50.55a and Appendix Q also issued under Sec. 102, Pub. L. 91-190, 83 Stat. 853 (42 U.S.C. 4332). Secs. 50.34 and 50.54 also issued under Sec. 204, 88 Stat. 1245 (42 U.S.C. 5844). Secs. 50.58, 50.91, and 50.92 also issued under Pub. L. 97-415, 96 Stat. 2073 (42 U.S.C. 2239). Sec. 50.78 also issued under Sec. 122, 68 Stat. 939

(42 U.S.C. 2152). Secs. 50.80-50.81 also issued under Sec. 184, 68 Stat. 954, as amended (42 U.S.C. 2234). Appendix F also issued under Sec. 187, 68 Stat. 955 (42 U.S.C. 2237).

2. In 50.8, paragraph (b) is revised to read as follows:

50.8 Information collection requirements: OMB approval

\*\*\*\*\*

(b) The approved information collection requirements contained in this part appear in 50.30, 50.33, 50.33a, 50.34, 50.34a, 50.35, 50.36, 50.36a, , 50.36b, 50.44, 50.46, 50.47, 50.48, 50.49, 50.54, 50.55, 50.55a, 50.59, 50.60, 50.61, 50.62, 50.63, 50.64, 50.65, 50.66, 50.67, 50.71, 50.72, 50.73, 50.74, 50.75, 50.80, 50.82, 50.90, 50.91, 50.120 and appendices A, B, E, G, H, I, J, K, M, N, O, Q, R, and S to this part.

\*\*\*\*\*

3. Section 50.2 is revised by adding in alphabetical order the definition for Shutdown operation as follows:

50.2 Definition

\*\*\*\*\*

Shutdown operation means the reactor coolant system (RCS) is in Cold Shutdown or Refueling (as defined in a plant s technical specifications) and one or more fuel assemblies are located in the reactor vessel or in the refueling cavity. Shutdown operation is a part of normal operation.

\*\*\*\*\*

4. Section 50.34 is revised to read as follows:

50.34 Contents of applications; technical information

\*\*\*\*\*

(b) \*\*\*  
(12) The assumptions and parameter values used in safety analyses required by 50.67(b) as reference bounds for design to demonstrate adequate decay heat removal for the fuel storage pool.

\*\*\*\*\*

5. Section 50.65(b) is revised to insert a new subparagraph (b)(2)(iv) as follows:

50.65 Requirements for monitoring the effectiveness of maintenance at nuclear power plants.

\*\*\*\*\*

(b) \*\*\*  
(2) \*\*\*  
(iv) necessary for compliance with 50.67 of this part.

\*\*\*\*\*

6. A new 50.67 is added to read as follows:

50.67 Shutdown and Fuel Storage Pool Operations at Nuclear Power Plant

(a) Shutdown Operations. Holders of operating licenses and combined licenses for a light-water reactor nuclear power plant, except those plants that have been permanently shut down with fuel permanently removed from the reactor vessel, shall comply with the following requirements except when all fuel has been transferred out of the reactor vessel:

(1) Shutdown Operation Procedures. Licensees shall establish and implement procedures (including procedures for training, and quality assurance and corrective action measures) for the activities for complying with the requirements of paragraph (a) of this section. Except for those procedures necessary for complying with paragraph (a)(4) of this section, the criteria for determining the adequacy of the procedures and the method for establishing, modifying, and superseding the procedures must be described in the administrative controls section of technical specifications.

(2) Performance Monitoring.

(i) Licensees shall establish, monitor, and comply with parameter limits during shutdown operation. The parameter limits must ensure compliance with the following safety function limits:

(A) Decay heat removal such that the water temperature above the reactor core is less than the saturation temperature.

(B) Reactor Coolant System (RCS) inventory control such that the RCS water level is sufficient for reliable operation of the normal means of decay heat removal.

(C) RCS and connected systems pressure control such that the design pressure and Low Temperature Overpressure Protection (LTOP) settings are not exceeded.

(ii) The parameters, parameter limits, and monitoring requirements (including the nature and frequency of monitoring) must be identified and described in a licensee-controlled document that is identified in the administrative controls section of the technical specifications. The criteria and method for licensee selection of the parameters, the parameter limits, and the nature and frequency

of monitoring must be described in the administrative controls section of technical specifications.

(3) Mitigation Capability. Licensees shall maintain available a mitigation capability to provide adequate core cooling, decay heat removal, and sufficient protection against the uncontrolled release of fission products following the loss or interruption of decay heat removal during shutdown operation. The structures, systems, and components for complying with this section must be identified in a licensee-controlled document that is identified in the administrative controls section of the technical specifications. The criteria and method for licensee selection of the structures, systems, and components necessary for complying with this section must be described in the administrative controls section of technical specifications.

(4) Fire Protection.

(i) Licensees shall:

(A) Minimize the frequency of fires during shutdown operation;

(B) Maintain the decay heat removal function free of fire damage or limit the levels of fire damage by promptly detecting, controlling, and extinguishing fires that do occur, and

(C) Develop and implement a contingency plan for maintaining adequate core cooling and in a timely fashion restoring decay heat removal in the event of a fire in those areas that interrupts or degrades heat removal to an ultimate heat sink.

(ii) The provisions necessary for complying with this paragraph (including the contingency plan) must be described in the fire protection plan required by 10 CFR 50.48.

(b) Fuel Storage Pool Operation. Holders of licenses authorizing storage or movement of fuel in a fuel storage pool refueling cavity or connected water-filled cavity at a light-water reactor nuclear power plant shall describe in the updated final safety analysis report the assumptions and parameter values used in safety analyses performed by the licensee as reference bounds for design to demonstrate adequate decay heat removal for the fuel storage pool and ensure that the procedures for the fuel storage pool contain operational limits that incorporate the assumptions and parameter values in the updated final safety analysis report.

(c) Implementation. Each licensee shall:

(1) Develop and submit for NRC review and approval technical specifications required by paragraph (a) of this section by [INSERT EFFECTIVE DATE OF FINAL RULE PLUS 6 MONTHS];

(2) Update the fire protection plan required by 50.48 of this part by [INSERT EFFECTIVE DATE OF FINAL RULE PLUS 12 MONTHS] by describing the various positions within the licensee's organization that are responsible for complying with paragraph (a)(4) of this section, the authorities that are delegated to each of these positions to implement these responsibilities, and the specific features necessary for complying with paragraph (a)(4); and

(3) Revise their updated final safety analysis report as required by paragraph (b) of this section at the next scheduled revision following [INSERT EFFECTIVE DATE OF FINAL RULE PLUS 6 MONTHS];

(4) Revise the procedures for the fuel storage pool as required by paragraph (b) of this section by [INSERT EFFECTIVE DATE OF FINAL RULE PLUS 12 MONTHS].

\*\*\*\*\*

7. Section 50.72 is revised to insert a new subparagraph (b)(1)(vii) as follows:

50.72 Immediate notification requirements for operating nuclear power reactors.

\*\*\*\*\*

(b) \*\*\*  
(1) \*\*\*  
(vii) Any event that results or should have resulted in the actuation of the mitigation capability required by 50.67(a)(3).

\*\*\*\*\*

8. Section 50.73 is revised to insert a new subparagraph (a)(2)(xi) as follows:

50.73 Licensee event report system

(a) \*\*\*  
(2) \*\*\*  
(xi) Any event that results or should have resulted in the actuation of the mitigation capability required by 50.67(a)(3).

\*\*\*\*\*

9. The authority citation for Part 54 continues to read as follows:

AUTHORITY: Secs. 102, 103, 104, 161, 181, 182, 183, 186, 189, 68 Stat. 936, 937, 938, 948, 953, 954, 955, as amended, sec. 234, 83 Stat. 1244, as amended (42 U.S.C. 2132, 2133, 2134, 2135, 2201, 2232, 2233, 2236, 2239, 2282); secs 201, 202, 206, 88 Stat. 1242, 1244, as amended (42 U.S.C. 5841, 5842), E.O. 12829, 3 CFR 1993 Comp., p. 570; E.O. 12958, as amended, 3 CFR, 1995 Comp., p. 333; E.O. 12968, 3 CFR, 1995 Comp., p. 391.

10. Section 54.4 is revised to read as follows:

#### 54.4 Scope

(a) \*\*\*  
(3) All systems, structures, and components relied on in safety analyses or plant evaluations to perform a function that demonstrates compliance with the Commission's regulations for fire protection (10 CFR 50.48), environmental qualification (10 CFR 50.49), pressurized thermal shock (10 CFR 50.61), anticipated transients without scram (10 CFR 50.62), station blackout (10 CFR 50.63), and shutdown and fuel storage pool operations (10 CFR 50.67).

\*\*\* \* \*

#### 5.3 Statement Regarding Nature of Proposed Requirement

The proposed rulemaking action is to issue the proposed rule for comment. Following the comment period and after addressing the comments, the staff will issue the rule as a final requirement to address shutdown and fuel storage pool operation.

#### 6 IMPLEMENTATION

The proposed action is a new rule that addresses shutdown operation of nuclear power plants. The licensee's response to the rule is to be documented by modification of its FSAR, procedures for the fuel storage pool, fire protection plan, and its technical specifications. Temporary instructions will be issued and workshops will be held to explain the rule and its implications to industry and to NRC staff. The rule specifies that technical specifications must be submitted to the NRC within 6 months of the date of issuance of the rule, and the fire protection plan and procedures for the fuel pool must be revised within 12 months of the date of issuance of the rule. The rule also specifies that the FSAR for the fuel pool must be updated at

the first scheduled revision of the FSAR following 6 months from the date of issuance of the rule.

## 7 REFERENCES

Advisory Committee on Reactor Safeguards, Proposed Rule on Shutdown Operations, Letter from Chairman, ACRS, to NRC Executive Director for Operations, June 4, 1996.

Advisory Committee on Reactor Safeguards, Establishing a Benchmark on Risk During Low-Power and Shutdown Operations, Letter from Chairman, ACRS to Chairman, NRC, April 18, 1997.

"Background Information for Westinghouse Owners Group Abnormal Response Guideline, ARG-1, Loss of RHR While Operating at Mid-Loop Conditions, Rev. 0, March 15, 1990.

Babcock and Wilcox, Nuclear Technologies, Emergency Operating Procedures Technical Bases Document, Rev. 7, (no number) October 1989.

Nuclear Management and Resources Council, Guidelines for Industry Actions to Assess Shutdown Management, NUMARC 91-06, December 1991.

U.S. Nuclear Regulatory Commission, Bulletin 80-12 Decay Heat Removal System Operability, May 1980.

U.S. Nuclear Regulatory Commission, COMSECY-95-033 Memorandum to Executive Director for Operations from Secretary, September 18, 1995.  
U.S. Nuclear Regulatory Commission, Shutdown and Low-Power Operations for Nuclear Power Reactors, Federal Register, Vol. 59, No. 201, page 52707, (59 FR 52707) October 19, 1994.

U.S. Nuclear Regulatory Commission, GL 80-42 Decay Heat Removal System Operability (also referenced as IE Bulletin 80-12), May 9, 1980.

U.S. Nuclear Regulatory Commission, GL 80-53 Decay Heat Removal Capability, June 11, 1980.

U.S. Nuclear Regulatory Commission, GL 81-21 Natural Circulation Cooldown, May 1981.

U.S. Nuclear Regulatory Commission, GL 85-05 Inadvertent Boron

Dilution

Events, January 1985.

U.S. Nuclear Regulatory Commission, GL 87-12 Loss of RHR While the RCS is Partially Filled, July 1987.

U.S. Nuclear Regulatory Commission, GL 88-17 Loss of Decay Heat Removal, October 17, 1988.

U.S. Nuclear Regulatory Commission, Review of Recent Shutdown Events, Memorandum from Michel Labatut and Mohammed A. Shuaibi to Chief, Reactor Systems Branch, NRR, August 14, 1995 (TAC No. M77701).

U.S. Nuclear Regulatory Commission, Region 1, Haddam Neck Station, NRC Inspection Report No. 50-213/96-08, September 3, 1996 ! October 2, 1996.

U.S. Nuclear Regulatory Commission, Augmented Inspection Team, Loss of Residual Heat Removal System, Diablo Canyon, Unit 2, April 10, 1987, NUREG-1269 June 1987.

U.S. Nuclear Regulatory Commission, Loss of Vital AC Power and the Residual Heat Removal System During Mid-Loop Operations at Vogtle Unit 1 on March 20, 1990, NUREG-1410, June 1990.

U.S. Nuclear Regulatory Commission, NRC Standard Technical Specification and Bases for Babcock and Wilcox Plants, NUREG-1430, April 7, 1995.

U.S. Nuclear Regulatory Commission, NRC Standard Technical Specification and Bases for Westinghouse Plants, NUREG-1431, April 7, 1995.

U.S. Nuclear Regulatory Commission, NRC Standard Technical Specification and Bases for Combustion Engineering Plants, NUREG-1432, April 7, 1995.

U.S. Nuclear Regulatory Commission, NRC Standard Technical Specification and Bases for Boiling Water Reactor " 4 Plants, NUREG-1433, April 7, 1995.

U.S. Nuclear Regulatory Commission, NRC Standard Technical Specification and Bases for Boiling Water Reactor " 6 Plants, NUREG-1434, April 7, 1995.

U.S. Nuclear Regulatory Commission, Shutdown and Low-Power Operation at Commercial Nuclear Power Plants in the United States, Final Report, NUREG-

1449, September 1993.

U.S. Nuclear Regulatory Commission, PRA Working Group, A Review of the NRC Staff Uses of Probabilistic Risk Assessment, NUREG-1489, March 1994.

U.S. Nuclear Regulatory Commission, NRC Regulations Handbook, Rev. 3, NUREG/BR-0053, June 1995.

U.S. Nuclear Regulatory Commission, Regulatory Analysis Guidelines of the

U.S. Nuclear Regulatory Commission, Revision 2, Final Report, NUREG/BR-0058, November 1995.

U.S. Nuclear Regulatory Commission, Technical Guidance for Siting Criteria Development, Sandia National Laboratory, NUREG/CR-2239, December 1982.

U.S. Nuclear Regulatory Commission, Technology, Safety and Costs of Decommissioning Reference Light Water Reactors Following Postulated Accidents, Pacific Northwest Laboratory, NUREG/CR-2601, November 1982.

U.S. Nuclear Regulatory Commission, Estimates of the Financial Consequences of Nuclear Power Reactor Accidents, Sandia National Laboratory, NUREG/CR-2723, November 1982.

U.S. Nuclear Regulatory Commission, Generic Cost Estimates, Science and Engineering Associates, Rev.1, NUREG/CR-4627, February 1989.

U.S. Nuclear Regulatory Commission, A Review of the Technical Issues of Air Ingression During Severe Reactor Accidents. Sandia National Laboratories, NUREG/CR-6218, September 1994.

U.S. Nuclear Regulatory Commission, Evaluation of Potential Severe Accidents During Low Power and Shutdown Operations at Grand Gulf, Unit 1, Sandia National Laboratories, NUREG/CR-6143, June 1994 (Main report; appendices published at later dates).

U.S. Nuclear Regulatory Commission, Evaluation of Potential Severe Accidents During Low Power and Shutdown Operations at Surry, Unit 1, Brookhaven National Laboratory, NUREG/CR-6144, June 1994 (Main report; appendices published at later dates).

U.S. Nuclear Regulatory Commission, Evaluation of Shutdown and Low

## Power Risk

Issues, Policy Issue (Information) from NRC Executive Director for Operations to the Commissioners, SECY-91-283, September 9, 1991.

U.S. Nuclear Regulatory Commission, Regulatory Approach to Shutdown and Low-Power Operations, Policy Issue (Information) from NRC Executive Director for Operations to the Commissioners, SECY-93-190, July 1993.

U.S. Nuclear Regulatory Commission, Issuance of Proposed Rulemaking Package on Shutdown and Low-Power Operations for Public Comment, Policy Issue (Information) from NRC Executive Director for Operations to the Commissioners, SECY-94-176, July 6, 1994.

U.S. Nuclear Regulatory Commission, Issuance of Regulatory Analysis Guidelines of the U.S. Nuclear Regulatory Commission, SECY-95-028, February 7, 1995.

Westinghouse Electric Corp., Power Systems, Loss of RHRS Cooling While the RCS is Partially Filled, Rev. 0, WCAP-11916, July 1988.

## APPENDIX A (FUEL STORAGE POOL OPERATION)

### Regulatory Analysis

#### Fuel Storage Pool Operation in the Proposed Rule

#### 50.67 Shutdown and Fuel Storage Pool Operations at Nuclear Power Plants

### 1 RULEMAKING OBJECTIVE, STATEMENT OF PROBLEM, RESOLUTION

#### 1.1 Objective

The objective of the fuel storage pool portion of the rulemaking is to present clearly defined regulatory controls for current fuel storage pool operational practices.

#### 1.2 Statement of Problem

The safety of fuel storage in the fuel storage pool is determined by the coolant inventory, coolant temperature, and fuel reactivity. Coolant inventory affects the capability to cool the stored fuel, the length of time for events involving the coolant to become significant, the degree of shielding provided for the operators, and the consequences of postulated fuel handling accidents. Coolant temperature affects operator performance during fuel handling, control of coolant chemistry and radionuclide concentration,

generation of thermal stress within structures, and, at elevated temperatures, environmental conditions in areas surrounding the storage pool. Environmental conditions are important because an adverse environment could preclude access to equipment necessary for control of coolant inventory and temperature, which is typically controlled and operated in areas adjacent to the fuel pool, and degrade the operation of essential systems. Fuel storage pools are designed to maintain a substantial reactivity margin to criticality under all postulated storage conditions to ensure the heat generated within each fuel assembly decreases with time.

The existing regulatory framework provides controls on the design of the fuel storage pool and related equipment in the form of the design bases for these structures, systems, and components (SSCs) and in the form of the design control provisions of each licensee's quality assurance program. However, the applicability of design control provisions to the fuel storage pool heat removal function is not clear and not uniform throughout industry, and this regulatory framework does not provide effective controls on the availability of equipment and the performance of operators in maintaining the heat removal and coolant level control safety functions. Methodical management of assumptions in the design basis is important to ensure operating conditions are within analyzed bounds.

Over the past few years, the NRC staff has reviewed fuel storage pool design features and operational practices and has evaluated the risk from storage of irradiated fuel in pools. The NRC's activities in these areas were influenced by the following occurrences: a notification of potential design defects related to irradiated fuel storage at Susquehanna, an NRC inspection identifying design weaknesses and substantial deviations from safety analysis conditions for storage of irradiated fuel at the permanently shutdown Dresden Unit 1, and a request for enforcement action regarding fuel storage pool operational practices at Millstone. The NRC coordinated these activities through implementation and modification of a generic spent fuel storage pool action plan [Memo to A. C. Thadani from G. M. Holahan, "Task Action Plan for

Spent Fuel Storage Pool Safety," October 13, 1994].

As specified in the action plan, the NRC gathered information on fuel storage pool design features and operational practices through operational event reviews, site visits, and reviews of licensing documents (including safety analysis reports). Using this information, the NRC reviewed fuel storage pool designs to identify particular sites having fuel storage pool related features that increased the potential for a significant loss of coolant inventory, reduced the reliability of fuel pool decay heat removal, or increased the potential for a consequential loss of essential safety functions affecting an operating reactor. On the basis of its review, the NRC determined that existing structures, systems, and components related to storage of irradiated fuel provide protection of the public health and safety. However, the NRC found that design features inconsistent with current design standards existed at several plants, and the NRC determined that further evaluation of these specific plants was warranted. ["Resolution of Spent Fuel Storage Pool Action Plan Issues," EDO report to the Commission, July 26, 1996].

In parallel, the NRC evaluated the conformance of refueling operational practices with design basis assumptions associated with the fuel storage pool and its support systems. During its evaluation, the NRC noted that routine refueling offload practices have not been consistent with licensing basis assumptions at several plants. In a number of instances, the NRC found that design basis assumptions have not been captured in procedures, including procedural controls governing the timing and size of fuel transfers and the availability and redundancy of fuel storage pool cooling systems and coolant inventory control systems. ["Report on Survey of Refueling Practices," EDO report to the Commission, May 21, 1996]. The NRC also determined that voluntary actions to govern fuel storage pool operations were inconsistently implemented despite industry-wide guidance and offered an inadequate basis for enforcement. Finally, an assessment of NRC oversight actions with regard to fuel storage pool operations at one plant site performed by the Office of the Inspector General noted considerable weaknesses in the staff's enforcement

practices ["NRC Failure to Adequately Regulate - Millstone Unit 1,"  
Office of  
the Inspector General Case No. 95-771, December 21,1995]. These findings  
led  
the NRC to conclude that an explicit regulatory framework needed to be  
established for fuel storage pool operations in order to ensure that  
activities are conducted in accordance with safety analysis assumptions,  
and  
to ensure that deviations from those assumptions are subject to  
enforcement.

### 1.3 Resolution

The resolution of the NRC's action plan for spent fuel storage pool  
safety  
identified three areas for regulatory action. The first action involves  
implementation of this proposed rule for fuel storage pool operations.  
The  
second action involves addressing certain identified design features that  
reduce the reliability of fuel storage pool decay heat removal, increase  
the  
potential for loss of spent fuel coolant inventory, or increase the  
potential  
for consequential loss of essential safety functions at an operating  
reactor.  
The identified design features that pose an increase potential of fuel  
storage  
pool events relative to common design practices will be addressed for  
each  
affected plant through regulatory analyses for safety enhancement  
backfits on  
a plant-specific basis. The third action is revision of the fuel storage  
pool  
design guidance documents.

The fuel storage pool portion of the rulemaking contains clearly defined  
regulatory controls for current fuel storage pool operational practices.  
The  
NRC believes that the proposed rule expresses NRC expectations for  
control of  
fuel storage pool operations and establishes a clear basis for  
enforcement  
actions.

## 2 BACKFIT ANALYSIS

Although the existing regulations governing the design of fuel storage  
pools  
provide protection of public health and safety, the NRC has determined  
that an  
enhancement of existing regulatory control of fuel storage pool  
operations is  
justified by the qualitative benefits of that action. Through its review  
activities associated with fuel storage pools, the NRC has found that the

design bases for fuel storage pools documented in safety analysis reports are inadequate for consistent enforcement and inspection of fuel storage pool operations. This condition, in combination with economic pressure to achieve shorter refueling outages and the safety benefits achieved by removing all fuel from the reactor vessel during certain refueling operations, has enabled some licensees to operate in conditions outside the envelope evaluated for safe operation of the fuel storage pool without effective methods for the NRC to apply regulatory controls.

To correct this situation, the NRC has drafted the fuel storage pool operation portion of the proposed rule. The regulatory analysis for the fuel storage pool operation shows no quantifiable risk benefit because risk is already believed to be very low. The low risk results from passive design features of the fuel storage pool and the resulting long time period available for mitigative actions from the occurrence of an event to the onset of fuel damage. However, the NRC concluded that the proposed requirements for fuel storage pool operation provide significant benefits. These non-quantifiable benefits include the enforcement and inspection capabilities that are facilitated by the documentation of key parameters and assumptions.

The requirement of 50.67 to incorporate these assumptions into procedures also facilitates the inspection and enforcement of operations that deviate from the procedures. The inclusion of the design parameters and assumptions in the safety analysis report will also result in increased regulatory control over changes to these parameters and assumptions, since they will be subject to the requirements of 50.59.

These non-quantifiable benefits permit the NRC to prevent significant events from occurring, particularly those that may occur at plants with practices that are well below average in terms of safety and, thus, more susceptible to identification through inspection and remediation through enforcement. These significant qualitative benefits address the perceived need for improved regulatory controls in this area and justify the associated cost.

## 2.1 Objective.

The objective of the fuel storage pool portion of the rulemaking is to provide clearly defined regulatory controls for current fuel storage pool operational practices.

## 2.2 Required Licensee Actions.

For fuel storage pool operation, each licensee must document the current design bases for fuel storage pool decay heat removal in the facility's safety analysis report and must ensure that operational limits derived from those bases are contained in procedures. To fulfill this requirement, each licensee shall review its own safety analyses to demonstrate adequate decay heat removal for the fuel storage pool and to identify assumptions and parameter values used as reference bounds for design. Then, the licensee shall resolve any discrepancies or inconsistencies in these assumptions and parameter values using its own procedures for resolving non-conforming conditions. After the licensee develops a consistent set of assumptions and parameter values from the safety analyses, the licensee shall describe that set of assumptions and parameter values in the safety analysis report and ensure that the procedures for the fuel storage pool contain operational limits that accurately reflect the assumptions and parameter values in the safety analysis report.

## 2.3 Potential Change in Risk to the Public.

The staff does not believe a significant, quantifiable change in risk to the public will result from implementing the fuel storage pool aspects of the proposed rule. Estimates of the frequency of a serious loss of fuel storage pool coolant inventory range from about  $6 \times 10^{-7}$  to  $1 \times 10^{-5}$  events per reactor year, and estimates of the frequency of a significant increase in fuel storage pool temperature range from about  $1 \times 10^{-6}$  to  $1 \times 10^{-5}$  events per reactor-year. On the basis of the expected equipment availability and the time available for human performance of activities necessary for recovery, the estimates of the frequency of fuel damage for these types of events is about  $4 \times 10^{-8}$  fuel

damage events per reactor-year [NUREG-1353, "Regulatory Analysis for the Resolution of Generic Issue 82, 'Beyond Design Basis Accidents in Spent Fuel Pools'"].

#### 2.4 Potential Impact on Occupational Radiation Exposure.

The proposed rule does not require the installation of equipment or the performance of any additional tasks inside radiologically controlled areas, nor does it require actions that reduce the potential occupational exposure during event recovery. Therefore, the potential impact on occupational radiation exposure is negligible.

#### 2.5 Industry Costs.

The proposed rule and regulatory guide have been drafted to minimize costs to licensees consistent with achieving minimum operating requirements. The NRC based its cost estimates on the one-time costs associated with revisions to the safety analysis report and to operating procedures.

On the basis of a survey of fuel storage pool licensing basis information completed in 1996, the NRC assumed that 40 operating reactor sites would implement complex revisions to operating procedures and, of those 40 sites, 15 operating reactor sites would implement complex revisions to the updated safety analysis reports and 25 sites would implement minor revisions to the updated safety analysis reports in order to comply with the requirements. The NRC estimated that the remaining 35 sites (i.e., the 29 remaining operating reactor sites and the 6 independent permanently shutdown sites) would implement only minor revisions to their updated safety analysis reports and operating procedures to demonstrate compliance with the proposed regulation.

All costs are given in 1997 dollars and all operating costs are discounted at an annual rate of 7 percent. Labor cost rates were developed using information from NUREG/CR-4627 updated to 1997 dollars by assuming an annual rate of inflation of 5 percent. The following industry costs were calculated:

ù develop and/or modify operations and maintenance procedures " Complex:  
(40 Sites) X (20 pages/site) X (\$1500/page)= \$1.2M; Minor: (35 sites) X (6

pages/site) X (\$1500/page) = \$0.3M.

ù revise the safety analysis report " Complex: ( 20 pages/site) X  
(\$5000/page) X (15 sites) = \$1.5M ; Minor: (5 pages/site) X  
(\$5000/page) X  
(60 sites) =\$1.5M.

The NRC expects continuing costs to be negligible for the documentation of the existing design basis because the administrative process controlling future changes and the operational limitations that evolve from the design are not required to be modified by the proposed regulation. On this basis, the NRC estimates the total cost of implementation for the entire industry at \$4.5M.

## 2.6 Potential Safety Impact of Changes.

Although unquantified, the portion of the rule focused on the fuel storage pool is expected to enhance public health and safety, and to help in averting onsite consequences. These expectations will be realized through increased attention to the operational bounds established by the fuel storage pool's design bases. The increased attention will be driven by the rule, which is a clear statement of NRC requirements, and which contains the framework needed to facilitate inspection and enforcement activities that were lacking in the past.

## 2.7 Estimated NRC Resource Burden.

NRC costs were estimated to be negligible on the basis that existing inspection and enforcement activities encompass the activities necessary to verify compliance with the proposed requirements.

## 2.8 Potential Impact of Facility Differences.

Because the proposed requirement for documentation of the design bases and translation of assumptions and parameter values used in the design process into operational limitations is specific to each facility, this requirement will not involve cost impacts associated with facility differences.

## 2.9 Interim or Final Action.

The proposed actions are final.

### 3 OFFICE POSITION ON PROPOSED GENERIC REQUIREMENT

#### 3.1 Statement Regarding Nature of Proposed Requirement

The proposed rulemaking action is to issue the proposed rule for comment. Following the comment period and after addressing the comments, the staff will issue the rule as a final requirement to address shutdown and fuel storage pool operations.

#### 3.2 Implementation

The proposed action is a new rule that addresses fuel storage pool operation at nuclear power plants. The rule specifies that the FSAR must be updated at the first scheduled revision of the FSAR following 6 months from the date of issuance of the rule. In addition, the rule specifies that the procedures for the fuel storage pool must be revised within 12 months of the date of issuance of the rule. Some work will be necessary to clarify reporting requirements under 50.72 and 50.73.

### 4 IDENTIFICATION AND PRELIMINARY ANALYSIS OF ALTERNATE APPROACHES

#### 4.1 No Action

The no action option has been rejected on the basis that licensees have inconsistently implemented industry initiatives related to fuel storage pool operations and because existing regulations have not provided a clear basis for effective regulation of fuel storage pool operation. The NRC judges that, absent a rule, an observed trend toward shorter refueling outages and tighter maintenance schedules will continue with the attendant increased potential for procedures to provide inadequate controls to maintain operation within the design basis for fuel storage pool operation.

#### 4.2 Information Notice

Numerous aspects of fuel storage pool design and operation have been addressed through information notices. Because fuel storage pool operation is broader

than can be addressed in a single information notice, and there is little accountability or regulatory authority associated with an information notice, the NRC has rejected this option.

#### 4.3 Generic Letter or Bulletin

Generic letters and bulletins have been used to request that licensees provide information regarding planned actions to address a variety of issues. These approaches do not establish a satisfactory enforcement basis because licensees can unilaterally change commitments for made in response to generic letters and bulletins. The NRC has rejected this option because the establishment of an enforcement basis is an essential objective of this rule.

#### 4.4 Technical Specifications Without Rulemaking

The NRC has rejected this approach because the regulatory basis for fuel storage pool decay heat removal specifications is inadequate. Specifications governing the availability and operation of systems are included in the category of limiting conditions for operation, but the fuel storage pool decay heat removal systems do not satisfy any of the criteria contained in 50.36 for establishment of a specification in this category.

#### 4.5 Rule Establishing Uniform Regulatory Controls for Fuel Storage Pool Operation

The NRC selected this alternative on the basis of the proposed rule's significant qualitative benefits. These benefits are seen to be the improved uniformity of regulatory controls and the clarification of staff expectations with regard to fuel storage pool operation. These benefits address the perceived need for improvement in this area and, thus, justify the associated cost.

### 5 FUEL STORAGE POOL REQUIREMENTS

#### 5.1 Proposed Individual Requirements

50.67 Shutdown and Fuel Storage Pool Operations at Nuclear Power Plants.

(a) \*\* \*

(b) Fuel Storage Pool Operation. Holders of licenses authorizing storage or movement of fuel in a fuel storage pool, refueling cavity, or connected water-filled cavity at

a light-water reactor nuclear power plant shall describe in the updated final safety analysis report the assumptions and parameter values used in safety analyses performed by the licensee as reference bounds for design to demonstrate adequate decay heat removal for the fuel storage pool and ensure that the procedures for the fuel storage pool contain operational limits which incorporate the assumptions and parameter values in the updated final safety analysis report.

(c) Implementation. Each licensee shall:

\* \* \* \*

(3) Revise their updated final safety analysis report as required by paragraph (b) of this section at the next scheduled revision following [INSERT EFFECTIVE DATE OF FINAL RULE PLUS 6 MONTHS];

\* \* \* \*

(4) Revise the procedures for the fuel storage pool as required by paragraph (b) of this section by [INSERT EFFECTIVE DATE OF FINAL RULE PLUS 12 MONTHS].

#### 50.34 Contents of applications; technical information

(a) \*\*\*

(b) \*\*\*

\*\*\*

(12) The assumptions and parameter values used in safety analyses required by paragraph 50.67(b) as reference bounds for design to demonstrate adequate decay heat removal for the fuel storage pool.

\*\*\*\*\*

## 5.2 Relationship to Existing Requirements

Some existing requirements apply to fuel storage pool operations. These include the following:

(1) Quality assurance (10 CFR 50.34(a)(7); 10 CFR 50.34(b)(6)(ii); 10 CFR 50.54(a)(1); and Appendix B to 10 CFR Part 50), safety evaluation of changes (10 CFR 50.59), and notification requirements related to the design basis (10 CFR 50.71(e); 10 CFR 50.72(b); and 10 CFR 50.73(a)(2))"

A primary function of these regulations is to ensure that operations are conducted within bounds that have been evaluated for safe operation. Because the quality assurance requirements do not apply equally to fuel storage pool decay heat removal systems at all licensed reactors, the NRC concluded that these regulations provide insufficient regulatory

control  
of fuel storage pool operations relative to the safety importance of  
the  
operations. Additionally, some licensees have not fully documented  
the  
assumptions for fuel storage pool decay heat removal in their safety  
analysis reports, and, consequently, the provisions of 50.59 are  
not  
fully controlling changes in operations related to these assumptions.

(2) Technical Specifications " Historically, technical specifications  
related  
to the fuel storage pool have been derived from the fuel handling  
accident analyses, and, consequently, the applicability of these  
technical specifications is limited to periods during movement of  
irradiated fuel or movement of loads over irradiated fuel. However,  
a  
small number of licenses for operating reactors contain technical  
specifications requiring the operability of equipment capable of  
cooling  
the fuel storage pool for a set period following reactor shutdown.  
Other  
licenses for operating reactors contain technical specifications for  
minimum fuel decay time preceding movement that is based on the time  
for  
the decay heat rate in the fuel to decrease to a value within the  
capacity of the fuel storage pool cooling system. Finally, another  
small  
group of licenses for operating reactors contain technical  
specifications  
that impose a limit on spent fuel storage pool temperature.

## Appendix B

### Regulatory Analysis Supplement Fire Protection For Shutdown Operations

#### 1 INTRODUCTION

This appendix covers the regulatory analysis for the fire protection  
aspects  
of the shutdown operations rule. An analysis comparing the vulnerability  
of  
the plant to a fire-induced core-damage event at shutdown to the plant  
vulnerability at power was performed for three cases: a base case  
crediting  
only existing fire protection regulatory requirements, a voluntary case  
crediting existing regulatory requirements and voluntary initiatives  
undertaken by licensees, and a rule case crediting the impact of the new  
fire  
protection requirements of 50.67. Factors important in relating the  
frequency  
of fire occurrence with core damage frequency were developed from the  
methodology used in NUREG/CR-5088 "Fire Risk Scoping Study: Investigation

of  
Nuclear Power Plant Fire Risk, Including Previously Unaddressed Issues."  
The  
following factors were considered for the base, voluntary, and rule  
cases:

- (1) the frequency of fires initiated during shutdown operations
- (2) the probability of having sufficient combustible loadings to allow a fire  
to propagate or to cause thermal/smoke degradation to important  
components, equipment, or systems needed to achieve and maintain the  
required safety function
- (3) the probability of important fire protection features being  
inoperable or  
degraded (e.g., fire detection and/or suppression system and the  
plant  
condition impact on, or delay of the fire brigade response) to  
detect,  
control, and extinguish the fire before it affected the redundant  
means  
of removing decay heat from the core
- (4) the probability of failure to recover from the loss of decay heat  
removal, due to fire-related component, equipment, or system damage,  
before core damage

## 2 CURRENT REQUIREMENTS

The current requirements for operating nuclear power plants' fire  
protection  
programs are described in 10 CFR 50.48, "Fire Protection," Appendix A to  
10  
CFR Part 50, "General Design Criteria for Nuclear Power Plants, Criterion  
3 -  
Fire Protection," and Appendix R to 10 CFR Part 50, "Fire Protection  
Program  
for Nuclear Power Facilities Operating Prior to January 1, 1979." In 10  
CFR  
50.48(a) and (e), the staff specifies that all operating nuclear power  
plants  
have a fire protection plan that satisfies Criterion 3 of Appendix A to  
10 CFR  
Part 50. This plan must describe the overall fire protection program for  
the  
facility and the specific features necessary to implement the program,  
such as  
administrative controls and personnel requirements for fire prevention  
and  
manual fire suppression activities, automatic and manually operated fire  
detection and suppression systems, and the means to limit fire damage to  
structures, systems, or components important to safety so that the  
capability  
to safely shut down the plant is ensured. The NRC basic fire protection  
program guidance is contained in Branch Technical Position Auxiliary  
Power

Conversion Systems Branch (BTP APCS) 9.5-1, "Guidelines for Fire Protection for Nuclear Power Plants," for plants docketed after July 1, 1976, and its Appendix A, "Guidelines for Fire Protection for Nuclear Power Plants Docketed Prior to July 1, 1976."

Criterion 3 of Appendix A to 10 CFR Part 50 only specifies the overall fire protection design criteria for the facility and does not establish operational fire protection requirements, such as administrative controls and personnel requirements related to fire prevention, manual fire fighting capabilities, and configuration controls regulating the operability of plant fire protection features. Current NRC fire protection requirements and guidance provide reasonable assurance that a significant fire event will not affect the plant's ability to achieve and maintain a safe hot shutdown under those conditions where it is operating at full power. In such an event, the plant will transition from power operation and achieve and maintain operation at hot shutdown conditions, using the post-fire, safe-shutdown train of systems that are free of fire damage, such as a high-pressure injection system for reactor makeup and by removing decay heat via the steam generators or the main condenser, while repairs to components, equipment, and systems necessary to achieve and maintain cold shutdown conditions and long-term decay heat removal are being implemented. However, if a significant fire event were to occur during shutdown operations (cold shutdown or refueling), current NRC fire protection regulations and guidance would allow damage to redundant systems necessary to remove decay heat and would only require that such systems be repaired within 72 hours. Depending on plant conditions, core damage may occur if decay heat removal is lost for 72 hours during shutdown operations. In summary, current fire protection requirements and related regulatory guidance focus on maintaining one train of those systems necessary for achieving and maintaining safe-shutdown conditions from power operations and do not address the effect of fires initiated during shutdown modes of operations, or the potential impact a fire may have on the plant's ability to remove decay heat and maintain reactor water temperature below saturation conditions.

### 3 REGULATORY ANALYSIS APPROACH

#### 3.1 Base Case

A draft special study performed by The Office for Analysis and Evaluation of Operational Data (AEOD) entitled "Fire Events - Feedback of U.S. Operating Experience," estimates the mean frequency of fires in areas with the potential to impact cold-shutdown equipment as follows: the BWR reactor building of  $2.7E-2$  per reactor-year, the PWR auxiliary building of  $1.8E-2$  per reactor-year, and the diesel generator building of  $3.2E-2$  per reactor-year. For the base case, however, the frequency of fires during shutdown operations is judged to be higher than that reported in the AEOD study because the study includes plants that have adopted voluntary measures to reduce the frequency of fire initiation. In addition, there is large uncertainty in the data base because of the reporting criteria used for assessing the frequency of fires. Fires are only reportable to the NRC under 10 CFR 50.72, Immediate Notification Requirements for Operating Nuclear Power Reactors, when the fire lasts for more than 10 minutes and, as such, results in the declaration of one of the emergency classes. Accordingly, the frequency of fires during shutdown operations is assumed to be in the  $1E-1$  to  $1E-2$  per reactor-year range. According to the AEOD study, the fire frequency at power was similar to the fire frequency at shutdown operations.

Once a fire has started, sufficient combustibles must be available for the fire to develop and release sufficient energy or combustion byproducts so that it could damage the components, equipment, or systems important and necessary for removing decay heat from the core. Virtually all extended outages involve the increased use of combustible materials. Therefore, the probability of having sufficient combustible materials to support the development of a fire during shutdown operations is judged to be higher than the probability associated with power operations.

Fire barriers, or combinations of fire barriers or spatial separation with automatic suppression and detection systems, are used in some plants to

ensure  
that one of the redundant trains of post-fire safe-shutdown equipment is  
free  
of fire damage following a fire. In order to perform maintenance or  
facilitate modification work during shutdown operations, some plant fire  
barriers, automatic detection, or suppression systems are often degraded  
or  
taken out of service. During shutdown operations, there are no  
requirements  
that fire barriers have to remain in place or that compensatory actions  
other  
than a roving fire watch be provided following their removal. Therefore,  
the  
probability of important plant fire barriers to effectively mitigate the  
spread of fires during shutdown operations is judged to be lower than  
that  
associated with power operations, where fire barriers for separating  
post-fire  
safe-shutdown systems are required to be in place.

Automatic fire suppression systems can be effective in mitigating the  
consequences of fires. During shutdown operations, there are no  
requirements  
for automatic fixed fire suppression capability in plant areas important  
to  
achieving and maintaining the decay heat removal function. In addition,  
manual fire fighting and fire detection features may be removed from  
service  
in plant areas important to decay heat removal, because of area related  
work  
activities. Accordingly, this factor is judged to be higher than that  
associated with power operations even though compensatory measures such  
as  
firewatches are being taken.

In the event that decay heat removal is lost because of a fire, there is  
the  
potential to recover decay heat removal before the onset of core damage.  
In  
general, there are no requirements in the regulations for procedures, or  
training for recovery of decay heat removal following a fire, except for  
the  
requirement that RHR be repairable within 72 hours. However, the time to  
reactor coolant system boiling and core uncovering are significantly less  
than  
the 72-hour repair period and, in some sequences, can be less than 2  
hours.  
Therefore, the failure to recover decay heat removal following a fire  
that  
results in fire damage and loss of decay heat removal is judged to be  
high.  
For power operations, one train of safe-shutdown equipment is protected  
from  
fire damage at all times.

All four of these factors indicate a greater threat from fires initiated during shutdown operations than from power operations. This analysis leads to the conclusion that the core-damage frequency from fires during shutdown operations for the base case is significantly higher than that for power operations.

### 3.2 Voluntary Case

On a voluntary basis, some plants have adopted enhanced practices for fire prevention and suppression. For example, licensees have trained fire brigades and generally comply with the guidance in BTP APCS 9.5-1 or Standard Review Plan Section 9.5.1 on fire brigades, and the safety evaluation reports for these plants reflect these commitments. In addition, plants have adopted measures to control transient combustible loadings. This is apparent in that, although a relatively high frequency of fires is observed during shutdown operations, the fires have typically been of short duration and of insignificant consequence. Furthermore, the AEOD study indicates that the fires that have occurred during shutdown operations have not resulted in unavailability of multiple trains of decay heat removal. The voluntary practices of licensees are therefore judged to provide a significant measure of safety relative to the base case.

### 3.3 Rule Case

The fire protection aspects of the shutdown rule require licensees to minimize the frequency of fires, maintain the decay heat removal function or limit the levels of fire damage following a fire, and provide contingency plans for maintaining the fuel clad wetted and restoring a decay heat removal path in the event of a fire. The fire protection aspects are intended to ensure that the components, equipment, and systems needed to support decay heat removal or the mitigation equipment in standby are not both lost as the result of a fire. The proposed rule requires licensees to either (1) incorporate fire protection features into the plant design, which would maintain the components, equipment, and systems needed to perform the decay heat removal function free of fire damage, or (2) limit the level of fire damage by promptly detecting, controlling, and extinguishing fires that do occur. For the components, equipment, and systems necessary to support and perform the decay heat

removal

function, licensees can adopt the fire protection features required by Appendix R, Section III.G.2 to ensure that the decay heat removal function

remains free of fire damage. Both approaches are generally consistent with

those fire protection measures that are implemented during full-power operations. These measures not only reduce the frequency of initiating events

but, make the measures contemplated by the proposed rule inspectable and enforceable. If implemented, it is estimated that these measures would reduce

the frequency of fires and their duration, and would reduce consequences from

the base case. Little change in duration is expected when compared to the

voluntary case, although some reduction in consequence may result from the

rule requirement for core cooling contingency plans.

#### 4. BACKFIT RULE

The staff is pursuing requirements for fire protection for shutdown modes of

operation in accordance with 10 CFR 50.109(a)(3), which specifies that the

Commission shall require the backfitting of a facility only when it determines

that there is a substantial increase in the overall protection of public health and safety or common defense and security to be derived from the backfit and that the direct and indirect costs of implementation for that facility are justified in view of this increased protection.

As discussed in sections 2 and 3.1, the existing fire protection requirements

for shutdown operations are limited in scope and, as a result, significant

risk to public health and safety may result from fires during shutdown operations, if licensees only implement the minimum requirements. The proposed fire protection requirements for shutdown operations are intended to

assure that a level of protection comparable to the level provided for power

operations is maintained during shutdown operations. Licensees will be required to include provisions to minimize the frequency of fires, protect

shutdown equipment from fire damage, and maintain the fuel cladding in a wetted condition until decay heat removal is restored. The cost of implementing the fire protection measures during shutdown operations has been

estimated to be between \$81 M and \$100 M for the entire industry. The staff

believes these costs are justified given the increased level of safety that

will be assured through the more extensive fire protection requirements during shutdown operations.

The nine items listed in Section 50.109(a)(3) are discussed below for the proposed fire protection requirements during shutdown operations.

- (1) Statement of the specific objectives that the proposed backfit is designed to achieve

The fire protection aspects of the shutdown operations rule are to ensure that a level of protection comparable to that provided for power operations is maintained during shutdown operations.

- (2) General description of the activity that would be required by the licensee or applicant in order to complete the backfit

The fire protection aspects of the shutdown rule require licensees to minimize the frequency of fires, maintain the decay heat removal function free of fire damage or limit the levels of fire damage following a fire, and provide contingency plans for maintaining the fuel cladding wetted and restoring a decay heat removal path following a fire. The fire protection aspects are intended to ensure that the components, equipment, and systems needed to provide decay heat removal and to have available mitigation equipment are not both lost as the result of a common mode failure, such as a fire. The proposed rule requires licensees to either incorporate fire protection features into the plant design which would maintain the components, equipment and systems needed to perform the decay heat removal function free of fire damage or limit the level of fire damage by promptly detecting, controlling, and extinguishing fires that do occur. For those components, equipment, and systems necessary to support and perform the decay heat removal function, licensees can adopt the fire protection features required by Appendix R, Section III.G.2 to ensure that the decay heat removal function remains free of fire damage.

- (3) Potential change in the risk to the public from the accidental off-site release of radioactive material

Significant decrease in the risk to the public is expected from the base

case with no fire protection requirements to the rule case. For the voluntary case to rule case, varying degrees of risk reduction are expected to be gained from the fire protection aspects. This is due to the fact that some licensees currently are implementing fire protection measures on a voluntary basis and therefore, little risk reduction would occur at these plants. However, significant risk reduction will be achieved for those licensees who have implemented only minimal fire protection measures during shutdown operations. Nevertheless, all of the voluntary measures can be retracted by licensees without NRC approval. The rule is designed to assure the level of protection is maintained.

(4) Potential impact on radiological exposure of facility employees

Three factors were considered in determining the impact of radiological exposure of facility employees: routine exposure, installation exposure, and cleanup exposure. No significant change is expected in routine and installation exposure since the plant design features necessary for compliance with this rule are already installed and maintained. Fire protection systems are largely situated in the auxiliary building of PWRs and the reactor building of BWRs. The routine doses in these areas is minimal. For the cleanup exposure, a significant decrease in exposure is expected because of the large decrease in core damage frequency from fires.

(5) Installation and continuing costs associated with the backfit, including the cost of facility downtime or the cost of construction delay

The rule allows licensees three approaches for addressing fire protection: a hardware-oriented approach, a software-oriented approach, or a combination software/hardware oriented approach. The hardware-oriented approach would be more expensive if equipment and features are not already in place. If the hardware does exist, minimal costs are anticipated; otherwise, a licensee would probably implement the software-oriented approach, which would mainly consist of procedures and contingency plans. In some cases, licensees may pursue a combination of the hardware and software approach.

The cost of implementing any of the approaches is likely to be highly plant-specific. The software approach consisting of procedures, training, quality assurance, corrective actions, and contingency plans has been estimated to cost approximately \$700 K per plant with annual

maintenance

costs of \$30 K. Much of the post-fire safe shutdown analysis to support the procedures, and training required to meet the software approach already exists in existing fire protection requirements for power operation and, therefore the costs associated with the shutdown operation rule would be limited to the extension of these measures to shutdown operation at an estimated cost of \$300 K (200 pages at \$1500 per page) per plant and annual maintenance costs of \$10 K. The contingency plans and the equipment and components necessary to support the contingency plans are estimated to cost \$400 K per plant, with annual maintenance costs of \$20 K per plant.

The hardware approach is estimated to cost approximately \$905 K. Before any fire protection hardware can be installed, a fire and post-fire analysis must be performed to determine the locations at which fire protection is needed. Much of this analysis has already been performed for power operations and, therefore, costs of \$75 K have been estimated to extend this analysis to shutdown operation. The actual fire protection hardware has been estimated to cost \$800 K per plant with annual maintenance costs of \$30 K.

The combined approach is estimated to cost approximately \$750 K with annual maintenance costs of \$30 K. This estimate was selected on the basis of a combination of the hardware and software costs.

Fire Protection  
Item Software Approach

	\$K Hardware Approach	\$K Combined Approach	\$K
Hardware Features	0800400		
Procedures, Training, and Analysis	300	75	150
Contingency Plans and Equipment	400	0	200
Annual Maintenance	30	30	30

The total fixed cost for the 110 plants ranges from \$77 M (\$700 K x 110) to \$96 M (\$875 K x 110). Industry annual maintenance costs (\$30 K) are incurred over the remaining life of each NSSS and are individually

converted to a present value via  $[1 - \exp(-rt_i)]/r$ , where  $r$  = discount rate (7 percent) and  $t_i$  = remaining life of plant "I." The present value of the continuing costs for 73 PWR plants is \$2.4 M, and the present value for the 37 BWR plants is \$1.2 M. Thus, the total sum of fixed plus present value of continuing costs ranges from approximately \$81 M to \$100 M for the industry.

- (6) The potential safety impact of changes in plant or operational complexity, including the relationship to proposed and existing regulatory requirements

As the rule will place additional burden on licensees, operational complexity will increase in that fire protection features will be required to remain in place during shutdown operations, or additional procedures and contingency plans will have to be developed and adhered to. This could complicate maintenance and outage activities and could lead to additional operational complexity and the need for more preplanning. However, many licensees have already implemented fire protection measures to decrease the risk associated with fires during shutdown operations and, therefore, this impact would be minimized for those licensees. The rule is designed to ensure that these or comparable measures remain in place. There are no new programs associated with implementation of the rule, only the extension of existing controls associated with fire prevention during power operations into shutdown operations.

- (7) The estimated resource burden on the NRC associated with the proposed backfit and the availability of such resources

The fire protection aspects are only a portion of the overall shutdown rule. The NRC resource burden associated with the implementation of the fire protection aspects is not expected to exceed 10 percent of the overall NRC resource burden from imposition of the shutdown operations rule.

- (8) The potential impact of differences in facility type, design or age on the relevancy and practicality of the proposed backfit

The impact of the shutdown rule requirements is dependent upon plant-specific features across all vendor designs and dependent upon the decay

heat removal system configuration and degree of separation. However, the overall impact is expected to be small when compared to the risk reduction provided.

(9) Whether the proposed backfit is interim or final and, if interim, the justification for imposing the proposed backfit on an interim basis

The proposed backfit is final.

July 24, 199

Draft Regulatory Guide DG-1066  
Shutdown and Fuel Storage Pool Operations at Nuclear Power Plants

A. INTRODUCTION

Overview

The United States Nuclear Regulatory Commission (NRC) is proposing to amend its regulations by adding a new section 50.67, "Shutdown and Fuel Storage Pool Operations at Nuclear Power Plants," to 10 CFR Part 50, "Domestic Licensing of Production and Utilization Facilities." The NRC is proposing Section 50.67 because it has determined that:

(1) Additional requirements for safety are needed during shutdown operation at light-water nuclear power plants, when operating in cold shutdown or refueling (as defined in a plant's technical specifications) with one or more fuel assemblies located in the reactor vessel or in the refueling cavity, and

(2) The updated final safety analysis report and the procedures for the fuel storage pool operation should document the assumptions and parameter values used in safety analyses that have been performed to demonstrate adequate decay heat removal for the fuel storage pool.

Protection of Public Health and Safety

The design criteria for nuclear power plants are intended to establish that the structures, systems, and components provided in the design of each plant

are capable of performing their safety function within credible bounds of operating and accident conditions. The safety analysis report for each plant contains design criteria and describes how the design satisfies the criteria.

Although the design criteria ensure that a capability to perform specific safety functions is included in the plant's design, the design criterion relevant to a particular functional capability does not control the availability or operation of the equipment that provides the capability. Several mechanisms, such as technical specifications, are in place to provide operational controls when the plant is operating at power and, in a less comprehensive manner, when it is shut down. Based on an assessment of risk, the NRC has determined that the protection provided to the public by current requirements and industry practices would be more uniformly implemented and maintained by generic regulatory action that more comprehensively addressed shutdown operation. This protection would be provided through new requirements for procedural control of shutdown operation; by requirements to establish, monitor, and comply with parameter limits associated with important safety functions; and by requirements to maintain a mitigation capability following events that result in the loss or interruption of decay heat removal. Regulatory guides are issued to describe and make available to the public such information as methods acceptable to the NRC staff for implementing specific parts of the Commission's regulations, techniques used by the staff in evaluating specific problems or postulated accidents, and guidance to licensees and applicants. Regulatory guides are not substitutes for regulations, and compliance with regulatory guides is not required. Regulatory guides are issued in draft form for public comment to involve the public in the early stages of developing the regulatory positions. Draft regulatory guides have not received complete staff review and do not represent official NRC staff positions.

The information collections contained in this draft regulatory guide are covered by the requirements of 10 CFR Part 50, which were approved by the Office of Management and Budget, approval number 3150-0011. The NRC may not conduct or sponsor, and a person is not required to respond to, a collection of information unless it displays a currently valid OMB control number.

## B. DISCUSSION

The proposed Section 50.67 would apply to all holders of operating licenses, combined licenses for a light-water reactor nuclear power plant (except those plants that have been permanently shutdown with fuel permanently removed from the reactor vessel), and licenses authorizing storage of fuel in a fuel storage pool at a light-water reactor nuclear power plant.

The requirements proposed for shutdown operation would apply when one or more fuel assemblies are located in the reactor vessel and when the plant is in cold shutdown or refueling (as defined in the technical specifications). Thus, the requirements do not apply when the licensee has transferred all of the fuel out of the reactor vessel.

The requirements proposed for fuel storage pool operation would apply when one or more fuel assemblies are located in the fuel storage pool or in connected water-filled cavities that are located outside the primary containment.

The proposed Section 50.67 would extend the regulatory coverage of power operation to shutdown operation through the development of additional administrative control technical specifications. The proposed requirements have been developed based upon engineering analyses, insights from risk studies, and experience from actual events.

The safety functions that must be ensured during shutdown operation are (1) removal of decay heat, (2) control of reactor coolant system (RCS) inventory, and (3) control of RCS boundary integrity. The shutdown operation rule would ensure that these safety functions are met by establishing parameter limits that are not to be exceeded. Licensees select the particular parameters to be monitored to ensure that the safety function limits are not exceeded. In the event the safety functions are challenged or the safety function limits are exceeded, the licensee's mitigation capability must consist of a minimum set of equipment that is required to remain functional following the occurrence of an event that interrupts or degrades the operating decay heat removal system. The new requirements (1) reduce the frequency and severity of events that may cause the safety function limits to be exceeded, (2) provide effective

monitoring of parameters indicative of safety function status, (3) ensure that mitigation capability and effective operator response is provided for those events that do occur, (4) ensure reliable methods are employed for decay heat removal, and (5) reduce the frequency of human errors and hardware failures that interrupt or degrade decay heat removal.

For fuel storage pool operation, licensees must document in the updated final safety analysis report (UFSAR) the assumptions and parameter values used in safety analyses performed to demonstrate adequate decay heat removal for the fuel storage pool. Licensees must also ensure that procedures for the fuel storage pool contain operational limits that incorporate the assumptions and parameter values.

#### C. REGULATORY POSITION

This section of the proposed regulatory guide discusses the regulatory requirements and provides guidance on meeting these requirements. The NRC solicits comments and suggested alternatives to the regulatory positions discussed in this section if the alternative will achieve the same level of protection of public health and safety.

##### 1. Proposed Section 50.67(a)(1), Shutdown Operation Procedures

Section 50.67(a)(1) would require licensees to establish and implement procedures to control activities that can effect decay heat removal and provide performance monitoring and mitigation capability. The adequacy of the procedures, and the method for establishing, modifying, and superseding the procedures would be described in the administrative controls section of the licensee's technical specifications. The procedural control process selected can be an approved industry standard or existing measures used by the licensee for control of procedures. An example of such procedural controls is within the model technical specification of Appendix B.

The procedures should address (1) all activities that could affect the availability or operation of the decay heat removal function, the parameter monitoring system, or the mitigation capability to respond to a loss of

decay

heat removal event, (2) training for all personnel who perform activities that could affect the availability or operation of the decay heat removal function, parameter monitoring system, or the mitigation capability to respond to a loss of decay heat removal event, (3) quality assurance for all activities that could affect the availability or operation of the decay heat removal function, parameter monitoring system, or the mitigation capability to respond to a loss of decay heat removal event, and (4) corrective actions for all conditions adverse to quality affecting the availability or operation of the decay heat removal function, parameter monitoring system, or the mitigation capability to respond to a loss of decay heat removal event.

If the procedures for meeting the proposed Section 50.67(a)(1) are not explicitly covered by the existing quality assurance requirements in Appendix B to 10 CFR Part 50, they should be governed by the quality assurance guidance in Appendix A to this regulatory guide.

## 2. Proposed Section 50.67(a)(2), Performance Monitoring

Section 50.67(a)(2)(I) would require licensees to establish, monitor, and comply with parameter limits during shutdown operation. The parameter limits must ensure compliance with the safety function limits of (1) decay heat removal such that the water temperature above the reactor core is less than the saturation temperature, (2) reactor coolant system (RCS) inventory control such that the RCS water level is sufficient for reliable operation of the normal means of decay heat removal, and (3) RCS and connected systems pressure control such that the design pressure and low-temperature overpressure protection (LTOP) settings are not exceeded. The parameters, parameter limits, and monitoring requirements (including the nature and frequency of monitoring) would be set forth in a licensee-controlled document. The criteria and method for licensee selection of the parameters, the parameter limits, and the nature and frequency of monitoring are to be described in the administrative controls section of the technical specifications. The parameters monitored should be RCS temperature, level, and pressure, but the method of measuring these parameters may vary. Appendix B contains model

administrative control technical specifications that licensees should consider in developing their plant specific administrative control technical specifications. The specific monitoring method and instrumentation used to monitor these parameters during shutdown operation, including alarms as appropriate, may vary based on the reactor coolant system configuration, outage activities, decay heat levels, and method for removing decay heat.

In selecting the parameter limits and the parameters to be monitored, licensees should ensure that the safety function limits are not exceeded in the event that the method used for monitoring the parameters is intentionally disabled or accidentally lost. With respect to the parameters monitored, engineering analyses could demonstrate an acceptable time frame for loss of parameter monitoring. Licensees should establish expected values or, for transient conditions, an expected range of values applicable to each planned phase of the outage for reactor water temperature, level, and pressure. Licensees should use these expected values to detect degradation of important safety functions. Parameter limits must be established in accordance with the methodology specified in the administrative controls technical specifications to ensure that the safety function limits associated with decay heat removal, reactor coolant system inventory control, and pressure boundary integrity are not exceeded. In addition, parameters should be monitored on a time scale commensurate with potential changes in the parameters based on the RCS conditions, decay heat levels, outage activities, and monitoring method.

The parameters specified in proposed section 50.67(a)(2) may be measured directly, or a correlation may be developed to relate another parameter or condition measured at another location to the specified values. The frequency for monitoring the parameters should be determined on the basis of the RCS and associated equipment operating conditions and the shutdown activities that could have an impact on the parameters.

If the structures, systems, and components for meeting the proposed Section 50.67(a)(2) are not explicitly covered by the existing quality assurance requirements in Appendix B to 10 CFR Part 50, they should be governed by the quality assurance guidance in Appendix A to this regulatory guide.

### 3. Proposed Section 50.67(a)(3), Mitigation Capability

Section 50.67(a)(3) would require licensees to maintain a capability to provide adequate core cooling, decay heat removal, and sufficient protection against the uncontrolled release of fission products following the loss or interruption of decay heat removal during shutdown operation. The structures, systems, and components used for this capability should be documented within a licensee-controlled document. The criteria and method for the licensee's selection of the structures, systems, and components should be described in the administrative controls section of the technical specifications. Appendix B contains model administrative controls technical specifications that licensees should consider in developing plant specific administrative controls technical specifications.

The mitigation capability required by the shutdown operation rule for incorporation into administrative controls technical specifications should include a safety injection path for adding water into the reactor vessel, an additional path for decay heat removal to an ultimate heat sink that does not share active components with the safety injection system (excluding support systems), and protection against an uncontrolled release comparable to that provided by an intact primary containment. The basis for providing the mitigation capability is to provide for core cooling following an event that results in a loss of decay heat removal. Events considered for the loss of decay heat removal include the random failure of residual heat removal equipment or its support systems and the loss of residual heat removal through a loss of inventory, loss of level control, or loss of AC power. With respect to the mitigation equipment, contingency plans should be developed to cover such actions as replenishing the water inventory or the boron used for injection, assuring the availability of containment sumps when needed for long-term recirculation, and maintaining RCS pressure control. In performing the Regulatory Analysis in support of the proposed Section 50.67, the following equipment was assumed available:

- 2 residual heat removal trains
- 1 service water system train configured for high reliability for RHR support (multiple pumps, parallel paths, common power)

- 1 emergency core cooling system pump and support equipment
- 1 emergency diesel generator
- 1 source of offsite power
- intact containment or comparable equipment
- indication of temperature immediately above the core
- reactor vessel or RCS (as appropriate) water-level indication
- capability to control pressure
- continued source of water for ECCS pump
- BWR Level III isolation

In selecting the particular equipment for meeting the requirements of the proposed Section 50.67, licensees should consider this list of equipment, the planned activities, the plant status and configuration, and potential initiating events.

The mitigation capability must be available to meet the provisions of proposed section 50.67(a)(3). Availability in this context includes credit for operator action to align SSCs. For example, operator actions may be credited to align breakers and valves and to start active components provided (1) the local environmental conditions (temperature, humidity, radiation) permit operator access, (2) appropriate procedures and training have been implemented to support these actions, and (3) sufficient time is available to accomplish the actions. Availability does not mean that the equipment may be disassembled and be restored to service when needed, because disassembly greatly reduces the probability of the equipment performing the function when needed. Unlike many design basis events during power operation, licensees have more time during shutdown operation to take manual actions for mitigation purposes. There is often time to realign valves, close breakers, and perform procedures before a plant reaches unacceptable conditions during shutdown. Contingency plans, as previously discussed, should ensure that the mitigation capability can perform its function for its intended mission time.

In selecting the SSCs to satisfy the decay heat removal path and the water addition path required by the proposed Section 50.67(a)(3), licensees should consider the decay heat load, RCS inventory, RCS configuration, and method of normal shutdown cooling as well as work evolutions that are planned or in progress. Independence from the systems and components used for the operating decay heat removal method, reliability, and protection against

common cause failures should be considered. The SSCs selected for the decay heat removal function should have the capacity to keep the temperature above the reactor core at less than the saturation temperature. In general, two methods for removing decay heat should be provided at all times. When the refueling cavity is flooded, licensees could rely on an operating decay heat removal method and credit the heat capacity of the flooded cavity in conjunction with contingency plans for recovering a decay heat removal path prior to saturation of the flooded cavity for the two methods of removing decay heat. The SSCs selected for the water addition path (safety injection or emergency core cooling) should have the capacity to provide adequate core cooling. Support systems for a safety injection or emergency core cooling system include its emergency onsite power source, which is typically an emergency diesel generator, an adequate source of water, and a reliable means of RCS pressure control. An adequate source of water means that the licensee should ensure that either (1) sufficient water remains in the water storage tank or (2) the sump is clear of debris and functional and the likelihood of a significant loss of inventory outside the primary containment is negligible. Maintenance of an intact primary containment for all containment types is encouraged, whenever possible, to provide protection against the uncontrolled release of fission products. However, it is recognized that the containment must be opened to support some outage and maintenance activities. An intact primary containment is one in which the equipment hatch is closed, the personnel hatch is capable of being readily closed, and all other containment penetrations are closed with a single barrier or capable of being remote-manually closed from the control room. When an intact primary containment is not available, alternative risk-comparable features should be provided. In defining the criteria for selecting these features, licensees should consider the ability of the features to mitigate a loss of decay heat removal event due to risk-significant events that were initiated by a range of events, including loss of ac power, loss of level control, loss of inventory, and loss of the

decay heat removal train. The selection criteria should also factor in plant conditions and the independence of the equipment from that credited for safety injection and backup decay heat removal.

The capability for primary containment closure and secondary containment closure may also be credited in combination with other mitigation equipment as an alternative to an intact containment. One alternative for BWRs could be a diesel-driven fire protection pump with injection capability into the reactor vessel. For PWRs, the staff's regulatory analysis assumed a containment closure capability in conjunction with an additional onsite power source, an additional injection source, the potential for steam generator cooling, and gravity feed as comparable to an intact containment. In assessing the ability to close the containment, consideration should be given to such factors as time to boiling, power supplies, equipment staging, and environmental effects on the ability to perform in-containment work necessary to effect containment closure. In addition, combinations of capabilities should be included such as injection (either safety-related or not safety-related), decay heat removal capability through steam generators or other means, sump recirculation capability with assurance of debris-free sumps, containment sprays, containment restoration capability, contingency plans, and other means that yield release frequencies comparable to those achieved with an intact pressure-retaining containment and that account for the reduction in defense-in-depth because of the substitution for the primary containment. Licensees are not expected to perform shutdown probabilistic risk assessments to comply with the proposed Section 50.67.

The structures, systems, and components intended to meet the requirements of the proposed Section 50.67(a)(3) that are not explicitly covered by the existing quality assurance requirements in Appendix B to 10 CFR Part 50 should be governed by the quality assurance guidance in Appendix A to this regulatory guide.

(4) Proposed Section 50.67(a)(4), Fire Protection

Section 50.67(a)(4) would require licensees to include in their fire protection plan provisions during shutdown operation to minimize the frequency of fires, maintain the decay heat removal function free of fire damage or limit the levels of fire damage by promptly detecting, controlling, and extinguishing fires that do occur, and developing contingency plans for maintaining adequate core cooling and restoring a decay heat removal path. During periods when the decay heat load is high and the coolant inventory is low, maintenance of a heat removal path is critical to maintaining control of event progression because of the short time necessary for the decay heat to bring the coolant to saturation. Fires pose a special threat to the heat removal paths because of their potential to affect redundant decay heat removal paths.

To minimize the frequency of fires during shutdown operation, specifically in those plant areas important to achieving and maintaining the decay heat removal function, licensees should implement controls on combustible materials and potential ignition sources. Licensees should conduct a fire hazards analysis that assesses the adequacy of plant fire protection features and the separation between the operating decay heat removal path and the backup decay heat removal path selected to meet the requirements of proposed Section 50.67(a)(3) under postulated fire conditions. This analysis should also describe the location of equipment and the routing of cables required to establish the heat removal path from the RCS to the ultimate heat sink and the provisions for either maintaining one path free of fire damage or establishing a path through the implementation of contingency plans. The paths are considered to be protected from fire in locations where fire protection features are provided in accordance with subparagraphs (a) through (f) of paragraph III.G.2 in Appendix R to 10 CFR Part 50. Where the separation between the two paths does not meet these criteria, licensees should develop and implement provisions to limit the levels of fire damage by promptly detecting, controlling, and extinguishing fires that do occur. Licensees should develop and implement contingency plans for maintaining adequate core cooling and restoring a heat removal path in the event of a fire in any areas that interrupt or degrade heat removal to an ultimate heat sink. The extent of the contingency plans should be commensurate with the level of protection provided by the proposed Section 50.67(a)(4)(I)(B). For example, if a licensee relies upon limiting the level of fire damage as opposed to maintaining the decay heat removal function free of fire damage, more

extensive contingency plans, including the technical bases that support their feasibility, should be developed. If supported by an analysis and a sound technical basis, a decay heat removal path may be recovered by routing new cable around damaged sections or by providing alternative equipment to replace the function of the damaged equipment.

(5) Proposed Section 50.67(b), Fuel Storage Pool Operation

Section 50.67(b) would require licensees to describe in the updated final safety analysis report the assumptions and parameter values used in safety analyses performed by the licensee as reference bounds for design to demonstrate adequate decay heat removal for the fuel storage pool and ensure that the procedures for the fuel storage pool contain operational limits that incorporate the assumptions and parameter values in the updated final safety analysis report.

For the fuel storage pool, licensees should establish coolant temperature limits and assumptions regarding equipment availability for routine refueling operation as primary design basis constraints. The temperature limits may be derived from design temperatures for the fuel storage pool structure or attached systems. Then, licensees should either establish new operational limitations for each refueling based on expected or planned ranges of secondary parameter values for that one refueling or establish a bounding set of secondary parameter values for all future refueling operation. The secondary parameters evaluated for limiting values should include ultimate heat sink temperature and the timing, size, and operational history of fuel transfers.

Licensees should resolve discrepancies between the safety analyses used in the design process, the facility's updated FSAR, and operating procedures using their process for resolution of degraded or non-conforming conditions. Changes to the facility or procedures made pursuant to 10 CFR 50.59 may also be employed to eliminate a nonconforming condition. The NRC issued Generic Letter 91-18, "Information to Licensees Regarding Two NRC Inspection Manual Sections on Resolution of Degraded and Nonconforming Conditions and Operability," dated November 7, 1991, to all nuclear power reactor

licensees and applicants for inspection of activities to resolve degraded and nonconforming conditions.

#### D. IMPLEMENTATION

The purpose of this section is to provide information to licensees and applicants regarding the NRC staff's plans for using this regulatory guide.

This draft guide has been released to encourage public participation in its development. Except in those cases in which a licensee or applicant proposes an acceptable alternative method for complying with specified portions of the NRC's regulations, the methods to be described in the active guide reflecting public comments will be used in the evaluation of submittals for construction permits and operating licenses (as appropriate) and will be used to evaluate the effectiveness of shutdown and fuel storage pool operation of licensees who are required to comply with 10 CFR 50.67.

#### E. REGULATORY ANALYSIS

A separate regulatory analysis was not prepared for this regulatory guide. The regulatory analysis prepared for 10 CFR 50.67, Shutdown and Fuel Storage Pool Operations at Nuclear Power Plants, provides the regulatory basis for this guide and examines the costs and benefits of the rule as implemented by the guide. A copy of this regulatory analysis is available for inspection and copying for a fee at the NRC Public Document Room, 2120 L Street NW., Washington, DC, as an enclosure to 10 CFR 50.67. APPENDIX A - QUALITY ASSURANCE FOR PROCEDURES AND NON-SAFETY EQUIPMENT ASSOCIATED WITH IMPLEMENTATION OF THE SHUTDOWN RULE

The quality assurance (QA) guidance provided here is applicable to structures, systems, and components (SSCs), including the programmatic elements related to procedural controls and training necessary to meet the requirements of the proposed Section 50.67, that are not explicitly covered by existing QA requirements in Appendix B to 10 CFR Part 50. Additionally, the installation or modification of non-safety-related SSCs required to meet the rule must be

controlled and implemented so that they do not degrade existing safety-related SSCs. A licensee can rely on non-safety-related equipment currently covered by the provisions of 10 CFR 50.62 and 50.63 to satisfy both the technical and QA requirements of 10 CFR 50.67. This is accomplished by making the non-safety-equipment as independent as practicable from existing safety-related systems. The design requirements and operational controls required by this rule should incorporate sufficient design criteria and appropriate quality elements to provide reasonable assurance that, when called upon, the equipment will perform its intended function. While the associated equipment will be required to be reliable, it is not anticipated that it will have to meet all the requirements normally applied to safety-related SSCs. Accordingly, this Appendix A outlines an acceptable QA program that is applicable to the non-safety-related SSCs that the licensee relies upon to satisfy the requirements of the rule.

#### 1. ORGANIZATION

The licensee's responsible engineering organization is expected to verify compliance with this guidance through the use of a peer review process. Therefore, a separate oversight process is not required. However, licensees may elect to use their existing QA organization to perform compliance verification activities.

#### 2. QUALITY ASSURANCE PROGRAM

The existing body of plant procedures and practices is expected to adequately address the QA controls applied to the subject equipment. Accordingly, there is no need for an additional or supplementary QA program to satisfy the requirements of proposed Section 50.67.

#### 3. DESIGN CONTROL

The design process should be defined, controlled, and verified. Applicable design inputs should be appropriately specified and correctly translated into design documents. Design interfaces should be identified and controlled. Design adequacy should be verified by persons other than those who were directly involved in the design of the system, structure, or component.

Design changes, including field changes, should be governed by control measures commensurate with those applied to the original design.

Design methods, materials, parts, equipment, and processes that are essential to the function of the structure, system, or component should be selected and reviewed for suitability of application. The final design (approved design output documents and approved changes thereto) should correlate to the design input documentation in sufficient detail to permit verification of the design.

To verify the adequacy of design, one or more design control measures should be applied: performing design reviews, using alternative calculations, or performing qualification tests. The responsible design organization should identify the particular design verification method or methods used.

#### 4. PROCUREMENT DOCUMENT CONTROL

Applicable design criteria and other requirements necessary to ensure component function and reliability should be included or referenced in documents for procurement of items and services. To the extent necessary, procurement documents should require suppliers to have a QA program consistent with the applicable requirements, such as those described in American National Standard ANSI/ASQC Q9001.

#### 5. INSTRUCTIONS, PROCEDURES, AND DRAWINGS

Technical requirements, inspections, tests, administrative controls, and training necessary for compliance with the proposed Section 50.67 should be prescribed by documented instructions, procedures, and drawings and should be accomplished in accordance with these documents. These documents should include or reference appropriate quantitative or qualitative acceptance criteria for determining that prescribed activities have been satisfactorily accomplished.

#### 6. DOCUMENT CONTROL

Measures should be established to control the issuance of and changes to documents related to the implementation of the proposed Section 50.67.

#### 7. CONTROL OF PURCHASED ITEMS AND SERVICES

Measures should be established to ensure that purchased material, equipment,

and services conform to the procurement documents and engineering specifications.

#### 8. IDENTIFICATION AND CONTROL OF ITEMS

Controls should be established to ensure that only correct and accepted items are used or installed.

#### 9. CONTROL OF SPECIAL PROCESSES

Special processes affecting the design integrity, function, or reliability of items or the quality of services should be controlled. Special processes that establish or verify quality-related activities, such as those used in welding, heat treating, and nondestructive examination, should be performed by qualified personnel using appropriate procedures in accordance with specified requirements.

#### 10. INSPECTION

Measures are to be established to inspect activities affecting the design integrity and function of equipment associated with the requirements of the proposed Section 50.67. Inspections should verify conformance with design requirements and confirm the appropriate accomplishment of activities intended to ensure reliable operation. In general, the licensee's cognizant engineering organization is responsible for determining the inspection requirements and for ensuring that sufficient inspections are performed. Inspections should be performed by knowledgeable personnel other than those who performed or supervised the work being inspected.

#### 11. TEST CONTROL

Tests required to verify conformance of an item to specified design and functional requirements and to demonstrate that items will perform reliably in service should be planned and executed. Characteristics to be tested and the test methods to be employed should be specified. Test results should be documented and their conformance with acceptance criteria should be appropriately evaluated. In general, the licensee's cognizant engineering organization is responsible for developing, implementing, and validating the acceptability of any required testing.

#### 12. CONTROL OF MEASURING AND TEST EQUIPMENT

Tools, gauges, instruments, and other measuring and test equipment used for activities affecting the design, function, or reliability of equipment associated with the implementation of the proposed Section 50.67 should be controlled and, at specified periods, calibrated and adjusted to maintain accuracy within specified limits.

#### 13. HANDLING, STORAGE, AND SHIPPING

Handling, storage, cleaning, packaging, shipping, and preservation of items should be controlled in accordance with utility practices and the manufacturers' recommendations to prevent damage and to minimize deterioration.

#### 14. INSPECTION, TEST, AND OPERATING STATUS

Measures should be established to properly indicate the status of inspection results, test data, and operational capabilities of installed equipment necessary to implement the provisions of the proposed Section 50.67.

#### 15. CONTROL OF NONCONFORMING ITEMS

Measures should be established to control items that do not conform to specified requirements to prevent inadvertent use or installation.

#### 16. CORRECTIVE ACTION

Measures should be established to ensure that failures, malfunctions, deficiencies, deviations, defective components, and nonconforming conditions, including programmatic and procedural discrepancies, are promptly identified, reported, and corrected. Conditions that adversely affect the design function or reliability of the equipment associated with the requirements of proposed Section 50.67 should be evaluated and corrected accordingly.

#### 17. QUALITY ASSURANCE RECORDS

Records should be prepared and maintained to furnish documented evidence that the criteria enumerated above are being accomplished for the activities required to comply with the proposed Section 50.67.

#### 18. AUDITS

Audits should be conducted and documented to verify compliance with design and procurement documents, instructions, procedures, drawings, and inspection and

test activities developed to comply with the proposed Section  
50.67. APPENDIX B - MODEL TECHNICAL SPECIFICATIONS

Model Administrative Controls Technical Specification for Shutdown  
Operation

## 5.0 ADMINISTRATIVE CONTROLS

### 5.5.X Shutdown Operation

- a. The purpose of this specification is to ensure that activities are planned, conducted, and controlled in a safe manner and that adequate monitoring and mitigation capabilities are available during the COLD SHUTDOWN and REFUELING modes of operation when one or more irradiated fuel assemblies are located within the reactor vessel or refueling cavity (shutdown operation).
- b. Procedures must be developed, implemented, and maintained for outage safety parameters, and operation affecting structures, systems, and components important for reactor vessel decay heat removal, reactor vessel coolant inventory control, reactor coolant system and connected systems pressure control, and protection against the uncontrolled release of radioactive material during shutdown operation. These procedures must be developed with appropriate consideration for shutdown safety issues including [mid-loop operation (PWRs), operation at reduced inventory, fuel movement, support system availability, use of soluble neutron poisons for reactivity control, RHR system isolation on low level, etc., ...]. [The criteria and method for establishing, modifying, and superseding the procedures must be {described or referenced}.]
- c. Training must be planned and conducted for individuals performing heat removal, reactor vessel coolant inventory control, reactor coolant system and connected systems pressure control, and protection against the uncontrolled release of radioactive material during shutdown operation. At a minimum, training is to cover outage planning and plan implementation, work control, maintenance, modification, and equipment operation under normal and abnormal conditions.
- d. Quality assurance and corrective action measures are to be developed,

implemented, and maintained for activities that affect the reliability of reactor vessel decay heat removal, reactor vessel coolant inventory control, reactor coolant system and connected systems pressure control, and protection against the uncontrolled release of radioactive material during shutdown operation. At a minimum, these measures must include the functions described in Appendix A to Regulatory Guide DG-1066 "Shutdown and Fuel Storage Pool Operations at Nuclear Power Plants."

e. Parameter limits and monitoring frequencies for shutdown operation must be established [criteria listed] to allow sufficient time for operator mitigative action to reasonably ensure meeting the plant conditions listed in paragraph (f) and the following safety parameter limits:

1. Maximum water temperature at all locations above the reactor core is below saturation.
2. RCS water level is sufficient for reliable operation of the decay heat removal method currently in use.
3. The design pressures of the RCS, connected systems, any other components that constitute part of the physical boundary necessary to contain RCS pressure, and the Low Temperature Overpressure Protection (LTOP) System settings, are not exceeded.

f. Mitigation capability, as described in paragraphs 1, 2, and 3 below, that remains functional following the occurrence of an event that interrupts or degrades the currently operating method for decay heat removal from the RCS, must be available at all times during shutdown operations. If the minimum capabilities, as described in paragraphs 1, 2, and 3 below, cannot be met, plant procedures must exist that address contingencies, establish actions for restoring mitigation capability, and halt all activities that could cause a further deterioration of plant conditions unless such activities are essential for safety.

1. [One subsystem of the safety injection or emergency core cooling system with a suction and recirculation source of [borated]

water

sufficient for providing adequate reactor core cooling and maintaining the reactor subcritical];

that  
system

2.[One path for decay heat removal to an ultimate heat sink does not share active components with the safety injection selected (exclusive of support equipment)]; and,

hatch  
from

3.[An intact primary containment in which (1) the personnel is capable of being readily closed, (2) all other containment penetrations are closed or capable of being remotely closed the control room, and (3) equipment hatch is closed.

OR

that

Equipment (which may include a reduced-capability containment) is comparable to an intact containment on the basis of risk and defense-in-depth considerations.]