

Baseline Risk Index for Initiating Events

The staff has developed the Baseline Risk Index for Initiating Events (BRIIE), a performance indicator that provides a mechanism for determining the risk significance of changes in industry performance, at both the individual initiating event level and at the integrated cornerstone of safety level.

A. BRIIE Derivation

A three-step process is used to derive the BRIIE:

- Step 1 - Identify appropriate risk-significant categories of initiating events;
- Step 2 - Trend and establish performance-based prediction limits for these individual event categories (Tier 1 performance monitoring); and
- Step 3 - Calculate an integrated, risk-informed indicator by assigning a risk importance factor to each initiating event category according to its relative contribution to industry core damage frequency (CDF) in order to calculate a change in CDF (Δ CDF) from a baseline CDF (Tier 2 performance monitoring).

Step 1 - Identification of Risk-Significant Initiating Events

The list of risk-significant initiating event types consists of 10 initiating event categories applicable to pressurized-water reactors (PWRs) and 9 applicable to boiling-water reactors (BWRs) as listed below in Table 1:

Table 1 - Risk-significant initiating event categories covered by the BRIIE

Pressurized Water Reactors (PWRs)	Boiling Water Reactors (BWRs)
1. Loss of offsite power (LOOP)	1. Loss of offsite power (LOOP)
2. Loss of vital AC bus (LOAC)	2. Loss of vital AC bus (LOAC)
3. Loss of vital DC bus (LODC)	3. Loss of vital DC bus (LODC)
4. Loss of main feedwater (LOMFW)	4. Loss of main feedwater (LOMFW)
5. Very small loss of coolant accident (VSLOCA)	5. Very small loss of coolant accident (VSLOCA)
6. PWR general transient (TRAN)	6. BWR general transient (TRAN)
7. PWR loss of condenser heat sink (LOCHS)	7. BWR loss of condenser heat sink (LOCHS)
8. PWR stuck open safety/relief valve (SORV)	8. BWR stuck open safety/relief valve (SORV)
9. PWR loss of instrument air (LOIA)	9. BWR loss of instrument air (LOIA)
10. Steam generator tube rupture (SGTR)	

In general, these risk-significant initiating event types cover approximately 60 percent of the internal event core damage risk (excluding internal flooding) from the operating commercial nuclear power plants in the United States. Also, these initiating events do not overlap.

Enclosure

Step 2 - Performance Monitoring of Risk-Significant Initiating Event Categories (Tier 1 Performance Monitoring)

Tier 1 performance monitoring activity consists of trending risk-significant initiating event categories and monitoring yearly industry performance against prediction limits. To accomplish this, the staff established up-to-date baseline frequencies for each of the risk-significant initiating event categories, and then determined performance-based prediction limits using these baseline frequencies and estimated yearly industry-total critical-reactor years of operation. The process is similar to the “prediction limit” process described in Appendix B of NRC Inspection Manual Chapter (IMC) 0313 for the ITP indicators. An example is presented in Figure 1 for one of the initiating events - PWR General Transients.

These Tier 1 activities are intended to help NRC identify degrading industry performance as an adjunct to the plant-specific performance assessment performed as part of the Reactor Oversight Process (ROP). Potential NRC responses if one or more of the prediction limits are reached or exceeded are outlined in Section E of this enclosure. Also, example scenarios are presented in Section E for illustrative purposes. Tier 1 activities and results are not reported to Congress but are used by NRC as a diagnostic tool to identify degrading industry performance before the emergence of any long-term adverse trends.

The Tier 1 results will be placed on the NRC Web site for access by interested stakeholders.




Figure 1 - Rate for PWR General Transients

Step 3 - Risk-Informed Monitoring of Initiating Events Cornerstone of Safety (Tier 2 Performance Monitoring)

Tier 2 performance monitoring provides an evaluation of the risk significance of changes in industry initiating event category performance in an integrated, risk-informed performance indicator -- the Risk significance is evaluated in terms of Δ CDF. This indicator combines operating experience for risk-significant initiating event categories with information associated

with internal event, CDF-based importance. Although Tier 2 does not provide strict trending information, it does provide an annual risk perspective of industry performance as a deviation from a baseline value and the proximity of the deviation from a set threshold.

Using BRIIE, the staff is able to appropriately combine frequent and infrequent initiating event category frequencies with different risk measures (i.e., Birnbaum importance measures). The main use of the BRIIE is to combine individual initiating event category performance changes into an integrated, risk-informed indicator at the Initiating Events Cornerstone of Safety level. The BRIIE solves several deficiencies in the present ITP: (1) no systematic and defined method for determining whether individual initiating event category performance changes or adverse trends are risk significant, (2) no systematic and defined method for integrating individual initiating event category performance changes into an overall risk result at the Cornerstone of Safety level, and (3) untimely risk-informed industry trend results. The staff proposes to use the results of the BRIIE in the ITP, along with the other qualified indicators, when reporting the number of adverse trends to Congress.

B. BRIIE Calculation

The quantification method used for formulating the related changes in CDF (Δ CDF) is given by the following:

$$BRIIE = \sum_{i=1}^m \bar{B}_i (\lambda_{ic}^* - \lambda_{ib})$$

where

\bar{B}_i = industry-average Birnbaum for initiating event i

Equation (1)

λ_{ic}^* = common industry current frequency for initiating event i

λ_{ib} = baseline frequency for initiating event i

m = number of initiating events covered in BRIIE

BWRs and PWRs have different core damage frequencies, which depend to some extent on different initiating event types. The risk weights for various initiating events also are different for the two types of reactors. Therefore, BRIIE results are provided for each reactor type and the two BRIIE results are also combined into a single index that provides an indication of overall industry performance.

The BRIIE formulation in Equation (1), above, uses PWR- or BWR-average Birnbaum importance measures and combines the industry-wide data to generate the “common industry current frequency” for each initiating event category.

In order to ensure that the BRIIE indicator reflects current industry performance, industry performance for components and initiating events will be reviewed and baseline CDF will be recalculated periodically. The industry-average Birnbaum importance measure for each initiating event category also will be recalculated periodically.

C. Reporting Thresholds

BRIIE results, although representing industry-wide results, are presented as average results per plant. The PWR-wide impact is (PWR BRIIE result per PWR) \times (total number of PWRs). Similarly, the BWR-wide impact is (BWR BRIIE result per BWR) \times (total number of BWRs).

These industry-wide impacts were considered in establishing reporting thresholds for the BRIIE, together with the following information:

1. Uncertainty in the BRIIEs and the 95 and 99 percentiles from simulations
2. Distribution of the Birnbaum importance measures for each initiating event category and understanding of the groups of plants that have large values for each category
3. Major contributors (i.e., dominant initiating event categories) to the BRIIEs
4. Sensitivity of BRIIEs to initiating event categories, especially those with lower frequencies
5. Other factors, such as the NRC safety goal policy and Regulatory Guide 1.174

An expert panel was convened in July 2006 with the objective of reviewing the BRIIE and establishing a threshold value for reporting to Congress. The panel reached the following conclusions:

1. The two-tier process for BRIIE provides an accurate and full picture of industry performance. The two-tier process provides trending information and an action level for NRC engagement if the 95 percent prediction limit of Tier 1 is reached, as detailed in Appendix B of NRC Inspection Manual Chapter 0313. Tier 2 provides an annual risk perspective of industry performance as a deviation from a baseline value.
2. The presentation for BRIIE should be in a bar graph that provides three separate annual values: one bar providing industry-wide results, one bar for BWR results, and the third bar for PWRs. All three bars for each year will be presented on one graph. This presentation provides more information than simply aggregating industry-wide results into one number or presenting BWRs and PWRs individually.
3. The BRIIE should be in the form of Δ CDF. The absolute CDF form will be calculated and be available, if requested, as a communication tool to provide additional insights to interested stakeholders. The Δ CDF form of BRIIE is preferred because the absolute CDF form of BRIIE would result in different CDF values for BWRs and PWRs. The Δ CDF form shows the change from the baseline for both types of reactors and hence is more understandable. Infrequently occurring initiating events such as Loss of Service Water, Loss of Component Cooling Water, Small Loss of Coolant Accident, and others would

not be included in the calculation of BRIIE. These events, if they occur, would be inspected as part of the ROP.

4. The threshold for reporting BRIIE results to Congress should be set at 1×10^{-5} per reactor critical year (rcry). It should be associated only with the Δ CDF BRIIE calculations for industry-wide results. This threshold value was arrived at from considerations of the NRC safety goals, RG 1.174, and consistency with the ROP and Accident Sequence Precursor (ASP) programs. The threshold was derived from coherency with current agency metrics and the surrogates for the safety goals discussed in RG 1.174. Two scenarios were discussed. The first was that a single event at 1×10^{-3} /rcry Δ CDF (e.g., the current ASP indicator threshold for reporting significant events to Congress) would make the aggregate industry performance about equal to 1×10^{-5} /rcry Δ CDF (1×10^{-3} divided by 100 plants). Also, if 10 percent of plants had a problem at about 1×10^{-4} /rcry Δ CDF, then this would also make industry performance about equal to 1×10^{-5} /rcry Δ CDF. The 10 percent number was chosen to provide a distinction between an industry problem in contrast to issues with individual plants.

D. BRIIE Historical Performance

Figure 2 provides representative industry BRIIE results for 1988 through 2005 and illustrates how this indicator successfully provided the desired information. As already stated, the baseline CDF value will be recalculated periodically to reflect ongoing industry performance. Since the BRIIE indicator shows a change from a baseline CDF value, negative BRIIE values indicate an improvement compared to the baseline CDF.




Figure 2 - Baseline Risk Index for Initiating Events 1988 – 2005

E. Potential Regulatory Responses to BRIIE Results

In this section we present two examples to show how the enhanced ITP might treat initiating event performance changes.

As a first example, consider if we observe four events in one year that are classified as very small break LOCAs (VSLOCA), and each event occurred at a different plant. A VSLOCA as an initiating event is rare. The 95 percent prediction limit (used in the Tier 1 analysis) is two events. Therefore, we have exceeded the 95 percent prediction limit. Because the number of actual events exceeds the prediction limit, this initiating event is a candidate for further investigation.

Because VSLOCAs do not occur very often, NRC would examine and review each event in more detail after it occurred. The ROP would review each event for performance deficiencies and the ITP would look at these events to see if there were similarities among the events and to provide any lessons learned from this evaluation. These lessons would be communicated to the industry via an appropriate generic communication. Further regulatory action would probably not be necessary because NRC investigated each event in detail. If all of these events had occurred at PWRs, the resulting PWR Δ CDF-BRIIE would be significantly below the 1×10^{-5} Δ CDF threshold. The plant-type average Birnbaum importance measure for the PWR VSLOCA is the smallest (least important) of the Birnbaum importance measures. This means that a much higher count of events would have to occur before the average PWR would exceed its BRIIE threshold or to have any significant impact in the composite industry Δ CDF BRIIE value. Therefore, since neither the PWR nor industry BRIIE reporting threshold is exceeded, NRC would not make a report to Congress. However, the staff would analyze and take appropriate action in response to these events.

Since the threshold for reporting to Congress is associated with the Δ CDF BRIIE calculations for industry-wide results, the same NRC response would apply if the PWR Δ CDF BRIIE value would exceed the 1×10^{-5} threshold but the industry average Δ CDF BRIIE value does not.

In a second example we assume that there is a marked increase in the number of BWR loss of DC (LODC) events, resulting in seven LODC events for the year. This exceeds the 95 percent prediction limit for Tier 1, which is three events for all plants. As such, this initiating event is a candidate for further investigation and NRC engagement. NRC would examine and review each event in more detail to see if there were similarities among the events and to provide any lessons learned from the evaluation. These lessons would be communicated to the industry via an appropriate generic communication. Further regulatory action would be taken as necessary based on the results of a detailed NRC investigation of each event.

However, unlike in the previous case, both the BWR Δ CDF BRIIE and the industry Δ CDF BRIIE would exceed 1×10^{-5} for this hypothetical case and NRC would report this result to Congress as part of the adverse industry trends metric along with actions that have already been taken or are planned in response to these events.