

RADIOLOGICAL RELEASES: CHECK OR FILL IN APPLICABLE ITEMS (specific details/explanations should be covered in event description)							
LIQUID RELEASE	GASEOUS RELEASE	UNPLANNED RELEASE	PLANNED RELEASE	ONGOING	TERMINATED		
MONITORED	UNMONITORED	OFFSITE RELEASE	T. S. EXCEEDED	RM ALARMS	AREAS EVACUATED		
PERSONNEL EXPOSED OR CONTAMINATED		OFFSITE PROTECTIVE ACTIONS RECOMMENDED			*State release path in description		
	Release Rate (Ci/sec)	% T. S. LIMIT	HOO GUIDE	Total Activity (Ci)	% T. S. LIMIT	HOO GUIDE	
Noble Gas			0.1 Ci/sec			1000 Ci	
Iodine			10 uCi/sec			0.01 Ci	
Particulate			1 uCi/sec			1 mCi	
Liquid (excluding tritium and dissolved noble gases)			10 uCi/min			0.1 Ci	
Liquid (tritium)			0.2 Ci/min			5 Ci	
Total Activity							
	PLANT STACK	CONDENSER/AIR EJECTOR	MAIN STEAM LINE	SG BLOWDOWN	OTHER		
RAD MONITOR READINGS							
ALARM SETPOINTS							
% T. S. LIMIT (if applicable)							
RCS OR SG TUBE LEAKS: CHECK OR FILL IN APPLICABLE ITEMS: (specific details/explanations should be covered in event description)							
LOCATION OF THE LEAK (e.g., SG #, valve, pipe, etc.)							
LEAK RATE	UNITS: gpm/gpd	T. S. LIMITS	SUDDEN OR LONG-TERM DEVELOPMENT				
LEAK START DATE	TIME	COOLANT ACTIVITY AND UNITS:	PRIMARY	SECONDARY			
LIST OF SAFETY RELATED EQUIPMENT NOT OPERATIONAL							

EVENT DESCRIPTION (Continued from front)