



International Agreement Report

RELAP5/MOD3 Assessment Using the Semiscale 50% Feed Line Break Test S-FS-11

Prepared by
E. J. Lee, B. D. Chung, H. J. Kim

Korea Institute of Nuclear Safety
P.O. Box 16, Daeduk-Danji
Daejon, Korea 305-353

**Office of Nuclear Regulatory Research
U.S. Nuclear Regulatory Commission
Washington, DC 20555**

June 1993

Prepared as part of
The Agreement on Research Participation and Technical Exchange
under the International Thermal-Hydraulic Code Assessment
and Application Program (ICAP)

**Published by
U.S. Nuclear Regulatory Commission**

NOTICE

This report was prepared under an international cooperative agreement for the exchange of technical information. Neither the United States Government nor any agency thereof, or any of their employees, makes any warranty, expressed or implied, or assumes any legal liability or responsibility for any third party's use, or the results of such use, of any information, apparatus product or process disclosed in this report, or represents that its use by such third party would not infringe privately owned rights.

Available from

Superintendent of Documents
U.S. Government Printing Office
P.O. Box 37082
Washington, D.C. 20013-7082

and

National Technical Information Service
Springfield, VA 22161

NUREG/IA-0104



International Agreement Report

RELAP5/MOD3 Assessment Using the Semiscale 50% Feed Line Break Test S-FS-11

Prepared by
E. J. Lee, B. D. Chung, H. J. Kim

Korea Institute of Nuclear Safety
P.O. Box 16, Daeduk-Danji
Daejon, Korea 305-353

Office of Nuclear Regulatory Research
U.S. Nuclear Regulatory Commission
Washington, DC 20555

June 1993

Prepared as part of
The Agreement on Research Participation and Technical Exchange
under the International Thermal-Hydraulic Code Assessment
and Application Program (ICAP)

Published by
U.S. Nuclear Regulatory Commission

NOTICE

This report is based on work performed under the sponsorship of The Korea Advanced Energy Institute of Korea. The information in this report has been provided to the USNRC under the terms of an information exchange agreement between the United States and Korea (Agreement on Thermal-Hydraulic Research between the United States Nuclear Regulatory Commission and The Korea Advanced Energy Research Institute, May 1, 1986). Korea has consented to the publication of this report as a USNRC document in order that it may receive the widest possible circulation among the reactor safety community. Neither the United States Government nor Korea or any agency thereof, or any of their employees, makes any warranty, expressed or implied, or assumes any legal liability of responsibility for any third party's use, or the results of such use, or any information, apparatus, product or process disclosed in this report or represents that its use by such third party would not infringe privately owned rights.

RELAPS/MOD3 ASSESSMENT USING THE SEMISCALE

50 % FEED LINE BREAK TEST S-FS-11

Abstract

The RELAPS/MOD3 5m5 code was assessed using the 1/1705 volume scaled Semiscale 50 % Feed Line Break (FLB) test S-FS-11. Test S-FS-11 was designed in three different phases:(a) blowdown phase, (b) stabilization phase, and (c) refill phase. The first objective was to assess the code applicability to 50 % FLB situation, the second was to evaluate FSAR conservatisms regarding SG heat transfer degradation, steam line check valve failure, break flow state, and peak primary system pressure, and the third was to validate the EOP effectiveness. The code was able to simulate the major T/H parameters except for the two-phase break flow and the secondary convective heat transfer rate. The two-phase break flow had still deficiencies. Correlations for the current boiling heat transfer coefficient were developed from the data for flow inside a heated tube, not for flow around heated tubes in a tube bundle. Results indicated that the assumption of 100 % heat transfer upto the liquid inventory depletion was not conservative, the failed affected steam generator main steam line check valve assumption was not conservative. The measured break flow experienced all types of flow conditions. The relative value to the 110 % design pressure limit was conservative. The automatic actions during the blowdown phase were effective in mitigating the consequences. The stabilization operation performed by operator actions was effective permitting natural circulation cooldown and depressurization. The voided secondary refill operations also verified the effectiveness of the operations while recovering the inventory in a voided steam generator.

List of Contents

1. Introduction	1
2. Facility and Test Description	3
2.1 Facility Description	3
2.2 Test Description	4
3. Code and Modelling Description	8
3.1 Code Description	8
3.2 Input Modelling	8
3.3 Initial and Boundary Conditions	11
4. Calculation and Discussion	12
4.1 Blowdown Phase	12
4.2 Stabilization Phase	15
4.3 Refill Phase	16
5. Run Statistics	18
6. Conclusions	19
References	22
Tables	23
Figures	24
Appendix A Input Deck for Steady State Calculation	A.1
Appendix B Input Deck for Transient Calculation	B.1

List of Figures

Fig.1	Axonometric configuration of Semiscale Mod-2C	24
Fig.2	Semiscale Type III Affected Loop (AL) SG Configuration.....	25
Fig.3	RELAPS Nodalization for Semiscale Test S-FS-11	26
Fig.4	Affected Loop (AL) SG feedline break mass flowrate(0-1000s)..	27
Fig.5	AL SG density before break.....	27
Fig.6	AL SG feed flowrate.....	28
Fig.7	AL SG auxfeed flowrate.....	28
Fig.8	AL SG steam flowrate.....	29
Fig.9	AL SG secondary pressure.....	29
Fig.10	AL SG liquid mass inventory.....	30
Fig.11	AL SG downcomer liquid level.....	30
Fig.12	AL SG heat transfer rate.....	31
Fig.13	IL SG heat transfer rate.....	31
Fig.14	Decay heat power.....	32
Fig.15	IL SG feed flowrate.....	32
Fig.16	IL SG auxfeed flowrate.....	33
Fig.17	IL SG steam flowrate.....	33
Fig.18	IL SG downcomer liquid level.....	34
Fig.19	IL SG secondary pressure.....	34
Fig.20	SG crossover line flowrate.....	35
Fig.21	PZR liquid level.....	35
Fig.22	PZR pressure.....	36
Fig.23	PZR heater power.....	36
Fig.24	IL charging flowrate.....	37

Fig.25	AL charging flowrate.....	37
Fig.26	PZR Saturation Temperature.....	38
Fig.27	ILHL liquid temperature.....	38
Fig.28	Primary subcooled margin.....	39
Fig.29	Upper plenum pressure.....	39
Fig.30	IL flowrate.....	40
Fig.31.	AL flowrate.....	40
Fig.32	IL pump velocity.....	41
Fig.33	AL pump velocity.....	41
Fig.34	Upper plenum temperature.....	42
Fig.35	Lower plenum temperature.....	42
Fig.36	Time step size(0-1000s).....	43
Fig.37	CPU time (0-1000s).....	43
Fig.38	IL SG secondary voidf.....	44
Fig.39	AL SG secondary voidf.....	44
Fig.40	AL SG auxfeed flowrate (1000-8000 s).....	45
Fig.41	AL SG secondary pressure.....	45
Fig.42	AL SG heat transfer rate.....	46
Fig.43	IL SG heat transfer rate.....	46
Fig.44	Decay heat power.....	47
Fig.45	IL SG auxfeed flowrate.....	47
Fig.46	IL SG downcomer liquid level.....	48
Fig.47	IL SG secondary pressure.....	48
Fig.48	PZR liquid level.....	49
Fig.49	PZR pressure.....	49
Fig.50	ILHL liquid temperature.....	50

Fig.51	Primary subcooled margin.....	50
Fig.52	AL pump velocity.....	51
Fig.53	Upper plenum temperature.....	51
Fig.54	Lower plenum temperature.....	52
Fig.55	Time step size (1000-8000 s).....	52
Fig.56	CPU time (1000-8000 s).....	53
Fig.57	IL SG secondary voidf.....	53
Fig.58	AL SG secondary voidf.....	54

List of Tables

Table 1. Initial Conditions for Test S-FS-11 23

Table 2. Sequence of Events for Test S-FS-11 23

Executive Summary

This report presents RELAPS/MOD3 code assessment calculation using the Semiscale 50 % feed line break (FLB) test S-FS-11 data. The Semiscale test facility was scaled to be 1/1705 in volume and 1/1 in elevation scaled. The code and the experiment data were released from INEL under the auspices of USNRC. Test S-FS-11 was designed in three parts:(a) blowdown phase in which only automatically functioning plant protection systems (0-600 s), followed by (b) an operator controlled stabilization period including pressurizer warm-up heater operation, and a controlled intact loop(IL) steam generator(SG) feed operation (600-4000 s). Test S-FS-11 was concluded with (c) refill phase including break isolation and affected loop(AL) steam generator(SG) refill (4000-8000 s). The first objective was to provide the data base and the code applicability to 50 % FLB, the second was to evaluate the conservatisms used in FSAR such as the assumption of 100 % heat transfer reduction with liquid inventory depletion, the assumption of main steam line check valve failure, the assumption of break flow saturation state untill the inventory depletion, and 110 % of the desing peak primary pressure value. The third was to validate the EOP effectiveness. The code was able to simulate the major T/H parameters except for the secondary side convective heat transfer rate and pressure. The current convective boiling heat transfer correlations were developed from data for flow inside of a heated tube, not for flow around heated tube in a tube bundle. The AL SG auxiliary feedwater was injected earlier due to a rapid depressurization rate of the secondary pressure. The faster decrease in secondary pressure was attributable to the excessive steam exhaust. The secondary side convective heat transfer rate is a function of void and liquid inventory. The liquid

inventory and velocity affect the heat transfer rate significantly. The code overestimated the blowdown peak heat transfer rate probably due to the overestimated steam flowrate. AL SG heat transfer rate was underestimated during the refill phase so that the pressure was underestimated. Based on results it was found that the assumption of the 100 % heat transfer upto the liquid inventory depletion followed by a step change reduction in the heat transfer to 0 % was not conservative but it was estimated closely by the experiment and the code. The failed AL SG main steam line check valve assumption utilized for the C-E Systyem 80 FSAR Appendix 15 B bottom main feed line break calculations was not conservative based on the results of the experiment and the code. The intersecondary communication, due to the failure, produces increased steam flow from the intact SG, which increases or maintains its primary energy removal, thereby reducing the effect of losing the AL SG heat sink. The assumption regarding the break flow state(i.e., that saturated liquid was discharged until no liquid remained at which time saturated steam was discharged) was not appropriate because the measured break flow did not consist of only saturated liquid and saturated steam flow but exhibited a transition through the full range of condition(i.e.,subcooled liquid, to saturated liquid, to two-phase fluid, to saturated steam), and the code underpredicted the maximum flowrate. The estimated peak primary pressure represented a pressure near, but not quite at, 110 % of the design pressure limit. The relative value of 110 % design pressure limit motivated the need to perform best-estimate calculations with a thermal-hydraulic computer code. The major concern with regard to the system recovery from a bottom main feedwater line break accident was the effectiveness of the recovery operations specified in the plant Emergency Operating Procedures in recovering and maintaining control of the plant. The automatic actions

performed by the plant safety systems (SCRAM, SI initiation, MSIV closure) were effective in mitigating the consequence. The stabilization operation performed by operator actions (PZR internal heater operation, normal charging/letdown operation, and IL SG feed operation) was effective in stabilizing the system at conditions that would permit natural circulation cooldown and depressurization. The voided secondary refill operations verified the effectiveness of the operations for maintaining stable condition while recovering the inventory in a voided SG. The EOP-specified operation was very effective in maintaining control of the Semiscale Mod-2C system during these experiments.

ACKNOWLEDGEMENTS

This report was completed under the sponsorship of Korean Ministry of Science and Technology. Dr. Sang-Hoon Lee, President of the Korea Institute of Nuclear Safety, contributed significantly to the administration of the project. Authors would like to express their gratitude to Mr. Dick Schultz and Mr. Hershall Hardy at INEL for managing the ICAP project and for providing the related documents and test data.

1. Introduction

The RELAPS/MOD3 code [1] has been developed by the Idaho National Engineering Laboratory (INEL) under the sponsorship of US Nuclear Regulatory Commission (USNRC) and its frozen version 5m5 was release at the end of 1990. The code has been assessed against various experimental data to provide input to code improvement and user guideline enhancement [2][3]. However, no assessment has been made against the steam generator (SG) bottom main feed line break (FLB) due to the limited data base and the recent release of the code.

One of the objectives from this assessment using the bottom main feed water line break test is to provide data to assist the USNRC in addressing the various concerns regarding this kind of events. The major concerns are the code applicability, conservatisms or assumptions used in FASR calculation, and the effectiveness of Emergency Operating Procedure (EOP) specified for recovering and cooling down the plant [4]. Specific objectives of this study are:

- to provide data base and applicable range of RELAPS/MOD3 5m5 for simulating 50 % feed line bottom break test, S-FS-11
- to evaluate the accuracy and the discrepancy of the code in predicting the TH behavior of the PCS (Primary Coolnat System) and SCS (Secondary Coolant System) during the test, especially focusing on
 - * Two phase break flow
 - * SG secondary pressure and heat transfer rate
 - * PCS pressurization/depressurization and cooldown

- to evaluate conservatisms used in the C-E System 80 FSAR App 15 B FLB calculations such as:
 - * SG 100 % heat transfer degradation with 100 % inventory depletion
 - * Failed main steam isolation valve(MSIV) check valve assumption
 - * Saturation state of the break flow
 - * 110 % of design primary pressure
- to validate the effectiveness of EOP during
 - * blowdown phase (0-600 s)
 - * stabilization phase (600-4000 s)
 - * refill phase (4000-8000 s)

This report was prepared to address the above questions. Descriptions of the Semiscale Mod-2C system and test S-FS-11 are given in Chapter 2. The code description, the input modelling and initial and boundary conditions are given in Chapter 3. The results of calculation are discussed in Chapter 4 and the run statistics given in Chapter 5. The conclusions obtained from the present assessment are summarized in Chapter 6.

2. Facility and Test Description

2.1 Facility Description

The Semiscale Mod-2C system configuration is illustrated in Fig. 1. The system is scaled from a reference four-loop PWR system based on the core power ratio, 2 MW/3411 MW [4]. Component elevations, dynamic pressure heads, and liquid distribution were maintained as similar as practical. The two-loop test configuration consisted of the vessel with a 25-rod electrically heated core with external downcomer, tube-and-shell steam generators and associated loop piping with circulation pumps. The affected loop (the loop in which the feed line break occurs) is scaled to represent one loop of a four-loop PWR. The Semiscale feedwater and feed line break Experiment Operating Specification contains more detailed information about specific components.

The facility configuration required for the FS Test Series is the Semiscale Mod-2C system. The Mod-2C system consists of the Mod-2B system with several modifications. A new "Type III" AL SG, new main steam line and feedwater line break assemblies, break effluent catch tank, and refined SG control systems have been incorporated into the system for this test series. A letdown line has been added to provide better control of primary system inventory. Scaling criteria specific to Test S-FS-11 are contained in the EOS Appendix [6]. The Type III AL SG design incorporates a downcomer which is external to the tube bundle and riser section (Fig. 2).

The bottom feedwater line break assembly for the AL SG consists of a break

flow nozzle and instrumentation to measure single-phase and two-phase break mass flows as well as fluid density, pressure and temperature. The break nozzle is interchangeable to allow simulation of a wide range of break sizes. For S-FS-11 a nozzle size of 0.609 cm was used to simulate the 50 % break size. Simulation of the MSIV closure will be realized by closing a valve in the connecting "crossoverline" between the SG's. Letdown simulation consists of a valve line connected to the AL cold leg, in which the flow rate is 0.01081 kg/s. Heat loss makeup is accomplished by using external heaters distributed fairly uniformly throughout the Semiscale system. Pressurizer internal heater simulation for Test S-FS-11 consisted of the system warmup heaters supplying 7.10 kW to maintain a primary system subcooling.

2.2 Test Description

Test S-FS-11 simulated a pressurized water reactor transient initiated by a 50 % break in a steam generator bottom feedwater line [5]. The accuracy of the measured parameters was summarized in the Appendix S-FS-11 of the experiment operating specification for the Semiscale Mod-2C feedwater and steam line break experiment series [6]. With the exception of primary pressure, the initial conditions represented those used for the C-E System 80 [7]. The reactor and turbine trip signals (SCRAM) were assumed to be generated by a high pressure signal. Loss-of-offsite power (LOP) was simulated to occur concurrently with SCRAM. The safety injection (SIS) and MSIV closure signals were assumed to be generated by a low steam generator pressure signal. SIS initiated the high pressure injection system (HPIS) and

auxiliary feedwater injection signals. The test was designed in three parts: (1) blowdown phase (0-600 s), (2) stabilization phase (600-4000 s), and (3) refill phase (4000-8000 s).

The test was initiated at t=0 s by opening the valve in the break assembly in the affected loop (AL) steam generator (SG). The simulated bottom feedwater line break (FLB), in conjunction with the simulated AL SG main steam line check valve failure, produced pressure drops and inventory losses in both SG secondary sides. Table 3 contains a sequence of events listing for S-FS-11. The first 600 s of the transient consisted of automatically occurring events such as main feedwater termination, core power decay initiation, normal steam flow control valve closure initiation, and HPIS flow initiation. The main feedwater was terminated at break initiation. The initiating event for the core power decay, normal steam flow control valve closure, and main coolant pump trip actions was a reactor and turbin trip (SCRAM) signal, due to a high pressurizer pressure of 15.86 MPa (2300.00 psia), compounded by a simulated LOP concurrent with the SCRAM signal. The initiating event for the MSIV closure action, and the auxiliary feedwater and HPIS initiation (SIS) actions was a low AL SG steam dome pressure of 4.47 MPa (648 psia). The recovery procedures for Test S-FS-11 consisted of: a) stabilization of the plant at the specified pressures, temperatures, and levels, using normal charging/letdown operations, pressurizer heater operation, and intact loop (IL) SG feed operation, and b) AL SG refill with auxiliary feedwater, while maintaining pressurizer level.

The plant stabilization procedure started at 600 s, the simulated time required for operator identification of the feed water line break event. The

AL SG auxiliary feedwater flow was terminated at 600 s. The pressurizer warm-up heaters, supplying 7.10 kw were cycled for 322 s at 120 s after the AL SG auxiliary feedwater termination to reestablish and maintain the primary system subcooling between 27.8 and 33.3 K. Safety injection (HPIS) flow termination criteria were satisfied at about 900 s with the primary system subcooled margin at 27.8 K and the pressurizer level at 250 cm. Since the primary system pressure remained above the 12.32 MPa HPIS shutoff head prior to HPIS flow termination, no HPIS flow injection occurred during the test. Charging flow was cycled, beginning at about 1062 s, to maintain the pressurizer level at 245 cm. Auxiliary feedwater flow was used to re-establish and maintain the IL SG secondary level between 910 and 1000 cm. The IL SG simulated atmospheric dump valve (ADV) was available to maintain the secondary pressure at < 6.98 MPa but was not needed. The plant was considered to be stabilized at 4055 s when the IL SG level reached 910 cm with all other stabilization criteria satisfied. No primary system voiding was produced during the stabilization phase of the test and all external heaters remained at full power throughout this part of the transient.

Following plant stabilization (4055 s) the AL SG refill was initiated by isolating the feedwater line break (4100 s) and commencing AL auxiliary feedwater (4100 s). The AL primary coolant pump was run at minimum speed starting at 4450 s to provide measurable primary tube flow rates for use in evaluating primary-to-secondary heat transfer during the refill phase. IL auxiliary feedwater was terminated at 5038 s when the IL SG secondary level had increased to 1000 cm. Normal charging flow was cycled throughout the refill phase to maintain the pressurizer level. AL auxiliary feedwater was

terminated upon meeting the refill criterion of 1036 cm at 7675 s. The test was terminated at 7700 s.

3. Code and Modelling Description

3.1 Code Description

RELAPS/MOD3 Version 5m5 [1], released by USNRC, was used in the present assessment calculation with Test S-FS-11. The features changed from the RELAPS/MOD2 were described in Reference [2].

3.2 Input Modelling

A standard input deck of Semiscale SBLLOCA Test S-LH-1 for RELAPS/MOD2 was received from INEL in January 1991. The deck was modified for RELAPS/MOD3 to simulate the Semiscale SBLLOCA Test S-NH-1 [8]. The conversion principle was based on the philosophy applied to model ROSA SBLLOCA Test SB-CL-18 in Japan[9]. Some modifications were made as follows:

- Modeling options related to volume, junction, heat structure were properly modified to work with RELAPS/MOD3 [1].
- For steady state run, the following set points were changed:
 - * IL feed/steam flowrate control to keep the inventory (103 kg) constant
 - * BL feed/steam flowrate control to keep the inventory (26 kg) constant
 - * PZR inlet/outlet flowrate control to keep the level (484 cm) constant
 - * RCP speed control to keep flowrate (9.4 kg/s for IL and 3.3 kg/s for AL)
- For steady state run, the test specific trips were deleted out.
- A restart transient input data was developed by deleting steady state controllers and changing the test specific trips to be activated.

As in the nodalization diagram of Fig. 3, the Semiscale system was nodalized by 181 volumes, 174 junctions and 256 heat structures after implementing the items stated above. A steady state input deck and a transient input deck were provided in Appendix A and B of this report.

3.2.1 Primary Coolant System Modelling

The PCS composed of an intact loop and a broken loop, the former included a hot leg, a loop seal, a pump suction tee, two PCPs and a cold leg. The intact loop was modelled by 13 hydrodynamic volumes. All piping metal structures exposed to environmental atmosphere were simulated by the heat structure to consider the associated heat loss. The detailed information can be found in Fig. 3. The volume and junction modelling options were set with default options.

3.2.2 Reactor Vessel Modelling

The Semiscale vessel was modelled by a downcomer annulus, a lower plenum, an active core, a core-bypass flow path, an upper plenum, an upper head. The active core and the downcomer were modeled by 6 volumes and 10 volumes stacked vertically, respectively. The rod bundle interphase friction model option was selected for the active core volumes. The axial power shape was described according to the reference [8]. The ANS-79 model was used for a decay heat simulation, which was changed from ANS-73 model in the posttest calculation.

3.2.3 Pressurizer Modelling

The pressurizer system was modelled by a surgeline, a pressurizer vessel, a spray line from the cold leg, a spray valve and an experiment PORV. Three volumes for the surge line, eight volumes for the vessel and one volume for the spray line were used, respectively. The spray valve and the PORV were simulated by the trip valves. The associated trip logics were prepared according to the experimental specification [5]. To consider the environmental heat loss from the pressurizer vessel wall, the vessel wall was modelled by nine heat structures.

3.2.4 Steam Generator Modelling

The steam generator consisted of a SG inlet plenum, U-tubes, an outlet plenum, a main feedwater tank and feed line, auxiliary feedwater tank and feed line, a feedwater inlet annulus, a SG secondary side downcomer, a boiler section, a separator inlet annulus, a separator, a steam dome, a steimeline, a MSIV, MSCV, a MSCV downstream piping and a air-cooled condenser. The number of volumes used for each flow path is given in Fig. 3. The separator section in SG was modelled by a branch component with dead end in outlet side and a SEPARATOR component with inlet junction from the adjacent branch component.

The heat transfer area of U-tube heat structure in the intact loop SG generally affects the initial conditions in the SG secondary side. According to the previous Semiscale calculations using RELAPS/MOD2 [8], the predicted

pressure in SG secondary side were generally underpredicted by 0.4 MPa. This discrepancy may be due to the underestimation of heat transfer area in the SG U-tube.

3.2.5 Others

The emergency core cooling system (ECCS) in Semiscale was also modeled. Fig 3 and Appendix A provide a detailed information of ECCS. The containment was also modeled by a time-dependent volume with a constant pressure.

3.3 Initial and Boundary conditions

To obtain all initial conditions of the whole system prior to the transient, a steady state run was made with three steady state controllers as stated above. The result obtained from the steady state run was compared with the measured initial conditions in Table 1. The agreement between the measured and the predicted values for initial conditions is fairly good.

4. Calculation and Discussion

A transient calculation using the input modellings, initial conditions and boundary conditions stated in Chapter 3 was made with the RELAPS/MOD3 Sm5 code. This chapter presents the results obtained from the transient calculation and compare the results with the measured data to assess the code applicability. Table 2 shows the predicted sequence of event along with the measured values. The detailed discussion of the comparison is provided for the following three phases:

- 1) blowdown phase (0-600 s)
- 2) stabilization phase (600-4000 s)
- 3) refill phase (4000-8000 s)

4.1 Blowdown Phase (0-600 s)

The blowdown phase is defined as the time interval between break initiation to a time when all automatic actions are completed and operator action is prepared. The measured and calculated break flow rates are compared in Fig. 4. The code underestimates the break flow rate for the first 20 s following the break initiation and also underestimates the maximum break flow rate. The code, however, overestimates the break flow rate from 20 s to 250 s because of the overestimated AL SG liquid inventory. The subcooled break flow rate is quite underestimated but the two-phase break flow rate is overestimated with this modeling. Fig. 5 shows the transient of the density

before break in the AL SG. The density decreases rapidly and increases again as the auxiliary feeding flow is injected. The code predicts the trends of the density properly so that the deficiency of the two-phase break flow model is not related to the poor prediction of the density. The crossover line valve is closed at 240 s, which simulates the failed MSIV failure allowing the intersecondary communicating flow rates between the SG's. The closure of the valve causes the AL SG steam dome pressure to decrease to zero (Fig. 9) and the IL SG steam dome pressure to increase again to its initial value (Fig. 19). The outgoing flow from the AL SG is increased by this flow in the crossover line. Fig. 6 shows the AL SG feed flow rate, which is terminated at 30 s and the trend is predicted fairly well. Fig. 7 shows the AL SG auxiliary feed flow rate, which is actuated by the AL SG secondary low pressure (4.47 MPa). The code predicts an earlier initiation time due to an overestimation of the AL SG steam flow rate (Fig. 8) and the rapid decrease of the AL SG secondary pressure (Fig. 9). Fig. 10 shows the AL SG secondary liquid mass inventory. The code predicts it closely during the first 20 s but overpredicts afterwards because of the early injected auxiliary feed flow rate and earlier closure of the steam valve. Fig. 11 shows the trend of the AL SG downcomer liquid level and the code underestimates the level as the pressure does. Fig. 12 shows that the AL SG heat transfer rate predicted by the code is fairly good. Fig. 13 shows the IL SG heat transfer rate, which is overpredicted due to the overestimated steam flow rate during the first 20 s. The AL SG secondary pressure decreases more quickly due to the steam flow rate. The lower decay power (Fig. 14) also caused not to repressurize and the crossoverline valve

closure affects the AL SG pressure to approach zero. Fig. 18 shows the trend of the IL SG secondary downcomer level. The code follows the trends of the measured values except for the timing due to the auxiliary feed initiation. Fig. 19 also shows the trend of the IL SG secondary pressure, which is underestimated by 1 MPa due to the earlier injection of the IL auxfeed flow (Fig. 16). The pressure ,however, becomes be stable after the crossoverline valve is closed at 200 s. The code underestimates, during the first 20 s, the IL SG secondary pressure probably due to the overestimated steam flow (Fig. 17). The overestimated steam flow causes to increase the IL SG heat transfer rate during the first 20 s. The failed main steam control line check valve assumption is not conservative since the communicating flow between the SG's increases the cooling capability. Also, the assumption of saturated state in break flow is not appropriate since the actual break flow experiences all types of the conditions. The value of 110 % primary pressure is found to be quite overestimated resulted from the improper assumptions. Fig. 21 shows the PZR liquid level and the level rises during the first 40 s because the heat sink capability is lost. Again, the level decreases after SCRAM and stays at 235 cm when auxiliary feeding starts. The normal charging set point of the PZR is 235 cm and the normal letdown set point is 255 cm. Fig. 22 shows the PZR pressure and the code predicts them fairly well except for the timing, which is related again to the rapid depressurization of the secondary pressure. The code also underpredicts the pressure due to the earlier injected auxiliary feed water flow rate. The charging contributes to repressurize, around 700 s, and the rate of the repressurization increases due to the internal heater operation

(Fig. 23). Fig. 26 shows the PZR saturation temperature and the code predicts fairly well. Fig. 27 shows the ILHL liquid temperature and the code underpredicts due to the earlier injection of the auxiliary feeding flow rate. The magnitude of the underestimation is about 20 K at around 100 s, which influences the subcooled margin to diverge as shown in Fig. 28. Fig. 29 shows the trend of upper plenum pressure. The trend is almost same as the one of the PZR pressure (Fig. 22). A SI signal is actuated by the SG low pressure but no flow is introduced into the system because the HPIS pump produces no flow at that pressure range. Fig. 30 and 31 show the trend of the AL and IL flow rate and the code predicts the RCP coastdown fairly well as can be seen in Fig. 32 and 33. The upper plenum temperature (Fig. 34) and the lower plenum temperature (Fig. 35) are underestimated by 20 K at around 600 s. Fig. 38 shows the trend of the IL SG secondary liquid void fraction and the upper part still has some liquid which enhances the heat transfer. However, Fig. 39 shows the trend of AL SG liquid void fraction, which decreases rapidly.

4.2 Stabilization Phase (600-4000 s)

The stabilization phase of Test S-FS-11 is defined to extend from 600 s to when criteria for a pressurizer liquid level (235-255 cm), primary subcooling (>27.8 K) and IL SG secondary pressure (<6.98 MPa) and liquid level (910-1000 cm) are met. These criteria are met at 4055 s in the test and predicted at 4000 s by the code.

Fig. 48 shows the PZR liquid level staying at 245 cm and the code predicts

the depressurization and the cooldown as in the trend of the PZR pressure (Fig. 49) and the ILHL liquid temperature (Fig 50). The calculated PZR pressure from 1000 s to 2000 s is overpredicted due to the earlier injection of the charging flow (Fig. 24 and 25). During the stabilization phase, the AL SG auxfeed is not operated so that the AL liquid mass inventory and SG downcomer level stays at zero level. Fig. 41 shows the AL SG secondary pressure staying at 0.1 MPa prior to the following refill phase. Fig. 45 shows the trend of IL SG auxiliary feed water flow rate feeding until 4500 s. Fig. 46 shows the IL SG secondary downcomer level. The level increases to 955 cm due to the feeding. Fig. 47 shows the IL SG secondary pressure approaching 6.98 MPa. The trend of the IL SG secondary downcomer level and the IL SG secondary pressure justifies the effectiveness of the EOP, indicating a safe operation with depressurization and cooldown as in Fig. 49 and 50.

4.3 Refill Phase

The refill phase of Test S-FS-11 is defined as the time interval from 4000 s to the end of the test at 8000 s. The refill phase starts with the initiation of the AL SG auxiliary feed water flow rate. This phase ends with the increased AL SG secondary pressure and the liquid level. The liquid level increases rapidly because the calculated aux feed is instated once but not cycled as in the measured. The final primary system pressure (Fig. 49) is underestimated because the secondary heat removal period is presumably extended longer than the measured (Fig. 40). The overestimated heat sink

contributed to the underestimation of the AL SG pressure. The IL SG secondary pressure, however, is overestimated because the calculated IL SG aux feed is terminated earlier, the level is lower, and vapor is generated as in Fig. 47.

The code underestimates the AL SG secondary pressure (Fig. 41) due to the underestimated AL SG heat transfer rate (Fig. 42). The heat transfer rate is generally function of liquid inventory and void fraction. The IL SG secondary heat transfer rate is well predicted as the void varies (Fig. 57). The code predicts the heat transfer rate to decrease as the void decreases and the liquid inventory increases. This result is contrary to the one in the blowdown phase. The reason for this comes from the fact that the convective heat transfer correlation was developed for a flow inside tube not for a flow around heated tubes in a tube bundle [4]. EOP with the AL SG auxiliary feed water flow operation is validated with a voided SG refill because primary coolant system stably depressurizes and cools down. The trend of primary subcooled margin is properly predicted considering the scale of the plotting and the underestimation of the ILHL liquid temperature (Fig. 50).

5. Run Statistics

The main frame computer used in the present calculation was a CRAY-2S in System Engineering Research Institute (SERI), Korea under UNICOS as a operating system. Fig. 36 and 37 present the plots of the time step size and the CPU time for the transient time in the calculation from 0 to 1000 s. And Fig. 55 and 56 show the time step size and the CPU time used from 1000 s to 8000 s. The grind time can be calculated as follows:

Computer time, CPU = 1754+ 5059 = 6814

Number of time step, DT = 12250+28307 = 40557

Number of volume, C = 181

Transient real time, RT = 8000 (sec)

$$\text{Grind time} = \text{CPU} \times 1000 / (\text{C} * \text{DT}) = 0.9080 \quad \text{CPU in sec/vol/step}$$

6. Conclusions

The RELAPS/MOD3 Sims code was assessed using the Semiscale test S-FS-11 for simulating the 50 % FLB. The assessment was performed in three different phases: (1) blowdown phase, (2) stabilization phase, and (3) refill phase. The calculated results were compared with the measured data to address the following questions:

- Code applicability to Semiscale FLB Test S-FS-11
- Code/Modeling deficiency
- FSAR conservatism evaluation

100 % SG heat transfer degradation

failed MSIV

saturation state of break flow

110 % of primary peak pressure

- EOP effectiveness

Main conclusions obtained from this assessment are:

- RELAPS/MOD3 Sims can simulate Test S-FS-11 and the code can predict full scale PWR plant system response.
- The code underestimated the subcooled break flow rate and the maximum break flow rate. The two-phase break flow rate model still has some deficiency
- The SG secondary pressure and heat transfer rate were underestimated due to the fact that the initial phase steam flow was quite overestimated and

the boiling heat transfer correlation was developed for a flow inside tube not for a flow around heated tubes in a tube bundle.

- The modeling technique regarding the IL steam valve and recycled charging/letdown should be improved to match the measured data more closely.
- The assumptions and simplifications made for FSAR accident calculations were evaluated.

First, the assumption made for the bottom main feed water line break calculations regarding the reduction of heat transfer with liquid inventory (i.e., 100 % heat transfer until the liquid inventory is depleted followed by a step change reduction in the heat transfer to 0 %) is not conservative at all for the Semiscale Type III SG FLB case. The assumed heat transfer degradation actually closely simulated the heat transfer rate according to the inventory loss.

Second, the failed affected SG MSIV assumption utilized for the C-E System 80 FSAR was not a conservative assumption because the intersecondary communication, that occurs due to the failure, produces increased steam flow from the IL SG, thereby increasing heat sink capability.

Third, the assumptions regarding the break flow state (i.e., that saturated liquid was discharged until no liquid remained at which time saturated steam was discharged) was not appropriate because the measured break flow did not consist of only saturated liquid and saturated steam flow, but exhibited a transition through the full range of conditions(i.e., subcooled liquid, to saturated liquid, to two-phase liquid, to saturated steam).

Four, the estimated peak primary pressure represent pressures near, but not quite at, 110 % of the design pressure limit. So the need for performing

this best estimate calculation is justified.

- The effectiveness of EOP-specified operation was validated in three phases:

First, the automatic action performed by the plant safety systems (i.e., SCRAM, SI termination, and MSIV closure) was effective in mitigating the consequences.

Second, the stabilization operation performed following operator identification of the transient(i.e., SI termination, PZR internal heater operations, normal charging/letdown operations, and IL SG feed operation) was effective in stabilizing the system at conditions that would permit a natural circulation cooldown and depressurization.

Third, the voided secondary refill operations performed following the stabilization phase were verified to be the effectivenes of the operations for maintaining stable conditions while recovering the inventory in a voided SG with the AL SG auxiliary feed water flow rate

References

1. EG&G, RELAPS Input Data Requirements, Appendix A to RELAPS/MOD3 Code Manual, January 1990.
2. W. Weaver, Improvement to the RELAPS/MOD3 Choking Model, EGG-EAST-8822, December 1989.
3. Guidelines and Procedures for the International Code Assessment and Applications Program, NUREG-1271, April 1987.
4. T. J. Boucher, Results of Semiscale mod-2C Feedwater and Steam Line Break (S-FS) Experiment Series: Bottom Main Feedwater Line Break Accident Experiments, NUREG/CR-4898, EGG-2503, Feb 1988.
5. M. P. Plessinger, Quick Look Report for Semiscale mod-2C Test S-FS-11, EGG-RTH-7103, November 1985.
6. T. J. Boucher, W. A. Owca, Appendix S-FS-11 of the Experiment Operating Specification for the Semiscale mod-2C Feedwater and Steam Line Break Experiment Series, EGG-SEMI-6909, June 1985.
7. CESSAR-80, Final Safety Analysis Report, Appendix 1SB, Combustion Engineering Company.
8. E. J. Lee et al, RELAPS Assessment Using Semiscale SBL0CA Test S-NH-1, Submitted to INEL and USNRC, Mar 1991.
9. S. H. Lee et al, RELAPS Assessment Using LSTF SB-CL-18, Submitted to INEL and USNRC, Feb 1991.

Table 1. Initial conditions for Test S-FS-11

<u>Parameter</u>	<u>Measured</u>	<u>RELAPS/MOD3</u>
Pressurizer pressure (MPa)	15.03	15.02
Core power (MW)	2.18	2.18
Core DT (K)	36.7	36.8
PZR liquid level (cm)	484.0	484.0
CL loop temperature difference (K)	4.5	3.8
CL fluid temperature (K)	568	572
IL primary flow rate (L/s)	9.4	9.4
AL primary flow rate (L/s)	3.3	3.3
IL SG secondary pressure (MPa)	6.27	6.24
AL SG secondary pressure (MPa)	6.23	6.22
IL SG secondary inventory (kg)	103	103
AL SG secondary inventory (kg)	26.0	26.3
IL SG feed flow rate (kg/s)	0.86	0.82
AL SG feed flow rate (kg/s)	0.24	0.25
IL SG feed temperature (K)	485.0	485.0
AL SG feed temperature (K)	481.0	481.0

Table 2. Sequence of events for Test S-FS-11

<u>Event</u>	<u>Description</u>	<u>Measured</u> (sec)	<u>Calculated</u> (sec)
Transient initiation		0.0	0.0
PZR pressure = 15.8 MPa	T=Tscram	23.0	24.0
RCP coastdown		25.0	26.0
Power decay		26.5	24.0
MSCV close		26.5	24.0
AL SG steam pressure = 4.47 MPa	T=Tsis	209.0	165.0
Aux feed initiation		211.0	165.0
HPIIS initiation		211.0	165.0
Crossover line valve close		214.0	214.0
PZR heater (on/off)		(731/1053)	(731/1053)
AL SG aux feed restart		4100.0	4100.0
AL RCP restart		4450.0	4450.0
IL aux feed termination		5038.0	4500.0
Test termination		7600.0	7600.0





Fig.1 Axonometric configuration of Semiscale Mod-2C



INEL - 3956

Fig.2 Semiscale Type III Affected Loop (AL) SG Configuration




Fig.3 RELAP5 Nodalization for Semiscale Test S-FS-11




Fig.4 Affected Loop (AL) SG feedline break mass flowrate(0-1000s)




Fig.5 AL SG density before break




Fig.6 AL SG feed flowrate




Fig.7 AL SG auxfeed flowrate




Fig.8 AL SG steam flowrate




Fig.9 AL SG secondary pressure




Fig.10 AL SG liquid mass inventory




Fig.11 AL SG downcomer liquid level




Fig.12 AL SG heat transfer rate




Fig.13 IL SG heat transfer rate




Fig.14 Decay heat power




Fig.15 IL SG feed flowrate




Fig.16 IL SG auxfeed flowrate




Fig.17 IL SG steam flowrate




Fig.18 IL SG downcomer liquid level




Fig.19 IL SG secondary pressure




Fig.20 SG crossover line flowrate




Fig.21 PZR liquid level




Fig.22 PZR pressure




Fig.23 PZR heater power




Fig.24 IL charging flowrate




Fig.25 AL charging flowrate




Fig.26 PZR Saturation Temperature




Fig.27 ILHL liquid temperature




Fig.28 Primary subcooled margin




Fig.29 Upper plenum pressure




Fig.30 IL flowrate




Fig.31 AL flowrate




Fig.32 IL pump velocity




Fig.33 AL pump velocity




Fig.34 Upper plenum temperature




Fig.35 Lower plenum temperature




Fig.36 Time step size(0-1000s)




Fig.37 CPU time (0-1000s)




Fig.38 IL SG secondary voidf




Fig.39 AL SG secondary voidf




Fig.40 AL SG auxfeed flowrate (1000-8000 s)




Fig.41 AL SG secondary pressure




Fig.42 AL SG heat transfer rate




Fig.43 IL SG heat transfer rate




Fig.44 Decay heat power




Fig.45 IL SG auxfeed flowrate




Fig.46 IL SG downcomer liquid level




Fig.47 IL SG secondary pressure




Fig.48 PZR liquid level




Fig.49 PZR pressure




Fig.50 ILHL liquid temperature




Fig.51 Primary subcooled margin




Fig.52 AL pump velocity




Fig.53 Upper plenum temperature




Fig.54 Lower plenum temperature




Fig.55 Time step size (1000-8000 s)




Fig.56 CPU time (1000-8000 s)




Fig.57 IL SG secondary voidf




Fig.58 AL SG secondary voidf

***** semiscale mod-2c *****
 ***** standard transient *****
 ***** input deck *****
 ***** for relap5/mod2 *****
 ***** notes-
 ***** 1. this model is based on the standard mod-2a model
 ***** documented in reference 2 below.
 ***** 2. steady state runs are made either with the provided
 ***** control systems package or with additional components
 ***** for single condition steady state calculations.
 ***** 3. vessel heater tape to offset vessel heat loss is
 ***** included with this model. a control system to shut off
 ***** the vessel heaters and redistribute the power among
 ***** the remaining heaters is also included in this model.
 ***** 4. the thermal conductivity of the insulation on the
 ***** vessel and piping has been modified to give 56 kw
 ***** heat loss. the thermal conductivity of the insulation
 ***** on the steam generators has been modified to give
 ***** 14 kw heat loss. an additional 35 kw is lost due to
 ***** pump seal cooling when pumps are running at full speed.
 ***** the heater tape is wrapped in the "no break"
 ***** configuration from drawing 41420.
 ***** 5. the system configuration incorporated in this model is
 ***** the communicative cold leg break configuration.
 ***** all shi system components are removed and upper head
 ***** internals are modeled as modified to reflect non-shi
 ***** plant configuration.
 ***** 6. steam generator components have been renodalized to
 ***** reflect the pocc guidelines as established by caap
 ***** letter from c. davis.
 ***** 7. steam separator components reflect recommended model
 ***** changes from j. trapp. (no junctions are abrupt, and
 ***** inlet is homogeneous)
 ***** 8. primary coolant pump discharge junction is homogeneous
 ***** 9. the pressurizer is the 20 foot long pressurizer with
 ***** heat structure to model the walls and with heater
 ***** tape and insulation on the outside.
 ***** 10. a leak between the upper head to the upper plenum
 ***** through the support columns around the plugs is
 ***** included in this model.
 ***** 11. the pressurizer spray and associated thermal shock

***** shield are included in this model. normal spray goes
 ***** from the intact loop cold leg to the pressurizer via
 ***** time dependent volumes and junctions, matching temp.
 ***** if auxiliary spray is also used the spray temp will not
 ***** match the cold leg temp. if the thermal shock shield
 ***** was not included in the test both the hydraulics and
 ***** heat structure of the pressurizer must be modified.

references

* l. v. h. ranson et al., relap5/mod2 code manual, volume 1 and 2,
 egg-saam-6377, september 1983.

* 2. m. t. leonard, "relap5 standard model for the semiscale mod-2a
 * 3. system design description for the mod-3 semiscale system,
 revision b, december 1980.

= relap5 model for the semiscale fs-11 posttest - steady state

** for control system steady state runs, make appropriate changes
 ** in components -
 ** 610, 635, 710, 735, 930, 989, 991, trips, and control systems

* problem type option

0000100 new stdy-st

* in-pck or run

0000101 run

* units input output (si or british)

0000102 british si

* time out min max

0000105 5.0 6.0

0000105 125.0 150.0

* noncondensable gas type

0000110 nitrogen

* mass fraction

0000115 1.0

* vol so elev fluid name

0000120 101010000 1.0 water primary

0000121 600010000 0.0 water ilsg

0000122 700010000 0.0 water blsg

* t end min st max st st cl n i w

0000201 2. 1.0-7 0.05 3 20 40 40

0000202 10. 1.0-7 0.05 3 20 150 150

0000203 25. 1.0-7 0.05 3 40 300 300

0000204 100. 1.0-7 0.05 3 40 1500 1500

0000205 200. 1.0-7 0.05 3 40 1000 1000

0000206 1005. 1.0-7 0.05 3 40 2000 2000

#000201	35.0	1.0-7	0.5	3	20	200	200				
#000202	40.0	1.0-7	0.01	3	500	5000	5000				
000201	300.0	1.0-7	1.0	3	50	500	500				

## trips - trip cancellation card 400	variable trip cards 401-599	##									
## - trip stop card 600	logical trip cards 601-699	##									

##		##									
## 401	terminate calculation	##									
## 402	open break	##									
## 403	always false - used in motor valves that only close, etc	##									
## 406	begin transient	##									
## 407	hpis pressure setpoint	##									
## 408	begin hpis	##									
## 409	begin core decay - scram	##									
## 410	close main intact loop steam generator steam valve	##									
## 411	close main broken loop steam generator steam valve	##									
## 412	begin intact loop primary coolant pump coastdown	##									
## 413	begin broken loop primary coolant pump coastdown	##									
## 414	close main intact loop steam generator feedwater valve	##									
## 415	close main broken loop steam generator feedwater valve	##									
## 416	open auxiliary intact loop steam generator feedwater valve	##									
## 417	open auxiliary broken loop steam generator feedwater valve	##									
## 418	open pressurizer spray valve	##									
## 419	turn off steam generator mass controller	##									
## 420	always true	##									
## 421	open pressurizer relief valve	##									
## 423	valve out time dependent volume pressurizer for steady state	##									
## 424	open steam generator cross-over line valve	##									
## 425	close steam generator cross-over line valve	##									
## 426	monitor maximum heater rod temp - may want to stop calculation	##									
## 429	turn off pressurizer level controller	##									
## 430	begin using test power for guard heater bank 110 (hot legs)	##									
## 431	begin using test power for guard heater bank 111 (bl pcp scc)	##									
## 432	begin using test power for guard heater bank 112 (cold legs)	##									
## 433	begin using test power for guard heater bank 113 (il pcp scc)	##									
## 436	begin using test power for vessel external heaters (bank 116)	##									
## 437	begin using test power for pressurizer ext heaters (bank 117)	##									
## 439	turn on pressurizer heater rods	##									
## 440	turn off power to upper head heaters	##									
## 441	turn off power to upper vessel heaters	##									
## 442	turn off power to middle vessel heaters	##									
## 443	turn off power to vessel and downcomer heaters	##									
## 450	pressure to open intact loop steam generator relief valve	##									
## 451	pressure to close intact loop steam generator relief valve	##									
## 452	upper limit on intact loop secondary pressure for steady state	##									
## 453	lower limit on intact loop secondary pressure for steady state	##									
## 454	rate to close main intact loop steam valve for steady state	##									
## 455	rate to open main intact loop steam valve for steady state	##									
## 470	pressure to open broken loop steam generator relief valve	##									
## 471	pressure to close broken loop steam generator relief valve	##									
## 472	upper limit on broken loop secondary pressure for steady state	##									
## 473	lower limit on broken loop secondary pressure for steady state	##									
## 474	rate to close main intact loop steam valve for steady state	##									
## 475	rate to open main broken loop steam valve for steady state	##									
## 500	stop calculation	##									
## 624	open steam generator cross-over line valve	##									
## 640	turn off power to upper head heaters	##									

641 turn off power to upper vessel heaters

642 turn off power to middle vessel heaters

643 turn off power to vessel and downcomer heaters

660 reset intact loop steam relief valve for hysteresis effects

661 open intact loop steam generator relief valve

662 used in steady state control to open intact loop steam valve

663 used in steady state control to close intact loop steam valve

670 reset broken loop steam relief valve for hysteresis effects

671 open broken loop steam generator relief valve

672 used in steady state control to open broken loop steam valve

673 used in steady state control to close broken loop steam valve

##

* trip vr co para rela va co para add indx timeof

000401	time	0	ge	null	0	1000.0	1	-1.			
000402	time	0	ge	null	0	9999.0	1	-1.			
000403	time	0	lt	null	0	0.	1	-1.			
000406	time	0	ge	null	0	9999.0	1	-1.			
000407	p	999010000	le	null	0	1827.5	1	-1.			
000408	time	0	ge	timeof	407	26.3	1	-1.			
000409	time	0	ge	timeof	407	4.6	1	-1.			
000410	time	0	ge	timeof	407	7.3	1	-1.			
000411	time	0	ge	timeof	407	7.3	1	-1.			
000412	time	0	ge	timeof	407	4.7	1	-1.			
000413	time	0	ge	timeof	407	4.35	1	-1.			
000414	time	0	ge	timeof	407	0.0	1	-1.			
000415	time	0	ge	timeof	407	0.0	1	-1.			
000416	time	0	lt	null	0	0.0	1	-1.			
000417	time	0	lt	null	0	0.0	1	-1.			
000418	time	0	lt	null	0	0.	1	-1.			
000419	time	0	le	null	0	500.	1	-1.	ejl		
000420	time	0	ge	null	0	0.	1	0.			
000421	p	999010000	ge	null	0	2305.	1	-1.			
000422	time	0	ge	timeof	412	64.	1	-1.			
000423	time	0	ge	null	0	9998.	1	-1.			
000424	time	0	lt	null	0	0.	1	-1.			
000425	time	0	lt	null	0	0.	1	-1.			
000426	ctrivar	29	ge	null	0	922.0	1	-1.			
000429	time	0	le	null	0	340.	1	-1.			
000430	time	0	ge	timeof	406	0.	1	-1.			
000431	time	0	ge	timeof	406	0.	1	-1.			
000432	time	0	ge	timeof	406	0.	1	-1.			
000433	time	0	ge	timeof	406	0.	1	-1.			
000436	time	0	ge	timeof	406	0.	1	-1.			
000437	time	0	ge	timeof	406	0.	1	-1.			
000439	time	0	lt	null	0	0.	1	-1.			
000440	ctrivar	555	lt	null	0	+184.0	1	-1.			
000441	ctrivar	554	lt	null	0	+90.0	1	-1.			
000442	ctrivar	551	lt	null	0	-52.0	1	-1.			
000443	ctrivar	551	lt	null	0	-423.0	1	-1.			

* S71

000600	401	426									
000624	424	and	-425	1	-1.						
000640	422	and	440	1	-1.						
000641	422	and	441	1	-1.						
000642	422	and	442	1	-1.						
000643	422	and	443	1	-1.						

* steam generator relief valve trips, including hysteresis effects
 * steam generator relief valve logic
 * trips used for controlling steam generator pressures in steady-state
 * acceptable pressure bands - trips 462 & 463 (il) and 472 & 473 (bl)
 * max and min pressure rate changes - trips 454, 465(il), 474, 475(bl)
 * open or close steam valves - trips 662 & 663 (il) and 672 & 673 (bl)

0000460 p 611010000 gt null 0 1048.0 n -1.	2010001 2
0000461 p 611010000 gt null 0 1045.0 n -1.	* area vol no
0000470 p 705010000 gt null 0 1043.0 n -1.	2010101 .03955302 1 * hot vessel nozzle (id = 2.880 in)
0000471 p 705010000 gt null 0 1045.0 n -1.	2010102 .0313314 2 * 3 in sch 160
* length vol no	
0000660 461 and 661 n -1.	2010301 2.6425000 1
0000661 460 or 660 n -1.	2010302 2.4716657 2 * spool pieces 1 and 2
0000670 471 and 671 n -1.	* bz ang vol no
0000671 470 or 670 n -1.	2010501 -45.0 1
0000672 472 and 672 n -1.	2010502 -45.0 2
0000673 473 and 673 n -1.	* vr ang vol no
0000680 462 and 464 n -1.	2010601 0.0 2
0000681 463 and 465 n -1.	* ely ch vol no
0000682 462 and 464 n -1.	2010701 0.0 2
0000683 463 and 465 n -1.	* rough by dia vol no
0000684 ctrlvar 631 gt null 0 -2500. n -1.	2010801 6.667e-5 0.0 2
0000685 ctrlvar 631 lt null 0 2500. n -1.	* f loss r loss jum no
0000686 462 and 464 n -1.	2010901 0.05 0.05 1
0000687 463 and 465 n -1.	* ctl flg vol no
0000688 472 and 474 n -1.	2011001 0 2
0000689 473 and 475 n -1.	* vcahs jum no
0000690 472 and 474 n -1.	2011101 0 1
0000691 473 and 475 n -1.	* ctl press temp zero zero air flg vol no
0000692 472 and 474 n -1.	2011201 3 2258.30 592.30 0.0 0.0 0 1
0000693 473 and 475 n -1.	2011202 3 2258.30 592.30 0.0 0.0 0 2
0000694 ctrlvar 731 gt null 0 -2500. n -1.	* ctl flg
0000695 ctrlvar 731 lt null 0 2500. n -1.	2011300 1
0000696 472 and 474 n -1.	* flow-f flow-g velj jum no
0000697 473 and 475 n -1.	2011301 17.450 0.0 0.0 1
* hot leg - pressurizer surge line tee	
* ref drawings: hot leg nozzle - 407986	
* 3 pc-1b (sp-1) - 414684	
* 2.5pc-18 (sp-2) - 407346	
* 2.5pc-2 (sp-3) - 415155	
* inlet elev = outlet elev = + 8.500 in.	
2010000 name type	* name type
2010001 c201 pipe	2020001 c202 branch
2010001 no jum	2020001 3ctl

```

*      area   length   volume   bz ang   vr ang   elv ch
2020101 .0246289 2.7433333    0.0     0.0     0.0     0.0
*
*      rough   by dia   ctl
2020102 6.667e-5    0.0     0
*
*      ctl press   temp
2020200 3 2258.30 592.30
*
*      from   to   jun area   f loss   r loss   vcahs
2021101 201010000 202000000 .0246289  0.075  0.075     0
2022101 202010000 203000000 .0246289  0.075  0.075     0
2023101 997010000 202000000 7.4657e-4  0.0     0.0     101
*
*      flow-f   flow-g   velj
2021201 17.450    0.0     0.0
2022201 17.450    0.0     0.0
2023201 0.000    0.0     0.0
*
*****pressurizer desired level time dependent junction ****
*      elev = +326.875 in.
*
*      name   type
9850000 c89 tndpvol
*
*      area   length   volume   bz ang   vr ang   elv ch
9830101 .06925263 10.00    0.0     0.0     0.0     0.0
*
*      rough   by dia   ctl
9830102 0.0     0.0     0
*
*      ctl flg
9830200 2
*
*      time pressure   quale
9830201 0.0 2243.73 1.0
*
*****time dependent pressurizer junction ****
*      elev = +326.875 in.
*
*      name   type
9910000 tnd-prz valve
*
*      from   to   jun area   f loss   r loss   vcahs
9910101 993000000 999000000 .06925263  0.0     0.0     100
*
*      ctl flow-f   flow-g   velj
9910201 1 0.0     0.0     0.0
*
*      vlv type
9910300 strvlv
*
*      op trip   cl trip   slope   init pos   table
9910301 403     423     0.20    1.0     0
*
*****pressurizer desired level time dependent junction ****
*      for steady state - input for getting and maintaining desired level
*      elev = 87.000 in.
*
*      name   type
9850000 pzlvlv tndpjun
*
*      from   to   jun area
9850101 988000000 999010000 .012
*
*      ctl flg   trip   search variable
9850200 1       0       contrivar 985
*
*      table takes into account conversion of kg to lb
*      kg   lb
9850201 -10.0   -22.0462  0.0     0.0
9850202 0.0     0.0     0.0     0.0
9850203 10.0    22.0462  0.0     0.0
*
*****pressurizer desired level time dep volume - temp from bottom prz ****
*      elev = +326.875 in.
*
*      name   type
9800000 pzlvlv tndpvol
*
*      area   length   volume   bz ang   vr ang   elv ch
9800101 .012    10.00    0.0     0.0     0.0     0.0
*
*      rough   by dia   ctl
9800102 0.0     0.0     0
*
*      ctl flg   trip   search variable
9800200 1       0       tempf 999070000
*
*      temp (f)   temp (f)   quale
9800201 80.0    80.0     0.0
9800202 575.0   575.0    0.0
9800203 1340.0  1340.0   0.0
9800204 17540.0 17540.0  0.0
*
*****pressurizer spray time dependent junction ****
*      elev = +326.875 in.
*
*      name   type

```

```

9100000  pzspry tdpjm
*
*      from      to jns area
9100101  92000000 99900000 .012
*
*      ctl flg    trip
9100200  1     418
*
*      check flows for 260 - same if normal spray only
*      time   flow-f   flow-g   velj
9100201  -1.0  0.0     0.0     0.0
9100202  0.0   0.0     0.0     0.0
9100203  2000.0 0.0     0.0     0.0
*
***** pressurizer spray time dep volume - temp from intact loop cold leg ****
*
*      elev = +326.875 in.
*
*      name      type
9200000  pzspry tdpvol
*
*      area      length   volume   bz ang   vr ang   elv ch
9200101  .012    10.00    0.0     0.0     0.0     0.0
*
*      rough    hy dia    ctl
9200102  0.0     0.0     0
*
**** normal spray ****
**      ctl flg    trip    search variable
9200200  1     0     temp 261010000
**
**      temp (f)  temp (f)  quale
9200201  80.0    80.0    0.0
9200202  575.0   575.0   0.0
9200203  1340.0  1340.0  0.0
9200204  17540.0 17540.0 0.0
**
**** auxilary spray or combination ****
**      ctl flg
9200200  3
*
**      time pressure   temp
9200201  0.0    12.3    80.0
*
***** pressurizer pressure relief valve ****
*
*      elev = +326.875 in.
*
*      elev = +326.875 in.
*
*      name      type
9300000  prsdrv tdpvol
*
*      area      length   volume   bz ang   vr ang   elv ch
9300101  10.00   10.00    0.0     0.0     0.0     0.0
*
*      rough    hy dia    ctl
9300102  0.0     0.0     0
*
*      ctl flg
9300200  2
*
**      time   pressure   quale
9300201  0.0    12.3    1.0
*
***** long pressurizer ****
*
*      ref drawings: 41620 - par assembly
*                      41619 - prz installation
*                      418126 - par thermal shield for spray, no liner
*
*      vessel id = 3.631 in, total interior height = 239.875 in
*      bottom of pressurizer model is top of heater rod retainer
*      which is 5.2 inches below the lower pressure tap
*      includes 6 heater rods 0.73 inches dia.
*
*      total volume = 2417.26 in3 without thermal shield
*
*      inlet elev = top = +326.875 in.
*      outlet elev = bottom = + 87.000 in.
*
*      name      type
9990000  c99     pipe
*
*      no vol
9990001  8
*
*      area   vol no

```

9990101 0.07190844 1
 9990102 0.07190844 7
 9990103 0.05350067 8 * includes 6 btr rods, grid plate.
 *
 * area jnn no
 9990201 0.07190844 1
 9990202 0.07190844 6
 9990203 0.05350067 7
 *
 * length vol no
 9990301 2.500000 1
 9990302 2.552500 6
 9990303 2.533333 7
 9990304 2.093750 8
 *
 * vr ang vol no
 9990501 -90.0 8
 *
 * elev ch vol no
 9990701 -2.500000 1
 9990702 -2.552500 6
 9990703 -2.533333 7
 9990704 -2.093750 8
 *
 * rough by dia vol no
 9990801 6.667e-5 .285333 1
 9990802 6.667e-5 .3025333 7
 9990803 6.667e-5 .1005325 8
 *
 * f loss r loss jnn no
 9990901 0.0 0.0 7
 *
 * ctl flg vol no
 9991001 0 8
 *
 * vcais jnn no
 9991103 0 7
 *
 * ctl press qmals zero zero air flg vol no
 9991201 2 2258.30 1.00 0.0 0.0 0 2
 9991202 2 2258.30 0.0777 0.0 0.0 0 3
 9991203 2 2258.30 0.00 0.0 0.0 0 8
 *
 * ctl flg
 9991300 1
 *
 * flow-f flow-g velj jnn no
 9991301 0.0 0.0 0.0 7
 *
 * pressurizer vessel outlet
 * ref drawings: 416204 & 416205
 * outlet 6 holes + annulus around grid plate
 * elev = 87.000 in.
 * name type
 9980000 j+998 singljm
 *
 * from to jnn area f loss r loss vcais
 9980101 999010000 997000000 6.1762e-3 0.0 0.0 100
 *
 * ctl flow-f flow-g velj
 9980201 1 0.0 0.0 0.0
 *
 * pressurizer surge line
 * ref drawings: 416119 & 416204
 * inlet elev = top = + 87.000 in.
 * outlet elev = bottom = + 8.500 in.
 * name type
 9970003 c+997 pipe
 *
 * no vol
 9970001 3
 *
 * area vol no
 9970101 6.1762e-3 1 * includes heater rod retainer
 9970102 7.4667e-4 2
 9970103 7.4667e-4 3
 *
 * length vol no
 9970301 0.5416667 1
 9970302 5.6453333 2
 9970303 4.0625000 3
 *
 * vr ang vol no
 9970601 -90.0 1
 9970602 -90.0 2
 9970603 -5.46 3
 *
 * elev ch vol no
 9970701 -0.5416667 1
 9970702 -5.6453333 2
 9970703 -0.3541667 3
 *
 * rough by dia vol no
 9970801 6.667e-5 .0479447 1
 9970802 6.667e-5 .0308333 3
 *
 * f loss r loss jnn no
 9970901 7.834 7.834 1 * total r' = 1.63e9 m⁻⁴
 9970902 7.834 7.834 2 * divided equally among
 * the two junctions
 * k = (r')/(2a²)
 *
 * ctl flg vol no
 9971001 0 3
 *
 * vcais jnn no
 9971101 0 2

*	ctl	press	temp	zero	zero	air flg	vol no
9971201	3	2258.30	592.30	0.0	0.0	0	3
*	ctl flg						
9971300		1					
*	flow-f	flow-g	velj	jum no			
9971301		0.0	0.0	0.0			2
*	*****	*****	*****	*****	*****	*****	*****
*	bot leg pressurizer surge line tee to steam generator inlet						
*****	*****	*****	*****	*****	*****	*****	*****
*	ref drawings:	2.5pc-6 (sp-4) - 414431					
*	2.5pc-7 (sp-5) - 414425						
*	2.5pc-8 (sp-6) - 414426						
*	2.5pc-9 (sp-7) - 414427						
*	inlet plenum	- 414271					
*	*****	*****	*****	*****	*****	*****	*****
*	inlet elev = + 8.500 in. (bot leg centerline)						
*	outlet elev = + 73.969 in. (bottom of inlet plenum)						
*	*****	*****	*****	*****	*****	*****	*****
*	name	type					
2030000	c203	pipe					
*	*****	*****	*****	*****	*****	*****	*****
*	no vol						
2030001		3					
*	*****	*****	*****	*****	*****	*****	*****
*	area	vol no					
2030101	.024629	3 ± 2.5 in sch-160					
*	*****	*****	*****	*****	*****	*****	*****
*	length	vol no					
2030001	2.6542072	1 ± spool pieces 4,5,6					
2030002	2.3329157	2					
2030003	2.1884513	3 ± spool piece 7 & inlet plenum connect					
*	*****	*****	*****	*****	*****	*****	*****
*	vr ang	vol no					
2030601	+45.0	1					
2030602	+90.0	2					
2030603	+45.0	3					
*	*****	*****	*****	*****	*****	*****	*****
*	elv ch	vol no					
2030701	1.3941666	1					
2030702	2.3329157	2					
2030703	1.7286602	3					
*	*****	*****	*****	*****	*****	*****	*****
*	rough	by dia	vol no				
2030801	6.657e-5	0.0	3				
*	*****	*****	*****	*****	*****	*****	*****
*	f loss	r loss	jum no				
2030901	0.075	0.075	1				
2030902	0.050	0.050	2				
*	*****	*****	*****	*****	*****	*****	*****
*	ctl flg	vol no					
2031001	0	3					
*	*****	*****	*****	*****	*****	*****	*****
*	vcabs	jum no					
ktt							
2031101	100000	2					

*	ctl	press	temp	zero	zero	air flg	vol no
2031201	3	2258.30	592.30	0.0	0.0	0	1
2031202	3	2258.30	592.30	0.0	0.0	0	2
2031203	3	2258.30	592.30	0.0	0.0	0	3
*	*****	*****	*****	*****	*****	*****	*****
*	ctl flg						
2031300		1					
*	*****	*****	*****	*****	*****	*****	*****
*	flow-f	flow-g	velj	jum no			
2031301		17.450	0.0	0.0			2
*	*****	*****	*****	*****	*****	*****	*****
*	kkt						
2031401	0.0	0.0	0.55	0.785	2		
*	*****	*****	*****	*****	*****	*****	*****
*	intact loop						
*	type-ii						
*	steam generator						
*****	*****	*****	*****	*****	*****	*****	*****
*	steam generator inlet						
*****	*****	*****	*****	*****	*****	*****	*****
*	ref drawing:	414271					
*	elev = +73.969 in.						
*	name	type					
2050000	j205	seg1jum					
*	*****	*****	*****	*****	*****	*****	*****
*	frpm	to jum area	f loss	r loss	vcabs		
2050101	203010000	21000000	0.024629	6.0	0.0	000	
*	*****	*****	*****	*****	*****	*****	*****
*	ctl	flow-f	flow-g	velj			
2050201	1	17.450	0.0	0.0			
*	*****	*****	*****	*****	*****	*****	*****
*	steam generator inlet plenum						
*****	*****	*****	*****	*****	*****	*****	*****
*	reference - type-ii (intact loop) steam generator part-leg drwg,						
*	and plenum drwg, 414271 (1,2)						
*	note - inlet plenum entrance is circular (dia=2.125 in),						
*	plenum tapers outward, nonuniformly, with rise to						
*	tube sheet inlet (inlet plenum outlet).						
*	outlet is rectangular with radiused corners.						
*	inlet elev = bottom = + 73.969 in.						
*	outlet elev = top = + 81.594 in.						
*	name	type					
2100000	c210	smglvol					
*	*****	*****	*****	*****	*****	*****	*****
*	area	length	volume	lz ang	vr ang	elv ch	
2100101	0.0	0.6354157	0.0478680	+90.0	+90.0	0.6354157	
*	*****	*****	*****	*****	*****	*****	*****
*	rough	by dia	ctl				
2100102	6.657e-5	0.2805910	0				

*
 * cil press temp zero
 2100200 3 2258.30 592.30 0.0
 *
 * intact loop steam generator tube sheet inlet
 *
 * ref drawing: 406416
 *
 * inlet elev = bottom = +81.594 in. (bottom of tube sheet)
 * outlet elev = top = +102.594 in. (top of tube sheet)
 *
 *
 * name type
 2150000 ilt-in branch
 *
 * no jun in cil
 2150001 2 1
 *
 * area length volume bz ang vr ang elv ch
 2150101 0.019757 1.7500 0.0 0.0 90.0 1.7500
 *
 * rough by dia cil
 2150102 5.000e-6 .06475 0
 *
 * cil press temp
 2150200 3 2258.30 592.30
 *
 * from to jun area f loss r loss wels
 2151101 210010000 215000000 0.019757 1.0 0.0 100
 2152101 215010000 220000000 0.019757 0.0 0.0 000
 *
 * flow-f flow-g velj
 2151201 17.450 0.0 0.0
 2152201 17.450 0.0 0.0
 *kkt
 2170000 ilsgin sngjia
 2170101 215010000 220000000 0.019757 0.0 0.0 100100
 2170110 0.0 0.0 0.725 1.0
 2170201 0.0 0.855 0.855 0.0
 *
 * steam generator tube bundle
 *
 * ref drawings: 413415 & 414271
 *
 * inlet elev = outlet elev = +102.594 in. (top of tube sheet)
 *
 * elev long tube = 391.24 in. above top of tube sheet
 * elev middle tube = 364.86 in. above top of tube sheet
 * elev short tube = 336.99 in. above top of tube sheet
 *
 * elev model tube = 364.490 in. above top of tube sheet
 *
 * name type
 2200000 isgtub pipe
 *
 * no vol
 2200001 8
 * area vol to
 2200101 0.019757 8 * 6 tubes, id = 0.777 in
 * length vol no
 2200301 7.9525000 1 * 8 volumes around u-tubes; 4 up and
 2200302 7.9108334 3 * 4 down. lengths are equivalent
 2200303 6.6920292 5 * to secondary side lengths (c000)
 2200304 7.9108334 7
 2200305 7.9525000 8
 * vr ang vol no
 2200601 +90.0 3
 2200602 +88.6 4
 2200603 -88.6 5
 2200604 -90.0 8
 * elv ch vol no
 2200701 +7.9525000 1
 2200702 +7.9108334 3
 2200703 +6.5999983 4
 2200704 +5.5999983 5
 2200705 -7.9108334 7
 2200706 -7.9525000 8
 * rough by dia vol no
 2200801 5.000e-6 .06475 8
 * f loss r loss jun no
 2200901 0.0 0.0 3
 2200902 0.0 0.0 4
 2200903 0.0 0.0 7
 * cil flg vol no
 2201001 0 8
 * cil flg jun no
 2201101 0 7
 * cil press temp zero zero air flg vol no
 2201201 3 2258.30 592.30 0.0 0.0 0 1
 2201202 3 2258.30 592.30 0.0 0.0 0 2
 2201203 3 2258.30 592.30 0.0 0.0 0 3
 2201204 3 2258.30 592.30 0.0 0.0 0 4
 2201205 3 2258.30 531.30 0.0 0.0 0 5
 2201206 3 2258.30 531.30 0.0 0.0 0 6
 2201207 3 2258.30 531.30 0.0 0.0 0 7
 2201208 3 2258.30 531.30 0.0 0.0 0 8
 * cil flg
 2201300 1
 * flow-f flow-g velj jun no
 2201301 17.450 0.0 0.0 7
 *

* steam generator secondary volume
 * ref drawings: 413463 - assembly 416419 - separator
 * 413357 - fillers 413415 - baffle plates
 * inlet elev = 0.000 in. above top of tube sheet
 * outlet elev = 436.875 in. above top of tube sheet
 * name type
 6000000 isgsec pipe
 * no vol
 6000001 5
 * area vol no
 6000101 0.0 5
 * area jun no
 6000201 .0533799 3 * single baffle plate along flow path
 6000202 .0917866 4 * baffle plate which supports tc-tube
 * length vol no
 6000301 7.9525000 1 * vol begins above top of tube sheet.
 6000302 7.9108334 3 * volumes are separated by junctions
 6000303 7.4762500 4 * at baffle plates. (not all plates are)
 6000304 5.1558333 5 * considered - some are within volumes
 * volume vol no
 6000401 1.0038417 1
 6000402 0.9402046 2
 6000403 0.8926058 3
 6000404 1.0017945 4
 6000405 2.2709806 5
 * vr ang vol no
 6000501 +90.0 5
 * elv ch vol no
 6000701 7.9525000 1
 6000702 7.9108334 3
 6000703 7.4762500 4
 6000704 5.1558333 5
 * rough by dia vol no
 6000801 6.667e-5 .0834737 3
 6000802 6.667e-5 .1058911 4
 6000803 6.667e-5 .5378870 5
 * ctl fig vol no
 6001001 0 5
 * vrabs jun no
 6001101 100 4 * baffle plates
 * ctl press qmals zero zero air flg vol no
 6001201 2 829.600 0.02054 0.0 0.0 0 1
 6001202 2 829.600 0.04054 0.0 0.0 0 2
 6001203 2 829.600 0.06054 0.0 0.0 0 3
 6001204 2 829.600 0.08054 0.0 0.0 0 4
 6001205 2 829.600 0.10000 0.0 0.0 0 5
 * ctl flg
 6001300 0
 * vel-f vel-g velj jun no
 6001301 2.800 4.500 0.0 1
 6001302 4.700 7.400 0.0 2
 6001303 5.200 10.500 0.0 3
 6001304 4.000 11.700 0.0 4
 * kkt
 6001401 0.0 1.0 1.0 1.0 3
 6001402 0.0 1.0 1.0 1.0 4
 * intact loop steam generator secondary separator
 * ref drawing: 413463
 * inlet elev = 436.875 in. above top of tube sheet
 * outlet elev = 446.375 in. above top of tube sheet
 * name type
 6010000 isgprt separator
 * no jun ctl
 6010001 3 0
 * area length volume bz ang vr ang elv ch
 6010101 0.0 .7916667 .4508175 0.0 90.0 .7916667
 * rough by dia ctl
 6010102 6.667e-5 0.0 0
 * ctl press qmals
 6010200 2 829.600 0.30
 * from to jun area f loss r loss eabs voidfr
 6011101 601201000 612000000 .4690572 0.0 0.0 1002 0.50
 6012101 601100000 602000000 .4690572 0.0 0.0 1002 0.15
 6013101 600010000 601000000 .5353713 0.0 0.0 1000
 * vel-f vel-g velj
 6011201 -2.500 1.600 0.0
 6012201 1.000 0.0 0.0
 6013201 1.600 1.600 0.0
 * intact loop steam generator secondary steam dome
 * ref drawing: 413795
 * inlet elev = 446.375 in. above top of tube sheet
 * outlet elev = 455.360 in. above top of tube sheet

```

*           name   type
6110000    isgsd  segval
*
*           area   length  volume  bz ang  vr ang  elv ch
6110101    0.0    .748750  .4249623  0.0     90.0    .748750
*
*           rough  by dia   ctl
6110102    6.667e-5  .5664355  0
*
*           ctl press  quals  zero
6110200    2 829.600  1.00    0
*
*           *****
*           intact loop steam generator secondary downcomer (top)
*           *****
*
*           ref drawing: 413463
*
*           inlet elev = 441.625 in. above top of tube sheet
*           outlet elev = 375.005 in. above top of tube sheet
*
*           name   type
6020000    isgbd  branch
*
*           no jun   ctl
6020001    1      0
*
*           area   length  volume  bz ang  vr ang  elv ch
6020101    0.0    5.5516667  3.0085308  0.0    -90.0    -5.5516667
*
*           rough  by dia   ctl
6020102    6.667e-5  .3369291  0
*
*           ctl press  quals
6020200    2 829.600  0.00
*
*           from   to jun area  f loss  r loss  vcahs
6021101    602010000 603000000  .0819037  0.0     0.0      0
*
*           vel-f   vel-g   velj
6021201    0.4300  -0.3400  0.0
*
*           *****
*           intact loop steam generator secondary separator bypass
*           *****
*
*           ref drawing: 413463
*
*           inlet elev = 441.625 in. above top of tube sheet
*           outlet elev = 460.110 in. above top of tube sheet
*
*           name   type
6120000    isgbp  branch
*
*           no jun   ctl
6120001    2      0
*
*           area   length  volume  bz ang  vr ang  elv ch
6120101    0.0    1.5494167  .7816260  0.0     90.0    1.5494167
*
*           rough  by dia   ctl
6120102    6.667e-5  .6533449  0
*
*           ctl press  quals
6120200    2 829.600  1.00
*
*           from   to jun area  f loss  r loss  vcahs
6121101    612010000 611000000  0.3139546  0.0     0.0      3
6122101    602000000 612000000  0.7880455  0.0     0.0      0
*
*           vel-f   vel-g   velj
6121201    0.0     0.0     0.0
6122201    0.0     0.0     0.0
*
*           *****
*           intact loop steam generator secondary downcomer (bottom)
*           *****
*
*           ref drawings: 413363 - assembly
*           414048 - fillers
*
*           inlet elev = 375.005 in. above top of tube sheet
*           outlet elev = 0.000 in. above top of tube sheet
*
*           name   type
6030000    isgdcb pipe
*
*           no vol
6030001    4
*
*           area   vol no
6030101    0.0     4
*
*           area   jun no
6030201    0.0292836  3
*
*           length  vol no
6030301    7.4762500  1
6030302    7.9108334  3
6030303    7.9525000  4
*
*           volume  vol no
6030401    .2211171  1
6030402    .2316581  2
6030403    .2316581  3
6030404    .3322701  4
*
*           vr ang  vol no
6030601    -90.0    4
*
*           elv ch  vol no
6030701    -7.4762500  1
6030702    -7.9108334  3
6030703    -7.9525000  4

```

* rough by dia vol no
 6030801 6.66e-5 .0128227 1
 6030802 6.66e-5 .0126581 3
 6030803 6.66e-5 .0201539 4
 *
 * ctl flg vol no
 6031001 0 4
 *
 * vchals junc no
 6031101 0 3
 *
 * ctl press quals zero zero air flg vol no
 6031201 2 829.609 0.0 0.0 0 1
 6031202 2 829.600 0.0 0.0 0 2
 6031203 2 829.600 0.0 0.0 0 3
 6031204 2 829.600 0.0 0.0 0 4
 *
 * ctl flg
 6031300 0
 *
 * vel-f vel-g velj junc no
 6031301 6.450 6.100 0.0 3
 *
 * * * * * downcomer - riser junction (thru flow divider) *
 * * * * * ref drawing: 413979, flow restrictor, adjustable area
 *
 * elev = 0.0 in. above top of tube sheet
 *
 * name type
 6040000 isgfs ssgljm
 *
 * from to junc area f loss r loss vchals
 6190101 603010000 600000000 .0417818 0.0 0.0 100
 *
 * ctl vel-f vel-g velj
 6040201 0 7.500 7.200 0.0
 *
 * * * * * steam generator secondary - time dep feedwater junction *
 * * * * * elev = 0.0 in. above top of tube sheet
 *
 * name type
 6100000 isgfvj tdpjnm
 *
 * from to junc area
 6100101 62000000 603010000 .012
 *
 * ctl flg trip
 6100200 1 414
 *
 * time flow-f flow-g velj
 *6100201 -1.0 5.6034 0.0 0.0
 *6100202 0.0 5.6034 0.0 0.0
 *6100203 200.0 0.0 0.0 0.0
 *
 * for steady state - input for keeping steam generator mass constant,
 * put in what goes out steam valve - (comment not cards 61002xx above)
 *
 *6100200 1 420 cetrivar 610
 * table takes into account conversion of kg to lb
 *6100201 -10.0 0.0 0.0 0.0 * ejl
 *6100201 -10.0 -22.0462 0.0 0.0
 *6100202 0.0 0.0 0.0 0.0
 *6100203 0.1 0.22046 0.0 0.0
 *6100204 10.0 22.0462 0.0 0.0
 *
 * * * * * steam generator secondary - time dep feedwater volume *
 * * * * *
 * elev = 0.0 in. above top of tube sheet
 *
 * name type
 6200000 isgfw tdpvol
 *
 * area length volume bx ang vr ang elv ch
 6200101 .012 10.00 0.0 0.0 0.0 0.0
 *
 * rough by dia ctl
 6200102 0.0 0.0 0
 *
 * ctl flg
 6200200 1 3
 *
 * time pressure temp
 6200201 0.0 1250.0 405.0 * ejl
 *
 * * * * * steam generator secondary - time dep aux feedwater junction *
 * * * * *
 * elev = 0.0 in. above top of tube sheet
 *
 * name type
 6150000 isgafvj tdpjnm
 *
 * from to junc area
 6150101 62300000 603010000 .012
 *
 * ctl flg trip
 6150200 1 415
 *
 * time flow-f flow-g velj
 6150201 -1.0 0.0 0.0 0.0
 6150202 0.0 0.0 0.0 0.0
 6150203 200.0 0.0 0.0 0.0
 *
 * * * * * steam generator secondary - time dep aux feedwater volume *
 * * * * *

```

* elev = 0.0 in. above top of tube sheet
*
*       name   type
6250000  isgafw  tdpvol
*
*       area   length  volume  bz ang  vr ang  elv ch
6250101  .012    10.00   0.0     0.0     0.0     0.0
*
*       rough  by dia   ctl
6250102  0.0     0.0     0
*
*       ctl flg
6250200  3
*
*       time  pressure  temp
6250201  0.0    900.0   80.0
*****
* steam generator secondary - discharge junction valve
*****
* elev = 455.360 in. above top of tube sheet
*
*       name   type
6350000  isgdfj  valve
*
*       from   to jnn area  f loss  r loss  vcahs
6350101  611010000 650000000 .007   204.67  204.67  100
*
*       ctl flow-f  flow-g  velj
6350201  1    0.0    5.6034  0.0
*
*       vlv type
6350300  triplv
*
*       op trip cl trip slope init pos table
6350301  403    410    .3333  0.294088  0
*
* input for steady state control systems (comment out cards 63503xx)
6350300  svlplv
6350301  637
*
* steam generator secondary - time dep discharge volume
*****
* elev = 455.360 in. above top of tube sheet
*
*       name   type
6340000  isgrv  valve * simulate adv
*
*       from   to jnn area  f loss  r loss  vcahs
6340101  611010000 640000000 .0002592  0.0    0.0    100
*
*       ctl flow-f  flow-g  velj
6340201  1    0.0    0.0    0.0
*
*       vlv type
6340300  triplv
*
*       trip
6340301  661
*****
* steam generator secondary - time dep relief discharge volume
*****
* elev = 455.360 in. above top of tube sheet
*
*       name   type
6400000  isgrv  tdpvol
*
*       area   length  volume  bz ang  vr ang  elv ch
6400101  .70584   10.0    0.0     0.0     0.0     0.0
*
*       rough  by dia   ctl
6400102  0.0     0.0     0
*
*       ctl flg
6400200  2
*
*       time  pressure  quale
6400201  0.0    12.3    1.0
*****
* cross connection - junction from il steam dome to connection pipe
*****
* elev = 455.360 in. above top of tube sheet
*
*       name   type
6370000  ilcadj  singljun
*
*       from   to jnn area  f loss  r loss  vcahs

```

*6370101 611010000 637000000 0.003003 0.0 0.0 000
 **
 ** ctl vel-f vel-g velj
 *6370201 0 0.0 0.0 0.0
 **

 * intact loop steam dome cross connection pipe to bl steam dome *

 *
 * inlet elev = 455.360 in. above top of tube sheet
 * outlet elev = 476.125 in. above top of tube sheet
 *
 * note - cross-over pipe snakes around:
 * vertically down 18.00 ft
 * horizontally over 8.000 ft
 * horizontally back 6.000 ft
 * vertically up 19.730 ft
 * horizontally over 5.000 ft, part of 746
 * horizontally forward 2.000 ft, part of 746
 *
 ** base type
 *6370000 ilcnp pipe
 **
 ** no vol
 *6370001 3
 **
 ** area vol no
 *6370101 .003003 3
 **
 ** length vol no
 *6370301 18.0 1
 *6370302 14.0 2
 *6370303 19.7304167 3
 **
 ** vr ang vol no
 *6370601 -90.0 1
 *6370602 0.0 2
 *6370603 +90.0 3
 **
 ** elv ch vol no
 *6370701 -18.0 1
 *6370702 0.0 2
 *6370703 19.7304167 3
 **
 ** rough by dia vol no
 *6370801 6.67e-5 0.0 3
 **
 ** ctl flg vol no
 *6371001 0 3
 **
 ** vcahs jno no
 *6371101 0 2
 **
 ** ctl press gvals zero zero air flg vol no
 *6371201 2 829.600 0.0 0.0 0.0 0 1
 *6371202 2 829.600 0.0 0.0 0.0 0 2
 *6371203 2 829.600 0.0 0.0 0.0 0 3
 **
 **ctl flg
 *6371300 0
 **
 ** vel-f vel-g velj jno no
 *6371301 0.0 0.0 0.0 2
 **

 * steam generator secondary - connection valve to broken loop secondary*

 *
 * elev = 455.360 in. above top of tube sheet
 *
 ** name type
 *670000 ilblc valve
 **
 ** from to jno area f loss r loss vcahs
 *6700101 637010000 746010000 0.00661 0.0 0.0 100
 **
 ** ctl flow-f flow-g velj
 *6700201 1 0.0 0.0 0.0
 **
 ** pvl type
 *6700300 nrvlv
 **
 ** op trip cl trip slope init pos table
 *6700301 624 425 1.0 0.0 0
 **
 *
 * end of *
 * steam generator *
 * secondary *

 * intact loop steam generator tube sheet outlet *

 *
 * ref drawings: 406416 & 414271
 *
 * inlet elev = +102.594 in. (top of tube sheet)
 * outlet elev = +81.594 in. (bottom of tube sheet)
 *
 ** name type
 2250000 ilts-ot branch
 **
 ** no jno ctl
 2250001 2 1
 **
 ** area length volume hr ang vr ang elv ch
 2250101 0.019757 1.7500 0.0 0.0 -90.0 -1.750
 **
 ** rough by dia ctl
 2250102 5.000e-6 .06475 0
 **
 ** ctl press temp
 2250200 3 2258.30 531.30
 **
 ** from to jno area f loss r loss vcahs
 2251101 220010000 225000000 0.019757 0.0 0.0 000
 2252101 225010000 230000000 0.019757 0.0 1.0 100

* inlet elev = +73.969 in.
 * u-bend bottom elev = -110.750 in.
 * outlet elev = -9.850 in.
 *
 * flow-f flow-g velj
 2251201 17.450 0.0 0.0
 2252201 17.450 0.0 0.0
 *
 * name type
 2300000 c240 pipe
 * steam generator outlet plenum *
 *
 * ref drawing: 414271
 * see note for steam generator inlet plenum (c210)
 *
 * inlet elev = top = +81.594 in.
 * outlet elev = bottom = +73.969 in.
 *
 * name type
 2300000 c230 snglvol
 *
 * area length volume bz ang vr ang elv ch
 2300101 0.0 0.6354167 0.0478680 +90.0 -90.0 -0.6354167
 *
 * rough by dia ctl
 2300102 6.667e-5 .2805910 0
 *
 * ctl press temp zero
 2300200 3 2258.30 531.30 0.0
 *
 * Steam generator outlet *
 *
 * elev = +73.969 in.
 *
 * name type
 2350000 j8 snglun
 *
 * from to jum area f loss r loss vcds
 2350101 230010000 240000000 0.024629 0.0 6.0 000
 *
 * ctl flow-f flow-g velj
 2350201 1 17.450 0.0 0.0
 *
 * pump section leg *
 *
 * ref drawings: inlet plenum - 414271
 * 2.5pc-10 (sp-8) - 41428
 * 2.5pc-11 (sp-9) - 41425-2
 * 2.5pc-12 (sp-10) - 41425-2
 * 2.5pc-13 (sp-11) - 41429
 * 2.5pc-14 (sp-12) - 41425-1
 * 2.5pc-15 (sp-13) - 414026
 * 2.5pc-16 (sp-14) - 414027
 * 2.5pc-17 (sp-15) - 414025-2
 * 2.5pc-18 (sp-16) - 414028

	area	length	vol no
2400101	0.024629	1.5217847	9 * 2.5 in sch-160
2400301		3.6662500	1 * spool piece - 8
2400302		3.4475000	2 * sp - 8,9,10
2400303		2.8958333	3 * sp - 11,12
2400304		3.5076302	4 * sp - 13
2400305		1.5219271	5 * sp - 14 straight + 30 deg bend
2400306		1.5219271	6 * sp - 14 60 deg of bend
2400307		3.5076302	7 * sp - 14 60 deg of bend
2400308		4.2083333	8 * sp - 14 straight + 30 deg bend
2400309			9 * sp - 15, 16

	vr ang	vol no
2400601	-45.0	1
2400602	-90.0	4
2400603	-86.79	5
2400604	-30.0	6
2400605	+30.0	7
2400606	+86.79	8
2400607	+90.0	9

	elv ch	vol no
2400701	-1.1836692	1
2400702	-3.6662500	2
2400703	-3.4475000	3
2400704	-2.8958333	4
2400705	-3.4733333	5
2400706	-0.7266667	6
2400707	0.7266667	7
2400708	3.4733333	8
2400709	4.2083333	9

	rough	by dia	vol no
2400801	6.667e-5	0	9

	f loss	r loss	jum no
2400901	0.0	0.0	1
2400902	0.0	0.0	4
2400903	0.0	0.0	7
2400904	0.3	0.3	8

	ctl fig	vol no
2401001	0	9

	ctl fig	jum no
2401101	0	8

```

*ctl press temp zero zero air flg vol no
2401201 3 2258.30 531.30 0.0 0.0 0 1
2401202 3 2258.30 531.30 0.0 0.0 0 2
2401203 3 2258.30 531.30 0.0 0.0 0 3
2401204 3 2258.30 531.30 0.0 0.0 0 4
2401205 3 2258.30 531.30 0.0 0.0 0 5
2401206 3 2258.30 531.30 0.0 0.0 0 6
2401207 3 2258.30 531.30 0.0 0.0 0 7
2401208 3 2258.30 531.30 0.0 0.0 0 8
2401209 3 2258.30 531.30 0.0 0.0 0 9
*stop data els tn mx-f-sp mx-r-sp
2500310 0.0 0.0 0.0 0.0
*card cccx00-cccx99 single phase pump head and torque curve set
* single phase 4 quadrant head tables (homologous curves)
*
2501100 1 1
2501101 0.000, 1.409 0.174, 1.364 0.349, 1.354 0.495, 1.317
2501102 0.700, 1.224 0.884, 1.093 1.000, 1.000
2501200 1 2
2501201 0.000,-0.650 0.250,-0.475 0.500,-0.194 0.624, 0.000
2501202 0.800, 0.400 0.900, 0.700 1.000, 1.000
2501300 1 3
2501301 -1.000, 2.725 -0.888, 2.470 -0.739, 2.240 -0.492, 1.880
2501302 -0.257, 1.570 0.000, 1.409
2501400 1 4
2501401 -1.000, 2.725 -0.783, 2.050 -0.653, 1.760 -0.454, 1.500
2501402 -0.253, 1.270 0.000, 1.057
2501500 1 5
2501501 0.000, 0.619 0.226, 0.577 0.411, 0.559 0.654, 0.612
2501502 0.875, 0.759 1.000, 1.000
2501600 1 6
2501601 0.000, 1.057 0.190, 0.888 0.315, 0.831 0.609, 0.807
2501602 0.934, 0.921 1.000, 1.000
2501700 1 7
2501701 -1.000,-0.550 -0.879,-0.275 -0.712, 0.000 -0.561, 0.367
2501702 -0.117, 0.642 0.000, 0.519
2501800 1 8
2501801 -1.000,-0.550 -0.500,-0.600 0.000,-0.650
* single phase 4 quadrant torque tables
*
2501900 2 1
2501901 0.000, 0.540 0.200, 0.590 0.400, 0.650 0.600, 0.770
2501902 0.800, 0.950 0.900, 0.980 0.950, 0.960 1.000, 0.870
2502000 2 2
2502001 0.000,-0.150 0.200, 0.020 0.400, 0.220 0.600, 0.460
2502002 0.800, 0.710 0.900, 0.810 0.950, 0.850 1.000, 0.870
2502100 2 3
2502101 -1.000, 0.620 -0.800, 0.680 -0.600, 0.530 -0.400, 0.460
2502102 -0.200, 0.490 0.000, 0.540
2502200 2 4
2502201 -1.000, 0.52 0.800, 0.530 -0.600, 0.460 -0.400, 0.420
2502202 -0.200, 0.390 0.000, 0.360
2502300 2 5
2502301 0.000,-0.630 0.200,-0.510 0.400,-0.390 0.600,-0.290
2502302 0.800,-0.200 0.900,-0.160 1.000,-0.130
2502400 2 6
2502401 0.000, 0.360 0.200, 0.320 0.400, 0.270 0.600, 0.180
2502402 0.800, 0.050 1.000,-0.130
2502500 2 7
2502501 -1.000,-1.440 -0.800,-1.250 -0.600,-1.080 -0.400,-0.920
2502502 -0.200,-0.770 0.000,-0.630
2502600 2 8
2502601 -1.000,-1.440 -0.800,-1.120 -0.500,-0.790 -0.400,-0.520
2502602 -0.200,-0.310 0.000,-0.150
* two phase head multiplier tables

```

*
 2503000 0
 2503001 0.000, 0.000 0.100, 0.000 0.150, 0.050 0.200, 0.000
 2503002 0.300, 0.950 0.400, 0.950 0.600, 0.570 0.800, 0.900
 2503003 0.900, 0.800 0.950, 0.500 1.000, 0.000
 2503100 0
 2503101 0.000, -0.170 .0001, -0.170 0.006, 0.000 0.100, 0.000
 2503102 0.150, 0.150 0.200, 0.550 0.800, 0.550 0.950, 0.450
 2503103 1.000, 0.000
 *
 * two phase head difference tables
 *
 2504100 1 1
 2504101 0.000, 0.000 0.100, 0.830 0.200, 1.090 0.500, 1.020
 2504102 0.700, 1.010 0.900, 0.940 1.000, 1.000
 2504200 1 2
 2504201 0.000, 0.000 0.100, -0.040 0.200, 0.000 0.300, 0.100
 2504202 0.400, 0.210 0.800, 0.570 0.900, 0.800 1.000, 1.000
 2504300 1 3
 2504301 -1.000, -1.160 -0.900, -1.240 -0.800, -1.770 -0.700, -2.360
 2504302 -0.600, -2.790 -0.500, -2.910 -0.400, -2.570 -0.250, -1.690
 2504303 -0.100, -0.500 0.000, 0.000
 2504400 1 4
 2504401 -1.000, -1.160 -0.900, -0.780 -0.800, -0.500 -0.700, -0.310
 2504402 -0.600, -0.170 -0.500, -0.080 -0.350, 0.000 -0.200, 0.050
 2504403 -0.100, 0.080 0.000, 0.110
 2504500 1 5
 2504501 0.000, 0.000 0.200, -0.034 0.400, -0.650 0.600, -0.930
 2504502 0.800, -1.190 1.000, -1.470
 2504600 1 6
 2504601 0.000, 0.110 0.100, 0.130 0.250, 0.150 0.400, 0.130
 2504602 0.500, 0.070 0.600, -0.040 0.700, -0.230 0.800, -0.510
 2504603 0.900, -0.910 1.000, -1.470
 2504700 1 7
 2504701 -1.000, 0.000 0.000, 0.000
 2504800 1 8
 2504801 -1.000, 0.000 0.000, 0.000
 *
 * two phase torque difference tables
 *
 2504900 2 1
 2504901 0.000, 0.540 0.200, 0.590 0.400, 0.650 0.600, 0.770
 2504902 0.800, 0.950 0.900, 0.980 0.950, 0.960 1.000, 0.870
 2505000 2 2
 2505001 0.000, -0.150 0.200, 0.020 0.400, 0.220 0.600, 0.460
 2505002 0.800, 0.710 0.900, 0.810 0.950, 0.850 1.000, 0.870
 2505100 2 3
 2505101 -1.000, 0.620 -0.800, 0.680 -0.600, 0.530 -0.400, 0.460
 2505102 -0.200, 0.490 0.000, 0.540
 2505200 2 4
 2505201 -1.000, 0.620 -0.800, 0.530 -0.600, 0.460 -0.400, 0.420
 2505202 -0.200, 0.390 0.000, 0.360
 2505300 2 5
 2505301 0.000, -0.630 0.200, -0.510 0.400, -0.390 0.600, -0.290
 2505302 0.800, -0.200 0.900, -0.160 1.000, -0.130
 2505400 2 6
 2505401 0.000, 0.360 0.200, 0.320 0.400, 0.270 0.600, 0.180
 2505402 0.800, 0.050 1.000, -0.130

2505500 2 7
 2505501 -1.000, -1.440 -0.800, -1.250 -0.600, -1.050 -0.400, -0.920
 2505502 -0.200, -0.770 0.000, -0.530
 2505600 2 8
 2505601 -1.000, -1.440 -0.800, -1.120 -0.600, -0.790 -0.400, -0.520
 2505602 -0.200, -0.310 0.000, -0.150

*
 * pump coast down table is general table 250
 * use control variables 250 and 251 to set pump speed.
 *
 * trip parameter
 2506100 420 ctrrlvar 251
 * table takes into account conversion of rad/sec to rev/min
 2506101 -1.0 20665.000
 2506102 0.0 0.000
 2506103 1.0 9.549
 2506104 100.0 954.930
 2506105 500.0 4774.297
 2506106 1000.0 959.297
 2506107 3000.0 28647.890
 *
 **** pressurizer spray line tee - time dependent junction ****
 * elev = 0.0 in.
 *
 * name type
 2500000 pzsptw tdpjtm
 *
 * from to jnt area
 2500101 251000000 230000000 .012
 *
 * ctl flg trip
 2500200 1 418
 *
 * time flow-f flow-g velj
 2500201 -1.0 0.0 0.0 0.0
 2500202 0.0 0.0 0.0 0.0
 2500203 2000.0 0.0 0.0 0.0
 *
 **** pressurizer spray line - time dependent volume ****
 * elev = 0.0 in.
 *
 * name type
 2500000 pzsptw tdpvol
 *
 * area length volume bz ang vr ang elv ch
 2500101 .012 10.00 0.0 0.0 0.0 0.0
 *
 * rough by dia ctl
 2500102 0.0 0.0 0 0
 *
 * ctl flg
 2500200 3

* inlet elev = outlet elev = 0.000 in.
 * time pressure temp
 2900201 0.0 12.3 80.0
 *
 * cold leg...pump outlet to ecc injection point tee
 *
 * ref drawings: 3pc-11a (sp-19) - 412544
 * 3pc-12 (sp-20) - 404759
 * 3pc-13 (sp-21) - 404794 or 3pc-1a - 407718
 * 3pc-19a (sp-22) - 414684-3
 *
 * inlet elev = outlet elev = 0.000 in.
 * name type
 2610000 c261 pipe
 *
 * no vol
 2610001 2
 *
 * area vol no
 2610101 .0375539 2 ± 3 in sch-160 (id = 2.624 in)
 *
 * length vol no
 2610301 2.076667 1 ± spool piece - 19,20
 2610302 2.076667 2 ± sp - 21 & to ecc tap in sp-22
 *
 * vr ang vol no
 2610601 0.0 2
 *
 * elv ch vol no
 2610701 0.0 2
 *
 * rough by dia vol no
 2610801 6.657e-5 0 2
 *
 * ctl flg vol no
 2611001 0 2
 *
 * vrabs jun no
 2611101 000 1
 *
 * ctl press temp zero zero air fig vol no
 2611201 3 2258.30 531.30 0.0 0.0 0 2
 *
 * ctl flg
 2611300 1
 *
 * flow-f flow-g velj ... jun no
 2611301 17.450 0.0 0.0 1
 *
 * ecc injection tee
 *
 * ref drawing: 3pc-19a (sp-22) - 414684-3

* inlet elev = outlet elev = 0.000 in.
 * name type
 2620000 c262 branch
 *
 * no jun ctl
 2620001 3 1
 *
 * area length volume bz ang vr ang elv ch
 2620101 .0375539 2.076667 0.0 202.5 0.0 0.0
 *
 * rough by dia ctl
 2620102 6.657e-5 0.0 0
 *
 * ctl press temp
 2620200 3 2258.30 531.30
 *
 * from to jun area f loss r loss vcahs
 2621101 261010000 262000000 .0375539 0.30 0.30 0
 2622101 262010000 263000000 .0375539 0.30 0.30 0
 2623101 400010000 262000000 .0049952 0.0 0.0 20121
 *
 * flow-f flow-g velj
 2621201 17.450 0.0 0.0
 2622201 17.450 0.0 0.0
 2623201 0.0 0.0 0.0
 *
 * ecc line
 *
 * inlet elev = outlet elev = 0.000 in.
 * name type
 4000000 ilercrpip pipe
 *
 * no vol
 4000001 1
 *
 * area vol no
 4000101 .0049952 1
 *
 * length vol no
 4000301 10.0 1
 *
 * vr ang vol no
 4000601 0.0 1
 *
 * elv ch vol no
 4000701 0.0 1
 *
 * rough by dia vol no
 4000801 6.657e-5 0.0 1
 *
 * ctl flg vol no
 4001001 0 1
 *
 * ctl press temp zero zero air fig vol no

400101 3 2253.30 531.30 0.0 0.0 0 1
 *
 * bpis - time dep junction
 *
 * elev = 0.0 in.
 *
 * name type
 410000 ilbpisj tdpnjm
 *
 * from to jum area
 4100101 42000000 40000000 .049952
 *
 * ctl flg trip table volume
 4100200 1 408 p 262010000
 *
 * pres(psia) flow-f flow-g velj
 4100201 -1.0 0.0000 0.0 0.0
 4100202 0.0 0.0000 0.0 0.0
 4100203 15.0 0.03219 0.0 0.0
 4100204 332.25 0.02545 0.0 0.0
 4100205 384.51 0.02434 0.0 0.0
 4100206 431.70 0.02509 0.0 0.0
 4100207 472.88 0.02400 0.0 0.0
 4100208 510.39 0.02338 0.0 0.0
 4100209 519.09 0.02371 0.0 0.0
 4100210 561.93 0.02375 0.0 0.0
 4100211 652.46 0.02531 0.0 0.0
 4100212 729.93 0.02516 0.0 0.0
 4100213 812.43 0.02329 0.0 0.0
 4100214 820.29 0.01873 0.0 0.0
 4100215 1123.65 0.01480 0.0 0.0
 4100216 1158.0 0.01418 0.0 0.0
 4100217 1258.0 0.01184 0.0 0.0
 4100218 1348.0 0.00968 0.0 0.0
 4100219 1407.0 0.00717 0.0 0.0
 4100220 1455.0 0.00460 0.0 0.0
 4100221 1560.0 0.00 0.0 0.0
 4100222 1600.0 0.00 0.0 0.0
 *
 * bpis time dependent volume
 *
 * inlet elev = outlet elev = 0.000 in.
 *
 * name type
 4200000 ilbpisv tdpvol
 *
 * area length volume bz ang vr ang elv ch
 4200101 10.0 10.0 0.0 0.0 0.0 0.0
 *
 * rough by dia ctl
 4200102 6.657e-5 0.0 0
 *
 * ctl flg
 4200200 3
 *
 * time pressure temp
 4200201 0.0 12.3 80.0
 *
 * accumulator
 *
 * inlet elev = bottom = 0.000 in.
 * outlet elev = top = + 43.066 in.
 *
 * name type
 4300000 ilacc accum
 *
 * area length volume bz ang vr ang elv ch
 4300101 0.7085 3.5888 0.0 0.0 90.0 3.5888
 *
 * rough by dia ctl
 4300102 6.657e-5 0.0 10
 *
 * pressure temp
 4300200 615.0 80.0
 *
 * to jum area f loss r loss vels
 4301101 40000000 .049952 17227.44 17227.44 000
 *
 * vliq liq lev lolen elev thick btr-flg takro takcp nlt-k
 4302200 1.582 0 30.0 0 .0574 0 0 0 0
 *
 * cold leg...ect injection point to downcomer inlet
 *
 * ref drawings: 407986 (downcomer cold leg nozzle)
 *
 * inlet elev = outlet elev = 0.000 in.
 *
 * name type
 2630000 c263 pipe
 *
 * do vol
 2630011 1
 *
 * area vol no
 2630101 .0396302 1 * 3 in sch-160 (id = 2.624 in)
 *
 * length vol no
 2630301 2.1535 1 * cold leg downcomer nozzle
 *
 * vr ang vol no
 2630601 0.0 1
 *
 * elv ch vol no
 2630701 0.0 1
 *
 * rough by dia vol no
 2630801 6.657e-5 0.0 1

*	ctl fig	vol no						
2631001	0	1						
*	ctl	press	temp	zero	zero	air fig	vol no	
2631201	3	2258.30	531.30	0.0	0.0	0	1	
*	*****	*****	*****	*****	*****	*****	*****	
*								
* reactor vessel								
* simulator								
* * *								
*****	*****	*****	*****	*****	*****	*****	*****	
* cold leg inlet annulus to downcomer tee								
*****	*****	*****	*****	*****	*****	*****	*****	
* ref drawings: assembly - 407986								
* inner liner - 407990								
* outer liner - 407991								
* * *								
* inlet elev = top = + 12.000 in.								
* outlet elev = bottom = - 12.000 in.								
* * *								
* name type								
1010000	coldtee	branch						
* * *								
* no junc	ctl							
1010001	4	1						
* * *								
* area length volume bz ang vr ang elv ch								
1010101	.1056970	2.0000	0.0	0.0	-90.0	-2.0000		
* * *								
* rough by dia	ctl							
1010102	6.667e-5	.142750	0					
* * *								
* ctl	press	temp						
1010200	3	2258.30	531.30					
* * *								
* from	to	junction	area	f loss	r loss	vcabs		
1011101	101000000	181000000	7.46674e-4	0.0	0.0	100		
1012101	101010000	110000000	0.026039	0.0	0.0	0		
1013101	263010000	101000000	0.045082	1.5	1.5	001		
1014101	353010000	101000000	0.045082	1.5	1.5	001		
* * *								
* flow-f	flow-g	relj						
1011201	0.5908	0.0	0.0					
1012201	22.900	0.0	0.0					
1013201	17.450	0.0	0.0					
1014201	5.840	0.0	0.0					
* * *								
* * *								
* downcomer								
*****	*****	*****	*****	*****	*****	*****	*****	
* inlet elev = top = - 12.000 in.								
* outlet elev = bottom = -214.770 in.								
* * *								
* name type								
1100000	dcomer	pipe						

no vol

1100001	10							
* * *								
* area	vol no							
1100101	0.030975	1	* includes reducing section of annulus					
1100102	0.026039	8	* downcomer pipe					
1100103	0.031502	9	* slanted pipe + entrance half annulus					
1100104	0.0762104	10	* distribution annulus					
* * *								
* length	vol no							
1100301	2.260833	1						
1100302	1.000833	2						
1100303	2.000000	7						
1100304	1.465567	8						
1100305	1.434751	9						
1100306	0.962500	10						
* * *								
* vr ang	vol no							
1100601	-90.0	8						
1100602	-55.75	9						
1100603	-90.0	10						
* * *								
* elv ch	vol no							
1100701	-2.260833	1						
1100702	-1.000833	2						
1100703	-2.000000	7						
1100704	-1.465567	8						
1100705	-1.207667	9						
1100706	-0.962500	10						
* * *								
* rough	by dia	vol no						
1100801	6.667e-5	0.193535	1					
1100802	6.667e-5	0.0	9					
1100803	6.667e-5	0.111833	10					
* * *								
* f loss	r loss	junc no						
1100901	0.0	0.0	6					
1100902	1.35	1.35	7 * mass flow measurement station					
1100903	0.0	0.0	8					
1100904	0.0	0.0	9					
* * *								
* ctl fig	vol no							
1101001	0	10						
* * *								
* vcabs	junc no							
1101101	0	9						
* * *								
* ctl	press	temp	zero	zero	air fig	vol no		
1101201	3	2258.30	531.30	0.0	0.0	0	1	
1101202	3	2258.30	531.30	0.0	0.0	0	2	
1101203	3	2258.30	531.30	0.0	0.0	0	3	
1101204	3	2258.30	531.30	0.0	0.0	0	4	
1101205	3	2258.30	531.30	0.0	0.0	0	5	
1101206	3	2258.30	531.30	0.0	0.0	0	6	
1101207	3	2258.30	531.30	0.0	0.0	0	7	
1101208	3	2258.30	531.30	0.0	0.0	0	8	
1101209	3	2258.30	531.30	0.0	0.0	0	9	

1101210 3 2253.30 531.30 0.0 0.0 0 10
 *
 * ctl flg
 1101300 1
 *
 * flow-f flow-g velj jun no
 1101301 22.900 0.0 0.0 9
 *
 * lower plenum
 *
 * inlet elev = top = -214.770 in.
 * outlet elev = bottom = -223.433 in.
 *
 * name type
 1300000 lo-plen branch
 *
 * no jun ctl
 1300001 3 1
 *
 * area length volume bz ang vr ang elv ch
 1300101 0.322478 0.721917 0.0 0.0 -90.0 -0.721917
 *
 * rough by dia ctl
 1300102 6.667e-5 0.229414 0
 *
 * ctl press temp
 1300200 3 2253.30 531.30
 *
 * from to jun area f loss r loss vcahs
 1301101 110010000 130000000 0.0762104 1.0 1.0 100
 1302101 130000000 140000000 0.075189 0.0 0.0 100
 1303101 130010000 120000000 0.32478 0.0 0.0 000
 *
 * flow-f flow-g velj
 1301201 22.900 0.0 0.0
 1302201 22.900 0.0 0.0
 1303201 0.0 0.0 0.0
 *
 1302110 0.229414 1.0 1.0 1.0
 1303110 0.229414 1.0 1.0 1.0
 *
 * lower plenum lower volume
 *
 * inlet elev = top = -223.433 in.
 * outlet elev = bottom = -229.033 in.
 *
 * name type
 1200000 lplvol saglvol
 *
 * area length volume bz ang vr ang elv ch
 1200101 0.518279 0.466657 0.0 0.0 -90.0 -0.466657
 *
 * rough by dia ctl
 1200102 6.667e-5 0.381247 0

*
 * ctl press temp zero
 1200200 3 2253.30 531.30 0.0
 *
 * core inlet
 *
 * inlet elev = bottom = -214.770 in.
 * outlet elev = top = -195.140 in.
 *
 * name type
 1400000 core-in saglvol
 *
 * area length volume bz ang vr ang elv ch
 1400101 0.075189 1.635333 0.0 0.0 90.0 1.635333
 *
 * rough by dia ctl
 1400102 6.667e-5 0.278329 0
 *
 * ctl press temp zero
 1400200 3 2253.30 531.30 0.0
 *
 * core inlet junction
 *
 * elev = -195.140 in.
 *
 * name type
 1450000 corein-j sagljum
 *
 * from to jun area f loss r loss vcahs
 1450101 140010000 150000000 0.026780 0.2 0.1 0
 *
 * ctl flow-f flow-g velj
 1450201 1 22.900 0.0 0.0
 *
 * average channel
 *
 * inlet elev = bottom = -195.140 in.
 * outlet elev = top = -51.140 in.
 *
 * name type
 1500000 a-chanl pipe
 *
 * no vol
 1500001 6
 *
 * area vol no
 1500101 0.030376 6
 *
 * area jun no
 1500201 0.026780 5

* length vol no
 1500301 2.0 6
 * vr ang vol no
 1500601 90.0 6
 * elv ch vol no
 1500701 2.0 6
 * rough by dia vol no
 1500801 6.667e-5 0.032836 6
 * f loss r loss jun no
 1500901 0.10 0.10 5
 *
 * ctl flg vol no
 1501001 0 6
 * vcahs jun no
 * kkt
 1501101 00100 5
 * inlet elev = bottom = - 39.130 in.
 * outlet elev = top = - 6.000 in.
 * core outlet
 *
 * inlet elev = bottom = - 51.140 in.
 * outlet elev = top = - 39.130 in.
 * upper core
 *
 * inlet elev = bottom = - 6.000 in.
 * outlet elev = top = + 23.000 in.
 *
 * name type
 1520000 coreout branch
 *
 * no jun ctl
 1520001 1 1
 *
 * area length volume kz ang vr ang elv ch
 1520101 0.045640 2.760833 0.0 0.0 90.0 2.760833
 *
 * rough by dia ctl
 1520102 6.667e-5 0.120892 0
 *
 * ctl press temp
 1520200 3 2258.30 591.90
 *
 * from to jun area f loss r loss vcahs
 1521101 150010000 151000000 0.025780 0.8 0.8 000
 1521201 151010000 152000000 0.017208 0.0 0.0 100
 1521301 152010000 151010000 0.0016085 0.0 0.0 100
 1521401 156010000 151010000 0.004606 .43613 .43613 100
 *
 * flow-f flow-g velj
 1521201 22.900 0.0 0.0
 1521201 21.000 0.0 0.0
 1521301 0.0 0.0 0.0
 1521401 -1.900 0.0 0.0
 *kkt
 1521100 0.07651 1.0 1.0 1.0
 1521100 0.07651 1.0 1.0 1.0
 *
 * core outlet
 *
 * inlet elev = bottom = - 39.130 in.
 * outlet elev = top = - 6.000 in.
 *
 * name type
 1530000 hotout branch
 *
 * no jun ctl
 1530001 1 1
 *
 * area length volume kz ang vr ang elv ch
 1510101 0.057859 1.000833 0.0 0.0 90.0 1.000833
 *
 * rough by dia ctl
 1510102 6.667e-5 0.07561 0
 *
 * ctl press temp

163001 4 1
 *
 * area length volume bz ang vr ang elv ch
 1630101 0.050621 2.416667 0.0 0.0 90.0 2.416667
 *
 * rough by dia ctl
 1630102 6.667e-5 0.143638 0
 *
 * ctl press temp
 1630200 3 2258.30 532.30
 *
 * from to jum area f loss r loss vcahs
 1631101 16300000 20100000 0.045082 2.5 2.5 002
 1632101 16300000 30100000 0.045082 2.5 2.5 002
 1633101 16301000 16300000 0.037533 3.0 3.0 000
 1634101 16301000 16400000 0.056700 0.0 0.0 000
 *
 * flow-f flow-g velj
 1631201 17.450 0.0 0.0
 1632201 5.840 0.0 0.0
 1633201 21.500 0.0 0.0
 1634201 -2.360 0.0 0.0
 *
 * inlet elev = bottom = + 23.000 in.
 * outlet elev = top = + 53.600 in.
 *
 * name type
 1640000 upplea smglvol
 *
 * area length volume bz ang vr ang elv ch
 1640101 0.056700 2.5500 0.0 0.0 90.0 2.5500
 *
 * rough by dia ctl
 1640102 6.667e-5 0.168707 0
 *
 * ctl press temp zero
 1640200 3 2258.30 538.00 0.0
 *
 * upper head top volume
 * geometry with shi *
 * inlet elev = top = +166.760 in. * tube removed *
 * outlet elev = bottom = +132.190 in. *****
 *
 * name type
 1930000 uppley branch
 *
 * no jum ctl
 1940001 2 1
 *
 * area length volume bz ang vr ang elv ch
 1940101 0.061655 2.880833 0.0 0.0 -90.0 -2.880833
 *
 * rough by dia ctl
 1940102 6.667e-5 0.280250 0
 *
 * ctl press temp
 1940200 3 2258.30 531.30
 *
 * from to jum area f loss r loss vcahs
 1941101 194010000 163000000 2.19233e-3 0.0 0.0 100
 1942101 194010000 163000000 0.053694 0.0 0.0 000
 *
 * flow-f flow-g velj
 1941201 0.5908 0.0 0.0
 1942201 -0.5908 0.0 0.0
 *
 * upper head - top mid volume
 *
 * geometry with shi *
 * inlet elev = top = +132.190 in. * tube removed *
 * outlet elev = bottom = + 90.750 in. *****
 *
 * name type
 1930000 tumpid branch
 *
 * no jum ctl
 1930001 2 1
 *
 * area length volume bz ang vr ang elv ch
 1930101 0.053694 3.453333 0.0 0.0 -90.0 -3.453333
 *
 * rough by dia ctl
 1930102 6.667e-5 0.206333 0
 *
 * ctl press temp
 1930200 3 2258.30 531.30
 *
 * from to jum area f loss r loss vcahs
 1931101 193010000 192000000 0.052300 0.0 0.0 000
 1932101 193010000 193010000 7.46674e-4 0.0 0.0 100
 *
 * flow-f flow-g velj
 1931201 0.0 0.0 0.0
 1932201 0.5908 0.0 0.0
 *
 * upper head middle volume
 *
 * geometry with shi *
 * inlet elev = top = + 90.750 in. * tube removed *
 * outlet elev = bottom = + 67.160 in. *****
 *
 * name type
 1920000 lo-plea branch
 *
 * no jum ctl

1920001 2 1
 * outlet elev = top = + 90.750 in.
 *
 * area length volume bz ang vr ang elv ch
 1920101 0.052330 1.955373 0.0 0.0 -90.0 -1.955333
 *
 * rough by dia ctl
 1920102 6.667e-5 0.178630 0
 *
 * ctl press temp
 1920200 3 2258.30 532.30
 *
 * from to jun area f loss r loss vcahs
 1921101 192010000 191000000 0.049603 0.0 0.0 000
 1922101 192010000 192000000 0.0015085 5000.0 5000.0 000
 *
 * flow-f flow-g velj
 1921201 0.0 0.0 0.0
 1922201 0.0 0.0 0.0
 *
 * upperhead lower volume
 *
 * inlet elev = top = + 67.160 in.
 * outlet elev = bottom = + 61.440 in.
 *
 * name type
 1910000 updown pipe
 *
 * no vol
 1910001 1
 *
 * area vol no
 1910101 0.049603 1
 *
 * length vol no
 1910301 0.476667 1
 *
 * vr ang vol no
 1910601 -90.0 1
 *
 * elv ch vol no
 1910701 -0.476667 1
 *
 * rough by dia vol no
 1910801 6.667e-5 0.138401 1
 *
 * ctl flg vol no
 1911001 0 1
 *
 * ctl press temp zero zero air flg vol no
 1911201 3 2258.30 532.30 0.0 0.0 0 1
 *
 * core support column(s) - both modeled as single flow path
 *
 * inlet elev = top = + 67.160 in.
 * outlet elev = bottom = - 39.130 in.
 *
 * name type

1820000 septub pipe
 *
 * no vol
 1820001 1
 *
 * area vol no
 1820101 0.0016085 1
 *
 * length vol no
 1820301 8.85750 1
 *
 * vr ang vol no
 1820601 -90.0 1
 *
 * elv ch vol no
 1820701 -8.85750 1
 *
 * rough by dia vol no
 1820801 5.000e-6 0 1
 *
 * ctl flg vol no
 1821001 0 1
 *
 * ctl press temp zero zero air flg vol no
 1821201 3 2258.30 592.30 0.0 0.0 0 1
 *
 * control rod guide tube (top)
 ----------*-----*-----*-----*-----*-----*-----*-----*
 * inlet elev = top = +132.190 in.
 * outlet elev = bottom = +84.200 in.
 *
 * name type
 1830000 guitmbl pipe
 *
 * no vol
 1830001 1
 *
 * area vol no
 1830101 2.1923e-3 1
 *
 * length vol no
 1830301 3.999157 1
 *
 * vr ang vol no
 1830601 -90.0 1
 *
 * elv ch vol no
 1830701 -3.999157 1
 *
 * rough by dia vol no
 1830801 5.000e-5 0.0 1
 *
 * ctl flg vol no
 1831001 0 1
 *
 * ctl press temp zero zero air flg vol no
 1831201 3 2258.30 592.30 0.0 0.0 0 1
 *
 ----------*-----*-----*-----*-----*-----*-----*-----*
 * cross-flow volume in guide tube through drill holes to upper plenum *
 ----------*-----*-----*-----*-----*-----*-----*-----*
 *
 * inlet elev = top = +84.200 in.
 * outlet elev = bottom = +23.000 in.
 *
 * name type
 1840000 guitmbl2 branch
 *
 * no junc ctrl
 1840001 3 1
 *
 * area length volume bz ang vr ang elv ch
 1840101 2.1923e-3 5.1000 0.0 0.0 -90.0 -5.1000
 *
 * rough by dia ctrl
 1840102 5.000e-6 0.0 0
 *
 * ctrl press temp
 1840200 3 2258.30 600.00
 *
 * from to junc area f loss r loss vcds
 1841101 183010000 184000000 2.1923e-3 0.0 0.0 0
 1842101 184010000 185000000 2.1923e-3 0.0 0.0 0
 1843101 184000000 184010000 4.26106e-3 5000.0 0.0 2
 * 8 - 5/16 in. diameter holes connect guide tube to upper plenum (164)
 ----------*-----*-----*-----*-----*-----*-----*-----*
 * flow-f flow-g relj
 1841201 2.3600 0.0 0.0
 1842201 2.3600 0.0 0.0
 1843201 -1.4000 0.0 0.0
 ----------*-----*-----*-----*-----*-----*-----*-----*
 * middle part of guide tube
 ----------*-----*-----*-----*-----*-----*-----*-----*
 *
 * inlet elev = top = +23.000 in.
 * outlet elev = bottom = - 6.000 in.
 *
 * name type
 1850000 guitmbl3 pipe
 *
 * no vol
 1850001 1
 *
 * area vol no
 1850101 2.1923e-3 1
 *
 * length vol no
 1850301 2.41667 1
 *
 * vr ang vol no
 1850601 -90.0 1
 *
 * elv ch vol no

1850701	-2.416607	1										
*	rough	by dia	vol no									
1850801	5.000e-6	0.0	1	301000	bl-bl	type						
*	ctl flg	vol no										
1851001	0	1		301001	no vol							
*	area	vol no										
1851201	ctl	press	temp	zero	zero	air flg	vol no	3010101	0.0268943	1 * 3 in. sch-160		
3	2258.30	591.90	0.0	0.0	0	0	1	3010102	0.0097643	6 * 1.5 in sch-160		
*	length	vol no										
*	lower part of guide tube (slotted section)			3010301	2.1725000	1 * hot leg nozzle						
*****	*****	*****	*****	3010302	2.2101267	3 * spool piece - 50						
*	ref drawing: 408010			3010303	2.725243	4 * sp-55						
*	inlet elev = top = - 6.000 in.			3010304	2.3580833	5 * sp-56, 57, 58 & 90 bend of 55						
*	outlet elev = bottom = - 39.130 in.			3010305	1.9753140	6 * sp-59, and inlet plenum						
*	name	type										
1860000	gnislot	branch										
*	no jun	ctl										
1860001	1	1										
*	area	length	volume	hz ang	vr ang	elv ch						
1860101	0.010809	2.760833	0.0	0.0	-90.0	-2.760833						
*	rough	by dia	ctl									
1860102	5.000e-6	0.120415	0									
*	ctl	press	temp									
1860200	3	2258.30	591.90									
*	from	to	jum area	f loss	r loss	recahs						
1861101	185010000	186000000	2.19233e-3	.49613	.49613	100						
*	flow-f	flow-g	velj									
1861201	-1.4000	0.0	0.0									
*	broken											
*	loop											
*****	*****	*****	*****									
*	hot leg											
*****	*****	*****	*****									
*	ref drawing: hot leg nozzle	- 407975										
*	1.5abl-1 (sp-50) - 414670											
*	1.5abl-14a (sp-55) - 414670											
*	1.5abl-30 (sp-55) - 414671											
*	1.5abl-31 (sp-57) - 414672											
*	1.5abl-32 (sp-58) - 414673											
*	1.5abl-33 (sp-59) - 414674											
*	inlet plenum - 414272											
*	inlet elev = + 8.500 in.											
*	outlet elev = + 71.969 in.											
*	ctl flg											

3011300 1
 * flow-f flow-g relj jnt no
 3011301 5.840 0.0 0.0 5
 *kt
 3011401 0.0 0.0 0.55 0.785 5
 *

 * steam generator inlet *

 * ref drawing: 414272 sh.2
 *
 * elev = +71.969 in.
 *
 * name type
 3050000 j305 sngljm
 *
 * from to jnt area f loss r loss vcahs
 3050101 301010000 310000000 0.0097633 0.0 0.0 000
 *
 * ctl flow-f flow-g relj
 3050201 1 5.840 0.0 0.0
 *

 * steam generator inlet plenum *

 *
 * reference - type-ii (broken loop) steam generator part-leg dryg,
 * and plenum drwg. 414272 (1,2)
 * note - inlet plenum entrance is circular (dia=1.388 in),
 * plenum tapers outward, nonuniformly, with rise to
 * tube sheet inlet (inlet plenum outlet).
 * outlet is rectangular with radiused corners.
 *
 * inlet elev = +71.969 in.
 * outlet elev = +81.594 in.
 *
 * name type
 3100000 blsgip smgvol
 *
 * area length volume bz ang vr ang elv ch
 3100101 0.0 0.8020833 0.495847 0.0 90.0 0.8020833
 *
 * rough by dia ctl
 3100102 6.667e-5 0.2600218 0
 *
 * ctl press temp zero
 3100200 3 2258.30 592.30 0.0
 *

 * broken loop steam generator tube sheet *

 * ref drawing: 418972
 *
 * inlet elev = +81.594 in. (bottom of tube sheet)
 * outlet elev = +102.604 in. (top of tube sheet)

*
 * name type
 3150000 blts-in branch
 *
 * bo jnt ctl
 3150001 2 1
 *
 * area length volume bz ang vr ang elv ch
 3150101 0.0060544 1.751830 0.0 0.0 88.07 1.7508333
 *
 * rough by dia ctl
 3150102 5.000e-6 .0620833 0
 *
 * ctl press temp zero
 3150200 3 2250.00 548.00
 *
 * from to jnt area f loss r loss vcahs
 3151101 310010000 315000000 0.0060544 0.0 0.0 100
 3152101 315010000 320000000 0.0060544 0.0 0.0 000
 *
 * flow-f flow-g relj
 3151201 7.310 0.0 0.0
 3152201 7.310 0.0 0.0
 *kt
 3170000 blsgin sngljm
 3170101 315010000 320000000 6.0544e-3 0.0 0.0 100100
 3170110 0.0 0.0 0.725 1.0
 3170201 0 0.855 0.855 0.0
 *

 * steam generator tube bundle *

 *
 * ref drawings: 418977 & 418980
 *
 * inlet elev = outlet elev = +102.604 in. (top of tube sheet)
 *
 * elev long tube = 391.00 in. above top of tube sheet
 * elev short tube = 336.00 in. above top of tube sheet
 *
 * elev model tube = 333.50 in. above top of tube sheet
 *
 * name type
 3200000 bsgrtb pipe
 *
 * bo vol
 3200001 8
 *
 * area vol no
 3200101 6.0544e-3 8
 *
 * length vol no
 3200301 7.7916667 1 * volumes 2 & 3, 6 & 7 have lengths
 3200302 7.5000000 3 * and elevations equal to their corres-
 3200303 7.542897 5 * pending secondary side volumes.
 3200304 7.5000000 7 * volumes 4 & 5 are each half of the
 3200305 7.7916667 8 * 180 degree bend.

* bz arg vol no
 3200501 -90.0 8
 * vr ang vol no
 3200601 +90.0 4
 3200602 -90.0 8
 * elv ch vol no
 3200701 +7.7916657 1
 3200702 +7.500000 3
 3200703 +7.500000 4
 3200704 -7.500000 5
 3200705 -7.500000 7
 3200706 -7.7916657 8
 * rough by dia vol no
 3200801 5.000e-6 .0620833 8
 * f loss r loss jun no
 3200901 0.34 0.34 7
 * ctl flg vol no
 3201001 0 8
 * ctl flg jun no
 3201101 0 7
 * ctl press temp zero zero air flg vol no
 3201201 3 2250.00 588.00 0.0 0.0 0 4
 3201202 3 2250.00 588.00 0.0 0.0 0 8
 * abs jun no
 7001101 100 3 * baffle plates
 7001102 100 4 * 180 deg return
 * flow-f flow-g velj jun no
 3201301 7.310 0.0 0.0 7
 * steam generator secondary volume
 * ref drawings: assembly - ##### baffle plates - #####
 separator - #####
 * inlet elev = 13.000 in. above top of tube sheet
 * outlet elev = 445.375 in. above top of tube sheet
 * name type
 7000000 bsgsec pipe
 * no vol
 7000001 5
 * area vol no
 7000101 0.0 5
 * area jun no
 7000201 0.0242368 3 * baffle plates
 7000202 0.0203199 4 * 180 deg return - top of short tube
 * length vol no
 7000301 6.7083333 1
 7000302 7.500000 4
 7000303 6.8229167 5
 * volume vol no
 7000401 0.2213819 1
 7000402 0.2476839 2
 7000403 0.2461911 3
 7000404 0.2649890 4
 7000405 0.3268035 5
 * vr ang vol no
 7000601 +90.0 5
 * elv ch vol no
 7000701 6.7063333 1
 7000702 7.500000 4
 7000703 6.8229167 5
 * rough by dia vol no
 7000802 6.657e-5 0.0638945 3
 7000803 6.657e-5 0.073070 4
 7000804 6.657e-5 0.1934227 5
 * ctl fig vol no
 7001001 0 5
 * abs jun no
 7001101 100 3 * baffle plates
 7001102 100 4 * 180 deg return
 * ctl press qmals zero zero air flg vol no
 7001201 2 876.000 0.00880 0.0 0.0 0 5
 * ctl fig
 7001300 0
 * vel-f vel-g velj jun no
 7001301 2.4000 3.4000 0.0 1
 7001302 3.5000 4.8000 0.0 2
 7001303 4.0000 6.4000 0.0 3
 7001304 3.4000 7.6000 0.0 4
 * kit
 7001401 0.0 1.0 1.0 1.0 3
 7001402 0.0 1.0 1.0 1.0 4
 * broken loop steam generator secondary riser (top) (swirl vane)
 * ref drawing: #####
 * inlet elev = 445.375 in. above top of tube sheet
 * outlet elev = 451.375 in. above top of tube sheet

* name type
 701000 swirl branch
 *
 * no jun cfl
 701001 2 0
 *
 * area length volume bz ang vr ang elv ch
 7010101 0.0 1.333333 .5794734 0.0 90.0 1.333333
 *
 * rough by dia cfl
 7010102 6.667e-5 .6944443 0
 *
 * cfl press quals zero
 7010200 2 876.000 1.00
 *
 * from to jun area f loss r loss voids
 7011101 700010000 701000000 .0453634 50.0 50.0 100
 7012101 701000000 711000000 .0215061 1.5 1.5 00000
 *
 * vel-f vel-g velj
 7011201 0.3500 0.3500 0.0
 7012201 0.0 0.0 0.0

* broken loop steam generator preliminary separator *

* ref drawing: #####
*
* inlet elev = 461.375 in. above top of tube sheet
* outlet elev = 465.875 in. above top of tube sheet
*
* name type
7030000 blsgsp branch
*
* no jun cfl
703001 1 0
*
* area length volume bz ang vr ang elv ch
7030101 0.0 0.375 .1534235 0.0 90.0 0.375
*
* rough by dia cfl
7030102 6.667e-5 .2429779 0
*
* cfl press quals zero
7030200 2 876.000 1.00
*
* from to jun area f loss r loss voids
7031101 701010000 703000000 .3477297 0.0 0.0 100
*
* vel-f vel-g velj
7031201 0.3500 0.3500 0.0

* broken loop steam generator secondary separator *

* ref drawing: #####
*
* inlet elev = 465.875 in. above top of tube sheet
* outlet elev = 461.500 in. above top of tube sheet

```

*          name   type
7110600 bsgaf pipe
*
*          no vol
7110001    1
*
*          area   vol no
7110101    0.0    1
*
*          length vol no
7110301 5.5088494    1
*
*          volume vol no
7110401 0.6232431    1
*
*          vr ang vol no
7110601 -30.0    1
*
*          elv ch vol no
7110701 -2.8229167    1
*
*          rough by dia vol no
7110801 6.657e-5 .3983363    1
*
*          ctl flg vol no
7111001    0    1
*
*          ctl press quals zero zero air flg vol no
7111201 2 876.000    0.0    0.0    0.0    0    1
*****
* broken loop steam generator secondary downcomer (top - horizontal)
*****
* ref drawing: #####
* inlet elev = 411.500 in. above top of tube sheet
* outlet elev = 411.500 in. above top of tube sheet
*
*          name   type
7130000 bsgm branch
*
*          no jun   ctl
7130001    3    0
*
*          area   length volume bz ang vr ang elv ch
7130101    0.0    3.146339 .0366917    0.0    0.0    0.0
*
*          rough by dia   ctl
7130102 6.657e-5 .1315182    0
*
*          ctl press quals zero
7130200 2 876.000    1.00
*
*          from   to jun area f loss r loss recls
7131101 711010000 71300000 .0120117    3.5    3.5    000
7132101 712010000 71300000 .0080362    50.0    50.0    000
7133101 713010000 71400000 .0103869    0.0    0.0    0
*
*          vel-f   vel-g   velj
7131201    0.3500    0.3300    0.0
7132201    0.0      0.0      0.0
7133201    0.3500    0.3300    0.0
*
*          broke loop steam generator secondary downcomer
*****
* ref drawing: assembly - #####
*           fillers - #####
*
*          inlet elev = 411.500 in. above top of tube sheet
*          outlet elev = 411.500 in. above top of tube sheet
*
*          name   type
7140000 bsgmc pipe

```

```

*      no vol
714001    5
*
*      area   vol no
7140101 .0103869    5
*
*      area   jun no
7140201 .0103869    4
*
*      length  vol no
7140301 4.0891869    1
7140302 7.5000010    4
7140303 7.3391869    5
*
*7140401 0.0415476    1
*7140402 0.0779017    4
*7140403 0.0753050    5
*
*      vr ang  vol no
7140501 -90.0    5
*
*      elev ch  vol no
7140701 -4.0000    1
7140702 -7.5000    4
7140703 -7.2500    5
*
*      rough by dia  vol no
7140801 6.667e-5  0.115    5
*
*      ctl flg  vol no
7141001    0    5
*
*      abs   jun no
7141101    0    4
*
*      ctl press  qmals  zero  zero  air flg  vol no
7141201 2 876.000  0.0    0.0    0.0    0    5
*
*      ctl flg
7141300    0
*
*      vel-f   vel-g   velj   jun no
7141301 6.9000  6.5900  0.0    4
*
*      broken loop steam generator secondary downcomer (bottom - horizontal)
*      ref drawing: #####
*      inlet elev = 6.500 in. above top of tube sheet
*      outlet elev = 6.500 in. above top of tube sheet
*
*      name   type
7150000  bsgimb  branch
*
*      no jun   ctl

```

	7150001	3	0			
*	area	length	volume	hz ang	vr ang	elv ch
7150101	0.0	7.8734167	.0972271	0.0	0.0	0.0
*	rough	by dia	ctl			
7150102	6.667e-5	.1302273	0			
*	ctl	press	qmals	zero		
7150200	2	876.000	0.00			
*	from	to	jun area	f loss	r loss	vcabs
7151101	714010000	715000009	.0103869	0.0	0.0	000
7152101	715010000	715000000	.0513379	50.0	50.0	00001
7153101	715000000	720010000	.0103869	0.0	0.0	20002
*	vel-f	vel-g	velj			
7151201	0.3500	0.3300	0.0			
7152201	0.3500	0.3300	0.0			
7153201	0.0	0.0	0.0			
*****	*****	*****	*****	*****	*****	*****
* broken loop steam generator riser bottom volume below feedwater inlet						
*****	*****	*****	*****	*****	*****	*****
*	ref drawing: #####					
*	inlet elev = 0.000 in. above top of tube sheet					
*	outlet elev = 13.000 in. above top of tube sheet					
*	name	type				
7160000	bsgimb	branch				
*	no jun	ctl				
7160001	1	0				
*	area	length	volume	hz ang	vr ang	elv ch
7160101	0.0	1.083333	.0344994	0.0	90.0	1.083333
*	rough	by dia	ctl			
7160102	6.667e-5	.0633945	0			
*	ctl	press	qmals	zero		
7160200	2	876.000	0.00			
*	from	to	jun area	f loss	r loss	vcabs
7161101	716010000	700000000	.0242668	0.0	0.0	100
*	vel-f	vel-g	velj			
7161201	0.3500	0.3300	0.0			
*****	*****	*****	*****	*****	*****	*****
* broken loop steam generator bottom feedwater pipe						
*****	*****	*****	*****	*****	*****	*****
*	ref drawing: assembly - #####					
*	inlet elev = -3.500 in. above top of tube sheet					

* outlet elev = 6.500 in. above top of tube sheet
 *
 * name type
 720000 bsgfed pipe
 *
 * no vol
 720001 1
 *
 * area vol no
 7200101 .0103869 1
 *
 * length vol no
 7200301 .8333333 1
 *
 * vr ang vol no
 7200601 90.0 1
 *
 * elv ch vol no
 7200701 .8333333 1
 *
 * rough by dia vol no
 7200801 6.67e-5 0.115 1
 *
 * ctl flg vol no
 7201001 0 1
 *
 * ctl press quals zero zero air flg vol no
 7201201 2 876,000 0.0 0.0 0 0 1
 *
 * steam generator secondary - main feedwater junction
 *
 * elev = 411.5 in. above top of tube sheet - top feed (to 726)
 * elev = 6.5 in. above top of tube sheet - bottom feed (to 720)
 *
 * name type
 7220000 bsgfvj bdpjm
 *
 * from to jum area
 7220101 72000000 72000000 0.004 * bot feed
 *
 * ctl flg trip
 7220200 1 415
 *
 * time flow-f flow-g relj
 7220201 -1.0 0.56119 0.0 0.0
 7220202 0.0 0.56119 0.0 0.0
 7220203 24.0 0.56119 0.0 0.0
 7220204 25.0 0.0 0.0 0.0
 *
 * for steady state - input for keeping steam generator mass constant,
 * put in what goes out steam valve - (comment out cards 71002xx above)
 *
 7220200 1 420 ctrlvar 710
 * table takes into account conversion of kg to lb
 7220201 -10.0 0.0 0.0 0.0
 7220201 -10.0 -22.046 0.0 0.0
 *
 * 720000 bsgfiv bdpvol
 *
 * area length volume bz ang vr ang elv ch
 7240101 10.00 10.00 0.0 0.0 0.0 0.0
 *
 * rough by dia ctl
 7240102 0.0 0.0 0
 *
 * ctl flg
 7240200 3
 *
 * time pressure temp
 7240201 0.0 1250.0 405.0 *ejl
 *
 * break valve
 *
 * top feedline break connects from 727 inlet
 * bottom feedline break connects from 720 inlet
 *
 *
 * name type
 725000 brk-vlv valve
 *
 * from to jum area f loss r loss vrels
 7250101 72000000 79000000 0.0097643 0.0 0.0 000
 *
 * cd1 cd2
 7250102 0.90 0.30
 *
 * ctl flow-f flow-g velj
 7250201 1 0.0 0.0 0.0
 *
 * vlv type
 7250300 trpvlv
 *
 * trip
 7250301 402
 *
 * containment
 *
 * elev = 0.000 in.
 *
 *
 * name type
 790000 feedctr bdpvol

**
 ** area length volume bz ang vr ang elv ch
 7900101 10.0 10.0 0.0 0.0 0.0 0.0
 **
 ** rough by dia ctl
 7900102 0.0 0.0 0
 **
 ** ctl flg
 7900200 2
 ** time pressure scale
 7900201 0.0 12.3 1.0
 **
 * broken loop steam generator top feedwater pipe
 *
 * ref drawing: \$\$\$\$\$\$
 *
 * inlet elev = 411.500 in. above top of tube sheet
 * outlet elev = 411.500 in. above top of tube sheet
 *
 * name type
 7260000 bsgfjd branch
 *
 * no jem ctl
 7260001 2 0
 *
 * area length volume bz ang vr ang elv ch
 7260101 .0103869 2.0 0.0 0.0 0.0 0.0
 *
 * rough by dia ctl
 7260102 6.667e-5 0.115 0
 *
 * ctl press quals zero
 7260200 2 876.000 0.00
 *
 * from to jem area f loss r loss reabs
 7261101 726010000 714000000 .0103869 0.0 0.0 000
 7262101 726000000 727010000 .0103869 0.0 0.0 20002
 *
 * vel-f vel-g velj
 7261201 0.0 0.0 0.0
 7262201 0.0 0.0 0.0
 *
 * broken loop steam generator top feedwater break pipe
 *
 * ref drawing: assembly - \$\$\$\$\$\$
 *
 * inlet elev = 411.500 in. above top of tube sheet
 * outlet elev = 401.500 in. above top of tube sheet
 *
 * name type
 7270000 bsgfbk pipe
 *
 * no vol
 *
 7270001 1
 *
 * area vol no
 7270101 0.0103869 1
 *
 * length vol no
 7270301 0.8333333 1
 *
 * vr ang vol no
 7270601 +90.0 1
 *
 * elv ch vol no
 7270701 +0.8333333 1
 *
 * rough by dia vol no
 7270801 6.667e-5 0.115 1
 *
 * ctl flg vol no
 7271001 0 1
 *
 * ctl press quals zero zero air flg vol no
 7271201 2 876.000 0.0 0.0 0.0 0 1
 *
 * steam generator secondary - auxiliary feedwater junction
 *
 * elev = 411.500 in. above top of tube sheet
 *
 * name type
 7280000 bsgafvj bdpjvm
 *
 * from to jem area
 7280101 729000000 726000000 .004
 *
 * ctl flg trip
 7280200 1 417
 *
 * time flow-f flow-g velj
 7280201 -1.0 0.0 0.0 0.0
 7280202 0.0 0.0 0.0 0.0
 7280206 2000.0 0.0 0.0 0.0
 *
 * steam generator secondary - auxiliary feedwater volume
 *
 * elev = 411.500 in. above top of tube sheet
 *
 * name type
 7290000 bsgafvr bdpvol
 *
 * area length volume bz ang vr ang elv ch
 7290101 10.00 10.00 0.0 0.0 0.0 0.0
 *
 * rough by dia ctl
 7290102 0.0 0.0 0
 *

```

*      ctl flg
7290300    3
*
*      time pressure temp
7290201    0.0    900.0   80.0
*****
* steam generator secondary - relief valve
*****  

* elev = 476.125 in. above top of tube sheet
*
*      name type
7340000  bsgrv valve
*
*      from to junc area f loss r loss wchbs
7350101  705010000 740000000 .007  0.0  0.0  100
*
*      ctl flow-f flow-g valj
7350201  1     0.0  0.56119  0.0
*
*      vlv type
7350300  trvly
*
*      op trip cl trip slope init pos table
7350301  403   411   0.2  .04567422  0
*
*      input for steady state control systems (comment out cards 73503xx above)
7350300  svrlv
7350301  737
*****
* steam generator secondary - time dep discharge volume
*****
* elev = 476.125 in. above top of tube sheet
*
*      base type
7500000  bsgdv tdpvol
*
*      area length volume hz ang vr ang elv ch
7500101  10.0   10.00  0.0   0.0   0.0   0.0
*
*      rough by dia ctl
7500102  0.0    0.0    0.0
*
*      ctl flg
7500200  2
*
*      time pressure qmals
7500201  0.0    12.3   1.0
*****
* cross connection - junction to cross connection pipe from blsg
*****
* elev = 476.125 in. above top of tube sheet
*
*      name type
7370000  blcnj sagjno
**
*      from to junc area f loss r loss wchbs
7370101  705010000 745000000 0.003003  0.0  0.0  100
**
*      ctl vel-f vel-g valj
7370201  0     0.0  0.0  0.0
**
* broken loop steam dome cross connection pipe to il steam dome
*****
* inlet elev = outlet elev = 476.125 in. above top of tube sheet

```

* note - cross-over pipe snakes around:
 * horizontally back 2,000 ft
 * horizontally over 5,000 ft
 * vertically down 18,000 ft, part of 647
 * horizontally forward 6,000 ft, part of 647
 * horizontally over 8,000 ft, part of 647
 * vertically up 19,730 ft, part of 647
 *
 ** name type
 *7460000 blcup pipe
 ** no vol
 *7460001 1
 ** area vol no
 *7460101 .003003 1
 ** length vol no
 *7460301 7.0 1
 ** vr ang vol no
 *7460601 0.0 1
 ** elv ch vol no
 *7460701 0.0 1
 ** rough by dia vol no
 *7460801 6.67e-5 0.0 1
 ** ctl flg vol no
 *7461001 0 1
 **
 ** ctl press quals zero zero air flg vol no
 *7461201 2 675.900 0.0 0.0 0.0 0 1
 **
 * broken loop steam generator tube sheet outlet
 **
 * ref drawing: 418972
 * inlet elev = +102.604 in. (top of tube sheet)
 * outlet elev = +81.594 in. (bottom of tube sheet)
 *
 * name type
 3250000 blts-of branch
 * no junc ctl
 3250001 2 1
 *
 * area length volume bz ang vr ang elv ch
 3250101 6.054e-3 1.751830 0.0 0.0 -38.07 -1.750333
 *
 * rough by dia ctl
 3250102 5.000e-6 .0620833 0
 *
 * ctl press temp zero
 3250200 3 2250.00 547.00

* from to junc area f loss r loss vcahs
 3251101 320010000 325000000 6.054e-3 0.0 0.0 000
 3252101 325010000 330000000 6.054e-3 0.0 0.0 100
 *
 * flow-f flow-g velj
 3251201 7.310 0.0 0.0
 3252201 7.310 0.0 -0.0
 *
 *
 * steam generator outlet plenum
 *
 * ref drawing: 414272, sh.2, see note for sg inlet plenum (c310)
 *
 * inlet elev = top = + 81.594 in.
 * outlet elev = bottom = + 71.969 in.
 *
 * name type
 3300000 st-outpl snglvol
 *
 * area length volume bz ang vr ang elv ch
 3300101 0.0 0.8020833 .0495847 0.0 -90.0 -0.8020833
 *
 * rough by dia ctl
 3300102 6.667e-5 0.2600218 0
 *
 * ctl press temp zero
 3300200 3 2250.30 531.30 0.0
 *
 * steam generator outlet
 *
 * elev = +71.969 in.
 *
 * name type
 3350000 sg-to-ps sngljm
 *
 * from to junc area f loss r loss vcahs
 3350101 330010000 340000000 0.0097633 0.0 0.0 000
 *
 * ctl flow-f flow-g velj
 3350201 1 5.830 0.0 0.0
 *
 * pump section leg
 *
 * ref drawings: inlet plenum - 414272
 * 1.5ab1-34 (sp-60) - 414675-1
 * 1.5ab1-35 (sp-61) - 414676-1
 * 1.5ab1-36 (sp-62) - 414672-2
 * 1.5ab1-37 (sp-63) - 414673-2
 * 1.5ab1-6a (sp-64) - 414677-1
 * 1.5ab1-7 (sp-65) - 407384-1
 * 1.5ab1-9 (sp-72) - 407380-1
 * 1.5ab1-11 (sp-73) - 407673-1

* inlet elev = + 71.969 in.
 * u-tube bottom elev = -110.155 in.
 * outlet elev = - 10.640 in.
 *
 * name type
 3400000 bl-ps pipe
 *
 * no vol
 3400001 9
 *
 * area vol no
 3400101 0.0097643 9 * 1 1/2 in sch-160
 *
 * length vol no
 3400301 1.6054810 1 * spool piece 60 and inlet plenum
 3400302 2.3393333 2 * sp-61,62
 3400303 1.6437500 3 * sp-63 & 64 to pressure tap
 3400304 4.9401250 4 * sp-64
 3400305 4.2964583 5 * sp-64 & 65 to bend of u
 3400306 1.0157816 6 * sp-65 1/2 of bend
 3400307 1.0157816 7 * sp-65 1/2 of bend
 3400308 5.2495833 8 * sp-63,72
 3400309 2.2966667 9 * sp-73
 *
 * bz ang vol no
 3400501 0.0 9
 * vr ang vol no
 3400601 -45.0 1
 3400602 -90.0 5
 3400603 -45.0 6
 3400604 +45.0 7
 3400605 +90.0 9
 *
 * elv ch vol no
 3400701 -1.3176602 1
 3400702 -2.3393333 2
 3400703 -1.6437500 3
 3400704 -4.9401250 4
 3400705 -4.2964583 5
 3400706 -0.6466667 6
 3400707 +0.6466667 7
 3400708 +5.2495833 8
 3400709 +2.2966667 9
 * rough by dia vol no
 3400801 6.667e-5 0.0 9
 * f loss r loss jun no
 3400901 0.0 0.0 1
 3400902 0.0 0.0 2
 3400903 0.0 0.0 7
 3400904 1.3 1.3 8
 *
 * ctl fig vol no
 3401001 0 9

	ctl fig	jun no					
3401101	0	8					
*							
*	ctl	press	temp	zero	zero	air fig	vol no
3401201	3	2258.30	531.30	0.0	0.0	0	1
3401202	3	2258.30	531.30	0.0	0.0	0	2
3401203	3	2258.30	531.30	0.0	0.0	0	3
3401204	3	2258.30	531.30	0.0	0.0	0	4
3401205	3	2258.30	531.30	0.0	0.0	0	5
3401206	3	2258.30	531.30	0.0	0.0	0	6
3401207	3	2258.30	531.30	0.0	0.0	0	7
3401208	3	2258.30	531.30	0.0	0.0	0	8
3401209	3	2258.30	531.30	0.0	0.0	0	9
*							
*	ctl fig						
3401300		1					
*							
*	flow-f	flow-g	velj	jun no			
3401301	5.840	0.0	0.0	8			
*							
*	***** pump discharge pipe and ecc injection tee *****						
*							
*	ref drawing: 1.5ab1-12 (sp-74) - 407674						
*							
*	inlet elev = outlet elev = 0.000 in.						
*							
*	name type						
3510000	pp-disc branch						
*							
*	no jun	ctl					
3510001	2	1					
*							
*	area	length	volume	bz ang	vr ang	elv ch	
3510101	0.0097643	1.9700	0.0	0.0	0.0	0.0	
*							
*	rough	by dia	ctl				
3510202	6.667e-5	0.0	0				
*							
*	ctl	press	temp				
3510200	3	2258.30	531.30				
*							
*	from	to	jun area	f loss	r loss	vcabs	
3511101	351010000	352000000	.0097643	1.2	1.2	000	
3512201	500010000	351000000	.002695	0.0	0.0	20121	
*							
*	flow-f	flow-g	velj				
3511201	5.840	0.0	0.0				
3512201	0.0	0.0	0.0				
*							
*	***** ecc line *****						
*							
*	inlet elev = outlet elev = 0.000 in.						
*							

*	name	type							
500000	bleccpip	pipe							
*	no vol								
500001	1								
*	area	vol no							
5000101	0.002695	1							
*	length	vol no							
5000301	10.0	1							
*	vr ang	vol no							
5000601	0.0	1							
*	elv ch	vol no							
5000701	0.0	1							
*	rough	by dia	vol no						
5000801	6.67e-5	0.0	1						
*	ctl flg	vol no							
5001001	0	1							
*	ctl press	temp	zero	zero	air flg	vol no			
5001201	3 2258.30	531.30	0.0	0.0	0	1			
*	hpis injection junction								
*	elev = 0.000 in.								
*	name	type							
5100000	blhpisj	trajjun							
*	from	to	jun area						
5100101	52000000	50000000	0.002695						
*	ctl flg	trip	table	volume					
5100200	1	408	p	361010000					
*	pres(psia)	flow-f	flow-g	velj					
5100201	-1.0	0.00	0.0	0.0					
5100202	0.0	0.00	0.0	0.0					
5100203	15.0	0.0125	0.0	0.0					
5100204	333.57	0.01113	0.0	0.0					
5100205	581.36	0.01000	0.0	0.0					
5100206	619.77	0.00974	0.0	0.0					
5100207	770.0	0.00868	0.0	0.0					
5100208	881.0	0.00795	0.0	0.0					
5100209	1007.23	0.00705	0.0	0.0					
5100210	1024.0	0.00633	0.0	0.0					
5100211	1158.0	0.0059	0.0	0.0					
5100212	1258.0	0.0051	0.0	0.0					
5100213	1248.0	0.0039	0.0	0.0					
5100214	1407.0	0.0031	0.0	0.0					
5100215	1455.0	0.0019	0.0	0.0					
*	name	type							
5100216	1550.0	0.00	0.0	0.0					
5100217	1600.0	0.00	0.0	0.0					
*	hpis volume								
*	elev = 0.000 in.								
*	name	type							
5200000	blbpisv	trajvol							
*	area	length	volume	hz ang	vr ang	elv ch			
5200101	10.0	10.0	0.0	0.0	0.0	0.0			
*	rough	by dia	ctl						
5200102	0.0	0.0	0						
*	ctl flg								
5200200	3								
*	time	pressure	temp						
5200201	0.0	12.3	80.0						
*	accumulator								
*	inlet elev = bottom = 0.000 in.								
*	outlet elev = top = + 13.757 in.								
*	elev = 0.000 in.								
*	name	type							
5300000	blecc	accum							
*	area	length	volume	hz ang	vr ang	elv ch			
5300101	0.7085	1.1464	0.0	0.0	90.0	1.1464			
*	rough	by dia	ctl						
5300102	0.0	0.0	10						
*	pressure	temp							
5300200	615.0	80.0							
*	to jun area	f loss	r loss	reabs					
5301101	50000000	0.002695	50149.59	50149.59	000				
*	vliq	liq lev	lnlen	elev	thick	litr-flg	takro	takcp	nit-k
5302200	0.55	0	20.00	0	.0417	0	0	0	0
*	brokeen loop cold leg break tee								
*	ref drawing: 1.5ab1-17 or 1.5ab126a (sp-76) - 407875								
*	inlet elev = outlet elev = 0.000 in.								
*	name	type							

3620000 brk-tee branch
 *
 * no jun ctl
 3620001 1 1
 *
 * area length volume bz ang vr ang elv ch
 3620101 0.0097643 1.647500 0.0 0.0 0.0 0.0
 *
 * rough by dia ctl
 3620102 6.657e-5 0.0 0
 *
 * ctl press temp
 3620200 3 2253.30 531.30
 *
 * from to jun area f loss r loss vcahs
 3621101 362010000 363000000 .0097643 1.2 1.2 000
 *
 * flow-f flow-g velj
 3621201 5.840 0.0 0.0
 *
 * break loop cold leg (downstream of break)
 *
 * ref drawings: 1.5ab1-17 (sp-76) - 407875
 * 1.5ab1-15 (sp-79) - 407675
 * cold leg nozzle - 407986
 *
 * name type
 3630000 bl-cl pipe
 *
 * bo vol
 3630001 2
 *
 * area vol no
 3630101 0.0097643 1 * 1 1/2 in sch-160 pipe
 3630102 0.0375539 2 * downcomer inlet annulus nozzle
 *
 * length vol no
 3630301 2.3341657 1 * sp-79
 3630302 1.2761577 2 * cold leg nozzle
 *
 * vr ang vol no
 3630601 0.0 2
 *
 * elv ch vol no
 3630701 0.0 2
 *
 * rough by dia vol no
 3630801 6.657e-5 0.0 2
 *
 * ctl flg vol no
 3631001 0 2
 *
 * vcahs jun no
 3631101 0 1
 *
 * ctl press temp zero zero air flg vol no
 * 3631201 3 2253.30 531.30 0.0 0.0 0 2
 *
 * ctl flg
 3631300 1
 *
 * flow-f flow-g velj jun no
 3631301 5.840 0.0 0.0 1
 *
 * break junction
 *
 * elev = 0.000 in.
 *
 * break sizes:
 * 0.52 - 0.0001279 (nominal) s-nb-1
 * 2.12 - 0.0005116 (nominal)
 * 2.52 - 0.0006175 (nominal)
 * 5.02 - 0.0012079 (nominal)
 * 10.02 - 0.00247 (nominal)

```

*900001    0.0   12.3   1.0
*
*****
* beat loss ambient volumes
*****
*      name      type
800000  ilsg      tndpvol
*
*      area      length     volume    hz ang    vr ang    elv ch
8000101 10.0       1.0        0.0       0.0       0.0       0.0
*
*      rough     by dia     ctl
8000102 0.0       0.0        0
*
*****ctl flg
8000200 1
*
*      time      temp      quale
8000201 0.0       80.0       1.0
*****
*      name      type
801000  ibll      tndpvol
*
*      area      length     volume    hz ang    vr ang    elv ch
8010101 10.0       1.0        0.0       0.0       0.0       0.0
*
*      rough     by dia     ctl
8010102 0.0       0.0        0
*
*****ctl flg
8010200 1
*
*      time      temp      quale
8010201 0.0       80.0       1.0
*****
*      name      type
802000  blps      tndpvol
*
*      area      length     volume    hz ang    vr ang    elv ch
8020101 10.0       1.0        0.0       0.0       0.0       0.0
*
*      rough     by dia     ctl
8020102 0.0       0.0        0
*
*****ctl flg
8020200 1
*
*      time      temp      quale
8020201 0.0       80.0       1.0
*****
*      name      type
8030000  ibcl      tndpvol
*
*      area      length     volume    hz ang    vr ang    elv ch
8030101 10.0       1.0        0.0       0.0       0.0       0.0
*
*      rough     by dia     ctl
8030102 0.0       0.0        0
*
*****ctl flg
8030200 1
*
*      time      temp      quale
8030201 0.0       80.0       1.0
*****
*      name      type
8040000  ilps      tndpvol
*
*      area      length     volume    hz ang    vr ang    elv ch
8040101 10.0       1.0        0.0       0.0       0.0       0.0
*
*      rough     by dia     ctl
8040102 0.0       0.0        0
*
*****ctl flg
8040200 1
*
*      time      temp      quale
8040201 0.0       80.0       1.0
*****
*      name      type
8050000  vsldnc   tndpvol
*
*      area      length     volume    hz ang    vr ang    elv ch
8050101 10.0       1.0        0.0       0.0       0.0       0.0
*
*      rough     by dia     ctl
8050102 0.0       0.0        0
*
*****ctl flg
8050200 1
*
*      time      temp      quale
8050201 0.0       80.0       1.0
*****
*      name      type
8060000  psrcap   tndpvol
*
*      area      length     volume    hz ang    vr ang    elv ch
8060101 10.0       1.0        0.0       0.0       0.0       0.0
*
*      rough     by dia     ctl
8060102 0.0       0.0        0

```

```

*          ctl flg
8060200    1
*
*          time   temp   quale
8060201    0.0    80.0   1.0
*****
*          name   type
8070000    pars1  tndpvol
*
*          area   length  volume  bz ang  vr ang  elv ch
8070101    10.0   1.0     0.0     0.0     0.0     0.0
*
*          rough  by dia  ctl
8070102    0.0     0.0     0
*****
*          ctl flg
8070200    1
*
*          time   temp   quale
8070201    0.0    80.0   1.0
*****
*          name   type
8080000    blsat  tndpvol
*
*          area   length  volume  bz ang  vr ang  elv ch
8080101    10.0   1.0     0.0     0.0     0.0     0.0
*
*          rough  by dia  ctl
8080102    0.0     0.0     0
*****
*          ctl flg
8080200    1
*
*          time   temp   quale
8080201    0.0    80.0   1.0
*****
*          name   type
8090000    blsg   tndpvol
*
*          area   length  volume  bz ang  vr ang  elv ch
8090101    10.0   1.0     0.0     0.0     0.0     0.0
*
*          rough  by dia  ctl
8090102    0.0     0.0     0
*****
*          ctl flg
8090200    1
*
*          time   temp   quale
8090201    0.0    80.0   1.0
*****
*          name   type
8100000    blsh   tndpvol
*
*          area   length  volume  bz ang  vr ang  elv ch
810101    10.0   1.0     0.0     0.0     0.0     0.0
*
*          rough  by dia  ctl
810102    0.0     0.0     0
*****
*          ctl flg
810200    1
*
*          time   temp   quale
810201    0.0    80.0   1.0
*****
*          name   type
8110000    blbh   tndpvol
*
*          area   length  volume  bz ang  vr ang  elv ch
8110101    10.0   1.0     0.0     0.0     0.0     0.0
*
*          rough  by dia  ctl
8110102    0.0     0.0     0
*****
*          ctl flg
8110200    1
*
*          time   temp   quale
8110201    0.0    80.0   1.0
*****
*          name   type
8120000    blph   tndpvol
*
*          area   length  volume  bz ang  vr ang  elv ch
8120101    10.0   1.0     0.0     0.0     0.0     0.0
*
*          rough  by dia  ctl
8120102    0.0     0.0     0
*****
*          ctl flg
8120200    1
*
*          time   temp   quale
8120201    0.0    80.0   1.0
*****
*          name   type
8130000    blbh   tndpvol
*
*          area   length  volume  bz ang  vr ang  elv ch
8130101    10.0   1.0     0.0     0.0     0.0     0.0
*
*          rough  by dia  ctl
8130102    0.0     0.0     0
*****
*          ctl flg
8130200    1
*
*          time   temp   quale
8130201    0.0    80.0   1.0
*****
*          name   type
8140000    blph   tndpvol
*
*          area   length  volume  bz ang  vr ang  elv ch
8140101    10.0   1.0     0.0     0.0     0.0     0.0

```

```

* gl data      nh    np    type   s-flg   l-cor
8140102      0.0    0.0    0       1       8       2       1   0.271375
*
* mesh        loc flg   frm flg
8140200      1
*
* geometry   no itv   r-cor   no itv   r-cor   no itv   r-cor
8140201      0.0    80.0    1.0
*
***** name   type
8150000      vs1mb  tadvol
*
* area    length   volume   bz ang   vr ang   elv ch
8150101      10.0    1.0     0.0     0.0     0.0     0.0
*
* rough   by dia   ctl
8150102      0.0    0.0    0
*
* ctl flg
8150200      1
*
* time    temp    quale
8150201      0.0    80.0    1.0
*
***** base   type
8150000      pzb   tadvol
*
* area    length   volume   bz ang   vr ang   elv ch
8150101      10.0    1.0     0.0     0.0     0.0     0.0
*
* rough   by dia   ctl
8150102      0.0    0.0    0
*
* ctl flg
8150200      1
*
* time    temp    quale
8150201      0.0    80.0    1.0
*
***** heat structure
***** information
* downcomer inlet annulus hollow center (above cold leg nozzle)
* left boundary = adiabatic
* right boundary = component 101
*
***** gl data      nh    np    type   s-flg   l-cor
11011000     1       6       2       1   0.12500
*
* mesh        loc flg   frm flg
11011100     0       1
*
* geometry   no itv   r-cor   no itv   r-cor   no itv   r-cor
11011101     2   0.18750    1   0.191667   2   0.20000
*
* materials  cap no   itv no   cap no   itv no   cap no   itv no
11011201     1       2       2       3       1       5

```

```

*source dis source itv no
11011301 0.0 5
*
*init temp flg
11011400 0
*
* temp mesh temp mesh
11011401 550.0 3 59.7 6
*
*l-body by-vol inc b-cdt a-code cy-length ht-str-no
11011501 0 0 0 1 0.87500 1
*
*r-body by-vol inc b-cdt a-code cy-length ht-str-no
11011601 101010000 0 1 1 0.87500 1
*
*source type is-mlpr l-dr-bt r-dr-bt ht-str-no
11011701 0 0 0 0 1
*
*l-b-st chf-btr by-dia b-eq-dia ch-length ht-str-no
*11011801 0 0.0 0.0 0.0 1
11011801 0.0 10.0 10.0 0 0 0 0 1.0 1
*
*r-b-st chf-btr by-dia b-eq-dia ch-length ht-str-no
*11011901 0 0.0 0.336444 1.87500 1
11011901 0.336444 10.0 10.0 0 0 0 0 1.0 1
*****
* downcomer inlet annulus hollow center (below cold leg nozzle)
*****
* left boundary = adiabatic
* right boundary = component 102
*
*g1 data nh np type s-flg l-cor
11021000 1 6 2 1 0.12500
*
*mesh loc flg frm flg
11021100 0 1
*
*geometry no itv r-cor no itv r-cor no itv r-cor
11021101 2 0.18750 1 0.191667 2 0.20000
*
*materials cmp no itv no cmp no itv no cmp no itv no
11021201 1 2 2 3 1 5
*
*source dis source itv no
11021301 0.0 5
*
*init temp flg
11021400 0
*
* temp mesh temp mesh
11021401 550.0 3 550.3 6
*
*l-body by-vol inc b-cdt a-code cy-length ht-str-no
11021501 0 0 0 1 1.00000 1
*
*r-body by-vol inc b-cdt a-code cy-length ht-str-no
11021601 101010000 0 1 1 1.00000 1
*
*source type is-mlpr l-dr-bt r-dr-bt ht-str-no
11021701 0 0 0 0 1
*
*l-b-st chf-btr by-dia b-eq-dia ch-length ht-str-no
*11021801 0 0.0 0.0 0.0 1
11021801 0.0 10.0 10.0 0 0 0 0 1.0 1
*
*r-b-st chf-btr by-dia b-eq-dia ch-length ht-str-no
*11021901 0 0.0 0.336444 1.87500 1
11021901 0.336444 10.0 10.0 0 0 0 0 1.0 1
*****

```

* downcomer pipe (heat loss to environment) - unheated

 *
 * left boundary = component 110 (volumes 1,2,3,4,5,6,7,8,9)
 * right boundary = ambient volume (805)
 *
 *gl data ab ap type s-flg l-cor
 11100003 9 10 2 1 .091041667
 *
 *mesh loc flg frm flg
 11100100 0 1
 *
 *geometry no itv r-cor no itv r-cor no itv r-cor
 11100101 1 .092541667 2 .107825000 1 .109325000
 11100102 3 .145333333 2 .312500000
 *
 *materials cmp no itv no cmp no itv no cmp no itv no
 11100201 10 1 12 3 10 4
 11100202 1 7 8 9
 *
 *source dis source itv no
 11100301 0.0 9
 *
 *init temp flg
 11100400 0
 *
 *temp mesh temp mesh temp mesh temp mesh temp mesh
 11100401 59.9 2 395.0 3 249.3 8 189.7 9 149.3 10
 *
 *l-body by-vol inc b-cut a-code cy-length bt-str-no
 11100501 110010000 0 1 1 1.715159 1
 11100502 110020000 0 1 1 0.773268 2
 11100503 110030000 0 1 1 1.272435 3
 11100504 110040000 0 1 1 1.272435 4
 11100505 110050000 0 1 1 1.272435 5
 11100506 110060000 0 1 1 1.272435 6
 11100507 110070000 0 1 1 1.272435 7
 11100508 110080000 0 1 1 1.465667 8
 11100509 110090000 0 1 1 1.434751 9
 *
 *r-body by-vol inc b-cut a-code cy-length bt-str-no
 11100601 805010000 0 4100 1 1.715159 1
 11100602 805010000 0 4100 1 0.773268 2
 11100603 805010000 0 4100 1 1.272435 3
 11100604 805010000 0 4100 1 1.272435 4
 11100605 805010000 0 4100 1 1.272435 5
 11100606 805010000 0 4100 1 1.272435 6
 11100607 805010000 0 4100 1 1.272435 7
 11100608 805010000 0 4100 1 1.465667 8
 11100609 805010000 0 4100 1 1.434751 9
 *
 *source type is-mpfr l-dr-bit r-dr-bit bt-str-no
 11100701 0 0 0 0 9
 *
 *l-h-st chf-htr by-dia h-eq-dia ch-length bt-str-no
 11100801 0 0.0 0.0 0.0 16.24581 9
 11100801 0.0 10.0 10.0 0 0 1.0 9
 *

11101703	10225	.035114	0	0	3	*11102301	0	0.0	0.0	0.0	0.96250	1		
11101704	10225	.035114	0	0	4	11102301	0.0	10.0	0.0	0.0	1.0	1		
11101705	10225	.035114	0	0	5	*	*****	*****	*****	*****	*****	*****		
11101706	10225	.035114	0	0	6	* lower downcomer distribution annulus - external heaters	*****	*****	*****	*****	*****	*****		
11101707	10225	.035114	0	0	7	*	*****	*****	*****	*****	*****	*****		
*						*								
*l-h-st	chf-htr	hy-dia	b-eq-dia	ch-length	ht-str-no	*l-h-st	chf-htr	hy-dia	b-eq-dia	ch-length	ht-str-no	*		
*11101801	0	0.0	0.0	16.244581	7	*11101801	0	0.0	0.0	0.0	0.0	*		
11101801	0.0	10.0	10.0	0 0 0 0	1.0	11101801	0.0	10.0	10.0	0 0 0 0	1.0	*		
*						*								
*r-h-st	chf-htr	hy-dia	b-eq-dia	ch-length	ht-str-no	*r-h-st	chf-htr	hy-dia	b-eq-dia	ch-length	ht-str-no	*		
*11101901	0	0.0	0.0	16.244581	7	*11101901	0	0.0	0.0	0.0	0.0	*		
11101901	0.0	10.0	10.0	0 0 0 0	1.0	11101901	0.0	10.0	10.0	0 0 0 0	1.0	*		
*						*								
*lower downcomer distribution annulus heat loss (with honeycomb)	*****	*****	*****	*****	*****	*lower downcomer distribution annulus heat loss (with honeycomb)	*****	*****	*****	*****	*****	*		
*						*								
* left boundary = component 110 (volume 10)	*****	*****	*****	*****	*****	* left boundary = component 110 (volume 10)	*****	*****	*****	*****	*****	*		
* right boundary = ambient volume (815)	*****	*****	*****	*****	*****	* right boundary = ambient volume (815)	*****	*****	*****	*****	*****	*		
*						*								
*gl data	nb	np	type	s-flg	l-cor	*gl data	nb	np	type	s-flg	l-cor	*		
11102000	1	10	2	1	0.244875	11102000	1	13	2	1	.244875	*		
*						*								
*mesh	loc flg	frm flg				*mesh	loc flg	frm flg				*		
11102100	0	1				11103100	0	1				*		
*						*								
*geometry	no itv	r-cor	no itv	r-cor	no itv	*geometry	no itv	r-cor	no itv	r-cor	no itv	r-cor		
11102101	1	.246541667	2	.256958333	1	11103101	1	.246541667	2	.256958333	1	.25662500		
11102102	3	.411541667	2	.578203333		11103102	3	.411541667	1	.411641667	2	.42805833		
*						11103103	2	.592725000						
*						*								
*materials	cmp no	itv no	cmp no	itv no	cmp no	*materials	cmp no	itv no	cmp no	itv no	cmp no	itv no		
11102201	10	1	11	3	10	11103201	10	1	11	3	10	4		
11102202	1	7	8	9		11103202	1	7	13	8	9	10		
*						11103203	8	12						
*						*								
*source dis	source	itv no				*source dis	source	itv no	source	itv no	source	itv no		
11102301	0.0	9				11103301	0.0	8	1.0	10	0.0	12		
*						*								
*init temp	flg					*init temp	flg							
11102400	0					11103400	-0							
*						*								
*temp mesh	temp mesh	temp mesh	temp mesh	temp mesh	temp mesh	*temp mesh	temp mesh	temp mesh	temp mesh	temp mesh	temp mesh	*		
11102401	549.3	2	440.6	3	323.7	8	241.6	9	181.1	10				
*						11103401	549.3	2	444.1	3	331.6	8		
*						11103402	182.9	13			335.1	11	247.5	12
*						*								
*l-body	hy-vol	inc	b-cut	a-code	cy-length	*l-body	hy-vol	inc	b-cut	a-code	cy-length	ht-str-no		
11102501	110100000	0	1	1	0.704681	11103501	110100000	0	1	1	0.257819	1		
*						*								
*r-body	hy-vol	inc	b-cut	a-code	cy-length	*r-body	hy-vol	inc	b-cut	a-code	cy-length	ht-str-no		
11102601	815010000	0	4100	1	0.704681	11103601	815010000	0	4100	1	0.257819	1		
*						*								
*source	type	is-mlr	l-dr-bt	r-dr-bt	ht-str-no	*source	type	is-mlr	l-dr-bt	r-dr-bt	ht-str-no			
11102701	0	0	0	0	1	11103701	10225	.035114	0	0	1			
*						*								
*l-h-st	chf-htr	hy-dia	b-eq-dia	ch-length	ht-str-no	*l-h-st	chf-htr	hy-dia	b-eq-dia	ch-length	ht-str-no	*		
*11102801	0	0.0	0.198130	0.96250	1	*11102801	0	0.0	0.198130	0.96250	1	*		
11102801	0.198130	10.0	10.0	0 0 0 0	1.0	11102801	0.198130	10.0	10.0	0 0 0 0	1.0	*		
*						*								
*r-h-st	chf-htr	hy-dia	b-eq-dia	ch-length	ht-str-no	*r-h-st	chf-htr	hy-dia	b-eq-dia	ch-length	ht-str-no	*		
*						*11102901	0	0	0.0	0.96250	1	*		
11102901	0.0	10.0	10.0	0 0 0 0	1.0	11102901	0.0	10.0	10.0	0 0 0 0	1.0	*		
*						*								
* downcomer distribution annulus to core inlet (thru lower extension)	*****	*****	*****	*****	*****	* downcomer distribution annulus to core inlet (thru lower extension)	*****	*****	*****	*****	*****	*		
*						*								
* left boundary = component 140	*****	*****	*****	*****	*****	* left boundary = component 140	*****	*****	*****	*****	*****	*		

```

* right boundary = component 110 (volume 10)
*
*gl data    nh    np    type    s-flg   l-cor
11140000    1      3      2        1  0.1796667
*
*mesh    loc flg   frm flg
11140100    0      1
*
*geometry  no itv   r-cor
11140101    2  0.188958
*
*materials  cmp no  itv no
11140201    1      2
*
*source dis  source  itv no
11140301    0.0     2
*
*init temp   flg
11140400    0
*
*temp mesh
11140401  559.0   3
*
*l-body    by-vol   inc  b-cut  a-code  cy-length  lt-str-no
11140501  180010000  0     1     1  0.96250    1
*
*r-body    by-vol   inc  b-cut  a-code  cy-length  lt-str-no
11140601  110100000  0     1     1  0.96250    1
*
*source    type  is-splr  l-dr-ht  r-dr-ht  lt-str-no
11140701    0      0       0       0       1
*
*l-h-st    chf-htr  by-dia  h-eq-dia  ch-length  lt-str-no
11140801    0      3.0     0.0     0.96250    1
11140801  0.0  10.0 10.0  0 0 0 0  1.0  1
*
*r-h-st    chf-htr  by-dia  h-eq-dia  ch-length  lt-str-no
11140901    0      0.0    0.255760  0.96250    1
11140901  0.25576  10.0 10.0  0 0 0 0  1.0  1
*
***** vessel bottom head (with honeycomb) *****
*
* left boundary = component 120
* right boundary = ambient volume (805)
*
*gl data    nh    np    type    s-flg   l-cor
11200000    1      9      2        1  0.412500
*
*mesh    loc flg   frm flg
11200100    0      1
*
*geometry  no itv   r-cor  no itv   r-cor  no itv   r-cor
11200101    1  .41416667  2  .42458333  1  .42525000
11200102    2  .74941666  2  .90708333
*
*materials  cmp no  itv no  cmp no  itv no  cmp no  itv no
11200201    10     1     11     3     10     4
11200202    1      6     8      8
*
*source dis  source  itv no
11200301    0.0     8
*
*init temp   flg
11200400    0
*
*temp mesh  temp mesh  temp mesh  temp mesh  temp mesh  temp mesh
11200401  540.1   2  441.3   3  343.5   5  317.0   6  295.6   7
11200402  237.0   8  179.5   9

```

```

*1-body by-vol inc b-cdt a-code cy-length bt-str-no
11200501 120010000 0 1 1 0.466667 1
*
*1-body by-vol inc b-cdt a-code cy-length bt-str-no
11200601 85010000 0 4100 1 0.466667 1
*
*source type is-mlr l-dr-bt r-dr-bt bt-str-no
11200701 0 0 0 0 1
*
*1-h-st chf-btr by-dia b-eq-dia ch-length bt-str-no
11200801 0 0.0 0.0 0.466667 1
11200801 0.0 10.0 10.0 0 0 0 0 1.0 1
*
*1-h-st chf-btr by-dia b-eq-dia ch-length bt-str-no
11200901 0 0.0 0.0 0.466667 1
11200901 0.0 10.0 10.0 0 0 0 0 1.0 1
*
***** vessel lower plenum wall (with honeycomb) *****
*
* left boundary = component 130
* right boundary = ambient volume (805)
*
*gl data nh np type s-flg l-cor
11300000 1 9 2 1 .363403395
*
*mesh loc flg frm flg
11300100 0 1
*
*geometry no itv r-cor no itv r-cor no itv r-cor
11300101 1 .363170062 2 .375486729 1 .37715339
11300102 2 .691320063 2 .857986730
*
*materials cmp no itv no cmp no itv no cmp no itv no
11300201 10 1 11 3 10 4
11300202 1 6 8 8
*
*source dis source itv no
11300301 0.0 8
*
*init temp flg
11300400 0
*
* temp mesh temp mesh temp mesh temp mesh temp mesh
11300401 540.8 2 488.3 3 337.1 5 310.3 6 290.3 7
11300402 232.2 8 176.5 9
*
*1-body by-vol inc b-cdt a-code cy-length bt-str-no
11300501 130010000 0 1 1 0.721917 1
*
*1-body by-vol inc b-cdt a-code cy-length bt-str-no
11300601 85010000 0 4100 1 0.721917 1
*
*source type is-mlr l-dr-bt r-dr-bt bt-str-no
11300701 0 0 0 0 1
*
*1-h-st chf-btr by-dia b-eq-dia ch-length bt-str-no
11300801 0 0.0 0.0 0.0 0.0 0.0 0.721917 1
11300801 0.0 10.0 10.0 0 0 0 0 1.0 1
*
*1-h-st chf-btr by-dia b-eq-dia ch-length bt-str-no
11300901 0 0.0 0.0 0.0 0.0 0.0 0.721917 1
11300901 0.0 10.0 10.0 0 0 0 0 1.0 1
*****
* heated core (active length)
*****
* left boundary = adiabatic
* right boundary = component 150
*
* note: the mod-2a core is a 5 x 5 rod matrix with
* two (2) unpowered rods in opposing corners.
* each rod has an od = 0.422 in. each power
* step (two per hydrodynamic volume) is
* modeled individually.
*
*gl data nh np type s-flg l-cor
11500000 12 18 2 1 0.0
*
*mesh loc flg frm flg
11500100 0 1
*
*geometry no itv r-cor no itv r-cor no itv r-cor
11500101 1 0.002917 4 0.00375 4 0.014500
11500102 4 0.015300 4 0.017533
*
*materials cmp no itv no cmp no itv no cmp no itv no
11500201 3 1 4 5 3 9
11500202 1 13 1 17
*
*source dis source itv no source itv no source itv no
11500301 0.0 1 1.0 5 0.0 17
*
*init temp flg
11500400 -1
*
*temp distribution
11500401 692.4 692.4 689.8 683.2 673.1 689.6 688.3 619.6 602.9
+ 537.8 585.7 583.7 581.7 579.7 575.7 571.7 557.9 564.2
11500402 822.4 822.4 817.5 804.9 785.6 760.1 717.9 681.2 648.7
+ 619.6 615.7 611.9 608.1 604.3 596.7 589.3 582.1 575.2
11500403 979.3 979.3 971.9 952.9 923.8 885.2 818.5 760.9 710.4
+ 665.5 659.7 654.1 648.5 642.9 631.6 620.7 610.0 599.5
11500404 1143.1 1143.1 1133.1 1107.0 1067.1 1014.2 917.8 835.8 764.6
+ 701.8 694.0 686.3 678.8 671.3 656.0 641.1 626.6 612.4
11500405 1275.5 1275.5 1263.7 1232.9 1185.7 1123.4 1004.1 903.7 817.4
+ 741.8 732.7 723.8 715.0 706.3 688.5 671.2 654.3 637.7
11500406 1333.6 1333.6 1320.8 1287.7 1236.9 1189.8 1038.8 929.3 835.4
+ 753.5 743.8 734.3 724.9 715.5 686.5 677.9 659.7 641.9
11500407 1350.8 1350.8 1338.1 1304.9 1254.2 1187.1 1055.0 944.6 850.1
+ 767.1 758.0 748.6 739.2 729.9 711.0 692.5 674.5 656.8
11500408 1293.2 1293.2 1281.4 1250.6 1203.4 1141.1 1020.7 919.6 832.6
+ 756.6 747.6 738.7 730.0 721.3 703.7 686.5 669.6 653.2

```

1150409 1190.8 1190.8 1180.7 1154.6 1114.7 1061.9 963.3 879.5 806.9
 + 743.0 735.4 727.9 720.4 713.1 688.1 683.5 660.2 655.3
 1150410 1026.1 1026.1 1018.7 999.7 970.6 932.0 853.9 805.2 753.7
 + 707.9 702.3 696.7 691.2 685.8 674.7 663.9 653.5 643.3
 1150411 886.2 886.2 881.3 883.7 899.4 823.9 780.6 742.9 709.5
 + 679.7 675.9 672.1 668.4 664.8 657.7 650.2 643.2 636.4
 1150412 755.6 755.6 753.0 746.4 736.2 722.8 700.9 681.7 664.6
 + 649.1 647.1 645.1 643.1 641.2 637.3 633.5 629.8 626.2
 *
 *1-body by-vol inc b-cdt a-code surf-area ht-str-no
 11500501 0 0 0 0 0.0 12
 *
 *r-body by-vol inc b-cdt a-code surf-area ht-str-no
 11500601 150010000 0 1 0 2.5410249 1
 11500602 150010000 0 1 0 2.5410249 2
 11500603 150020000 0 1 0 2.5410249 3
 11500604 150020000 0 1 0 2.5410249 4
 11500605 150030000 0 1 0 2.5410249 5
 11500606 150030000 0 1 0 2.5410249 6
 11500607 150040000 0 1 0 2.5410249 7
 11500608 150040000 0 1 0 2.5410249 8
 11500609 150050000 0 1 0 2.5410249 9
 11500610 150050000 0 1 0 2.5410249 10
 11500611 150060000 0 1 0 2.5410249 11
 11500612 150060000 0 1 0 2.5410249 12
 *
 *source type is-splir l-dr-bt r-dr-bt ht-str-no
 11500701 10151 0.02584 0 0 1
 11500702 10151 0.04917 0 0 2
 11500703 10151 0.07416 0 0 3
 11500704 10151 0.10165 0 0 4
 11500705 10151 0.12001 0 0 5
 11500706 10151 0.12916 0 0 6
 11500707 10151 0.12916 0 0 7
 11500708 10151 0.12001 0 0 8
 11500709 10151 0.10165 0 0 9
 11500710 10151 0.07416 0 0 10
 11500711 10151 0.04917 0 0 11
 11500712 10151 0.02584 0 0 12
 *
 *1-h-st chf-btr hy-dia b-eq-dia ch-length ht-str-no
 *11500801 0 0.0 0.0 0.0 12.0 12
 11500801 0.0 10.0 10.0 0 0 0 0 1.0 12
 *
 *1-h-st chf-btr hy-dia b-eq-dia ch-length ht-str-no
 *11500901 0 0.0 0.043992 0.043992 12.0 12
 11500901 0.043992 10.0 10.0 0 0 0 0 1.0 12
 *

 * vessel core barrel wall (rod-3 "steam-gap") - unheated

 *
 * left boundary = component 150
 * right boundary = ambient volume (805)
 *
 *gl data nh np type s-flg l-corr
 11501000 6 13 2 1 0.132114
 *

*resb loc flg fm flg
 11501100 0 1
 *
 *geometry co itv r-corr no itv r-corr no itv r-corr
 11501101 2 .133954 1 .155531 2 .149864
 11501102 3 .200256 2 .272255 2 .438956
 *
 *materials cap no itv no cap no itv no cap no itv no
 11501201 1 2 2 3 1 5
 11501202 1 8 1 10 8 12
 *
 *source dis source itv no
 11501301 0.0 12
 *
 *init temp flg
 11501400 -1
 *
 *temp distribution
 11501401 551.6 551.3 551.0 360.7 359.2 357.8 351.9 346.7 342.1
 + 334.4 328.0 257.4 186.8
 11501402 564.4 564.1 563.7 367.8 366.3 364.8 358.7 353.4 348.6
 + 340.7 334.0 261.6 189.2
 11501403 581.9 581.5 581.2 377.5 375.5 374.4 368.1 362.5 357.5
 + 349.3 342.4 267.4 192.4
 11501404 598.5 598.1 597.8 386.9 385.3 383.7 377.1 371.3 366.1
 + 357.6 350.5 273.1 195.6
 11501405 609.7 609.3 609.0 393.4 391.7 390.0 383.3 377.3 372.0
 + 363.3 356.0 276.9 197.8
 11501406 614.2 613.8 613.5 395.2 393.5 391.8 384.9 378.9 373.6
 + 364.8 357.4 277.9 198.3
 *
 *1-body by-vol inc b-cdt a-code cy-length ht-str-no
 11501501 150010000 0 1 1 0.635984 1
 11501502 150020000 0 1 1 0.635984 2
 11501503 150030000 0 1 1 0.635984 3
 11501504 150040000 0 1 1 0.635984 4
 11501505 150050000 0 1 1 0.635984 5
 11501506 150060000 0 1 1 0.635984 6
 *
 *r-body by-vol inc b-cdt a-code cy-length ht-str-no
 11501601 85010000 0 4100 1 0.635984 1
 11501602 85010000 0 4100 1 0.635984 2
 11501603 85010000 0 4100 1 0.830843 3
 11501604 85010000 0 4100 1 0.830843 4
 11501605 85010000 0 4100 1 0.830843 5
 11501606 85010000 0 4100 1 0.635984 6
 *
 *source type is-splir l-dr-bt r-dr-bt ht-str-no
 11501701 0 0 0 0 0 6
 *
 *1-h-st chf-btr hy-dia b-eq-dia ch-length ht-str-no
 *11501801 0 0.0 0.129489 0.129489 12.0 6
 11501801 0.129489 10.0 10.0 0 0 0 0 1.0 6
 *
 *1-h-st chf-btr hy-dia b-eq-dia ch-length ht-str-no
 *11501901 0 0.0 0.0 0.0 12.0 6
 11501901 0.0 10.0 10.0 0 0 0 0 1.0 6
 *

```

*****
* vessel core barrel wall - external heaters
*****
*
* left boundary = component 150
* right boundary = ambient volume (815)
*
*g1 data    nh      np      type    s-flg    l-cor
11502000     6       16      2        1   0.132114
*
*mesh    loc flg   frm flg
11502100     0       1
*
*geometry    no itv    r-cor    no itv    r-cor    no itv    r-cor
11502101     2   .133964     -1   .135531     2   .133964
11502102     3   .200256     2   .272256     1   .272256
11502103     2   .282777     2   .449494
*
*materials   cmp no    itv no    cmp no    itv no    cmp no    itv no
11502201     1       2       2       3       1       5
11502202     1       8       1      10      13      11
11502203     9      13       8      15
*
*source dis  source    itv no    source    itv no    source    itv no
11502301     0.0      11      1.0      13      0.0      15
*
*init temp   flg
11502400     -1
*
*temp distribution
11502401 637.7 637.5 637.2 492.3 491.2 490.1 485.7 481.9 478.7
+ 473.8 470.2 466.8 461.8 453.4 344.5 235.6
11502402 643.0 642.8 642.6 497.0 495.9 494.8 490.3 486.5 483.3
+ 478.3 474.6 471.1 465.9 457.4 347.3 237.1
11502403 648.7 648.5 648.2 503.1 502.0 500.9 496.4 492.6 489.4
+ 484.3 480.4 476.8 471.5 462.8 351.0 239.1
11502404 653.2 653.0 652.8 508.3 507.0 506.1 501.7 497.9 494.6
+ 489.4 485.5 481.7 476.3 467.4 354.2 240.9
11502405 653.3 653.1 652.9 510.7 509.6 508.6 504.2 500.4 497.2
+ 492.0 488.1 484.3 478.7 469.8 355.8 241.8
11502406 653.4 653.1 652.9 511.5 510.4 509.4 505.0 501.3 498.0
+ 492.9 488.9 485.1 479.5 470.6 356.4 242.1
*
*l-body    by-vol    inc    b-cut    a-code    cy-length    bt-str-no
11502501 150010000     0       1       1   1.364016     1
11502502 150020000     0       1       1   1.364016     2
11502503 150030000     0       1       1   1.169157     3
11502504 150040000     0       1       1   1.169157     4
11502505 150050000     0       1       1   1.169157     5
11502506 150060000     0       1       1   1.364016     6
*
*r-body    by-vol    inc    b-cut    a-code    cy-length    bt-str-no
11502601 815010000     0      4100      1   1.364016     1
11502602 815010000     0      4100      1   1.364016     2
11502603 815010000     0      4100      1   1.169157     3
11502604 815010000     0      4100      1   1.169157     4
11502605 815010000     0      4100      1   1.169157     5
11502606 815010000     0      4100      1   1.364016     6
*
*source    type    is-nplr    l-dr-bit    r-dr-bit    bt-str-no
11502701     10225   .122878      0       0       1
11502702     10225   .122878      0       0       2
11502703     10225   .105342      0       0       3
11502704     10225   .105342      0       0       4
11502705     10225   .105342      0       0       5
11502706     10225   .122878      0       0       6
*
*l-h-st    chf-btr    by-dia    b-eq-dia    ch-length    bt-str-no
11502801     0       0.0   0.129489   12.0       6
11502801 0.129489 10.0 10.0 0 0 0 0 1.0 6
*
*l-h-st    chf-btr    by-dia    b-eq-dia    ch-length    bt-str-no
11502901     0       0.0   0.0       0.0   12.0       6
11502901 0.0 10.0 10.0 0 0 0 0 1.0 6
*
*****
```

* 11610801 0 0.0 0.173513 1.0083 1
 * 11610801 0.173513 10.0 10.0 0 0 0 0 1.0 1
 *
 * r-h-st chf-htr by-dia b-eq-dia ch-length ht-str-no
 * 11610901 0 0.0 0.0 1.0083 1
 * 11610901 0.0 10.0 10.0 0 0 0 0 1.0 1
 *
 * vessel upper plenum wall - unheated
 *
 * left boundary = components 162,163,164
 * right boundary = ambient volume (805)
 *
 * gl data nh np type s-flg l-cor
 11600000 3 13 -2 1 0.133854
 *
 * mesh loc flg frm flg
 11600100 0 1
 *
 * geometry no itv r-cor no itv r-cor no itv r-cor
 11600101 2 0.142184 1 0.146351 3 .200518
 11600102 4 0.422392 2 0.589059
 *
 * materials cmp no itv no cmp no itv no cmp no itv no
 11600201 1 2 2 3 1 5
 11600302 1 10 8 12
 *
 * source dis source itv no
 11600301 0.0 12
 *
 * init temp flg
 11600400 0
 *
 * temp mesh temp mesh temp mesh temp mesh temp mesh
 11600401 600.0 3 270.0 4 265.0 5 260.0 7 245.0 9
 11600402 232.0 11 188.0 12 150.0 13
 *
 * source dis source itv no source itv no
 11611301 0.0 11 1.0 13 0.0 15
 *
 * init temp flg
 11611400 0
 *
 * temp mesh temp mesh temp mesh temp mesh temp mesh
 11611401 609.7 3 376.5 6 360.8 9 309.5 11 315.1 13
 11611402 313.1 14 238.5 15 178.0 16
 *
 * 1-body by-vol inc b-cut a-code cy-length ht-str-no
 11611501 161010000 0 1 1 0.236729 1
 *
 * 1-body by-vol inc b-cut a-code cy-length ht-str-no
 11611601 815010000 0 4100 1 0.236729 1
 *
 * source type is-mlr 1-dr-ht r-dr-ht ht-str-no
 11611701 1025 .043539 0 0 1
 *
 * 1-h-st chf-htr by-dia b-eq-dia ch-length ht-str-no
 * 11611801 0 0.0 0.173513 1.0083 1
 * 11611801 0.173513 10.0 10.0 0 0 0 0 1.0 1
 *
 * r-h-st chf-htr by-dia b-eq-dia ch-length ht-str-no
 * 11611901 0 0.0 0.0 1.0083 1
 * 11611901 0.0 10.0 10.0 0 0 0 0 1.0 1
 *
 * vessel upper plenum wall - external heaters
 *

* upper core support plate (separates upper plenum and upper head) *

* left boundary = components 162,163,164
 * right boundary = ambient volume (815)
 *
 *gl data nb np type s-flg l-cor
 11601000 3 16 2 1 0.133854
 *
 *mesh loc flg frm flg
 11601100 0 1
 *
 *geometry no itv r-cor no itv r-cor no itv r-cor
 11601101 2 0.142184 1 0.146351 3 0.209518
 11601102 4 0.422392 1 0.422492 2 0.432987
 11601103 2 0.5995754
 *
 *materials cap no itv no cap no itv no cap no itv no
 11601201 1 2 2 3 1 6
 11601202 1 10 13 11 9 13
 11601203 8 15
 *
 *source dis source itv no source itv no source itv no
 11601301 0.0 11 1.0 13 0.0 15
 *
 *init temp flg
 11601400 0
 *
 * temp mesh temp mesh temp mesh temp mesh temp mesh
 11601401 600.0 3 275.0 4 267.4 7 283.7 10 260.0 13
 11601402 264.2 14 200.3 15 155.0 16
 *
 *l-body by-vol inc b-cdt a-code cy-length ht-str-no
 11601501 162010000 0 1 1 1.004785 1
 11601502 163010000 0 1 1 1.004785 2
 11601503 164010000 0 1 1 0.753589 3
 *
 *r-body by-vol inc b-cdt a-code cy-length ht-str-no
 11601601 815010000 0 4100 1 1.004785 1
 11601602 815010000 0 4100 1 1.004785 2
 11601603 815010000 0 4100 1 0.753589 3
 *
 *source type is-splir l-dr-bt r-dr-bt ht-str-no
 11601701 10217 .500072 0 0 1
 11601702 10217 .499928 0 0 2
 11601703 10212 1.0 0 0 3
 *
 *l-b-st chf-btr by-dia b-eq-dia ch-length ht-str-no
 11601801 0 0.0 0.201536 2.760833 1
 11601801 0.201536 10.0 10.0 0 0 0 0 1.0 1
 *11601802 0 0.0 0.244660 2.416657 2
 11601802 0.244660 10.0 10.0 0 0 0 0 1.0 2
 *11601803 0 0.0 0.255926 2.550000 3
 11601803 0.255926 10.0 10.0 0 0 0 0 1.0 3
 *
 *r-b-st chf-btr by-dia b-eq-dia ch-length ht-str-no
 *11601901 0 0.0 0.0 0.0 0.0 3
 11601901 0.0 10.0 10.0 0 0 0 0 1.0 3
 *

* upper core support plate (separates upper plenum and upper head) *

*
 * left boundary = component 164
 * right boundary = component 191
 *
 *gl data nb np type s-flg l-cor
 11690000 1 4 -1 1 0.0
 *
 *mesh loc flg frm flg
 11690100 0 1
 *
 *geometry no itv r-cor no itv r-cor no itv r-cor
 11690101 3 0.654
 *
 *materials cap no itv no
 11690201 1 3
 *
 *source dis source itv no
 11690301 0.0 3
 *
 *init temp flg
 11690400 0
 *
 * temp mesh temp mesh temp mesh temp mesh
 11690401 602.9 1 611.9 2 612.0 3 611.2 4
 *
 *l-body by-vol inc b-cdt a-code surf-area ht-str-no
 11690501 164010000 0 1 1 0.1263155 1
 *
 *r-body by-vol inc b-cdt a-code surf-area ht-str-no
 11690601 191010000 0 1 1 0.1263155 1
 *
 *source type is-splir l-dr-bt r-dr-bt ht-str-no
 11690701 0 0 0 0 0 0 0 0 1
 *
 *l-b-st chf-btr by-dia b-eq-dia ch-length ht-str-no
 *11690801 0 0.0 0.0 0.0 0.0 1
 11690801 0.0 10.0 10.0 0 0 0 0 1.0 1
 *
 *r-b-st chf-btr by-dia b-eq-dia ch-length ht-str-no
 *11690901 0 0.0 0.0 0.0 0.0 1
 11690901 0.0 10.0 10.0 0 0 0 0 1.0 1
 *

* vessel upper head wall - top & bottom - unheated *

*
 * left boundary = components 191 & 194
 * right boundary = ambient volume (805)
 *
 *gl data nb np type s-flg l-cor
 11901000 2 13 2 1 0.133854
 *
 *mesh loc flg frm flg
 11901100 0 1
 *
 *geometry no itv r-cor no itv r-cor no itv r-cor

11901101	2	0.142184	1	0.146351	3	0.200518				
11901102	4	0.34834	2	0.5151007						
*										
*materials	cmp no	itv no	cmp no	itv no	cmp no	itv no				
11901201	1	2	2	3	1	6				
11901202	1	10	8	12						
*										
*source dis	source	itv no								
11901301	0.0	12								
*										
*init temp	flg									
11901400	0									
*										
*temp mesh	temp mesh	temp mesh	temp mesh	temp mesh	temp mesh	temp mesh				
11901401	577.5	3	276.9	4	271.0	6	263.0	8	259.9	11
11901402	197.7	12	155.3	13						
*										
*l-body	by-vol	inc	b-cdt	a-code	cy-length	bt-str-no				
11901501	191010000	0	1	1	0.172152	1				
11901502	193010000	0	1	1	2.429058	2				
*										
*r-body	by-vol	inc	b-cdt	a-code	cy-length	bt-str-no				
11901601	805010000	0	4100	1	0.172152	1				
11901602	805010000	0	4100	1	2.429058	2				
*										
*source	type	is-splc	l-dr-ht	r-dr-ht	bt-str-no					
11901701	0	0	0	0	2					
*										
*l-h-st	chf-htr	by-dia	b-eq-dia	ch-length	bt-str-no					
11901801	0	0.0	0.209097	8.776667	1					
11901801	0.209097	10.0	10.0	0 0 0 0	1.0	1				
*										
11901802	0	0.0	0.255470	8.776667	2					
11901802	0.255470	10.0	10.0	0 0 0 0	1.0	2				
*										
*r-h-st	chf-htr	by-dia	b-eq-dia	ch-length	bt-str-no					
11901901	0	0.0	0.0	8.776667	2					
11901901	0.0	10.0	10.0	0 0 0 0	1.0	2				
*										
* vessel upper head wall - middle - unheated										

*										
* left boundary = components 192 & 193										
* right boundary = ambient volume (815)										
*										
*gl data	nh	np	type	s-flg	l-cor					
11902000	2	13	2	1	0.133854					
*										
*mesh	loc flg	frm flg								
11902100	0	1								
*										
*geometry	no itv	r-cor	no itv	r-cor	no itv	r-cor				
11902101	2	0.142184	1	0.146351	3	0.200518				
11902102	4	0.274476	2	0.441143						
*										
*materials	cmp no	itv no	cmp no	itv no	cmp no	itv no				
11902201	1	2	2	3	1	6				
11902202	1	10	8	12						
*										
*source dis	source	itv no	source	itv no	source	itv no				
11903301	0.0	11	1.0	13	0.0	15				

```

*init temp flg
11903400 0

*
*      temp mesh   temp mesh   temp mesh   temp mesh   temp mesh
11903401 573.1 3 295.6 4 292.0 5 289.0 6 286.8 7
11903402 284.0 10 288.0 11 297.5 12 301.7 13 299.0 14
11903403 221.6 15 166.4 16

*
*:l-body by-vol inc b-cdt a-code cy-length lt-str-no
11903501 192010000 0 1 1 0.386557 1
11903502 193010000 0 1 1 0.966417 2

*
*:r-body by-vol inc b-cdt a-code cy-length lt-str-no
11903601 815010000 0 4100 1 0.386557 1
11903602 815010000 0 4100 1 0.966417 2

*
*:source type is-wplr l-dr-bit r-dr-bit lt-str-no
11903701 10208 .166667 0 0 1
11903702 10208 .416667 0 0 2

*
*:l-h-st chf-btr by-dia b-eq-dia ch-length lt-str-no
11903801 0 0.0 0.222013 8.776667 1
11903801 0.222013 10.0 10.0 0 0 0 0 1.0 1
*:l11903802 0 0.0 0.222473 8.776667 2
11903802 0.222473 10.0 10.0 0 0 0 0 1.0 2

*
*:r-h-st chf-btr by-dia b-eq-dia ch-length lt-str-no
11903901 0 0.0 0.0 0.0 0.0 2
11903901 0.0 10.0 10.0 0 0 0 0 1.0 2

*
***** vessel upper head wall - top & bottom - external heaters *****
*
*: left boundary = components 191 & 194
*: right boundary = ambient volume (815)
*
*:gl data nb np type s-flg l-cor
11904000 2 16 2 1 0.133854

*
*:mesh loc flg frm flg
11904100 0 1

*
*:geometry no itv r-cor no itv r-cor no itv r-cor
11904101 2 0.142184 1 0.146351 3 0.200518
11904102 4 0.348434 1 0.348534 2 0.3589507
11904103 2 0.5256174

*
*:materials cmp no itv no cmp no itv no cmp no itv no
11904201 1 2 2 3 1 6
11904202 1 10 13 11 9 13
11904203 8 15

*
*:source dis source itv no source itv no source itv no
11904301 0.0 11 1.0 13 0.0 15

*
*:init temp flg
11904400 0

*      temp mesh   temp mesh   temp mesh   temp mesh   temp mesh
11904401 575.9 3 282.0 4 278.1 5 274.8 6 271.7 7
11904402 262.0 10 264.6 11 275.4 12 280.4 13 278.4 14
11904403 209.0 15 159.9 16

*
*:l-body by-vol inc b-cdt a-code cy-length lt-str-no
11904501 191010000 0 1 1 0.304515 1
11904502 194010000 0 1 1 0.455772 2

*
*:r-body by-vol inc b-cdt a-code cy-length lt-str-no
11904601 815010000 0 4100 1 0.304515 1
11904602 815010000 0 4100 1 0.455772 2

*
*:source type is-wplr l-dr-bit r-dr-bit lt-str-no
11904701 10208 .166667 0 0 1
11904702 10208 .250000 0 0 2

*
*:l-h-st chf-btr by-dia b-eq-dia ch-length lt-str-no
11904801 0 0.0 0.209097 8.776667 1
11904801 0.209097 10.0 10.0 0 0 0 0 1.0 1
*:l11904802 0 0.0 0.255470 8.776667 2
11904802 0.255470 10.0 10.0 0 0 0 0 1.0 2

*
*:r-h-st chf-btr by-dia b-eq-dia ch-length lt-str-no
11904901 0 0.0 0.0 0.0 8.776667 2
11904901 0.0 10.0 10.0 0 0 0 0 1.0 2

*
*
***** heat slab... steam generator tube bundle (intact loop) *****
*: rising primary coolant...first half of r-tube *****
*
*: left boundary = steam generator primary coolant (component 220)
*: right boundary = steam generator secondary coolant (component 600)
*
*:gl data nb np type s-flg l-cor
12200000 4 5 2 1 0.032375

*
*:mesh loc flg frm flg
12200100 0 1

*
*:geometry no itv r-cor
12200101 4 0.036453333

*
*:materials cmp no itv no
12200201 5 4

*
*:source dis source itv no
12200301 0.0 4

*
*:init temp flg
12200400 -1

*
*:temp distribution
12200401 575.9 555.1 554.5 544.2 534.2

```

12201402 557.9 558.9 550.1 541.6 533.3
 12201403 551.0 553.5 546.3 541.6 533.3
 12201404 556.5 550.3 544.3 538.4 532.7
 *
 * l-body by-vol inc b-cut a-code cy-length bt-str-no
 12201501 220010000 0 1 1 47.715000 1
 12201502 220020000 10000 1 1 47.465000 3
 12201503 220040000 0 1 1 40.152175 4
 *
 * r-body by-vol inc b-cut a-code cy-length bt-str-no
 12201601 600010000 0 1 1 47.715000 1
 12201602 600020000 10000 1 1 47.465000 3
 12201603 600040000 0 1 1 40.152175 4
 *
 * source type is-splc l-dr-bit r-dr-bit bt-str-no
 12201701 0 0 0 0 0 0 0 0 4
 *
 * l-b-st chf-htr by-dia b-eq-dia ch-length bt-str-no
 12201801 0 0.064750 0.064750 29.5 4
 12201801 0.064750 10.0 10.0 0 0 0 0 1.0 4
 *
 * r-b-st chf-htr by-dia b-eq-dia ch-length bt-str-no
 12201901 0 .0887292 .3115210 29.5 3
 12201901 0.3115210 10.0 10.0 0 0 0 0 1.0 3
 12201902 0 .1077433 .4104615 29.5 4
 12201902 0.4104615 10.0 10.0 0 0 0 0 1.0 4
 *
 * heat slab... steam generator tube bundle (intact loop)
 * (decreasing primary coolant...second half of w-tube)
 *
 * left boundary = steam generator primary coolant (component 220)
 * right boundary = steam generator secondary coolant (component 600)
 *
 * gl data nh np type s-flg l-cor
 12201000 4 5 2 1 0.032375
 *
 * mesh loc flg frm flg
 12201100 0 1
 *
 * geometry no itv r-cor
 12201101 4 0.036458333
 *
 * materials cmp no itv no
 12201201 5 4 * inconel 600
 *
 * source dis source itv no
 12201301 0.0 4
 *
 * init temp flg
 12201400 -1
 *
 * temp distribution
 12201401 551.9 546.5 541.2 538.4 532.7
 12201402 546.5 541.7 537.0 532.5 528.1
 12201403 542.2 538.1 534.1 530.2 526.4
 12201404 538.5 535.0 531.5 528.3 525.1
 *
 * l-body by-vol inc b-cut a-code cy-length bt-str-no
 12201501 220050000 0 1 1 40.152175 1
 12201502 220060000 10000 1 1 47.465000 3
 12201503 220080000 0 1 1 47.715000 4
 *
 * r-body by-vol inc b-cut a-code cy-length bt-str-no
 12201601 600090000 0 -1 1 40.152175 1
 12201602 600030000 0 1 1 47.465000 2
 12201603 600020000 0 1 1 47.465000 3
 12201604 600010000 0 1 1 47.715000 4
 *
 * source type is-splc l-dr-bit r-dr-bit bt-str-no
 12201701 0 0 0 0 0 0 0 0 4
 *
 * l-b-st chf-htr by-dia b-eq-dia ch-length bt-str-no
 12201801 0 0.064750 0.064750 29.5 4
 12201801 0.064750 10.0 10.0 0 0 0 0 1.0 4
 *
 * r-b-st chf-htr by-dia b-eq-dia ch-length bt-str-no
 12201901 0 .1077433 .4104615 29.5 1
 12201901 0.4104615 10.0 10.0 0 0 0 0 1.0 1
 12201902 0 .0887292 .3115210 29.5 4
 12201902 0.3115210 10.0 10.0 0 0 0 0 1.0 4
 *
 * beat slab... intact loop st. generator heat transfer from
 * the riser to the downcomer
 *
 * left boundary = component 600
 * right boundary = component 602 & 603
 *
 * gl data nh np type s-flg l-cor
 16000000 5 6 2 1 .2680135
 *
 * mesh loc flg frm flg
 16000100 0 1
 *
 * geometry no itv r-cor
 16000101 2 .3537825 1 .3655038 2 .3782030
 *
 * materials cmp no itv no cmp no itv no cmp no itv no
 16000201 14 2 15 3 1 5
 *
 * source dis source itv no
 16000301 0.0 5
 *
 * init temp flg
 16000400 0
 *
 * temp mesh temp mesh temp mesh temp mesh temp mesh
 16000401 514.0 1 522.3 2 503.2 3 501.8 4 501.7 5
 16000402 501.3 6
 *
 * l-body by-vol inc b-cut a-code cy-length bt-str-no
 16000501 600010000 0 1 1 7.9525000 1
 16000502 600020000 10000 1 1 7.9108334 3

16000503 60004000 0 1 1 7.4762500 4 *
 16000504 60005000 0 1 1 1.4054167 5
 *
 *r-body by-vol inc b-cut a-code cy-length ht-str-no
 16000601 603040000 0 1 1 7.9525000 1
 16000602 603030000 0 1 1 7.9108334 2
 16000603 603020000 0 1 1 7.9108334 3
 16000604 603010000 0 1 1 7.4762500 4
 16000605 602010000 0 1 1 1.4054167 5
 *
 *source type is-mlr l-dr-ht r-dr-ht ht-str-no
 16100701 0 0 0 0 5
 *
 *l-h-st chf-htr by-dia b-eq-dia ch-length ht-str-no
 *16000801 0 .0884737 .2535283 7.9525000 1
 16000801 0.2535283 10.0 10.0 0 0 0 0 1.0 1
 *16000802 0 .0884737 .2535283 7.9108334 3
 16000802 0.2535283 10.0 10.0 0 0 0 0 1.0 3
 *16000803 0 .1058911 .2728316 7.4762500 4
 16000803 0.2728316 10.0 10.0 0 0 0 0 1.0 4
 *16000804 0 .2145338 .3379099 1.4054167 5
 16000804 0.3379099 10.0 10.0 0 0 0 0 1.0 5
 *r-h-st chf-htr by-dia b-eq-dia ch-length ht-str-no
 *16000901 0 .0201639 .0732836 7.9525000 1
 16000901 0.0732836 10.0 10.0 0 0 0 0 1.0 1
 *16000902 0 .0126881 .0518749 7.9108334 3
 16000902 0.0518749 10.0 10.0 0 0 0 0 1.0 3
 *16000903 0 .0128227 .0523927 7.4762500 4
 16000903 0.0523927 10.0 10.0 0 0 0 0 1.0 4
 *16000904 0 .3369291 .7902365 1.4054167 5
 16000904 0.7902365 10.0 10.0 0 0 0 0 1.0 5
 *

 * heat slab... steam dome heat loss to environment *
 * (includes upper section of downcomer) *

 *
 * left boundary = components 600, 601
 * right boundary = components 602
 *
 *gl data nh np type s-flg l-cor
 16100000 3 6 2 1 .5719167
 *
 *mesh loc flg frm flg
 16100100 0 1
 *
 *geometry no itv r-cor no itv r-cor
 16100101 2 0.750 3 1.000
 *
 *materials cmp no itv no cmp no itv no
 16100201 1 2 17 5
 *
 *source dis source itv no
 16100301 0.0 5
 *
 *init temp flg
 16100400 0
 *
 *temp mesh temp mesh temp mesh temp mesh
 16100401 519.1 1 501.3 2 488.0 3
 *
 *l-body by-vol inc b-cut a-code cy-length ht-str-no

16001501	600050000	0	1	1	3.5802339	1								
16001502	601010000	0	1	1	0.4375000	2								
*														
*r-body	by-vol	inc	b-cut	a-code	cy-length	bt-str-no								
16001501	602010000	0	1	1	3.5802339	1								
16001502	602010000	0	1	1	0.4375000	2								
*														
*source	type	is-spl	l-dr-bit	r-dr-bit	bt-str-no									
16001701		0	0	0	0	2								
*														
*l-b-st	chf-btr	by-dia	b-eq-dia	ch-length	bt-str-no									
*16001801	0	.7332265	.8251205	3.7504157	1									
16001801	0.8251205	10.0	10.0	0	0	0	1.0	1						
*16001802	0	.8683333	.8683333	0.4375000	2									
16001802	0.8683333	10.0	10.0	0	0	0	1.0	2						
*														
*r-b-st	chf-btr	by-dia	b-eq-dia	ch-length	bt-str-no									
*16001901	0	.3369291	.7902365	3.7504157	1									
16001901	0.7902365	10.0	10.0	0	0	0	1.0	1						
*16001902	0	.3369291	.7902365	0.4375000	2									
16001902	0.7902365	10.0	10.0	0	0	0	1.0	2						
*														
*****heat slab... intact loop steam generator downcomer fillers*****														
*														
* left boundary = component 602, 603														
* right boundary = components 602, 603														
*														
*gl data	nh	np	type	s-flg	l-cor									
16031000	5	3	2	1	.3645833									
*														
*mesh	loc flg	frc flg												
16031100	0	1												
*														
*geometry	no itv	r-cor												
16031101	2	.3958333												
*														
*materials	cpr no	itv no												
16031201	1	2												
*														
*source dis	source	itv no												
16031301	0.0	2												
*														
*init temp	flg													
16031400	0													
*														
* temp mesh	temp mesh	temp mesh												
16031401	524.5	1	528.7	2	517.9	3								
*														
*l-body	by-vol	inc	b-cut	a-code	cy-length	bt-str-no								
16031501	602010000	0	1	1	1.1902317	1								
16031502	603010000	0	1	1	6.3953472	2								
16031503	603020000	0	1	1	6.7681575	3								
16031504	603030000	0	1	1	6.7681575	4								
16031505	603040000	0	1	1	5.3422315	5								
*														
*r-body	by-vol	inc	b-cut	a-code	cy-length	bt-str-no								
16031601	602010000	0	1	1	1.1902317	1								
16031602	603010000	0	1	1	6.3953472	2								
16031603	603020000	0	1	1	6.7681575	3								
16031604	603030000	0	1	1	6.7681575	4								
16031605	603040000	0	1	1	5.3422315	5								
*														
*source	type	is-spl	l-dr-bit	r-dr-bit	bt-str-no									
16031701		0	0	-0	0	5								
*														
*l-b-st	chf-btr	by-dia	b-eq-dia	ch-length	bt-str-no									
*16031801	0	.3369291	.7902365	1.3912500	1									
16031801	0.7902365	10.0	10.0	0	0	0	1.0	1						
*16031802	0	.0128227	.0523927	7.4762500	2									
16031802	0.0523927	10.0	10.0	0	0	0	1.0	2						
*16031803	0	.0126981	.0518749	7.9108334	3									
16031803	0.0518749	10.0	10.0	0	0	0	1.0	3						
*16031804	0	.0126981	.0518749	7.9108334	4									
16031804	0.0518749	10.0	10.0	0	0	0	1.0	4						
*16031805	0	.0126981	.0518749	6.2441667	5									
16031805	0.0518749	10.0	10.0	0	0	0	1.0	5						
*														
*l-b-st	chf-btr	by-dia	b-eq-dia	ch-length	bt-str-no									
*16031901	0	.3369291	.7902365	1.3912500	1									
16031901	0.7902365	10.0	10.0	0	0	0	1.0	1						
*16031902	0	.0128227	.0472456	7.4762500	2									
16031902	0.0472456	10.0	10.0	0	0	0	1.0	2						
*16031903	0	.0126981	.0467818	7.9108334	3									
16031903	0.0467818	10.0	10.0	0	0	0	1.0	3						
*16031904	0	.0126981	.0467818	7.9108334	4									
16031904	0.0467818	10.0	10.0	0	0	0	1.0	4						
*16031905	0	.0126981	.0467818	6.2441667	5									
16031905	0.0467818	10.0	10.0	0	0	0	1.0	5						
*														
*gl data	nh	np	type	s-flg	l-cor									
16030000	4	6	2	1	.3985000									
*														
*mesh	loc flg	frc flg												
16030100	0	1												
*														
*geometry	no itv	r-cor	no itv	r-cor										
16030101	2	.4479167	3	.6979167										
*														
*materials	cpr no	itv no	cpr no	itv no										
16030201	1	2	17	5										
*														
*source dis	source	itv no												
16030301	0.0	5												
*														
*init temp	flg													
16030400	0													

* temp mesh temp mesh temp mesh temp mesh temp mesh
 16030401 514.1 1 514.0 2 513.9 3 369.0 4 232.0 5
 16030402 95.3 6

* l-body by-vol inc b-cdt a-code cy-length ht-str-no
 16030501 603010000 0 1 1 7.4762500 1
 16030502 603020000 0 1 1 7.9108334 2
 16030503 603030000 0 1 1 7.9108334 3
 16030504 603040000 0 1 1 7.9525000 4

* r-body by-vol inc b-cdt a-code cy-length ht-str-no
 16030601 800010000 0 4100 1 7.4762500 1
 16030602 800010000 0 4100 1 7.9108334 3
 16030603 800010000 0 4100 1 7.9525000 4

* source type is-mlr l-dr-bt r-dr-bt ht-str-no
 16030701 0 0 0 0 4

* l-b-st chf-htr by-dia b-eq-dia ch-length ht-str-no
 16030801 9 .0128227 .0472456 7.4762500 1
 16030801 0.0472456 10.0 10.0 0 0 0 0 1.0 1
 16030802 0 .0126981 .0467818 7.9108334 2
 16030802 0.0467818 10.0 10.0 0 0 0 0 1.0 2
 16030803 0 .0126981 .0467818 7.9108334 3
 16030803 0.0467818 10.0 10.0 0 0 0 0 1.0 3
 16030804 0 .0201639 .0657482 7.9525000 4
 16030804 0.0657482 10.0 10.0 0 0 0 0 1.0 4

* r-b-st chf-htr by-dia b-eq-dia ch-length ht-str-no
 16030901 0 0.0 0.0 0.0 0.0 4
 16030901 0.0 10.0 10.0 0 0 0 0 1.0 4

 * heat slab... steam generator tube bundle (broken loop)
 * (rising primary coolant...first half of u-tubes)

* left boundary = steam generator primary coolant (component 320)
 * right boundary = steam generator secondary coolant (component 700)

* gl data nb np type s-flg l-cor
 13200000 5 5 2 1 0.0310417

* mesh loc fig frm fig
 13201100 0 1

* geometry no itv r-cor
 13201101 4 0.0364583

* materials cmp no itv no
 13201201 5 4 *inconel 600

* source dis source itv no
 13201301 0.0 4

* init temp flg
 13201400 -1

* temp distribution
 13200401 579.0 569.2 559.6 550.3 541.2
 13200402 575.0 566.0 552.3 548.8 540.5
 13200403 570.9 562.8 554.9 547.2 539.7
 13200404 567.5 560.1 552.9 545.9 539.0
 13200405 564.1 557.4 550.9 544.5 538.3

* l-body by-vol inc b-cdt a-code cy-length ht-str-no
 13200501 320010000 0 1 1 2.1666667 1
 13200502 320010000 0 1 1 13.4166667 2
 13200503 320020000 10000 1 1 15.0000000 4
 13200504 320040000 0 1 1 15.0856194 5

* r-body by-vol inc b-cdt a-code cy-length ht-str-no
 13200601 710010000 0 1 1 2.1666667 1
 13200602 700010000 0 1 1 13.4166667 2
 13200603 700020000 10000 1 1 15.0000000 4
 13200604 700040000 0 1 1 15.0856194 5

* source type is-mlr l-dr-bt r-dr-bt ht-str-no
 13200701 0 0 0 0 5

* l-b-st chf-htr by-dia b-eq-dia ch-length ht-str-no
 13200801 0 .0620833 .0620833 0.0 5
 13200801 0.0620833 10.0 10.0 0 0 0 0 1.0 5

* r-b-st chf-htr by-dia b-eq-dia ch-length ht-str-no
 13200901 0 .0653945 .2900678 0.0 4
 13200901 0.2900678 10.0 10.0 0 0 0 0 1.0 4
 13200902 0 .0753070 .3067184 0.0 5
 13200902 0.3067184 10.0 10.0 0 0 0 0 1.0 5

 * heat slab... steam generator tube bundle (broken loop)
 * (descending primary coolant...second half of u-tubes)

* left boundary = steam generator primary coolant (component 320)
 * right boundary = steam generator secondary coolant (component 700)

* gl data nb np type s-flg l-cor
 13201000 5 5 2 1 0.0310417

* mesh loc fig frm fig
 13201100 0 1

* geometry no itv r-cor
 13201101 4 0.0364583

* materials cmp no itv no
 13201201 5 4 *inconel 600

* source dis source itv no
 13201301 0.0 4

* init temp flg
 13201400 -1

```

*temp distribution
13201401 554.5 549.6 544.9 540.3 535.8
13201402 552.4 547.9 543.6 539.4 535.3
13201403 550.2 545.2 542.2 538.4 534.7
13201404 548.4 544.7 541.1 537.6 534.2
13201405 546.6 543.2 540.0 536.8 533.7

*1-body by-vol inc b-cut a-code cy-length bt-str-no
13201501 320050000 0 1 1 15.0856194 1
13201502 320060000 10000 1 1 15.0000000 3
13201503 320080000 0 1 1 13.4166667 4
13201504 320080000 0 1 1 2.1666667 5

*x-body by-vol inc b-cut a-code cy-length bt-str-no
13201601 70040000 0 1 1 15.0856194 1
13201602 70030000 -10000 1 1 15.0000000 3
13201603 700010000 0 1 1 13.4166667 4
13201604 715010000 0 1 1 2.1666667 5

*source type is-splir l-dr-bit r-dr-bit bt-str-no
13201701 0 0 0 0 5

*1-h-st chf-htr by-dia b-eq-dia ch-length bt-str-no
13201801 0 .0620833 .0620833 0.0 5
13201801 0.0620833 10.0 10.0 0 0 0 0 1.0 5

*x-h-st chf-htr by-dia b-eq-dia ch-length bt-str-no
13201901 0 .0753070 .3067184 0.0 1
13201901 0.3067184 10.0 10.0 0 0 0 0 1.0 1
13201902 0 .0635845 .2900678 0.0 5
13201902 0.2900678 10.0 10.0 0 0 0 0 1.0 5

*****heat slab... broken loop st. generator secondary riser heat loss to the environment (includes upper section of riser and separator)
*****left boundary = component 700 & 716
*****right boundary = ambient volume (809)

*gl data nh np type s-flg l-cor
17000000 6 5 2 1 .1278333

*mesh loc flg frm flg
17000100 0 1

*geometry no itv r-cor no itv r-cor
17000101 2 .4479167 2 .6145834

*materials cmp no itv no cmp no itv no
17000201 1 2 32 4

*source dis source itv no
17000301 0.0 4

*init temp flg
17000400 0

*temp mesh temp mesh temp mesh temp mesh temp mesh
17000401 519.1 1 501.3 2 488.9 3 320.6 4 94.1 5

*1-body by-vol inc b-cut a-code cy-length bt-str-no
17000501 70001000 0 1 1 6.7083333 1
17000502 70002000 10000 1 1 1 7.5000000 4
17000503 70005000 0 1 1 6.8229167 5

```

17000504 716010000 0 1 1 1.0833333 6
 *
 *r-body by-vol inc b-cdt a-code cy-length bt-str-no
 17000601 809010000 0 4500 1 6.7083333 1
 17000602 809010000 0 4500 1 7.5000000 4
 17000603 809010000 0 4500 1 6.8229167 5
 17000604 809010000 0 4500 1 1.0833333 6
 *
 *source type is-splr l-dr-bit r-dr-bit bt-str-no
 17000701 0 0 0 0 6
 *
 *l-b-st chf-htr by-dia b-eq-dia ch-length bt-str-no
 *17000801 0 .0653845 .1654559 0.0 3
 17000801 0.1654559 10.0 10.0 0 0 0 1.0 3
 *17000802 0 .0753070 .1729521 0.0 4
 17000802 0.1729521 10.0 10.0 0 0 0 1.0 4
 *17000803 0 .1934227 .2385353 0.0 5
 17000803 0.2385353 10.0 10.0 0 0 0 1.0 5
 *17000804 0 .0653845 .1654559 0.0 6
 17000804 0.1654559 10.0 10.0 0 0 0 1.0 6
 *
 *r-b-st chf-htr by-dia b-eq-dia ch-length bt-str-no
 *17000901 0 0.0 0.0 0.0 6
 17000901 0.0 10.0 10.0 0 0 0 1.0 6
 *
 * beat slab... broken loop st. generator downcomer
 * heat loss to the environment
 * left boundary = components 713, 714, & 715
 * right boundary = ambient volume (809)
 *
 *gl data nh np type s-flg l-cor
 17140000 7 5 2 1 .0575
 *
 *mesh loc flg frm flg
 17140100 0 1
 *
 *geometry no itv r-cor no itv r-cor
 17140101 2 .0691667 2 .2383334
 *
 *materials cap no itv no cap no itv no
 17140201 1 2 32 4
 *
 *source dis source itv no
 17140301 0.0 4
 *
 *init temp flg
 17140400 0
 *
 *temp mesh temp mesh temp mesh temp mesh temp mesh
 17140401 514.5 1 514.7 2 513.9 3 300.0 4 95.3 5
 *
 *l-body by-vol inc b-cdt a-code cy-length bt-str-no
 17140501 711010000 0 1 1 4.6776013 1
 *
 *r-body by-vol inc b-cdt a-code cy-length bt-str-no
 17140601 809010000 0 4500 1 4.5776013 1
 *
 *source type is-splr l-dr-bit r-dr-bit bt-str-no
 17140701 0 0 0 0 1
 *
 *l-b-st chf-htr by-dia b-eq-dia ch-length bt-str-no
 *17140801 0 .3983363 .3983363 0.0 1
 17140801 0.3983363 10.0 10.0 0 0 0 1.0 1
 *
 *r-b-st chf-htr by-dia b-eq-dia ch-length bt-str-no
 *17140901 0 0.0 0.0 0.0 1
 17140901 0.0 10.0 10.0 0 0 0 1.0 1
 *
 * beat slab... broken loop st. generator downcomer
 * heat loss to the environment
 * left boundary = components 713, 714, & 715
 * right boundary = ambient volume (809)
 *
 *gl data nh np type s-flg l-cor
 17140000 7 5 2 1 .0575
 *
 *mesh loc flg frm flg
 17140100 0 1
 *
 *geometry no itv r-cor no itv r-cor
 17140101 2 .0691667 2 .2383334
 *
 *materials cap no itv no cap no itv no
 17140201 1 2 32 4
 *
 *source dis source itv no
 17140301 0.0 4
 *
 *init temp flg
 17140400 0
 *
 *temp mesh temp mesh temp mesh temp mesh temp mesh
 17140401 514.1 1 514.0 2 513.9 3 300.0 4 95.3 5
 *
 *l-body by-vol inc b-cdt a-code cy-length bt-str-no
 17140501 713010000 0 1 1 3.1426389 1
 17140502 714010000 0 1 1 4.0891869 2
 17140503 714020000 10000 1 1 7.5000000 5
 17140504 714050000 0 1 1 7.4537703 6
 17140505 715010000 0 1 1 7.8734167 7
 *
 *r-body by-vol inc b-cdt a-code cy-length bt-str-no
 17140601 809010000 0 4500 1 3.1426389 1
 17140602 809010000 0 4500 1 4.0891869 2
 17140603 809010000 0 4500 1 7.5000000 5
 17140604 809010000 0 4500 1 7.4537703 6
 17140605 809010000 0 4500 1 7.8734167 7
 *
 *source type is-splr l-dr-bit r-dr-bit bt-str-no
 17140701 0 0 0 0 7

*
 *l-h-st chf-htr by-dia b-eq-dia ch-length ht-str-no
 *17149801 0 .1316182 .1316182 0.0 1
 17149801 0.1316182 10.0 10.0 0 0 0 0 1.0 1
 *17149802 0 .1150000 .1150000 0.0 6
 17149802 0.1150000 10.0 10.0 0 0 0 0 1.0 6
 *17149803 0 .1303373 .1303373 0.0 7
 17149803 0.1303373 10.0 10.0 0 0 0 0 1.0 7
 *
 *r-h-st chf-htr by-dia b-eq-dia ch-length ht-str-no
 *17149901 0 0.0 0.0 0.0 7
 17149901 0.0 10.0 10.0 0 0 0 0 1.0 7
 *
 * heat slab... il sg inlet-outlet plenum - middle trapezoidal section *

 * left boundary = components 210 & 230
 * right boundary = ambient volume (808)
 *
 *gl data nh np type s-flg l-cor
 12101000 2 10 2 1 .329989
 *
 *mesh loc flg frm flg
 12101100 0 1
 *
 *geometry no itv r-cor no itv r-cor
 12101101 7 .953333 2 1.125
 *
 *materials cmp no itv no cmp no itv no
 12101201 1 7 26 9
 *
 *source dis source itv no
 12101301 0.0 9
 *
 *init temp flg
 12101400 -1
 *
 *temp distribution
 12101401 606.0 603.0 600.0 597.0 594.0 591.0 588.0 585.0 582.0
 + 325.0 68.0
 12101402 540.0 537.0 534.0 531.0 528.0 525.0 522.0 519.0 516.0 292.0
 + 68.0
 *
 *l-body by-vol inc b-cut a-code cy-length ht-str-no
 12101501 21001000 0 1 1 0.078125 1
 12101502 23001000 0 1 1 0.078125 2
 *
 *r-body by-vol inc b-cut a-code cy-length ht-str-no
 12101601 80801000 0 4100 1 0.078125 1
 12101602 80801000 0 4100 1 0.078125 2
 *
 *source type is-nlpr l-dr-bt r-dr-bt ht-str-no
 12101701 0 0 0 0 2
 *
 *l-h-st chf-htr by-dia b-eq-dia ch-length ht-str-no
 *12101801 0 .2513333 .490904 0.145834 2
 12101801 0.2513333 10.0 10.0 0 0 0 0 1.0 2
 *
 *r-h-st chf-htr by-dia b-eq-dia ch-length ht-str-no
 *12101901 0 0.0 0.0 0.0 2
 12101901 0.0 10.0 10.0 0 0 0 0 1.0 2
 *
 * heat slab... il sg inlet-outlet plenum - bottom trapezoidal section *

```

* left boundary = components 210 & 230
* right boundary = ambient volume (803)
*
*gl data    nb    np    type   s-flg   l-cor
12102000      2      4      2       1     .243733
*
*mesh    loc flg   frm flg
12102100      0      1
*
*geometry    no itv    r-cor    no itv    r-cor
12102101      1     .333333      2      0.5
*
*materials   cmp no   itv no   cmp no   itv no
12102201      1      1      26      3
*
*source dis  source   itv no
12102301      0.0      3
*
*init temp   flg
12102400     -1
*
*temp distribution
12102401 606.0 582.0 325.0 80.0
12102402 540.0 516.0 292.0 80.0
*
*l-body    by-vol    inc   b-cdt   a-code   cy-length   bt-str-no
12102501 210010000      0      1      1     0.166667      1
12102502 230010000      0      1      1     0.166667      2
*
*r-body    by-vol    inc   b-cdt   a-code   cy-length   bt-str-no
12102601 808010000      0     4100      1     0.166667      1
12102602 808010000      0     4100      1     0.166667      2
*
*source    type  is-alpr   l-dr-bt   r-dr-bt   bt-str-no
12102701      0      0          0          0      2
*
*l-h-st    chf-btr   by-dia   b-eq-dia   ch-length   bt-str-no
12102801      0     .251333     .4800904     0.333334      2
12102801 0.4800904 10.0 10.0 0 0 0 0 1.0 2
*
*r-h-st    chf-btr   by-dia   b-eq-dia   ch-length   bt-str-no
12102901      0     0.0          0.0     0.333334      2
12102901 0.0 10.0 10.0 0 0 0 0 1.0 2
*
* heat slab... il sg plenum between up & dn stream trapezoidal section *
*****
* left boundary = component 210
* right boundary = component 230
*
*gl data    nb    np    type   s-flg   l-cor
12103000      1      4      1       1     0.0
*
*mesh    loc flg   frm flg
12103100      0      1
*
*geometry    no itv    r-cor
12103101            3     .095417
*
*materials   cmp no   itv no
12103201            1      3
*
*source dis  source   itv no
12103301      0.0      3
*
*init temp   flg
12103400     -1
*
*temp distribution
12103401 606.0 584.0 562.0 540.0
*
*l-body    by-vol    inc   b-cdt   a-code   surf-area   bt-str-no
12103501 210010000      0      1      0     0.102761      1
*
*r-body    by-vol    inc   b-cdt   a-code   surf-area   bt-str-no
12103601 230010000      0      1      0     0.102761      1
*
*source    type  is-alpr   l-dr-bt   r-dr-bt   bt-str-no
12103701      0      0          0          0      1
*
*l-h-st    chf-btr   by-dia   b-eq-dia   ch-length   bt-str-no
12103801      0     .325893     0.875000     0.156250      1
12103801 0.875000 10.0 10.0 0 0 0 0 1.0 1
*
*r-h-st    chf-btr   by-dia   b-eq-dia   ch-length   bt-str-no
12103901      0     .325893     0.875000     0.156250      1
12103901 0.875000 10.0 10.0 0 0 0 0 1.0 1
*****
* heat slab... il sg plenum between up & dn stream rectangular section *
*****
* left boundary = component 210
* right boundary = component 230
*
*gl data    nb    np    type   s-flg   l-cor
12104000      1      4      1       1     0.0
*
*mesh    loc flg   frm flg
12104100      0      1
*
*geometry    no itv    r-cor
12104101            3     .162398
*
*materials   cmp no   itv no
12104201            1      3
*
*source dis  source   itv no
12104301      0.0      3
*
*init temp   flg
12104400     -1
*
*temp distribution

```

12104901 606.0 589.0 562.0 540.0
 *
 *1-body by-vol inc b-cut a-code surf-area ht-str-no
 12104501 210010000 0 1 0 0.229152 1
 *
 *r-body by-vol inc b-cut a-code surf-area ht-str-no
 12104601 230010000 0 1 0 0.229152 1
 *
 *source type is-alpr l-dr-bit r-dr-bit ht-str-no
 12104701 0 0 0 0 0 1
 *
 *l-h-st chf-htr by-dia b-eq-dia ch-length ht-str-no
 *12104801 0 2513333 .5274709 0.479167 1
 12104901 0.5274709 10.0 10.0 0 0 0 0 1.0 1
 *
 *r-h-st chf-htr by-dia b-eq-dia ch-length ht-str-no
 *12104901 0 2513333 .5274709 0.479167 1
 12104901 0.5274709 10.0 10.0 0 0 0 0 1.0 1
 *

 * heat slabs... il sg tube sheet conical section - up(1), downstream(2)*

 *
 * left boundary = components 215 & 225
 * right boundary = ambient volume (808)
 *
 *gl data ab ap type s-flg l-cor
 12150000 2 14 2 1 .212031
 *
 *mesh loc flg fut flg
 12150100 0 1
 *
 *geometry no itv r-cor no itv r-cor no itv r-cor
 12150101 1 .216114 1 .216406 3 .447917
 12150102 1 .528545 5 .953033 2 1.12500
 *
 *materials cmp no itv no cmp no itv no cmp no itv no
 12150201 5 1 13 2 25 11
 12150202 26 13
 *
 *source dis source itv no
 12150301 0.0 13
 *
 *init temp flg
 12150400 -1
 *
 *temp distribution
 12150401 606.0 605.5 605.0 604.5 604.0 601.0 600.0 598.0 596.0
 * 594.0 592.0 590.0 589.0 589.0
 12150402 590.0 589.5 589.0 588.6 588.2 586.4 584.6 582.8 581.0
 * 582.2 581.4 581.6 581.6 580.0
 *
 *1-body by-vol inc b-cut a-code cy-length ht-str-no
 12150501 215010000 0 1 1 0.380208 1
 12150502 225010000 0 1 1 0.380208 2
 *
 *r-body by-vol inc b-cut a-code cy-length ht-str-no
 12150601 808010000 0 4100 1 0.380208 1
 12150602 808010000 0 4100 1 0.380208 2
 *
 *source type is-alpr l-dr-bit r-dr-bit ht-str-no
 12150701 0 0 0 0 0 2
 *
 *l-h-st chf-htr by-dia b-eq-dia ch-length ht-str-no
 *12150801 0 0.064750 0.120724 0.769417 2
 12150801 0.120724 10.0 10.0 0 0 0 0 1.0 2
 *
 *r-h-st chf-htr by-dia b-eq-dia ch-length ht-str-no
 *12150901 0 0.0 0.0 0.0 0.0 0.769417 2
 12150901 0.0 10.0 10.0 0 0 0 0 1.0 2
 *

 * heat slabs... il sg tube sheet conical section - up(1), downstream(2)*

 *
 * left boundary = components 215 & 225
 * right boundary = ambient volume (808)
 *
 *gl data ab ap type s-flg l-cor
 12151000 2 9 2 1 .212031
 *
 *mesh loc flg fut flg
 12151100 0 1
 *
 *geometry no itv r-cor no itv r-cor no itv r-cor
 12151101 1 .216114 1 .216406 3 .447917
 12151102 1 .528545 2 .695211
 *
 *materials cmp no itv no cmp no itv no cmp no itv no
 12151201 5 1 13 2 25 6
 12151202 26 8
 *
 *source dis source itv no
 12151301 0.0 8
 *
 *init temp flg
 12151400 -1
 *
 *temp distribution
 12151401 606.0 605.5 605.0 604.5 604.0 601.0 600.0 595.0 590.0 590.0 329.0 80.0
 12151402 590.0 589.5 589.0 588.6 588.2 586.4 584.6 582.8 581.0 580.0 580.0 296.6 80.0
 *
 *1-body by-vol inc b-cut a-code cy-length ht-str-no
 12151501 215010000 0 1 1 0.327925 1
 12151502 225010000 0 1 1 0.327925 2
 *
 *r-body by-vol inc b-cut a-code cy-length ht-str-no
 12151601 808010000 0 4100 1 0.327925 1
 12151602 808010000 0 4100 1 0.327925 2
 *
 *source type is-alpr l-dr-bit r-dr-bit ht-str-no
 12151701 0 0 0 0 0 2
 *
 *l-h-st chf-htr by-dia b-eq-dia ch-length ht-str-no
 *12151801 0 0.064750 0.120724 0.655849 2
 12151801 0.120724 10.0 10.0 0 0 0 0 1.0 2

```

* left boundary = component 215
* right boundary = component 225
*
*gl data      nh      np      type      s-flg      l-cor
12153000      1       4       1       1       0.0
*
*mesh      loc flg      fnt flg
12153100      0       1
*
*geometry      no itv      r-cor
12153101      3      .255117
*
*materials      cmp no      itv no
12153201      25      3
*
*source dis      source      itv no
12153301      0.0      3
*
*init temp      flg
12153400      -1
*
*temp distribution
12153401 606.0 584.0 562.0 540.0
*
*1-body      by-vol      inc      b-cdt      a-code      surf-area      ht-str-no
12153501 215010000      0       1       0      0.693957      1
*
*1-h-st      chf-btr      by-dia      b-eq-dia      ch-length      ht-str-no
12153601      0      0.064750      0.139552      1.75      1
12153601 0.139552 10.0 10.0 0 0 0 1.0 1
*
*1-h-st      chf-btr      by-dia      b-eq-dia      ch-length      ht-str-no
12153701      0      0.064750      0.139552      1.75      1
12153701 0.139552 10.0 10.0 0 0 0 1.0 1
*
*heat slab... bl sg inlet-outlet plenum - top rectangular section
*****
* left boundary = components 310 & 330
* right boundary = ambient volume (808)
*
*gl data      nh      np      type      s-flg      l-cor
13100000      2       10      2       1      .329960
*
*mesh      loc flg      fnt flg
13100100      0       1
*
*geometry      no itv      r-cor      bo itv      r-cor
13100101      7      .958003      2      1.125

```

*materials cmp no itv no cmp no itv no
 13100301 1 7 26 9
 *
 *source dis source itv no
 13100301 0.0 9
 *
 *init temp flg
 13100400 -1
 *
 *temp distribution
 13100401 606.0 600.0 597.0 594.0 591.0 588.0 585.0 582.0 325.0
 + 68.0
 13100402 540.0 534.0 531.0 528.0 525.0 522.0 519.0 516.0 292.0
 + 68.0
 *
 *l-body by-vol inc b-cut a-code cy-length bt-str-no
 13100501 310010000 0 1 1 0.078125 1
 13100502 330010000 0 1 1 0.078125 2
 *
 *r-body by-vol inc b-cut a-code cy-length bt-str-no
 13100601 808010000 0 4100 1 0.078125 1
 13100602 808010000 0 4100 1 0.078125 2
 *
 *source type is-alpr l-dr-ht r-dr-ht bt-str-no
 13100701 0 0 0 0 0 2
 *
 *l-h-st chf-htr by-dia h-eq-dia ch-length bt-str-no
 13100801 0 .3258603 .5192263 0.156250 2
 13100801 0.5192263 10.0 10.0 0 0 0 0 1.0 2
 *r-h-st chf-htr by-dia h-eq-dia ch-length bt-str-no
 13100901 0 0.0 0.0 0.0 0.156250 2
 13100901 0.0 10.0 10.0 0 0 0 0 1.0 2
 *
 **** heat slab... bl sg inlet-outlet plenum - bottom trapezoidal section *
 **** left boundary = components 310 & 330
 * right boundary = ambient volume (808)
 *
 *gl data nh np type s-flg l-cor
 13101000 2 11 2 1 .247205
 *
 *mesh loc flg fat flg
 13101100 0 1
 *
 *geometry no itv r-cor no itv r-cor no itv r-cor
 13101101 1 .333333 7 .958333 2 1.125
 *
 *materials cmp no itv no cmp no itv no
 13101201 1 8 26 10
 *
 *source dis source itv no
 13101301 0.0 10
 *
 *init temp flg
 13101400 -1
 *

*temp distribution
 13101501 606.0 600.0 597.0 594.0 591.0 588.0 585.0 582.0
 + 325.0 68.0
 13101502 540.0 537.0 534.0 531.0 528.0 525.0 522.0 519.0 516.0
 + 292.0 68.0
 *
 *l-body by-vol inc b-cut a-code cy-length bt-str-no
 13101501 310010000 0 1 1 0.072917 1
 13101502 330010000 0 1 1 0.072917 2
 *
 *r-body by-vol inc b-cut a-code cy-length bt-str-no
 13101601 808010000 0 4100 1 0.072917 1
 13101602 808010000 0 4100 1 0.072917 2
 *
 *source type is-alpr l-dr-ht r-dr-ht bt-str-no
 13101701 0 0 0 0 0 2
 *
 *l-h-st chf-htr by-dia h-eq-dia ch-length bt-str-no
 13101801 0 .2243822 .397532 0.145334 2
 13101801 0.397532 10.0 10.0 0 0 0 0 1.0 2
 *
 *r-h-st chf-htr by-dia h-eq-dia ch-length bt-str-no
 13101901 0 0.0 0.0 0.0 0.145334 2
 13101901 0.0 10.0 10.0 0 0 0 0 1.0 2
 *
 **** heat slab... bl sg inlet-outlet plenum - middle trapezoidal section *
 **** left boundary = components 310 & 330
 * right boundary = ambient volume (808)
 *
 *gl data nh np type s-flg l-cor
 13102000 2 4 2 1 .247205
 *
 *mesh loc flg fat flg
 13102100 0 1
 *
 *geometry no itv r-cor no itv r-cor
 13102101 1 .333333 2 0.5
 *
 *materials cmp no itv no cmp no itv no
 13102201 1 1 26 3
 *
 *source dis source itv no
 13102301 0.0 3
 *
 *init temp flg
 13102400 -1
 *
 *temp distribution
 13102501 606.0 582.0 325.0 80.0
 13102502 540.0 516.0 292.0 80.0
 *
 *l-body by-vol inc b-cut a-code cy-length bt-str-no
 13102501 310010000 0 1 1 0.250000 1
 13102502 330010000 0 1 1 0.250000 2
 *

*r-body by-vol inc b-cdt a-code cy-length bt-str-no
 13102601 808010000 0 4100 1 0.250000 1
 13102602 808010000 0 4100 1 0.250000 2
 *
 *source type is-nlpr l-dr-bt r-dr-bt bt-str-no
 13102701 0 0 0 0 2
 *
 *l-h-st chf-btr by-dia b-eq-dia ch-length bt-str-no
 *13102801 0 .2243822 .3974532 0.500000 2
 13102801 0.3974532 10.0 10.0 0 0 0 1.0 2
 *
 *r-h-st chf-btr by-dia b-eq-dia ch-length bt-str-no
 *13102901 0 0.0 0.0 0.500000 2
 13102901 0.0 10.0 10.0 0 0 0 1.0 2
 *

 * heat slab... bl sg plenum between up & dn stream trapezoidal section *

 * left boundary = component 310
 * right boundary = component 330
 *
 *gl data nh np type s-flg l-cor
 13103000 1 4 1 1 0.0
 *
 *mesh loc flg frm flg
 13103100 0 1
 *
 *geometry no itv r-cor
 13103101 3 .095333
 *
 *materials cmp no itv no
 13103201 1 3
 *
 *source dis source itv no
 13103301 0.0 3
 *
 *init temp flg
 13103400 -1
 *
 *temp distribution
 13103401 606.0 584.0 562.0 540.0
 *
 *l-body by-vol inc b-cdt a-code surf-area bt-str-no
 13103501 310010000 0 1 0 0.102753 1
 *
 *r-body by-vol inc b-cdt a-code surf-area bt-str-no
 13103601 330010000 0 1 0 0.102753 1
 *
 *source type is-nlpr l-dr-bt r-dr-bt bt-str-no
 13103701 0 0 0 0 1
 *
 *l-h-st chf-btr by-dia b-eq-dia ch-length bt-str-no
 *13103801 0 .3258603 .5192263 0.156250 1
 13103801 0.5192263 10.0 10.0 0 0 0 1.0 1
 *
 *r-h-st chf-btr by-dia b-eq-dia ch-length bt-str-no
 *13103901 0 .3258603 .5192263 0.156250 1
 13103901 0.5192263 10.0 10.0 0 0 0 1.0 1
 *

 * heat slab... bl sg plenum between up & dn stream rectangular section *

 * left boundary = component 310
 * right boundary = component 330
 *
 *gl data nh np type s-flg l-cor
 13104000 1 4 1 1 0.0
 *
 *mesh loc flg frm flg
 13104100 0 1
 *
 *geometry no itv r-cor
 13104101 3 .222145
 *
 *materials cmp no itv no
 13104201 1 3
 *
 *source dis source itv no
 13104301 0.0 3
 *
 *init temp flg
 13104400 -1
 *
 *temp distribution
 13104401 606.0 584.0 562.0 540.0
 *
 *l-body by-vol inc b-cdt a-code surf-area bt-str-no
 13104501 310010000 0 1 0 0.228673 1
 *
 *r-body by-vol inc b-cdt a-code surf-area bt-str-no
 13104601 330010000 0 1 0 0.228673 1
 *
 *source type is-nlpr l-dr-bt r-dr-bt bt-str-no
 13104701 0 0 0 0 1
 *
 *l-h-st chf-btr by-dia b-eq-dia ch-length bt-str-no
 *13104801 0 .2243822 .5152883 0.479167 1
 13104801 0.5152883 10.0 10.0 0 0 0 1.0 1
 *
 *r-h-st chf-btr by-dia b-eq-dia ch-length bt-str-no
 *13104901 0 .2243822 .5152883 0.479167 1
 13104901 0.5152883 10.0 10.0 0 0 0 1.0 1
 *

 * heat slabs... bl sg tube sheet flanges - up(1) & downstream(2) *

 *
 * left boundary = components 315 & 325
 * right boundary = ambient volume (808)
 *
 *gl data nh np type s-flg l-cor
 13105000 2 15 2 1 .1277344
 *
 *mesh loc flg frm flg

13150100 0 1
 *
 *geometry no itv r-cor no itv r-cor no itv r-cor
 13150101 1 .131511 1 .133427 1 .1958013
 13150102 1 .291667 2 .4534361 6 .9530033
 13150103 2 1.1250000
 *
 *materials cmp no itv no cmp no itv no cmp no itv no
 13150201 5 1 13 2 25 12
 13150202 26 14
 *
 *source dis source itv no
 13150301 0.0 14
 *
 *init temp flg
 13150400 -1
 *
 *temp distribution
 13150401 606.0 605.5 605.0 604.5 604.0 601.0 600.0 593.0 596.0
 + 594.0 593.0 592.0 590.0 529.0 80.0
 13150402 590.0 589.5 589.0 588.6 588.2 536.4 534.6 532.8 531.0
 + 529.2 528.3 527.4 526.2 296.6 80.0
 *
 *l-body by-vol inc b-cdt a-code cy-length bt-str-no
 13151501 315010000 0 1 1 0.203125 1
 13151502 325010000 0 1 1 0.203125 2
 *
 *r-body by-vol inc b-cdt a-code cy-length bt-str-no
 13150601 808010000 0 4100 1 0.203125 1
 13150602 808010000 0 4100 1 0.203125 2
 *
 *source type is-nlpr l-dr-bit r-dr-bit bt-str-no
 13150701 0 0 0 0 0 2
 *
 *l-h-st chf-htr by-dia b-eq-dia ch-length bt-str-no
 13150801 0 .0620833 .1167128 0.406250 2
 13150801 0.1167128 10.0 10.0 0 0 0 0 1.0 2
 *
 *r-h-st chf-htr by-dia b-eq-dia ch-length bt-str-no
 13150901 0 0.0 0.0 0.0 0.406250 2
 13150901 0.0 10.0 10.0 0 0 0 0 1.0 2
 *
 heat slabs... bl sg tube sheet cylindrical section - up(1) & down(2)
 *
 * left boundary = components 315 & 325
 * right boundary = ambient volume (808)
 *
 *gl data nb np type s-flg l-cor
 13151000 2 7 2 1 .1277344
 *
 *mesh loc flg frm flg
 13151100 0 1
 *
 *geometry no itv r-cor no itv r-cor no itv r-cor
 13151101 1 .131511 1 .133427 1 .1958013
 13151102 1 .291667 2 .4534361 2 .9530033
 *
 *materials cmp no itv no cmp no itv no cmp no itv no
 13151201 5 1 13 2 25 6
 13151202 26 6
 *
 *source dis source itv no
 13151301 0.0 6
 *
 *init temp flg
 13151400 -1
 *
 *temp distribution
 13151401 606.0 605.5 605.0 604.0 604.0 600.0 595.0 590.0 329.0 80.0
 13151402 590.0 589.5 589.0 536.4 534.6 530.8 526.6 296.6 80.0
 *
 *l-body by-vol inc b-cdt a-code cy-length bt-str-no
 13151501 315010000 0 1 1 .2966746 1
 13151502 325010000 0 1 1 .2966746 2
 *
 *r-body by-vol inc b-cdt a-code cy-length bt-str-no
 13151601 808010000 0 4100 1 .2966746 1
 13151602 808010000 0 4100 1 .2966746 2
 *
 *source type is-nlpr l-dr-bit r-dr-bit bt-str-no
 13151701 0 0 0 0 0 2
 *
 *l-h-st chf-htr by-dia b-eq-dia ch-length bt-str-no
 13151801 0 .0620833 .1167128 0.5770833 2
 13151801 0.1167128 10.0 10.0 0 0 0 0 1.0 2
 *
 *r-h-st chf-htr by-dia b-eq-dia ch-length bt-str-no
 13151901 0 0.0 0.0 0.0 0.5770833 2
 13151901 0.0 10.0 10.0 0 0 0 0 1.0 2
 *
 heat slabs... bl sg tube sheet cylindrical section - up(1) & down(2)
 *
 * left boundary = components 315 & 325
 * right boundary = ambient volume (808)
 *
 *gl data nb np type s-flg l-cor
 13152000 2 7 2 1 .1277344
 *
 *mesh loc flg frm flg
 13152100 0 1
 *
 *geometry no itv r-cor no itv r-cor no itv r-cor
 13152101 1 .131511 1 .133427 1 .1958013
 13152102 1 .291667 2 .4534361
 *
 *materials cmp no itv no cmp no itv no cmp no itv no
 13152201 5 1 13 2 25 4
 13152202 26 6
 *
 *source dis source itv no
 13152301 0.0 6
 *

```

*init temp flg
13152400 -1
*
*temp distribution
13152401 606.0 604.0 600.0 590.0 329.0 80.0
13152402 540.0 539.0 536.4 534.6 530.8 296.6 80.0
*
*i-body by-vol inc b-cut a-code cy-length bt-str-no
13152501 315010000 0 1 1 0.2920754 1
13152502 325010000 0 1 1 0.2920754 2
*
*i-r-body by-vol inc b-cut a-code cy-length bt-str-no
13152601 808010000 0 4100 1 0.2920754 1
13152602 808010000 0 4100 1 0.2920754 2
*
*source type is-nlpr l-dr-bit r-dr-bit bt-str-no
13152701 0 0 0 0 2
*
*i-l-st chf-htr by-dia b-eq-dia ch-length bt-str-no
13152801 0 .0620833 .1167128 0.5841508 2
13152801 0.1167128 10.0 10.0 0 0 0 1.0 2
*
*i-r-h-st chf-htr by-dia b-eq-dia ch-length bt-str-no
13152901 0 0.0 0.0 0.0 0.5841508 2
13152901 0.0 10.0 10.0 0 0 0 1.0 2
*
*heat slabs... bl sg tube sheet hub section - up(1) & downstream(2)
*****
* left boundary = components 315 & 325
* right boundary = ambient volume (808)
*
*gl data nh np type s-flg l-cor
13153000 2 6 2 1 .1277344
*
*mesh loc flg frm flg
13153100 0 1
*
*geometry no itv r-cor no itv r-cor no itv r-cor
13153101 1 .1331511 1 .1334427 1 .1958013
13153102 2 .3624679
*
*materials cap no itv no cap no itv no cap no itv no
13153201 5 1 13 2 25 3
13153202 25 5
*
*source dis source itv no
13153301 0.0 5
*
*init temp flg
13153400 -1
*
*temp distribution
13153401 606.0 604.0 600.0 590.0 329.0 80.0
13153402 540.0 539.0 536.4 534.6 530.8 296.6 80.0
*
*i-body by-vol inc b-cut a-code cy-length bt-str-no
13153501 315010000 0 1 1 0.0835417 1
13153502 325010000 0 1 1 0.0835417 2
*
*i-r-body by-vol inc b-cut a-code cy-length bt-str-no
13153601 808010000 0 4100 1 0.0835417 1
13153602 808010000 0 4100 1 0.0835417 2
*
*source type is-nlpr l-dr-bit r-dr-bit bt-str-no
13153701 0 0 0 0 2
*
*i-l-st chf-htr by-dia b-eq-dia ch-length bt-str-no
13153801 0 .0620833 .1167128 0.1670833 2
13153801 0.1167128 10.0 10.0 0 0 0 1.0 2
*
*i-r-h-st chf-htr by-dia b-eq-dia ch-length bt-str-no
13153901 0 0.0 0.0 0.0 0.1670833 2
13153901 0.0 10.0 10.0 0 0 0 1.0 2
*
***** heat slab... bl sg tube sheet between up & dn stream hyd. volumes ****
*
*i
* left boundary = component 315
* right boundary = component 325
*
*gl data nh np type s-flg l-cor
13154000 1 3 1 1 0.0
*
*mesh loc flg frm flg
13154100 0 1
*
*geometry no itv r-cor
13154101 2 .165750
*
*materials cap no itv no
13154201 25 2
*
*source dis source itv no
13154301 0.0 2
*
*init temp flg
13154400 -1
*
*temp distribution
13154401 606.0 573.0 540.0
*
*i-body by-vol inc b-cut a-code surf area bt-str-no
13154501 315010000 0 1 0 0.4135420 1
*
*i-r-body by-vol inc b-cut a-code surf area bt-str-no
13154601 325010000 0 1 0 0.4135420 1
*
*source type is-nlpr l-dr-bit r-dr-bit bt-str-no
13154701 0 0 0 0 1
*
*i-l-st chf-htr by-dia b-eq-dia ch-length bt-str-no
13154801 0 .0620833 .1326376 1.751830 1
13154801 0.1326376 10.0 10.0 0 0 0 1.0 1

```

	source	type	is-nplr	l-dr-ht	r-dr-ht	bt-str-no
*-r-h-st	chf-htr	by-dia	b-eq-dia	ch-length	bt-str-no	
*13152901	0	0.064750	0.064750	1.751830	1	
13152901	0.064750	10.0	10.0	0 0 0 0	1.0	1
*	*****	*****	*****	*****	*****	*****
* heat slab... intact & broken loop, 3 in. sch-160 piping	*	*	*	*	*	*
* note - contains only volume lengths which	*	*	*	*	*	*
* are heated by heater tape.	*	*	*	*	*	*
*	*****	*****	*****	*****	*****	*****
* left boundary = components 201,261,262,263,301,363	*	*	*	*	*	*
* right boundary = ambient volumes (811 & 813)	*	*	*	*	*	*
*	*****	*****	*****	*****	*****	*****
* gl data	nh	np	type	s-flg	l-cor	
12002000	8	8	2	1	.10933333	
*	*****	*****	*****	*****	*****	*****
* mesh	loc flg	frm flg				
12002100	0	1				
*	*****	*****	*****	*****	*****	*****
* geometry	no itv	r-cor	no itv	r-cor	no itv	r-cor
12002101	2	.14533333	1	.14533333	2	.156350
12002102	2	.33301667				
*	*****	*****	*****	*****	*****	*****
* materials	csp no	itv no	csp no	itv no	csp no	itv no
12002201	1	2	13	3	9	5
12002202	16	7				
*	*****	*****	*****	*****	*****	*****
* source dis	source	itv no	source	itv no	source	itv no
12002301	0.0	3	1.0	5	0.0	7
*	*****	*****	*****	*****	*****	*****
* init temp	flg					
12002400	0					
*	*****	*****	*****	*****	*****	*****
* temp mesh	temp mesh	temp mesh	temp mesh	temp mesh	temp mesh	
12002401	548.9	1	560.4	2	570.4	3
12002402	606.3	6	357.7	7	154.3	8
*	*****	*****	*****	*****	*****	*****
* l-body	by-vol	inc	b-cut	a-code	cy-length	bt-str-no
12002501	201010000	0	1	1	0.18189	1
12002502	201020000	0	1	1	0.54557	2
12002503	251010000	0	1	1	1.03188	3
12002504	251020000	0	1	1	0.78704	4
12002505	252010000	0	1	1	0.72757	5
12002506	253010000	0	1	1	0.54557	6
12002507	301010000	0	1	1	0.72757	7
12002508	353010000	0	1	1	0.36378	8
*	*****	*****	*****	*****	*****	*****
* r-body	by-vol	inc	b-cut	a-code	cy-length	bt-str-no
12002601	811010000	0	4100	1	0.18189	1
12002602	811010000	0	4100	1	0.54557	2
12002603	813010000	0	4100	1	1.03188	3
12002604	813010000	0	4100	1	0.78704	4
12002605	813010000	0	4100	1	0.72757	5
12002606	813010000	0	4100	1	0.54557	6
12002607	811010000	0	4100	1	0.72757	7
12002608	813010000	0	4100	1	0.36378	8
*	*****	*****	*****	*****	*****	*****
* source	type	is-nplr		l-dr-ht	r-dr-ht	bt-str-no
12002701	110	.013207		0	0	1
12002702	110	.039077		0	0	2
12002703	112	.246930		0	0	3
12002704	112	.186657		0	0	4
12002705	112	.174759		0	0	5
12002706	112	.129414		0	0	6
12002707	110	.052769	-	0	0	7
12002708	112	.087280		0	0	8
*	*****	*****	*****	*****	*****	*****
* l-h-st	chf-htr	by-dia	b-eq-dia	ch-length	bt-str-no	
*12002801	0	0.0	0.0	0.218666	8	
12002801	0.0	10.0	10.0	0 0 0 0	1.0	8
*	*****	*****	*****	*****	*****	*****
* r-h-st	chf-htr	by-dia	b-eq-dia	ch-length	bt-str-no	
*12002901	0	0.0	0.0	0.218666	8	
12002901	0.0	10.0	10.0	0 0 0 0	1.0	8
*	*****	*****	*****	*****	*****	*****
* heat slab... intact loop, 3 in. sch-160 piping	*	*	*	*	*	*
* note - heat slab contains only volume lengths which	*	*	*	*	*	*
* are not heated	*	*	*	*	*	*
*	*****	*****	*****	*****	*****	*****
* left boundary = intact loop primary coolant (201,261,262,263)	*	*	*	*	*	*
* right boundary = ambient volumes (801 & 803)	*	*	*	*	*	*
*	*****	*****	*****	*****	*****	*****
* gl data	nh	np	type	s-flg	l-cor	
12003000	6	5	2	1	0.10933333	
*	*****	*****	*****	*****	*****	*****
* mesh	loc flg	frm flg				
12003100	0	1				
*	*****	*****	*****	*****	*****	*****
* actual wall thk. mult by 2.0 to account for clamp+hub mass	*	*	*	*	*	*
* geometry	no itv	r-cor	no itv	r-cor		
12003101	2	0.182333	2	0.349000		
*	0.43233 for 3 in. of insul					
*	*****	*****	*****	*****	*****	*****
* materials	csp no	itv no	csp no	itv no		
12003201	1	2	16	4		
*	*****	*****	*****	*****	*****	*****
* source dis	source	itv no				
12003301	0.0	4				
*	*****	*****	*****	*****	*****	*****
* init temp	flg					
12003400	0					
*	*****	*****	*****	*****	*****	*****
* temp mesh	temp mesh	temp mesh	temp mesh	temp mesh	temp mesh	
12003401	550.5	1	549.9	2	540.8	3
12003401	328.2	4	147.7	5		
*	*****	*****	*****	*****	*****	*****
* l-body	by-vol	inc	b-cut	a-code	cy-length	bt-str-no
12003501	201010000	0	1	1	2.40661	1
12003502	201020000	0	1	1	0.75516	2
12003503	251010000	0	1	1	1.04479	3
12003504	251020000	0	1	1	1.28963	4
12003505	252010000	0	1	1	1.34910	5
12003506	253010000	0	1	1	1.60783	6
*	*****	*****	*****	*****	*****	*****

*r-body	by-vol	inc	b-cdt	a-code	cy-length	bt-str-no		12004507	240020000	0	1	1	1	1.5503	7	
12003601	801010000	0	4100	1	2.46061	1		12004508	240030000	0	1	1	1	0.66430	8	
12003602	801010000	0	4100	1	0.75516	2		12004509	240030000	0	1	1	1	1.77146	9	
12003603	803010000	0	4100	1	1.0479	3		12004510	240040000	0	1	1	1	2.21433	10	
12003604	803010000	0	4100	1	1.28953	4		12004511	240050000	0	1	1	1	3.08856	11	
12003605	803010000	0	4100	1	1.34910	5		12004512	240060000	0	1	1	1	1.34009	12	
12003606	803010000	0	4100	1	1.60783	6		12004513	240070000	0	1	1	1	1.34009	13	
*								12004514	240080000	0	1	1	1	3.08856	14	
*source	type	is-splir	l-dr-it	r-dr-it	bt-str-no			12004515	240090000	0	1	1	1	2.65719	15	
12003701	0	0	0	0	6			*								
*								*r-body	by-vol	inc	b-cdt	a-code	cy-length	bt-str-no		
*1-h-st	chf-btr	by-dia	b-eq-dia	ch-length	bt-str-no			12004601	811010000	0	4100	1	0.88573	1		
*	0	0.0	0.0	0.218666	6			12004602	811010000	0	4100	1	1.77146	2		
12003801	0.0	10.0	10.0	0 0 0 0	1.0 6			12004603	811010000	0	4100	1	1.99290	3		
*								12004604	811010000	0	4100	1	0.66430	4		
*r-h-st	chf-btr	by-dia	b-eq-dia	ch-length	bt-str-no			12004605	811010000	0	4100	1	0.88573	5		
*	12003901	0	0.0	0.0	0.218666	6			12004606	811010000	0	4100	1	0.88573	6	
12003901	0.0	10.0	10.0	0 0 0 0	1.0 6			12004607	811010000	0	4100	1	1.5503	7		
*								12004608	811010000	0	4100	1	0.66430	8		
*								12004609	814010000	0	4100	1	1.77146	9		
*	beat slab... intact loop , 2 1/2 in. sch-160 piping							12004610	814010000	0	4100	1	2.21433	10		
*	note - beat slab contains only volume lengths which							12004611	814010000	0	4100	1	3.08856	11		
*	are heated with heater tape.							12004612	814010000	0	4100	1	1.34009	12		
*								12004613	814010000	0	4100	1	1.34009	13		
*								12004614	814010000	0	4100	1	3.08856	14		
*								12004615	814010000	0	4100	1	2.65719	15		
*								*								
*gl data	nh	np	type	s-flg	l-cor			*source	type	is-splir	l-dr-it	r-dr-it	bt-str-no			
12004000	15	8	2	1	0.088542			12004701	110	.052769	0	0	1			
*								12004702	110	.105537	0	0	2			
*mesh	loc flg	fms flg						12004703	110	.118744	0	0	3			
12004100	0	1						12004704	110	.039077	0	0	4			
*								12004705	110	.052769	0	0	5			
*geometry	no itv	r-cor	no itv	r-cor	no itv	r-cor		12004706	110	.052769	0	0	6			
12004101	2	0.119792	1	0.119892	2	0.130309		12004707	110	.091845	0	0	7			
12004102	2	0.206975						12004708	110	.039077	0	0	8			
*								12004709	113	.114289	0	0	9			
*materials	cpx no	itv no	cpx no	itv no	cpx no	itv no		12004710	113	.142829	0	0	10			
12004201	1	2	13	3	9	5		12004711	113	.199265	0	0	11			
12004202	15	7						12004712	113	.086459	0	0	12			
*								12004713	113	.086459	0	0	13			
*source dis	source	itv no	source	itv no	source	itv no		12004714	113	.199265	0	0	14			
12004301	0.0	3	1.0	5	0.0	7		12004715	113	.171434	0	0	15			
*								*								
*init temp	flg							*1-h-st	chf-btr	by-dia	b-eq-dia	ch-length	bt-str-no			
12004400	0							12004801	0	0.0	0.0	0.0	0.177084	15		
*								12004801	0.0	10.0	10.0	0 0 0 0	1.0 15			
*								*								
*								*r-h-st	chf-btr	by-dia	b-eq-dia	ch-length	bt-str-no			
*								12004901	0	0.0	0.0	0.0	0.177084	15		
*								12004901	0.0	10.0	10.0	0 0 0 0	1.0 15			
*								*								
*								*heat slab... intact loop , 2 1/2 in. sch-160 piping								
*								*note - heat slab contains only volume lengths which								
*								are not heated.								
*																

* left boundary = intact loop primary coolant (201,202,203,240)
 * right boundary = ambient volumes (801 & 804)
 *
 *gl data nh np type s-flg l-cor
 12005000 14 5 2 1 0.083542
 *
 *mesh loc flg frm flg
 12005100 0 1
 *
 * actual wall thk. mult. by 2.0 to account for clamp + hub mass
 *geometry no itv r-cor no itv r-cor
 12005101 2 0.151042 2 0.317709
 *
 *materials cap no itv no cap no itv no
 12005201 1 2 16 4
 *
 *source dis source itv no
 12005301 0.0 4
 *
 *init temp flg
 12005400 0
 *
 * temp mesh temp mesh temp mesh temp mesh temp mesh temp mesh
 12005401 550.1 1 545.2 2 541.5 3 323.6 4 195.1 5
 *
 *l-body by-vol inc b-cut a-code cy-length ht-str-no
 12005501 201020000 0 1 1 0.28510 1
 12005502 202010000 0 1 1 0.97187 2
 12005503 213011000 0 1 1 0.66131 3
 12005504 233020000 0 1 1 1.68862 4
 12005505 233030000 0 1 1 1.30272 5
 12005506 240010000 0 1 1 0.63605 6
 12005507 240020000 0 1 1 2.11622 7
 12005508 240030000 0 1 1 1.01174 8
 12005509 240040000 0 1 1 0.68150 9
 12005510 240050000 0 1 1 0.41907 10
 12005511 240060000 0 1 1 0.18183 11
 12005512 240070000 0 1 1 0.18183 12
 12005513 240080000 0 1 1 0.41907 13
 12005514 240090000 0 1 1 1.55114 14
 *
 *r-body by-vol inc b-cut a-code cy-length ht-str-no
 12005601 801010000 0 4100 1 0.28510 1
 12005602 801010000 0 4100 1 0.97187 2
 12005603 801010000 0 4100 1 0.66131 3
 12005604 801010000 0 4100 1 1.68862 4
 12005605 801010000 0 4100 1 1.30272 5
 12005606 801010000 0 4100 1 0.63605 6
 12005607 801010000 0 4100 1 2.11622 7
 12005608 804010000 0 4100 1 1.01174 8
 12005609 804010000 0 4100 1 0.68150 9
 12005610 804010000 0 4100 1 0.41907 10
 12005611 804010000 0 4100 1 0.18183 11
 12005612 804010000 0 4100 1 0.18183 12
 12005613 804010000 0 4100 1 0.41907 13
 12005614 804010000 0 4100 1 1.55114 14
 *
 *source type is-mlr l-dr-ht r-dr-ht ht-str-no
 12005701 0 0 0 0 0 14
 *
 *l-b-st chf-htr by-dia b-eq-dia ch-length ht-str-no
 12005801 0 0.0 0.0 0.0 0.177084 14
 12005801 0.0 10.0 10.0 0 0 0 0 1.0 14
 *
 *r-b-st chf-htr by-dia b-eq-dia ch-length ht-str-no
 12005901 0 0.0 0.0 0.0 0.177084 14
 12005901 0.0 10.0 10.0 0 0 0 0 1.0 14
 *
 *heat slab... broken loop - 1 1/2 in. sch 160 piping
 * note - heat slab contains only volume lengths which
 * are heated by heater bands
 *
 *left boundary = broken loop primary coolant (340 - volumes 4,5,7)
 *right boundary = ambient volume (812)
 *
 *gl data nh np type s-flg l-cor
 13001000 3 11 2 1 .0557500
 *
 *mesh loc flg frm flg
 13001100 0 1
 *
 *geometry no itv r-cor no itv r-cor no itv r-cor
 13001101 2 .0791667 1 .0792000 1 .081804167
 13001102 3 .09222083 1 .09824997 2 .251491663
 *
 *materials cap no itv no cap no itv no cap no itv no
 13001201 -1 2 13 3 1 4
 13001202 -9 7 1 8 16 10
 *
 *source dis source itv no source itv no source itv no
 13001301 0.0 5 1.0 6 0.0 10
 *
 *init temp flg
 13001400 0
 *
 * temp mesh temp mesh temp mesh temp mesh temp mesh
 13001401 555.0 1 573.4 2 588.8 3 605.0 5 640.0 6
 13001402 652.8 7 648.0 9 363.3 10 145.0 11
 *
 *l-body by-vol inc b-cut a-code cy-length ht-str-no
 13001501 340040000 0 1 1 2.29167 1
 13001502 340050000 0 1 1 2.25000 2
 13001504 340060000 0 1 1 0.20833 3
 *
 *r-body by-vol inc b-cut a-code cy-length ht-str-no
 13001601 812010000 0 4100 1 2.29167 1
 13001602 812010000 0 4100 1 2.25000 2
 13001604 812010000 0 4100 1 0.20833 3
 *
 *source type is-mlr l-dr-ht r-dr-ht ht-str-no
 13001701 111 .394975 0 0 1
 13001702 111 .392055 0 0 2
 13001704 111 .036122 0 0 3

*l-h-st chf-htr by-dia b-eq-dia ch-length ht-str-no
 *13001801 0 0.0 0.0 0.0 0.111500 3
 13001801 0.0 10.0 10.0 0 0 0 1.0 3
 *
 *r-h-st chf-htr by-dia b-eq-dia ch-length ht-str-no
 *13001901 0 0.0 0.0 0.0 0.111500 3
 13001901 0.0 10.0 10.0 0 0 0 1.0 3
 *

 * heat slab... broken loop - 1 1/2 in. sch-160 piping :
 * note - heat slab contains only volume lengths which :
 * are heated with heater tape. :

 * left boundary = broken loop primary coolant (301,340,361,362,363)
 * right boundary = ambient volumes (811,812,813)
 *
 *gl data nh np type s-flg l-cor
 13002000 17 8 2 1 .0557500
 *
 *mesh loc flg frm flg
 13002100 0 1
 *
 *geometry no itv r-cor no itv r-cor
 13002101 2 .07916657 1 .07920000
 13002102 2 .08958340 2 .256360
 *
 *materials cmp no itv no cmp no itv no cmp no itv no
 13002201 1 2 13 3 9 5
 13002202 16 7
 *
 *source dis source itv no source itv no source itv no
 13002301 0.0 3 1.0 5 0.0 7
 *
 *init temp flg
 13002400 0
 *
 * temp mesh temp mesh temp mesh temp mesh temp mesh
 13002401 548.7 1 545.0 3 542.7 4 536.9 5 531.6 6
 13002402 239.4 7 139.1 8
 *
 *l-body by-vol inc b-cdt a-code cy-length ht-str-no
 13002501 301010000 0 1 1 0.33506 1
 13002502 301020000 0 1 1 0.67013 2
 13002503 301030000 0 1 1 1.34025 3
 13002504 301040000 0 1 1 1.34025 4
 13002505 301050000 0 1 1 0.67013 5
 13002506 301060000 0 1 1 1.06519 6
 13002507 340010000 0 1 1 0.67013 7
 13002508 340020000 0 1 1 0.67013 8
 13002509 340030000 0 1 1 0.67013 9
 13002510 340040000 0 1 1 1.34025 10
 13002511 340050000 0 1 1 0.33506 11
 13002512 340060000 0 1 1 0.67013 12
 13002513 340070000 0 1 1 0.67013 13
 13002514 340080000 0 1 1 4.35581 14
 13002515 361010000 0 1 1 0.33506 15
 13002516 362010000 0 1 1 0.67013 16
 13002517 363010000 0 1 1 0.33506 17
 *
 *r-body by-vol inc b-cdt a-code cy-length ht-str-no
 13002601 811010000 0 4100 1 0.33506 1
 13002602 811010000 0 4100 1 0.67013 2
 13002603 811010000 0 4100 1 1.34025 3
 13002604 811010000 0 4100 1 1.34025 4
 13002605 811010000 0 4100 1 0.67013 5
 13002606 811010000 0 4100 1 1.00519 6
 13002607 811010000 0 4100 1 0.67013 7
 13002608 811010000 0 4100 1 0.67013 8
 13002609 811010000 0 4100 1 0.67013 9
 13002610 811010000 0 4100 1 1.34025 10
 13002611 812010000 0 4100 1 0.33506 11
 13002612 812010000 0 4100 1 0.67013 12
 13002613 812010000 0 4100 1 0.67013 13
 13002614 812010000 0 4100 1 4.35581 14
 13002615 813010000 0 4100 1 0.33506 15
 13002616 813010000 0 4100 1 0.67013 16
 13002617 813010000 0 4100 1 0.33506 17
 *
 *source type is-rplc l-dr-ht r-dr-ht ht-str-no
 13002701 110 .013207 0 0 1
 13002702 110 .026384 0 0 2
 13002703 110 .052769 0 0 3
 13002704 110 .062738 0 0 4
 13002705 110 .026354 0 0 5
 13002706 110 .039077 0 0 6
 13002707 110 .026354 0 0 7
 13002708 110 .026354 0 0 8
 13002709 110 .026354 0 0 9
 13002710 110 .052769 0 0 10
 13002711 111 .009385 0 0 11
 13002712 111 .019147 0 0 12
 13002713 111 .019147 0 0 13
 13002714 111 .124468 0 0 14
 13002715 112 .043790 0 0 15
 13002716 112 .087480 0 0 16
 13002717 112 .043790 0 0 17
 *
 *l-h-st chf-htr by-dia b-eq-dia ch-length ht-str-no
 *13002801 0 0.0 0.0 0.0 0.111500 17
 13002801 0.0 10.0 10.0 0 0 0 1.0 17
 *
 *r-h-st chf-htr by-dia b-eq-dia ch-length ht-str-no
 *13002901 0 0.0 0.0 0.0 0.111500 17
 13002901 0.0 10.0 10.0 0 0 0 1.0 17

 * heat slab... broken loop - 1 1/2 in. sch-160 piping :
 * note - heat slab contains only volume lengths which :
 * are not heated. :

 * left boundary = broken loop primary coolant (301,340,361,362,363)
 * right boundary = ambient volumes (801,802,803)
 *
 *gl data nh np type s-flg l-cor
 13003000 18 5 2 1 0.0557500

```

*mesh loc flg frm flg
13003100 0 1
*
* actual wall thk. melt by 2.0 to acet for clasp:bch mass
*geometry no itv r-cor no itv r-cor
13003101 2 0.1002534 2 0.2669251
*
*materials cmp no itv no cmp no itv no
13003201 1 2 16 4
*
*source dis source itv no
13003301 0.0 4
*
*init temp flg
13003400 0
*
* temp mesh temp mesh temp mesh temp mesh temp mesh
13003401 529.7 1 544.8 2 541.5 3 336.7 4 140.5 5
*
*1-body hy-vol inc b-cdt a-code cy-length bt-str-no
13003501 301010000 0 1 1 0.49827 1
13003502 301020000 0 1 1 1.54000 2
13003503 301030000 0 1 1 0.86987 3
13003504 301040000 0 1 1 1.3427 4
13003505 301050000 0 1 1 1.68795 5
13003506 301060000 0 1 1 0.97012 6
13003507 340010000 0 1 1 0.93335 7
13003508 340020000 0 1 1 1.66920 8
13003509 340030000 0 1 1 0.97352 9
13003510 340040000 0 1 1 1.31120 10
13003511 340050000 0 1 1 1.71140 11
13003512 340060000 0 1 1 0.34555 12
13003513 340070000 0 1 1 0.34555 13
13003514 340080000 0 1 1 0.93377 14
13003515 340090000 0 1 1 2.08834 15
13003516 351010000 0 1 1 1.63494 16
13003517 362010000 0 1 1 0.97737 17
13003518 363010000 0 1 1 1.99911 18
*
*r-body hy-vol inc b-cdt a-code cy-length bt-str-no
13003601 801010000 0 4100 1 0.49827 1
13003602 801020000 0 4100 1 1.54000 2
13003603 801030000 0 4100 1 0.86987 3
13003604 801040000 0 4100 1 1.3427 4
13003605 801050000 0 4100 1 1.68795 5
13003606 801060000 0 4100 1 0.97012 6
13003607 801070000 0 4100 1 0.93335 7
13003608 801080000 0 4100 1 1.66920 8
13003609 801090000 0 4100 1 0.97352 9
13003610 801100000 0 4100 1 1.31120 10
13003611 802010000 0 4100 1 1.71140 11
13003612 802010000 0 4100 1 0.34555 12
13003613 802020000 0 4100 1 0.34555 13
13003614 802030000 0 4100 1 0.93377 14
13003615 802040000 0 4100 1 2.08834 15
13003616 803010000 0 4100 1 1.63494 16
13003617 803020000 0 4100 1 0.97737 17
*
*source type is-nlpr l-dr-bt r-dr-bt bt-str-no
13003701 0 0 0 0 0 18
*
*1-h-st chf-btr hy-dia b-eq-dia ch-length bt-str-no
13003801 0 0.0 0.0 0.0 0.111500 18
13003801 0.0 10.0 10.0 0 0 0 1.0 18
*
*1-h-b-st chf-btr hy-dia b-eq-dia ch-length bt-str-no
13003901 0 0.0 0.0 0.0 0.111500 18
13003901 0.0 10.0 10.0 0 0 0 1.0 18
*
*****
* heat slab... broken loop, vessel nozzles (3 in, sch-160)
* note - heat slab contains only volume lengths which
* are not heated
*****
*
* left boundary = broken loop primary coolant vessel nozzles (301,363)
* right boundary = ambient volumes (801,803)
*
*gl data nh np type s-flg l-cor
13004000 2 5 2 1 0.10933333
*
*mesh loc flg frm flg
13004100 0 1
*
*geometry no itv r-cor no itv r-cor
13004101 2 0.145333 2 0.312500
*
*materials cmp no itv no cmp no itv no
13004201 1 2 16 4
*
*source dis source itv no
13004301 0.0 4
*
*init temp flg
13004400 -1
*
*temp distribution
13004401 610.1 606.8 604.3 352.4 152.5
13004402 546.9 544.1 541.9 318.8 144.8
*
*1-body hy-vol inc b-cdt a-code cy-length bt-str-no
13004501 301010000 0 1 1 0.61160 1
13004502 363020000 0 1 1 0.91239 2
*
*r-body hy-vol inc b-cdt a-code cy-length bt-str-no
13004601 801010000 0 4100 1 0.61160 1
13004602 803010000 0 4100 1 0.91239 2
*
*source type is-nlpr l-dr-bt r-dr-bt bt-str-no
13004701 0 0 0 0 0 2
*
*1-h-st chf-btr hy-dia b-eq-dia ch-length bt-str-no
13004801 0 0.0 0.0 0.0 0.218666 2

```

1300301 0.0 10.0 10.0 0 0 0 0 1.0 2
 *
 *r-h-st chf-htr hy-dia b-eq-dia ch-length ht-str-no
 *1300301 0 0.0 0.0 0.0 0.218666 2
 1300301 0.0 10.0 10.0 0 0 0 0 1.0 2
 *

 * heat slab... intact loop pump
 * note - heat slab models heat loss due to pump seal cooling

 * left boundary = component 350
 * right boundary = specified in table 351
 *
 * pump heat loss is tabulated as a linear function of pump angular speed
 *
 *gl data nh np type s-flg l-cor
 13500000 1 4 2 1 0.07019
 *
 *mesh loc flg frm flg
 13500100 0 1
 *
 *geometry no itv r-cor
 13500101 3 0.12325
 *
 *materials cap no itv no
 13500201 1 3
 *
 *source dis source itv no
 13500301 0.0 3
 *
 *init temp flg
 13500400 0
 *
 * temp mesh temp mesh temp mesh temp mesh
 13500401 531.1 1 434.0 2 350.8 3 277.4 4
 *
 *l-body by-vol inc b-cdt a-code cy-length ht-str-no
 13500501 350010000 0 1 1 1 1.9635 1
 *
 *r-body by-vol inc b-cdt a-code cy-length ht-str-no
 13500601 0 0 2351 1 1 1.9635 1
 *
 *source type is-mlr l-dr-ht r-dr-ht ht-str-no
 13500701 0 0 0 0 1
 *
 *l-h-st chf-htr hy-dia b-eq-dia ch-length ht-str-no
 *13500801 0 0.0 0.0 0.0 2.26167 1
 13500801 0.0 10.0 10.0 0 0 0 0 1.0 1
 *
 *r-h-st chf-htr hy-dia b-eq-dia ch-length ht-str-no
 *13500901 0 0.0 0.0 0.0 2.26167 1
 13500901 0.0 10.0 10.0 0 0 0 0 1.0 1

 * heat slab... broken loop pump
 * note - heat slab models heat loss due to pump seal cooling

*geometry no itv r-cor no itv r-cor no itv r-cor
 19990101 3 .187500 4 .270833 1 .272157
 19990102 1 .272267 2 .282683 2 .49350
 *
 *materials cap no itv no cap no itv no cap no itv no
 19990201 1 3 19 7 20 8
 19990202 13 9 9 11 30 13
 *
 *source dis source itv no source itv no source itv no
 19990301 0.0 9 1.0 11 0.0 13
 *
 *init temp flg
 19990400 0
 *
 *temp mesh temp mesh temp mesh
 19990401 602.0 2 602.0 12 190.0 14
 *
 *l-body by-vol inc b-cdt a-code cy-length ht-str-no
 19990501 999010000 0 1 1 2.500000 1
 19990502 999020000 10000 1 1 2.562500 6
 19990503 999070000 0 1 1 2.583333 7
 19990504 999080000 0 1 1 2.093750 8
 *
 *r-body by-vol inc b-cdt a-code cy-length ht-str-no
 19990601 816010000 0 4100 1 2.500000 1
 19990602 816010000 0 4100 1 2.562500 6
 19990603 816010000 0 4100 1 2.583333 7
 19990604 816010000 0 4100 1 2.093750 8
 *
 *source type is-mlr l-dr-ht r-dr-ht ht-str-no
 19990701 117 .123065 0 0 1
 19990702 117 .128192 0 0 6
 19990703 117 .129234 0 0 7
 19990704 117 .109742 0 0 8
 *
 *l-h-st chf-htr hy-dia b-eq-dia ch-length ht-str-no
 19990801 0 .258333 2914500 2.500000 1
 19990801 0.29145 10.0 10.0 0 0 0 0 1.0 1
 19990802 0 .302583 3025833 2.562500 6
 19990802 0.30258 10.0 10.0 0 0 0 0 1.0 6
 19990803 0 .302583 3025833 2.583333 7
 19990803 0.30258 10.0 10.0 0 0 0 0 1.0 7
 19990804 0 .1005325 .2251253 2.093750 8
 19990804 0.22512 10.0 10.0 0 0 0 0 1.0 8
 *
 *r-h-st chf-htr hy-dia b-eq-dia ch-length ht-str-no
 19990901 0 0.0 0.0 2.500000 1
 19990901 0.0 10.0 10.0 0 0 0 0 1.0 1
 19990902 0 0.0 0.0 2.562500 6
 19990902 0.0 10.0 10.0 0 0 0 0 1.0 6
 19990903 0 0.0 0.0 2.583333 7
 19990903 0.0 10.0 10.0 0 0 0 0 1.0 7
 19990904 0 0.0 0.0 2.093750 8
 19990904 0.0 10.0 10.0 0 0 0 0 1.0 8
 *
 *heat slab... pressurizer heater rods — data from rama corp.,
 *beater rod manufacturer

 * left boundary = adiabatic
 * right boundary = component 999
 *
 *gl data nh np type s-flg l-cor
 19990000 1 8 2 1 0.0
 *
 *mesh loc flg frm flg
 19992100 0 1
 *
 *geometry no itv r-cor no itv r-cor no itv r-cor
 19992101 2 2.1509e-2 1 2.1833e-2 2 2.693e-2
 19992102 2 3.1042e-2
 *
 *materials cap no itv no cap no itv no cap no itv no
 19992201 21 2 22 3 21 5
 19992202 23 7
 *
 *source dis source itv no source itv no source itv no
 19992301 0.0 2 1.0 3 0.0 7
 *
 *init temp flg
 19992400 0
 *
 *temp mesh
 19992401 631.0 8
 *
 *l-body by-vol inc b-cdt a-code cy-length ht-str-no
 19992501 0 0 0 0 0.0 1
 *
 *r-body by-vol inc b-cdt a-code cy-length ht-str-no
 19992601 999080000 0 1 1 12.0 1
 *
 *source type is-mlr l-dr-ht r-dr-ht ht-str-no
 19992701 10999 1.0 0 0 1
 *
 *l-h-st chf-htr hy-dia b-eq-dia ch-length ht-str-no
 19992801 0 0.0 0.0 2.093750 1
 19992801 0.0 10.0 10.0 0 0 0 0 1.0 1
 *
 *r-h-st chf-htr hy-dia b-eq-dia ch-length ht-str-no
 19992901 0 .1005325 .1901660 2.093750 1
 19992901 0.1901660 10.0 10.0 0 0 0 0 1.0 1
 *

 * heat slab... pressurizer heat transfer out end caps and instrument
 * ports - thermal conductivity calculated to match test

 *
 * left boundary = component 999
 * right boundary = ambient volume (306)
 *
 *gl data nh np type s-flg l-cor
 19993000 8 3 2 1 .1512917
 *
 *mesh loc flg frm flg
 19993100 0 1

```

*gl data          nb    np   type s-flg l-cor
1997000          2      5     2     1   .0154167
*
*mesh          loc flg frm flg
19970100         0      1
*
*geometry      no itv r-cor
19993101         2   .49350
*
*materials    cmp no itv no
19993201         31     2
*
*source dis  source itv no
19993301         0.0    2
*
*init temp    flg
19993400         0
*
*temp mesh   temp mesh temp mesh
19993401   602.0  1  370.0  2  140.0  3
*
*l-body      by-vol   inc b-cut a-code cy-length ht-str-no
19993501  999010000  0     1     1   2.500000   1
19993502  999020000 10000  1     1   2.552500   6
19993503  999070000  0     1     1   2.583333   7
19993504  999080000  0     1     1   2.093750   8
*
*r-body      by-vol   inc b-cut a-code cy-length ht-str-no
19993601  806010000  0     4100   1   2.500000   1
19993602  806010000  0     4100   1   2.552500   6
19993603  806010000  0     4100   1   2.583333   7
19993604  806010000  0     4100   1   2.093750   8
*
*source      type is-splr l-dr-ht r-dr-ht ht-str-no
19993701         0     0     0     0     8
*
*l-h-st    chf-htr by-dia b-eq-dia ch-length ht-str-no
19993801         0   .2858333   .291500   2.500000   1
19993801  0.29145 10.0 10.0 0 0 0 0 1.0 1
19993802         0   .3025833   .3025833   2.552500   6
19993802  0.30258 10.0 10.0 0 0 0 0 1.0 6
19993803         0   .3025833   .3025833   2.583333   7
19993803  0.30258 10.0 10.0 0 0 0 0 1.0 7
19993804         0   .1065325   .251253   2.093750   8
19993804  0.22512 10.0 10.0 0 0 0 0 1.0 8
*
*r-h-st    chf-htr by-dia b-eq-dia ch-length ht-str-no
19993901         0     0.0    0.0   2.500000   1
19993901  0.0 10.0 10.0 0 0 0 0 1.0 1
19993902         0     0.0    0.0   2.552500   6
19993902  0.0 10.0 10.0 0 0 0 0 1.0 6
19993903         0     0.0    0.0   2.583333   7
19993903  0.0 10.0 10.0 0 0 0 0 1.0 7
19993904         0     0.0    0.0   2.093750   8
19993904  0.0 10.0 10.0 0 0 0 0 1.0 8
*****
***** heat structure thermal property data *****
*****
*heat slab... pressurizer surge line heat loss
*****
* left boundary = component 997
* right boundary = ambient volume (807)
*

```

*								
*incasel 600	tbl/fctn	1	1					
2010050	tbl/fctn	1	1					
*								
*grafoil (grafoil is a trade name of a union carbide product)	tbl/fctn	1	1					
2010060	tbl/fctn	1	1					
*								
*copper ca 102 (oxygen free copper)	tbl/fctn	1	1					
20100700	tbl/fctn	1	1					
*								
*cal-temp insulation (modified values for vessel heat loss)	tbl/fctn	1	1					
20100800	tbl/fctn	1	1					
*								
*alumina (aluminum oxide)	tbl/fctn	1	1					
20100900	tbl/fctn	1	1					
*								
*incasel 718	tbl/fctn	1	1					
20101000	tbl/fctn	1	1					
*								
*honeycomb - hexagonal matrix core	tbl/fctn	1	1					
20101100	tbl/fctn	1	1					
*								
*honeycomb - square matrix core	tbl/fctn	1	1					
20101200	tbl/fctn	1	1					
*								
*contact resistance properties (conductivity of air; storage = 0.0)	tbl/fctn	1	1					
20101300	tbl/fctn	1	1					
*								
*steam generator filler piece construction	tbl/fctn	1	1					
20101400	tbl/fctn	1	1					
*								
*water	tbl/fctn	1	1					
20101500	tbl/fctn	1	1					
*								
*cal-temp insulation (modified values for piping heat loss)	tbl/fctn	1	1					
20101600	tbl/fctn	1	1					
*								
*cal-temp insulation (modified values for steam generator heat loss)	tbl/fctn	1	1					
20101700	tbl/fctn	1	1					
*								
*thermal liner - john's manville min-k 2000, 30-35 pcf	tbl/fctn	1	1					
20101800	tbl/fctn	1	1					
*								
*cal-temp insulation (modified values for pressurizer heat loss)	tbl/fctn	1	1					
20101900	tbl/fctn	1	1					
*								
*alumina (used in pressurizer guard heaters)	tbl/fctn	1	1					
20102000	tbl/fctn	1	1					
*								
*magnesium oxide (used in pressurizer heater rods)	tbl/fctn	1	1					
20102100	tbl/fctn	1	1					
*								
*nickrose v (used in pressurizer heater rods)	tbl/fctn	1	1					
20102200	tbl/fctn	1	1					
*								
*incoloy 800 (used in pressurizer heater rods)	tbl/fctn	1	1					
20102300	tbl/fctn	1	1					
*								
*cal-temp insulation (for pressurizer surge line heat loss)	tbl/fctn	1	1					
20102400	tbl/fctn	1	1					
*								
* 0.357 carbon steel used for sg tube sheets	tbl/fctn	1	1					
20102500	tbl/fctn	1	1					
*								
*cal-temp insulation (for inlet plenum heat loss)	tbl/fctn	1	1					
20102600	tbl/fctn	1	1					
*								
*no2 used in nuclear core	tbl/fctn	1	1					
20102700	tbl/fctn	1	1					
*								
*zircaloy used in nuclear core	tbl/fctn	1	1					
20102800	tbl/fctn	1	1					
*								
*gap used in nuclear core	tbl/fctn	1	1					
20102900	tbl/fctn	1	1					
*								
*steap-mat insulation (modified values for pressurizer heat loss)	tbl/fctn	1	1					
20103000	tbl/fctn	1	1					
*								
*pressurizer end cap and instrument heat loss - calculated values	tbl/fctn	1	1					
20103100	tbl/fctn	1	1					
*								
*cal-temp insulation (modified values for bl steam generator heat loss)	tbl/fctn	1	1					
20103200	tbl/fctn	1	1					
*								
.....								
*								
*thermal conductivity btu/(s ft f)								
*								
*	temp	cond	temp	cond	temp	cond		
*316L stainless steel								
20100101	32.00	.00215						
20100102	100.00	.00215	800.00	.00306	1600.00	.00397		
20100103	4000.00	.00397						
*								
*average two phase data								
20100201	32.00	.00006						
20100202	212.00	.00006	572.00	.00008	4000.00	.00008		
*								
*boron nitride (new curve from c.finneran..in 1/30/79 by disk)								
20100301	32.00	.00255						
20100302	200.00	.00241	500.00	.00216	1000.00	.00174		
20100303	1500.00	.00133	2000.00	.00093	2500.00	.00061		
20100304	3000.00	.00074	3500.00	.00074	4000.00	.00074		
*								
*constantan								
20100401	0.00	.00389	3000.00	.00389	4000.00	.00389		
*								
*incoloy 600								
20100501	32.00	.00236						
20100502	100.00	.00236	300.00	.00267	500.00	.00294		
20100503	700.00	.00322	900.00	.00350	1100.00	.00378		
20100504	4000.00	.00378						
*								
*grafoil								
20100601	32.00	.000799						

20100602	250.00	.000799	500.00	.000633	750.00	.000579				
20100603	1000.00	.000509	1250.00	.000494	1500.00	.000468				
20100604	200.00	.000463	300.00	.000486	400.00	.000486				
<hr/>										
*copper ca 102										
20100701	32.00	.0622	212.00	.0606	572.00	.0589				
20100702	932.00	.0575	4000.00	.0575						
<hr/>										
*cal-temp insul (increased by factor of 35.0 for vessel heat loss)										
20100801	0.00	3.2410e-4	100.00	3.2410e-4	200.00	3.4420e-4				
20100802	300.00	3.8500e-4	400.00	4.0540e-4	500.00	4.4530e-4				
20100803	600.00	4.8610e-4	700.00	5.3290e-4	800.00	5.8720e-4				
<hr/>										
*alumina (aluminum oxide)										
20100901	0.00	.00034722	300.00	.00034722						
<hr/>										
*inconel 718										
20101001	0.00	.0021657	200.00	.0022778	400.00	.0023333				
20101002	600.00	.0025555	800.00	.0026055	1000.00	.0026555				
20101003	1200.00	.0033333	1400.00	.0035555	1600.00	.0038333				
<hr/>										
*honeycomb - hexagonal matrix core										
20101101	0.00	2.61110e-5	700.00	2.61110e-5						
<hr/>										
*honeycomb - square matrix core										
20101201	0.00	2.27780e-5	700.00	2.27780e-5						
<hr/>										
*contact resistance (heaters to piping) (conductivities of air)										
20101301	0.00	3.5750e-6	80.00	4.2110e-6	170.00	4.8190e-6				
20101302	200.00	5.4000e-6	350.00	5.9500e-6	440.00	6.4810e-6				
20101303	530.00	6.9970e-6	620.00	7.4780e-6	710.00	7.9500e-6				
20101304	800.00	8.3940e-6	890.00	8.8490e-6	980.00	9.2750e-6				
<hr/>										
*steam generator filler pieces (conductivities from test grp-14-82)										
20101401	80.00	3.0280e-4	260.00	3.3610e-4	440.00	3.6950e-4				
20101402	620.00	4.0280e-4	800.00	4.3610e-4						
<hr/>										
*water										
20101501	32.0	88.6110e-6	104.0	100.8330e-6	176.0	107.2220e-6				
20101502	248.0	110.0000e-6	356.0	108.3370e-6	464.0	101.9440e-6				
20101503	500.0	98.0550e-6	572.0	86.6660e-6	700.0	85.5560e-6				
<hr/>										
*cal-temp insul (increased by factor of 7.0 for piping heat loss)										
20101601	0.00	6.4810e-5	100.00	6.4810e-5	200.00	6.8830e-5				
20101602	300.00	7.7000e-5	400.00	8.1080e-5	500.00	8.9050e-5				
20101603	600.00	9.7220e-5	700.00	10.5580e-5	800.00	11.740e-5				
<hr/>										
*cal-temp insul (increased by factor of 2.6125 for ilsg heat loss)										
20101701	0.00	2.4189e-5	100.00	2.4189e-5	200.00	2.5597e-5				
20101702	300.00	2.8740e-5	400.00	3.0255e-5	500.00	3.3233e-5				
20101703	600.00	3.6595e-5	700.00	3.9784e-5	800.00	4.3987e-5				
<hr/>										
*thermal liner - john's manville min-k 2000, 30-35 pcf										
20101801	300.00	1.1110e-5	600.00	1.2730e-5	1000.00	1.4810e-5				
<hr/>										
*cal-temp insul (increased by factor of 1.0 for pressurizer heat loss)										
20101901	0.00	9.2600e-6	100.00	9.2600e-6	200.00	9.8330e-6				
20101902	300.00	1.1000e-5	400.00	1.1580e-5	500.00	1.2720e-5				
<hr/>										
*titanium (used in pressurizer guard heaters)										
20102001	32.00	3.2434e-2	212.00	3.3076e-2	392.00	3.4521e-2				
20102002	572.00	3.6609e-2	752.00	3.9930e-2	1000.00	4.2603e-2				
<hr/>										
*magnesia oxide (used in pressurizer heater rods)										
20102101	100.00	4.6296e-4	1000.00	3.3795e-4						
<hr/>										
*chromite v (used in pressurizer heater rods)										
20102201	32.00	1.9749e-3	212.00	2.2153e-3	392.00	2.5048e-3				
20102202	572.00	2.7455e-3	752.00	2.8902e-3	1112.00	3.6127e-3				
<hr/>										
*incoloy 800 (used in pressurizer heater rods)										
20102301	70.00	1.8519e-3	1000.00	3.2175e-3	1500.00	4.0278e-3				
<hr/>										
*cal-temp insul (increased by factor of 1.0 for surge line heat loss)										
20102401	0.00	9.2600e-6	100.00	9.2600e-6	200.00	9.8330e-6				
20102402	300.00	1.1000e-5	400.00	1.1580e-5	500.00	1.2720e-5				
20102403	600.00	1.3890e-5	700.00	1.5230e-5	800.00	1.5780e-5				
<hr/>										
*0.357 carbon steel used for sg tube sheets										
20102501	32.00	.00944	68.00	.00917	212.00	.00889				
20102502	392.00	.00817	572.00	.00750	752.00	.00694				
20102503	1112.00	.00564	1472.00	.00478						
<hr/>										
*cal-temp insul (increased by factor of 1.0 for inlet plenum heat loss)										
20102601	0.00	9.2600e-6	100.00	9.2600e-6	200.00	9.8330e-6				
20102602	300.00	1.1000e-5	400.00	1.1580e-5	500.00	1.2720e-5				
20102603	600.00	1.3890e-5	700.00	1.5230e-5	800.00	1.5780e-5				
20102604	1000.00	1.9880e-5								
<hr/>										
*zircaloy used in nuclear core										
20102801	32.00	.00197	109.50	.00320	119.30	.00330				
20102802	1478.80	.00366	1498.60	.00369	1529.20	.00373				
20102803	1579.80	.00381	1599.60	.00384	1619.70	.00387				
20102804	1639.70	.00391	1759.80	.00411	1999.20	.00458				
<hr/>										
*gap used in nuclear core										
20102901	32.00	2.2500e-5	602.30	3.8520e-5	998.33	4.6500e-5				
20102902	1502.30	5.7800e-5	2006.30	6.7420e-5	5498.33	1.2040e-5				
<hr/>										
*temp-mat ins (increased by a factor of 1.0 for pressurizer heat loss)										
20103001	0.00	4.9770e-6	100.00	5.7870e-6	200.00	6.5970e-6				
20103002	300.00	7.6390e-6	400.00	8.7950e-6	500.00	1.0420e-5				
20103003	600.00	1.2040e-5	700.00	1.4120e-5	800.00	1.6320e-5				
20103004	1000.00	1.6960e-5								
<hr/>										

*cal-temp insul (increased by factor of 2.2049 for blsg heat loss)								
20103201	0.00	2.0340e-5	100.00	2.0340e-5	200.00	2.1671e-5	300.00	2.88729
20103202	300.00	2.4238e-5	400.00	2.5521e-5	500.00	2.8028e-5	1000.00	3.41018
20103203	600.00	3.0606e-5	700.00	3.3564e-5	800.00	3.6975e-5		3.6931
20103204	1000.00	4.3794e-5						3.6975
*								
*.....								
*volumetric heat capacity data (btu/cuft-f)								
*	temp	cap	temp	cap	temp	cap		
*316L stainless steel								
20100151	32.00	61.30	400.00	61.30	600.00	64.60		
20100152	800.00	67.10	1000.00	69.35	4000.00	69.35		
*								
*average two phase								
20100251	32.00	1.00	212.00	1.00	572.00	64.00		
20100252	4000.00	64.00						
*								
*boron nitride								
20100351	32.00	37.50	400.00	37.50	800.00	48.30		
20100352	1200.00	54.60	1600.00	58.30	2000.00	60.00		
20100353	2400.00	61.40	3400.00	62.50	4000.00	62.50		
*								
*constantan								
20100451	32.00	55.00	212.00	55.00	572.00	61.00		
20100452	932.00	67.00	1472.00	73.00	2192.00	78.00		
20100453	2552.00	84.00	3000.00	90.00	4000.00	90.00		
*								
*inconel 600								
20100551	32.00	52.225	4000.00	52.225				
*								
*grafoil								
20100651	32.00	11.90	80.40	11.90	170.40	14.70		
20100652	260.40	17.15	350.40	19.60	440.40	21.35		
20100653	530.40	22.40	620.40	23.80	710.40	25.20		
20100654	800.40	26.32	4000.00	26.32				
*								
*copper ca 102								
20100751	32.00	51.336	4000.00	51.336				
*								
*cal-temp insulation								
20100851	0.00	2.898	1000.00	2.898				
*								
*alumina (aluminum oxide)								
20100951	0.00	55.20	3000.00	55.20				
*								
*inconel 718								
20101051	0.00	48.5797	200.00	53.7597	400.00	55.458		
20101052	600.00	61.5912	800.00	65.1840	1000.00	69.290		
20101053	1200.00	74.4227	1400.00	76.9890	1600.00	82.121		
*								
*honeycomb - hexagonal matrix core								
20101151	0.00	2.28969	200.00	2.53081	400.00	2.6512		
20101152	600.00	2.89224	800.00	3.06095	1000.00	3.2537		
20101153	1200.00	3.49379	1400.00	3.61530	1600.00	3.8563		
*								
*honeycomb - square matrix core								
20101251	0.00	2.15978	200.00	2.38713	400.00	2.5008		
*								
20101252	600.00	2.71815	800.00	2.88729	1000.00	3.0691		
20101253	1200.00	3.29551	1400.00	3.41018	1600.00	3.5375		
*								
*contact resistacce (heaters to piping)								
20101351	0.00	0.00	3300.00	0.00				
*								
*steam generator filler piece (calculation from test grb-14-82)								
20101451	0.00	13.00	1000.00	13.00				
*								
*water (saturated)								
20101551	32.00	63.033	104.00	61.966	176.00	60.950		
20101552	288.00	59.895	356.00	58.553	464.00	57.85		
20101553	500.00	57.939	572.00	60.999	700.00	62.576		
*								
*cal-temp insulation								
20101651	0.00	2.898	1000.00	2.898				
*								
*cal-temp insulation								
20101751	0.00	2.898	1000.00	2.898				
*								
*thermal liner - john's manville mia-k 2000, 30-35 pcf								
20101851	400.00	7.475	800.00	8.125				
20101852	1200.00	8.775	1600.00	8.775				
*								
*cal-temp insulation								
20101951	0.00	2.898	1000.00	2.898				
*								
*aluminum (used in pressurizer guard heaters)								
20102051	32.00	35.177	10000.00	35.177				
*								
*magnesium oxide (used in pressurizer heater rods)								
20102151	10.00	43.07	10000.00	43.07				
*								
*nickchrome v (used in pressurizer heater rods)								
20102251	10.00	55.07	10000.00	55.07				
*								
*incoloy 800 (used in pressurizer heater rods)								
20102351	10.00	61.00	10000.00	61.00				
*								
*cal-temp insulation								
20102451	0.00	2.898	1000.00	2.898				
*								
*0.35% carbon steel								
20102551	68.00	51.40	3000.00	51.40				
*								
*cal-temp insulation								
20102651	0.00	2.898	1000.00	2.898				
*								
*mo2 used in nuclear core								
20102751	32.00	43.255	200.00	45.394	400.00	47.459		
20102752	600.00	49.072	800.00	50.308	1000.00	51.238		
20102753	1200.00	51.939	1500.00	52.721	2000.00	53.920		
20102754	2500.00	55.994	3000.00	60.096	4000.00	70.014		
*								
*zircaloy used in nuclear core								
20102851	32.00	27.820	1099.50	33.550	1199.80	35.190		
20102852	1478.80	35.190	1498.60	53.180	1529.20	59.330		
20102853	1579.80	62.190	1599.60	73.640	1619.70	77.790		

20102854	1639.70	79.780	1759.80	34.790	1999.20	34.790	20225002	0.0	1.0
*							20225003	1.1956	0.97220
*gap used in nuclear core							20225004	8.3695	0.55521
20102951	32.00	8.051e-5	5408.30	8.0514e-5			20225005	9.5552	0.50440
*							20225006	19.1304	0.32739
*temp-mat insulation							20225007	29.8913	0.23458
20103051	0.00	2.125	1000.00	2.125			20225008	38.2608	0.22025
*							20225009	59.7836	0.21159
*pressurizer end cap and instrument heat loss							20225010	62.1739	0.19573
20103151	0.00	0.000	1000.00	0.000			20225011	64.5552	0.18887
*							20225012	66.9555	0.04289
*cal-temp insulation							20225013	68.1521	0.0
20103251	0.00	2.838	1000.00	2.838			20225014	4000.0	0.0
*							*		
*							20225000	reac-t	413 * broken loop pcp
*****	*****	*****	*****	*****	*****	*****	20225001	-1.0	1.0
*	tables	*					20225002	0.0	1.0
*****	*****	*****	*****	*****	*****	*****	20225003	1.1956	0.98527
*							20225004	8.3695	0.63678
*	***** core power *****						20225005	10.7608	0.55975
*							20225006	20.3260	0.42278
*	table	trip	time coef	power coef			20225007	40.6521	0.40220
20225000	power	419	1.0	1.000 * btu			20225008	59.7836	0.40315
*							20225009	60.9782	0.32766
*	time	power	(ans standard decay curve)				20225010	64.5552	0.25842
20225001	0.0	1.000					20225011	65.7608	0.16130
20225002	1.1957	.98216					20225012	69.3478	0.0
20225003	5.9783	.29432					20225013	4000.0	0.0
20225004	7.1739	.22553					*		
20225005	10.7608	.17781					*****	*****	*****
20225006	11.9555	.10006					*		
20225007	21.5217	.05289					*		
20225008	31.0870	.04263					*		
20225009	51.4130	.03880					*****	*****	*****
20225010	81.3148	.03500					*		
20225011	100.4348	.03313					*		
20225012	979.2388	.02880					*heat loss due to intact loop pump passive cooling, 20.0 kw at full flow		
*							*		
*	1.0 btu = 1055.056 joules (international table)						**		
*							**		
*****	*****	*****	*****	*****	*****	*****	**		
*	pressurizer heater rod power	*					**		
*							**		
*	table	trip	time coef	power coef			**		
20225900	power	419	1.0	10.4200e-3 * btu			**		
*							**		
*	time	power					**		
20225901	0.0	0.000					**		
20225902	10000.0	0.000					**		
*							**		
*	pump speed tables (normalized speed)	*					**		
*							**		
*****	*****	*****	*****	*****	*****	*****	**		
*							**		
*	heat loss due to intact loop pump active cooling, 4.3 kw always						**		
*							**		
*	table	trip					**		
20225000	react-t	412 * intact loop pump					**		
*							**		
*	time	norm pump speed					**		
20225001	-1.0	1.0					**		
*							**		
*	time	norm h.t.rate					**		
*							**		

2025101	0.0	1.000					
2025102	2000.0	1.000					
*							

* heat loss due to broken loop pump passive cooling, 14.7 kw at full flow							
* from test so-2b-38, h. s. crapo, hsc-2-84, 3 feb 1984							
* 1.0 btu = 1055.055 joules (international table)							
*							
**	table	trip	time coef	rate coef			
2025100	btrate	413	1.0	9.1631	* btu/s-ft ²		
**	time	norm b.t.rate					
2025101	-1.0	1.000					
2025102	0.0	1.000					
2025103	9.6	0.590					
2025104	13.6	0.498					
2025105	20.8	0.407					
2025106	30.4	0.385					
2025107	60.0	0.385					
2025108	64.8	0.000					
2025109	4000.0	0.000					
**							
* heat loss due to broken loop pump active cooling, 4.3 kw always							
* from test so-2b-38, h. s. crapo, hsc-2-84, 3 feb 1984							
*							
**	table	trip	time coef	rate coef			
2025100	btrate	413	1.0	2.6804	* btu/s-ft ²		
**	time	norm b.t.rate					
2025101	0.0	1.000					
2025102	2000.0	1.000					
*							

*							
* specified heat transfer coefficients on piping insulation surface							
* (values calculated for free convection in air + radiation)							
*							
*	table						
20210000	btc-temp						
*	temp	b.t.coef	(btu/s-ft ² -f)				
2021001	100.0	0.00136					
2021002	150.0	0.00206					
2021003	200.0	0.00247					
2021004	300.0	0.00302					
2021005	500.0	0.00374					
2021006	750.0	0.00438					
*							
* specified heat transfer coefficients on ilsg insulation surface							
* (values calculated for free convection in air + radiation)							
*							
*	table						
20220000	btc-temp	0	1.0	0.0	3.5426		
*	temp	b.t.coef	(btu/s-ft ² -f)				
2022001	100.0	0.00136					
2022002	150.0	0.00206					
2022003	200.0	0.00247					
*							
***** power tables for piping heaters *****							
*							
*	*****	power table for guard heater power bus 110	*****				
*	*****	(power to intact and broken loop hot legs)	*****				
*							
*	table	trip	time coef	power coef			
20211000	power	430	1.0	8.4380e-3	* w		
*							
*	time		power				
20211001	0.0		1.00				

20211102	10000.0	1.00			*	time	power
*					20211701	-1.0	1.00
*****	*****	*****	*****	*****	20211702	0.0	0.00
*					20211703	10000.0	0.00
*	***** power table for guard heater power bus 111 *****				*		
*	***** (power to broken loop pump suction) *****				*****		
*					*	control variables	*
*	table	trip	time coef	power coef	**		
20211100	power	431	1.0	4.0130e-3 * mW	**		
*					**	1 vessel interface level (-13 -578)	**
*	time		power		**	2 core interface level (105 -501)	**
20211101	0.0		1.00		**	3 downcomer interface level (+23 -578)	**
20211102	10000.0		1.00		**	4 upper plenum interface level (+153 -13)	**
*					**	5 upper head interface level (+421 +160)	**
*	*****	*****	*****	*****	**	6 pressurizer interface level	**
*	***** power table for guard heater power bus 112 *****				**	7 intact loop u-tube up side interface level	**
*	***** (power to intact and broken loop cold legs) *****				**	8 intact loop u-tube down side interface level	**
*					**	9 intact loop pump suction down side interface level	**
*	table	trip	time coef	power coef	**	10 intact loop pump suction up side interface level	**
202111200	power	432	1.0	3.1220e-3 * mW	**	11 broken loop u-tube up side interface level	**
*					**	12 broken loop u-tube down side interface level	**
*	time		power		**	13 broken loop pump suction down side interface level	**
202111201	0.0		1.00		**	14 broken loop pump suction up side interface level	**
202111202	10000.0		1.00		**	15 intact loop steam generator riser interface level	**
*					**	16 intact loop steam generator downcomer interface level	**
*	*****	*****	*****	*****	**	17 broken loop steam generator riser interface level	**
*	***** power table for guard heater power bus 113 *****				**	18 broken loop steam generator downcomer interface level	**
*	***** (power to intact loop pump suction) *****				**	19 intact loop steam generator secondary riser mass	**
*					**	20 intact loop steam generator secondary downcomer mass	**
*	table	trip	time coef	power coef	**	21 intact loop steam generator secondary total mass	**
202111300	power	433	1.0	8.2610e-3 * mW	**	22 broken loop steam generator secondary riser mass	**
*					**	23 broken loop steam generator secondary downcomer mass	**
*	time		power		**	24 broken loop steam generator secondary total mass	**
202111301	0.0		1.00		**	25 total steam generator secondary mass	**
202111302	10000.0		1.00		**	26 energy removed from primary to secondary by intact loop sg	**
*					**	27 energy removed from primary to secondary by broken loop sg	**
*	*****	*****	*****	*****	**	28 energy removed from core heater rods to primary coolant	**
*	***** power table for guard heater power bus 116 *****				**	29 maximum core heater rod temperature	**
*	***** (power to external heaters on vessel and downcomer) *****				**	150-151 control system for core heater rod power	**
*					**	200-221 control system to redistribute power on vessel heaters	**
*	table	trip	time coef	power coef	**	250-251 control system to obtain desired intact loop mass flow rate	**
202111600	power	436	1.0	19.8300e-3 * mW	**	350-351 control system to obtain desired broken loop mass flow rate	**
*					**	400 fluid mass in downcomer	**
*	time		power		**	401 fluid mass in lower plenum	**
202111601	0.0		1.00		**	402 fluid mass in core	**
202111602	10000.0		1.00		**	403 fluid mass in upper plenum	**
*					**	404 fluid mass in upper head	**
*	*****	*****	*****	*****	**	405 fluid mass in bypass line, support columns, guide tubes	**
*	***** power table for guard heater power bus 117 *****				**	406 fluid mass in pressurizer	**
*	***** (power to external heaters on pressurizer) *****				**	407 fluid mass in intact loop hot leg	**
*					**	408 fluid mass in intact loop u-tubes	**
*	table	trip	time coef	power coef	**	409 fluid mass in intact loop cold leg	**
202111700	power	437	1.0	1.5930e-3 * mW	**	410 fluid mass in broken loop hot leg	**
*					**	411 fluid mass in broken loop u-tubes	**
*	*****	*****	*****	*****	**	412 fluid mass in broken loop cold leg	**
*	***** power table for guard heater power bus 118 *****				**	413 total primary coolant system fluid mass	**
*	***** (power to external heaters on vessel and downcomer) *****				**	501 vessel delta p -13 to -578 cm	**
*					**	502 vessel core delta p -105 to -501 cm	**

** 503 vessel downcomer delta p 29 to -578 cm **
 ** 504 vessel upper plenum delta p 135 to -13 cm **
 ** 505 vessel upper head delta p 421 to 160 cm **
 ** 506 pressurizer delta p 632 to 30 cm **
 ** 507 intact loop steam generator u-tube upside delta p 926 to -57e **
 ** 508 intact loop steam generator u-tube downside delta p 926 to -57x **
 ** 509 intact loop pump suction downside delta p -57x to 114 **
 ** 510 intact loop pump suction upside delta p 114 to 116 **
 ** 511 broken loop steam generator u-tube upside delta p 925 to -57e **
 ** 512 broken loop steam generator u-tube downside delta p 925 to -57x **
 ** 513 broken loop pump suction downside delta p -57x to 665 **
 ** 514 broken loop pump suction upside delta p 665 to 673 **
 ** 515 intact loop steam generator riser delta p 1117 to 89 cm **
 ** 516 intact loop steam generator downcomer delta p 1117 to 51 cm **
 ** 517 broken loop steam generator riser delta p 1186 to -7 cm **
 ** 518 broken loop steam generator downcomer delta p 1186 to 18 cm **
 ** 519 broken loop steam generator downcomer delta p between horizs **
 ** 531 vessel collapsed level -13 to -578(ref) cm **
 ** 532 vessel core collapsed level -105 to -501(ref) cm **
 ** 533 vessel downcomer collapsed level 29 to -578(ref) cm **
 ** 534 vessel upper plenum collapsed level 135 to -13(ref) cm **
 ** 535 vessel upper head collapsed level 421 to 160(ref) cm **
 ** 536 pressurizer collapsed level 632 to 30(ref) cm **
 ** 537 ilsg u-tube upside collapsed level 926 to -57e(ref) cm **
 ** 538 ilsg u-tube downside collapsed level 926 to -57x(ref) cm **
 ** 539 intact loop pump suction downside collapsed level ref 116 cm **
 ** 540 intact loop pump suction upside collapsed level ref 116 cm **
 ** 541 blsg u-tube upside collapsed level 925 to -57e(ref) cm **
 ** 542 blsg u-tube downside collapsed level 925 to -57x(ref) cm **
 ** 543 broken loop pump suction downside collapsed level ref 665 cm **
 ** 544 broken loop pump section upside collapsed level ref 665 cm **
 ** 545 intact loop steam generator riser collapsed level ref 89 cm **
 ** 546 intact loop steam generator downcomer collapsed level ref 51cm**
 ** 547 broken loop steam generator riser collapsed level ref -7 cm **
 ** 548 broken loop steam generator downcomer collapsed level ref 18cm**
 ** 549 broken loop steam generator dmcw hor collapsed level ref 18cm**
 ** 551 vessel collapsed level -13 to -578 ref cold leg **
 ** 552 vessel core collapsed level -105 to -501 ref cold leg **
 ** 553 vessel downcomer collapsed level 29 to -578 ref cold leg **
 ** 554 vessel upper plenum collapsed level 135 to -13 ref cold leg **
 ** 555 vessel upper head collapsed level 421 to 160 ref cold leg **
 ** 556 pressurizer collapsed level 632 to 30 ref zero cm **
 ** 557 ilsg u-tube upside collapsed level 926 to -57e ref tube sheet **
 ** 558 ilsg u-tube downside collapsed level 926 to -57x ref tub sht **
 ** 559 intact loop pump section downside collapsed level ref cold leg**
 ** 570 intact loop pump section upside collapsed level ref cold leg **
 ** 571 blsg u-tube upside collapsed level 925 to -57e ref tube sheet **
 ** 572 blsg u-tube downside collapsed level 925 to -57x ref tub sht **
 ** 573 broken loop pump section downside collapsed level ref cold leg**
 ** 574 broken loop pump section upside collapsed level ref cold leg **
 ** 575 intact loop steam generator riser collapsed level ref tub sht **
 ** 576 intact loop steam generator downcomer collpsd lvl ref tub sht **
 ** 577 broken loop steam generator riser collapsed level ref tub sht **
 ** 578 broken loop steam generator downcomer collpsd lvl ref tub sht **
 ** 579 broken loop steam generator dmcw hor collpsd lvl ref tub sht **
 ** 606-610 control system to obtain desired mass in intact loop sg **
 ** 620 intact loop steam generator recirculation ratio **
 ** 625 intact loop steam generator circulation ratio **
 ** 633-637 control system to hold bl steam dome pressure within band **
 ** 706-710 control system to obtain desired mass in broken loop sg **
 ** 720 broken loop steam generator recirculation ratio **
 ** 725 broken loop steam generator circulation ratio **
 ** 730-737 control system to hold bl steam dome pressure within band **
 ** 800 total heat loss monitoring system **
 ** 930-935 control system to obtain desired pressurizer liquid level **
 ** 930-999 control system for pressurizer internal heater rods **
 ** *****
 * control variables for comparison to equivalent semiscale data
 * liquid levels *****
 * name type coef init val flg
 * 20500100 vslvl1 sm 30.48 -13.000 1 * vessel level (cm)
 * * (-13 to -578)
 20500101 -19.05533 0.073591 voidf 153010000
 20500102 2.765333 voidf 162010000
 20500103 1.000833 voidf 151010000
 20500104 2.0 voidf 150060000
 20500105 2.0 voidf 150050000
 20500106 2.0 voidf 150040000
 20500107 2.0 voidf 150030000
 20500108 2.0 voidf 150020000
 20500109 2.0 voidf 150010000
 20500110 1.635333 voidf 140010000
 20500111 0.721917 voidf 130010000
 20500112 0.466667 voidf 120010000
 * 20500200 corelvl sm 30.48 -105.092 1 * core level (cm)
 * * (-105. to -501.)
 20500201 -16.42833 0.16667 voidf 140010000
 20500202 2.00000 voidf 150010000
 20500203 2.00000 voidf 150020000
 20500204 2.00000 voidf 150030000
 20500205 2.00000 voidf 150040000
 20500206 2.00000 voidf 150050000
 20500207 2.00000 voidf 150060000
 20500208 0.81375 voidf 161010000
 * 20500300 dmclvl sm 30.48 30.480 1 * downcomer lvl (cm)
 * * (+29 to -578)
 20500301 -19.08608 2.0 voidf 101010000
 20500302 2.260833 voidf 110010000
 20500303 1.000833 voidf 110020000
 20500304 2.0 voidf 110030000
 20500305 2.0 voidf 110040000
 20500306 2.0 voidf 110050000
 20500307 2.0 voidf 110060000
 20500308 2.0 voidf 110070000
 20500309 1.465667 voidf 110080000
 20500310 1.207667 voidf 110090000
 20500311 0.962500 voidf 110100000
 20500312 0.721917 voidf 130010000
 20500313 0.466667 voidf 120010000
 *

20504900 up1vl1 scr 39.48 136.144 1 * up plane lvl (cm)
 * (*135 to -13)
 20504901 -0.426509 2.55000 voidf 164010000
 20504902 2.343176 voidf 163010000
 *
 20505000 rh1vl1 scr 39.48 423.570 1 * op. head lvl (cm)
 * (*421 to +160)
 2050501 45.120 2.880833 voidf 194010000
 2050502 3.453333 voidf 193010000
 2050503 1.965833 voidf 192010000
 2050504 0.476667 voidf 191010000
 *
 2050600 pzlvl1 scr 30.48 625.793 1 * pzr level (cm)
 *
 2050601 0.0 2.50 voidf 999010000
 2050602 2.5625 voidf 999020000
 2050603 2.5625 voidf 999030000
 2050604 2.5625 voidf 999040000
 2050605 2.5625 voidf 999050000
 2050606 2.5625 voidf 999060000
 2050607 2.583333 voidf 999070000
 2050608 2.09375 voidf 999080000
 2050609 0.541667 voidf 997010000
 *
 *
 2050700 ilsts scr 30.48 925.830 1 * il u-tube up
 * (*cm) - from
 2050701 -1.75 1.750000 voidf 215010000 * -57 cm below
 2050702 7.952500 voidf 220010000 * top of tube sheet
 2050703 7.9108334 voidf 220020000 * to top of model
 2050704 7.9108334 voidf 220030000 * u-tube
 2050705 6.5999883 voidf 220040000
 *
 2050820 iltd scr 30.48 925.830 1 * il -tube down
 * (*cm) - from
 2050801 -1.75 1.750000 voidf 225010000 * -57 cm below
 2050802 6.5999883 voidf 220050000 * top of tube sheet
 2050803 7.9108334 voidf 220060000 * to top of model
 2050804 7.9108334 voidf 220070000 * u-tube
 2050805 7.9525000 voidf 220080000
 *
 2050900 ilpsd scr 30.48 151.803 1 * il p-s down (cm)
 * (*dpi-57x14)
 2050901 -9.229167 0.6354167 voidf 230010000
 *
 * heat slab... broken loop, vessel nozzles (3 in. sch-160)
 * note - heat slab contains only volume lengths which
 * are not heated
 * left boundary = broken loop primary coolant vessel nozzles (301,363)
 * right boundary = ambient volumes (801,803)
 *
 * gl data nb np type s-flg l-cor
 12004000 2 5 2 1 0.10333333
 * mesh loc flg frm flg
 12500100 0 1
 * geometry no itv r-cor
 1250101 3 0.1500
 * materials cmp no itv no

```

12500201      1      3
*
*source dis  source  itv no
12500301      0.0      3
*
*init temp    flg
12500400      0
*
*      temp mesh  temp mesh  temp mesh  temp mesh
12500401 540.7  1  436.6  2  345.9  3  265.0  4
*
*1-body      by-vol   inc   b-cdt   a-code   cy-length   bt-str-no
12500501 2500010000      0      1      1      2.26167      1
*
*r-body      by-vol   inc   b-cdt   a-code   cy-length   bt-str-no
12500601      0      0      2251      1      2.26167      1
*
*source      type  is-aplr   l-dr-bt   r-dr-bt   bt-str-no
12500701      0      0          0          0          1
*
*1-h-st      chf-btr   hy-dia   b-eq-dia   ch-length   bt-str-no
12500801      0      0.0      0.0      0.0      2.26167      1
12500801 0.0 10.0 10.0 0 0 0 0 1.0 1
*
*r-h-st      chf-btr   hy-dia   b-eq-dia   ch-length   bt-str-no
12500901      0      0.0      0.0      0.0      2.26167      1
12500901 0.0 10.0 10.0 0 0 0 0 1.0 1
*****
* heat slab... pressurizer heat transfer to pressurizer walls
* without liner - aluminum sheath heated by heater tape
*****
*
* left boundary = component 999
* right boundary = ambient volume (316)
*
*gl data      nh      np      type      s-flg      l-cor
19990000      8      14      2      1      .1512917
*
*mesh      loc flg      frm flg
19990100      0      1
*
*geometry      no itv      r-cor
19990101      3      0.12325
*
*materials      cmp no      itv no
19990201      1      3
*
*source dis  source  itv no
12500301      0.0      3
*
*init temp    flg
12500400      0
*
*      temp mesh  temp mesh  temp mesh  temp mesh
12500401 531.1  1  434.0  2  350.8  3  277.4  4
*
*1-body      by-vol   inc   b-cdt   a-code   cy-length   bt-str-no
19990501 999010000      0      1      1      2.500000      1
19990502 999020000     10000      1      1      2.552500      6
19990503 999070000      0      1      1      2.533333      7
19990504 999080000      0      1      1      2.083750      8
*
*r-body      by-vol   inc   b-cdt   a-code   cy-length   bt-str-no
19990601 816010000      0      4100      1      2.500000      1
19990602 816010000      0      4100      1      2.552500      6

```

19990603 816010000 0 4100 1 2.583333 7
 19990604 816010000 0 4100 1 2.093750 8
 *
 *source type is-mlr l-dr-bt r-dr-bt bt-str-no
 19990701 117 .125065 0 0 1
 19990702 117 .128192 0 0 6
 19990703 117 .129234 0 0 7
 19990704 117 .104742 0 0 8
 *
 *l-h-st chf-btr by-dia b-eq-dia ch-length bt-str-no
 *19990801 0 .2858333 .2914500 2.500000 1
 19990801 0.29145 10.0 10.0 0 0 0 0 1.0 1
 *19990802 0 .3025833 .3025833 2.562500 6
 19990802 0.30258 10.0 10.0 0 0 0 0 1.0 6
 *19990803 0 .3025833 .3025833 2.583333 7
 19990803 0.30258 10.0 10.0 0 0 0 0 1.0 7
 *19990804 0 .1005325 .2251253 2.093750 8
 19990804 0.22512 10.0 10.0 0 0 0 0 1.0 8
 *
 *r-h-st chf-btr by-dia b-eq-dia ch-length bt-str-no
 *19990901 0 0.0 0.0 2.500000 1
 19990901 0.0 10.0 10.0 0 0 0 0 1.0 1
 *19990902 0 0.0 0.0 2.562500 6
 19990902 0.0 10.0 10.0 0 0 0 0 1.0 6
 *19990903 0 0.0 0.0 2.583333 7
 19990903 0.0 10.0 10.0 0 0 0 0 1.0 7
 *19990904 0 0.0 0.0 2.093750 8
 19990904 0.0 10.0 10.0 0 0 0 0 1.0 8
 *
 * heat slab... pressurizer heater rods —— data from rasa corp.,
 * beater rod manufacturer
 *
 * left boundary = adiabatic
 * right boundary = component 999
 *
 *gl data nh np type s-flg l-cor
 19992000 1 8 2 1 0.0
 *
 *mesh loc flg frm flg
 19992100 0 1
 *
 *geometry no itv r-cor no itv r-cor no itv r-cor
 19992101 2 2.1539e-2 1 2.1833e-2 2 2.6953e-2
 19992102 2 3.1042e-2
 *
 *materials cap no itv no cap no itv no cap no itv no
 19992201 21 2 22 3 21 5
 19992202 23 7
 *
 *source dis source itv no source itv no source itv no
 19992301 0.0 2 1.0 3 0.0 7
 *
 *init temp flg
 19992400 0
 *
 * temp mesh

19992401 631.0 8
 *
 *l-body by-vol inc b-cdt a-code cy-length bt-str-no
 19992501 999010000 0 0 0 0.0 1
 *
 *r-body by-vol inc b-cdt a-code cy-length bt-str-no
 19992601 999060000 0 1 1 12.0 1
 *
 *source type is-mlr l-dr-bt r-dr-bt bt-str-no
 19992701 1099 1.0 0 0 1
 *
 *l-h-st chf-btr by-dia b-eq-dia ch-length bt-str-no
 *19992801 0 0.0 0.0 2.093750 1
 19992801 0.0 10.0 10.0 0 0 0 0 1.0 1
 *
 *r-h-st chf-btr by-dia b-eq-dia ch-length bt-str-no
 *19992901 0 .1005325 .1901660 2.093750 1
 19992901 0.1901660 10.0 10.0 0 0 0 0 1.0 1
 *

 * heat slab... pressurizer heat transfer out end caps and instrument ports - thermal conductivity calculated to match test

 *
 * left boundary = component 999
 * right boundary = ambient volume (806)
 *
 *gl data nh np type s-flg l-cor
 19993000 8 3 2 1 .1512917
 *
 *mesh loc flg frm flg
 19993100 0 1
 *
 *geometry no itv r-cor
 19993101 2 .449350
 *
 *materials cap no itv no
 19993201 31 2
 *
 *source dis source itv no
 19993301 0.0 2
 *
 *init temp flg
 19993400 0
 *
 * temp mesh temp mesh temp mesh
 19993401 602.0 1 370.0 2 140.0 3
 *
 *l-body by-vol inc b-cdt a-code cy-length bt-str-no
 19993501 999010000 0 1 1 2.500000 1
 19993502 999020000 10000 1 1 2.562500 6
 19993503 999030000 0 1 1 2.583333 7
 19993504 999040000 0 1 1 2.093750 8
 *
 *r-body by-vol inc b-cdt a-code cy-length bt-str-no
 19993601 806010000 0 4100 1 2.500000 1
 19993602 806010000 0 4100 1 2.562500 6
 19993603 806010000 0 4100 1 2.583333 7

1999364 866010000 0 4100 1 2.093750 8
 *
 *source type is-splr l-dr-bt r-dr-bt bt-str-no
 19993701 0 0 0 0 0 0 8
 *
 *l-h-st chf-btr by-dia b-eq-dia ch-length bt-str-no
 *19993801 0 .265333 .2914500 2.500000 1
 19993801 0.29145 10.0 10.0 0 0 0 0 1.0 1
 *19993802 0 .302533 .302533 2.562500 6
 19993802 0.302538 10.0 10.0 0 0 0 0 1.0 6
 *19993803 0 .302533 .302533 2.583333 7
 19993803 0.302538 10.0 10.0 0 0 0 0 1.0 7
 *19993804 0 .1005325 .2251253 2.093750 8
 19993804 0.22512 10.0 10.0 0 0 0 0 1.0 8
 *
 *r-h-st chf-btr by-dia b-eq-dia ch-length bt-str-no
 *19993901 0 0.0 0.0 2.500000 1
 19993901 0.0 10.0 10.0 0 0 0 0 1.0 1
 *19993902 0 0.0 0.0 2.562500 6
 19993902 0.0 10.0 10.0 0 0 0 0 1.0 6
 *19993903 0 0.0 0.0 2.583333 7
 19993903 0.0 10.0 10.0 0 0 0 0 1.0 7
 *19993904 0 0.0 0.0 2.093750 8
 19993904 0.0 10.0 10.0 0 0 0 0 1.0 8
 *
 ***** beat slab... pressurizer surge line heat loss *****
 *
 * left boundary = component 997
 * right boundary = ambient volume (807)
 *
 *gl data nh np type s-flg l-cor
 19970000 2 5 2 1 .0154167
 *
 *mesh loc flg frm flg
 19970100 0 1
 *
 *geometry no itv r-cor no itv r-cor
 19970101 2 .035000 2 .054460
 *
 *materials cap no itv no cap no itv no
 19970201 1 2 24 4
 *
 *source dis source itv no
 19970301 0.0 4
 *
 *init temp flg
 19970400 0
 *
 * temp mesh temp mesh
 19970401 602.0 2 602.0 5
 *
 *l-body by-vol inc b-cut a-code cy-length bt-str-no
 19970501 997020000 0 1 1 5.6458333 1
 19970502 997030000 0 1 1 4.0625000 2
 *
 *r-body by-vol inc b-cut a-code cy-length bt-str-no
 19970601 807010000 0 4100 1 5.6458333 1
 19970602 807010000 0 4100 1 4.0625000 2
 *
 *source type is-splr l-dr-bt r-dr-bt bt-str-no
 19970701 0 0 0 0 0 2
 *
 *l-h-st chf-btr by-dia b-eq-dia ch-length bt-str-no
 *19970801 0 0.0 0.0 0.0 2
 19970801 0.0 10.0 10.0 0 0 0 0 1.0 2
 *
 *r-h-st chf-btr by-dia b-eq-dia ch-length bt-str-no
 *19970901 0 0.0 0.0 0.0 2
 19970901 0.0 10.0 10.0 0 0 0 0 1.0 2
 *
 ***** beat structure thermal property data *****
 *
 * type cn flg ca flg
 *316L stainless steel
 20100100 tbl/fctn 1 1
 *
 *average two phase data
 20100200 tbl/fctn 1 1
 *
 *boron nitride
 20100300 tbl/fctn 1 1
 *
 *constantan
 20100400 tbl/fctn 1 1
 *
 *inconel 600
 20100500 tbl/fctn 1 1
 *
 *grafoil (grafoil is a trade name of a union carbide product)
 20100600 tbl/fctn 1 1
 *
 *copper ca 102 (oxyen free copper)
 20100700 tbl/fctn 1 1
 *
 *cal-temp insulation (modified values for vessel heat loss)
 20100800 tbl/fctn 1 1
 *
 *alumina (aluminum oxide)
 20100900 tbl/fctn 1 1
 *
 *inconel 718
 20101000 tbl/fctn 1 1 ..
 *
 *honeycomb - hexagonal matrix core
 20101100 tbl/fctn 1 1
 *
 *honeycomb - square matrix core
 20101200 tbl/fctn 1 1
 *
 *contact resistance properties (conductivity of air; storage = 0.0)

20101300 tbl/fctn 1 1
 *
 *steam generator filler piece construction
 20101400 tbl/fctn 1 1
 *
 *water
 20101500 tbl/fctn 1 1
 *
 *cal-temp insulation (modified values for piping heat loss)
 20101600 tbl/fctn 1 1
 *
 *cal-temp insulation (modified values for steam generator heat loss)
 20101700 tbl/fctn 1 1
 *
 *thermal liner - john's manville min-k 2000, 30-35 pcf
 20101800 tbl/fctn 1 1
 *
 *cal-temp insulation (modified values for pressurizer heat loss)
 20101900 tbl/fctn 1 1
 *
 *alumina (used in pressurizer guard heaters)
 20102000 tbl/fctn 1 1
 *
 *magnesia oxide (used in pressurizer heater rods)
 20102100 tbl/fctn 1 1
 *
 *nickelue v (used in pressurizer heater rods)
 20102200 tbl/fctn 1 1
 *
 *incoloy 800 (used in pressurizer heater rods)
 20102300 tbl/fctn 1 1
 *
 *cal-temp insulation (for pressurizer surge line heat loss)
 20102400 tbl/fctn 1 1
 *
 * 0.35% carbon steel used for sg tube sheets
 20102500 tbl/fctn 1 1
 *
 *cal-temp insulation (for inlet plenum heat loss)
 20102600 tbl/fctn 1 1
 *
 *zircaloy used in nuclear core
 20102700 tbl/fctn 1 1
 *
 *gap used in nuclear core
 20102800 tbl/fctn 1 1
 *
 *temp-mat insulation (modified values for pressurizer heat loss)
 20102900 tbl/fctn 1 1
 *
 *pressurizer end cap and instrument heat loss - calculated values
 20103000 tbl/fctn 1 1
 *
 *cal-temp insulation (modified values for bl steam generator heat loss)
 20103100 tbl/fctn 1 1
 *
 *.....
 *
 *thermal conductivity btu/(s ft f)
 *
 * temp cond temp cond temp cond
 *316l stainless steel
 20100101 32.00 .00215
 20100102 100.00 .00215 800.00 .00306 1600.00 .00397
 20100103 4000.00 .00397
 *
 *average two phase data
 20100201 32.00 .00006
 20100202 212.00 .00006 572.00 .00008 4000.00 .00008
 *
 * boron nitride (new curve from c.finneran.. in 1/30/79 by disk)
 20100301 32.00 .00255
 20100302 200.00 .00241 500.00 .00216 1000.00 .00174
 20100303 1500.00 .00133 2000.00 .00099 2500.00 .00061
 20100304 3000.00 .00074 3500.00 .00074 4000.00 .00074
 *
 *constantan
 20100401 0.00 .00389 3000.00 .00389 4000.00 .00389
 *
 *inconel 600
 20100501 32.00 .00236
 20100502 100.00 .00236 300.00 .00257 500.00 .00294
 20100503 700.00 .00322 900.00 .00350 1100.00 .00378
 20100504 4000.00 .00378
 *
 *grafoil
 20100601 32.00 .000799
 20100602 250.00 .000799 500.00 .000633 750.00 .000579
 20100603 1000.00 .000509 1250.00 .000484 1500.00 .000468
 20100604 2000.00 .000463 3000.00 .000486 4000.00 .000486
 *
 *copper ca 102
 20100701 32.00 .0622 212.00 .0626 572.00 .0589
 20100702 932.00 .0575 4000.00 .0575
 *
 *cal-temp insul (increased by factor of 35.0 for vessel heat loss)
 20100801 0.00 3.2410e-4 100.00 3.2410e-4 200.00 3.4420e-4
 20100802 300.00 3.8500e-4 400.00 4.0540e-4 500.00 4.4530e-4
 20100803 600.00 4.8610e-4 700.00 5.3290e-4 800.00 5.8720e-4
 *
 *alumina (aluminum oxide)
 20100901 0.00 .00035722 3300.00 .00035722
 *
 *inconel 718
 20101001 0.00 .0021667 200.00 .0022778 400.00 .0023333
 20101002 600.00 .0025556 800.00 .0028056 1000.00 .0030556
 20101003 1200.00 .0033333 1400.00 .0035556 1600.00 .0038333
 *
 *honeycomb - hexagonal matrix core
 20101101 0.00 2.61110e-5 700.00 2.61110e-5
 *
 *honeycomb - square matrix core
 20101201 0.00 2.27780e-5 700.00 2.27780e-5

* contact resistance (heaters to piping)	(conductivities of air)					
20101301	0.00	3.575e-6	80.00	4.211e-6	170.00	4.819e-6
20101302	260.00	5.400e-6	350.00	5.950e-6	440.00	6.481e-6
20101303	530.00	6.997e-6	620.00	7.478e-6	710.00	7.950e-6
20101304	800.00	8.394e-6	890.00	8.842e-6	980.00	9.275e-6
*						
* steam generator filler pieces (conductivities from test gtb-14-82)						
20101401	80.00	3.028e-4	260.00	3.361e-4	440.00	3.695e-4
20101402	620.00	4.028e-4	800.00	4.361e-4		
*						
* water						
20101501	32.0	88.611e-6	104.0	100.833e-6	176.0	107.222e-6
20101502	248.0	110.000e-6	356.0	108.337e-6	464.0	101.944e-6
20101503	500.0	98.655e-6	572.0	86.666e-6	700.0	86.666e-6
*						
* cal-temp insul (increased by factor of 7.0 for piping heat loss)						
20101601	0.00	6.481e-5	100.00	6.481e-5	200.00	6.883e-5
20101602	300.00	7.700e-5	400.00	8.108e-5	500.00	8.905e-5
20101603	600.00	9.722e-5	700.00	10.658e-5	800.00	11.744e-5
*						
* cal-temp insul (increased by factor of 2.6125 for ilsg heat loss)						
20101701	0.00	2.4189e-5	100.00	2.4189e-5	200.00	2.5697e-5
20101702	300.00	2.8740e-5	400.00	3.0255e-5	500.00	3.3233e-5
20101703	600.00	3.6595e-5	700.00	3.9784e-5	800.00	4.3987e-5
*						
* thermal liner - john's manville min-k 2000, 30-35 pcf						
20101801	300.00	1.1110e-5	600.00	1.273e-5	1000.00	1.4810e-5
*						
* cal-temp insul (increased by factor of 1.0 for pressurizer heat loss)						
20101901	0.00	9.2600e-6	100.00	9.2600e-6	200.00	9.833e-6
20101902	300.00	1.1000e-5	400.00	1.1580e-5	500.00	1.2720e-5
20101903	600.00	1.3890e-5	700.00	1.5230e-5	800.00	1.6780e-5
20101904	1000.00	1.9880e-5				
*						
* aluminum (used in pressurizer guard heaters)						
20102001	32.00	3.2344e-2	212.00	3.3076e-2	392.00	3.4521e-2
20102002	572.00	3.6609e-2	752.00	3.9983e-2	1000.00	4.2608e-2
*						
* magnesium oxide (used in pressurizer heater rods)						
20102101	100.00	4.6296e-4	1000.00	3.3796e-4		
*						
* nichrome v (used in pressurizer heater rods)						
20102201	32.00	1.9749e-3	212.00	2.2153e-3	392.00	2.5048e-3
20102202	572.00	2.7455e-3	752.00	2.8902e-3	1112.00	3.6127e-3
*						
* inconel 800 (used in pressurizer heater rods)						
20102301	70.00	1.8519e-3	1000.00	3.2176e-3	1500.00	4.0278e-3
*						
* cal-temp insul (increased by factor of 1.0 per surge line heat loss)						
20102401	0.00	9.2600e-6	100.00	9.2600e-6	200.00	9.8330e-6
20102402	300.00	1.1000e-5	400.00	1.1580e-5	500.00	1.2720e-5
20102403	600.00	1.3890e-5	700.00	1.5230e-5	800.00	1.6780e-5
*						
* 0.35% carbon steel used for sg tube sheets						
20102501	32.00	.00944	68.00	.00917	212.00	.00889
20102502	392.00	.00817	572.00	.00750	752.00	.00694
20102503	1112.00	.00564	1472.00	.00478		
*						
* cal-temp insul (increased by factor of 1.0 for inlet plenum heat loss)						
20102601	0.00	9.2600e-6	190.00	9.2600e-6	200.00	9.8330e-6
20102602	300.00	1.1000e-5	400.00	1.1580e-5	500.00	1.2720e-5
20102603	600.00	1.3890e-5	700.00	1.5230e-5	800.00	1.6780e-5
20102604	1000.00	1.9880e-5				
*						
* ipo2 used in nuclear core						
20102701	32.00	.00152	200.00	.00120	400.00	.00100
20102702	600.00	.00090	800.00	.00074	1000.00	.00066
20102703	1200.00	.00059	1500.00	.00052	2000.00	.00044
20102704	2500.00	.00039	3000.00	.00037	4000.00	.00033
*						
* zircaloy used in nuclear core						
20102801	32.00	.00197	1099.50	.00320	1199.80	.00330
20102802	178.80	.00366	195.60	.00369	1529.20	.00373
20102803	157.80	.00381	159.60	.00384	1619.70	.00387
20102804	1639.70	.00391	1753.80	.00411	1999.20	.00458
*						
* gap used in nuclear core						
20102901	32.00	2.2500e-5	602.30	3.8520e-5	998.33	4.5500e-5
20102902	1502.30	5.7800e-5	2006.30	6.7420e-5	5408.33	1.2040e-5
*						
* temp-mat ins (increased by a factor of 1.0 for pressurizer heat loss)						
20103001	0.00	4.9770e-6	100.00	5.7870e-6	200.00	6.5870e-6
20103002	300.00	7.6390e-6	400.00	8.7960e-6	500.00	1.0420e-5
20103003	600.00	1.2040e-5	700.00	1.4120e-5	800.00	1.6320e-5
20103004	1000.00	1.6960e-5				
*						
* pressurizer end cap and instrument heat loss - calculated values						
20103101	0.00	1.8304e-6	1000.00	1.8334e-6		
*						
* cal-temp insul (increased by factor of 2.2040 for blsg heat loss)						
20103201	0.00	2.0340e-5	100.00	2.0340e-5	200.00	2.1671e-5
20103202	300.00	2.4238e-5	400.00	2.5521e-5	500.00	2.8028e-5
20103203	600.00	3.0606e-5	700.00	3.3564e-5	800.00	3.6975e-5
20103204	1000.00	4.3794e-5				
*						
*						
* volumetric heat capacity data (btu/cuft-f)						
*	temp	cap	temp	cap	temp	cap
* 316L stainless steel						
20100151	32.00	61.30	400.00	61.30	600.00	61.50
20100152	800.00	57.10	1000.00	69.35	4000.00	69.35
*						
* average two phase						
20100251	32.00	1.00	212.00	1.00	572.00	64.00
20100252	4000.00	64.00				
*						
* boron nitride						
20100351	32.00	37.50	400.00	37.50	800.00	48.30
20100352	1200.00	54.60	1600.00	58.30	2000.00	60.00
20100353	2400.00	61.40	3400.00	62.50	4000.00	62.50
*						
* constantan						
20100451	32.00	56.00	212.00	56.00	572.00	61.00
20100452	932.00	67.00	1972.00	73.00	2192.00	78.00

2010453	2552.00	84.00	3000.00	90.00	4000.00	90.00	*
*							*alcerite (used in pressurizer guard heaters)
*inconel 600							2010251 32.00 36.177 10000.00 36.177
2010651	32.00	52.225	4000.00	52.225			*
*							*agresite oxide (used in pressurizer heater rods)
*grafoil							2010251 10.00 43.07 10000.00 43.07
2010651	32.00	11.90	80.40	11.90	170.40	14.70	*
2010652	260.40	17.15	350.40	19.60	450.40	21.35	*nickel 9 (used in pressurizer heater rods)
2010653	530.40	22.40	620.40	23.80	710.40	25.20	2010251 10.00 55.07 10000.00 55.07
2010654	800.40	26.32	4000.00	26.32			*
*							*incoloy 800 (used in pressurizer heater rods)
*copper ca 102							2010251 10.00 61.00 10000.00 61.00
2010751	32.00	51.336	4000.00	51.336			*
*							*cal-temp insulation
*cal-temp insulation							2010251 0.00 2.898 1000.00 2.898
2010651	0.00	2.898	1000.00	2.898			*
*							* 0.35% carbon steel
*alumina (aluminum oxide)							2010251 68.00 51.40 3000.00 51.40
2010951	0.00	55.20	3300.00	55.20			*
*							*cal-temp insulation
*inconel 718							2010251 0.00 2.898 1000.00 2.898
20101051	0.00	48.757	200.00	53.757	400.00	55.453	*
20101052	600.00	61.5912	800.00	65.1849	1000.00	69.290	*co2 used in nuclear core
20101053	1200.00	74.4227	1400.00	76.9890	1600.00	82.121	2010251 32.00 43.255 200.00 45.394 400.00 47.459
*							2010252 600.00 49.072 800.00 50.308 1000.00 51.238
*honeycomb - hexagonal matrix core							2010253 1200.00 51.939 1500.00 52.721 2000.00 53.920
20101151	0.00	2.28969	200.00	2.53081	400.00	2.65112	2010254 2500.00 55.994 3000.00 60.096 4000.00 73.014
20101152	600.00	2.89224	800.00	3.06095	1000.00	3.2537	*
20101153	1200.00	3.49379	1400.00	3.61530	1600.00	3.8563	*zircaloy used in nuclear core
*							2010251 32.00 27.820 1099.50 33.550 1199.80 35.190
*honeycomb - square matrix core							2010252 1478.80 35.190 1498.60 53.180 1529.20 59.330
20101251	0.00	2.15978	200.00	2.38713	400.00	2.5008	2010253 1579.80 62.190 1599.60 73.640 1619.70 77.790
20101252	600.00	2.71815	800.00	2.88729	1000.00	3.0691	2010254 1639.70 79.780 1759.80 34.790 1999.20 34.790
20101253	1200.00	3.29651	1400.00	3.41018	1600.00	3.6375	*
*							*gap used in nuclear core
*contact resistance (heaters to piping)							2010251 32.00 8.051e-5 5408.30 8.0514e-5
20101351	0.00	0.00	3300.00	0.00			*
*							*temp-mat insulation
*steam generator filler piece (calculation from test grb-14-82)							2010351 0.00 2.125 1000.00 2.125
20101451	0.00	13.00	1000.00	13.00			*
*							*pressurizer end cap and instrument heat loss
*water (saturated)							2010351 0.00 0.000 1000.00 0.000
20101551	32.00	63.033	104.00	61.966	176.00	60.950	*
20101552	248.00	59.895	356.00	58.553	464.00	57.835	*cal-temp insulation
20101553	500.00	57.989	572.00	60.999	700.00	62.576	2010251 0.00 2.898 1000.00 2.898
*							*
*cal-temp insulation							***** tables *****
20101651	0.00	2.898	1000.00	2.898			*
*							*
*cal-temp insulation							*
20101751	0.00	2.898	1000.00	2.898			*
*							***** core power *****
*thermal liner - john's manville min-k 2000, 30-35 pcf							*
20101851	400.00	7.475	800.00	8.125			*table trip time coef power coef
20101852	1200.00	8.775	1600.00	8.775			20215000 power 409 1.0 1.000 *w
*							*
*cal-temp insulation							*
20101951	0.00	2.898	1000.00	2.898			time power (ans standard decay curve)
*							20215001 0.0 1.000

20215002	1.1957	.99216		20235012	69.3478	0.0		
20215003	5.9783	.29432		20235013	4000.0	0.0		
20215004	7.1739	.22553		*				
20215005	10.7608	.11781		*****				
20215006	11.9555	.10006		*		*		
20215007	21.5217	.05289		*	system heat loss tables	*		
20215008	31.0870	.04263		*		*		
20215009	51.4130	.03880		*****				
20215010	81.3048	.03500		*				
20215011	100.4348	.03313		*heat loss due to intact loop pump passive cooling, 20.0 kw at full flow				
20215012	979.2388	.02080		* 1.0 btu = 1055.056 joules (international table)				
*				**				
*****				**	table	trip	time coef	rate coef
*				20225100	btu/rate	412	1.0	8.8931 * btu/s)ft ²
*				**	time	norm b.t.rate		
*				20225101	-1.0	1.000		
20239900	power	439	1.0	20225102	0.0	1.000		
*				20225103	19.4	0.595		
*				20225104	21.8	0.325		
20239901	0.0	0.000		20225105	32.0	0.227		
20239902	10000.0	0.000		20225106	42.4	0.181		
*				20225107	62.4	0.150		
*****				20225108	64.0	0.000		
*				20225109	4000.0	0.000		
*				**				
*****				*	heat loss due to intact loop pump active cooling, 4.3 kw always			
*				*	table	trip	time coef	rate coef
20225100	table	trip	412	20225100	btu/rate	412	1.0	1.9120 * btu/s-ft ²
*				**	time	norm b.t.rate		
*				20225101	0.0	1.000		
20225001	time	norm pump speed		20225102	20000.0	1.000		
20225002	-1.0	1.0		*****				
20225003	0.0	1.0		*	heat loss due to broken loop pump passive cooling, 14.7 kw at full flow			
20225004	1.1956	0.97220		*	from test sn-2b-38, h. s. crapo, bsc-2-84, 3 feb 1984			
20225005	8.3695	0.55521		*	1.0 btu = 1055.056 joules (international table)			
20225006	9.5552	0.50440		**				
20225007	19.1304	0.32739		**	table	trip	time coef	rate coef
20225008	29.8913	0.23498		20235100	btu/rate	413	1.0	9.1631 * btu/s-ft ²
20225009	38.2608	0.22025		**	time	norm b.t.rate		
20225010	59.7826	0.21159		20235101	-1.0	1.000		
20225011	62.1739	0.19573		20235102	0.0	1.000		
20225012	64.5552	0.15887		20235103	9.6	0.590		
20225013	66.9555	0.04289		20235104	13.6	0.498		
20225014	68.1521	0.0		20235105	20.8	0.407		
*				20235106	30.4	0.385		
20235000	react-t	413	* broken loop pump	20235107	60.0	0.385		
20235001	-1.0	1.0		20235108	64.8	0.000		
20235002	0.0	1.0		20235109	4000.0	0.000		
20235003	1.1956	0.98527		**				
20235004	8.3695	0.63678		*	heat loss due to broken loop pump active cooling, 4.3 kw always			
20235005	10.7608	0.55975		*	from test sn-2b-38, h. s. crapo, bsc-2-84, 3 feb 1984			
20235006	20.3260	0.42278		*	table	trip	time coef	rate coef
20235007	40.6521	0.40220						
20235008	59.7826	0.40315						
20235009	60.9782	0.32766						
20235010	64.5552	0.25842						
20235011	65.7608	0.16130						

20235100 Minrate 413 1.0 2.6894 * btu/s-ft²
 * time corr h.t.rate
 20235101 0.0 1.00
 20235102 2000.0 1.00
 *

 * specified heat transfer coefficients on piping insulation surface
 * (values calculated for free convector in air + radiation)
 *
 * table
 20210000 btc-temp
 * temp h.t.coef (btu/s-ft²-f)
 20210001 100.0 0.00136
 20210002 150.0 0.00206
 20210003 200.0 0.00247
 20210004 300.0 0.00302
 20210005 500.0 0.00374
 20210006 750.0 0.00438
 *
 * specified heat transfer coefficients on blsg insulation surface
 * (values calculated for free convector in air + radiation)
 *
 * table
 20220000 btc-temp 0 1.0 0.0 3.5426
 * temp h.t.coef (btu/s-ft²-f)
 20220001 100.0 0.00136
 20220002 150.0 0.00206
 20220003 200.0 0.00247
 20220004 300.0 0.00302
 20220005 500.0 0.00374
 20220006 750.0 0.00438
 *
 * specified heat transfer coefficients on blsg steam dome insulation
 * surface (values calculated for free convector in air + radiation)
 *
 * table
 20230000 btc-temp 0 1.0 0.0 3.35
 * temp h.t.coef (btu/s-ft²-f)
 20230001 100.0 0.00136
 20230002 150.0 0.00206
 20230003 200.0 0.00247
 20230004 300.0 0.00302
 20230005 500.0 0.00374
 20230006 750.0 0.00438
 *
 * specified heat transfer coefficients on blsg riser insulation
 * surface (values calculated for free convector in air + radiation)
 *
 * table
 20240000 btc-temp 0 1.0 0.0 3.35
 * temp h.t.coef (btu/s-ft²-f)
 20240001 100.0 0.00136
 20240002 150.0 0.00206
 20240003 200.0 0.00247
 20240004 300.0 0.00302
 20240005 500.0 0.00374
 20240006 750.0 0.00438
 *
 * specified heat transfer coefficients on blsg downcomer insulation
 * surface (values calculated for free convector in air + radiation)
 *
 * table
 20250000 btc-temp 0 1.0 0.0 3.35
 * temp h.t.coef (btu/s-ft²-f)
 20250001 100.0 0.00136
 20250002 150.0 0.00206
 20250003 200.0 0.00247
 20250004 300.0 0.00302
 20250005 500.0 0.00374
 20250006 750.0 0.00438
 *
 * power tables for piping heaters

 * **** power table for guard heater power bus 110 ****
 * **** (power to intact and broken loop hot legs) ****
 *
 * table trip time coef power coef
 20211000 power 430 1.0 8.4880e-3 *
 *
 * time power
 20211001 0.0 1.00
 20211002 10000.0 1.00
 *
 * **** power table for guard heater power bus 111 ****
 * **** (power to broken loop pump suction) ****
 *
 * table trip time coef power coef
 20211100 power 431 1.0 4.0130e-3 *
 *
 * time power
 20211101 0.0 1.00
 20211102 10000.0 1.00
 *
 * **** power table for guard heater power bus 112 ****
 * **** (power to intact and broken loop cold legs) ****
 *
 * table trip time coef power coef
 20211200 power 432 1.0 3.1220e-3 *
 *
 * time power
 20211201 0.0 1.00
 20211202 10000.0 1.00

*****	power table for guard heater power bus 113	*****			
*****	(power to intact loop pump suction)	*****			
*	table	trip	time coef	power coef	
20211300	power	433	1.0	8.2610e-3	* by
*	time	power			
20211301	0.0	1.00			
20211302	10000.0	1.00			
*****	power table for guard heater power bus 116	*****			
*****	(power to external heaters on vessel and downcomer)	*****			
*	table	trip	time coef	power coef	
20211600	power	436	1.0	19.8320e-3	* by
*	time	power			
20211601	0.0	1.00			
20211602	10000.0	1.00			
*****	power table for guard heater power bus 117	*****			
*****	(power to external heaters on pressurizer)	*****			
*	table	trip	time coef	power coef	
20211700	power	437	1.0	1.5930e-3	* by
*	time	power			
20211701	-1.0	1.00			
20211702	0.0	0.00			
20211703	10000.0	0.00			
*	control variables				
**	1 vessel interface level (-13 -578)				**
**	2 core interface level (105 -501)				**
**	3 downcomer interface level (+29 -578)				**
**	4 upper plenum interface level (+153 -13)				**
**	5 upper head interface level (+421 +160)				**
**	6 pressurizer interface level				**
**	7 intact loop u-tube up side interface level				**
**	8 intact loop u-tube down side interface level				**
**	9 intact loop pump section down side interface level				**
**	10 intact loop pump section up side interface level				**
**	11 broken loop u-tube up side interface level				**
**	12 broken loop u-tube down side interface level				**
**	13 broken loop pump section down side interface level				**
**	14 broken loop pump section up side interface level				**
**	15 intact loop steam generator riser interface level				**
**	16 intact loop steam generator downcomer interface level				**
**	17 broken loop steam generator riser interface level				**
**	18 broken loop steam generator downcomer interface level				**
**	19 intact loop steam generator secondary riser mass				**
**	20 intact loop steam generator secondary downcomer mass				**
**	21 intact loop steam generator secondary total mass				**
**	22 broken loop steam generator secondary riser mass				**
**	23 broken loop steam generator secondary downcomer mass				**
**	24 broken loop steam generator secondary total mass				**
**	25 total steam generator secondary mass				**
**	26 energy removed from primary to secondary by intact loop sg				**
**	27 energy removed from primary to secondary by broken loop sg				**
**	28 energy removed from core heater rods to primary coolant				**
**	29 maximum core heater rod temperature				**
**	150-151 control system for core heater rod power				**
**	200-221 control system to redistribute power on vessel heaters				**
**	250-251 control system to obtain desired intact loop mass flow rate				**
**	350-351 control system to obtain desired broken loop mass flow rate				**
**	400 fluid mass in downcomer				**
**	401 fluid mass in lower plenum				**
**	402 fluid mass in core				**
**	403 fluid mass in upper plenum				**
**	404 fluid mass in upper head				**
**	405 fluid mass in bypass line, support columns, guide tubes				**
**	406 fluid mass in pressurizer				**
**	407 fluid mass in intact loop hot leg				**
**	408 fluid mass in intact loop u-tubes				**
**	409 fluid mass in intact loop cold leg				**
**	410 fluid mass in broken loop hot leg				**
**	411 fluid mass in broken loop u-tubes				**
**	412 fluid mass in broken loop cold leg				**
**	413 total primary coolant system fluid mass				**
**	501 vessel delta p -13 to -578 cm				**
**	502 vessel core delta p -105 to -501 cm				**
**	503 vessel downcomer delta p 29 to -578 cm				**
**	504 vessel upper plenum delta p 135 to -13 cm				**
**	505 vessel upper head delta p 421 to 160 cm				**
**	506 pressurizer delta p 632 to 30 cm				**
**	507 intact loop steam generator u-tube upside delta p 926 to -57e				**
**	508 intact loop steam generator u-tube downside delta p 926 to -57x				**
**	509 intact loop pump suction downside delta p -57z to il4				**
**	510 intact loop pump suction upside delta p il4 to il6				**
**	511 broken loop steam generator u-tube upside delta p 925 to -57e				**
**	512 broken loop steam generator u-tube downside delta p 925 to -57x				**
**	513 broken loop pump suction downside delta p -57z to b65				**
**	514 broken loop pump suction upside delta p b65 to b73				**
**	515 intact loop steam generator riser delta p 1117 to 89 cm				**
**	516 intact loop steam generator downcomer delta p 1117 to 51 cm				**
**	517 broken loop steam generator riser delta p 1186 to -7 cm				**
**	518 broken loop steam generator downcomer delta p 1186 to 18 cm				**
**	519 broken loop steam generator downcomer delta p between horizs				**
**	521 vessel collapsed level -13 to -578(ref) cm				**
**	522 vessel core collapsed level -105 to -501(ref) cm				**
**	523 vessel downcomer collapsed level 29 to -578(ref) cm				**
**	524 vessel upper plenum collapsed level 135 to -13(ref) cm				**
**	525 vessel upper head collapsed level 421 to 160(ref) cm				**
**	526 pressurizer collapsed level 632 to 30(ref) cm				**
**	527 ilsg u-tube upside collapsed level 926 to -57e(ref) cm				**
**	528 ilsg u-tube downside collapsed level 926 to -57x(ref) cm				**
**	529 intact loop pump suction downside collapsed level ref il6 cm				**

** 530	intact loop pump section upside collapsed level ref ilb	cm	**	20500109	2.0	voidf	150010000
** 531	blsg u-tube upside collapsed level 925 to -57e(ref)	cm	**	20500110	1.635833	voidf	130010000
** 542	blsg u-tube downside collapsed level 925 to -57x(ref)	cm	**	20500111	0.721917	voidf	130010000
** 533	broken loop pump suction downside collapsed level ref b65	cm	**	20500112	0.466667	voidf	120010000
** 544	broken loop pump suction upside collapsed level ref b65	cm	**	*			
** 545	intact loop steam generator riser collapsed level ref 89	cm	**	20500200	corelvl	sm	30.48 -105.092 1 * core level (cm)
** 536	intact loop steam generator downcomer collapsed level ref 51c	cm	**	*			* (-105. to -501.)
** 547	broken loop steam generator riser collapsed level ref -7	cm	**	20500201	-16.42833	0.166667	voidf 140010000
** 548	broken loop steam generator downcomer collapsed level ref 18c	cm	**	20500202	2.00000	voidf	150010000
** 549	broken loop steam generator downcomer hor collapsed level ref 18cm	cm	**	20500203	2.00000	voidf	150020000
** 561	vessel collapsed level -13 to -578 ref cold leg	**		20500204	2.00000	voidf	150030000
** 562	vessel core collapsed level -105 to -501 ref cold leg	**		20500205	2.00000	voidf	150040000
** 563	vessel downcomer collapsed level 29 to -578 ref cold leg	**		20500206	2.00000	voidf	150050000
** 564	vessel upper plenum collapsed level 135 to -13 ref cold leg	**		20500207	2.00000	voidf	150060000
** 565	vessel upper head collapsed level 421 to 160 ref cold leg	**		20500208	0.81375	voidf	161010000
** 566	pressurizer collapsed level 632 to 30 ref zero cm	**		*			
** 567	ilsg u-tube upside collapsed level 925 to -57e ref tube sheet	**		20500300	dcrlvl	sm	30.48 30.480 1 * downcomer lvl (cm)
** 568	ilsg u-tube downside collapsed level 925 to -57x ref tub sh	**		*			* (+29 to -578)
** 569	intact loop pump section downside collapsed level ref cold leg	**		20500301	-19.08608	2.0	voidf 101010000
** 570	intact loop pump section upside collapsed level ref cold leg	**		20500302	2.260833	voidf	110010000
** 571	blsg u-tube upside collapsed level 925 to -57e ref tube sheet	**		20500303	1.000833	voidf	110020000
** 572	blsg u-tube downside collapsed level 925 to -57x ref tub sh	**		20500304	2.0	voidf	110030000
** 573	broken loop pump suction downside collapsed level ref cold leg	**		20500305	2.0	voidf	110040000
** 574	broken loop pump suction upside collapsed level ref cold leg	**		20500306	2.0	voidf	110050000
** 575	intact loop steam generator riser collapsed level ref tub sh	**		20500307	2.0	voidf	110060000
** 576	intact loop steam generator downcomer collsd lvl ref tub sh	**		20500308	2.0	voidf	110070000
** 577	broken loop steam generator riser collapsed level ref tub sh	**		20500309	1.466667	voidf	110080000
** 578	broken loop steam generator downcomer collsd lvl ref tub sh	**		20500310	1.207667	voidf	110090000
** 579	broken loop steam generator downcomer hor collpsd lvl ref tub sh	**		20500311	0.952500	voidf	110100000
** 606-610	control system to obtain desired mass in intact loop sg	**		20500312	0.721917	voidf	130010000
** 620	intact loop steam generator recirculation ratio	**		20500313	0.466667	voidf	120010000
** 625	intact loop steam generator circulation ratio	**		*			
** 630-637	control system to hold il steam dome pressure within band	**		20500400	uplavl	sm	30.48 136.144 1 * up plenum lvl (cm)
** 706-710	control system to obtain desired mass in broken loop sg	**		*			* (+135 to -13)
** 720	broken loop steam generator recirculation ratio	**		20500401	-0.426509	2.550000	voidf 164010000
** 725	broken loop steam generator circulation ratio	**		20500402	2.343176	voidf	163010000
** 730-737	control system to hold bl steam dome pressure within band	**		*			
** 800	total heat loss monitoring system	**		20500500	whlvl	sm	30.48 423.570 1 * up. head lvl (cm)
** 980-985	control system to obtain desired pressurizer liquid level	**		*			* (+421 to +160)
** 990-999	control system for pressurizer internal heater rods	**		20500501	+5.120	2.880833	voidf 194010000
**		**		20500502	3.453333	voidf	193010000
*****		*****		20500503	1.965833	voidf	192010000
*****		*****		20500504	0.476667	voidf	191010000
*				*			
*	control variables for comparison to equivalent semiscale data			20500600	parlvl	sm	30.48 625.793 1 * ppr level (cm)
*	***** liquid levels *****			*			
*				21500601	0.0	2.50	voidf 999010000
20500100	vsllvl	sm	30.48 -13.000 1 * vessel level (cm)	21500602	2.5625	voidf	999020000
*			* (-13 to -578)	21500603	2.5625	voidf	999030000
20500101	-19.08608	0.073491	voidf 163010000	21500604	2.5625	voidf	999040000
20500102	2.760833	voidf	162010000	21500605	2.5625	voidf	999050000
20500103	1.000833	voidf	161010000	21500606	2.5625	voidf	999060000
20500104	2.0	voidf	150060000	21500607	2.583333	voidf	999070000
20500105	2.0	voidf	150050000	21500608	2.09375	voidf	999080000
20500106	2.0	voidf	150040000	21500609	0.541667	voidf	997010000
20500107	2.0	voidf	150030000	*			
20500108	2.0	voidf	150020000	*			
20500700	ilato	sm	30.48 925.830 1 * il s-tube up				

*					*	(cm) - from						
20501701	-1.75	1.7500000	voidf	215010000	* -57 cm below		20501400	blpsu	sum	30.48	-27.025	1 * bl p-s up (cm)
20501702		7.9525000	voidf	220010000	* top of tube sheet		20501401	-9.179583	0.6456667	voidf	340070000	* (dpb-65+73a)
20501703		7.9108334	voidf	220020000	* to top of model		20501402		5.3495833	voidf	340080000	
20501704		7.9108334	voidf	220030000	* u-tube		20501403		2.2956667	voidf	340090000	
20501705		6.5999833	voidf	220040000		*						
*						*						
20501800	ilstd	sum	30.48	925.830	1 * il -tube down		20501500	ilsgrs1	sum	30.48	1130.780	1 * i.l. s.g. lvl (cm)
*					* (cm) - from		*					* (top of tube
20501801	-1.75	1.7500000	voidf	225010000	* -57 cm below		20501501	0.0	7.9525000	voidf	600010000	* sheet to top of
20501802		6.5999833	voidf	220050000	* top of tube sheet		20501502		7.9108334	voidf	600020000	* cent. separator
20501803		7.9108334	voidf	220060000	* to top of model		20501503		7.9108334	voidf	600030000	* (0 to +1130)
20501804		7.9108334	voidf	220070000	* u-tube		20501504		7.4762500	voidf	600040000	* riser side
20501805		7.9525000	voidf	220080000			20501505		5.1553333	voidf	600050000	
*						*						
20501900	ilpsd	sum	30.48	151.803	1 * il p-s down (cm)		20501600	ilsgcl1	sum	30.48	1130.780	1 * i.l. s.g. lvl (cm)
*					* (dpb-57+14)		*					* (top of tube
20501901	-9.229167	0.6354167	voidf	230010000			20501601	0.0	7.4762500	voidf	600010000	* sheet to top of
20501902		1.1826602	voidf	230010000			20501602		7.9108334	voidf	600020000	* cent. separator
20501903		3.6662500	voidf	240020000			20501603		7.9108334	voidf	600030000	* (0 to +1130)
20501904		3.4756800	voidf	240030000			20501604		7.9525000	voidf	600040000	* downcomer side
20501905		2.8553333	voidf	240040000			20501605		5.5516667	voidf	600050000	
20501906		3.4733333	voidf	240050000			20501606		1.5404167	voidf	612010000	
20501907		0.7266667	voidf	240060000		*						
*						*	20501700	blsgrs1	sum	30.48	1120.150	1 * b.l.s.g. lvl (cm)
*					* (dpb-14+16)		*					* (top of tube
20501701	-9.229167	0.7266667	voidf	240070000			20501701	0.0	1.0833333	voidf	715010000	* sheet to top of
20501702		3.4733333	voidf	240080000			20501702		6.7083333	voidf	700010000	* grav. separator
20501703		4.2083333	voidf	240090000			20501703		7.5000000	voidf	700020000	* (0.0 to 1172)
*							20501704		7.5000000	voidf	700030000	* riser side
*							20501705		7.5000000	voidf	700040000	
*							20501706		6.8229167	voidf	700050000	
*							20501707		1.3333333	voidf	701010000	
*						*						
20501100	bltsu	sum	30.48	923.290	1 * bl u-tube up		20501800	blsgcl1	sum	30.48	1120.140	1 * b.l.s.g. lvl (cm)
*					* (cm) - from		*					* (top of tube
20501101	-1.7508333	1.7508333	voidf	315010000	* -57 cm below		20501801	.5416667	4.0000000	voidf	714010000	* sheet to bot of
20501102		7.7915667	voidf	320010000	* top of tube sheet		20501802		7.5000000	voidf	714020000	* grav. separator
20501103		7.5000000	voidf	320020000	* to top of model		20501803		7.5000000	voidf	714030000	* (0.0 to 1131)
20501104		7.5000000	voidf	320030000	* u-tube		20501804		7.5000000	voidf	714040000	* downcomer side
20501105		7.5000000	voidf	320040000			20501805		7.2500000	voidf	714050000	
*							20501806		2.8229167	voidf	711010000	
*						*						
20501200	bltd	sum	30.48	923.290	1 * bl -tube down							
*					* (cm) - from							
20501201	-1.7508333	1.7508333	voidf	325010000	* -57 cm below							
20501202		7.5000000	voidf	320050000	* top of tube sheet							
20501203		7.5000000	voidf	320060000	* to top of model							
20501204		7.5000000	voidf	320070000	* u-tube							
20501205		7.7915667	voidf	320080000								
*						*						
20501300	blpsd	sum	30.48	142.944	1 * bl p-s down (cm)		20501900	ilsgmr	sum	.0283163846	0.0	1 * il s.g. secondary
*					* (dpb-57+63a)		*					* riser mass (kg)
20501301	-9.179583	0.8020833	voidf	330010000			20501901	0.0	1.0033417	rho	600010000	
20501302		1.3076602	voidf	340010000			20501902		0.9402046	rho	600020000	
20501303		2.3333333	voidf	340020000			20501903		0.8926958	rho	600030000	
20501304		1.6437500	voidf	340030000			20501904		1.0017945	rho	600040000	
20501305		4.9431250	voidf	340040000			20501905		2.2709806	rho	600050000	
20501306		4.2954533	voidf	340050000			20501906		0.4508175	rho	601010000	
20501307		0.6466667	voidf	340060000			20501907		0.4249523	rho	611010000	
*						*						
20502000	ilsgnd	sum	.0283163846	0.0	1 * il s.g. secondary							
*						*						* downcomer mass(kg)
20502001	0.0		3.0085308	rho	602010000							

2050202	0.7316260	rho	612010000		2050207	1.00	q	22070000
2050203	0.2211171	rho	603010000		2050208	1.00	q	220630000
2050204	0.2315531	rho	603020000	*				
2050205	0.2315531	rho	603030000		20502700	blsg _q	sum -1.0e-3	0.0 1 * bl sg q (hv)
2050206	0.3322701	rho	603040000	*				
*					20502701	0.0	1.00	q 320010000
20502100	ilsg ₃	sum	1.0 0.0 1 * il s.g. secondary	* mass (kg)	20502702		1.00	q 320020000
*					20502703		1.00	q 320330000
20502101	0.0	1.00	cotrlvar 19		20502704		1.00	q 320440000
20502102		1.00	cotrlvar 20		20502705		1.00	q 320550000
*					20502706		1.00	q 320660000
*					20502707		1.00	q 320770000
20502200	blsg _q	sum .028316846	0.0 1 * bl s.g. secondary	* riser mass (kg)	20502708		1.00	q 320880000
*								
20502201	0.0	0.0244994	rho 716010000		20502800	corepow	sum .23607e-3	0.0 1 * core power (hv)
20502202		0.2213819	rho 700010000	*				
20502203		0.2576839	rho 700020000		20502801	0.0	1.00	btemp 15000101
20502204		0.2451911	rho 700030000		20502802		1.00	btemp 15000201
20502205		0.2549590	rho 700040000		20502803		1.00	btemp 15000301
20502206		0.3265005	rho 700050000		20502804		1.00	btemp 15000401
20502207		0.5794734	rho 701010000		20502805		1.00	btemp 15000501
20502208		0.1534235	rho 703010000		20502806		1.00	btemp 15000601
20502209		0.1002201	rho 704010000		20502807		1.00	btemp 15000701
20502210		0.0680654	rho 705010000		20502808		1.00	btemp 15000801
*					20502809		1.00	btemp 15000901
20502300	blsg _q	sum .028316846	0.0 1 * bl s.g. secondary	* downcomer mass(kg)	20502810		1.00	btemp 15000101
*					20502811		1.00	btemp 150001101
20502301	0.0	0.6232431	rho 711010000		20502812		1.00	btemp 150001201
20502302		0.0718342	rho 712010000	*				
20502303		0.0366917	rho 713010000	*				
20502304		0.0424740	rho 714010000	*				
20502305		0.0779018	rho 714020000		20502900	maxrod	stfactn 1.0 0.0 1 * max rod temp	
20502306		0.0779018	rho 714030000	*				
20502307		0.0779018	rho 714040000		20502901	max	btemp 150000118	
20502308		0.0774216	rho 714050000		20502902		btemp 150000218	
20502309		0.0972227	rho 715010000		20502903		btemp 150000318	
*					20502904		btemp 150000418	
20502400	blsg ₃	sum 1.0 0.0 1 * bl s.g. secondary	* liquid mass (kg)		20502905		btemp 150000518	
*					20502906		btemp 150000618	
20502401	0.0	1.00	cotrlvar 22		20502907		btemp 150000718	
20502402		1.00	cotrlvar 23		20502908		btemp 150000818	
*					20502909		btemp 150000918	
*					20502910		btemp 150001018	
20502500	totsg _q	sum 1.0 0.0 1 * total secondary	* liquid mass (kg)		20502911		btemp 150001118	
*					20502912		btemp 150001218	
20502501	0.0	1.00	cotrlvar 21					
20502502		1.00	cotrlvar 24					
*								
*								
20502600	ilsg _q	sum -1.0e-3	0.0 1 * il sg q (hv)					
*								
20502601	0.0	1.00	q 220010000		20540000	dmcmas	sum .028316846	0.0 1 * downcomer mass
20502602		1.00	q 220020000					* (kg)
20502603		1.00	q 220030000		20540001	0.0	0.2113940	rho 101010000
20502604		1.00	q 220040000		20540002		0.0700293	rho 110010000
20502605		1.00	q 220050000		20540003		0.0260607	rho 110020000
20502606		1.00	q 220060000		20540004		0.0520780	rho 110030000
					20540005		0.0520780	rho 110040000
					20540006		0.0520780	rho 110050000

2054007	0.0520789	rho	110060000	*										
2054008	0.0520780	rho	110070000	20540700	ibotmas	sm	.028316845	0.0	1	* intact loop				
2054009	0.0381645	rho	110080000	*						* bot leg				
2054010	0.0451975	rho	110090000	20540701	0.0	0.1047757	rho	201010000		* mass (kg)				
2054011	0.0733525	rho	110100000	20540702		0.0776379	rho	201020000						
*				20540703		0.0675653	rho	202010000						
20540100	lplmas	sm	.028316845	0.0	1	* lower plenum		20540704		0.053702	rho	203010000		
*				*		* mass (kg)		20540705		0.0574572	rho	203020000		
20540101	0.0	0.2381304	rho	120010000	20540706		0.0538994	rho	203030000					
20540102		0.238024	rho	130010000	20540707		0.0478680	rho	210010000					
20540103		0.1229956	rho	140010000	20540708		0.0345748	rho	215010000					
*				*										
20540200	coremas	sm	.028316845	0.0	1	* core mass (kg)		20540600	itubmas	sm	.028316845	0.0	1	* intact loop
*				*		* v-tube		20540601	0.0	0.1571175	rho	220010000		
20540201	0.0	0.0607520	rho	150010000	20540602		0.1562943	rho	220020000					
20540202		0.0607520	rho	150020000	20540603		0.1562943	rho	220030000					
20540203		0.0607520	rho	150030000	20540604		0.1322144	rho	220040000					
20540204		0.0607520	rho	150040000	20540605		0.1322144	rho	220050000					
20540205		0.0607520	rho	150050000	20540606		0.1562943	rho	220050000					
20540206		0.0607520	rho	150060000	20540607		0.1562943	rho	220070000					
*				*				20540608		0.1571175	rho	220080000		
20540300	uplmas	sm	.028316845	0.0	1	* upper plenum		*						
*				*		* mass (kg)		20540900	icldmas	sm	.028316845	0.0	1	* intact loop
20540301	0.0	0.0579072	rho	161010000	20540901		0.0345748	rho	225010000					
20540302		0.1260044	rho	162010000	20540902		0.0478680	rho	230010000					
20540303		0.1223341	rho	163010000	20540903		0.0374799	rho	240010000					
20540304		0.1445850	rho	164010000	20540904		0.0902957	rho	240020000					
*				*				20540905		0.0849351	rho	240030000		
20541300	uphmas	sm	.028316845	0.0	1	* upper head		20540906		0.0713212	rho	240040000		
*				*		* mass (kg)		20540907		0.0863894	rho	240050000		
20541301	0.0	0.0236441	rho	191010000	20540908		0.0374835	rho	240060000					
20541302		0.1028720	rho	192010000	20540909		0.0374835	rho	240070000					
20541303		0.1854233	rho	193010000	20540910		0.0863894	rho	240080000					
20541304		0.1777042	rho	194010000	20540911		0.1036556	rho	240090000					
*				*				20540912		0.0558400	rho	250010000		
20540500	byscg	sm	.028316845	0.0	1	* bypass line,		20540913		0.0779569	rho	261010000		
*				*		* support columns,		20540914		0.0779569	rho	261020000		
20540501	0.0	0.0025551	rho	181010000	20540915		0.0779569	rho	262010000					
20540502		0.0032783	rho	181020000	20540916		0.0854513	rho	263010000					
20540503		0.0142473	rho	182010000	20541000	btotmas	sm	.028316845	0.0	1	* broken loop			
20540504		0.0087675	rho	183010000	*			20541001		0.0584279	rho	301010000		
20540505		0.01111809	rho	184010000	20541002		0.0215803	rho	301020000					
20540506		0.0052931	rho	185010000	20541003		0.0215803	rho	301030000					
20540507		0.0298418	rho	186010000	20541004		0.0266031	rho	301040000					
*				*				20541005		0.0236250	rho	301050000		
20540600	pzmass	sm	.028316845	0.0	1	* pressurizer		20541006		0.0192876	rho	301060000		
*				*		* mass (kg)		20541007		0.0495847	rho	310010000		
20540601	0.0	0.0033454	rho	997010000	20541008		0.0115250	rho	315010000					
20540602		0.0042155	rho	997020000	20541100	btubes	sm	.028316845	0.0	1	* broken loop			
20540603		0.0030333	rho	997030000	*			20541101		0.0471739	rho	320010000		
20540604		0.1731566	rho	999010000	20541102		0.0454080	rho	320020000					
20540605		0.1842654	rho	999020000	20541103		0.0454080	rho	320030000					
20540606		0.1842654	rho	999030000										
20540607		0.1842654	rho	999040000										
20540608		0.1842654	rho	999050000										
20540609		0.1842654	rho	999060000										
20540610		0.1857634	rho	999070000										
20540611		0.1120170	rho	999080000										

20541104	0.0456672	rho	320040000						205503000	dmcndp	sm	1.0e-3	100.0	1	*	dmcm level dp
20541105	0.0456672	rho	320050000						*						*	-578 cm
20541106	0.0454630	rho	320060000						20550301	0.0	1.0	p	120010000	0.3303	rho	120010000
20541107	0.0454630	rho	320070000						20550302	-1.0	p	101010000	2.8420	rho	101010000	
20541108	0.0471739	rho	320080000						*						*	
*									*						*	
20541200	bcl1das	sm	.028316845	0.0	1	*	broken loop		20550400	vescpdp	sm	1.0e-3	100.0	1	*	vessel upper
*						*	cold leg		*						*	plenum dp
20541201	0.0	0.0115250	rho	325010000	*	mass (kg)			*						*	135 to -13 cm
20541202		0.0495847	rho	330010000					20550401	0.0	1.0	p	163010000	3.3898	rho	163010000
20541203		0.0156764	rho	340010000					20550402	-1.0	p	164010000	3.6954	rho	164010000	
20541204		0.0228420	rho	340020000					*						*	
20541205		0.0160501	rho	340030000					*						*	
20541206		0.0482662	rho	340040000					20550500	veschdp	sm	1.0e-3	100.0	1	*	vessel upper
20541207		0.0419519	rho	340050000					*						*	head dp
20541208		0.0099184	rho	340060000					*						*	421 to 160 cm
20541209		0.0099184	rho	340070000					20550501	0.0	1.0	p	191010000	0.3255	rho	191010000
20541210		0.0522349	rho	340080000					20550502	-1.0	p	194010000	4.0503	rho	194010000	
20541211		0.0249253	rho	340090000					*						*	
20541212		0.0303500	rho	350010000					*						*	
20541213		0.0192357	rho	361010000					20550600	prcp	sm	1.0e-3	100.0	1	*	pressarizer
20541214		0.0160887	rho	362010000					*						*	632 to 30 cm
20541215		0.0227915	rho	363010000					20550601	0.0	1.0	p	999080000	1.8327	rho	999080000
20541216		0.0479251	rho	363020000					20550602	-1.0	p	999010000	4.3145	rho	999010000	
*									*						*	
20541300	pcmass	sm	1.0	0.0	1	*	total primary		*						*	
*						*	coolant system		20550700	isgndp	sm	1.0e-3	100.0	1	*	ilsg upside
20541301	0.0	1.00	ctr1var	400	*	mass (kg)			*						*	926 to -57e cm
20541302	.	1.00	ctr1var	401					20550701	0.0	1.0	p	210010000	-0.5900	rho	210010000
20541303	.	1.00	ctr1var	402					20550702	-1.0	p	220040000	9.8588	rho	220040000	
20541304	.	1.00	ctr1var	403					*						*	
20541305	.	1.00	ctr1var	404					*						*	
20541306	.	1.00	ctr1var	405					20550800	isgndp	sm	1.0e-3	100.0	1	*	ilsg downside
20541307	.	1.00	ctr1var	406					*						*	926 to -57x cm
20541308	.	1.00	ctr1var	407					20550801	0.0	1.0	p	230010000	-0.5900	rho	230010000
20541309	.	1.00	ctr1var	408					20550802	-1.0	p	220050000	9.8588	rho	220050000	
20541310	.	1.00	ctr1var	409					*						*	
20541311	.	1.00	ctr1var	410					*						*	
20541312	.	1.00	ctr1var	411					20550900	ipsndp	sm	1.0e-3	100.0	1	*	il pump section
20541313	.	1.00	ctr1var	412					*						*	downside
*									*						*	-57x to j14
*						*	ctr1var delta p (kpa)		20550901	0.0	0.5	p	240060000	0.5115	rho	240060000
*						*			20550902	0.5	p	240070000	0.5115	rho	240070000	
*						*			20550903	-1.0	p	230010000	0.5900	rho	230010000	
*						*			*						*	
*						*			20551000	ipsdp	sm	1.0e-3	-100.0	1	*	il pump section
*						*			*						*	upside
*						*			*						*	i14 to i16
*						*			20551001	0.0	0.5	p	240060000	0.5115	rho	240060000
*						*			20551002	0.5	p	240070000	0.5115	rho	240070000	
*						*			20551003	-1.0	p	240090000	4.3006	rho	240090000	
*						*			*						*	
*						*			20551100	bsgdp	sm	1.0e-3	100.0	1	*	blsg upside
*						*			*						*	926 to -57e
*						*			20551101	0.0	1.0	p	310010000	-0.8093	rho	310010000
*						*			20551102	-1.0	p	320040000	10.0822	rho	320040000	

```

*      name type scale init val flg
20551200 bsgndp sca 1.0e-3 100.0 1 * blsg downside
*          * 925 to -57x
20551201 0.0 1.0 p 330010000 -0.8393 rho 330010000
20551202 -1.0 p 320050000 10.0322 rho 320050000
*
*      name type scale init val flg
20551300 bpsndp sca 1.0e-3 100.0 1 * bl pump suction
*          * downside
*          * -57x to 665
20551301 0.0 0.5 p 340060000 0.4829 rho 340060000
20551302 0.5 p 340070000 0.4829 rho 340070000
20551303 -1.0 p 330010000 0.8393 rho 330010000
*
*      name type scale init val flg
20551400 bpsndp sca 1.0e-3 100.0 1 * bl pump section
*          * upside
*          * 665 to 673
20551401 0.0 0.5 p 340060000 0.4829 rho 340060000
20551402 0.5 p 340070000 0.4829 rho 340070000
20551403 -1.0 p 340090000 0.6504 rho 340090000
*
*      name type scale init val flg
20551500 ilsgndp sca 1.0e-3 100.0 1 * ilsg riser
*          * 1117 to 89 cm
20551501 0.0 1.0 p 600010000 3.1356 rho 600010000
20551502 -1.0 p 602010000 7.8576 rho 602010000
*
*      name type scale init val flg
20551600 ilsgndp sca 1.0e-3 100.0 1 * ilsg downcomer
*          * 1117 to 51 cm
20551601 0.0 1.0 p 603040000 6.9282 rho 603040000
20551602 -1.0 p 602010000 7.8576 rho 602010000
*
*      name type scale init val flg
20551700 blsgrdp sca 1.0e-3 100.0 1 * blsg riser
*          * 1186 to -7 cm
20551701 0.0 1.0 p 716010000 2.3049 rho 716010000
20551702 -1.0 p 703010000 0.5601 rho 703010000
*
*      name type scale init val flg
20551800 blsgrdp sca 1.0e-3 100.0 1 * blsg downcomer
*          * 1186 to 18 cm
20551801 0.0 1.0 p 715010000
20551802 -1.0 p 703010000 0.5601 rho 703010000
*
*      name type scale init val flg
20551900 blsgrdp sca 1.0e-3 100.0 1 * blsg dwa horiz
*          * 1036 to 18 cm
20551901 0.0 1.0 p 715010000
20551902 -1.0 p 713010000
*
*      name type scale val0 flg * vessel clspd
20553100 vescl div 10204.082 100. 1 * level -13 to
*          * -57x ref -57x
20553101 rhof 163010000 contrivar 501
*
*      name type scale val0 flg * core clspd
20553200 corecl div 10204.082 100. 1 * level -105 to
*          * -501 ref -501
20553201 rhof 161010000 contrivar 502
*
*      name type scale val0 flg * dmcn clspd
20553300 dmcncl div 10204.082 100. 1 * level 29 to
*          * -57x ref -57x
20553301 rhof 161010000 contrivar 503
*
*      name type scale val0 flg * ves ep clspd
20553400 vesepcl div 10204.082 100. 1 * level 135 to
*          * -13 ref -13
20553401 rhof 164010000 contrivar 504
*
*      name type scale val0 flg * ves nh clspd
20553500 vesnhcl div 10204.082 100. 1 * level 421 to
*          * 160 ref 160
20553501 rhof 194010000 contrivar 505
*
*      name type scale val0 flg * prz clspd
20553600 przcl div 10204.082 100. 1 * level 632 to
*          * 30 ref 30
20553601 rhof 999010000 contrivar 506
*
*      name type scale val0 flg * ilsg up clspd
20553700 isgpc1 div 10204.082 100. 1 * level 925 to
*          * -57x ref -57
20553701 rhof 220040000 contrivar 507
*
*      name type scale val0 flg * ilsg dn clspd
20553800 isgpd1 div 10204.082 100. 1 * level 925 to
*          * -57x ref -57
20553801 rhof 220050000 contrivar 508
*
*      name type scale val0 flg * ilps dn clspd
20553900 ipsdcl div 10204.082 100. 1 * level -57x to
*          * i14 ref i14
20553901 rhof 230010000 contrivar 509
*
*      name type scale val0 flg * ilps ep clspd
20554000 ipspcl div 10204.082 100. 1 * level i14 to
*          * i16 ref i14
20554001 rhof 240090000 contrivar 510

```

```

*          name type      scale val0 flg * blsg ep clspd
20554100 bsgpcl div 10204.082 100. 1 * level 925 to
*          * -57e ref -57
20554101 rhof 320490000 cntrivar 511
*
*          name type      scale val0 flg * blsg da clspd
20554200 bsgpcl div 10204.082 100. 1 * level 925 to
*          * -57e ref -57
20554201 rhof 320450000 cntrivar 512
*
*          name type      scale val0 flg * blps dn clspd
20554300 bpspcl div 10204.082 100. 1 * level -57x to
*          * b65 ref b65
20554301 rhof 330010000 cntrivar 513
*
*          name type      scale val0 flg * blps np clspd
20554400 bpspcl div 10204.082 100. 1 * level b65 to
*          * b73 ref b65
20554401 rhof 340090000 cntrivar 514
*
*          name type      scale val0 flg * ilsg ris clspd
20554500 ilsgpcl div 10204.082 100. 1 * level 1117 to
*          * 89 ref 89
20554501 rhof 611010000 cntrivar 515
*
*          name type      scale val0 flg * ilsg da clspd
20554600 ilsgpcl div 10204.082 100. 1 * level 1117 to
*          * 51 ref 51
20554601 rhof 611010000 cntrivar 516
*
*          name type      scale val0 flg * blsg ris clspd
20554700 blsgpcl div 10204.082 100. 1 * level 1186 to
*          * -7 ref -7
20554701 rhof 703010000 cntrivar 517
*
*          name type      scale val0 flg * blsg da clspd
20554800 blsgpcl div 10204.082 100. 1 * level 1186 to
*          * 18 ref 18
20554801 rhof 703010000 cntrivar 518
*
*          name type      scale val0 flg * blsg dmz clspd
20554900 blsgpcl div 10204.082 100. 1 * level 1036 to
*          * 18 ref 18
20554901 rhof 703010000 cntrivar 519
*****
*          name type      scale val0 flg * vessel clspd
20555100 vesclr sma      1.0 -13.0 1 * level -13 to
*          * -57e ref zero
20555101 -57.0 1.0 cntrivar 521
*
*          name type      scale val0 flg * core clspd
20555200 coreclr sma      1.0 -105.0 1 * level -105 to
*          * -501 ref zero
20555201 -501.0 1.0 cntrivar 522
*
*          name type      scale val0 flg * dwcm clspd
20555300 dwcmclr sma      1.0 +29.0 1 * level 29 to
*          * -57e ref zero
20555301 -57.0 1.0 cntrivar 523
*
*          name type      scale val0 flg * ves ep clspd
20555400 vesepclr sma      1.0 +135.0 1 * level 135 to
*          * -13 ref zero
20555401 -13.0 1.0 cntrivar 524
*
*          name type      scale val0 flg * ves dn clspd
20555500 vesdnclr sma      1.0 +421.0 1 * level 421 to
*          * 160 ref zero
20555501 160.0 1.0 cntrivar 525
*
*          name type      scale val0 flg * prc clspd
20555600 prcclr sma      1.0 +532.0 1 * level 632 to
*          * 30 ref zero
20555601 30.0 1.0 cntrivar 526
*
*          name type      scale val0 flg * ilsg np clspd
20555700 isgepclr sma      1.0 +926.0 1 * level 926 to
*          * -57e ref zero
20555701 -57.0 1.0 cntrivar 527
*
*          name type      scale val0 flg * ilsg da clspd
20555800 isgndclr sma      1.0 +926.0 1 * level 926 to
*          * -57e ref zero
20555801 -57.0 1.0 cntrivar 528
*
*          name type      scale val0 flg * ilps da clspd
20555900 ipsdnclr sma      1.0 203.6 1 * level -57x to
*          * i14 ref zero
20555901 -281.3 1.0 cntrivar 529
*
*          name type      scale val0 flg * ilps np clspd
20556000 ipsepclr sma      1.0 0.0 1 * level i14 to
*          * i16 ref zero
20556001 -281.3 1.0 cntrivar 530
*

```

```

*      name type      scale val0 flg * blsg ep clspd
20557100 bsgpclr sum      1.0 +925.0 1 * level 925 to
*                                         * -5% ref zero
20557101 -57.0 1.0 contrlvar 541

*
*      name type      scale val0 flg * blsg dn clspd
20557200 bsgnclr sum      1.0 +925.0 1 * level 925 to
*                                         * -5% ref zero
20557201 -57.0 1.0 contrlvar 542

*
*      name type      scale val0 flg * blps dn clspd
20557300 bpsdnclr sum      1.0 203.6 1 * level -5% to
*                                         * b65 ref zero
20557301 -279.8 1.0 contrlvar 543

*
*      name type      scale val0 flg * blps ep clspd
20557400 bpsepclr sum      1.0 0.0 1 * level b65 to
*                                         * b73 ref zero
20557401 -279.8 1.0 contrlvar 544

*
*      name type      scale val0 flg * ilsg ris clspd
20557500 ilsgclr sum      1.0 +1117.0 1 * level 1117 to
*                                         * 89 ref zero
20557501 89.2 1.0 contrlvar 545

*
*      name type      scale val0 flg * ilsg dwn clspd
20557600 ilsgdclr sum      1.0 +1117.0 1 * level 1117 to
*                                         * 51 ref zero
20557601 50.5 1.0 contrlvar 546

*
*      name type      scale val0 flg * blsg ris clspd
20557700 blsgclr sum      1.0 +1186.0 1 * level 1186 to
*                                         * -7 ref zero
20557701 -7.0 1.0 contrlvar 547

*
*      name type      scale val0 flg * blsg dnw clspd
20557800 blsgdnclr sum      1.0 +1186.0 1 * level 1186 to
*                                         * 18 ref zero
20557801 16.51 1.0 contrlvar 548

*
*      name type      scale val0 flg * blsg dnhz clspd
20557900 blsgdnclr sum      1.0 0.0 1 * level 1036 to
*                                         * 18 ref zero
20557901 16.51 1.0 contrlvar 549

*****
*      control block for core power
*****
```

20538100 pzzerr sum 0.01 0.0 1 * input desired
 * ejl
 20538101 484.0 -1.0 cntrlvar 6
 * 20538101 132.3 -1.0 cntrlvar 6 * level in cm
 *
 20538200 pzcorr mult 1.0 0.0 0 * correct level in
 20538201 cntrlvar 980 cntrlvar 981 * pz until t529
 *
 20538500 pzfiv mult .006805 0.0 0 * pressurizer
 20538501 rbo 999070000 cntrlvar 982 * feed flow rate
 *
 ***** control block for pumps *****
 *
 * steady state *****
 *
 * intact loop pump speed --- input desired intact loop flow rate (kg/s)*
 20525000 blerr sum 1.0 0.0 1
 20525001 7.05000 -1.0 mflowj 163010000
 *
 20525100 blpspd integral 20.0 1873.37 1
 20525101 cntrlvar 250
 *
 * broken loop pump speed --- input desired broken loop flow rate (kg/s)*
 20535000 blerr sum 1.0 0.0 1
 20535001 2.47500 -1.0 mflowj 163020000
 *
 20535100 blpspd integral 60.0 1492.32 1
 20535101 cntrlvar 350
 *
 ***** transient *****
 *
 * intact loop
 *
 * 20525100 ilppspd function 1873.37 0.0 1 * from cntrlvar 251
 * 20525101 time 0 250 * in steady-state
 *
 * broken loop
 *
 * 20535100 blppspd function 1492.32 0.0 1 * from cntrlvar 351
 * 20535101 time 0 350 * in steady state
 *
 ***** control block for steam generators *****
 *
 * obtain specified and maintain constant mass in the steam generators
 *
 20560600 t419 tripunit 1.0 0.0 1
 20560601 419
 *
 20560700 blerr sum 1.0 0.0 1 * input desired blsg
 20560701 103.0 -1.0 cntrlvar 21 * liquid mass in kg
 *
 20560800 blcorr mult 1.0 0.0 0 * correct mass in
 20560801 cntrlvar 606 cntrlvar 607 * blsg until t519
 *
 20550900 ilsgls sum 1.0 0.0 0 * mass flow out ilsg
 20550901 0.0 1.0 mflowj 635000000
 * 20550902 1.0 mflowj 637000000
 *
 20551000 ilsgfv sum 1.0 0.0 0 * intact loop
 20551001 0.0 1.0 cntrlvar 608 * feed flow rate
 20551002 1.0 cntrlvar 609
 *
 20552000 brer div 1.0 0.0 1 * recirc ratio
 20552001 mflowj 601010000 mflowj 601020000
 *
 20552500 brer div 1.0 0.0 1 * circulation ratio
 20552501 mflowj 601010000 mflowj 601030000
 *
 20570600 t419 tripunit 1.0 0.0 1
 20570601 419
 *
 20570700 blerr sum 1.0 0.0 1 * input desired blsg
 20570701 26.0 -1.0 cntrlvar 24 * liquid mass in kg
 *
 20570800 blcorr mult 1.0 0.0 0 * correct mass in
 20570801 cntrlvar 706 cntrlvar 707 * blsg until t519
 *
 20570900 blsgls sum 1.0 0.0 0 * mass flow out blsg
 20570901 0.0 1.0 mflowj 735000000
 * 20570902 1.0 mflowj 737000000
 *
 20571000 blsgfv sum 1.0 0.0 0 * broken loop
 20571001 0.0 1.0 cntrlvar 708 * feed flow rate
 20571002 1.0 cntrlvar 709
 *
 20572000 brer div 1.0 0.0 1 * recirc ratio
 20572001 mflowj 704010000 mflowj 713030000
 *
 20572500 brer div 1.0 0.0 1 * circulation ratio
 20572501 mflowj 704010000 mflowj 701010000
 *
 *
 * control intact loop steam valve to hold steam dome pressure in
 * band given by trips 462 and 463 - open and close steam valve at
 * rates given in trips 464 and 465 - open or close depending on
 * trips 662 and 663
 *
 20563000 perr sum -1.0 0.0 1 * desired pressure
 20563001 6.2765 -1.0 p 61101000 * pascals - mid band
 *
 20563100 dperr diffrend 1.0 0.0 1
 20563101 cntrlvar 630
 *
 20563200 pdpdt tripunit 1.0 0.0 1
 20563201 662
 *
 20563300 negdpdt tripunit 1.0 0.0 1
 20563301 663
 *
 20563400 open mult 1.0 0.0 1

2053401	cntrlvar	630	cntrlvar	632	*	20520400	mstrip	tripinit	1.0	0.0	1		
*	close	mult	1.0	0.0	1	20520401			642				
2053500	cntrlvar	630	cntrlvar	633	*	20520500	invbkt	sum	1.0	1.0	1		
*	rate	sum	1.e-8	0.0	0	20520501	1.0	-1.0		cntrlvar	202		
2053600	0.0	1.0	cntrlvar	634	*	20520600	invwt	sum	1.0	-1.0	1		
2053601	1.0	cntrlvar	635	*	20520601	1.0	-1.0		cntrlvar	203			
*	2053700	posa	integral	1.0	0.294688	0	*	20520700	invwt	sum	1.0	1.0	1
2053701	cntrlvar	636	*	20520701	1.0	-1.0		cntrlvar	204				
*	*	*	*	20520800	wpwr	mult	0.13193	1.0		1			
*	control broken loop steam valve to hold steam dome pressure in band given by trips 472 and 473 - open and close steam valve at rates given in trips 474 and 475 - open or close depending on trips 672 and 673	*	*	20520801	cntrlvar	201	cntrlvar		205				
*	2053000	perr	sum	-1.0	0.0	1	*	20520900	wpwra	mult	0.06597	1.0	1
2053001	6.23e5	-1.0	p	705010000	*	20520901	cntrlvar	201					
*	2053100	dperf	diffrend	1.0	0.0	1	*	20521000	wpwrb	mult	0.01603	1.0	1
2053101	cntrlvar	730	*	20521001	cntrlvar	201	cntrlvar		202				
*	2053200	posdpdt	tripinit	1.0	0.0	1	*	20521100	wpwrt	sum	1.0	1.0	1
2053201	672	*	*	20521101	0.0	1.0		cntrlvar	203				
*	2053300	negdpdt	tripinit	1.0	0.0	1	*	20521102	1.0			204	
2053301	673	*	*	20521200	wpwr	mult	1.0	1.0		1			
*	2053400	open	mult	1.0	0.0	1	*	20521201	cntrlvar	211	cntrlvar		205
2053401	cntrlvar	730	cntrlvar	732	*	*	20521300	wpwra	mult	0.17589	1.0	1	
*	2053500	close	mult	1.0	0.0	1	*	20521301	cntrlvar	201			
2053501	cntrlvar	730	cntrlvar	733	*	*	20521400	wpwrb	mult	0.02673	1.0	1	
*	2053600	rate	sum	4.e-9	0.0	0	*	20521401	cntrlvar	201	cntrlvar		202
2053601	0.0	1.0	cntrlvar	734	*	*	20521500	wpwrc	mult	0.01657	1.0	1	
2053602	1.0	cntrlvar	735	*	*	*	20521501	cntrlvar	201	cntrlvar		203	
*	2053700	posa	integral	1.0	0.0367422	0	*	20521600	wpwrt	sum	1.0	1.0	1
2053701	cntrlvar	736	*	20521601	0.0	1.0		cntrlvar		204			
*	***** vessel, downcomer, and upper head external heaters *****	*	*	*	*	*	20521602	1.0			213		
*	vessel, downcomer, and upper head external heaters	*	*	*	*	*	20521603	1.0			214		
*	2052000	parbase	function	1.0	0.0	0	*	20521700	wpwr	mult	1.0	1.0	1
2052001	time	0	116	*	*	*	20521701	cntrlvar	216	cntrlvar		207	
*	20520100	vsipwr	mult	1.0	1.0	0	*	20521800	wpwra	mult	0.62621	1.0	1
20520101	cntrlvar	200	*	*	*	*	20521801	cntrlvar	201				
*	20520200	mstrip	tripinit	1.0	0.0	1	*	20521900	wpwrb	mult	0.09517	1.0	1
20520201	640	*	*	*	*	*	20521901	cntrlvar	201	cntrlvar		202	
*	20520300	wtstrip	tripinit	1.0	0.0	1	*	20522000	wpwrc	mult	0.05933	1.0	1
20520301	641	*	*	*	*	*	20522001	cntrlvar	201	cntrlvar		203	

2052200	vspur	scr	1.0	1.0	1		0000302	p	162010000	* pwp (Pa)	(p+p-13)
2052201	0.0	1.0		ctrlvar	218		0000303	ctrlvar	6	* pwr level	(lprz+process)
*2052202		1.0		ctrlvar	219		0000304	p	999010000	* pwr pressure	(p+pz+532)
*2052203		1.0		ctrlvar	220		0000305	ctrlvar	150	* decay power	(dcypower)
*2052204		1.0		ctrlvar	221		0000306	aflowj	262010000	* ilhl flowrate	(qi+1)
*							0000307	aflowj	362010000	* blhl flowrate	(qb+79)
*							0000308	aflowj	635000000	* il steam rate	(mdot+ilstm)
2052200	strip	tripenit	1.0	0.0	1		0000309	aflowj	735000000	* bl steam rate	(mdot+blstm)
2052201			643				0000310	p	601010000	* il sg pressure	(pis+1117)
*							0000311	p	701010000	* bl sg pressure	(pbg+1186)
2052200	invt	sum	1.0	1.0	1		0000312	ctrlvar	15	* il sg level	(lsp+971-57e)
2052201	1.0	-1.0		ctrlvar	223		0000313	ctrlvar	17	* bl sg level	(lbp1h933-57e)
*							0000314	aflowj	634000000	* il sg adv rate	(mdot+il+adv)
2052200	vspur	mult	1.0	1.0	1		0000315	aflowj	734000000	* bl sg adv rate	(mdot+bl+adv)
2052201	ctrlvar	222	ctrlvar	224			0000316	aflowj	430010000	* il acc rate	(mdot+il+accm)
*							0000317	aflowj	530010000	* bl acc rate	(mdot+bl+accm)
heat loss monitoring block							0000318	ctrlvar	510	* il pump up dp	(dp+14p+16)
*****							0000319	ctrlvar	514	* bl pump up dp	(dpb+65+73a)
*							0000320	rho	363020000	* density bcl	(rb+79)
2053000	btloss	scr	1.0	0.0	1		0000321	aflowj	110010000	* downcorer rate	(qr+dc+42)
2053001	0.	1.0	q		800010000		0000322	ctrlvar	1	* core level	(lv-13+57s)
2053002		1.0	q		801010000		0000323	btemp	150000612	* pct	(thr+peak)
2053003		1.0	q		802010000		0000324	dt	0	* time step	
2053004		1.0	q		803010000		*0000324	ctrlvar	81	* time step	
2053005		1.0	q		804010000		0000325	cptime		* cptime	
2053006		1.0	q		805010000		0000326	ctrlvar	51	* int brk mass	
2053007		1.0	q		806010000		0000327	aflowj	610000000	* il sg2i	
2053008		1.0	q		807010000		0000328	aflowj	722000000	* bl sg2i	
2053009		1.0	q		808010000		0000329	aflowj	615000000	* il sg2 aux	
2053010		1.0	q		809010000		0000330	aflowj	728000000	* bl sg2 aux	
2053011		1.0	q		811010000		0000331	voidf	220010000	* il sgl	
2053012		1.0	q		812010000		0000332	voidf	220020000		
2053013		1.0	q		813010000		0000333	voidf	220030000		
2053014		1.0	q		814010000		0000334	voidf	220040000	* bl sgl	
2053015		1.0	q		815010000		0000335	voidf	320010000		
2053016		1.0	q		816010000		0000336	voidf	320020000		
*							0000337	voidf	320030000		
* int brk							0000338	voidf	320040000		
*							0000339	voidf	240080000	* il pump up	
20505100	intbrk	integral	1.0	0.0	0		0000340	voidf	240090000		
20505101	aflowj	725000000					0000341	voidf	340080000	* bl pump up	
*							0000342	voidf	340090000		
* sum statistics							0000343	voidf	150010000	* core void	
*							0000344	voidf	150020000		
20507800	oldtime	sum	1.0	0.0	0		0000345	voidf	150030000		
20507801	0.0	1.0		ctrlvar	79		0000346	voidf	150040000		
*							0000347	voidf	150050000		
20507900	newtime	sum	1.0	0.0	0		0000348	voidf	150060000		
20507901	0.0	1.0		time	0.0		0000349	pepel	250	* il pump vel	
*							0000350	pepel	350	* bl pump vel	
20508100	tstep	sum	1.0	0.0	0		0000351	btemp	150001118	* core btm temp	
20508101	0.0	-1.0		ctrlvar	78		0000352	btemp	150001218	* core top temp	
20508102		1.0		ctrlvar	79		0000353	tempf	162010000	* core up l temp	
*							0000354	tempf	140010000	* core dn l temp	
* minor edit							0000355	btemp	150006118		
*							0000356	btemp	150007118		
0000301	aflowj	725000000	* mbrk	(kg/s)	(mdot+break)		0000357	btemp	150008118		
							0000358	btemp	150009118		

0000359 htemp 150001018
0000360 htemp 150001118
0000361 voidf 351010000
0000362 cotrivar 21 * il sg total mass
0000363 cotrivar 24 * bl

*** end of relap5 mod3 input deck ***

= relaps model for the semiscale fs-11 posttest - transient run

*
*problem type option
0000100 restart transnt
*
* inp-chk or run
0000101 run
*
*units input output (si or british)
0000102 british si
*
0000103 3592 * sfsh.out & sfsh.rst
*
* t end min st max st st cl wr ej wr
*
000201 1000.0 1.0e-7 1.0 3 10 200 800 * blowdown phase
*
* isolate the break valve at 4100 sec
*
000334 time 0 le null 0 4100.0 n -1.0
000602 434 and 434 n -1.
*
725000 brk-vlv valve
7250101 72000000 79000000 0.00314159 0.0 0.0 0.000 * ejl
7250102 0.90 0.80 * ejl
7250201 1 0.0 0.0 0.0
7250300 trvly
7250301 602
*
* cross valve
*
6370000 ilcnj sngljns
6370101 611010000 647000000 0.003003 0.0 0.0 0.0
6370201 0 0.0 0.0 0.0
*
* il steam dome cross connection pipe to bl steam dome
*
6470000 ilcnjp pipe
6470001 3
6470101 0.003003 3
6470301 18.0 1
6470302 14.0 2
6470303 19.7304167 3
6470501 -90.0 1
6470602 0.0 2
6470603 90.0 3
6470701 -18.0 1
6470702 0.0 2
6470703 19.7304167 3
6470801 6.667e-5 0.0 3
6471001 0 3
6471101 0 2
6471201 2 829.6 0.0 0.0 0.0 0
6471202 2 829.6 0.0 0.0 0.0 0 2
6471203 2 829.6 0.0 0.0 0.0 0 3
6471300 0
6471301 0.0 0.0 0.0 0 2
*
* close the cross valve at 200 sec
*
000435 time 0 lt null 0 200.0 n -1.0
000624 492 and 435 n -1. * ejl 910423
000625 -624 or -624 n -1.
*
6700000 ilb1c valve
6700101 657010000 745010000 0.003631 0.0 0.0 100
6700201 1 0.0 0.0 0.0
6700300 mtrvly
6700301 624 625 1.0 0.0 0
*
7370000 blcnj sngljns
7370101 705010000 745000000 0.003003 0.0 0.0 100
7370201 0 0.0 0.0 0.0
*
7460000 blcnjp pipe
7460001 1
7460101 0.003003 1
7460301 7.0 1
7460501 0.0 1
7460701 0.0 1
7460801 6.667e-5 0.0 1
7461001 0 1
7461201 2 675.9 0.0 0.0 0.0 0 1
*
* phase 1
* open break valve
0000402 time 0 ge null 0 0.0 1 -1.
* scram
0000404 p 999010000 ge null 0 2287.5 1 -1.
* msiv close
0000410 time 0 ge timeof 404 4.0 1 -1.
0000411 time 0 ge timeof 404 4.0 1 -1.
* rcp coastdown
0000412 time 0 ge timeof 404 2.0 1 -1.
0000413 time 0 ge timeof 404 2.0 1 -1.
* power decay
0000409 time 0 ge timeof 404 3.2 1 -1.
* sis
0000407 p 700010000 le null 0 635.5 n -1.
* hpis
0000450 time 0 ge timeof 407 25.0 1 -1.
0000451 cntrlyvar 6 le null 0 235.0 n -1.
0000608 450 or 451 n -1. * ejl
* main feedwater stop
00000414 time 0 ge timeof 407 0.0 1 -1.
0000414 time 0 ge null 0 1.0 1 -1.
*0000415 time 0 ge timeof 407 0.0 1 -1.
0000415 time 0 ge null 0 1.0 1 -1.
* aux feedwater initiated
*0000416 time 0 ge timeof 407 4.0 1 -1.
0000416 time 0 ge timeof 407 5.0 1 -1.0
*0000417 time 0 ge timeof 407 4.0 1 -1.
0000426 cntrlyvar 15 lt null 0 955. n -1. * auxfeed on
0000445 time 0 ge null 0 600.0 n -1.0

0000611 415 and 416 n -1.
 0000612 416 and 416 n -1.
 *
 0000616 407 and 407 n -1.
 0000617 407 and 407 n -1.
 *
 * phase 2
 *
 * open letdown valve
 0000453 ctrlvar 30 ge null 0 33.0 n -1.
 0000455 ctrlvar 6 ge null 0 235.0 n -1. * open ldn vv eos
 0000456 ctrlvar 6 le null 0 235.0 n -1. * open chg vv
 *
 0000651 455 and 456 n -1.
 0000657 453 and 455 n -1.
 *
 4150000 ilchg tripjus
 4150101 425000000 400000000 0.04995
 4150200 1 651
 * 4150201 0.0 0.0514 0.0 0.0
 * 4150202 1800.0 0.0514 0.0 0.0
 * 4150203 2000.0 0.0514 0.0 0.0
 * 4150204 2500.0 0.0514 0.0 0.0
 4150201 -1.0 0.0 0.0 0.0
 4150202 0.0 0.023 0.0 0.0
 4150203 1000.0 0.023 0.0 0.0
 4150204 1001.0 0.0 0.0 0.0
 * 4150205 300.0 0.0 0.0 0.0
 *
 4250000 ilchgy tripvol
 4250101 10.0 10.0 0.0 0.0 0.0 0.0
 4250102 0.0 0.0 0
 4250200 3
 4250201 0.0 2500.0 80.0
 *
 5150000 blchg tripjus
 5150101 525000000 500000000 0.04995
 * 5150200 1 651 p 361010000
 * 5150201 0.0 0.00758 0.0 0.0
 * 5150202 1800.0 0.00758 0.0 0.0
 * 5150203 2000.0 0.00758 0.0 0.0
 * 5150204 2500.0 0.00758 0.0 0.0
 5150200 1 651
 5150201 -1.0 0.0 0.0 0.0
 5150202 0.0 0.00758 0.0 0.0
 5150203 1000.0 0.00758 0.0 0.0
 5150204 1001.0 0.0 0.0 0.0
 * 5150205 300.0 0.0 0.0 0.0
 *
 5250000 blchgy tripvol
 5250101 10.0 10.0 0.0 0.0 0.0 0.0
 5250102 0.0 0.0 0
 5250200 3
 5250201 0.0 2500.0 80.0
 *
 * subcooled margin control
 *

20503000 subca set 1.0 0.0 0
 20503001 0.0 1.0 sattemp 999980000
 20503002 -1.0 tempf 201010000
 *
 2450000 letdown tripjus
 2450101 261010000 245000000 0.04995
 2450200 1 657
 2450201 -1.0 0.0 0.0 0.0
 2450202 0.0 0.024 0.0 0.0
 2450203 1000.0 0.024 0.0 0.0
 2450204 1001.0 0.0 0.0 0.0
 *
 2450000 letdown tripvol
 2450101 1.0 1.0 0.0 0.0 0.0 0.0
 2450102 4.0-5 0.0 0.0
 2450200 3
 2450301 0.0 18.0 100.0
 * adv control
 0000452 p 600010000 ge null 0 1000.0 n -1.
 0000454 ctrlvar 16 ge null 0 955.0 n -1.
 0000661 452 and 454 n -1.
 0000671 452 and 454 n -1.
 *
 * phase 3 refill
 *
 *
 * change hpis performance data p37, eos
 *
 4100000 ilhpisj tripjus
 *
 * from to jnu area
 4100101 420000000 400000000 0.049952
 *
 *
 *
 4100200 ctl flg trip table volume
 4100200 1 603 p 263010000
 *
 * pres(psia) flow-f flow-g velj
 * 4100201 -1.0 0.0000 0.0 0.0
 * 4100202 0.0 0.058626 0.0 0.0
 * 4100203 50.0 0.057690 0.0 0.0
 * 4100204 100.0 0.055935 0.0 0.0
 * 4100205 150.0 0.055847 0.0 0.0
 * 4100206 200.0 0.054910 0.0 0.0
 * 4100207 310.0 0.052798 0.0 0.0
 * 4100208 605.0 0.046888 0.0 0.0
 * 4100209 865.0 0.041142 0.0 0.0
 * 4100210 1095.0 0.035287 0.0 0.0
 * 4100211 1270.0 0.029422 0.0 0.0
 * 4100212 1440.0 0.023554 0.0 0.0
 * 4100213 1650.0 0.01784 0.0 0.0
 * 4100214 1730.0 0.005393 0.0 0.0
 * 4100215 1775.0 0.0 0.0 0.0
 4100201 -1.0 0.0 0.0 0.0
 4100202 0.0 0.0 0.0 0.0
 4100203 15.0 0.03219 0.0 0.0
 4100204 332.25 0.02545 0.0 0.0
 4100205 393.51 0.02334 0.0 0.0

410026 431.79 0.02569 0.0 0.0
 410027 471.88 0.02500 0.0 0.0
 410028 510.39 0.02538 0.0 0.0
 410029 519.09 0.02371 0.0 0.0
 4100210 561.93 0.02375 0.0 0.0
 4100211 652.45 0.02531 0.0 0.0
 4100212 729.93 0.02516 0.0 0.0
 4100213 812.43 0.02329 0.0 0.0
 4100214 820.29 0.01873 0.0 0.0
 4100215 1123.66 0.01480 0.0 0.0
 4100216 1158.0 0.01418 0.0 0.0
 4100217 1158.0 0.01184 0.0 0.0
 4100218 1348.0 0.00953 0.0 0.0
 4100219 1307.0 0.00717 0.0 0.0
 4100220 1455.0 0.00550 0.0 0.0
 4100221 1560.0 0.0 0.0 0.0
 4100222 1600.0 0.0 0.0 0.0
 * sf11 trip changes
 *
 000491 time 0 ge null 0 8000.0 1 -1.0
 000496 time 0 ge null 0 0.0 1 -1.0 * ej1
 *
 26505100 intblk integral 1.0 0.0 0
 26505101 nflospj 725000000
 *
 * add pump transient controller
 *
 26525100 ilppspd function 1873.37 0.0 1
 26525101 time 0 250
 26535100 blppspd function 1492.32 0.0 1
 26535101 time 0 350
 *
 * restart pump
 *
 000493 time 0 ge null 0 400.00 1 -1.0
 *
 5100000 blhpisj tdpjm
 *
 * from to jnn area
 5100101 52000000 50000000 0.002695
 *
 * ct1 flg trip table volume
 5100200 1 608 p 361010000
 *
 * pres(psia) flow-f flow-g velj
 5100201 -1.0 0.00 0.0 0.0
 5100202 0.0 0.00 0.0 0.0
 5100203 15.0 0.0125 0.0 0.0
 5100204 333.57 0.01113 0.0 0.0
 5100205 581.35 0.01000 0.0 0.0
 5100206 699.77 0.00974 0.0 0.0
 5100207 770.0 0.00868 0.0 0.0
 5100208 881.0 0.00795 0.0 0.0
 5100209 1007.23 0.00705 0.0 0.0
 5100210 1024.0 0.00633 0.0 0.0
 5100211 1158.0 0.0059 0.0 0.0
 5100212 1258.0 0.0051 0.0 0.0
 5100213 1348.0 0.0039 0.0 0.0
 5100214 1407.0 0.0031 0.0 0.0
 5100215 1455.0 0.0019 0.0 0.0
 5100216 1560.0 0.00 0.0 0.0
 5100217 1600.0 0.00 0.0 0.0
 *
 6010000 isgict separatr
 6010001 3 0
 6010101 0.0 0.7916667 0.4508175 0.0 90.0 0.7916667
 6010102 6.67e-5 0.0 0
 6010200 2 829.6 0.3
 6011101 601010000 612000000 0.4690572 0.0 0.0 0002 0.5
 6012101 601000000 602000000 0.4690572 100.0 100.0 0002 0.15
 6013101 600010000 601000000 0.5353713 0.0 0.0 0000
 6012201 -2.50 1.60 0.0
 6012201 1.00 0.00 0.0
 6013201 1.60 1.60 0.0
 * delete par level controller
 *
 20538000 t419 delete 0.0 0.0 0.0 0.0 0.0 0.0
 20538100 pzerr delete 0.0 0.0 0.0 0.0 0.0 0.0
 20538200 pzcrr delete 0.0 0.0 0.0 0.0 0.0 0.0
 20538500 pzfv delete 0.0 0.0 0.0 0.0 0.0 0.0
 * delete par component
 * 9100000 pzspry delete
 * 9200000 pzsprv delete
 *
 000418 p 999010000 ge null 0 2250.0 n -1.
 9100000 pzspry tdpjm

9100101 92000000 99900000 0.012
 9100200 1 418
 9100201 -1.0 0.0 0.0 0.0
 9100202 0.0 0.033 0.0 0.0
 9100203 3000.0 0.033 0.0 0.0
 9100204 3001.0 0.0 0.0 0.0
 *
 9200000 prsrw tdpvol
 9200101 0.012 10.0 0.0 0.0 0.0
 9200102 0.0 0.0 0
 9200200 3
 9200201 0.0 2400.0 80.0
 *
 9340000 prsry delete
 9400000 prsdy delete
 9500000 prlvly delete
 9550000 prlvlyj delete
 9580000 c593 delete
 9910000 twi-prz delete
 * delete s/g level controller
 20560500 t419 delete 0.0 0.0 0.0 0.0 0.0 0.0
 20567000 ilcorr delete 0.0 0.0 0.0 0.0 0.0 0.0
 20568000 ilcorr delete 0.0 0.0 0.0 0.0 0.0 0.0
 20569000 ilsgls delete 0.0 0.0 0.0 0.0 0.0 0.0
 20561000 ilsgfv delete 0.0 0.0 0.0 0.0 0.0 0.0
 20562000 icrrr delete 0.0 0.0 0.0 0.0 0.0 0.0
 20562500 icrrr delete 0.0 0.0 0.0 0.0 0.0 0.0
 20570600 t419 delete 0.0 0.0 0.0 0.0 0.0 0.0
 20570700 blcorr delete 0.0 0.0 0.0 0.0 0.0 0.0
 20570800 blcorr delete 0.0 0.0 0.0 0.0 0.0 0.0
 20570900 blsgls delete 0.0 0.0 0.0 0.0 0.0 0.0
 20571000 blsgfv delete 0.0 0.0 0.0 0.0 0.0 0.0
 20572000 bctrcc delete 0.0 0.0 0.0 0.0 0.0 0.0
 20572500 bctrcc delete 0.0 0.0 0.0 0.0 0.0 0.0
 20553000 perr delete 0.0 0.0 0.0 0.0 0.0 0.0
 20553100 dperr delete 0.0 0.0 0.0 0.0 0.0 0.0
 20553200 posipdt delete 0.0 0.0 0.0 0.0 0.0 0.0
 20553300 negipdt delete 0.0 0.0 0.0 0.0 0.0 0.0
 20553400 open delete 0.0 0.0 0.0 0.0 0.0 0.0
 20553500 close delete 0.0 0.0 0.0 0.0 0.0 0.0
 20553600 rate delete 0.0 0.0 0.0 0.0 0.0 0.0
 20553700 posu delete 0.0 0.0 0.0 0.0 0.0 0.0
 20573100 dperr delete 0.0 0.0 0.0 0.0 0.0 0.0
 20573200 posipdt delete 0.0 0.0 0.0 0.0 0.0 0.0
 20573300 negipdt delete 0.0 0.0 0.0 0.0 0.0 0.0
 20573400 open delete 0.0 0.0 0.0 0.0 0.0 0.0
 20573500 close delete 0.0 0.0 0.0 0.0 0.0 0.0
 20573600 rate delete 0.0 0.0 0.0 0.0 0.0 0.0
 20573700 posu delete 0.0 0.0 0.0 0.0 0.0 0.0
 *
 * run statistics
 *
 20507800 oldtime sum 1.0 0.0 0
 20507801 0.0 1.0 cntrivar 79
 20507900 newtime sum 1.0 0.0 0
 20507901 0.0 1.0 time 0.0

20503100 tstep sum 1.0 0.0 0
 20503101 0.0 -1.0 cntrivar 78
 20503102 1.0 cntrivar 79
 *
 6150000 isgafvj tdpjcn
 6150101 62500000 603010000 0.012
 6150200 1 616
 6150301 -1.0 0.0 0.0 0.0
 6150302 0.0 0.0510 0.0 0.0
 6150303 4800.0 0.051 0.0 0.0
 6150304 4801.0 0.0 0.0 0.0
 *
 6340000 isgrv valve * simulated adv
 6340101 611010000 640000000 0.002592 0.0 0.0 100
 6340201 1 0.0 0.0 0.0
 6340300 trpv
 6340301 661
 *
 7280000 bsgafvj tdpjcn
 7280101 729000000 726000000 0.004
 7280200 1 617
 7280201 -1.0 0.0 0.0 0.0
 7280202 0.0 0.030 0.0 0.0
 7280203 390.0 0.030 0.0 0.0
 7280204 391.0 0.0 0.0 0.0
 7280205 4000.0 0.0 0.0 0.0
 7280206 4001.0 0.030 0.0 0.0
 7280207 6300.0 0.030 0.0 0.0
 *
 7340009 bsgrv valve * simulated b adv
 7340101 705010000 740000000 0.007 0.0 0.0 100
 7340201 1 0.0 0.0 0.0
 7340300 trpv
 7340301 671
 *
 20225100 btrrate 412 1.0 8.8931
 20225101 -1.0 1.000
 20225102 0.0 1.000
 20225103 10.4 0.505
 20225104 20.8 0.325
 20225105 32.0 0.227
 20225106 42.4 0.181
 20225107 62.4 0.150
 20225108 64.0 0.000
 20225109 4000.0 0.000
 *
 20235100 btrrate 413 1.0 9.1631
 20235101 -1.0 1.000
 20235102 0.0 1.000
 20235103 9.6 0.590
 20235104 13.6 0.498
 20235105 20.8 0.407
 20235106 30.4 0.385
 20235107 60.0 0.385
 20235108 64.8 0.000
 20235109 4000.0 0.000
 *

* lpis set point time
 0000499 p 999010000 lt null 0 200.0 1 -1.
 *
 * add sg main fw component
 *
 6100000 isgfvj twdpjm
 6100101 62000000 603010000 0.012
 6100200 1 414
 6100201 -1.0 1.80 0.0 0.0 * 91.05.08 ejl
 6100202 0.0 1.8078 0.0 0.0
 * 6100203 24.0 1.8078 0.0 0.0
 6100204 26.0 0.0 0.0 0.0
 *
 7200000 bsgfvj twdpjm
 7200101 724000000 720000000 0.004
 7200200 1 415
 7200201 -1.0 0.56 0.0 0.0
 7200202 0.0 0.56119 0.0 0.0
 * 7200203 24.0 0.56119 0.0 0.0
 7200204 26.0 0.0 0.0 0.0
 *
 * 6350009 isgij twdpjm
 * 6350101 611010001 650000000 0.007
 * 6350200 1 410
 * 6350201 -1.0 0.0 0.0 0.0
 * 6350202 0.0 0.0 1.8 0.0
 * 6350203 50.0 0.0 1.8 0.0
 * 6350204 51.0 0.0 0.5 0.0
 * 6350205 230.0 0.0 0.5 0.0
 * 6350206 231.0 0.0 0.0 0.0
 *
 6350000 isgij valve
 6350101 611010000 650000000 0.007 204.67 204.67 100
 6350201 1 0.0 1.78476 0.0
 6350300 mtrvly
 6350301 403 410 .01 0.23367 0
 *
 7350000 bsgij valve
 7350101 705010000 750000000 0.007 1022.36 1022.36 100
 7350201 1 0.0 0.51964 0.0
 7350300 mtrvly
 7350301 403 411 .2 0.03367 0
 *
 ** trips - trip cancellation card 400 variable trip cards 401-599 **
 ** - trip stop card 600 logical trip cards 601-699 **
 0000462 discard
 0000463 discard
 0000464 discard
 0000465 discard
 0000662 409 discard
 0000663 409 discard
 *
 0000472 discard
 0000473 discard
 0000474 discard
 0000475 discard
 0000672 409 discard

0000673 409 discard
 *
 * minor edit variables
 *
 *
 0000301 nflowj 725000000 * break flowrate
 0000302 p 701010000 * bl sg2 pressure
 0000303 p 601010000 * il sg2 pressure
 0000304 nflowj 670000000 * sg2 crossoverline flowrate
 0000305 ctrlvar 51 * integrated break flow
 0000306 ctrlvar 21 * bl sg2 mass
 0000307 ctrlvar 24 * bl sg2 mass
 0000308 rho 720010000 * density before break
 0000309 ctrlvar 16 * il sg2dn level
 0000310 ctrlvar 18 * bl sg2dn level
 0000311 nflowj 635000000 * msg2 out
 0000312 nflowj 735000000 * absig2 out
 0000313 nflowj 610000000 * msg2 in
 0000314 nflowj 722000000 * absig2 in
 0000315 nflowj 615000000 * il auxfeed
 0000316 nflowj 728000000 * bl auxfeed
 0000317 nflowj 634000000 * il sg2 adv
 0000318 nflowj 734000000 * bl sg2 adv
 0000319 tempf 620010000 * il sg2 fv temp
 0000320 tempf 720010000 * bl sg2 fv temp
 0000321 voidf 600010000 * il sg2 voidf
 0000322 voidf 600020000
 0000323 voidf 600030000
 0000324 voidf 600040000
 0000325 voidf 600050000
 0000326 voidf 700010000
 0000327 voidf 700020000
 0000328 voidf 700030000
 0000329 voidf 700040000
 0000330 voidf 700050000
 0000331 ctrlvar 26 * il sg heat
 0000332 ctrlvar 27 * bl sg heat
 0000333 ctrlvar 150 * decay power
 *
 0000341 ctrlvar 6 * pwr level
 0000342 p 999080000 * pwr pressure
 0000343 ctrlvar 999 * pwr heater power
 0000344 nflowj 415000000 * il chg
 0000345 nflowj 515000000 * bl chg
 0000346 nflowj 245000000 * letdown flowrate
 0000347 sattemp 999080000 * pwr sat temp
 0000348 tempf 201010000 * ilhl temp
 0000349 ctrlvar 30 * subcooled margin
 0000350 p 152010000 * upper plenum pressure
 0000351 nflowj 410000000 * il hpis
 0000352 nflowj 430010000 * il acc
 0000353 nflowj 510000000 * bl hpis
 0000354 nflowj 530010000 * bl acc
 0000355 nflowj 252010000 * il flowrate
 0000356 nflowj 352010000 * bl flowrate
 0000357 pumpvel 250 * il pump velocity

```

000358 pppvel 350 * bl ppp velocity
000359 tempf 162010000 * upper plenum temp
000360 tempf 140010000 * lower plenum temp
000361 cntrlvar 29 * pct
000362 voidf 162010000 * upper plenum void
000363 cntrlvar 81 * time step size
000364 optime 0 * cpo time
000365 cntrlvar 999 * pwr power
. ##### ***** end of relap5 input ***** #####
* relap5 model for the seismcale nh-i posttest - restart run
* problem type option
0000100 restart transnt
*
*      inp-chk or run
0000101          run
*
*units      input    output (si or british)
0000102      british   si
*
0000103 12653 * sft1.oct & sft1.rst
*
0000200 1000.0
*           t end min st max st st cl m n j vr
*
0000201 4000.0 1.0e-7 5.0 3 40 800 8000 * recovery
0000202 8000.0 1.0e-7 5.0 3 40 800 8000 * refill
*
0000615 426 and 426 n -1. * aux on sg1 le 955
000427 time 0 ge null 0 4100.0 n -1.0
000428 time 0 le null 0 7700.0 1 -1.0
000617 427 and 428 n -1.
*
6150000 isgafvij bdpjmn
6150101 625000000 603010000 0.012
6150200 1 616
6150201 -1.0 0.0 0.0 0.0
6150202 0.0 0.0510 0.0 0.0
6150203 7000.0 0.0510 0.0 0.0
*
7280000 lsgafvij bdpjmn
7280101 729000000 726000000 0.004
7280200 1 617
7280201 -1.0 0.0 0.0 0.0
7280202 0.0 0.030 0.0 0.0
7280203 7000.0 0.030 0.0 0.0
*
20535100 blpppsd function 425.0 0.0 1
20535101 time 0 252
000423 time 0 ge null 0 4400.0 n -1.
20525200 ilppprs function 425.0 0.0 1
20525201 time 0 252
20525200 react-t 423
20525201 -1.0 0.0
20525202 0.0 1.0
20525203 400.0 1.0
20525204 401.0 0.0
20525205 499.0 0.0
20525206 500.0 1.0
20525207 5000.0 1.0

```

BIBLIOGRAPHIC DATA SHEET

(See instructions on the reverse)

2. TITLE AND SUBTITLE

RELAP5/MOD3 Assessment Using the Semiscale 50% Feed Line Break Test S-FS-11

1. REPORT NUMBER
(Assigned by NRC. Add Vol., Supp., Rev.,
and Addendum Number, if any.)
NUREG/IA-0104

5. AUTHOR(S)

E. J. Lee, B. D. Chung, H. J. Kim

3. DATE REPORT PUBLISHED

MONTH YEAR
June 1993

4. FIN OR GRANT NUMBER
L2245

6. TYPE OF REPORT

Technical

7. PERIOD COVERED (Inclusive Dates)

8. PERFORMING ORGANIZATION - NAME AND ADDRESS (If NRC, provide Division, Office or Region, U.S. Nuclear Regulatory Commission, and mailing address; if contractor, provide name and mailing address.)

Korea Institute of Nuclear Safety
P.O. Box 16, Daeduk-Danji
Daejon, Korea 305-353

9. SPONSORING ORGANIZATION - NAME AND ADDRESS (If NRC, type "Same as above"; if contractor, provide NRC Division, Office or Region, U.S. Nuclear Regulatory Commission, and mailing address.)

Office of Nuclear Regulatory Research
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

10. SUPPLEMENTARY NOTES

11. ABSTRACT (200 words or less)

The RELAP5/MOD3 5m5 code was assessed using the 1/1705 volume scaled Semiscale 50% Feed Line Break (FLB) test S-FS-11. Test S-FS-11 was designed in three phases: (a) blowdown phase, (b) stabilization phase, and (c) refill phase. The first objective was to assess the code applicability to 50% FLB situation, the second was to evaluate the FSAR conservatisms regarding SG heat transfer degradation, steam line check valve failure, break flow state, and peak primary system pressure, and the third was to validate the EOP effectiveness. The code was able to simulate the major T/H parameters except for the two-phase break flow and the secondary convective heat transfer rate. The two-phase break flow had still deficiencies. The current boiling heat transfer rate was developed from the data for flow inside of a heated tube, not for flow around heated tubes in a tube bundle. Results indicated that the assumption of 100% heat transfer until the liquid inventory depletion was not conservative, the failed affected steam generator main steam line check valve assumption was not either conservative, the measured break flow experienced all types of flow conditions, the relative proximity to the 110% design pressure limit was conservative. The automatic actions during the blowdown phase were effective in mitigating the consequences. The stabilization operation performed by operator actions were effective to permit natural circulation cooldown and depressurization. The voided secondary refill operations also verified the effectiveness of the operations while recovering the inventory in a voided steam generator.

12. KEY WORDS/DESCRIPTORS (List words or phrases that will assist researchers in locating the report.)

ICAP Program
RELAP5/MOD3
Semiscale S-FS-11

13. AVAILABILITY STATEMENT

Unlimited

14. SECURITY CLASSIFICATION

(This Page)


Unclassified

(This Report)

Unclassified

15. NUMBER OF PAGES

16. PRICE



Federal Recycling Program



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

SPECIAL FOURTH-CLASS RATE
POSTAGE AND FEES PAID
USNRC
PERMIT NO. G-67

OFFICIAL BUSINESS
PENALTY FOR PRIVATE USE, \$300