



# International Agreement Report

## Assessment of RELAP5/MOD2 Cycle 36.04 Using LOFT Intermediate Break Experiment L5-1

Prepared by  
E. J. Lee, B. D. Chung, H. J. Kim

Korea Institute of Nuclear Safety  
P.O. Box 16, Daeduk-Danji  
Daejon, Korea

Office of Nuclear Regulatory Research  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

April 1992

Prepared as part of  
The Agreement on Research Participation and Technical Exchange  
under the International Thermal-Hydraulic Code Assessment  
and Application Program (ICAP)

Published by  
U.S. Nuclear Regulatory Commission

## **NOTICE**

This report was prepared under an international cooperative agreement for the exchange of technical information.\* Neither the United States Government nor any agency thereof, or any of their employees, makes any warranty, expressed or implied, or assumes any legal liability or responsibility for any third party's use, or the results of such use, of any information, apparatus product or process disclosed in this report, or represents that its use by such third party would not infringe privately owned rights.

Available from

Superintendent of Documents  
U.S. Government Printing Office  
P.O. Box 37082  
Washington, D.C. 20013-7082

and

National Technical Information Service  
Springfield, VA 22161



# International Agreement Report

---

## Assessment of RELAP5/MOD2 Cycle 36.04 Using LOFT Intermediate Break Experiment L5-1

Prepared by  
E. J. Lee, B. D. Chung, H. J. Kim

Korea Institute of Nuclear Safety  
P.O. Box 16, Daeduk-Danji  
Daejon, Korea

Office of Nuclear Regulatory Research  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

April 1992

Prepared as part of  
The Agreement on Research Participation and Technical Exchange  
under the International Thermal-Hydraulic Code Assessment  
and Application Program (ICAP)

Published by  
U.S. Nuclear Regulatory Commission

NOTICE

This report is based on work performed under the sponsorship of The Korea Advanced Energy Institute of Korea. The information in this report has been provided to the USNRC under the terms of an information exchange agreement between the United States and Korea (Agreement on Thermal-Hydraulic Research between the United States Nuclear Regulatory Commission and The Korea Advanced Energy Research Institute, May 1, 1986). Korea has consented to the publication of this report as a USNRC document in order that it may receive the widest possible circulation among the reactor safety community. Neither the United States Government nor Korea or any agency thereof, or any of their employees, makes any warranty, expressed or implied, or assumes any legal liability of responsibility for any third party's use, or the results of such use, or any information, apparatus, product or process disclosed in this report or represents that its use by such third party would not infringe privately owned rights.

**ICAP**

**ASSESSMENT OF RELAP5/MOD2, Cycle 36.04  
USING LOFT INTERMEDIATE BREAK EXPERIMENT L5-1**

**Abstract**

The LOFT intermediate break experiment L5-1, which simulates 12 inch diameter ECC line break in a typical PWR, has been analyzed using the reactor thermal/hydraulic analysis code RELAP5/MOD2, Cycle 36.04. The base calculation, which modeled the core with single flow channel and two heat structures without using the options of reflood and gap conductance model, has been successfully completed and compared with experimental data. Sensitivity studies were carried out to investigate the effects of nodalization at reactor vessel and core modeling on major thermal hydraulic parameters, especially on peak cladding temperature(PCT). These sensitivity items are: single flow channel and single heat structure (Case A), two flow channel and two heat structures (Case B), reflood option added (Case C) and both reflood and gap conductance options added (Case D). The code,RELAP5/MOD2 Cycle 36.04 with the base modeling, predicted the key parameters of LOFT IBLLOCA Test L5-1 better than Cases A,B,C and D. Thus, it is concluded that the single flow channel modeling for core is better than the two flow channel modeling and two heat structure is also better than single heat structure modeling to predict PCT at the central fuel rods. It is recommended to use the reflood option and not to use gap conductance option for this L5-1 type IBLLOCA.



## LIST OF CONTENTS

ABSTRACT .....	iii
LIST OF CONTENTS .....	v
LIST OF TABLES AND FIGURES .....	vi
EXECUTIVE SUMMARY .....	vii
ACKNOWLEDGEMENT .....	ix
1. INTRODUCTION .....	1
2. FACILITY AND TEST .....	4
2.1 LOFT .....	4
2.2 L5-1. ....	4
3. CODE AND MODELING .....	6
3.1 RELAP5/MOD2 Cycle 36.04 .....	6
3.2 Modeling and Nodalization .....	6
3.3 Initial and Boundary Conditions .....	8
4. RESULTS AND DISCUSSIONS FROM BASE CASE CALCULATION .....	10
4.1 Hydraulic Behavior .....	10
4.2 Thermal Behavior .....	13
5. NODALIZATION AND MODEL SENSITIVITY STUDIES .....	15
5.1 Nodalization Sensitivity Study .....	15
5.1.1 Single flow Channel and Single Heat Structure (Case A) .....	15
5.1.2 Two Flow Channels and Two heat Structures (Case B) .....	15
5.2 Model Sensitivity Study .....	16
5.2.1 Reflood Option Added (Case C) .....	16
5.2.2 Reflood and Gap Conductance Option Added (Case D) .....	16
5.3 Inventory Sensitivity Study .....	17
6. RUN STATISTICS .....	19
7. CONCLUSIONS .....	20
REFERENCES .....	23
TABLES .....	24
FIGURES .....	27
Appendix: Input Listing .....	A1

## List of Tables

1. Initial Conditions for Experiment L5-1 and Calculation. . . . .	24
2. Sequence of Events for Experiment L5-1 and Calculation. . . . .	25
3. Assessment Data and Measurement Uncertainties . . . . .	26

## List of Figures

1. RELAP5 Nodalization for LOFT Test L5-1 . . . . .	27
2. Axial profile of Linear heat generation rate for Test L5-1 . . . . .	28
3. Upper plenum pressure transient . . . . .	29
4. Steam dome pressure transient . . . . .	29
5. Steam mass flow rate transient . . . . .	30
6. Feedwater mass flow rate transient . . . . .	30
7. Primary system inventory transient . . . . .	31
8. Intact Loop Hot Leg density transient. . . . .	31
9. Broken Loop Cold Leg density transient . . . . .	32
10. HPIS volume flow rate transient. . . . .	32
11. Accumulator level transient. . . . .	33
12. LPIS volume flow rate transient. . . . .	33
13. Intact Loop Hot Leg mass flow rate transient . . . . .	34
14. Reflooding mass flow rate transient. . . . .	34
15. Integrated break mass transient. . . . .	35
16. Pressurizer level transient. . . . .	35
17. Steam generator level transient. . . . .	36
18. Reactor liquid collapsed level transient . . . . .	36
19. Cladding temperatures at central 15 inch . . . . .	37
20. Cladding temperatures at central 21 and 26 inches . . . . .	37
21. Cladding temperatures at central 37 inch . . . . .	38
22. Cladding temperatures at central 49 inch . . . . .	38
23. Cladding temperatures at peripheral 26 inch. . . . .	39
24. Cladding temperatures at peripheral 45 inch. . . . .	39
25. Void fractions along the core. . . . .	40
26. Time step size . . . . .	41
27. CPU time . . . . .	42
28. The effect of core nodalization sensitivity on PCT . . . . .	43
29. The effect of model option sensitivity on PCT . . . . .	43
30. The effect of two flow channels on peripheral clad temperature . . . . .	44
31. The changes of primary system inventory . . . . .	45
32. The effect of primary system inventory on primary system pressure . . . . .	45
33. The effect of primary system inventory on accumulator liquid level . . . . .	46
34. The effect of primary system inventory on LPSI flowrates . . . . .	46
35. The effect of primary system inventory on PCT . . . . .	47

## Executive Summary

This report describes the assessment calculations using RELAP5/MOD2 Cycle 36.04, a frozen version of the code, to predict the thermal-hydraulic responses of the Loss of Fluid Test (LOFT) L5-1 Intermediate Break Loss of Coolant Accident (IBLOCA). LOFT IBLOCA Test L5-1 simulated 12 inch diameter ECC line break in a typical PWR. The objectives of the present assessment are to provide the applicability and optimum modeling of RELAP5/MOD2 Cycle 36.04 for LOFT IBLOCA Test L5-1. Since ICAP assessment requires sensitivity studies for nodalization and models, the effect of two nodalization and two model option sensitivities on PCT are performed under LOFT L5-1 configuration and sequence. Therefore, the results from this IBLOCA assessment will be helpful to model a similiar transient of a typical PWR IBLOCA. RELAP5/MOD2 Cycle 36.04, used in this assessment, was received in October 1986 from USNRC. Indexing errors were corrected in subroutine RACCUM, IHTCMP and IRFLHT from the frozen code version. There are no changes in physical models and hence the corrected version can also be regarded as RELAP5/MOD2 Cycle 36.04. Results indicated that the base case modeling (single channel and two heat structures) predicted the PCT at the central rods better than Case A and Case B.

However, Case A improved to predict the clad temperature rising time by 10 seconds while Case B improved to predict the PCT in peripheral rods. The code with reflood option underpredicted the PCT than the base case by 7 K. The code, with both reflood and gap conductance model used, also underpredicted the PCT than the base case by 15 K. Conclusively the code, RELAP5/MOD2 Cycle 36.04 with the base modeling, predicted the key parameters of LOFT IBLOCA Test L5-1 better than Cases A, B, C and D. Therefore, it is recommended to use single flow channel and two heat structure modeling; and, to use the reflood option and not to use gap conductance option for this L5-1 type IBLOCA.

## Acknowledgement

This report was completed under the sponsorship of the Korean Ministry of Science and Technology. Dr. Sang-Hoon Lee, President of the Korea Institute of Nuclear Safety, contributed significantly to the project administration. Authors expresses a great appreciation to professors E. C. Lee, C. S. Kang in Seoul National University and professors M. H. Chun, S. H. Chang in Korea Advanced Institute of Science and Technology for their in-depth technical reviews in Korea. Final thank goes to Miss E. K. Kim for preparing data plots.



## 1. INTRODUCTION

The International Code Assessment and Applications Program (ICAP) has been conducted by fourteen nations and multinational organizations under the auspices of the USNRC [1][2]. The USNRC selected two Best Estimate (BE) codes: RELAP5/MOD2 [3][4] and TRAC/PF1/MOD1. The goal of the program is to assess the prediction capabilities and models [5] of the current BE thermal hydraulic(T/H) codes utilizing the available facility test and plant data in the world. The USNRC has plans to replace its present 10 CFR 50 Appendix K LOCA/ECCS rule with a best-estimate approach and an evaluation of uncertainty [2]. The USNRC plans to employ the results from code assessment works to provide conclusions relative to code accuracy and uncertainties through ICAP. The present ICAP aims to quantify uncertainties in the codes so that the code may be used for licensing purposes.

Korean contributions to ICAP include the assessments of RELAP5/MOD2 using ten experiments and five acutal plant data. Six of the assessments are performed with LOFT Integral Effect Test (IET) data [6] and two with semiscale IET data. Two Separate Effect Test (SET) data for critical flow and condensation are used to assess the code RELAP5/MOD2. The work has been conducted by KAERI (Korea Atomic Energy Research Institute), KEPCO (Korea Electric Power Company) and the overall ICAP work inside Korea has been organized and performed in KNSC (Korea Nuclear Safety Center), which is regulatory body in Korea.

Key thermal and hydraulic phenomena such as blowdown, refill and reflood regarding on LBLOCA and SBLOCA separately are well identified over the past

years. Now, it is necessary to investigate the key phenomena of intermediate break loca (IBLOCA). The LOFT IBLOCA experiment L5-1 [8] simulated 12 inch diameter ECC line break (14 % break of 32 inch main piping) in a typical PWR by utilizing a 0.047 m diameter orifice. As quick look report for Test L5-1 [9] summarized the overalls of the experiment, the objective of experiment L5-1 is to provide data to assess the analytical techniques used to model the principal phenomena of an intermediate size break.

The RELAP5/MOD2/cycle 36.04 [3] was implemented in 1986 on a CDC 170-875 computer of KAERI. The code was corrected regarding to indexing errors in subroutines RACCUM and IHTCMP from the frozen version [11]. There are no changes in physical models and hence the corrected version can also be considered as RELAP5/MOD2 Cycle 36.04. Chen and Modro used RELAP5/MOD1 Cycle 13 for pretest [7] and posttest [12] calculations for LOFT L5-1. E. J. Lee and present authors [10] assessed RELAP5/MOD2 Cycle 36.05 by using LOFT SBLOCA Test data L3-7. The input deck for the LOFT IBLOCA Test L5-1 was basically equivalent to that used for LOFT L3-7 simulation with some modifications, which will be explained in Section 3.2.

The base calculation, which modeled the core with single flow channel and two heat structures without using the options of reflood and gap conductance model, has been successfully completed and compared with experimental data. Two types of nodalization sensitivity studies and two types of model option sensitivity studies were carried out to investigate the following effects on PCTs: single flow channel and single heat structure (Case A), two flow channel and two heat structures (Case B), reflood option added (Case C) and both reflood and gap conductance options added (Case D).

To summarize the objectives, this report aims to provide the applicability and optimum modeling of RELAP5/MOD2 Cycle 36.04 for LOFT IBLOCA Test L5-1. Since ICAP assessment requires sensitivity studies for nodalization and models, the effect of two nodalization and two model option sensitivities on PCT will be quantified under LOFT L5-1 configuration and experiment sequence. Thus, the results from this IBLOCA assessment will be helpful to model a similiar transient of typical PWR.

To address these objectives, the report composed of the following sections. The descriptions of the LOFT system and the experiment L5-1 are provided in Chapter 2. The code and modelling for a base calculation are described in Chapter 3. The results of the base case calculation are discussed in Chapter 4 in terms of thermal and hydraulic behaviors. The scope and results of nodalization and model sensitivity studies are presented in Chapter 6. Final conclusions and recommendations from this assessment are presented in Chapter 7. Appendix A contains the input listing used for base case calculation.

## 2. FACILITY AND TEST

### 2.1 LOFT

The LOFT Integral Effect Test (IET) facility [50 Mwt] has been designed to simulate the major components and system responses of a commercial four-loop PWR [1]. The LOFT facility consists of (1) a reactor vessel with a nuclear core(4 wt% U-235), (2) an intact loop (a steam generator and two primary pumps parallel), (3) a broken loop (simulated pump and steam generator and two quick opening valves), (4) the blowdown suppression system and (5) the emergency core coolant (ECC) system (two LPIS, two HPIS pumps and two accumulators). To relate LOFT into a PWR, the test facility is designed as follows: (1) the same linear heat generation rate of the large reactor is used, (2) LOFT powers are scaled according to component volumes (1:60), (3) flow areas are scaled to provide the identical flow to large reactor values, (4) pipe break areas are set in the ratio of core volume and (5) pressure, temperature and mass flux are identical to large reactor values.

### 2.2 L5-1

The LOFT intermediate break experiment series L5 was designed to identify and evaluate the LOFT system thermal-hydraulic response during an intermediate size break LOCE. Experiment L5-1 was initially operated at thermal power of 45.9 Mwt, vessel temperature difference of 27.0 K, mass flow rate of 308.2 kg/s at 14.93 MPa system pressure. The specific objectives of experiment L5-1 are to (1) obtain sufficient data to characterize the prevalent phenomena caused by an ECCS injection line rupture, (2) generate

applicable data for use as a base line in the future planning of intermediate size break, (3) provide data to assess the analytical techniques used to model the principal phenomena of an intermediate size break. Also, data acquisition system was validated during this experiment L5-1.

### 3. CODE AND MODELING

#### 3.1 RELAP5/MOD2 Cycle 36.04

RELAP5/MOD2 Cycle 36.04, a frozen version of RELAP5/MOD2 used in this assessment, was received at October 1986 from USNRC. The code was corrected regarding to indexing errors in subroutine RACCUM, IHTCMP and IRFLHT. There are no changes in physical models and hence the corrected version can also be regarded as RELAP5/MOD2 Cycle 36.04. These corrections were based on the update work of KWU and STUDSVIK [11].

#### 3.2 Modeling and Nodalization

Break, vessel and system modeling including boundary conditions are described in this section. The break for the IBLOCA was modeled with a motor valve whose rate of change for the normalized valve area was 14.0 unit per sec. The full open area, for instance, of LOFT SBLOCA Test L3-7 was 1.278E-5 m<sup>2</sup> while the area of L5-1 break was 173.49E-5 m<sup>2</sup> so that the area ratio of two experiments was about 138. For example, L3-7 simulated 1 inch SBLOCA while L5-1 simulated 11.2 inch I.D. accumulator line rupture. The diameter of actual orifice used in L5-1 experiment was 0.047 m [9] while a 0.004 m diameter orifice was used for L3-7 and so the diameter ratio of two experiments was 11.7. The option of normal junction, nonhomogeneous, smooth area change and choking modeling applied (0000) were used to model L5-1 break.

The pellet stack length of core was 1.68 m and five sets of 15X15 and

four sets of 12X12 nuclear fuel assemblies existed [8]. Among 1300 fuel rods in the LOFT core, the central 204 fuels were modeled as a central hotter pin and the other 1096 fuels were described as a peripheral heat structure. The core basically was modeled as one flow channel which has six almost equal volume length of 0.221 m. Two heat structures were used to model the central assemblies (12300000) and the peripheral (12310000) assemblies respectively. Thus, a multiplication factor for the 204 central pins was calculated as 57.12 ( $1.68 \times 204 / 6$ ) while the factor for the 1096 peripheral pins was 306.88 ( $1.68 \times 1096 / 6$ ). Both reflood and gap conductance option were not used since the primary pressure was kept higher than 1.0 MPa during the period of interest and a tabular form of temperature vs. gap conductance data was used.

The input deck for LOFT L5-1 was basically from the deck equivalent to that for LOFT L3-7 simulation [10]. Some correction were made from the deck. For instance, core length was corrected to 1.68 from 1.98 m. HPIS was modeled with a time dependent junction connected directly into cold leg. HPIS injection was initiated based on a set pressure , 10.6 MPa of hot leg pressure. Accumulator was modeled with "ACCUM" , single volume and a valve. The initial accumulator water level was corrected to be 1.54 m as in experiment and activated when the cold leg pressure was lower than 1.66 MPa. The model "ACCUM" was disconnected in the calculation when accumulator was emptied to overcome an accumulator related error. The flows from accumulator and LPIS were merged into a single volume ECCS header. The values for LPIS capacity were corrected based on the experiment L5-1 and LPIS was activated when the RCS pressure decreased to 1.08 MPa. Primary coolant pump was set to trip at 4.0 seconds. Thermal power was inputted with the combined data from

fission and decay power [8]. Other hydraulic and thermal modelings for primary and secondary loop were conceptually the same as the one used for L3-7 SBLOCA assessment work [10].

The RELAP5/MOD2 nodalization diagram of the base case is shown in Figure 1. The nodalization has 130 volumes, 136 junctions, 143 heat structures and 793 mesh points. Basically the same nodalization concept as L3-7 was applied to L5-1. The nodalization for L3-7 [10] is the reference and few changes were added as described above. Figure 2 shows the comparisons of linear heat generation rate (kW/m) for experiment and calculation along the core height. The history of thermal power from fission and decay was properly described in the input deck.

### 3.3 Initial and Boundary Conditions

The decks L51S12 and L51T12 in Cyber 170-875 were prepared for the purpose of assessment. Convergency was not achieved with the steady deck but the key values for the initial stages (Table 1) were generally within tolerable ranges at 300 second steady calculation. So, the values at 300 seconds were taken as the initial conditions for the following transient calculation. Table 1 shows the initial conditions of both experiment and calculation. The code predicted the primary system mass flow as 308.27 kg/s, hot leg temperature as 581.34 K and cold leg temperature as 553.76 K. Other T/H values for reactor vessel, pressurizer and accumulator were well predicted except the temperatures for the broken loop. The code overpredicted the broken loop hot leg temperature as 561.75 K which was 7.45 K higher than experiment. However, the discrepancy would not affect the

results of later transient because of the small mass flow (about 2.88 kg/s) rate through the broken loop. The major values for the steam generator secondary side were also fairly well predicted. The pressure was 5.00 MPa and steam mass flow rate was 31.5 kg/s initially. Figure 7 shows the initial condition and the transient of primary system inventory. Primary system coolant inventory mass was about 5000 kg and its measurement uncertainty was about 300 kg. The initial offset from the measurement occurred because the mass in the broken loop steam generator and pump was not included in the experiment and analysis [12]. Later, an extra calculation with a revised initial condition might be required to assess its effect on primary system pressure, accumulator and LPIS flow rates, and PCT.

Boundary conditions, composed of initial condition and sequence of event, should be matched with actual experimental conditions to describe the dynamic system boundary properly. Table 2 shows the sequence of events for experiment L5-1 and the base calculation. Within one second, reactor was scrammed and the secondary side inlet/outlet valves were closed and HPIS trip point was reached (10.6 MPa). HPIS injection was initiated with 2.48 seconds delay. Lowest in-core thermal excursion started at 184 and 182 seconds in experiment and base calculation. Accumulator (1.66 MPa) was injected at 185.8 and 189 seconds respectively. Maximum fuel cladding temperature reached 715 K at 198 seconds in experiment and 676 K at 210 seconds in base calculation. So the code underpredicted the PCT by 39 K. Finally LPIS (1.08 MPa) flow was initiated at 201 seconds in calculation and 227 seconds in experiment.

#### 4. RESULTS AND DISCUSSIONS FROM BASE CASE CALCULATION

Table 3 summarizes the list of assessment parameters. It describes the identification of calculated and measured parameter in addition to uncertainties of measurements. The corresponding figure numbers to the assessment parameters are also listed in Table 3. The system phenomena governing the response of I5-1 are classified as hydraulic and thermal behavior for the purpose of further discussions. Hydraulic behavior can be explained primarily with discharge flow rate, depressurization, external ECCS flow, system inventory and core mixture level. Thermal behavior can be categorized with the core thermal power, S/G secondary operation, core void and PCT. Since the break diameter is greater than 9 inch, it experiences a relatively rapid depressurization process compared with a typical SBLOCA. Thus, the transient can be characterized by a blowdown/refill process occurred relatively slower than typical LBLOCA and the safety is mainly affected by accumulator and LPIS flow rather than HPIS flow.

##### 4.1 Hydraulic Behavior

The upper plenum pressure was depressurized very rapidly to 7 MPa in 20 seconds, and then, slowly depressurized at a rate of 1 MPa per 50 seconds until LPIS was initiated (Figure 3). The steam dome pressure was well predicted (Figure 4) besides the mass flow rates of steam generator inlet (Figure 5) and outlet (Figure 6). The primary system inventory was well represented indicating that the discharge and incharge flows from ECCS were properly described (Figure 7). However, Figure 8 shows the density of ILHL overpredicted in 50 sec and 250 sec, probably due to overpredicted system

pressure (Figure 3) and overestimated LPIS flow (Figure 12). Figure 9 and 10 show the density of BLHL and HPIS flow rate matching with the experiment fairly well. Figure 11 shows the liquid level of accumulator; and, interestingly a 15 sec stagnant existed in 215 sec because of the repressurized system pressure (Figure 3) due to LPIS flow (Figure 12). Figure 13 shows the flow rate of ILHL and Figure 14 shows the reflooding rate, which influences the PCT most. Figure 14 indicates the negative flow after 37 sec till accumulator injects. The positive mass flow is less than 50 kg/s in reflood phase. The slow depressurization occurred because the energy removed through the break (Figure 15) was less than the energy generated in the reactor core. After the interface between liquid and vapor fell below the break elevation, the rate of energy removal through the break increased. The RCS continued to depressurize after pressurizer was emptied (Figure 16) until accumulator injected.

The calculations showed that a large volume of water supplied from accumulator and LPIS more than compensated for the loss of reactor coolant inventory and repressurized again at 217 seconds (Figure 3, 11 and 12). It was verified again that accumulator and LPIS influenced more on safety than HPIS for this type of larger SBLOCA, i.e. IBLOCA transient (Figure 21). In core wise, the liquid was drained off at 180 seconds and started to be filled up again at 190 seconds due to the accumulator injection at 189 seconds. Significant core uncovering occurred but the core quenches again due to the accumulator flow initiation (Figure 18).

Although the primary pressure decreased to 1 MPa in 200 seconds (Figure 3), the accumulator flow was injected at 186 seconds so that the fuel

cladding temperature quickly dropped thereafter (Figure 21). The steam dome pressure was predicted initially properly and overpredicted by 0.2 MPa at 25 seconds but, after 90 seconds, underpredicted upto by 0.8 MPa (Figure 4). The ILHL density at 50 seconds and 250 seconds were overestimated (Figure 8) probably due to overestimated ILHL mass flow rate (Figure 13). The overestimated mass flow rates were caused by overpumping HPIS (Figure 10) and LPIS (Figure 12) flow rates. These overestimated flow rates caused a 17 second stagnant of accumulator water level (Figure 11) at 217 second and it also affected the plateau of core mixture level. The base calculation predicted the key parameters of L5-1 experiment fairly well except two cases: the starting time of cladding temperature rise (dry-out) and earlier heat up in peripheral PCT measured. The base calculation predicted the start time of PCT rise 30 seconds later than the experiment (Figure 21). Figure 15 showed that the integrated break flow was predicted fairly well within maximum range of 200 kg. Figure 7 indicated that the primary system inventory was initially overpredicted by 500 kg and this affected to overpredict the inventory by 400 - 500 kg over the transient. The overestimated water inventory probably caused the heatup to start later. Otherwise the low mass flux CHF correlation from modified Zuber [5] has a deficiency in the operating range because core mass flow was less than order of 20 kg and flow area was 0.17 m<sup>2</sup> and, therefore, the mass flux surely less than 100 kg/m<sup>2</sup>/s. Providing that the discharge flow rate and the inventory were well predicted, Modified Zuber correlation overpredicted Q(CHF) and needs to be examined for this low range mass flux and pressure. Also, fuel cladding temperature measurements in a peripheral assembly 4 at 45 inch (T-4E8-45) indicated an early heat-up, quenching, reheat-up and final quenching (Figure 24). However, the calculation did not catch the early heat-up.

Therefore, nodalization sensitivity study including two-flow channel effect on the peripheral fuel clad temperature is motivated to investigate whether the source of the deficiency comes from the code, modelling or experiment.

#### 4.2 Thermal Behavior

This assessment used a combined thermal power from fission and decay power. History of thermal power from Reference 8 shows that the magnitude of fission power is very small after 10 seconds and thereafter the decay power, ranging from 2 MW to 1 MW, is dominant. A rapid core mixture level drop lead to a core uncovering. As two-phase circulation through the primary loop stops, the mixture levels in the S/G tubes drop steadily on both uphill and downhill side moving into a reflux cooling mode. The vessel mixture level also drops slowly during this S/G tube draining period until the mixture level reaches the bottom of the hot leg. Once the level reaches the bottom of the hot leg, it starts to decrease very rapidly because of the lack of a significant water supplied to the core from S/G. The mixture level affecting the fuel cladding temperature strongly decreases or increases depending upon loop seal clearing or degree of ECCS water supply. In this case, the mixture level increased again due to sufficient ECCS water supply.

Liquid void fraction of 230040000 became zero at 150 sec (Figure 25) and, then, thermal excursion started. At 198 seconds, maximum fuel cladding temperature of 715 K measured while the code predicted the start time of dry-out later by 25 second and the peak as 675 K (Figure 21). At the central and 26 inch (T-5F4-026) location of fuel assemblies, the code still predicted

the start of heatup later with the same heatup rate and underpredicted the peak by 15 K (Figure 20). At the central and 49 inch (T-5E8-49), the code predicted the start time of core heatup 25 seconds later than the one of the experiment and still underpredicted the peak by 40 K (Figure 22). At the peripheral and 26 inch (T-4F9-26), the code overpredicted the peak by 150 K due to highly estimated LHGR at the peripheral locations (Figure 23). The measured peak cladding temperature of 715 K at 198 second was obtained at the central and 37 inch (T-5D8-37) measurement location. The calculation, at central 36.5 inch, with single flow channel and two heat structures underestimated the peak as 675 K at 210 seconds while the experiment produced the PCT as 715 K at 198 seconds.

Consequently, it showed again that compensating effects of discharge flow, decay power and external ECCS water supply decided the mixture level of the core. Considering heat transfer mechanism in core side, the core experienced a slow downward liquid drain off until 180 seconds (blowdown phase) and started to be filled up again from 190 seconds (refill/reflood phase). The first part can be considered as a slow blowdown phase and the second part as a refill or reflood period. Core mixture level increased again due to the flows from accumulator and LPIS. Accumulator and LPIS flow injection finally cooled down the fuel.

The effect of two flow channel and even single heat structure on PCT would be interesting to quantify its effect. The base modeling did not use the options of reflood and gap conductance model. Therefore, the effects of each options on PCT will be demonstrated as alternatives of model sensitivity studies.

## **5. NODALIZATION AND SENSITIVITY STUDIES**

From the discussions in the base calculations, two types (Case A and Case B) of nodalization and two types (Case C and Case D) of model option sensitivity studies were proposed to quantify its effect on a key safety parameter, PCT. The central PCT measured at T-5D8-37 was compared with HTTEMP 2300410 and a peripheral PCT measured at T-4E8-45 compared with HTTEMP 2310510. First, reflood option was added to the base modeling and, then, recalculation has been done with gap conductance option added as model sensitivity items.

### **5.1 Nodalization Sensitivity Study**

#### **5.1.1 Single Flow Channel and Single Heat Structure (Case A)**

Case A, which modeled the core as single flow channel and single heat structure, indicated the start time of clad temperature rise 10 seconds earlier and underpredicted the PCT by 25 K in comparison with the base case. A later peak was calculated due to a stagnation of accumulator flow. Consequently, single pin modeling had advantage of predicting earlier dry-out time but disadvantage of PCT prediction when compared with the base case, which modeled the core as single flow channel and two heat structures (Figure 28).

#### **5.1.2 Two Flow Channel and Two Heat Structures (Case B)**

Case B, two flow channel and two heat structures, showed a later heatup

and still lower PCT but better than Case A. However, a second peak was observed and not appeared in the experiment, which was directly due to the stagnant flow from accumulator. Two flow channel and two pin model did not improve the central PCT prediction but the peripheral PCT was predicted better. Figure 29 and 30 showed an earlier measurement peak, which was not predicted in calculations. The earlier peak probably was caused by a liquid deentrainment during the experiment and the modeling concept based on one-dimensional could not catch the earlier heatup.

## 5.2 Model Sensitivity Study

### 5.2.1 Reflood Option Added (Case C)

Case C, reflood option only added, predicted the PCT 10 K lower than the base case (Figure 29). The reflood initiation pressure at Volume 230060000 was set as 2.0 MPa because the overall system pressure did not go below 1.0 MPa in experiment and to turn on the reflood option as in the experiment. Case C did not include the accompanying peak during quenching, which was experienced in the base calculation. This straight quenching without the peak behaved more closely to the experiment than the base case. Therefore, using the reflood option is recommended even for the transient process pressure about 2.00 MPa.

### 5.2.2 Reflood and Gap Conductance Option Added (Case D)

Case D, both reflood and gap conductance option used, indicated the start time of clad temperature rise 10 seconds later and even lower PCT by 25

K than the base (Figure 29). The second peak during quenching was observed but the magnitude was negligible. Both models contributed to calculate the PCT lower than the base case. The higher gap conductance values, the lower PCTs were calculated. This study also indicated that the gap conductance data given in the base deck were lower than the data calculated by gap conductance model. Since the heatup rates of the two cases were similar and the PCT was underestimated, it is not recommended to use the gap conductance option for this type IBLOCA; and, instead, tabular form used in the base case is more preferable.

### 5.3 Inventory Sensitivity Study

Primary system inventory mass is the one of key safety parameters for a LOCA. It affects primarily to primary system pressure, ECCS flow rates, core blowdown/flooding rates, and PCT finally. Thus, the effect of the inventory mass was investigated to see its effects on the key T/H parameters for L5-1 type IBLOCA. Figure 31 shows the changes of the primary system inventory, which excluded the mass in the simulated steam generator and pump of the broken loop so that the initial mass and inventory were reduced during the overall transient. Figure 32 shows the effect of the mass inventory on primary system pressure. The reduced one was able to follow the transient of the experiment more closely till blowdown period around 100 seconds. Afterwards, it depressurized more rapidly so that the core started to boil off earlier and, also, the accumulator (Figure 33) and LPIS (Figure 34) were turned on earlier, too. The earlier actuation of the ECCS components resulted in quenching the heater rod to heat up earlier. Therefore, the reduced inventory affected the heater rod to heatup 10 seconds earlier but

the maximum PCT was underestimated due to the earlier ECCS actuation.

## 6. RUN STATISTICS

The input models for the base case of LOFT L5-1 included 130 volumes, 136 junctions and 143 heat structures. Figure 26 compared time step size, DT vs. transient time. Figure 27 compared CPU time vs. transient time. The ratio of CPU vs transient time came out to be about 1537/300, i.e. 5.12 for the base case calculation.

During the transient calculation the following resources were used :

Base	
Computer time CPU (s)	1537
Number of time step DT	6539
Number of Volumes C	130
Transient real time RT(s)	300

The calculated grind time (code efficiency factor) for 300 s is

$$\frac{CPU * 1000}{C * DT} = \frac{(1537) * 1000}{(130) (6539)} = 1.80 \text{ (m sec/vol/step) for Base Case}$$

The computer used was a cyber 170-875

## 7. CONCLUSIONS

RELAP5/MOD2 Cycle 36.04 code was assessed using LOFT L5-1 IBLOCA test data. A base case calculation including single flow channel and two heat structures was carried out without using reflood and gap conductance models as a reference case. Two cases of nodalization studies and two types of model sensitivity studies were conducted to quantify their effects primarily on PCT. Case A modeled the core as single flow channel and single heat structure while Case B modeled the core as two flow channels and two heat structures. Case C used reflood option over the base modeling and Case D added gap conductance option to Case C. Additional calculation with the revised initial inventory showed that it affected to reduce the primary system pressure more rapidly and, therefore, the fuel rod started to heat up 10 seconds earlier so that the accumulator and LPIS were turned on earlier, too. Consequently the revised one improved to predict the core heatup time but the maximum PCT was predicted not more accurately due to the earlier injection flows from accumulator and LPIS. Based on the results from the given scope, the following conclusions can be made.

- 1) Using LOFT IBLOCA test data L5-1, a base case calculation with a base nodalization was successfully executed and matched fairly well with the LOFT IBLOCA L5-1 experimental data.
- 2) The code with base nodalization showed that core clad temperature rise occurred 25 sec later and underpredicted the PCT by 40 K in comparison with the experiment. The modeling with a single flow channel and a single heat structure improved the start of clad temperature rise (heatup) by 10 seconds

but underpredicted the PCT worse by 50 K, compared with the experiment. The model with two-channel and two heat structures predicted the PCT a little better than Case A by 5 K but heatup started later than the base case by 10 seconds. Therefore, the base modeling, a single flow channel and two heat structures, proves to be better than the Case A and the Case B to predict the PCT for LOFT IBLOCA L5-1 transient.

- 3) The base modeling did not predict the early peak occurred at 125 sec as in temperature measurement at T-4E8-045 (Figure 30) and the limitation of one dimensional modeling caused not to predict the earlier peak observed in the experiment. The model with two channels and two pins improved to predict the PCT in the peripheral assemblies by 20 K compared with the base case; but, still the code overpredicted the reflood PCT at the peripheral assemblies because the modeling assumed higher LHGR.
- 4) Model sensitivity studies revealed that the case with reflood model option underpredicted the PCT more than the base case by 10 K. The case with both reflood and gap conductance option underpredicted the PCT even worse than the base case by 20 K. Consequently, if both model options were added, then lower PCT was calculated. The higher the gap conductance values, the lower PCTs were calculated. This means that the gap conductance data inputted to the base deck are lower than the values calculated from gap conductance model. So it is recommended to use reflood option and not to use gap conductance option additionally for the IBLOCA application.
- 5) 25 seconds later dry-out time encountered in calculating the core thermal behavior was not significantly improved through the four proposed sensitivity

studies although Case A improved the start time of dry-out by 10 seconds. Results with the revised initial inventory mass indicated that the reduced inventory improved the core heatup time 10 seconds but the maximum PCT was underestimated due to the earlier injection of accumulator and LPIS. The code should model the depressurization properly to predict the heatup and the CHF modeling at the corresponding pressure and flow rates during the blowdown was the area for further improvements[12,13,14]. So, the originally proposed L5-1 base modelling is the optimum for LOFT IBLOCA Test L5-1 simulation among the tested cases.

## References

1. U. S. Regulatory Commission, Compendium of ECCS Research for Realistic LOCA Analysis, NUREG-1230, May 1987.
2. Guidelines and Procedures for the International Code Assessment and Applications Program, NUREG-1271, April 1987.
3. V. H. Ransom et al., RELAP5/MOD2 Code Manual  
Volume 1: Code Structure, Systems Models and Solution Methods  
Volume 2: Users Guide and Input Requirements, NUREG/CR-4312, March 1987.
4. V. H. Ransom et al., RELAP5/MOD2 Code Manual  
Volume 3: Developmental Assessment Problems, EGG-TFM-7952, December 1987.
5. R. A. Dimenna et al., RELAP5/MOD2 Models and Correlations, NUREG/CR-5194, August 1988.
6. C. L. Nalezny, Summary of Nuclear Regulatory Commission's LOFT Program Experiments, NUREG/CR-3214, EGG-2248, July 1983.
7. T. H. Chen and S. M. Modro, Best Estimate Prediction for LOFT Nuclear Experiment L5-1, EGG-LOFT-5540, September 1981.
8. D. B. Jarrell and J. M. Divine, Experiment Data Report for LOFT Intermediate Break Experiment L5-1 and Severe Core transient Experiment L8-2, NUREG/CR-2398, EGG-2136, November 1981.
9. J. P. Adams, Quick-Look Report on LOFT Nuclear Experiments L5-1 and L8-2, EGG-LOFT-5625, October 1981.
10. E. J. Lee et al., Assessment of RELAP5/MOD2, Cycle 36.05 Against LOFT Small Break Experiment L3-7 (NUREG/IA Draft)
11. Seeberger, RELAP5/MOD2-RH2 Modification of Cycle 36.04, U811-87-3065a, December 22 1987, Kraftwerk Union, Erlangen.
12. T. H. Chen and S. M. Modro, Posttest Calculation of LOFT Intermediate Break Experiment L5-1 and Severe Core Transient Experiment L8-2, EGG-LOFT-6004, September 1982.
13. S. N. Aksan et al., Switzerland's Code Assessment Activities in Support of the ICAP, PSI Paper Presented at the 16th Water Reactor Safety Information Meeting, October 24 1988, Gaithersburg, Maryland, U.S.A.
14. H. J. Kim, Letter to R. R. Schultz, Jan 17, 1991

Table 1 INITIAL CONDITIONS FOR EXPERIMENT L5-1

Parameter	Experiment L5-1 Measured Value (EDR [8])	REALP5/MOD2/Cycle 36.04 Calculated Value (L51S12) [I.C. of L51T12]
<b>Primary System</b>		
Mass flow (kg/s)	308.20	308.27
Hot leg pressure (MPa)[a]	14.93	14.87
Cold leg temperature (K)	552.30	553.76
Hot leg temperature (K)	579.10	581.34
Boron concentration (ppm)	669.00	-
Vessel DT (K)	26.80	27.58
<b>Reactor Vessel</b>		
Power level (MW)	45.90	45.77
Max LHGR (kW/m)	46.00	42.50
<b>Pressurizer</b>		
Vapor volume (m <sup>3</sup> )	0.33	-
Liquid volume (m <sup>3</sup> )	0.60	-
Liquid temperature (K)	615.00	614.48
Liquid level (m) [a]	1.13	1.10
<b>Broken Loop</b>		
Cold leg temperature (K)	549.20	557.40
Hot leg temperature (K)	554.30	561.75
<b>Steam Generator Secondary Side</b>		
Liquid level (m) [b]	0.27	0.287
Liquid temperature (K)	537.80	533.210
Pressure (MPa)	5.05	5.010
Mass flow (kg/s)	25.30	24.493
<b>Accumulator A</b>		
Liquid level (m) [c]	1.49	1.490
Pressure (MPa)	1.66	1.660
Liquid temperature (K)	308.20	308.200

[a] Out of specification, but did not impair results

[b] The liquid level is defined as 0.0 at 2.95 m  
above the top of the tube sheet

[c] Liquid level is measured from 0.32 m  
above the bottom of the accumulator vessel

Table 2 SEQUENCE OF EVENTS FOR EXPERIMENT L5-1

Events	Time after Experiment Initiation (s)	
	Experiment L5-1 [8]	Calculation L51T12
Cold leg QOBV opened [a]	0.0	0.0
Reactor scrammed	0.17	0.06
Main feed pump tripped and steam control valve started to close	0.17	0.07
Upper plenum reached saturation	0.20	0.25
HPIS trip point reached (10.6 MPa)	0.40	0.30
HPIS injection flow initiated	2.88	2.90
Primary coolant pump tripped	4.00	4.00
Broken loop cold leg reached saturation	10.50	11.00
Steam generator steam control valve closed	12.10	12.00
Pressurizer indicated empty	15.50	15.00
Primary pressure dropped below secondary	53.00	50.00
Fuel cladding thermal excursion started	108.40	141.00
Lowest in-core thermal excursion level reached	184.00	181.00
Accumulator A injection started	185.80	187.25
Maximum fuel cladding temperature reached (715 K for Experiment L5-1)	198.00	207.00
LPIS flow initiated	201.00	(675 K at 23004) 195.49

[a] Experiment initiation is defined to be the time when the broken loop cold leg pressure began to increase.

**Table 3 List of Assessment Parameters (LOFT L5-1)**

Description	Calculation	Measurement	Uncertainty	Figure
<b>Primary System</b>				
Pressure (Pa)	P 25001	PE-1UP-001A	0.140-0.777 EDR [8]	3
Steam Dome Pressure (Pa)	P 53001	PE-SGS-001	0.087-0.077	4
Steam Mass				
Flow rate (kg/s)	MFLOWJ 54000	FT-P004-012	0.28	5
Feedwater Mass				
Flow Rate (kg/s)	MFLOWJ 56900	FT-P004-722	2.40	6
<b>Primary System Inventory (kg)</b>	CNTRVAR 72	Fig 4 EDR	300.0	7
ILHL				
Density (Mg/m3)	RHO 10001	DE-PC-002B	0.13	8
BLCL				
Density (Mg/m3)	RHO 34501	DE-BL-002B	0.099	9
HPIS Volume				
Flow Rate (L/s)	MFLOWJ 64000	FT-P128-104	0.014	10
Accumulator				
Level (m)	CNTRVAR 4	LE-ECC-01A	0.007	11
LPIS Volume				
Flow Rate (L/s)	MFLOWJ 63000	FT-P120-085	0.37	12
ILHL Mass				
Flow Rate (kg/s)	MFLOWJ 10001	FT-P139-272	4.6	13
Reflooding Mass				
Flow Rate (kg/s)	MFLOWJ 23001	-	-	14
Integrated Break				
Mass Flow Rate (kg/s)	CNTRVAR 51	QLR [9]	-	15
Pressurizer				
Level (m)	CNTRVAR 2		-	16
Steam Generator				
Level (m)	CNTRVAR 1		-	17
Reactor Water				
Level (m)	CNTRVAR 10		-	18
Cladding Temp (K)	2300110 ( 7.5 " )	T-5E8-015	4.2 K	
(Central, 15 inch)	2300210 (19.5 " )		at 600 K	19
Cladding Temp (K)	2300310 (27.5 " )	T-5F4-021	"	
(Central, 21 & 26 " )		T-5F4-026	"	20
Cladding Temp (K)	2300410 (36.5 " )	T-5D8-037	"	
(Central, 37 inch)				21
Cladding Temp (K)	2300510 (45.5 " )	T-5E8-049	"	
(Central, 49 inch)	2300610 (52.5 " )			22
Cladding Temp (K)				
(Peripheral, 26 " )	2310310 (27.5 " )	T-4F9-026	"	23
Cladding Temp (K)				
(Peripheral, 45 " )	2310510 (45.5 " )	T-4E8-045	"	24
Void Fraction	VOIDF 23001 - 06		-	25
Time Step,DT (sec)	CNTRVAR 81	-	-	26
CPU time (sec)	CPUTIME	-	-	27

- Not available




Figure 1. RELAP5 Nodalization for LOFT Test L5-1




Figure 2. Axial profile of linear heat generation rate for Test L5-1




Figure 3. Upper plenum pressure transient




Figure 4. Steam dome pressure transient




Figure 5. Steam mass flow rate transient




Figure 6. Feedwater mass flow rate transient




Figure 7. Primary system inventory transient




Figure 8. Intact Loop Hot Leg density transient




Figure 9. Broken Loop Cold Leg density transient .




Figure 10. HPIS volume flow rate transient




Figure 11. Accumulator level transient




Figure 12. LPIS volume flow rate transient




Figure 13. Intact Loop Hot Leg mass flow rate transient




Figure 14. Reflooding mass flow rate transient




Figure 15. Integrated break mass transient




Figure 16. Pressurizer level transient




Figure 17. Steam generator level transient




Figure 18. Reactor liquid collapsed level transient




Figure 19. Cladding temperatures at central 15 inch




Figure 20. Cladding temperatures at central 21 and 26 inches




Figure 21. Cladding temperatures at central 37 inch




Figure 22. Cladding temperatures at central 49 inch




Figure 23. Cladding temperatures at peripheral 26 inch




Figure 24. Cladding temperatures at peripheral 45 inch




Figure 25. Liquid fractions along the core




Figure 26. Time step size




Figure 27. CPU time




Figure 28. The effect of core nodalization sensitivity on PCT




Figure 29. The effect of model option sensitivity on PCT




Figure 30. The effect of two flow channels on peripheral clad temperature




Figure 31. The changes of primary system inventory




Figure 32. The effect of primary system inventory on primary system pressure




Figure 33. The effect of primary system inventory on accumulator liquid level




Figure 34. The effect of primary system inventory on LPISI flowrates




Figure 35. The effect of primary system inventory on PCT

## **Appendix: Input Listing**





0000319	SATTEMP	180010000	* TE-PC-1
0000320	SATTEMP	114010000	* TE-SG-1
0000321	SATTEMP	116010000	* TE-SG-2
0000322	SATTEMP	510030000	* TE-SG-3
0000323	SATTEMP	415040000	* TE-139-19
0000324	SATTEMP	415030000	* TE-139-20
0000325	SATTEMP	205010000	* TE-1ST-1 / TE-2ST-1
0000326	SATTEMP	210010000	* TE-1ST-2 / TE-2ST-2
0000327	SATTEMP	210050000	* TE-1ST-6 / TE-2ST-6
0000328	SATTEMP	210060000	* TE-1ST-7 / TE-2ST-7
0000329	SATTEMP	215010000	* TE-1ST-10 / TE-2ST-10
0000330	SATTEMP	220010000	* TE-1ST-13 / TE-2ST-13
0000331	SATTEMP	250010000	* TE-1UP-6
0000332	SATTEMP	251010000	* TE-2UP-4
0000333	SATTEMP	255010000	* TE-1UP-3
*-----1-----1-----1-----1-----1-----1-----			
<b>* DENSITIES</b>			
*-----1-----1-----1-----1-----1-----1-----			
0000334	RHO	345010000	* DE-BL-1
0000335	RHO	310010000	* DE-BL-2
0000336	RHO	180010000	* DE-PC-1
0000337	RHO	100010000	* DE-PC-2
0000338	RHO	118020000	* DE-PC-3
*-----1-----1-----1-----1-----1-----1-----			
<b>* VELOCITIES</b>			
*-----1-----1-----1-----1-----1-----1-----			
0000339	VELF	345010000	* FE-BL-1
0000340	VELF	310010000	* FE-BL-2
0000341	VELF	180010000	* FE-PC-1
0000342	VELF	100010000	* FE-PC-2
0000343	VELG	345010000	* FE-BL-1
0000344	VELG	310010000	* FE-BL-2
0000345	VELG	180010000	* FE-PC-1
0000346	VELG	100010000	* FE-PC-2
*-----1-----1-----1-----1-----1-----1-----			
<b>* MASS FLOW RATES</b>			
*-----1-----1-----1-----1-----1-----1-----			
0000347	MFLOWJ	350010000	* BREAK PLANE BLCL
0000348	MFLOWJ	315110000	* BREAK PLANE BLHL
0000349	MFLOWJ	345020000	* DTT-RAKE BLCL
0000350	MFLOWJ	310020000	* DTT-RAKE BLHL
0000351	MFLOWJ	180010000	* DTT-RAKE ILCL
0000352	MFLOWJ	100020000	* DTT-RAKE ILHL
0000353	MFLOWJ	400010000	* PRES. SURGE LINE FLOW
0000354	MFLOWJ	541010000	* FE-P4-12
0000355	MFLOWJ	566000000	* FE-P4-72-1
*-----1-----1-----1-----1-----1-----1-----			
<b>* CLADDING TEMPERATURES CONTROL MODULE</b>			
*-----1-----1-----1-----1-----1-----1-----			
0000356	HTTEMP	230000110	*
0000357	HTTEMP	230000210	*
0000358	HTTEMP	230000310	*
0000359	HTTEMP	230000410	*
0000360	HTTEMP	230000510	*
0000361	HTTEMP	230000610	*
*-----1-----1-----1-----1-----1-----1-----			
<b>* LIQUID FRACTIONS IN THE PRESSURIZER</b>			
*-----1-----1-----1-----1-----1-----1-----			





	"RVN ILHL "		BRANCH			
1000001	2	0				
1000101	0.0	1.58878	0.102752	0.0	0.0	0.0
1000102	4.0E-5	0.0	00			
1000200	0	14913500.	1328990.	2461830.	0.0	0.0
1001101	252010000	100000000	0.0634	0.1	0.1	0002
1002101	100010000	105000000	0.0	0.1	0.1	0000
1001201	10.523000	10.523000	0.0			
1002201	10.517000	10.517000	0.0			
*	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----
* PRESSURIZER CONNECTION TEE REACTOR VESSEL SIDE						
*	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----
1050000	"PZR T RVS "		BRANCH			
1050001	1	0				
1050101	0.0634444	1.0531192	0.0	0.0	0.0	0.0
1050102	4.0E-5	0.0	00			
1050200	0	14905700.	1328990.	2461990.	0.0	0.0
1051101	105010000	107000000	0.0	0.12	0.12	0000
1051201	10.757000	10.757000	0.0			
*	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----
* PRESSURIZER CONNECTION TEE						
*	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----
1070000	"PZR T "		BRANCH			
1070001	1	0				
1070101	0.0620253	0.2810215	0.0	0.0	0.0	0.0
1070102	4.0E-5	0.0	00			
1070200	0	14897600.	1328990.	2462160.	0.0	0.0
1071101	107010000	110000000	0.0	0.135	0.135	0000
1071201	11.009	11.009	0.0			
*	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----
* PRESSURIZER CONNECTION TEE STEAM GENERATOR SIDE						
*	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----
1100000	"PZR T SGS "		BRANCH			
1100001	1	0				
1100101	0.0606063	0.9207292	0.0	0.0	0.0	0.0
1100102	4.0E-5	0.0	00			
1100200	0	14888500.	1328980.	2462350.	0.0	0.0
1101101	110010000	112000000	0.0	0.15	0.15	0000
1101201	11.628000	11.628000	0.0			
*	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----
* HOT LEG PIPING						
*	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----
1120000	"HOT LEG PP"		PIPE			
1120001	2					
1120101	0.0	2				
1120201	0.0	1				
1120301	1.38893	1				
1120302	0.707687	2				
1120401	0.0796973	1				
1120402	0.0579614	2				
1120501	0.0	2				
1120601	0.0	1				
1120602	90.0	2				
1120701	0.0	1				
1120702	0.246447	2				
1120801	4.0E-5	0.0	2			
1120901	0.20	0.20	1			
1121001	00	2				

1121101	0000	1					
1121201	0	14873600.	1328970.	2462670.	0.0	0.0	01
1121202	0	14885900.	1328970.	2462410.	0.0	0.0	02
1121300	0						
1121301	11.628000	11.628000	0.0	01			
*-----	1-----	1-----	1-----	1-----	1-----	1-----	1-----
* SG INLET PLENUM							
*-----	1-----	1-----	1-----	1-----	1-----	1-----	1-----
1140000	"SG IN PLNM"	BRANCH					
1140001	2	0					
1140101	0.0	0.629795	0.33532	0.0	90.0	0.512756	
1140102	4.E-5	0.0102	00				
1140200	0	14801000.	1328950.	2464200.	0.0		
1141101	112010000	114000000	0.0512	0.0	0.0	0.0	0100
1142101	114010000	115000000	0.0	0.0	0.0	0.0	0100
1142101	8.1466000	8.1466000	0.0				
1142201	4.4143000	4.4143000	0.0				
*-----	1-----	1-----	1-----	1-----	1-----	1-----	1-----
* SG U-TUBES							
*-----	1-----	1-----	1-----	1-----	1-----	1-----	1-----
1150000	"SG TUBES "	PIPE					
1150001	8						
1150101	0.0	8					
1150201	0.151171	7					
1150301	0.902	1					
1150302	0.6096	3					
1150303	0.462908	5					
1150304	0.6096	7					
1150305	0.902	8					
1150401	0.136356	1					
1150402	0.0921538	3					
1150403	0.0699783	5					
1150404	0.0921538	7					
1150405	0.136356	8					
1150501	0.0	8					
1150601	90.0	4					
1150602	-90.0	8					
1150701	0.902	1					
1150702	0.6096	3					
1150703	0.299572	4					
1150704	-0.299572	5					
1150705	-0.6096	7					
1150706	-0.902	8					
1150801	1.27-7	0.01022	8				
1150901	0.0	0.0	7				
1151001	00	8					
1151101	0000	7					
1151201	0	14781200.	1308850.	2464620.	0.0	0.0	01
1151202	0	14767100.	1292040.	2464910.	0.0	0.0	02
1151203	0	14755800.	1277830.	2465150.	0.0	0.0	03
1151204	0	14746400.	1267890.	2465350.	0.0	0.0	04
1151205	0	14741200.	1258740.	2465460.	0.0	0.0	05
1151206	0	14738500.	1247990.	2465520.	0.0	0.0	06
1151207	0	14736200.	1237950.	2465570.	0.0	0.0	07
1151208	0	14733400.	1228440.	2465630.	0.0	0.0	08
1151300	0						
1151301	4.3678000	4.3678000	0.0	01			
1151302	4.3300000	4.3300000	0.0	02			

1151303	4.2988000	4.2988000	0.0	03			
1151304	4.2777000	4.2777000	0.0	04			
1151305	4.2587000	4.2587000	0.0	05			
1151306	4.2370000	4.2370000	0.0	06			
1151307	4.2166000	4.2166000	0.0	07			
*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----							
* SG OUTLET PLENUM							
*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----							
1160000	"SG OUT PLN"	BRANCH					
1160001	2	0					
1160101	0.0	0.629795	0.33532	0.0	-90.0	-0.512756	
1160102	4.E-5	0.0102	00				
1160200	0	14735800.	1228440.	2465580.	0.0		
1161101	115010000	116000000	0.0	0.0	0.0	0100	
1162101	116010000	118000000	0.0512	0.0	0.0	0100	
1161201	4.1997000	4.1997000	0.0				
1162201	7.7841000	7.7841000	0.0				
*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----							
* PUMP SUCTION PIPING							
*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----							
1180000	"PMP SUC PP"	PIPE					
1180001	3						
1180101	0.0	3					
1180201	0.0	2					
1180301	0.546638	1					
1180302	0.688596	2					
1180303	0.558577	3					
1180401	0.0445625	1					
1180402	0.0445137	2					
1180403	0.0354278	3					
1180501	0.0	3					
1180601	-90.0	3					
1180701	-0.498052	1					
1180702	-0.688596	2					
1180703	-0.355604	3					
1180801	4.E-5	0.0	3				
1180901	0.083	0.083	1				
1180902	0.104	0.104	2				
1181001	00	3					
1181101	0000	2					
1181201	0	14659900.	1228430.	2467190.	0.0	0.0	01
1181202	0	14646900.	1228430.	2467470.	0.0	0.0	02
1181203	0	14644400.	1228430.	2467520.	0.0	0.0	03
1181300	0						
1181301	9.8172000	9.8172000	0.0	01			
1181302	10.006000	10.006000	0.0	02			
*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----							
* PUMP SUCTION TEE							
*-----1-----1-----1-----1-----1-----1-----1-----1-----							
1200000	"PMP SCT T "	BRANCH					
1200001	3	0					
1200101	0.0	0.759614	0.0487901	0.0	0.0	0.0	
1200102	4.0E-5	0.0	00				
1200200	0	14641700.	1228420.	2467580.	0.0		
1201101	118010000	120000000	0.0	0.1	0.1	0000	
1202101	120010000	125000000	0.0317	0.4	0.4	0100	
1203101	120010000	155000000	0.0317	0.4	0.4	0100	
1201201	10.006000	10.006000	0.0				



1500001	2	0				
1500101	0.0636463	0.3542995	0.0	0.0	0.0	0.0
1500102	4.0E-5	0.0	00			
1500200	0	15079600.	1228680.	2457980.	0.0	
1501101	170010000	150000000	0.0183	0.1	0.1	0100
1502101	150010000	172000000	0.0	0.0	0.0	0000
1501201	8.0488000	8.0488000	0.0			
1502201	9.9847000	9.9847000	0.0			
*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----						
* PUMP 2 SUCTION TEE OUTLET						
*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----						
1550000	"PMP2 SCT T"		BRANCH			
1550001	1	0				
1550101	0.0	1.00308	0.0640548	0.0	90.0	0.520704
1550102	4.0E-5	0.0	00			
1550200	0	14629600.	1228410.	2467830.	0.0	
1551101	155010000	160000000	0.0	0.13	0.13	0000
1551201	7.7885000	7.7885000	0.0			
*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----						
* PUMP 2 INLET PIPE						
*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----						
1600000	"PMP2 INLET"		SNGLVOL			
1600101	0.0	0.457201	0.0177444	0.0	90.0	0.457201
1600102	4.0E-5	0.0	00			
1600200	0	14608000.	1228410.	2468300.	0.0	
*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----						
* PRIMARY COOLANT PUMP 2						
*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----						
1650000	"PCPUMP2 "		PUMP			
1650101	0.0	0.514	0.0991	0.0	90.0	0.317900
1650102	0					
1650108	160010000	0.0	0.017	0.017	0000	
1650109	170000000	0.0	0.1	0.1	0000	
1650200	0	14928600.	1228710.	2461510.	0.0	
1650201	0	7.7887000	7.7887000	0.0		
1650202	0	8.0515000	8.0515000	0.0		
1650301	135	135	-1	-1	697	0
1650302	369.00000	.93018970	.31550000	96.000000	500.60000	1.4310000
1650303	613.6	0.0	207.433	0.0444	19.5987	0.0
1650308	78.53982	0.0	-22.86511	27.16403	5.74589	
1650310	0.0	0.0	0.0			
*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----						
* PUMP 2 OUTLET						
*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----						
1700000	"PMP2 OUT T"		BRANCH			
1700001	0	0				
1700101	0.0	0.514071	0.0192958	0.0	0.0	0.0
1700102	4.0E-5	0.0	00			
1700200	0	15203100.	1228710.	2454990.	0.0	
*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----						
* PRESSURIZER SPRAY TEE						
*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----						
1720000	"PZR SPR T "		BRANCH			
1720001	1	0				
1720101	0.0635359	0.2844229	0.0	0.0	0.0	0.0
1720102	4.0E-5	0.0	00			
1720200	0	15078900.	1228680.	2458000.	0.0	
1721101	172010000	175000000	0.0	0.0	0.0	0000















3150704	0.457202	5					
3150705	-0.457202	6					
3150706	-0.993978	8					
3150707	-1.371350	9					
3150708	-0.520701	10					
3150709	1.212851	11					
3150710	0.0	12					
3150801	4.0E-5	0.0	3				
3150802	4.0E-5	0.124	4				
3150803	4.0E-5	0.0	6				
3150804	4.0E-5	0.124	7				
3150805	4.0E-5	0.0	12				
3150901	0.2	0.2	1				
3150902	0.0	0.0	2				
3150903	93.9	93.9	4				
3150904	0.4	0.4	5				
3150905	93.9	93.9	7				
3150906	0.0	0.0	8				
3150907	0.2	0.2	9				
3150908	4.1	4.1	10				
3150909	0.4	0.4	11				
3151001	00	12					
3151101	0000	1					
3151102	0100	2					
3151103	0000	7					
3151104	0100	8					
3151105	0000	10					
3151106	0100	11					
3151201	0	14956800.	1204970.	2460900.	0.0	0.0	01
3151202	0	14954200.	1196960.	2460960.	0.0	0.0	02
3151203	0	14948400.	1216750.	2461090.	0.0	0.0	03
3151204	0	14941000.	1217220.	2461250.	0.0	0.0	04
3151205	0	14935500.	1219110.	2461370.	0.0	0.0	05
3151206	0	14935500.	1219140.	2461370.	0.0	0.0	06
3151207	0	14941000.	1217240.	2461250.	0.0	0.0	07
3151208	0	14948400.	1217200.	2461090.	0.0	0.0	08
3151209	0	14957300.	1206410.	2460890.	0.0	0.0	09
3151210	0	14964400.	1209760.	2460730.	0.0	0.0	10
3151211	0	14961800.	1196570.	2460790.	0.0	0.0	11
3151212	0	14957200.	1215100.	2460890.	0.0	0.0	12
3151300	0						
3151301	-.14625-4	-.14625-4	0.0		01		
3151302	-.35422-4	-.35422-4	0.0		02		
3151303	-.13114-4	-.13114-4	0.0		03		
3151304	-.72833-5	-.72833-5	0.0		04		
3151305	-.24333-5	-.24333-5	0.0		05		
3151306	-.88365-5	-.88365-5	0.0		06		
3151307	-.29947-5	-.29947-5	0.0		07		
3151308	-.19321-4	-.19321-4	0.0		08		
3151309	-.16785-4	-.16785-4	0.0		09		
3151310	-.16628-4	-.16628-4	0.0		10		
3151311	-.12497-4	-.12497-4	0.0		11		
*-----	1-----	1-----	1-----	1-----	1-----	1-----	1-----
* REACTOR VESSEL NOZZLE - BROKEN LOOP COLD LEG							
*-----	1-----	1-----	1-----	1-----	1-----	1-----	1-----
3350000	"RVN BLCL "		BRANCH				
3350001	2	0					
3350101	0.0	0.749305	0.047979	0.0	0.0	0.0	0.0



\* COLD LEG PIPE BETWEEN ISOLATION VALVE AND QOBV

\*-----1-----1-----1-----1-----1-----1-----1-----  
3600000 "CL IS-QOBV" SNGLVOL  
3600101 0.0 0.569219 0.0297722 0.0 0.0 0.0  
3600102 4.0E-5 0.0 00  
3600200 0 15031700. 1241690. 2459150. 0.0  
\*-----1-----1-----1-----1-----1-----1-----1-----

\* COLD LEG QUICK OPENING BLOWDOWN VALVE

\*-----1-----1-----1-----1-----1-----1-----1-----  
3650000 "CL QOBV " VALVE  
3650101 360010000 805000000 0.0466 0.0 0.0 0000  
3650201 0 .00000000 .00000000 0.0  
3650300 TRPVLV  
3650301 677  
\*-----1-----1-----1-----1-----1-----1-----1-----

\* REFLOOD ASSIST BYPASS PIPING - COLD LEG SIDE

\*-----1-----1-----1-----1-----1-----1-----1-----  
3700000 "RABS C L " PIPE  
3700001 3  
3700101 0.0388 2  
3700102 0.0776 3  
3700201 0.0388 2  
3700301 0.0 3  
3700401 0.0279 1  
3700402 0.070 2  
3700403 0.1165 3  
3700601 90.0 1  
3700602 0.0 3  
3700701 0.64 1  
3700702 0.0 3  
3700801 4.0-5 0.0 3  
3700901 0.28 0.28 1  
3700902 0.84 0.84 2  
3701001 00 3  
3701101 0000 2  
3701201 0 15029300. 1226830. 2459210. 0.0 0.0 01  
3701202 0 15026900. 1226050. 2459270. 0.0 0.0 02  
3701203 0 15026900. 1224760. 2459270. 0.0 0.0 03  
3701300 0  
3701301 .21514000 .21514000 0.0 01  
3701302 .21508000 .21508000 0.0 02  
\*-----1-----1-----1-----1-----1-----1-----1-----

\* REFLOOD ASSIST BYPASS VALVES

\*-----1-----1-----1-----1-----1-----1-----1-----  
3750000 "RABS VALVS" SNGLJUN  
3750101 370010000 380000000 0.0 1.55+4 1.55+4 0000  
3750201 0 .10749000 .10749000 0.0  
\*-----1-----1-----1-----1-----1-----1-----1-----

\* REFLOOD ASSIST BYPASS PIPING - HOT LEG SIDE

\*-----1-----1-----1-----1-----1-----1-----1-----  
3800000 "RABS H L " PIPE  
3800001 3  
3800101 0.0776 1  
3800102 0.0388 3  
3800201 0.0388 2  
3800301 0.0 3  
3800401 0.0915 1  
3800402 0.048 2



4100201	0	-.0608789	-.0608789	0.0				
*	-1	-1	-1	-1	-1	-1	-1	-1
<b>* PRESSURIZER VESSEL</b>								
*	-1	-1	-1	-1	-1	-1	-1	-1
4150000	"PZR VESSEL"		PIPE					
4150001	6							
4150101	0.0	2						
4150102	0.5653	5						
4150103	0.0	6						
4150201	0.0	5						
4150301	0.1815	1						
4150302	0.1524	2						
4150303	0.3967	3						
4150304	0.5289	4						
4150305	0.3967	5						
4150306	0.1943	6						
4150401	0.0684	1						
4150402	0.0838	2						
4150403	0.0	5						
4150404	0.0732	6						
4150501	0.0	6						
4150601	90.0	6						
4150801	4.0E-5	0.0	6					
4151001	00	6						
4151101	0000	5						
4151201	0	14889200.	1551340.	2462340.	0.0	0.0	01	
4151202	0	14888200.	1576890.	2462360.	0.0	0.0	02	
4151203	0	14888600.	1578210.	2462390.	0.0	0.0	03	
4151204	0	14884300.	1579040.	2463380.	.31381	0.0	04	
4151205	0	14882900.	1581860.	2462380.	1.0	0.0	05	
4151206	0	14882600.	1581850.	2462350.	1.0	0.0	06	
4151300	0							
4151301	4.13174-5	4.13174-5	0.0	01				
4151302	2.75755-5	2.75755-5	0.0	02				
4151303	2.50280-5	.50049	0.0	03				
4151304	-.37026	5.25011-5	0.0	04				
4151305	-.13472	1.81309-5	0.0	05				
*	-1	-1	-1	-1	-1	-1	-1	-1
<b>* PRESSURIZER VESSEL TO TOP HAT</b>								
*	-1	-1	-1	-1	-1	-1	-1	-1
4170000	"VSSL-TPHAT"		SNGLJUN					
4170101	415010000	420000000	0.0	0.0	0.0	0000		
4170201	0	-.19776	3.46367-5	0.0				
*	-1	-1	-1	-1	-1	-1	-1	-1
<b>* PRESSURIZER TOP HAT AND RELIEF CONNECTION</b>								
*	-1	-1	-1	-1	-1	-1	-1	-1
4200000	"PZR TOPHAT"		PIPE					
4200001	2							
4200101	0.0	2						
4200201	0.0	1						
4200301	0.1104915	2						
4200401	0.0139870	2						
4200601	90.0	2						
4200801	4.E-5	0.346066	2					
4201001	00	2						
4201101	0000	1						
4201201	0	14882500.	1581850.	2462380.	1.0	0.0	01	
4201202	0	14882400.	1581840.	2462380.	1.0	0.0	02	

4201300	0						
4201301	-.10996	2.21137-5	0.0	01			
*	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----
* SPRAY LINE							
*	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----
4300000	"SPRAY "		BRANCH				
4300001	1	0					
4300101	0.0003363	6.322	0.0	0.0	90.0	2.9905	
4300102	4.0-5	0.0	00				
4300200	0	15067800.	1227770.	2458270.	0.0		
4301101	172000000	430000000	0.0	0.0	0.0	0002	
4301201	-5.3194-6	-5.3194-6	0.0				
* \$*							
*							
* STEAM GENERATOR SECONDARY SIDE							
*							
*	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----
* PRIMARY SEPARATOR							
*	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----
5000000	"SEPARATOR "		SEPARATR				
5000001	3	0					
5000101	0.0	0.4445	0.2425	0.0	90.0	0.4445	
5000102	4.E-5	0.2840	00				
5000200	0	5222780.0	1161490.	2595710.	.89049		
5001101	500010000	520000000	0.087745	0.0	0.0	0100	
5002101	500000000	505000000	0.087745	0.0	0.0	0100	0.3
5003101	515010000	500000000	0.29187	0.4	0.4	0100	
5001201	1.3751	1.4411	0.0				
5002201	.53770	.50887	0.0				
5003201	2.7804	3.5935	0.0				
*	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----
* SEPARATOR BYPASS							
*	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----
5030000	"SEPBYPASS "		BRANCH				
5030001	2	0					
5030101	0.0	0.4445	0.4384	0.0	90.0	0.4445	
5030102	4.E-5	0.3678	00				
5030200	0	5222780.0	1611330.	2595720.	.99999		
5031101	505000000	503000000	0.98627	0.0	0.0	0100	
5032101	503010000	520000000	0.98627	0.8	0.0	0100	
5031201	-.16063	.48006	0.0				
5032201	2.38241-2	.17866	0.0				
*	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----
* SEPARATOR OUTLET REGION							
*	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----
5050000	"LWR SEPAR "		BRANCH				
5050001	1	0					
5050101	0.0	1.2131	1.4850	0.0	-90.0	-1.2131	
5050102	4.E-5	1.9048	00				
5050200	0	5222770.0	1161410.	2595720.	.37208		
5051101	505010000	508000000	0.0	0.0	0.0	0100	
5051201	.47026	-.47917	0.0				
*	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----
* FEED INLET VOLUME							
*	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----
5080000	"UPR DWNCMR"		BRANCH				
5080001	1	0					
5080101	0.0	0.6096	0.22107	0.0	-90.0	-0.6096	

5080102	4.E-5	0.163697	00					
5080200	0	5228350.0	1094450.	2595690.	0.0			
5081101	508010000	510000000	0.0	0.0	0.0	0100		
5081201	.58694	.58694	0.0					
*	-1	-1	-1	-1	-1	-1	-1	-1
* STEAM GENERATOR DOWNCOMER								
*	-1	-1	-1	-1	-1	-1	-1	-1
5100000	"DWNCMR "		ANNULUS					
5100001	3							
5100101	0.232	3						
5100201	0.0	2						
5100301	0.6096	3						
5100401	0.0	3						
5100601	-90.0	3						
5100701	-0.6096	3						
5100801	4.E-5	0.10793	3					
5100901	0.0	0.0	2					
5101001	00	3						
5101101	0000	2						
5101201	0	5233030.0	1094480.	2595670.	0.0	0.0	01	
5101202	0	5237770.0	1095280.	2595640.	0.0	0.0	02	
5101203	0	5242510.0	1095650.	2595610.	0.0	0.0	03	
5101300	0							
5101301	.58704	.58704	0.0	01				
5101302	.58714	.58714	0.0	02				
*	-1	-1	-1	-1	-1	-1	-1	-1
* JUNCTION FROM DOWNCOMER TO BOILER								
*	-1	-1	-1	-1	-1	-1	-1	-1
5130000	"DNCMR-BLR "		SNGLJUN					
5130101	510010000	515000000	0.0	17.5	17.5	0100		
5130201	0	.58722	.83849	0.0				
*	-1	-1	-1	-1	-1	-1	-1	-1
* STEAM GENERATOR BOILER								
*	-1	-1	-1	-1	-1	-1	-1	-1
5150000	"BOILER "		PIPE					
5150001	5							
5150101	0.2776	4						
5150102	0.306294	5						
5150201	0.0	4						
5150301	1.8288	4						
5150302	1.2131	5						
5150401	0.0	5						
5150601	60.0	4						
5150602	90.0	5						
5150701	0.6096	4						
5150702	1.2131	5						
5150801	4.E-5	0.0234	4					
5150802	4.E-5	0.5962	5					
5150901	4.05	4.05	4					
5151001	00	5						
5151101	0100	4						
5151201	0	5241030.0	1154980.	2595580.	.49316	0.0	01	
5151202	0	5237440.0	1161810.	2595610.	.71327	0.0	02	
5151203	0	5233350.0	1162120.	2595650.	.80605	0.0	03	
5151204	0	5232841.0	1161820.	2595680.	.85407	0.0	04	
5151205	0	5237361.0	1161540.	2595700.	.87426	0.0	05	
5151300	0							
5151301	.94859	1.3289	0.0	01				

5151302	1.5589	2.3557	0.0	02		
5151303	2.1266	3.3332	0.0	03		
5151304	2.6440	4.0529	0.0	04		
*-----1-----1-----1-----1-----1-----1-----1-----1-----						
* LOWER PORTION OF STEAM DOME						
*-----1-----1-----1-----1-----1-----1-----1-----						
5200000	"LWR STM DM"	BRANCH				
5200001	1	0				
5200101	0.0	0.46956	0.705312	0.0	90.0	0.46956
5200102	4.E-5	1.383	00			
5200200	0	5219990.0	1161320.	2595680.	1.0	
5201101	520010000	525000000	0.0	0.0	0.0	0100
5201201	.50120	.64094	0.0			
*-----1-----1-----1-----1-----1-----1-----1-----1-----						
* UPPER PORTION OF STEAM DOME						
*-----1-----1-----1-----1-----1-----1-----1-----1-----						
5250000	"UPR STM DM"	BRANCH				
5250001	1	0				
5250101	0.0	0.46956	0.705312	0.0	90.0	0.46956
5250102	4.E-5	1.383	00			
5250200	0	5219870.0	1161310.	2595700.	1.0	
5251101	525010000	530000000	0.0	0.8	0.8	0100
5251201	15.687	20.771	0.0			
*-----1-----1-----1-----1-----1-----1-----1-----1-----						
* STEAM PIPE FROM GENERATOR TO CONTROL VALVE						
*-----1-----1-----1-----1-----1-----1-----1-----						
5300000	"STEAM PIPE"	SNGLVOL				
5300101	0.04635	25.074	0.0	0.0	0.0	0.0
5300102	4.E-5	0.0	00			
5300200	0	5203370.0	1160330.	2595740.	.99998	
*-----1-----1-----1-----1-----1-----1-----1-----						
* STEAM FLOW CONTROL VALVE						
*-----1-----1-----1-----1-----1-----1-----1-----						
5400000	"CV-P4-10 "	VALVE				
5400101	530010000	541000000	0.0047772	0.0	0.0	1100
5400201	0	16.933	36.097	0.0		
5400300	MTRVLV					
5400301	685	686	0.05	0.645229	540	
20254000	NORMAREA					
20254001	0.0	9.25-4				
20254002	9.25-4	9.25-4				
20254003	1.0	1.0				
*-----1-----1-----1-----1-----1-----1-----1-----1-----						
* PIPE DOWNSTREAM OF STEAM CONTROL VALVE						
*-----1-----1-----1-----1-----1-----1-----1-----						
5410000	"COND INLET"	BRANCH				
5410001	1	0				
5410101	0.06557	54.44	0.0	0.0	0.0	0.0
5410102	4.E-5	0.0	00			
5410200	0	2009650.0	907346.	2597920.	.99820	
5411101	541010000	542000000	0.0	0.0	0.0	0100
5411201	16.933	36.097	0.0			
*-----1-----1-----1-----1-----1-----1-----1-----1-----						
* AIR COOLED CONDENSER						
*-----1-----1-----1-----1-----1-----1-----1-----						
5420000	"CONDENSER "	TMDPVOL				
5420101	0.21677	17.67	0.0	0.0	0.0	0.0
5420102	4.E-5	0.02	00			

5420200 2  
 5420207 0.0 2.00E6 1.0  
 \*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----  
**\* STEAM BYPASS VALVE**  
 \*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----  
 5450000 "STM BYPSS " VALVE  
 5450101 530010000 546000000 3.2-4 0.0 0.0 0100  
 5450201 0 .00000000 .00000000 0.0  
 5450300 TRPVLV  
 5450301 687  
 \*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----  
**\* AIR COOLED CONDENSER**  
 \*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----  
 5460000 "CONDENSER " TMDPVOL  
 5460101 0.21677 17.67 0.0 0.0 0.0 0.0  
 5460102 4.E-5 0.02 00  
 5460200 1 516  
 5460201 0.0 554.8 0.999  
 5460202 18000. 332.5 0.999  
 \*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----  
**\* FEED STORAGE TANK**  
 \*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----  
 5650000 "FEED TANK " TMDPVOL  
 5650101 29.81 3.048 0.0 0.0 0.0 0.0  
 5650102 4.E-5 0.0 00  
 5650200 1 689  
 5650201 -1.0 478.706 0.0  
 \*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----  
**\* FEED WATER**  
 \*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----  
 5660000 "FEED " TMDPJUN  
 5660101 565000000 508000000 0.05  
 5660200 1 688  
 5660201 0.0 25.553 0.0 0.0  
 5660202 0.7 0.0 0.0 0.0  
 5660203 59.5 0.0 0.0 0.0  
 5660204 60.0 0.50364 0.0 0.0  
 5660205 1860.0 0.50364 0.0 0.0  
 5660206 1861.0 0.0 0.0 0.0  
 \*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----  
**\* AUX FEED STORAGE TANK**  
 \*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----  
 5680000 "AUX FD TNK" TMDPVOL  
 5680101 29.81 3.048 0.0 0.0 0.0 0.0  
 5680102 4.E-5 0.0 00  
 5680200 1  
 5680201 0.0 305.0 0.0  
 \*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----  
**\* AUX FEED WATER**  
 \*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----  
 5690000 "AUX FEED " TMDPJUN  
 5690101 568000000 508000000 0.05  
 5690200 1 690  
 5690201 -1.0 0.00 0.0 0.0  
 5690202 0.0 0.50364 0.0 0.0  
 \*\$\*\$\$\*  
 \*  
**\* ECC SYSTEM**

\*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----  
 \* ECC CHECK VALVE  
 \*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----  
 6000000 "ECC CHKVLV" VALVE  
 6000101 605010000 185000000 5.9896-3 0.935 0.935 1120  
 6000201 0 .0000000 .0000000 0.0  
 6000300 TRPVLV  
 6000301 681  
 \*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----  
 \* ECCS HEADER TO PCS  
 \*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----  
 6050000 "ECCS HEADR" SNGLVOL  
 6050101 5.9896-3 5.0148 0.0 0.0 90.0 3.3071202  
 6050102 4.0-5 0.0 01  
 6050200 0 13595900. 172410. 2489140. 0.0  
 \*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----  
 \* ACCUMULATOR VALVE  
 \*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----  
 6100000 "ACCUM VLV" VALVE  
 6100101 615010000 605000000 5.9896-3 6.278 6.278 1000  
 6100201 0 0.0 0.0 0.0  
 6100300 TRPVLV  
 6100301 682  
 \*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----  
 \* ACCUMULATOR PIPE  
 \*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----  
 6150000 "ACC PIPE" SNGLVOL  
 6150101 0.0 25.997165 0.4074774 0.0 0.0 0.0  
 6150102 4.0-5 0.0 01  
 6150200 0 13580200. 112409. 2489450. 0.0  
 \*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----  
 \* ACCUMULATOR VESSEL  
 \*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----  
 \*6200000 "ACCUMULATR" ACCUM  
 \*6200101 0.0 1.8103 2.3422 0.0 90.0 1.8103  
 \*6200102 4.0-5 0.0 01  
 \*6200200 4.31+6 306.6  
 \*6201101 615000000 8.2132-3 13.3 13.3 0  
 \*6202200 0.0 1.0662 2.4509 1.6927 0.04445 0 0 0 0  
 \*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----  
 \* BWST LPIS  
 \*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----  
 6250000 "BWST LPIS" TMDPVOL  
 6250101 20.44 5.0 0.0 0.0 90.0 5.0  
 6250102 4.0E-5 0.0 00  
 6250200 3  
 6250201 0.0 1.0+5 300.0  
 \*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----  
 \* LOW PRESSURE INJECTION SYSTEM  
 \*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----  
 6300000 "LPIS" TMDPJUN  
 6300101 625000000 605000000 5.9896-3  
 6300200 1 684 P 605010000  
 6300201 -1.0 0.0 0.0 0.0  
 6300202 0.0 0.0 0.0 0.0  
 6300203 8.483+4 7.045 0.0 0.0  
 6300204 4.297+5 6.091 0.0 0.0

6300205	7.745+5	5.045	0.0	0.0		
6300206	9.448+5	4.313	0.0	0.0		
6300207	1.119+6	3.454	0.0	0.0		
6300208	1.186+6	3.173	0.0	0.0		
6300209	1.257+6	2.673	0.0	0.0		
6300210	1.326+6	2.159	0.0	0.0		
6300211	1.395+6	1.536	0.0	0.0		
6300212	1.464+6	0.7182	0.0	0.0		
6300213	1.517+6	0.0	0.0	0.0		
-----1-----1-----1-----1-----1-----1-----1-----1-----1-----						
* BWST HPIS						
-----1-----1-----1-----1-----1-----1-----1-----1-----1-----						
6350000	"BWST HPIS "		TMDPVOL			
6350101	20.44	5.0	0.0	0.0	90.0	5.0
6350102	4.0E-5	0.0	00			
6350200	3					
6350201	0.0	1.0+5	300.0			
-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----						
* HIGH PRESSURE INJECTION SYSTEM						
-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----						
6400000	"HPIS "		TMDPJUN			
6400101	635000000	185000000	5.9896-3			
6400200	1	683	P	185010000		
6400201	-1.0	0.0	0.0	0.0		
6400202	0.0	.75687272	0.0	0.0		
6400203	7.72514+6	.75687272	0.0	0.0		
6400204	8.3597+6	.31536281	0.0	0.0		
6400205	17.2436+6	.31536281	0.0	0.0		
*\$\$\$\$\$*\$\$\$\$\$*\$\$\$\$\$*\$\$\$\$\$*\$\$\$\$\$*\$\$\$\$\$*\$\$\$\$\$*\$\$\$\$\$*\$\$\$\$\$*\$\$\$\$\$*\$\$\$\$\$**						
*						
* CONTAINMENT						
*						
-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----						
* CONTAINMENT BROKEN LOOP COLD LEG						
-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----						
8050000	"CONT BLCL "		TMDPVOL			
8050101	0.0	1.0	0.1	0.0	0.0	0.0
8050102	0.0	0.0	00			
8050200	2					
8050201	0.0	1.0+5	1.0			
*\$\$\$\$\$*\$\$\$\$\$*\$\$\$\$\$*\$\$\$\$\$*\$\$\$\$\$*\$\$\$\$\$*\$\$\$\$\$*\$\$\$\$\$*\$\$\$\$\$*\$\$\$\$\$**						
*						
* REACTOR VESSEL HEAT STRUCTURES						
*						
-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----						
* REACTOR VESSEL WALL HEAT STRUCTURES						
-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----						
* THE REACTOR VESSEL WALL IS NOT MODELLED ABOVE THE NOZZLES.						
* THE VESSEL TO FILLER GAP IS ASSUMED TO INSULATE THE VESSEL						
* FROM THE FILLERS. THE VESSEL TO FILLER GAP IS NOT MODELLED						
* AT THIS ELEVATION.						
-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----						
* REACTOR VESSEL WALL ABOVE STATION 178 - 5.50 INCHES THICK						
* STATION 178 TO 258						
-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----						
12231000	2	5	2	1	0.7328	
12231100	0	1				
12231101	4	0.8725				

12231201	5	4				
12231301	0.0	4				
12231401	551.0	5				
12231501	223010000	0	1	1	1.4218585	1
12231502	223020000	0	1	1	0.7621415	2
12231601	-939	0	3949	1	1.4218585	1
12231602	-939	0	3949	1	0.7621415	2
12231701	0	0.0	0.0	0.0	2	
12231801	0	0.0127	0.1922	1.4218585	1	
12231802	0	0.0127	0.1922	0.7621415	2	
*	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----
* REACTOR VESSEL WALL BELOW STATION 178 - 3.62 INCHES THICK						
* STATION 67.7 TO 178						
*	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----
12232000	4	5	2	1	0.7328	
12232100	0	1				
12232101	4	0.8247				
12232201	5	4				
12232301	0.0	4				
12232401	553.0	5				
12232501	223020000	0	1	1	0.4340098	1
12232502	223030000	0	1	1	1.2110867	2
12232503	223040000	0	1	1	0.7802975	3
12232504	220010000	0	1	1	0.3741720	4
12232601	-939	0	3949	1	0.4340098	1
12232602	-939	0	3949	1	1.2110867	2
12232603	-939	0	3949	1	0.7802975	3
12232604	-939	0	3949	1	0.3741720	4
12232701	0	0.0	0.0	0.0	4	
12232801	0	0.0127	0.1922	0.4340098	1	
12232802	0	0.0127	0.1922	1.2110867	2	
12232803	0	0.0127	0.1922	0.7802975	3	
12232804	0	0.0127	0.1922	0.3741720	4	
*	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----
* REACTOR VESSEL BOTTOM						
* STATION 67.7						
*	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----
12200000	1	5	1	1	0.0	
12200100	0	1				
12200101	4	0.092				
12200201	5	4				
12200301	0.0	4				
12200401	551.0	5				
12200501	220010000	0	1	0	1.68	1
12200601	-939	0	3949	0	1.68	1
12200701	0	0.0	0.0	0.0	1	
12200801	0	0.0	0.0	5.00	1	
*	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----
* REACTOR VESSEL FILLER BLOCKS HEAT STRUCTURES						
*	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----
* INLET ANNULUS TOP VOLUME						
* STATION 264 TO 277						
*	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----
12000000	2	5	2	1	0.508	
12000100	0	1				
12000101	4	0.7264				
12000201	4	4				
12000301	0.0	4				

12000401	556.0	5				
12000501	200010000	0	1	1	0.1876129	1
12000502	202010000	0	1	1	0.2851823	2
12000601	0	0	0	1	0.1876129	1
12000602	0	0	0	1	0.2851823	2
12000701	0	0.0	0.0	0.0	2	
12000801	0	0.1524	0.3245	0.1876129	1	
12000802	0	0.1524	0.3245	0.2851823	2	
*-----1-----	-1-----	-1-----	-1-----	-1-----	-1-----	-1-----
* INLET ANNULUS LOWER VOLUME						
* STATION 247.3 TO 264.0						
*-----1-----	-1-----	-1-----	-1-----	-1-----	-1-----	-1-----
12050000	1	5	2	1	0.501	
12050100	0	1				
12050101	4	0.7264				
12050201	4	4				
12050301	0.0	4				
12050401	556.0	5				
12050501	205010000	0	1	1	0.2525361	1
12050601	223010000	0	1	1	0.2525361	1
12050701	0	0.0	0.0	0.0	1	
12050801	0	0.1524	0.3245	0.2525361	1	
12050901	0	0.0127	0.0253	0.2525361	1	
*-----1-----	-1-----	-1-----	-1-----	-1-----	-1-----	-1-----
* DOWNCOMER AND LOWER PLENUM						
* STATION 67.7 TO 247.3						
*-----1-----	-1-----	-1-----	-1-----	-1-----	-1-----	-1-----
12100000	7	5	2	1	0.47	
12100100	0	1				
12100101	4	0.7264				
12100201	4	4				
12100301	0.0	4				
12100401	556.0	5				
12100501	210010000	0	1	1	1.0267313	1
12100502	210020000	0	1	1	0.4933248	2
12100503	210030000	0	1	1	0.7028265	3
12100504	210040000	0	1	1	0.5588068	4
12100505	210050000	0	1	1	0.6522799	5
12100506	210060000	0	1	1	0.4269792	6
12100507	215010000	0	1	1	0.3533183	7
12100601	223010000	0	1	1	1.0267313	1
12100602	223020000	0	1	1	0.4933248	2
12100603	223020000	0	1	1	0.7028265	3
12100604	223030000	0	1	1	0.5588068	4
12100605	223030000	0	1	1	0.6522799	5
12100606	223040000	0	1	1	0.4269792	6
12100607	223040000	0	1	1	0.3533183	7
12100701	0	0.0	0.0	0.0	7	
12100801	0	0.1016	0.2155	1.0267313	1	
12100802	0	0.1016	0.2155	0.4933248	2	
12100803	0	0.1016	0.2155	0.7028265	3	
12100804	0	0.1016	0.2155	0.5588068	4	
12100805	0	0.1016	0.2155	0.6522799	5	
12100806	0	0.1016	0.2155	0.4269792	6	
12100807	0	0.1016	0.2155	0.3533183	7	
12100901	0	0.0127	0.0253	1.0267313	1	
12100902	0	0.0127	0.0253	0.4933248	2	
12100903	0	0.0127	0.0253	0.7028265	3	

12100904	0	0.0127	0.0253	0.5588068	4
12100905	0	0.0127	0.0253	0.6522799	5
12100906	0	0.0127	0.0253	0.4269792	6
12100907	0	0.0127	0.0253	0.3533183	7
*	-1-	-1-	-1-	-1-	-1-
* CORE SUPPORT BARREL					
* STATION 96.44 TO 277					
*	-1-	-1-	-1-	-1-	-1-
12001000	9	5	2	1	0.381
12001100	0	1			
12001101	4	0.419			
12001201	4	4			
12001301	0.0	4			
12001401	556.0	5			
12001501	0	0	0	1	0.1876129 1
12001502	0	0	0	1	0.2851823 2
12001503	0	0	0	1	0.2525361 3
12001504	0	0	0	1	1.0267313 4
12001505	0	0	0	1	0.4933248 5
12001506	0	0	0	1	0.7028265 6
12001507	0	0	0	1	0.5588068 7
12001508	0	0	0	1	0.6522799 8
12001509	0	0	0	1	0.4269792 9
12001601	200010000	0	1	1	0.1876129 1
12001602	202010000	0	1	1	0.2851823 2
12001603	205010000	0	1	1	0.2525361 3
12001604	210010000	0	1	1	1.0267313 4
12001605	210020000	0	1	1	0.4933248 5
12001606	210030000	0	1	1	0.7028265 6
12001607	210040000	0	1	1	0.5588068 7
12001608	210050000	0	1	1	0.6522799 8
12001609	210060000	0	1	1	0.4269792 9
12001701	0	0.0	0.0	0.0	9
12001901	0	0.1016	0.2155	0.1876129	1
12001902	0	0.1016	0.2155	0.2851823	2
12001903	0	0.1016	0.2155	0.2525361	3
12001904	0	0.1016	0.2155	1.0267313	4
12001905	0	0.1016	0.2155	0.4933248	5
12001906	0	0.1016	0.2155	0.7028265	6
12001907	0	0.1016	0.2155	0.5588068	7
12001908	0	0.1016	0.2155	0.6522799	8
12001909	0	0.1016	0.2155	0.4369792	9
*	-1-	-1-	-1-	-1-	-1-
* FLOW SKIRT - CORE FILLER ASSEMBLY					
* STATION 96.44 TO 261.13					
*	-1-	-1-	-1-	-1-	-1-
12250000	10	5	2	1	0.3
12250100	0	1			
12250101	4	0.38			
12250201	4	4			
12250301	0.0	4			
12250401	575.0	5			
12250501	225010000	0	1	1	0.4269792 1
12250502	230010000	0	1	1	0.3728765 2
12250503	230020000	10000	1	1	0.2794034 6
12250504	230060000	0	1	1	0.4234231 7
12250505	240010000	5000000	1	1	0.4933248 9
12250506	250010000	0	1	1	0.7850547 10

12250601	0	0	0	1	0.4269792	1
12250602	0	0	0	1	0.3728765	2
12250603	0	0	0	1	0.2794034	6
12250604	0	0	0	1	0.4234231	7
12250605	0	0	0	1	0.4933248	9
12250606	0	0	0	1	0.7850547	10
12250701	0	0.0	0.0	0.0	10	
12250801	0	0.095	0.095	0.4269792	1	
12250802	0	0.0124	0.5713	0.3728765	2	
12250803	0	0.0124	0.5713	0.2794034	6	
12250804	0	0.0124	0.5713	0.4234231	7	
12250805	0	0.145	0.5713	0.4933248	9	
12250806	0	0.131	0.5713	0.7850547	10	

\*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----

\* LOWER CORE SUPPORT STRUCTURE

\* STATION 96.44 TO 116.91

\* INCLUDES CORE SUPPORT BARREL LIP , LOWER CORE SUPPORT

\* STRUCTURE , AND FUEL MODULE LOWER END BOXES

\*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----

12251000	1	5	2	1	0.282	
----------	---	---	---	---	-------	--

12251100	0	1				
----------	---	---	--	--	--	--

12251101	4	0.3				
----------	---	-----	--	--	--	--

12251201	4	4				
----------	---	---	--	--	--	--

12251301	0.0	4				
----------	-----	---	--	--	--	--

12251401	556.0	5				
----------	-------	---	--	--	--	--

12251501	225010000	0	1	1	0.4269792	1
----------	-----------	---	---	---	-----------	---

12251601	0	0	0	1	0.4269792	1
----------	---	---	---	---	-----------	---

12251701	0	0.0	0.0	0.0	1	
----------	---	-----	-----	-----	---	--

12251801	0	0.095	0.095	0.4269792	1	
----------	---	-------	-------	-----------	---	--

\*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----

\* ACTIVE CORE

\* STATION 116.91 TO 182.94

\*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----

12300000	6	10	2	1	0.0	
----------	---	----	---	---	-----	--

12300100	0	1				
----------	---	---	--	--	--	--

12300101	5	4.647E-3				
----------	---	----------	--	--	--	--

12300102	1	4.742E-3				
----------	---	----------	--	--	--	--

12300103	3	5.359E-3				
----------	---	----------	--	--	--	--

12300201	1	5				
----------	---	---	--	--	--	--

12300202	-2	6				
----------	----	---	--	--	--	--

12300203	-3	9				
----------	----	---	--	--	--	--

12300301	1.0	5				
----------	-----	---	--	--	--	--

12300302	0.0	9				
----------	-----	---	--	--	--	--

12300401	575.0	10				
----------	-------	----	--	--	--	--

12300501	0	0	0	1	57.000	6 * 1.68X204/6
----------	---	---	---	---	--------	----------------

12300601	230010000	10000	1	1	57.000	6 * 89/11/09
----------	-----------	-------	---	---	--------	--------------

12300701	900	0.03695	0.0	0.0	1	* 100% POWER * 89/11/06
----------	-----	---------	-----	-----	---	-------------------------

12300702	900	0.03979	0.0	0.0	2	* 100% POWER
----------	-----	---------	-----	-----	---	--------------

12300703	900	0.04153	0.0	0.0	3	* 100% POWER
----------	-----	---------	-----	-----	---	--------------

12300704	900	0.03521	0.0	0.0	4	* 100% POWER
----------	-----	---------	-----	-----	---	--------------

12300705	900	0.02802	0.0	0.0	5	* 100% POWER
----------	-----	---------	-----	-----	---	--------------

12300706	900	0.02161	0.0	0.0	6	* 100% POWER
----------	-----	---------	-----	-----	---	--------------

12300901	0	0.01240	0.01504	1.775	6	
----------	---	---------	---------	-------	---	--

\*

\* HEAT STRUCTURE MODEL FOR 1096 RODS IN PERIPERAL

\*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----

\* ACTIVE CORE (PERIPERAL 1096 RODS)

\* STATION 116.91 TO 182.94

12310000	6	10	2	1	0.0	
12310100	0	1				
12310101	5	4.647E-3				
12310102	1	4.742E-3				
12310103	3	5.359E-3				
12310201	1	5				
12310202	-2	6				
12310203	-3	9				
12310301	1.0	5				
12310302	0.0	9				
12310401	575.0	10				
12310501	0	0	0	1	307.00	6 * 1.68X1096/6
12310601	230010000	10000	1	1	307.00	6 * 89/11/09
12310701	900	0.13896	0.0	0.0	1 * 100%	POWER
12310702	900	0.15345	0.0	0.0	2 * 100%	POWER
12310703	900	0.16486	0.0	0.0	3 * 100%	POWER
12310704	900	0.13947	0.0	0.0	4 * 100%	POWER
12310705	900	0.11431	0.0	0.0	5 * 100%	POWER
12310706	900	0.08461	0.0	0.0	6 * 100%	POWER
12310901	0	0.01240	0.01504	1.775	6	
12400000	2	5	2	1	0.282	
12400100	0	1				
12400101	4	0.31				
12400201	4	4				
12400301	0.0	4				
12400401	575.0	5				
12400501	240010000	5000000	1	1	0.4933248	2
12400601	0	0	0	1	0.4933248	2
12400701	0	0.0	0.0	0.0	2	
12400801	0	0.56	0.0	0.9866496	2	
12510000	1	5	1	1	0.0	
12510100	0	1				
12510101	4	0.01				
12510201	4	4				
12510301	0.0	4				
12510401	575.0	5				
12510501	250010000	0	1	1	1.8	1
12510601	251010000	0	1	1	1.8	1
12510701	0	0.0	0.0	1.8	1	
12510801	0	0.0	0.0	1.8	1	
12510901	0	0.0	0.0	1.8	1	
12551000	3	5	1	1	0.0	
12551100	0	1				
12551101	4	0.005				
12551201	4	4				
12551301	0.0	4				

12551401	575.0	5				
12551501	252010000	0	1	1	1.0	1
12551502	255010000	0	1	1	1.0	2
12551503	250010000	0	1	1	1.0	3
12551601	0	0	0	1	1.0	3
12551701	0	0.0	0.0	0.0	3	
12551801	0	0.0	0.0	1.0	3	
*-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	
* CORE SUPPORT BARREL - UPPER PLENUM LOWER VOLUME						
* STATION 264 TO 297.6						
*-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	
12552000	2	5	2	1	0.381	
12552100	0	1				
12552101	4	0.474				
12552201	5	4				
12552301	0.0	4				
12552401	575.0	5				
12552501	255010000	0	1	1	0.6312304	1
12552502	252010000	0	1	1	0.2869580	2
12552601	0	0	0	1	0.6312304	1
12552602	0	0	0	1	0.2869580	2
12552701	0	0.0	0.0	0.0	2	
12552801	0	0.762	0.0	0.6312304	1	
12552802	0	0.762	0.0	0.2869580	2	
*-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	
* CORE SUPPORT BARREL - UPPER PLENUM TOP VOLUME						
* STATION 297.6 TO 325						
*-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	
12601000	1	5	2	1	0.381	
12601100	0	1				
12601101	4	0.728				
12601201	5	4				
12601301	0.0	4				
12601401	575.0	5				
12601501	260010000	0	1	1	0.7747094	1
12601601	0	0	0	1	0.7747094	1
12601701	0	0.0	0.0	0.0	1	
12601801	0	0.762	0.0	0.7747094	1	
*-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	
* UPPER HEAD TOP PLATE						
* STATION 325						
*-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	
12602000	1	5	1	1	0.0	
12602100	0	1				
12602101	4	0.474				
12602201	5	4				
12602301	0.0	4				
12602401	560.0	5				
12602501	260010000	0	1	1	0.712	1
12602601	-939	0	3949	1	0.712	1
12602701	0	0.0	0.0	0.0	1	
12602801	0	0.0	0.0	0.712	1	
*\$*						
*						
* STEAM GENERATOR HEAT STRUCTURES						
*						
*-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	
* TUBING						

*-----	1-----	1-----	1-----	1-----	1-----	1-----
10060000	8	8	2	1	0.0051054	
10060100	0	1				
10060101	7	0.006348984				
10060201	6	7				
10060301	0.0	7				
10060401	551.0	8				
10060501	115010000	10000	1	1	1124.71	3
10060502	115040000	10000	1	1	849.063	5
10060503	115060000	10000	1	1	1124.71	8
10060601	515010000	10000	1	1	1124.71	3
10060602	515040000	0	1	1	849.063	4
10060603	515040000	0	1	1	849.063	5
10060604	515030000	-10000	1	1	1124.71	8
10060701	0	0	0	0	8	
10060801	0	0	0	0	8	
10060901	0	0	0	0	8	
*-----	1-----	1-----	1-----	1-----	1-----	1-----
* SHROUD - UPPER SECTION						
*-----	1-----	1-----	1-----	1-----	1-----	1-----
15000000	2	4	2	1	0.3048	
15000100	0	1				
15000101	3	0.3143				
15000201	5	3				
15000301	0.0	3				
15000401	539.0	4				
15000501	500010000	0	1	0	0.85127	1
15000502	515050000	0	1	0	2.51199	2
15000601	503010000	0	1	0	0.87780	1
15000602	505010000	0	1	0	2.59028	2
15000701	0	0.0	0.0	0.0	2	
15000801	0	0.0	0.0	0.0	2	
15000901	0	0.0	0.0	0.0	2	
*-----	1-----	1-----	1-----	1-----	1-----	1-----
* SHROUD - LOWER SECTION						
*-----	1-----	1-----	1-----	1-----	1-----	1-----
15100000	4	4	2	1	0.6445	
15100100	0	1				
15100101	3	0.6572				
15100201	5	3				
15100301	0.0	3				
15100401	533.0	4				
15100501	515040000	0	1	1	0.646354	1
15100502	515030000	-10000	1	0	2.46858	4
15100601	508010000	0	1	1	0.646354	1
15100602	510010000	10000	1	0	2.51723	4
15100701	0	0.0	0.0	0.0	4	
15100801	0	0.0	0.0	0.0	4	
15100901	0	0.0	0.0	0.0	4	
*-----	1-----	1-----	1-----	1-----	1-----	1-----
* VESSEL WALL						
*-----	1-----	1-----	1-----	1-----	1-----	1-----
15250000	8	5	2	1	0.7112	
15250100	0	1				
15250101	4	0.76397				
15250201	5	4				
15250301	0.0	4				
15250401	540.0	5				

15250501	525010000	0	1	1	0.46956	1
15250502	520010000	0	1	1	0.46956	2
15250503	503010000	0	1	1	0.4445	3
15250504	505010000	0	1	1	1.2131	4
15250505	508010000	0	1	1	0.6096	5
15250506	510010000	10000	1	1	0.6096	8
15250601	-939	0	3959	1	0.46956	1
15250602	-939	0	3959	1	0.46956	2
15250603	-939	0	3959	1	0.4445	3
15250604	-939	0	3959	1	1.2131	4
15250605	-939	0	3959	1	0.6096	5
15250606	-939	0	3959	1	0.6096	8
15250701	0	0.0	0.0	0.0	8	
15250801	0	0.0	0.0	0.0	8	
*-----*						
*	* PIPING HEAT STRUCTURES					
*						
*	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----
*	* INTACT LOOP PIPING					
*	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----
*	* .284 METER DIAMETER PIPING					
*	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----
11001000	14	5	2	1	0.142	
11001100	0	1				
11001101	4	0.1780				
11001201	4	4				
11001301	0.0	4				
11001401	560.0	5				
11001501	100010000	0	1	1	1.58878	1
11001502	105010000	0	1	1	1.0531192	2
11001503	107010000	0	1	1	0.2810215	3
11001504	110010000	0	1	1	0.9207292	4
11001505	112010000	0	1	1	1.38893	5
11001506	118020000	0	1	1	0.688596	6
11001507	118030000	0	1	1	0.558577	7
11001508	120010000	0	1	1	0.759614	8
11001509	150010000	0	1	1	0.3542995	9
11001510	172010000	0	1	1	0.2844229	10
11001511	175010000	0	1	1	0.4163655	11
11001512	175020000	0	1	1	0.613244	12
11001513	180010000	0	1	1	1.15189	13
11001514	185010000	0	1	1	1.00965	14
11001601	-939	0	3949	1	1.58878	1
11001602	-939	0	3949	1	1.0531192	2
11001603	-939	0	3949	1	0.2810215	3
11001604	-939	0	3949	1	0.9207292	4
11001605	-939	0	3949	1	1.38893	5
11001606	-939	0	3949	1	0.688596	6
11001607	-939	0	3949	1	0.558577	7
11001608	-939	0	3949	1	0.759614	8
11001609	-939	0	3949	1	0.3542995	9
11001610	-939	0	3949	1	0.2844229	10
11001611	-939	0	3949	1	0.4163655	11
11001612	-939	0	3949	1	0.613244	12
11001613	-939	0	3949	1	1.15189	13
11001614	-939	0	3949	1	1.00965	14
11001701	0	0	0	0	14	

11001801	0	0	0	1.58878	1
11001802	0	0	0	1.0531192	2
11001803	0	0	0	0.2810215	3
11001804	0	0	0	0.9207292	4
11001805	0	0	0	1.38893	5
11001806	0	0	0	0.688596	6
11001807	0	0	0	0.558577	7
11001808	0	0	0	0.759614	8
11001809	0	0	0	0.3542995	9
11001810	0	0	0	0.2844229	10
11001811	0	0	0	0.4163655	11
11001812	0	0	0	0.613244	12
11001813	0	0	0	1.15189	13
11001814	0	0	0	1.00965	14

\*-----1-----1-----1-----1-----1-----1-----1-----

#### \* STEAM GENERATOR CONNECTIONS

*	-----1-----1-----1-----1-----1-----1-----1-----					
11002000	2	5	2	1	0.1625	
11002100	0	1				
11002101	4	0.203				
11002201	4	4				
11002301	0.0	4				
11002401	560.0	5				
11002501	112020000	0	1	1	0.707687	1
11002502	118010000	0	1	1	0.546638	2
11002601	-939	0	3949	1	0.707687	1
11002602	-939	0	3949	1	0.546638	2
11002701	0	0	0	0	2	
11002801	0	0	0	0.707687	1	
11002802	0	0	0	0.546638	2	

\*-----1-----1-----1-----1-----1-----1-----1-----

#### \* .216 METER DIAMETER PIPING

*	-----1-----1-----1-----1-----1-----1-----1-----					
11003000	7	5	2	1	0.108	
11003100	0	1				
11003101	4	0.1365				
11003201	4	4				
11003301	0.0	4				
11003401	560.0	5				
11003501	125010000	0	1	1	1.00308	1
11003502	130010000	0	1	1	0.457201	2
11003503	140010000	0	1	1	0.502185	3
11003504	145010000	0	1	1	1.40843	4
11003505	155010000	0	1	1	1.00308	5
11003506	160010000	0	1	1	0.457201	6
11003507	170010000	0	1	1	0.514071	7
11003601	-939	0	3949	1	1.00308	1
11003602	-939	0	3949	1	0.457201	2
11003603	-939	0	3949	1	0.502185	3
11003604	-939	0	3949	1	1.40843	4
11003605	-939	0	3949	1	1.00308	5
11003606	-939	0	3949	1	0.457201	6
11003607	-939	0	3949	1	0.514071	7
11003701	0	0	0	0	7	
11003801	0	0	0	1.00308	1	
11003802	0	0	0	0.457201	2	
11003803	0	0	0	0.502185	3	
11003804	0	0	0	1.40843	4	

11003805	0	0	0	1.00308	5
11003806	0	0	0	0.457201	6
11003807	0	0	0	0.514071	7
*-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----
<b>* STEAM GENERATOR PLENA</b>					
*-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----
11004000	2	5	3	1	0.6858
11004100	0	1			
11004101	4	0.7747			
11004201	5	4			
11004301	0.0	4			
11004401	560.0	5			
11004501	114010000	0	1	1	0.25
11004502	116010000	0	1	1	0.25
11004601	-939	0	3949	1	0.25
11004602	-939	0	3949	1	0.25
11004701	0	0	0	0	2
11004801	0	0	0	0.630	1
11004802	0	0	0	0.630	2
11004901	0	0	0	0.630	2
*-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----
<b>* BROKEN LOOP HOT LEG PIPING</b>					
*-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----
<b>* NOZZLE PIPING</b>					
*-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----
13000000	3	5	2	1	0.1420
13000100	0	1			
13000101	4	0.1780			
13000201	4	4			
13000301	0.0	4			
13000401	560.0	5			
13000501	300010000	0	1	1	0.876303
13000502	305010000	0	1	1	0.698336
13000503	310010000	0	1	1	0.974349
13000601	-939	0	3949	1	0.876303
13000602	-939	0	3949	1	0.698336
13000603	-939	0	3949	1	0.974349
13000701	0	0	0	0	3
13000801	0	0	0	0.876303	1
13000802	0	0	0	0.698336	2
13000803	0	0	0	0.974349	3
*-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----
<b>* INLET TO STM GEN SIMULATOR</b>					
*-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----
13151000	3	5	2	1	0.0515
13151100	0	1			
13151101	4	0.0705			
13151201	4	4			
13151301	0.0	4			
13151401	545.0	5			
13151501	310010000	0	1	1	0.525781
13151502	315010000	0	1	1	0.367768
13151503	315020000	0	1	1	0.552201
13151601	-939	0	3949	1	0.525781
13151602	-939	0	3949	1	0.367768
13151603	-939	0	3949	1	0.552201
13151701	0	0	0	0	3
13151801	0	0	0	0.525781	1

13151802	0	0	0	0.36768	2
13151803	0	0	0	0.552201	3
*	-1	-1	-1	-1	-1
* STEAM GENERATOR SIMULATOR					
*	-1	-1	-1	-1	-1
13152000	6	5	2	1	0.1835
13152100	0	1			
13152101	4	0.2285			
13152201	4	4			
13152301	0.0	4			
13152401	545.0	5			
13152501	315030000	10000	1	1	0.993978 2
13152502	315050000	10000	1	1	0.849744 4
13152503	315070000	10000	1	1	0.993978 6
13152601	-939	0	3949	1	0.993978 2
13152602	-939	0	3949	1	0.849744 4
13152603	-939	0	3949	1	0.993978 6
13152701	0	0	0	0	6
13152801	0	0	0	0.993978	2
13152802	0	0	0	0.849744	4
13152803	0	0	0	0.993978	6
*	-1	-1	-1	-1	-1
* STM GEN SIMULATOR OUTLET					
*	-1	-1	-1	-1	-1
13153000	1	5	2	1	0.0550
13153100	0	1			
13153101	4	0.0705			
13153201	4	4			
13153301	0.0	4			
13153401	545.0	5			
13153501	315090000	0	1	1	1.371350 1
13153601	-939	0	3949	1	1.371350 1
13153701	0	0	0	0	1
13153801	0	0	0	1.371350	1
*	-1	-1	-1	-1	-1
* PUMP SIMULATOR					
*	-1	-1	-1	-1	-1
13154000	1	5	2	1	0.1420
13154100	0	1			
13154101	4	0.1780			
13154201	4	4			
13154301	0.0	4			
13154401	545.0	5			
13154501	315100000	0	1	1	1.365029 1
13154601	-939	0	3949	1	1.365029 1
13154701	0	0	0	0	1
13154801	0	0	0	1.365029	1
*	-1	-1	-1	-1	-1
* PUMP SIMULATOR OUTLET					
*	-1	-1	-1	-1	-1
13155000	1	5	2	1	0.0660
13155100	0	1			
13155101	4	0.0840			
13155201	4	4			
13155301	0.0	4			
13155401	545.0	5			
13155501	315110000	0	1	1	1.674812 1
13155601	-939	0	3949	1	1.674812 1

13155701	0	0	0	0	1
13155801	0	0	0	1.674812	1
*-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----
<b>* PIPING BETWEEN BREAK AND ISOLATION VALVE</b>					
*-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----
13156000	1	5	2	1	0.1285
13156100	0	1			
13156101	4	0.1620			
13156201	4	4			
13156301	0.0	4			
13156401	545.0	5			
13156501	315120000	0	1	1	0.545209 1
13156601	-939	0	3949	1	0.545209 1
13156701	0	0	0	0	1
13156801	0	0	0	0.545209	1
*-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----
<b>* BROKEN LOOP COLD LEG PIPING</b>					
*-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----
<b>* NOZZLE PIPING</b>					
*-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----
13350000	3	5	2	1	0.1420
13350100	0	1			
13350101	4	0.1780			
13350201	4	4			
13350301	0.0	4			
13350401	550.0	5			
13350501	335010000	0	1	1	0.749305 1
13350502	340010000	0	1	1	0.698336 2
13350503	345010000	0	1	1	0.974349 3
13350601	-939	0	3949	1	0.749305 1
13350602	-939	0	3949	1	0.698336 2
13350603	-939	0	3949	1	0.974349 3
13350701	0	0	0	0	3
13350801	0	0	0	0.749305	1
13350802	0	0	0	0.698336	2
13350803	0	0	0	0.974349	3
*-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----
<b>* SMALL PIPING NEAR BREAK</b>					
*-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----
13501000	1	5	2	1	0.0550
13501100	0	1			
13501101	4	0.1780			
13501201	4	4			
13501301	0.0	4			
13501401	545.0	5			
13501501	345010000	0	1	1	0.525781 1
13501601	-939	0	3949	1	0.525781 1
13501701	0	0	0	0	1
13501801	0	0	0	0.525781	1
*-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----
<b>* PIPING BETWEEN BREAK AND ISOLATION VALVE</b>					
*-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----
13502000	2	5	2	1	0.0865
13502100	0	1			
13502101	4	0.1095			
13502201	4	4			
13502301	0.0	4			
13502401	545.0	5			

13502501	350010000	0	1	1	0.453394	1
13502502	350020000	0	1	1	1.074803	2
13502601	-939	0	3949	1	0.453394	1
13502602	-939	0	3949	1	1.074803	2
13502701	0	0	0	0	2	
13502801	0	0	0	0.453394	1	
13502802	0	0	0	1.074803	2	

\*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----

\* REFLOOD ASSIST PIPING AND VALVES

*	-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----					
13700000	6	5	2	1	0.111	
13700100	0	1				
13700101	4	0.1365				
13700201	4	4				
13700301	0.0	4				
13700401	550.0	5				
13700501	370010000	0	1	1	0.7251	1
13700502	370020000	0	1	1	1.8200	2
13700503	370030000	0	1	1	2.9055	3
13700504	380010000	0	1	1	2.2898	4
13700505	380020000	0	1	1	1.2231	5
13700506	380030000	0	1	1	1.1065	6
13700601	-939	0	3949	1	0.7251	1
13700602	-939	0	3949	1	1.8200	2
13700603	-939	0	3949	1	2.9055	3
13700604	-939	0	3949	1	2.2898	4
13700605	-939	0	3949	1	1.2231	5
13700606	-939	0	3949	1	1.1065	6
13700701	0	0	0	0	6	
13700801	0	0	0	0.7246	1	
13700802	0	0	0	1.820	2	
13700803	0	0	0	1.7230	3	
13700804	0	0	0	1.144	4	
13700805	0	0	0	1.181	5	
13700806	0	0	0	1.2586	6	

\*\$\*\$\$\*

\*

\* PRESSURIZER HEAT STRUCTURES

\*

\*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----

\* VESSEL BOTTOM

*	-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----					
14151000	1	5	1	1	0.0	
14151100	0	1				
14151101	4	0.0762				
14151201	5	4				
14151301	0.0	4				
14151401	613.0	5				
14151501	415010000	0	1	1	0.362	1
14151601	-939	0	3969	1	0.362	1
14151701	0	0	0	0	1	
14151801	0	0.0	0.0	0.0	1	

\*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----

\* VESSEL SIDES - LARGE DIAMETER SECTION

*	-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----					
14152000	6	5	2	1	0.42291	
14152100	0	1				
14152101	4	0.49911				

14152201	5	4				
14152301	0.0	4				
14152401	613.0	5				
14152501	415010000	0	1	1	0.1815	1
14152502	415020000	0	1	1	0.1524	2
14152503	415030000	0	1	1	0.3967	3
14152504	415040000	0	1	1	0.5289	4
14152505	415050000	0	1	1	0.3967	5
14152506	415060000	0	1	1	0.1943	6
14152601	-939	0	3969	1	0.1815	1
14152602	-939	0	3969	1	0.1524	2
14152603	-939	0	3969	1	0.3967	3
14152604	-939	0	3969	1	0.5289	4
14152605	-939	0	3969	1	0.3967	5
14152606	-939	0	3969	1	0.1943	6
14152701	0	0	0	0	6	
14152801	0	0.0	0.0	0.0	6	

\*-----1-----1-----1-----1-----1-----1-----1-----

#### \* VESSEL SIDES - SMALL DIAMETER SECTION

14153000	2	5	2	1	0.2032	
14153100	0	1				
14153101	4	0.3683				
14153201	5	4				
14153301	0.0	4				
14153401	613.0	5				
14153501	420010000	10000	1	1	0.1029	2
14153601	-939	0	3969	1	0.1029	2
14153701	0	0	0	0	2	
14153801	0	0.0	0.0	0.0	2	

\*-----1-----1-----1-----1-----1-----1-----1-----

#### \* VESSEL TOP

14201000	1	5	1	1	0.0	
14201100	0	1				
14201101	4	0.18415				
14201201	5	4				
14201301	0.0	4				
14201401	613.0	5				
14201501	420020000	0	1	1	0.13	1
14201601	-939	0	3969	1	0.13	1
14201701	0	0	0	0	1	
14201801	0	0.0	0.0	0.0	1	

\*\$\*

\*

#### \* HEAT STRUCTURE THERMAL PROPERTY DATA

\*

20100100	TBL/FCTN	1	1	* U02	
20100200	TBL/FCTN	1	1	* GAP	
20100300	TBL/FCTN	1	1	* ZR	
20100400	TBL/FCTN	1	1	* S-STEEL	
20100500	C-STEEL				
20100600	TBL/FCTN	1	1	* INCONEL 600	

\*-----1-----1-----1-----1-----1-----1-----1-----

#### \* U02 - THERMAL CONDUCTIVITY

\*-----1-----1-----1-----1-----1-----1-----1-----

20100101 2.7315E2 8.44

20100102	4.1667E2	6.46
20100103	5.3315E2	5.782385
20100104	6.99817E2	4.633177
20100105	8.66483E2	3.880307
20100106	1.03315E3	3.357625
20100107	1.08871E3	3.155129
20100108	1.19982E3	2.983787
20100109	1.28315E3	2.836674
20100110	1.36648E3	2.713792
20100111	1.53315E3	2.521680
20100112	1.61648E3	2.448990
20100113	1.69982E3	2.391875
20100114	1.97759E3	2.289762
20100115	2.25537E3	2.307069
20100116	2.53315E3	2.433413
20100117	2.81093E3	2.661870
20100118	3.08871E3	2.994171
-----1-----1-----1-----1-----1-----1-----1-----1-----1-----		
* U02 - VOLUMETRIC HEAT CAPACITY		
-----1-----1-----1-----1-----1-----1-----1-----1-----1-----		
20100151	2.73150E2	2.310427E6
20100152	3.23150E2	2.571985E6
20100153	3.73150E2	2.746357E6
20100154	6.7315E2	3.138694E6
20100155	1.37315E3	3.443844E6
20100156	1.77315E3	3.531030E6
20100157	1.97315E3	3.792588E6
20100158	2.17315E3	4.228518E6
20100159	2.37315E3	4.882412E6
20100160	2.67315E3	6.015829E6
20100161	2.77315E3	6.320980E6
20100162	2.87315E3	6.582538E6
20100163	2.97315E3	6.713317E6
20100164	3.11315E3	6.800503E6
20100165	4.69982E3	6.800503E6
-----1-----1-----1-----1-----1-----1-----1-----1-----1-----		
* GAP - THERMAL CONDUCTIVITY		
-----1-----1-----1-----1-----1-----1-----1-----1-----1-----		
20100201	273.15	0.14
20100202	590.0	0.24
20100203	810.0	0.29
20100204	1090.0	0.36
20100205	1370.0	0.42
20100206	3260.0	0.75
-----1-----1-----1-----1-----1-----1-----1-----1-----1-----		
* GAP - VOLUMETRIC HEAT CAPACITY		
-----1-----1-----1-----1-----1-----1-----1-----1-----1-----		
20100251	273.15	5.4
20100252	3260.0	5.4
-----1-----1-----1-----1-----1-----1-----1-----1-----1-----		
* ZIRCALOY-4 - THERMAL CONDUCTIVITY FROM MATPRO		
-----1-----1-----1-----1-----1-----1-----1-----1-----1-----		
20100301	380.4	13.6
20100302	469.3	14.6
20100303	577.6	15.8
20100304	685.9	17.3
20100305	774.8	18.4
20100306	872.0	19.8

20100307	973.2	21.8
20100308	1073.2	23.2
20100309	1123.2	25.4
20100310	1152.3	24.2
20100311	1232.2	25.5
20100312	1331.2	26.6
20100313	1404.2	28.2
20100314	1576.2	33.0
20100315	1625.2	36.7
20100316	1755.2	41.2
20100317	2273.2	55.0

\*-----1-----1-----1-----1-----1-----1-----1-----  
 \* ZIRCALOY-4 - VOLUMETRIC HEAT CAPACITY      FROM MATPRO  
 \*-----1-----1-----1-----1-----1-----1-----1-----

20100351	300.0	1.841E6
20100352	400.0	1.978E6
20100353	640.0	2.168E6
20100354	1090.0	2.456E6
20100355	1093.0	3.288E6
20100356	1113.0	3.865E6
20100357	1133.0	4.028E6
20100358	1153.0	4.709E6
20100359	1173.0	5.345E6
20100360	1193.0	5.044E6
20100361	1213.0	4.054E6
20100362	1233.0	3.072E6
20100363	1243.0	2.332E6
20100364	1477.0	2.332E6

\*-----1-----1-----1-----1-----1-----1-----1-----  
 \* S-STEEL - THERMAL CONDUCTIVITY  
 \*-----1-----1-----1-----1-----1-----1-----1-----

20100401	273.15	12.98
20100402	1199.82	25.1

\*-----1-----1-----1-----1-----1-----1-----1-----  
 \* S-STEEL - VOLUMETRIC HEAT CAPACITY  
 \*-----1-----1-----1-----1-----1-----1-----1-----

20100451	273.15	3.83E6
20100452	366.5	3.83E6
20100453	477.59	4.190E6
20100454	588.59	4.336E6
20100455	699.82	4.504E6
20100456	810.93	4.639E6
20100457	922.04	4.773E6
20100458	1144.26	5.076E6
20100459	1366.5	5.376E6
20100460	1477.59	5.546E6

\*-----1-----1-----1-----1-----1-----1-----1-----  
 \* INCONEL-600 - THERMAL CONDUCTIVITY  
 \*-----1-----1-----1-----1-----1-----1-----1-----

20100601	366.5	13.85
20100602	477.6	15.92
20100603	588.7	18.17
20100604	700.0	20.42
20100605	810.9	22.50
20100606	922.0	24.92
20100607	1033.2	26.83
20100608	1144.3	29.42
20100609	1477.6	36.06



20506208		9.21538-2	RHO	115070000		
20506209		0.136356	RHO	115080000		
20506210		0.335320	RHO	116010000		
* 063 PUMP SUCTION PIPING MASS						
20506300	PMPSUMASS	SUM	1.0	0.0	1	
20506301	0.0	4.45625-2	RHO	118010000		
20506302		4.45137-2	RHO	118020000		
20506303		3.54278-2	RHO	118030000		
20506304		4.87901-2	RHO	120010000		
20506305		6.40548-2	RHO	125010000		
20506306		1.77444-2	RHO	130010000		
20506307		6.40548-2	RHO	155010000		
20506308		1.77444-2	RHO	160010000		
* 064 INTACT LOOP COLD LEG MASS						
20506400	ILCLMASS	SUM	1.0	0.0	1	
20506401	0.0	9.91000-2	RHO	135010000		
20506402		1.83849-2	RHO	140010000		
20506403		6.33861-2	RHO	145010000		
20506404		3.16011-2	RHO	150010000		
20506405		9.91000-2	RHO	165010000		
20506406		1.92958-2	RHO	170010000		
20506407		3.54280-2	RHO	175010000		
20506408		3.88950-2	RHO	175020000		
20506409		7.30598-2	RHO	180010000		
20506410		6.44920-2	RHO	185010000		
* 065 DOWNCOMER/LOWER PLENUM MASS						
20506500	DCLPMASS	SUM	1.0	0.0	1	
20506501	0.0	0.0864164	RHO	200010000		
20506502		0.0907360	RHO	205010000		
20506503		0.1509710	RHO	210010000		
20506504		0.0706690	RHO	210020000		
20506505		0.1060015	RHO	210030000		
20506506		0.0795138	RHO	210040000		
20506507		0.0998947	RHO	210050000		
20506508		0.06252	RHO	210060000		
20506509		0.24520	RHO	215010000		
20506510		0.29656	RHO	220010000		
* 066 REACTOR VESSEL FILLER GAP MASS						
20506600	FGAPMASS	SUM	1.0	0.0	1	
20506601	0.0	0.0899085	RHO	223010000		
20506602		0.0722790	RHO	223020000		
20506603		0.0334096	RHO	223030000		
20506604		0.03098	RHO	223040000		
* 067 CORE/UPPER PLENUM MASS						
20506700	CRUPMASS	SUM	1.0	0.0	1	
20506701	0.0	0.12094	RHO	225010000		
20506702		0.0683340	RHO	230010000		
20506703		0.0478582	RHO	230020000		
20506704		0.0483329	RHO	230030000		
20506705		0.0479138	RHO	230040000		
20506706		0.0479052	RHO	230050000		
20506707		0.0750459	RHO	230060000		
20506708		0.0091280	RHO	235010000		
20506709		0.0072325	RHO	235020000		
20506710		0.0088095	RHO	235030000		
20506711		0.1195494	RHO	240010000		
20506712		0.1280806	RHO	245010000		
20506713		0.1436936	RHO	250010000		

20506714		0.1154214	RHO	251010000	
20506715		0.2031741	RHO	255010000	
20506716		0.1914909	RHO	260010000	
* 068 BROKEN LOOP HOT LEG MASS					
20506800	BLHLMASS	SUM	1.0	0.0	1
20506801	0.0	5.75410-2	RHO	300010000	
20506802		4.42927-2	RHO	305010000	
20506803		6.78467-2	RHO	310010000	
20506804		3.07670-3	RHO	315010000	
20506805		4.67621-3	RHO	315020000	
20506806		8.60554-2	RHO	315030000	
20506807		8.60554-2	RHO	315040000	
20506808		8.97552-2	RHO	315050000	
20506809		8.97552-2	RHO	315060000	
20506810		8.60554-2	RHO	315070000	
20506811		8.60554-2	RHO	315080000	
20506812		1.82303-2	RHO	315090000	
20506813		5.46687-2	RHO	315100000	
20506814		1.82489-2	RHO	315110000	
20506815		2.83241-2	RHO	315120000	
20506816		9.15000-2	RHO	380010000	
20506817		4.80000-2	RHO	380020000	
20506818		4.89000-2	RHO	380030000	
* 069 BROKEN LOOP COLD LEG MASS					
20506900	BLCCLMASS	SUM	1.0	0.0	1
20506901	0.0	4.79790-2	RHO	335010000	
20506902		4.43927-2	RHO	340010000	
20506903		6.73163-2	RHO	345010000	
20506904		1.06640-2	RHO	350010000	
20506905		4.07801-2	RHO	350020000	
20506906		2.97722-2	RHO	360010000	
20506907		2.79000-2	RHO	370010000	
20506908		7.00000-2	RHO	370020000	
20506909		1.16500-1	RHO	370030000	
* 070 PRESSURIZER MASS					
20507000	PZRMASS	SUM	1.0	0.0	1
20507001	0.0	3.33500-3	RHO	400010000	
20507002		3.33500-3	RHO	405010000	
20507003		3.33500-3	RHO	405020000	
20507004		6.84000-2	RHO	415010000	
20507005		8.38000-2	RHO	415020000	
20507006		2.24255-1	RHO	415030000	
20507007		2.98987-1	RHO	415040000	
20507008		2.24255-1	RHO	415050000	
20507009		7.32000-2	RHO	415060000	
20507010		1.42000-2	RHO	420010000	
20507011		1.42000-2	RHO	420020000	
20507012		2.12609-3	RHO	430010000	
* 071 REACTOR VESSEL TOTAL MASS					
20507100	RVMASS	SUM	1.0	0.0	1
20507101	0.0	1.0	CNTRLVAR	65	
20507102		1.0	CNTRLVAR	66	
20507103		1.0	CNTRLVAR	67	
* 072 PCS TOTAL MASS					
20507200	PCSMASS	SUM	1.0	0.0	1
20507201	0.0	1.0	CNTRLVAR	61	
20507202		1.0	CNTRLVAR	62	
20507203		1.0	CNTRLVAR	63	

20507204	1.0	CNTRLVAR	64
20507205	1.0	CNTRLVAR	68
20507206	1.0	CNTRLVAR	69
20507207	1.0	CNTRLVAR	70
20507208	1.0	CNTRLVAR	71

\*-----1-----1-----1-----1-----1-----1-----

\* 073-076 STEAM GENERATOR MASS CALCULATOR

\*-----1-----1-----1-----1-----1-----1-----

\* 073 STEAM GENERATOR DOWNCOMER MASS

20507300	SGDCMASS	SUM	1.0	0.0	1
20507301	0.0	0.4384	RHO	503010000	
20507302		1.4850	RHO	505010000	
20507303		2.21070-1	RHO	508010000	
20507304		1.41427-1	RHO	510010000	
20507305		1.41427-1	RHO	510020000	
20507306		1.41427-1	RHO	510030000	

\* 074 STEAM GENERATOR BOILER MASS

20507400	SGBLRMASS	SUM	1.0	0.0	1
20507401	0.0	5.07675-1	RHO	515010000	
20507402		5.07675-1	RHO	515020000	
20507403		5.07675-1	RHO	515030000	
20507404		5.07675-1	RHO	515040000	
20507405		3.71565-1	RHO	515050000	
20507406		0.2425	RHO	500010000	

\* 075 STEAM GENERATOR DOME AND PIPE MASS

20507500	SGDMMASS	SUM	1.0	0.0	1
20507501	0.0	0.705312	RHO	520010000	
20507502		0.705312	RHO	525010000	
20507503		1.162180	RHO	530010000	

\* 076 STEAM GENERATOR TOTAL MASS

20507600	SGMASS	SUM	1.0	0.0	1
20507601	0.0	1.0	CNTRLVAR	73	
20507602		1.0	CNTRLVAR	74	
20507603		1.0	CNTRLVAR	75	

\*\$\*\$\$\*

\*

\* GENERAL TABLE DATA

\*

TABLE NUMBER	DESCRIPTION
900	REACTOR POWER VS TIME AFTER SCRAM
939	ENVIRONMENTAL HEAT LOSS BOUNDARY TEMPERATURE
949	PRIMARY SYSTEM ENVR LOSS HEAT XFER COEFFICIENT
959	STEAM GENERATOR ENVR LOSS HEAT XFER COEFFICIENT
969	PRESSURIZER ENVR LOSS HEAT XFER COEFFICIENT

\*-----1-----1-----1-----1-----1-----1-----1-----

20290000	POWER	699	1.0	45.9+6
20290001	0.0	1.0	* FROM F3S-20&F2-2 OF EDR L5-1	
20290002	0.50	0.55374		
20290003	1.00	0.18625		
20290004	1.50	0.10259		
20290005	2.00	0.08423		
20290006	2.50	0.080020		

20290007	3.0	0.07603
20290008	3.5	0.072700
20290009	5.0	0.064940
20290010	10.0	0.055882
20290011	25.0	0.046738
20290012	65.	0.035
20290013	100.	0.031546
20290014	250.	0.025210
20290015	650.	0.0188
20290016	1000.	0.0164
20290017	1500.	0.0140
20290018	3000.	0.0110
20290019	5000.	0.0092
20290020	1.+5	0.001460 * CHANGED 89/11/06 BASED ON EDR F2-2 F3S-20
*-1--	-1---	-1---
* ENVIRONMENTAL HEAT LOSS BOUNDARY TEMPERATURE		
*-----1-----	-----1-----	-----1-----
20293900	TEMP	
20293901	0.0	311.0
*-----1-----	-----1-----	-----1-----
* PRIMARY SYSTEM ENVIRONMENTAL LOSS HEAT XFER COEFFICIENT		
*-----1-----	-----1-----	-----1-----
20294900	HTC-T	
20294901	0.0	10.76 * 174 KW FROM PCS (EXCEPT PZR)
*-----1-----	-----1-----	-----1-----
* STEAM GENERATOR ENVIRONMENTAL LOSS HEAT XFER COEFFICIENT		
*-----1-----	-----1-----	-----1-----
20295900	HTC-T	
20295901	0.0	3.385 * 20 KW FROM STEAM GENERATOR
*-----1-----	-----1-----	-----1-----
* PRESSURIZER ENVIRONMENTAL LOSS HEAT XFER COEFFICIENT		
*-----1-----	-----1-----	-----1-----
20296900	HTC-T	
20296901	0.0	3.019 * 6 KW FROM PRESSURIZER
*\$*		
*		
* PUMP DATA		
*		
*-----1-----	-----1-----	-----1-----
* SINGLE PHASE HEAD CURVES		
*-----1-----	-----1-----	-----1-----
* HEAD CURVE NO. 1		
*-----1-----	-----1-----	-----1-----
1351100	1	1
1351101	0.000000E+00	1.403600E+00
1351102	1.906100E-01	1.363600E+00
1351103	3.896300E-01	1.318600E+00
1351104	5.939600E-01	1.232800E+00
1351105	7.902000E-01	1.133600E+00
1351106	1.000000E+00	1.000000E+00
*-----1-----	-----1-----	-----1-----
* HEAD CURVE NO. 2		
*-----1-----	-----1-----	-----1-----
1351200	1	2
1351201	0.000000E+00	-6.700000E-01
1351202	2.000000E-01	-5.000000E-01
1351203	4.000000E-01	-2.500000E-01
1351204	5.755400E-01	0.000000E+00

1351205	7.443200E-01	2.583000E-01
1351206	7.734800E-01	3.778000E-01
1351207	8.631300E-01	6.326000E-01
1351208	1.000000E+00	1.000000E+00
*-----1-----1-----1-----1-----1-----1-----1-----1-----		
* HEAD CURVE NO. 3		
*-----1-----1-----1-----1-----1-----1-----1-----1-----		
1351300	1	3
1351301	-1.000000E+00	2.472200E+00
1351302	-8.057400E-01	2.047400E+00
1351303	-6.069000E-01	1.831000E+00
1351304	-4.068300E-01	1.624000E+00
1351305	-2.001710E-01	1.470500E+00
1351306	0.000000E+00	1.403600E+00
*-----1-----1-----1-----1-----1-----1-----1-----1-----		
* HEAD CURVE NO. 4		
*-----1-----1-----1-----1-----1-----1-----1-----1-----		
1351400	1	4
1351401	-1.000000E+00	2.472200E+00
1351402	-8.229700E-01	1.996800E+00
1351403	-6.333200E-01	1.589700E+00
1351404	-4.553400E-01	1.327900E+00
1351405	-2.710900E-01	1.194900E+00
1351406	-1.771600E-01	1.060500E+00
1351407	-9.073000E-02	1.015600E+00
1351408	0.000000E+00	9.342790E-01
*-----1-----1-----1-----1-----1-----1-----1-----1-----		
* HEAD CURVE NO. 5		
*-----1-----1-----1-----1-----1-----1-----1-----1-----		
1351500	1	5
1351501	0.000000E+00	2.500000E-01
1351502	2.000000E-01	2.800000E-01
1351503	4.000000E-01	3.400000E-01
1351504	4.118000E-01	2.768000E-01
1351505	5.976300E-01	4.584000E-01
1351506	7.934670E-01	6.992000E-01
1351507	1.000000E+00	1.000000E+00
*-----1-----1-----1-----1-----1-----1-----1-----1-----		
* HEAD CURVE NO. 6		
*-----1-----1-----1-----1-----1-----1-----1-----1-----		
1351600	1	6
1351601	0.000000E+00	9.342790E-01
1351602	9.109900E-02	9.229000E-01
1351603	1.865090E-01	8.963000E-01
1351604	2.717620E-01	8.750000E-01
1351605	4.558720E-01	8.433000E-01
1351606	5.744060E-01	8.355000E-01
1351607	7.405760E-01	8.466000E-01
1351608	7.666190E-01	8.469000E-01
1351609	8.714710E-01	8.838000E-01
1351610	1.000000E+00	1.000000E+00
*-----1-----1-----1-----1-----1-----1-----1-----1-----		
* HEAD CURVE NO. 7		
*-----1-----1-----1-----1-----1-----1-----1-----1-----		
1351700	1	7
1351701	-1.000000E+00	-1.000000E+00
1351702	-8.000000E-01	-6.300000E-01
1351703	-6.000000E-01	-3.000000E-01

1351704	-4.000000E-01	-5.000000E-02
1351705	-2.000000E-01	1.500000E-01
1351706	0.000000E+00	2.500000E-01
*	-----1-----	-----1-----1-----1-----1-----
* HEAD CURVE NO. 8		
*	-----1-----1-----1-----1-----1-----1-----1-----	
1351800	1	8
1351801	-1.000000E+00	-1.000000E+00
1351802	-8.000000E-01	-9.700000E-01
1351803	-6.000000E-01	-9.500000E-01
1351804	-4.000000E-01	-8.800000E-01
1351805	-2.000000E-01	-8.000000E-01
1351806	0.000000E+00	-6.700000E-01
*	-----1-----1-----1-----1-----1-----1-----1-----	
* SINGLE PHASE TORQUE DATA		
*	-----1-----1-----1-----1-----1-----1-----1-----	
* TORQUE CURVE NO. 1		
*	-----1-----1-----1-----1-----1-----1-----1-----	
1351900	2	1
1351901	0.000000E+00	6.032000E-01
1351902	1.930000E-01	6.325000E-01
1351903	3.930000E-01	7.369000E-01
1351904	5.955200E-01	8.331000E-01
1351905	7.978200E-01	9.229000E-01
1351906	1.000000E+00	1.000000E+00
*	-----1-----1-----1-----1-----1-----1-----1-----	
* TORQUE CURVE NO. 2		
*	-----1-----1-----1-----1-----1-----1-----1-----	
1352000	2	2
1352001	0.000000E+00	-6.700000E-01
1352002	4.000000E-01	-2.500000E-01
1352003	5.000000E-01	1.500000E-01
1352004	7.372550E-01	5.265860E-01
1352005	7.680490E-01	6.065940E-01
1352006	8.672300E-01	7.436600E-01
1352007	1.000000E+00	1.000000E+00
*	-----1-----1-----1-----1-----1-----1-----1-----	
* TORQUE CURVE NO. 3		
*	-----1-----1-----1-----1-----1-----1-----1-----	
1352100	2	3
1352101	-1.000000E+00	1.984300E+00
1352102	-8.009600E-01	1.394000E+00
1352103	-6.063800E-01	1.097500E+00
1352104	-4.068600E-01	8.220000E-01
1352105	-1.992800E-01	6.648000E-01
1352106	0.000000E+00	6.032000E-01
*	-----1-----1-----1-----1-----1-----1-----1-----	
* TORQUE CURVE NO. 4		
*	-----1-----1-----1-----1-----1-----1-----1-----	
1352200	2	4
1352201	-1.000000E+00	1.984300E+00
1352202	-8.223400E-01	1.830800E+00
1352203	-6.337100E-01	1.682400E+00
1352204	-4.585300E-01	1.557000E+00
1352205	-2.670230E-01	1.436200E+00
1352206	-1.761070E-01	1.387900E+00
1352207	-8.931000E-02	1.348100E+00
1352208	0.000000E+00	1.233610E+00

\*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----  
 \* TORQUE CURVE NO. 5  
 \*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----  
 1352300 2 5  
 1352301 0.000000E+00 -4.500000E-01  
 1352302 4.000000E-01 -2.500000E-01  
 1352303 5.000000E-01 0.000000E+00  
 1352304 1.000000E+00 3.569000E-01  
 \*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----  
 \* TORQUE CURVE NO. 6  
 \*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----  
 1352400 2 6  
 1352401 0.000000E+00 1.233610E+00  
 1352402 9.064300E-02 1.196500E+00  
 1352403 1.885690E-01 1.109600E+00  
 1352404 2.734700E-01 1.041600E+00  
 1352405 4.586690E-01 8.958000E-01  
 1352406 5.744800E-01 7.807000E-01  
 1352407 7.381600E-01 6.134000E-01  
 1352408 7.685200E-01 5.849000E-01  
 1352409 8.700570E-01 4.877000E-01  
 1352410 1.000000E+00 3.569000E-01  
 \*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----  
 \* TORQUE CURVE NO. 7  
 \*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----  
 1352500 2 7  
 1352501 -1.000000E+00 -1.000000E+00  
 1352502 -3.000000E-01 -9.000000E-01  
 1352503 -1.000000E-01 -5.000000E-01  
 1352504 0.000000E+00 -4.500000E-01  
 \*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----  
 \* TORQUE CURVE NO. 8  
 \*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----  
 1352600 2 8  
 1352601 -1.000000E+00 -1.000000E+00  
 1352602 -2.500000E-01 -9.000000E-01  
 1352603 -8.000000E-02 -8.000000E-01  
 1352604 0.000000E+00 -6.700000E-01  
 \*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----  
 \* TWO - PHASE MULTIPLIER DATA FROM L5-1 TEST DATA  
 \*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----  
 \* HEAD CURVE  
 \*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----  
 1353000 0  
 1353001 0.000000E+00 0.000000E+00  
 1353002 1.000000E-01 0.000000E+00  
 1353003 2.000000E-01 1.000000E-01  
 1353004 3.000000E-01 2.000000E-01  
 1353005 3.500000E-01 3.000000E-01  
 1353006 4.000000E-01 6.000000E-01  
 1353007 5.000000E-01 6.000000E-01  
 1353008 6.000000E-01 6.000000E-01  
 1353009 7.000000E-01 6.000000E-01  
 1353010 8.000000E-01 5.000000E-01  
 1353011 9.000000E-01 3.000000E-01  
 1353012 1.000000E+00 0.000000E+00  
 \*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----  
 \* TORQUE CURVE

	1	1	1	1	1	1
1353100	0					
1353101	0.000000E+00	0.000000E+00				
1353102	1.000000E-01	0.000000E+00				
1353103	2.000000E-01	1.000000E-01				
1353104	3.000000E-01	3.000000E-01				
1353105	3.500000E-01	5.000000E-01				
1353106	4.000000E-01	7.500000E-01				
1353107	5.000000E-01	7.500000E-01				
1353108	6.000000E-01	7.500000E-01				
1353109	7.000000E-01	7.500000E-01				
1353110	8.000000E-01	7.500000E-01				
1353111	9.000000E-01	5.000000E-01				
1353112	1.000000E+00	0.000000E+00				
*-----1-----1-----1-----1-----1-----1-----1-----						
* PUMP 2-PHASE DIFFERENCE DATA						
*-----1-----1-----1-----1-----1-----1-----1-----						
* HEAD CURVE NO. 1						
*-----1-----1-----1-----1-----1-----1-----1-----						
1354100	1	1				
1354101	0.000000E+00	1.000000E+00				
1354102	1.000000E+00	1.000000E+00				
*-----1-----1-----1-----1-----1-----1-----1-----						
* HEAD CURVE NO. 2						
*-----1-----1-----1-----1-----1-----1-----1-----						
1354200	1	2				
1354201	0.000000E+00	1.000000E+00				
1354202	1.000000E+00	1.000000E+00				
*-----1-----1-----1-----1-----1-----1-----1-----						
* HEAD CURVE NO. 3						
*-----1-----1-----1-----1-----1-----1-----1-----						
1354300	1	3				
1354301	-1.000000E+00	-1.160000E+00				
1354302	-9.000000E-01	-1.240000E+00				
1354303	-8.000000E-01	-1.770000E+00				
1354304	-7.000000E-01	-2.360000E+00				
1354305	-6.000000E-01	-2.790000E+00				
1354306	-5.000000E-01	-2.910000E+00				
1354307	-4.000000E-01	-2.670000E+00				
1354308	-2.500000E-01	-1.690000E+00				
1354309	-1.000000E-01	-5.000000E-01				
1354310	0.000000E+00	0.000000E+00				
*-----1-----1-----1-----1-----1-----1-----1-----						
* HEAD CURVE NO. 4						
*-----1-----1-----1-----1-----1-----1-----1-----						
1354400	1	4				
1354401	-1.000000E+00	-1.160000E+00				
1354402	-9.000000E-01	-7.800000E-01				
1354403	-8.000000E-01	-5.000000E-01				
1354404	-7.000000E-01	-3.100000E-01				
1354405	-6.000000E-01	-1.700000E-01				
1354406	-5.000000E-01	-8.000000E-02				
1354407	-3.500000E-01	0.000000E+00				
1354408	-2.000000E-01	5.000000E-02				
1354409	-1.000000E-01	8.000000E-02				
1354410	0.000000E+00	1.100000E-01				
*-----1-----1-----1-----1-----1-----1-----1-----						
* HEAD CURVE NO. 5						

1354500	1	5
1354501	0.000000E+00	0.000000E+00
1354502	2.000000E-01	-3.400000E-01
1354503	4.000000E-01	-6.500000E-01
1354504	6.000000E-01	-9.300000E-01
1354505	8.000000E-01	-1.190000E+00
1354506	1.000000E+00	-1.470000E+00
* HEAD CURVE NO. 6		
1354600	1	6
1354601	0.000000E+00	1.100000E-01
1354602	1.000000E-01	1.300000E-01
1354603	2.500000E-01	1.500000E-01
1354604	4.000000E-01	1.300000E-01
1354605	5.000000E-01	7.000000E-02
1354606	6.000000E-01	-4.000000E-02
1354607	7.000000E-01	-2.300000E-01
1354608	8.000000E-01	-5.100000E-01
1354609	9.000000E-01	-9.100000E-01
1354610	1.000000E+00	-1.470000E+00
* HEAD CURVE NO. 7		
1354700	1	7
1354701	-1.000000E+00	0.000000E+00
1354702	0.000000E+00	0.000000E+00
* HEAD CURVE NO. 8		
1354800	1	8
1354801	-1.000000E+00	0.000000E+00
1354802	0.000000E+00	0.000000E+00
* TORQUE CURVE NO. 1		
1354900	2	1
1354901	0.000000E+00	1.000000E+00
1354906	1.000000E+00	1.000000E+00
* TORQUE CURVE NO. 2		
1355000	2	2
1355001	0.000000E+00	1.000000E+00
1355007	1.000000E+00	1.000000E+00
* TORQUE CURVE NO. 3		
1355100	2	3
1355101	-1.000000E+00	1.984300E+00
1355102	-8.009600E-01	1.394000E+00
1355103	-6.063800E-01	1.097500E+00
1355104	-4.068600E-01	8.220000E-01
1355105	-1.992800E-01	6.648000E-01
1355106	0.000000E+00	6.032000E-01
* TORQUE CURVE NO. 4		

```

*-----1-----1-----1-----1-----1-----1-----1-----
1355200 2 4
1355201 -1.000000E+00 1.984300E+00
1355202 -8.223400E-01 1.830800E+00
1355203 -6.337100E-01 1.682400E+00
1355204 -4.585300E-01 1.557000E+00
1355205 -2.670230E-01 1.436200E+00
1355206 -1.761070E-01 1.387900E+00
1355207 -8.931000E-02 1.348100E+00
1355208 0.000000E+00 1.233610E+00
*-----1-----1-----1-----1-----1-----1-----1-----
* TORQUE CURVE NO. 5
*-----1-----1-----1-----1-----1-----1-----1-----
1355300 2 5
1355301 0.000000E+00 -4.500000E-01
1355302 4.000000E-01 -2.500000E-01
1355303 5.000000E-01 0.000000E+00
1355304 1.000000E+00 3.569000E-01
*-----1-----1-----1-----1-----1-----1-----1-----
* TORQUE CURVE NO. 6
*-----1-----1-----1-----1-----1-----1-----1-----
1355400 2 6
1355401 0.000000E+00 1.233610E+00
1355402 9.064300E-02 1.196500E+00
1355403 1.885690E-01 1.109600E+00
1355404 2.734700E-01 1.041600E+00
1355405 4.586690E-01 8.958000E-01
1355406 5.744800E-01 7.807000E-01
1355407 7.381600E-01 6.134000E-01
1355408 7.685200E-01 5.849000E-01
1355409 8.700570E-01 4.877000E-01
1355410 1.000000E+00 3.569000E-01
*-----1-----1-----1-----1-----1-----1-----1-----
* TORQUE CURVE NO. 7
*-----1-----1-----1-----1-----1-----1-----1-----
1355500 2 7
1355501 -1.000000E+00 -1.000000E+00
1355502 -3.000000E-01 -9.000000E-01
1355503 -1.000000E-01 -5.000000E-01
1355504 0.000000E+00 -4.500000E-01
*-----1-----1-----1-----1-----1-----1-----1-----
* TORQUE CURVE NO. 8
*-----1-----1-----1-----1-----1-----1-----1-----
1355600 2 8
1355601 -1.000000E+00 -1.000000E+00
1355602 -2.500000E-01 -9.000000E-01
1355603 -8.000000E-02 -8.000000E-01
1355604 0.000000E+00 -6.700000E-01
* $$$ REMOVE ALL REMAINING DATA CARDS AFTER ACHIEVING STEADY STATE
*$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$*
* PUMP DATA
*
*-----1-----1-----1-----1-----1-----1-----1-----
* SINGLE PHASE HEAD CURVES
*-----1-----1-----1-----1-----1-----1-----1-----
* HEAD CURVE NO. 1
*-----1-----1-----1-----1-----1-----1-----1-----

```



1651603	1.865090E-01	8.963000E-01
1651604	2.717620E-01	8.750000E-01
1651605	4.558720E-01	8.433000E-01
1651606	5.744060E-01	8.355000E-01
1651607	7.405760E-01	8.466000E-01
1651608	7.666190E-01	8.469000E-01
1651609	8.714710E-01	8.838000E-01
1651610	1.000000E+00	1.000000E+00
*-----1-----1-----1-----1-----1-----1-----1-----		
* HEAD CURVE NO. 7		
*-----1-----1-----1-----1-----1-----1-----1-----		
1651700	1	7
1651701	-1.000000E+00	-1.000000E+00
1651702	-8.000000E-01	-6.300000E-01
1651703	-6.000000E-01	-3.000000E-01
1651704	-4.000000E-01	-5.000000E-02
1651705	-2.000000E-01	1.500000E-01
1651706	0.000000E+00	2.500000E-01
*-----1-----1-----1-----1-----1-----1-----1-----		
* HEAD CURVE NO. 8		
*-----1-----1-----1-----1-----1-----1-----1-----		
1651800	1	8
1651801	-1.000000E+00	-1.000000E+00
1651802	-8.000000E-01	-9.700000E-01
1651803	-6.000000E-01	-9.500000E-01
1651804	-4.000000E-01	-8.800000E-01
1651805	-2.000000E-01	-8.000000E-01
1651806	0.000000E+00	-6.700000E-01
*-----1-----1-----1-----1-----1-----1-----1-----		
* SINGLE PHASE TORQUE DATA		
*-----1-----1-----1-----1-----1-----1-----1-----		
* TORQUE CURVE NO. 1		
*-----1-----1-----1-----1-----1-----1-----1-----		
1651900	2	1
1651901	0.000000E+00	6.032000E-01
1651902	1.930000E-01	6.325000E-01
1651903	3.930000E-01	7.369000E-01
1651904	5.955200E-01	8.331000E-01
1651905	7.978200E-01	9.229000E-01
1651906	1.000000E+00	1.000000E+00
*-----1-----1-----1-----1-----1-----1-----1-----		
* TORQUE CURVE NO. 2		
*-----1-----1-----1-----1-----1-----1-----1-----		
1652000	2	2
1652001	0.000000E+00	-6.700000E-01
1652002	4.000000E-01	-2.500000E-01
1652003	5.000000E-01	1.500000E-01
1652004	7.372550E-01	5.265860E-01
1652005	7.680490E-01	6.065940E-01
1652006	8.672300E-01	7.436600E-01
1652007	1.000000E+00	1.000000E+00
*-----1-----1-----1-----1-----1-----1-----1-----		
* TORQUE CURVE NO. 3		
*-----1-----1-----1-----1-----1-----1-----1-----		
1652100	2	3
1652101	-1.000000E+00	1.984300E+00
1652102	-8.009600E-01	1.394000E+00
1652103	-6.063800E-01	1.097500E+00

1652104	-4.068600E-01	8.220000E-01
1652105	-1.992800E-01	6.648000E-01
1652106	0.000000E+00	6.032000E-01
*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----		
* TORQUE CURVE NO. 4		
*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----		
1652200	2	4
1652201	-1.000000E+00	1.984300E+00
1652202	-8.223400E-01	1.830800E+00
1652203	-6.337100E-01	1.682400E+00
1652204	-4.585300E-01	1.557000E+00
1652205	-2.670230E-01	1.436200E+00
1652206	-1.761070E-01	1.387900E+00
1652207	-8.931000E-02	1.348100E+00
1652208	0.000000E+00	1.233610E+00
*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----		
* TORQUE CURVE NO. 5		
*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----		
1652300	2	5
1652301	0.000000E+00	-4.500000E-01
1652302	4.000000E-01	-2.500000E-01
1652303	5.000000E-01	0.000000E+00
1652304	1.000000E+00	3.569000E-01
*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----		
* TORQUE CURVE NO. 6		
*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----		
1652400	2	6
1652401	0.000000E+00	1.233610E+00
1652402	9.064300E-02	1.196500E+00
1652403	1.885690E-01	1.109600E+00
1652404	2.734700E-01	1.041600E+00
1652405	4.586690E-01	8.958000E-01
1652406	5.744800E-01	7.807000E-01
1652407	7.381600E-01	6.134000E-01
1652408	7.685200E-01	5.849000E-01
1652409	8.700570E-01	4.877000E-01
1652410	1.000000E+00	3.569000E-01
*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----		
* TORQUE CURVE NO. 7		
*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----		
1652500	2	7
1652501	-1.000000E+00	-1.000000E+00
1652502	-3.000000E-01	-9.000000E-01
1652503	-1.000000E-01	-5.000000E-01
1652504	0.000000E+00	-4.500000E-01
*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----		
* TORQUE CURVE NO. 8		
*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----		
1652600	2	8
1652601	-1.000000E+00	-1.000000E+00
1652602	-2.500000E-01	-9.000000E-01
1652603	-8.000000E-02	-8.000000E-01
1652604	0.000000E+00	-6.700000E-01
*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----		
* TWO - PHASE MULTIPLIER DATA FROM L5-1 TEST DATA		
*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----		
* HEAD CURVE		
*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----		

1653000	0	
1653001	0.000000E+00	0.000000E+00
1653002	1.000000E-01	0.000000E+00
1653003	2.000000E-01	1.000000E-01
1653004	3.000000E-01	2.000000E-01
1653005	3.500000E-01	3.000000E-01
1653006	4.000000E-01	6.000000E-01
1653007	5.000000E-01	6.000000E-01
1653008	6.000000E-01	6.000000E-01
1653009	7.000000E-01	6.000000E-01
1653010	8.000000E-01	5.000000E-01
1653011	9.000000E-01	3.000000E-01
1653012	1.000000E+00	0.000000E+00
*-----1-----1-----1-----1-----1-----1-----1-----		
* TORQUE CURVE		
*-----1-----1-----1-----1-----1-----1-----1-----		
1653100	0	
1653101	0.000000E+00	0.000000E+00
1653102	1.000000E-01	0.000000E+00
1653103	2.000000E-01	1.000000E-01
1653104	3.000000E-01	3.000000E-01
1653105	3.500000E-01	5.000000E-01
1653106	4.000000E-01	7.500000E-01
1653107	5.000000E-01	7.500000E-01
1653108	6.000000E-01	7.500000E-01
1653109	7.000000E-01	7.500000E-01
1653110	8.000000E-01	7.500000E-01
1653111	9.000000E-01	5.000000E-01
1653112	1.000000E+00	0.000000E+00
*-----1-----1-----1-----1-----1-----1-----1-----		
* PUMP 2-PHASE DIFFERENCE DATA		
*-----1-----1-----1-----1-----1-----1-----1-----		
* HEAD CURVE NO. 1		
*-----1-----1-----1-----1-----1-----1-----1-----		
1654100	1	1
1654101	0.000000E+00	1.000000E+00
1654102	1.000000E+00	1.000000E+00
*-----1-----1-----1-----1-----1-----1-----1-----		
* HEAD CURVE NO. 2		
*-----1-----1-----1-----1-----1-----1-----1-----		
1654200	1	2
1654201	0.000000E+00	1.000000E+00
1654202	1.000000E+00	1.000000E+00
*-----1-----1-----1-----1-----1-----1-----1-----		
* HEAD CURVE NO. 3		
*-----1-----1-----1-----1-----1-----1-----1-----		
1654300	1	3
1654301	-1.000000E+00	-1.160000E+00
1654302	-9.000000E-01	-1.240000E+00
1654303	-8.000000E-01	-1.770000E+00
1654304	-7.000000E-01	-2.360000E+00
1654305	-6.000000E-01	-2.790000E+00
1654306	-5.000000E-01	-2.910000E+00
1654307	-4.000000E-01	-2.670000E+00
1654308	-2.500000E-01	-1.690000E+00
1654309	-1.000000E-01	-5.000000E-01
1654310	0.000000E+00	0.000000E+00
*-----1-----1-----1-----1-----1-----1-----1-----		

\* HEAD CURVE NO. 4

1654400	1	4
1654401	-1.000000E+00	-1.160000E+00
1654402	-9.000000E-01	-7.800000E-01
1654403	-8.000000E-01	-5.000000E-01
1654404	-7.000000E-01	-3.100000E-01
1654405	-6.000000E-01	-1.700000E-01
1654406	-5.000000E-01	-8.000000E-02
1654407	-3.500000E-01	0.000000E+00
1654408	-2.000000E-01	5.000000E-02
1654409	-1.000000E-01	8.000000E-02
1654410	0.000000E+00	1.100000E-01

\*-----1-----1-----1-----1-----1-----1-----

\* HEAD CURVE NO. 5

1654500	1	5
1654501	0.000000E+00	0.000000E+00
1654502	2.000000E-01	-3.400000E-01
1654503	4.000000E-01	-6.500000E-01
1654504	6.000000E-01	-9.300000E-01
1654505	8.000000E-01	-1.190000E+00
1654506	1.000000E+00	-1.470000E+00

\*-----1-----1-----1-----1-----1-----1-----

\* HEAD CURVE NO. 6

1654600	1	6
1654601	0.000000E+00	1.100000E-01
1654602	1.000000E-01	1.300000E-01
1654603	2.500000E-01	1.500000E-01
1654604	4.000000E-01	1.300000E-01
1654605	5.000000E-01	7.000000E-02
1654606	6.000000E-01	-4.000000E-02
1654607	7.000000E-01	-2.300000E-01
1654608	8.000000E-01	-5.100000E-01
1654609	9.000000E-01	-9.100000E-01
1654610	1.000000E+00	-1.470000E+00

\*-----1-----1-----1-----1-----1-----1-----

\* HEAD CURVE NO. 7

1654700	1	7
1654701	-1.000000E+00	0.000000E+00
1654702	0.000000E+00	0.000000E+00

\*-----1-----1-----1-----1-----1-----1-----

\* HEAD CURVE NO. 8

1654800	1	8
1654801	-1.000000E+00	0.000000E+00
1654802	0.000000E+00	0.000000E+00

\*-----1-----1-----1-----1-----1-----1-----

\* TORQUE CURVE NO. 1

1654900	2	1
1654901	0.000000E+00	1.000000E+00
1654906	1.000000E+00	1.000000E+00

\*-----1-----1-----1-----1-----1-----1-----

\* TORQUE CURVE NO. 2

\*-----1-----1-----1-----1-----1-----1-----

1655000	2	2
1655001	0.000000E+00	1.000000E+00
1655007	1.000000E+00	1.000000E+00
*-----1-----1-----1-----1-----1-----1-----1-----1-----		
* TORQUE CURVE NO. 3		
*-----1-----1-----1-----1-----1-----1-----1-----1-----		
1655100	2	3
1655101	-1.000000E+00	1.984300E+00
1655102	-8.009600E-01	1.394000E+00
1655103	-6.063800E-01	1.097500E+00
1655104	-4.068600E-01	8.220000E-01
1655105	-1.992800E-01	6.648000E-01
1655106	0.000000E+00	6.032000E-01
*-----1-----1-----1-----1-----1-----1-----1-----1-----		
* TORQUE CURVE NO. 4		
*-----1-----1-----1-----1-----1-----1-----1-----1-----		
1655200	2	4
1655201	-1.000000E+00	1.984300E+00
1655202	-8.223400E-01	1.830800E+00
1655203	-6.337100E-01	1.682400E+00
1655204	-4.585300E-01	1.557000E+00
1655205	-2.670230E-01	1.436200E+00
1655206	-1.761070E-01	1.387900E+00
1655207	-8.931000E-02	1.348100E+00
1655208	0.000000E+00	1.233610E+00
*-----1-----1-----1-----1-----1-----1-----1-----1-----		
* TORQUE CURVE NO. 5		
*-----1-----1-----1-----1-----1-----1-----1-----1-----		
1655300	2	5
1655301	0.000000E+00	-4.500000E-01
1655302	4.000000E-01	-2.500000E-01
1655303	5.000000E-01	0.000000E+00
1655304	1.000000E+00	3.569000E-01
*-----1-----1-----1-----1-----1-----1-----1-----1-----		
* TORQUE CURVE NO. 6		
*-----1-----1-----1-----1-----1-----1-----1-----1-----		
1655400	2	6
1655401	0.000000E+00	1.233610E+00
1655402	9.064300E-02	1.196500E+00
1655403	1.885690E-01	1.109600E+00
1655404	2.734700E-01	1.041600E+00
1655405	4.586690E-01	8.958000E-01
1655406	5.744800E-01	7.807000E-01
1655407	7.381600E-01	6.134000E-01
1655408	7.685200E-01	5.849000E-01
1655409	8.700570E-01	4.877000E-01
1655410	1.000000E+00	3.569000E-01
*-----1-----1-----1-----1-----1-----1-----1-----1-----		
* TORQUE CURVE NO. 7		
*-----1-----1-----1-----1-----1-----1-----1-----1-----		
1655500	2	7
1655501	-1.000000E+00	-1.000000E+00
1655502	-3.000000E-01	-9.000000E-01
1655503	-1.000000E-01	-5.000000E-01
1655504	0.000000E+00	-4.500000E-01
*-----1-----1-----1-----1-----1-----1-----1-----1-----		
* TORQUE CURVE NO. 8		
*-----1-----1-----1-----1-----1-----1-----1-----1-----		

1655600 2 8  
1655601 -1.000000E+00 -1.000000E+00  
1655602 -2.500000E-01 -9.000000E-01  
1655603 -8.000000E-02 -8.000000E-01  
1655604 0.000000E+00 -6.700000E-01  
\*-----\$-----\$-----\$-----\$-----\$-----\$-----\$-----\$-----\$-----\$-----\$  
\*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----  
\* PRIMARY COOLANT PUMP SPEED CONTROLLERS  
\*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----  
\* CALCULATE MASS FLOW ERROR  
\*-----1-----1-----1-----  
20590100 MSSERR SUM 1.0 0.0 1  
20590101 308.20 -1.0 MFLOWJ 100010000 \* EJL 89/9/23  
\* SP XXXXXX  
\* SP - HOT LEG MASS FLOW SETPOINT  
\*-----1-----1-----1-----  
\* PUMP 1 SPEED  
\*-----1-----1-----1-----  
20590200 PCP1SPD INTEGRAL 0.34482 321.95 1  
20590201 CNTRLVAR 901  
\*-----1-----1-----1-----  
\* PCP1 PUMP VELOCITY TABLE  
\*-----1-----1-----1-----  
1356100 501 CNTRLVAR 902  
1356101 0.0 0.0  
1356102 369.0 369.0  
\*-----1-----1-----1-----  
\* MODIFY PCP1 PUMP DATA  
\*-----1-----1-----1-----  
1350301 0 0 0 -1 0 695 0  
\*-----1-----1-----1-----  
\* PUMP 2 SPEED  
\*-----1-----1-----1-----  
20590300 PCP2SPD INTEGRAL 0.34482 328.74 1  
20590301 CNTRLVAR 901  
\*-----1-----1-----1-----  
\* PCP2 PUMP VELOCITY TABLE  
\*-----1-----1-----1-----  
1656100 501 CNTRLVAR 903  
1656101 0.0 0.0  
1656102 369.0 369.0  
\*-----1-----1-----1-----  
\* MODIFY PCP2 PUMP DATA  
\*-----1-----1-----1-----  
1650301 0 0 0 -1 0 697 0  
\*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----  
\* PRESSURIZER SPRAY VALVE CONTROLLER  
\*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----  
\* SPRAY VALVE  
\*-----1-----1-----1-----  
4350000 "SPRVLV " VALVE  
4350101 430010000 415010000 3.3451E-4 1.5432E01 1.5432E01 0100  
4350201 0 .0000000 .0000000 0.0  
4350300 SRVVLV  
4350301 904 999

\*-----1-----1-----1-----  
 \* SPRAY VALVE POSITION CALCULATOR  
 \*-----1-----1-----1-----  
 20590400 SPRAY SUM -1.0 0.0 1 \* CONTIN  
 + 3 0.0 1.0  
 20590401 14.90+6 -1.0 P 420010000  
 \* SP XXXXXX  
 \* SP - TOP END OF PRESSURE CONTROL BAND ; SPRAY TURNS ON  
 \*-----1-----1-----1-----  
 \* POSITION VS AREA TABLE  
 \*-----1-----1-----1-----  
 20299900 NORMAREA  
 20299901 0.0 0.0  
 20299902 0.0001 0.0  
 20299903 1.0 1.0  
 \*-----1-----1-----1-----1-----1-----1-----1-----  
 \* PRESSURIZER HEATERS IN INITIALIZATION  
 \*-----1-----1-----1-----1-----1-----1-----  
 \* TRIP SETPOINTS  
 \*-----1-----1-----1-----  
 \* LT 693 CYCLING HEATERS CARD 20241700  
 0000585 P 100010000 GT NULL 0 14.85+6 N  
 \* SP XXXXXX  
 \* SP - BOTTOM END OF PRESSURE CONTROL BAND ; HEATERS TURN OFF  
 0000586 P 100010000 LT NULL 0 14.8499+6 N  
 \* SP XXXXXXXX  
 \* SP - (BOTTOM END . . .) - DELTA ; HEATERS TURN ON  
 0000666 586 OR 693 N  
 0000667 -585 AND 666 N  
 0000693 -503 AND 667 N  
 \*-----1-----1-----1-----  
 \* LT 694 BACKUP HEATERS CARD 20241800  
 0000587 P 420010000 GT NULL 0 14.85+6 N  
 \* SP XXXXXX  
 \* SP - BACKUP HEATERS TURN OFF  
 0000588 P 420010000 LT NULL 0 14.84+6 N  
 \* SP XXXXXX  
 \* SP - BACKUP HEATERS TURN ON  
 0000668 588 OR 694 N  
 0000669 -587 AND 668 N  
 0000694 -503 AND 669 N  
 \*-----1-----1-----1-----  
 \* PRESSURIZER HEATERS  
 \*-----1-----1-----1-----  
 14172000 2 9 2 1 0.0  
 14172100 0 1  
 14172101 8 8.3820E-3  
 14172201 4 8  
 14172301 1.0 8  
 14172401 615. 9  
 14172501 0 0 0 1 5.4864 1  
 14172502 0 0 0 1 1.8288 2  
 14172601 415040000 0 1 1 5.4864 1  
 14172602 415040000 0 1 1 1.8288 2  
 14172701 417 1.0 0.0 0.0 1 \* CYCLING  
 14172702 418 1.0 0.0 0.0 2 \* BACKUP  
 14172901 0 1.6764E-2 1.6764E-2 5.4864 1  
 14172902 0 1.6764E-2 1.6764E-2 1.8288 2

\*-----1-----1-----1-----  
 \* PRESSURIZER CYCLING HEATERS  
 \*-----1-----1-----1-----  
 20241700 POWER 693  
 20241701 -1.0 0.0  
 20241702 0.0 0.0  
 20241703 1.0 3.6+4  
 \*-----1-----1-----1-----  
 \* PRESSURIZER BACKUP HEATERS  
 \*-----1-----1-----1-----  
 20241800 POWER 694  
 20241801 -1.0 0.0  
 20241802 0.0 0.0  
 20241803 1.0 3.6+4  
 \*-----1-----1-----1-----1-----1-----1-----1-----  
 \* PRESSURIZER LEVEL CONTROL USING CHARGING AND LETDOWN COMPONENTS  
 \*-----1-----1-----1-----1-----1-----1-----1-----  
 \* MODIFY PZR LEVEL CONTROL VARIABLE  
 \*-----1-----1-----1-----  
 20500206 0.1249 VOIDF 415060000  
 20500207 0.02477 VOIDF 420010000  
 20500208 0.02447 VOIDF 420020000  
 \*-----1-----1-----1-----  
 \* CHARGING RESERVIOR  
 \*-----1-----1-----1-----  
 9800000 "CHRG RESRV" TMDPVOL  
 9800101 1.0 1.0 0.0 0.0 0.0 0.0  
 9800102 4.0-5 0.0 00  
 9800200 3  
 9800201 0.0 2.07+07 559.2  
 \*-----1-----1-----1-----  
 \* CHARGING VALVE  
 \*-----1-----1-----1-----  
 9850000 "CHRG VALVE" VALVE  
 9850101 980000000 185000000 3.8E-05 0.0 0.0 0100  
 9850201 0 .00000000 .00000000 0.0  
 9850300 SRVVLV  
 9850301 905 999  
 \*-----1-----1-----1-----  
 \* CHARGING VALVE POSITION CALCULATOR  
 \*-----1-----1-----1-----  
 20590500 CHARGE SUM 7.7 0.0 1 \*CONTIN  
 + 3 0.0 1.0  
 20590501 1.09 -1.0 CNTRLVAR 2  
 \* SP XXXXX  
 \* SP - BOTTOM END OF LEVEL CONTROL BAND : CHARGING TURNS ON  
 \*-----1-----1-----1-----  
 \* LETDOWN SINK  
 \*-----1-----1-----1-----  
 9900000 "LTDWN SINK" TMDPVOL  
 9900101 1.0 1.0 0.0 0.0 0.0 0.0  
 9900102 4.0-5 0.0 00  
 9900200 3  
 9900201 0.0 1.4+7 559.2  
 \*-----1-----1-----1-----  
 \* LETDOWN VALVE  
 \*-----1-----1-----1-----  
 9950000 "LTDWN VLV " VALVE

9950101	185000000	990000000	2.5-5	0.0	0.0	0100
9950201	0	.00000000	.00000000	0.0		
9950300	SRVVLV					
9950301	906	999				
*-----1-----1-----1-----						
* LETDOWN VALVE POSITION CALCULATOR						
*-----1-----1-----1-----						
20590600	LETDOWN	SUM	-7.7	0.0	1	*CONTIN
+	3	0.0	1.0			
20590601	1.11	-1.0	CNTRLVAR	2		
* SP	XXXXX					
* SP - TOP END OF LEVEL CONTROL BAND : LETDOWN TURNS ON						
*-----1-----1-----1-----1-----1-----1-----						
* STEAM VALVE CONTROLLER						
*-----1-----1-----1-----1-----1-----1-----						
* CHANGES TO STEAM VALVE						
*-----1-----1-----1-----						
5400201	0	16.946000	20.832000	0.0		
5400300	SRVVLV					
5400301	910	540				
20254000	NORMAREA					
20254001	0.0	0.0				
20254002	0.0001	0.0				
20254003	1.0	1.0				
*-----1-----1-----1-----						
* COMPUTE DELTA T ERROR						
*-----1-----1-----1-----						
20590700	"DELTA T"	SUM	1.0	0.0	1	
20590701	552.30	-1.	TEMPPF	185010000		
* SP	XXXXXX					
* SP - COLD LEG TEMPERATURE SETPOINT						
*-----1-----1-----1-----						
* FILTER DELTA T THRU DEADBAND						
*-----1-----1-----1-----						
20590800	DEADBAND	FUNCTION	1.0	0.0	1	
20590801	CNTRLVAR	907	908			
20290800	REAC-T					
20290801	-100.	-100.				
20290802	-0.25	-0.25				
20290803	-0.25	0.0				
20290804	0.25	0.0				
20290805	0.25	0.25				
20290806	100.	100.				
*-----1-----1-----1-----						
* INTEGRATE DELTA T ERROR						
*-----1-----1-----1-----						
20590900	"INT D T"	INTEGRAL	1.0	0.0	1	
20590901	CNTRLVAR	908				
*-----1-----1-----1-----						
* STEAM VALVE POSITION CALCULATOR						
*-----1-----1-----1-----						
20591000	TCONTROL	SUM	1.0	0.645229	0	*CONTI
+	3	0.6	0.90			
* SP	XXXXXXX					
* SP - STEAM VALVE INITIAL POSITION						
20591001	0.645229	-0.07126	CNTRLVAR	908		
* SP	XXXXXXX					
* SP - STEAM VALVE INITIAL POSITION						

```

20591002      -0.01492  CNTRLVAR 909
*-----1-----1-----1-----1-----1-----1-----1-----
* SIMPLIFIED FEED SYSTEM CONTROLLER
*-----1-----1-----1-----1-----1-----1-----1-----
20591100  SGLVLERR  SUM     1.0    0.0      1
20591101  3.20     -1.0    CNTRLVAR  001
* SP      XXXXXX
* SP - STEAM GENERATOR LEVEL SETPOINT
20591200  FEEDFLOW  SUM     1.0    0.0      1
20591201  0.0       1.0    MFLOWJ   540000000
20591202           48.4    CNTRLVAR  911
*-----1-----1-----1-----1-----
* REPLACE FEED JUNCTION TABLE
*-----1-----1-----1-----1-----
5660200  1         0    CNTRLVAR  912
5660201 -100.0    25.553   0.0    0.0
* SP      XXXXXX
* SP - INITIAL FEED FLOW RATE
5660202 -1.0      0.0    0.0    0.0
5660203 0.0       0.0    0.0    0.0
5660204 50.0      50.0   0.0    0.0
5660205
5660206
5660207
5660208
5660209
*-----1-----1-----1-----1-----1-----1-----1-----
* CONSTANT REACTOR POWER TABLE
*-----1-----1-----1-----1-----1-----1-----1-----
20290000  POWER
20290001  0.0      45.9+6
20290002  100.     45.9+6
20290003  200.     45.9+6
20290004  1.E+3    45.9+6
20290005
20290006
20290007
20290008
20290009
20290010
20290011
20290012
20290013
20290014
20290015
20290016
20290017
20290018
20290019
20290020
*-----1-----1-----1-----1-----1-----1-----1-----
* REPLACE TRIPS FOR STEADY STATE
*-----1-----1-----1-----1-----1-----1-----1-----
* SCRAM
0000510  TIME      0      GE    NULL      0      1.+9    L
* BREAK OPENS
0000511  TIME      0      GE    NULL      0      1.+9    L
* HPIIS ON

```



```
/JOB  
L51T12,T6000.  
/USER  
ATTACH,RE364BX.  
ATTACH,STH2XT.  
*PURGE,L51TRP1/NA.  
*DEFINE,RSTPLT=L51TRP1.  
PURGE,L51PF12/NA.  
DEFINE,PLOTFL=L51PF12.  
ATTACH,RSTIN=L5SRP12.  
FILE,RSTIN,SBF=NO.  
FILE,RSTPLT,SBF=NO.  
RFL,CM=350000,EC=200.  
REDUCE(-)  
RE364BX,,*PL=50000.  
/EOR  
= LOFT L5-1 ASSESSMENT CALCULATION (1-FLOW AND 2-PIN MODEL)  
0000100 RESTART TRANSNT  
0000101 RUN  
0000103 1845 * 89/11/10  
0000105 5.0 10.0  
0000201 10.0 1.0-6 0.02 3 5 2500 1000  
0000202 300.0 1.0-6 0.05 3 20 2000 1000  
*****  
* REMOVE S. S. PUMP SPEED CONTROLLERS  
*****  
20590100 MSSERR DELETE 0.0 0.0 0.0 0.0 0.0 0.0  
20590200 PCP1SPD DELETE 0.0 0.0 0.0 0.0 0.0 0.0  
20590300 PCP2SPD DELETE 0.0 0.0 0.0 0.0 0.0 0.0  
*****  
* CV 51 FOR INTEGRATED BREAK FLOW  
****  
20505100 INTBFLW INTEGRAL 1.0 0.0 0  
20505101 MFLOWJ 365000000  
*****  
* RENODALIZE PUMP1  
*****  
1350000 "PCPUMP1 " PUMP  
1350101 0.0 0.4572 0.0991 0.0 90.0 0.317900  
1350102 0  
1350108 130010000 0.0 0.017 0.017 0000  
1350109 140000000 0.0 0.05 0.05 0000  
1350200 0 1.48280+7 1.22765+6 2.46363+6 0.  
1350201 0 8.5604 8.5604 0.0  
1350202 0 9.0732 9.0732 0.0  
1350301 0 0 0 -1 -1 695 0  
1350302 369.00000 .91140921 .31550000 96.000000 500.60000 1.4310000  
1350303 613.6 0.0 207.433 .0444 19.5987 0.0  
1350308 0.212845 0.0 -22.86511 27.16043 5.74589  
1350310 0.0 0.0 0.0  
*****  
* PUMP DATA  
*  
*****  
* SINGLE PHASE HEAD CURVES
```

\*---- 1----1----1----1----1----1----1----1----1----1----1----  
 \* HEAD CURVE NO. 1  
 \*---- 1----1----1----1----1----1----1----1----1----1----  
 1351100 1 1  
 1351101 0.000000E+00 1.403600E+00  
 1351102 1.906100E-01 1.363600E+00  
 1351103 3.896300E-01 1.318600E+00  
 1351104 5.939600E-01 1.232800E+00  
 1351105 7.902000E-01 1.133600E+00  
 1351106 1.000000E+00 1.000000E+00  
 \*---- 1----1----1----1----1----1----1----1----1----1----  
 \* HEAD CURVE NO. 2  
 \*---- 1----1----1----1----1----1----1----1----1----1----  
 1351200 1 2  
 1351201 0.000000E+00 -6.700000E-01  
 1351202 2.000000E-01 -5.000000E-01  
 1351203 4.000000E-01 -2.500000E-01  
 1351204 5.755400E-01 0.000000E+00  
 1351205 7.443200E-01 2.583000E-01  
 1351206 7.734800E-01 3.778000E-01  
 1351207 8.631300E-01 6.326000E-01  
 1351208 1.000000E+00 1.000000E+00  
 \*---- 1----1----1----1----1----1----1----1----1----1----  
 \* HEAD CURVE NO. 3  
 \*---- 1----1----1----1----1----1----1----1----1----1----  
 1351300 1 3  
 1351301 -1.000000E+00 2.472200E+00  
 1351302 -8.057400E-01 2.047400E+00  
 1351303 -6.069000E-01 1.831000E+00  
 1351304 -4.068300E-01 1.624000E+00  
 1351305 -2.001710E-01 1.470500E+00  
 1351306 0.000000E+00 1.403600E+00  
 \*---- 1----1----1----1----1----1----1----1----1----1----  
 \* HEAD CURVE NO. 4  
 \*---- 1----1----1----1----1----1----1----1----1----1----  
 1351400 1 4  
 1351401 -1.000000E+00 2.472200E+00  
 1351402 -8.229700E-01 1.996800E+00  
 1351403 -6.333200E-01 1.589700E+00  
 1351404 -4.553400E-01 1.327900E+00  
 1351405 -2.710900E-01 1.194900E+00  
 1351406 -1.771600E-01 1.060500E+00  
 1351407 -9.073000E-02 1.015600E+00  
 1351408 0.000000E+00 9.342790E-01  
 \*---- 1----1----1----1----1----1----1----1----1----1----  
 \* HEAD CURVE NO. 5  
 \*---- 1----1----1----1----1----1----1----1----1----1----  
 1351500 1 5  
 1351501 0.000000E+00 2.500000E-01  
 1351502 2.000000E-01 2.800000E-01  
 1351503 4.000000E-01 3.400000E-01  
 1351504 4.118000E-01 2.768000E-01  
 1351505 5.976300E-01 4.584000E-01  
 1351506 7.934670E-01 6.992000E-01  
 1351507 1.000000E+00 1.000000E+00  
 \*---- 1----1----1----1----1----1----1----1----1----1----  
 \* HEAD CURVE NO. 6  
 \*---- 1----1----1----1----1----1----1----1----1----1----

1351600	1	6
1351601	0.000000E+00	9.342790E-01
1351602	9.109900E-02	9.229000E-01
1351603	1.865090E-01	8.963000E-01
1351604	2.717620E-01	8.750000E-01
1351605	4.558720E-01	8.433000E-01
1351606	5.744060E-01	8.355000E-01
1351607	7.405760E-01	8.466000E-01
1351608	7.666190E-01	8.469000E-01
1351609	8.714710E-01	8.838000E-01
1351610	1.000000E+00	1.000000E+00
*	-1-----1-----1-----1-----1-----1-----1-----1-----	
* HEAD CURVE NO. 7		
*	-1-----1-----1-----1-----1-----1-----1-----1-----	
1351700	1	7
1351701	-1.000000E+00	-1.000000E+00
1351702	-8.000000E-01	-6.300000E-01
1351703	-6.000000E-01	-3.000000E-01
1351704	-4.000000E-01	-5.000000E-02
1351705	-2.000000E-01	1.500000E-01
1351706	0.000000E+00	2.500000E-01
*	-1-----1-----1-----1-----1-----1-----1-----1-----	
* HEAD CURVE NO. 8		
*	-1-----1-----1-----1-----1-----1-----1-----1-----	
1351800	1	8
1351801	-1.000000E+00	-1.000000E+00
1351802	-8.000000E-01	-9.700000E-01
1351803	-6.000000E-01	-9.500000E-01
1351804	-4.000000E-01	-8.800000E-01
1351805	-2.000000E-01	-8.000000E-01
1351806	0.000000E+00	-6.700000E-01
*	-1-----1-----1-----1-----1-----1-----1-----1-----	
* SINGLE PHASE TORQUE DATA		
*	-1-----1-----1-----1-----1-----1-----1-----1-----	
* TORQUE CURVE NO. 1		
*	-1-----1-----1-----1-----1-----1-----1-----1-----	
1351900	2	1
1351901	0.000000E+00	6.032000E-01
1351902	1.930000E-01	6.325000E-01
1351903	3.930000E-01	7.369000E-01
1351904	5.955200E-01	8.331000E-01
1351905	7.978200E-01	9.229000E-01
1351906	1.000000E+00	1.000000E+00
*	-1-----1-----1-----1-----1-----1-----1-----1-----	
* TORQUE CURVE NO. 2		
*	-1-----1-----1-----1-----1-----1-----1-----1-----	
1352000	2	2
1352001	0.000000E+00	-6.700000E-01
1352002	4.000000E-01	-2.500000E-01
1352003	5.000000E-01	1.500000E-01
1352004	7.372550E-01	5.265860E-01
1352005	7.680490E-01	6.065940E-01
1352006	8.672300E-01	7.436600E-01
1352007	1.000000E+00	1.000000E+00
*	-1-----1-----1-----1-----1-----1-----1-----1-----	
* TORQUE CURVE NO. 3		
*	-1-----1-----1-----1-----1-----1-----1-----1-----	
1352100	2	3

1352101	-1.000000E+00	1.984300E+00
1352102	-8.009600E-01	1.394000E+00
1352103	-6.063800E-01	1.097500E+00
1352104	-4.068600E-01	8.220000E-01
1352105	-1.992800E-01	6.648000E-01
1352106	0.000000E+00	6.032000E-01
*	-----1-----	-----1-----1-----1-----1-----
* TORQUE CURVE NO. 4		
*	-----1-----1-----	-----1-----1-----1-----1-----
1352200	2	4
1352201	-1.000000E+00	1.984300E+00
1352202	-8.223400E-01	1.830800E+00
1352203	-6.337100E-01	1.682400E+00
1352204	-4.585300E-01	1.557000E+00
1352205	-2.670230E-01	1.436200E+00
1352206	-1.761070E-01	1.387900E+00
1352207	-8.931000E-02	1.348100E+00
1352208	0.000000E+00	1.233610E+00
*	-----1-----1-----	-----1-----1-----1-----1-----
* TORQUE CURVE NO. 5		
*	-----1-----1-----	-----1-----1-----1-----1-----
1352300	2	5
1352301	0.000000E+00	-4.500000E-01
1352302	4.000000E-01	-2.500000E-01
1352303	5.000000E-01	0.000000E+00
1352304	1.000000E+00	3.569000E-01
*	-----1-----1-----	-----1-----1-----1-----1-----
* TORQUE CURVE NO. 6		
*	-----1-----1-----	-----1-----1-----1-----1-----
1352400	2	6
1352401	0.000000E+00	1.233610E+00
1352402	9.064300E-02	1.196500E+00
1352403	1.885690E-01	1.109600E+00
1352404	2.734700E-01	1.041600E+00
1352405	4.586690E-01	8.958000E-01
1352406	5.744800E-01	7.807000E-01
1352407	7.381600E-01	6.134000E-01
1352408	7.685200E-01	5.849000E-01
1352409	8.700570E-01	4.877000E-01
1352410	1.000000E+00	3.569000E-01
*	-----1-----1-----	-----1-----1-----1-----1-----
* TORQUE CURVE NO. 7		
*	-----1-----1-----	-----1-----1-----1-----1-----
1352500	2	7
1352501	-1.000000E+00	-1.000000E+00
1352502	-3.000000E-01	-9.000000E-01
1352503	-1.000000E-01	-5.000000E-01
1352504	0.000000E+00	-4.500000E-01
*	-----1-----1-----	-----1-----1-----1-----1-----
* TORQUE CURVE NO. 8		
*	-----1-----1-----	-----1-----1-----1-----1-----
1352600	2	8
1352601	-1.000000E+00	-1.000000E+00
1352602	-2.500000E-01	-9.000000E-01
1352603	-8.000000E-02	-8.000000E-01
1352604	0.000000E+00	-6.700000E-01
*	-----1-----1-----	-----1-----1-----1-----1-----
* TWO - PHASE MULTIPLIER DATA FROM L3-6 TEST DATA		



1354309	-1.000000E-01	-5.000000E-01
1354310	0.000000E+00	0.000000E+00
*	-----1-----	-----1-----1-----
* HEAD CURVE NO. 4		
*	-----1-----1-----	-----1-----1-----1-----
1354400	1	4
1354401	-1.000000E+00	-1.160000E+00
1354402	-9.000000E-01	-7.800000E-01
1354403	-8.000000E-01	-5.000000E-01
1354404	-7.000000E-01	-3.100000E-01
1354405	-6.000000E-01	-1.700000E-01
1354406	-5.000000E-01	-8.000000E-02
1354407	-3.500000E-01	0.000000E+00
1354408	-2.000000E-01	5.000000E-02
1354409	-1.000000E-01	8.000000E-02
1354410	0.000000E+00	1.100000E-01
*	-----1-----1-----	-----1-----1-----1-----
* HEAD CURVE NO. 5		
*	-----1-----1-----	-----1-----1-----1-----
1354500	1	5
1354501	0.000000E+00	0.000000E+00
1354502	2.000000E-01	-3.400000E-01
1354503	4.000000E-01	-6.500000E-01
1354504	6.000000E-01	-9.300000E-01
1354505	8.000000E-01	-1.190000E+00
1354506	1.000000E+00	-1.470000E+00
*	-----1-----1-----	-----1-----1-----1-----
* HEAD CURVE NO. 6		
*	-----1-----1-----	-----1-----1-----1-----
1354600	1	6
1354601	0.000000E+00	1.100000E-01
1354602	1.000000E-01	1.300000E-01
1354603	2.500000E-01	1.500000E-01
1354604	4.000000E-01	1.300000E-01
1354605	5.000000E-01	7.000000E-02
1354606	6.000000E-01	-4.000000E-02
1354607	7.000000E-01	-2.300000E-01
1354608	8.000000E-01	-5.100000E-01
1354609	9.000000E-01	-9.100000E-01
1354610	1.000000E+00	-1.470000E+00
*	-----1-----1-----	-----1-----1-----1-----
* HEAD CURVE NO. 7		
*	-----1-----1-----	-----1-----1-----1-----
1354700	1	7
1354701	-1.000000E+00	0.000000E+00
1354702	0.000000E+00	0.000000E+00
*	-----1-----1-----	-----1-----1-----1-----
* HEAD CURVE NO. 8		
*	-----1-----1-----	-----1-----1-----1-----
1354800	1	8
1354801	-1.000000E+00	0.000000E+00
1354802	0.000000E+00	0.000000E+00
*	-----1-----1-----	-----1-----1-----1-----
* TORQUE CURVE NO. 1		
*	-----1-----1-----	-----1-----1-----1-----
1354900	2	1
1354901	0.000000E+00	1.000000E+00
1354906	1.000000E+00	1.000000E+00

*-----	1	-----	1	-----	1	-----	1	-----	1	-----
* TORQUE CURVE NO. 2										
*-----	1	-----	1	-----	1	-----	1	-----	1	-----
1355000	2		2							
1355001	0.000000E+00		1.000000E+00							
1355007	1.000000E+00		1.000000E+00							
*-----	1	-----	1	-----	1	-----	1	-----	1	-----
* TORQUE CURVE NO. 3										
*-----	1	-----	1	-----	1	-----	1	-----	1	-----
1355100	2		3							
1355101	-1.000000E+00		1.984300E+00							
1355102	-8.009600E-01		1.394000E+00							
1355103	-6.063800E-01		1.097500E+00							
1355104	-4.068600E-01		8.220000E-01							
1355105	-1.992800E-01		6.648000E-01							
1355106	0.000000E+00		6.032000E-01							
*-----	1	-----	1	-----	1	-----	1	-----	1	-----
* TORQUE CURVE NO. 4										
*-----	1	-----	1	-----	1	-----	1	-----	1	-----
1355200	2		4							
1355201	-1.000000E+00		1.984300E+00							
1355202	-8.223400E-01		1.830800E+00							
1355203	-6.337100E-01		1.682400E+00							
1355204	-4.585300E-01		1.557000E+00							
1355205	-2.670230E-01		1.436200E+00							
1355206	-1.761070E-01		1.387900E+00							
1355207	-8.931000E-02		1.348100E+00							
1355208	0.000000E+00		1.233610E+00							
*-----	1	-----	1	-----	1	-----	1	-----	1	-----
* TORQUE CURVE NO. 5										
*-----	1	-----	1	-----	1	-----	1	-----	1	-----
1355300	2		5							
1355301	0.000000E+00		-4.500000E-01							
1355302	4.000000E-01		-2.500000E-01							
1355303	5.000000E-01		0.000000E+00							
1355304	1.000000E+00		3.569000E-01							
*-----	1	-----	1	-----	1	-----	1	-----	1	-----
* TORQUE CURVE NO. 6										
*-----	1	-----	1	-----	1	-----	1	-----	1	-----
1355400	2		6							
1355401	0.000000E+00		1.233610E+00							
1355402	9.064300E-02		1.196500E+00							
1355403	1.885690E-01		1.109600E+00							
1355404	2.734700E-01		1.041600E+00							
1355405	4.586690E-01		8.958000E-01							
1355406	5.744800E-01		7.807000E-01							
1355407	7.381600E-01		6.134000E-01							
1355408	7.685200E-01		5.849000E-01							
1355409	8.700570E-01		4.877000E-01							
1355410	1.000000E+00		3.569000E-01							
*-----	1	-----	1	-----	1	-----	1	-----	1	-----
* TORQUE CURVE NO. 7										
*-----	1	-----	1	-----	1	-----	1	-----	1	-----
1355500	2		7							
1355501	-1.000000E+00		-1.000000E+00							
1355502	-3.000000E-01		-9.000000E-01							
1355503	-1.000000E-01		-5.000000E-01							
1355504	0.000000E+00		-4.500000E-01							

```

*-----1-----1-----1-----1-----1-----1-----1-----1-----
* TORQUE CURVE NO. 8
*-----1-----1-----1-----1-----1-----1-----1-----
1355600 2 8
1355601 -1.000000E+00 -1.000000E+00
1355602 -2.500000E-01 -9.000000E-01
1355603 -8.000000E-02 -8.000000E-01
1355604 0.000000E+00 -6.700000E-01
*-----1-----1-----1-----1-----1-----1-----1-----
* RENODALIZE PUMP 2
*-----1-----1-----1-----1-----1-----1-----1-----
1650000 "PCPUMP2 " PUMP
1650101 0.0 0.514 0.0991 0.0 90.0 0.317900
1650102 0
1650108 160010000 0.0 0.017 0.017 0000
1650109 170000000 0.0 0.1 0.1 0000
1650200 0 1.48858+7 1.22768+6 2.46241+6 0.
1650201 0 7.7855 7.7855 0.0
1650202 0 8.0481 8.0481 0.0
1650301 135 135 135 -1 -1 697 0
1650302 369.00000 .92981030 .31550000 96.000000 500.60000 1.4310000
1650303 613.60000 .00000000 207.43300 .04440000 19.598700 .00000000
1650308 0.212845 0.0 -22.86511 27.16043 5.74589
1650310 0.0 0.0 0.0
*-----1-----1-----1-----1-----1-----1-----1-----
* REMOVE SPRAY VALVE AND CALCULATOR
*-----1-----1-----1-----1-----1-----1-----1-----
4350000 SPRVLV DELETE
20590400 SPRAY DELETE 0.0 0.0 0.0 0.0 0.0 0.0
*-----1-----1-----1-----1-----1-----1-----1-----
* REMOVE PRESSURIZER TRIPS AND HEATERS
*-----1-----1-----1-----1-----1-----1-----1-----
0000585 DISCARD
0000586 DISCARD
0000666 510 DISCARD
0000667 510 DISCARD
0000693 510 DISCARD
0000587 DISCARD
0000588 DISCARD
0000668 510 DISCARD
0000669 510 DISCARD
0000694 510 DISCARD
14172000 DELETE
20241700 DELETE
20241800 DELETE
*-----1-----1-----1-----1-----1-----1-----1-----
* REMOVE PRESSURIZER LEVEL CONTROLLERS, CHARGING COMPONENT, AND
* LETDOWN COMPONENT
*-----1-----1-----1-----1-----1-----1-----1-----
20500200 PZRLVL SUM 1.0 0.0 1
20500201 0.0 0.1815 VOIDF 415010000
20500202 0.1524 VOIDF 415020000
20500203 0.3967 VOIDF 415030000
20500204 0.5289 VOIDF 415040000
20500205 0.3967 VOIDF 415050000
20500206 0.1943 VOIDF 415060000
20500207 0.1029 VOIDF 420010000
20500208 0.1029 VOIDF 420020000

```

9800000	"CHRG R"	DELETE									
9850000	"CHRG V"	DELETE									
20590500	CHARGE	DELETE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
9900000	"LTDWN S"	DELETE									
9950000	"LTDWN V"	DELETE									
20590600	LETDOWN	DELETE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
*-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----
* REMOVE STEAM VALVE CONTROLLER											
*-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----
5400000	"CV-P4-10 "	VALVE									
5400101	530010000	541000000	0.0047772	0.0		0.0		1100			
5400201	0	16.963	20.945	0.0							
5400300	MTRVLV										
5400301	685	686	0.05	.649345	540						
20254000	NORMAREA										
20254001	0.0	7.066-3									
20254002	7.066-3	7.066-3									
20254003	1.0	1.0									
20590700	"DELTA T"	DELETE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
20590800	DEADBAND	DELETE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
20590900	"INT D T"	DELETE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
20591000	TCONTROL	DELETE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
20290800	DELETE										
*-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----
* REMOVE FEED SYSTEM CONTROLLER											
*-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----
20591100	SGLVLERR	DELETE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
20591200	FEEDFLOW	DELETE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
5660000	"FEED "	TMDPJUN									
5660101	565000000	508000000	0.05								
5660200	1	688									
5660201	0.0	25.593	0.0	0.0							
5660202	0.7	0.0	0.0	0.0							
5660203	59.5	0.0	0.0	0.0							
5660204	60.0	0.50364	0.0	0.0							
5660205	1860.0	0.50364	0.0	0.0							
5660206	1861.0	0.0	0.0	0.0							
*-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----
* REPLACE REACTOR POWER TABLE											
*-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----
20290000	POWER	699	1.0	45.9+6							
20290001	0.0	1.0		* FROM F3S-20&F2-2 OF EDR L5-1	89/11/09						
20290002	0.50	0.55374									
20290003	1.00	0.18625									
20290004	1.50	0.10259									
20290005	2.00	0.08423									
20290006	2.50	0.080020									
20290007	3.0	0.07603									
20290008	3.5	0.072700									
20290009	5.0	0.064940									
20290010	10.0	0.055882									
20290011	25.0	0.046738									
20290012	65.	0.035									
20290013	100.	0.031546									
20290014	250.	0.025210									
20290015	650.	0.0188									
20290016	1000.	0.0164									
20290017	1500.	0.0140									

20290018 3000. 0.0110  
 20290019 5000. 0.0092  
 20290020 1.+5 0.001460 \* CHANGED 89/11/06 BASED ON EDR F2-2 F3S-20  
 \*-----1-----1-----1-----1-----1-----1-----1-----1-----  
 \*-----1-----1-----1-----1-----1-----1-----1-----1-----  
 \* REPLACE TRIPS 510,511,513  
 \*-----1-----1-----1-----1-----1-----1-----1-----1-----  
 \* SCRAM  
 0000510 P 100010000 LT NULL 0 1.4190+7 L  
 \* BREAK ISOLATION  
 0000511 TIME 0 LT NULL 0 7302. N  
 \* HPI'S ON  
 0000513 P 100010000 LE NULL 0 10.600+6 L  
 \*-----1-----1-----1-----1-----1-----1-----1-----1-----  
 \*  
 \* RENODALIZE DEAD END OF FUEL MODULES AND BROKEN LOOP  
 \*-----1-----1-----1-----1-----1-----1-----1-----1-----  
 \* DEAD END OF FUEL MODULES  
 \*-----1-----1-----1-----1-----1-----1-----1-----1-----  
 2510000 "DE FL MODS" SNGLVOL  
 2510101 0.0 0.7844123 0.1154214 0.0 90.0 0.7844123  
 2510102 3.81-6 0.214 00  
 2510200 0 1.49207+7 1.33213+6 2.46168+6 0.0  
 \*-----1-----1-----1-----1-----1-----1-----1-----1-----  
 \* REACTOR VESSEL NOZZLE - BROKEN LOOP HOT LEG  
 \*-----1-----1-----1-----1-----1-----1-----1-----1-----  
 3000000 "RVN BLHL " BRANCH  
 3000001 2 0  
 3000101 0.0 0.876303 0.0575410 0.0 0.0 0.0  
 3000102 4.0E-5 0.0 00  
 3000200 0 1.49144+7 1.25750+6 2.46181+6 0.0  
 3001101 252010000 300000000 0.067014 0.0 0.0 0002  
 3002101 300010000 305000000 0.063426 0.1 0.1 0000  
 3001201 0.0 0.0 0.0  
 3002201 0.0 0.0 0.0  
 \*-----1-----1-----1-----1-----1-----1-----1-----1-----  
 \* HOT LEG PIPE TO REFLOOD ASSIST BYPASS TEE  
 \*-----1-----1-----1-----1-----1-----1-----1-----1-----  
 3050000 "HLP-RABS T" BRANCH  
 3050001 1 0  
 3050101 0.0 0.698336 0.0442927 0.0 0.0 0.0  
 3050102 4.0E-5 0.0 00  
 3050200 0 1.49144+7 1.25750+6 2.46181+6 0.0  
 3051101 305010000 310000000 0.0 0.1 0.1 0100  
 3051201 0.0 0.0 0.0  
 \*-----1-----1-----1-----1-----1-----1-----1-----1-----  
 \* BROKEN LOOP HOT LEG CONTRACTION  
 \*-----1-----1-----1-----1-----1-----1-----1-----1-----  
 3100000 "BLHL CONTR" BRANCH  
 3100001 2 0  
 3100101 0.0 1.50013 0.0678467 0.0 0.0 0.0  
 3100102 4.0E-5 0.0 00  
 3100200 0 1.49144+7 1.25750+6 2.46181+6 0.0  
 3101101 380010000 310000000 0.0388 0.84 0.84 0100  
 3102101 310010000 315000000 0.0083647 0.0 0.0 0100  
 3101201 0.0 0.0 0.0  
 3102201 0.0 0.0 0.0

* STEAM GENERATOR AND PUMP SIMULATION				
	"SG+PMP SIM"	PIPE		
3150000				
3150001	12			
3150101	0.0	12		
3150201	0.0083647	2		
3150202	0.032603	4		
3150203	0.105626	5		
3150204	0.032603	7		
3150205	0.0083647	9		
3150206	0.008364	10		
3150207	0.0046398	11		
3150301	0.367768	1		
3150302	0.552201	2		
3150303	0.993978	4		
3150304	0.849744	6		
3150305	0.993978	8		
3150306	1.371350	9		
3150307	1.365029	10		
3150308	1.674812	11		
3150309	0.545209	12		
3150401	3.0767-3	1		
3150402	4.67621-3	2		
3150403	8.60554-2	4		
3150404	8.97552-2	6		
3150405	8.60554-2	8		
3150406	1.82303-2	9		
3150407	5.46687-2	10		
3150408	1.82489-2	11		
3150409	2.83241-2	12		
3150601	90.0	5		
3150602	-90.0	10		
3150603	90.0	11		
3150604	0.0	12		
3150701	0.127000	1		
3150702	0.552201	2		
3150703	0.993978	4		
3150704	0.457202	5		
3150705	-0.457202	6		
3150706	-0.993978	8		
3150707	-1.371350	9		
3150708	-0.520701	10		
3150709	1.212851	11		
3150710	0.0	12		
3150801	4.0E-5	0.0	3	
3150802	4.0E-5	0.124	4	
3150803	4.0E-5	0.0	6	
3150804	4.0E-5	0.124	7	
3150805	4.0E-5	0.0	12	
3150901	0.2	0.2	1	
3150902	0.0	0.0	2	
3150903	93.9	93.9	4	
3150904	0.4	0.4	5	
3150905	93.9	93.9	7	
3150906	0.0	0.0	8	
3150907	0.2	0.2	9	
3150908	4.1	4.1	10	

3150909	0.4	0.4	11				
3151001	00	12					
3151101	0000	1					
3151102	0100	2					
3151103	0000	7					
3151104	0100	8					
3151105	0000	10					
3151106	0100	11					
3151201	0	14914000.	1257500.	2461820.	0.0	0.0	01
3151202	0	14911400.	1257500.	2461870.	0.0	0.0	02
3151203	0	14905500.	1257500.	2461990.	0.0	0.0	03
3151204	0	14998100.	1257500.	2462150.	0.0	0.0	04
3151205	0	14992600.	1257500.	2462270.	0.0	0.0	05
3151206	0	14992600.	1257500.	2462270.	0.0	0.0	06
3151207	0	14998100.	1257500.	2462150.	0.0	0.0	07
3151208	0	14905500.	1257500.	2461990.	0.0	0.0	08
3151209	0	14914500.	1257500.	2461810.	0.0	0.0	09
3151210	0	14921600.	1257500.	2461660.	0.0	0.0	10
3151211	0	14919000.	1257500.	2461710.	0.0	0.0	11
3151212	0	14914300.	1257500.	2461810.	0.0	0.0	12
3151300	0						
3151301	0.0	0.0	0.0	11			
*-----1-----1-----1-----1-----1-----1-----1-----1-----							
* REACTOR VESSEL NOZZLE - BROKEN LOOP COLD LEG							
*-----1-----1-----1-----1-----1-----1-----1-----1-----							
3350000	"RVN BLCL "	BRANCH					
3350001	2	0					
3350101	0.0	0.749305	0.047979	0.0	0.0	0.0	
3350102	4.0E-5	0.0	00				
3350200	0	1.49889+7	1.23500+6	2.46018+6	0.0		
3351101	202000000	335000000	0.064130	1.0	1.0	0002	
3352101	335010000	340000000	0.0	0.1	0.1	0000	
3351201	0.0	0.0	0.0				
3352201	0.0	0.0	0.0				
*-----1-----1-----1-----1-----1-----1-----1-----1-----							
* COLD LEG PIPE TO REFLOOD ASSIST BYPASS TEE							
*-----1-----1-----1-----1-----1-----1-----1-----1-----							
3400000	"CLP-RABS T"	BRANCH					
3400001	1	0					
3400101	0.0	0.698336	0.0443927	0.0	0.0	0.0	
3400102	4.0E-5	0.0	00				
3400200	0	1.49889+7	1.23500+6	2.46018+6	0.0		
3401101	340010000	345000000	0.0	0.1	0.1	0100	
3401201	0.0	0.0	0.0				
*-----1-----1-----1-----1-----1-----1-----1-----1-----							
* BROKEN LOOP COLD LEG CONTRACTION TO BREAK PLANE							
*-----1-----1-----1-----1-----1-----1-----1-----1-----							
3450000	"BLCL CONTR"	BRANCH					
3450001	2	0					
3450101	0.0634	0.974	0.0	0.0	0.0	0.0	
3450102	4.0E-5	0.0	00				
3450200	0	1.49889+7	1.23500+6	2.46018+6	0.0		
3451101	345000000	370000000	0.0388	0.84	0.84	0100	
3452101	345010000	350000000	0.0	0.0	0.0	0100	
3451201	0.0	0.0	0.0				
3452201	0.0	0.0	0.0				
*-----1-----1-----1-----1-----1-----1-----1-----1-----							
* SPOOL PIECE AND PIPE TO ISOLATION VALVE							

3500000	"BRK SP+PPE"		SNGLVOL				
3500101	0.0525	0.823	0.0	0.0	0.0	0.0	
3500102	4.0E-5	0.0	00				
3500200	0	1.49889+7	1.23500+6	2.46018+6	0.0		
* REMOVE COLD LEG ISOLATION VALVE AND COLD LEG PIPE BETWEEN							
* ISOLATION VALVE AND QOBV							
3550000	"CL ISO VLV"		DELETE				
3600000	"CL IS-QOBV"		DELETE				
* COLD LEG QUICK OPENING BLOWDOWN VALVE							
3650000	"CO QOBV "		VALVE				
3650101	350010000	805000000	1.729E-3	0.0	0.0	0100	1.0 1.0
3650201	0	0.0	0.0	0.0			
3650300	MTRVLV						
3650301	677 502	14.0	0.0				
* REFLOOD ASSIST BYPASS PIPING - COLD LEG SIDE							
3700000	"RABS C L "		PIPE				
3700001	3						
3700101	0.0388	2					
3700102	0.0776	3					
3700201	0.0388	2					
3700301	0.0	3					
3700401	0.0279	1					
3700402	0.070	2					
3700403	0.1165	3					
3700601	90.0	1					
3700602	0.0	3					
3700701	0.64	1					
3700702	0.0	3					
3700801	4.0-5	0.0	3				
3700901	0.28	0.28	1				
3700902	0.84	0.84	2				
3701001	00	3					
3701101	0000	2					
3701201	0	1.49865+7	1.23500+6	2.46023+6	0.0	0.0	01
3701202	0	1.49841+7	1.23500+6	2.46028+6	0.0	0.0	02
3701203	0	1.49841+7	1.23500+6	2.46028+6	0.0	0.0	03
3701300	0						
3701301	0.0	0.0	0.0	01			
3701302	0.0	0.0	0.0	02			
* REFLOOD ASSIST BYPASS VALVES							
3750000	"RABS VALVS"		SNGLJUN				
3750101	370010000	380000000	0.0	1.55+2	1.55+2	0000	
3750201	0	0.0	0.0	0.0			
* REFLOOD ASSIST BYPASS PIPING - HOT LEG SIDE							
3800000	"RABS H L "		PIPE				
3800001	3						
3800101	0.0776	1					



0000329	SATTEMP	415030000	* TE-139-20
0000330	SATTEMP	205010000	* TE-1ST-1 / TE-2ST-1
0000331	SATTEMP	210010000	* TE-1ST-2 / TE-2ST-2
0000332	SATTEMP	210050000	* TE-1ST-6 / TE-2ST-6
0000333	SATTEMP	210060000	* TE-1ST-7 / TE-2ST-7
0000334	SATTEMP	215010000	* TE-1ST-10 / TE-2ST-10
0000335	SATTEMP	220010000	* TE-1ST-13 / TE-2ST-13
0000336	SATTEMP	250010000	* TE-1UP-6
0000337	SATTEMP	251010000	* TE-2UP-4
0000338	SATTEMP	255010000	* TE-1UP-3
-----1-----1-----1-----1-----1-----1-----			
* DENSITIES			
-----1-----1-----1-----1-----1-----1-----			
0000341	RHO	345010000	* DE-BL-1
0000342	RHO	310010000	* DE-BL-2
0000343	RHO	180010000	* DE-PC-1
0000344	RHO	100010000	* DE-PC-2
0000345	RHO	118020000	* DE-PC-3
-----1-----1-----1-----1-----1-----1-----			
* VELOCITIES			
-----1-----1-----1-----1-----1-----1-----			
0000351	VELF	345010000	* FE-BL-1
0000352	MFLOWJ	630000000	* LPISL-2
0000353	VELF	180010000	* FE-PC-1
0000354	VELF	100010000	* FE-PC-2
0000355	VELG	345010000	* FE-BL-1
0000356	VELG	310010000	* FE-BL-2
0000357	VELG	180010000	* FE-PC-1
0000358	VELG	100010000	* FE-PC-2
-----1-----1-----1-----1-----1-----1-----			
* MASS FLOW RATES			
-----1-----1-----1-----1-----1-----1-----			
0000361	MFLOWJ	345020000	* BREAK PLANE BLCL
0000362	MFLOWJ	315110000	* BREAK PLANE BLHL
0000363	MFLOWJ	345020000	* DTT-RAKE BLCL
0000364	MFLOWJ	310020000	* DTT-RAKE BLHL
0000365	MFLOWJ	180010000	* DTT-RAKE ILCL
0000366	MFLOWJ	100020000	* DTT-RAKE ILHL
0000367	MFLOWJ	400010000	* PRES. SURGE LINE FLOW
0000369	MFLOWJ	541010000	* FE-P4-12
0000370	MFLOWJ	566000000	* FE-P4-72-1
0000371	MFLOWJ	230010000	* REFLOODING FLOW
0000372	CNTRLVAR	51	* INT BRK FLOW
0000373	HTTEMP	231000110	
0000374	HTTEMP	231000210	
0000375	HTTEMP	231000310	
0000376	HTTEMP	231000410	
0000377	HTTEMP	231000510	
0000378	HTTEMP	231000610	
-----1-----1-----1-----1-----1-----1-----			
* CLADDING TEMPERATURES CONTROL MODULE			
-----1-----1-----1-----1-----1-----1-----			
0000381	HTTEMP	230000110	*
0000382	HTTEMP	230000210	*
0000383	HTTEMP	230000310	*
0000384	HTTEMP	230000410	*
0000385	HTTEMP	230000510	*
0000386	HTTEMP	230000610	*

```

*-----1-----1-----1-----1-----1-----1-----1-----1-----1-----
* LIQUID FRACTIONS IN THE PRESSURIZER *
*-----1-----1-----1-----1-----1-----1-----1-----1-----
0000391 VOIDF    415010000
0000392 VOIDF    415020000
0000393 VOIDF    415030000
0000394 VOIDF    415040000
0000395 VOIDF    415050000
0000396 VOIDF    415060000
0000397 VOIDF    420010000
0000398 VOIDF    420020000
0000309 CNTRLVAR 4 * ACC LEVEL -.32 M STAND PIPE
0000340 CNTRLVAR 10 * RX LEVEL
0000346 CNTRLVAR 71 * RX WATER INVENTORY
0000347 CNTRLVAR 72 * PRIMARY WATER INVENTORY
0000348 CNTRLVAR 73 * SECONDARY WATER INVENTORY
0000349 CNTRLVAR 81 * TIME STEP SIZE
0000350 MFLOWJ   600000000 * ECC TO CL
0000351 MFLOWJ   610000000 * ACCUMULATOR
0000352 MFLOWJ   640000000 * HPIS
*-----1-----1-----1-----1-----1-----1-----1-----1-----
* ECCS HEADER TO PCS
*-----1-----1-----1-----1-----1-----1-----1-----1-----
6050000 "ECCS HEADR" SNGLVOL
6050101 5.9896-3 5.0148 0.0 0.0 90.0 3.3071202
6050102 4.0-5 0.0 00
6050200 0 13595900. 172410. 2489140. 0.0
*-----1-----1-----1-----1-----1-----1-----1-----
* ACCUMULATOR PIPE
*-----1-----1-----1-----1-----1-----1-----1-----
6150000 "ACC PIPE " SNGLVOL
6150101 0.0 25.997165 0.4074774 0.0 0.0 0.0
6150102 4.0-5 0.0 00
6150200 0 13580200. 112409. 2489450. 0.0
*-----1-----1-----1-----1-----1-----1-----1-----
* PIPING BETWEEN BREAK AND VALVE
*-----1-----1-----1-----1-----1-----1-----1-----
13502000 1 5 2 1 0.0865
13502100 0 1
13502101 4 0.1095
13502201 4 4
13502301 0.0 4
13502401 551.0 5
13502501 350010000 0 1 1 0.823 1
13502601 -939 0 3949 1 0.823 1
13502701 0 0 0 0 1
13502801 0 0 0 0.823 1
*-----1-----1-----1-----1-----1-----1-----1-----
* 069 BROKEN LOOP COLD LEG MASS
*-----1-----1-----1-----1-----1-----1-----1-----
20506900 BLCLMASS SUM 1.0 0.0 1
20506901 0.0 4.79790-2 RHO 335010000
20506902 4.43927-2 RHO 340010000
20506903 6.73163-2 RHO 345010000
20506904 4.32075-2 RHO 350010000
20506905 2.79000-2 RHO 370010000
20506906 7.00000-2 RHO 370020000
20506907 1.16500-1 RHO 370030000

```

\* REACTOR VESSEL LIQUID LEVEL CONTROL VARIABLE

	RVLVL	SUM	0.2794034	0.0	1
20501000	0.0	1.0	VOIDF	230010000	
20501001					
20501002		1.0	VOIDF	230020000	
20501003		1.0	VOIDF	230030000	
20501004		1.0	VOIDF	230040000	
20501005		1.0	VOIDF	230050000	
20501006		1.0	VOIDF	230060000	

\* — —

\*

\* REPLACE HPIS 89.2.13

—

## \* DELAYED HPIS INJECTION

```

0000583    TIME,0    GE    TIMEOF,513    2.48    L   -1.0 * 89/11/08
0000683    583 AND 583 L
6400000 "HP1S"      TMDPJUN
6400101    635000000 185000000 5.9896-3
6400200    1          683        P      185010000 * 89/11/08
6400201    -1.0       0.0        0.0    0.0
6400202    0.0        0.700     0.0    0.0
6400203    3.5+6     0.575     0.0    0.0
6400204    6.6+6     0.460     0.0    0.0
6400205    17.0+6    0.100     0.0    0.0

```

☆

\* LPIS CAPACITY CORRECTED BASED ON EXPERIMENT DATA TAPE

6

	"LPIS " TMDPJUN			
6300000	625000000	605000000	5.9896-3	
6300101				
6300200	1	684	P	605010000
6300201	0.0	5.5	0.0	0.0
6300202	0.2+6	5.0	0.0	0.0
6300203	0.6+6	4.0	0.0	0.0
6300204	0.8+6	3.0	0.0	0.0
6300205	1.0+6	2.0	0.0	0.0
6300206	1.2+6	1.6	0.0	0.0
6300207	1.3+6	1.5	0.0	0.0
6300208	1.4+6	1.4	0.0	0.0
6300209	1.5+6	0.0	0.0	0.0

5

1

#### \* IMPROVE ACCUMULATOR (E. L. LEE 89-2-28)

1

\*----  
\*----1----1----1----1----1----1----1----

#### \* ACCUMULATOR VALVE TRIPS

0000579 MFLOWJ 610000000 GE NULL 0 0.0 N

0000580 CNTRLVAR 4 LT NULL 0 1.050 L \* EJL 89/10/23  
MODIFIED THE LIMIT OF ACCUM EMPTY CASE INTO 1.53 FROM 0.920 (D160 FDR 89-5-15) EN

\* MODIFIED THE LIMIT OF ACCUM EMPTY CASE  
2222222 570 AND 560 N

0000682 579 AND -580 N

#### **ACCUMLATOR LEVEL CONTROL VARIABLE**

\* ACCUMULATOR LEVEL CONTROL VARIABLE

20500400 ACCM1.VI INTEGRAL -6.549E-3 1.54 0

20500400 RECHEVE INTEGRAL  
20500401 VELÉ J 620010000

**\* ECC CHECK VALVE**

```

*-----1-----1-----1-----1-----1-----1-----1-----1-----
6000000 "ECC CHKVLV"      VALVE
6000101 605010000 185000000 0.0      1.3869   1.3869   0100
6000201 0          0.0      0.0      0.0
6000300 TRPVLV
6000301 681
*-----1-----1-----1-----1-----1-----1-----1-----1-----
* ECCS HEADER TO PCS
*-----1-----1-----1-----1-----1-----1-----1-----1-----
6050000 "ECCS HEADR"      SNGLVOL
6050101 5.989E-3 4.8247    0.0      0.0      90.0     2.2061
6050102 1.0165E-5 0.0      10
6050200 0          1.66E+6   125472.   2600290.  0.0
*-----1-----1-----1-----1-----1-----1-----1-----1-----
* ACCUMULATOR VALVE
*-----1-----1-----1-----1-----1-----1-----1-----1-----
6100000 "ACCUM VLV"      VALVE
6100101 615010000 605000000 0.0      8.1009   8.1009   0000
6100201 0          0.0      0.0      0.0
6100300 TRPVLV
6100301 682
*-----1-----1-----1-----1-----1-----1-----1-----1-----
* ACCUMULATOR PIPE
*-----1-----1-----1-----1-----1-----1-----1-----1-----
6150000 "ACC PIPE "      SNGLVOL
6150101 0.01608 24.5486    0.0      0.0      0.0      0.0
6150102 1.0165E-5 0.0      10
6150200 3          1.66E+6   308.2
*-----1-----1-----1-----1-----1-----1-----1-----1-----
* ACCUMULATOR VESSEL
*-----1-----1-----1-----1-----1-----1-----1-----1-----
*
* MOVE TO S/S COMPONENT BY B. D. CHUNG
*
*
6200000 "ACCUMULATR"      ACCUM
6200101 1.254 1.8261563 0.0      0.0      -90.0     -1.8261563
6200102 2.286E-5 0.0      10
6200200 1.66E+6 308.2
6201101 615000000 8.213E-3 6.7582   8.3202   0
6202200 1.10    0.0      4.0251   0.67056   0.04445   0 0 0 0
*-----1-----1-----1-----1-----1-----1-----1-----1-----
*****
*** TRIP CHANGE FOR L5-1
0000518 TIME 0 GE NULL 0 4.0 N
0000695 518 AND 518 N
0000697 518 AND 518 N
*
* LPIS
0000520 P 100010000 LT NULL 0 1.08E+6 N
*
* RUN STATISTICS
*
20507800 OLDTIME SUM 1. 0. 0
20507801 0. 1. CNTRLVAR 79
*
20507900 NEWTIME SUM 1. 0. 0
20507901 0. 1. TIME 0.

```

\*  
 20508100 TSTEP SUM 1. 0. 0  
 20508101 0. -1. CNTRLVAR 78  
 20508102 1. CNTRLVAR 79  
 \*  
 \*  
 \*00 PLOT REQUEST VARIABLES \*  
 \*  
 20300100 P 250010000 \* UPPLENUM PRESSURE(PE-1UP-1A1)  
 20300200 P 530010000 \* STEAMDOME PRESSURE(PE-SGS-1)  
 20300300 HTTEMP 230000110  
 20300400 HTTEMP 230000210  
 20300500 HTTEMP 230000310  
 20300600 HTTEMP 230000410  
 20300700 HTTEMP 230000510  
 20300800 HTTEMP 230000610  
 20300900 HTTEMP 231000110 \* PERIPHERAL 89/11/10  
 20301000 HTTEMP 231000210  
 20301100 HTTEMP 231000310  
 20301200 HTTEMP 231000410  
 20301300 HTTEMP 231000510  
 20301400 HTTEMP 231000610  
 20301600 VELFJ 112010000 \* IL HL LIQUID VEL  
 20301700 VELGJ 112010000 \* IL HL VAPOR VEL  
 20301800 RHO 100010000 \* IL HL DENSITY(DE-PC-2)  
 20301900 RHO 345010000 \* BL CL DENSITY(DE-BL-1)  
 20302000 MFLOWJ 365000000 \*BREAK FLOW(FR-BL-111)  
 20302100 MFLOWJ 640000000 \*HPIIS FLOW  
 20302200 MFLOWJ 230010000 \* REFLOODING RATE  
 20302300 CPUTIME 0 \*CPU TIME  
 \*20302400 ACVLIQ 620000000 \*ACCUMU VOL  
 20302500 MFLOWJ 545000000 \* STEAM MASS OUT  
 20302600 MFLOWJ 540000000 \* STAEM MASS OUT  
 20302700 MFLOWJ 569000000 \* STEAM MASS IN  
 20302800 MFLOWJ 566000000 \* STAEM MASS IN (AUX)  
 20302900 VOIDF 515010000 \* SG2  
 20303000 VOIDF 515020000 \*  
 20303100 VOIDF 515030000  
 20303200 VOIDF 515040000  
 20303300 VOIDF 515050000  
 20303400 VOIDG 250010000 \* UPPER PLenum  
 20303500 VOIDF 250010000  
 20303600 VOIDF 245010000  
 20303700 VOIDF 240010000  
 20303800 VOIDF 230060000  
 20303900 VOIDF 230050000  
 20304000 VOIDF 230040000  
 20304100 VOIDF 230030000  
 20304200 VOIDF 230020000  
 20304300 VOIDF 230010000  
 20304400 VOIDF 225010000  
 20304500 VOIDF 215010000  
 20304600 MFLOWJ 610000000  
 20304700 MFLOWJ 630000000 \*LPIS  
 20304800 RHO 345010000 \*DENSITY BEFORE BREAK  
 20304900 VOIDG 345010000  
 20305000 VELFJ 180010000 \* LIQ VELOCITY AT ILCL (FE-PC-001B)  
 20305100 CNTRLVAR 1

```
20305200  CNTRLVAR  2
20305300  CNTRLVAR  4
20305400  CNTRLVAR  10
20305500  CNTRLVAR  71
20305600  CNTRLVAR  81  * TIME STEP DT FROM CV 81
20305700  MFLOWJ 100010000
20305800  CNTRLVAR  72
20305900  CNTRLVAR  51  * INT BRK FLOW
*
.  * END OF INPUT DATA
```

BIBLIOGRAPHIC DATA SHEET

(See instructions on the reverse)

1. REPORT NUMBER  
(Assigned by NRC, Add Vol., Supp., Rev.,  
and Addendum Numbers, if any.)

NUREG/IA-0069

2. TITLE AND SUBTITLE

Assessment of RELAP5/MOD2 Cycle 36.04 Using LOFT  
Intermediate Break Experiment L5-1

3. DATE REPORT PUBLISHED

MONTH	YEAR
April	1992

4. FIN OR GRANT NUMBER

A4682

5. AUTHOR(S)

E. J. Lee, B. D. Chung, H. J. Kim

6. TYPE OF REPORT

Technical

7. PERIOD COVERED (Inclusive Dates)

8. PERFORMING ORGANIZATION - NAME AND ADDRESS (If NRC, provide Division, Office or Region, U.S. Nuclear Regulatory Commission, and mailing address; if contractor, provide name and mailing address.)

Korea Institute of Nuclear Safety  
P.O. Box 16, Daeduk-Danji  
Daejon, Korea

9. SPONSORING ORGANIZATION - NAME AND ADDRESS (If NRC, type "Same as above"; if contractor, provide NRC Division, Office or Region, U.S. Nuclear Regulatory Commission, and mailing address.)

Office of Nuclear Regulatory Research  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

10. SUPPLEMENTARY NOTES

11. ABSTRACT (200 words or less)

The LOFT intermediate break experiment L5-1, which simulates 12 inch diameter ECC line break in a typical PWR, has been analyzed using the reactor thermal/hydraulic analysis code RELAP/MOD2, Cycle 36.05. The base calculation, which modeled the core with single flow channel and two heat structures without using the options of reflood and gap conductance model has been successfully completed and compared with experimental data. Sensitivity studies were carried out to investigate the effects of nodalization at reactor vessel and core modeling on major thermal hydraulic parameters, especially on peak cladding temperature (PCT). These sensitivity items are: single flow channel and single heat structure (Case A), two flow channel and two heat structures (Case B), reflood options added (Case C) and both reflood and gap conductance options added (Case D). The code, RELAP/MOD2 Cycle 36.04 with the base modeling, predicted the key parameters of LOFT IBLOCA Test L5-1 better than Cases A, B, C and D. Thus, it is concluded that the single flow channel modeling for core is better than the two flow channel modeling and two heat structure is also better than a single heat structure modeling to predict PCT at the central fuel rods. It is recommended to use the reflood option and not to use gap conductance option for this L5-1 type IBLOCA.

12. KEY WORDS/DESCRIPTORS (List words or phrases that will assist researchers in locating the report.)

Assessment, RELAP5/MOD2, Cycle 36.04, LOFT Intermediate Break,  
Experiment L5-1

13. AVAILABILITY STATEMENT

Unlimited

14. SECURITY CLASSIFICATION

(This Page)

Unclassified

(This Report)

Unclassified

15. NUMBER OF PAGES

16. PRICE





**THIS DOCUMENT WAS PRINTED USING RECYCLED PAPER**



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555

SPECIAL FOURTH-CLASS RATE  
POSTAGE AND FEES PAID  
USNRC  
PERMIT NO. G-67

OFFICIAL BUSINESS  
PENALTY FOR PRIVATE USE, \$300