



Entergy Nuclear Northeast  
Entergy Nuclear Operations, Inc.  
James A. Fitzpatrick NPP  
P.O. Box 110  
Lycoming, NY 13093  
Tel 315 349 6024 Fax 315 349 6480

Pete Dietrich  
Site Vice President - JAF

April 26, 2007  
JAFP-07-0054

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D.C. 20555

SUBJECT: James a. Fitzpatrick Nuclear Power Plant  
Docket No. 50-333, License No. DPR-59  
Annual Radioactive Effluent Release Report

Gentlemen:

Attachment 1 is the Annual Radioactive Effluent Release Report for the period of January 1, 2006 through December 31, 2006. This report is submitted in accordance with the requirements of the James A. FitzPatrick Nuclear Power Plant Offsite Dose Calculation Manual, Part 1, Radiological Controls, Section 6.2.

This report includes, an assessment of the radiation doses to the public due to the radioactive liquid and gaseous effluents released during the 2006 calendar year. The format used for the effluent data is outlined in Appendix B of Regulatory Guide 1.21, Revision 1. Distribution is in accordance with Regulatory Guide 10.1, Revision 4 and 10 CFR 50.4.

If you have any questions concerning the attached report, please contact Crystal A. Boucher, Chemistry Superintendent, at the James A. FitzPatrick Nuclear Power Plant at (315)349-6748.

There are no commitments contained in this letter.

Very truly yours,

  
Pete Dietrich  
Site Vice President

PD/CAB/jbh

Attachments: 1) James A. FitzPatrick Nuclear Power Plant Annual Radioactive Effluent Release Report

cc: Next Page

IE48

cc: Mr. Samuel Collins  
Regional Administrator, Region I  
U. S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406-1415

Resident Inspector's Office  
U. S. Nuclear Regulatory Commission  
James A. FitzPatrick Nuclear Power Plant  
P.O. Box 136  
Lycoming, NY 13093

Mr. John Boska  
Plant Licensing Branch  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation  
U. S. Nuclear Regulatory Commission  
Mail Stop O-8-C2  
Washington D.C. 20555

Mr. Don Sherman  
American Nuclear Insurers  
95 Glastonbury Boulevard  
Glastonbury, CT 06033-4438

Paul Merges, PhD  
Chief, Bureau of Radiation  
Division of Hazardous Substance Regulation  
New York State Department of Environmental Conservation  
Albany, NY 12233

K. Mulligan (JAF)  
C. Faison (ENOC/WPO)  
J. McCann (ENOC/WPO)  
J. Furfaro (ENOC/WPO)  
W. Hamblin (CHEM/JAF)  
T. Kurtz (NMPC)

**JAFP-07-0054 ATTACHMENT 1**

**ENTERGY NUCLEAR OPERATIONS, INC.  
JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT**

**JANUARY 1, 2006 - DECEMBER 31, 2006**

**DOCKET NO.: 50-333**

**LICENSE NO.: DPR-59**

ENTERGY NUCLEAR OPERATIONS, INC.  
JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
JANUARY 2006-DECEMBER 2006

**SUPPLEMENTAL INFORMATION**

FACILITY: JAFNPP LICENSEE: ENTERGY NUCLEAR OPERATIONS, INC.

**1. Offsite Dose Calculation Manual Part 1 Radiological Controls**

a. Fission and Activation Gases:

- (1) The dose rate at or beyond the site boundary due to radioactive materials released from the plant in gaseous effluent shall be limited as follows:
  - (a) Less than or equal to 500 mrem/year to the whole body and less than or equal to 3000 mrem/year to the skin from noble gases.
- (2) The air dose to areas at or beyond the site boundary from noble gases released from the plant in gaseous effluent shall be limited:
  - (a) During any calendar quarter, to less than or equal to 5 mrad from gamma radiation, and less than or equal to 10 mrad from beta radiation; and,
  - (b) During any calendar year, to less than or equal to 10 mrad from gamma radiation and less than or equal to 20 mrad from beta radiation.

b. Tritium, Iodines and Particulates, Half Lives > 8 days:

- (1) The dose to a member of the public at or beyond the site boundary from Iodine-131, Iodine-133, Tritium, and radionuclides in particulate form with half-lives greater than 8 days released from the plant in gaseous effluent shall be limited:
  - (a) During any calendar quarter to less than or equal to 7.5 mrem to any organ; and,
  - (b) During any calendar year to less than or equal to 15 mrem to any organ.
  - (c) Less than 0.1% of the limits of Specification 3.4.1.c.1.a and 3.4.1.c.1.b as a result of burning contaminated oil.
- (2) The dose rate at or beyond the site boundary due to radioactive materials released from the plant in gaseous effluents shall be limited as follows:
  - (a) Less than or equal to 1500 mrem/year to any organ from Iodine-131, Iodine-133, Tritium and for radioactive materials in particulate form with half-lives greater than 8 days (inhalation pathway only).

ENTERGY NUCLEAR OPERATIONS, INC.  
 JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
 JANUARY 2006-DECEMBER 2006

**SUPPLEMENTAL INFORMATION (continued)**

c. Liquid Effluents:

- (1) The concentration of radioactive materials released to the unrestricted areas shall not exceed ten times the values specified in 10 CFR 20.1001-20.2402, Appendix B, Table 2, Column 2. For dissolved or entrained noble gases the concentration shall be limited to 2.00E-04  $\mu\text{Ci/ml}$ .
- (2) The dose to a member of the public from radioactive materials released from the plant in liquid effluents to unrestricted areas shall be limited as follows:
  - (a) During any calendar quarter, limited to less than or equal to 1.5 mrem to the whole body and to less than or equal to 5 mrem to any organ; and,
  - (b) During any calendar year, limited to less than or equal to 3 mrem to the whole body and to less than or equal to 10 mrem to any organ.

2. 10X Effluent Concentrations

- a. Fission and activation gases: (None specified)
- b. Iodines: (None specified)
- c. Particulates, half-lives >8 days: (None specified)

d. Liquid effluents:	<u>Quarter 1</u>	<u>Quarter 2</u>	<u>Quarter 3</u>	<u>Quarter 4</u>
(1) Fission and activation products (mixture EC) ( $\mu\text{Ci/ml}$ )	None	None	None	1.14E-04
(2) Tritium ( $\mu\text{Ci/ml}$ )	1.00E-02	1.00E-02	1.00E-02	1.00E-02
(3) Dissolved and entrained gases ( $\mu\text{Ci/ml}$ )	2.00E-04	2.00E-04	2.00E-04	2.00E-04

ENERGY NUCLEAR OPERATIONS, INC.  
JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
JANUARY 2006-DECEMBER 2006

**SUPPLEMENTAL INFORMATION (continued)**

3. Average Energy

(None specified)

4. Measurements and Approximations of Total Radioactivity

- a. Fission and Activation Gases: Continuous monitor on each release path calibrated to a marinelli grab sample analyzed by gamma spectroscopy; bubbler grab sample analyzed for Tritium.
- b. Iodines: Gamma spectral analysis of charcoal cartridge and particulate filter on each release path.
- c. Particulates: Gamma spectral analysis of each particulate filter and charcoal cartridge for each release path. A four week per quarter composite of particulate filters for each release path for Strontium-89 and Strontium-90. One week per month particulate filter for each release path for gross alpha.
- d. Liquid Effluents: Gamma spectral analysis of each batch discharged, except composite analysis for Strontium-89, Strontium-90, Iron-55, Tritium, and Alpha.
- e. Solid Waste: Gamma spectral analysis of a representative sample of each waste shipment. Scaling factors established from off-site composite sample analyses to estimate concentration of non-gamma emitters. Low activity trash shipments, curie content estimated by dose rate measurement and application of appropriate scaling factors.
- f. Error Estimation Method: Overall error for sampling and analysis estimated by combining individual errors using error propagation methods. This process is composed of determinate and undeterminate errors.

Determinate - Pump flowrates, volume measurements and analysis collection yields

Undeterminate - Random counting error estimated using accepted statistical calculations

ENTERGY NUCLEAR OPERATIONS, INC.  
 JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
 JANUARY 2006-DECEMBER 2006

**SUPPLEMENTAL INFORMATION (continued)**

**5. Batch Releases**

a. <u>Liquid: Canal</u>	<u>Quarter 1</u>	<u>Quarter 2</u>	<u>Quarter 3</u>	<u>Quarter 4</u>
(1) Number of batch releases:	2.00E+00	6.00E+00	4.00E+00	3.10E+01
(2) Total time period for batch release: (min)	1.01E+02	1.73E+02	1.55E+02	1.73E+03
(3) Maximum time period for batch release: (min)	6.50E+01	6.30E+01	7.00E+01	1.05E+02
(4) Average time period for batch release: (min)	5.05E+01	2.88E+01	3.89E+01	5.58E+01
(5) Minimum time period for batch release: (min)	3.60E+01	2.00E+00	3.00E+00	5.00E+00
(6) Total Activity Released (Ci)	3.94E-06	1.53E-04	2.28E-04	3.81E+00
(7) Total Volume Released (liters)	1.48E+03	6.35E+03	8.55E+03	8.68E+05
b. <u>Liquid: Non-Canal</u>				
(1) Number of batch releases:	4.00E+00	1.20E+01	1.20E+01	1.20E+01
(2) Total time period for batch release: (min)	4.00E+00	3.36E+01	3.75E+02	1.72E+02
(3) Maximum time period for batch release: (min)	1.00E+00	1.40E+01	8.00E+01	1.11E+02
(4) Average time period for batch release: (min)	1.00E+00	2.80E+00	3.15E+01	1.43E+01
(5) Minimum time period for batch release: (min)	1.00E+00	1.00E+00	2.00E+00	1.00E+00
(6) Total Activity Released (Ci)	3.87E-06	2.64E-05	3.19E-04	8.79E-05
(7) Total Volume Released (liters)	1.82E+03	1.27E+04	1.42E+05	6.56E+04

ENTERGY NUCLEAR OPERATIONS, INC.  
JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
JANUARY 2006-DECEMBER 2006

**SUPPLEMENTAL INFORMATION (continued)**

c. Gaseous:

There were no gaseous batch releases for this report period.

**6. Abnormal Releases**

a. Liquid:	<u>Quarter 1</u>	<u>Quarter 2</u>	<u>Quarter 3</u>	<u>Quarter 4</u>
(1) Number of releases:	NONE	NONE	NONE	NONE
(2) Total activity released:	NONE	NONE	NONE	NONE
b. Gaseous				
(1) Number of releases:	NONE	NONE	NONE	NONE
(2) Total activity released:	NONE	NONE	NONE	NONE



ENTERGY NUCLEAR OPERATIONS, INC.  
 JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
 JANUARY 2006-DECEMBER 2006

**TABLE 1A  
 GASEOUS EFFLUENTS--SUMMATION OF ALL RELEASES**

	<u>UNIT</u>	<u>QTR 1</u>	<u>QTR 2</u>	<u>QTR 3</u>	<u>QTR 4</u>	<u>EST TOTAL ERROR %</u>
<b>A. FISSION AND ACTIVATION GASES</b>						
1. Total Release	Ci	4.14E+02	4.02E+02	3.87E+02	8.43E+01	≤2.50E+01
2. Average release rate for period	μCi/sec	5.27E+01	5.11E+01	4.86E+01	1.06E+01	
3. Applicable ODCM Limit	%	*	*	*	*	
<b>B. IODINE-131</b>						
1. Total Iodine-131	Ci	5.80E-04	5.84E-04	3.97E-04	2.21E-03	≤2.50E+01
2. Average release rate for period	μCi/sec	7.37E-05	7.43E-05	4.99E-05	2.78E-04	
3. Applicable ODCM Limit	%	*	*	*	*	
<b>C. PARTICULATES</b>						
1. Particulates with half-lives >8 days	Ci	4.82E-04	6.60E-04	5.93E-04	2.87E-04	≤3.60E+01
2. Average release rate for period	μCi/sec	6.14E-05	8.39E-05	7.46E-05	3.61E-05	
3. Applicable ODCM Limit	%	*	*	*	*	
4. Gross alpha radioactivity	Ci	4.52E-07	1.26E-07	3.88E-07	4.60E-07	≤2.50E+01
<b>D. TRITIUM</b>						
1. Total Release	Ci	3.99E+00	3.41E+00	4.48E+00	5.19E+00	≤2.50E+01
2. Average release rate for period	μCi/sec	5.07E-01	4.34E-01	5.64E-01	6.52E-01	
3. Applicable ODCM Limit	%	*	*	*	*	
<b>*E. PERCENT OF APPLICABLE ODCM LIMITS</b>						
<b>FISSION AND ACTIVATION GASES</b>						
1. Quarterly gamma air dose limit	%	5.37E-02	9.25E-02	1.24E-01	2.34E-02	
2. Quarterly beta air dose limit	%	2.12E-01	1.10E-01	7.34E-02	8.54E-03	
3. Yearly gamma air dose limit	%	2.68E-02	4.62E-02	6.18E-02	1.17E-02	
4. Yearly beta air dose limit	%	1.06E-01	5.48E-02	3.67E-02	4.27E-03	
5. Whole body dose rate limit	%	3.60E-02	5.50E-02	1.29E-02	1.24E-02	
6. Skin dose rate limit	%	1.03E-02	1.53E-02	4.70E-03	3.46E-03	
<b>HALOGENS, TRITIUM AND PARTICULATES WITH HALF-LIVES &gt;8 DAYS</b>						
7. Quarterly dose limit (organ)	%	9.01E-02	9.28E-02	6.37E-02	3.72E-01	
8. Yearly dose limit (organ)	%	4.51E-02	4.64E-02	3.18E-02	1.86E-01	
9. Organ dose rate limit	%	5.00E-05	3.87E-05	2.01E-05	6.18E-04	

ENTERGY NUCLEAR OPERATIONS, INC.  
 JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
 JANUARY 2006-DECEMBER 2006

**TABLE 1B**  
**GASEOUS EFFLUENTS--ELEVATED RELEASE**

<u>NUCLIDES RELEASED</u>	<u>UNIT</u>	<u>CONTINUOUS MODE</u>			
		<u>QUARTER 1</u>	<u>QUARTER 2</u>	<u>QUARTER 3</u>	<u>QUARTER 4</u>
<b>1. <u>Fission Gases</u></b>					
Argon-41	Ci	2.32E+00	1.99E+00	1.83E+00	1.45E+00
Krypton-85	Ci	-----	-----	-----	1.35E+01
Krypton-85m	Ci	4.60E+01	4.76E+01	7.67E+01	1.69E+01
Krypton-87	Ci	1.15E+00	3.40E+00	6.76E+00	8.61E-01
Krypton-88	Ci	2.57E+01	3.61E+01	9.02E+01	1.66E+01
Krypton-89	Ci	-----	5.53E+00	-----	-----
Xenon-133	Ci	5.71E+01	5.36E+01	8.21E+01	1.43E+01
Xenon-135	Ci	1.40E+00	2.64E+00	1.15E+00	7.40E-01
Xenon-135m	Ci	6.28E+00	1.21E+01	3.48E+00	9.63E-01
Xenon-137	Ci	3.12E+01	6.77E+01	1.33E+01	1.02E+00
Xenon-138	Ci	1.80E+01	3.82E+01	1.06E+01	1.68E+00
TOTAL	Ci	1.88E+02	2.69E+02	2.86E+02	6.80E+01
<b>2. <u>Iodines</u></b>					
Iodine-131	Ci	3.07E-04	2.56E-04	1.69E-04	5.05E-04
Iodine-133	Ci	1.56E-03	4.09E-04	2.28E-04	6.96E-05
Iodine-135	Ci	1.35E-03	3.93E-05	8.31E-05	-----
TOTAL	Ci	3.22E-03	7.04E-04	4.80E-04	5.75E-04
<b>3. <u>Particulates</u></b>					
Chromium-51	Ci	-----	-----	-----	1.56E-06
Manganese-54	Ci	-----	-----	-----	8.83E-07
Cobalt-60	Ci	-----	-----	-----	4.34E-07
Strontium-89	Ci	4.64E-05	1.26E-04	1.51E-04	1.13E-04
Strontium-90	Ci	3.58E-07	2.20E-07	3.61E-07	5.74E-07
Cesium-137	Ci	-----	6.35E-07	2.33E-07	2.18E-07
Barium-140	Ci	6.32E-05	7.31E-05	2.97E-05	4.59E-05
TOTAL	Ci	1.10E-04	2.00E-04	1.81E-04	1.63E-04
<b>4. <u>Tritium</u></b>					
Hydrogen-3	Ci	4.37E-01	4.48E-01	8.46E-01	1.23E+00

Note: There were no batch releases for this report period.

ENERGY NUCLEAR OPERATIONS, INC.  
 JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
 JANUARY 2006-DECEMBER 2006

**TABLE 1C**  
**GASEOUS EFFLUENTS--GROUND LEVEL RELEASES**

<u>NUCLIDES RELEASED</u>	<u>UNIT</u>	<u>QUARTER 1</u>	<u>CONTINUOUS MODE</u>		<u>QUARTER 4</u>
			<u>QUARTER 2</u>	<u>QUARTER 3</u>	
<b>1. <u>Fission Gases</u></b>					
Krypton-87	Ci	6.76E-02	-----	-----	-----
Xenon-133	Ci	7.43E-01	1.54E+00	1.40E+00	7.28E+00
Xenon-135	Ci	3.86E+00	4.44E+00	3.19E+00	1.01E+00
Xenon-135M	Ci	1.83E+01	1.70E+01	1.32E+01	1.10E+00
Xenon-137	Ci	1.32E+02	5.10E+01	3.02E+01	3.16E+00
Xenon-138	Ci	7.01E+01	5.94E+01	5.25E+01	3.80E+00
TOTAL	Ci	2.25E+02	1.33E+02	1.00E+02	1.64E+01
<b>2. <u>Iodines</u></b>					
Iodine-131	Ci	2.73E-04	3.28E-04	2.28E-04	1.71E-03
Iodine-133	Ci	6.91E-04	6.98E-04	6.07E-04	3.54E-04
TOTAL	Ci	9.64E-04	1.03E-03	8.35E-04	2.06E-03
<b>3. <u>Particulates</u></b>					
Manganese-54	Ci	-----	-----	-----	6.23E-06
Cobalt-60	Ci	-----	1.49E-06	-----	1.92E-06
Zinc-65	Ci	-----	-----	-----	7.66E-06
Strontium-89	Ci	1.68E-04	2.07E-04	2.38E-04	9.65E-05
Strontium-90	Ci	3.95E-08	1.27E-06	1.36E-06	2.08E-06
Barium-140	Ci	2.05E-04	2.50E-04	1.72E-04	7.14E-06
TOTAL	Ci	3.73E-04	4.60E-04	4.11E-04	1.22E-04
<b>4. <u>Tritium</u></b>					
Hydrogen-3	Ci	3.55E+00	2.96E+00	3.64E+00	3.90E+00

Note: There were no batch releases for this report period.

ENTERGY NUCLEAR OPERATIONS, INC.  
 JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
 JANUARY 2006-DECEMBER 2006

**TABLE 1D - SUPPLEMENTAL  
 GASEOUS EFFLUENTS—UNMONITORED SHORT-TERM RELEASE**

<u>NUCLIDES RELEASED</u>	<u>UNIT</u>	<u>QUARTER 1</u>	<u>CONTINUOUS MODE</u>		<u>QUARTER 4</u>
			<u>QUARTER 2</u>	<u>QUARTER 3</u>	
<b>1. <u>Fission Gases</u></b>					
None					
<b>2. <u>Iodines</u></b>					
None					
<b>3. <u>Particulates</u></b>					
Chromium-51	Ci	-----	-----	-----	1.57E-08
Manganese-54	Ci	-----	-----	-----	1.53E-07
Cobalt-58	Ci	-----	-----	-----	5.40E-08
Iron-59	Ci	-----	-----	-----	9.67E-09
Cobalt-60	Ci	-----	-----	-----	1.55E-07
Zinc-65	Ci	-----	-----	-----	2.09E-06
TOTAL	Ci	-----	-----	-----	2.48E-06
<b>4. <u>Tritium</u></b>					
Hydrogen-3	Ci	-----	-----	-----	6.24E-02

ENTERGY NUCLEAR OPERATIONS, INC.  
 JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
 JANUARY 2006-DECEMBER 2006

**TABLE 2A**  
**LIQUID EFFLUENTS--SUMMATION OF ALL RELEASES**

	<u>UNIT</u>	<u>QTR 1</u>	<u>QTR 2</u>	<u>QTR 3</u>	<u>QTR 4</u>	<u>EST TOTAL ERROR %</u>
<b>A. FISSION AND ACTIVATION PRODUCTS</b>						
1. Total Release (not including tritium, gases and alpha)	Ci	NONE	NONE	NONE	3.67E-04	≤2.50E+01
2. Average diluted concentration during period	μCi/ml	NONE	NONE	NONE	1.33E-10	
3. Applicable ODCM Limit	%	-----	-----	-----	*	
<b>B. TRITIUM</b>						
1. Total Release	Ci	7.82E-06	1.80E-04	5.46E-04	3.81E+00	≤2.50E+01
2. Average diluted concentration during period (Note 1)	μCi/ml	1.17E-06	2.31E-06	2.11E-06	1.47E-06	
3. Applicable ODCM Limit	%	*	*	*	*	
<b>C. DISSOLVED AND ENTRAINED GASES</b>						
1. Total Release	Ci	NONE	NONE	NONE	-----	≤2.50E+01
2. Average diluted concentration during period	μCi/ml	NONE	NONE	NONE	-----	
3. Applicable ODCM Limit	%	-----	-----	-----	-----	
<b>D. GROSS ALPHA RADIOACTIVITY</b>						
1. Total Release	Ci	NONE	NONE	NONE	5.17E-06	≤4.20E+01
<b>E. VOLUME OF WASTE RELEASED (PRIOR TO DILUTION)</b>						
	liters	3.30E+03	1.91E+04	1.51E+05	9.34E+05	
<b>F. VOLUME OF DILUTION WATER USED DURING PERIOD</b>						
	liters	1.51E+08	2.47E+08	2.32E+08	2.57E+09	
<b>*G. PERCENT OF APPLICABLE ODCM LIMITS</b>						
1. Quarterly Whole Body Dose	%	8.58E-05	3.19E-04	1.87E-04	8.50E-04	
2. Quarterly Organ Dose	%	2.57E-05	9.57E-05	5.61E-05	2.63E-04	
3. Annual Whole Body Dose	%	4.29E-05	1.59E-04	9.34E-05	4.25E-04	
4. Annual Organ Dose	%	1.29E-05	4.78E-05	2.80E-05	1.32E-04	

(Note 1) Concentration includes summation from diluted and undiluted values from Canal and Non-Canal releases (Table 2B).

ENTERGY NUCLEAR OPERATIONS, INC.  
 JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
 JANUARY 2006-DECEMBER 2006

**TABLE 2B**  
**LIQUID EFFLUENTS CANAL**

<u>NUCLIDES RELEASED</u>	<u>UNIT</u>	<u>BATCH MODE</u>			<u>QUARTER 4</u>
		<u>QUARTER 1</u>	<u>QUARTER 2</u>	<u>QUARTER 3</u>	
<b>1. <u>Fission and Activation Products</u></b>					
Manganese-54	Ci	-----	-----	-----	1.04E-04
Iron-55	Ci	-----	-----	-----	2.02E-04
Cobalt-60	Ci	-----	-----	-----	1.59E-05
Zinc-65	Ci	-----	-----	-----	3.83E-05
Strontium-90	Ci	-----	-----	-----	7.06E-06
TOTAL	Ci	-----	-----	-----	3.67E-04
<b>2. <u>Tritium</u></b>					
HYDROGEN-3	Ci	7.81E-06	1.80E-04	5.47E-04	3.81E+00
<b>3. <u>Dissolved and Entrained Gases</u></b>					
NONE	Ci	-----	-----	-----	-----

Note: There were no continuous mode discharges during this report period.

ENTERGY NUCLEAR OPERATIONS, INC.  
 JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
 JANUARY 2006-DECEMBER 2006

**TABLE 2B (SUPPLEMENT)  
 LIQUID EFFLUENTS NON-CANAL**

<u>NUCLIDES RELEASED</u>	<u>UNIT</u>	<u>BATCH MODE</u>			
		<u>QUARTER 1</u>	<u>QUARTER 2</u>	<u>QUARTER 3</u>	<u>QUARTER 4</u>
<b>1. <u>Fission and Activation Products</u></b>					
NONE	Ci	-----	-----	-----	-----
<b>2. <u>Tritium</u></b>					
HYDROGEN-3	Ci	3.87E-06	2.64E-05	3.19E-04	8.79E-05
<b>3. <u>Dissolved and Entrained Gases</u></b>					
NONE	Ci	-----	-----	-----	-----

Note: There were no continuous mode discharges during this report period.

ENTERGY NUCLEAR OPERATIONS, INC.  
 JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
 JANUARY 2006-DECEMBER 2006

**TABLE 3A  
 SOLID WASTE AND IRRADIATED FUEL SHIPMENTS**

A. SOLID WASTE SHIPPED OFFSITE FOR BURIAL OR DISPOSAL (NOT IRRADIATED FUEL)						Est. Total
1. Type of Waste	Unit	Class A	Class B	Class C		Error %
a. Spent resins, filter sludges evaporator bottoms, etc.	m <sup>3</sup> Ci	0.00E+00 0.00E+00	0.00E+00 0.00E+00	0.00E+00 0.00E+00	0.00E+00 0.00E+00	0.00E+00 0.00E+00
b. Dry compressible waste, contaminated equipment, etc.	m <sup>3</sup> Ci	0.00E+00 0.00E+00	0.00E+00 0.00E+00	0.00E+00 0.00E+00	0.00E+00 0.00E+00	0.00E+00 0.00E+00
c. Irradiated components, control rods, etc.	m <sup>3</sup> Ci	0.00E+00 0.00E+00	0.00E+00 0.00E+00	0.00E+00 0.00E+00	0.00E+00 0.00E+00	0.00E+00 0.00E+00
d. Other: Dry compressible waste, contaminated equipment, spent resins for volume reduction.	m <sup>3</sup> Ci	1.08E+03 2.76E+01	5.83E+00 5.13E+01	0.00E+00 0.00E+00	1.00E+01 1.00E+01	1.00E+01 1.00E+01

2. Estimate of Major Nuclide Composition (by type of waste)

a. Spent resins, filter sludges, evaporator bottoms, etc.

NONE

b. Dry compressible waste, contaminated equipment, etc.

NONE

c. Irradiated components, control rods, etc.

NONE

d. Other: Dry compressible waste, contaminated equipment, spent resins for volume reduction.

Isotope	Percent	Curies		Isotope	Percent	Curies	
Iron-55	6.94E+01	5.47E+01	E	Nickel-63	9.24E-01	7.29E-01	E
Cobalt-60	1.09E+01	8.59E+00	E	Tritium	5.39E-01	4.25E-01	E
Manganese-54	2.67E+00	2.11E+00	E	Cesium-134	1.49E+00	1.17E+00	E
Cesium-137	2.78E+00	2.19E+00	E	Cobalt-58	1.60E-02	1.26E-02	E
Zinc-65	1.06E+01	8.38E+00	E	Cerium-141	1.47E-02	1.16E-02	E
Plutonium-241	2.44E-02	1.93E-02	E	Strontium-90	3.13E-01	2.47E-01	E
Cerium-144	3.15E-01	2.48E-01	E				

(E- Estimated M- Measured)

Percentage of nuclides and total activities are based on a combination of direct measurements and scaling for non-gamma emitting nuclides.



ENTERGY NUCLEAR OPERATIONS, INC.  
 JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
 JANUARY 2006-DECEMBER 2006

**TABLE 3A (continued)**  
**SOLID WASTE AND IRRADIATED FUEL SHIPMENTS**

3. Solid Waste Disposition

<u>No. of Shipments</u>	<u>Mode of Transportation</u>	<u>Destination</u>
14	Truck	*Duratek Oak Ridge, TN
7	Truck	* Studsvik Erwin, TN
10	Truck	* Alaron Wampum, PA
7	Truck	*Duratek GIC Kingston, TN
2	Truck	*GE Global Nuclear Fuel Wilmington, NC

\*- Volume Reduction Facility

B. IRRADIATED FUEL SHIPMENTS (Disposition)

<u>No. of Shipments</u>	<u>Mode of Transportation</u>	<u>Destination</u>
NONE	-----	-----

ENTERGY NUCLEAR OPERATIONS, INC.  
 JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
 JANUARY 2006-DECEMBER 2006

**TABLE 3B  
 SOLID WASTE AND IRRADIATED FUEL SHIPMENTS**

NRC CLASS A

<u>SOURCE OF WASTE</u>	<u>PROCESSING EMPLOYED</u>	<u>CONTAINER VOLUME</u>	<u>TYPE OF CONTAINER</u>	<u>NUMBER OF CONTAINERS</u>
Spent Resins, Filter Sludges, evaporator Bottoms, etc.	Air Drying Non-compacted	205.8 ft <sup>3</sup>	HIC	4
Dry compressible Waste (DAW), Contaminated Equipment, etc.	Non-compacted	1280 ft <sup>3</sup>	STC	13
Dry compressible Waste(DAW), Contaminated Equipment, etc.	Non-compacted	2560 ft <sup>3</sup>	STC	1
Dry compressible Waste(DAW), Contaminated Equipment, etc.	Non-compacted	96 ft <sup>3</sup>	STC	47
Contaminated Oil	Non-compacted	7.5 ft <sup>3</sup>	STC	13
Dry compressible Waste(DAW), Contaminated Equipment	Non-compacted	111 ft <sup>3</sup>	STC	3
Dry compressible Waste(DAW), Contaminated Equipment	Non-compacted	206.1 ft <sup>3</sup>	STC	1
Dry compressible Waste(DAW), Contaminated Equipment	Non-compacted	209.1 ft <sup>3</sup>	STC	1
Dry compressible Waste(DAW), Contaminated Equipment	Non-compacted	292 ft <sup>3</sup>	STC	5
Dry compressible Waste(DAW), Contaminated Equipment	Non-compacted	1033.5 ft <sup>3</sup>	STC	11

ENTERGY NUCLEAR OPERATIONS, INC.  
 JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
 JANUARY 2006-DECEMBER 2006

B. NRC CLASS B

<u>SOURCE OF WASTE</u>	<u>PROCESSING EMPLOYED</u>	<u>CONTAINER VOLUME</u>	<u>TYPE OF CONTAINER</u>	<u>NUMBER OF CONTAINERS</u>
Spent Resins, Filter Sludges, evaporator Bottoms, etc.	Air Drying Non-compacted	205.8 ft <sup>3</sup>	HIC	1

C. NRC CLASS C

<u>SOURCE OF WASTE</u>	<u>PROCESSING EMPLOYED</u>	<u>CONTAINER VOLUME</u>	<u>TYPE OF CONTAINER</u>	<u>NUMBER OF CONTAINERS</u>
NONE	-----	-----	-----	-----

Solidification Agent:                      NONE

HIC- High Integrity Container  
 STC- Strong Tight Container

ENTERGY NUCLEAR OPERATIONS, INC.  
JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
JANUARY 2006-DECEMBER 2006

**ATTACHMENT NO. 1**

**CHANGES TO THE OFFSITE DOSE CALCULATION MANUAL (ODCM)**

In accordance with the James A. FitzPatrick Nuclear Power Plant Offsite Dose Calculation Manual (ODCM), Part 1 Radiological Controls (REC) Section 6.2.3, changes made to the Offsite Dose Calculation Manual (ODCM) during the reporting period shall be included in the Annual Radioactive Effluent Release Report.

There were no changes to the Offsite Dose Calculation Manual (ODCM).

ENTERGY NUCLEAR OPERATIONS, INC.  
JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
JANUARY 2006-DECEMBER 2006

**ATTACHMENT NO. 2**

**SUMMARY OF CHANGES TO THE PROCESS CONTROL PROGRAM**

In accordance with the James A. FitzPatrick Nuclear Power Plant Offsite Dose Calculation Manual (ODCM), Part 1 Radiological Controls (REC) Section 6.2.3, changes made to the Process Control Program (PCP) during the reporting period shall be included in the Annual Radioactive Effluent Release Report.

Revisions to the Performance Reference procedures of the Process Control Program procedure were made and approved on 5/22/06. These revisions do not reduce the overall conformance of the solidified waste product to existing criteria for solid waste. Listed below is a brief summary of changes incorporated in this revision.

- 1) CNSI-FO-OP-032-41802, Setup and Operating Procedure for RDS-1000 Unit Number 9 at James A. FitzPatrick Nuclear Power Plant was withdrawn and replaced by CNSI-FO-P-033-41802. This was due to an equipment change to replace obsolete and unreliable equipment.
- 2) CNSI-FO-OP-023-41802, Bead Resin/Activated Carbon Dewatering Procedure for CNSI-14-215 or Smaller liners at James A. FitzPatrick Nuclear Plant was revised to dewater liners with new equipment. The major change was the new procedure uses multiple drying cycles instead of an air conditioning system to dewater liners.

ENTERGY NUCLEAR OPERATIONS, INC.  
JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
JANUARY 2006-DECEMBER 2006

**ATTACHMENT NO. 3**

**SUMMARY OF CHANGES TO THE ENVIRONMENTAL  
MONITORING AND DOSE CALCULATION LOCATIONS**

In accordance with the James A. FitzPatrick Nuclear Power Plant Off Site Dose Calculation Manual (ODCM), Part 1, Sections 6.2.3 a listing of new locations for dose calculation and/or environmental monitoring identified by the land use census shall be included in the Annual Radioactive Effluent Release Report.

**CHANGES IN ENVIRONMENTAL MONITORING LOCATIONS**

During the report period, no changes were made to the Environmental Monitoring Locations sampled to implement the requirements of the ODCM, Part 1, table 5.1-1. Sample location selections were based on the 2006 annual land use census.

**NEW LOCATIONS FOR DOSE CALCULATIONS**

During the report period, no changes in Dose Calculation Receptor Locations were required based on the results of the land use census.

ENTERGY NUCLEAR OPERATIONS, INC.  
JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
JANUARY 2006-DECEMBER 2006

**ATTACHMENT NO. 4**

**DEVIATIONS FROM THE REQUIRED  
ENVIRONMENTAL SAMPLING SCHEDULE**

In accordance with the James A. FitzPatrick Nuclear Power Plant Off Site Dose Calculation Manual (ODCM), Part 1, Section 6.2.7 the cause for the unavailability of any environmental samples required during the report period shall be included in the Annual Radioactive Effluent Release Report.

The following reports samples that were a deviation from the requirements of ODCM Part 1, Table 5.1-1. ODCM Part I, Section 5.1.1.c.1 allows for deviations from the program due to hazardous conditions, seasonal unavailability, theft, uncooperative residents, or to malfunction of automatic sampling equipment.

**DEVIATION AND EXCEPTIONS TO THE PROGRAM**

The noted exceptions to the 2006 sample program address only those samples or monitoring requirements which are required by the ODCM, Part I, Table 5.1-1. This section satisfies the reporting requirements of ODCM, Part I, Section 5.1.1.c.1.

**A. ODCM Program Deviations**

The following are deviations from the program specified by the ODCM:

1. The air sampling pump at the R5 Environmental Sampling Station was inoperable for approximately 3 hours during the sample period of 1/17/06 through 1/24/06. The air sample pump was running at the time of sample collection. The sample pump out of service time was determined based on the sample pump run time integrator. The inoperability of the pump was due to a loss of power to the sampler. No corrective actions were required to restore the unit to service.
2. The air sampling pump at the R3 and R4 Environmental Sampling Stations were inoperable for approximately 1 hour on 2/22/06 due to high winds that caused a power outage. The sample pump out of service times were determined based on the sample pump run time integrator. No corrective actions were implemented.
3. The air sampling pump at the R5 Environmental Sampling Station was inoperable for approximately 2.6 hours on 2/22/06 due to high winds that caused a power outage. The sample pump out of service time was determined based on the sample pump run time integrator. No corrective action was implemented.

ENTERGY NUCLEAR OPERATIONS, INC.  
JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
JANUARY 2006-DECEMBER 2006

**ATTACHMENT NO. 4 (Continued)**

4. The air sampling pump at the R1 and R2 Environmental Sampling Stations were inoperable for approximately 0.8 hours during the sample period of 3/28/06 through 4/4/06. The air sample pumps were running at the time of sample collection. The sample pump out of service times were determined based on the sample pump run time integrators. The inoperability of the pumps was due to a loss of power to the samplers. No corrective actions were required to restore these units to service.
5. The air sampling pump at the R5 Environmental Sampling Station was inoperable for approximately 2.4 hours on 6/6/06. The sample pump out of service time was determined based on the sample pump run time integrator. The inoperability of the pump was due to a loss of power to the sampler. No corrective actions were required to restore the unit to service.
6. The air sampling pump at the R1 and R2 Environmental Sampling Stations were inoperable for approximately 0.7 hours on 8/1/06. The sample pump out of service times were determined based on the sample pump run time integrators. The inoperability of the pumps was due to a loss of power to the samplers. No corrective actions were required to restore the unit to service.
7. The air sampling pump at the R5 Environmental Sampling Stations was inoperable for approximately 2.5 hours during the sample period of 9/26/06 through 10/3/06. The air sample pump was running at the time of sample collection. The sample pump out of service time was determined based on the sample pump run time integrator. The inoperability of the pump was due to a loss of power to the sampler. No corrective actions were required to restore these units to service.
8. The air sampling pump at R1 and R2 Environmental Sampling Stations were inoperable for approximately 9.7 hours for the sample period 10/23/06 through 10/31/06. The sample pump out of service times were determined based on the sample pump run time integrators. The sample pumps were found running. The inoperability of the pumps was due to a loss of power caused by strong winds. No corrective actions were required to restore the unit to service.
9. The air sampling pump at the R5 Environmental Sampling Stations was inoperable for approximately 2.0 hours during the sample period of 12/05/06 through 12/12/06. The air sample pump was running at the time of sample collection. The sample pump out of service time was determined based on the sample pump run time integrator. The inoperability of the pump was due to a loss of power to the sampler. No corrective actions were required to restore these units to service.



ENTERGY NUCLEAR OPERATIONS, INC.  
JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
JANUARY 2006-DECEMBER 2006

**ATTACHMENT NO. 4 (Continued)**

B. Air Sampling Station Operability Assessment

The ODCM required air sampling program consists of 5 individual sampling locations. The collective operable time period for the air monitoring stations was 43,763 hours out of a possible 43,800 hours. The air sampling availability factor for the report period was 99.92%.

ENTERGY NUCLEAR OPERATIONS, INC.  
JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
JANUARY 2006-DECEMBER 2006

**ATTACHMENT NO. 5**

**ANNUAL SUMMARY OF HOURLY METEOROLOGICAL DATA**

The James A. FitzPatrick Nuclear Power Plant Offsite Dose Calculation Manual (ODCM), Part 1, Radiological Controls (REC) Section 6.2 and 6.2.2 states in part: The Annual Radioactive Effluent Release Report submitted prior to May 1 of each year may include an annual summary of meteorological data collected over the previous year. If the meteorological data is not included, the licensee shall retain it on file and provide it to the U.S. Nuclear Regulatory Commission upon request. In accordance with the aforementioned ODCM requirement, meteorological data is not included in this report. It is retained on file and is available upon request.

ENTERGY NUCLEAR OPERATIONS, INC.  
JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
JANUARY 2006-DECEMBER 2006

**ATTACHMENT NO. 6**

**MAJOR MODIFICATIONS TO RADIOACTIVE LIQUID, GASEOUS AND SOLID  
WASTE TREATMENT SYSTEMS**

In accordance with the James A. FitzPatrick Nuclear Power Plant Offsite Dose Calculation Manual (ODCM), Part 1 Radiological Controls (REC) Section 7.0, Major Modifications to Radioactive Waste Treatment Systems (liquid, gaseous and solid) shall be reported in the Annual Radioactive Effluent Release Report for the period in which the modification is completed and made operational.

There were no major modifications to any liquid, gaseous, or solid radioactive waste treatment systems.

ENTERGY NUCLEAR OPERATIONS, INC.  
JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
JANUARY 2006-DECEMBER 2006

**ATTACHMENT NO. 7**

**GASEOUS EFFLUENTS – UNMONITORED SHORT-TERM RELEASE**

- a) **Date:** October 28, 2006
- b) **Location:** Unmonitored Release from the Reactor Building via the Decay Heat Removal System Basin
- c) **Duration:** 16 Hours and 32 minutes
- d) **Flowrate:** 2.80E+05 cfm
- e) **Volume Released:** 2.78E+08
- f) **Nuclides Released:** See Table 1 – Supplemental Gaseous Effluents – Unmonitored Short-Term Release
- g) **Resultant Doses:** See Addendum 1—Assessment of Radiation Doses to the Public January-December 2006 Table 1.D
- h) **Dose Calculations:** Doses were calculated in accordance with the Offsite Dose Calculation Manual (ODCM) Section 4.4.3 Short Term Releases

ENTERGY NUCLEAR OPERATIONS, INC.  
JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
JANUARY 2006-DECEMBER 2006

ADDENDUM 1

ASSESSMENT OF RADIATION DOSES TO THE PUBLIC  
JANUARY - DECEMBER 2006

1. INTRODUCTION

The James A. FitzPatrick Nuclear Power Plant Offsite Dose Calculation Manual (ODCM), Part 1 Radiological Controls, requires an assessment of the radiation doses to the public due to radioactive liquid and gaseous effluents. This assessment of doses to the public is based on accepted methodologies found in the Offsite Dose Calculation Manual (ODCM).

2. DOSE LIMITS

A. DOSE FROM LIQUID EFFLUENTS (ODCM, Part 1, REC 2.3)

Applicability

Applies to doses from radioactive material in liquid effluents.

Objective

To ensure that the dose limitations of 10 CFR 50, Appendix I, are met.

Specifications

The dose to a member of the public from radioactive materials released from the plant in liquid effluents to unrestricted areas shall be limited as follows:

1. During any calendar quarter, limited to less than or equal to 1.5 mrem to the whole body and to less than or equal to 5 mrem to any organ.
2. During any calendar year, limited to less than or equal to 3 mrem to the whole body and to less than or equal to 10 mrem to any organ.

B. GASEOUS DOSE RATES (ODCM, Part 1, REC 3.2)

Applicability

Applies to the radiation dose from radioactive material in gaseous effluents.

ENTERGY NUCLEAR OPERATIONS, INC.  
JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
JANUARY 2006-DECEMBER 2006

**ADDENDUM 1 (continued)**

Objective

To ensure that the dose rates at or beyond the site boundary from gaseous effluents do not exceed the annual dose limits of 10 CFR 20, for unrestricted areas.

Specifications

The dose rate at or beyond the site boundary due to radioactive materials released from the plant in gaseous effluents shall be limited as follows:

1. Less than or equal to 500 mrem/year to the whole body and less than or equal to 3000 mrem/year to the skin from noble gases; and,
2. Less than or equal to 1500 mrem/year to any organ from Iodine-131, Iodine-133, Tritium and for radioactive materials in particulate form with half-lives greater than 8 days (inhalation pathway only).

C. AIR DOSE, NOBLE GASES (ODCM, Part 1, REC 3.3)

Applicability

Applies to the air dose due to noble gases in gaseous effluents.

Objective

To ensure that the noble gas dose limitations of 10 CFR 50, Appendix I, are met.

Specifications

The air dose to areas at or beyond the site boundary from noble gases released from the plant in gaseous effluents shall be limited:

1. During any calendar quarter, to less than or equal to 5 mrad from gamma radiation, and less than or equal to 10 mrad from beta radiation; and,
2. During any calendar year, to less than or equal to 10 mrad from gamma radiation and less than or equal to 20 mrad from beta radiation.

ENTERGY NUCLEAR OPERATIONS, INC.  
JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
JANUARY 2006-DECEMBER 2006

**ADDENDUM 1 (continued)**

- D. DOSE DUE TO IODINE-131, IODINE-133, TRITIUM AND RADIONUCLIDES IN PARTICULATE FORM (ODCM, Part 1, REC 3.4)

Applicability

Applies to the cumulative dose from Iodine-131, Iodine-133, Tritium, and radionuclides in particulate form with half-lives greater than 8 days in gaseous effluents.

Objective

To ensure that the dose limitations of 10 CFR 50, Appendix I, are met.

Specifications

The dose to a member of the public at or beyond the site boundary from Iodine-131, Iodine-133, Tritium, and radionuclides in particulate form with half-lives greater than 8 days released from the plant in gaseous effluents shall be limited:

1. During any calendar quarter to less than or equal to 7.5 mrem to any organ; and,
2. During any calendar year to less than or equal to 15 mrem to any organ.

- E. TOTAL DOSE FROM URANIUM FUEL CYCLE (ODCM, Part 1, REC 4.0)

Applicability

Applies to radiation dose from releases of radioactivity and radiation from uranium fuel cycle sources.

Objective

To ensure that the requirements of 40 CFR 190 are met.

ENTERGY NUCLEAR OPERATIONS, INC.  
JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
JANUARY 2006-DECEMBER 2006

**ADDENDUM 1 (continued)**

Specifications

The dose or dose commitment to any member of the public, due to releases of radioactivity and radiation, from uranium fuel cycle sources shall be limited as follows:

1. Less than or equal to 25 mrem/year to the whole body; and,
2. Less than or equal to 25 mrem/year to any organ except the thyroid which shall be limited to less than or equal to 75 mrem/year.

**3. DOSE ASSESSMENT**

**A. METHODOLOGY**

The assessment of radiation doses to the public due to radioactive liquid and gaseous effluents is performed in accordance with the ODCM. The ODCM is based on methodologies and models suggested by the "Guidance Manual For Preparation of Radiological Effluent Technical Specifications for Nuclear Power Plants" (NUREG-0133) and "Calculation of Annual Doses to Man from Routine Releases of Reactor Effluents for the purpose of Evaluating Compliance with 10CFR50, Appendix I" (Regulatory Guide 1.109).

**B. ASSUMPTIONS**

Dose calculations are performed using formulas and constants defined in the ODCM. Specific radioactive release activities used in the dose calculations are listed in the Annual Radioactive Effluent Release Report (1.21 Report) for the period of January 1, 2006 to December 31, 2006. Historical meteorological data was used to generate tables of average dispersion factors. Locations of interest were identified from the 2006 land use census. Dispersion factors and locations of interest used in performing the dose calculations are listed in Table 2.

**C. ASSESSMENT RESULTS SUMMARY**

The calculated doses to the public due to radioactive effluents are listed in Table 1. The calculated doses are small fractions of their respective dose limits.



ENTERGY NUCLEAR OPERATIONS, INC.  
JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
JANUARY 2006-DECEMBER 2006

**ADDENDUM 1 (continued)**

**4. 40 CFR 190 DOSE ASSESSMENT**

**A. METHODOLOGY**

Evaluation to demonstrate compliance with the 40 CFR 190 dose limits must be performed when the doses calculated for 10 CFR 50 compliance exceed twice their respective limits. When additional dose assessment is required to demonstrate compliance with 40 CFR 190 it is performed in accordance with the ODCM.

**B. RESULTS SUMMARY**

The cumulative dose contribution from liquid and gaseous effluents for this report period were calculated and are listed in Table 1. The cumulative dose contribution from direct radiation from the reactor unit and from radwaste storage tanks is measured by environmental thermoluminescent dosimeters for the report period. This data is contained in the Annual Environmental Operating Report. The calculated doses from liquid and gaseous effluents are less than twice their respective 10 CFR 50 limits, therefore, additional calculations are not necessary to demonstrate compliance with 40 CFR 190 dose limits (ODCM, Part 1, REC 4.1.1.c)

ENTERGY NUCLEAR OPERATIONS, INC.  
 JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
 JANUARY 2006-DECEMBER 2006

**ADDENDUM 1 (continued)**

**TABLE 1  
 ANNUAL DOSE ASSESSMENT 2006**

---

A. LIQUIDS					
QUARTER	<u>1</u>	<u>2</u>	<u>3</u>	<u>4</u>	<u>ANNUAL</u>
	(a)	(a)	(a)	(a)	(a)
Organ (mrem)	1.29E-06	4.78E-06	2.80E-06	1.32E-05	2.21E-05
% of Limit	2.57E-05	9.57E-05	5.61E-05	2.63E-04	2.21E-04
	(b)	(b)	(b)	(b)	(b)
Whole Body (mrem)	1.29E-06	4.78E-06	2.80E-06	1.32E-05	2.21E-05
% of Limit	8.58E-05	3.19E-04	1.87E-04	8.50E-04	7.37E-04

(a) Dose to the Child Liver primarily by the potable water pathway.  
 (b) Dose to the Child Whole Body primarily by the potable water pathway.

---

B. NOBLE GASES					
QUARTER	<u>1</u>	<u>2</u>	<u>3</u>	<u>4</u>	<u>ANNUAL</u>
Total Body (mrem/yr)	1.80E-01	2.75E-01	6.43E-02	6.20E-02	2.75E-01
% of Limit	3.60E-02	5.50E-02	1.29E-02	1.24E-02	5.50E-02
Skin (mrem/yr)	3.09E-01	4.60E-01	1.41E-01	1.04E-01	4.60E-01
% of Limit	1.03E-02	1.53E-02	4.70E-03	3.46E-03	1.53E-02
Gamma (mrad)	2.68E-03	4.62E-03	6.18E-03	1.17E-03	1.47E-02
% of Limit	5.37E-02	9.25E-02	1.24E-01	2.34E-02	1.47E-01
Beta (mrad)	2.12E-02	1.10E-02	7.34E-03	8.54E-04	4.03E-02
% of Limit	2.12E-01	1.10E-02	7.34E-02	8.54E-03	2.02E-01

---

ENTERGY NUCLEAR OPERATIONS, INC.  
 JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
 JANUARY 2006-DECEMBER 2006

**ADDENDUM 1 (continued)**

**TABLE 1  
 ANNUAL DOSE ASSESSMENT 2006**

---

**C. IODINES AND PARTICULATES**

<u>QUARTER</u>	<u>1</u>	<u>2</u>	<u>3</u>	<u>4</u>	<u>ANNUAL</u>
	(a)	(b)	(a)	(b)	(b)
Organ (mrem)	6.76E-03	6.96E-03	4.78E-03	2.79E-02	4.64E-02
% of Limit	9.01E-02	9.28E-02	6.37E-02	3.72E-01	3.09E-01
	(c)	(c)	(c)	(c)	(c)
Organ Dose Rate (mrem/yr)	7.51E-04	5.81E-04	3.01E-04	9.26E-03	9.26E-03
% of Limit	5.00E-05	3.87E-05	2.01E-05	6.17E-04	6.17E-04

---

- (a) Dose to the Infant Thyroid primarily by the goats milk pathway.  
 (b) Dose to the Infant Thyroid primarily by the cows milk pathway.  
 (c) Dose to the Child Thyroid primarily by the vegetation pathway.
- 

**D. UNMONITORED SHORT-TERM RELEASE  
 QUARTER 4**

<u>QUARTER</u>	<u>1</u>	<u>2</u>	<u>3</u>	<u>4</u>	<u>ANNUAL</u>
				(a)	(b)
Organ (mrem)				1.45E-04	1.45E-04
% of Limit				1.93E-03	9.67E-04
Organ Dose Rate (mrem/yr)				6.28E-04	6.28E-04
% of Limit				4.19E-05	4.19E-05

---

- (a) Dose to the Child Liver primarily by the vegetation pathway.  
 (b) Dose to the Child Thyroid primarily by the vegetation pathway.

ENTERGY NUCLEAR OPERATIONS, INC.  
 JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
 JANUARY 2006-DECEMBER 2006

**ADDENDUM 1 (continued)**

**TABLE 2  
 METEOROLOGICAL DATA AND LOCATIONS OF INTEREST**

RECEPTOR	GEOGRAPHIC LOCATION	ATMOSPHERIC** DISPERSION FACTOR			
		DISTANCE/ DIRECTION	RELEASE POINT	X/Q (sec/m <sup>3</sup> )	D/Q (l/m <sup>2</sup> )
A. IODINE & PARTICULATES	1. Garden	0.90 mi @ 83°E	ST	2.83E-08*	1.75E-09
	Grazing Season	0.90 mi @ 83°E	RX	2.02E-07*	5.01E-09
	Cary	0.90 mi @ 83°E	TB	1.83E-07*	4.80E-09
	Location No. 78	0.90 mi @ 83°E	RF	2.02E-07*	5.01E-09
		0.90 mi @ 83°E	RW	3.21E-07*	5.76E-09
2. Meat	Grazing Season	1.18 mi @ 127°SE	ST	1.72E-08*	6.80E-10
	Parkhurst	1.18 mi @ 127°SE	RX	5.36E-08*	1.30E-09
	Location No. 26	1.18 mi @ 127°SE	TB	5.14E-08*	1.27E-09
		1.18 mi @ 127°SE	RF	5.36E-08*	1.30E-09
		1.18 mi @ 127°SE	RW	9.12E-08*	1.46E-09
3. Cow	Grazing Season	2.50 mi @ 139°SE	ST	1.67E-08*	2.65E-10
	France	2.50 mi @ 139°SE	RX	2.76E-08*	4.14E-10
	Location No. 10	2.50 mi @ 139°SE	TB	2.71E-08*	4.07E-10
		2.50 mi @ 139°SE	RF	2.76E-08*	4.14E-10
		2.50 mi @ 139°SE	RW	4.15E-08*	4.36E-10
4. Goat (D/Q)	Grazing Season	3.62 mi @ 113°ESE	ST	-----	2.28E-10
	Showers	3.62 mi @ 113°ESE	RX	-----	3.40E-10
	Location No. 71	3.62 mi @ 113°ESE	TB	-----	3.33E-10
		3.62 mi @ 113°ESE	RF	-----	3.40E-10
		3.62 mi @ 113°ESE	RW	-----	3.49E-10
5. Goat (X/Q)	Grazing Season	2.64 mi @ 152°SSE	ST	1.94E-08*	-----
	Nickolas	2.64 mi @ 152°SSE	RX	2.58E-08*	-----
	Location No. 61	2.64 mi @ 152°SSE	TB	2.57E-08*	-----
		2.64 mi @ 152°SSE	RF	2.58E-08*	-----
		2.64 mi @ 152°SSE	RW	3.59E-08*	-----

ENTERGY NUCLEAR OPERATIONS, INC.  
 JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
 JANUARY 2006-DECEMBER 2006

**ADDENDUM 1 (continued)**

**TABLE 2  
 METEOROLOGICAL DATA AND LOCATIONS OF INTEREST**

RECEPTOR	GEOGRAPHIC LOCATION	ATMOSPHERIC** DISPERSION FACTOR		
A. IODINE & PARTICULATES	DISTANCE/ DIRECTION	RELEASE POINT	X/Q (sec/m3)	D/Q (l/m2)
<hr/>				
6. Resident Annual Average				
a. Inhalation <sup>(2)</sup>				
Cary	1.55 mi @ 90°E <sup>(1)</sup>	ST	2.99E-08	-----
Location No. 78	0.90 mi @ 83°E	RX	2.07E-07	-----
	0.90 mi @ 83°E	TB	1.88E-07	-----
	0.90 mi @ 83°E	RF	2.07E-07	-----
	0.90 mi @ 83°E	RW	3.06E-07	-----
b. Deposition <sup>(3)</sup>				
Whaley	0.71 mi @ 118°ESE	ST	-----	1.60E-09
Location No. 199	0.71 mi @ 118°ESE	RX	-----	5.52E-09
	0.71 mi @ 118°ESE	TB	-----	5.30E-09
	0.71 mi @ 118°ESE	RF	-----	5.52E-09
	0.71 mi @ 118°ESE	RW	-----	6.28E-09
<hr/>				
B. NOBLE GASES				
1. Air Dose				
Annual Average	1.55 mi @ 90°E <sup>(1)</sup>	ST	2.99E-08	-----
Site Boundary	0.60 mi @ 90°E	ST(fc)	1.16E-07	-----
	0.60 mi @ 90°E	RX	3.58E-07	-----
	0.60 mi @ 90°E	TB	3.19E-07	-----
	0.60 mi @ 90°E	RF	3.58E-07	-----
	0.60 mi @ 90°E	RW	5.39E-07	-----
2. Total Body				
Annual Average	0.60 mi @ 90°E	ST(fc)	1.16E-07	-----
Site Boundary	0.60 mi @ 90°E	RX	3.58E-07	-----
	0.60 mi @ 90°E	TB	3.19E-07	-----
	0.60 mi @ 90°E	RF	3.58E-07	-----
	0.60 mi @ 90°E	RW	5.39E-07	-----

ENTERGY NUCLEAR OPERATIONS, INC.  
 JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
 JANUARY 2006-DECEMBER 2006

**ADDENDUM 1 (continued)**

**TABLE 2  
 METEOROLOGICAL DATA AND LOCATIONS OF INTEREST**

RECEPTOR	GEOGRAPHIC LOCATION	ATMOSPHERIC** DISPERSION FACTOR		
		RELEASE POINT	X/Q (sec/m <sup>3</sup> )	D/Q (l/m <sup>2</sup> )
B. NOBLE GASES (continued)	DISTANCE/ DIRECTION			
3. Skin	1.55 mi @ 90°E	ST	2.99E-08	-----
Annual Average	0.60 mi @ 90°E	ST(fc)	1.16E-07	-----
Site Boundary	0.60 mi @ 90°E	RX	3.58E-07	-----
	0.60 mi @ 90°E	TB	3.19E-07	-----
	0.60 mi @ 90°E	RF	3.58E-07	-----
	0.60 mi @ 90°E	RW	5.39E-07	-----

\* Tritium Dose Calculation

\*\* Based on ODCM X/Q, D/Q Values Rev. 08

- (1) Highest Sector Average X/Q in a populated area, not an identified residence.
- (2) Inhalation uses Annual Average X/Q values. All other receptors use grazing season meteorology.
- (3) Deposition uses Annual Average D/Q values. All other receptors use grazing season meteorology.

ST = Main Stack

RX = Reactor Building Vent

TB = Turbine Building Vent

RF = Refuel Floor Vent

RW = Radwaste Building Vent

fc = Finite Cloud