



---

# ANNUAL RADIOLOGICAL ENVIRONMENTAL OPERATING REPORT

---

**DUKE ENERGY CORPORATION  
CATAWBA NUCLEAR STATION  
Units 1 and 2**

**2006**



---

# TABLE OF CONTENTS

---

<b>1.0 Executive Summary</b>	1-1
<b>2.0 Introduction</b>	2-1
2.1 Site Description and Sample Locations	2-1
2.2 Scope and Requirements of the REMP	2-1
2.3 Statistical and Calculational Methodology	2-2
2.3.1 Estimation of the Mean Value	2-2
2.3.2 Lower Level of Detection and Minimum Detectable Activity	2-3
2.3.3 Trend Identification	2-3
<b>3.0 Interpretation of Results</b>	3-1
3.1 Airborne Radioiodine and Particulates	3-2
3.2 Drinking Water	3-4
3.3 Surface Water	3-6
3.4 Ground Water	3-8
3.5 Milk	3-9
3.6 Broadleaf Vegetation	3-10
3.7 Food Products	3-12
3.8 Fish	3-13
3.9 Shoreline Sediment	3-16
3.10 Direct Gamma Radiation	3-18
3.11 Land Use Census	3-20
<b>4.0 Evaluation of Dose</b>	4-1
4.1 Dose from Environmental Measurements	4-1
4.2 Estimated Dose from Releases	4-1
4.3 Comparison of Doses	4-2
<b>5.0 Quality Assurance</b>	5-1
5.1 Sample Collection	5-1
5.2 Sample Analysis	5-1
5.3 Dosimetry Analysis	5-1
5.4 Laboratory Equipment Quality Assurance	5-1
5.4.1 Daily Quality Control	5-1
5.4.2 Calibration Verification	5-1
5.4.3 Batch Processing	5-2
5.5 Duke Energy Intercomparison Program	5-2
5.6 Duke Energy Audits	5-2
5.7 U.S. Nuclear Regulatory Commission Inspections	5-2
5.8 State of South Carolina Intercomparison Program	5-2
5.9 TLD Intercomparison Program	5-2
5.9.1 Nuclear Technology Services Intercomparison Program	5-2
5.9.2 State of North Carolina Intercomparison Program	5-3
5.9.3 Internal Crosscheck (Duke Energy)	5-3
<b>6.0 References</b>	6-1

## Appendices

Appendix A: Environmental Sampling and Analysis Procedures . . . . .	A-1
I. Change of Sampling Procedures . . . . .	A-2
II. Description of Analysis Procedures . . . . .	A-2
III. Change of Analysis Procedures . . . . .	A-3
IV. Sampling and Analysis Procedures . . . . .	A-3
A.1 Airborne Particulate and Radioiodine . . . . .	A-3
A.2 Drinking Water . . . . .	A-3
A.3 Surface Water . . . . .	A-4
A.4 Ground Water . . . . .	A-4
A.5 Milk . . . . .	A-4
A.6 Broadleaf Vegetation . . . . .	A-4
A.7 Food Products . . . . .	A-5
A.8 Fish . . . . .	A-5
A.9 Shoreline Sediment . . . . .	A-5
A.10 Direct Gamma Radiation (TLD) . . . . .	A-5
A.11 Annual Land Use Census . . . . .	A-6
V. Global Positioning System (GPS) Analysis . . . . .	A-6
Appendix B: Radiological Env. Monitoring Program - Summary of Results . . . . .	B-1
Air Particulate . . . . .	B-2
Air Radioiodine. . . . .	B-3
Drinking Water . . . . .	B-4
Surface Water . . . . .	B-5
Ground Water . . . . .	B-6
Milk . . . . .	B-7
Broadleaf Vegetation . . . . .	B-8
Food Products . . . . .	B-9
Fish . . . . .	B-10
Shoreline Sediment . . . . .	B-11
Direct Gamma Radiation (TLD) . . . . .	B-12
Appendix C: Sampling Deviations and Unavailable Analyses . . . . .	C-1
C.1 Sampling Deviations . . . . .	C-2
C.2 Unavailable Analyses . . . . .	C-3
Appendix D: Analytical Deviations . . . . .	D-1
Appendix E: Radiological Environmental Monitoring Program Results . . . . .	E-1

## LIST OF FIGURES

2.1-1	Sampling Locations Map (One Mile Radius) . . . . .	2-4
2.1-2	Sampling Locations Map (Ten Mile Radius) . . . . .	2-5
3.1	Concentration of Gross Beta in Air Particulate . . . . .	3-2
3.2	Concentration of Tritium in Drinking Water . . . . .	3-5
3.3	Concentration of Tritium in Surface Water . . . . .	3-6
3.6	Concentration of Cs-137 in Broadleaf Vegetation . . . . .	3-10
3.8-1	Concentration of Co-58 in Fish . . . . .	3-14
3.8-2	Concentration of Co-60 in Fish . . . . .	3-14
3.9-1	Concentration of Co-58 in Shoreline Sediment . . . . .	3-16
3.9-2	Concentration of Co-60 in Shoreline Sediment . . . . .	3-17
3.10	Direct Gamma Radiation (TLD) Results . . . . .	3-18
3.11	2006 Land Use Census Map . . . . .	3-21

## LIST OF TABLES

2.1-A	Radiological Monitoring Program Sampling Locations . . . . .	2-6
2.1-B	Radiological Monitoring Program Sampling Locations (TLD Sites) . . . . .	2-7
2.2-A	Reporting Levels for Radioactivity Concentrations in Environmental Samples . . . . .	2-8
2.2-B	REMP Analysis Frequency . . . . .	2-8
2.2-C	Maximum Values for the Lower Limits of Detection . . . . .	2-9
3.1-A	Mean Concentration of Gross Beta in Air Particulate . . . . .	3-3
3.1-B	Mean Concentration of Air Radioiodine (I-131) . . . . .	3-3
3.2	Mean Concentrations of Radionuclides in Drinking Water . . . . .	3-5
3.3	Mean Concentrations of Radionuclides in Surface Water . . . . .	3-7
3.5	Mean Concentration of Radionuclides in Milk . . . . .	3-9
3.6	Mean Concentration of Radionuclides in Broadleaf Vegetation . . . . .	3-11
3.7	Mean Concentration of Radionuclides in Food Products . . . . .	3-12
3.8	Mean Concentrations of Radionuclides in Fish . . . . .	3-15
3.9	Mean Concentrations of Radionuclides in Shoreline Sediment . . . . .	3-17
3.10	Direct Gamma Radiation (TLD) Results . . . . .	3-19
3.11	Land Use Census Results . . . . .	3-20
4.1-A	2006 Environmental and Effluent Dose Comparison . . . . .	4-3
4.1-B	Maximum Individual Dose for 2006 based on Environmental Measurements for Catawba Nuclear Station . . . . .	4-6
5.0-A	2006 Cross-Check Results for EnRad Laboratories . . . . .	5-4
5.0-B	2006 Environmental Dosimeter Cross-Check Results . . . . .	5-10

## LIST OF ACRONYMS USED IN THIS TEXT *(in alphabetical order)*

BW	BiWeekly
C	Control
CNS	Catawba Nuclear Station
DEHNR	Department of Environmental Health and Natural Resources
DHEC	Department of Health and Environmental Control
EPA	Environmental Protection Agency
GI-LLI	Gastrointestinal – Lower Large Intestine
GPS	Global Positioning System
LLD	Lower Limit of Detection
M	Monthly
MDA	Minimum Detectable Activity
mrem	Millirem
NIST	National Institute of Standards and Technology
NRC	Nuclear Regulatory Commission
ODCM	Offsite Dose Calculation Manual
pCi/kg	picocurie per kilogram
pCi/l	picocurie per liter
pCi/m <sup>3</sup>	picocurie per cubic meter
PIP	Problem Investigation Process
Q	Quarterly
REMP	Radiological Environmental Monitoring Program
SA	Semiannually
SLCs	Selected Licensee Commitments
SM	Semimonthly
TECH SPECS	Technical Specifications
TLD	Thermoluminescent Dosimeter
μCi/ml	microcurie per milliliter
UFSAR	Updated Final Safety Analysis Report
W	Weekly

---

# 1.0 EXECUTIVE SUMMARY

---

This Annual Radiological Environmental Operating Report describes the Catawba Nuclear Station Radiological Environmental Monitoring Program (REMP), and the program results for the calendar year 2006.

Included are the identification of sampling locations, descriptions of environmental sampling and analysis procedures, comparisons of present environmental radioactivity levels and pre-operational environmental data, comparisons of doses calculated from environmental measurements and effluent data, analysis of trends in environmental radiological data as potentially affected by station operations, and a summary of environmental radiological sampling results. Quality assurance practices, sampling deviations, unavailable samples, and program changes are also discussed.

Sampling activities were conducted as prescribed by Selected Licensee Commitments (SLCs). Required analyses were performed and detection capabilities were met for all collected samples as required by SLCs. Eight-hundred eighty-seven samples were analyzed comprising 1,199 test results in order to compile data for the 2006 report. Based on the annual land use census, the current number of sampling sites for Catawba Nuclear Station is sufficient.

Concentrations observed in the environment in 2006 for station related radionuclides were generally within the ranges of concentrations observed in the past. Inspection of data showed that radioactivity concentrations in surface water, drinking water, shoreline sediment, and fish are higher than the activities reported for samples collected prior to the operation of the station. Measured concentrations were not higher than expected, and all positively identified measurements were within limits as specified in SLCs.

Additionally, environmental radiological monitoring data is consistent with effluents introduced into the environment by plant operations. The total body dose estimated to the maximum exposed member of the public as calculated by environmental sampling data, excluding TLD results, was 3.82E-01 mrem for 2006. It is therefore concluded that station operations has had no significant radiological impact on the health and safety of the public or the environment.



Shoreline Sediment sampling

---

## **2.0 INTRODUCTION**

---

### **2.1 SITE DESCRIPTION AND SAMPLE LOCATIONS**

Duke Energy Corporation's Catawba Nuclear Station is a two-unit facility located on the shore of Lake Wylie in York County, South Carolina. Each of the two essentially identical units employs a pressurized water reactor nuclear steam supply system furnished by Westinghouse Electric Corporation. Each generating unit is designed to produce a net electrical output of approximately 1145 MWe. Units 1 and 2 achieved initial criticality on January 7, 1985, and May 8, 1986, respectively.

Condenser cooling is accomplished utilizing a closed system incorporating cooling towers, instead of using lake water directly. Liquid effluents are released into Lake Wylie via the station discharge canal and are not accompanied by the large additional dilution water flow associated with "once-through" condenser cooling. This design results in greater radionuclide concentrations in the discharge canal given comparable liquid effluent source terms.

Figures 2.1-1 and 2.1-2 are maps depicting the Thermoluminescent Dosimeter (TLD) monitoring locations and the sampling locations. The location numbers shown on these maps correspond to those listed in Tables 2.1-A and 2.1-B. Figure 2.1-1 comprises all sample locations within a one mile radius of CNS. Figure 2.1-2 comprises all sample locations within a 10 mile radius of CNS.

### **2.2 SCOPE AND REQUIREMENTS OF THE REMP**

An environmental monitoring program has been in effect at Catawba Nuclear Station since 1981, four years prior to operation of Unit 1 in 1985. The preoperational program provides data on the existing environmental radioactivity levels for the site and vicinity which may be used to determine whether increases in environmental levels are attributable to the station. The operational program provides surveillance and backup support of detailed effluent monitoring which is necessary to evaluate the significance, if any, of the contributions to the existing environmental radioactivity levels that result from station operation.

This monitoring program is based on NRC guidance as reflected in the Selected Licensee Commitments Manual, with regard to sample media, sampling locations, sampling frequency and analytical sensitivity requirements. Indicator and control locations were established for comparison purposes to distinguish radioactivity of station origin from natural or other "man-made" environmental radioactivity. The environmental monitoring program also verifies projected and anticipated radionuclide concentrations in the environment and related exposures from releases of radionuclides from Catawba Nuclear Station. This program satisfies the requirements of Section IV.B.2 of Appendix I to 10CFR50 and provides surveillance of all appropriate critical exposure pathways to man and protects vital interests of

the company, public and state and federal agencies concerned with the environment. Reporting levels for activity found in environmental samples are listed in Table 2.2-A. Table 2.2-B lists the REMP analysis and frequency schedule.

The Annual Land Use Census, required by Selected Licensee Commitments, is performed to ensure that changes in the use of areas at or beyond the site boundary are identified and that modifications to the REMP are made if required by changes in land use. This census satisfies the requirements of Section IV.B.3 of Appendix I to 10CFR50. Results are shown in Table 3.11.

Participation in an interlaboratory comparison program as required by Selected Licensee Commitments provides for independent checks on the precision and accuracy of measurements of radioactive material in REMP sample matrices. Such checks are performed as part of the quality assurance program for environmental monitoring in order to demonstrate that the results are valid for the purposes of Section IV.B.2 of Appendix I to 10CFR50. A summary of the results obtained as part of this comparison program are in Section 5 of this annual report.

## **2.3 STATISTICAL AND CALCULATIONAL METHODOLOGY**

### **2.3.1 ESTIMATION OF THE MEAN VALUE**

There was one (1) basic statistical calculation performed on the raw data resulting from the environmental sample analysis program. The calculation involved the determination of the mean value for the indicator and the control samples for each sample medium. The mean is a widely used statistic. This value was used in the reduction of the data generated by the sampling and analysis of the various media in the REMP. The following equation was used to estimate the mean (Reference 6.8):

$$\bar{x} = \frac{\sum_{i=1}^N x_i}{N}$$

Where:

$\bar{x}$  = estimate of the mean,

i = individual sample,

N = total number of samples with a net activity (or concentration),

$x_i$  = net activity (or concentration) for sample i.

NOTE: "Net activity (or concentration)" is the activity (or concentration) determined to be present in the sample. No "Minimum Detectable Activity", "Lower Limit of Detection", "Less Than Level", or negative activities or concentrations are included in the calculation of the mean.

### **2.3.2 LOWER LEVEL OF DETECTION AND MINIMUM DETECTABLE ACTIVITY**

The Lower Level of Detection (LLD), and Minimum Detectable Activity (MDA) are used throughout the REMP.

**LLD** - The LLD, as defined in the Selected Licensee Commitments Manual is the smallest concentration of radioactive material in a sample that will yield a net count, above the system background, that will be detected with 95% probability with only 5% probability of falsely concluding that a blank observation represents a "real" signal. The LLD is an *a priori* lower limit of detection. The actual LLD is dependent upon the standard deviation of the background counting rate, the counting efficiency, the sample size (mass or volume), the radiochemical yield and the radioactive decay of the sample between sample collection and counting. The "required" LLD's for each sample medium and selected radionuclides are given in the Selected Licensee Commitments and are listed in Table 2.2-C.

**MDA** - The MDA may be thought of as an "actual" LLD for a particular sample measurement remembering that the MDA is calculated using a sample background instead of a system background.

### **2.3.3 TREND IDENTIFICATION**

One of the purposes of an environmental monitoring program is to determine if there is a buildup of radionuclides in the environment due to the operation of the nuclear station. Visual inspection of tabular or graphical presentations of data (including preoperational) is used to determine if a trend exists. A decrease in a particular radionuclide's concentration in an environmental medium does not indicate that reactor operations are removing radioactivity from the environment but that reactor operations are not adding that radionuclide to the environment in quantities exceeding the preoperational level and that the normal removal processes (radioactive decay, deposition, resuspension, etc.) are influencing the concentration.

Substantial increases or decreases in the amount of a particular radionuclide's release from the nuclear plant will greatly affect the resulting environmental levels; therefore, a knowledge of the release of a radionuclide from the nuclear plant is necessary to completely interpret the trends, or lack of trends, determined from the environmental data. Factors that may affect environmental levels of radionuclides include prevailing weather conditions (periods of drought, solar cycles or heavier than normal precipitation), construction in or around either the nuclear plant or the sampling location, and addition or deletion of other sources of radioactive materials (such as the Chernobyl accident). Some of these factors may be obvious while others are sometimes unknown. Therefore, how trends are identified will include some judgment by plant personnel.



Figure 2.1-1





Figure 2.1-2



**TABLE 2.1-A**

**CATAWBA RADIOLOGICAL MONITORING PROGRAM  
SAMPLING LOCATIONS**

Table 2.1-B Codes			
W	Weekly	SM	Semimonthly
BW	BiWeekly	Q	Quarterly
M	Monthly	SA	Semiannually
C	Control		

Site #	Location Description*	Air Rad. & Part.	Surface Water	Drinking Water	Shoreline Sediment	Food Products (a)	Fish	Milk	Broad Leaf Veg. (b)	Ground Water
200	Site Boundary (0.63 mi NNE)	W							M	
201	Site Boundary (0.53 mi NE)	W							M	
205	Site Boundary (0.23 mi SW)	W								
208	Discharge Canal (0.45 mi S)		M		SA		SA			
210	Ebenezer Access (2.31 mi SE)				SA					
211	Wylie Dam (4.06 mi ESE)		M							
212	Tega Cay (3.32 mi E)	W								
214	Rock Hill Water Supply (7.30 mi SSE)			M						
215 C	River Pointe - Hwy 49 (4.21 mi NNE)		M		SA					
216 C	Hwy 49 Bridge (4.19 mi NNE)						SA			
218 C	Belmont Water Supply (13.5 mi NNE)			M						
221 C	Dairy (14.5 mi NW)							SM		
222	Site Boundary (0.70 mi N)								M	
226	Site Boundary (0.48 mi S)								M	
252	Residence (0.64 mi SW)									Q
253	Irrigated Gardens (1.90 mi SSE)					M(a)				
254	Residence (0.82 mi N)									Q
258 C	Fairhope Road (9.84 mi W)	W							M	

- (a) During Harvest Season
- (b) When Available

\* GPS data reflect approximate accuracy to within 2-5 meters. GPS field measurements were taken as close as possible to the item of interest.

**TABLE 2.1-B**  
**CATAWBA RADIOLOGICAL MONITORING PROGRAM**  
**SAMPLING LOCATIONS**

**(TLD SITES)**

Site #	Location*	Distance	Sector	Site #	Location*	Distance	Sector
200	SITE BOUNDARY	0.63 miles	NNE	234	HOME FEDERAL BANK	4.50 miles	E
201	SITE BOUNDARY	0.53 miles	NE	235	LAKE WYLIE DAM	4.07 miles	ESE
203	SITE BOUNDARY	0.38 miles	ESE	236	SC WILDLIFE FEDERATION OFFICE	4.25 miles	SE
204	SITE BOUNDARY	0.48 miles	SSW	237	TWIN LAKES ROAD AND HOMESTEAD ROAD	4.75 miles	SSE
205	SITE BOUNDARY	0.23 miles	SW	238	PENNINGTON ROAD AND WEST OAK ROAD	4.02 miles	S
206	SITE BOUNDARY	0.67 miles	WNW	239	CARTER LUMBER COMPANY	4.49 miles	SSW
207	SITE BOUNDARY	0.95 miles	NNW	240	PARAHAM ROAD	4.07 miles	SW
212 SI	TEGA CAY AIR SITE	3.32 miles	E	241	CAMPBELL ROAD	4.58 miles	WSW
217 C	ROCK HILL AIR SITE	10.3 miles	SSE	242	TRANSMISSION TOWER ON PARAHAM ROAD	4.56 miles	W
222	SITE BOUNDARY	0.69 miles	N	243	KINGSBERRY ROAD	4.39 miles	WNW
223	SITE BOUNDARY	0.57 miles	E	244	BETHEL ELEMENTARY SCHOOL	4.02 miles	NW
225	SITE BOUNDARY	0.68 miles	SE	245	CROWDERS CREEK BOAT LANDING	4.01 miles	NNW
226	SITE BOUNDARY	0.48 miles	S	246 SI	CAROWINDS GUARD HOUSE	7.87 miles	ENE
227	SITE BOUNDARY	0.52 miles	WSW	247 C	FORT MILL	7.33 miles	ESE
228	SITE BOUNDARY	0.61 miles	W	248 SI	PIEDMONT MEDICAL CENTER	6.54 miles	S
229	SITE BOUNDARY	0.84 miles	NW	249 SI	YORK COUNTY OPERATIONS CENTER	7.17 miles	S
230	RIVER HILLS COMMUNITY CHURCH	4.37 miles	N	250 SI	YORK DUKE POWER OFFICE	10.4 miles	WSW
231	RIVER HILLS FRONT ENTRANCE	4.21 miles	NNE	251 C	CLOVER	9.72 miles	WNW
232	PLEASANT HILL ROAD	4.18 miles	NE	255	SITE BOUNDARY	0.61 miles	ENE
233	ZOAR ROAD AND THOMAS DRIVE	3.95 miles	ENE	256	SITE BOUNDARY	0.58 miles	SSE
				258	FAIRHOPE ROAD	9.84 miles	W

C = Control  
SI = Special Interest

\* GPS data reflect approximate accuracy to within 2-5 meters. GPS field measurements were taken as close as possible to the item of interest.

**TABLE 2.2-A**

**REPORTING LEVELS FOR RADIOACTIVITY  
CONCENTRATIONS IN ENVIRONMENTAL SAMPLES**

Analysis	Water (pCi/liter)	Air Particulates or Gases (pCi/m <sup>3</sup> )	Fish (pCi/kg-wet)	Milk (pCi/liter)	Food Products (pCi/kg-wet)
H-3	20,000 <sup>(a),(b)</sup>				
Mn-54	1,000		30,000		
Fe-59	400		10,000		
Co-58	1,000		30,000		
Co-60	300		10,000		
Zn-65	300		20,000		
Zr-Nb-95	400				
I-131	2	0.9		3	100
Cs-134	30	10	1,000	60	1,000
Cs-137	50	20	2,000	70	2,000
Ba-La-140	200			300	

- (a) If no drinking water pathway exists, a value of 30,000 pCi/liter may be used.  
 (b) H-3 Reporting level not applicable to surface water

**TABLE 2.2-B**

**REMP ANALYSIS FREQUENCY**

Sample Medium	Analysis Schedule	Gamma Isotopic	Tritium	Low Level I-131	Gross Beta	TLD
Air Radioiodine	Weekly	X				
Air Particulate	Weekly	X			X	
Direct Radiation	Quarterly					X
Surface Water	Monthly Composite	X				
	Quarterly Composite		X			
Drinking Water	Monthly Composite	X		(a)	X	
	Quarterly Composite		X			
Ground Water	Quarterly	X	X			
Shoreline Sediment	Semiannually	X				
Milk	Semimonthly	X		X		
Fish	Semiannually	X				
Broadleaf Vegetation	Monthly <sup>(b)</sup>	X				
Food Products	Monthly <sup>(b)</sup>	X				

- (a) Low-level I-131 analysis will be performed if the dose calculated for the consumption of drinking water is > 1 mrem per year. An LLD of 1 pCi/liter will be required for this analysis.  
 (b) When Available

**TABLE 2.2-C****MAXIMUM VALUES FOR THE LOWER LIMIT OF DETECTION**

Analysis	Water (pCi/liter)	Air Particulates or Gases (pCi/m <sup>3</sup> )	Fish (pCi/kg-wet)	Milk (pCi/liter)	Food Products (pCi/kg-wet)	Sediment (pCi/kg-dry)
Gross Beta	4	0.01				
H-3	2000 <sup>(a)</sup>					
Mn-54	15		130			
Fe-59	30		260			
Co-58, 60	15		130			
Zn-65	30		260			
Zr-Nb-95	15					
I-131	1 <sup>(b)</sup>	0.07		1	60	
Cs-134	15	0.05	130	15	60	150
Cs-137	18	0.06	150	18	80	180
Ba-La-140	15			15		

(a) If no drinking water pathway exists, a value of 3000 pCi/liter may be used.

(b) If no drinking water pathway exists, the LLD of gamma isotopic analysis may be used.

---

## 3.0 INTERPRETATION OF RESULTS

---

Review of all 2006 REMP analysis results was performed to identify changes in environmental levels as a result of station operations. The following section depicts and explains the review of these results. Sample data for 2006 was compared to preoperational and historical data. Over the years of operation, analysis and collection changes have taken place that do not allow direct comparisons for some data collected from 1984 (preoperational) through 2006. Summary tables containing 2006 information required by Technical Specification Administrative Control 5.6.2 are located in Appendix B.

Evaluation for significant trends was performed for radionuclides that are listed as required within Selected Licensee Commitments 16.11-13. The radionuclides include: H-3, Mn-54, Fe-59, Co-58, Co-60, Zn-65, Zr-95, Nb-95, I-131, Cs-134, Cs-137, Ba-140 and La-140. Gross beta analysis results were trended for drinking water and gross beta trending for air particulates was initiated in 1996. Other radionuclides detected that are the result of plant operation, but not required for reporting, are trended.

A comparison of annual mean concentrations of effluent-based detected radionuclides to historical results provided trending bases. Frequency of detection and concentrations related to SLC reporting levels (Table 2.2-A) were used as criteria for trending conclusions. All 2006 maximum percentages of reporting levels were well below the 100% action level. The highest value noted during 2006 was 7.99% for tritium in drinking water collected at the Rock Hill Water Supply, Location 214.

Selected Licensee Commitment section 16.11-13 addresses actions to be taken if radionuclides other than those required are detected in samples collected. The occurrences of these radionuclides are the result of CNS liquid effluents which contained the radionuclides.

During 1979-1986, all net activity results (sample minus background), both positive and negative were included in calculation of sample mean. A change in the EnRad gamma spectroscopy system on September 1, 1987, decreased the number of measurements yielding detectable low-level activity for indicator and control location samples. It was thought that the method used by the previous system was vulnerable to false-positive results.

All 2006 sample analysis results were reviewed to detect and identify any significant trends. Tables and graphs are used throughout this section to display data from effluent-based radionuclides identified since the system change in late 1987. All negative concentration values were replaced with zero for calculation purposes. Any zero concentrations used in tables or graphs represent activity measurements less than detectable levels.

Review of all 2006 data presented in this section supports the conclusion that there were no significant changes in environmental sample radionuclide concentrations of samples collected and analyzed from CNS site and surrounding areas that were attributable to plant operations.

### 3.1 AIRBORNE RADIOIODINE AND PARTICULATES

In 2006, 260 radioiodine and particulate samples were analyzed, 208 from four indicator locations and 52 at the control location. Particulate samples were analyzed weekly for gamma and gross beta. Radioiodine samples received a weekly gamma analysis.

Figure 3.1 shows individual sample gross beta results for the indicator location with highest annual mean and the control location samples during 2006. The two sample locations' results are similar in concentration and have varied negligibly since preoperational periods.


There were no detectable gamma emitters identified for particulate filters analyzed during 2006. Table 3.1-A shows the highest indicator annual mean and control location annual mean for gross beta in air particulate.



There was no detectable I-131 in air radioiodine samples analyzed in 2006. Table 3.1-B shows the highest indicator annual mean and control location annual mean for I-131 since 1984 (preoperational period).

K-40 and Be-7 that occur naturally were routinely detected in charcoal cartridges collected during the year. Cs-137 activity was detected in one indicator cartridge in 2006. Cs-137 detection on the charcoal cartridge was determined in 1990 to be an active constituent of the charcoal. A similar study was performed in 2001 again yielding this conclusion. Therefore, any Cs-137 activities were not used in any dose calculations in Section 4.0 of this report.

**Figure 3.1** *There is no reporting level for gross beta in air particulate*





**Table 3.1-A Mean Concentration of Gross Beta in Air Particulate**

Year	Indicator Location (pCi/m <sup>3</sup> )	Control Location (pCi/m <sup>3</sup> )
1984	2.25E-2	1.82E-2
1985	2.12E-2	1.53E-2
1986	3.62E-2	3.41E-2
1987	2.67E-2	2.32E-2
1988	2.29E-2	2.30E-2
1989	2.11E-2	2.13E-2
1990	2.39E-2	2.72E-2
1991	2.19E-2	2.51E-2
1992	1.90E-2	2.01E-2
1993	1.87E-2	1.94E-2
1994	2.03E-2	2.03E-2
1995	4.88E-2	3.23E-2
1996	3.49E-2	2.60E-2
1997	2.83E-2	2.28E-2
1998	2.69E-2	2.12E-2
1999	2.53E-2	2.04E-2
2000	2.28E-2	1.86E-2
2001	1.76E-2	1.78E-2
2002	1.60E-2	1.57E-2
2003	1.54E-2	1.42E-2
2004	1.65E-2	1.49E-2
2005	1.66E-2	1.68E-2
Average (1996 - 2005)	2.20E-2	1.88E-2
2006	1.74E-02	1.74E-02

**Table 3.1-B Mean Concentration of Air Radioiodine (I-131)**

Year	Indicator Location (pCi/m <sup>3</sup> )	Control Location (pCi/m <sup>3</sup> )
1984	1.30E-3	1.46E-2
1985	4.75E-3	2.38E-2
1986	1.43E-2	1.02E-2
1987	1.38E-2	0.00E0
1988	0.00E0	0.00E0
1989	0.00E0	0.00E0
1990	0.00E0	0.00E0
1991	0.00E0	0.00E0
1992	0.00E0	0.00E0
1993	0.00E0	0.00E0
1994	0.00E0	0.00E0
1995	0.00E0	0.00E0
1996	0.00E0	0.00E0
1997	0.00E0	0.00E0
1998	0.00E0	0.00E0
1999	0.00E0	0.00E0
2000	0.00E0	0.00E0
2001	0.00E0	0.00E0
2002	0.00E0	0.00E0
2003	0.00E0	0.00E0
2004	0.00E0	0.00E0
2005	0.00E0	0.00E0
2006	0.00E0	0.00E0

0.00E0 = no detectable measurements

## **3.2 DRINKING WATER**

Gross beta and gamma spectroscopy were performed on 26 drinking water samples. The samples were composited to create 8 quarterly samples that were analyzed for tritium. One indicator location was sampled, along with one control location.

No gamma emitting radionuclides were identified in 2006 drinking water samples. There have been no gamma emitting radionuclides identified in drinking water samples since 1988.


Table 3.2 shows highest annual mean gross beta concentrations for the indicator location and control location since preoperation. The indicator location (downstream of the plant effluent release point) average concentration was 2.30 pCi/l in 2006 and the control location concentration was 2.17 pCi/l. The 2005 indicator mean was 2.05 pCi/l. The table shows that current gross beta levels are not statistically different from preoperational concentrations.

Tritium was detected at low levels in the four indicator samples and the four control samples during 2006. The mean indicator tritium concentration for 2006 was 1598 pCi/l, 7.99% of reporting level. The mean control tritium concentration for 2005 was 769 pCi/l, 3.85% of reporting level. Figure 3.2 and Table 3.2 display the highest indicator and control location annual mean concentrations for tritium since 1984.

Tritium in drinking water control and indicator samples was higher in 2006 because of increased release volumes due to plant operations (See PIP C-06-08761) and releases from the McGuire Nuclear Station located approximately 40 miles upstream of Catawba on the Catawba River.

The dose for consumption of water was less than one mrem per year, historically and for 2006; therefore low-level iodine analysis is not required.

Figure 3.2



**Table 3.2 Mean Concentration of Radionuclides in Drinking Water**

YEAR	Gross Beta (pCi/l)		Tritium (pCi/l)	
	Indicator Location	Control Location	Indicator Location	Control Location
1984	4.72	1.83	3.10E-2	3.10E-2
1985	2.70	2.24	4.13E2	4.00E2
1986	3.11	2.26	7.23E2	7.33E2
1987	3.10	2.40	7.80E2	4.80E2
1988	3.60	2.60	6.64E2	0.00E0
1989	3.60	2.90	8.91E2	5.72E2
1990	4.50	3.20	7.03E2	0.00E0
1991	3.70	2.20	7.04E2	0.00E0
1992	3.20	2.40	7.65E2	5.38E2
1993	3.50	2.50	7.06E2	0.00E0
1994	3.30	2.70	0.00E0	0.00E0
1995	4.80	4.50	4.28E2	2.21E2
1996	3.08	3.14	3.71E2	3.27E2
1997	3.74	3.15	3.54E2	2.28E2
1998	2.51	2.44	5.07E2	1.83E2
1999	3.55	2.48	6.71E2	2.70E2
2000	3.04	2.27	5.87E2	3.26E2
2001	3.49	2.30	8.66E2	4.50E2
2002	3.44	2.36	1.22E3	4.11E2
2003	2.27	2.02	6.36E2	2.88E2
2004	1.88	1.69	5.47E2	2.54E2
2005	2.05	1.84	7.69E2	4.50E2
2006	2.30	2.17	1.59E3	7.70E2

0.00E0 = no detectable measurements  
 1984 - 1986 mean based on all net activity

### 3.3 SURFACE WATER


A total of 39 monthly surface water samples was analyzed for gamma emitting radionuclides. The samples were composited to create 12 quarterly samples for tritium analysis. Two indicator locations and one control location were sampled. One indicator location (208) is located near the liquid effluent discharge point.

Tritium was the only radionuclide identified in surface water samples collected during 2006. All indicator location samples contained tritium with an average concentration of 8998 pCi/l. Indicator Location 208 (Discharge Canal) showed a range of activities from 15400 to 18000 pCi/l which had the highest mean concentration of 16700 pCi/l. Tritium was detected in all four control samples during 2006 with an average concentration of 583 pCi/l.

Figure 3.3 displays the indicator and control annual means for tritium since 1984. Table 3.3 lists indicator annual means.

Tritium in surface water was higher than usual during 2006 because of increased release volumes due to plant operations (See PIP C-06-08761) and releases from the McGuire Nuclear Station located approximately 40 miles upstream of Catawba on the Catawba River.

Figure 3.3



*There is no reporting level for tritium in surface water, however, if no drinking water pathway exists, a value of 30,000 pCi/l may be used. A drinking water pathway exists for Catawba Nuclear Station, so this limit does not apply for surface water. See section 3.2 for drinking water results.*

**Table 3.3 Mean Concentrations of Radionuclides in Surface Water (pCi/l)**

<b>YEAR</b>	<b>Co-58</b>	<b>Co-60</b>	<b>Nb-95</b>	<b>Cs-137</b>	<b>H-3 Indicator</b>	<b>H-3 Control</b>
1984	4.59E-1	5.71E-1	6.48E-1	9.08E-1	3.35E2	3.18E2
1985	3.46E0	4.83E-2	2.70E0	8.19E-1	1.19E3	5.05E2
1986	3.10E-1	-4.12E-2	2.05E0	4.85E-1	2.34E3	5.05E2
1987	0.00E0	3.10E0	4.30E0	9.90E0	4.17E3	6.20E2
1988	9.20E0	0.00E0	0.00E0	0.00E0	6.03E3	6.07E2
1989	0.00E0	0.00E0	0.00E0	0.00E0	5.27E3	0.00E0
1990	6.50E0	0.00E0	0.00E0	0.00E0	3.98E3	7.73E2
1991	0.00E0	0.00E0	0.00E0	0.00E0	4.87E3	0.00E0
1992	0.00E0	0.00E0	0.00E0	0.00E0	6.91E3	6.64E2
1993	4.70E0	1.80E0	0.00E0	0.00E0	5.98E3	0.00E0
1994	0.00E0	0.00E0	0.00E0	0.00E0	8.42E3	0.00E0
1995	0.00E0	0.00E0	0.00E0	0.00E0	5.13E3	2.89E2
1996	0.00E0	0.00E0	0.00E0	0.00E0	7.36E3	2.61E2
1997	0.00E0	0.00E0	0.00E0	0.00E0	7.77E3	2.20E2
1998	0.00E0	0.00E0	0.00E0	0.00E0	6.61E3	0.00E0
1999	0.00E0	0.00E0	0.00E0	0.00E0	8.13E3	2.41E2
2000	0.00E0	0.00E0	0.00E0	0.00E0	7.19E3	2.56E2
2001	0.00E0	0.00E0	0.00E0	0.00E0	7.13E3	3.28E2
2002	0.00E0	0.00E0	0.00E0	0.00E0	1.00E4	3.80E2
2003	0.00E0	0.00E0	0.00E0	0.00E0	1.31E4	2.37E2
2004	0.00E0	0.00E0	0.00E0	0.00E0	9.43E3	2.60E2
2005	0.00E0	0.00E0	0.00E0	0.00E0	1.40E4	3.78E2
2006	0.00E0	0.00E0	0.00E0	0.00E0	1.67E4	5.83E2

0.00E0 = no detectable measurements

1984 - 1986 mean based on all net activity

### **3.4 GROUND WATER**

A total of eight ground water samples was collected and analyzed for gamma emitters. There are two indicator locations and no control locations. Naturally occurring K-40 was the only radionuclide identified during 2006.

There have been no radionuclides identified in ground water samples since 1988. Only naturally occurring K-40 and Be-7 were noted.

### 3.5 MILK

A total of 26 milk samples was analyzed by gamma spectroscopy and low level iodine during 2006. There was one control location sampled. No indicator dairies were identified by the 2006 land use census.

There were no gamma emitting radionuclides identified in milk during 2006. Airborne Cs-137 has not been released from the plant since 1992.

Cs-137 was last detected in an indicator sample during 1996. The occurrence of Cs-137 in milk samples has been noted several times since 1984. During 1995 there was also one sample analyzed in which Cs-137 was identified with a concentration of 8.6 pCi/l. Cs-137 attributable to past nuclear weapons testing is known to exist in many environmental media at low, highly variable levels.

Table 3.5 lists highest indicator location annual mean and control location annual mean for Cs-137 since the preoperational period. Concentrations are similar for the two sample types. Cs-137 is the only radionuclide, other than K-40 and Be-7, reported in milk samples since 1988.

**Table 3.5 Mean Concentration of Radionuclides in Milk**

YEAR	Cs-137 Indicator (pCi/l)	Cs-137 Control (pCi/l)
1984	2.95E0	2.98E0
1985	2.11E0	2.12E0
1986	3.76E0	4.54E0
1987	5.00E0	5.50E0
1988	3.20E0	3.80E0
1989	0.00E0	0.00E0
1990	8.00E0	6.70E0
1991	0.00E0	0.00E0
1992	3.40E0	5.00E0
1993	5.00E0	0.00E0
1994	2.80E0	0.00E0
1995	8.60E0	0.00E0
1996	6.05E0	0.00E0
1997	0.00E0	0.00E0
1998	0.00E0	0.00E0
1999	0.00E0	0.00E0
2000	0.00E0	0.00E0
2001	0.00E0	0.00E0
2002	0.00E0	0.00E0
2003	0.00E0	0.00E0
2004	NO INDICATOR LOCATION	0.00E0
2005	NO INDICATOR LOCATION	0.00E0
2006	NO INDICATOR LOCATION	0.00E0

0.00E0 = no detectable measurements

1984 - 1986 mean based on all net activity

### 3.6 BROADLEAF VEGETATION

Gamma spectroscopy was performed on 60 broadleaf vegetation samples during 2006. Four indicator locations and one control location were sampled.

Nine of the forty-eight samples collected at indicator locations contained detectable Cs-137 activity. Cs-137 was detected in nine of the twelve samples collected at Location 201. The highest concentration detected at Location 201 was 125 pCi/kg which is 6.25% of the reporting level. Cs-137 was not detected in any of the twelve control location samples.


Figure 3.6 shows indicator and control annual means for Cs-137 in vegetation since 1984. Table 3.6 lists indicator and annual means. Values shown from 1984 to 2006 show a stable trend for Cs-137 in vegetation.



No airborne Cs-137 has been released from the plant since 1992. Cs-137 attributable to past nuclear weapons testing is known to exist in many environmental media at low and highly variable levels.

K-40 and Be-7 were observed in broadleaf vegetation samples.

Figure 3.6





**Table 3.6 Mean Concentration of Radionuclides in Broadleaf Vegetation**

<b>YEAR</b>	<b>Cs-137 Indicator (pCi/kg)</b>	<b>Cs-137 Control (pCi/kg)</b>
1984	3.76E1	1.30E1
1985	5.48E1	4.16E1
1986	7.42E1	2.22E1
1987	6.10E1	5.10E1
1988	9.10E1	7.40E1
1989	1.00E2	4.80E1
1990	7.70E1	5.80E1
1991	1.98E2	8.60E1
1992	9.70E1	0.00E0
1993	1.13E2	3.20E1
1994	7.00E1	0.00E0
1995	3.60E1	0.00E0
1996	2.23E2	6.22E1
1997	7.57E1	0.00E0
1998	6.53E1	0.00E0
1999	1.08E2	0.00E0
2000	1.04E2	0.00E0
2001	3.76E1	0.00E0
2002	7.02E1	0.00E0
2003	4.96E1	2.40E1
2004	5.45E1	0.00E0
2005	5.48E1	0.00E0
2006	5.79E1	0.00E0

0.00E0 = no detectable measurements  
1984 - 1986 mean based on all net activity

### 3.7 FOOD PRODUCTS

Collection of food product samples (crops) from an irrigated garden began in 1989. The garden is located on Lake Wylie downstream from CNS, Location 253. During the 2006 growing season, four samples were collected and analyzed for gamma radionuclides. There is no control location for this media type.

Table 3.7 shows Cs-137 indicator location highest annual mean concentrations since 1989.

**Table 3.7 Mean Concentration of Radionuclides in Food Products**

<b>YEAR</b>	<b>Cs-137 Indicator (pCi/kg)</b>
1989	0.00E0
1990	0.00E0
1991	0.00E0
1992	0.00E0
1993	2.50E1
1994	0.00E0
1995	0.00E0
1996	0.00E0
1997	0.00E0
1998	0.00E0
1999	0.00E0
2000	0.00E0
2001	0.00E0
2002	0.00E0
2003	0.00E0
2004	0.00E0
2005	0.00E0
2006	0.00E0

0.00E0 = no detectable measurements

### 3.8 FISH

Gamma spectroscopy was performed on 12 fish samples collected during 2006. One downstream indicator location and one control location were sampled.

Co-58, Co-60, and Cs-137 are normally the predominant radionuclides identified in fish samples. Cs-137 was detected in one indicator sample in 2006 at a concentration of 14.4 pCi/kg, which is 0.72% of the reporting level. Cs-137 was not detected in any control location samples.

Figures 3.8-1 and 3.8-2 are graphs displaying annual mean concentrations for Co-58 and Co-60. Table 3.8 depicts the highest indicator location annual mean for radionuclides detected. In addition, radionuclides identified in fish samples since 1988 have been included in the table. Overall, radionuclides have not shown a significant trend or accumulation.



K-40 was observed in fish samples collected during 2006.

Figure 3.8-1





Figure 3.8-2



**Table 3.8 Mean Concentrations of Radionuclides in Fish (pCi/kg)**

Year	Mn-54	Co-58	Co-60	Cs-134	Cs-137	Nb-95	Fe-59	Sb-122	Sb-125
1984	3.07E0	3.00E0	6.11E-1	-5.32E0	1.83E0	0.00E0	0.00E0	0.00E0	0.00E0
1985	7.68E-1	3.40E1	9.11E0	3.22E0	1.28E1	5.07E0	0.00E0	0.00E0	0.00E0
1986	2.01E1	1.86E2	4.01E1	3.51E1	9.29E1	0.00E0	7.30E0	0.00E0	0.00E0
1987	7.24E0	7.57E1	4.81E1	3.83E0	4.27E1	5.40E0	0.00E0	0.00E0	0.00E0
1988	2.85E1	1.40E2	9.70E1	1.67E1	8.24E1	0.00E0	0.00E0	0.00E0	0.00E0
1989	8.28E0	1.33E2	3.83E1	1.47E1	4.37E1	8.58E-1	0.00E0	0.00E0	0.00E0
1990	2.51E1	1.75E2	7.77E1	1.32E1	4.66E1	3.33E0	0.00E0	7.00E0	9.25E0
1991	3.15E1	1.46E2	1.29E2	1.03E1	4.60E1	7.90E-1	2.30E0	0.00E0	7.45E0
1992	1.34E1	9.02E1	6.20E1	1.27E1	4.61E1	0.00E0	0.00E0	0.00E0	0.00E0
1993	2.14E1	3.58E2	1.21E2	2.73E0	2.56E1	0.00E0	0.00E0	0.00E0	0.00E0
1994	1.91E0	4.75E1	1.81E1	0.00E0	1.75E1	0.00E0	0.00E0	0.00E0	1.45E1
1995	5.65E1	8.90E2	2.66E2	0.00E0	6.77E1	1.38E1	0.00E0	0.00E0	0.00E0
1996	0.00E0	5.95E1	6.68E1	0.00E0	3.02E1	0.00E0	0.00E0	0.00E0	0.00E0
1997	0.00E0	4.93E1	9.88E0	0.00E0	2.74E1	0.00E0	0.00E0	0.00E0	0.00E0
1998	0.00E0	6.44E1	2.86E1	0.00E0	1.58E1	0.00E0	0.00E0	0.00E0	0.00E0
1999	0.00E0	3.12E1	2.71E1	0.00E0	1.87E1	0.00E0	0.00E0	0.00E0	0.00E0
2000	0.00E0	2.13E2	2.69E2	0.00E0	1.52E1	0.00E0	0.00E0	0.00E0	0.00E0
2001	0.00E0	4.66E1	0.00E0	0.00E0	2.08E1	0.00E0	0.00E0	0.00E0	0.00E0
2002	0.00E0	5.23E1	7.00E1	0.00E0	1.73E1	0.00E0	0.00E0	0.00E0	0.00E0
2003	0.00E0	1.43E2	2.61E1	0.00E0	1.19E1	0.00E0	0.00E0	0.00E0	0.00E0
2004	4.92E1	1.81E1	0.00E0	0.00E0	0.00E0	0.00E0	0.00E0	0.00E0	0.00E0
2005	0.00E0	0.00E0	0.00E0	0.00E0	0.00E0	0.00E0	0.00E0	0.00E0	0.00E0
2006	0.00E0	0.00E0	0.00E0	0.00E0	1.44E1	0.00E0	0.00E0	0.00E0	0.00E0

0.00E0 = no detectable measurements

### 3.9 SHORELINE SEDIMENT

During 2006, a total of 6 shoreline sediment samples was analyzed, four from two indicator locations and two from the control location.


Co-58 and Co-60 were identified in one sample collected from indicator location 208-1S, which is closest to the plant's liquid effluent release point. Naturally occurring K-40 was identified in many of the indicator and control locations. Activity released in plant effluents has decreased since 1996 and as a result decreased activity has been measured in the environment.

The shoreline sediment location with the highest annual mean for all detectable radionuclides was location 208-1S. Co-58 was identified at location 208-1S with an annual mean concentration of 54.0 pCi/kg. Co-60 was identified with an annual mean concentration of 111 pCi/kg. Naturally occurring K-40 and Be-7 were also identified in samples from this location.

Table 3.9 lists highest indicator location annual mean since 1984. Included in the table are radionuclides that have been identified in shoreline sediment samples since 1988.


Figure 3.9-1 graphically depicts Co-58 annual mean concentrations. Figure 3.9-2 depicts Co-60 annual mean concentrations.

**Figure 3.9-1**



*There is no reporting level for Co-58 in Shoreline Sediment*

Figure 3.9-2



*There is no reporting level for Co-60 in Shoreline Sediment*

**Table 3.9 Mean Concentrations of Radionuclides in Shoreline Sediment (pCi/kg)**

Year	Mn-54	Co-58	Co-60	Nb-95	Zr-95	Cs-134	Cs-137	Co-57	Sb-125
1984	1.03E0	4.40E0	-2.34E0	0.00E0	0.00E0	3.19E1	1.07E2	0.00E0	0.00E0
1985	-3.12E0	1.16E2	5.18E0	0.00E0	0.00E0	2.11E2	2.97E2	0.00E0	0.00E0
1986	1.09E2	3.79E2	2.05E2	0.00E0	3.96E1	6.50E1	1.61E2	0.00E0	0.00E0
1987	8.83E1	4.08E2	1.61E2	4.22E1	0.00E0	6.08E1	1.26E2	0.00E0	0.00E0
1988	1.07E2	3.29E2	2.63E2	2.28E1	7.54E0	2.59E1	1.07E2	7.65E-1	3.68E0
1989	4.58E1	1.94E2	1.21E2	5.02E0	0.00E0	1.65E1	5.77E1	0.00E0	1.57E1
1990	5.39E1	2.08E2	1.77E2	0.00E0	0.00E0	1.66E1	8.18E1	0.00E0	7.15E0
1991	8.50E1	3.70E2	4.19E2	5.30E0	0.00E0	1.82E1	8.33E1	1.20E0	1.50E1
1992	1.17E2	1.13E3	5.80E2	3.50E0	0.00E0	1.69E1	1.07E2	3.00E0	2.70E1
1993	1.33E2	1.07E3	1.04E3	0.00E0	0.00E0	2.80E1	1.26E2	2.47E1	2.16E2
1994	4.93E1	7.98E2	5.73E2	0.00E0	0.00E0	5.67E0	1.07E2	4.38E0	4.60E1
1995	1.02E2	1.33E3	8.65E2	1.13E2	0.00E0	0.00E0	8.50E1	3.69E1	1.49E2
1996	8.73E1	3.39E2	5.81E2	0.00E0	0.00E0	0.00E0	8.30E1	0.00E0	1.96E2
1997	6.96E1	5.90E2	7.64E2	0.00E0	0.00E0	0.00E0	1.43E2	0.00E0	1.76E2
1998	3.07E1	1.88E2	2.30E2	0.00E0	0.00E0	0.00E0	7.11E1	0.00E0	0.00E0
1999	7.28E1	2.29E2	4.39E2	0.00E0	0.00E0	0.00E0	9.42E1	0.00E0	1.40E2
2000	0.00E0	3.90E1	1.03E2	0.00E0	0.00E0	0.00E0	4.96E1	0.00E0	0.00E0
2001	3.86E1	8.27E1	3.29E2	0.00E0	0.00E0	0.00E0	5.58E1	0.00E0	0.00E0
2002	3.51E1	2.41E2	2.22E2	0.00E0	0.00E0	0.00E0	8.83E1	0.00E0	0.00E0
2003	2.17E1	8.75E1	1.08E2	0.00E0	0.00E0	0.00E0	2.69E1	0.00E0	0.00E0
2004	6.60E1	2.67E2	3.83E2	0.00E0	0.00E0	0.00E0	3.79E1	0.00E0	0.00E0
2005	0.00E0	1.61E2	1.41E2	0.00E0	0.00E0	0.00E0	0.00E0	0.00E0	0.00E0
2006	0.00E0	5.40E1	1.11E2	0.00E0	0.00E0	0.00E0	0.00E0	0.00E0	0.00E0

0.00E0 = no detectable measurements  
 1984 - 1986 mean based on all net activity  
 Negative values are calculated as zeroes

### 3.10 DIRECT GAMMA RADIATION


In 2006, 158 TLDs were analyzed, 147 at indicator locations and 11 at control locations. TLDs are collected and analyzed quarterly. The highest annual mean exposure for an indicator location was 105.6 milliroentgen. The annual mean exposure for the control locations was 57.2 milliroentgen.



Figure 3.10 and Table 3.10 show TLD inner ring (site boundary), outer ring (4-5 miles), and control location annual averages in milliroentgen per year. Preoperational data and rolling ten year operational data averages are also given. As shown in the graph, inner ring, outer ring, and control data averages historically compare closely. Inner and outer ring averages comprise a number of data points with control averages representing only three locations.

The calculated total body dose (from gaseous effluents) for 2006 was 5.95E-1 mrem, which is 0.77% of the average inner ring TLD values. Therefore, it can be concluded that discharges from the plant had very little impact upon the measured TLD values.

Figure 3.10



*There is no reporting level for Direct Radiation (TLD)*



**Table 3.10 Direct Gamma Radiation (TLD) Results**

<b>Year</b>	<b>Inner Ring Average (mR/yr)</b>	<b>Outer Ring Average (mR/yr)</b>	<b>Control Average (mR/yr)</b>
1984*	87.5	82.6	79.3
1985	116.9	108.7	108.9
1986	104.3	98.5	94.4
1987	97.0	87.4	84.7
1988	74.6	70.3	67.1
1989	67.1	60.8	60.0
1990	52.0	44.5	39.1
1991	62.0	54.1	46.7
1992	80.4	72.5	64.5
1993	70.3	60.9	53.6
1994	76.3	69.3	63.9
1995	99.6	89.7	80.8
1996	84.3	73.9	63.6
1997	82.4	71.9	57.4
1998	85.3	74.2	64.6
1999	80.0	68.1	57.8
2000	75.0	63.0	52.4
2001	81.0	70.5	55.2
2002	78.8	69.5	55.2
2003	81.7	72.6	56.0
2004	78.6	73.8	55.6
2005	79.8	75.2	57.7
<b>Average (1996 – 2005)</b>	<b>80.7</b>	<b>71.3</b>	<b>57.6</b>
2006	76.9	73.6	57.2

\* Preoperational Data

### 3.11 LAND USE CENSUS

The 2006 Annual Land Use Census was conducted July 17 and July 18, 2006 as required by SLC 16.11-14. Table 3.11 summarizes census results. A map indicating identified locations is shown in Figure 3.11.


During the 2006 census, no new or closer irrigated gardens were identified. The nearest residence is located in the NE sector at 0.56 miles. No environmental program changes were required as a result of the 2006 land use census.

**Table 3.11 Catawba 2006 Land Use Census Results**

<b>Sector</b>			<b>Sector</b>		
<b>Distance (Miles)</b>			<b>Distance (Miles)</b>		
<b>N</b>	Nearest Residence	0.63	<b>S</b>	Nearest Residence	0.63
	Nearest Garden	1.55		Nearest Garden	0.80
	Nearest Milk Animal	-		Nearest Milk Animal	-
<b>NNE</b>	Nearest Residence	0.66	<b>SSW</b>	Nearest Residence	0.81
	Nearest Garden	2.53		Nearest Garden	1.67
	Nearest Milk Animal	-		Nearest Milk Animal	-
<b>NE</b>	Nearest Residence	0.56	<b>SW</b>	Nearest Residence	0.66
	Nearest Garden	2.87		Nearest Garden (irrigated)	0.66
	Nearest Milk Animal	-		Nearest Milk Animal	-
<b>ENE</b>	Nearest Residence	0.61	<b>WSW</b>	Nearest Residence	0.64
	Nearest Garden (irrigated)	0.61		Nearest Garden	2.04
	Nearest Milk Animal	-		Nearest Milk Animal	-
<b>E</b>	Nearest Residence	0.65	<b>W</b>	Nearest Residence	0.81
	Nearest Garden	3.51		Nearest Garden	0.96
	Nearest Milk Animal	-		Nearest Milk Animal	-
<b>ESE</b>	Nearest Residence	0.84	<b>WNW</b>	Nearest Residence	1.10
	Nearest Garden	1.23		Nearest Garden	1.19
	Nearest Milk Animal	-		Nearest Milk Animal	-
<b>SE</b>	Nearest Residence	0.97	<b>NW</b>	Nearest Residence	1.39
	Nearest Garden (irrigated)	2.55		Nearest Garden	1.54
	Nearest Milk Animal	-		Nearest Milk Animal	-
<b>SSE</b>	Nearest Residence	0.74	<b>NNW</b>	Nearest Residence	1.06
	Nearest Garden	1.01		Nearest Garden	2.21
	Nearest Milk Animal	-		Nearest Milk Animal	-

“-“ indicates no occurrences within the 5 mile radius

Figure 3.11



---

## 4.0 EVALUATION OF DOSE

---

### 4.1 DOSE FROM ENVIRONMENTAL MEASUREMENTS

Annual doses to maximum exposed individuals were estimated based on measured concentrations of radionuclides in 2006 CNS REMP samples. The primary purpose of estimating doses based on sample results is to allow comparison to effluent program dose estimates.

Doses based on sample results were calculated using the methodology and data presented in NRC Regulatory Guide 1.109. Measured radionuclide concentrations, averaged over the entire year for a specific radionuclide, indicator location and sample type, were used to calculate REMP-based doses. Where applicable, average background concentration at the corresponding control location was subtracted. Regulatory Guide 1.109 consumption rates for the maximum exposed individual were used in the calculations. When the guide listed “NO DATA” as the dose factor for a given radionuclide and organ, a dose factor of zero was assumed.

Maximum dose estimates (Highest Annual Mean Concentration) based on drinking water, broadleaf vegetation, fish, and shoreline sediment sample results are reported in Table 4.1-A. The individual critical population and pathway dose calculations are reported in Table 4.1-B.

REMP-based dose estimates are not reported for airborne radioiodine, airborne particulate, milk, or ground water sample types because no radionuclides other than naturally occurring K-40 and Be-7 were detected in the samples. Dose estimates are not reported for surface water because sampled surface water is not considered to be a potable drinking water source although surface water tritium concentrations are used in calculating doses from fish. Exposure estimates based upon REMP TLD results are discussed in Section 3.10.

The maximum environmental organ dose estimate for any single sample type (other than direct radiation from gaseous effluents) collected during 2006 was 5.95E-1 mrem to the maximum exposed child total body from consuming broadleaf vegetation.

### 4.2 ESTIMATED DOSE FROM RELEASES

Throughout the year, dose estimates were calculated based on actual 2006 liquid and gaseous effluent release data. Effluent-based dose estimates were calculated using the RETDAS computer program which employs methodology and data presented in NRC Regulatory Guide 1.109. These doses are shown in Table 4.1-A along with the corresponding REMP-based dose estimates. Summaries of RETDAS dose

calculations are reported in the Annual Radioactive Effluent Release Report (reference 6.6).

The effluent-based liquid release doses are summations of the dose contributions from the drinking water, fish, and shoreline pathways. The effluent-based gaseous release doses report noble gas exposure separately from iodine, particulate, and tritium exposure. For noble gas exposure there is no critical age group; as the maximum exposed individuals are assumed to receive the same doses, regardless of their age group. For iodine, particulate, and tritium exposure the effluent-based gaseous release doses are summations of the dose contributors from ground/plane, inhalation, milk and vegetation pathways.

### **4.3 COMPARISON OF DOSES**

The environmental and effluent dose estimates given in Table 4.1-A agree reasonably well. The similarity of the doses indicate that the radioactivity levels in the environment do not differ significantly from those expected based on effluent measurements and modeling of the environmental exposure pathways. This indicates that effluent program dose estimates are both valid and reasonably conservative.

There are some differences in how effluent and environmental doses are calculated that affect the comparison. Doses calculated from environmental data are conservative because they are based on a mean that includes only samples with a net positive activity versus a mean that includes all sample results (i.e. zero results are not included in the mean). Also, airborne tritium is not measured in environmental samples but is used to calculate effluent doses.

In calculations based on liquid release pathways, fish, drinking water, and shoreline sediment were the predominant dose pathways based on environmental and effluent data. The maximum total organ dose based on 2006 environmental sample results was 1.37E-1 mrem to the child liver. The maximum total organ dose of 1.71E-1 mrem for liquid effluent-based estimates was to the adult GI-LLI.

In calculations based on gaseous release pathways, vegetation was the predominant dose pathway for effluent samples. The maximum total organ dose for gaseous effluent estimates was 5.95E-1 mrem to the child's liver, total body, thyroid, kidney, lung, and GI-LLI. Vegetation was the predominant dose pathway for environmental samples. The maximum total organ dose for gaseous environmental estimates was 4.92E-1 mrem to the child bone.

Noble gas samples are not collected as part of the REMP, preventing an analogous comparison of effluent-based noble gas exposure estimates.

The doses calculated do not exceed the 40CFR190 dose commitment limits for members of the public. Doses to members of the public attributable to the operation of CNS are being maintained well within regulatory limits.

**TABLE 4.1-A**

**CATAWBA NUCLEAR STATION  
2006 ENVIRONMENTAL AND EFFLUENT DOSE COMPARISON**

**LIQUID RELEASE PATHWAY**

<b>Organ</b>	<b>Environmental or Effluent Data</b>	<b>Critical Age <sup>(1)</sup></b>	<b>Critical Pathway <sup>(2)</sup></b>	<b>Location</b>	<b>Maximum Dose <sup>(3)</sup> (mrem)</b>
Skin	Environmental	Teen	Shoreline Sediment	208 (0.45 mi S)	1.43E-03
Skin	Effluent	Teen	Shoreline Sediment	0.5 mi S	9.41E-03
Bone	Environmental	Child	Fish	208 (0.45 mi S)	3.25E-02
Bone	Effluent	Teen	Fish	0.5 mi S	1.92E-02
Liver	Environmental	Child	Drinking Water	214 (7.30 mi SSE)	1.37E-01
Liver	Effluent	Child	Drinking Water	0.5 mi S	1.13E-01
T. Body	Environmental	Adult	Drinking Water	214 (7.30 mi SSE)	1.17E-01
T. Body	Effluent	Child	Drinking Water	0.5 mi S	1.02E-01
Thyroid	Environmental	Child	Drinking Water	214 (7.30 mi SSE)	1.06E-01
Thyroid	Effluent	Child	Drinking Water	0.5 mi S	9.82E-02
Kidney	Environmental	Child	Drinking Water	214 (7.30 mi SSE)	1.16E-01
Kidney	Effluent	Child	Drinking Water	0.5 mi S	1.03E-01
Lung	Environmental	Child	Drinking Water	214 (7.30 mi SSE)	1.10E-01
Lung	Effluent	Child	Drinking Water	0.5 mi S	9.97E-02
GI-LLI	Environmental	Child	Drinking Water	214 (7.30 mi SSE)	1.06E-01
GI-LLI	Effluent	Adult	Fish	0.5 mi S	1.71E-01

- (1) Critical Age is the highest total dose (all pathways) to an age group.
- (2) Critical Pathway is the highest individual dose within the identified Critical Age group.
- (3) Maximum dose is a summation of the fish, drinking water and shoreline sediment pathways.

GASEOUS RELEASE PATHWAY**IODINE, PARTICULATE, and TRITIUM**

<b>Organ</b>	<b>Environmental or Effluent Data</b>	<b>Critical Age <sup>(1)</sup></b>	<b>Critical Pathway <sup>(2)</sup></b>	<b>Location</b>	<b>Maximum Dose <sup>(3)</sup> (mrem)</b>
Skin	Environmental	-	-	-	0.00E+00
Skin	Effluent	-	-	0.5 mi S	0.00E+00
Bone	Environmental	Child	Vegetation	201 (0.53 mi NE)	4.92E-01
Bone	Effluent	-	-	0.5 mi S	0.00E+00
Liver	Environmental	Child	Vegetation	201 (0.53 mi NE)	4.71E-01
Liver	Effluent	Child	Vegetation	0.5 mi S	5.95E-01
T. Body	Environmental	Adult	Vegetation	201 (0.53 mi NE)	2.65E-01
T. Body	Effluent	Child	Vegetation	0.5 mi S	5.95E-01
Thyroid	Environmental	-	-	-	0.00E+00
Thyroid	Effluent	Child	Vegetation	0.5 mi S	5.95E-01
Kidney	Environmental	Child	Vegetation	201 (0.53 mi NE)	1.54E-01
Kidney	Effluent	Child	Vegetation	0.5 mi S	5.95E-01
Lung	Environmental	Child	Vegetation	201 (0.53 mi NE)	5.52E-02
Lung	Effluent	Child	Vegetation	0.5 mi S	5.95E-01
GI-LLI	Environmental	Adult	Vegetation	201 (0.53 mi NE)	7.82E-03
GI-LLI	Effluent	Child	Vegetation	0.5 mi S	5.95E-01

(1) Critical Age is the highest total dose (all pathways) to an age group.

(2) Critical Pathway is the highest individual dose within the identified Critical Age group.

(3) Maximum dose is a summation of the ground/plane, inhalation, milk and vegetation pathways.

**NOBLE GAS**

<b>Air Dose</b>	<b>Environmental or Effluent Data</b>	<b>Critical Age</b>	<b>Critical Pathway</b>	<b>Location</b>	<b>Maximum Dose (mrad)</b>
Beta	Environmental	-	-	-	Not Sampled
Beta	Effluent	N/A	Noble Gas	0.5 mi. NNE	1.74E-02
Gamma	Environmental	-	-	-	Not Sampled
Gamma	Effluent	N/A	Noble Gas	0.5 mi. NNE	3.86E-02



**TABLE 4.1-B***Maximum Individual Dose for 2006 based on Environmental Measurements (mrem) for Catawba Nuclear Station*

Age	Sample Medium	Bone	Liver	T. Body	Thyroid	Kidney	Lung	GI-LLI	Skin
<b>Infant</b>	Airborne	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
	Drinking Water	0.00E+00	8.42E-02	8.42E-02	8.42E-02	8.42E-02	8.42E-02	8.42E-02	0.00E+00
	Milk	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
	<u>TOTAL</u>	0.00E+00	8.42E-02	8.42E-02	8.42E-02	8.42E-02	8.42E-02	8.42E-02	8.42E-02
<b>Child</b>	Airborne	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
	Drinking Water	0.00E+00	8.57E-02	8.57E-02	8.57E-02	8.57E-02	8.57E-02	8.57E-02	0.00E+00
	Milk	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
	Broadleaf Vegetation	4.92E-01	4.71E-01	6.95E-02	0.00E+00	1.54E-01	5.52E-02	2.95E-03	0.00E+00
	Fish	3.25E-02	5.14E-02	2.49E-02	2.03E-02	3.05E-02	2.40E-02	2.05E-02	0.00E+00
	<u>Shoreline Sediment</u>	0.00E+00	0.00E+00	2.54E-04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.98E-04
	<u>TOTAL</u>	5.25E-01	6.08E-01	1.80E-01	1.06E-01	2.70E-01	1.65E-01	1.09E-01	2.98E-04
<b>Teen</b>	Airborne	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
	Drinking Water	0.00E+00	4.48E-02	4.48E-02	4.48E-02	4.48E-02	4.48E-02	4.48E-02	0.00E+00
	Milk	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
	Broadleaf Vegetation	2.72E-01	3.62E-01	1.26E-01	0.00E+00	1.23E-01	4.79E-02	5.16E-03	0.00E+00
	Fish	2.58E-02	5.89E-02	3.66E-02	2.46E-02	3.63E-02	2.91E-02	2.51E-02	0.00E+00
	<u>Shoreline Sediment</u>	0.00E+00	0.00E+00	1.21E-03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.43E-03
	<u>TOTAL</u>	2.98E-01	4.66E-01	2.09E-01	6.94E-02	2.04E-01	1.22E-01	7.51E-02	1.43E-03
<b>Adult</b>	Airborne	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
	Drinking Water	0.00E+00	6.35E-02	6.35E-02	6.35E-02	6.35E-02	6.35E-02	6.35E-02	0.00E+00
	Milk	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
	Broadleaf Vegetation	2.95E-01	4.04E-01	2.65E-01	0.00E+00	1.37E-01	4.56E-02	7.82E-03	0.00E+00
	Fish	2.41E-02	6.49E-02	5.36E-02	3.20E-02	4.32E-02	3.57E-02	3.26E-02	0.00E+00
	<u>Shoreline Sediment</u>	0.00E+00	0.00E+00	2.17E-04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.56E-04
	<u>TOTAL</u>	3.19E-01	5.32E-01	3.82E-01	9.55E-02	2.44E-01	1.45E-01	1.04E-01	2.56E-04

Note: Dose tables are provided for sample media displaying positive nuclide occurrence.

**Catawba Nuclear Station**  
**Dose from Drinking Water Pathway for 2006 Data**  
**Maximum Exposed Infant**

Infant Dose from Drinking Water Pathway (mrem) = Usage (l) x Dose Factor (mrem/pCi ingested) x Concentration (pCi/l)

Usage (intake in one year) = 330 l

Radionuclide	<u>Ingestion Dose Factor</u>							<u>Highest Annual Net Mean Concentration</u>		<u>Dose (mrem)</u>						
	Bone	Liver	T. Body	Thyroid	Kidney	Lung	GI-LLI	Indicator Location	Water (pCi/l)	Bone	Liver	T. Body	Thyroid	Kidney	Lung	GI-LLI
Mn-54	NO DATA	1.99E-05	4.51E-06	NO DATA	4.41E-06	NO DATA	7.31E-06	ALL	0.00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Co-58	NO DATA	3.60E-06	8.98E-06	NO DATA	NO DATA	NO DATA	8.97E-06	ALL	0.00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Fe-59	3.08E-05	5.38E-05	2.12E-05	NO DATA	NO DATA	1.59E-05	2.57E-05	ALL	0.00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Co-60	NO DATA	1.08E-05	2.55E-05	NO DATA	NO DATA	NO DATA	2.57E-05	ALL	0.00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Zn-65	1.84E-05	6.31E-05	2.91E-05	NO DATA	3.06E-05	NO DATA	5.33E-05	ALL	0.00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Nb-95	4.20E-08	1.73E-08	1.00E-08	NO DATA	1.24E-08	NO DATA	1.46E-05	ALL	0.00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Zr-95	2.06E-07	5.02E-08	3.56E-08	NO DATA	5.41E-08	NO DATA	2.50E-05	ALL	0.00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-131	3.59E-05	4.23E-05	1.86E-05	1.39E-02	4.94E-05	NO DATA	1.51E-06	ALL	0.00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Cs-134	3.77E-04	7.03E-04	7.10E-05	NO DATA	1.81E-04	7.42E-05	1.91E-06	ALL	0.00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Cs-137	5.22E-04	6.11E-04	4.33E-05	NO DATA	1.64E-04	6.64E-05	1.91E-06	ALL	0.00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
BaLa-140	1.71E-04	1.71E-07	8.81E-06	NO DATA	4.06E-08	1.05E-07	4.20E-05	ALL	0.00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
H-3	NO DATA	3.08E-07	3.08E-07	3.08E-07	3.08E-07	3.08E-07	3.08E-07	214	828	0.00E+00	8.42E-02	8.42E-02	8.42E-02	8.42E-02	8.42E-02	8.42E-02
Dose Commitment (mrem) =										0.00E+00	8.42E-02	8.42E-02	8.42E-02	8.42E-02	8.42E-02	8.42E-02

**Catawba Nuclear Station**  
**Dose from Drinking Water Pathway for 2006 Data**  
**Maximum Exposed Child**

Child Dose from Drinking Water Pathway (mrem) = Usage (l) x Dose Factor (mrem/pCi ingested) x Concentration (pCi/l)

Usage (intake in one year) = 510 l

Radionuclide	<u>Ingestion Dose Factor</u>							<u>Highest Annual Net Mean Concentration</u>		<u>Dose (mrem)</u>						
	Bone	Liver	T. Body	Thyroid	Kidney	Lung	GI-LLI	Indicator Location	Water (pCi/l)	Bone	Liver	T. Body	Thyroid	Kidney	Lung	GI-LLI
Mn-54	NO DATA	1.07E-05	2.85E-06	NO DATA	3.00E-06	NO DATA	8.98E-06	ALL	0.00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Co-58	NO DATA	1.80E-06	5.51E-06	NO DATA	NO DATA	NO DATA	1.05E-05	ALL	0.00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Fe-59	1.65E-05	2.67E-05	1.33E-05	NO DATA	NO DATA	7.74E-06	2.78E-05	ALL	0.00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
C0-60	NO DATA	5.29E-06	1.56E-05	NO DATA	NO DATA	NO DATA	2.93E-05	ALL	0.00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Zn-65	1.37E-05	3.65E-05	2.27E-05	NO DATA	2.30E-05	NO DATA	6.41E-06	ALL	0.00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Nb-95	2.25E-08	8.76E-09	6.26E-09	NO DATA	8.23E-09	NO DATA	1.62E-05	ALL	0.00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Zr-95	1.16E-07	2.55E-08	2.27E-08	NO DATA	3.65E-08	NO DATA	2.66E-05	ALL	0.00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-131	1.72E-05	1.73E-05	9.83E-06	5.72E-03	2.84E-05	NO DATA	1.54E-06	ALL	0.00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Cs-134	2.34E-04	3.84E-04	8.10E-05	NO DATA	1.19E-04	4.27E-05	2.07E-06	ALL	0.00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Cs-137	3.27E-04	3.13E-04	4.62E-05	NO DATA	1.02E-04	3.67E-05	1.96E-06	ALL	0.00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
BaLa-140	8.31E-05	7.28E-08	4.85E-06	NO DATA	2.37E-08	4.34E-08	4.21E-05	ALL	0.00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
H-3	NO DATA	2.03E-07	2.03E-07	2.03E-07	2.03E-07	2.03E-07	2.03E-07	214	828	0.00E+00	8.57E-02	8.57E-02	8.57E-02	8.57E-02	8.57E-02	8.57E-02
Dose Commitment (mrem) =										0.00E+00	8.57E-02	8.57E-02	8.57E-02	8.57E-02	8.57E-02	8.57E-02

**Catawba Nuclear Station**  
**Dose from Broadleaf Vegetation Pathway for 2006 Data**  
**Maximum Exposed Child**

Child Dose from Vegetation Pathway (mrem) = Usage (kg) x Dose Factor (mrem/pCi ingested) x Concentration (pCi/kg)

Usage (intake in one year) = 26 kg

Radionuclide	<u>Ingestion Dose Factor</u>							<u>Highest Annual Net Mean Concentration</u>		<u>Dose (mrem)</u>						
	Bone	Liver	T. Body	Thyroid	Kidney	Lung	GI-LLI	Indicator Location	Food (pCi/kg)	Bone	Liver	T. Body	Thyroid	Kidney	Lung	GI-LLI
I-131	1.72E-05	1.73E-05	9.83E-06	5.72E-03	2.84E-05	NO DATA	1.54E-06	ALL	0.00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Cs-134	2.34E-04	3.84E-04	8.10E-05	NO DATA	1.19E-04	4.27E-05	2.07E-06	ALL	0.00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Cs-137	3.27E-04	3.13E-04	4.62E-05	NO DATA	1.02E-04	3.67E-05	1.96E-06	201	57.9	4.92E-01	4.71E-01	6.95E-02	0.00E+00	1.54E-01	5.52E-02	2.95E-03
Dose Commitment (mrem) =										4.92E-01	4.71E-01	6.95E-02	0.00E+00	1.54E-01	5.52E-02	2.95E-03

***Catawba Nuclear Station  
Dose from Fish Pathway for 2006 Data  
Maximum Exposed Child***

Child Dose from Fish Pathway (mrem) = Usage (kg) x Dose Factor (mrem/pCi ingested) x Concentration (pCi/kg)

H-3 Concentration in Fish = Surface Water pCi/l x Bioaccumulation Factor 0.9 pCi/kg per pCi/l = 16117 pCi/l x 0.9 = 14505 pCi/kg

Usage (intake in one year) = 6.9 kg

Radionuclide	<u>Ingestion Dose Factor</u>							<u>Highest Annual Net Mean Concentration</u>		<u>Dose (mrem)</u>						
	Bone	Liver	T. Body	Thyroid	Kidney	Lung	GI-LLI	Indicator Location	Fish (pCi/kg)	Bone	Liver	T. Body	Thyroid	Kidney	Lung	GI-LLI
Mn-54	NO DATA	1.07E-05	2.85E-06	NO DATA	3.00E-06	NO DATA	8.98E-06	ALL	0.00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Co-58	NO DATA	1.80E-06	5.51E-06	NO DATA	NO DATA	NO DATA	1.05E-05	ALL	0.00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Fe-59	1.65E-05	2.67E-05	1.33E-05	NO DATA	NO DATA	7.74E-06	2.78E-05	ALL	0.00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
C0-60	NO DATA	5.29E-06	1.56E-05	NO DATA	NO DATA	NO DATA	2.93E-05	ALL	0.00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Zn-65	1.37E-05	3.65E-05	2.27E-05	NO DATA	2.30E-05	NO DATA	6.41E-06	ALL	0.00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Cs-134	2.34E-04	3.84E-04	8.10E-05	NO DATA	1.19E-04	4.27E-05	2.07E-06	ALL	0.00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Cs-137	3.27E-04	3.13E-04	4.62E-05	NO DATA	1.02E-04	3.67E-05	1.96E-06	208	14.4	3.25E-02	3.11E-02	4.59E-03	0.00E+00	1.01E-02	3.65E-03	1.95E-04
H-3	NO DATA	2.03E-07	2.03E-07	2.03E-07	2.03E-07	2.03E-07	2.03E-07	208	14505	0.00E+00	2.03E-02	2.03E-02	2.03E-02	2.03E-02	2.03E-02	2.03E-02
Dose Commitment (mrem) =										3.25E-02	5.14E-02	2.49E-02	2.03E-02	3.05E-02	2.40E-02	2.05E-02

***Catawba Nuclear Station***  
***Dose from Shoreline Sediment Pathway for 2006 Data***  
***Maximum Exposed Child***

Shoreline Recreation = 14 hr (in one year)  
 Shore Width Factor = 0.2  
 Sediment Surface Mass = 40 kg/m<sup>2</sup>

Child Dose from Shoreline Sediment Pathway (mrem) = Shoreline Recreation (hr) x External Dose Factor (mrem/hr per pCi/m<sup>2</sup>) x Shore Width Factor x Sediment Surface Mass (kg/m<sup>2</sup>) x Sediment Concentration (pCi/kg)

Radionuclide	External Dose Factor Standing on Contaminated Ground		Indicator Location	Highest Annual Net Mean Concentration Sediment (pCi/kg)	Dose	
	(mrem/hr per pCi/m <sup>2</sup> )				(mrem)	
	T. Body	Skin			T. Body	Skin
Mn-54	5.80E-09	6.80E-09	ALL	0.00	0.00E+00	0.00E+00
Co-58	7.00E-09	8.20E-09	208-1S	54.0	4.23E-05	4.96E-05
Co-60	1.70E-08	2.00E-08	208-1S	111	2.11E-04	2.49E-04
Cs-134	1.20E-08	1.40E-08	ALL	0.00	0.00E+00	0.00E+00
Cs-137	4.20E-09	4.90E-09	ALL	0.00	0.00E+00	0.00E+00
Dose Commitment (mrem) =					2.54E-04	2.98E-04

**Catawba Nuclear Station**  
**Dose from Drinking Water Pathway for 2006 Data**  
**Maximum Exposed Teen**

Teen Dose from Drinking Water Pathway (mrem) = Usage (l) x Dose Factor (mrem/pCi ingested) x Concentration (pCi/l)

Usage (intake in one year) = 510 l

Radionuclide	<u>Ingestion Dose Factor</u>							<u>Highest Annual Net Mean Concentration</u>		<u>Dose (mrem)</u>						
	Bone	Liver	T. Body	Thyroid	Kidney	Lung	GI-LLI	Indicator Location	Water (pCi/l)	Bone	Liver	T. Body	Thyroid	Kidney	Lung	GI-LLI
Mn-54	NO DATA	5.90E-06	1.17E-06	NO DATA	1.76E-06	NO DATA	1.21E-05	ALL	0.00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Co-58	NO DATA	9.72E-07	2.24E-06	NO DATA	NO DATA	NO DATA	1.34E-05	ALL	0.00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Fe-59	5.87E-06	1.37E-05	5.29E-06	NO DATA	NO DATA	4.32E-06	3.24E-05	ALL	0.00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Co-60	NO DATA	2.81E-06	6.33E-06	NO DATA	NO DATA	NO DATA	3.66E-05	ALL	0.00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Zn-65	5.76E-06	2.00E-05	9.33E-06	NO DATA	1.28E-05	NO DATA	8.47E-06	ALL	0.00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Nb-95	8.22E-09	4.56E-09	2.51E-09	NO DATA	4.42E-09	NO DATA	1.95E-05	ALL	0.00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Zr-95	4.12E-08	1.30E-08	8.94E-09	NO DATA	1.91E-08	NO DATA	3.00E-05	ALL	0.00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-131	5.85E-06	8.19E-06	4.40E-06	2.39E-03	1.41E-05	NO DATA	1.62E-06	ALL	0.00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Cs-134	8.37E-05	1.97E-04	9.14E-05	NO DATA	6.26E-05	2.39E-05	2.45E-06	ALL	0.00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Cs-137	1.12E-04	1.49E-04	5.19E-05	NO DATA	5.07E-05	1.97E-05	2.12E-06	ALL	0.00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
BaLa-140	2.84E-05	3.48E-08	1.83E-06	NO DATA	1.18E-08	2.34E-08	4.38E-05	ALL	0.00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
H-3	NO DATA	1.06E-07	1.06E-07	1.06E-07	1.06E-07	1.06E-07	1.06E-07	214	828	0.00E+00	4.48E-02	4.48E-02	4.48E-02	4.48E-02	4.48E-02	4.48E-02
Dose Commitment (mrem)=										0.00E+00	4.48E-02	4.48E-02	4.48E-02	4.48E-02	4.48E-02	4.48E-02

**Catawba Nuclear Station**  
**Dose from Broadleaf Vegetation Pathway for 2006 Data**  
**Maximum Exposed Teen**

Teen Dose from Vegetation Pathway (mrem) = Usage (kg) x Dose Factor (mrem/pCi ingested) x Concentration (pCi/kg)

Usage (intake in one year) = 42 kg

Radionuclide	<u>Ingestion Dose Factor</u>							<u>Highest Annual Net Mean Concentration</u>		<u>Dose (mrem)</u>						
	Bone	Liver	T. Body	Thyroid	Kidney	Lung	GI-LLI	Indicator Location	Food (pCi/kg)	Bone	Liver	T. Body	Thyroid	Kidney	Lung	GI-LLI
I-131	5.85E-06	8.19E-06	4.40E-06	2.39E-03	1.41E-05	NO DATA	1.62E-06	ALL	0.00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Cs-134	8.37E-05	1.97E-04	9.14E-05	NO DATA	6.26E-05	2.39E-05	2.45E-06	ALL	0.00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Cs-137	1.12E-04	1.49E-04	5.19E-05	NO DATA	5.07E-05	1.97E-05	2.12E-06	201	57.9	2.72E-01	3.62E-01	1.26E-01	0.00E+00	1.23E-01	4.79E-02	5.16E-03
Dose Commitment (mrem) =										2.72E-01	3.62E-01	1.26E-01	0.00E+00	1.23E-01	4.79E-02	5.16E-03



**Catawba Nuclear Station**  
**Dose from Fish Pathway for 2006 Data**  
**Maximum Exposed Teen**

Teen Dose from Fish Pathway (mrem) = Usage (kg) x Dose Factor (mrem/pCi ingested) x Concentration (pCi/kg)

H-3 Concentration in Fish = Surface Water pCi/l x Bioaccumulation Factor 0.9 pCi/kg per pCi/l = 16117 pCi/l x 0.9 = 14505 pCi/kg

Usage (intake in one year) = 16 kg

Radionuclide	<u>Ingestion Dose Factor</u>							<u>Highest Annual Net Mean Concentration</u>		<u>Dose (mrem)</u>						
	Bone	Liver	T. Body	Thyroid	Kidney	Lung	GI-LLI	Location	(pCi/kg)	Bone	Liver	T. Body	Thyroid	Kidney	Lung	GI-LLI
Mn-54	NO DATA	5.90E-06	1.17E-06	NO DATA	1.76E-06	NO DATA	1.21E-05	ALL	0.00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Co-58	NO DATA	9.72E-07	2.24E-06	NO DATA	NO DATA	NO DATA	1.34E-05	ALL	0.00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Fe-59	5.87E-06	1.37E-05	5.29E-06	NO DATA	NO DATA	4.32E-06	3.24E-05	ALL	0.00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Co-60	NO DATA	2.81E-06	6.33E-06	NO DATA	NO DATA	NO DATA	3.66E-05	ALL	0.00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Zn-65	5.76E-06	2.00E-05	9.33E-06	NO DATA	1.28E-05	NO DATA	8.47E-06	ALL	0.00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Cs-134	8.37E-05	1.97E-04	9.14E-05	NO DATA	6.26E-05	2.39E-05	2.45E-06	ALL	0.00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Cs-137	1.12E-04	1.49E-04	5.19E-05	NO DATA	5.07E-05	1.97E-05	2.12E-06	208	14.4	2.58E-02	3.43E-02	1.20E-02	0.00E+00	1.17E-02	4.54E-03	4.88E-04
H-3	NO DATA	1.06E-07	1.06E-07	1.06E-07	1.06E-07	1.06E-07	1.06E-07	208	14505	0.00E+00	2.46E-02	2.46E-02	2.46E-02	2.46E-02	2.46E-02	2.46E-02
Dose Commitment (mrem) =										2.58E-02	5.89E-02	3.66E-02	2.46E-02	3.63E-02	2.91E-02	2.51E-02

***Catawba Nuclear Station***  
***Dose from Shoreline Sediment Pathway for 2006 Data***  
***Maximum Exposed Teen***

Shoreline Recreation = 67 hr (in one year)  
 Shore Width Factor = 0.2  
 Sediment Surface Mass = 40 kg/m<sup>2</sup>

Teen Dose from Shoreline Sediment Pathway (mrem) = Shoreline Recreation (hr) x External Dose Factor (mrem/hr per pCi/m<sup>2</sup>) x Shore Width Factor x Sediment Surface Mass (kg/m<sup>2</sup>) x Sediment Concentration (pCi/kg)

Radionuclide	External Dose Factor Standing on Contaminated Ground		Indicator Location	Sediment (pCi/kg)	Dose	
	(mrem/hr per pCi/m <sup>2</sup> )				(mrem)	
	T. Body	Skin			T. Body	Skin
Mn-54	5.80E-09	6.80E-09	ALL	0.00	0.00E+00	0.00E+00
Co-58	7.00E-09	8.20E-09	208-1S	54.0	2.03E-04	2.37E-04
Co-60	1.70E-08	2.00E-08	208-1S	111	1.01E-03	1.19E-03
Cs-134	1.20E-08	1.40E-08	ALL	0.00	0.00E+00	0.00E+00
Cs-137	4.20E-09	4.90E-09	ALL	0.00	0.00E+00	0.00E+00
Dose Commitment (mrem) =					1.21E-03	1.43E-03

**Catawba Nuclear Station**  
**Dose from Drinking Water Pathway for 2006 Data**  
**Maximum Exposed Adult**

Adult Dose from Drinking Water Pathway (mrem) = Usage (l) x Dose Factor (mrem/pCi ingested) x Concentration (pCi/l)

Usage (intake in one year) = 730 l

Radionuclide	<u>Ingestion Dose Factor</u>							<u>Highest Annual Net Mean Concentration</u>		<u>Dose (mrem)</u>						
	Bone	Liver	T. Body	Thyroid	Kidney	Lung	GI-LLI	Indicator	Water (pCi/l)	Bone	Liver	T. Body	Thyroid	Kidney	Lung	GI-LLI
								Location								
Mn-54	NO DATA	4.57E-06	8.72E-07	NO DATA	1.36E-06	NO DATA	1.40E-05	ALL	0.00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Co-58	NO DATA	7.45E-07	1.67E-06	NO DATA	NO DATA	NO DATA	1.51E-05	ALL	0.00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Fe-59	4.34E-06	1.02E-05	3.91E-06	NO DATA	NO DATA	2.85E-06	3.40E-05	ALL	0.00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Co-60	NO DATA	2.14E-06	4.72E-06	NO DATA	NO DATA	NO DATA	4.02E-05	ALL	0.00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Zn-65	4.84E-06	1.54E-05	6.96E-06	NO DATA	1.03E-05	NO DATA	9.70E-06	ALL	0.00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Nb-95	6.22E-09	3.46E-09	1.86E-09	NO DATA	3.42E-09	NO DATA	2.10E-05	ALL	0.00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Zr-95	3.04E-08	9.75E-09	6.60E-09	NO DATA	1.53E-08	NO DATA	3.09E-05	ALL	0.00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-131	4.16E-06	5.95E-06	3.41E-06	1.95E-03	1.02E-05	NO DATA	1.57E-06	ALL	0.00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Cs-134	6.22E-05	1.48E-04	1.21E-04	NO DATA	4.79E-05	1.59E-05	2.59E-06	ALL	0.00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Cs-137	7.97E-05	1.09E-04	7.14E-05	NO DATA	3.70E-05	1.23E-05	2.11E-06	ALL	0.00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
BaLa-140	2.03E-05	2.55E-08	1.33E-06	NO DATA	8.67E-09	1.46E-08	4.18E-05	ALL	0.00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
H-3	NO DATA	1.05E-07	1.05E-07	1.05E-07	1.05E-07	1.05E-07	1.05E-07	214	828	0.00E+00	6.35E-02	6.35E-02	6.35E-02	6.35E-02	6.35E-02	6.35E-02
Dose Commitment (mrem) =										0.00E+00	6.35E-02	6.35E-02	6.35E-02	6.35E-02	6.35E-02	6.35E-02

**Catawba Nuclear Station**  
**Dose from Broadleaf Vegetation Pathway for 2006 Data**  
**Maximum Exposed Adult**

Adult Dose from Vegetation (mrem) = Usage (kg) x Dose Factor (mrem/pCi ingested) x Concentration (pCi/kg)

Usage (intake in one year) = 64 kg

Radionuclide	<u>Ingestion Dose Factor</u>							<u>Highest Annual Net Mean Concentration</u>		<u>Dose (mrem)</u>						
	Bone	Liver	T. Body	Thyroid	Kidney	Lung	GI-LLI	Indicator Location	Food (pCi/kg)	Bone	Liver	T. Body	Thyroid	Kidney	Lung	GI-LLI
I-131	4.16E-06	5.95E-06	3.41E-06	1.95E-03	1.02E-05	NO DATA	1.57E-06	ALL	0.00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Cs-134	6.22E-05	1.48E-04	1.21E-04	NO DATA	4.79E-05	1.59E-05	2.59E-06	ALL	0.00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Cs-137	7.97E-05	1.09E-04	7.14E-05	NO DATA	3.70E-05	1.23E-05	2.11E-06	201	57.9	2.95E-01	4.04E-01	2.65E-01	0.00E+00	1.37E-01	4.56E-02	7.82E-03
Dose Commitment (mrem) =										2.95E-01	4.04E-01	2.65E-01	0.00E+00	1.37E-01	4.56E-02	7.82E-03

***Catawba Nuclear Station  
Dose from Fish Pathway for 2006 Data  
Maximum Exposed Adult***

Adult Dose from Fish Pathway (mrem) = Usage (kg) x Dose Factor (mrem/pCi ingested) x Concentration (pCi/kg)

H-3 Concentration in Fish = Surface Water pCi/l x Bioaccumulation Factor 0.9 pCi/kg per pCi/l = 16117 pCi/l x 0.9 = 14505 pCi/kg

Usage (intake in one year) = 21 kg

Radionuclide	<u>Ingestion Dose Factor</u>							<u>Highest Annual Net Mean Concentration</u>		<u>Dose (mrem)</u>						
	Bone	Liver	T. Body	Thyroid	Kidney	Lung	GI-LLI	Location	(pCi/kg)	Bone	Liver	T. Body	Thyroid	Kidney	Lung	GI-LLI
Mn-54	NO DATA	4.57E-06	8.72E-07	NO DATA	1.36E-06	NO DATA	1.40E-05	ALL	0.00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Co-58	NO DATA	7.45E-07	1.67E-06	NO DATA	NO DATA	NO DATA	1.51E-05	ALL	0.00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Fe-59	4.34E-06	1.02E-05	3.91E-06	NO DATA	NO DATA	2.85E-06	3.40E-05	ALL	0.00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Co-60	NO DATA	2.14E-06	4.72E-06	NO DATA	NO DATA	NO DATA	4.02E-05	ALL	0.00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Zn-65	4.84E-06	1.54E-05	6.96E-06	NO DATA	1.03E-05	NO DATA	9.70E-06	ALL	0.00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Cs-134	6.22E-05	1.48E-04	1.21E-04	NO DATA	4.79E-05	1.59E-05	2.59E-06	ALL	0.00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Cs-137	7.97E-05	1.09E-04	7.14E-05	NO DATA	3.70E-05	1.23E-05	2.11E-06	208	14.4	2.41E-02	3.30E-02	2.16E-02	0.00E+00	1.12E-02	3.72E-03	6.38E-04
H-3	NO DATA	1.05E-07	1.05E-07	1.05E-07	1.05E-07	1.05E-07	1.05E-07	208	14505	0.00E+00	3.20E-02	3.20E-02	3.20E-02	3.20E-02	3.20E-02	3.20E-02
Dose Commitment (mrem) =										2.41E-02	6.49E-02	5.36E-02	3.20E-02	4.32E-02	3.57E-02	3.26E-02

***Catawba Nuclear Station***  
***Dose from Shoreline Sediment Pathway for 2006 Data***  
***Maximum Exposed Adult***

Shoreline Recreation = 12 hr (in one year)  
 Shore Width Factor = 0.2  
 Sediment Surface Mass = 40 kg/m<sup>2</sup>

Adult Dose from Shoreline Sediment Pathway (mrem) = Shoreline Recreation (hr) x External Dose Factor (mrem/hr per pCi/m<sup>2</sup>) x Shore Width Factor x Sediment Surface Mass (kg/m<sup>2</sup>) x Sediment Concentration (pCi/kg)

Radionuclide	External Dose Factor Standing on Contaminated Ground (mrem/hr per pCi/m <sup>2</sup> )		Highest Annual Net Mean Concentration		Dose (mrem)	
	T. Body	Skin	Indicator Location	Sediment (pCi/kg)	T. Body	Skin
Mn-54	5.80E-09	6.80E-09	ALL	0.00	0.00E+00	0.00E+00
Co-58	7.00E-09	8.20E-09	208-1S	54.0	3.63E-05	4.25E-05
Co-60	1.70E-08	2.00E-08	208-1S	111	1.81E-04	2.13E-04
Cs-134	1.20E-08	1.40E-08	ALL	0.00	0.00E+00	0.00E+00
Cs-137	4.20E-09	4.90E-09	ALL	0.00	0.00E+00	0.00E+00
Dose Commitment (mrem) =					2.17E-04	2.56E-04

---

# 5.0 QUALITY ASSURANCE

---

## 5.1 SAMPLE COLLECTION

EnRad Laboratories, Fisheries, and Aquatic Ecology performed the environmental sample collections as specified by approved sample collection procedures.

## 5.2 SAMPLE ANALYSIS

EnRad Laboratories performed the environmental sample analyses as specified by approved analysis procedures. EnRad Laboratories is located in Huntersville, North Carolina, at Duke Energy Corporation's Environmental Center.



Duke Energy Corporation's  
Environmental Center

## 5.3 DOSIMETRY ANALYSIS

The Radiation Dosimetry and Records group performed environmental dosimetry measurements as specified by approved dosimetry analysis procedures.

## 5.4 LABORATORY EQUIPMENT QUALITY ASSURANCE

### 5.4.1 DAILY QUALITY CONTROL

EnRad Laboratories has an internal quality assurance program which monitors each type of instrumentation for reliability and accuracy. Daily quality control checks ensure that instruments are in proper working order and these checks are used to monitor instrument performance.

### 5.4.2 CALIBRATION VERIFICATION

National Institute of Standards and Technology (NIST) standards that represent counting geometries are analyzed as unknowns at various frequencies ranging from weekly to annually to verify that efficiency calibrations are valid. The frequency is dependent upon instrument use and performance. Investigations are performed and documented should calibration verification data fall out of limits.

### **5.4.3 BATCH PROCESSING**

Method quality control samples are analyzed with sample analyses that are processed in batches. These include gross beta in drinking water and tritium analyses.

## **5.5 DUKE ENERGY INTERCOMPARISON PROGRAM**

EnRad Laboratories participated in the Duke Energy Nuclear Generation Department Intercomparison Program during 2006. Interlaboratory cross-check standards, including, Marinelli beakers, air filters, air cartridges, gross beta on smears, and tritium in water samples were analyzed at various times of the year by the four counting laboratories in Duke Energy for this program. A summary of these Intercomparison Reports for 2006 is documented in Table 5.0-A.

## **5.6 DUKE ENERGY AUDITS**

The Catawba Radiation Protection Section was audited by the Quality Assurance Group in 2006. There were no REMP recommendations as a result of the audit.

EnRad Laboratories was audited by the Quality Assurance Group in 2006. There were no REMP recommendations as a result of the audit.

## **5.7 U.S. NUCLEAR REGULATORY COMMISSION INSPECTIONS**

The Catawba Nuclear Station Radiological Environmental Monitoring Program was not audited by the NRC in 2006. The program was audited in 2005 (Reference 6.12). There were no findings or issues identified by the audit.

## **5.8 STATE OF SOUTH CAROLINA INTERCOMPARISON PROGRAM**

EnRad Laboratories routinely participates with the Bureau of Radiological Health of the State's Department of Health and Environmental Control (DHEC) in an intercomparison program. EnRad Laboratories sends air, water, milk, vegetation, sediment, and fish samples which have been collected to the State of South Carolina DHEC Laboratory for intercomparison analysis.

## **5.9 TLD INTERCOMPARISON PROGRAM**

### **5.9.1 NUCLEAR TECHNOLOGY SERVICES INTERCOMPARISON PROGRAM**

Radiation Dosimetry and Records participates in a quarterly TLD intercomparison program administered by Nuclear Technology Services, Inc. of Roswell, GA. Nuclear Technology Services irradiates environmental



dosimeters quarterly and sends them to the Radiation Dosimetry and Records group for analysis of the unknown estimated delivered exposure. A summary of the Nuclear Technology Services Intercomparison Report is documented in Table 5.0-B.

### **5.9.2 STATE OF NORTH CAROLINA INTERCOMPARISON PROGRAM**

Radiation Dosimetry and Records routinely participates in a TLD intercomparison program. The State of North Carolina Radiation Protection Section irradiates environmental dosimeters and sends them to the Radiation Dosimetry and Records group for analysis of the unknown estimated delivered exposure. A summary of the State of North Carolina Environmental Dosimetry Intercomparison Report for 2006 is documented in Table 5.0-B.

### **5.9.3 INTERNAL CROSSCHECK (DUKE ENERGY)**

Radiation Dosimetry and Records participates in a quarterly TLD intracomparison program administered internally by the Dosimetry Lab. The Dosimetry Lab Staff irradiates environmental dosimeters quarterly and submits them for analysis of the unknown estimated delivered exposure. A summary of the Internal Cross Check (Duke Energy) Result is documented in Table 5.0-B.

**TABLE 5.0-A**  
**DUKE POWER COMPANY**  
**INTERLABORATORY COMPARISON PROGRAM**  
**2006 CROSS-CHECK RESULTS FOR**  
**ENRAD LABORATORIES**

Cross-Check samples are normally analyzed a minimum of three times. A status of "3 Pass" indicates that all three analyses yielded results within the designated acceptance range. A status of "1 Pass" indicates that one analysis of the cross-check was performed.

Footnote explanations are included following this data table.

***Gamma in Water 3.5 liters***

Reference Date	Sample I.D.	Nuclide	Acceptance Range pCi/l	Reference Value pCi/l	Mean Reported Value pCi/l	Cross Check Status
3/20/2006	Q061GWS	Cr-51	3.02 - 5.35 E5	4.02 E5	3.88 E5	3 Pass
		Co-57	1.37 - 2.42 E4	1.82 E4	1.86 E4	3 Pass
		Co-60	0.76 - 1.34 E5	1.01 E5	0.95 E5	3 Pass
		Sr-85	7.28 - 12.91 E4	9.71 E4	9.00 E4	3 Pass
		Y-88	1.27 - 2.25 E5	1.69 E5	1.62 E5	3 Pass
		Cd-109	3.72 - 6.60 E5	4.96 E5	4.97 E5	3 Pass
		Sn-113	6.65 - 11.80 E4	8.87 E4	8.60 E4	3 Pass
		Te-123M	1.62 - 2.86 E4	2.15 E4	2.09 E4	3 Pass
		Cs-137	6.30 - 11.17 E4	8.40 E4	7.69 E4	3 Pass
5/16/2006	Q062GWR	Cr-51	0.94 - 1.67 E4	1.26 E4	1.26 E4	3 Pass
		Co-57	1.97 - 3.50 E2	2.63 E2	2.76 E2	3 Pass
		Co-60	0.98 - 1.75 E3	1.31 E3	1.30 E3	3 Pass
		Sr-85	1.39 - 2.47 E3	1.86 E3	1.82 E3	3 Pass
		Y-88	2.07 - 3.66 E3	2.76 E3	2.69 E3	3 Pass
		Cd-109	4.99 - 8.86 E3	6.66 E3	6.57 E3	3 Pass
		Sn-113	1.06 - 1.89 E3	1.42 E3	1.25 E3	3 Pass
		Te-123M	2.62 - 4.64 E2	3.49 E2	3.40 E2	3 Pass
		Cs-137	0.82 - 1.45 E3	1.09 E3	1.06 E3	3 Pass
10/11/2006	Q064GWS	Cr-51	7.12 - 12.62 E4	9.49 E4	9.66 E4	3 Pass
		Mn-54	5.26 - 9.33 E4	7.02 E4	7.41 E4	3 Pass
		Co-58	4.17 - 7.39 E4	5.55 E4	5.66 E4	3 Pass
		Fe-59	1.42 - 2.53 E4	1.90 E4	2.01 E4	3 Pass
		Co-60	6.57 - 11.65 E4	8.76 E4	9.26 E4	3 Pass
		Zn-65	6.67 - 11.84 E4	8.90 E4	9.30 E4	3 Pass
		Cs-134	4.12 - 7.30 E4	5.49 E4	5.12 E4	3 Pass
		Cs-137	0.87 - 1.54 E5	1.16 E5	1.12 E5	3 Pass
		Ce-141	2.40 - 4.26 E4	3.20 E4	3.30 E4	3 Pass

**Gamma in Water 1.0 liter**

Reference Date	Sample I.D.	Nuclide	Acceptance Range pCi/l	Reference Value pCi/l	Mean Reported Value pCi/l	Cross Check Status
3/20/2006	Q061GWS	Cr-51	3.02 - 5.35 E5	4.02 E5	3.70 E5	3 Pass
		Co-57	1.37 - 2.42 E4	1.82 E4	1.80 E4	3 Pass
		Co-60	0.76 - 1.34 E5	1.01 E5	0.92 E5	3 Pass
		Sr-85	7.28 - 12.91 E4	9.71 E4	8.73 E4	3 Pass
		Y-88	1.27 - 2.25 E5	1.69 E5	1.56 E5	3 Pass
		Cd-109	3.72 - 6.60 E5	4.96 E5	4.59 E5	3 Pass
		Sn-113	6.65 - 11.80 E4	8.87 E4	8.27 E4	3 Pass
		Te-123M	1.62 - 2.86 E4	2.15 E4	2.00 E4	3 Pass
		Cs-137	6.30 - 11.17 E4	8.40 E4	7.54 E4	3 Pass
5/16/2006	Q062GWR	Cr-51	0.94 - 1.67 E4	1.26 E4	1.20 E4	3 Pass
		Co-57	1.97 - 3.50 E2	2.63 E2	2.64 E2	3 Pass
		Co-60	0.98 - 1.75 E3	1.31 E3	1.26 E3	3 Pass
		Sr-85	1.39 - 2.47 E3	1.86 E3	1.76 E3	3 Pass
		Y-88	2.07 - 3.66 E3	2.76 E3	2.58 E3	3 Pass
		Cd-109	4.99 - 8.86 E3	6.66 E3	6.34 E3	3 Pass
		Sn-113	1.06 - 1.89 E3	1.42 E3	1.17 E3	3 Pass
		Te-123M	2.62 - 4.64 E2	3.49 E2	3.02 E2	3 Pass
		Cs-137	0.82 - 1.45 E3	1.09 E3	0.99 E3	3 Pass
10/11/2006	Q064GWS	Cr-51	7.12 - 12.62 E4	9.49 E4	9.42 E4	3 Pass
		Mn-54	5.26 - 9.33 E4	7.02 E4	7.38 E4	3 Pass
		Co-58	4.17 - 7.39 E4	5.55 E4	5.63 E4	3 Pass
		Fe-59	1.42 - 2.53 E4	1.90 E4	2.00 E4	3 Pass
		Co-60	6.57 - 11.65 E4	8.76 E4	8.73 E4	3 Pass
		Zn-65	6.67 - 11.84 E4	8.90 E4	9.26 E4	3 Pass
		Cs-134	4.12 - 7.30 E4	5.49 E4	5.02 E4	3 Pass
		Cs-137	0.87 - 1.54 E5	1.16 E5	1.12 E5	3 Pass
		Ce-141	2.40 - 4.26 E4	3.20 E4	3.25 E4	3 Pass

**Gamma in Water 0.5 liter**

Reference Date	Sample I.D.	Nuclide	Acceptance Range pCi/l	Reference Value pCi/l	Mean Reported Value pCi/l	Cross Check Status
3/20/2006	Q061GWS	Cr-51	3.02 - 5.35 E5	4.02 E5	3.76 E5	3 Pass
		Co-57	1.37 - 2.42 E4	1.82 E4	1.70 E4	3 Pass
		Co-60	0.76 - 1.34 E5	1.01 E5	0.92 E5	3 Pass
		Sr-85	7.28 - 12.91 E4	9.71 E4	8.50 E4	3 Pass
		Y-88	1.27 - 2.25 E5	1.69 E5	1.54 E5	3 Pass
		Cd-109	3.72 - 6.60 E5	4.96 E5	4.53 E5	3 Pass
		Sn-113	6.65 - 11.80 E4	8.87 E4	8.23 E4	3 Pass
		Te-123M	1.62 - 2.86 E4	2.15 E4	1.96 E4	3 Pass
		Cs-137	6.30 - 11.17 E4	8.40 E4	7.26 E4	3 Pass

**Gamma in Water 0.5 liter, continued**

Reference Date	Sample I.D.	Nuclide	Acceptance Range pCi/l	Reference Value pCi/l	Mean Reported Value pCi/l	Cross Check Status
10/11/2006	Q064GWS	Cr-51	7.12 - 12.62 E4	9.49 E4	10.13 E4	3 Pass
		Mn-54	5.26 - 9.33 E4	7.02 E4	7.40 E4	3 Pass
		Co-58	4.17 - 7.39 E4	5.55 E4	5.64 E4	3 Pass
		Fe-59	1.42 - 2.53 E4	1.90 E4	2.08 E4	3 Pass
		Co-60	6.57 - 11.65 E4	8.76 E4	8.96 E4	3 Pass
		Zn-65	6.67 - 11.84 E4	8.90 E4	9.51 E4	3 Pass
		Cs-134	4.12 - 7.30 E4	5.49 E4	4.97 E4	3 Pass
		Cs-137	0.87 - 1.54 E5	1.16 E5	1.11 E5	3 Pass
		Ce-141	2.40 - 4.26 E4	3.20 E4	3.23 E4	3 Pass

**Gamma in Water 0.25 liter**

Reference Date	Sample I.D.	Nuclide	Acceptance Range pCi/l	Reference Value pCi/l	Mean Reported Value pCi/l	Cross Check Status
5/16/2006	Q062GWR	Cr-51	0.94 - 1.67 E4	1.26 E4	1.20 E4	3 Pass
		Co-57	1.95 - 3.55 E2	2.63 E2	2.66 E2	3 Pass
		Co-60	0.98 - 1.75 E3	1.31 E3	1.34 E3	3 Pass
		Sr-85	1.39 - 2.47 E3	1.86 E3	1.68 E3	3 Pass
		Y-88	2.07 - 3.66 E3	2.76 E3	2.61 E3	3 Pass
		Cd-109	4.66 - 9.52 E3	6.66 E3	6.60 E3	3 Pass
		Sn-113	1.06 - 1.89 E3	1.42 E3	1.14 E3	3 Pass
		Te-123M	2.58 - 4.71 E2	3.49 E2	2.96 E2	3 Pass
		Cs-137	0.82 - 1.45 E3	1.09 E3	1.00 E3	3 Pass
10/11/2006	Q064GWS	Cr-51	7.12 - 12.62 E4	9.49 E4	9.80 E4	3 Pass
		Mn-54	5.26 - 9.33 E4	7.02 E4	7.50 E4	3 Pass
		Co-58	4.17 - 7.39 E4	5.55 E4	5.63 E4	3 Pass
		Fe-59	1.42 - 2.53 E4	1.90 E4	2.14 E4	3 Pass
		Co-60	6.57 - 11.65 E4	8.76 E4	8.93 E4	3 Pass
		Zn-65	6.67 - 11.84 E4	8.90 E4	9.60 E4	3 Pass
		Cs-134	4.12 - 7.30 E4	5.49 E4	4.91 E4	3 Pass
		Cs-137	0.87 - 1.54 E5	1.16 E5	1.12 E5	3 Pass
		Ce-141	2.40 - 4.26 E4	3.20 E4	3.29 E4	3 Pass

**Gamma in Filter**

Reference Date	Sample I.D.	Nuclide	Acceptance Range pCi	Reference Value pCi	Mean Reported Value pCi	Cross Check Status
2/24/2006	A20206-04	Cr-51	7.33 - 12.99 E4	9.77 E4	9.56 E4	3 Pass
		Mn-54	1.29 - 2.29 E4	1.72 E4	1.76 E4	3 Pass
		Co-57	Sample Contaminant	Sample Contaminant	2.30 E2	N/A <sup>(1)</sup>
		Co-58	1.82 - 3.23 E4	2.43 E4	2.35 E4	3 Pass
		Fe-59	1.76 - 3.13 E4	2.35 E4	2.32 E4	3 Pass
		Co-60	1.72 - 3.05 E4	2.29 E4	2.22 E4	3 Pass
		Zn-65	2.54 - 4.51 E4	3.39 E4	3.34 E4	3 Pass
		Cs-134	1.65 - 2.93 E4	2.20 E4	2.01 E4	3 Pass
		Cs-137	1.19 - 2.10 E4	1.58 E4	1.47 E4	3 Pass
		Ce-139	Sample Contaminant	Sample Contaminant	3.99 E2	N/A <sup>(1)</sup>
		Ce-141	2.47 - 4.38 E4	3.29 E4	3.16 E4	3 Pass
6/8/2006	E4980-37	Cr-51	1.41 - 3.04 E2	2.07 E2	1.98 E2	3 Pass
		Mn-54	0.88 - 1.56 E2	1.17 E2	1.16 E2	3 Pass
		Co-58	6.00 - 10.64 E1	8.00 E1	7.86 E1	3 Pass
		Fe-59	5.63 - 9.98 E1	7.50 E1	7.73 E1	3 Pass
		Co-60	0.77 - 1.37 E2	1.03 E2	1.05 E2	3 Pass
		Zn-65	1.11 - 1.97 E2	1.48 E2	1.40 E2	3 Pass
		Cd-109	Sample Contaminant	Sample Contaminant	Too Low to Quantify	N/A <sup>(1)</sup>
		Cs-134	0.76 - 1.34 E2	1.01 E2	0.91 E2	3 Pass
		Cs-137	7.05 - 12.50 E1	9.40 E1	8.72 E1	3 Pass
		Ce-139	Sample Contaminant	Sample Contaminant	8.90 E0	N/A <sup>(1)</sup>
		Ce-141	1.10 - 1.96 E2	1.47 E2	1.35 E2	3 Pass

**Iodine in Water**

Reference Date	Sample I.D.	Nuclide	Acceptance Range pCi/l	Reference Value pCi/l	Mean Reported Value pCi/l	Cross Check Status
3/20/2006	Q061LIW1	I-131	2.42 - 4.30 E3	3.23 E3	3.31 E3	3 Pass
3/20/2006	Q061LIW2	I-131	N/A	0.00E+00	0.00E+00	3 Pass
3/20/2006	Q061LIW3	I-131	1.60 - 2.83 E3	2.13 E3	2.31 E3	3 Pass

**Iodine on Cartridge**

Reference Date	Sample I.D.	Nuclide	Acceptance Range pCi	Reference Value pCi	Mean Reported Value pCi	Cross Check Status
2/24/2006	A20207-04	I-131	N/A	N/A	N/A	N/A <sup>(2)</sup>
6/8/2006	E4981-37	I-131	4.88 - 8.65 E1	6.50 E1	7.31 E1	3 Pass

***Beta in Water***

Reference Date	Sample I.D.	Nuclide	Acceptance Range pCi/l	Reference Value pCi/l	Mean Reported Value pCi/l	Cross Check Status
6/8/2006	E4982-37	Beta	1.27 -2.25 E2	1.69 E2	1.65 E2	3 Pass

***Beta Smear***

Reference Date	Sample I.D.	Nuclide	Acceptance Range dpm	Reference Value dpm	Mean Reported Value dpm	Cross Check Status
2/24/2006	A20204-04	Beta	1.18 - 2.09 E4	1.57 E4	1.59 E4	3 Pass
11/10/2006	A21058-04	Beta	1.02 - 1.81 E4	1.36 E4	1.32 E4	3 Pass

***Tritium in Water***

Reference Date	Sample I.D.	Nuclide	Acceptance Range pCi/l	Reference Value pCi/l	Mean Reported Value pCi/l	Cross Check Status
3/21/2006	Q061TWSL1	H-3	1.52 - 2.70 E5	2.03 E5	1.99 E5	3 Pass
3/21/2006	Q061TWSL2	H-3	N/A	0.00E+00	0.00E+00	3 Pass
5/8/2006	Q062TWR1	H-3	N/A	0.00E+00	0.00E+00	3 Pass
5/8/2006	Q062TWR2	H-3	2.70 - 4.79 E3	3.60 E3	3.59 E3	3 Pass
5/8/2006	Q062TWR3	H-3	5.89 - 10.45 E2	7.86 E2	8.12 E2	3 Pass
9/13/2006	Q063TWSL1	H-3	0.77 - 1.37 E5	1.03 E5	1.03 E5	3 Pass
9/13/2006	Q063TWSL2	H-3	N/A	0.00E+00	0.00E+00	3 Pass

### **Table 5.0-A Footnote Explanations**

- (1) Gamma in Filter, Sample ID A20206-04, Reference Date 2/24/2006 & Gamma in Filter, Sample ID E4980-37, Reference Date 6/8/2006

Co-57, Cd-109 and Ce-139 was identified and reported for two cross-check samples. Co-57 and Ce-139 was identified in gamma filter A20206-04 and Cd-109 and Ce-139 was identified in gamma filter E4980-37. The cross check supplier does not include these radionuclides on the certificates of analysis for these two cross-check samples. These radionuclides were determined to be inherent contaminants in the cross-check samples. PIP G-06-00421 written.

- (2) Iodine on Cartridge, Sample ID A20207-04, Reference Date 2/24/2006

Cross-check A20207-04 was not analyzed in a timely manner for reporting. Cross-check data was not reported for this sample due to excessive sample decay. PIP G-06-00246 written.

# TABLE 5.0-B

## 2006 ENVIRONMENTAL DOSIMETER CROSS-CHECK RESULTS

### Nuclear Technology Services

1st Quarter 2006						2nd Quarter 2006					
TLD Number	Delivered (mrem)	Reported (mrem)	Bias (% diff)	Pass/Fail Criteria	Pass/Fail	TLD Number	Delivered (mrem)	Reported (mrem)	Bias (% diff)	Pass/Fail Criteria	Pass/Fail
102038	89	96.9	8.88	<+/-15%	Pass	102480	67	68.5	2.24	<+/-15%	Pass
102055	89	92.1	3.48	<+/-15%	Pass	102481	67	68.6	2.39	<+/-15%	Pass
102057	89	91.7	3.03	<+/-15%	Pass	102437	67	67.7	1.04	<+/-15%	Pass
102303	89	91.0	2.25	<+/-15%	Pass	102395	67	69.5	3.73	<+/-15%	Pass
102305	89	91.6	2.92	<+/-15%	Pass	102399	67	69.8	4.18	<+/-15%	Pass
Average Bias (B)			4.11			Average Bias (B)			2.72		
Standard Deviation (S)			2.70			Standard Deviation (S)			1.25		
Measure Performance  B +S			6.81	<15%	Pass	Measure Performance  B +S			3.97	<15%	Pass
3rd Quarter 2006						4th Quarter 2006					
TLD Number	Delivered (mrem)	Reported (mrem)	Bias (% diff)	Pass/Fail Criteria	Pass/Fail	TLD Number	Delivered (mrem)	Reported (mrem)	Bias (% diff)	Pass/Fail Criteria	Pass/Fail
102444	83.6	88.1	5.38	<+/-15%	Pass	100046	86.5	94.6	9.36	<+/-15%	Pass
102424	83.6	87.7	4.90	<+/-15%	Pass	100052	86.5	92.3	6.71	<+/-15%	Pass
102502	83.6	87.2	4.31	<+/-15%	Pass	100065	86.5	90.1	4.16	<+/-15%	Pass
102464	83.6	85.3	2.03	<+/-15%	Pass	100240	86.5	93.0	7.51	<+/-15%	Pass
102157	83.6	83.7	0.12	<+/-15%	Pass	100358	86.5	94.8	9.60	<+/-15%	Pass
Average Bias (B)			3.35			Average Bias (B)			7.47		
Standard Deviation (S)			2.22			Standard Deviation (S)			2.22		
Measure Performance  B +S			5.56	<15%	Pass	Measure Performance  B +S			9.68	<15%	Pass

### State of North Carolina, Division of Radiation Protection

Spring 2006						Fall 2006					
TLD Number	Delivered (mrem)	Reported (mrem)	Bias (% diff)	Pass/Fail Criteria	Pass/Fail	TLD Number	Delivered (mrem)	Reported (mrem)	Bias (% diff)	Pass/Fail Criteria	Pass/Fail
100246	55.0	58.8	6.91	<+/-15%	Pass					<+/-15%	
100243	55.0	61.6	12.00	<+/-15%	Pass					<+/-15%	
100241	55.0	58.0	5.45	<+/-15%	Pass					<+/-15%	
100240	55.0	58.2	5.82	<+/-15%	Pass					<+/-15%	
100239	55.0	59.6	8.36	<+/-15%	Pass					<+/-15%	
100236	55.0	57.2	4.00	<+/-15%	Pass					<+/-15%	
100232	55.0	**		<+/-15%						<+/-15%	
100217	55.0	56.7	3.09	<+/-15%	Pass					<+/-15%	
Average Bias (B)			6.52			Average Bias (B)					
Standard Deviation (S)			2.98			Standard Deviation (S)					
Measure Performance  B +S			9.50	<15%	Pass	Measure Performance  B +S				<15%	

\*\* TLD Damaged



### Internal Crosscheck (Duke Energy)

1st Quarter 2006						2nd Quarter 2006					
TLD Number	Delivered (mrem)	Reported (mrem)	Bias (% diff)	Pass/Fail Criteria	Pass/Fail	TLD Number	Delivered (mrem)	Reported (mrem)	Bias (% diff)	Pass/Fail Criteria	Pass/Fail
102261	49.0	48.6	-0.82	<+/-15%	Pass	100007	61.0	58.4	-4.23	<+/-15%	Pass
102244	49.0	49.1	0.13	<+/-15%	Pass	100021	61.0	58.8	-3.54	<+/-15%	Pass
102436	49.0	46.9	-4.31	<+/-15%	Pass	100035	61.0	60.2	-1.38	<+/-15%	Pass
102318	49.0	47.0	-4.17	<+/-15%	Pass	100072	61.0	60.2	-1.39	<+/-15%	Pass
102482	49.0	48.3	-1.39	<+/-15%	Pass	100168	61.0	60.8	-0.30	<+/-15%	Pass
102292	49.0	48.1	-1.93	<+/-15%	Pass	100123	61.0	59.5	-2.43	<+/-15%	Pass
102321	49.0	46.6	-4.86	<+/-15%	Pass	100734	61.0	59.4	-2.55	<+/-15%	Pass
102346	49.0	47.2	-3.70	<+/-15%	Pass	100108	61.0	60.6	-0.61	<+/-15%	Pass
102479	49.0	46.3	-5.46	<+/-15%	Pass	100049	61.0	58.6	-3.94	<+/-15%	Pass
102293	49.0	47.3	-3.45	<+/-15%	Pass	100169	61.0	58.2	-4.65	<+/-15%	Pass
Average Bias (B)			-3.00			Average Bias (B)			-2.50		
Standard Deviation (S)			1.87			Standard Deviation (S)			1.55		
Measure Performance  B +S			4.87	<15%	Pass	Measure Performance  B +S			4.05	<15%	Pass
3rd Quarter 2006						4th Quarter 2006					
TLD Number	Delivered (mrem)	Reported (mrem)	Bias (% diff)	Pass/Fail Criteria	Pass/Fail	TLD Number	Delivered (mrem)	Reported (mrem)	Bias (% diff)	Pass/Fail Criteria	Pass/Fail
101281	61.0	64.6	5.84	<+/-15%	Pass	101024	60.0	62.0	3.28	<+/-15%	Pass
101209	61.0	62.6	2.60	<+/-15%	Pass	101190	60.0	60.3	0.50	<+/-15%	Pass
101203	61.0	63.3	3.77	<+/-15%	Pass	101191	60.0	60.3	0.51	<+/-15%	Pass
101202	61.0	63.7	4.36	<+/-15%	Pass	101195	60.0	60.8	1.32	<+/-15%	Pass
101369	61.0	63.8	4.61	<+/-15%	Pass	101038	60.0	62.6	4.27	<+/-15%	Pass
101198	61.0	65.5	7.40	<+/-15%	Pass	100026	60.0	61.9	3.19	<+/-15%	Pass
101177	61.0	61.6	0.98	<+/-15%	Pass	100096	60.0	60.2	0.32	<+/-15%	Pass
101239	61.0	62.9	3.13	<+/-15%	Pass	100522	60.0	62.5	4.21	<+/-15%	Pass
101259	61.0	63.7	4.37	<+/-15%	Pass	100740	60.0	60.8	1.36	<+/-15%	Pass
101271	61.0	63.8	4.63	<+/-15%	Pass	100759	60.0	61.8	3.03	<+/-15%	Pass
Average Bias (B)			4.17			Average Bias (B)			2.20		
Standard Deviation (S)			1.75			Standard Deviation (S)			1.56		
Measure Performance  B +S			5.92	<15%	Pass	Measure Performance  B +S			3.76	<15%	Pass

---

## 6.0 REFERENCES

---

- 6.1 Catawba Selected License Commitment Report
- 6.2 Catawba Technical Specifications
- 6.3 Catawba Updated Final Safety Analysis Review
- 6.4 Catawba Offsite Dose Calculation Manual
- 6.5 Catawba Annual Environmental Operating Report 1985 - 2005
- 6.6 Catawba Annual Effluent Report 1985 - 2006
- 6.7 Probability and Statistics in Engineering and Management Science, Hines and Montgomery, 1969, pages 287-293.
- 6.8 Practical Statistics for the Physical Sciences, Havilcek and Crain, 1988, pages 83-93.
- 6.9 Nuclear Regulatory Commission Regulatory Guide 1.109, Calculation of Annual Doses to Man from Routine Releases of Reactor Effluents for the Purposes of Evaluating Compliance with 10CFR50, Appendix I.
- 6.10 EnRad Laboratories Operating Procedures
- 6.11 RETDAS, Radiological Effluent Tracking and Dose Assessment Software, Canberra Version 3.5.1, DPC Revision #4.0
- 6.12 NRC Integrated Inspection Report 05-04
- 6.13 Duke Energy Corporation EnRad Laboratory Charcoal Cartridge Study, performed 2001

**APPENDIX A**

**ENVIRONMENTAL SAMPLING  
&  
ANALYSIS PROCEDURES**

---

# APPENDIX A

---

## ENVIRONMENTAL SAMPLING AND ANALYSIS PROCEDURES

Adherence to established procedures for sampling and analysis of all environmental media at Catawba Nuclear Station was required to ensure compliance with Station Selected Licensee Commitments. Analytical procedures were employed to ensure that Selected Licensee Commitments detection capabilities were achieved.

Environmental sampling and analyses were performed by EnRad Laboratories, Dosimetry and Records, Fisheries and Aquatic Ecology.

This appendix describes the environmental sampling frequencies and analysis procedures by media type.

### I. CHANGE OF SAMPLING PROCEDURES

No changes were made to the sampling procedures during 2006.

### II. DESCRIPTION OF ANALYSIS PROCEDURES

Gamma spectroscopy analyses are performed using high purity germanium gamma detectors and Canberra analytical software. Designated sample volumes are transferred to appropriate counting geometries and analyzed by gamma spectroscopy. Perishable samples such as fish and broadleaf vegetation are ground to achieve a homogeneous mixture. Soils and sediments are dried, sifted to remove foreign objects (rocks, clams, glass, etc.) then transferred to appropriate counting geometry.

Low-level iodine analyses are performed by passing a designated sample aliquot through a pre-weighed amount of ion exchange resin to remove and concentrate any iodine in the aqueous sample (milk). The resin is then dried, mixed thoroughly, and a net resin weight determined before being transferred to appropriate counting geometry and analyzed by gamma spectroscopy.

Tritium analyses are performed quarterly by using low-level environmental liquid scintillation analysis technique on a Packard 2550 liquid scintillation system or Perkin-Elmer 2900TR liquid scintillation system. Tritium samples are distilled and batch processed with a tritium spike and blank to verify instrument performance and sample preparation technique are acceptable.

Gross beta analysis is performed by concentrating a designated aliquot of sample precipitate and analyzing by Tennelec XLB Series 5 gas-flow proportional counters. Samples are batch processed with a blank to ensure sample contamination has not occurred.

### **III. CHANGE OF ANALYSIS PROCEDURES**

A methodology based on nuclide abundance was implemented for determining Mn-54 activity in the presence of naturally occurring Ac-228 interference in certain media types. The method is described in PIP G-06-00040.

### **IV. SAMPLING AND ANALYSIS PROCEDURES**

#### **A.1 AIRBORNE PARTICULATE AND RADIOIODINE**

Airborne particulate and radioiodine samples at each of five locations were composited continuously by means of continuous air samplers. Air particulates were collected on a particulate filter and radioiodines were collected in a charcoal cartridge positioned behind the filter in the sampler. The samplers are designed to operate at a constant flow rate (in order to compensate for any filter loading) and are set to sample approximately 2 cubic feet per minute. Filters and cartridges were collected weekly. A separate weekly gamma analysis was performed on each charcoal cartridge and air particulate. A weekly gross beta analysis was performed on each filter. The continuous composite samples were collected from the locations listed below.

Location 200	=	Site Boundary (0.63 mi. NNE)
Location 201	=	Site Boundary (0.53 mi. NE)
Location 205	=	Site Boundary (0.23 mi. SW)
Location 212	=	Tega Cay (3.32 mi. E)
Location 258	=	Fairhope Road (9.84 mi. W)

#### **A.2 DRINKING WATER**

Monthly composite drinking water samples were collected at each of two locations. A gross beta and gamma analysis was performed on monthly composites. Tritium analysis was performed on the quarterly composites. The composites were collected monthly from the locations listed below.

Location 214	=	Rock Hill Water Supply (7.30 mi. SSE)
Location 218	=	Belmont Water Supply (13.5 mi. NNE)

### **A.3 SURFACE WATER**

Monthly composite samples were collected at each of three locations. A gamma analysis was performed on the monthly composites. Tritium analysis was performed on the quarterly composites. The composites were collected monthly from the locations listed below.

Location 208	=	Discharge Canal (0.45 mi. S)
Location 211	=	Wylie Dam (4.06 mi. ESE)
Location 215	=	River Pointe - Hwy 49 (4.21 mi. NNE)

### **A.4 GROUND WATER**

Grab samples were collected quarterly from residential wells at each of two locations. A gamma analysis and tritium analysis were performed on each sample. The samples were collected from the locations listed below.

Location 252	=	Residence (0.64 mi. SW)
Location 254	=	Residence (0.82 mi. N)

### **A.5 MILK**

Biweekly grab samples were collected at one location. A gamma and low-level Iodine-131 analysis was performed on each sample. The biweekly grab samples were collected from the location listed below.

Location 221	=	Dairy (14.5 mi. NW)
--------------	---	---------------------

### **A.6 BROADLEAF VEGETATION**

Monthly samples were collected at each of five locations. A gamma analysis was performed on each sample. The samples were collected from the locations listed below.

Location 200	=	Site Boundary (0.63 mi. NNE)
Location 201	=	Site Boundary (0.53 mi. NE)
Location 222	=	Site Boundary (0.70 mi. N)
Location 226	=	Site Boundary (0.48 mi. S)
Location 258	=	Fairhope Road (9.84 mi. W)

## **A.7 FOOD PRODUCTS**

Monthly samples were collected when available during the harvest season at one location. A gamma analysis was performed on each sample. The samples were collected from the location listed below.

Location 253 = Irrigated Gardens (1.90 mi. SSE)

## **A.8 FISH**

Semiannual samples were collected at each of two locations. A gamma analysis was performed on the edible portions of each sample. Boney fish (i.e. Sunfish) were prepared whole minus the head and tail portions. The samples were collected from the locations listed below.

Location 208 = Discharge Canal (0.45 mi. S)

Location 216 = Hwy 49 Bridge (4.19 mi. NNE)

## **A.9 SHORELINE SEDIMENT**

Semiannual samples were collected at each of three locations. A gamma analysis was performed on each sample following the drying and removal of rocks and clams. The samples were collected from the locations listed below.

Location 208 = Discharge Canal (0.45 mi. S)

Location 210 = Ebenezer Access (2.31 mi. SE)

Location 215 = River Pointe - Hwy 49 (4.21 mi. NNE)

## **A.10 DIRECT GAMMA RADIATION (TLD)**

Thermoluminescent dosimeters (TLD) were collected quarterly at forty-one locations. A gamma exposure rate was determined for each TLD. TLD locations are listed in Table 2.1-B. The TLDs were placed as indicated below.

- \* An inner ring of 16 TLDs, one in each meteorological sector in the general area of the site boundary.
- \* An outer ring of 16 TLDs, one in each meteorological sector in the 6 to 8 kilometer range.
- \* The remaining TLDs were placed in special interest areas such as population centers, residential areas, schools, and at three control locations.

#### **A.11 ANNUAL LAND USE CENSUS**

An Annual Land Use Census was conducted to identify within a distance of 8 kilometers (5.0 miles) from the station, the nearest location from the site boundary in each of the sixteen meteorological sectors, the following:

- \* The Nearest Residence
- \* The Nearest Garden greater than 50 square meters or 500 square feet
- \* The Nearest Milk-giving Animal (cow, goat, etc.)

The census was conducted during the growing season on 7/17 and 7/18/2006. Results are shown in Table 3.11. No changes were made to the sampling procedures during 2006 as a result of the 2006 census.

#### **V. GLOBAL POSITIONING SYSTEM (GPS) ANALYSIS**

The Catawba site centerline used for GPS measurements was referenced from the Catawba Nuclear Station Updated Final Safety Analysis Report (UFSAR), section 2.1.1.1, Specification of Location. Waypoint coordinates used for CNS GPS measurements were latitude 35°-3'-5"N and longitude 81°-4'-10"W. Maps and tables were generated using North American Datum (NAD) 27. Data normally reflect accuracy to within 2 to 5 meters from point of measurement. All GPS field measurements were taken as close as possible to the item of interest. Distances for the locations are displayed using three significant figures.



**APPENDIX B**

**RADIOLOGICAL  
ENVIRONMENTAL MONITORING  
PROGRAM**

**SUMMARY OF RESULTS**

**2006**

## Environmental Radiological Monitoring Program Summary

Facility: Catawba Nuclear Station

Docket No. 50-413,414

Location: York County, South Carolina

Report Period: 01-JAN-2006 to 31-DEC-2006

Medium or Pathway Sampled	Type and Total Number of	Lower Limit of Detection (LLD)	All Indicator Locations Mean (Fraction) Range	Location with Highest Annual Mean Name, Distance, Direction		Control Location Mean (Fraction) Range	No. of Non-Routine Report Meas.
				Location Code	Mean (Fraction) Range		
Air Particulate (pCi/m3)						258 (9.84 mi W)	
BETA	260	1.00E-02	1.65E-2 (208/208) 3.27E-3 - 2.73E-2	200 (0.63 mi NNE)	1.74E-2 (52/52) 7.68E-3 - 2.73E-2	1.74E-2 (52/52) 6.67E-3 - 2.56E-2	0
CS-134	260	5.00E-02	0.00 (0/208) 0.00 - 0.00		0.00 (0/52) 0.00 - 0.00	0.00 (0/52) 0.00 - 0.00	0
CS-137	260	6.00E-02	0.00 (0/208) 0.00 - 0.00		0.00 (0/52) 0.00 - 0.00	0.00 (0/52) 0.00 - 0.00	0
I-131	260	7.00E-02	0.00 (0/208) 0.00 - 0.00		0.00 (0/52) 0.00 - 0.00	0.00 (0/52) 0.00 - 0.00	0

Mean and range based upon detectable measurements only

Fraction of detectable measurements at specified locations is indicated in parentheses, (Fraction)

Zero range indicates no detectable activity measurements

## Environmental Radiological Monitoring Program Summary

Facility: Catawba Nuclear Station

Docket No. 50-413,414

Location: York County, South Carolina

Report Period: 01-JAN-2006 to 31-DEC-2006

Medium or Pathway Sampled	Type and Total Number of		Lower Limit of Detection (LLD)	All Indicator Locations  Mean (Fraction) Range	Location with Highest Annual Mean Name, Distance, Direction		Control Location  Mean (Fraction) Range	No. of Non-Routine Report Meas.
	Analyses Performed				Location Code	Mean (Fraction) Range		
Air Radioiodine (pCi/m <sup>3</sup> )							258 (9.84 mi W)	
	CS-134	260	5.00E-02	0.00 (0/208) 0.00 - 0.00		0.00 (0/52) 0.00 - 0.00	0.00 (0/52) 0.00 - 0.00	0
	CS-137	260	6.00E-02	9.87E-3 (1/208) 9.87E-3 - 9.87E-3	200 (0.63 mi NNE)	9.87E-3 (1/52) 9.87E-3 - 9.87E-3	0.00 (0/52) 0.00 - 0.00	0
	I-131	260	7.00E-02	0.00 (0/208) 0.00 - 0.00		0.00 (0/52) 0.00 - 0.00	0.00 (0/52) 0.00 - 0.00	0

Mean and range based upon detectable measurements only

Fraction of detectable measurements at specified locations is indicated in parentheses, (Fraction)

Zero range indicates no detectable activity measurements

## Environmental Radiological Monitoring Program Summary

Facility: Catawba Nuclear Station

Docket No. 50-413,414

Location: York County, South Carolina

Report Period: 01-JAN-2006 to 31-DEC-2006

Medium or Pathway Sampled	Type and Total Number of Analyses Performed	Lower Limit of Detection (LLD)	All Indicator Locations		Location with Highest Annual Mean Name, Distance, Direction		Control Location Mean (Fraction) Range	No. of Non-Routine Report Meas.
			Mean (Fraction) Range		Location Code	Mean (Fraction) Range		
Drinking Water (pCi/liter)							218 (13.5 mi NNE)	
BALA-140	26	15	0.00 (0/13) 0.00 - 0.00			0.00 (0/14) 0.00 - 0.00	0.00 (0/13) 0.00 - 0.00	0
BETA	26	4	2.30 (13/13) 1.36 - 3.51	214 (7.30 mi SSE)		2.30 (13/13) 1.36 - 3.51	2.17 (13/13) 1.31 - 3.77	0
CO-58	26	15	0.00 (0/13) 0.00 - 0.00			0.00 (0/14) 0.00 - 0.00	0.00 (0/13) 0.00 - 0.00	0
CO-60	26	15	0.00 (0/13) 0.00 - 0.00			0.00 (0/14) 0.00 - 0.00	0.00 (0/13) 0.00 - 0.00	0
CS-134	26	15	0.00 (0/13) 0.00 - 0.00			0.00 (0/14) 0.00 - 0.00	0.00 (0/13) 0.00 - 0.00	0
CS-137	26	18	0.00 (0/13) 0.00 - 0.00			0.00 (0/14) 0.00 - 0.00	0.00 (0/13) 0.00 - 0.00	0
FE-59	26	30	0.00 (0/13) 0.00 - 0.00			0.00 (0/14) 0.00 - 0.00	0.00 (0/13) 0.00 - 0.00	0
H-3	8	2000	1598 (4/4) 1000 - 2200	214 (7.30 mi SSE)		1598 (4/4) 1000 - 2200	770 (4/4) 582 - 1170	0
I-131	26	15	0.00 (0/13) 0.00 - 0.00			0.00 (0/14) 0.00 - 0.00	0.00 (0/13) 0.00 - 0.00	0
MN-54	26	15	0.00 (0/13) 0.00 - 0.00			0.00 (0/14) 0.00 - 0.00	0.00 (0/13) 0.00 - 0.00	0
NB-95	26	15	0.00 (0/13) 0.00 - 0.00			0.00 (0/14) 0.00 - 0.00	0.00 (0/13) 0.00 - 0.00	0
ZN-65	26	30	0.00 (0/13) 0.00 - 0.00			0.00 (0/14) 0.00 - 0.00	0.00 (0/13) 0.00 - 0.00	0
ZR-95	26	15	0.00 (0/13) 0.00 - 0.00			0.00 (0/14) 0.00 - 0.00	0.00 (0/13) 0.00 - 0.00	0

Mean and range based upon detectable measurements only

Fraction of detectable measurements at specified locations is indicated in parentheses, (Fraction)

Zero range indicates no detectable activity measurements

## Environmental Radiological Monitoring Program Summary

Facility: Catawba Nuclear Station

Docket No. 50-413,414

Location: York County, South Carolina

Report Period: 01-JAN-2006 to 31-DEC-2006

Medium or Pathway Sampled  Unit of Measurement	Type and Total Number of  Analyses Performed		Lower Limit of Detection  (LLD)	All Indicator Locations  Mean (Fraction) Range	Location with Highest Annual Mean Name, Distance, Direction  Location Code      Mean (Fraction) Range		Control Location  Mean (Fraction) Range	No. of Non-Routine Report Meas.
	Surface Water (pCi/liter) <span style="float: right;">215 (4.21 mi NNE)</span>							
BALA-140	39	15	0.00 (0/26)	0.00 - 0.00		0.00 (0/13)	0.00 (0/13)	0
CO-58	39	15	0.00 (0/26)	0.00 - 0.00		0.00 (0/13)	0.00 (0/13)	0
CO-60	39	15	0.00 (0/26)	0.00 - 0.00		0.00 (0/13)	0.00 (0/13)	0
CS-134	39	15	0.00 (0/26)	0.00 - 0.00		0.00 (0/13)	0.00 (0/13)	0
CS-137	39	18	0.00 (0/26)	0.00 - 0.00		0.00 (0/13)	0.00 (0/13)	0
FE-59	39	30	0.00 (0/26)	0.00 - 0.00		0.00 (0/13)	0.00 (0/13)	0
H-3	12	2000	8998 (8/8)	681 - 18000	208 (0.45 mi S)	16700 (4/4)	583 (4/4)	0
I-131	39	15	0.00 (0/26)	0.00 - 0.00		0.00 (0/13)	0.00 (0/13)	0
MN-54	39	15	0.00 (0/26)	0.00 - 0.00		0.00 (0/13)	0.00 (0/13)	0
NB-95	39	15	0.00 (0/26)	0.00 - 0.00		0.00 (0/13)	0.00 (0/13)	0
ZN-65	39	30	0.00 (0/26)	0.00 - 0.00		0.00 (0/13)	0.00 (0/13)	0
ZR-95	39	15	0.00 (0/26)	0.00 - 0.00		0.00 (0/13)	0.00 (0/13)	0

Mean and range based upon detectable measurements only

Fraction of detectable measurements at specified locations is indicated in parentheses, (Fraction)

Zero range indicates no detectable activity measurements

## Environmental Radiological Monitoring Program Summary

Facility: Catawba Nuclear Station

Docket No. 50-413,414

Location: York County, South Carolina

Report Period: 01-JAN-2006 to 31-DEC-2006

Medium or Pathway Sampled  Unit of Measurement	Type and Total Number of  Analyses Performed	Lower Limit of Detection  (LLD)	All Indicator Locations  Mean (Fraction) Range	Location with Highest Annual Mean Name, Distance, Direction		Control Location  Mean (Fraction) Range	No. of Non-Routine Report Meas.
				Location Code	Mean (Fraction) Range		
Ground Water (pCi/liter)						NO CONTROL LOCATION	
	BALA-140	8	15	0.00 (0/8) 0.00 - 0.00		0.00 (0/8) 0.00 - 0.00	0
	CO-58	8	15	0.00 (0/8) 0.00 - 0.00		0.00 (0/8) 0.00 - 0.00	0
	CO-60	8	15	0.00 (0/8) 0.00 - 0.00		0.00 (0/8) 0.00 - 0.00	0
	CS-134	8	15	0.00 (0/8) 0.00 - 0.00		0.00 (0/8) 0.00 - 0.00	0
	CS-137	8	18	0.00 (0/8) 0.00 - 0.00		0.00 (0/8) 0.00 - 0.00	0
	FE-59	8	30	0.00 (0/8) 0.00 - 0.00		0.00 (0/8) 0.00 - 0.00	0
	H-3	8	2000	0.00 (0/8) 0.00 - 0.00		0.00 (0/8) 0.00 - 0.00	0
	I-131	8	15	0.00 (0/8) 0.00 - 0.00		0.00 (0/8) 0.00 - 0.00	0
	MN-54	8	15	0.00 (0/8) 0.00 - 0.00		0.00 (0/8) 0.00 - 0.00	0
	NB-95	8	15	0.00 (0/8) 0.00 - 0.00		0.00 (0/8) 0.00 - 0.00	0
	ZN-65	8	30	0.00 (0/8) 0.00 - 0.00		0.00 (0/8) 0.00 - 0.00	0
	ZR-95	8	15	0.00 (0/8) 0.00 - 0.00		0.00 (0/8) 0.00 - 0.00	0

Mean and range based upon detectable measurements only

Fraction of detectable measurements at specified locations is indicated in parentheses, (Fraction)

Zero range indicates no detectable activity measurements

## Environmental Radiological Monitoring Program Summary

Facility: Catawba Nuclear Station

Docket No. 50-413,414

Location: York County, South Carolina

Report Period: 01-JAN-2006 to 31-DEC-2006

Medium or Pathway Sampled	Type and Total Number of	Lower Limit of Detection (LLD)	All Indicator Locations		Location with Highest Annual Mean		Control Location	No. of Non-Routine Report Meas.
			Mean (Fraction) Range	Location Code	Mean (Fraction) Range	Mean (Fraction) Range		
Milk (pCi/liter)			NO INDICATOR LOCATION				221 (14.5 mi NW)	
	BALA-140	26	15	0.00 (0/0)		0.00 (0/0)	0.00 (0/26)	0
				0.00 - 0.00		0.00 - 0.00	0.00 - 0.00	
	CS-134	26	15	0.00 (0/0)		0.00 (0/0)	0.00 (0/26)	0
				0.00 - 0.00		0.00 - 0.00	0.00 - 0.00	
	CS-137	26	18	0.00 (0/0)		0.00 (0/0)	0.00 (0/26)	0
				0.00 - 0.00		0.00 - 0.00	0.00 - 0.00	
	I-131	26	15	0.00 (0/0)		0.00 (0/0)	0.00 (0/26)	0
				0.00 - 0.00		0.00 - 0.00	0.00 - 0.00	
	LLI-131	26	1	0.00 (0/0)		0.00 (0/0)	0.00 (0/26)	0
				0.00 - 0.00		0.00 - 0.00	0.00 - 0.00	

Mean and range based upon detectable measurements only

Fraction of detectable measurements at specified locations is indicated in parentheses, (Fraction)

Zero range indicates no detectable activity measurements

## Environmental Radiological Monitoring Program Summary

Facility: Catawba Nuclear Station

Docket No. 50-413,414

Location: York County, South Carolina

Report Period: 01-JAN-2006 to 31-DEC-2006

Medium or Pathway Sampled  Unit of Measurement	Type and Total Number of  Analyses Performed		Lower Limit of Detection  (LLD)	All Indicator Locations  Mean (Fraction) Range	Location with Highest Annual Mean Name, Distance, Direction		Control Location  Mean (Fraction) Range	No. of Non-Routine Report Meas.
					Location Code	Mean (Fraction) Range		
Broadleaf Vegetation (pCi/kg-wet)							258 (9.84 mi W)	
	CS-134	60	60	0.00 (0/48) 0.00 - 0.00		0.00 (0/12) 0.00 - 0.00	0.00 (0/12) 0.00 - 0.00	0
	CS-137	60	80	57.9 (9/48) 24.6 - 125	201 (0.53 mi NE)	57.9 (9/12) 24.6 - 125	0.00 (0/12) 0.00 - 0.00	0
	I-131	60	60	0.00 (0/48) 0.00 - 0.00		0.00 (0/12) 0.00 - 0.00	0.00 (0/12) 0.00 - 0.00	0

Mean and range based upon detectable measurements only

Fraction of detectable measurements at specified locations is indicated in parentheses, (Fraction)

Zero range indicates no detectable activity measurements



## Environmental Radiological Monitoring Program Summary

Facility: Catawba Nuclear Station

Docket No. 50-413,414

Location: York County, South Carolina

Report Period: 01-JAN-2006 to 31-DEC-2006

Medium or Pathway Sampled  Unit of Measurement	Type and Total Number of  Analyses Performed	Lower Limit of Detection  (LLD)	All Indicator Locations		Location with Highest Annual Mean Name, Distance, Direction		Control Location  Mean (Fraction) Range	No. of Non-Routine Report Meas.
			Mean (Fraction) Range	Location Code	Mean (Fraction) Range	Mean (Fraction) Range		
Food Products (pCi/kg-wet)							NO CONTROL LOCATION	
	CS-134	4	60	0.00 (0/4) 0.00 - 0.00		0.00 (0/4) 0.00 - 0.00	0.00 (0/0) 0.00 - 0.00	0
	CS-137	4	80	0.00 (0/4) 0.00 - 0.00		0.00 (0/4) 0.00 - 0.00	0.00 (0/0) 0.00 - 0.00	0
	I-131	4	60	0.00 (0/4) 0.00 - 0.00		0.00 (0/4) 0.00 - 0.00	0.00 (0/0) 0.00 - 0.00	0

Mean and range based upon detectable measurements only

Fraction of detectable measurements at specified locations is indicated in parentheses, (Fraction)

Zero range indicates no detectable activity measurements

## Environmental Radiological Monitoring Program Summary

Facility: Catawba Nuclear Station

Docket No. 50-413,414

Location: York County, South Carolina

Report Period: 01-JAN-2006 to 31-DEC-2006

Medium or Pathway Sampled  Unit of Measurement	Type and Total Number of  Analyses Performed	Lower Limit of Detection  (LLD)	All Indicator Locations		Location with Highest Annual Mean Name, Distance, Direction		Control Location  Mean (Fraction) Range	No. of Non-Routine Report Meas.
			Mean (Fraction) Range		Location Code	Mean (Fraction) Range		
Fish (pCi/kg-wet)							216 (4.19 mi NNE)	
	CO-58	12	130	0.00 (0/6) 0.00 - 0.00		0.00 (0/6) 0.00 (0/6)	0.00 (0/6) 0.00 - 0.00	0
	CO-60	12	130	0.00 (0/6) 0.00 - 0.00		0.00 (0/6) 0.00 (0/6)	0.00 (0/6) 0.00 - 0.00	0
	CS-134	12	130	0.00 (0/6) 0.00 - 0.00		0.00 (0/6) 0.00 - 0.00	0.00 (0/6) 0.00 - 0.00	0
	CS-137	12	150	14.4 (1/6) 14.4 - 14.4	208 (0.45 mi S)	14.4 (1/6) 14.4 - 14.4	0.00 (0/6) 0.00 - 0.00	0
	FE-59	12	260	0.00 (0/6) 0.00 - 0.00		0.00 (0/6) 0.00 - 0.00	0.00 (0/6) 0.00 - 0.00	0
	MN-54	12	130	0.00 (0/6) 0.00 - 0.00		0.00 (0/6) 0.00 - 0.00	0.00 (0/6) 0.00 - 0.00	0
	ZN-65	12	260	0.00 (0/6) 0.00 - 0.00		0.00 (0/6) 0.00 - 0.00	0.00 (0/6) 0.00 - 0.00	0

Mean and range based upon detectable measurements only

Fraction of detectable measurements at specified locations is indicated in parentheses, (Fraction)

Zero range indicates no detectable activity measurements

## Environmental Radiological Monitoring Program Summary

Facility: Catawba Nuclear Station

Docket No. 50-413,414

Location: York County, South Carolina

Report Period: 01-JAN-2006 to 31-DEC-2006

Medium or Pathway Sampled  Unit of Measurement	Type and Total Number of  Analyses Performed	Lower Limit of Detection  (LLD)	All Indicator Locations		Location with Highest Annual Mean Name, Distance, Direction		Control Location  Mean (Fraction) Range	No. of Non-Routine Report Meas.
			Mean (Fraction) Range		Location Code	Mean (Fraction) Range		
Shoreline Sediment (pCi/kg-dry)							215 (4.21 mi NNE)	
	MN-54	6	0	0.00 (0/4) 0.00 - 0.00		0.00 (0/2) 0.00 - 0.00	0.00 (0/2) 0.00 - 0.00	
	CO-58	6	0	54.0 (1/4) 54.0 - 54.0	208-1S (0.45 mi S)	54.0 (1/2) 54.0 - 54.0	0.00 (0/2) 0.00 - 0.00	0
	CO-60	6	0	111 (1/4) 111 - 111	208-1S (0.45 mi S)	111 (1/2) 111 - 111	0.00 (0/2) 0.00 - 0.00	0
	CS-134	6	150	0.00 (0/4) 0.00 - 0.00		0.00 (0/2) 0.00 - 0.00	0.00 (0/2) 0.00 - 0.00	0
	CS-137	6	180	0.00 (0/4) 0.00 - 0.00		0.00 (0/2) 0.00 - 0.00	0.00 (0/2) 0.00 - 0.00	0

Mean and range based upon detectable measurements only

Fraction of detectable measurements at specified locations is indicated in parentheses, (Fraction)

Zero range indicates no detectable activity measurements

If LLD is equal to 0.00, then the LLD is not required by Selected Licensee Commitments

## Environmental Radiological Monitoring Program Summary

Facility: Catawba Nuclear Station

Docket No. 50-413,414

Location: York County, South Carolina

Report Period: 01-JAN-2006 to 31-DEC-2006

Medium or Pathway Sampled  Unit of Measurement	Type and Total Number of  Analyses Performed	Lower Limit of Detection  (LLD)	All Indicator Locations  Mean (Fraction) Range	Location with Highest Annual Mean Name, Distance, Direction		Control Location  Mean (Fraction) Range	No. of Non-Routine Report Meas.
				Location Code	Mean (Fraction) Range		
Direct Radiation TLD (mR/standard quarter)						217 (10.3 mi SSE) 247 (7.33 mi ESE) 251 (9.72 mi WNW)	
	158	0.00E+00	18.6 (147/147) 9.90 - 30.9	235 (4.07 mi ESE)	26.4 (4/4) 23.4 - 30.9	14.3 (11/11) 10.0 - 19.3	0

Mean and range based upon detectable measurements only

Fraction of detectable measurements at specified locations is indicated in parentheses, (Fraction)

Zero range indicates no detectable activity measurements

**APPENDIX C**

**SAMPLING DEVIATIONS  
&  
UNAVAILABLE ANALYSES**

# APPENDIX C

## CATAWBA NUCLEAR STATION SAMPLING DEVIATIONS & UNAVAILABLE ANALYSES

DEVIATION & UNAVAILABLE REASON CODES			
BF	Blown Fuse	PO	Power Outage
FZ	Sample Frozen	PS	Pump out of service / Undergoing Repair
IW	Inclement Weather	SL	Sample Loss/Lost due to Lab Accident
LC	Line Clog to Sampler	SM	Motor / Rotor Seized
OT	Other	TF	Torn Filter
PI	Power Interrupt	VN	Vandalism
PM	Preventive Maintenance	CN	Construction

### C.1 SAMPLING DEVIATIONS

#### Air Particulate and Air Radioiodines

Location	Scheduled Collection Dates	Actual Collection Dates	Reason Code	Corrective Action
205*	8/22-8/29/2006	8/22-8/24/2006	BF	A blown fuse in air sampler was found at time of collection. Fuse was replaced and normal sampling resumed.
212	9/26-10/3/2006	9/26-10/3/2006	PI	Deviation due to planned power interruption. Tega Cay Retail performed work on the AC Load Center that supplies power to site. Power was interrupted to the site at 9/28/2006 12:30. The duration of the interruption was 2.20 hours. Power was restored 9/28/2006 14:42. Samplers were verified operational following power restoration and normal sampling resumed.
205*	10/17-10/24/2006	10/17-10/18/2006	BF	A blown fuse in air sampler was found at time of collection. Fuse was replaced and normal sampling resumed.
205*	10/31-11/7/2006	10/31-11/6/2006	BF	A blown fuse in air sampler was found at time of collection. Fuse was replaced and normal sampling resumed.
205*	12/5-12/12/2006	12/5-12/11/2006	BF	A blown fuse in air sampler was found at time of collection. Fuse was replaced and normal sampling resumed.

\* Location 205 is not configured for redundant operation of air sampling equipment. Historically, this location has not been problematic for this type of deviation. The last occurrence of a blown fuse to an air sampler at this location prior to 2006 was for scheduled monitoring period of 9/23-9/30/1998. Moisture interference with the line conditioner at this location is the suspected cause for the repeated occurrence of blown fuses.

## Drinking Water

Location	Scheduled Collection Dates	Actual Collection Dates	Reason Code	Corrective Action
214	1/17-2/14/2006	1/17-2/13/2006	PI	Power to sampling equipment was interrupted. The water treatment plant manager indicated the power was interrupted at approximately 2/13/2006 09:00 for sandblasting of the interior walls where sampling equipment is located. Construction work and its potential impact on sampling equipment at this location is described in PIP G-05-00200.
218	4/11-5/9/2006	5/9/2006	LC	Line clog to sampling equipment interrupted water flow. Work request 65283 and PIP C-06-03581 initiated. A grab sample was taken on 5/9/2006. Normal sampling resumed 5/9/2006 16:00.
214	5/9-6/6/2006	6/6/2006	PI	Power to sampling equipment was interrupted due to construction. Insufficient composite volume was available so a grab sample was taken. Construction work and its potential impact on sampling equipment at this location is described in PIP G-05-00200. Equipment was verified operational and normal sampling resumed.

## C.2 UNAVAILABLE ANALYSES

### TLD

Location	Scheduled Collection Dates	Reason Code	Corrective Action
234*	12/14-3/15/2006	VN	TLD missing. 2 <sup>nd</sup> quarter 2006 TLD placed in field.
225	3/15-6/14/2006	VN	TLD missing. 3 <sup>rd</sup> quarter 2006 TLD placed in field.
237	3/15-6/14/2006	CN	TLD missing. 3 <sup>rd</sup> quarter 2006 TLD placed in field.
240	6/14-9/13/2006	VN	TLD missing. 4 <sup>th</sup> quarter 2006 TLD placed in field.
246	9/13-12/13/2006	VN	TLD missing. 1 <sup>st</sup> quarter 2007 TLD placed in field.
251	9/13-12/13/2006	VN	TLD missing. 1 <sup>st</sup> quarter 2007 TLD placed in field.

\* TLD 234 is located in the E sector at 4.50 miles. The TLD is currently placed near the corner of a commercial bank parking lot which is heavily traveled by the general public. This location has undergone tremendous commercial development recently. A study TLD was placed in the same sector at 4.48 miles (GPS handheld measurement made on 3/15/2006) on a South Carolina highway road sign indicating "Beck Meacham Richardson Highway" which is on Gold Hill Road on the other side of the commercial bank parking lot. "Study TLD" placed as part of ASSESSMENT NO.: GO-06-62(RP)(REMP)(CNS) & PIP No: G-06-00151. Study TLD was added to program as a secondary TLD location for site 234.

# **APPENDIX D**

## **ANALYTICAL DEVIATIONS**

No Analytical deviations were incurred for the  
2006 Radiological Environmental Monitoring Program



# **APPENDIX E**

## **RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM RESULTS**

This appendix includes all of the sample analysis reports generated from each sample medium for 2006. Appendix E is located separately from this report and is permanently archived at the Duke Energy Corporation Environmental Center radiological environmental master file, located at the McGuire Nuclear Station Site in Huntersville, North Carolina.