

CONTRACTOR REPORT

NUREG/CR-2321

SAND81-7144

RP


Investigation of Fire Stop Test Parameters Final Report

Leon Przybyla
Underwriters Laboratories
333 Pfingsten Road
Northbrook, IL 60062

Printed September 1981

Prepared for Sandia National Laboratories
under Contract No. 07-9116

Prepared for
US NUCLEAR REGULATORY COMMISSION



NUREG/CR-2321
SAND81-7144
RP

US83
78NK8858

INVESTIGATION OF
FIRE STOP TEST PARAMETERS
FINAL REPORT

September 1981


Sandia Project Officer: L. J. Klamerus

Prepared for

Sandia National Laboratories
Albuquerque, New Mexico 87185
operated by
Sandia Corporation
for the
US Department of Energy

Work performed under Sandia Contract No. 07-9116

Funded by
Division of Engineering Technology
Office of Nuclear Reactor Research
Washington, DC 20555
Under Memorandum of Understanding DOE 40-550-75
NRC Fin No. A1010



ABSTRACT

An experimental investigation was performed to determine the effects of pressure differential, fire exposure conditions and sample construction on the performance of fire stops used to seal electric cable and conduit penetrations through concrete fire barriers. Experiments were conducted using a differential pressure of -12 to +125 Pa, various sample constructions and two fire exposure conditions. Results indicate that the effect of pressure differential is not significant for those fire-stop materials which do not have cracks or other through openings that allow passage of gases during fire exposure. However, if the material allows passage for gases through cracks or other holes, such as those left open after a cable pull, the pressure differential affects fire stop performance. Effects of the size of the opening; size, location and type of the penetrating items installed through the opening; and severity of fire exposure on the performance of fire stops are demonstrated.





TABLE OF CONTENTS

Abstract	-i-
Table of Contents	-iii-
List of Figures	-v-
List of Tables	-ix-
Foreword	-x-
1. Introduction	1
2. Experimental Procedure	2
2.1 General	2
2.2 Samples	2
2.3 Apparatus	3
2.4 Method	4
3. Experimental Results	5
3.1 General	5
3.2 Effect of Pressure Differential	5
3.3 Effect of Fire Exposure	7
3.4 Effect of Sample Construction	7
4. Recommendations	9
5. References	10
Appendix A - Sample Details	43
Appendix B - Instrumentation	46
Appendix C - Experimental Results	70



LIST OF FIGURES

<u>Figure</u>		<u>Page</u>
1	Appearance Of Unexposed Side Of Fire Stop Sample Prior To Experiment	29
2	Appearance Of Unexposed Side Of Fire Stop Sample Prior To Experiment	30
3	Furnace	31
4	Enclosure	32
5	Temperature-Time Curve	33
6	The Rate Of Propagation Of 725 F (285 C) Temperature (Experiments P1, P3, P5)	34
7	The Rate Of Propagation Of 300 F (149 C) Temperature (Experiments P14, P16)	35
8	Unexposed Surface Temperatures Of Fire Stop Material (Standard Versus Special Fire Exposure)	36
9	Unexposed Surface Temperatures Of Fire Stop Material (Standard Versus Special Fire Exposure)	37
10	Unexposed Surface Temperatures Of Fire Stop Material (Copper Versus Aluminum Conductor)	38
11	Unexposed Surface Temperatures Of Fire Stop Material (Conductor Size)	39
12	Unexposed Surface Temperatures Of Fire Stop Material (Pipe Size)	40
13	Unexposed Surface Temperatures Of Fire Stop Material (Steel Versus Aluminum Conduit)	41
14	Unexposed Surface Temperatures Of Fire Stop Material (Cable Loading)	42
A1	Floor Slabs	45
B1	Group 1 - Thermocouple Locations	47
B2	Group 2 - Thermocouple Locations	48
B3	Group 3 - Thermocouple Locations	49
B4	Group 4 - Thermocouple Locations	50
B5	Group 5 - Thermocouple Locations	51
B6	Group 6 - Thermocouple Locations	52
B7	Group 7 - Thermocouple Locations	53
B8	Group 8 - Thermocouple Locations	54
B9	Group 9 - Thermocouple Locations	55
B10	Group 10 - Thermocouple Locations	56
B11	Group 11 - Thermocouple Locations	57

LIST OF FIGURES (CONT'D)

<u>Figure</u>		<u>Page</u>
B12	Group 12 - Thermocouple Locations	58
B13	Group 13 - Thermocouple Locations	59
B14	Group 14 - Thermocouple Locations	60
B15	Group 15 - Thermocouple Locations	61
B16	Group 16 - Thermocouple Locations	62
B17	Group 17 - Thermocouple Locations	63
B18	Group 18 - Thermocouple Locations	64
B19	Group 19 - Thermocouple Locations	65
B20	Group 20 - Thermocouple Locations	66
B21	Group 21 - Thermocouple Locations	67
B22	Location Of Thermocouples Within Fire Stop	68
B23	Location Of Pressure Probes	69
C1	Unexposed Surface Temperatures Of Fire Stop Material (P22)	74
C2	Unexposed Surface Temperatures Of Fire Stop Material (P19)	75
C3	Unexposed Surface Temperatures Of Fire Stop Material (P1)	76
C4	Unexposed Surface Temperatures Of Fire Stop Material (P3)	77
C5	Unexposed Surface Temperatures Of Fire Stop Material (P5)	78
C6	Unexposed Surface Temperatures Of Fire Stop Material (P23)	79
C7	Unexposed Surface Temperatures Of Fire Stop Material (P20)	80
C8	Unexposed Surface Temperatures Of Fire Stop Material (P2)	81
C9	Unexposed Surface Temperatures Of Fire Stop Material (P4)	82
C10	Unexposed Surface Temperatures Of Fire Stop Material (P6)	83
C11	Unexposed Surface Temperatures Of Fire Stop Material (P9)	84
C12	Unexposed Surface Temperatures Of Fire Stop Material (P11)	85
C13	Unexposed Surface Temperatures Of Fire Stop Material (P10)	86
C14	Unexposed Surface Temperatures Of Fire Stop Material (P12)	87
C15	Unexposed Surface Temperatures Of Fire Stop Material (P13)	88
C16	Unexposed Surface Temperatures Of Fire Stop Material (P15)	89
C17	Unexposed Surface Temperatures Of Fire Stop Material (P14)	90

LIST OF FIGURES (CONT'D)


<u>Figure</u>		<u>Page</u>
C18	Unexposed Surface Temperatures Of Fire Stop Material (P16)	91
C19	Unexposed Surface Temperatures Of Fire Stop Material (P7)	92
C20	Unexposed Surface Temperatures Of Fire Stop Material (P8)	93
C21	Unexposed Surface Temperatures Of Fire Stop Material (P21)	94
C22	Unexposed Surface Temperatures Of Fire Stop Material (P21)	95
C23	Unexposed Surface Temperatures Of Fire Stop Material (P21)	96
C24	Unexposed Surface Temperatures Of Fire Stop Material (P17)	97
C25	Unexposed Surface Temperatures Of Fire Stop Material (P17)	98
C26	Unexposed Surface Temperatures Of Fire Stop Material (P17)	99
C27	Unexposed Surface Temperatures Of Fire Stop Material (P18)	100
C28	Unexposed Surface Temperatures Of Fire Stop Material (P18)	101
C29	Unexposed Surface Temperatures Of Fire Stop Material (P18)	102
C30	Unexposed Surface Temperatures Of Fire Stop Material (FC1)	103
C31	Unexposed Surface Temperatures Of Fire Stop Material (FC1)	104
C32	Unexposed Surface Temperatures Of Fire Stop Material (FC2)	105
C33	Unexposed Surface Temperatures Of Fire Stop Material (FC2)	106
C34	Unexposed Surface Temperatures Of Fire Stop Material (FC3)	107
C35	Unexposed Surface Temperatures Of Fire Stop Material (FC3)	108
C36	Unexposed Surface Temperatures Of Fire Stop Material (FC3)	109
C37	Unexposed Surface Temperatures Of Fire Stop Material (FC3)	110
C38	Unexposed Surface Temperatures Of Fire Stop Material (CT1)	111
C39	Unexposed Surface Temperatures Of Fire Stop Material (CT2)	112
C40	Unexposed Surface Temperatures Of Fire Stop Material (CT3)	113

LIST OF FIGURES (CONT'D)

<u>Figure</u>		<u>Page</u>
C41	Unexposed Surface Temperatures Of Fire Stop Material (CT4)	114
C42	Unexposed Surface Temperatures Of Fire Stop Material (CS1)	115
C43	Unexposed Surface Temperatures Of Fire Stop Material (CS2)	116
C44	Unexposed Surface Temperatures Of Fire Stop Material (CS3)	117
C45	Unexposed Surface Temperatures Of Fire Stop Material (CS4)	118
C46	Unexposed Surface Temperatures Of Fire Stop Material (T1)	119
C47	Unexposed Surface Temperatures Of Fire Stop Material (T2)	120
C48	Unexposed Surface Temperatures Of Fire Stop Material (T3)	121
C49	Unexposed Surface Temperatures Of Fire Stop Material (T4)	122
C50	Unexposed Surface Temperatures Of Fire Stop Material (PS1)	123
C51	Unexposed Surface Temperatures Of Fire Stop Material (PS2)	124
C52	Unexposed Surface Temperatures Of Fire Stop Material (CD1)	125
C53	Unexposed Surface Temperatures Of Fire Stop Material (CD2)	126
C54	Unexposed Surface Temperatures Of Fire Stop Material (CD3)	127
C55	Unexposed Surface Temperatures Of Fire Stop Material (CD4)	128
C56	Unexposed Surface Temperatures Of Fire Stop Material (CL1)	129
C57	Unexposed Surface Temperatures Of Fire Stop Material (CL1)	130
C58	Unexposed Surface Temperatures Of Fire Stop Material (CL1)	131
C59	Unexposed Surface Temperatures Of Fire Stop Material (CL2)	132
C60	Unexposed Surface Temperatures Of Fire Stop Material (CL2)	133
C61	Unexposed Surface Temperatures Of Fire Stop Material (CL2)	134
C62	Unexposed Surface Temperatures Of Fire Stop Material (S1)	135
C63	Unexposed Surface Temperatures Of Fire Stop Material (S2)	136
C64	Unexposed Surface Temperatures Of Fire Stop Material (S3)	137
C65	Unexposed Surface Temperatures Of Fire Stop Material (S4)	138

LIST OF TABLES

<u>Table</u>		<u>Page</u>
1	Experimental Summary	11
2	Pressure Differential Samples	13
3	Pressure Differential Samples	14
4	Fire Exposure Samples	15
5	Sample Constructions - Conductors	16
6	Sample Constructions - Penetrating Items	17
7	Sample Constructions - Cable Loading	18
8	Sample Constructions - Opening Sizes	19
9	Pressure Differential Experiments	20
10	Pressure Differential Experiments	21
11	Fire Exposure Experiments	22
12	Sample Experiments - Conductor Type And Size	23
13	Sample Experiments - Cable Type	24
14	Sample Experiments - Conduit Or Pipe Type And Size	25
15	Sample Experiments - Cable Loading	26
16	Sample Experiments - Size	27
17	Flame Occurrence Time - Pressure Experiments	28
A1	Cable Description	44
C1	Duration And Time To Flaming For Pressure Differential Experiments	71
C2	Duration And Time To Flaming For Fire Exposure Experiments	72
C3	Duration And Time To Flaming For Sample Experiments	73



FORWARD

This investigation is part of the Fire Research Program of the U.S. Nuclear Regulatory Commission (NRC). This program was established as a result of the Browns Ferry fire and the recommendations made in NUREG-0050.¹ The objective of this program is to obtain data to confirm or modify the current regulatory guides and standards for fire protection and to determine the adequacy of generic designs and materials with respect to fire safety.² This program consists of eight elements which encompass a broad range of fire protection concerns in light water reactor (LWR) power plants. A part of one element of this program is to obtain information on test parameters used to evaluate fire stops. This investigation sponsored by Sandia Laboratories, provides a limited assessment of several of these test parameters.

All the fire experiments were conducted at UL's Fire Protection Department in Northbrook, Illinois. The author acknowledges the assistance of Thomas Plens in constructing, instrumenting and conducting these experiments; Sandi Hansen in obtaining computer generated graphics of the data; and R. Parks and W. Christian in preparing the text.

Respectfully submitted:
Underwriters Laboratories Inc.



Leon J. Przybyla
Engineering Team Leader
Fire Protection Department


Reviewed and Approved by:



R. L. Parks
Staff Engineer
Fire Protection Department



W. J. Christian
Manager, Research and Technology Development



INVESTIGATION OF FIRE STOP TEST PARAMETERS

1. Introduction

Fire stops installed in nuclear power plants are generally qualified by testing in accordance with IEEE 634-1978.³ This Standard prescribes the test procedure and method to evaluate results. The test procedure consists of subjecting the fire stop sample to a fire exposure in accordance with Standard ASTM E119.⁴ Immediately after fire exposure, the sample is subjected to a water spray (hose stream test). Fire stops are acceptable if they withstand the fire test without passage of flame or gases hot enough to ignite cable on the non-fire side, and if they limit the temperature on the non-fire side to less than 700 F. Additionally, the sample must withstand the hose stream test without developing an opening which allows the passage of a water stream.

Although pressure differentials (the pressure at one side of the fire stop with respect to the other side) exist at various areas in the plant under normal operation, the IEEE 634 test method does not require a specific pressure differential to be applied during the test. The Standard recognizes this aspect, but does not address it.

Also, according to IEEE 634, sample selection for testing is to be representative of the fire stop installed in the field. In order to facilitate the selection, suggested guidelines are given for size of opening and types and sizes of cables but, data substantiating the selection is not given. The effects of varying the sample construction by changing its size, number of cables and location of cables is not known.

This investigation was conducted to develop information on the effect changes in pressure differential and sample construction have on the performance of the fire stop. Additionally, the effect of subjecting the fire stops to a fire exposure less severe in temperature than the ASTM E119 exposure was also investigated.

2. Experimental Procedure

2.1 General

This investigation consisted of conducting 50 small-scale fire experiments using several types of fire stop samples. A summary of the experiments conducted is shown in Table 1. These experiments were organized into twenty-one groups to facilitate comparison of results. Within each group, the parameter under consideration was varied with the sample and test procedure held constant.

Each sample was subjected to the prescribed fire exposure until either flaming occurred on the unexposed side or until the appropriate information was obtained. During each experiment, temperatures of the unexposed surface and visual observations of physical performance were recorded. For some experiments, temperatures within the fire stop material were recorded for supplemental information.

2.2 Samples

All fire stops were installed in 6 in. (150 mm)⁺ thick concrete floor slabs. Openings in all but three slabs were either circular 6 in. (150 mm) in diameter or 12 in. (310 mm) square. The remaining slabs had circular openings of 2 in. (51 mm), 9 in. (230 mm) and 13 in. (330 mm) in diameter.

The fire stop materials used were silicone foam, silicone elastomer, and a fire stop device. These are representative of materials currently used in nuclear power plants. The silicone foam and silicone elastomer were two-component materials which vulcanized at room temperature (RTV). These materials which were mixed, poured into the openings, and cured in accordance with the manufacturer's installation instructions. The nominal free rise densities were 30 pcf (0.48 Mg/m³) and 90 pcf (1.42 Mg/m³) for the silicone foam and silicone elastomer, respectively. However, the device was constructed from several separate components of steel plates, intumescent material, and a neoprene gasket. The device was installed by friction fit from the compression of the neoprene material in accordance with the manufacturer's installation instructions.

+ - Equivalent SI units included in parenthesis may only be approximate.

Various types of penetrating items were used in the construction of the fire stop samples. The penetrating items included cables, cable trays, conduits, and pipes. Details of these items are presented in Appendix A.

Samples were constructed with the penetrating items protruding about 12 in. (300 mm) below the exposed surface and 36 in. (910 mm) above the unexposed surface. When cable trays were used the penetrating items were fastened to them on the unexposed side for support.

These samples were designed to facilitate performance measurement so as to provide an increased data base upon which the evaluation of changes in parameters could be made. It should not be misconstrued that the samples were designed to obtain a 3 hr fire rating which is required for field installed fire stops as specified in Appendix R of 10CFR Part 50. A summary description of the various experimental samples is shown in Tables 2-8. Examples of the appearance of the fire stop samples prior to test are shown in Figures 1 and 2.

2.3 Apparatus

2.3.1 Furnace

The small scale floor furnace (Fig. 3) of Underwriters Laboratories Inc. was used in these experiments.

2.3.2 Enclosure

In some experiments, to obtain the desired pressure differential, an enclosure was placed on the unexposed side of the sample, and the air pressure within the enclosure either increased or decreased as needed. The general construction of the enclosure was as shown in Fig. 4. Air flowed continuously through the enclosure through the ports. The inlet and exhaust ports were adjusted to provide the desired pressure control. Flow through the ports was diverted toward the walls of the enclosure away from the sample and penetrating items.

2.3.3 Instrumentation

Type K Chromel-Alumel thermocouples were used for all temperature measurements of the unexposed surface of the fire stop materials and of the material interior for some samples. All thermocouples on the unexposed surface were covered by a 0.75 in. (19 mm) by 0.75 in. (19 mm) by 0.16 in. (4 mm) thick asbestos pad. Pressure was measured with probes connected to either a manometer or an electronic barometer.

2.4 Method

Summaries of the experiments are shown in Tables 9-16. Except in three experiments, the samples were subjected to a fire exposure with the furnace temperatures controlled in accordance with the standard temperature-time curve specified in ASTM E119 (shown in Figure 5). In the remaining experiments, the furnace temperatures were controlled in accordance with the other less severe temperature-time curve also shown in Figure 5. The pressure differential between the exposed surface and unexposed surface was measured and controlled to the desired pressure for each experiment. Positive pressure differential was obtained by having a greater pressure at the exposed surface of the fire stop with respect to the unexposed surface. A negative pressure differential was obtained by having a greater pressure at the unexposed surface of the fire stop with respect to the exposed surface. Experiments were conducted until flaming occurred on the unexposed side or until the appropriate information was obtained.

3. Experimental Results

3.1 General

The results of all the experiments are included in Appendix C. The temperatures on the unexposed surface of the fire stop material were plotted versus time for each experiment and are shown in Figures C1-C65. The experiment duration and the time at which flaming occurred on the unexposed side are shown in Tables C1-C3.

The effect of each parameter was considered separately. In order to determine the effect of changes in each parameter, results of applicable experiments were compared (see Table 1 for groups of applicable experiments). The primary means of assessing results was to compare the appropriate unexposed surface temperatures. If a comparison could not be obtained due to minor changes in temperature during the experiment, or if supplemental data was desired, a comparison of time to flaming was conducted. Also in evaluating pressure differential, sample construction - cable type, and sample construction - opening size, a comparison of visual observations was conducted.

3.2 Effect Of Pressure Differential

Results indicated that for those materials which remained integral during the test and did not allow a path for gas flow, the effect of changes in pressure differential was not significant.

In tests with a positive pressure differential between 0.01 and 0.50 in H₂O (2 and 125 Pa), no significant change was observed in the transmission of heat through the material, in the time at which flaming occurred, or in the formation of cracks in the decomposing material. The rate of heat transmission through the silicone foam and silicone elastomer materials can be seen by the rate at which a specific temperature propagates through the material. The propagation rate of the 725 F (285 C) temperature was selected for comparison since it also represents the approximate front of the char layer. As shown in Fig. 6, the rate at which this temperature propagated through the material was not significantly affected by changes in the positive pressure differential. For the device the propagation rate of 300 F (149 C) temperature was arbitrarily selected for comparison since a specific temperature associated with the degradation of the material was not readily obtainable. Fig. 7 shows that the propagation rate of the 300 F (149 C) temperature also was not significantly affected by the pressure differential.

The time at which flaming occurred on the unexposed side was not affected by changes in positive pressure differential. The times at which flaming occurred for the experiments with silicone foam are shown in Table 16. It ranged from 110 min to 116 min. This is considered within the normal range of repeatability for failure times (for structural integrity) of fire resistant assemblies. During the conduct of all the experiments for the silicone elastomer and device in Groups 3 through 6, flaming did not occur on the unexposed side.

The formation of cracks in the decomposing material was not affected by changes in the positive pressure differential. In all experiments which produced flaming failure, propagation of a crack through the material was rapid, usually occurring within 5 min. after crack formation. Collapse of the material occurred immediately after the crack propagated through the material and ignition of the unexposed surface was almost instantaneous. Because of this, flame passage through the crack was not a significant factor in the ignition process.

Testing with a negative pressure differential did not significantly affect the performance of the silicone foam material installed without through openings. One experiment was conducted at a negative pressure differential of 0.05 in H₂O (12 Pa) while a similar sample was tested at a positive pressure differential of 0.01 in H₂O (2 Pa). The time of failure was essentially the same (154 min for -0.05 in H₂O (-12 Pa) and 153 min for 0.01 in H₂O (2 Pa)). However, the failure mode was different for these experiments. For the positive pressure differential experiment, the material cracked, collapsed, and the unexposed surface of the material ignited. In the negative pressure differential experiment the material cracked, collapsed, and the cable ignited.

Testing with a positive pressure differential affected the performance of the silicone elastomer material installed with through openings. Two experiments were conducted with two nominal 0.50 in. (12 mm) diameter holes in the silicone elastomer material created by pulling cables from the bundle after the material had been installed. One experiment was conducted at 0.015 in H₂O (3 Pa) pressure differential, while the other experiment was conducted at -0.05 in H₂O (-12 Pa). During the positive pressure experiment smoke and hot gases issued through the holes. However, the gases were sufficiently cooled that flames from the fire side did not issue through the holes. After 15 min, the hot gases were melting the cable material surrounding the holes. The smoke and gases issuing from the holes was rich in unburned fuel and could be ignited by a small flame source such as a match. During the negative pressure experiment, smoke and hot gases were not observed issuing through the holes. However, after 27 mins, the radiant heat from the furnace began to melt the cable material surrounding the holes which produced smoking on the unexposed side.

3.3 Effect Of Fire Exposure

Three experiments were conducted with a fire less severe in temperature than the standard temperature-time curve specified in ASTM E119. As expected, temperatures on the unexposed side of the samples for these experiments were lower than for comparable samples subjected to a ASTM E119 fire exposure (Figs. 8 and 9). Consequentially, the time to failure increased for the samples exposed to the less severe fire. For example, failure occurred at 153 mins for Experiment P7 while it occurred at 177 mins for Experiment FCl.

3.4 Effect Of Changes In Sample

Changes in sample construction investigated were conductor type and size, cable type, conduit or pipe type and size, cable loading, and opening size. Results indicate that changes in fire stop construction can effect the performance.

Changes in conductor type (copper vs. aluminum) affected unexposed surface temperatures of the fire stop material near the conductor (Fig. 10). The temperature rise near the copper 300 MCM cable was greater than at the aluminum 300 MCM cable. Increasing the conductor size also resulted in increased temperature on the unexposed surface of the fire stop material near the conductor as shown in Fig. 11.

The physical performance of different cable jacket/insulation types was compared. It was observed that during each experiment, the temperature of the cable gradually increased for about the first 4 in. (100 mm) above the base of the cable on the unexposed side of the fire stop. As the temperature increased, each cable jacket/insulation material reacted differently. For example, one cable jacket/insulation material melted quickly, dripped, and the molten material then coagulated into a mass on the surface. Another cable jacket/insulation material did not melt, but swelled and cracked near the base.

The size of pipe or conduit affected the temperature of the surrounding fire stop material as shown in Fig. 12. Based upon the temperature at the material-pipe interface, the temperature tended to be greater near the 3 in. pipe than at the smaller 1 in. pipe. The type of conduit, either steel or aluminum, also had an effect on the surrounding fire stop material temperature as shown in Fig. 13. The temperature at the material-pipe interface tended to be generally greater near the aluminum conduit than near the steel conduit.

It was observed that increasing the number of cables penetrating the fire stop increased the temperature of the fire stop material near the cables as shown in Fig. 14. The temperature near a three layer bundle of cable was greater than the temperature near a one layer bundle of cable.

The size of the opening appeared to affect the structural integrity of the material. It was observed that for the larger openings 6 in. (152 mm), 9 in. (230 mm) and 12 in. (305 mm), the material tended to deflect downward at the center of the opening during fire exposure. The rate of deflection appeared to increase with increasing opening size. This downward deflection tended to affect the performance of the material by causing cracks along the periphery of the opening, which in turn decreased the structural integrity of the material.

4. Recommendations

This report has provided only a limited, qualitative assessment of the effects due to changes in pressure differential, fire exposure, and sample construction. It is recommended that further study of these data be conducted to determine if other effects can be ascertained, if quantitative relationships can be derived, and to define further experimental data which may be needed.

5. References

1. U.S. Nuclear Regulatory Commission, Recommendations Related to Browns Ferry Fire, USNRC Report NUREG-0050, February 1976. Available for purchase from National Technical Information Service, Springfield, Virginia 22161.
2. U.S. Nuclear Regulatory Commission, Water Reactor Safety Research Program, USNRC Report NUREG-0006, February 1979. Available for purchase from National Technical Information Service, Springfield, Virginia 22161.
3. "IEEE Standard Cable Penetration Fire Stop Qualification Test," IEEE 634-1978. Available for purchase from the Institute of Electrical and Electronics Engineers, Inc., 345 East 47th Street, New York, New York 10017.
4. "Standard Methods Of Fire Tests Of Building Construction And Materials," ASTM E119-80. Available for purchase from the American Society For Testing And Materials, 1916 Race Street, Philadelphia, PA 19103.

Table 1

Experimental Summary

Parameter	Group	Experiments	Description
Pressure Differential	1	P22, P19, P1, P3, P5	Pressure +2 to +125 Pa; silicone foam; cables
	2	P23, P20, P2, P4, P6	Pressure +2 to +125 Pa; silicone foam; no cables
	3	P9, P11	Pressure +2 and +125 Pa; silicone elastomer; cables
	4	P10, P12	Pressure +2 and +125 Pa; silicone elastomer; no cables
	5	P13, P15	Pressure +2 and +125 Pa; device; cables
	6	P14, P16	Pressure +2 and +125 Pa; device; no cables
	7	P7, P8	Pressure +2 and -12 Pa; silicone foam; cables
	8	P21	Pressure +125 Pa; silicone foam with formed crack
	9	P17, P18	Pressure +3 and -12 Pa; silicone elastomer with two holes created by cable pull
Fire Exposure	10	FC1, FC2,	Silicone Foam - less severe temperature curve
		P7*	Silicone Foam - ASTM E119 temperature curve
	11	FC3	Silicone Elastomer - less severe temperature curve
		CL1*	Silicone Elastomer - ASTM E119 temperature curve
Sample (Conductor Size & Type)	12	CT1, CT3	300 MCM CU Cable
		CT2, CT4	300 MCM AL Cable
	13	CS1	3C/12 AWG Cable - Silicone Elastomer
		CS2	7C/12 AWG Cable - Silicone Elastomer
		CT1*	300 MCM Cable - Silicone Elastomer

* - Experiment used for comparison with others in group

Table 1 (Cont'd)

Parameter	Group	Experiments	Description
	14	CS3	3C/12 AWG Cable - Device
		CS4	7C/12 AWG Cable - Device
		CT4*	300 MCM Cable - Device
Sample (Cable Type)	15	T1	Cable Type A - Silicone Elastomer
		T2	Cable Type G - Silicone Elastomer
		T3	Cable Type H - Silicone Elastomer
		CS2*	Cable Type F - Silicone Elastomer
	16	T4	Cable Type A - Device
		CS4*	Cable Type F - Device
Sample (Pipe)	17	PS1	1 in. Steel Pipe
		PS2	3 in. Steel Pipe
Sample (Conduit)	18	CD1	1 in. Steel Conduit
		CD2	1 in. AL Conduit
	19	CD3	3 in. Steel Conduit
		CD4	3 in. AL Conduit
Sample (Cable Loading)	20	CL1	One Layer of Cables
		CL2	Three Layers of Cables
Sample (Opening)	21	S1	2 in. (51 mm) Opening
		S2	6 in. (152 mm) Opening
		S3	9 in. (230 mm) Opening
		S4	12 in. (300 mm) Opening

* - Experiment used for comparison with others in group

TABLE 2

Pressure Differential Samples

<u>Sample Reference</u>	<u>Floor Slab</u>		<u>Fire Stop Material</u>		<u>Hole 1 Cable</u>		<u>Hole 2 Cable</u>	
	<u>Type</u>	<u>No.</u>	<u>Type</u>	<u>Thickness, In. (mm)</u>	<u>Type*</u>	<u>No.</u>	<u>Type</u>	<u>No.</u>
100	I	5	SF	6.0 (150)	A	3	None	
101	I	2	SR	6.0 (150)	A	3	None	
102	I	2	D	3.75 (95)	A	3	None	

SF = Silicone Foam

SR = Silicone Elastomer

D = Fire Stop Device

* = See Appendix A

TABLE 3

Pressure Differential Samples

<u>Sample Reference</u>	<u>Floor Slab</u>		<u>Fire Stop Material</u>		<u>Cable</u>	
	<u>Type</u>	<u>No.</u>	<u>Type</u>	<u>Thickness, In. (mm)</u>	<u>Type*</u>	<u>No.</u>
103	II	2	SF	6.0 (150)	B	1
103**	II	1	SF	6.0 (150)	B	1
103***	II	2	SR	2.5 (64)	B	31

SF = Silicone Foam

SR = Silicone Elastomer

* = See Appendix A

** = Fire stop formed with a 0.38 in. (10 mm) wide by 9.5 in. (240 mm) long by 4 in. (100 mm) deep crack, as seen from the unexposed side, along one edge of the opening.

*** = Fire stop formed with two holes caused by pulling cables out after material had cured. Cable tray used as raceway for the cable bundle.

TABLE 4

Fire Exposure Samples

<u>Sample Reference</u>	<u>Floor Slab</u>		<u>Fire Stop Material</u>		<u>Cable</u>	
	<u>Type</u>	<u>No.</u>	<u>Type</u>	<u>Thickness, In. (mm)</u>	<u>Type*</u>	<u>No.</u>
104	II	2	SF	6.0 (150)	B	1
105	II	1	SR	4.0 (100)	A	11

SF = Silicone Foam

SR = Silicone Elastomer

* = See Appendix A

TABLE 5

Sample Constructions - Conductors

Sample Reference	Hole 1			Hole 2			
	Floor Slab Type* No.	Fire Stop Material		Fire Stop Material Type	Fire Stop Material		Cable Type* No.
		Thickness, In. (mm)	Cable Type* No.		Thickness, In. (mm)	Cable Type* No.	
106	I 1	SR	6.0 (150)	C 1	D	3.75 (95)	C 1
107	I 1	SR	6.0 (150)	E 1	D	3.75 (95)	E 1
108	I 1	SR	6.0 (150)	F 1	D	3.75 (95)	F 1
109	I 1	SR	6.0 (150)	B 1	D	3.75 (95)	B 1
110	I 1	SR	6.0 (150)	A 1	D	3.75 (95)	A 1
111	I 1	SR	6.0 (150)	G 1	SR	6.0 (150)	H 1

SR = Silicone Elastomer

D = Fire Stop Device

* = See Appendix A

TABLE 6

Sample Constructions - Penetrating Items

<u>Sample Reference</u>	<u>Floor Slab</u>		<u>Penetrating Items</u>			<u>Cable Per Item</u>	
	<u>Type*</u>	<u>No.</u>	<u>Type</u>	<u>No.</u>	<u>Size**</u>	<u>Type</u>	<u>No.</u>
112	II	1	Steel Pipe	3	1	None	
			Steel Pipe	2	3	None	
113	II	1	Steel Conduit	3	1	A	1
			Steel Conduit	2	3	A	3
114	II	1	AL Conduit	3	1	A	1
			AL Conduit	2	3	A	3

Silicone elastomer, 4.0 in. (100 mm) thick, used as fire stop material.

* = See Appendix A

** = Trade Size (In.)

TABLE 7

Sample Constructions - Cable Loading

<u>Sample Reference</u>	<u>Floor Slab</u>		<u>Cable</u>		<u>Fire Stop Material</u>	
	<u>Type*</u>	<u>No.</u>	<u>Type*</u>	<u>No.</u>	<u>Type</u>	<u>Thickness, In. (mm)</u>
115	I	1	A	11	SR	4.0 (101)
116	I	1	A	33	SR	4.0 (101)

Cables installed in 6 in. wide cable tray.

SR = Silicone Elastomer

* = See Appendix A

TABLE 8

Sample Constructions - Opening Sizes

<u>Sample Reference</u>	<u>Floor Slab</u>		<u>Hole Diameter Size In. (mm)</u>	<u>Fire Stop Material</u>	
	<u>Type*</u>	<u>No.</u>		<u>Type</u>	<u>Thickness, In. (mm)</u>
117	III	1	2 (51) and 6 (150)	SF	6.0 (150)
118	IV	1	9 (230)	SF	6.0 (150)
119	V	1	12 (300)	SF	6.0 (150)

All samples installed without cables.

SF = Silicone Foam

* = See Appendix A

TABLE 9

Pressure Differential Experiments

<u>Group No.</u>	<u>Experiment Identification</u>	<u>Sample Reference</u>	<u>Pressure In H₂O (Pa)</u>	<u>General Description</u>
1	P22	100	+0.01 (+2)	Silicone foam with cables
	P19	100	+0.05 (+12)	
	P1	100	+0.05 (+12)	
	P3	100	+0.50 (+125)	
	P5	100	+0.50 (+125)	
2	P23	100	+0.01 (+2)	Silicone foam without cables
	P20	100	+0.05 (+12)	
	P2	100	+0.05 (+12)	
	P4	100	+0.25 (+62)	
	P6	100	+0.50 (+125)	
3	P9	101	+0.50 (+125)	Silicone elastomer with cables
	P11	101	+0.01 (+2)	
4	P10	101	+0.50 (+125)	Silicone elastomer without cables
	P12	101	+0.01 (+2)	
5	P13	102	+0.05 (+12)	Device with cables
	P15	102	+0.50 (+125)	
6	P14	102	+0.05 (+12)	Device without cables
	P16	102	+0.50 (+125)	

TABLE 10

Pressure Differential Experiments

<u>Group No.</u>	<u>Experiment Identification</u>	<u>Sample Reference</u>	<u>Pressure In H2O (Pa)</u>	<u>General Description</u>
7	P7	103	+0.01 (+2)	Silicone foam with cable
	P8	103	-0.05 (-12)	
8	P21	103**	+0.50 (+125)	Silicone foam with formed crack
9	P17	103***	+0.015 (+3)	Silicone elastomer with two holes created by cable pull
	P18	103***	+0.05 (-12)	

TABLE 11

Fire Exposure Experiments

<u>Group No.</u>	<u>Experiment Identification</u>	<u>Sample Reference</u>	<u>General Description</u>
10	FC1 FC2	104 104	Silicone foam with cable
11	FC3	105	Silicone elastomer with cables

Experiments conducted with furnace temperature controlled as shown in Fig. 5.

TABLE 12

Sample Experiments - Conductor Type & Size

<u>Group No.</u>	<u>Experiment Identification</u>	<u>Sample Reference</u>	<u>General Description</u>
12	CT1	106	Silicone elastomer - 300MCM Cu
	CT2	106	Device - 300MCM Cu
	CT3	107	Silicone elastomer - 300MCM AL
	CT4	107	Device - 300 MCM AL
13	CS1	109	Silicone elastomer - 3C/12 AWG
	CS2	108	Silicone elastomer - 7C/12 AWG
14	CS3	109	Device - 3C/12 AWG
	CS4	108	Device - 7C/12 AWG

TABLE 13

Sample Experiments - Cable Type

<u>Group No.</u>	<u>Experiment Identification</u>	<u>Sample Reference</u>	<u>General Description</u>
	T1	110	Silicone elastomer Cable Type A
15	T2	111	Silicone elastomer Cable Type G
	T3	111	Silicone elastomer Cable Type H
16	T4	110	Device - Cable Type A

TABLE 14

Sample Experiments - Conduit or Pipe Type & Size

<u>Group No.</u>	<u>Experiment Identification</u>	<u>Sample Reference</u>	<u>General Description</u>
17	PS1	112	1 in. steel pipe
	PS2	112	3 in. steel pipe
18	CD1	113	1 in. steel conduit
	CD2	114	1 in. AL conduit
19	CD3	113	3 in. steel conduit
	CD4	114	3 in. AL conduit

TABLE 15

Sample Experiments - Cable Loading

<u>Group No.</u>	<u>Experiment Identification</u>	<u>Sample Reference</u>	<u>General Description</u>
20	CL1	115	One layer of cables
	CL2	116	Three layers of cables

TABLE 16


Sample Experiments - Size

<u>Group No.</u>	<u>Experiment Identification</u>	<u>Sample Reference</u>	<u>General Description</u>
21	S1	117	2 in. (51 mm) opening
	S2	117	6 in. (152 mm) opening
	S3	118	9 in. (230 mm) opening
	S4	119	12 in. (305 mm) opening

TABLE 17

Flame Occurrence Time - Pressure Experiments

<u>Pressure in H₂O (Pa)</u>	<u>Experiment Identification</u>	<u>Time (Min)</u>
0.05 +12	P1	116
0.25 +62	P3	110
0.50 +125	P5	112



C81-2667

Figure 1: Appearance Of Unexposed Side Of Fire Stop Sample Prior To Experiment




Figure 2 - Appearance Of Unexposed Side Of Fire Stop Sample Prior To Experiment

SMALL SCALE HORIZONTAL EXPOSURE FURNACE




Figure 3 - Furnace




Figure 4 - Enclosure





Figure 5 - Temperature-Time Curve




Temperature Rise Through The Material At The Center Of Fire Stop

P1
(+12 Pa)

P3
(+62 Pa)

P5
(+125 Pa)

Figure 6 - The Rate Of Propagation Of 725 F (285 C) Temperature (Experiments P1, P3, P5)



Temperature Rise Through The Device At 1.5 In. (38 mm) From The Center


P14
(+12 Pa)

P16
(+125 Pa)

Figure 7 - The Rate Of Propagation Of 300 F (149 C) Temperature
(Experiments P14, P16)

UNEXPOSED SURFACE TEMPERATURES

(STANDARD VS SPECIAL FIRE EXPOSURE)




* See Figure B7
 ** See Figure B10

STANDARD EXP. P7 * 1400 Location A1
 STANDARD EXP. P7 * Location A2
 SPECIAL EXP. FC1 ** Location A1
 SPECIAL EXP. FC1 ** 400 Location A2

Figure 8 - Unexposed Surface Temperatures Of Fire Stop Material (Standard Versus Special Fire Exposure)

UNEXPOSED SURFACE TEMPERATURES

(STANDARD VS SPECIAL FIRE EXPOSURE)




* See Figure B20
 ** See Figure B11

STANDARD EXP. CL1 Location A4 *
 STANDARD EXP. CL1 Location A2 *
 SPECIAL EXP. FC3 Location A4 **
 SPECIAL EXP. FC3 Location A2 **

Figure 9 - Unexposed Surface Temperatures Of Fire Stop Material (Standard Versus Special Fire Exposure)

UNEXPOSED SURFACE TEMPERATURES




* See Figure B12

300 MCM - CU
 EXP. CT1
 Location A1

300 MCM - AL
 EXP. CT3
 Location A1

Figure 10 - Unexposed Surface Temperatures Of Fire Stop Material (Copper Versus Aluminum Conductor)

UNEXPOSED SURFACE TEMPERATURES



* See Figure B13
 ** See Figure B12

3C/12 AVG
 EXP. CS1
 Location A1 *


7C/12 AVG
 EXP. CS2
 Location A1 *

300 MCM
 EXP. CT1 **
 Location A1 **

Figure 11 - Unexposed Surface Temperatures Of Fire Stop Material (conductor Size)

UNEXPOSED SURFACE TEMPERATURES

PIPE SIZE




*See Figure B17

1 IN. PIPE
EXP. PS1
Location A1*

3 IN. PIPE
EXP. PS2
Location A5*

Figure 12 - Unexposed Surface Temperatures Of Fire Stop Material (Pipe Size)

UNEXPOSED SURFACE TEMPERATURES




** See Figure B19
 * See Figure B18

- 1 IN. STEEL EXP. C01 Location A1 *
- 3 IN. STEEL EXP. C02 Location A5 **
- 1 IN. AL EXP. C03 Location A1 *
- 3 IN. AL EXP. C04 Location A5 **

Figure 13 - Unexposed Surface Temperatures Of Fire Stop Material (Steel Versus Aluminum Conduit).

UNEXPOSED SURFACE TEMPERATURES



*See Figure B20

- ONE LAYER
EXP. CL1
Location A4 *
- ONE LAYER
EXP. CL1
Location A2 *
- THREE LAYERS
EXP. CL2
Location A2 *
- THREE LAYERS
EXP. CL2
Location A4 *

Figure 14 - Unexposed Surface Temperatures Of Fire Stop Material (Cable Loading)

APPENDIX A

Sample Details

Floor Slabs - The reinforced concrete floor slabs were 36 in. (915 mm) by 36 in. (915 mm) by 6 in. (150 mm) thick. The slabs were cast with openings as shown in Fig. A1. The concrete consisted of one part Type I portland cement, 2.13 parts sand, and 3.45 parts gravel by bulk volume and mixed with about 7 gal of water per bag of cement. The strength of the concrete, as determined from standard 6 in. (150 mm) by 12 in. (305 mm) cylinders aged 28 days at room temperature, ranged between 3290-3430 psi (22.68-23.65 MPa) and averaged 3350 psi (23.10 MPa). The 28 day unit weight was 146.7 pcf (2.35 Mg/m³).

Silicone Foam And Silicone Elastomer - The materials were two-component silicone systems. The mixing ratio of Parts A and B was 1:1 on a volume basis and in accordance with the manufacturer's installation instructions. The free rise densities were between 27.5-32.0 pcf (0.44-0.51 Mg/m³) for the silicone foam and 86.0-89.0 pcf (1.38-1.43 Mg/m³) for the silicone elastomer.


Fire Stop Device - The devices used consisted of three components. Steel pressure discs, 0.365 in. (9 mm) thick, were located one at the top and one at the bottom. Between the steel discs were two layers of 1 in. (25 mm) thick intumescent material with a 1 in. (25 mm) thick neoprene grommet at the center. The devices were installed by tightening screws until the grommet material squeezed around the cables and the inside of the opening.

Cables - Seven types of cables were used in these experiments. Details of their construction are shown in Table A1.

Cable Trays - The cable tray used was a steel, open-ladder type, nominally 6 in. (150 mm) wide, with 3.375 in. (86 mm) side rails, and a 9 in. (230 mm) spacing between rungs.

Pipe And Conduit - The 1 in. and 3 in. trade size, schedule 40 steel pipe was used. Also 1 in. and 3 in. rigid steel and aluminum conduits were used.

Cable Type	Conductor		Generic Description	Cable Cross Section Diameter, In. (mm)	Insulation/Jacket Material	Approximate Conductor Insulation/Jacket Thickness, In. (mm)	Cable Jacket Material	Approximate Cable Jacket Thickness, In. (mm)
	No./Size	Type						
G	7/12AWG	Cu	EPR-Hypalon/Hypalon	0.785 (19.9)	Ethylene propylene rubber/chloro-sulphonated polyethylene	0.028/0.017 (0.71/0.43)	Chlorosulphonated polyethylene	0.134 (3.4)
H	7/12AWG	Cu	XLPO/XLPO	0.493 (12.5)	Crosslinked polyolefin	0.030/- (0.76/-)	Crosslinked polyolefin	0.054 (1.4)
F	7/12AWG	Cu	PE-PVC/PVC	0.602 (15.3)	Polyethylene/ Polyvinyl chloride	0.029/0.012 (0.74/0.31)	Polyvinyl chloride	0.062 (1.6)
A	7/12AWG	Cu	PVC-NYLON/PVC	0.515 (13.1)	Polyvinyl chloride/ nylon	0.022/0.006 (0.56/0.15)	Polyvinyl chloride	0.050 (1.3)
B	3/12AWG	Cu	PE-PVC/PVC	0.445 (11.3)	Polyethylene/ Polyvinyl chloride	0.039/0.012 (0.99/0.30)	Polyvinyl Chloride	0.056 (1.42)
C	300MCM	Cu	PVC	0.821 (20.8)	Polyvinyl chloride	0.149 (3.78)	_____	_____
E	300MCM	AL	PVC	0.832 (21.1)	Polyvinyl chloride	0.140 (3.56)	_____	_____



ALL SLABS - NOMINAL 36 x 36 x 6 IN. THICK

Figure A1 - Floor Slabs

APPENDIX B


Instrumentation

Unexposed Surface Temperatures - Temperatures on the unexposed surface of the fire stop were measured with No. 28 gauge Chromel Alumel thermocouples. The thermocouple bead was held against the surface and covered with a 0.75 by 0.75 by 0.156 in. (19 by 19 by 4 mm) asbestos pad. Locations of these thermocouples are shown in Figs. B1 - B21.

Fire Stop Material Temperatures - Temperatures within the silicone elastomer in experiments P1, P3 and P5 were measured with No. 28 gauge Chromel Alumel thermocouples with a 0.062 in. (1.6 mm) diameter inconel shield. Temperatures between layers of the device in experiments P14 and P16 were measured with unshielded No. 28 gauge Chromel Alumel thermocouples. The locations of these thermocouples are shown in Fig. B22.


Furnace Temperatures - Furnace temperatures were measured with three shielded thermocouples of the type specified in ASTM E119. The thermocouples were located 12 in. (305 mm) from the exposed surface and symmetrically distributed within the furnace chamber.

Pressure Differential - The pressure differential at the exposed surface with respect to the unexposed surface was measured with probes connected to a manometer or electronic barometer. The probes were located as shown in Fig. B23.




<u>T.C.</u>	<u>Location</u>
A1	In contact with cable jacket and silicone foam
A2	1/2 in. from cable
A3	3/4 in. from cable
B1	1 in. from periphery of silicone foam
C1	Center of silicone foam

Group 1 Thermocouple Locations
Fig. B1




<u>T.C.</u>	<u>Location</u>
B1	At periphery of silicone foam
B2	1/2 in. from periphery of silicone foam
C1	Center of silicone foam
C2	1-1/2 in. from periphery of silicone foam

Group 2 Thermocouple Locations
Fig. B2




<u>T.C.</u>	<u>Location</u>
A1	In contact with cable jacket and silicone foam
A2	1/2 in. from cable
A3	3/4 in. from cable
B1	1 in. from periphery of silicone foam
C1	Center of silicone foam

Group 3 Thermocouple Location
Fig. B3




<u>T.C.</u>	<u>Location</u>
B1	At periphery of silicone foam
B2	1/2 in. from periphery of silicone foam
C1	Center of silicone foam
C2	1-1/2 in. from periphery of silicone foam

Group 4 Thermocouple Locations
Fig. B4



<u>T.C.</u>	<u>Location</u>
A1	1/2 in. from cable
A2	3/4 in. from cable
B1	1/2 in. from periphery of device
C1	Center of device

Group 5 Thermocouple Locations
Fig. B5




T.C.

Location

B1	1/2 in. from periphery of device
C1	1-1/2 in. from periphery of device
C2	1-1/2 in. from periphery of device
C3	1-1/2 in. from periphery of device
C4	Center of device

Group 6 Thermocouple Locations
Fig. B6




T.C.

Location

A1	1/2 in. from cable
A2	3/4 in. from cable
B1	At periphery of silicone foam
B2	1/2 in. from periphery of silicone foam
C1	3 in. from periphery of silicone foam
C2	3 in. from periphery of silicone foam

Group 7 Thermocouple Locations
Fig. B7




T.C.

Location

A1	In contact with cable jacket and silicone foam
A2	In contact with cable jacket and silicone foam
A3	1/2 in. from cable
A4	3/4 in. from cable
B1	At periphery of silicone foam
B2	1/2 in. from periphery of silicone foam
B3	At periphery of crack in foam
B4	2-5/8 in. from centerline, 3/16 in. from periphery
B5	On centerline, 3/16 in. from periphery
B6	2-5/8 in. from centerline, 3/16 in. from periphery
C1	3 in. from periphery of silicone foam
C2	3 in. from periphery of silicone foam

Group 8 Thermocouple Locations

Fig. B8




T.C.

Locations


A1	In contact with cable jacket and silicone elastomer
A2	Over center hole in silicone elastomer
A3	Over center hole in silicone elastomer
A4	1 in. from cable
A5	Center of hole in silicone elastomer
A6	Center of hole in silicone elastomer
A7	Unexposed surface in contact with tray and silicone elastomer
A8	1 in. from tray
A9	1 in. from tray
A10	In contact with cable jacket, cable tray and silicone elastomer
B1	At periphery of silicone elastomer
B2	At periphery of silicone elastomer
C1	1-1/2 in. from tray
C2	1-1/2 in. from periphery of hole
C3	2-1/4 in. from periphery of hole

Group 9 Thermocouple Locations
Fig. B9




<u>T.C.</u>	<u>Location</u>
A1	1/2 in. from cable
A2	3/4 in. from cable
B1	At periphery of silicone foam
B2	1/2 in. from periphery of silicone foam
C1	3 in. from periphery of silicone foam
C2	3 in. from periphery of silicone foam

Group 10 Thermocouple Locations
Fig. B10




T.C.	Location
A1	In contact with cable tray, cable jacket and silicone elastomer
A2	In contact with cable jacket and silicone elastomer
A3	Center cable in contact with cable jacket
A4	In contact with cable jacket and silicone elastomer
A5	3 in. from edge of tray, 3-3/8 in. from back of tray
A6	1-1/2 in. from tray
A7	1 in. from edge of tray, 1-1/2 in. from front of tray
A8	1 in. from tray
A9	1 in. from tray
B1	In contact with silicone elastomer and concrete
B2	At periphery in contact with concrete and silicone elastomer
C1	2-1/4 in. from periphery of hole
C2	1-1/2 in. from periphery of hole

Group 11 Thermocouple Locations
Fig. B11




<u>T.C.</u>	<u>Location</u>
A1	1/16 in. from cable jacket
A2	1/16 in. from cable jacket
A3	1/2 in. from cable jacket
A4	1/2 in. from cable jacket
B1	1/4 in. from periphery of hole

Group 12 Thermocouple Locations
Fig. B12




<u>T.C.</u>	<u>Location</u>
A1	1/16 in. from cable jacket
A2	1/16 in. from cable jacket
A3	1/2 in. from cable jacket
A4	1/2 in. from cable jacket
B1	1/4 in. from periphery of hole

Group 13 Thermocouple Locations
Fig. B13




<u>T.C.</u>	<u>Location</u>
A1	1/16 in. from cable jacket
A2	1/16 in. from cable jacket
A3	1/2 in. from cable jacket
A4	1/2 in. from cable jacket
B1	1/4 in. from periphery of hole

Group 14 Thermocouple Locations
Fig. B14




<u>T.C.</u>	<u>Location</u>
A1	1/16 in. from cable jacket
A2	1/16 in. from cable jacket
A3	1/2 in. from cable jacket
A4	1/2 in. from cable jacket
A5	1/4 in. from cable jacket
A6	1/2 in. from cable jacket
B1	1/4 in. from periphery of hole
B2	At periphery in contact with concrete and silicone elastomer
B3	1/2 in. from periphery of hole
C1	1-1/2 in. from cable jacket

Group 15 Thermocouple Locations
Fig. B15




<u>T.C.</u>	<u>Location</u>
A1	1/16 in. from cable jacket
A2	1/16 in. from cable jacket
A3	1/2 in. from cable jacket
A4	1/2 in. from cable jacket
B1	1/4 in. from periphery of hole

Group 16 Thermocouple Locations
Fig. B16



T.C.	Location
A1	In contact with pipe and silicone elastomer
A2	2-1/2 in. from periphery, 1/2 in. from center pipe
A3	2-1/2 in. from periphery, 1/2 in. from pipe
A4	1/2 in. from pipe, 3-1/2 in. from periphery
A5	In contact with 3 in. pipe and silicone
A6	3-1/2 in. from periphery
A7	1/2 in. from center of 3 in. pipe
B1	At periphery in contact with concrete and silicone elastomer
C1	5 in. from periphery

Group 17 Thermocouple Locations
Fig. B17




T.C.

Location

A1	In contact with pipe and silicone elastomer
A2	2-1/1 in. from periphery of hole, 1/2 in. from pipe
A3	2-1/2 in. from periphery of hole, 1/2 in. from pipe
B1	At periphery in contact with concrete and silicone elastomer
C1	5 in. from periphery of hole

Group 18 Thermocouple Locations
Fig. B18





T.C.

Location


A4	1/2 in. from pipe, 3-1/2 in. from periphery
A5	In. contact with silicone elastomer and 3 in. pipe
A6	3-1/2 in. from periphery
A7	1/2 in. from center of 3 in. pipe

Group 19 Thermocouple Locations
Fig. B19






T.C.	Location
A1	Corner of cable tray in contact with cable tray, cable jacket and silicone elastomer
A2	Center of cable in contact with cable jacket and silicone elastomer
A3	In contact with center cable and silicone elastomer
A4	Center cable in contact with cable jacket and silicone elastomer
A5	4-5/16 in. from periphery of hole
A6	1-1/4 in. from back of tray, in contact with tray and silicone elastomer
A7	1 in. from tray
A8	1 in. from tray
A9	1 in. from tray
A10	Center cable in contact with cable jacket and silicone elastomer
A11	1 in. from tray
B1	At periphery in contact with concrete and silicone elastomer
B2	At periphery in contact with concrete and silicone elastomer
C1	1-1/2 in. from periphery of hole
C2	2-1/4 in. from periphery of hole

Group 20 Thermocouple Locations
Fig. B20




<u>T.C.</u>	<u>Location</u>
B1	At periphery in contact with concrete and silicone foam
B2	At periphery in contact with concrete and silicone foam
B3	At periphery in contact with concrete and silicone foam
B4	At periphery in contact with concrete and silicone foam
C1	Center of 2 in. diameter hole
C2	Center of 6 in. diameter hole
C3	1-1/2 in. from periphery of hole
C4	Center of 9 in. diameter hole
C5	2-1/4 in. from periphery of hole
C6	2-1/4 in. from periphery of hole
C7	Center of 12 in. diameter hole
C8	3-1/4 in. from periphery of hole
C9	3-1/4 in. from periphery of hole

Group 21 Thermocouple Locations
Fig. B21




SECTION A-A



SECTION B-B

• THERMOCOUPLE LOCATION

Figure B22 - Location Of Thermocouples Within Fire Stop



Pressure Probe Location
Fig. B23

APPENDIX C

Experimental Results

Unexposed Surface Temperatures - The recorded temperature of each thermocouple was plotted versus time for each experiment. These graphs are shown in Figs. C1-C65.

Experiment Duration And Flaming Times - The experiment duration and time at which flaming occurred on the unexposed side are shown in Tables C1-C3.

Table C1

Duration And Time To Flaming
For Pressure Differential Experiments

<u>Experiment</u>	<u>Duration (Min.)</u>	<u>Time To Flaming (Min.)</u>
P22	215	NR
P19	88	86
P1	117	116
P3	112	110
P5	113	112
P23	215	208
P20	88	NR
P2	117	NR
P4	112	NR
P6	113	NR
P9, P10	270	NR
P11, P12	245	NR
P13, P14, P15, P16	185	NR
P7	155	153
P8	156	154
P21	106	104
P17	125	*
P18	125	NR

* - Smoke, rich in unburned fuel, which issued through hole was ignited by match several times during the experiment

NR - Flaming did not occur during experiment

Table C2

Duration And Time To Flaming
For Fire Exposure Experiments

<u>Experiment</u>	<u>Duration (Min.)</u>	<u>Time To Flaming (Min.)</u>
FC1	180	177
FC2	212	211
FC3	270	NR

NR - Flaming did not occur during experiment

Table C3


Duration And Time To Flaming
For Sample Experiments

<u>Experiment</u>	<u>Duration (Min.)</u>	<u>Time To Flaming (Min.)</u>
CT1, CT2	245	NR
CT3, CT4	245	NR
CS1, CS2	245	NR
CS3, CS4	245	NR
T1, T1, T3, T4	245	NR
PS1, PS2	270	NR
CD1, CD1	270	NR
CD3, CD4	170	NR
CL1, CL2	270	NR
S1	120	NR
S2	120	119
S3	132	131
S4	125	124

NR - Flaming did not occur during experiment

UNEXPOSED SURFACE FIRE STOP TEMPERATURES

EXPERIMENT P22



* See Figure B1





Figure C1 - Unexposed Surface Temperatures Of Fire Stop Material

UNEXPOSED SURFACE FIRE STOP TEMPERATURES

EXPERIMENT P19



* See Figure B1

LOCATION A1 *

LOCATION A2 *

LOCATION A3 *


LOCATION C1 *

LOCATION B1 *

Figure C2 - Unexposed Surface Temperatures Of Fire Stop Material

UNEXPOSED SURFACE FIRE STOP TEMPERATURES

EXPERIMENT P1




* See Figure B1

LOCATION *
 A1 *
 LOCATION *
 A2 *
 LOCATION *
 A3 *
 LOCATION *
 C1 *
 LOCATION *
 B1 *

Figure C3 - Unexposed Surface Temperatures of Fire Stop Material

UNEXPOSED SURFACE FIRE STOP TEMPERATURES

EXPERIMENT P3



* See Figure B1

LOCATION A1 *

LOCATION A2 *

LOCATION A3 *


LOCATION C1 *

LOCATION B1 *

Figure C4 - Unexposed Surface Temperatures Of Fire Stop Material

UNEXPOSED SURFACE FIRE STOP TEMPERATURES

EXPERIMENT P5



* See Figure B1

LOCATION
A1 *

LOCATION
A2 *

LOCATION
A3 *


LOCATION
C1 *

LOCATION
B1 *

Figure C5 - Unexposed Surface Temperatures Of Fire Stop Material

UNEXPOSED SURFACE FIRE STOP TEMPERATURES

EXPERIMENT P23



* See Figure B2

LOCATION C1 *

LOCATION Ca *


LOCATION B2 *

LOCATION B1 *

Figure C6 - Unexposed Surface Temperatures Of Unexposed Surface

UNEXPOSED SURFACE FIRE STOP TEMPERATURES

EXPERIMENT P20



* See Figure B2





Figure C7 - Unexposed Surface Temperatures Of Fire Stop Material

UNEXPOSED SURFACE FIRE STOP TEMPERATURES

EXPERIMENT P2



* See Figure B2

LOCATION C1 *

—

LOCATION C2 *

- - -

LOCATION e2 *

· · ·


LOCATION B1 *

· · ·

Figure C8 - Unexposed Surface Temperatures Of Fire Stop Material

UNEXPOSED SURFACE FIRE STOP TEMPERATURES

EXPERIMENT P4



* See Figure B2

LOCATION C1 *

LOCATION C2 *


LOCATION B2 *

LOCATION B1 *

Figure C9 - Unexposed Surface Temperatures Of Fire Stop Material

UNEXPOSED SURFACE FIRE STOP TEMPERATURES

EXPERIMENT P6



* See Figure B2

LOCATION C1 *

LOCATION C2 *


LOCATION B2 *

LOCATION B1 *

Figure C10 - Unexposed Surface Temperatures Of Fire Stop Material

UNEXPOSED SURFACE FIRE STOP TEMPERATURES

EXPERIMENT P9



* See Figure B3





Figure C11 - Unexposed Surface Temperatures Of Fire Stop Material

UNEXPOSED SURFACE FIRE STOP TEMPERATURES

EXPERIMENT P11



* See Figure B3

LOCATION
A1 *

LOCATION
A2 *

LOCATION
A3 *


LOCATION
C1 *

LOCATION
B1 *

Figure C11 - Unexposed Surface Temperatures of Fire Stop Material

UNEXPOSED SURFACE FIRE STOP TEMPERATURES

EXPERIMENT P10



* See Figure B4

LOCATION *
C1

LOCATION *
C2


LOCATION *
B2

LOCATION *
B1

Figure C13 - Unexposed Surface Temperatures Of Fire Stop Material.

UNEXPOSED SURFACE FIRE STOP TEMPERATURES

EXPERIMENT P12



* See Figure B4

LOCATION *
C1

LOCATION *
C2


LOCATION *
B2

LOCATION *
B1

Figure C14 - Unexposed Surface Temperatures Of Fire Stop Material

UNEXPOSED SURFACE FIRE STOP TEMPERATURES

EXPERIMENT P13



* See Figure B5





Figure C15 - Unexposed Surface Temperatures of Fire Stop Material

UNEXPOSED SURFACE FIRE STOP TEMPERATURES

EXPERIMENT P15



* See Figure B5

LOCATION A1 *

LOCATION A2 *


LOCATION C1 *

LOCATION B1 *

Figure C16 - Unexposed Surface Temperatures of Fire Stop Material

UNEXPOSED SURFACE FIRE STOP TEMPERATURES

EXPERIMENT P14



* See Figure B6





Figure C17 - Unexposed Surface Temperatures of Fire Stop Material

UNEXPOSED SURFACE FIRE STOP TEMPERATURES

EXPERIMENT P16



* See Figure B6

LOCATION C4 *

LOCATION C1 *

LOCATION C2 *


LOCATION C3 *

LOCATION B1 *

Figure C18 - Unexposed Surface Temperatures of Fire Stop Material

UNEXPOSED SURFACE FIRE STOP TEMPERATURES

EXPERIMENT P7



* See Figure B7

LOCATION A1

LOCATION A2

LOCATION B2


LOCATION B1

LOCATION C2

Figure C19 - Unexposed Surface Temperatures of Fire Stop Material

UNEXPOSED SURFACE FIRE STOP TEMPERATURES

EXPERIMENT P8



* See Figure B7

LOCATION *
A1

LOCATION *
A2

LOCATION *
B2


LOCATION *
e1

LOCATION *
C1

Figure C20 - Unexposed Surface Temperatures of Fire Stop Material

UNEXPOSED SURFACE FIRE STOP TEMPERATURES

EXPERIMENT P21



* See Figure B8

LOCATION B3 *

LOCATION B4 *


LOCATION B5 *

LOCATION B6 *

Figure C21 - Unexposed Surface Temperatures of Fire Stop Material

UNEXPOSED SURFACE FIRE STOP TEMPERATURES

EXPERIMENT P21



* See Figure B8

LOCATION A1 *

LOCATION A2 *


LOCATION B2 *

LOCATION E1 *

Figure C22 - Unexposed Surface Temperatures of Fire Stop Material

UNEXPOSED SURFACE FIRE STOP TEMPERATURES

EXPERIMENT P21



* See Figure B8

LOCATION *
A3

LOCATION *
A4


LOCATION *
C1

LOCATION *
C2

Figure C23 - Unexposed Surface Temperatures of Fire Stop Material

UNEXPOSED SURFACE FIRE STOP TEMPERATURES

EXPERIMENT P17



* See Figure B9

LOCATION C2 *

LOCATION B2 *

LOCATION B4 *


LOCATION A9 *

LOCATION C3 *

Figure C24 - Unexposed Surface Temperatures of Fire Stop Material

UNEXPOSED SURFACE FIRE STOP TEMPERATURES

EXPERIMENT P17



* See Figure B9





Figure C25 - Unexposed Surface Temperatures of Fire Stop Material

UNEXPOSED SURFACE FIRE STOP TEMPERATURES

EXPERIMENT P17



* See Figure B9

LOCATION *
C1

LOCATION *
A2

LOCATION *
A3


LOCATION *
A5

LOCATION *
A6

Figure C26 - Unexposed Surface Temperatures of Fire Stop Material

UNEXPOSED SURFACE FIRE STOP TEMPERATURES

EXPERIMENT P18



* See Figure B9

LOCATION C2 *

LOCATION B2 *

LOCATION B1 *


LOCATION A9 *

LOCATION C3 *

Figure C27 - Unexposed Surface Temperatures of Fire Stop Material

UNEXPOSED SURFACE FIRE STOP TEMPERATURES

EXPERIMENT P18




* See Figure B9

LOCATION A0*
 LOCATION A1*
 LOCATION A6*
 LOCATION A4*
 LOCATION A7*

Figure C28 - Unexposed Surface Temperatures of Fire Stop Material

UNEXPOSED SURFACE FIRE STOP TEMPERATURES

EXPERIMENT P18



* See Figure B9

LOCATION *
C1

LOCATION *
A2

LOCATION *
A3


LOCATION *
A5

LOCATION *
A6

Figure C29 - Unexposed Surface Temperatures of Fire Stop Material

UNEXPOSED SURFACE FIRE STOP TEMPERATURES

EXPERIMENT FC1



* See Figure B10


LOCATION
B2 *

LOCATION
C1 *

LOCATION
C2 *

Figure C30 - Unexposed Surface Temperatures of Fire Stop Material

UNEXPOSED SURFACE FIRE STOP TEMPERATURES



* See Figure B10





Figure C31 - Unexposed Surface Temperatures of Fire Stop Material

UNEXPOSED SURFACE FIRE STOP TEMPERATURES

EXPERIMENT FC2



* See Figure B10

LOCATION A1 *


LOCATION A2 *

LOCATION B1 *

Figure C32 - Unexposed Surface Temperatures of Fire Stop Material

UNEXPOSED SURFACE FIRE STOP TEMPERATURES

EXPERIMENT FC2



* See Figure B10





Figure C33 - Unexposed Surface Temperatures of Fire Stop Material

UNEXPOSED SURFACE FIRE STOP TEMPERATURES

EXPERIMENT FC3




* See Figure B11

LOCATION
A3 *

Figure C35 - Unexposed Surface Temperatures of Fire Stop Material

UNEXPOSED SURFACE FIRE STOP TEMPERATURES

EXPERIMENT FC3



* See Figure B11

LOCATION A3 *

LOCATION A1 *

LOCATION A4 *


LOCATION A6 *

LOCATION A8 *

Figure C36 - Unexposed Surface Temperatures of Fire Stop Material

UNEXPOSED SURFACE FIRE STOP TEMPERATURES

EXPERIMENT FC3



* See Figure B11

LOCATION A1 *

LOCATION A2 *


LOCATION A5 *

LOCATION A7 *

C37 - Unexposed Surface Temperatures of Fire Stop Material

UNEXPOSED FIRE STOP SURFACE TEMPERATURES

EXPERIMENT CT1



* See Figure B12





Figure C38 - Unexposed Surface Temperatures of Fire Stop Material

UNEXPOSED FIRE STOP SURFACE TEMPERATURES

EXPERIMENT CT2



* See Figure B12

LOCATION A3 *

LOCATION A4 *

LOCATION A1 *


LOCATION A2 *

LOCATION B1 *

Figure C39 - Unexposed Surface Temperatures of Fire Stop Material

UNEXPOSED FIRE STOP SURFACE TEMPERATURES

EXPERIMENT CT3



* See Figure B12

LOCATION A3 *

LOCATION A4 *

LOCATION A1 *


LOCATION A2 *

LOCATION B1 *

Figure C40 - Unexposed Surface Temperatures of Fire Stop Material

UNEXPOSED FIRE STOP SURFACE TEMPERATURES

EXPERIMENT CT4



* See Figure B12

LOCATION A3 *

LOCATION A4 *

LOCATION A1 *


LOCATION A2 *

LOCATION B1 *

Figure C31 - Unexposed Surface Temperatures of Fire Stop Material

UNEXPOSED FIRE STOP SURFACE TEMPERATURES

EXPERIMENT CS1



* See Figure B13

LOCATION A3 *

LOCATION A4 *

LOCATION A1 *


LOCATION A2 *

LOCATION B1 *

Figure C42 - Unexposed Surface Temperatures of Fire Stop Material

UNEXPOSED FIRE STOP SURFACE TEMPERATURES

EXPERIMENT CS2



* See Figure B13





Figure C43 - Unexposed Surface Temperatures of Fire Stop Material

UNEXPOSED FIRE STOP SURFACE TEMPERATURES

EXPERIMENT CS3



* See Figure B14

LOCATION A3 *

LOCATION A4 *

LOCATION A1 *


LOCATION A2 *

LOCATION B1 *

C44 - Unexposed Surface Temperatures of Fire Stop Material

UNEXPOSED FIRE STOP SURFACE TEMPERATURES

EXPERIMENT CS4



* See Figure B14

LOCATION A3 *

LOCATION A4 *

LOCATION A1 *


LOCATION A2 *

LOCATION B1 *

Figure C45 - Unexposed Surface Temperatures Of Fire Stop Material

UNEXPOSED FIRE STOP SURFACE TEMPERATURES

EXPERIMENT T1



* See Figure B15

LOCATION A3 *

LOCATION A4 *

LOCATION A1 *


LOCATION A2 *

LOCATION B1 *

Figure C46 ← Unexposed Surface Temperatures of Fire Stop Material

UNEXPOSED FIRE STOP SURFACE TEMPERATURES

EXPERIMENT T2



* See Figure B15

LOCATION
A6 *

LOCATION
A5 *

LOCATION
C1 *


LOCATION
B3 *

LOCATION
B2 *

Figure C47 - Unexposed Surface Temperatures of Fire Stop Material

UNEXPOSED FIRE STOP SURFACE TEMPERATURES

EXPERIMENT T3



* See Figure B15

LOCATION A6 *

LOCATION A5 *

LOCATION C1 *


LOCATION B3 *

LOCATION B2 *

Figure C48 - Unexposed Surface Temperatures of Fire Stop Material

UNEXPOSED FIRE STOP SURFACE TEMPERATURES

EXPERIMENT T4



* See Figure B16

LOCATION A3 *

LOCATION A4 *


LOCATION A1 *

LOCATION A2 *

LOCATION B1 *

Figure C49 - Unexposed Surface Temperatures of Fire Stop Material

UNEXPOSED FIRE STOP SURFACE TEMPERATURES




* See Figure B17

- LOCATION A1 * ———
- LOCATION A2 * - - -
- LOCATION A3 * ·····
- LOCATION C1 * - - -
- LOCATION B1 * - - -

Figure C50 - Unexposed Surface Temperatures of Fire Stop Material

UNEXPOSED FIRE STOP SURFACE TEMPERATURES

EXPERIMENT PS2



* See Figure B17

LOCATION *
A5


LOCATION *
A7

LOCATION *
A4

LOCATION *
A6

Figure C51 - Unexposed Surface Temperatures of Fire Stop Material

UNEXPOSED FIRE STOP SURFACE TEMPERATURES



* See Figure B18





Figure C52 - Unexposed Surface Temperatures of Fire Stop Material

UNEXPOSED FIRE STOP SURFACE TEMPERATURES

EXPERIMENT 002



* See Figure B18





Figure C53 - Unexposed Surface Temperatures of Fire Stop Material

UNEXPOSED FIRE STOP SURFACE TEMPERATURES

EXPERIMENT C03



* See Figure B19

LOCATION A5 *

LOCATION A7 *


LOCATION A4 *

LOCATION A6 *

Figure C54 - Unexposed Surface Temperatures of Fire Stop Material

UNEXPOSED FIRE STOP SURFACE TEMPERATURES

EXPERIMENT C04



* See Figure B19

LOCATION
A5 *


LOCATION
A7 *

LOCATION
A4 *

LOCATION
A6 *

Figure C55 - Unexposed Surface Temperatures of Fire Stop Material

UNEXPOSED FIRE STOP SURFACE TEMPERATURES



* See Figure B20

LOCATION A3 *

LOCATION A8 *


LOCATION A1 *

LOCATION A6 *

Figure C56 - Unexposed Surface Temperatures of Fire Stop Material

UNEXPOSED FIRE STOP SURFACE TEMPERATURES

EXPERIMENT CL1



* See Figure B20





Figure C57 - Unexposed Surface Temperatures of Fire Stop Material

UNEXPOSED FIRE STOP SURFACE TEMPERATURES

EXPERIMENT C.1



* See Figure B20

LOCATION A4 *

LOCATION A2 *


LOCATION A5 *

LOCATION A7 *

Figure C58 - Unexposed Surface Temperatures of Fire Stop Material

UNEXPOSED FIRE STOP SURFACE TEMPERATURES

EXPERIMENT 012



* See Figure B20

LOCATION C1 *

LOCATION B1 *

LOCATION B2 *


LOCATION A9 *

LOCATION C2 *

Figure C59 - Unexposed Surface Temperatures of Fire Stop Material

UNEXPOSED FIRE STOP SURFACE TEMPERATURES

EXPERIMENT CL2



* See Figure B20

LOCATION A1 *

LOCATION A2 *


LOCATION A4 *

LOCATION A11 *

Figure C60 - Unexposed Surface Temperatures of Fire Stop Material

UNEXPOSED FIRE STOP SURFACE TEMPERATURES

EXPERIMENT C12



* See Figure B20





Figure C61 - Unexposed Surface Temperatures of Fire Stop Material

UNEXPOSED FIRE STOP SURFACE TEMPERATURES

EXPERIMENT S1



* See Figure B21





Figure C62 - Unexposed Surface Temperatures of Fire Stop Material

UNEXPOSED FIRE STOP SURFACE TEMPERATURES

EXPERIMENT S2



* See Figure B21

LOCATION C2 *


LOCATION C3 *

LOCATION B2 *

Figure C63 - Unexposed Surface Temperatures Of Fire Stop Material

UNEXPOSED FIRE STOP SURFACE TEMPERATURES

EXPERIMENT S3



* See Figure B21

LOCATION *
C4

LOCATION *
C5


LOCATION *
C6

LOCATION *
B3

Figure C64 - Unexposed Surface Temperatures of Fire Stop Material

UNEXPOSED FIRE STOP SURFACE TEMPERATURES

EXPERIMENT S4



* See Figure B21

LOCATION C7 *

LOCATION C8 *

LOCATION C9 *

LOCATION B4 *

Figure C65 - Unexposed Surface Temperatures of Fire Stop Material

DISTRIBUTION:

U.S. Nuclear Regulatory Commission
Distribution Contractor (CDSI)
7300 Pearl Street
Bethesda, MD 20014

344 copies for RP
25 copies for NTIS

Author selected distribution - 14 copies
(List available from author)

3652 V. L. Duke
4400 A. W. Snyder
4440 G. R. Otey
4442 W. A. Von Rieseemann
4442 L. J. Klamerus
4442 D. A. Dube
4442 L. D. Lambert
4442 W. H. Schmidt
4443 D. A. Dahlgren
8144 M. A. Pound
3141 L. J. Erickson (5)
3151 W. L. Garner (3)
DOE-TIC Unlimited Release