

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE -- PNO-I-07-006

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by the Region I staff on this date.

Facility

Amergen Energy Company, LLC
Oyster Creek
Forked River, NJ
Docket: 50-219

Licensee Emergency Classification

Notification of Unusual Event
 Alert
 Site Area Emergency
 General Emergency
 Not Applicable

SUBJECT: REACTOR SCRAM ON LOW REACTOR VESSEL WATER LEVEL DUE TO A TRIP OF THE 'C' REACTOR FEED PUMP

On July 17, 2007, at 5:22 a.m., the Oyster Creek reactor scrammed due to a low reactor water level following a trip of the 'C' Reactor Feed Pump (RFP). Reactor water level reached the low level setpoint which, among other actions, automatically isolated the main steam isolation valves and initiated the isolation condensers. The isolation condensers steam off plant condensate to remove decay heat. Although there was no abnormal amount of radioactivity released during the event, a small amount of activity was released by steaming off condensate that contained trace amounts of radioactive tritium. The preliminary estimates of the activity released was about 1.05 curies which resulted in a worst case offsite dose of about 0.005 millirem which is about 3000 times less than the annual organ limit of 15 millirem and 25 millirem total body.

Immediately prior the scram, reactor water level had decreased due to a steam flow/feed flow mismatch. After the scram, water level increased due to excessive feeding causing a high reactor water level which necessitated cycling two Electromagnetic Relief Valves (EMRVs). The steam relief from the EMRVs caused an increase in the torus temperature that was controlled by using the Containment Spray System in torus cooling mode. No emergency action level was declared as a result of this event. The reactor was placed in a cold shutdown condition at 2:00 p.m., July 17, 2007.

Preliminary information indicates that the 'C' RFP tripped due to an electrical fault. Planned licensee actions include a review to determine the cause of the 'C' RFP trip, repairs to the 'C' RFP, and a review of plant and operator response during the event.

The NRC resident inspector responded to the site and has been supported by regional inspectors during the NRC's initial assessment of this event. The NRC is continuing to assess the licensee's response to this event. The facts of this Preliminary Notification were verified with the Oyster Creek Plant Manager and were current as of 4:00 p.m., July 17, 2007.

AmerGen has issued an event notification (EN #43495) in accordance to 10 CFR 50.72 and has issued press releases. The state of New Jersey has been notified.

This PN will be updated as close to plant restart as possible.
ADAMS Accession Number: ML071990428

CONTACT: G. Scott Barber
(610) 337-5232

DISTRIBUTIONS:

BY E-MAIL:

OWFN

Chairman Klein
 Comm. McGaffigan Jr.
 Comm. Jaczko
 Comm. Lyons

TWFN

NMSS
 OIG
 RES

OIP
 OCA
 OGC
 EDO
 OE
 NRR
 SECY
 Regional Offices

BY FAX:

DOT:Trans

INPO

NSAC

RI Resident Office

Licensee: AmerGen Energy Company, LLC
Oyster Creek Nuclear Generating Station

ADAMS ML071990428

SUNSI Review Complete: GSB (Reviewer's Initials)

DOCUMENT NAME: T:\DRP\PNs\PNO-I-07-006 Oyster Creek scam due to a loss of C RFP
 Rev 2.wpd

After declaring this document "An Official Agency Record" it **will** be released to the Public.

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure
 "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	RI/DRP		RI/ORA		RI/ORA		RI/DRP	
NAME	SBarber/GSB		DScrenci/DPS		MMcLaughlin/MM		DLew/DCL	
DATE	07/17/07		07/17 /07		07/17/07		07/18 /07	

OFFICIAL RECORD COPY