

Date: April 7, 2008

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE – PNO-I-08-004

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by the Region I, King of Prussia, PA, staff on this date.

Facility	License Emergency Classification
Dominion Resources	<input checked="" type="checkbox"/> Notification of Unusual Event
Millstone Power Station, Unit 2	<input type="checkbox"/> Alert
Niantic, CT 06357	<input type="checkbox"/> Site Area Emergency
Docket: 050-336	<input type="checkbox"/> General Emergency
License: DPR-65	<input type="checkbox"/> Not Applicable

SUBJECT: NOTIFICATION OF UNUSUAL EVENT DUE TO INCREASE IN UNIDENTIFIED LEAKAGE FOLLOWING SHUTDOWN FOR A REFUELING OUTAGE

DESCRIPTION:

On April 6, 2008, at 1:17 p.m., Millstone Unit 2 declared an Unusual Event due to an unexpected increase in reactor coolant system (RCS) unidentified leakage rate. At the time, Millstone Unit 2 was shut down for a scheduled refueling outage and proceeding to the shutdown cooling mode of operation. At 12:36 p.m., on April 6, the RCS unidentified leakrate increased concurrent with an unexpected increase in refueling water storage tank (RWST) level.

Region I entered the Monitoring Mode at 2:30 p.m. Resident inspectors reported to the site to monitor the event. At 1:56 p.m., the unidentified leak rate returned to normal, following licensee actions to identify and close valves in the leakage path from the RCS to the RWST.

While no radioactive liquids were released from the site, some low-level radioactive gas was likely released through the RWST vent. The NRC independently evaluated the potential release and radiological consequence. Preliminary estimates indicate that any release was well below regulatory limits for normal operations.

Millstone Unit 3, another reactor operated by Dominion, was not affected by the event and continues to operate at 100-percent power.

The Unusual Event was terminated at 6:56 p.m., after verification that the RCS leak was stopped. The plant is in the process of cooling down. Region I exited the Monitoring Mode at 7:20 p.m. The NRC will continue to follow the licensee's activities and the conditions that lead to the event.

Federal and state officials have been notified of the event. NRC Region I Public Affairs is prepared to respond to media inquiries. This notification was reviewed with the

Operations Manager on-call, at 8:15 p.m. on April 6, and represents available information as of that time.

It is not expected that this PN will be updated.

ADAMS Accession Number: ML080980197

CONTACT: Barry Norris
(610) 337-5111
BSN@nrc.gov

DISTRIBUTION: (PN Recipient List)

<u>OWFN</u>	<u>TWFN</u>
Chairman Klein	
Comm. Lyons	NMSS
Comm. Jaczko	ACRS
Comm. Svinicki	
OIP	NSIR
OCA	OIG
OGC	
EDO	
OE	
NRR	
SECY	
Regional Offices	

BY FAX:

Dot: Trans
INPO
NSAC
RI Resident Office
Licensee: Dominion Resources
Millstone Power Plant

ML080980197

SUNSI Review Complete: BSN (Reviewer's Initials)

DOCUMENT NAME: T:\DRP\PNs\PN108004.doc

After declaring this document "An Official Agency Record" it will be released to the Public.

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	RI/DRP	RI/ORA	RI/ORA	RI/ORA	RI/DRP
NAME	BNorris/BSN	RBarkley/RSB	NMcNamara/NTM	DScrenci/DPS	DLew/DCL
DATE	04/07/08	04/07/08	04/07/08	04/07/08	04/07/08

OFFICIAL RECORD COPY