

Mark B. Bezilla
Vice President

440-280-5382
Fax: 440-280-8029

April 29, 2008
L-08-162

10CFR50.36a(a)(2)

ATTN: Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, DC 20555-0001

SUBJECT:
Perry Nuclear Power Plant
Docket No. 50-440
Annual Environmental and Effluent Release Report

Enclosed is the Annual Environmental and Effluent Release Report for the Perry Nuclear Power Plant (PNPP) for the period of January 1, 2007 through December 31, 2007. This document includes the radiological environmental operating report, radioactive effluent release report, and the non-radiological environmental operating report which satisfies the requirements of the PNPP Technical Specifications, the PNPP Offsite Dose Calculation Manual, and the Environmental Protection Plan, Appendix B of the PNPP Operating License.

There are no regulatory commitments contained in this letter. If there are any questions or if additional information is required, please contact Mr. Michael J. Alfonso, Manager-Chemistry at (440) 280-7204.

Sincerely,



Mark B. Bezilla

Enclosure:
PNPP 2007 Annual Environmental and Effluent Release Report

cc: NRC Region III Administrator
NRC Resident Inspector
NRR Project Manager


JE48
LRR

Enclosure
L-08-162

PNPP 2007 Annual Environmental and Effluent Release Report

Perry Nuclear Power Plant

Annual Environmental & Effluent Release Report 2007



2007

**ANNUAL ENVIRONMENTAL
AND
EFFLUENT RELEASE
REPORT**

**for the
Perry Nuclear Power Plant**

PREPARED BY:
CHEMISTRY SECTION
PERRY NUCLEAR POWER PLANT
FIRSTENERGY NUCLEAR OPERATING COMPANY
PERRY, OHIO
MARCH, 2007

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

TABLE OF CONTENTS

EXECUTIVE SUMMARY.....	1
Radioactive Effluent Releases.....	1
Radiological Environmental Monitoring	1
Land Use Census.....	2
Clam/Mussel Monitoring	3
Herbicide Use.....	3
Special Reports	3
INTRODUCTION	4
Radiation Fundamentals.....	4
Radiation and Radioactivity.....	4
Units of Measure.....	5
Lower Limit of Detection.....	5
Background Radiation.....	6
RADIOACTIVE EFFLUENT RELEASES.....	7
Introduction.....	7
Regulatory Limits	7
Release Summary.....	9
Meteorological Data.....	17
Dose Assessment.....	17
Abnormal Releases	19
Non-Compliances.....	19
Offsite Dose Calculation Manual Changes	20
Process Control Program Changes.....	20
RADIOLOGICAL ENVIRONMENTAL MONITORING	21
Introduction.....	21
Sampling Locations.....	21
Sample Analysis.....	26
2007 Sampling Program.....	27
Inter-Laboratory Cross-Check Comparison Program	36
Land Use Census.....	37
CLAM/MUSSEL MONITORING.....	40
Introduction.....	40
Corbicula Program	40
Dreissena Program	41
Conclusions.....	41
HERBICIDE APPLICATIONS	42
SPECIAL REPORTS.....	45
Non-Compliances.....	45
Unreviewed Environmental Questions.....	45
Appendix A, 2007 Inter-Laboratory Cross Check Comparison Program Results	46
Appendix B, 2007 REMP Data Summary Reports.....	64
Appendix C, 2007 REMP Detailed Data Report.....	77

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

EXECUTIVE SUMMARY

The Annual Environmental and Effluent Release Report (AEERR) details the results of environmental and effluent monitoring programs conducted at the Perry Nuclear Power Plant (PNPP) from January 01 through December 31, 2007. This report meets all of the requirements in PNPP Technical Specifications, the Environmental Protection Plan (EPP), and Regulatory Guide 1.21. It incorporates the requirements of the Annual Radioactive Effluent Release Report (ARERR), the Annual Radiological Environmental Operating Report (AREOR) and the Annual Environmental Operating Report (AEOR). Report topics include radioactive effluent releases, radiological environmental monitoring, land use census, clam/mussel monitoring, herbicide use, and special reports. The results of the environmental and effluent programs, for 2007, indicate that the operations of the Perry Nuclear Power Plant did not result in any significant environmental impact.

RADIOACTIVE EFFLUENT RELEASES

During the normal operation of a nuclear power plant, small quantities of radioactivity may be released to the environment in liquid and gaseous effluents. Radioactive material may also be released as solid waste. PNPP maintains a comprehensive program to control and monitor the release of radioactive materials from the site in accordance with Nuclear Regulatory Commission (NRC) release regulations.

The dose to the general public from the plant's liquid and gaseous effluents was below the applicable regulatory limits. The calculated hypothetical maximum individual whole body dose potentially received by an individual resulting from PNPP liquid effluents was $7.40E-4$ mrem (0.03 % of the applicable limit). The calculated hypothetical maximum individual whole body dose potentially received by an individual resulting from PNPP gaseous effluents was $1.84E-6$ mrem ($<0.00004\%$ of the applicable limit). The summation of the hypothetical maximum individual dose from effluents in 2007 is equivalent to <0.1 % of the total dose an individual living in the PNPP area receives from all sources of radiation.

Shipments of solid waste consisted of waste generated during water treatment; radioactive material generated during normal daily operations and maintenance, and irradiated components. PNPP complied with applicable regulations governing radioactive shipments in 2007; making shipments of solid radioactive waste to a licensed burial site.

RADIOLOGICAL ENVIRONMENTAL MONITORING

The Radiological Environmental Monitoring Program (REMP) was established in 1981 to monitor the radiological conditions in the environment around PNPP. The REMP is conducted in accordance with PNPP Technical Specifications and the Offsite Dose Calculation Manual (ODCM). This program includes the collection and analysis of environmental samples and evaluation of results.

The REMP was established at PNPP six (6) years before the plant became operational. This pre-operational program was designed to provide data on background radiation and radioactivity normally present in the area. PNPP has continued to monitor the environment during plant operation by collecting and analyzing samples of air, precipitation, milk, fish, produce, water and sediment, as well as by measuring radiation directly.

There were over 2900 radioactivity analyses performed on the 1262 radiological environmental samples collected in 2007. The results of the REMP indicate the adequacy of the control of the release of radioactivity in the effluents from PNPP. These results also demonstrate that PNPP complies with applicable federal regulations. The REMP results are divided into four sections: atmospheric monitoring, terrestrial monitoring, aquatic monitoring, and direct radiation monitoring.

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

Samples of air were collected to monitor the radioactivity in the atmosphere. The 2007 results were similar to those observed for the pre-operational and operational programs from prior years. Only natural background environmental radioactivity was detected.

Terrestrial monitoring included the analysis of milk and produce. The PNPP ODCM does not require vegetation or soil samples to be included in the monitoring program. The results of the sample analyses in 2007 indicated concentrations of radioactivity similar to that found in previous years. Analyses of other terrestrial samples also detected concentrations of natural radioactivity similar to those observed in previous years, and indicated no build-up of radioactivity attributable to the operation of PNPP.

Aquatic monitoring included the collection and analyses of water, fish, and shoreline sediments. The 2007 analytical results for water and fish samples showed normal background radionuclide concentrations. The results of sediment sample analyses indicated that the annual average cesium radioactivity was similar to previous years for the control location. Cesium-137 activity was detected in five (5) of the twelve (12) samples collected. The average cesium-137 radioactivity for all locations was 451.70 pCi/kg and is within the maximum value of 864 pCi/kg established in 1981.

In 1999, a sediment sample of the northwest drain impoundment (sampling location #64) was analyzed to contain 62 pCi/kg of cobalt-60. During 2007, enhanced monitoring activities continued within the boundaries of the impoundment. The cobalt-60 remains centered within the organic material located at the top of the spillway, with little or no activity found farther upstream. Sample analyses continue to identify cobalt-60 levels similar to those found in previous years. Refer to Table 16 for detailed sample results.

Direct radiation measurements showed no change from previous years. The indicator locations averaged 52.70 mrem/year and control locations averaged 49.63 mrem/year. In 2007, radiation dose in the area of PNPP was similar to the radiation dose measured at locations greater than ten (10) miles away from the Plant.

Based on these results, during 2007, the operation of the PNPP resulted in no significant increase in the radionuclide concentrations observed in the environment.

LAND USE CENSUS

In order to estimate radiation dose attributable to the operation of PNPP, the potential pathways through which public exposure can occur must be known. To identify these exposure pathways, an Annual Land Use Census is performed as part of the REMP. During the census, PNPP personnel travel every public road within a five (5) mile radius of the plant to locate key radiological exposure pathways. These key pathways include the nearest resident, garden, and milk animal in each of the sixteen meteorological sectors. The information obtained from the census is entered into a computer program, which is used to assess the hypothetical dose to members of the public. In recent years, however, it has been noted that tracts of land once used for farming are now being developed as mini-industrial parks and residential housing tracts. This is reflected in the loss of available milking animals within a five mile radius of PNPP to support the Radiological Environmental Monitoring Program (REMP). For 2007, the predominant land use within the census area continues to be rural/agricultural.

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

CLAM/MUSSEL MONITORING

Clam and mussel shells can clog plant piping and components that use water from Lake Erie. For this reason, sampling for clams and mussels has been conducted in Lake Erie in the vicinity of PNPP since 1971. The monitoring is specifically for *Corbicula* (Asiatic clams), since their introduction into the Great Lakes, in 1981, and for *Dreissena* (zebra mussels), since their discovery in Lake Erie, in 1989. Since no *Corbicula* have ever been found at PNPP, routine *Corbicula* monitoring will provide early detection capability, when this pest species arrives at PNPP. The *Dreissena* program includes both monitoring and control and is directed at minimizing the mussel's impact on plant operation. As in past years, this program has successfully prevented *Dreissena* from causing any significant operational problems at PNPP.

HERBICIDE USE

The use of herbicides on the PNPP site is monitored to ensure compliance with Ohio Environmental Protection Agency (OEPA) requirements and to protect the site's natural areas. Based on the results of on-site herbicide applications, and weekly general site inspections, herbicide use has not had a negative impact on the environment around the plant.

SPECIAL REPORTS

Significant environmental events (for example, spills, releases), noncompliance with environmental regulations [e.g., Ohio Environmental Protection Agency (OEPA) discharge limits], and changes in plant design or operation that affect the environment are reported to regulatory agencies as they occur.

One special report was submitted in 2007:

- On September 20, 2007, the Perry Plant reported a noncompliance to the OEPA due to exceeding the discharge limitation for pH at the Major Stream diversion (also referred to as "Red Mill Run"). The event actually occurred on September 19, 2007.

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

INTRODUCTION

Nuclear energy provides an alternative energy source, which is readily available and has very limited impact upon the environment. To more fully understand nuclear energy as a source of generating electricity, one must understand basic radiation concepts and its occurrence in nature.

RADIATION FUNDAMENTALS

Atoms are the basic building blocks of all matter. Simply described, atoms are made up of positively and negatively charged particles, and particles which are neutral. These particles are called protons, electrons, and neutrons, respectively. The relatively large protons and neutrons are packed together in the center of the atom called the nucleus. Orbiting around the nucleus are one or more smaller electrons. In an electrically neutral atom, the positively charged protons in the nucleus balance the negatively charged electrons. Due to their dissimilar charges, the protons and electrons have a strong attraction for each other, which helps hold the atom together. Other attractive forces between the protons and neutrons keep the densely packed protons from repelling each other, and preventing the nucleus from breaking apart.

Atoms with the same number of protons in their nuclei make up an element. The number of neutrons in the nuclei of an element may vary. Atoms with the same number of protons but different numbers of neutrons are called isotopes. All isotopes of the same element have the same chemical properties and many are stable or non-radioactive. An unstable or radioactive isotope of an element is called a radioisotope, or radionuclide. Radionuclides contain an excess amount of energy in the nucleus, which is usually due to an excess number of neutrons.

Radioactive atoms attempt to reach a stable, non-radioactive state through a process known as radioactive decay. Radioactive decay is the release of energy from an atom's nucleus through the emission of radiation. Radionuclides vary greatly in the frequency with which their atoms release radiation. The length of time an atom remains radioactive is defined in terms of its half-life. Half-life is defined as the time required for a radioactive substance to lose half its activity through the process of radioactive decay. Half-lives vary from millionths of a second to millions of years.

RADIATION AND RADIOACTIVITY

Radioactive decay is a process in which the nucleus of an unstable atom becomes more stable by spontaneously emitting energy. Radiation refers to the energy that is released when radioactive decay occurs within the nucleus. This section includes a discussion on the three (3) primary forms of radiation produced by radioactive decay.

Alpha Particles

Alpha particles consist of two protons and two neutrons and have a positive charge. Because of their charge and large size, alpha particles do not travel very far when released (less than 4 inches, in air). They are unable to penetrate any solid material, such as paper or skin, to any significant depth. However, if alpha particles are released inside the body, they can damage the soft internal tissues because they deposit all their energy in a small area.

Beta Particles

Beta particles are essentially free electrons, which usually carry a negative electrical charge. They are much smaller than alpha particles and travel at nearly the speed of light. Thus they can travel for longer distances than alpha particles. External beta radiation primarily affects the skin. Because of their electrical charge, paper, plastic or thin metals can stop beta particles.

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

Gamma Rays

Gamma rays are bundles of electromagnetic energy, called photons, which behave as though they were particles. They are similar to visible light, but of a much higher energy. Gamma rays can travel long distances in air and are often released during radioactive decay, along with alpha and beta particles. Potassium-40 is an example of a naturally occurring radionuclide found in all humans that decays by emitting a gamma ray.

Interaction with Matter

When radiation interacts with other materials, it affects the atoms of those materials principally by knocking the negatively charged electrons out of orbit. This causes an atom to lose its electrical neutrality and become positively charged. An atom that is charged, either positively or negatively, is called an ion and the radiation is called ionizing radiation.

UNITS OF MEASURE

Some of the units of measure used in this report require explanation.

Activity

Activity is the number of atoms in a material that decay per unit of time. Each time an atom decays, radiation is emitted. The curie (Ci) is the unit used to describe the activity of a material and indicates the rate at which the atoms are decaying. One curie of activity indicates the decay of 37 billion atoms per second. Smaller units of the curie are often used in this report. Two common units are the microcurie (μCi), one millionth of a curie, and the picocurie (pCi), one trillionth of a curie. The mass, or weight, of radioactive material, which would result in one (1) curie of activity, depends on the disintegration rate. For example, one gram of radium-226 is equivalent to one (1) curie of activity. It would require about 1.5 million grams of natural uranium, however, to equal one (1) curie.

Dose

Biological damage due to alpha, beta, and gamma radiation may result from the ionization caused by these types of radiation. Some types of radiation, especially alpha particles, which causes dense local ionization, can result in much more biological damage for the same energy imparted than does gamma or beta radiation. Therefore, a quality factor must be applied to account for the different ionizing capabilities of various types of ionizing radiation. When the quality factor is multiplied by the absorbed dose (as measured in rads), the result is the dose equivalent, which is an estimate of the possible biological damage resulting from exposure to any type of ionizing radiation. The dose equivalent is measured in terms of the Roentgen Equivalent Man (rem). When discussing environmental radiation effects, the rem is a large unit. Therefore, a smaller unit, the millirem (mrem) is often used. One mrem is equivalent to 1/1000 of a rem.

LOWER LIMIT OF DETECTION


Sample results are often reported as below the Lower Limit of Detection (LLD). The LLD for an analysis is the smallest amount of radioactive material that will show a positive result for which there can be a 95% confidence that radioactivity is present. This statistical parameter is used as a measure of the sensitivity of a sample analysis. When a measurement is reported as less than the LLD (<LLD), it means that no radioactivity was detected. Had radioactivity been present at (or above) the stated LLD value, it statistically would have been detected. The NRC has established LLD values for environmental and effluent sample analyses.

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

BACKGROUND RADIATION

Background radiation is a part of nature. Natural background radioactive decay occurs in the soil, water, air, and space. Common sources of radiation that contribute to the natural background radiation includes: the decay of radioactive elements in the earth's crust, a steady stream of high-energy particles from space (called cosmic radiation), naturally-occurring radioactive isotopes in the human body like potassium-40, the decay of radioisotopes used in medical procedures, man-made phosphate fertilizers (phosphates and uranium are often found together in nature), fallout from nuclear weapons testing, and even household items like smoke detectors. In the United States, a person's average annual exposure from background radiation is 360 mrem, and is due to the sources shown in Figure 1 [Source: National Council on Radiation Protection and Measurements].

Figure 1: Sources of Background Radiation



Many radionuclides are present in the environment due to sources such as cosmic radiation and fallout from nuclear weapons testing. These radionuclides are expected to be present in many of the environmental samples collected in the vicinity of PNPP. Some of the radionuclides normally present include:

- ◆ Beryllium-7, present as a result of the interaction of cosmic radiation with the upper atmosphere,
- ◆ Potassium-40, a naturally occurring radionuclide normally found in humans and throughout the environment, and
- ◆ Radionuclides from nuclear weapons testing fallout, including tritium and cesium-137. These radionuclides may also be released in minute amounts from nuclear facilities.

Beryllium-7 and potassium-40 are especially common in REMP samples. Since they are naturally occurring and are expected to be present, positive results for these radionuclides are not discussed in the section for the 2007 Sampling Program results. These radionuclides are included; however, in Appendix A, 2007 Inter-Laboratory Cross Check Comparison Program Results.

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

RADIOACTIVE EFFLUENT RELEASES

INTRODUCTION

The source of radioactive material in a nuclear power plant is the generation of fission products (e.g., noble gas, iodine, and particulate) or neutron activation of water and corrosion products (e.g., tritium and cobalt). The majority of the fission products generated remain within the nuclear fuel pellet and fuel cladding. Most fission products that escape from the fuel cladding, as well as the majority of the activated corrosion products, are removed by plant processing equipment.

During the normal operation of a nuclear power plant, small amounts of radioactive material are released in the form of solids, liquids, and gases. PNPP was designed, and is operated in such a manner as to control and monitor these effluent releases. Effluents are controlled to ensure any radioactivity released to the environment is minimal and within regulatory limits. Effluent release programs include the operation of monitoring systems, in-plant sampling and analysis, quality assurance, and detailed procedures covering all aspects of effluent monitoring.

The liquid and gaseous radioactive waste treatment systems at PNPP are designed to collect and process these wastes in order to remove most of the radioactivity. Effluent monitoring systems are used to provide continuous indication of the radioactivity present and are sensitive enough to measure several orders of magnitude lower than the applicable release limits. This monitoring equipment is equipped with alarms and indicators in the plant control room. The alarms are set to provide warnings to alert plant operators when radioactivity levels reach a small fraction of actual limits. The waste streams are sampled and analyzed to identify and quantify the radionuclides being released to the environment.

Gaseous effluent release data is coupled with on-site meteorological data in order to calculate the dose to the general public. Devices are maintained at various locations around PNPP to constantly sample the air in the surrounding environment. Frequent samples of other environmental media are also taken to determine if any radioactive material deposition has occurred. The Radiological Environmental Monitoring Program (REMP) is described in detail in the next section.

Generation of solid waste is carefully monitored to identify opportunities for minimization. Limiting the amount of material taken into the plant, sorting material as radioactive or non-radioactive, shredding and compacting, or incinerating waste once it is identified help to lower the volume of radioactive solid waste generated. Solid waste is shipped to a licensed burial site.

REGULATORY LIMITS

The Nuclear Regulatory Commission has established limits for liquid and gaseous effluents that comply with:

- Title 10 of the Code of Federal Regulations, Part 20 (Standards for Protection Against Radiation) [10CFR20], Appendix B;
- Title 10 of the Code of Federal Regulations, Part 50 (Domestic Licensing of Production and Utilization Facilities) [10CFR50], Appendix I; and
- Title 40 of the Code of Federal Regulations, Part 190 (Environmental Radiation Protection Standards for Nuclear Power Plants) [40CFR190].

These limits were incorporated into the PNPP Technical Specifications, and subsequently into the PNPP Offsite Dose Calculation Manual (ODCM). The ODCM prescribes the maximum doses and dose rates due to radioactive effluents resulting from the operation of PNPP. These limits are defined in several ways to limit the overall impact on persons living near the plant. Since there are

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

no other fuel sources near the PNPP, the 40CFR190 limits, which are described below, were not exceeded in 2007.

The 40CFR190 limit for total direct-radiation dose is 25 mrem. For 2007, the total whole body dose to a member of the general public, considering all sectors, was 1.17E-2 mrem. This value was determined by summing the annual whole body doses from liquid and gaseous radioactive effluents, the annual gaseous and liquid organ dose (refer to Table 7) and the maximum, direct-radiation dose. Since the direct radiation dose, as determined by TLD, was indistinguishable from natural background (refer to Figure 8), it was not included in the calculation.

Liquid Effluents

The concentration of radioactive material released in liquid effluents to unrestricted areas shall be limited to the concentrations specified in 10CFR20, Appendix B, Table 2, Column 2 for radionuclides other than dissolved or entrained noble gases, as required by the ODCM. For dissolved or entrained noble gases, the concentration shall be limited to 2.0E-04 $\mu\text{Ci/mL}$ of total activity. These values are the maximum effluent concentrations.

The dose or dose commitment to a member of the public from radioactive materials in liquid effluents released to unrestricted areas shall be limited to the following:

During any calendar quarter:

- Less than or equal to 1.5 mrem to the whole body, and
- Less than or equal to 5 mrem to any organ.

During any calendar year:

- Less than or equal to 3 mrem to the whole body, and
- Less than or equal to 10 mrem to any organ.

Gaseous Effluents

Dose rate due to radioactive materials released in gaseous effluents from the site to areas at and beyond the site boundary shall be limited to the following:

Noble gases:

- Less than or equal to 500 mrem per year to the whole body, and
- Less than or equal to 3000 mrem per year to any organ.

Iodine-131, Iodine-133, Tritium, and all radionuclides in particulate form with half lives greater than eight days:

- Less than or equal to 1500 mrem per year to any organ

Air dose due to noble gases to areas at, and beyond the site boundary, shall be limited to the following:

During any calendar quarter:

- Less than or equal to 5 mrad for gamma radiation, and
- Less than or equal to 10 mrad for beta radiation.

During any calendar year:

- Less than or equal to 10 mrad for gamma radiation, and
- Less than or equal to 20 mrad for beta radiation.

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

Dose to a member of the public from Iodine-131, Iodine-133, Tritium, and all radionuclides in particulate form with half lives greater than eight days in gaseous effluents released to areas at and beyond the site boundary shall be limited to the following:

Less than or equal to 7.5 mrem to any organ per any calendar quarter, and

Less than or equal to 15 mrem to any organ per any calendar year.

The PNPP ODCM does not contain a concentration reference for gaseous effluents. For this reason, effluent concentrations are not used to calculate maximum release rates for gaseous effluents.

RELEASE SUMMARY

Effluents are sampled and analyzed to identify both the type and quantity of radionuclides present. This information is combined with effluent path flow measurements to determine the composition, concentration, and dose contribution of the radioactive effluents.

Liquid Effluents

The PNPP liquid radioactive waste system is designed to collect and treat all radioactive liquid waste produced in the plant. The treatment process used for radioactive liquid waste depends on its physical and chemical properties. It is designed to reduce the concentration of radioactive material in the liquid by filtration to remove suspended solids and demineralization to remove dissolved solids. Normally, the effluent from the liquid radioactive waste system is returned to plant systems. To reduce the volume of water stored in plant systems; however, the processed liquid effluent may be discharged from the plant via a controlled release. In this case, effluent activity and dose calculations are performed prior to, and after discharging this processed water to Lake Erie to ensure regulatory compliance and dose minimization principals are maintained.

Liquid radioactive waste system effluents may be intermittently released, which are considered to be "batch" releases. Table 1 provides information on the number and duration of these releases for 2007.

Table 1: Liquid Batch Releases

	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4	TOTAL
Number of batch releases	5	40	30	28	103
Total time period for batch releases, min	1.09E+03	8.32E+03	6.73E+03	6.25E+03	2.24E+04
Maximum time for a batch release, min	2.27E+02	2.66E+02	2.32E+02	2.32E+02	
Average time period for a batch release, min	2.19E+02	2.08E+02	2.24E+02	2.23E+02	
Minimum time for a batch release, min	1.97E+02	1.00E+00	2.17E+02	2.04E+02	
Average stream flow during periods of effluent release into a flowing stream, L/min	1.93E+05	2.58E+05	2.47E+05	1.81E+05	

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

Table 2 provides information on the nuclide composition for the liquid radioactive effluent system releases. If a radionuclide was not present at a level "greater than or equal to the LLD" (\geq LLD), then the value is expressed as "less than the LLD" (<LLD). In each case, LLDs were met, or were below the levels required by the ODCM. Table 2a provides information specific to radioactive effluent batch releases while Table 2b provides information specific to continuous radioactive effluent releases.

Table 2: Summation of All Liquid Effluent Releases

	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4	EST. TOTAL ERROR, %
A. Fission and Activation Products					
1. Total Released, Ci (excluding tritium, gases, alpha)	2.55E-05	1.98E-03	2.13E-03	5.60E-04	1.00E+01
2. Average Diluted Concentration, μ Ci/mL *	8.17E-13	5.32E-11	5.53E-11	1.99E-11	
3. Percent of Applicable Limit, %	N/A	N/A	N/A	N/A	
B. Tritium					
1. Total Released, Ci	2.64E+00	1.81E+01	1.19E+01	1.38E+01	1.00E+01
2. Average Diluted Concentration, μ Ci/mL	8.46E-08	4.86E-07	3.09E-07	4.90E-07	
3. Percent of Applicable Limit, %	8.46E-03	4.86E-02	3.09E-02	4.90E-02	
C. Dissolved and Entrained Gases					
1. Total Released, Ci	<LLD	<LLD	<LLD	<LLD	1.00E+01
2. Average Diluted Concentration, μ Ci/mL	<LLD	<LLD	<LLD	<LLD	
3. Percent of Applicable Limit, %	N/A	N/A	N/A	N/A	
D. Alpha Activity, Ci	<LLD	7.49E-06	<LLD	<LLD	1.00E+01
E. Waste Volume Released, Liters (prior to dilution)	7.49E+05	5.04E+06	9.24E+06	5.82E+06	1.00E+01
F. Dilution Water Volume Used, Liters	3.12E+10	3.72E+10	3.85E+10	2.82E+10	1.00E+01

<LLD - Less than the lower limit of detection

N/A - Not Applicable, the ODCM does not have a limit for fission and activation products.

*Average diluted concentrations are based on total volume of water released during quarter.

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

Table 2a: Summation of Batch Liquid Effluent Releases

	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4	EST. TOTAL ERROR, %
A. Fission and Activation Products					
Total Released, Ci (excluding tritium, gases, alpha)	2.55E-05	1.98E-03	2.13E-03	5.60E-04	1.00E+01
B. Tritium					
Total Released, Ci	2.62E+00	1.79E+01	1.19E+01	1.38E+01	1.00E+01
C. Dissolved and Entrained Gases					
Total Released, Ci	<LLD	<LLD	<LLD	<LLD	1.00E+01
D. Alpha Activity, Ci	LLD	<LLD	<LLD	<LLD	1.00E+01
E. Waste Volume Released, Liters (prior to dilution)	7.49E+05	4.39E+06	4.28E+06	3.63E+06	1.00E+01

<LLD - Less than the lower limit of detection

Table 2b: Summation of Continuous Liquid Effluent Releases

	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4	EST. TOTAL ERROR, %
A. Fission and Activation Products					
Total Released, Ci (excluding tritium, gases, alpha)	<LLD	<LLD	<LLD	<LLD	1.00E+01
B. Tritium					
Total Released, Ci	2.24E-02	2.00E-01	2.81E-02	2.57E-02	1.00E+01
C. Dissolved and Entrained Gases					
Total Released, Ci	<LLD	<LLD	<LLD	<LLD	1.00E+01
D. Alpha Activity, Ci	<LLD	<LLD	<LLD	<LLD	1.00E+01
E. Waste Volume Released, Liters (prior to dilution)	0	6.47E+05	4.96E+06	2.19E+06	1.00E+01

<LLD - Less than the lower limit of detection

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

Table 3 lists the total number of curies (Ci) of each radionuclide present in liquid effluent releases for each quarter. If a radionuclide was not present at a level "greater than or equal to the LLD" (\geq LLD), then the value is expressed as "less than the LLD" (<LLD). In each case, the LLDs were either met, or were below the levels required by the ODCM.

Table 3: Radioactive Liquid Effluent Nuclide Composition

	UNIT	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4	ANNUAL TOTAL
Tritium	Ci	2.62E+00	1.79E+01	1.19E+01	1.38E+01	4.64E+01
Chromium-51	Ci	<LLD	<LLD	<LLD	<LLD	<LLD
Manganese-54	Ci	<LLD	3.82E-04	3.04E-05	1.71E-05	4.30E-04
Iron-55	Ci	<LLD	<LLD	<LLD	<LLD	<LLD
Iron-59	Ci	<LLD	<LLD	<LLD	<LLD	<LLD
Cobalt-58	Ci	<LLD	3.76E-05	<LLD	<LLD	3.76E-05
Cobalt-60	Ci	2.55E-05	1.42E-03	1.06E-04	3.16E-04	1.87E-03
Zinc-65	Ci	<LLD	6.06E-05	<LLD	<LLD	6.06E-05
Strontium-92	Ci	<LLD	<LLD	<LLD	<LLD	<LLD
Zirconium-95	Ci	<LLD	<LLD	<LLD	<LLD	<LLD
Niobium-95	Ci	<LLD	<LLD	<LLD	<LLD	<LLD
Technetium-99M	Ci	<LLD	<LLD	<LLD	<LLD	<LLD
Rhuthenium-105	Ci	<LLD	<LLD	<LLD	<LLD	<LLD
Silver-110m	Ci	>LLD	3.27E-05	<LLD	<LLD	3.27E-05
Antimony-124	Ci	<LLD	<LLD	2.32E-04	<LLD	2.32E-04
Antimony-125	Ci	<LLD	<LLD	1.49E-03	2.03E-04	1.69E-03
Iodine-131	Ci	<LLD	<LLD	<LLD	<LLD	<LLD
Xenon-133	Ci	<LLD	<LLD	<LLD	<LLD	<LLD
Cesium-134	Ci	<LLD	<LLD	<LLD	<LLD	<LLD
Cesium-137	Ci	<LLD	4.63E-05	2.71E-04	2.36E-05	3.41E-04
Cesium-138	Ci	<LLD	<LLD	<LLD	<LLD	<LLD
Lanthanum-140	Ci	<LLD	<LLD	<LLD	<LLD	<LLD
Gold-199	Ci	<LLD	<LLD	<LLD	<LLD	<LLD
Total for Period	Ci	2.62E+00	1.79E+01	1.19E+01	1.38E+01	4.64E+01

<LLD - Less than the lower limit of detection

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

Gaseous Effluents

Gaseous effluents are made up of fission and activation gases, iodine and particulate releases. The fission and activation gas releases are primarily a result of containment purge operations, small steam leaks, and offgas system operation. The iodine and particulate releases are primarily a result of small steam leaks. Gaseous effluents from PNPP exit the plant via one of four effluent vents. Each of these four effluent vents contains radiation detectors that continuously monitor the air to ensure that the levels of radioactivity released are well below regulatory limits. Samples are also collected and analyzed on a routine basis to ensure regulatory compliance and dose minimization principals are maintained. The majority of gaseous effluents released from PNPP are considered continuous and at ground level.

A summation of all gaseous radioactive effluent releases is given in Table 4. If a radionuclide was not present at a level "greater than or equal to the LLD" (\geq LLD), then the value is expressed as "less than the LLD" (<LLD). In each case, the measured LLDs either met or were below the levels required by the PNPP ODCM.

Table 4: Summation of All Gaseous Effluents

	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4	EST. TOTAL ERROR, %
A. Fission and Activation Products					
1. Total Released, Ci	2.10E+01	6.09E+00	2.74E-01	3.81E-02	1.00E+01
2. Average Release Rate, μ Ci/sec	2.70E+00	7.74E-01	3.44E-02	4.79E-03	
3. Percent of Applicable Limit, %	N/A	N/A	N/A	N/A	
B. Iodine					
1. Total Iodine-131 Released, Ci	< LLD	3.06E-4	1.16E-05	1.55E-04	1.00E+01
2. Average Release Rate, μ Ci/sec	N/A	3.89E-5	1.46E-06	1.95E-05	
3. Percent of Applicable Limit, %	N/A	N/A	N/A	N/A	
C. Particulates with Half-Lives > 8 days					
1. Total Released, Ci	< LLD	3.56E-5	< LLD	< LLD	1.00E+01
2. Average Release Rate, μ Ci/sec	N/A	4.53E-6	N/A	N/A	
3. Percent of Applicable Limit, %	N/A	N/A	N/A	N/A	
D. Alpha Activity, Ci					
	6.15E-7	4.24E-07	2.27E-07	1.03E-07	
E. Tritium					
1. Total Released, Ci	< LLD	< LLD	< LLD	< LLD	1.00E+01
2. Average Release Rate, μ Ci/sec	N/A	N/A	N/A	N/A	
3. Percent of ODCM Limit, %	N/A	N/A	N/A	N/A	

<LLD - Less than the lower limit of detection

N/A - Not Applicable, the ODCM does not have a limit for fission and activation products.

The radionuclide composition of all gaseous radioactive effluents for a continuous-mode, ground-level release is given in Table 5. If a radionuclide was not present at a level "greater than or equal to the LLD" (\geq LLD), then the value is expressed as "less than the LLD" (<LLD). In each case, LLDs were met or were below the levels required by the ODCM.

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

Table 5: Radioactive Gaseous Effluent Nuclide Composition

	UNIT	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4	ANNUAL TOTAL
A. FISSION AND ACTIVATION GASES						
Tritium	Ci	<LLD	<LLD	<LLD	<LLD	<LLD
Argon-41	Ci	4.82E+00	5.16E+00	<LLD	<LLD	9.98E+00
Krypton-85m	Ci	4.83E+00	<LLD	<LLD	<LLD	4.83E+00
Krypton-85	Ci	2.98E-01	<LLD	<LLD	<LLD	2.98E-01
Krypton-87	Ci	3.36E-01	<LLD	<LLD	<LLD	3.36E-01
Krypton-88	Ci	9.19E+00	<LLD	<LLD	<LLD	9.19E+00
Xenon-131m	Ci	<LLD	<LLD	<LLD	<LLD	<LLD
Xenon-133m	Ci	<LLD	<LLD	<LLD	<LLD	<LLD
Xenon-133	Ci	1.51E+00	4.53E-02	4.02E-02	<LLD	1.60E+00
Xenon-135m	Ci	<LLD	2.21E-02	<LLD	<LLD	2.21E-02
Xenon-135	Ci	<LLD	8.24E-01	2.26E-01	2.24E-02	1.07E+00
Xenon-137	Ci	<LLD	<LLD	<LLD	<LLD	<LLD
Xenon-138	Ci	<LLD	3.74E-02	7.76E-03	1.56E-02	2.33E-02
Total for Period	Ci	2.10E+01	6.09E+00	2.74E-01	3.80E-02	2.68E+01
B. IODINE						
Iodine-131	Ci	<LLD	3.06E-4	1.16E-05	1.55E-04	1.67E-04
Iodine-132	Ci	<LLD	<LLD	<LLD	<LLD	<LLD
Iodine-133	Ci	<LLD	5.53E-4	7.01E-05	1.32E-04	2.02E-04
Iodine-134	Ci	<LLD	<LLD	<LLD	<LLD	<LLD
Iodine-135	Ci	<LLD	<LLD	<LLD	<LLD	<LLD
Total for Period	Ci	<LLD	8.59E-4	8.17E-05	2.87E-04	3.69E-04
B. PARTICULATE						
Chromium-51	Ci	<LLD	<LLD	<LLD	<LLD	<LLD
Manganese-54	Ci	<LLD	<LLD	<LLD	<LLD	<LLD
Iron-59	Ci	<LLD	<LLD	<LLD	<LLD	<LLD
Cobalt-58	Ci	<LLD	<LLD	<LLD	<LLD	<LLD
Cobalt-60	Ci	<LLD	<LLD	<LLD	<LLD	<LLD
Zinc-65	Ci	<LLD	<LLD	<LLD	<LLD	<LLD
Rubidium-88	Ci	<LLD	<LLD	<LLD	<LLD	<LLD
Rubidium-89	Ci	<LLD	<LLD	<LLD	<LLD	<LLD
Strontium-89	Ci	<LLD	<LLD	<LLD	<LLD	<LLD
Strontium-90	Ci	<LLD	<LLD	<LLD	<LLD	<LLD
Strontium-91	Ci	<LLD	<LLD	<LLD	<LLD	<LLD
Yttrium-91m	Ci	<LLD	<LLD	<LLD	<LLD	<LLD
Strontium-92	Ci	<LLD	<LLD	<LLD	<LLD	<LLD
Zirconium-95	Ci	<LLD	<LLD	<LLD	<LLD	<LLD
Molybdenum-99	Ci	<LLD	<LLD	<LLD	<LLD	<LLD
Cesium-137	Ci	<LLD	3.56E-5	<LLD	<LLD	<LLD
Cesium-138	Ci	<LLD	<LLD	<LLD	<LLD	<LLD
Barium-139	Ci	<LLD	<LLD	<LLD	<LLD	<LLD
Barium-140	Ci	<LLD	<LLD	<LLD	<LLD	<LLD
Lanthanum-140	Ci	<LLD	<LLD	<LLD	<LLD	<LLD
Total for Period	Ci	<LLD	3.56E-5	<LLD	<LLD	<LLD

<LLD – Less than the lower limit of detection

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

Solid Waste

There were 7 shipments of PNPP solid radioactive waste transported, by truck, directly to the Barnwell, South Carolina disposal facility for burial. Other solid radioactive waste from PNPP was processed and combined with waste from several other utilities by intermediate vendors (Energy Solutions, Duratek in Oak Ridge, TN and Studsvik, in Erwin, TN). This waste was ultimately sent to the Barnwell, South Carolina, or Clive, Utah, disposal facilities for burial. The solid radioactive waste summary in Table 6 includes all PNPP shipments for 2007.

Table 6: Solid Waste Shipped Offsite for Burial or Disposal

A. Type of Solid Waste Shipped	Volume m ³	Activity Ci	Period	Est. Total Error %
Spent resin, filter sludge, evaporator bottoms, etc.	13.52	449.8	1/1/2007- 12/31/2007	+/- 25
Dry compressible waste, contaminated equipment, etc.	102.92	8.10	1/1/2007- 12/31/2007	+/- 25
Irradiated components, control rods, etc.	0.95	39000	1/1/2007- 12/31/2007	+/- 25
Other (describe)	0	0	N/A	N/A

B. Estimate of Major ⁽¹⁾ Nuclide Composition (by type of waste)	Radionuclide	Abundance %	Est. Total Error, %
Spent Resin, Filter Sludge, Evaporator Bottoms, etc.	Mn-54	4.2	+/- 25
	Fe-55	39.0	
	Zn-65	3.5	
	Co-60	50.6	
Dry Compressible Waste, Contaminated Equipment, etc.	Mn-54	3.1	+/- 25
	Fe-55	73.0	
	Co-60	22.7	
Irradiated Components, Control Rods, etc.	Fe-55	1.1	+/- 25
	Co-60	5.4	
	Zr-95	23.9	
	Nb-95	39.6	
	Sn-119m	18.1	
	Sb-125	10.0	
	Te-125m	1.0	
Other (describe)	N/A	N/A	N/A

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

C. Disposition	Number of Shipments	Mode of Transportation	Destination
Solid Waste ⁽²⁾	22	Public Highway	Studsvik, Erwin, TN
Solid Waste ⁽²⁾	21	Public Highway	Duratek, Oak Ridge, TN
Solid Waste	7	Public Highway	Barnwell, Barnwell, S.C.
Irradiated Fuel Shipments	0	N/A	N/A

N/A -- Not Applicable

(1) -- "Major" is defined as any individual radionuclide identified as >1% of the waste type abundance.

(2) -- This waste was combined with waste from other utilities and disposed of at Barnwell, SC or Clive, Utah.

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

METEOROLOGICAL DATA

The Meteorological Monitoring System at PNPP consists of a 60-meter tower equipped with two independent systems for measuring wind speed, wind direction, and temperature at both 10-meter and 60-meter heights. The tower also has instrumentation to measure dew point and barometric pressure. Data is logged from the tower through separate data loggers, and transmitted to a common plant computer. This system compiles the data and calculates a variety of atmospheric parameters, communicates with the Meteorological Information Dose Assessment System (MIDAS), and sends data over communication links to the plant Control Room.

DOSE ASSESSMENT

The maximum concentration for any radioactive release is controlled by the limits set forth in Title 10 of the Code of Federal Regulations, Part 20 (10CFR20). Sampling, analyzing, processing, and monitoring the effluent stream ensures compliance with these concentration limits. Dose limit compliance is verified through periodic dose assessment calculations. Some dose calculations are conservatively performed for a hypothetical individual who is assumed to reside on the site boundary at the highest potential dose location all year. This person, called the "maximum individual", would incur the maximum potential dose from direct exposure (air plus ground plus water), inhalation, and ingestion of water, milk, vegetation, and fish. Because no one actually meets these criteria, the actual dose received by a real member of the public is significantly less than what is calculated for this hypothetical individual.

Dose calculations for this maximum individual at the site boundary are performed for two cases. First, they are performed using data for a 360° radius around the plant site (land and water based meteorological sectors), even though some of these sectors are over Lake Erie, which has no permanent residents. The second calculation is performed considering only those sectors around the plant in which people reside (land-based meteorological sectors).

The calculated hypothetical, maximum individual dose values at the site boundary are provided in Table 7. This table considers all meteorological sectors around PNPP and provides either the whole body or worst-case, organ dose values. If any radionuclide was not present at a level greater than the LLD, it was not used in the dose calculations.

Table 7: Maximum Individual Site Boundary Dose, Considering All Sectors

TYPE OF DOSE	ORGAN	ESTIMATED DOSE, mrem	LIMIT	% OF LIMIT
Liquid Effluent	Whole body	2.33E-03	3.0E+00	7.8E-02
	Liver	3.13E-03	1.0E+01	3.1E-02
Noble Gas - gamma air - beta air	N/A	5.40E-02	1.0E+01	5.4E-01
	N/A	1.68E-02	2.0E+01	8.4E-02
Noble Gas	Whole body	3.53E-2	5.0E+00	7.1E-1
	Skin	5.36E-2	1.5E+01	3.6E-1
Particulate & Iodine	Thyroid	3.63E-03	1.5E+01	2.4E-02

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

The calculated hypothetical, maximum population dose values at the site boundary are provided in Table 8. This table considers all meteorological sectors around PNPP and provides either the whole body or worst-case, organ dose values.

Table 8: Population Dose, Considering All Sectors

	ORGAN	ESTIMATED DOSE person-rem
Liquid Effluent	Whole body	4.30E-01
	Thyroid	3.10E-01
Gaseous Effluent	Whole body	1.20E-03
	Thyroid	2.60E-03

Table 9 provides the calculated hypothetical maximum site boundary dose values considering only the land-based sectors. If any radionuclide was not present at a level greater than the LLD, it was not used in the dose calculations.

Table 9: Maximum Individual Site Boundary Dose, Considering Sectors on Land

TYPE OF DOSE	ORGAN	ESTIMATED DOSE, mrem	LIMIT	% OF LIMIT
Liquid Effluent	Whole body	7.40E-4	3.0E+00	2.5E-2
	Liver	8.21E-4	1.0E+01	8.2E-3
Noble Gas - gamma air - beta air	5.40E-02	3.02E-6	5.4E-01	3.0E-5
	1.68E-02	3.87E-6	8.4E-02	1.9E-5
Noble Gas	Whole body	1.84E-6	5.0E+00	3.7E-5
	Skin	4.84E-6	1.5E+01	3.2E-5
Particulate & Iodine	Thyroid	8.29E-5	1.5E+01	5.5E-4

Other dose calculations are performed for a hypothetical individual who is assumed to be inside the site boundary for some specified amount of time. This person would receive the maximum dose during the time spent inside site boundary. Because no one actually meets the criteria established for these conservative calculations, the actual dose received by a real member of the public is significantly less than what is calculated for this hypothetical individual. This dose is assessed relative to the offsite dose, and considers dilution, dispersion, and occupancy factors.

The highest hypothetical dose from liquid effluents to a member of the public inside the site boundary is to a person who is fishing on Lake Erie from the shore on PNPP property. The calculations assume that this person will spend 60 hours per year fishing, with a liquid dilution factor of 10. The ratio of the exposure pathway to the doses calculated for offsite locations yields the dose values shown in Table 10.

Table 10: Maximum Site Dose from Liquid Effluents

	WHOLE BODY DOSE, mrem	ORGAN DOSE, mrem
First Quarter	1.2E-6	1.4E-6
Second Quarter	6.5E-5	7.6E-5
Third Quarter	1.9E-5	1.2E-5
Fourth Quarter	1.9E-5	2.0E-5
Annual	1.0E-4	1.1E-4

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

Although several cases were evaluated to determine the highest hypothetical dose from gaseous effluents to members of the public inside site boundary, the activity inside the site boundary with the highest dose potential is also shoreline fishing. The cases evaluated included traversing a public road within the site boundary, shoreline fishing (assuming fishing 60 hours per year), non-plant related training, car-pooling, and job interviews. The maximum on-site gaseous doses generated are shown in Table 11.

Table 11: Maximum Site Dose from Gaseous Effluents

	WHOLE BODY DOSE, mrem	ORGAN DOSE, mrem
First Quarter	4.3E-3	0.00E+00
Second Quarter	2.0E-3	1.7E-4
Third Quarter	1.4E-5	2.0E-5
Fourth Quarter	1.8E-5	1.3E-4
Annual	3.8E-3	3.9E-4

An average whole body dose to individual members of the public, at or beyond the site boundary is then determined by combining the dose from gaseous and liquid radiological effluents. The dose from gaseous radiological effluents is based upon the population that lives within 50 miles of PNPP (2,420,000 people). The dose from liquid radiological effluents is determined for the population that receives drinking water from intakes within 50 miles of PNPP (1,820,000 people). The results of this calculation are provided in Table 12.

Table 12: Average Individual Whole Body Dose

	Liquid Effluents (mrem)	Gaseous Effluents (mrem)
First Quarter	5.4E-9	8.3E-10
Second Quarter	4.5E-8	2.3E-10
Third Quarter	8.3E-8	7.4E-12
Fourth Quarter	5.0E-8	4.1E-13
Annual	1.8E-7	1.1E-9

ABNORMAL RELEASES

There was one abnormal radioactive release event during 2007. On November 5, 2007, routine analysis of the particulate filter from the Waste Abatement and Reclamation Facility (WARF) identified gross alpha presence. There was no work in progress at the WARF which could have produced alpha contamination. The alpha could potentially been due to radon daughters from naturally-occurring background radiation. Based on the ventilation flow, this would have equated to a release of 2.32E-09 curies. This was detailed under Condition Report 07-29979.

NON-COMPLIANCES

There was one non-compliance to the ODCM Controls requirements in 2007.

In March, 2006, the Perry Plant began supplemental monitoring of the underdrains system (plant system P72) as a response to tritium releases to groundwater at other stations. On March 28, 2006, tritium was discovered in the underdrain system at Perry. A root cause investigation was conducted and a comprehensive testing plan was established as part of the corrective actions.

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

The underdrain system discharges ultimately to the suction bay of the Emergency Service Water pumphouse, which discharges to the approved plant outfall. All identified tritium releases to date have been incorporated as part of this report as batch releases, based on which Emergency Service Water (ESW) pump was in service. In 2007, Perry continued to monitor and report tritium releases via the underdrains system by assessing the tritium in the two terminal underdrains before the ESW suction bay. By the end of the year, several months had elapsed with no tritium detected. The sampling plan was revised to relax the sampling frequency. There have been no indications of tritium release via liquid pathway from the plant from any source besides the underdrains.

In 2007, Perry also contracted with a hydrogeology consulting firm to more definitively evaluate groundwater movement in the plant. Initial groundwater data was obtained using plant piezometer tubes, which were installed during plant construction. Site characterization studies contained in the USAR were also utilized. Based on these evaluations, twelve groundwater monitoring wells were drilled around the station perimeter. These were first sampled in August, 2007. The samples were analyzed by an independent lab for tritium, as well as for the "hard-to-detect" nuclides, such as Sr89/90 and Fe55. None of the preceding were detected. No gamma activity was detected at any well location or depth. The maximum concentration of tritium detected was 261 pCi/liter.

Summary of Onsite Groundwater Samples							Are Any H-3 Analyses Greater Than The Pre Operational Mean For H-3 ?	NEI and FENOC Reporting Level For H-3 (pCi/l)	EPA Reporting Level For H-3 (pCi/l)
2007 H-3 Maximum (pCi/l)	2007 H-3 Minimum (pCi/l)	2007 H-3 Average (pCi/l)	Typical H-3 LLD (pCi/l)	Required H-3 LLD (pCi/l)	Pre-Operation (Developed) Mean For H-3 (pCi/l)				
1st Quarter:	N/A	N/A	N/A	<200	<2000	400	No	2000	20000
2nd Quarter:	N/A	N/A	N/A	<200	<2000	400	No	2000	20000
3rd Quarter:	261	<LLD	221	<200	<2000	400	No	2000	20000
4th Quarter:	N/A	N/A	N/A	<200	<2000	400	No	2000	20000

All On-site Ground Water Monitoring Program tritium (H-3) sample analyses from August 2007 were below the PNPP pre-operational mean value (400 pCi/l; this value was developed from onsite sampling). Therefore, no adverse effect to the onsite groundwater has been detected due to PNPP operation. Also, Since the industry proposed notification level (i.e.; 2,000 pCi/l for H-3) was not reached or exceeded, then notification to Federal, State & County Agencies were not required. For information, the industry proposed notification level was developed through the Nuclear Energy Institute (NEI) and adopted by FENOC.

Also, all On-site Ground Water Monitoring Program samples (as described above) were analyzed for Principal Gamma Emitters , and no positive indication of Licensed Radioactive Material (LRM) were identified in any of these analyses.

OFFSITE DOSE CALCULATION MANUAL CHANGES

During this reporting period, there were no (0) revisions to the Offsite Dose Calculation Manual.

PROCESS CONTROL PROGRAM CHANGES

During this reporting period, there was no (0) change to the Process Control Program.

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

RADIOLOGICAL ENVIRONMENTAL MONITORING

INTRODUCTION

The Radiological Environmental Monitoring Program (REMP) was established at PNPP for several reasons. First, it verifies the adequacy of plant design and operation to control radioactive materials and limit effluent releases. Second, it assesses the radiological impact, if any, that the plant has had on the surrounding environment. Third, it ensures compliance with regulatory guidelines. The REMP is conducted in accordance with the PNPP Operating License, Appendix B, Technical Specifications and the ODCM. The Nuclear Regulatory Commission (NRC) established the REMP requirements.

A wide variety of samples are collected as part of the PNPP REMP. The selection of sample types, sampling locations, and sample collection frequency are based on many things. Potential pathways for the transfer of radionuclides through the environment to humans, sample availability, local meteorology, population characteristics, land use and NRC requirements are all considered.

To ensure that the REMP data are meaningful and useful, detailed sampling methods and procedures are followed. This ensures that samples are collected in the same manner and from the same locations each time. All samples are packaged on site, then shipped to an independent vendor laboratory for analysis. The vendor laboratory analyzes the samples and reports results to the PNPP Chemistry Unit staff, the Lake County General Health District, and the State of Ohio Department of Health.

The REMP began in 1981 with 24 direct radiation monitoring locations, four sediment locations, and two fish sampling locations. In 1982, collections of air, water, milk, food products, and feed/silage were added. Vegetation, precipitation and soil were added in 1985. Although the NRC did not require these last three media, they were incorporated into the program to establish baseline data. In 1993, feed/silage sampling was dropped from the program, based on ten years worth of data. For the same reason, strontium analyses were deleted from the program in 1994, gross beta and tritium were deleted from precipitation analyses in 1995, and precipitation sampling was deleted entirely in 1996. In 1999, grass and soil sampling were dropped from the program.

SAMPLING LOCATIONS

REMP samples are collected at numerous locations, both on site and up to 22 miles away from the plant. Sampling locations are divided into two general categories: indicator and control. Indicator locations are those which would be most likely to display effects caused by plant operation. They are relatively close to the plant. Control locations are those which are considered to be unaffected by plant operation. Typically, they are a greater distance from the plant, in the least prevalent wind directions. Data obtained from the indicator locations are compared with data from the control locations. This comparison allows naturally occurring background radiation to be taken into account when evaluating any radiological impact PNPP may have had on the environment. Table 13, Figure 2, Figure 3 and Figure 4 identify the PNPP REMP sampling locations.

Many REMP samples are collected in addition to those required by the PNPP ODCM. The ODCM requirements for each sample type are discussed in more detail below. Sample types and locations required by the ODCM are shown in **Bold** in Table 13.

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

Table 13: REMP Sampling Locations ⁽¹⁾


Location #	Description	Miles	Direction	Media ⁽²⁾
1	Chapel Road	3.4	ENE	TLD, AIP
2	Kanda Garden	1.9	ENE	Food Products
3	Meteorological Tower	1.0	SE	TLD, AIP
4	Site Boundary	0.7	S	TLD, AIP
5	Quincy Substation	0.6	SW	TLD, Air
6	Concord Service Center	11.0	SSW	TLD, AIP
7	Site Boundary	0.6	NE	TLD, AIP
8	Site Boundary	0.8	E	TLD
9	Site Boundary	0.7	ESE	TLD
10	Site Boundary	0.8	SSE	TLD
11	Parmly Rd.	0.6	SSW	TLD
12	Site Boundary	0.6	WSW	TLD
13	Madison-on-the-Lake	4.7	ENE	TLD
14	Hubbard Rd.	4.9	E	TLD
15	Eagle St. Substation	5.1	ESE	TLD
16	Eubank Garden.	0.8	S	Food Products
20	Rainbow Farms	1.9	E	Food Products
21	Hardy Rd.	5.1	WSW	TLD
22	Corfias Farm (goat)	4.9	S	Milk
23	High St. Substation	7.9	WSW	TLD
24	St. Clair Ave.	15.1	SW	TLD
25	Offshore - PNPP discharge	0.6	NNW	Sediment, Fish
26	Offshore - Redbird	4.2	ENE	Sediment
27	Offshore - Fairport Harbor	7.9	WSW	Sediment
28	CEI Ashtabula Plant Intake	22.0	ENE	Water
29	River Rd.	4.3	SSE	TLD
30	Lane Rd.	4.8	SSW	TLD
31	Wood and River Rd.	4.8	SE	TLD
32	Offshore - Mentor	15.8	WSW	Sediment, Fish
33	River Rd.	4.5	S	TLD
34	PNPP Intake	0.7	NW	Water
35	Site Boundary	0.6	E	TLD, AIP
36	Lake County Water Plant	3.9	WSW	TLD, Water
37	Gerlica Farm	1.5	ENE	Food Products
41	Tuttle Farm (goat)	5.8	SSE	Milk
51	Rettger Milk Farm (cow)	9.6	S	Milk
53	Neff Perkins	0.5	WSW	TLD
54	Hale Rd. School	4.6	SW	TLD
55	Center Rd.	2.5	S	TLD
56	Madison High School	4.0	ESE	TLD
58	Antioch Rd.	0.8	ENE	TLD
59	Lake Shoreline at Green Rd.	4.0	ENE	Water
60	Lake Shoreline at Perry Park	1.0	WSW	Water
61	Keller Milk Farm (goat)	7.4	SE	Milk
63	Minor Stream Mouth	0.08	NNE	Sediment
64	Northwest Drain Mouth	0.09	NW	Sediment
65	Major Stream Mouth	0.18	W	Sediment
70	H&H Farm Stand	16.2	SSW	Food Products

(1) chronologically missing location numbers denote deleted or retired sampling locations.

(2) AIP = Air, Iodine and Particulate
 Veg = Vegetation
 TLD = Thermoluminescent Dosimeter


ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

Figure 2: REMP Sampling Locations Within Two Miles of Plant Site



ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

Figure 3: REMP Sampling Locations Between Two and Eight Miles of Plant Site






Figure 4: REMP Sampling Locations Greater Than Eight Miles from the Plant Site
Radiological Environmental Monitoring Page 25

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

SAMPLE ANALYSIS

When environmental samples are analyzed for radioactivity, several types of measurements are performed to provide information about the types of radiation and radionuclides present. The major analyses that are performed are discussed below.

Gross beta activity measures the total amount of beta-emitting radioactivity present in a sample, and acts as a tool to identify samples that may require further analysis. Beta radiation may be released by many different radionuclides. Since beta decay results in a continuous energy spectrum rather than the discrete energy levels, or "peaks", associated with gamma radiation, identification of specific beta-emitting nuclides is much more difficult. Therefore, gross beta activity only indicates whether the sample contains normal, or abnormal amounts of beta-emitting radioactivity; it does not specifically identify the radionuclides present.

Gamma spectral analysis provides more specific information than does the analysis for gross beta activity. Gamma spectral analysis identifies each radionuclide, and the amount of radioactivity, present in the sample emitting gamma radiation. Each radionuclide has a very specific "fingerprint" that allows for accurate identification and quantification.

Iodine activity analysis measures the amount of radioactive iodine present in a sample. Some media (for example, air sample charcoal cartridges) are analyzed directly by gamma spectral analysis. With other media (for example, milk), the radioiodines are extracted by chemical separation before being analyzed by gamma spectral analysis.

Tritium activity analysis measures the amount of the radionuclide tritium (H-3) present in a sample. Tritium is an isotope of hydrogen that emits low-energy beta particles. Tritium occurs naturally and is also man-made.

Gamma doses received by Thermoluminescent Dosimeters (TLD) while in the field are determined by a special laboratory procedure. Thermoluminescence is a process by which ionizing radiation interacts with the sensitive phosphor material in the TLD. Energy is trapped in the TLD material and can be stored for months or years. This capability provides an excellent method to measure the dose received over long periods of time. The amount of energy that was stored in the TLD as a result of interaction with radiation is released by a controlled heating process and measured in a calibrated reading system. As the TLD is heated, the phosphor releases the stored energy as light. The amount of light is directly proportional to the amount of radiation to which the TLD was exposed. The reading process also zeroes the TLD and prepares it for reuse. Table 14 provides a list of the analyses performed on environmental samples collected for the PNPP REMP in 2007.

Sample results are often reported as less than the lower limit of detection (< LLD), which is defined as the smallest amount of radioactive material that will show a positive result for which there can be confidence that radioactivity is present. This statistical parameter is used as a measure of the sensitivity of a sample analysis. When a measurement is reported as < LLD, it means that no radioactivity was detected at a value above, or equal to the appropriate ODCM table value. The NRC has established LLD values for REMP sample analyses. The vendor laboratory for REMP sample analyses complied with those values in 2007.

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

Table 14: REMP Sample Analyses

TYPE	SAMPLE	FREQUENCY	ANALYSIS
Atmospheric Monitoring	Airborne Particulates	Weekly, Quarterly	Gross Beta Activity Gamma Spectral Analysis
	Airborne Radioiodine	Weekly	Iodine-131
Terrestrial Monitoring	Milk	Bi-Monthly	Gamma Spectral Analysis Iodine-131
	Food Products	Monthly	Gamma Spectral Analysis
	Vegetation	As Required	Gamma Spectral Analysis
Aquatic Monitoring	Water	Monthly	Gross Beta Activity, Gamma Spectral Analysis Tritium Activity
		Quarterly	
	Fish	Annually	Gamma Spectral Analysis
	Sediment	Biannually	Gamma Spectral Analysis
Direct Radiation Monitoring	TLD	Quarterly	Gamma Dose
		Annually	Gamma Dose

2007 SAMPLING PROGRAM

The contribution of radionuclides to the environment resulting from PNPP operation is assessed by comparing results from the 2007 program with pre-operational data (i.e., data from before 1986), operational data from previous years, and control location data. The results for each sample type are discussed below and compared to historical data to determine if there are any observable trends. All results are expressed as concentrations. Refer to Appendix B, 2007 REMP Data Summary Reports for a detailed listing of these results. The NRC requires special reporting whenever sample analysis results exceed set limits. No values exceeded these reporting levels in 2007.

Program Changes

Due to other commitments, milk location 22, the Corfias Farm, did not participate during the 2007 milking season. It is hoped that they will participate in 2008.

Missed Samples

On occasion, samples cannot be collected. This can be due to a variety of events, including equipment malfunction, animal husbandry practices, or lost shipments. Events may also occur which prevent a sample from being collected in the normal way, or prevent a complete sample from being collected. The drying period for goats is an annual occurrence, since unlike cows, goats cannot produce milk year-round. Food products are weather dependent and are susceptible to excessive spring rains or summer drought that can significantly impact the garden harvest. Shoreline lake water samples are collected by grab sample utilizing a container and scoop. During the winter months the shoreline can become inaccessible due to ice and snow buildup, preventing the safe collection of these samples. Shoreline sediment samples are collected with spoon and container. On occasion, the accessibility of these locations and sample collection may be impacted due to high lake levels, shifting lake bottom sand or bluff erosion and shoreline collapse. Table 15 provides information on samples missed during 2007.

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

Table 15: Missed REMP Samples in 2007

MEDIA	LOCATION	DATE	REASON
Air Samples	6	4/11/07	Sampler not re-started after collection
	35	5/2/07, 5/9/07	Electrical fire
Food Products	All	April, May, June, Nov. 2007	Insufficient growth in spring due to excessive rain followed by summer drought. Die-off/frost damage in the fall.
	20	July	Same as above reason
Lake Water	59	Jan., Feb. and March 2007	Sample unavailable due to frozen shoreline
	60	Jan., Feb. and March 2007	Sample unavailable due to frozen shoreline
Milk	22	Year 2007	Not participating
	41, 61	Jan, Feb, March, Apr., May, June, Dec. 2007	Drying period for goats/sample availability
Sediment	63	June and October 2007	Bluff collapse, location inaccessible

Atmospheric Monitoring

Air

Air sampling is conducted to detect any increase in the concentration of airborne radionuclides. The PNPP ODCM requires five locations (four indicator and one control). Air sampling pumps are used to draw continuous samples at a rate of approximately two cubic feet per minute. The air is drawn through glass fiber filters (to collect particulate material) and a charcoal cartridge (to adsorb iodine). The samples are collected on a weekly basis, 52 weeks a year, from each of seven air sampling stations. Six (6) of these locations are within four miles of the plant site; the seventh is used as a control location and is eleven miles from PNPP.

On occasion, air sample locations can experience power losses associated with storms and/or malfunctioning equipment. For 2007 three samples were missed, one due to human error and two due to malfunctioning equipment. On April 11, 2007, sample location #6 was found not running during routine sample collection. The investigation revealed that although the sampler was operational no elapsed time or volume had been recorded. It was determined that the sampler had not been restarted after change-out the week before. On May 2, 2007 sample location #35 lost power due to an electrical short and subsequent fire. The investigation revealed that a mouse nest had been built inside the pole mounted breaker box which shorted and caught fire. Extensive repairs were completed and the sampler returned to service. Both of these events were reviewed with department personnel for heightened human performance.

Air samples are analyzed weekly for gross beta activity and radioiodine activity. The air samples are also analyzed by gamma spectral analysis quarterly. A total of 362 air particulate and 362 air radioiodine samples were collected and analyzed in 2007.

Gross beta activity was detected in all air samples and ranged up to 0.05 pCi/m³. The average gross beta activity at both indicator and control locations was 0.02 pCi/m³ for 2007. Historically, the


ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

concentration of gross beta in air has been essentially identical at indicator and control locations. Figure 5 reflects the average gross beta activity for 2007 and the previous years.

Except for naturally occurring beryllium-7, no radionuclides were identified in the gamma spectral analysis above the LLD values. Iodine-131 was not detected in any sample above the LLD of 0.05 pCi/m³.

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

Figure 5: Annual Average Gross Beta Activity, in Air



Terrestrial Monitoring

Collecting and analyzing samples of milk, food products and vegetation provides data to assess the build-up of radionuclides that may be ingested by humans. The historical data from soil and vegetation samples provides information on the atmospheric radionuclide deposition. The PNPP ODCM requires neither vegetation nor soil samples.

Milk

Samples of milk are collected once each month from November through March, and twice each month from April through October. Sampling is increased during the summer because animals usually feed outside on pasture and not on stored feed. For 2007 the PNPP REMP included three (3) milk locations located 5.8, 7.4 and 9.6 miles away from the plant. Location 22, 4.9 miles away from the plant in the South sector did not participate due to time restraints and other commitments. It is hoped that they will return for the 2008 season. Since the majority of milk sampling locations do not meet the requirements of the ODCM (no milk-producing animals located within the required areas), food product sampling (discussed below) was performed. Milk is collected from the available locations, even though they do not meet the ODCM requirements. If new locations that meet the ODCM requirements are identified in the future, they will be added to the program.

Milk samples are analyzed by gamma spectral analysis for radioiodines and other radionuclides. A total of forty two (42) milk samples were collected in 2007. Iodine was not detected above the LLD of 0.75 pCi/L in any of the samples. The concentrations of all radionuclides, except naturally occurring potassium-40, were below LLDs in all samples collected.

Food Products

Food products can provide a direct pathway to humans by ingestion. They can absorb radionuclides from atmospheric deposition on soil or from irrigation water drawn from a lake or pond receiving airborne or liquid effluents. Also, radionuclides in the soil may be absorbed by the roots of the plants and become incorporated into the edible portions. Because there is not a sufficient number of dependable milk sampling locations, the PNPP REMP is required to include two food product indicator locations and one control location. Food products are collected monthly during the growing season from five gardens in the vicinity of PNPP. The control location for food products is 16.2 miles from PNPP.

A total of fifty (50) food product samples were collected and analyzed by gamma spectral analysis in 2007. Limiting factors for the 2007 growing season included heavy spring rains followed by a

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

summer drought, accounting for the missed samples referenced in Table 15. Five (5) food products were collected which included: beet greens, collard greens, turnip greens, kale and swiss chard. Beryllium-7 and potassium-40, naturally-occurring radionuclides, were found in several samples, as expected. No other radionuclides were detected above the required LLDs.

Aquatic Monitoring

Radionuclides may be present in Lake Erie from many sources other than the PNPP. These sources include atmospheric deposition, run-off/soil erosion, and releases of radioactivity in liquid effluents from hospitals, universities or other industrial facilities. These sources provide two forms of potential radiation exposure, external and internal. External exposure can occur from contact with water or shoreline sediments, while internal exposure can occur from either direct ingestion of radionuclides or the transfer of radionuclides through the aquatic food chain. Direct ingestion can occur from drinking the water, while the transfer via the aquatic food chain occurs from the eventual consumption of aquatic organisms, such as fish. To monitor these pathways, PNPP samples water, shoreline sediments, and fish.


Water

Water is sampled from five locations along Lake Erie in the vicinity of the PNPP as required by the PNPP ODCM. Samples from three locations are collected using composite sample pumps. The pumps are designed to collect water at regular intervals and composite it in a sample container. The containers are emptied monthly and the samples shipped to the laboratory for analysis. Samples from two locations are collected weekly and combined. Each month the combined samples for each location are shipped for analysis.

Fifty-two (52) water samples were collected and analyzed for gross beta activity and gamma spectral analysis in 2007. From these monthly samples, a quarterly composite sample was obtained and analyzed for tritium activity. Refer to Table 15 for an explanation of any missed samples.

Gross beta activity was detected in three (3) of the fifty-two (52) samples collected. For 2007, the detectable gross beta activity was 3.68 pCi/L vs. the lab LLD value of 3.00 pCi/L. Refer to Figure 6 for the annual average gross beta activity for both indicator and control locations. The significant difference between the pre-1988 data and post-1988 data has been attributed to a change in vendor laboratories in 1987/1988. A comprehensive explanation for the observed difference is provided in the 1988 Annual Environmental Operating Report.

Figure 6: Annual Average Gross Beta Activity, in Water



There were no radionuclides detected by gamma spectral analysis above the LLD. Tritium was not detected above the LLD value in any of the eighteen (18) samples analyzed. These results are well

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

within the range of those measured in previous years, which have ranged from below the LLD to 2,200 pCi/L.

Sediment


Sampling lake bottom sediments can provide an indication of the accumulation of particulate radionuclides which may lead to internal exposure to humans through the ingestion of fish, the re-suspension into drinking water, or as an external radiation source to fishermen and swimmers from shoreline exposure. Although the PNPP ODCM requires only one location, sediment is sampled twice each year from seven (7) locations. Two (2) of the sampling locations are also fish sampling locations. Sediment samples from offshore are collected using a hand dredge. Shoreline samples are collected using a scoop. Twelve (12) sediment samples were collected in 2007 and analyzed by gamma spectrometry. Beginning in 2006, access to sample location 63 was prevented due to ongoing shoreline erosion which resulted in a bluff collapse. No samples were collected for this location. Shoreline erosion continues to prevent safe access. The predominant radionuclide detected by gamma spectral analysis was naturally-occurring potassium-40. Potassium-40 has been detected in all samples, since the program began in 1981.

Cesium-137 activity was detected in five (5) of the twelve (12) samples collected and ranged from 147.68 pCi/kg to 844.36 pCi/kg. The annual average cesium-137 activity was 200.74 pCi/kg at the indicator locations and 828.13 pCi/kg at the control location. The average cesium-137 radioactivity for all locations was 451.70 pCi/kg and is within the maximum value of 864 pCi/kg established in 1981. Year-to-year variations in lake bottom sediment sample activity is expected and beyond the control of PNPP. For example, cesium-137 activity variations (refer to Figure 7) in the control locations from year-to-year may be contributed to:

1. The movement of sediment on the lake bottom due to wave action and currents.
2. Sampling in nearly the same location approximately 4½ miles off-shore, even with GPS, is extremely difficult.

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

Figure 7: Annual Average Cesium-137 Concentration in Sediment



In 1999, a sediment sample from location #64 (shoreline discharge point of the Northwest Drain Impoundment) was found to contain trace levels of cobalt-60. Ten (10) additional sample locations were established upstream from location #64 and within the Impoundment to identify the boundary of the cobalt-60 activity and to support supplemental monitoring activities. In recent years, the shoreline adjacent to the impoundment has experienced extensive bluff erosion and preventing access and sample collection for locations 64-4 and 64-5. For 2007, sample results for cobalt-60 from eight (8) locations confirm that no activity was identified at the discharge point (Location #64), and continues to remain within the Northwest Drain Impoundment with an activity range of <5.1 pCi/kg to 185 +/- 52 pCi/kg (Refer to Table 16). For informational purposes, Cesium-137 activity within the impoundment is reflected in Table 17.

Table 16: Northwest Drain Impoundment Cobalt-60 Activity, pCi/kg (dry)

Location	05/22/07	05/24/07	09/05/07	10/04/07
64		<17.2	<5.1	
64-1	<19.2			<18.9
64-2	<31.8			<21.1
64-3	<24.5			<15.6
64-4	*			*
64-5	*			*
64-6	115 +/- 33			<26.5
64-7	146 +/- 55			119 +/- 30
64-8	34 +/- 15			<18.5
64-9	185 +/- 52			123 +/- 30
64-10	149 +/- 50			155 +/- 29

* No sample available or insufficient sample for analysis

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

Table 17: Northwest Drain Impoundment Cesium-137 Activity, pCi/kg (dry)

Location	05/22/07	05/24/07	09/05/07	10/04/07
64		<18.3	<12.5	
64-1	<27.8			<28.1
64-2	522 +/- 67			721 +/- 58
64-3	83 +/- 33			408 +/- 36
64-4	*			*
64-5	*			*
64-6	1950 +/- 101			464 +/- 58
64-7	1935 +/- 113			2100 +/- 83
64-8	727 +/- 49			518 +/- 38
64-9	2478 +/- 127			1986 +/- 89
64-10	2094 +/- 97			1591 +/- 77

* No sample available or insufficient sample for analysis

Fish

Fish are analyzed primarily to quantify the dietary radionuclide intake by humans, and secondarily to serve as indicators of radioactivity in the aquatic ecosystem. Fish are collected from two locations, annually during the fishing season as required by the ODCM. An important sport or commercial species is targeted, and only the fillets are sent to the laboratory for analysis. In 2007, fish sampling was performed for PNPP by a local licensed sport fisherman.

Two (2) fish samples representing yellow perch were collected and analyzed by gamma spectral analysis in 2007. As expected, naturally occurring potassium-40 was found in all samples. No other radionuclides were detected above the LLD.

Direct Radiation Monitoring

Thermoluminescent Dosimeter (TLD)


Environmental radiation is measured directly at twenty-eight locations around the PNPP site, two of which are control locations. The locations are positioned in two rings around the plant as well as at the site boundary. The inner ring is within a one-mile radius of the plant site; the outer ring is four to five miles from the plant. The control locations are over ten miles from the plant in the two least prevalent wind directions. Each location is equipped with three TLDs, two of which are changed quarterly and one is changed annually.

A total of 252 TLDs were collected and analyzed in 2007. This includes 224 collected on a quarterly basis and twenty-eight (28) collected annually. Annual TLDs are not required per the ODCM and are used for supplemental data only.

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

For 2007, the annual average dose for all indicator locations was 52.70 mrem, and 49.63 mrem for the control locations. The indicator annual dose is believed to be influenced by location #36 (Figure 3) which has been consistently higher in dose than TLDs positioned closer to the plant (Figure 2). Referring to Figure 8, the average quarterly dose for all indicator locations was 13.06 mrem, and 12.64 mrem for all control locations. Please refer to Appendix B, 2007 REMP Detailed Data Report for all TLD results. Prior to 1988, the TLD results were higher due to a change in the vendor laboratory services. A comprehensive explanation of this difference was provided in the 1988 Annual Environmental Operating Report.

Figure 8: Average Quarterly TLD Dose



Conclusion

Sediment samples continue to confirm cobalt-60 in the northwest drain impoundment. Additional monitoring is being performed to monitor this location. An environmental evaluation determined that there would be less impact upon the environment by leaving this material in place. Atmospheric monitoring results were consistent with past results. The prevalent radionuclide in air was beryllium-7, which is naturally occurring. Naturally occurring potassium-40 was detected in all terrestrial samples, as expected.

Finally, direct radiation measurements are consistent with past data.

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

INTER-LABORATORY CROSS-CHECK COMPARISON PROGRAM

Introduction

The purpose of the Inter-laboratory Cross-Check Comparison Program (ICCCP) is to provide an independent check on the vendor laboratory's analytical procedures. Samples with a known concentration of specific radionuclides are provided to the vendor laboratory. The vendor laboratory measures and reports the concentration of specified radionuclides. The known values are then compared to the vendor results. Results consistently outside established acceptance criteria indicate a need to check instruments or procedures. Regulatory Guide 4.15 specifically required that contractor laboratories that performed environmental measurement participate in the EPA's Environmental Radioactivity Laboratory Inter-Comparison Studies Program, or an equivalent program.

The EPA's program is no longer funded or offered. The reason that the EPA program was referenced in the regulatory guide is that the EPA standards were traceable to National Bureau of Standards (now known as National Institute Standard Technology). In response to this problem, Teledyne (PNPP vendor lab) incorporated a program offered by Environmental Resource Associates (ERA Company), which covered the same analyses in the same matrix at the same frequency as the EPA program. The ERA Company has received NIST accreditation for its program, as an equivalent program. In addition to comparison cross checks performed with the ERA Company, the vendor laboratory routinely monitors the quality of their analyses by:

- ◆ Analyzing "spiked" samples (samples with a specific quantity of radioactive material present in them) and
- ◆ Participating in the Department of Energy's Mixed Analyte Performance Program (MAPEP).

Through 2004, Teledyne also participated in the Environmental Measurements Laboratory Quality Assessment Program (EML). This program was discontinued in 2005.

Conclusion

Appendix A, 2007 Inter-Laboratory Cross-Check Comparison Program Results, includes results from both the above referenced programs and the ERA Company cross-check program.

- 1) The sample results for Table A-1, Environmental Resource Associates (ERA) Interlaboratory Comparison Crosscheck Program and Table A-2, Vendor Laboratory's Cross-Check testing of Thermoluminescent Dosimetry were found to be within their expected control limits.
- 2) Table A-3, In-House "Spike" Samples: Sample SPW-2909 initially failed its Fe-55 analysis. The recounted sample (12557 +/- 355) was found to be within acceptable program criteria.
- 3) Table A-4, In-House "Blank" Samples identified sample SPMI-2850 to be outside the program acceptance criteria. Levels of Sr-90 remain in the environment and concentrations of (1-5 pCi/l) found in milk is not unusual.
- 4) Table A-5, In-House "Duplicate" Samples were all within their control limits.
- 5) Table A-6, Department of Energy MAPEP: Analysis of water sample STW-1111 (Am-241) initially failed. Re-analysis was within control limits. Initial laboratory result of soil sample STSO-1112 (Am-241) was outside of the control limits. The sample was recounted on a lower background detector to achieve a result within the control limits.

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

- 6) Table A-7, Interlaboratory Comparison Crosscheck Program Environmental Resource Associates (ERA) laboratory result for air filter sample STAP-1117 for Cs-137 analysis initially failed. A composite filter geometry vs. single filter was used to achieve the result of 305.8 +/- 6.0 pCi/filter

LAND USE CENSUS

Introduction

Each year a land use census, which is required by Section 3/4.12.2 of the PNPP ODCM, is conducted to identify the locations of the nearest milk animal, garden (of greater than 500 square feet), and residence in each of the meteorological sectors that is over land. Information gathered during the Land Use Census is used for off-site dose assessment and to update sampling locations for the Radiological Environmental Monitoring Program. The census is conducted by traveling all roads within a five-mile radius of the plant site, and recording and mapping the location of the nearest resident, milk animal, and vegetable garden. The 2007 Land Use Census, which was conducted July 18th, 19th and 20th provided the garden, residence and milk animal locations tabulated in Tables 18, 19 and 20 and depicted in Figure 9. Note that the W, WNW, NNW, NW, N, and NNE sectors extend over Lake Erie, and therefore, are not included in the survey.

Discussions and Results

In general, the predominant land use within the census area continues to be rural/agricultural. In recent years however, it has been noted that tracts of land once used for farming are now being developed as mini-industrial parks and residential housing tracts. This is reflected in the loss of available milking animals within a five mile radius of PNPP to support the Radiological Environmental Monitoring Program (REMP). The 2007 Land Use Survey used the 1999 survey map produced by the Commercial Survey Co. of Cleveland. GPS units are also used for more accurate location identification.

Table 18 identifies the nearest residences, by sector, to the PNPP. The table is updated annually to reflect any changes identified during the annual Land Use Census. For 2007, there was one change noted for the "nearest residence". The nearest residence in the SSE sector was demolished. There was no change in the distance from PNPP for the new location identified below.

Table 18: Nearest Residence, By Sector

SECTOR	LOCATION ADDRESS	MILES FROM PNPP	X/Q VALUE, sec/m ³	MAP LOCATOR NUMBER
NE	4384 Lockwood	0.7	2.66E-06	1
ENE	4412 Lockwood	0.7	1.96E-06	2
E	2626 Antioch	1.1	6.77E-07	3
ESE	2836 Antioch	1.0	8.57E-07	4
SE	4537 North Ridge	1.3	3.44E-07	5
SSE	4225 Redmill Valley Rd.	1.1	5.52E-06	6
S	3119 Parmly	0.9	2.25E-06	7
SSW	3121 Center	1.0	9.49E-07	8
SW	3440 Clark	1.3	4.42E-07	9
WSW	3462 Parmly	1.1	8.67E-07	10




Figure 9: Land Use Census Map

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

Table 19 identifies the nearest milking animal by sector, to the PNPP. During the 2007 Land Use Census, no changes were identified regarding the nearest milk animal. The milking animal identified in the S sector was a participant in the REMP program beginning in June 2006. For 2007, the animal's owner did not participate due to time constraints but hopes to rejoin in 2008.

Table 19: Nearest Milk Animal, By Sector

SECTOR	LOCATION ADDRESS	MILES FROM PNPP	MAP LOCATOR NUMBER
S	5245 Blair Rd.	4.9	22

There were no changes in the nearest gardens during this year's census. Changes can include either the loss of the previous year's garden or the addition of a new garden identified in this year's census. Table 20 lists the nearest gardens occupying at least 500 square feet identified during the 2007 Land Use Census.

Table 20: Nearest Garden, By Sector

SECTOR	LOCATION ADDRESS	MILES FROM PNPP	D/Q VALUE, m ²	MAP LOCATOR NUMBER
NE	2330 Lakehurst	0.9	8.91E-09	11
ENE	4630 Lockwood	1.1	4.77E-09	12
E	2626 Antioch	1.1	5.29E-09	3
ESE	2836 Antioch	1.0	3.96E-09	4
SE	3040 Antioch	1.3	1.01E-09	15
SSE	3288 Call Rd.	1.4	2.04E-09	16
S	3964 North Ridge	1.4	2.73E-09	17
SSW	3121 Center	1.0	4.66E-09	8
SW	3440 Clark	1.3	1.95E-09	9
WSW	2975 Perry Park	1.3	2.31E-09	20

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

CLAM/MUSSEL MONITORING

INTRODUCTION

Sampling for macro-invertebrates (clams and mussels) has been conducted in Lake Erie in the vicinity of PNPP, since 1971. The clam/mussel program currently focuses on two species: *Corbicula fluminea* (Asiatic clam) and *Dreissena polymorpha* (zebra mussel).

CORBICULA PROGRAM

Monitoring specifically for *Corbicula* was initiated in response to a NRC bulletin and concerns of the Atomic Safety and Licensing Board. The 2007 monitoring was done as part of the Environmental Protection Plan (Operating License, Appendix B). The program consists of visually inspecting the raw water systems, when they are opened for maintenance. The purpose of this program is to detect *Corbicula*, should it appear at PNPP.

No *Corbicula* have been found in any sample collected from PNPP. Two *Corbicula* were found in a sample collected from the Eastlake plant in June, 1987. No *Corbicula* have been found in any other sample collected since that time. A more detailed program history can be found in the 1986 and 1987 PNPP Annual Environmental Operating Reports.

Monitoring

In 2007, samples were collected from the Service Water (SW), Emergency Service Water (ESW), Circulating Water and Fire Water Systems at PNPP and examined for Asiatic clam shells and fragments. Samples were either collected by hand scoop or scraper. In addition to sample collections, plant components that use raw water are inspected when opened for maintenance or repair. Sample collection/inspection dates are listed in Table 21.

Table 21: 2007 Corbicula Monitoring

DATE	SAMPLE LOCATION	DATE	SAMPLE LOCATION
4/11/07	Emergency Service Water B pump strainer	10/26/07	P54 D5511 fire hydrant
4/15/07	N61 1B0002B Aux condenser		
4/20/07	N61 Aux condenser		
5/4/07	N61 1B0001B Main IP condenser		
5/17/07	Lube oil cooler 1N34B0001B		
6/21/07	Lube oil cooler 1N34B0001A		
7/31/07	Lube oil cooler 1N34B0001B		
8/4/07	Lube oil cooler 1N34B0001A		
8/17/07	Lube oil cooler 1N34B0001A		
8/28/07	1N34B0001B		
9/14/07	1N34B0001A		

Conclusions

The sample collected in June, 1987, was the only indication of *Corbicula* in the vicinity of PNPP. Although the presence of *Corbicula* was detected at the Eastlake Power Plant, it has not been demonstrated that their presence has created any operational problems there, or at PNPP. As in the past, the 2007 monitoring program did not identify *Corbicula* in any sample collected.

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

Dreissena Program

Dreissena, or Zebra mussels were first discovered at PNPP in September, 1988. The initial collection of 19 mussels was made as part of the Corbicula monitoring program. The Dreissena monitoring program began in 1989, with monitoring and testing. The current control program was designed and implemented in 1990.

Monitoring

In addition to visually inspecting the plant's raw water systems when they are opened for maintenance or repair, monitoring methods include the use of commercial divers and side-stream monitors. Commercial divers monitor mussel infestation during the inspection of forebays, basins, and the intake and discharge structures. Divers have also been used to take underwater videotapes of the water basins and intake tunnel. Side-stream monitors are flow-through containers that receive water diverted from plant systems and are set up at two in-plant locations during the mussel season. The side-stream monitors are fitted with slides and inspected for veliger settlement and growth of adult mussels.

Treatment

Chemicals used for mussel control in 2007 included chlorine and a commercial molluscicide. The chlorine is intermittently injected into the plant service water, emergency service water, and circulating water systems by metering sodium hypochlorite into each system's influent. Sodium bisulfite is added at the plant discharge structure for dechlorination prior to return into Lake Erie.

The use of a commercial molluscicide has been approved by the Ohio Environmental Protection Agency (OEPA). The chemical selected for use at the PNPP in 2007 was alkyl-dimethyl-benzyl-ammonium chloride. Treatment was applied on September 13, 2007. The active ingredients were detoxified by adsorption using bentonite clay, prior to discharge into Lake Erie.

Results

The effectiveness of the intermittent chlorination treatment has been determined in several ways. First, visual inspections of raw water system components are conducted when systems are open during maintenance or repair. In addition, settlement monitors were inspected for new settlement. No live settlement has been found in any plant component to date.

The effectiveness of the application of the commercial molluscicide was measured by observing mortality of mussels placed in a flow-through container placed in plant service water and subjected to the chemical treatment. The observed mortality rate utilizing the flow-through container for 2007 was 99 %. To date, PNPP has had no significant problems related to zebra mussels.

CONCLUSIONS

Perry Nuclear Power Plant has taken the approach that the best method for avoiding problems with zebra mussels is preventive treatment of plant water systems. The current program of monitoring and chemical treatment will be continued to minimize the possibility that PNPP will experience future problems due to zebra mussels.

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

HERBICIDE APPLICATIONS

Herbicides are used sparingly on the PNPP site. A request must be made to, and approved by the PNPP Chemistry Unit prior to spraying to ensure that only approved chemicals are used, and only in approved areas.

In 2007 two (2) general and one (1) specific herbicide requests were initiated for chemical applications. Each application was in compliance with the Ohio Environmental Protection Agency's rules and regulations. There were no adverse environmental impacts observed during weekly site environmental inspections as a result of these applications. The herbicides approved for use in the Owner-Controlled Area are Round-Up, Krovar, and Oust. For each application, the type of weed to be treated dictated the herbicide and concentration to be used. Table 22 provides detailed documentation for each application in 2007. The quantity represents the amount of herbicide applied, after any dilution.

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

Table 22: 2007 Herbicide Applications

DATE APPLIED	LOCATION	AMOUNT (GAL.)	CHEMICAL NAME
3/30/07	Transmission Yard	64.2 lbs	Krovar
3/30/07	Transmission Yard	0.38	Oust
5/26/07	Protected Area Perimeter	2.34	Round-up
5/29/07	Protected Area Perimeter & Protected Area NE, NW, SE, SW, Quadrant & Gravel Area	0.39	Round-up
6/4/07	Admin., Training, WHSE, IPC, P&R Buildings and All Owner Control & Gravel Areas	0.47	Round-up
6/8/07	Admin., Training, WHSE, IPC P&R Buildings	2.11	Round-up
6/11/07	Transmission Yard, Waste Accumulation Facility, Barrel Salvage Area	0.51	Round-up
6/25/07	Protected Area NW Quadrant, Owner Control Area, Transmission yard	0.20	Round-up
6/25/07	Admin., Training, WHSE, IPC P&R Buildings and OCA landscape beds/gravel Areas	0.11	Round-up
7/2/07	Protected Area Perimeter & Protected Area NE,NW,SE,SW, Quadrant	4.69	Round-up
7/23/07	Protected Area NE Quadrant, Protected Area Perimeter , Vehicle Trap & Transmission Yard	0.78	Round-up
7/25/07	WHSE, P&R Building, Hydrogen/Gravel Area and Roadways	0.94	Round-up
8/13/07	Transmission yard	1.17	Round-up
8/22/07	Admin., Training, WHSE, IPC P&R Buildings and Landscape beds/gravel Areas	0.78	Round-up
8/22/07	Protected Area NE, NW, SE, SW, Quadrant	0.31	Round-up
8/24/07	Protected Area NE, NW, SE, SW, Quadrant	2.11	Round-up

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

Table 22 continued: 2007 Herbicide Applications

APPLICATION DATE	LOCATION	AMOUNT (GAL)	CHEMICAL NAME
9/13/07	Admin., Training, WHSE, IPC Buildings and Gravel and Roadway Area	3.51	Round-up
9/17/07	Admin, WHSE, IPC Buildings & Gravel and Roadway Area	1.17	Round-up
9/24/07	Admin., WHSE, IPC Buildings and Gravel and Roadway Area	0.47	Round-up
9/13/07	Admin., Training, WHSE, IPC Buildings and Gravel and Roadway Area	3.51	Round-up

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

SPECIAL REPORTS

NON-COMPLIANCES

NPDES Permit

The National Pollutant Discharge Elimination System (NPDES) permit is issued by the Ohio Environmental Protection Agency (OEPA). It establishes monitoring requirements and limits for discharges from the PNPP. It also specifies the locations from which the plant is allowed to discharge.

One special report was submitted in 2007:

- On September 20, 2007, the Perry Plant reported a noncompliance to the OEPA due to exceeding the discharge limitation for pH at the Major Stream diversion (also referred to as "Red Mill Run"). Cloudy water was discovered in "Major Stream" diversion at approximately 1525 hours on September 19, 2007. The pH of the stream was 11.2 standard units (SU) at 1650 hours on September 19, 2007 with white powdery deposition on the stream bed. At 1000 hours on September 20, 2007, a sample taken for pH indicated 8.48 SU. The high pH was a result of maintenance activities that pumped approximately 25,000 gallons of accumulated ground and rain water from the Unit 2 Turbine Power Complex basement, with a pH level above the permit limit to the Major Stream diversion. The procedure that allowed this pumping has been revised and no longer permits the pumping of water unless NPDES permit limitations are met.

Environmental Protection Plan

The Environmental Protection Plan (EPP), which is Appendix B of the PNPP Operating License, requires a non-radiological environmental monitoring and reporting program be established at the PNPP. There were no instances of an EPP non-compliance identified in 2007.

UNREVIEWED ENVIRONMENTAL QUESTIONS

All proposed changes to the PNPP design or operation, as well as tests or experiments, must be evaluated for potential environmental impacts in accordance with the EPP and administrative quality assurance procedures. In 2007 there were no proposed changes to the facility or programs that if performed, could have resulted in an adverse environmental impact. Therefore, there were no unreviewed environmental questions identified.



700 Landwehr Road • Northbrook, IL 60062-2310
ph. (847) 564-0700 • fax (847) 564-4517

APPENDIX A

INTERLABORATORY COMPARISON PROGRAM RESULTS

NOTE: *Environmental Inc., Midwest Laboratory participates in intercomparison studies administered by Environmental Resources Associates, and serves as a replacement for studies conducted previously by the U.S. EPA Environmental Monitoring Systems Laboratory, Las Vegas, Nevada. Results are reported in Appendix A. TLD Intercomparison results, in-house spikes, blanks, duplicates and mixed analyte performance evaluation program results are also reported. Appendix A is updated four times a year; the complete Appendix is included in March, June, September and December monthly progress reports only.*

January through December, 2007

Appendix A

Interlaboratory Comparison Program Results

Environmental, Inc., Midwest Laboratory has participated in interlaboratory comparison (crosscheck) programs since the formulation of its quality control program in December 1971. These programs are operated by agencies which supply environmental type samples containing concentrations of radionuclides known to the issuing agency but not to participant laboratories. The purpose of such a program is to provide an independent check on a laboratory's analytical procedures and to alert it of any possible problems.

Participant laboratories measure the concentration of specified radionuclides and report them to the issuing agency. Several months later, the agency reports the known values to the participant laboratories and specifies control limits. Results consistently higher or lower than the known values or outside the control limits indicate a need to check the instruments or procedures used.

Results in Table A-1 were obtained through participation in the environmental sample crosscheck program administered by Environmental Resources Associates, serving as a replacement for studies conducted previously by the U.S. EPA Environmental Monitoring Systems Laboratory, Las Vegas, Nevada.

The results in Table A-2 list results for thermoluminescent dosimeters (TLDs), via International Intercomparison of Environmental Dosimeters, when available, and internal laboratory testing.

Table A-3 lists results of the analyses on in-house "spiked" samples for the past twelve months. All samples are prepared using NIST traceable sources. Data for previous years available upon request.

Table A-4 lists results of the analyses on in-house "blank" samples for the past twelve months. Data for previous years available upon request.

Table A-5 lists REMP specific analytical results from the in-house "duplicate" program for the past twelve months. Acceptance is based on the difference of the results being less than the sum of the errors. Complete analytical data for duplicate analyses is available upon request.

The results in Table A-6 were obtained through participation in the Mixed Analyte Performance Evaluation Program.

Results in Table A-7 were obtained through participation in the environmental sample crosscheck program administered by Environmental Resources Associates, serving as a replacement for studies conducted previously by the Environmental Measurement Laboratory Quality Assessment Program (EML).

Attachment A lists acceptance criteria for "spiked" samples.

Out-of-limit results are explained directly below the result.

Attachment A

ACCEPTANCE CRITERIA FOR "SPIKED" SAMPLES

LABORATORY PRECISION: ONE STANDARD DEVIATION VALUES FOR VARIOUS ANALYSES^a

Analysis	Level	One standard deviation for single determination
Gamma Emitters	5 to 100 pCi/liter or kg > 100 pCi/liter or kg	5.0 pCi/liter 5% of known value
Strontium-89 ^b	5 to 50 pCi/liter or kg > 50 pCi/liter or kg	5.0 pCi/liter 10% of known value
Strontium-90 ^b	2 to 30 pCi/liter or kg > 30 pCi/liter or kg	5.0 pCi/liter 10% of known value
Potassium-40	≥ 0.1 g/liter or kg	5% of known value
Gross alpha	≤ 20 pCi/liter > 20 pCi/liter	5.0 pCi/liter 25% of known value
Gross beta	≤ 100 pCi/liter > 100 pCi/liter	5.0 pCi/liter 5% of known value
Tritium	≤ 4,000 pCi/liter > 4,000 pCi/liter	± 1σ = 169.85 x (known) ^{0.0933} 10% of known value
Radium-226,-228	≥ 0.1 pCi/liter	15% of known value
Plutonium	≥ 0.1 pCi/liter, gram, or sample	10% of known value
Iodine-131, Iodine-129 ^b	≤ 55 pCi/liter > 55 pCi/liter	6.0 pCi/liter 10% of known value
Uranium-238, Nickel-63 ^b Technetium-99 ^b	≤ 35 pCi/liter > 35 pCi/liter	6.0 pCi/liter 15% of known value
Iron-55 ^b	50 to 100 pCi/liter > 100 pCi/liter	10 pCi/liter 10% of known value
Others ^b	---	20% of known value

^a From EPA publication, "Environmental Radioactivity Laboratory Intercomparison Studies Program, Fiscal Year, 1981-1982, EPA-600/4-81-004.

^b Laboratory limit.

TABLE A-1. Interlaboratory Comparison Crosscheck program, Environmental Resource Associates (ERA)^a.

Lab Code	Date	Analysis	Concentration (pCi/L)			Acceptance
			Laboratory Result ^b	ERA Result ^c	Control Limits	
STW-1121	04/09/07	Sr-89	30.7 ± 4.3	35.4	26.7 - 44.1	Pass
STW-1121	04/09/07	Sr-90	39.3 ± 1.8	42.1	33.4 - 50.8	Pass
STW-1122	04/09/07	Ba-133	30.0 ± 2.4	29.3	20.6 - 38.0	Pass
STW-1122	04/09/07	Co-60	118.5 ± 3.9	119.0	109.0 - 129.0	Pass
STW-1122	04/09/07	Cs-134	52.6 ± 2.3	54.3	45.6 - 63.0	Pass
STW-1122	04/09/07	Cs-137	49.5 ± 3.8	50.3	41.6 - 59.0	Pass
STW-1122	04/09/07	Zn-65	91.7 ± 6.3	88.6	73.3 - 104.0	Pass
STW-1123	04/09/07	Gr. Alpha	33.8 ± 3.5	56.5	32.0 - 81.0	Pass
STW-1123	04/09/07	Gr. Beta	24.2 ± 2.3	25.3	16.6 - 34.0	Pass
STW-1124	04/09/07	I-131	19.2 ± 1.2	18.9	13.7 - 24.1	Pass
STW-1125	04/09/07	H-3	7540.0 ± 255.0	8060.0	6660.0 - 9450.0	Pass
STW-1125	04/09/07	Ra-226	13.0 ± 0.6	13.4	9.9 - 16.9	Pass
STW-1125	04/09/07	Ra-228	19.9 ± 2.7	18.2	10.3 - 26.1	Pass
STW-1125	04/09/07	Uranium	4.5 ± 0.2	4.6	0.0 - 9.8	Pass
STW-1127	07/09/07	Sr-89	51.7 ± 5.0	58.2	49.5 - 66.9	Pass
STW-1127	07/09/07	Sr-90	21.4 ± 2.3	19.0	10.3 - 27.7	Pass
STW-1128	07/09/07	Ba-133	19.4 ± 2.2	19.4	10.7 - 28.1	Pass
STW-1128	07/09/07	Co-60	32.8 ± 2.0	33.5	24.8 - 42.2	Pass
STW-1128	07/09/07	Cs-134	67.0 ± 2.9	68.9	60.2 - 77.6	Pass
STW-1128	07/09/07	Cs-137	61.6 ± 3.8	61.3	52.6 - 70.0	Pass
STW-1128	07/09/07	Zn-65	55.6 ± 7.5	54.6	45.2 - 64.0	Pass
STW-1129	07/09/07	Gr. Alpha	19.2 ± 1.6	27.1	15.4 - 38.8	Pass
STW-1129	07/09/07	Gr. Beta	9.1 ± 0.9	11.5	2.8 - 20.2	Pass
STW-1130	07/09/07	Ra-226	7.0 ± 0.5	7.7	5.7 - 9.7	Pass
STW-1130	07/09/07	Ra-228	9.2 ± 2.3	9.1	5.2 - 13.1	Pass
STW-1130	07/09/07	Uranium	23.9 ± 1.1	25.1	19.9 - 30.3	Pass
STW-1131	10/05/07	Sr-89	27.3 ± 3.3	27.4	19.3 - 33.9	Pass
STW-1131	10/05/07	Sr-90	17.7 ± 1.2	18.2	12.9 - 21.6	Pass
STW-1132	10/05/07	Ba-133	12.2 ± 3.3	12.6	8.6 - 15.5	Pass
STW-1132	10/05/07	Co-60	23.8 ± 1.4	23.2	19.9 - 28.3	Pass
STW-1132	10/05/07	Cs-134	70.5 ± 4.2	71.1	58.0 - 78.2	Pass
STW-1132	10/05/07	Cs-137	178.2 ± 3.3	180.0	162.0 - 200.0	Pass
STW-1132	10/05/07	Zn-65	263.9 ± 6.9	251.0	226.0 - 294.0	Pass
STW-1133	10/05/07	Gr. Alpha	54.7 ± 2.1	58.6	30.6 - 72.9	Pass
STW-1133	10/05/07	Gr. Beta	11.9 ± 0.9	9.7	4.3 - 18.2	Pass
STW-1134	10/05/07	I-131	33.0 ± 1.5	28.9	24.0 - 33.8	Pass
STW-1135	10/05/07	H-3	9965.0 ± 250.0	9700.0	8430.0 - 10700.0	Pass
STW-1135	10/05/07	Ra-226	12.7 ± 0.2	12.9	9.6 - 14.9	Pass
STW-1135	10/05/07	Ra-228	19.6 ± 2.4	17.9	12.0 - 21.5	Pass
STW-1135	10/05/07	Uranium	27.3 ± 1.1	27.5	22.1 - 30.8	Pass

^a Results obtained by Environmental, Inc., Midwest Laboratory as a participant in the crosscheck program for proficiency testing in drinking water conducted by Environmental Resources Associates (ERA).

^b Unless otherwise indicated, the laboratory result is given as the mean ± standard deviation for three determinations.

^c Results are presented as the known values, expected laboratory precision (1 sigma, 1 determination) and control limits as provided by ERA.

TABLE A-2. Crosscheck program results; Thermoluminescent Dosimetry, (TLD, CaSO₄: Dy Cards).

Lab Code	Date	Description	Known Value	mR		Acceptance
				Lab Result ± 2 sigma	Control Limits	
<u>Environmental, Inc.</u>						
2007-1	7/13/2007	30 cm.	54.25	60.56 ± 5.54	37.98 - 70.53	Pass
2007-1	7/13/2007	40 cm.	30.51	34.23 ± 0.96	21.36 - 39.66	Pass
2007-1	7/13/2007	50 cm.	19.53	17.95 ± 1.86	13.67 - 25.39	Pass
2007-1	7/13/2007	60 cm.	13.56	16.61 ± 0.60	9.49 - 17.63	Pass
2007-1	7/13/2007	70 cm.	9.96	9.72 ± 0.90	6.97 - 12.95	Pass
2007-1	7/13/2007	80 cm.	7.63	7.79 ± 0.33	5.34 - 9.92	Pass
2007-1	7/13/2007	90 cm.	6.03	5.53 ± 0.72	4.22 - 7.84	Pass
2007-1	7/13/2007	100 cm.	4.88	5.32 ± 0.17	3.42 - 6.34	Pass
2007-1	7/13/2007	110 cm.	4.03	3.49 ± 0.14	2.82 - 5.24	Pass
2007-1	7/13/2007	120 cm.	3.39	2.64 ± 0.14	2.37 - 4.41	Pass
2007-1	7/13/2007	150 cm.	2.17	2.13 ± 0.87	1.52 - 2.82	Pass
<u>Environmental, Inc.</u>						
2007-2	11/12/2007	30 cm.	54.37	65.47 ± 5.25	38.06 - 70.68	Pass
2007-2	11/12/2007	40 cm.	30.59	37.43 ± 2.18	21.41 - 39.77	Pass
2007-2	11/12/2007	60 cm.	13.59	15.18 ± 0.50	9.51 - 17.67	Pass
2007-2	11/12/2007	70 cm.	9.99	12.18 ± 0.46	6.99 - 12.99	Pass
2007-2	11/12/2007	80 cm.	7.65	8.74 ± 0.39	5.36 - 9.95	Pass
2007-2	11/12/2007	90 cm.	6.04	5.89 ± 0.25	4.23 - 7.85	Pass
2007-2	11/12/2007	110 cm.	4.04	4.13 ± 0.41	2.83 - 5.25	Pass
2007-2	11/12/2007	120 cm.	3.4	2.92 ± 0.13	2.38 - 4.42	Pass
2007-2	11/12/2007	120 cm.	3.4	2.91 ± 0.31	2.38 - 4.42	Pass
2007-2	11/12/2007	150 cm.	2.17	1.95 ± 0.72	1.52 - 2.82	Pass
2007-2	11/12/2007	180 cm.	1.51	1.38 ± 0.05	1.06 - 1.96	Pass

APPENDIX A, 2007 INTER-LABORATORY CROSS CHECK COMPARISON PROGRAM RESULTS

TABLE A-3. In-House "Spike" Samples

Lab Code ^b	Date	Analysis	Concentration (pCi/L) ^a			Acceptance
			Laboratory results 2s, n=1 ^c	Known Activity	Control Limits ^d	
W-30707	3/7/2007	Gr. Alpha	19.51 ± 0.40	20.08	10.04 - 30.12	Pass
W-30707	3/7/2007	Gr. Beta	67.45 ± 0.49	65.73	55.73 - 75.73	Pass
SPAP-1566	3/23/2007	Cs-134	25.35 ± 1.31	27.82	17.82 - 37.82	Pass
SPAP-1566	3/23/2007	Cs-137	107.52 ± 3.02	116.48	104.83 - 128.13	Pass
SPW-1568	3/23/2007	H-3	65595.00 ± 672.00	71118.00	56894.40 - 85341.60	Pass
SPW-1678	3/28/2007	Tc-99	28.44 ± 1.12	32.35	20.35 - 44.35	Pass
SPW-1595	4/5/2007	Cs-134	54.48 ± 2.12	54.99	44.99 - 64.99	Pass
SPW-1595	4/5/2007	Cs-137	59.03 ± 2.94	58.19	48.19 - 68.19	Pass
SPW-1595	4/5/2007	I-131(G)	83.11 ± 3.51	82.07	72.07 - 92.07	Pass
SPW-1595A	4/5/2007	I-131	78.40 ± 1.10	82.07	65.66 - 98.48	Pass
SPW-1595B	4/5/2007	I-131	78.97 ± 1.10	82.07	65.66 - 98.48	Pass
SPMI-1597	4/5/2007	Cs-134	54.03 ± 2.15	54.99	44.99 - 64.99	Pass
SPMI-1597	4/5/2007	Cs-137	59.81 ± 4.75	58.19	48.19 - 68.19	Pass
SPMI-1597	4/5/2007	I-131(G)	83.97 ± 4.07	82.07	72.07 - 92.07	Pass
SPMI-1597A	4/5/2007	I-131	79.53 ± 1.03	82.07	65.66 - 98.48	Pass
SPMI-1597B	4/5/2007	I-131	83.51 ± 1.05	82.07	65.66 - 98.48	Pass
SPCH-2839	5/17/2007	I-131(G)	78.70 ± 7.36	70.40	60.40 - 80.40	Pass
SPW-2847	5/17/2007	Cs-134	55.43 ± 1.68	52.85	42.85 - 62.85	Pass
SPW-2847	5/17/2007	Cs-137	59.86 ± 2.71	58.03	48.03 - 68.03	Pass
SPW-2847	5/17/2007	I-131(G)	63.95 ± 2.69	70.87	60.87 - 80.87	Pass
SPMI-2849	5/17/2007	Cs-134	51.37 ± 1.65	52.85	42.85 - 62.85	Pass
SPMI-2849	5/17/2007	Cs-137	60.42 ± 4.31	58.03	48.03 - 68.03	Pass
SPMI-2849	5/17/2007	I-131(G)	62.44 ± 3.14	70.87	60.87 - 80.87	Pass
SPCH-2922	5/17/2007	I-131(G)	80.00 ± 6.40	70.40	41.60 - 99.20	Pass
SPW-2847	5/18/2007	I-131	60.14 ± 0.89	70.87	56.70 - 85.04	Pass
SPW-2847	5/18/2007	Sr-89	104.93 ± 6.64	121.90	97.52 - 146.28	Pass
SPW-2847	5/18/2007	Sr-89	46.72 ± 1.97	46.08	36.08 - 56.08	Pass
SPMI-2849	5/18/2007	I-131	67.97 ± 0.88	70.87	56.70 - 85.04	Pass
SPW-2909 ^e	5/22/2007	Fe-55	11137.00 ± 316.00	14271.50	11417.20 - 17125.80	Fail
SPW-2911	5/22/2007	H-3	65023.00 ± 679.00	70485.00	56388.00 - 84582.00	Pass
SPAP-2913	5/22/2007	Gr. Beta	55.27 ± 8.51	52.65	42.12 - 73.71	Pass
SPAP-2915	5/22/2007	Cs-134	22.53 ± 1.12	26.42	16.42 - 36.42	Pass
SPAP-2915	5/22/2007	Cs-137	111.14 ± 3.57	116.06	104.45 - 127.67	Pass
SPF-2922	5/22/2007	Cs-134	0.52 ± 0.03	0.53	0.32 - 0.74	Pass
SPF-2922	5/22/2007	Cs-137	2.58 ± 0.07	2.32	1.39 - 3.25	Pass
SPW-3223	5/24/2007	Ni-63	2233.10 ± 10.32	2135.90	1281.54 - 2990.26	Pass
W-60507	6/5/2007	Gr. Alpha	20.93 ± 0.42	20.08	10.04 - 30.12	Pass
W-60507	6/5/2007	Gr. Beta	60.50 ± 0.46	65.73	55.73 - 75.73	Pass
SPW-4327	7/18/2007	Tc-99	25.58 ± 1.11	32.35	20.35 - 44.35	Pass
SPW-5476	8/17/2007	Ni-63	1925.18 ± 9.62	2135.90	1281.54 - 2990.26	Pass
W-92107	9/21/2007	Gr. Alpha	23.02 ± 0.44	20.08	10.04 - 30.12	Pass
W-92107	9/21/2007	Gr. Beta	61.48 ± 0.47	65.73	55.73 - 75.73	Pass

TABLE A-3. In-House "Spike" Samples

Lab Code	Date	Analysis	Concentration (pCi/L) ^a		Control Limits ^c	Acceptance
			Laboratory results 2s, n=1 ^b	Known Activity		
SPW-6880	10/10/2007	Tc-99	30.97 ± 1.21	32.35	20.35 - 44.35	Pass
w-111007	11/10/2007	Gr. Alpha	22.43 ± 0.42	20.08	10.04 - 30.12	Pass
w-111007	11/10/2007	Gr. Beta	64.49 ± 0.48	65.73	55.73 - 75.73	Pass
SPAP-7742	11/13/2007	Cs-134	21.18 ± 1.29	22.41	12.41 - 32.41	Pass
SPAP-7742	11/13/2007	Cs-137	113.61 ± 3.16	114.76	103.28 - 126.24	Pass
SPAP-7744	11/13/2007	Gr. Beta	53.41 ± 0.13	52.03	41.62 - 72.84	Pass
SPMI-7746	11/13/2007	Cs-134	42.20 ± 1.48	44.83	34.83 - 54.83	Pass
SPMI-7746	11/13/2007	Cs-137	56.05 ± 2.83	57.40	47.40 - 67.40	Pass
SPMI-7746	11/13/2007	Sr-90	41.02 ± 1.61	45.54	36.43 - 54.65	Pass
SPW-7748	11/13/2007	Cs-134	43.11 ± 1.52	44.80	34.80 - 54.80	Pass
SPW-7748	11/13/2007	Cs-137	59.28 ± 3.50	57.40	47.40 - 67.40	Pass
SPW-7748	11/13/2007	Sr-90	37.23 ± 1.51	45.54	36.43 - 54.65	Pass
SPW-7752	11/13/2007	Fe-55	12935.10 ± 357.00	12640.50	10112.40 - 15168.60	Pass
SPW-7758	11/13/2007	H-3	65405.00 ± 712.50	68618.00	54894.40 - 82341.60	Pass
SPF-7760	11/13/2007	Cs-134	0.45 ± 0.02	0.45	0.27 - 0.63	Pass
SPF-7760	11/13/2007	Cs-137	2.45 ± 0.07	2.29	1.37 - 3.21	Pass
SPW-8034	11/13/2007	Ni-63	2194.06 ± 10.77	2129.03	1277.42 - 2980.64	Pass

^a Liquid sample results are reported in pCi/Liter, air filters (pCi/filter), charcoal (pCi/m³), and solid samples (pCi/g).

^b Laboratory codes as follows: W (water), MI (milk), AP (air filter), SO (soil), VE (vegetation), CH (charcoal canister), F (fish).

^c Results are based on single determinations.

^d Control limits are based on Attachment A, Page A2 of this report.

^e Sample recount: 12557 ± 335.

NOTE: For fish, Jello is used for the Spike matrix. For Vegetation, cabbage is used for the Spike matrix.

APPENDIX A, 2007 INTER-LABORATORY CROSS CHECK COMPARISON PROGRAM RESULTS

TABLE A-4. In-House "Blank" Samples

Lab Code	Sample Type	Date	Analysis ^b	Concentration (pCi/L) ^a		Acceptance Criteria (4.66 σ)
				Laboratory results (4.66 σ)		
				LLD	Activity ^c	
W-30707	water	3/7/2007	Gr. Alpha	0.40	0.01 \pm 0.28	2
W-30707	water	3/7/2007	Gr. Beta	0.75	0.06 \pm 0.53	4
SPAP-1567	Air Filter	3/23/2007	Cs-134	0.79		10
SPW-1567	Air Filter	3/23/2007	Cs-137	1.01		10
SPW-1568	water	3/23/2007	H-3	176.10	-26.16 \pm 91.62	200
SPW-1596	water	4/5/2007	Cs-134	3.28		10
SPW-1596	water	4/5/2007	Cs-137	3.45		10
SPW-1596	water	4/5/2007	I-131	0.27	0.02 \pm 0.18	0.5
SPW-1596	water	4/5/2007	I-131(G)	2.91		20
SPMI-1598	Milk	4/5/2007	Cs-134	3.30		10
SPMI-1598	Milk	4/5/2007	Cs-137	5.08		10
SPMI-1598	Milk	4/5/2007	I-131	0.26	-0.10 \pm 0.17	0.5
SPMI-1598	Milk	4/5/2007	I-131(G)	4.10		20
SPCH-2839	Charcoal Canister	5/17/2007	I-131(G)	2.24		9.6
SPW-2848	water	5/17/2007	Cs-134	3.14		10
SPW-2848	water	5/17/2007	Cs-137	1.37		10
SPW-2848	water	5/17/2007	I-131(G)	5.34		20
SPMI-2850	Milk	5/17/2007	Cs-134	3.32		10
SPMI-2850	Milk	5/17/2007	Cs-137	2.60		10
SPMI-2850	Milk	5/17/2007	I-131(G)	4.77		20
SPW-2848	water	5/18/2007	I-131	0.34	-0.06 \pm 0.19	0.5
SPW-2848	water	5/18/2007	Sr-89	0.81	-0.02 \pm 0.65	5
SPW-2848	water	5/18/2007	Sr-90	0.53	0.01 \pm 0.25	1
SPMI-2850	Milk	5/18/2007	I-131	0.45	0.20 \pm 0.26	0.5
SPMI-2850	Milk	5/18/2007	Sr-89	0.96	-0.73 \pm 1.02	5
SPMI-2850 ^d	Milk	5/18/2007	Sr-90	0.58	0.96 \pm 0.38	1
SPAP-2914	Air Filter	5/22/2007	Gr. Beta	0.004	-0.002 \pm 0.002	0.01
SPAP-2916	Air Filter	5/22/2007	Cs-134	2.84		10
SPAP-2916	Air Filter	5/22/2007	Cs-137	2.24		10
SPF-2923	Fish	5/22/2007	Cs-134	8.71		100
SPF-2923	Fish	5/22/2007	Cs-137	8.35		100
SPW-3224	water	5/24/2007	Ni-63	1.61	-0.30 \pm 0.84	20
W-60507	water	6/5/2007	Gr. Alpha	0.43	-0.01 \pm 0.30	2
W-60507	water	6/5/2007	Gr. Beta	0.77	0.01 \pm 0.54	4
SPW-4328	water	7/18/2007	Tc-99	6.41	-3.12 \pm 3.84	10
SPW-5477	water	8/17/2007	Ni-63	1.48	4.38 \pm 1.01	20
W-92107	water	9/21/2007	Gr. Alpha	0.41	0.09 \pm 0.29	2
W-92107	water	9/21/2007	Gr. Beta	0.75	-0.26 \pm 0.51	4

TABLE A-4. In-House "Blank" Samples

Lab Code	Sample Type	Date	Analysis ^b	Concentration (pCi/L) ^a		
				Laboratory results (4.66σ)		Acceptance Criteria (4.66 σ)
				LLD	Activity ^c	
SPW-6881	water	10/10/2007	Tc-99	6.82	-6.58 ± 4.04	10
SPAP-7743	Air Filter	11/13/2007	Gr. Beta	0.003	-0.002 ± 0.002	0.01
SPMI-7745	Milk	11/13/2007	Cs-134	2.16		10
SPMI-7745	Milk	11/13/2007	Cs-137	3.46		10
SPMI-7745	Milk	11/13/2007	I-131(G)	5.89		20
SPMI-7745	Milk	11/13/2007	Sr-90	0.59	0.73 ± 0.35	1
SPW-7747	water	11/13/2007	Cs-134	2.39		10
SPW-7747	water	11/13/2007	Cs-137	3.53		10
SPW-7747	water	11/13/2007	I-131(G)	12.51		20
SPW-7747	water	11/13/2007	Sr-90	0.71	-0.04 ± 0.32	1
SPW-7751	water	11/13/2007	Fe-55	15.50	-4.18 ± 9.20	1000
SPW-7757	water	11/13/2007	H-3	151.35	-14.98 ± 78.85	200
SPF-7759	Fish	11/13/2007	Cs-134	5.50		100
SPF-7759	Fish	11/13/2007	Cs-137	5.10		100
SPW-8033	water	11/13/2007	Ni-63	1.45	-0.19 ± 0.87	20
W-120607	water	12/6/2007	Gr. Alpha	0.40	0.02 ± 0.28	2
W-120607	water	12/6/2007	Gr. Beta	0.77	-0.70 ± 0.51	4

^a Liquid sample results are reported in pCi/Liter, air filters(pCi/filter), charcoal (pCi/charcoal canister), and solid samples (pCi/kg).

^b I-131(G); iodine-131 as analyzed by gamma spectroscopy.

^c Activity reported is a net activity result. For gamma spectroscopic analysis, activity detected below the LLD value is not reported.

^d Low levels of Sr-90 are still detected in the environment. A concentration of (1-5 pCi/L) in milk is not unusual.

APPENDIX A, 2007 INTER-LABORATORY CROSS CHECK COMPARISON PROGRAM RESULTS

TABLE A-5. In-House "Duplicate" Samples

Lab Code	Date	Analysis	Concentration (pCi/L) ^a			Acceptance
			First Result	Second Result	Averaged Result	
E-20, 21	1/2/2007	Gr. Beta	1.76 ± 0.07	1.70 ± 0.06	1.73 ± 0.05	Pass
E-20, 21	1/2/2007	K-40	1.49 ± 0.24	1.57 ± 0.27	1.53 ± 0.18	Pass
CF-41, 42	1/2/2007	Gr. Beta	18.02 ± 0.41	18.81 ± 0.42	18.42 ± 0.29	Pass
CF-41, 42	1/2/2007	K-40	11.68 ± 1.12	12.67 ± 0.97	12.18 ± 0.74	Pass
CF-41, 42	1/2/2007	Sr-90	0.039 ± 0.011	0.026 ± 0.010	0.033 ± 0.007	Pass
P-9516, 9517	1/3/2007	H-3	270.78 ± 91.74	301.18 ± 92.99	285.98 ± 65.31	Pass
LW-9579, 9580	1/4/2007	Gr. Beta	0.91 ± 0.31	0.93 ± 0.30	0.92 ± 0.22	Pass
DW-70085, 70086	1/9/2007	Gr. Alpha	7.95 ± 1.20	7.92 ± 1.42	7.94 ± 0.93	Pass
DW-70037, 70038	1/11/2007	Gr. Alpha	55.47 ± 3.99	52.87 ± 4.02	54.17 ± 2.83	Pass
DW-70054, 70055	1/18/2007	Gr. Alpha	2.68 ± 0.88	1.88 ± 0.78	2.28 ± 0.59	Pass
DW-70122, 70123	1/18/2007	Gr. Alpha	4.30 ± 1.14	6.25 ± 1.16	5.28 ± 0.81	Pass
DW-70122, 70123	1/18/2007	Gr. Beta	4.22 ± 0.70	5.33 ± 0.75	4.78 ± 0.51	Pass
DW-70098, 70099	1/25/2007	Gr. Alpha	3.27 ± 0.90	1.97 ± 0.92	2.62 ± 0.64	Pass
DW-70110, 70111	1/25/2007	Gr. Alpha	2.19 ± 0.92	1.69 ± 0.79	1.94 ± 0.61	Pass
SWU-676, 677	1/30/2007	Gr. Beta	1.77 ± 0.39	2.11 ± 0.39	1.94 ± 0.28	Pass
DW-70148, 70149	1/30/2007	Gr. Alpha	4.65 ± 1.37	5.20 ± 1.81	4.93 ± 1.14	Pass
SW-600, 601	2/1/2007	K-40	1.24 ± 0.12	1.20 ± 0.12	1.22 ± 0.08	Pass
SW-601, 602	2/1/2007	Gr. Beta	0.89 ± 0.37	1.02 ± 0.25	0.96 ± 0.22	Pass
DW-1138, 1139	2/9/2007	H-3	2707.00 ± 161.00	2700.00 ± 161.00	2703.50 ± 113.84	Pass
MI-721, 722	2/13/2007	K-40	1330.40 ± 117.60	1316.40 ± 116.50	1323.40 ± 82.77	Pass
SW-847, 848	2/13/2007	Gr. Alpha	3.82 ± 1.67	2.61 ± 1.24	3.22 ± 1.04	Pass
SW-847, 848	2/13/2007	Gr. Beta	7.33 ± 1.37	5.89 ± 0.90	6.61 ± 0.82	Pass
DW-70175, 70176	2/14/2007	Gr. Alpha	11.72 ± 1.68	8.84 ± 1.32	10.28 ± 1.07	Pass
DW-70187, 70188	2/14/2007	Gr. Alpha	6.79 ± 1.18	6.47 ± 1.08	6.63 ± 0.80	Pass
SWU-1162, 1163	2/27/2007	Gr. Beta	3.63 ± 0.69	2.61 ± 0.44	3.12 ± 0.41	Pass
DW-70205, 70206	2/28/2007	Gr. Alpha	0.88 ± 0.80	1.31 ± 0.79	1.10 ± 0.56	Pass
PW-1117, 1118	3/1/2007	Gr. Alpha	3.79 ± 1.91	3.62 ± 2.09	3.71 ± 1.42	Pass
PW-1117, 1118	3/1/2007	Gr. Beta	7.12 ± 1.40	7.20 ± 1.39	7.16 ± 0.99	Pass
W-2122, 2123	3/5/2007	Gr. Alpha	6.10 ± 4.16	3.80 ± 4.30	4.95 ± 2.99	Pass
W-2122, 2123	3/5/2007	Gr. Beta	10.65 ± 2.15	13.11 ± 2.42	11.88 ± 1.62	Pass
W-2085, 2086	3/6/2007	Gr. Alpha	2.51 ± 2.29	1.10 ± 2.78	1.81 ± 1.80	Pass
W-2085, 2086	3/6/2007	Gr. Beta	11.02 ± 1.85	9.50 ± 2.01	10.26 ± 1.37	Pass
DW-70232, 70233	3/8/2007	Gr. Alpha	4.75 ± 1.28	5.98 ± 1.31	5.37 ± 0.92	Pass
WW-1477, 1478	3/12/2007	Gr. Beta	6.41 ± 1.48	4.10 ± 1.25	5.26 ± 0.97	Pass
WW-1498, 1499	3/15/2007	Gr. Beta	0.83 ± 0.31	0.97 ± 0.33	0.90 ± 0.22	Pass
W-2140, 2141	3/19/2007	Gr. Alpha	2.31 ± 1.57	1.33 ± 1.64	1.82 ± 1.14	Pass
W-2140, 2141	3/19/2007	Gr. Beta	4.26 ± 1.00	5.58 ± 1.02	4.92 ± 0.71	Pass
DW-1626, 1627	3/21/2007	H-3	4973.00 ± 209.00	5190.00 ± 213.00	5081.50 ± 149.21	Pass
MI-1647, 1648	3/21/2007	K-40	1448.80 ± 120.20	1439.30 ± 126.00	1444.05 ± 87.07	Pass
DW-70248, 70249	3/21/2007	Gr. Alpha	11.10 ± 1.18	9.90 ± 1.16	10.50 ± 0.83	Pass
W-2150, 2151	3/26/2007	Gr. Alpha	3.56 ± 2.20	3.30 ± 1.81	3.43 ± 1.42	Pass
W-2150, 2151	3/26/2007	Gr. Beta	9.26 ± 1.00	10.17 ± 1.90	9.72 ± 1.07	Pass
LW-1941, 1942	3/31/2007	Gr. Beta	1.35 ± 0.43	1.36 ± 0.41	1.36 ± 0.30	Pass

APPENDIX A, 2007 INTER-LABORATORY CROSS CHECK COMPARISON PROGRAM RESULTS

TABLE A-5. In-House "Duplicate" Samples

Lab Code	Date	Analysis	Concentration (pCi/L) ^a			Acceptance
			First Result	Second Result	Averaged Result	
MI-1824, 1825	4/2/2007	K-40	1316.10 ± 110.60	1229.80 ± 110.50	1272.95 ± 78.17	Pass
MI-1824, 1825	4/2/2007	Sr-90	1.20 ± 0.50	1.10 ± 0.36	1.15 ± 0.31	Pass
AP-2170, 2171	4/2/2007	Be-7	0.08 ± 0.01	0.08 ± 0.01	0.08 ± 0.01	Pass
WW-1850, 1851	4/3/2007	H-3	-5.83 ± 102.29	150.05 ± 80.14	72.11 ± 64.97	Pass
AP-2198, 2199	4/3/2007	Be-7	0.08 ± 0.01	0.08 ± 0.01	0.08 ± 0.01	Pass
AP-2370, 2371	4/3/2007	Be-7	0.07 ± 0.01	0.07 ± 0.01	0.07 ± 0.01	Pass
DW-70300, 70301	4/4/2007	Gr. Alpha	3.78 ± 0.89	3.66 ± 0.96	3.72 ± 0.65	Pass
DW-70300, 70301	4/4/2007	Gr. Beta	2.93 ± 0.61	2.91 ± 0.64	2.92 ± 0.44	Pass
DW-70335, 70336	4/5/2007	Gr. Alpha	24.37 ± 2.89	22.72 ± 2.91	23.55 ± 2.05	Pass
DW-70335, 70336	4/5/2007	Gr. Beta	20.26 ± 1.37	18.33 ± 1.34	19.30 ± 0.96	Pass
SW-1898, 1899	4/10/2007	Gr. Alpha	3.86 ± 1.40	4.78 ± 1.51	4.32 ± 1.03	Pass
SW-1898, 1899	4/10/2007	Gr. Beta	6.31 ± 1.36	7.03 ± 1.42	6.67 ± 0.98	Pass
SW-1898, 1899	4/10/2007	H-3	241.99 ± 93.35	318.10 ± 96.48	280.04 ± 67.12	Pass
DW-70346, 70347	4/11/2007	Gr. Alpha	1.83 ± 1.08	2.54 ± 1.04	2.19 ± 0.75	Pass
DW-70346, 70347	4/11/2007	Gr. Beta	4.62 ± 0.72	4.01 ± 0.71	4.32 ± 0.51	Pass
DW-70376, 70377	4/11/2007	Gr. Alpha	1.81 ± 0.80	1.66 ± 0.86	1.74 ± 0.59	Pass
DW-70376, 70377	4/11/2007	Gr. Beta	1.84 ± 0.62	2.24 ± 0.61	2.04 ± 0.44	Pass
DW-70311, 70312	4/12/2007	Gr. Alpha	10.82 ± 1.50	13.20 ± 1.56	12.01 ± 1.08	Pass
WW-2349, 2350	4/17/2007	Gr. Alpha	0.71 ± 0.56	0.62 ± 0.52	0.66 ± 0.38	Pass
WW-2461, 2462	4/25/2007	H-3	190.30 ± 100.31	115.95 ± 97.65	153.13 ± 70.00	Pass
LW-2437, 2438	4/26/2007	Gr. Beta	2.71 ± 0.50	2.15 ± 0.45	2.43 ± 0.34	Pass
LW-2917, 2918	4/30/2007	Gr. Beta	1.97 ± 0.79	2.78 ± 0.81	2.38 ± 0.57	Pass
SO-2583, 2584	5/1/2007	Be-7	544.99 ± 247.70	601.13 ± 192.20	573.06 ± 156.76	Pass
SO-2583, 2584	5/1/2007	Cs-137	119.22 ± 36.61	87.46 ± 23.97	103.34 ± 21.88	Pass
SO-2583, 2584	5/1/2007	K-40	17825.00 ± 749.90	17672.00 ± 724.30	17748.50 ± 521.29	Pass
SO-2583, 2584	5/1/2007	Gr. Alpha	11.49 ± 3.96	8.04 ± 3.88	9.77 ± 2.77	Pass
SO-2583, 2584	5/1/2007	Gr. Beta	31.02 ± 3.74	26.10 ± 3.40	28.56 ± 2.53	Pass
SO-2583, 2584	5/1/2007	Sr-90	0.086 ± 0.024	0.068 ± 0.025	0.077 ± 0.017	Pass
S-2620, 2621	5/2/2007	H-3	277.90 ± 126.70	304.40 ± 101.00	291.15 ± 81.02	Pass
MI-2610, 2611	5/3/2007	K-40	1549.20 ± 184.20	1388.80 ± 128.20	1469.00 ± 112.21	Pass
W-4469, 4470	5/7/2007	Gr. Beta	10.60 ± 1.90	11.10 ± 1.80	10.85 ± 1.31	Pass
SS-2697, 2698	5/8/2007	Cs-137	0.06 ± 0.02	0.05 ± 0.03	0.05 ± 0.02	Pass
SS-2697, 2698	5/8/2007	K-40	8.03 ± 0.57	7.36 ± 0.68	7.70 ± 0.44	Pass
MI-2790, 2791	5/14/2007	K-40	1694.30 ± 126.20	1627.60 ± 128.80	1660.95 ± 90.16	Pass
W-4505, 4506	5/14/2007	Gr. Beta	3.30 ± 1.70	3.90 ± 1.50	3.60 ± 1.13	Pass
DW-3219, 3220	5/26/2007	I-131	0.62 ± 0.32	0.69 ± 0.31	0.66 ± 0.22	Pass
SO-3416, 3417	5/31/2007	Cs-137	0.15 ± 0.03	0.15 ± 0.03	0.15 ± 0.02	Pass
SO-3416, 3417	5/31/2007	Gr. Beta	22.88 ± 2.33	22.46 ± 2.37	22.67 ± 1.66	Pass
SO-3416, 3417	5/31/2007	K-40	12.26 ± 0.80	12.36 ± 0.65	12.31 ± 0.52	Pass
F-3561, 3562	5/31/2007	K-40	3.06 ± 0.39	3.37 ± 0.45	3.21 ± 0.30	Pass
SL-3311, 3312	6/4/2007	Be-7	0.61 ± 0.29	0.55 ± 0.25	0.58 ± 0.19	Pass
SL-3311, 3312	6/4/2007	K-40	5.78 ± 0.67	4.87 ± 0.25	5.33 ± 0.36	Pass

APPENDIX A, 2007 INTER-LABORATORY CROSS CHECK COMPARISON PROGRAM RESULTS

TABLE A-5. In-House "Duplicate" Samples.

Lab Code	Date	Analysis	Concentration (pCi/L) ^a			Acceptance
			First Result	Second Result	Averaged Result	
SL-3992, 3993	6/4/2007	Be-7	0.75 ± 0.19	0.74 ± 0.32	0.75 ± 0.19	Pass
SL-3992, 3993	6/4/2007	Gr. Beta	13.61 ± 1.12	14.06 ± 1.08	13.84 ± 0.78	Pass
SL-3992, 3993	6/4/2007	K-40	2.43 ± 0.36	2.29 ± 0.40	2.36 ± 0.27	Pass
W-5087, 5088	6/11/2007	Gr. Beta	8.70 ± 1.90	7.70 ± 1.90	8.20 ± 1.34	Pass
SW-3710, 3711	6/14/2007	H-3	9571.51 ± 287.22	9879.21 ± 291.42	9725.36 ± 204.59	Pass
W-4062, 4063	6/28/2007	Gr. Alpha	0.76 ± 0.63	0.32 ± 0.66	0.54 ± 0.45	Pass
W-4062, 4063	6/28/2007	Gr. Beta	0.97 ± 0.53	0.58 ± 0.57	0.78 ± 0.39	Pass
AP-4448, 4449	6/28/2007	Be-7	0.10 ± 0.02	0.09 ± 0.02	0.10 ± 0.01	Pass
SG-3735, 3736	6/30/2007	Be-7	0.84 ± 0.12	0.82 ± 0.18	0.83 ± 0.11	Pass
SG-3735, 3736	6/30/2007	Cs-137	0.07 ± 0.01	0.07 ± 0.01	0.07 ± 0.01	Pass
SG-3735, 3736	6/30/2007	Gr. Beta	29.51 ± 2.22	30.81 ± 2.22	30.16 ± 1.57	Pass
SG-3735, 3736	6/30/2007	K-40	9.41 ± 0.31	8.90 ± 0.48	9.16 ± 0.29	Pass
LW-4175, 4176	6/30/2007	Gr. Beta	2.18 ± 0.60	1.93 ± 0.68	2.06 ± 0.45	Pass
SG-5422, 5423	7/2/2007	Gr. Alpha	10.31 ± 1.98	10.57 ± 1.99	10.44 ± 1.40	Pass
SG-5422, 5423	7/2/2007	Gr. Beta	18.59 ± 1.46	20.97 ± 1.49	19.78 ± 1.04	Pass
AP-4656, 4657	7/3/2007	Be-7	0.09 ± 0.02	0.10 ± 0.02	0.10 ± 0.01	Pass
AP-4763, 4764	7/3/2007	Be-7	0.11 ± 0.02	0.10 ± 0.02	0.11 ± 0.01	Pass
SG-5430, 5431	7/11/2007	Be-7	10.17 ± 0.48	10.06 ± 0.51	10.12 ± 0.35	Pass
SG-5430, 5431	7/11/2007	Cs-137	0.050 ± 0.010	0.059 ± 0.011	0.055 ± 0.007	Pass
SG-5430, 5431	7/11/2007	Gr. Alpha	17.86 ± 2.78	15.74 ± 2.70	16.80 ± 1.94	Pass
SG-5430, 5431	7/11/2007	Gr. Beta	26.19 ± 1.74	25.04 ± 1.86	25.62 ± 1.27	Pass
SG-5430, 5431	7/11/2007	K-40	7.69 ± 0.30	7.65 ± 0.28	7.67 ± 0.21	Pass
WW-4298, 4299	7/12/2007	Gr. Beta	1.74 ± 0.74	2.22 ± 0.80	1.98 ± 0.55	Pass
DW-70612, 70613	7/23/2007	Gr. Alpha	4.54 ± 1.11	4.19 ± 0.97	4.37 ± 0.74	Pass
WW-4918, 4919	7/25/2007	H-3	240.43 ± 111.12	216.68 ± 110.27	228.56 ± 78.27	Pass
MI-4742, 4743	7/26/2007	K-40	1820.30 ± 134.10	1802.90 ± 199.50	1811.60 ± 120.19	Pass
VE-4939, 4940	8/1/2007	Be-7	0.39 ± 0.21	0.45 ± 0.20	0.42 ± 0.15	Pass
VE-4939, 4940	8/1/2007	Gr. Beta	5.50 ± 0.14	5.76 ± 0.13	5.63 ± 0.10	Pass
VE-4939, 4940	8/1/2007	K-40	3.36 ± 0.45	3.36 ± 0.21	3.36 ± 0.25	Pass
SG-6274, 6275	8/6/2007	Gr. Alpha	16.68 ± 3.29	19.26 ± 3.39	17.97 ± 2.36	Pass
SG-6274, 6275	8/6/2007	Gr. Beta	40.93 ± 2.74	42.42 ± 2.66	41.68 ± 1.91	Pass
SW-5218, 5219	8/7/2007	I-131	1.31 ± 0.24	1.42 ± 0.24	1.37 ± 0.17	Pass
SG-6284, 6285	8/8/2007	Cs-137	0.043 ± 0.006	0.051 ± 0.007	0.047 ± 0.005	Pass
SG-6284, 6285	8/8/2007	Gr. Alpha	9.38 ± 2.93	13.61 ± 3.38	11.50 ± 2.24	Pass
SG-6284, 6285	8/8/2007	Gr. Beta	33.46 ± 2.84	32.87 ± 2.93	33.17 ± 2.04	Pass
SG-6284, 6285	8/8/2007	K-40	16.15 ± 0.24	16.23 ± 0.25	16.19 ± 0.17	Pass
WW-5310, 5311	8/9/2007	H-3	644.00 ± 106.00	831.00 ± 113.00	737.50 ± 77.47	Pass
SW-5393, 5394	8/14/2007	Gr. Beta	2.32 ± 1.31	1.71 ± 1.27	2.02 ± 0.92	Pass
SW-5393, 5394	8/14/2007	H-3	190.06 ± 86.80	69.05 ± 80.88	129.55 ± 59.32	Pass
W-5468, 5469	8/15/2007	H-3	262.58 ± 108.43	346.53 ± 111.42	304.55 ± 77.74	Pass

APPENDIX A, 2007 INTER-LABORATORY CROSS CHECK COMPARISON PROGRAM RESULTS

TABLE A-5. In-House "Duplicate" Samples

Lab Code	Date	Analysis	Concentration (pCi/L) ^a			Acceptance
			First Result	Second Result	Averaged Result	
VE-5553, 5554	8/22/2007	K-40	1.89 ± 0.33	1.89 ± 0.22	1.89 ± 0.20	Pass
WW-5643, 5644	8/22/2007	H-3	259.00 ± 110.00	266.00 ± 110.00	262.50 ± 77.78	Pass
SWU-5799, 5800	8/28/2007	Gr. Beta	2.64 ± 1.18	3.62 ± 1.06	3.13 ± 0.79	Pass
DW-70752, 70753	8/31/2007	Gr. Alpha	14.41 ± 1.48	12.90 ± 1.50	13.66 ± 1.05	Pass
VE-5917, 5918	9/4/2007	Be-7	0.94 ± 0.17	0.83 ± 0.20	0.89 ± 0.13	Pass
VE-5917, 5918	9/4/2007	K-40	3.73 ± 0.37	3.58 ± 0.36	3.66 ± 0.26	Pass
VE-5917, 5918	9/4/2007	Gr. Beta	2.71 ± 0.10	2.69 ± 0.10	2.70 ± 0.07	Pass
MI-6009, 6010	9/11/2007	K-40	1348.90 ± 113.40	1388.10 ± 116.40	1368.50 ± 81.25	Pass
MI-6030, 6031	9/12/2007	K-40	1242.70 ± 118.00	1475.60 ± 119.60	1359.15 ± 84.01	Pass
MI-6030, 6031	9/12/2007	Sr-90	1.00 ± 0.38	0.90 ± 0.34	0.95 ± 0.26	Pass
DW-70718, 70719	9/12/2007	Gr. Alpha	23.04 ± 3.71	23.22 ± 3.61	23.13 ± 2.59	Pass
DW-70718, 70719	9/12/2007	Gr. Beta	16.13 ± 1.59	17.36 ± 1.69	16.75 ± 1.16	Pass
SO-6156, 6157	9/14/2007	H-3	181.99 ± 90.67	232.19 ± 92.95	207.09 ± 64.92	Pass
SO-6484, 6485	9/17/2007	Cs-137	0.01 ± 0.00	0.01 ± 0.00	0.01 ± 0.00	Pass
SO-6484, 6485	9/17/2007	Gr. Beta	24.20 ± 2.60	23.30 ± 2.30	23.75 ± 1.74	Pass
SO-6484, 6485	9/17/2007	K-40	11.52 ± 1.16	10.89 ± 1.10	11.20 ± 0.80	Pass
WW-6469, 6470	9/21/2007	Gr. Beta	27.19 ± 2.51	24.23 ± 2.29	25.71 ± 1.70	Pass
E-6647, 6648	10/1/2007	Gr. Beta	1.82 ± 0.10	1.93 ± 0.11	1.88 ± 0.07	Pass
E-6647, 6648	10/1/2007	K-40	1.48 ± 0.24	1.31 ± 0.23	1.40 ± 0.17	Pass
WW-6656, 6657	10/1/2007	Gr. Beta	2.80 ± 0.97	1.95 ± 0.87	2.38 ± 0.65	Pass
TD-7080, 7081	10/2/2007	H-3	332.00 ± 229.00	383.00 ± 191.00	357.50 ± 149.10	Pass
SG-6891, 6892	10/3/2007	Gr. Alpha	12.93 ± 2.12	13.52 ± 2.07	13.23 ± 1.48	Pass
SG-6891, 6892	10/3/2007	Gr. Beta	18.08 ± 1.41	18.27 ± 1.36	18.18 ± 0.98	Pass
AP-7191, 7192	10/3/2007	Be-7	0.09 ± 0.01	0.09 ± 0.01	0.09 ± 0.01	Pass
WW-6786, 6787	10/8/2007	H-3	13333 ± 322	13532 ± 324	13433 ± 228	Pass
WW-6786, 6787	10/8/2007	H-3	13188 ± 322	13556 ± 326	13372 ± 229	Pass
VE-6828, 6829	10/8/2007	Gr. Alpha	0.06 ± 0.04	0.06 ± 0.05	0.06 ± 0.03	Pass
VE-6828, 6829	10/8/2007	Gr. Beta	5.55 ± 0.21	5.20 ± 0.22	5.38 ± 0.10	Pass
VE-6828, 6829	10/8/2007	K-40	5.45 ± 0.43	5.20 ± 0.49	5.32 ± 0.33	Pass
SS-6870, 6871	10/9/2007	Gr. Beta	18.10 ± 2.08	21.71 ± 2.19	19.90 ± 1.51	Pass
SS-6870, 6871	10/9/2007	K-40	10.19 ± 0.66	9.72 ± 0.68	9.95 ± 0.47	Pass
LW-7507, 7508	10/11/2007	Gr. Beta	1.40 ± 0.56	1.44 ± 0.54	1.42 ± 0.39	Pass
MI-6933, 6934	10/16/2007	K-40	1386.60 ± 104.70	1331.20 ± 106.70	1358.90 ± 74.74	Pass
MI-6933, 6934	10/16/2007	Sr-90	1.73 ± 0.52	2.17 ± 0.57	1.95 ± 0.39	Pass
MI-7059, 7060	10/17/2007	K-40	1424.80 ± 106.60	1448.60 ± 115.30	1436.70 ± 78.51	Pass
F-7213, 7214	10/24/2007	H-3	6.83 ± 0.22	7.24 ± 0.22	7.03 ± 0.16	Pass
F-7213, 7214	10/24/2007	K-40	3.13 ± 0.51	3.16 ± 0.48	3.15 ± 0.35	Pass
WW-7408, 7409	10/24/2007	H-3	340.71 ± 90.45	346.22 ± 90.67	343.46 ± 64.03	Pass
DW-70856, 70857	10/24/2007	Gr. Alpha	11.03 ± 1.66	10.71 ± 1.34	10.87 ± 1.07	Pass
SO-7508, 7509	10/26/2007	Cs-137	0.30 ± 0.04	0.29 ± 0.05	0.29 ± 0.03	Pass
SO-7508, 7509	10/26/2007	Gr. Beta	34.43 ± 2.72	37.25 ± 3.07	35.84 ± 2.05	Pass
SO-7508, 7509	10/26/2007	K-40	16.84 ± 0.84	17.43 ± 1.05	17.14 ± 0.67	Pass

TABLE A-5. In-House "Duplicate" Samples

Lab Code	Date	Analysis	Concentration (pCi/L) ^a			Acceptance
			First Result	Second Result	Averaged Result	
SS-7529, 7530	10/29/2007	Cs-137	0.12 ± 0.03	0.12 ± 0.02	0.12 ± 0.02	Pass
SS-7529, 7530	10/29/2007	K-40	11.85 ± 0.68	11.75 ± 0.58	11.80 ± 0.45	Pass
SW-7589, 7590	10/30/2007	Gr. Beta	1.75 ± 0.29	1.24 ± 0.26	1.50 ± 0.19	Pass
SWU-7733, 7734	10/30/2007	Gr. Beta	1.66 ± 1.01	2.43 ± 1.13	2.05 ± 0.76	Pass
MI-7618, 7619	10/31/2007	K-40	1376.80 ± 114.30	1426.70 ± 128.80	1401.75 ± 86.10	Pass
VE-7666, 7667	11/5/2007	Gr. Alpha	0.07 ± 0.04	0.16 ± 0.05	0.11 ± 0.03	Pass
VE-7666, 7667	11/5/2007	Gr. Beta	6.03 ± 0.15	6.13 ± 0.15	6.08 ± 0.10	Pass
VE-7666, 7667	11/5/2007	K-40	5.82 ± 0.36	5.74 ± 0.36	5.78 ± 0.25	Pass
DW-7853, 7854	11/9/2007	I-131	1.61 ± 0.40	1.08 ± 0.39	1.35 ± 0.28	Pass
MI-7874, 7875	11/14/2007	K-40	1407.70 ± 101.30	1362.60 ± 114.50	1385.15 ± 76.44	Pass
WW-8142, 8143	11/28/2007	Gr. Beta	9.51 ± 2.21	7.86 ± 2.01	8.68 ± 1.49	Pass
DW-8094, 8095	11/29/2007	Gr. Beta	1.60 ± 0.58	1.25 ± 0.54	1.43 ± 0.40	Pass
F-8328, 8329	12/11/2007	Gr. Beta	3.97 ± 0.08	4.00 ± 0.08	3.99 ± 0.05	Pass
WW-8378, 8379	12/11/2007	H-3	296.00 ± 103.00	407.00 ± 107.00	351.50 ± 74.26	Pass

Note: Duplicate analyses are performed on every twentieth sample received in-house. Results are not listed for those analyses with activities that measure below the LLD.

^a Results are reported in units of pCi/L, except for air filters (pCi/Filter), food products, vegetation, soil, sediment (pCi/g).

TABLE A-6. Department of Energy's Mixed Analyte Performance Evaluation Program (MAPEP)^a.

Lab Code ^c	Date	Analysis	Concentration ^b			Acceptance
			Laboratory result	Known Activity	Control Limits ^d	
STW-1110	01/01/07	Gr. Alpha	0.45 ± 0.08	0.33	0.00 - 0.65	Pass
STW-1110	01/01/07	Gr. Beta	0.90 ± 0.14	0.85	0.43 - 1.28	Pass
STW-1111 ^e	01/01/07	Am-241	2.80 ± 0.21	1.71	1.20 - 2.22	Fail
STW-1111	01/01/07	Co-57	151.60 ± 10.00	143.70	100.60 - 186.80	Pass
STW-1111	01/01/07	Cs-134	79.20 ± 8.00	83.50	58.50 - 108.60	Pass
STW-1111	01/01/07	Cs-137	168.70 ± 12.10	163.00	114.10 - 211.90	Pass
STW-1111	01/01/07	Fe-55	130.30 ± 19.90	129.30	90.50 - 168.10	Pass
STW-1111	01/01/07	H-3	262.20 ± 9.10	283.00	198.10 - 367.90	Pass
STW-1111	01/01/07	Mn-54	130.60 ± 11.50	123.80	86.70 - 160.90	Pass
STW-1111	01/01/07	Ni-63	127.80 ± 3.60	130.40	91.30 - 169.50	Pass
STW-1111	01/01/07	Ni-63	127.80 ± 3.60	130.40	91.30 - 169.50	Pass
STW-1111	01/01/07	Pu-238	2.03 ± 0.17	2.25	1.58 - 2.93	Pass
STW-1111	01/01/07	Pu-239/40	2.27 ± 0.17	2.22	1.55 - 2.89	Pass
STW-1111	01/01/07	Sr-90	9.60 ± 1.40	8.87	6.21 - 11.53	Pass
STW-1111	01/01/07	Tc-99	8.80 ± 1.50	88.00	7.40 - 13.70	Pass
STW-1111	01/01/07	U-233/4	2.44 ± 0.21	2.49	1.74 - 3.24	Pass
STW-1111	01/01/07	U-238	2.44 ± 0.21	2.48	1.74 - 3.22	Pass
STW-1111	01/01/07	Zn-65	123.70 ± 17.00	114.80	80.40 - 149.20	Pass
STSO-1112 ^f	01/01/07	Am-241	46.40 ± 9.00	34.80	24.40 - 45.20	Fail
STSO-1112	01/01/07	Co-57	501.20 ± 2.90	471.20	329.80 - 612.60	Pass
STSO-1112	01/01/07	Co-60	285.90 ± 2.10	274.70	192.30 - 357.10	Pass
STSO-1112	01/01/07	Cs-134	325.90 ± 7.40	327.40	229.20 - 425.60	Pass
STSO-1112	01/01/07	Cs-137	855.70 ± 4.60	799.70	559.80 - 1039.60	Pass
STSO-1112	01/01/07	Mn-54	750.90 ± 4.70	685.20	479.60 - 890.80	Pass
STAP-1113	01/01/07	Gr. Alpha	0.27 ± 0.04	0.60	0.00 - 1.20	Pass
STAP-1113	01/01/07	Gr. Beta	0.57 ± 0.05	0.44	0.22 - 0.66	Pass
STAP-1114	01/01/07	Am-241	0.10 ± 0.03	0.10	0.07 - 0.13	Pass
STAP-1114	01/01/07	Co-57	3.51 ± 0.07	2.89	2.02 - 3.75	Pass
STAP-1114	01/01/07	Co-60	2.98 ± 0.10	2.91	2.03 - 3.78	Pass
STAP-1114	01/01/07	Cs-134	4.02 ± 0.16	4.20	2.94 - 5.45	Pass
STAP-1114	01/01/07	Cs-137	2.75 ± 0.12	2.57	1.80 - 3.34	Pass
STAP-1114	01/01/07	Mn-54	3.94 ± 0.12	3.52	2.46 - 4.57	Pass
STAP-1114	01/01/07	Pu-238	0.07 ± 0.01	0.07	0.05 - 0.09	Pass
STAP-1114	01/01/07	Pu-239/40	0.08 ± 0.01	0.08	0.06 - 0.11	Pass
STAP-1114	01/01/07	Sr-90	0.58 ± 0.18	0.61	0.43 - 0.79	Pass
STAP-1114	01/01/07	U-233/4	0.09 ± 0.01	0.10	0.07 - 0.13	Pass
STAP-1114	01/01/07	U-238	0.09 ± 0.01	0.10	0.07 - 0.13	Pass
STAP-1114	01/01/07	Zn-65	2.70 ± 0.10	2.68	1.88 - 3.49	Pass

TABLE A-6. Department of Energy's Mixed Analyte Performance Evaluation Program (MAPEP)^a.

Lab Code ^c	Date	Analysis	Concentration ^b			Acceptance
			Laboratory result	Known Activity	Control Limits ^d	
STVE-1115	01/01/07	Co-57	8.90 ± 0.20	8.19	5.73 - 10.64	Pass
STVE-1115	01/01/07	Co-60	6.50 ± 0.20	5.82	4.08 - 7.57	Pass
STVE-1115	01/01/07	Cs-134	6.90 ± 0.30	6.21	4.35 - 8.07	Pass
STVE-1115	01/01/07	Cs-137	8.20 ± 0.30	6.99	4.90 - 9.09	Pass
STVE-1115	01/01/07	Mn-54	10.10 ± 0.30	8.46	5.91 - 10.98	Pass

^a Results obtained by Environmental, Inc., Midwest Laboratory as a participant in the Department of Energy's Mixed Analyte Performance Evaluation Program, Idaho Operations office, Idaho Falls, Idaho

^b Results are reported in units of Bq/kg (soil), Bq/L (water) or Bq/total sample (filters, vegetation).

^c Laboratory codes as follows: STW (water), STAP (air filter), STSO (soil), STVE (vegetation).

^d MAPEP results are presented as the known values and expected laboratory precision (1 sigma, 1 determination) and control limits as defined by the MAPEP.

^e Result of reanalysis, 2.08 ± 0.13 pCi/L.

^f The test samples were recounted on lower background detectors. Result of the recounts: 41.4 ± 6.3 Bq/kg.

TABLE A-7. Interlaboratory Comparison Crosscheck program, Environmental Resource Associates (ERA) ^a.

Lab Code ^b	Date	Analysis	Concentration (pCi/L)		Control Limits	Acceptance
			Laboratory Result ^c	ERA Result ^d		
STAP-1116	03/19/07	Gr. Alpha	34.64 ± 2.56	25.8	12.4 - 39	Pass
STAP-1116	03/19/07	Gr. Beta	93.41 ± 3.20	79.5	48.8 - 116	Pass
STAP-1117	03/19/07	Am-241	56.04 ± 3.90	57.5	33.1 - 80	Pass
STAP-1117	03/19/07	Co-60	1610.00 ± 8.40	1300.0	1010.0 - 1620	Pass
STAP-1117	03/19/07	Cs-134	1340.40 ± 48.84	1120.0	732.0 - 1380	Pass
STAP-1117 ^e	03/19/07	Cs-137	345.30 ± 8.20	255.0	192.0 - 336	Fail
STAP-1117 ^f	03/19/07	Fe-55	< 134.0	0.0		Pass
STAP-1117 ^f	03/19/07	Mn-54	< 5.0	0.0		Pass
STAP-1117	03/19/07	Pu-238	43.32 ± 2.28	37.4	25.7 - 49	Pass
STAP-1117	03/19/07	Pu-239/40	35.23 ± 2.24	31.6	22.9 - 41	Pass
STAP-1117	03/19/07	Sr-90	156.10 ± 6.60	156.0	66.6 - 246	Pass
STAP-1117	03/19/07	U-233/4	42.22 ± 1.84	47.8	30.1 - 71	Pass
STAP-1117	03/19/07	U-238	42.00 ± 1.84	47.4	30.2 - 68	Pass
STAP-1117	03/19/07	Uranium	85.79 ± 3.60	97.3	49.5 - 155	Pass
STAP-1117	03/19/07	Zn-65	363.80 ± 11.90	245.0	208.0 - 412	Pass
STSO-1118	03/19/07	Ac-228	3097.77 ± 94.96	2790.0	1790.0 - 3930	Pass
STSO-1118	03/19/07	Am-241	1000.70 ± 156.10	927.0	548.0 - 1200	Pass
STSO-1118	03/19/07	Bi-212	2467.87 ± 114.33	2500.0	658.0 - 3730	Pass
STSO-1118	03/19/07	Co-60	7847.40 ± 86.60	7330.0	5340.0 - 9820	Pass
STSO-1118	03/19/07	Cs-134	7910.60 ± 356.88	7560.0	4850.0 - 9070	Pass
STSO-1118	03/19/07	Cs-137	4635.00 ± 99.10	4300.0	3290.0 - 5580	Pass
STSO-1118	03/19/07	K-40	12201.60 ± 423.20	11100.0	8050.0 - 15000	Pass
STSO-1118 ^f	03/19/07	Mn-54	< 34.0	0.0		Pass
STSO-1118	03/19/07	Pb-212	2046.80 ± 127.20	1730.0	1120.0 - 2430	Pass
STSO-1118	03/19/07	Pb-214	4142.80 ± 110.40	3330.0	1980.0 - 4980	Pass
STSO-1118	03/19/07	Pu-238	1099.20 ± 73.10	857.0	490.0 - 1200	Pass
STSO-1118	03/19/07	Pu-239/40	1586.10 ± 82.00	1360.0	928.0 - 1810	Pass
STSO-1118	03/19/07	Sr-90	6163.30 ± 791.60	7500.0	2610.0 - 12400	Pass
STSO-1118	03/19/07	Th-234	4329.40 ± 569.10	3590.0	2190.0 - 4560	Pass
STSO-1118	03/19/07	U-233/4	3236.70 ± 106.00	3620.0	2280.0 - 4520	Pass
STSO-1118	03/19/07	U-238	3425.20 ± 134.00	3590.0	2190.0 - 4560	Pass
STSO-1118	03/19/07	Uranium	6787.80 ± 240.00	7380.0	4210.0 - 9930	Pass
STSO-1118	03/19/07	Uranium	6787.80 ± 240.00	7380.0	4210.0 - 9930	Pass
STSO-1118 ^f	03/19/07	Zn-65	0.00 ± 0.00	0.0	0.0 - 0	Pass

TABLE A-7. Interlaboratory Comparison Crosscheck program, Environmental Resource Associates (ERA)^a.

Lab Code ^b	Date	Analysis	Concentration (pCi/L)		Control Limits	Acceptance
			Laboratory Result ^c	ERA Result ^d		
STVE-1119	03/19/07	Am-241	3249.60 ± 150.30	3550.0	2020.0 - 4890	Pass
STVE-1119	03/19/07	Cm-244	1860.70 ± 91.50	1840.0	905.0 - 2870	Pass
STVE-1119	03/19/07	Co-60	2827.90 ± 62.40	2600.0	1760.0 - 3720	Pass
STVE-1119	03/19/07	Cs-134	654.80 ± 48.40	579.0	308.0 - 822	Pass
STVE-1119	03/19/07	Cs-137	3307.30 ± 58.80	2920.0	2150.0 - 4060	Pass
STVE-1119	03/19/07	K-40	40814.20 ± 618.80	37900.0	27200.0 - 53600	Pass
STVE-1119 ^f	03/19/07	Mn-54	< 27.6	0.0		Pass
STVE-1119	03/19/07	Pu-238	2762.00 ± 251.10	2430.0	1250.0 - 3600	Pass
STVE-1119	03/19/07	Pu-239/40	2156.60 ± 83.40	1900.0	1180.0 - 2600	Pass
STVE-1119	03/19/07	Sr-90	8999.70 ± 580.90	8890.0	4900.0 - 11800	Pass
STVE-1119	03/19/07	U-233/4	2821.90 ± 73.50	2940.0	1930.0 - 3920	Pass
STVE-1119	03/19/07	U-238	2896.10 ± 50.70	2910.0	2090.0 - 3610	Pass
STVE-1119	03/19/07	Uranium	5718.00 ± 124.15	5980.0	4110.0 - 7770	Pass
STVE-1119	03/19/07	Zn-65	474.30 ± 45.70	366.0	267.0 - 500	Pass
STW-1120	03/19/07	Am-241	133.50 ± 10.60	179.0	123.0 - 243	Pass
STW-1120	03/19/07	Co-60	541.40 ± 9.00	536.0	467.0 - 631	Pass
STW-1120	03/19/07	Cs-134	1623.80 ± 66.10	1750.0	1290.0 - 2020	Pass
STW-1120	03/19/07	Cs-137	1839.10 ± 17.90	1850.0	1570.0 - 2220	Pass
STW-1120	03/19/07	Fe-55	829.50 ± 226.80	671.0	392.0 - 896	Pass
STW-1120 ^f	03/19/07	Mn-54	< 8.1	0.0		Pass
STW-1120	03/19/07	Pu-238	123.30 ± 4.30	116.0	87.6 - 144	Pass
STW-1120	03/19/07	Pu-239/40	95.10 ± 3.80	90.9	70.3 - 113	Pass
STW-1120	03/19/07	Sr-90	949.40 ± 16.70	989.0	630.0 - 1320	Pass
STW-1120	03/19/07	U-233/4	164.20 ± 6.58	192.0	145.0 - 247	Pass
STW-1120	03/19/07	U-238	169.20 ± 8.22	190.0	145.0 - 236	Pass
STW-1120	03/19/07	Uranium	339.60 ± 10.66	391.0	282.0 - 521	Pass
STW-1120	03/19/07	Zn-65	2009.00 ± 36.40	1910.0	1600.0 - 2410	Pass

^a Results obtained by Environmental, Inc., Midwest Laboratory as a participant in the crosscheck program for proficiency testing administered by Environmental Resources Associates, serving as a replacement for studies conducted previously by the Environmental Measurements Laboratory Quality Assessment Program (EML).

^b Laboratory codes as follows: STW (water), STAP (air filter), STSO (soil), STVE (vegetation).

^c Unless otherwise indicated, the laboratory result is given as the mean ± standard deviation for three determinations.

^d Results are presented as the known values, expected laboratory precision (1 sigma, 1 determination) and control limits as provided by ERA.

^e A high bias (~ 20%) was observed in gamma results for air filters. A composite filter geometry was used in the calculations vs. a single filter geometry. Result of recalculation. Cs-137, 305.8 ± 6.0 pCi/filter.

^f Included in the testing series as a "false positive". No activity expected.

Air Gamma Spectral Summary Report 2007
 Radiological Environmental Monitoring Program Data Summary
 Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Type and Units	Type and Number of Analyses Performed	Lower Limit (LLD)	Mean of Results from All Locations and Number Detected/Number Collected and Range	Mean of Results from All Indicator Locations and Number Detected/Number Collected and Range	Location with Highest Annual Mean:		Mean of Results from All Control Locations and Number Detected/Number Collected and Range
					Location # and Distance and Direction	Mean and Number Detected/Number Collected and Range	
Air pCi/m3	Be-7 28	N/A	0.07 28 / 28 0.05 - 0.12	0.07 24 / 24 0.05 - 0.12	7 0.60 NE	0.08 4 / 20 0.05 - 0.12	0.07 4 / 4 0.05 - 0.08
Air pCi/m3	Co-58 28	N/A	LLD	-	-	-	-
Air pCi/m3	Co-60 28	N/A	LLD	-	-	-	-
Air pCi/m3	Cs-134 28	0.04	LLD	-	-	-	-
Air pCi/m3	Cs-137 28	0.05	LLD	-	-	-	-

APPENDIX B, 2007 REMP DATA SUMMARY REPORTS

Air Gross Beta Summary Report 2007
 Radiological Environmental Monitoring Program Data Summary
 Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Type and Units	Type and Number of Analyses Performed	Lower Limit (LLD)	Mean of Results from All Locations and Number Detected/Number Collected and Range	Mean of Results from All Indicator Locations and Number Detected/Number Collected and Range	Location with Highest Annual Mean:		Mean of Results from All Control Locations and Number Detected/Number Collected and Range
					Location # and Distance and Direction	Mean and Number Detected/Number Collected and Range	
Air pCi/m3	Gross Beta 362	0.01	0.02 362 / 362 0.01 - 0.05	0.02 311 / 311 0.01 - 0.05	6 11.00 SSW	0.03 51 / 51 0.01 - 0.05	0.03 51 / 51 0.01 - 0.05

Air Iodine Summary Report 2007
 Radiological Environmental Monitoring Program Data Summary
 Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Type and Units	Type and Number of Analyses Performed	Lower Limit (LLD)	Mean of Results from All Locations and Number Detected/Number Collected and Range	Mean of Results from All Indicator Locations and Number Detected/Number Collected and Range	Location with Highest Annual Mean:		Mean of Results from All Control Locations and Number Detected/Number Collected and Range
					Location # and Distance and Direction	Mean and Number Detected/Number Collected and Range	
Air pCi/m3	I-131 362	0.05	LLD	-	-	-	-

Fish Gamma Spectral Summary Report 2007
 Radiological Environmental Monitoring Program Data Summary
 Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Type and Units	Type and Number of Analyses Performed	Lower Limit (LLD)	Mean of Results from All Locations and Number Detected/Number Collected and Range	Mean of Results from All Indicator Locations and Number Detected/Number Collected and Range	Location with Highest Annual Mean:		Mean of Results from All Control Locations and Number Detected/Number Collected and Range
					Location # and Distance and Direction	Mean and Number Detected/Number Collected and Range	
Fish pCi/kg wet	Co-58 2	97.00	LLD	-	-	-	-
Fish pCi/kg wet	Co-60 2	97.00	LLD	-	-	-	-
Fish pCi/kg wet	Cs-134 2	97.00	LLD	-	-	-	-
Fish pCi/kg wet	Cs-137 2	112.00	LLD	-	-	-	-
Fish pCi/kg wet	Fe-59 2	195.00	LLD	-	-	-	-
Fish pCi/kg wet	K-40 2	N/A	1.631.65 2 / 2 1.619.90 - 1.643.40	1.643.40 1 / 1 1.643.40 - 1.643.40	25 0.60 NNW	1.643.40 1 / 8 1.643.40 - 1.643.40	1.619.90 1 / 1 1.619.90 - 1.619.90
Fish pCi/kg wet	Mn-54 2	97.00	LLD	-	-	-	-
Fish pCi/kg wet	Zn-65 2	195.00	LLD	-	-	-	-

APPENDIX B, 2007 REMP DATA SUMMARY REPORTS

Food Products Gamma Spectral Summary Report 2007
 Radiological Environmental Monitoring Program Data Summary
 Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Type and Units	Type and Number of Analyses Performed	Lower Limit (LLD)	Mean of Results from All Locations and Number Detected/Number Collected and Range	Mean of Results from All Indicator Locations and Number Detected/Number Collected and Range	Location with Highest Annual Mean:		Mean of Results from All Control Locations and Number Detected/Number Collected and Range
					Location # and Distance and Direction	Mean and Number Detected/Number Collected and Range.	
Food Products pCi/kg wet	Be-7 50	N/A	373.64 24 / 50 130.09 - 864.18	379.91 19 / 38 130.09 - 864.18	20 1.90 E	562.27 4 / 28 362.70 - 800.39	349.79 5 / 12 161.03 - 490.06
Food Products pCi/kg wet	Co-58 50	N/A	LLD	-	-	-	-
Food Products pCi/kg wet	Co-60 50	N/A	LLD	-	-	-	-
Food Products pCi/kg wet	Cs-134 50	45.00	LLD	-	-	-	-
Food Products pCi/kg wet	Cs-137 50	60.00	LLD	-	-	-	-
Food Products pCi/kg wet	I-131 50	45.00	LLD	-	-	-	-
Food Products pCi/kg wet	K-40 50	N/A	5.819.23 50 / 50 2.777.20 - 10.667.00	5.773.22 38 / 38 3.551.80 - 7.778.10	37 1.50 ENE	6.108.58 12 / 84 3.551.80 - 7.778.10	5.964.90 12 / 12 2.777.20 - 10.667.00

APPENDIX B: 2007 REMP DATA SUMMARY REPORTS

Milk Gamma Spectral Summary Report 2007
 Radiological Environmental Monitoring Program Data Summary
 Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Type and Units	Type and Number of Analyses Performed	Lower Limit (LLD)	Mean of Results from All Locations and Number Detected/Number Collected and Range	Mean of Results from All Indicator Locations and Number Detected/Number Collected and Range	Location with Highest Annual Mean:		Mean of Results from All Control Locations and Number Detected/Number Collected and Range
					Location # and Distance and Direction	Mean and Number Detected/Number Collected and Range	
Milk pCi/L	Ba-140 42	45.00	LLD	-	-	-	-
Milk pCi/L	Cs-134 42	11.00	LLD	-	-	-	-
Milk pCi/L	Cs-137 42	13.00	LLD	-	-	-	-
Milk pCi/L	K-40 42	N/A	1.561.10 42 / 42 600.54 - 2.080.50	1.792.18 23 / 23 1.575.10 - 2.080.50	61 7.40 SE	1.807.90 14 / 70 1.609.30 - 2.080.50	1.281.35 19 / 19 600.54 - 1.488.30
Milk pCi/L	La-140 42	11.00	LLD	-	-	-	-

APPENDIX B, 2007 REMP DATA SUMMARY REPORTS

Milk Iodine Summary Report 2007
 Radiological Environmental Monitoring Program Data Summary
 Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Type and Units	Type and Number of Analyses Performed	Lower Limit (LLD)	Mean of Results from All Locations and Number Detected/Number Collected and Range	Mean of Results from All Indicator Locations and Number Detected/Number Collected and Range	Location with Highest Annual Mean:		Mean of Results from All Control Locations and Number Detected/Number Collected and Range
					Location # and Distance and Direction	Mean and Number Detected/Number Collected and Range	
Milk pCi/L	I-131 42	0.75	LLD	-	-	-	-

Sediment Gamma Spectral Summary Report 2007
 Radiological Environmental Monitoring Program Data Summary
 Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Type and Units	Type and Number of Analyses Performed	Lower Limit (LLD)	Mean of Results from All Locations and Number Detected/Number Collected and Range	Mean of Results from All Indicator Locations and Number Detected/Number Collected and Range	Location with Highest Annual Mean:		Mean of Results from All Control Locations and Number Detected/Number Collected and Range
					Location # and Distance and Direction	Mean and Number Detected/Number Collected and Range	
Sediment pCi/kg drv	Cs-137 12	135.00	451.70 5 / 12 147.68 - 844.36	200.74 3 / 10 147.68 - 246.38	32 15.80 WSW	828.13 2 / 10 811.89 - 844.36	828.13 2 / 2 811.89 - 844.36
Sediment pCi/kg drv	K-40 12	N/A	14.054.43 12 / 12 7.272.20 - 25.332.00	11.810.02 10 / 10 7.272.20 - 15.642.00	32 15.80 WSW	25.276.50 2 / 10 25.221.00 - 25.332.00	25.276.50 2 / 2 25.221.00 - 25.332.00
Sediment pCi/kg drv	Co-58 12	50.00	LLD	-	-	-	-
Sediment pCi/kg drv	Co-60 12	40.00	LLD	-	-	-	-
Sediment pCi/kg drv	Cs-134 12	112.00	LLD	-	-	-	-

APPENDIX B, 2007 REMP DATA SUMMARY REPORTS

TLD Gamma Dose Summary Report 2007
 Radiological Environmental Monitoring Program Data Summary
 Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Type and Units	Type and Number of Analyses Performed	Lower Limit (LLD)	Mean of Results from All Locations and Number Detected/Number Collected and Range	Mean of Results from All Indicator Locations and Number Detected/Number Collected and Range	Location with Highest Annual Mean:		Mean of Results from All Control Locations and Number Detected/Number Collected and Range
					Location # and Distance and Direction	Mean and Number Detected/Number Collected and Range	
TLD mR/91 days	Direct 112	1.00	13.19 112 / 112 7.69 - 18.75	13.21 104 / 104 7.69 - 18.75	29 4.30 SSE	17.11 4 / 4 15.82 - 18.57	12.89 8 / 8 12.13 - 14.33
TLD mR/91 days	Direct 112	1.00	12.86 112 / 112 8.58 - 17.74	12.90 104 / 104 8.58 - 17.74	33 4.50 S	16.60 4 / 4 15.78 - 17.74	12.39 8 / 8 10.99 - 13.65
TLD mR/365 days	Direct 28	1.00	52.48 28 / 28 40.95 - 68.88	52.70 26 / 26 40.95 - 68.88	33 4.50 S	68.88 1 / 1 68.88 - 68.88	49.63 2 / 2 46.35 - 52.90

Water Gamma Spectral Summary Report 2007
 Radiological Environmental Monitoring Program Data Summary
 Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Type and Units	Type and Number of Analyses Performed	Lower Limit (LLD)	Mean of Results from All Locations and Number Detected/Number Collected and Range	Mean of Results from All Indicator Locations and Number Detected/Number Collected and Range	Location with Highest Annual Mean:		Mean of Results from All Control Locations and Number Detected/Number Collected and Range
					Location # and Distance and Direction	Mean and Number Detected/Number Collected and Range	
Water pCi/L	Ba-140 52	45.00	LLD	-	-	-	-
Water pCi/L	Nb-95 52	11.00	LLD	-	-	-	-
Water pCi/L	Zn-65 52	22.00	LLD	-	-	-	-
Water pCi/L	Zr-95 52	22.00	LLD	-	-	-	-
Water pCi/L	Co-58 52	11.00	LLD	-	-	-	-
Water pCi/L	Co-60 52	11.00	LLD	-	-	-	-
Water pCi/L	Cs-134 52	11.00	LLD	-	-	-	-
Water pCi/L	Cs-137 52	13.00	LLD	-	-	-	-
Water pCi/L	Fe-59 52	22.00	LLD	-	-	-	-
Water pCi/L	La-140 52	11.00	LLD	-	-	-	-

Water Gamma Spectral Summary Report 2007

Radiological Environmental Monitoring Program Data Summary

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Type and Units	Type and Number of Analyses Performed	Lower Limit (LLD)	Mean of Results from All Locations and Number Detected/Number Collected and Range	Mean of Results from All Indicator Locations and Number Detected/Number Collected and Range	Location with Highest Annual Mean:		Mean of Results from All Control Locations and Number Detected/Number Collected and Range
					Location # and Distance and Direction	Mean and Number Detected/Number Collected and Range	
Water pCi/L	Mn-54 52	11.00	LLD				

Water Gross Beta Summary Report 2007
 Radiological Environmental Monitoring Program Data Summary
 Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Type and Units	Type and Number of Analyses Performed	Lower Limit (LLD)	Mean of Results from All Locations and Number Detected/Number Collected and Range	Mean of Results from All Indicator Locations and Number Detected/Number Collected and Range	Location with Highest Annual Mean:		Mean of Results from All Control Locations and Number Detected/Number Collected and Range
					Location # and Distance and Direction	Mean and Number Detected/Number Collected and Range	
Water pCi/L	Gross Beta 52	3.00	3.68 3 / 52 3.17 - 3.97	3.53 2 / 40 3.17 - 3.89	28 22.00 ENE	3.97 1 / 12 3.97 - 3.97	3.97 1 / 12 3.97 - 3.97

Water Tritium Summary Report 2007
 Radiological Environmental Monitoring Program Data Summary
 Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Type and Units	Type and Number of Analyses Performed	Lower Limit (LLD)	Mean of Results from All Locations and Number Detected/Number Collected and Range	Mean of Results from All Indicator Locations and Number Detected/Number Collected and Range	Location with Highest Annual Mean:		Mean of Results from All Control Locations and Number Detected/Number Collected and Range
					Location # and Distance and Direction	Mean and Number Detected/Number Collected and Range	
Water pCi/L	H-3 18	1.500.00	LLD				

Air Gamma Spectral Detail Report 2007

Radiological Environmental Monitoring Program Detail Data

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Frequency is: Quarterly Results in pCi/m3 +/- 2 Sigma

Location	Sample Type	Collection Date	Bc-7	Co-58	Co-60	Cs-134	Cs-137
1	Air	3/28/2007	0.062 +/- 0.010	< 0.000	< 0.000	< 0.000	< 0.001
1	Air	6/27/2007	0.107 +/- 0.012	< 0.000	< 0.000	< 0.000	< 0.001
1	Air	10/3/2007	0.079 +/- 0.009	< 0.000	< 0.000	< 0.000	< 0.000
1	Air	1/2/2008	0.062 +/- 0.008	< 0.000	< 0.000	< 0.000	< 0.000
3	Air	3/28/2007	0.066 +/- 0.008	< 0.000	< 0.000	< 0.000	< 0.000
3	Air	6/27/2007	0.079 +/- 0.007	< 0.000	< 0.000	< 0.000	< 0.000
3	Air	10/3/2007	0.073 +/- 0.010	< 0.000	< 0.000	< 0.000	< 0.000
3	Air	1/2/2008	0.050 +/- 0.006	< 0.000	< 0.000	< 0.000	< 0.000
4	Air	3/28/2007	0.055 +/- 0.010	< 0.000	< 0.000	< 0.000	< 0.000
4	Air	6/27/2007	0.089 +/- 0.011	< 0.001	< 0.000	< 0.000	< 0.000

APPENDIX C, 2007 REMP DETAILED DATA REPORT

Air Gamma Spectral Detail Report 2007

Radiological Environmental Monitoring Program Detail Data

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Frequency is: Quarterly Results in pCi/m3 +/- 2 Sigma

Location	Sample Type	Collection Date	Be-7	Co-58	Co-60	Cs-134	Cs-137
4	Air	10/3/2007	0.076 +/- 0.011	< 0.000	< 0.000	< 0.000	< 0.000
4	Air	1/2/2008	0.055 +/- 0.008	< 0.001	< 0.000	< 0.000	< 0.000
5	Air	3/28/2007	0.068 +/- 0.009	< 0.000	< 0.000	< 0.000	< 0.000
5	Air	6/27/2007	0.098 +/- 0.010	< 0.000	< 0.000	< 0.000	< 0.000
5	Air	10/3/2007	0.071 +/- 0.008	< 0.000	< 0.000	< 0.000	< 0.000
5	Air	1/2/2008	0.062 +/- 0.009	< 0.000	< 0.000	< 0.000	< 0.000
6	Air	3/28/2007	0.065 +/- 0.010	< 0.000	< 0.000	< 0.000	< 0.000
6	Air	6/27/2007	0.082 +/- 0.011	< 0.001	< 0.001	< 0.000	< 0.000
6	Air	10/3/2007	0.075 +/- 0.008	< 0.000	< 0.000	< 0.000	< 0.000
6	Air	1/2/2008	0.054 +/- 0.010	< 0.000	< 0.000	< 0.000	< 0.000

APPENDIX C, 2007 REMM DETAILED DATA REPORT

Air Gamma Spectral Detail Report 2007

Radiological Environmental Monitoring Program Detail Data

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Frequency is: Quarterly Results in pCi/m3 +/- 2 Sigma

Location	Sample Type	Collection Date	Bc-7	Co-58	Co-60	Cs-134	Cs-137
7	Air	3/28/2007	0.080 +/- 0.013	< 0.000	< 0.000	< 0.000	< 0.000
7	Air	6/27/2007	0.125 +/- 0.014	< 0.001	< 0.001	< 0.000	< 0.000
7	Air	10/3/2007	0.076 +/- 0.009	< 0.000	< 0.000	< 0.000	< 0.000
7	Air	1/2/2008	0.054 +/- 0.009	< 0.000	< 0.000	< 0.000	< 0.000
35	Air	3/28/2007	0.066 +/- 0.011	< 0.000	< 0.000	< 0.000	< 0.000
35	Air	6/27/2007	0.105 +/- 0.013	< 0.000	< 0.000	< 0.000	< 0.000
35	Air	10/3/2007	0.069 +/- 0.009	< 0.000	< 0.000	< 0.000	< 0.000
35	Air	1/2/2008	0.053 +/- 0.010	< 0.000	< 0.000	< 0.000	< 0.000

APPENDIX C, 2007 REMP DETAILED DATA REPORT

Air Gross Beta Detail Report 2007

Radiological Environmental Monitoring Program Data Summary

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Frequency is: Weekly Results in pCi/m3 +/- 2 Sigma

Collection Date	Sample Type	Location				
		1 7	3 35	4	5	6
1/10/2007	Air	0.023 +/- 0.003 0.022 +/- 0.003	0.022 +/- 0.003 0.019 +/- 0.003	0.018 +/- 0.003	0.021 +/- 0.003	0.026 +/- 0.003
1/17/2007	Air	0.015 +/- 0.002 0.016 +/- 0.003	0.016 +/- 0.003 0.017 +/- 0.003	0.014 +/- 0.003	0.016 +/- 0.003	0.025 +/- 0.003
1/24/2007	Air	0.027 +/- 0.003 0.028 +/- 0.003	0.026 +/- 0.003 0.025 +/- 0.003	0.026 +/- 0.003	0.026 +/- 0.003	0.026 +/- 0.003
1/31/2007	Air	0.027 +/- 0.003 0.030 +/- 0.003	0.032 +/- 0.003 0.030 +/- 0.003	0.029 +/- 0.003	0.030 +/- 0.003	0.029 +/- 0.003
2/7/2007	Air	0.032 +/- 0.003 0.041 +/- 0.004	0.028 +/- 0.003 0.032 +/- 0.003	0.035 +/- 0.003	0.029 +/- 0.003	0.028 +/- 0.003
2/14/2007	Air	0.030 +/- 0.003 0.030 +/- 0.003	0.030 +/- 0.003 0.028 +/- 0.003	0.028 +/- 0.003	0.031 +/- 0.003	0.028 +/- 0.003
2/21/2007	Air	0.024 +/- 0.003 0.025 +/- 0.003	0.027 +/- 0.003 0.025 +/- 0.003	0.025 +/- 0.003	0.027 +/- 0.003	0.027 +/- 0.003
2/28/2007	Air	0.019 +/- 0.003 0.019 +/- 0.003	0.019 +/- 0.003 0.021 +/- 0.003	0.021 +/- 0.003	0.018 +/- 0.003	0.019 +/- 0.003
3/7/2007	Air	0.021 +/- 0.003 0.022 +/- 0.003	0.024 +/- 0.003 0.023 +/- 0.003	0.023 +/- 0.003	0.024 +/- 0.003	0.020 +/- 0.003
3/14/2007	Air	0.040 +/- 0.003 0.031 +/- 0.003	0.030 +/- 0.003 0.029 +/- 0.003	0.030 +/- 0.003	0.028 +/- 0.003	0.030 +/- 0.003
3/21/2007	Air	0.024 +/- 0.003 0.024 +/- 0.003	0.025 +/- 0.003 0.024 +/- 0.003	0.028 +/- 0.003	0.023 +/- 0.003	0.027 +/- 0.003
3/28/2007	Air	0.022 +/- 0.003 0.021 +/- 0.003	0.021 +/- 0.003 0.019 +/- 0.003	0.021 +/- 0.003	0.021 +/- 0.003	0.022 +/- 0.003
4/4/2007	Air	0.018 +/- 0.003 0.021 +/- 0.003	0.016 +/- 0.003 0.019 +/- 0.003	0.019 +/- 0.003	0.019 +/- 0.003	0.022 +/- 0.003
4/11/2007	Air	0.010 +/- 0.002 0.012 +/- 0.003	0.014 +/- 0.003 0.012 +/- 0.003	0.012 +/- 0.003	0.011 +/- 0.003	

APPENDIX C, 2007 REMP DETAILED DATA REPORT

Air Gross Beta Detail Report 2007

Radiological Environmental Monitoring Program Data Summary

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Frequency is: Weekly Results in pCi/m3 +/- 2 Sigma

Collection Date	Sample Type	Location				
		1 7	3 35	4	5	6
4/18/2007	Air	0.016 +/- 0.003 0.017 +/- 0.003	0.018 +/- 0.003 0.016 +/- 0.003	0.017 +/- 0.003	0.017 +/- 0.003	0.017 +/- 0.003
4/25/2007	Air	0.017 +/- 0.003 0.020 +/- 0.003	0.016 +/- 0.003 0.020 +/- 0.003	0.020 +/- 0.003	0.020 +/- 0.003	0.021 +/- 0.003
5/2/2007	Air	0.015 +/- 0.003 0.018 +/- 0.003	0.016 +/- 0.003	0.015 +/- 0.003	0.015 +/- 0.003	0.015 +/- 0.003
5/9/2007	Air	0.017 +/- 0.003 0.020 +/- 0.003	0.019 +/- 0.003 0.026 +/- 0.015	0.019 +/- 0.003	0.018 +/- 0.003	0.020 +/- 0.003
5/16/2007	Air	0.024 +/- 0.003 0.024 +/- 0.003	0.021 +/- 0.003 0.021 +/- 0.003	0.022 +/- 0.003	0.024 +/- 0.003	0.022 +/- 0.003
5/23/2007	Air	0.015 +/- 0.003 0.018 +/- 0.003	0.014 +/- 0.002 0.018 +/- 0.003	0.017 +/- 0.003	0.017 +/- 0.003	0.017 +/- 0.003
5/30/2007	Air	0.033 +/- 0.003 0.034 +/- 0.003	0.029 +/- 0.003 0.034 +/- 0.003	0.036 +/- 0.003	0.037 +/- 0.003	0.032 +/- 0.003
6/6/2007	Air	0.029 +/- 0.003 0.035 +/- 0.003	0.024 +/- 0.003 0.029 +/- 0.003	0.030 +/- 0.003	0.033 +/- 0.003	0.028 +/- 0.003
6/13/2007	Air	0.019 +/- 0.003 0.020 +/- 0.003	0.019 +/- 0.003 0.023 +/- 0.003	0.022 +/- 0.003	0.022 +/- 0.003	0.022 +/- 0.003
6/20/2007	Air	0.025 +/- 0.003 0.027 +/- 0.003	0.024 +/- 0.003 0.023 +/- 0.003	0.026 +/- 0.003	0.028 +/- 0.003	0.025 +/- 0.003
6/27/2007	Air	0.023 +/- 0.003 0.023 +/- 0.003	0.018 +/- 0.003 0.021 +/- 0.003	0.020 +/- 0.003	0.020 +/- 0.003	0.023 +/- 0.003
7/4/2007	Air	0.011 +/- 0.003 0.012 +/- 0.003	0.012 +/- 0.002 0.016 +/- 0.003	0.013 +/- 0.003	0.015 +/- 0.003	0.013 +/- 0.002
7/11/2007	Air	0.035 +/- 0.003 0.037 +/- 0.003	0.035 +/- 0.003 0.033 +/- 0.003	0.032 +/- 0.003	0.034 +/- 0.003	0.034 +/- 0.003
7/18/2007	Air	0.014 +/- 0.003 0.015 +/- 0.003	0.014 +/- 0.003 0.015 +/- 0.003	0.014 +/- 0.003	0.016 +/- 0.003	0.014 +/- 0.003

APPENDIX C, 2007 REMP DETAILED DATA REPORT

Air Gross Beta Detail Report 2007

Radiological Environmental Monitoring Program Data Summary

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Frequency is: Weekly Results in pCi/m3 +/- 2 Sigma

Collection Date	Sample Type	Location				
		1 7	3 35	4	5	6
7/25/2007	Air	0.015 +/- 0.003 0.016 +/- 0.003	0.017 +/- 0.003 0.014 +/- 0.003	0.016 +/- 0.003	0.016 +/- 0.003	0.016 +/- 0.003
8/1/2007	Air	0.026 +/- 0.003 0.027 +/- 0.003	0.024 +/- 0.003 0.023 +/- 0.003	0.025 +/- 0.003	0.026 +/- 0.003	0.028 +/- 0.003
8/8/2007	Air	0.046 +/- 0.010 0.037 +/- 0.003	0.035 +/- 0.003 0.037 +/- 0.003	0.038 +/- 0.003	0.038 +/- 0.003	0.038 +/- 0.003
8/15/2007	Air	0.022 +/- 0.003 0.022 +/- 0.003	0.024 +/- 0.003 0.024 +/- 0.003	0.022 +/- 0.003	0.026 +/- 0.003	0.025 +/- 0.003
8/22/2007	Air	0.016 +/- 0.003 0.013 +/- 0.003	0.015 +/- 0.003 0.017 +/- 0.003	0.014 +/- 0.003	0.016 +/- 0.003	0.015 +/- 0.003
8/29/2007	Air	0.020 +/- 0.003 0.020 +/- 0.003	0.018 +/- 0.002 0.020 +/- 0.003	0.021 +/- 0.003	0.022 +/- 0.003	0.020 +/- 0.003
9/5/2007	Air	0.033 +/- 0.003 0.032 +/- 0.003	0.026 +/- 0.003 0.030 +/- 0.003	0.031 +/- 0.003	0.028 +/- 0.003	0.035 +/- 0.003
9/12/2007	Air	0.028 +/- 0.003 0.032 +/- 0.003	0.028 +/- 0.003 0.031 +/- 0.003	0.031 +/- 0.003	0.035 +/- 0.003	0.032 +/- 0.003
9/19/2007	Air	0.016 +/- 0.003 0.021 +/- 0.003	0.018 +/- 0.003 0.020 +/- 0.003	0.015 +/- 0.003	0.018 +/- 0.003	0.019 +/- 0.003
9/26/2007	Air	0.040 +/- 0.003 0.038 +/- 0.003	0.039 +/- 0.003 0.039 +/- 0.003	0.041 +/- 0.003	0.043 +/- 0.003	0.041 +/- 0.003
10/3/2007	Air	0.026 +/- 0.003 0.029 +/- 0.003	0.024 +/- 0.003 0.025 +/- 0.003	0.026 +/- 0.003	0.028 +/- 0.003	0.025 +/- 0.003
10/10/2007	Air	0.025 +/- 0.003 0.028 +/- 0.003	0.027 +/- 0.003 0.026 +/- 0.003	0.027 +/- 0.003	0.028 +/- 0.003	0.026 +/- 0.003
10/17/2007	Air	0.019 +/- 0.002 0.022 +/- 0.003	0.017 +/- 0.002 0.018 +/- 0.002	0.018 +/- 0.003	0.019 +/- 0.002	0.021 +/- 0.003
10/24/2007	Air	0.025 +/- 0.003 0.024 +/- 0.002	0.027 +/- 0.003 0.024 +/- 0.003	0.027 +/- 0.003	0.027 +/- 0.003	0.026 +/- 0.003

APPENDIX C, 2007 REMP DETAILED DATA REPORT

Air Gross Beta Detail Report 2007

Radiological Environmental Monitoring Program Data Summary

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Frequency is: Weekly Results in pCi/m3 +/- 2 Sigma

Collection Date	Sample Type	Location				
		1 7	3 35	4	5	6
10/31/2007	Air	0.019 +/- 0.003 0.019 +/- 0.003	0.019 +/- 0.003 0.020 +/- 0.003	0.017 +/- 0.003	0.019 +/- 0.003	0.020 +/- 0.003
11/7/2007	Air	0.022 +/- 0.003 0.027 +/- 0.003	0.022 +/- 0.003 0.019 +/- 0.003	0.021 +/- 0.003	0.024 +/- 0.003	0.023 +/- 0.003
11/14/2007	Air	0.036 +/- 0.003 0.035 +/- 0.003	0.032 +/- 0.003 0.030 +/- 0.003	0.031 +/- 0.003	0.030 +/- 0.003	0.034 +/- 0.003
11/21/2007	Air	0.023 +/- 0.003 0.024 +/- 0.003	0.027 +/- 0.003 0.024 +/- 0.003	0.024 +/- 0.003	0.023 +/- 0.003	0.029 +/- 0.003
11/28/2007	Air	0.019 +/- 0.003 0.017 +/- 0.003	0.019 +/- 0.003 0.017 +/- 0.003	0.020 +/- 0.003	0.016 +/- 0.003	0.017 +/- 0.003
12/5/2007	Air	0.023 +/- 0.003 0.025 +/- 0.003	0.024 +/- 0.003 0.025 +/- 0.003	0.021 +/- 0.003	0.026 +/- 0.003	0.031 +/- 0.003
12/12/2007	Air	0.029 +/- 0.003 0.032 +/- 0.003	0.028 +/- 0.003 0.030 +/- 0.003	0.028 +/- 0.003	0.029 +/- 0.003	0.030 +/- 0.003
12/19/2007	Air	0.035 +/- 0.003 0.038 +/- 0.003	0.030 +/- 0.003 0.036 +/- 0.003	0.034 +/- 0.003	0.029 +/- 0.003	0.036 +/- 0.003
12/26/2007	Air	0.043 +/- 0.003 0.043 +/- 0.004	0.047 +/- 0.004 0.049 +/- 0.004	0.047 +/- 0.004	0.039 +/- 0.003	0.048 +/- 0.004
1/2/2008	Air	0.034 +/- 0.003 0.036 +/- 0.003	0.035 +/- 0.003 0.031 +/- 0.003	0.036 +/- 0.003	0.035 +/- 0.003	0.040 +/- 0.004

APPENDIX C, 2007 REMP DETAILED DATA REPORT

Air Iodine Detail Report 2007

Radiological Environmental Monitoring Program Detail Data
Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441
Sample Frequency is: Weekly Results in pCi/m3 +/- 2 Sigma

Location	Sample Type	Collection Date	I-131
1	Air	1/10/2007	< 0.003
1	Air	1/17/2007	< 0.006
1	Air	1/24/2007	< 0.007
1	Air	1/31/2007	< 0.008
1	Air	2/7/2007	< 0.008
1	Air	2/14/2007	< 0.006
1	Air	2/21/2007	< 0.009
1	Air	2/28/2007	< 0.006
1	Air	3/7/2007	< 0.007
1	Air	3/14/2007	< 0.006
1	Air	3/21/2007	< 0.003
1	Air	3/28/2007	< 0.005
1	Air	4/4/2007	< 0.008
1	Air	4/11/2007	< 0.003
1	Air	4/18/2007	< 0.006
1	Air	4/25/2007	< 0.005
1	Air	5/2/2007	< 0.005
1	Air	5/9/2007	< 0.007
1	Air	5/16/2007	< 0.005
1	Air	5/23/2007	< 0.006
1	Air	5/30/2007	< 0.007
1	Air	6/6/2007	< 0.006
1	Air	6/13/2007	< 0.007
1	Air	6/20/2007	< 0.004
1	Air	6/27/2007	< 0.007
1	Air	7/4/2007	< 0.006
1	Air	7/11/2007	< 0.007
1	Air	7/18/2007	< 0.006
1	Air	7/25/2007	< 0.008
1	Air	8/1/2007	< 0.006
1	Air	8/8/2007	< 0.017
1	Air	8/15/2007	< 0.007
1	Air	8/22/2007	< 0.011
1	Air	8/29/2007	< 0.004

Air Iodine Detail Report 2007

Radiological Environmental Monitoring Program Detail Data

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Frequency is: Weekly Results in pCi/m3 +/- 2 Sigma

2

Location	Sample Type	Collection Date	I-131
1	Air	9/5/2007	< 0.005
1	Air	9/12/2007	< 0.006
1	Air	9/19/2007	< 0.011
1	Air	9/26/2007	< 0.007
1	Air	10/3/2007	< 0.005
1	Air	10/10/2007	< 0.005
1	Air	10/17/2007	< 0.005
1	Air	10/24/2007	< 0.005
1	Air	10/31/2007	< 0.003
1	Air	11/7/2007	< 0.000
1	Air	11/14/2007	< 0.006
1	Air	11/21/2007	< 0.005
1	Air	11/28/2007	< 0.003
1	Air	12/5/2007	< 0.008
1	Air	12/12/2007	< 0.008
1	Air	12/19/2007	< 0.005
1	Air	12/26/2007	< 0.006
1	Air	1/2/2008	< 0.006
3	Air	1/10/2007	< 0.003
3	Air	1/17/2007	< 0.006
3	Air	1/24/2007	< 0.007
3	Air	1/31/2007	< 0.008
3	Air	2/7/2007	< 0.008
3	Air	2/14/2007	< 0.006
3	Air	2/21/2007	< 0.009
3	Air	2/28/2007	< 0.007
3	Air	3/7/2007	< 0.008
3	Air	3/14/2007	< 0.006
3	Air	3/21/2007	< 0.003
3	Air	3/28/2007	< 0.005
3	Air	4/4/2007	< 0.008
3	Air	4/11/2007	< 0.004
3	Air	4/18/2007	< 0.007
3	Air	4/25/2007	< 0.005

APPENDIX C, 2007 REMP DETAILED DATA REPORT

Air Iodine Detail Report 2007

Radiological Environmental Monitoring Program Detail Data:

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Frequency is: Weekly Results in pCi/m3 +/- 2 Sigma

Location	Sample Type	Collection Date	I-131
3	Air	5/2/2007	< 0.006
3	Air	5/9/2007	< 0.006
3	Air	5/16/2007	< 0.005
3	Air	5/23/2007	< 0.005
3	Air	5/30/2007	< 0.006
3	Air	6/6/2007	< 0.006
3	Air	6/13/2007	< 0.006
3	Air	6/20/2007	< 0.004
3	Air	6/27/2007	< 0.007
3	Air	7/4/2007	< 0.006
3	Air	7/11/2007	< 0.007
3	Air	7/18/2007	< 0.006
3	Air	7/25/2007	< 0.007
3	Air	8/1/2007	< 0.005
3	Air	8/8/2007	< 0.004
3	Air	8/15/2007	< 0.007
3	Air	8/22/2007	< 0.011
3	Air	8/29/2007	< 0.004
3	Air	9/5/2007	< 0.004
3	Air	9/12/2007	< 0.006
3	Air	9/19/2007	< 0.011
3	Air	9/26/2007	< 0.007
3	Air	10/3/2007	< 0.004
3	Air	10/10/2007	< 0.005
3	Air	10/17/2007	< 0.005
3	Air	10/24/2007	< 0.005
3	Air	10/31/2007	< 0.003
3	Air	11/7/2007	< 0.000
3	Air	11/14/2007	< 0.006
3	Air	11/21/2007	< 0.005
3	Air	11/28/2007	< 0.003
3	Air	12/5/2007	< 0.008
3	Air	12/12/2007	< 0.008
3	Air	12/19/2007	< 0.005
3	Air	12/26/2007	< 0.006

APPENDIX C: 2007 REMP DETAILED DATA REPORT

Air Iodine Detail Report 2007

Radiological Environmental Monitoring Program Detail Data

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Frequency is: Weekly Results in pCi/m3 +/- 2 Sigma

Location	Sample Type	Collection Date	I-131
3	Air	1/2/2008	< 0.006
4	Air	1/10/2007	< 0.003
4	Air	1/17/2007	< 0.006
4	Air	1/24/2007	< 0.007
4	Air	1/31/2007	< 0.008
4	Air	2/7/2007	< 0.008
4	Air	2/14/2007	< 0.006
4	Air	2/21/2007	< 0.009
4	Air	2/28/2007	< 0.006
4	Air	3/7/2007	< 0.008
4	Air	3/14/2007	< 0.006
4	Air	3/21/2007	< 0.003
4	Air	3/28/2007	< 0.005
4	Air	4/4/2007	< 0.008
4	Air	4/11/2007	< 0.004
4	Air	4/18/2007	< 0.006
4	Air	4/25/2007	< 0.005
4	Air	5/2/2007	< 0.006
4	Air	5/9/2007	< 0.007
4	Air	5/16/2007	< 0.005
4	Air	5/23/2007	< 0.006
4	Air	5/30/2007	< 0.007
4	Air	6/6/2007	< 0.006
4	Air	6/13/2007	< 0.007
4	Air	6/20/2007	< 0.004
4	Air	6/27/2007	< 0.008
4	Air	7/4/2007	< 0.006
4	Air	7/11/2007	< 0.007
4	Air	7/18/2007	< 0.006
4	Air	7/25/2007	< 0.007
4	Air	8/1/2007	< 0.005
4	Air	8/8/2007	< 0.004
4	Air	8/15/2007	< 0.008
4	Air	8/22/2007	< 0.011

APPENDIX C, 2007 REMP DETAILED DATA REPORT

Air Iodine Detail Report 2007

Radiological Environmental Monitoring Program Detail Data
 Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441
 Sample Frequency is: Weekly Results in pCi/m3 +/- 2 Sigma

Location	Sample Type	Collection Date	I-131
4	Air	8/29/2007	< 0.004
4	Air	9/5/2007	< 0.005
4	Air	9/12/2007	< 0.006
4	Air	9/19/2007	< 0.011
4	Air	9/26/2007	< 0.007
4	Air	10/3/2007	< 0.005
4	Air	10/10/2007	< 0.006
4	Air	10/17/2007	< 0.005
4	Air	10/24/2007	< 0.005
4	Air	10/31/2007	< 0.003
4	Air	11/7/2007	< 0.000
4	Air	11/14/2007	< 0.006
4	Air	11/21/2007	< 0.005
4	Air	11/28/2007	< 0.003
4	Air	12/5/2007	< 0.008
4	Air	12/12/2007	< 0.008
4	Air	12/19/2007	< 0.005
4	Air	12/26/2007	< 0.006
4	Air	1/2/2008	< 0.007
5	Air	1/10/2007	< 0.003
5	Air	1/17/2007	< 0.006
5	Air	1/24/2007	< 0.007
5	Air	1/31/2007	< 0.008
5	Air	2/7/2007	< 0.008
5	Air	2/14/2007	< 0.006
5	Air	2/21/2007	< 0.009
5	Air	2/28/2007	< 0.006
5	Air	3/7/2007	< 0.008
5	Air	3/14/2007	< 0.006
5	Air	3/21/2007	< 0.003
5	Air	3/28/2007	< 0.005
5	Air	4/4/2007	< 0.008
5	Air	4/11/2007	< 0.003
5	Air	4/18/2007	< 0.006

APPENDIX C, 2007 REMP DETAILED DATA REPORT

Air Iodine Detail Report 2007

Radiological Environmental Monitoring Program Detail Data
 Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441
 Sample Frequency is: Weekly Results in pCi/m3 +/- 2 Sigma

Location	Sample Type	Collection Date	I-131
5	Air	4/25/2007	< 0.005
5	Air	5/2/2007	< 0.005
5	Air	5/9/2007	< 0.007
5	Air	5/16/2007	< 0.005
5	Air	5/23/2007	< 0.006
5	Air	5/30/2007	< 0.006
5	Air	6/6/2007	< 0.006
5	Air	6/13/2007	< 0.006
5	Air	6/20/2007	< 0.004
5	Air	6/27/2007	< 0.007
5	Air	7/4/2007	< 0.006
5	Air	7/11/2007	< 0.007
5	Air	7/18/2007	< 0.006
5	Air	7/25/2007	< 0.007
5	Air	8/1/2007	< 0.005
5	Air	8/8/2007	< 0.004
5	Air	8/15/2007	< 0.008
5	Air	8/22/2007	< 0.011
5	Air	8/29/2007	< 0.004
5	Air	9/5/2007	< 0.005
5	Air	9/12/2007	< 0.006
5	Air	9/19/2007	< 0.011
5	Air	9/26/2007	< 0.007
5	Air	10/3/2007	< 0.004
5	Air	10/10/2007	< 0.005
5	Air	10/17/2007	< 0.005
5	Air	10/24/2007	< 0.005
5	Air	10/31/2007	< 0.003
5	Air	11/7/2007	< 0.000
5	Air	11/14/2007	< 0.006
5	Air	11/21/2007	< 0.005
5	Air	11/28/2007	< 0.003
5	Air	12/5/2007	< 0.008
5	Air	12/12/2007	< 0.008
5	Air	12/19/2007	< 0.005

APPENDIX C, 2007 REMP DETAILED DATA REPORT

Air Iodine Detail Report 2007

Radiological Environmental Monitoring Program Detail Data
Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441
Sample Frequency is: Weekly Results in pCi/m3 +/- 2 Sigma

Location	Sample Type	Collection Date	I-131
5	Air	12/26/2007	< 0.006
5	Air	1/2/2008	< 0.006
6	Air	1/10/2007	< 0.003
6	Air	1/17/2007	< 0.006
6	Air	1/24/2007	< 0.007
6	Air	1/31/2007	< 0.008
6	Air	2/7/2007	< 0.008
6	Air	2/14/2007	< 0.006
6	Air	2/21/2007	< 0.009
6	Air	2/28/2007	< 0.006
6	Air	3/7/2007	< 0.008
6	Air	3/14/2007	< 0.006
6	Air	3/21/2007	< 0.003
6	Air	3/28/2007	< 0.005
6	Air	4/4/2007	< 0.008
6	Air	4/11/2007	
6	Air	4/18/2007	< 0.007
6	Air	4/25/2007	< 0.005
6	Air	5/2/2007	< 0.005
6	Air	5/9/2007	< 0.007
6	Air	5/16/2007	< 0.005
6	Air	5/23/2007	< 0.005
6	Air	5/30/2007	< 0.006
6	Air	6/6/2007	< 0.006
6	Air	6/13/2007	< 0.006
6	Air	6/20/2007	< 0.004
6	Air	6/27/2007	< 0.007
6	Air	7/4/2007	< 0.006
6	Air	7/11/2007	< 0.007
6	Air	7/18/2007	< 0.006
6	Air	7/25/2007	< 0.007
6	Air	8/1/2007	< 0.005
6	Air	8/8/2007	< 0.004
6	Air	8/15/2007	< 0.007

APPENDIX C, 2007 REMP DETAILED DATA REPORT

Air Iodine Detail Report 2007

Radiological Environmental Monitoring Program Detail Data

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Frequency is: Weekly Results in pCi/m3 +/- 2 Sigma

Location	Sample Type	Collection Date	I-131
6	Air	8/22/2007	< 0.010
6	Air	8/29/2007	< 0.004
6	Air	9/5/2007	< 0.004
6	Air	9/12/2007	< 0.006
6	Air	9/19/2007	< 0.010
6	Air	9/26/2007	< 0.007
6	Air	10/3/2007	< 0.004
6	Air	10/10/2007	< 0.005
6	Air	10/17/2007	< 0.005
6	Air	10/24/2007	< 0.005
6	Air	10/31/2007	< 0.003
6	Air	11/7/2007	< 0.000
6	Air	11/14/2007	< 0.006
6	Air	11/21/2007	< 0.005
6	Air	11/28/2007	< 0.003
6	Air	12/5/2007	< 0.008
6	Air	12/12/2007	< 0.008
6	Air	12/19/2007	< 0.005
6	Air	12/26/2007	< 0.006
6	Air	1/2/2008	< 0.007
7	Air	1/10/2007	< 0.003
7	Air	1/17/2007	< 0.006
7	Air	1/24/2007	< 0.007
7	Air	1/31/2007	< 0.008
7	Air	2/7/2007	< 0.009
7	Air	2/14/2007	< 0.006
7	Air	2/21/2007	< 0.009
7	Air	2/28/2007	< 0.007
7	Air	3/7/2007	< 0.008
7	Air	3/14/2007	< 0.007
7	Air	3/21/2007	< 0.004
7	Air	3/28/2007	< 0.005
7	Air	4/4/2007	< 0.008
7	Air	4/11/2007	< 0.004

APPENDIX C, 2007 REMP DETAILED DATA REPORT

Air Iodine Detail Report 2007

Radiological Environmental Monitoring Program Detail Data

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Frequency is: Weekly Results in pCi/m3 +/- 2 Sigma

Location	Sample Type	Collection Date	I-131
7	Air	4/18/2007	< 0.007
7	Air	4/25/2007	< 0.005
7	Air	5/2/2007	< 0.006
7	Air	5/9/2007	< 0.007
7	Air	5/16/2007	< 0.005
7	Air	5/23/2007	< 0.006
7	Air	5/30/2007	< 0.006
7	Air	6/6/2007	< 0.006
7	Air	6/13/2007	< 0.006
7	Air	6/20/2007	< 0.004
7	Air	6/27/2007	< 0.007
7	Air	7/4/2007	< 0.006
7	Air	7/11/2007	< 0.007
7	Air	7/18/2007	< 0.006
7	Air	7/25/2007	< 0.008
7	Air	8/1/2007	< 0.006
7	Air	8/8/2007	< 0.004
7	Air	8/15/2007	< 0.008
7	Air	8/22/2007	< 0.011
7	Air	8/29/2007	< 0.004
7	Air	9/5/2007	< 0.005
7	Air	9/12/2007	< 0.006
7	Air	9/19/2007	< 0.011
7	Air	9/26/2007	< 0.007
7	Air	10/3/2007	< 0.005
7	Air	10/10/2007	< 0.006
7	Air	10/17/2007	< 0.005
7	Air	10/24/2007	< 0.005
7	Air	10/31/2007	< 0.003
7	Air	11/7/2007	< 0.000
7	Air	11/14/2007	< 0.006
7	Air	11/21/2007	< 0.006
7	Air	11/28/2007	< 0.003
7	Air	12/5/2007	< 0.008
7	Air	12/12/2007	< 0.008

APPENDIX C, 2007 REMP DETAILED DATA REPORT

Air Iodine Detail Report 2007

Radiological Environmental Monitoring Program Detail Data

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Frequency is: Weekly Results in pCi/m3 +/- 2 Sigma

Location	Sample Type	Collection Date	I-131
7	Air	12/19/2007	< 0.005
7	Air	12/26/2007	< 0.006
7	Air	1/2/2008	< 0.007
35	Air	1/10/2007	< 0.007
35	Air	1/17/2007	< 0.009
35	Air	1/24/2007	< 0.009
35	Air	1/31/2007	< 0.004
35	Air	2/7/2007	< 0.008
35	Air	2/14/2007	< 0.007
35	Air	2/21/2007	< 0.006
35	Air	2/28/2007	< 0.007
35	Air	3/7/2007	< 0.007
35	Air	3/14/2007	< 0.008
35	Air	3/21/2007	< 0.008
35	Air	3/28/2007	< 0.006
35	Air	4/4/2007	< 0.008
35	Air	4/11/2007	< 0.016
35	Air	4/18/2007	< 0.005
35	Air	4/25/2007	< 0.005
35	Air	5/2/2007	< 0.036
35	Air	5/9/2007	< 0.041
35	Air	5/16/2007	< 0.006
35	Air	5/23/2007	< 0.007
35	Air	5/30/2007	< 0.006
35	Air	6/6/2007	< 0.008
35	Air	6/13/2007	< 0.007
35	Air	6/20/2007	< 0.006
35	Air	6/27/2007	< 0.008
35	Air	7/4/2007	< 0.009
35	Air	7/11/2007	< 0.006
35	Air	7/18/2007	< 0.007
35	Air	7/25/2007	< 0.009
35	Air	8/1/2007	< 0.006
35	Air	8/8/2007	< 0.006

Air Iodine Detail Report 2007

Radiological Environmental Monitoring Program Detail Data
Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441
Sample Frequency is: Weekly Results in pCi/m3 +/- 2 Sigma

Location	Sample Type	Collection Date	I-131
35	Air	8/15/2007	< 0.000
35	Air	8/22/2007	< 0.006
35	Air	8/29/2007	< 0.004
35	Air	9/5/2007	< 0.006
35	Air	9/12/2007	< 0.004
35	Air	9/19/2007	< 0.008
35	Air	9/26/2007	< 0.006
35	Air	10/3/2007	< 0.006
35	Air	10/10/2007	< 0.009
35	Air	10/17/2007	< 0.006
35	Air	10/24/2007	< 0.006
35	Air	10/31/2007	< 0.007
35	Air	11/7/2007	< 0.000
35	Air	11/14/2007	< 0.006
35	Air	11/21/2007	< 0.009
35	Air	11/28/2007	< 0.008
35	Air	12/5/2007	< 0.011
35	Air	12/12/2007	< 0.011
35	Air	12/19/2007	< 0.009
35	Air	12/26/2007	< 0.007
35	Air	1/2/2008	< 0.009

APPENDIX C, 2007 REMP DETAILED DATA REPORT

Fish Gamma Spectral Detail Report 2007

Radiological Environmental Monitoring Program Detail Data

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Frequency is: Bi-Annually Results in pCi/kg wet +/- 2 Sigma

Location	Sample Type	Collection Date	Co-58 K-40	Co-60 Mn-54	Cs-134 Zn-65	Cs-137	Fe-59
25	yellow perch	8/19/2007	< 11.78 1,643.40 +/- 300.50	< 13.52 < 12.80	< 12.82 < 16.14	< 11.95	< 19.71
32	yellow perch	8/19/2007	< 10.04 1,619.90 +/- 311.50	< 17.19 < 11.12	< 12.59 < 22.28	< 15.67	< 14.49

APPENDIX C, 2007 REMP DETAILED DATA REPORT

Food Products Gamma Spectral Detail Report 2007

Radiological Environmental Monitoring Program Detail Data

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Frequency is: Monthly Results in pCi/kg wet +/- 2 Sigma

Location	Sample Type	Collection Date	Be-7 I-131	Co-58 K-40	Co-60	Cs-134	Cs-137
2	collard greens	7/9/2007	< 83.46 < 9.03	< 4.82 4,632.90 +/- 339.40	< 7.85	< 5.63	< 6.52
2	swiss chard	7/9/2007	< 132.37 < 24.31	< 12.92 6,917.70 +/- 583.30	< 16.04	< 14.88	< 14.28
2	beet greens	8/16/2007	441.58 +/- 167.90 < 23.49	< 17.18 7,511.90 +/- 651.60	< 15.14	< 12.96	< 18.00
2	collard greens	8/16/2007	292.86 +/- 164.20 < 15.56	< 8.38 4,687.20 +/- 436.40	< 14.12	< 9.90	< 9.51
2	swiss chard	8/16/2007	< 138.63 < 24.18	< 12.01 4,752.70 +/- 487.80	< 19.20	< 11.04	< 17.43
2	beet greens	9/18/2007	335.72 +/- 125.60 < 23.93	< 13.41 6,164.50 +/- 443.40	< 9.93	< 11.32	< 13.19
2	kale	9/18/2007	321.47 +/- 113.80 < 16.26	< 8.18 6,110.50 +/- 428.20	< 14.27	< 10.35	< 13.36
2	swiss chard	9/18/2007	249.66 +/- 112.00 < 25.83	< 12.17 6,095.80 +/- 485.80	< 7.53	< 5.55	< 16.42
2	kale	10/18/2007	295.13 +/- 114.70 < 16.73	< 6.21 4,862.80 +/- 413.10	< 12.78	< 11.69	< 15.48
2	swiss chard	10/18/2007	< 149.21 < 15.55	< 16.30 5,676.80 +/- 510.60	< 10.53	< 11.89	< 14.75

APPENDIX C, 2007 REMP DETAILED DATA REPORT

Food Products Gamma Spectral Detail Report 2007

Radiological Environmental Monitoring Program Detail Data

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Frequency is: Monthly Results in pCi/kg wet +/- 2 Sigma

Location	Sample Type	Collection Date	Be-7 I-131	Co-58 K-40	Co-60	Cs-134	Cs-137
16	beet greens	7/9/2007	< 128.16 < 28.33	< 9.13 6,248.10 +/- 515.10	< 12.91	< 8.02	< 13.58
16	collard greens	7/9/2007	< 136.58 < 18.54	< 11.76 6,070.80 +/- 552.10	< 17.69	< 13.03	< 9.97
16	turnip greens	7/9/2007	< 162.29 < 27.41	< 18.95 6,881.10 +/- 578.50	< 19.13	< 12.95	< 13.29
16	beet greens	8/16/2007	271.92 +/- 121.60 < 17.32	< 7.84 6,875.20 +/- 433.30	< 8.13	< 9.57	< 13.12
16	collard greens	8/16/2007	< 117.32 < 17.62	< 7.84 4,533.30 +/- 250.74	< 8.87	< 6.70	< 9.26
16	swiss chard	8/16/2007	< 170.41 < 22.16	< 15.36 4,273.30 +/- 512.90	< 10.66	< 15.95	< 12.96
16	beet greens	9/18/2007	348.48 +/- 185.00 < 28.96	< 5.51 6,025.00 +/- 490.10	< 11.20	< 10.49	< 12.21
16	collard greens	9/18/2007	< 128.56 < 19.21	< 7.69 4,920.30 +/- 341.70	< 8.94	< 9.62	< 8.92
16	swiss chard	9/18/2007	< 187.44 < 29.53	< 10.74 4,595.30 +/- 533.50	< 13.81	< 12.55	< 12.12
16	beet greens	10/18/2007	< 184.66 < 30.51	< 9.58 6,131.00 +/- 458.40	< 18.80	< 14.74	< 16.00
16	collard greens	10/18/2007	< 118.53 < 12.78	< 11.43 4,431.90 +/- 374.00	< 8.90	< 8.55	< 10.03

APPENDIX C, 2007 REMPI DETAILED DATA REPORT

Food Products Gamma Spectral Detail Report 2007

Radiological Environmental Monitoring Program Detail Data

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Frequency is: Monthly Results in pCi/kg wet +/- 2 Sigma

Location	Sample Type	Collection Date	Be-7 I-131	Co-58 K-40	Co-60	Cs-134	Cs-137
16	swiss chard	10/18/2007	323.06 +/- 174.80 < 27.49	< 5.62 6,115.60 +/- 477.20	< 7.71	< 17.36	< 17.32
20	beet greens	8/16/2007	390.24 +/- 144.10 < 18.97	< 5.83 3,607.20 +/- 317.40	< 12.00	< 7.72	< 11.20
20	turnip greens	8/16/2007	362.70 +/- 137.30 < 9.21	< 7.16 5,537.90 +/- 411.60	< 11.64	< 11.16	< 9.70
20	turnip greens	9/18/2007	800.39 +/- 241.80 < 25.97	< 12.96 6,461.70 +/- 568.20	< 17.22	< 17.16	< 19.09
20	turnip greens	10/18/2007	695.74 +/- 203.80 < 26.86	< 15.76 5,959.00 +/- 537.50	< 12.65	< 15.13	< 17.17
37	beet greens	7/9/2007	< 91.00 < 20.79	< 8.95 7,435.30 +/- 416.90	< 7.87	< 5.44	< 8.78
37	collard greens	7/9/2007	< 151.02 < 26.48	< 16.00 6,195.40 +/- 571.90	< 12.15	< 7.04	< 17.54
37	turnip greens	7/9/2007	130.09 +/- 69.29 < 12.14	< 10.30 6,748.50 +/- 375.30	< 5.48	< 8.32	< 10.05
37	beet greens	8/16/2007	184.09 +/- 97.23 < 15.34	< 11.92 7,563.80 +/- 431.90	< 14.88	< 8.01	< 13.22
37	collard greens	8/16/2007	< 66.13 < 6.35	< 3.56 4,398.90 +/- 308.50	< 7.52	< 4.64	< 7.34

APPENDIX C, 2007 REMP DETAILED DATA REPORT

Food Products Gamma Spectral Detail Report 2007

Radiological Environmental Monitoring Program Detail Data

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Frequency is: Monthly Results in pCi/kg wet +/- 2 Sigma

Location	Sample Type	Collection Date	Be-7 I-131	Co-58 K-40	Co-60	Cs-134	Cs-137
37	swiss chard	8/16/2007	< 139.53 < 19.70	< 10.20 4,755.50 +/- 522.40	< 9.38	< 13.59	< 14.31
37	beet greens	9/18/2007	< 196.44 < 34.58	< 18.38 6,921.70 +/- 614.40	< 12.80	< 13.35	< 17.36
37	swiss chard	9/18/2007	346.71 +/- 156.40 < 31.91	< 8.59 6,739.00 +/- 502.00	< 16.75	< 14.96	< 14.17
37	turnip greens	9/18/2007	864.18 +/- 237.30 < 39.35	< 15.65 7,778.10 +/- 714.20	< 14.74	< 12.35	< 20.90
37	beet greens	10/18/2007	296.41 +/- 156.90 < 28.50	< 13.73 6,544.00 +/- 589.40	< 10.01	< 17.68	< 18.31
37	collard greens	10/18/2007	< 175.07 < 31.53	< 9.44 3,551.80 +/- 485.50	< 10.97	< 20.58	< 16.15
37	turnip greens	10/18/2007	267.94 +/- 141.10 < 14.42	< 8.95 4,671.00 +/- 346.10	< 9.19	< 7.90	< 9.05
70	beet greens	7/9/2007	< 145.11 < 23.23	< 20.31 10,667.00 +/- 722.80	< 18.18	< 11.24	< 13.84
70	collard greens	7/9/2007	< 124.08 < 27.58	< 10.70 6,778.50 +/- 556.90	< 19.60	< 9.34	< 14.96
70	swiss chard	7/9/2007	161.03 +/- 94.96 < 15.98	< 8.86 10,028.00 +/- 505.30	< 11.37	< 8.57	< 12.67

APPENDIX C: 2007 REMP DETAILED DATA REPORT

Food Products Gamma Spectral Detail Report 2007
 Radiological Environmental Monitoring Program Detail Data
 Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441
 Sample Frequency is: Monthly Results in pCi/kg wet +/- 2 Sigma

Location	Sample Type	Collection Date	Be-7 I-131	Co-58 K-40	Co-60	Cs-134	Cs-137
70	beet greens	8/16/2007	414.59 +/- 179.20 < 21.68	< 16.34 5,518.80 +/- 556.90	< 11.08	< 9.34	< 15.00
70	collard greens	8/16/2007	< 127.97 < 17.68	< 10.69 3,991.70 +/- 353.40	< 12.61	< 11.86	< 8.19
70	swiss chard	8/16/2007	< 166.65 < 27.90	< 17.57 5,324.50 +/- 557.90	< 21.09	< 16.47	< 13.95
70	collard greens	9/18/2007	< 124.92 < 25.38	< 8.93 4,072.10 +/- 348.60	< 6.17	< 9.19	< 6.87
70	swiss chard	9/18/2007	351.10 +/- 199.60 < 33.08	< 7.56 6,648.40 +/- 456.50	< 14.49	< 10.17	< 15.70
70	turnip greens	9/18/2007	332.18 +/- 73.92 < 11.92	< 10.72 4,588.85 +/- 233.58	< 8.58	< 8.77	< 9.57
70	collard greens	10/18/2007	< 203.17 < 42.78	< 16.13 2,777.20 +/- 507.20	< 16.02	< 11.22	< 20.53
70	swiss chard	10/18/2007	< 191.71 < 30.61	< 12.31 5,820.30 +/- 620.60	< 18.22	< 14.37	< 12.83
70	turnip greens	10/18/2007	490.06 +/- 209.70 < 36.76	< 8.41 5,363.40 +/- 527.30	< 11.61	< 16.93	< 12.13

APPENDIX C, 2007 REMP DETAILED DATA REPORT

Milk Gamma Spectral Detail Report 2007

Radiological Environmental Monitoring Program Detail Data

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Frequency is: Bi-Monthly Results in pCi/L +/- 2 Sigma

Location	Sample Type	Collection Date	Ba-140	Cs-134	Cs-137	K-40	La-140
41	Milk	7/2/2007	< 21	< 4	< 6	1,575 +/- 174	< 6
41	Milk	7/17/2007	< 8	< 3	< 5	1,776 +/- 111	< 1
41	Milk	8/6/2007	< 17	< 4	< 6	1,818 +/- 141	< 2
41	Milk	8/20/2007	< 13	< 4	< 4	1,858 +/- 130	< 4
41	Milk	9/4/2007	< 25	< 5	< 4	1,755 +/- 130	< 5
41	Milk	9/17/2007	< 17	< 3	< 2	1,783 +/- 134	< 2
41	Milk	10/1/2007	< 10	< 2	< 4	1,762 +/- 89	< 2
41	Milk	10/15/2007	< 10	< 3	< 3	1,827 +/- 134	< 5
41	Milk	11/6/2007	< 13	< 2	< 3	1,757 +/- 118	< 3
51	Milk	1/3/2007	< 18	< 3	< 2	601 +/- 84	< 4

APPENDIX C, 2007 REMP DETAILED DATA REPORT

Milk Gamma Spectral Detail Report 2007
 Radiological Environmental Monitoring Program Detail Data
 Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441
 Sample Frequency is: Bi-Monthly Results in pCi/L +/- 2 Sigma

Location	Sample Type	Collection Date	Ba-140	Cs-134	Cs-137	K-40	La-140
51	Milk	2/5/2007	< 9	< 3	< 4	1,368 +/- 108	< 2
51	Milk	3/5/2007	< 13	< 4	< 5	1,384 +/- 109	< 2
51	Milk	4/2/2007	< 14	< 3	< 4	1,298 +/- 122	< 5
51	Milk	4/16/2007	< 15	< 3	< 3	1,364 +/- 136	< 2
51	Milk	5/7/2007	< 15	< 3	< 4	1,442 +/- 119	< 2
51	Milk	5/21/2007	< 10	< 4	< 2	1,389 +/- 127	< 3
51	Milk	6/4/2007	< 14	< 5	< 4	1,343 +/- 113	< 2
51	Milk	6/18/2007	< 11	< 4	< 4	1,488 +/- 122	< 3
51	Milk	7/2/2007	< 16	< 4	< 5	1,220 +/- 116	< 4
51	Milk	7/18/2007	< 19	< 4	< 6	1,282 +/- 137	< 5
51	Milk	8/6/2007	< 21	< 4	< 5	1,400 +/- 129	< 4

APPENDIX C, 2007 REMM DETAILED DATA REPORT

Milk Gamma Spectral Detail Report 2007
 Radiological Environmental Monitoring Program Detail Data
 Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441
 Sample Frequency is: Bi-Monthly Results in pCi/L +/- 2 Sigma

Location	Sample Type	Collection Date	Ba-140	Cs-134	Cs-137	K-40	La-140
51	Milk	8/20/2007	< 7	< 3	< 4	1,324 +/- 109	< 1
51	Milk	9/4/2007	< 13	< 4	< 5	1,461 +/- 131	< 3
51	Milk	9/17/2007	< 12	< 3	< 3	1,173 +/- 111	< 2
51	Milk	10/1/2007	< 17	< 3	< 3	1,219 +/- 111	< 2
51	Milk	10/15/2007	< 16	< 4	< 3	1,125 +/- 98	< 3
51	Milk	11/5/2007	< 19	< 4	< 4	1,349 +/- 105	< 2
51	Milk	12/3/2007	< 14	< 3	< 2	1,117 +/- 100	< 2
61	Milk	4/16/2007	< 16	< 3	< 4	1,609 +/- 122	< 2
61	Milk	5/7/2007	< 15	< 2	< 4	1,812 +/- 97	< 2
61	Milk	5/21/2007	< 18	< 3	< 4	1,648 +/- 125	< 3

APPENDIX C, 2007 REMP DETAILED DATA REPORT

Milk Gamma Spectral Detail Report 2007
 Radiological Environmental Monitoring Program Detail Data
 Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441
 Sample Frequency is: Bi-Monthly Results in pCi/L +/- 2 Sigma

Location	Sample Type	Collection Date	Ba-140	Cs-134	Cs-137	K-40	La-140
61	Milk	6/4/2007	< 14	< 4	< 4	1,720 +/- 130	< 2
61	Milk	6/18/2007	< 10	< 3	< 4	1,825 +/- 136	< 2
61	Milk	7/2/2007	< 18	< 4	< 5	1,665 +/- 100	< 2
61	Milk	7/17/2007	< 18	< 5	< 5	1,698 +/- 171	< 4
61	Milk	8/6/2007	< 15	< 4	< 5	1,849 +/- 136	< 2
61	Milk	8/20/2007	< 13	< 2	< 5	1,656 +/- 143	< 1
61	Milk	9/4/2007	< 39	< 4	< 5	1,927 +/- 190	< 8
61	Milk	9/17/2007	< 22	< 4	< 4	1,985 +/- 146	< 2
61	Milk	10/1/2007	< 19	< 7	< 5	2,081 +/- 208	< 6
61	Milk	10/15/2007	< 18	< 3	< 5	1,991 +/- 142	< 2
61	Milk	11/5/2007	< 20	< 3	< 5	1,845 +/- 114	< 5

APPENDIX C, 2007 REM/ DETAILED DATA REPORT

Milk Gamma Spectral Detail Report 2007

Radiological Environmental Monitoring Program Detail Data

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Frequency is: Bi-Monthly Results in pCi/L +/- 2 Sigma

Location	Sample Type	Collection Date	Ba-140	Cs-134	Cs-137	K-40	La-140
----------	-------------	-----------------	--------	--------	--------	------	--------

APPENDIX C, 2007 REMP DETAILED DATA REPORT

Milk Iodine Detail Report 2007

Radiological Environmental Monitoring Program Detail Data
 Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441
 Sample Frequency is: Bi-Monthly Results in pCi/L +/- 2 Sigma

Location	Sample Type	Collection Date	I-131
22	Milk	1/3/2007	
22	Milk	2/5/2007	
22	Milk	3/5/2007	
22	Milk	4/2/2007	
22	Milk	4/16/2007	
22	Milk	5/7/2007	
22	Milk	5/21/2007	
22	Milk	6/4/2007	
22	Milk	6/18/2007	
41	Milk	1/3/2007	
41	Milk	2/5/2007	
41	Milk	3/5/2007	
41	Milk	4/2/2007	
41	Milk	4/16/2007	
41	Milk	5/7/2007	
41	Milk	5/21/2007	
41	Milk	6/4/2007	
41	Milk	6/18/2007	
41	Milk	7/2/2007	< 0.37
41	Milk	7/17/2007	< 0.37
41	Milk	8/6/2007	< 0.20
41	Milk	8/20/2007	< 0.40
41	Milk	9/4/2007	< 0.16
41	Milk	9/17/2007	< 0.26
41	Milk	10/1/2007	< 0.33
41	Milk	10/15/2007	< 0.29
41	Milk	11/6/2007	< 0.41
41	Milk	12/3/2007	
51	Milk	1/3/2007	< 0.45
51	Milk	2/5/2007	< 0.49
51	Milk	3/5/2007	< 0.26
51	Milk	4/2/2007	< 0.28

APPENDIX C, 2007 REMM DETAILED DATA REPORT

Milk Iodine Detail Report 2007

Radiological Environmental Monitoring Program Detail Data

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Frequency is: Bi-Monthly Results in pCi/L +/- 2 Sigma

Location	Sample Type	Collection Date	I-131
51	Milk	4/16/2007	< 0.27
51	Milk	5/7/2007	< 0.44
51	Milk	5/21/2007	< 0.42
51	Milk	6/4/2007	< 0.25
51	Milk	6/18/2007	< 0.35
51	Milk	7/2/2007	< 0.44
51	Milk	7/18/2007	< 0.46
51	Milk	8/6/2007	< 0.17
51	Milk	8/20/2007	< 0.39
51	Milk	9/4/2007	< 0.29
51	Milk	9/17/2007	< 0.28
51	Milk	10/1/2007	< 0.31
51	Milk	10/15/2007	< 0.29
51	Milk	11/5/2007	< 0.33
51	Milk	12/3/2007	< 0.42
61	Milk	1/3/2007	
61	Milk	2/5/2007	
61	Milk	3/5/2007	
61	Milk	4/2/2007	
61	Milk	4/16/2007	< 0.28
61	Milk	5/7/2007	< 0.45
61	Milk	5/21/2007	< 0.43
61	Milk	6/4/2007	< 0.16
61	Milk	6/18/2007	< 0.40
61	Milk	7/2/2007	< 0.46
61	Milk	7/17/2007	< 0.41
61	Milk	8/6/2007	< 0.17
61	Milk	8/20/2007	< 0.41
61	Milk	9/4/2007	< 0.37
61	Milk	9/17/2007	< 0.29
61	Milk	10/1/2007	< 0.20
61	Milk	10/15/2007	< 0.27
61	Milk	11/5/2007	< 0.43
61	Milk	12/3/2007	

APPENDIX C, 2007 REMP DETAILED DATA REPORT

Milk Iodine Detail Report 2007

Radiological Environmental Monitoring Program Detail Data
Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441
Sample Frequency is: Bi-Monthly Results in pCi/L +/- 2 Sigma

Location	Sample Type	Collection Date	I-131
----------	-------------	-----------------	-------

APPENDIX C, 2007 REMP DETAILED DATA REPORT



Sediment Gamma Spectral Detail Report 2007

Radiological Environmental Monitoring Program Detail Data

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Frequency is: Bi-Annually Results in pCi/kg dry +/- 2 Sigma

Location	Sample Type	Collection Date	Co-58	Co-60	Cs-134	Cs-137	K-40
25	Sediment	5/23/2007	< 37.39	< 27.22	< 46.10	147.68 +/- 44.33	11,706.00 +/- 975.00
25	Sediment	9/6/2007	< 27.83	< 18.53	< 36.53	246.38 +/- 30.66	15,642.00 +/- 708.40
26	Sediment	5/23/2007	< 21.07	< 22.37	< 15.73	LLD	14,557.00 +/- 754.80
26	Sediment	9/6/2007	< 24.17	< 13.60	< 23.97	LLD	13,236.00 +/- 552.30
27	Sediment	5/23/2007	< 20.48	< 21.33	< 16.40	208.17 +/- 37.85	14,614.00 +/- 765.40
27	Sediment	9/6/2007	< 14.50	< 7.88	< 19.45	LLD	10,880.00 +/- 466.60
32	Sediment	5/23/2007	< 38.51	< 33.41	< 50.80	844.36 +/- 77.28	25,332.00 +/- 1,259.00
32	Sediment	9/6/2007	< 46.92	< 32.11	< 48.91	811.89 +/- 62.34	25,221.00 +/- 1,181.00
64	Sediment	5/24/2007	< 23.33	< 17.17	< 26.20	< 18.30	7,272.20 +/- 571.50

APPENDIX C, 2007 REMP DETAILED DATA REPORT

Sediment Gamma Spectral Detail Report 2007
 Radiological Environmental Monitoring Program Detail Data
 Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441
 Sample Frequency is: Bi-Annually Results in pCi/kg dry +/- 2 Sigma

Location	Sample Type	Collection Date	Co-58	Co-60	Cs-134	Cs-137	K-40
64	Sediment	9/5/2007	< 16.38	< 5.13	< 9.40	< 12.55	10,244.00 +/- 502.90
65	Sediment	5/24/2007	< 21.67	< 21.36	< 33.98	< 22.09	9,570.00 +/- 674.70
65	Sediment	9/5/2007	< 16.37	< 6.28	< 20.28	< 9.27	10,379.00 +/- 513.40

APPENDIX C, 2007 REMM DETAILED DATA REPORT

TLD Gamma Dose Detail Report 2007

Radiological Environmental Monitoring Program Detail Data

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Frequency is: Quarterly Results in mR/91 days +/- 2 Sigma

Location	Sample Type	Collection Period	Exposure
1	TLD	1/4/2007 to 4/19/2007	10.92 +/- 0.58
1	TLD	4/19/2007 to 7/5/2007	10.37 +/- 1.06
1	TLD	7/5/2007 to 10/8/2007	10.55 +/- 0.76
1	TLD	10/8/2007 to 1/21/2008	10.34 +/- 1.01
3	TLD	1/4/2007 to 4/19/2007	11.15 +/- 0.77
3	TLD	4/19/2007 to 7/5/2007	11.40 +/- 0.84
3	TLD	7/5/2007 to 10/8/2007	11.28 +/- 0.69
3	TLD	10/8/2007 to 1/21/2008	11.64 +/- 0.73
4	TLD	1/4/2007 to 4/19/2007	12.12 +/- 0.86
4	TLD	4/19/2007 to 7/5/2007	12.01 +/- 0.66
4	TLD	7/5/2007 to 10/8/2007	11.94 +/- 0.56
4	TLD	10/8/2007 to 1/21/2008	12.09 +/- 0.50
5	TLD	1/4/2007 to 4/19/2007	10.66 +/- 0.63
5	TLD	4/19/2007 to 7/5/2007	12.33 +/- 0.65
5	TLD	7/5/2007 to 10/8/2007	11.01 +/- 0.60
5	TLD	10/8/2007 to 1/21/2008	11.97 +/- 0.61
6	TLD	1/4/2007 to 4/19/2007	12.36 +/- 0.77
6	TLD	4/19/2007 to 7/5/2007	13.41 +/- 0.61
6	TLD	7/5/2007 to 10/8/2007	12.46 +/- 0.76
6	TLD	10/8/2007 to 1/21/2008	12.68 +/- 0.54
7	TLD	1/4/2007 to 4/19/2007	11.94 +/- 0.68
7	TLD	4/19/2007 to 7/5/2007	13.70 +/- 0.69
7	TLD	7/5/2007 to 10/8/2007	12.79 +/- 1.25
7	TLD	10/8/2007 to 1/21/2008	13.09 +/- 0.58
8	TLD	1/4/2007 to 4/19/2007	10.66 +/- 0.66
8	TLD	4/19/2007 to 7/5/2007	12.18 +/- 0.58
8	TLD	7/5/2007 to 10/8/2007	10.99 +/- 0.53
8	TLD	10/8/2007 to 1/21/2008	11.61 +/- 0.50
9	TLD	1/4/2007 to 4/19/2007	10.35 +/- 0.53

APPENDIX C, 2007 REMP DETAILED DATA REPORT

TLD Gamma Dose Detail Report 2007

Radiological Environmental Monitoring Program Detail Data
 Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441
 Sample Frequency is: Quarterly Results in mR/91 days +/- 2 Sigma

Location	Sample Type	Collection Period	Exposure
9	TLD	4/19/2007 to 7/5/2007	11.86 +/- 0.67
9	TLD	7/5/2007 to 10/8/2007	11.63 +/- 0.81
9	TLD	10/8/2007 to 1/21/2008	11.76 +/- 0.67
10	TLD	1/4/2007 to 4/19/2007	13.01 +/- 0.59
10	TLD	4/19/2007 to 7/5/2007	15.31 +/- 0.96
10	TLD	7/5/2007 to 10/8/2007	14.18 +/- 0.82
10	TLD	10/8/2007 to 1/21/2008	15.10 +/- 0.84
11	TLD	1/4/2007 to 4/19/2007	12.96 +/- 0.70
11	TLD	4/19/2007 to 7/5/2007	13.50 +/- 0.70
11	TLD	7/5/2007 to 10/8/2007	14.26 +/- 0.60
11	TLD	10/8/2007 to 1/21/2008	13.12 +/- 0.58
12	TLD	1/4/2007 to 4/19/2007	12.34 +/- 0.95
12	TLD	4/19/2007 to 7/5/2007	13.02 +/- 0.97
12	TLD	7/5/2007 to 10/8/2007	12.83 +/- 0.69
12	TLD	10/8/2007 to 1/21/2008	12.67 +/- 0.76
13	TLD	1/4/2007 to 4/19/2007	13.19 +/- 1.01
13	TLD	4/19/2007 to 7/5/2007	12.58 +/- 1.19
13	TLD	7/5/2007 to 10/8/2007	12.90 +/- 0.58
13	TLD	10/8/2007 to 1/21/2008	12.71 +/- 0.96
14	TLD	1/4/2007 to 4/19/2007	11.13 +/- 0.56
14	TLD	4/19/2007 to 7/5/2007	12.36 +/- 0.75
14	TLD	7/5/2007 to 10/8/2007	11.30 +/- 0.51
14	TLD	10/8/2007 to 1/21/2008	11.73 +/- 0.55
15	TLD	1/4/2007 to 4/19/2007	10.67 +/- 0.67
15	TLD	4/19/2007 to 7/5/2007	7.69 +/- 0.90
15	TLD	7/5/2007 to 10/8/2007	10.93 +/- 0.63
15	TLD	10/8/2007 to 1/21/2008	9.15 +/- 0.67
21	TLD	1/4/2007 to 4/19/2007	13.45 +/- 0.59
21	TLD	4/19/2007 to 7/5/2007	14.76 +/- 0.98
21	TLD	7/5/2007 to 10/8/2007	13.90 +/- 0.58

TLD Gamma Dose Detail Report 2007

Radiological Environmental Monitoring Program Detail Data

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441
 Sample Frequency is: Quarterly Results in mR/91 days +/- 2 Sigma

Location	Sample Type	Collection Period	Exposure
21	TLD	10/8/2007 to 1/21/2008	15.55 +/- 0.88
23	TLD	1/4/2007 to 4/19/2007	14.05 +/- 0.69
23	TLD	4/19/2007 to 7/5/2007	14.98 +/- 0.65
23	TLD	7/5/2007 to 10/8/2007	14.75 +/- 0.71
23	TLD	10/8/2007 to 1/21/2008	15.45 +/- 0.47
24	TLD	1/4/2007 to 4/19/2007	12.13 +/- 0.57
24	TLD	4/19/2007 to 7/5/2007	13.57 +/- 1.19
24	TLD	7/5/2007 to 10/8/2007	12.19 +/- 0.55
24	TLD	10/8/2007 to 1/21/2008	14.33 +/- 0.63
29	TLD	1/4/2007 to 4/19/2007	15.82 +/- 0.62
29	TLD	4/19/2007 to 7/5/2007	17.33 +/- 0.76
29	TLD	7/5/2007 to 10/8/2007	16.72 +/- 0.67
29	TLD	10/8/2007 to 1/21/2008	18.57 +/- 0.96
30	TLD	1/4/2007 to 4/19/2007	14.58 +/- 0.66
30	TLD	4/19/2007 to 7/5/2007	15.31 +/- 0.68
30	TLD	7/5/2007 to 10/8/2007	14.65 +/- 0.67
30	TLD	10/8/2007 to 1/21/2008	16.65 +/- 0.50
31	TLD	1/4/2007 to 4/19/2007	14.63 +/- 0.66
31	TLD	4/19/2007 to 7/5/2007	17.24 +/- 1.46
31	TLD	7/5/2007 to 10/8/2007	15.53 +/- 1.23
31	TLD	10/8/2007 to 1/21/2008	18.09 +/- 0.75
33	TLD	1/4/2007 to 4/19/2007	15.38 +/- 0.69
33	TLD	4/19/2007 to 7/5/2007	17.55 +/- 0.79
33	TLD	7/5/2007 to 10/8/2007	16.18 +/- 0.71
33	TLD	10/8/2007 to 1/21/2008	18.75 +/- 0.55
35	TLD	1/4/2007 to 4/19/2007	10.99 +/- 0.53
35	TLD	4/19/2007 to 7/5/2007	12.42 +/- 0.61
35	TLD	7/5/2007 to 10/8/2007	11.59 +/- 0.52
35	TLD	10/8/2007 to 1/21/2008	13.24 +/- 0.57

APPENDIX C, 2007 REMP DETAILED DATA REPORT

TLD Gamma Dose Detail Report 2007

Radiological Environmental Monitoring Program Detail Data
 Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441
 Sample Frequency is: Quarterly Results in mR/91 days +/- 2 Sigma

Location	Sample Type	Collection Period	Exposure
36	TLD	1/4/2007 to 4/19/2007	14.73 +/- 0.73
36	TLD	4/19/2007 to 7/5/2007	16.95 +/- 0.81
36	TLD	7/5/2007 to 10/8/2007	15.98 +/- 0.80
36	TLD	10/8/2007 to 1/21/2008	17.70 +/- 0.99
53	TLD	1/4/2007 to 4/19/2007	11.79 +/- 0.61
53	TLD	4/19/2007 to 7/5/2007	13.97 +/- 0.60
53	TLD	7/5/2007 to 10/8/2007	13.16 +/- 0.59
53	TLD	10/8/2007 to 1/21/2008	14.88 +/- 0.61
54	TLD	1/4/2007 to 4/19/2007	11.77 +/- 0.87
54	TLD	4/19/2007 to 7/5/2007	12.86 +/- 0.58
54	TLD	7/5/2007 to 10/8/2007	12.45 +/- 0.84
54	TLD	10/8/2007 to 1/21/2008	13.91 +/- 0.57
55	TLD	1/4/2007 to 4/19/2007	11.99 +/- 1.36
55	TLD	4/19/2007 to 7/5/2007	14.52 +/- 0.67
55	TLD	7/5/2007 to 10/8/2007	13.34 +/- 1.26
55	TLD	10/8/2007 to 1/21/2008	15.55 +/- 0.59
56	TLD	1/4/2007 to 4/19/2007	12.00 +/- 0.65
56	TLD	4/19/2007 to 7/5/2007	13.31 +/- 0.69
56	TLD	7/5/2007 to 10/8/2007	12.52 +/- 0.65
56	TLD	10/8/2007 to 1/21/2008	14.29 +/- 0.86
58	TLD	1/4/2007 to 4/19/2007	10.06 +/- 0.58
58	TLD	4/19/2007 to 7/5/2007	11.65 +/- 0.55
58	TLD	7/5/2007 to 10/8/2007	10.96 +/- 0.61
58	TLD	10/8/2007 to 1/21/2008	12.23 +/- 0.58

APPENDIX C, 2007 REMP DETAILED DATA REPORT

TLD Gamma Dose Detail Report 2007

Radiological Environmental Monitoring Program Detail Data

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Frequency is: Quarterly Results in mR/91 days +/- 2 Sigma

Location	Sample Type	Collection Period	Exposure
1	TLB	1/4/2007 to 4/19/2007	10.02 +/- 0.85
1	TLB	4/19/2007 to 7/5/2007	9.18 +/- 0.95
1	TLB	7/5/2007 to 10/8/2007	11.91 +/- 1.31
1	TLB	10/8/2007 to 1/21/2008	11.36 +/- 0.98
3	TLB	1/4/2007 to 4/19/2007	10.88 +/- 0.47
3	TLB	4/19/2007 to 7/5/2007	8.58 +/- 0.88
3	TLB	7/5/2007 to 10/8/2007	12.58 +/- 1.53
3	TLB	10/8/2007 to 1/21/2008	10.90 +/- 0.86
4	TLB	1/4/2007 to 4/19/2007	11.19 +/- 0.38
4	TLB	4/19/2007 to 7/5/2007	11.60 +/- 0.73
4	TLB	7/5/2007 to 10/8/2007	12.77 +/- 0.59
4	TLB	10/8/2007 to 1/21/2008	14.01 +/- 0.51
5	TLB	1/4/2007 to 4/19/2007	11.48 +/- 0.50
5	TLB	4/19/2007 to 7/5/2007	10.65 +/- 0.78
5	TLB	7/5/2007 to 10/8/2007	12.37 +/- 0.69
5	TLB	10/8/2007 to 1/21/2008	13.42 +/- 1.52
6	TLB	1/4/2007 to 4/19/2007	11.67 +/- 0.53
6	TLB	4/19/2007 to 7/5/2007	11.29 +/- 0.61
6	TLB	7/5/2007 to 10/8/2007	13.65 +/- 1.56
6	TLB	10/8/2007 to 1/21/2008	13.30 +/- 0.52
7	TLB	1/4/2007 to 4/19/2007	12.22 +/- 0.64
7	TLB	4/19/2007 to 7/5/2007	12.37 +/- 0.86
7	TLB	7/5/2007 to 10/8/2007	14.07 +/- 1.40
7	TLB	10/8/2007 to 1/21/2008	14.72 +/- 0.74
8	TLB	1/4/2007 to 4/19/2007	10.88 +/- 0.50
8	TLB	4/19/2007 to 7/5/2007	11.19 +/- 0.88
8	TLB	7/5/2007 to 10/8/2007	12.26 +/- 0.63
8	TLB	10/8/2007 to 1/21/2008	13.08 +/- 0.49
9	TLB	1/4/2007 to 4/19/2007	10.31 +/- 0.59
9	TLB	4/19/2007 to 7/5/2007	10.47 +/- 0.74

APPENDIX C, 2007 REMP DETAILED DATA REPORT

TLD Gamma Dose Detail Report 2007

Radiological Environmental Monitoring Program Detail Data
 Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441
 Sample Frequency is: quarterly Results in mR/91 days +/- 2 Sigma

Location	Sample Type	Collection Period	Exposure
9	TLB	7/5/2007 to 10/8/2007	11.74 +/- 0.64
9	TLB	10/8/2007 to 1/21/2008	12.78 +/- 0.71
10	TLB	1/4/2007 to 4/19/2007	12.65 +/- 0.47
10	TLB	4/19/2007 to 7/5/2007	13.21 +/- 0.66
10	TLB	7/5/2007 to 10/8/2007	14.54 +/- 0.62
10	TLB	10/8/2007 to 1/21/2008	15.38 +/- 0.62
11	TLB	1/4/2007 to 4/19/2007	11.17 +/- 0.40
11	TLB	4/19/2007 to 7/5/2007	12.26 +/- 0.76
11	TLB	7/5/2007 to 10/8/2007	13.56 +/- 1.36
11	TLB	10/8/2007 to 1/21/2008	14.32 +/- 0.71
12	TLB	1/4/2007 to 4/19/2007	11.67 +/- 0.44
12	TLB	4/19/2007 to 7/5/2007	11.44 +/- 0.82
12	TLB	7/5/2007 to 10/8/2007	13.52 +/- 0.63
12	TLB	10/8/2007 to 1/21/2008	13.80 +/- 0.96
13	TLB	1/4/2007 to 4/19/2007	11.41 +/- 0.44
13	TLB	4/19/2007 to 7/5/2007	10.77 +/- 1.16
13	TLB	7/5/2007 to 10/8/2007	12.46 +/- 0.51
13	TLB	10/8/2007 to 1/21/2008	12.66 +/- 0.97
14	TLB	1/4/2007 to 4/19/2007	9.62 +/- 0.51
14	TLB	4/19/2007 to 7/5/2007	10.57 +/- 0.84
14	TLB	7/5/2007 to 10/8/2007	10.36 +/- 0.68
14	TLB	10/8/2007 to 1/21/2008	12.00 +/- 0.68
15	TLB	1/4/2007 to 4/19/2007	9.42 +/- 0.47
15	TLB	4/19/2007 to 7/5/2007	9.78 +/- 0.75
15	TLB	7/5/2007 to 10/8/2007	10.23 +/- 0.76
15	TLB	10/8/2007 to 1/21/2008	11.02 +/- 0.74
21	TLB	1/4/2007 to 4/19/2007	12.65 +/- 0.44
21	TLB	4/19/2007 to 7/5/2007	12.50 +/- 1.07
21	TLB	7/5/2007 to 10/8/2007	13.91 +/- 0.85
21	TLB	10/8/2007 to 1/21/2008	15.21 +/- 1.34

TLD Gamma Dose Detail Report 2007

Radiological Environmental Monitoring Program Detail Data

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Frequency is: Quarterly Results in mR/91 days +/- 2 Sigma

Location	Sample Type	Collection Period	Exposure
23	TLB	1/4/2007 to 4/19/2007	11.93 +/- 0.78
23	TLB	4/19/2007 to 7/5/2007	12.63 +/- 0.80
23	TLB	7/5/2007 to 10/8/2007	13.21 +/- 0.98
23	TLB	10/8/2007 to 1/21/2008	14.40 +/- 0.72
24	TLB	1/4/2007 to 4/19/2007	12.42 +/- 0.97
24	TLB	4/19/2007 to 7/5/2007	10.99 +/- 0.79
24	TLB	7/5/2007 to 10/8/2007	13.02 +/- 1.40
24	TLB	10/8/2007 to 1/21/2008	12.74 +/- 0.57
29	TLB	1/4/2007 to 4/19/2007	15.06 +/- 0.71
29	TLB	4/19/2007 to 7/5/2007	16.04 +/- 1.03
29	TLB	7/5/2007 to 10/8/2007	16.63 +/- 0.68
29	TLB	10/8/2007 to 1/21/2008	17.65 +/- 0.91
30	TLB	1/4/2007 to 4/19/2007	13.68 +/- 0.57
30	TLB	4/19/2007 to 7/5/2007	13.99 +/- 0.71
30	TLB	7/5/2007 to 10/8/2007	14.99 +/- 0.63
30	TLB	10/8/2007 to 1/21/2008	15.18 +/- 0.42
31	TLB	1/4/2007 to 4/19/2007	14.85 +/- 0.70
31	TLB	4/19/2007 to 7/5/2007	14.64 +/- 1.14
31	TLB	7/5/2007 to 10/8/2007	15.64 +/- 0.84
31	TLB	10/8/2007 to 1/21/2008	16.70 +/- 0.81
33	TLB	1/4/2007 to 4/19/2007	15.78 +/- 0.61
33	TLB	4/19/2007 to 7/5/2007	16.25 +/- 0.75
33	TLB	7/5/2007 to 10/8/2007	16.62 +/- 0.69
33	TLB	10/8/2007 to 1/21/2008	17.74 +/- 0.61
35	TLB	1/4/2007 to 4/19/2007	11.39 +/- 0.59
35	TLB	4/19/2007 to 7/5/2007	11.50 +/- 0.74
35	TLB	7/5/2007 to 10/8/2007	11.73 +/- 0.68
35	TLB	10/8/2007 to 1/21/2008	13.05 +/- 0.52
36	TLB	1/4/2007 to 4/19/2007	15.31 +/- 0.48

TLD Gamma Dose Detail Report 2007

Radiological Environmental Monitoring Program Detail Data
 Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441
 Sample Frequency is: Quarterly Results in mR/91 days +/- 2 Sigma

Location	Sample Type	Collection Period	Exposure
36	TLB	4/19/2007 to 7/5/2007	15.97 +/- 0.76
36	TLB	7/5/2007 to 10/8/2007	16.53 +/- 0.60
36	TLB	10/8/2007 to 1/21/2008	16.92 +/- 0.55
53	TLB	1/4/2007 to 4/19/2007	12.36 +/- 0.57
53	TLB	4/19/2007 to 7/5/2007	13.08 +/- 0.77
53	TLB	7/5/2007 to 10/8/2007	13.82 +/- 0.72
53	TLB	10/8/2007 to 1/21/2008	14.42 +/- 0.63
54	TLB	1/4/2007 to 4/19/2007	12.91 +/- 0.63
54	TLB	4/19/2007 to 7/5/2007	12.93 +/- 0.68
54	TLB	7/5/2007 to 10/8/2007	13.70 +/- 0.70
54	TLB	10/8/2007 to 1/21/2008	13.62 +/- 0.42
55	TLB	1/4/2007 to 4/19/2007	12.52 +/- 0.53
55	TLB	4/19/2007 to 7/5/2007	13.23 +/- 0.75
55	TLB	7/5/2007 to 10/8/2007	13.91 +/- 0.70
55	TLB	10/8/2007 to 1/21/2008	14.83 +/- 0.57
56	TLB	1/4/2007 to 4/19/2007	12.79 +/- 0.55
56	TLB	4/19/2007 to 7/5/2007	12.12 +/- 1.05
56	TLB	7/5/2007 to 10/8/2007	13.00 +/- 0.70
56	TLB	10/8/2007 to 1/21/2008	13.30 +/- 0.95
58	TLB	1/4/2007 to 4/19/2007	10.01 +/- 0.66
58	TLB	4/19/2007 to 7/5/2007	10.18 +/- 0.67
58	TLB	7/5/2007 to 10/8/2007	10.60 +/- 0.73
58	TLB	10/8/2007 to 1/21/2008	11.21 +/- 0.48

APPENDIX C: 2007 REMP DETAILED DATA REPORT

TLD Gamma Dose Detail Report 2007

Radiological Environmental Monitoring Program Detail Data
 Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441
 Sample Frequency is: Annual Results in mR/365 days +/- 2 Sigma

Location	Sample Type	Collection Period	Exposure
1	TLA	1/4/2007 to 1/21/2008	42.81 +/- 1.84
3	TLA	1/4/2007 to 1/21/2008	41.06 +/- 1.28
4	TLA	1/4/2007 to 1/21/2008	52.92 +/- 1.30
5	TLA	1/4/2007 to 1/21/2008	44.04 +/- 1.26
6	TLA	1/4/2007 to 1/21/2008	52.90 +/- 1.26
7	TLA	1/4/2007 to 1/21/2008	50.81 +/- 0.95
8	TLA	1/4/2007 to 1/21/2008	49.58 +/- 1.52
9	TLA	1/4/2007 to 1/21/2008	45.43 +/- 3.14
10	TLA	1/4/2007 to 1/21/2008	60.72 +/- 1.60
11	TLA	1/4/2007 to 1/21/2008	56.25 +/- 4.43
12	TLA	1/4/2007 to 1/21/2008	51.87 +/- 1.74
13	TLA	1/4/2007 to 1/21/2008	49.92 +/- 2.54
14	TLA	1/4/2007 to 1/21/2008	40.95 +/- 2.73
15	TLA	1/4/2007 to 1/21/2008	41.34 +/- 1.24
21	TLA	1/4/2007 to 1/21/2008	57.80 +/- 3.63
23	TLA	1/4/2007 to 1/21/2008	51.05 +/- 1.22
24	TLA	1/4/2007 to 1/21/2008	46.35 +/- 1.37
29	TLA	1/4/2007 to 1/21/2008	61.76 +/- 2.05
30	TLA	1/4/2007 to 1/21/2008	58.07 +/- 1.19

APPENDIX C, 2007 REMP DETAILED DATA REPORT

TLD Gamma Dose Detail Report 2007

Radiological Environmental Monitoring Program Detail Data
Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441
Sample Frequency is: Annual Results in mR/365 days +/- 2 Sigma

Location	Sample Type	Collection Period	Exposure
31	TLA	1/4/2007 to 1/21/2008	63.97 +/- 1.79
33	TLA	1/4/2007 to 1/21/2008	68.88 +/- 2.85
35	TLA	1/4/2007 to 1/21/2008	49.63 +/- 1.39
36	TLA	1/4/2007 to 1/21/2008	67.91 +/- 1.80
53	TLA	1/4/2007 to 1/21/2008	55.13 +/- 1.91
54	TLA	1/4/2007 to 1/21/2008	53.06 +/- 4.11
55	TLA	1/4/2007 to 1/21/2008	55.41 +/- 4.80
56	TLA	1/4/2007 to 1/21/2008	56.00 +/- 2.85
58	TLA	1/4/2007 to 1/21/2008	43.92 +/- 1.29

APPENDIX C, 2007 REMP DETAILED DATA REPORT

TLD Gamma Dose Detail Report 2007

Radiological Environmental Monitoring Program Detail Data
Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441
Sample Frequency is: Annual Results in mR/365 days +/- 2 Sigma

Location	Sample Type	Collection Period	Exposure
----------	-------------	-------------------	----------

Water Gamma Spectral Detail Report 2007

Radiological Environmental Monitoring Program Detail Data

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Frequency is: Monthly Results in pCi/L +/- 2 Sigma

Location	Sample Type	Collection Period	Ba-140 Fe-59 Zr-95	Co-58 La-140	Co-60 Mn-54	Cs-134 Nb-95	Cs-137 Zn-65
28	Water	12/28/2006 to 1/25/2007	< 10.25 < 5.15 < 4.20	< 3.21 < 3.86	< 3.12 < 2.15	< 2.33 < 2.09	< 3.18 < 4.16
28	Water	2/22/2007 to 2/22/2007	< 16.15 < 5.59 < 5.38	< 2.38 < 4.08	< 0.85 < 1.91	< 2.06 < 2.26	< 3.97 < 2.11
28	Water	2/22/2007 to 3/29/2007	< 12.33 < 5.14 < 12.92	< 4.22 < 4.45	< 3.24 < 3.35	< 5.16 < 5.37	< 5.83 < 7.88
28	Water	3/29/2007 to 4/26/2007	< 11.53 < 4.27 < 6.92	< 1.94 < 1.69	< 2.38 < 1.98	< 3.34 < 1.32	< 2.95 < 3.72
28	Water	4/26/2007 to 5/31/2007	< 17.61 < 10.42 < 7.55	< 2.83 < 7.30	< 2.79 < 3.59	< 4.27 < 3.69	< 3.64 < 3.97
28	Water	5/31/2007 to 6/28/2007	< 10.74 < 4.93 < 5.76	< 1.93 < 4.40	< 2.02 < 1.95	< 2.83 < 2.24	< 2.56 < 3.69
28	Water	6/28/2007 to 7/26/2007	< 13.98 < 5.77 < 6.11	< 2.51 < 3.36	< 2.72 < 2.65	< 2.62 < 3.63	< 2.09 < 4.80
28	Water	7/26/2007 to 8/30/2007	< 30.40 < 4.31 < 9.71	< 4.44 < 8.77	< 4.17 < 2.87	< 2.29 < 4.44	< 4.64 < 4.10
28	Water	8/30/2007 to 9/26/2007	< 9.06 < 5.76 < 4.07	< 1.35 < 2.18	< 2.87 < 2.19	< 2.72 < 2.97	< 2.20 < 1.58
28	Water	9/26/2007 to 10/25/2007	< 28.46 < 8.46 < 4.49	< 3.10 < 5.63	< 2.29 < 2.81	< 2.15 < 3.71	< 3.28 < 6.18
28	Water	10/25/2007 to 11/29/2007	< 16.32 < 5.37 < 5.26	< 2.55 < 5.99	< 2.22 < 2.46	< 3.04 < 3.12	< 3.55 < 2.54

APPENDIX C, 2007 REMP DETAILED DATA REPORT

Water Gamma Spectral Detail Report 2007

Radiological Environmental Monitoring Program Detail Data

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Frequency is: Monthly Results in pCi/L +/- 2 Sigma

Location	Sample Type	Collection Period	Ba-140 Fe-59 Zr-95	Co-58 La-140	Co-60 Mn-54	Cs-134 Nb-95	Cs-137 Zn-65
28	Water	11/29/2007 to 12/26/2007	< 13.49 < 5.17 < 2.50	< 3.31 < 2.38	< 1.59 < 3.23	< 3.23 < 2.19	< 2.74 < 3.22
34	Water	12/28/2006 to 1/25/2007	< 9.86 < 5.26 < 5.08	< 2.67 < 2.71	< 3.40 < 3.16	< 3.86 < 4.19	< 2.69 < 2.28
34	Water	1/25/2007 to 2/22/2007	< 7.98 < 2.70 < 3.87	< 1.16 < 2.26	< 2.12 < 1.84	< 2.59 < 1.96	< 3.01 < 3.06
34	Water	2/22/2007 to 3/29/2007	< 20.81 < 2.25 < 8.62	< 2.61 < 1.97	< 2.36 < 3.55	< 3.49 < 2.66	< 3.12 < 4.42
34	Water	3/29/2007 to 4/26/2007	< 15.76 < 5.37 < 6.95	< 2.29 < 3.24	< 2.33 < 2.89	< 2.09 < 2.14	< 3.62 < 3.19
34	Water	4/26/2007 to 5/31/2007	< 15.02 < 3.32 < 4.04	< 1.89 < 2.44	< 2.25 < 2.84	< 3.81 < 4.29	< 2.26 < 5.42
34	Water	5/31/2007 to 6/28/2007	< 10.39 < 3.86 < 3.14	< 2.11 < 3.39	< 2.07 < 1.94	< 1.76 < 2.22	< 2.10 < 3.25
34	Water	6/28/2007 to 7/26/2007	< 23.45 < 6.66 < 6.33	< 3.32 < 2.82	< 2.92 < 2.52	< 3.47 < 3.65	< 2.92 < 4.83
34	Water	7/26/2007 to 8/30/2007	< 24.33 < 11.21 < 7.32	< 3.74 < 10.22	< 1.85 < 4.88	< 4.18 < 4.49	< 4.71 < 7.90
34	Water	8/30/2007 to 9/26/2007	< 13.73 < 5.23 < 4.76	< 1.80 < 1.82	< 2.30 < 2.70	< 2.89 < 2.67	< 3.25 < 2.85

APPENDIX C, 2007 REMP DETAILED DATA REPORT

Water Gamma Spectral Detail Report 2007

Radiological Environmental Monitoring Program Detail Data

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Frequency is: Monthly Results in pCi/L +/- 2 Sigma

Location	Sample Type	Collection Period	Ba-140 Fe-59 Zr-95	Co-58 La-140	Co-60 Mn-54	Cs-134 Nb-95	Cs-137 Zn-65
34	Water	9/26/2007 to 10/25/2007	< 9.61 < 3.35 < 4.20	< 1.72 < 2.95	< 1.95 < 2.47	< 1.96 < 3.11	< 2.90 < 4.64
34	Water	10/25/2007 to 11/29/2007	< 13.99 < 3.45 < 3.96	< 1.59 < 1.74	< 1.92 < 3.03	< 2.61 < 2.87	< 3.29 < 5.37
34	Water	11/29/2007 to 12/26/2007	< 19.46 < 3.92 < 6.69	< 1.67 < 4.61	< 3.02 < 2.31	< 1.76 < 3.67	< 3.60 < 4.55
36	Water	12/28/2006 to 1/25/2007	< 14.62 < 4.49 < 3.21	< 3.18 < 4.35	< 1.34 < 3.27	< 3.22 < 3.34	< 2.07 < 4.68
36	Water	1/25/2007 to 2/22/2007	< 18.04 < 5.96 < 6.07	< 1.81 < 4.89	< 3.81 < 3.26	< 2.66 < 3.51	< 3.78 < 3.60
36	Water	2/22/2007 to 3/29/2007	< 11.72 < 3.52 < 4.16	< 1.87 < 2.21	< 1.45 < 2.82	< 2.33 < 2.60	< 2.79 < 3.05
36	Water	3/29/2007 to 4/26/2007	< 11.28 < 10.30 < 3.68	< 4.22 < 5.12	< 3.05 < 3.53	< 3.53 < 5.26	< 6.27 < 6.71
36	Water	4/26/2007 to 5/31/2007	< 3.91 < 1.64 < 1.24	< 0.92 < 2.42	< 1.41 < 1.17	< 0.99 < 0.87	< 1.19 < 2.71
36	Water	5/31/2007 to 6/28/2007	< 18.48 < 4.78 < 10.54	< 4.04 < 4.95	< 2.24 < 3.99	< 3.13 < 3.54	< 2.44 < 2.92
36	Water	6/28/2007 to 7/26/2007	< 19.67 < 5.06 < 6.00	< 2.33 < 2.96	< 2.89 < 3.09	< 3.45 < 2.75	< 3.54 < 4.66

APPENDIX C, 2007 REMP DETAILED DATA REPORT

Water Gamma Spectral Detail Report 2007

Radiological Environmental Monitoring Program Detail Data

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Frequency is: Monthly Results in pCi/L +/- 2 Sigma

Location	Sample Type	Collection Period	Ba-140 Fe-59 Zr-95	Co-58 La-140	Co-60 Mn-54	Cs-134 Nb-95	Cs-137 Zn-65
36	Water	7/26/2007 to 8/30/2007	< 17.67 < 6.90 < 7.70	< 2.48 < 10.81	< 3.76 < 3.68	< 3.57 < 3.80	< 3.53 < 3.71
36	Water	8/30/2007 to 9/26/2007	< 19.99 < 6.20 < 6.66	< 3.54 < 5.45	< 3.25 < 1.95	< 2.92 < 4.15	< 3.80 < 4.77
36	Water	9/26/2007 to 10/25/2007	< 14.21 < 4.51 < 6.05	< 2.98 < 3.76	< 2.35 < 1.95	< 2.60 < 2.16	< 3.46 < 4.14
36	Water	10/25/2007 to 11/29/2007	< 17.80 < 4.51 < 3.63	< 3.27 < 3.23	< 2.53 < 1.83	< 2.46 < 2.47	< 3.45 < 4.44
36	Water	11/29/2007 to 12/26/2007	< 12.36 < 4.20 < 4.38	< 2.06 < 2.41	< 2.56 < 2.29	< 2.37 < 2.32	< 2.69 < 2.29
59	Water	3/29/2007 to 4/26/2007	< 14.24 < 3.83 < 6.75	< 2.30 < 3.69	< 2.02 < 1.97	< 2.08 < 3.75	< 4.03 < 5.04
59	Water	4/26/2007 to 5/31/2007	< 27.70 < 8.55 < 9.88	< 4.63 < 6.16	< 3.20 < 3.73	< 4.85 < 6.11	< 4.61 < 4.25
59	Water	5/31/2007 to 6/28/2007	< 17.68 < 5.46 < 4.88	< 2.27 < 3.75	< 1.25 < 2.27	< 2.92 < 3.37	< 1.59 < 2.93
59	Water	6/28/2007 to 7/26/2007	< 18.38 < 8.03 < 6.26	< 3.89 < 3.21	< 1.92 < 2.63	< 2.51 < 3.36	< 2.51 < 3.38
59	Water	7/26/2007 to 8/30/2007	< 44.11 < 7.87 < 5.82	< 3.70 < 10.70	< 2.76 < 4.23	< 4.34 < 4.27	< 4.90 < 6.99

APPENDIX C, 2007 REMP DETAILED DATA REPORT

Water Gamma Spectral Detail Report 2007

Radiological Environmental Monitoring Program Detail Data

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Frequency is: Monthly Results in pCi/L +/- 2 Sigma

Location	Sample Type	Collection Period	Ba-140 Fe-59 Zr-95	Co-58 La-140	Co-60 Mn-54	Cs-134 Nb-95	Cs-137 Zn-65
59	Water	8/30/2007 to 9/26/2007	< 12.17 < 3.81 < 5.57	< 1.55 < 2.88	< 2.50 < 3.22	< 3.12 < 2.62	< 3.72 < 1.84
59	Water	9/26/2007 to 10/25/2007	< 20.32 < 6.76 < 6.39	< 2.84 < 6.29	< 1.80 < 2.29	< 3.73 < 4.02	< 2.75 < 3.94
59	Water	10/25/2007 to 11/29/2007	< 18.45 < 4.79 < 6.34	< 1.83 < 5.10	< 2.18 < 1.58	< 3.05 < 3.03	< 2.85 < 3.43
60	Water	3/29/2007 to 4/26/2007	< 12.20 < 5.20 < 4.96	< 1.63 < 2.05	< 2.16 < 1.73	< 2.57 < 3.42	< 3.32 < 3.86
60	Water	4/26/2007 to 5/31/2007	< 14.92 < 7.13 < 7.31	< 3.87 < 4.31	< 3.29 < 5.64	< 1.80 < 4.14	< 4.41 < 8.84
60	Water	5/31/2007 to 6/28/2007	< 13.20 < 4.28 < 5.29	< 2.53 < 4.29	< 2.52 < 2.66	< 1.72 < 3.57	< 2.02 < 3.02
60	Water	6/28/2007 to 7/26/2007	< 20.73 < 5.05 < 4.20	< 1.43 < 3.38	< 1.88 < 2.47	< 3.47 < 2.87	< 3.71 < 2.80
60	Water	7/26/2007 to 8/30/2007	< 13.89 < 3.70 < 6.99	< 3.03 < 10.20	< 2.41 < 3.34	< 2.39 < 3.85	< 3.29 < 2.96
60	Water	8/30/2007 to 9/26/2007	< 11.59 < 4.52 < 5.00	< 1.98 < 5.53	< 2.72 < 1.47	< 3.12 < 2.42	< 3.32 < 3.41
60	Water	9/26/2007 to 10/25/2007	< 22.13 < 8.44 < 2.98	< 2.87 < 5.70	< 1.20 < 2.70	< 2.68 < 2.09	< 3.43 < 1.84

APPENDIX C, 2007 REMP DETAILED DATA REPORT

Water Gamma Spectral Detail Report 2007

Radiological Environmental Monitoring Program Detail Data

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Frequency is: Monthly Results in pCi/L +/- 2 Sigma

Location	Sample Type	Collection Period	Ba-140 Fe-59 Zr-95	Co-58 La-140	Co-60 Mn-54	Cs-134 Nb-95	Cs-137 Zn-65
60	Water	10/25/2007 to 11/29/2007	< 17.61 < 2.34 < 3.50	< 2.25 < 2.09	< 2.88 < 2.57	< 2.04 < 2.33	< 2.32 < 2.74

APPENDIX C, 2007 REMP DETAILED DATA REPORT

Water Gross Beta Detail Report 2007
 Radiological Environmental Monitoring Program Data Summary
 Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441
 Sample Frequency is: Monthly Results in pCi/L +/- 2 Sigma

Collection Period	Sample Type	Location				
		28	34	36	59	60
12/28/2006 to 1/25/2007	Water	LLD	LLD	LLD		
1/25/2007 to 2/22/2007	Water		LLD	3.17 +/- 0.63		
2/22/2007 to 2/22/2007	Water	3.97 +/- 0.81				
2/22/2007 to 3/29/2007	Water	LLD	LLD	LLD		
3/29/2007 to 4/26/2007	Water	LLD	LLD	LLD	LLD	LLD
4/26/2007 to 5/31/2007	Water	LLD	LLD	LLD	LLD	LLD
5/31/2007 to 6/28/2007	Water	LLD	LLD	LLD	LLD	LLD
6/28/2007 to 7/26/2007	Water	LLD	LLD	LLD	LLD	LLD
7/26/2007 to 8/30/2007	Water	LLD	LLD	LLD	LLD	LLD
8/30/2007 to 9/26/2007	Water	LLD	LLD	LED	LLD	LLD
9/26/2007 to 10/25/2007	Water	LLD	LLD	LLD	LLD	LLD

APPENDIX C, 2007 REMP DETAILED DATA REPORT

Water Gross Beta Detail Report 2007

Radiological Environmental Monitoring Program Data Summary

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Frequency is: Monthly Results in pCi/L +/- 2 Sigma

Collection Period	Sample Type	Location				
		28	34	36	59	60
10/25/2007 to 11/29/2007	Water	LLD	LLD	3.89 +/- 0.67	LLD	LLD
11/29/2007 to 12/26/2007	Water	LLD	LLD	LLD		

APPENDIX C, 2007 REMP DETAILED DATA REPORT


Water Tritium Detail Report 2007

Radiological Environmental Monitoring Program Detail Data
Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441
Sample Frequency is: Quarterly Results in pCi/L +/- 2 Sigma

Location	Sample Type	Collection Date	H-3
28	Water	3/29/2007	< 171.86
28	Water	6/28/2007	< 149.52
28	Water	9/26/2007	< 147.27
28	Water	12/26/2007	< 151.38
34	Water	3/29/2007	< 171.86
34	Water	6/28/2007	< 149.52
34	Water	9/26/2007	< 147.27
34	Water	12/26/2007	LLD
36	Water	3/29/2007	< 171.86
36	Water	6/28/2007	< 149.06
36	Water	9/26/2007	< 147.27
36	Water	12/26/2007	< 151.38
59	Water	3/29/2007	
59	Water	6/28/2007	LLD
59	Water	9/26/2007	< 147.27
59	Water	11/29/2007	< 152.01
60	Water	3/29/2007	
60	Water	6/28/2007	< 149.06
60	Water	9/26/2007	< 147.27
60	Water	11/29/2007	< 152.01

APPENDIX C, 2007 REMP DETAILED DATA REPORT

PNPPD



Generating Success!

For more information, write :

Perry Nuclear Power Plant

10 Center Road

P.O. Box 97

Perry OH 44081-0097