

May 18, 2009

Dr. Mario V. Bonaca, Chairman
Advisory Committee on Reactor Safeguards
U.S. Nuclear Regulatory Commission
Washington, DC 20055

SUBJECT: RESPONSE TO THE ADVISORY COMMITTEE ON REACTOR
SAFEGUARDS LETTER, DATED APRIL 21, 2009, ON THE DRAFT
FINAL REGULATORY GUIDE (RG) 1.211, "QUALIFICATION OF
SAFETY-RELATED CABLES AND FIELD SPLICES FOR NUCLEAR
POWER PLANTS"

Dear Dr. Bonaca:

I am responding to your letter dated April 21, 2009, regarding the Advisory Committee on Reactor Safeguards (ACRS or Committee) meeting on April 2-4, 2009.

During the full committee meeting, the staff discussed how condition monitoring may be limited to safety-related cables within the scope of the Maintenance Rule. We appreciate the recommendation to better clarify the scope and remove the reference to the Maintenance Rule. In the final version of RG 1.211, we removed the reference to the Maintenance Rule and simplified the scope to safety-related cables. In addition, we will remain cognizant of advances in condition monitoring techniques in order to refine the guidance in the future. We appreciate the recommendation and comments provided by the ACRS.

Sincerely,

/RA M. Johnson for/

R. W. Borchardt
Executive Director
for Operations

cc: Chairman Jaczko
Commissioner Lyons
Commissioner Klein
Commissioner Svinicki
SECY

May 18,2009

Dr. Mario V. Bonaca, Chairman
Advisory Committee on Reactor Safeguards
U.S. Nuclear Regulatory Commission
Washington, DC 20055

SUBJECT: RESPONSE TO THE ADVISORY COMMITTEE ON REACTOR SAFEGUARDS LETTER, DATED APRIL 21, 2009, ON THE DRAFT FINAL REGULATORY GUIDE (RG) 1.211, "QUALIFICATION OF SAFETY-RELATED CABLES AND FIELD SPLICES FOR NUCLEAR POWER PLANTS"

Dear Dr. Bonaca:

I am responding to your letter dated April 21, 2009, regarding the Advisory Committee on Reactor Safeguards (ACRS or Committee) meeting on April 2-4, 2009.

During the full committee meeting, the staff discussed how condition monitoring may be limited to safety-related cables within the scope of the Maintenance Rule. We appreciate the recommendation to better clarify the scope and remove the reference to the Maintenance Rule. In the final version of RG 1.211, we removed the reference to the Maintenance Rule and simplified the scope to safety-related cables. In addition, we will remain cognizant of advances in condition monitoring techniques in order to refine the guidance in the future. We appreciate the recommendation and comments provided by the ACRS.

Sincerely,

/RA M. Johnson for/

R. W. Borchardt
Executive Director
for Operations

cc: Chairman Jaczko
Commissioner Lyons
Commissioner Klein
Commissioner Svinicki
SECY

DISTRIBUTION: G20090239/EDATS: OEDO-2009-0230

R. Borchardt, EDO M. Virgilio, DEDMRT B. Mallett, DEDR D. Ash, DEDCM D. Diaz-Toro, OEDO
J. Adams, OEDO E. Leeds, NRR ACRS File DE r/f

ADAMS Accession No.: ML091250139

OFFICE	RES/DE/MEEB	SUNSI Review	Tech Editor	RES/DE/MEEB
NAME	L. Ramadan	T. Koshy (J. Burke for)	J. Zabel (via e-mail)	T. Koshy (J. Burke for)
DATE	05/06/09	05/06/09	05/01/09	05/06/09
OFFICE	D: RES/DE	D: RES	EDO	
NAME	M. Case (S. Richards for)	B. Sheron	R. Borchardt/MJohnson for/	
DATE	05/13/09	05/15/09	05/18/09	

OFFICIAL RECORD COPY