

June 29, 2009

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE -- PNO-III-09-005A

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by the Region III staff on this date.

Facility

Davis-Besse
FirstEnergy Nuclear Operating Company
Oak Harbor, OH
Docket: 50-346
License: NPF-3

Licensee Emergency Classification

Notification of Unusual Event
 Alert
 Site Area Emergency
 General Emergency
 Not Applicable

SUBJECT: TRANSITORY ALERT DUE TO ELECTRIC DEVICE FAILURE (UPDATE)

DESCRIPTION:

On June 26, 2009, the Davis-Besse facility restored its normal off-site power sources averting the need to shut down the facility. At 11:05 p.m. (EDT) the facility successfully restored the "J" bus and its associated start-up transformer thereby re-establishing two sources of off-site power as required by NRC regulations.

The resident inspectors monitored the utility's restoration of the start-up transformer.

The State of Ohio has been informed. The information in this preliminary notification has been reviewed with licensee management.

This information is current as of 10:09 a.m. (CDT) on June 29, 2009.

CONTACTS:

Geoffrey Wright
(630) 829-9602

Jamnes Cameron
(630) 829-9833