

## PRELIMINARY NOTIFICATION - REGION III

August 18, 2009

### PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE -- PNO-III-09-008

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by the Region III staff on this date.

#### Facility

LaSalle Station, Unit 2  
Exelon Generation Co.  
Marseilles, Illinois  
Docket: 50-373  
License: DPR-22

#### Licensee Emergency Classification

Notification of Unusual Event  
 Alert  
 Site Area Emergency  
 General Emergency  
 Not Applicable

SUBJECT: LASALLE UNIT 2 UNPLANNED SHUTDOWN GREATER THAN 72 HOURS

#### DESCRIPTION:

At 1606 on Saturday, August 15, 2009, the Unit 2 reactor tripped after the turbine tripped during the performance of a weekly turbine overspeed surveillance test. Prior to the reactor trip, Unit 2 was operating at 100 percent power. All control rods inserted during the scram, reactor water level was being maintained by the main feedwater system and decay heat was being removed via the turbine bypass valves.

The turbine trip occurred after two of the three turbine overspeed channels were in a trip condition. One of the channels was placed in the trip condition as part of the ongoing surveillance testing. The second channel had apparently been in the trip condition since August 9, unknown by the licensee. Both Unit 1 and Unit 2 have installed a digital electro-hydraulic control system for turbine control.

The licensee is investigating the cause of the turbine over-speed logic trip signal that existed starting on August 9 and which was present during the surveillance testing. Additionally, the licensee is reviewing other anomalies that occurred during the scram. These anomalies did not significantly challenge the licensee's response and they are being evaluated by the resident inspectors.

The plant is currently in hot shutdown and is performing troubleshooting and repair activities.

The information presented herein has been discussed with the licensee and is current as of 7:00 a.m. (CDT) on August 18, 2009.

NRC Region III will update this PN after plant restart.

ADAMS Accession Number: ML092300236

CONTACT: Ken Riemer  
630-829-9628

Nirodh Shah  
630-829-9821