

## **PRELIMINARY NOTIFICATION - REGION III**

October 26, 2009

### **PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE - PNO-III-09-011A**

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation, and is all that is known by the Region III staff on this date.

#### **Facility**

Clinton Power Station  
Exelon Generation Company  
Clinton, IL 61727-9313  
Docket: 50-461  
License: NPF-62

#### **Licensee Emergency Classification**

- Notification of Unusual Event
- Alert
- Site Area Emergency
- General Emergency
- Not Applicable

SUBJECT: UPDATE – CLINTON POWER STATION UNPLANNED SHUTDOWN GREATER THAN 72 HOURS

#### **DESCRIPTION:**

At 0537 (CDT) on October 15, 2009, Clinton Power Station experienced a trip of the "B" reactor recirculation pump. Due to the pump trip, reactor water level rose above 48 inches, at which point licensed operators manually scrammed the reactor in accordance with their operating procedures. All safety-related systems functioned as required. Due to the manual shutdown, reactor water level did not reach the high-level automatic scram set point of 52 inches.

Immediately following the shutdown, the licensee discovered that two ground fault relays actuated, causing both breakers supplying power for high speed operation to the "B" reactor recirculation pump to open. The licensee subsequently tested the "B" reactor recirculation pump motor and power cabling, verifying that a hard ground existed on the motor.

On October 24, 2009, the Unit was restarted and later synched to the grid following the motor replacement. The Unit is expected to be returned to full power by October 26, 2009.

ADAMS Accession Number: ML092990367

#### **CONTACT:**

Mark Ring  
630-829-9703

Jamie Benjamin  
630-829-9753