

Mark B. Bezilla Vice President Perry Nuclear Power Station 10 Center Road Perry, Ohio 44081

> 440-280-5382 Fax: 440-280-8029

April 29, 2010 L-10-114

10 CFR 50.36a(a)(2)

ATTN: Document Control Desk U. S. Nuclear Regulatory Commission Washington, DC 20555-0001

SUBJECT: Perry Nuclear Power Plant Docket No. 50-440 Annual Environmental and Effluent Release Report

Enclosed is the Annual Environmental and Effluent Release Report for the Perry Nuclear Power Plant (PNPP) for the period of January 1, 2009 through December 31, 2009. This document includes the radiological environmental operating report, radioactive effluent release report, and the non-radiological environmental operating report which satisfies the requirements of the PNPP Technical Specifications (TS), the PNPP Offsite Dose Calculation Manual (ODCM), and the Environmental Protection Plan, Appendix B of the PNPP Operating License.

There are no regulatory commitments contained in this letter. If there are any questions or if additional information is required, please contact Mr. Jeffrey Tufts, Manager-Chemistry at (440) 280-5458.


Sincerely,

Mark B. Bezilla

Enclosure: PNPP 2009 Annual Environmental and Effluent Release Report

cc: NRC Region III Administrator NRC Resident Inspector NRR Project Manager

Perry Nuclear Power Plant



Annual Environmental & Effluent Release Report 2009

2009

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

for the Perry Nuclear Power Plant

PREPARED BY: CHEMISTRY SECTION PERRY NUCLEAR POWER PLANT FIRSTENERGY NUCLEAR OPERATING COMPANY PERRY, OHIO MARCH, 2010

TABLE OF CONTENTS

APPENDICES

Appendix A: 2009 Inter-Laboratory Cross Check Comparison Program Results

Appendix B: 2009 REMP Data Summary Reports

Appendix C: 2009 REMP Detailed Data Report

Appendix D: Corrections to Previous AEERR

EXECUTIVE SUMMARY

The Annual Environmental and Effluent Release Report (AEERR) details the results of environmental and effluent monitoring programs conducted at the Perry Nuclear Power Plant (PNPP) from January 01 through December 31, 2009. This report meets all of the requirements in PNPP Technical Specifications, the Environmental Protection Plan (EPP), and Regulatory Guide 1.21. It incorporates the requirements of the Annual Radioactive Effluent Release Report (ARERR), the Annual Radiological Environmental Operating Report (AREOR) and the Annual Environmental Operating Report (AEOR). Report topics include radioactive effluent releases, radiological environmental monitoring, land use census, clam/mussel monitoring, herbicide use, and special reports. The results of the environmental and effluent programs, for 2009 indicate that the operations of the Perry Nuclear Power Plant did not result in any significant environmental impact.

RADIOACTIVE EFFLUENT RELEASES

During the normal operation of a nuclear power plant, small quantities of radioactivity may be released to the environment in liquid and gaseous effluents. Radioactive material may also be released as solid waste. PNPP maintains a comprehensive program to control and monitor the release of radioactive materials from the site in accordance with Nuclear Regulatory Commission (NRC) release regulations.

The dose to the general public from the plant's liquid and gaseous effluents was below the applicable regulatory limits. The calculated hypothetical maximum individual whole body dose potentially received by an individual resulting from PNPP liquid effluents was 3.57E-04 mrem (0.01 % of the applicable limit). The calculated hypothetical maximum individual whole body dose potentially received by an individual resulting from PNPP gaseous effluents was 4.45E-8 mrem (<0.00000009% of the applicable limit). The summation of the hypothetical maximum individual dose from effluents in 2009 is equivalent to < 0.01 % of the total dose an individual living in the PNPP area receives from all sources of radiation.

Shipments of solid waste consisted of waste generated during water treatment; radioactive material generated during normal daily operations and maintenance, and irradiated components. PNPP complied with applicable regulations governing radioactive shipments in 2009, making shipments of solid radioactive waste to a licensed burial site.

An additional section covers the groundwater monitoring program. It includes a brief history of groundwater tritium issues at the Perry Plant, and results from current sampling and monitoring activities.

RADIOLOGICAL ENVIRONMENTAL MONITORING

The Radiological Environmental Monitoring Program (REMP) was established in 1981 to monitor the radiological conditions in the environment around PNPP. The REMP is conducted in accordance with PNPP Technical Specifications and the Offsite Dose Calculation Manual (ODCM). This program includes the collection and analysis of environmental samples and evaluation of results.

The REMP was established at PNPP six (6) years before the plant became operational. This preoperational program was designed to provide data on background radiation and radioactivity normally present in the area. PNPP has continued to monitor the environment during plant operation by collecting and analyzing samples of air, precipitation, milk, fish, produce, water and sediment, as well as by measuring radiation directly.

There were over 2700 radioactivity analyses performed on the 1356 radiological environmental samples collected in 2009. The results of the REMP indicate the adequacy of the control of the release of radioactivity in the effluents from PNPP. These results also demonstrate that PNPP

complies with applicable federal regulations. The REMP results are divided into four sections: atmospheric monitoring, terrestrial monitoring, aquatic monitoring, and direct radiation monitoring.

Samples of air were collected to monitor the radioactivity in the atmosphere. The 2009 results were similar to those observed for the pre-operational and operational programs from prior years. Only natural background environmental radioactivity was detected.

Terrestrial monitoring included the analysis of milk and produce. The PNPP ODCM does not require vegetation or soil samples to be included in the monitoring program. The results of the sample analyses in 2009 indicated concentrations of radioactivity similar to that found in previous years. Analyses of other terrestrial samples also detected concentrations of natural radioactivity similar to those observed in previous years, and indicated no build-up of radioactivity attributable to the operation of PNPP.

Aquatic monitoring included the collection and analyses of water, fish, and shoreline sediments. The 2009 analytical results for water and fish samples showed normal background radionuclide concentrations. The results of sediment sample analyses indicated that the annual average cesium radioactivity was similar to previous years for the control location. Cesium-137 activity was detected in four (4) of the eleven (11) samples collected. The average cesium-137 radioactivity for all locations was 505.24 pCi/kg and is within the maximum value of 864 pCi/kg established in 1981.

In 1999, a sediment sample of the northwest drain impoundment (sampling location #64) was analyzed to contain 62 pCi/kg of cobalt-60. During 2009, enhanced monitoring activities continued within the boundaries of the impoundment. The cobalt-60 remains centered within the organic material located at the top of the spillway, with little or no activity found farther upstream. Sample analyses continue to identify cobalt-60 levels similar to those found in previous years. Refer to Table 17 for detailed sample results.

Direct radiation measurements showed no change from previous years. The indicator locations averaged 54.03 mrem/year and control locations averaged 50.20 mrem/year. In 2009, radiation dose in the area of PNPP was similar to the radiation dose measured at locations greater than ten (10) miles away from the Plant.

Based on these results, during 2009, the operation of the PNPP resulted in no significant increase in the radionuclide concentrations observed in the environment.

LAND USE CENSUS

In order to estimate radiation dose attributable to the operation of PNPP, the potential pathways through which public exposure can occur must be known. To identify these exposure pathways, an Annual Land Use Census is performed as part of the REMP. During the census, PNPP personnel travel every public road within a five (5) mile radius of the plant to locate key radiological exposure pathways. These key pathways include the nearest resident, garden, and milk animal in each of the sixteen meteorological sectors. The information obtained from the census is entered into a computer program, which is used to assess the hypothetical dose to members of the public. In recent years, however, it has been noted that tracts of land once used for farming are now being developed as mini-industrial parks and residential housing tracts. For 2009, the predominant land use within the census area continues to be rural and/or agricultural.

CLAM/MUSSEL MONITORING

Clam and mussel shells can clog plant piping and components that use water from Lake Erie. For this reason, sampling for clams and mussels has been conducted in Lake Erie in the vicinity of PNPP since 1971. The monitoring is specifically for Corbicula (Asiatic clams), since their introduction into the Great Lakes, in 1981, and for Dreissena (zebra mussels), since their discovery in Lake Erie, in 1989. Since no Corbicula have ever been found at PNPP, routine Corbicula monitoring will provide early detection capability when this pest species arrives at PNPP. The Dreissena program includes both monitoring and control and is directed at minimizing the mussel's impact on plant operation. As in past years, this program has successfully prevented Dreissena from causing any significant operational problems at PNPP.

HERBICIDE USE

The use of herbicides on the PNPP site is monitored to ensure compliance with Ohio Environmental Protection Agency (OEPA) requirements and to protect the site's natural areas. Based on the results of on-site herbicide applications, and weekly general site inspections, herbicide use has not had a negative impact on the environment around the plant.

SPECIAL REPORTS

Significant environmental events (for example, spills, releases), noncompliance with environmental regulations [e.g., Ohio Environmental Protection Agency (OEPA) discharge limits], and changes in plant design or operation that affect the environment are reported to regulatory agencies as they occur.

One special report was submitted in 2009:

• A spill of approximately 3-5gallons of hydraulic fluid entered two storm drains that caused a sheen in the Minor Steam Impoundment on October 9, 2009. The spill was promptly cleaned up and all proper notifications were made.

INTRODUCTION

Nuclear energy provides an alternative energy source, which is readily available and has very limited impact upon the environment. To more fully understand nuclear energy as a source of generating electricity, one must understand basic radiation concepts and its occurrence in nature.

RADIATION FUNDAMENTALS

Atoms are the basic building blocks of all matter. Simply described, atoms are made up of positively and negatively charged particles, and particles which are neutral. These particles are called protons, electrons, and neutrons, respectively. The relatively large protons and neutrons are packed together in the center of the atom called the nucleus. Orbiting around the nucleus are one or more smaller electrons. In an electrically neutral atom, the positively charged protons in the nucleus balance the negatively charged electrons. Due to their dissimilar charges, the protons and electrons have a strong attraction for each other, which helps hold the atom together. Other attractive forces between the protons and neutrons keep the densely packed protons from repelling each other, and preventing the nucleus from breaking apart.

Atoms with the same number of protons in their nuclei make up an element. The number of neutrons in the nuclei of an element may vary. Atoms with the same number of protons but different numbers of neutrons are called isotopes. All isotopes of the same element have the same chemical properties and many are stable or non-radioactive. An unstable or radioactive isotope of an element is called a radioisotope, or radionuclide. Radionuclides contain an excess amount of energy in the nucleus, which is usually due to an excess number of neutrons.

Radioactive atoms attempt to reach a stable, non-radioactive state through a process known as radioactive decay. Radioactive decay is the release of energy from an atom's nucleus through the emission of radiation. Radionuclides vary greatly in the frequency with which their atoms release radiation. The length of time an atom remains radioactive is defined in terms of its half-life. Half-life is defined as the time required for a radioactive substance to lose half its activity through the process of radioactive decay. Half-lives vary from millionths of a second to millions of years.

RADIATION AND RADIOACTIVITY

Radioactive decay is a process in which the nucleus of an unstable atom becomes more stable by spontaneously emitting energy. Radiation refers to the energy that is released when radioactive decay occurs within the nucleus. This section includes a discussion on the three (3) primary forms of radiation produced by radioactive decay.

Alpha Particles

Alpha particles consist of two protons and two neutrons and have a positive charge. Because of their charge and large size, alpha particles do not travel very far when released (less than 4 inches, in air). They are unable to penetrate any solid material, such as paper or skin, to any significant depth. However, if alpha particles are released inside the body, they can damage the soft internal tissues because they deposit all their energy in a small area.

Beta Particles

Beta particles are essentially free electrons, which usually carry a negative electrical charge. They are much smaller than alpha particles and travel at nearly the speed of light. Thus they can travel for longer distances than alpha particles. External beta radiation primarily affects the skin. Because of their electrical charge, paper, plastic or thin metals can stop beta particles.

Gamma Rays

Gamma rays are bundles of electromagnetic energy, called photons, which behave as though they were particles. They are similar to visible light, but of a much higher energy. Gamma rays can travel long distances in air and are often released during radioactive decay, along with alpha and beta particles. Potassium-40 is an example of a naturally occurring radionuclide found in all humans that decays by emitting a gamma ray.

Interaction with Matter

When radiation interacts with other materials, it affects the atoms of those materials principally by knocking the negatively charged electrons out of orbit. This causes an atom to lose its electrical neutrality and become positively charged. An atom that is charged, either positively or negatively, is called an ion and the radiation is called ionizing radiation.

UNITS OF MEASURE

Some of the units of measure used in this report require explanation.

Activity

Activity is the number of atoms in a material that decay per unit of time. Each time an atom decays, radiation is emitted. The curie (Ci) is the unit used to describe the activity of a material and indicates the rate at which the atoms are decaying. One curie of activity indicates the decay of 37 billion atoms per second. Smaller units of the curie are often used in this report. Two common units are the microcurie (μ Ci), one millionth of a curie, and the picocurie (pCi), one trillionth of a curie. The mass, or weight, of radioactive material, which would result in one (1) curie of activity, depends on the disintegration rate. For example, one gram of radium-226 is equivalent to one (1) curie of activity. It would require about 1.5 million grams of natural uranium, however, to equal one (1) curie.

Dose

Biological damage due to alpha, beta, and gamma radiation may result from the ionization caused by these types of radiation. Some types of radiation, especially alpha particles, which causes dense local ionization, can result in much more biological damage for the same energy imparted than does gamma or beta radiation. Therefore, a quality factor must be applied to account for the different ionizing capabilities of various types of ionizing radiation. When the quality factor is multiplied by the absorbed dose (as measured in rads), the result is the dose equivalent, which is an estimate of the possible biological damage resulting from exposure to any type of ionizing radiation. The dose equivalent is measured in terms of the Roentgen Equivalent Man (rem). When discussing environmental radiation effects, the rem is a large unit. Therefore, a smaller unit, the millirem (mrem) is often used. One mrem is equivalent to 1/1000 of a rem.

LOWER LIMIT OF DETECTION

Sample results are often reported as below the Lower Limit of Detection (LLD). The LLD for an analysis is the smallest amount of radioactive material that will show a positive result for which there can be a 95% confidence that radioactivity is present. This statistical parameter is used as a measure of the sensitivity of a sample analysis. When a measurement is reported as less than the LLD (<LLD), it means that no radioactivity was detected. Had radioactivity been present at (or above) the stated LLD value, it statistically would have been detected. The NRC has established LLD values for environmental and effluent sample analyses.

BACKGROUND RADIATION

Background radiation is a part of nature. Natural background radioactive decay occurs in the soil, water, air, and space. Common sources of radiation that contribute to the natural background radiation includes: the decay of radioactive elements in the earth's crust, a steady stream of highenergy particles from space (called cosmic radiation), naturally-occurring radioactive isotopes in the human body like potassium-40, the decay of radioisotopes used in medical procedures, man-made phosphate fertilizers (phosphates and uranium are often found together in nature), fallout from nuclear weapons testing, and even household items like smoke detectors. In the United States, a person's average annual exposure from background radiation is 360 mrem, and is due to the sources shown in Figure 1 [Source: National Council on Radiation Protection and Measurements].




Figure 1: Sources of Background Radiation

Many radionuclides are present in the environment due to sources such as cosmic radiation and fallout from nuclear weapons testing. These radionuclides are expected to be present in many of the environmental samples collected in the vicinity of PNPP. Some of the radionuclides normally present include:

- Beryllium-7, present as a result of the interaction of cosmic radiation with the upper atmosphere,
- Potassium-40, a naturally occurring radionuclide normally found in humans and throughout the environment, and
- Radionuclides from nuclear weapons testing fallout, including tritium and cesium-137. These
 radionuclides may also be released in minute amounts from nuclear facilities.

Beryllium-7 and potassium-40 are especially common in REMP samples. Since they are naturally occurring and are expected to be present, positive results for these radionuclides are not discussed in the section for the 2009 Sampling Program results. These radionuclides are included; however, in Appendix A, 2009 Inter-Laboratory Cross Check Comparison Program Results.

RADIOACTIVE EFFLUENT RELEASES

INTRODUCTION

The source of radioactive material in a nuclear power plant is the generation of fission products (e.g., noble gas, iodine, and particulate) or neutron activation of water and corrosion products (e.g., tritium and cobalt). The majority of the fission products generated remain within the nuclear fuel pellet and fuel cladding. Most fission products that escape from the fuel cladding, as well as the majority of the activated corrosion products, are removed by plant processing equipment.

During the normal operation of a nuclear power plant, small amounts of radioactive material are released in the form of solids, liquids, and gases. PNPP was designed, and is operated in such a manner as to control and monitor these effluent releases. Effluents are controlled to ensure any radioactivity released to the environment is minimal and within regulatory limits. Effluent release programs include the operation of monitoring systems, in-plant sampling and analysis, quality assurance, and detailed procedures covering all aspects of effluent monitoring.

The liquid and gaseous radioactive waste treatment systems at PNPP are designed to collect and process these wastes in order to remove most of the radioactivity. Effluent monitoring systems are used to provide continuous indication of the radioactivity present and are sensitive enough to measure several orders of magnitude lower than the applicable release limits. This monitoring equipment is equipped with alarms and indicators in the plant control room. The alarms are set to provide warnings to alert plant operators when radioactivity levels reach a small fraction of actual limits. The waste streams are sampled and analyzed to identify and quantify the radionuclides being released to the environment.

Gaseous effluent release data is coupled with on-site meteorological data in order to calculate the dose to the general public. Devices are maintained at various locations around PNPP to constantly sample the air in the surrounding environment. Frequent samples of other environmental media are also taken to determine if any radioactive material deposition has occurred. The Radiological Environmental Monitoring Program (REMP) is described in detail in the next section.

Generation of solid waste is carefully monitored to identify opportunities for minimization. Limiting the amount of material taken into the plant, sorting material as radioactive or non-radioactive waste, and incinerating waste once it is identified help to lower the volume of radioactive solid waste generated. Solid waste is shipped to a licensed burial site.

REGULATORY LIMITS

The Nuclear Regulatory Commission has established limits for liquid and gaseous effluents that comply with:

- Title 10 of the Code of Federal Regulations, Part 20 (Standards for Protection Against Radiation) [10CFR20], Appendix B;
- Title 10 of the Code of Federal Regulations, Part 50 (Domestic Licensing of Production and Utilization Facilities) [10CFR50], Appendix I; and
- Title 40 of the Code of Federal Regulations, Part 190 (Environmental Radiation Protection Standards for Nuclear Power Plants) [40CFR190].

These limits were incorporated into the PNPP Technical Specifications, and subsequently into the PNPP Offsite Dose Calculation Manual (ODCM). The ODCM prescribes the maximum doses and dose rates due to radioactive effluents resulting from the operation of PNPP. These limits are defined in several ways to limit the overall impact on persons living near the plant. Since there are

no other fuel sources near the PNPP, the 40CFR190 limits, which are described below, were not exceeded in 2009.

The 40CFR190 limit for total direct-radiation dose is 25 mrem. For 2009, the total whole body dose to a member of the general public, considering all sectors, was 3.4E-1 person-Rem. This value was determined by summing the annual whole body doses from liquid and gaseous radioactive effluents, the annual gaseous and liquid organ dose (refer to Table 8) and the maximum, direct-radiation dose. Since the direct radiation dose, as determined by TLD, was indistinguishable from natural background (refer to Figure 9), it was not included in the calculation.

Liquid Effluents

The concentration of radioactive material released in liquid effluents to unrestricted areas shall be limited to the concentrations specified in 10CFR20, Appendix B, Table 2, Column 2 for radionuclides other than dissolved or entrained noble gases, as required by the ODCM. For dissolved or entrained noble gases, the concentration shall be limited to 2.0E-04 μ Ci/mL of total activity. These values are the maximum effluent concentrations.

The dose or dose commitment to a member of the public from radioactive materials in liquid effluents released to unrestricted areas shall be limited to the following:

During any calendar quarter:

Less than or equal to 1.5 mrem to the whole body, and

Less than or equal to 5 mrem to any organ.

During any calendar year:

Less than or equal to 3 mrem to the whole body, and

Less than or equal to 10 mrem to any organ.

Gaseous Effluents

Dose rate due to radioactive materials released in gaseous effluents from the site to areas at and beyond the site boundary shall be limited to the following:

Noble gases:

Less than or equal to 500 mrem per year to the whole body, and

Less than or equal to 3000 mrem per year to any organ.

Iodine-131, Iodine-133, Tritium, and all radionuclides in particulate form with half lives greater than eight days:

Less than or equal to 1500 mrem per year to any organ

Air dose due to noble gases to areas at, and beyond the site boundary, shall be limited to the following:

During any calendar quarter:

Less than or equal to 5 mrad for gamma radiation, and

Less than or equal to 10 mrad for beta radiation.

During any calendar year:

Less than or equal to 10 mrad for gamma radiation, and

Less than or equal to 20 mrad for beta radiation.

Dose to a member of the public from Iodine-131, Iodine-133, Tritium, and all radionuclides in particulate form with half lives greater than eight days in gaseous effluents released to areas at and beyond the site boundary shall be limited to the following:

Less than or equal to 7.5 mrem to any organ per any calendar quarter, and

Less than or equal to 15 mrem to any organ per any calendar year.

The PNPP ODCM does not contain a concentration reference for gaseous effluents. For this reason, effluent concentrations are not used to calculate maximum release rates for gaseous effluents.

RELEASE SUMMARY

Effluents are sampled and analyzed to identify both the type and quantity of radionuclides present. This information is combined with effluent path flow measurements to determine the composition, concentration, and dose contribution of the radioactive effluents.

Liquid Effluents

The PNPP liquid radioactive waste system is designed to collect and treat all radioactive liquid waste produced in the plant. The treatment process used for radioactive liquid waste depends on its physical and chemical properties. It is designed to reduce the concentration of radioactive material in the liquid by filtration to remove suspended solids and demineralization to remove dissolved solids. Normally, the effluent from the liquid radioactive waste system is returned to plant systems. To reduce the volume of water stored in plant systems; however, the processed liquid effluent may be discharged from the plant via a controlled release. In this case, effluent activity and dose calculations are performed prior to, and after discharging this processed water to Lake Erie to ensure regulatory compliance and dose minimization principals are maintained.

Liquid radioactive waste system effluents may be intermittently released, which are considered to be "batch" releases. Table 1 provides information on the number and duration of these releases for 2009.

	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4	Annual · Total
Number of batch releases	41	30	5	21	97
Total time period for batch releases, min	9.12E+03	7.01E+03	1.09E+03	5.17E+03	2.24E+04
Maximum time for a batch release, min	2.63E+02	2.42E+02	2.32E+02	2.79E+02	2.79E+02
Average time period for a batch release, min	2.22E+02	2.34E+02	2.19E+02	2.46E+02	2.30E+02
Minimum time for a batch release, min	2.00E+02	1.92E+02	2.09E+02	1.63E+02	1.63E+02
Average stream flow during periods of effluent release into a flowing stream, L/min	1.83E+05	2.31E+05	2.87E+05	2.04E+05	2.08E+05

Table 1: Liquid Batch Releases

Table 2 provides information on the nuclide composition for the liquid radioactive effluent system releases. If a radionuclide was not present at a level "greater than or equal to the LLD" (\geq LLD), then the value is expressed as "less than the LLD" (\leq LLD). In each case, LLDs were met, or were below the levels required by the ODCM. Table 2a provides information specific to radioactive effluent batch releases while Table 2b provides information specific to continuous radioactive effluent releases.

,	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4	EST. Total Error, (%)
A. Fission and Activation Products					
 Total Released, Ci (excluding tritium, gases, alpha) 	1.99E-02	2.55E-03	5.14E-04	7.66E-04	1.00E+01
2. Average Diluted Concentration, μCi/mL *	9.92E-10	8.88E-11	1.43E-11	3.62E-11	
3. Percent of Applicable Limit, %	N/A	N/A	N/A	N/A	,
B. Tritium					
1. Total Released, Ci	1.62E+01	1.02E+01	1.55E+00	1.06E+01	1.00E+01
2. Average Diluted Concentration, μCi/mL	8.08E-07	3.55E-07	4.30E-08	5.01E-07	
3. Percent of Applicable Limit, %	8.08E-03	3.55E-03	4.30E-02	5.01E-03	
C. Dissolved and Entrained Gases					
1. Total Released, Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td>1.00E+01</td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td>1.00E+01</td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td>1.00E+01</td></lld<></td></lld<>	<lld< td=""><td>1.00E+01</td></lld<>	1.00E+01
2. Average Diluted Concentration, μCi/mL	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td></td></lld<></td></lld<>	<lld< td=""><td></td></lld<>	
3. Percent of Applicable Limit, %	N/A	N/A	N/A	N/A	
D. Gross Alpha Activity, Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td>1.00E+01</td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td>1.00E+01</td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td>1.00E+01</td></lld<></td></lld<>	<lld< td=""><td>1.00E+01</td></lld<>	1.00E+01
E. Waste Volume Released, Liters (prior to dilution)	5.19E+06	4.94E+06	4.94E+6	3.40E+06	1.00E+01
F. Dilution Water Volume Used, Liters	2.01E11	2.76E11	3.60E11	2.12E11	1.00E+01

Table 2: Summation of All Liquid Effluent Releases

<LLD – Less than the lower limit of detection

N/A – Not Applicable, the ODCM does not have a limit for fission and activation products.

*Average diluted concentrations are based on total volume of water released during quarter.

		QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4	Est. Total Error, (%)
A.	Fission and Activation Products					
	Total Released, Ci (excluding tritium, gases, alpha)	1.99E-02	2.55E-03	5.14E-04	7.66E-04	1.00E+01
B.	Tritium					•
	Total Released, Ci	1.59E+01	1.02E+01	1.55E+00	1.06E+01	1.00E+01
C.	Dissolved and Entrained Gases					
	Total Released, Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td>1.00E+01</td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td>1.00E+01</td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td>1.00E+01</td></lld<></td></lld<>	<lld< td=""><td>1.00E+01</td></lld<>	1.00E+01
D.	Gross Alpha Activity, Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td>1.00E+01</td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td>1.00E+01</td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td>1.00E+01</td></lld<></td></lld<>	<lld< td=""><td>1.00E+01</td></lld<>	1.00E+01
E.	Waste Volume Released, Liters (prior to dilution)	5.19E+06	4.09E+06	6.28E+05	2.66E+06	1.00E+01

Table 2a: Summation of Batch Liquid Effluent Releases

<LLD – Less than the lower limit of detection

Table 2b: Summation of Continuous Liquid Effluent Releases

		QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4	EST. Total Error, (%)
A.	Fission and Activation Products					
	Total Released, Ci (excluding tritium, gases, alpha)	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td>1.00E+01</td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td>1.00E+01</td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td>1.00E+01</td></lld<></td></lld<>	<lld< td=""><td>1.00E+01</td></lld<>	1.00E+01
B.	Tritium					
	Total Released, Ci	2.13E-01	3.07E-02	<lld< td=""><td><lld< td=""><td>1.00E+01</td></lld<></td></lld<>	<lld< td=""><td>1.00E+01</td></lld<>	1.00E+01
C.	Dissolved and Entrained Gases					
	Total Released, Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td>1.00E+01</td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td>1.00E+01</td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td>1.00E+01</td></lld<></td></lld<>	<lld< td=""><td>1.00E+01</td></lld<>	1.00E+01
D.	Gross Alpha Activity, Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td>1.00E+01</td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td>1.00E+01</td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td>1.00E+01</td></lld<></td></lld<>	<lld< td=""><td>1.00E+01</td></lld<>	1.00E+01
E.	Waste Volume Released, Liters (prior to dilution)	5.19E+06	8.52E+05	4.31E+06	7.42E+05	1.00E+01

<LLD – Less than the lower limit of detection

Table 3 lists the total number of curies (Ci) of each radionuclide present in liquid effluent releases for each quarter. If a radionuclide was not present at a level "greater than or equal to the LLD" (\geq LLD), then the value is expressed as "less than the LLD" (\leq LLD). In each case, the LLDs were either met, or were below the levels required by the ODCM.

	Unit	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4	Annual Total
Tritium	Ci	1.59E+01	1.02E+01	1.55E+00	1.06E+01	3.83E+01
Chromium-51	Ci	9.72E-03	<lld< td=""><td><lld< td=""><td>1.42E-04</td><td>9.86E-03</td></lld<></td></lld<>	<lld< td=""><td>1.42E-04</td><td>9.86E-03</td></lld<>	1.42E-04	9.86E-03
Manganese-54	Ci	1.28E-03	1.12E-04	<lld< td=""><td>8.79E-05</td><td>1.48E-03</td></lld<>	8.79E-05	1.48E-03
Iron-55	Ci	<lld< td=""><td>1.96E-04</td><td><lld< td=""><td><lld< td=""><td>1.96E-04</td></lld<></td></lld<></td></lld<>	1.96E-04	<lld< td=""><td><lld< td=""><td>1.96E-04</td></lld<></td></lld<>	<lld< td=""><td>1.96E-04</td></lld<>	1.96E-04
Iron-59	Ci	5.06E-04	<lld< td=""><td><lld< td=""><td><lld< td=""><td>5.06E-04</td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td>5.06E-04</td></lld<></td></lld<>	<lld< td=""><td>5.06E-04</td></lld<>	5.06E-04
Cobalt-58	Ci	2.59E-04	<lld< td=""><td><lld< td=""><td><lld< td=""><td>2.59É-04</td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td>2.59É-04</td></lld<></td></lld<>	<lld< td=""><td>2.59É-04</td></lld<>	2.59É-04
Cobalt-60	Ci	7.90E-03	2.17E-03	2.61E-04	2.79E-04	1.06E-02
Zinc-65	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Strontium-92	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Zirconium-95	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Niobium-95	Ci	4.62E-05	<lld< td=""><td><lld< td=""><td><lld< td=""><td>4.62E-05</td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td>4.62E-05</td></lld<></td></lld<>	<lld< td=""><td>4.62E-05</td></lld<>	4.62E-05
Technetium-99M	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Rhuthenium-105	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Silver-110m	Ci	>LLD	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Antimony-124	Ci	<lld< td=""><td><lld< td=""><td>1.58E-05</td><td><lld< td=""><td>1.58E-05</td></lld<></td></lld<></td></lld<>	<lld< td=""><td>1.58E-05</td><td><lld< td=""><td>1.58E-05</td></lld<></td></lld<>	1.58E-05	<lld< td=""><td>1.58E-05</td></lld<>	1.58E-05
Antimony-125	Ci	<lld< td=""><td>5.35E-05</td><td>2.37E-04</td><td><lld< td=""><td>2.91E-04</td></lld<></td></lld<>	5.35E-05	2.37E-04	<lld< td=""><td>2.91E-04</td></lld<>	2.91E-04
Iodine-131	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Xenon-133	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Cesium-134	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Cesium-137	Ci	1.80E-04	<lld< td=""><td><lld< td=""><td><lld< td=""><td>1.80E-04</td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td>1.80E-04</td></lld<></td></lld<>	<lld< td=""><td>1.80E-04</td></lld<>	1.80E-04
Cesium-138	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Lanthanum-140	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Gold-199	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Total for Period	Ci	1.59E+01	1.02E+01	1.55E+00	2.57E-04	2.77E+01

<LLD – Less than the lower limit of detection

Gaseous Effluents

Gaseous effluents are made up of fission and activation gases, iodine and particulate releases. The fission and activation gas releases are primarily a result of containment purge operations, small steam leaks, and offgas system operation. The iodine and particulate releases are primarily a result of small steam leaks. Gaseous effluents from PNPP exit the plant via one of four effluent vents. Each of these four effluent vents contains radiation detectors that continuously monitor the air to ensure that the levels of radioactivity released are well below regulatory limits. Samples are also collected and analyzed on a routine basis to ensure regulatory compliance and dose minimization principals are maintained. The majority of gaseous effluents released from PNPP are considered continuous and at ground level.

A summation of all gaseous radioactive effluent releases is given in Table 4. If a radionuclide was not present at a level "greater than or equal to the LLD" (\geq LLD), then the value is expressed as "less than the LLD" (<LLD). In each case, the measured LLDs either met or were below the levels required by the PNPP ODCM.

		QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4	EST. TOTAL Error, %
Α.	Fission and Activation Products					
	1. Total Released, Ci	0.00E+00	1.07E+00	0.00E+00	8.67E-02	1.00E+01
	2. Average Release Rate, µCi/sec	0.00E+00	1.36E-01	0.00E+00	1.09E-02	
	3. Percent of Applicable Limit, %	N/A	N/A	N/A	N/A	
B.	Iodine	· · ·				
	1. Total Iodine-131 Released, Ci	1.17E-04	4.20E-05	< LLD	3.88E-05	1.00E+01
	2. Average Release Rate, µCi/sec	1.50E-05	5.34E-06	N/A	4.88E-06	
	3. Percent of Applicable Limit, %	N/A	N/A	N/A	N/A	
C.	Particulates with Half-Lives > 8 days	· ·				
	1. Total Released, Ci	<lld< td=""><td>< LLD</td><td>0.00E+00</td><td>0.00E+00</td><td>1.00E+01</td></lld<>	< LLD	0.00E+00	0.00E+00	1.00E+01
	2. "Average Release Rate, µCi/sec	<lld< td=""><td>< LLD</td><td><lld< td=""><td><lld< td=""><td></td></lld<></td></lld<></td></lld<>	< LLD	<lld< td=""><td><lld< td=""><td></td></lld<></td></lld<>	<lld< td=""><td></td></lld<>	
	3. Percent of Applicable Limit, %	. N/A	N/A	N/A	N/A ·	
D.	Alpha Activity, Ci	1.25E-06	9.07E-07	3.46E-09	1.10E-07	
E.	Tritium					
	1. Total Released, Ci	< LLD	< LLD	< LLD	< LLD	1.00E+01
	2. Average Release Rate, μCi/sec	N/A	N/A	N/A	N/A	
	3. Percent of ODCM Limit, %	N/A	N/A	N/A	N/A	

Table 4: Summation of All Gaseous Effluents

<LLD – Less than the lower limit of detection

N/A – Not Applicable, the ODCM does not have a limit for fission and activation products.

The radionuclide composition of all gaseous radioactive effluents for a continuous-mode, groundlevel release is given in Table 5. If a radionuclide was not present at a level "greater than or equal to the LLD" (\geq LLD), then the value is expressed as "less than the LLD" (\leq LLD). In each case, LLDs were met or were below the levels required by the ODCM.

		Unit	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4	Annual Total
Α.	FISSION AND ACTIVATION GASES						
	Tritium	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
	Argon-41	Ci	<lld< td=""><td><lld< td=""><td><lld.< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld.<></td></lld<></td></lld<>	<lld< td=""><td><lld.< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld.<></td></lld<>	<lld.< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld.<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
	Krypton-85m	Ci	<lld< td=""><td>7.86E-03</td><td><lld< td=""><td><lld< td=""><td>7.86E-03</td></lld<></td></lld<></td></lld<>	7.86E-03	<lld< td=""><td><lld< td=""><td>7.86E-03</td></lld<></td></lld<>	<lld< td=""><td>7.86E-03</td></lld<>	7.86E-03
	Krypton-85	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
	Kryton-87	Ci	<lld< td=""><td>6.87E-02</td><td><llď< td=""><td>1.04E-02</td><td>7.91E-02</td></llď<></td></lld<>	6.87E-02	<llď< td=""><td>1.04E-02</td><td>7.91E-02</td></llď<>	1.04E-02	7.91E-02
	Krypton-88	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td>8.96E-03</td><td>8.96E-03</td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td>8.96E-03</td><td>8.96E-03</td></lld<></td></lld<>	<lld< td=""><td>8.96E-03</td><td>8.96E-03</td></lld<>	8.96E-03	8.96E-03
	Xenon-131m	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
	Xenon-133m	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
	Xenon-133	. Ci	<lld< td=""><td>1.61E-02</td><td><lld< td=""><td><lld< td=""><td>1.61E-02</td></lld<></td></lld<></td></lld<>	1.61E-02	<lld< td=""><td><lld< td=""><td>1.61E-02</td></lld<></td></lld<>	<lld< td=""><td>1.61E-02</td></lld<>	1.61E-02
	Xenon-135m	Ci	<lld< td=""><td>7.22E-02</td><td><lld< td=""><td><lld< td=""><td>7.22E-02</td></lld<></td></lld<></td></lld<>	7.22E-02	<lld< td=""><td><lld< td=""><td>7.22E-02</td></lld<></td></lld<>	<lld< td=""><td>7.22E-02</td></lld<>	7.22E-02
	Xenon-135	Ci	<lld< td=""><td>3.20E-01</td><td><lld< td=""><td><lld< td=""><td>3.20E-01</td></lld<></td></lld<></td></lld<>	3.20E-01	<lld< td=""><td><lld< td=""><td>3.20E-01</td></lld<></td></lld<>	<lld< td=""><td>3.20E-01</td></lld<>	3.20E-01
	Xenon-137	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
	Xenon-138	Ci	<lld< td=""><td>5.86E-01</td><td><lld< td=""><td>6.74E-02</td><td>6.53E-01</td></lld<></td></lld<>	5.86E-01	<lld< td=""><td>6.74E-02</td><td>6.53E-01</td></lld<>	6.74E-02	6.53E-01
	Total for Period	Ci	<lld< td=""><td>1.70E+00</td><td><lld< td=""><td>8.67E-02</td><td>1.16E+00</td></lld<></td></lld<>	1.70E+00	<lld< td=""><td>8.67E-02</td><td>1.16E+00</td></lld<>	8.67E-02	1.16E+00
B.	Iodine		• · · · · · · · · · · · · · · · · · · ·				
	lodine-131	Ci	1.17E-04	4.20E-05	<lld< td=""><td>3.88E-05</td><td>1.98E-04</td></lld<>	3.88E-05	1.98E-04
	Iodine-132	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
_	Iodine-133	Ci	<lld< td=""><td>3.56E-04</td><td><lld< td=""><td>2.51E-05</td><td>3.31E-04</td></lld<></td></lld<>	3.56E-04	<lld< td=""><td>2.51E-05</td><td>3.31E-04</td></lld<>	2.51E-05	3.31E-04
	Iodine-134	Ci	<lld< td=""><td><lld< td=""><td><lld td="" ·<=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld></td></lld<></td></lld<>	<lld< td=""><td><lld td="" ·<=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld></td></lld<>	<lld td="" ·<=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
	Iodine-135	Ci	<lld td="" ·<=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
	Total for Period	Ci	1.17E-04	3.98E-04	<lld< td=""><td>6.39E-5</td><td>5.79E-04</td></lld<>	6.39E-5	5.79E-04
C.	PARTICULATE				· · · · · · · · · · · · · · · · · · ·	L	
	Chromium-51	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
	Manganese-54	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
	Iron-59	Ci	<lld< td=""><td><pre> <lld< pre=""></lld<></pre></td><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<pre> <lld< pre=""></lld<></pre>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
	Cobalt-58	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
	Cobalt-60	· · Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
	Zinc-65	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
	Rubidium-88	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
	Rubidium-89	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
	Strontium-89	Ci	<lld< td=""><td>6.62E-06</td><td><lld< td=""><td><lld< td=""><td>6.62E-06</td></lld<></td></lld<></td></lld<>	6.62E-06	<lld< td=""><td><lld< td=""><td>6.62E-06</td></lld<></td></lld<>	<lld< td=""><td>6.62E-06</td></lld<>	6.62E-06
	Strontium-90	Ci	<lld< td=""><td>1.09E-05</td><td><lld< td=""><td><lld< td=""><td>1.09E-05</td></lld<></td></lld<></td></lld<>	1.09E-05	<lld< td=""><td><lld< td=""><td>1.09E-05</td></lld<></td></lld<>	<lld< td=""><td>1.09E-05</td></lld<>	1.09E-05
	Strontium-91	Ci	<lld< td=""><td><lld< td=""><td>. <lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td>. <lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	. <lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
	Yttrium-91m	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
	Strontium-92	Ci	<lld< td=""><td><lld< td=""><td> <lld< li=""> </lld<></td><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td> <lld< li=""> </lld<></td><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	 <lld< li=""> </lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
	Zirconium-95	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
	Molybdenum-99	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
	Cesium-137	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
	Cesium-138	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
	Barium-139	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
	Darraneisz						
			<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
	Barium-140 Lanthanum-140	Ci Ci	<lld <lld< td=""><td><lld <lld< td=""><td><lld <lld< td=""><td><lld <lld< td=""><td><lld <lld< td=""></lld<></lld </td></lld<></lld </td></lld<></lld </td></lld<></lld </td></lld<></lld 	<lld <lld< td=""><td><lld <lld< td=""><td><lld <lld< td=""><td><lld <lld< td=""></lld<></lld </td></lld<></lld </td></lld<></lld </td></lld<></lld 	<lld <lld< td=""><td><lld <lld< td=""><td><lld <lld< td=""></lld<></lld </td></lld<></lld </td></lld<></lld 	<lld <lld< td=""><td><lld <lld< td=""></lld<></lld </td></lld<></lld 	<lld <lld< td=""></lld<></lld

Table 5: Radioactive Gaseous Effluent Nuclide Composition

<LLD - Less than the lower limit of detection

Solid Waste .

All solid radioactive waste from PNPP was processed and combined with waste from several other utilities by intermediate vendors (Energy Solutions, Duratek in Oak Ridge, TN and Studsvik, in Erwin, TN). This waste was ultimately sent to Clive, Utah disposal facilities for burial. The solid radioactive waste summary in Table 6 includes all PNPP shipments for 2009.

Table 6: Solid Waste Shipped Offsite for Burial or Disposal

A. TYPE OF SOLID WASTE SHIPPED	VOLUME (M3)	ACTIVITY (CI)	PERIOD	Est. Total Error (%)
Spent resin, filter sludge, evaporator bottoms, etc.	5.55E+1	1.02E+2	1/1/2009-12/31/2009	+/- 25
Dry compressible waste, contaminated equipment, etc.	1.86E+3	7.71E+0	1/1/2009-12/31/2009	+/- 25
Irradiated components, control rods, etc.	0	0	1/1/2009-12/31/2009	+/- 25
Other (Standby Liquid Control Waste Water)	0	0	1/1/2009-12/31/2009	+/- 25

В.	ESTIMATE OF MAJOR ⁽¹⁾ NUCLIDE COMPOSITION (BY TYPE OF WASTE)	RADIONUCLIDE	Abundance (%)	EST. TOTAL Error, (%)
	Spent Resin, Filter Sludge, Evaporator Bottoms, etc.	Mn-54	3.60	+/- 25
		Fe-55	59.0	
		Zn-65	3.10	
		Co-60	30.5	
		Cs-137	1.10	
	Dry Compressible Waste, Contaminated Equipment, etc.	Mn-54	3.90	+/- 25
		Fe-55	23.3	
		Co-60	51.7	
		Ni-63	1.50	
		Zn-65	15.7	
	·	Cs-137	2.40	
	Irradiated Components, Control Rods, etc.	None	0	
	Other (Standby Liquid Control Waste Water)	None	0	

C. **DISPOSITION** NUMBER OF **MODE OF TRANSPORTATION** DESTINATION SHIPMENTS Solid Waste⁽²⁾ 14 Public Highway Studsvik, Erwin, TN Solid Waste⁽²⁾ 34 Public Highway Duratek, Oak Ridge, TN Solid Waste 0 **Public Highway** Barnwell, Barnwell, S.C. 0 Irradiated Fuel Shipments N/A N/A

N/A -- Not Applicable

(1) -- "Major" is defined as any individual radionuclide identified as >1% of the waste type abundance.

(2) -- This waste was combined with waste from other utilities and disposed of at Clive, Utah.

METEOROLOGICAL DATA

The Meteorological Monitoring System at PNPP consists of a 60-meter tower equipped with two independent systems for measuring wind speed, wind direction, and temperature at both 10-meter and 60-meter heights. The tower also has instrumentation to measure dew point and barometric pressure. Data is logged from the tower through separate data loggers, and transmitted to a common plant computer. This system compiles the data and calculates a variety of atmospheric parameters, communicates with the Meteorological Information Dose Assessment System (MIDAS), and sends data over communication links to the plant Control Room.

A detailed report of the monthly and annual operation of the PNPP Meteorological Monitoring Program is produced under separate cover. For the period of January 1, 2009 through December 31, 2009, the report substantiates the quality and quantity of meteorological date collected in accordance with applicable regulatory guidance.

DOSE ASSESSMENT

The maximum concentration for any radioactive release is controlled by the limits set forth in Title 10 of the Code of Federal Regulations, Part 20 (10CFR20). Sampling, analyzing, processing, and monitoring the effluent stream ensures compliance with these concentration limits. Dose limit compliance is verified through periodic dose assessment calculations. Some dose calculations are conservatively performed for a hypothetical individual who is assumed to reside on the site boundary at the highest potential dose location all year. This person, called the "maximum individual", would incur the maximum potential dose from direct exposure (air plus ground plus water), inhalation, and ingestion of water, milk, vegetation, and fish. Because no one actually meets these criteria, the actual dose received by a real member of the public is significantly less than what is calculated for this hypothetical individual.

Dose calculations for this maximum individual at the site boundary are performed for two cases. First, they are performed using data for a 360° radius around the plant site (land and water based meteorological sectors), even though some of these sectors are over Lake Erie, which has no permanent residents. The second calculation is performed considering only those sectors around the plant in which people reside (land-based meteorological sectors).

The calculated hypothetical, maximum individual dose values at the site boundary are provided in Table 7. This table considers all meteorological sectors around PNPP and provides either the whole body or worst-case, organ dose values. If any radionuclide was not present at a level greater than the LLD, it was not used in the dose calculations.

TYPE OF DOSE	ORGAN	ESTIMATED DOSE, (MREM)	LIMIT	% OF Limit
Liquid Effluent	Whole body	1.81E-03	3.0E+00	6.0E-02
	Liver	2.48E-03	1.0E+01	2.5E-02
Noble Gas - gamma air	N/A	7.36E-03	1.0E+01	7.4E-02
- beta air	N/A	4.39E-03	2.0E+01	2.2E-02
Noble Gas	Whole body	3.63E-06	5.0E+00	7.3E-05
	Skin	8.17E-06	1.5E+01	5.4E-05
Particulate & Iodine	Thyroid	1.90E-04	1.5E+01	1.3E-03

Table 7: Maximum Individual Site Boundary Dose, Considering All Sectors

The calculated hypothetical, maximum population dose values at the site boundary are provided in Table 8. This table considers all meteorological sectors around PNPP and provides either the whole body or worst-case, organ dose values.

		•
	ORGAN	ESTIMATED DOSE (PERSON-REM)
Liquid Effluent	Whole body	3.4E-01
-	Thyroid	2.1E-01
Gaseous Effluent	Whole body	4.2E-05
	Thyroid	8.9E-03

Table 8: Population Dose, Considering All Sectors

Table 9 provides the calculated hypothetical maximum site boundary dose values considering only the land-based sectors. If any radionuclide was not present at a level greater than the LLD, it was not used in the dose calculations.

Type of Dose	ORGAN	ESTIMATED DOSE, (MREM)	Limit	% of Limit
Liquid Effluent	Whole body	3.57E-04	3.0E+00	1.2E-02
1	Liver	3.61E-04	1.0E+01	3.6E-03
Noble Gas - gamma air	N/A	2.80E-05	1.0E+01	2.8E-04
- beta air	N/A	1.87E-05	2.0E+01	9.4E-05
Noble Gas	Whole body	4.45E-08	5.0E+00	8.9E-07
	Skin	6.20E-08	1.5E+01	4.1E-07
Particulate & Iodine	Thyroid	5.33E-05	1.5E+01	3.6E-04

Table 9: Maximum Individual Site Boundary Dose, Considering Sectors on Land

Other dose calculations are performed for a hypothetical individual who is assumed to be inside the site boundary for some specified amount of time. This person would receive the maximum dose during the time spent inside site boundary. Because no one actually meets the criteria established for these conservative calculations, the actual dose received by a real member of the public is significantly less than what is calculated for this hypothetical individual. This dose is assessed relative to the offsite dose, and considers dilution, dispersion, and occupancy factors.

The highest hypothetical dose from liquid effluents to a member of the public inside the site boundary is to a person who is fishing on Lake Erie from the shore on PNPP property. The calculations assume that this person will spend 60 hours per year fishing, with a liquid dilution factor of 10. The ratio of the exposure pathway to the doses calculated for offsite locations yields the dose values shown in Table 10.

	WHOLE BODY DOSE, (MREM)	ORGAN DOSE, (MREM)
First Quarter	5.00E-04	5.9E-04
Second Quarter	1.30E-04	1.5E-4
Third Quarter	1.10E-05	1.2E-05
Fourth Quarter	1.50E-05	1.7E-05
Annual	6.50E-04	7.7E-04

Table 10: Maximum Site Dose from Liquid Effluents

Although several cases were evaluated to determine the highest hypothetical dose from gaseous effluents to members of the public inside site boundary, the activity inside the site boundary with the highest dose potential is also shoreline fishing. The cases evaluated included traversing a public road within the site boundary, shoreline fishing (assuming fishing 60 hours per year), non-plant related training, car-pooling, and job interviews. The maximum on-site gaseous doses generated are shown in Table 11.

	and the second		
	WHOLE BODY DOSE, (MREM)	ORGAN DOSE, (MREM)	
First Quarter	0.0E+00	0.0E+00	
Second Quarter	3.9E-07	8.8E-07	
Third Quarter	0.0E+00	0.0E+00	
Fourth Quarter	0.0E+00	0.0E+00	
Annual	3.9E-07	8.8E-07	

Table 11:	Maximum	Site Dose	from	Gaseous	Effluents

An average whole body dose to individual members of the public at or beyond the site boundary is then determined by combining the dose from gaseous and liquid radiological effluents. The dose from gaseous radiological effluents is based upon the population that lives within 50 miles of PNPP (2,420,000 people). The dose from liquid radiological effluents is determined for the population that receives drinking water from intakes within 50 miles of PNPP (1,820,000 people). The results of this calculation are provided in Table 12.

	LIQUID EFFLUENTS (MREM)	GASEOUS EFFLUENTS (MREM)
First Quarter	9.50E-8	1.40E-13
Second Quarter	1.10E-7	1.30E-11
Third Quarter	2.30E-9	0.00E+00
Fourth Quarter	2.20E-8	3.90E-12
Annual	1.40E-7	1.70E-11

ON-SITE GROUNDWATER MONITORING PROGRAM

Introduction

History

In March, 2006, a routine sample of the underdrain system at the Perry plant showed detectable tritium concentration. The underdrains are a porous pipe system which drains groundwater from the foundations of the site buildings. As such, it would not be expected to be a contaminated system. A Condition Report, 06-01477, was submitted, and a Root Cause Investigation was conducted. Concurrently, a program of groundwater monitoring was initiated.

It was determined at that time that there was no detectable tritium beyond the boundaries of the underdrain system. Piezometer tubes located both inside and outside of the power block, (area encompassing equipment utilized for the generation of electricity) were sampled and analyzed. In 2007, Perry contracted with Environmental Resource Management (ERM) of Boston, Massachusetts to perform site hydrogeology evaluations, and to facilitate installation of additional groundwater monitoring wells, based on their findings. FirstEnergy fleet chemistry formalized the program with the issuance of fleet procedure NOP-LP-2012, "Groundwater Monitoring."

Cause

The buildings at the Perry site are designed with seismic spaces between building walls. These would serve to drain plant buildings in the event of an earthquake of sufficient strength to break plant piping, minimizing the flooding of vital equipment areas, and facilitate continued safe operation, or safe shutdown, as conditions warrant.

It was surmised that these "rattle spaces" also allow the drainage from some plant systems to reach the outside. Since this discovery, the plant has developed a more rigorous stance towards plant observations, and has minimized process water intrusion into the rattle spaces.

It should be noted that no leakage was identified from either the radwaste system, or from the Spent Fuel Building.

Underdrain System

As mentioned earlier, the underdrain system drains water away from plant foundations. It is separate and distinct from the storm drain system, which is designed purely for rain water control. The underdrain system has a number of installed sump pumps, with the ability to gravity-drain and cascade forward should the pumps fail. There are two major branches of underdrains, one for each of the east and west sides of the power block. These branches ultimately flow into 2 underdrain manholes, designated MH-20 and MH-23, before draining to the suction bay of the Emergency Service Water (ESW) pump house. From there, the water is discharged from the plant. Refer to Figure 2 for locations of Manholes 1 through 23.

Sampling Locations


Prior to the installation of monitoring wells, Manholes 20 and 23 were sampled to assess groundwater tritium in-leakage to the system. This continued through July 2007, and sampling frequency was established at weekly thereafter. Besides tritium, the samples were also analyzed via gamma spectroscopy to environmental lower limits of detection. No gamma activity was ever detected in any sample.

Manholes 20 and 23 were sampled daily through the middle of 2007, and weekly thereafter through the end of the year. Tritium releases from the station were documented as abnormal releases, and the required dose calculations were completed per the Offsite Dose Calculation Manual (ODCM). Overall, the released tritium represented a very small fraction of the limits prescribed in 10CFR20 Appendix B and 10CFR50.

Based on the ERM hydrogeology study, 12 wells were recommended for the site. Since most groundwater flow was anticipated to drain north, towards Lake Erie, the majority of wells are drilled there. A set of control wells was drilled in a more southerly direction, to assess what a typical groundwater profile would be.

There are 4 sets of triplet wells installed at each location. Each triplet has a shallow well (approximately 25 feet), a mid-depth well of approximately 50 feet, and a deep well of approximately 75 feet. These 3 depths are designated A, B and C, from shallowest to deepest, respectively. Refer to Figure 2 for locations of Groundwater wells 1A through 4C.

Besides these wells, there are a number of plant piezometers which date back to early plant construction. Outside of the power block, these are located directionally along the 4 major compass points. There are also piezometers inside the plant buildings in numerous locations. Refer to Figure 2 for locations of Piezometers.



Radioactive Effluent Releases Page 20

State of the Program

Currently, the monitoring wells are sampled twice annually, in spring and fall. The sampling is done under a controlled protocol, and is conducted by personnel from FirstEnergy's BETA Laboratories. Selected plant piezometers are also sampled.

The samples are analyzed for shipping purposes, and are then shipped to Midwest Laboratories in Illinois. Midwest analyzes the sample for gamma isotopic and tritium. On alternate samples, Perry has also requested analysis of "hard-to-detect" isotopes such as Sr-89/90, Ni-63 and Fe-55. Starting in 2010 the NRC will require additional testing for C-14.

Sample Analysis

The May 2009 sample set for the 12 installed monitoring wells showed gamma isotopic activity <LLD and tritium activity was barely over the LLD for one well site at 261 pCi/liter. The November 2009 sample set showed gamma activity <LLD and tritium activity was barely over the LLD for one well site at 313 pCi/liter. Analyses for the hard-to-detect nuclides were negative, all less than LLD. Two samples (4A and 4B) for the November 2009 collection were lost in transit. Condition report #10-75950 was generated for documentation purposes.

Significant Items

A fleet level procedure was implemented for notifications in the event that detectable tritium reaches 10% of the EPA-mandated trigger level of 20,000 pCi/liter. This formalized the protocol for any groundwater contamination issues.

A fleet self-assessment was conducted to verify alignment with NEI 07-07, the Groundwater Protection Initiative. There were minor items noted, but no substantial shortfalls in compliance with the NEI document.

	H-3 Max. (PC1/L)	H-3 Min. (PC1/L)	H-3 Avg. (PCI/L)	TYPICAL H-3 LLD (PCI/L)	REQUIRED H-3 LLD (PC1/L)	PRE- OPERATIONAL (DEVELOPED) MEAN FOR H-3 (PCI/L)	H-3 ANALYSES > Pre- Operational Mean for H-3?	NEI AND FENOC Level For H-3 (PCi/L)	EPA Reporting Level for H-3 (PCI/L)
First Half 2009	261	N/A	N/A	< 200	< 2000	400	No	2000	20000
Second Half 2009	313	N/A	N/A	< 200	< 2000	400	No	2000	20000

Table 13: Summary of Onsite Groundwater Samples

ABNORMAL RELEASES

There was one abnormal radioactive release events during 2009. On March 10, 2009 chemistry sampled Emergency Service Water A from the hose connected to the drain of the Residual Heat Removal A heat exchanger (ESW side). When the test for tritium was complete results showed a tritium level of 4.14e-6 uCi/ml. Normal tritium activity in ESW is less than detectable. Back up

sample from the same sample point but without the hose connected showed tritium results of 4.02e-6 uCi/ml. Chemistry Supervision, Operations Control Center Shift Outage Director, and Operations Shift Manager were informed. Chemistry was instructed to sample ESW Forebay (8.78E-07 uCi/ml), Underdrain Manholes 20 (2.66E-06 uCi/ml) and 23 (1.26E-06 uCi/ml) which all had detectable levels of Tritium. The ESW A system is to be drained to the Plant Discharge Tunnel (Normal effluent release path) and will be treated as an abnormal release and processed in accordance with chemistry effluents program to account for Doses to the Public. The out of spec tritium is believed to be from multiple Radwaste releases that occurred during Refuel Outage 12 February- May. Based on the flow, this would have equated to a release of 2.04E-01 curies.

NON-COMPLIANCES

There were six non-compliances to the ODCM Controls requirements in 2009.

The Emergency Service Water Radiation Monitor was inoperable greater than 30 days. Total days inoperable (31) days.

The Emergency Service Water B Radiation Monitor, (1D17-K605) was declared inoperable on 1/26/09 due to planned maintenance. Following maintenance, the monitor failed downscale. Troubleshooting performed by Fix It Now/ Maintenance team and reworked. The instrument was returned to service on 2/26/2009.

The Liquid Radwaste to Emergency Service Water Discharge Radiation Monitor was inoperable greater than 30 days. Total days inoperable (121) days.

The Liquid Radwaste to Emergency Service Water Discharge Radiation Monitor, (0D17-K606) was declared inoperable on 3/2/09 due to spiking. Notification given a low priority due to competing priorities. The instrument was returned to service on 7/1/2009.

The Liquid Radwaste High Flow Discharge Header Flow Monitor was inoperable greater than 30 days. Total days inoperable (69) days.

The Liquid Radwaste High Flow Discharge Header Flow Monitor, (0G50-K466) was declared inoperable on 4/3/09 due to erratic readings. Previously identified problem of inaccurate and calibration deficiencies on the 0G50R087 recorder combined with failing total flow readings contributed to erroneous data being entered on the Liquid Radwaste Discharge SVI. Calibrations of both instruments needed prior to any future Radwaste discharges. Calibration and verification performed. The instrument was returned to service on 6/11/2009.

The Turbine Building Radiation Monitor Noble Gas Channel was inoperable greater than 30 days. Total days inoperable (31) days.

The Turbine Building Radiation Monitor Noble Gas Channel declared inoperable on 4/10/09 due to the alarm and alert lights not working during the performance of SVI-D17-T8000D. Returned to service and verified on 5/10/09, and the noble gas channel was declared operable on 5/11/09.

The Emergency Service Water B Radiation Monitor was inoperable greater than 30 days. Total days inoperable (38) days.

The Emergency Service Water B Radiation Monitor, (1D17-K605) was declared inoperable on 4/12/09 due to spurious low flow alarms. Maintenance team replaced the annunciator card for the channel. The instrument was returned to service on 5/20/2009.

OFFSITE DOSE CALCULATION MANUAL CHANGES

During this reporting period, there were no (0) changes to the Offsite Dose Calculation Manual.

PROCESS CONTROL PROGRAM CHANGES

During this reporting period, there were no (0) changes to the Process Control Program.

RADIOLOGICAL ENVIRONMENTAL MONITORING

INTRODUCTION

The Radiological Environmental Monitoring Program (REMP) was established at PNPP for several reasons. First, it verifies the adequacy of plant design and operation to control radioactive materials and limit effluent releases. Second, it assesses the radiological impact, if any, that the plant has had on the surrounding environment. Third, it ensures compliance with regulatory guidelines. The REMP is conducted in accordance with the PNPP Operating License, Appendix B, Technical Specifications and the ODCM. The Nuclear Regulatory Commission (NRC) established the REMP requirements.

A wide variety of samples are collected as part of the PNPP REMP. The selection of sample types, sampling locations, and sample collection frequency are based on many things. Potential pathways for the transfer of radionuclides through the environment to humans, sample availability, local meteorology, population characteristics, land use and NRC requirements are all considered.

To ensure that the REMP data are meaningful and useful, detailed sampling methods and procedures are followed. This ensures that samples are collected in the same manner and from the same locations each time. All samples are packaged on site, and then shipped to an independent vendor laboratory for analysis. The vendor laboratory analyzes the samples and reports results to the PNPP Chemistry Unit staff, the Lake County General Health District, and the State of Ohio Department of Health.

The REMP began in 1981 with 24 direct radiation monitoring locations, four sediment locations, and two fish sampling locations. In 1982, collections of air, water, milk, food products, and feed/silage were added. Vegetation, precipitation and soil were added in 1985. Although the NRC did not require these last three media, they were incorporated into the program to establish baseline data. In 1993, feed/silage sampling was dropped from the program, based on ten years worth of data. For the same reason, strontium analyses were deleted from the program in 1994, gross beta and tritium were deleted from precipitation analyses in 1995, and precipitation sampling was deleted entirely in 1996. In 1999, grass (vegetation) and soil sampling were dropped from the program.

SAMPLING LOCATIONS

REMP samples are collected at numerous locations, both on site and up to 22 miles away from the plant. Sampling locations are divided into two general categories: indicator and control. Indicator locations are those which would be most likely to display effects caused by plant operation. They are relatively close to the plant. Control locations are those which are considered to be unaffected by plant operation. Typically, they are a greater distance from the plant, in the least prevalent wind directions. Data obtained from the indicator locations are compared with data from the control locations. This comparison allows naturally occurring background radiation to be taken into account when evaluating any radiological impact PNPP may have had on the environment. Table 14, Figure 3, Figure 4 and Figure 5 identify the PNPP REMP sampling locations.

Many REMP samples are collected in addition to those required by the PNPP ODCM. The ODCM requirements for each sample type are discussed in more detail below. Sample types and locations required by the ODCM are shown in **Bold** in Table 14.

.

LOCATION #	DESCRIPTION	MILES	DIRECTION	MEDIA(2)
1	Chapel Road	3.4	ENE	TLD, AIP
2	Kanda Garden	1.9	ENE	Food Products
3	Meteorological Tower	1.0	SE	TLD, AIP
4	Site Boundary	0.7	S	TLD, AIP
5	Quincy Substation	. 0.6	SW	TLD, AIP
6	Concord Service Center	11.0	SSW	TLD, AIP
7	Site Boundary	0.6	NE	TLD, AIP
8	Site Boundary	0.8	Е	TLD
9	Site Boundary	0.7	ESE	TLD
. 10	Site Boundary	· 0.8	SSE	TLD
11	Parmly Rd.	0.6	SSW	TLD
12	Site Boundary	0.6	WSW	TLD
13	Madison-on-the-Lake	4.7	ENE	TLD
14	Hubbard Rd.	4.9	Е	TLD
15	Eagle St. Substation	5.1	ESE	TLD
16	Eubank Garden.	0.8	. S	Food Products
18	Kijauskas Farm	2.5	E	Food Products, Milk
20	Rainbow Farms	1.9	E '	Food Products
21	Hardy Rd.	5.1	WSW	TLD
23	High St. Substation	7.9	WSW	TLD
24	St. Clair Ave.	15.1	SW	TLD
25	Offshore - PNPP discharge	0.6	NNW	Sediment, Fish
26	Offshore - Redbird	4.2	ENE	Sediment
27	Offshore - Fairport Harbor	7.9	WSW	Sediment
28	CEI Ashtabula Plant Intake	22.0	ENE	Water
29	River Rd.	4.3	SSE	TLD
30	Lane Rd.	4.8	SSW	TLD
31	Wood and River Rd.	4.8	SE	TLD
32	Offshore - Mentor	15.8	WSW	Sediment, Fish
33	River Rd.	4.5	S	TLD
34	PNPP Intake	0.7	NW	Water
35				
	Site Boundary	0.6	E	TLD. AIP
	Site Boundary Lake County Water Plant	0.6	E WSW	TLD, AIP
36	Lake County Water Plant	3.9	WSW	TLD, Water
36 37	Lake County Water Plant Gerlica Farm	3.9 1.5	WSW ENE	TLD, Water Food Products
36 37 41	Lake County Water Plant Gerlica Farm Tuttle Farm (goat)	3.9 1.5 5.8	WSW ENE SSE	TLD, Water Food Products Milk
36 37 41 51	Lake County Water Plant Gerlica Farm Tuttle Farm (goat) Rettger Milk Farm (cow)	3.9 1.5 5.8 9.6	WSW ENE SSE S	TLD, Water Food Products Milk Milk
36 37 41 51 53	Lake County Water Plant Gerlica Farm Tuttle Farm (goat) Rettger Milk Farm (cow) Neff Perkins	3.9 1.5 5.8 9.6 0.5	WSW ENE SSE S WSW	TLD, Water Food Products Milk Milk TLD
36 37 41 51 53 54	Lake County Water Plant Gerlica Farm Tuttle Farm (goat) Rettger Milk Farm (cow) Neff Perkins Hale Rd. School	3.9 1.5 5.8 9.6 0.5 4.6	WSW ENE SSE S WSW SW	TLD, Water Food Products Milk Milk TLD TLD
36 37 41 51 53 54 55	Lake County Water Plant Gerlica Farm Tuttle Farm (goat) Rettger Milk Farm (cow) Neff Perkins Hale Rd. School Center Rd.	3.9 1.5 5.8 9.6 0.5 4.6 2.5	WSW ENE SSE S WSW SW S S	TLD, Water Food Products Milk Milk TLD TLD TLD
36 37 41 51 53 54 55 56	Lake County Water Plant Gerlica Farm Tuttle Farm (goat) Rettger Milk Farm (cow) Neff Perkins Hale Rd. School Center Rd. Madison High School	3.9 1.5 5.8 9.6 0.5 4.6 2.5 4.0	WSW ENE SSE S WSW SW SW SS ESE	TLD, Water Food Products Milk Milk TLD TLD TLD TLD TLD
36 37 41 51 53 54 55 56 58	Lake County Water Plant Gerlica Farm Tuttle Farm (goat) Rettger Milk Farm (cow) Neff Perkins Hale Rd. School Center Rd. Madison High School Antioch Rd.	3.9 1.5 5.8 9.6 0.5 4.6 2.5 4.0 0.8	WSW ENE SSE S WSW SW SW SSW SSE ESE ENE	TLD, Water Food Products Milk Milk TLD TLD TLD TLD TLD TLD TLD
36 37 41 51 53 54 55 56 58 59	Lake County Water PlantGerlica FarmTuttle Farm (goat)Rettger Milk Farm (cow)Neff PerkinsHale Rd. SchoolCenter Rd.Madison High SchoolAntioch Rd.Lake Shoreline at Green Rd.	3.9 1.5 5.8 9.6 0.5 4.6 2.5 4.0 0.8 4.0	WSW ENE SSE S WSW SW SW SSW ESE ENE ENE	TLD, Water Food Products Milk Milk TLD TLD TLD TLD TLD Water
36 37 41 51 53 54 55 56 58 59 60	Lake County Water PlantGerlica FarmTuttle Farm (goat)Rettger Milk Farm (cow)Neff PerkinsHale Rd. SchoolCenter Rd.Madison High SchoolAntioch Rd.Lake Shoreline at Green Rd.Lake Shoreline at Perry Park	3.9 1.5 5.8 9.6 0.5 4.6 2.5 4.0 0.8 4.0 1.0	WSW ENE SSE S WSW SW SW SSW ESE ENE ENE ENE WSW	TLD, Water Food Products Milk Milk TLD TLD TLD TLD TLD Water Water
36 37 41 51 53 54 55 56 58 59 60 61	Lake County Water PlantGerlica FarmTuttle Farm (goat)Rettger Milk Farm (cow)Neff PerkinsHale Rd. SchoolCenter Rd.Madison High SchoolAntioch Rd.Lake Shoreline at Green Rd.Lake Shoreline at Perry ParkKeller Milk Farm (goat)	3.9 1.5 5.8 9.6 0.5 4.6 2.5 4.0 0.8 4.0 1.0 7.4	WSW ENE SSE S WSW SW SW SSW ESE ENE ENE ENE SE	TLD, WaterFood ProductsMilkMilkTLDTLDTLDTLDWaterWaterMilk
36 37 41 51 53 54 55 56 58 59 60 61 63	Lake County Water Plant Gerlica Farm Tuttle Farm (goat) Rettger Milk Farm (cow) Neff Perkins Hale Rd. School Center Rd. Madison High School Antioch Rd. Lake Shoreline at Green Rd. Lake Shoreline at Perry Park Keller Milk Farm (goat) Minor Stream Mouth	3.9 1.5 5.8 9.6 0.5 4.6 2.5 4.0 1.0 7.4 0.08	WSW ENE SSE S WSW SW SW SS ESE ENE ENE ENE WSW SE NNE	TLD, Water Food Products Milk Milk TLD TLD TLD TLD Water Water Water Milk Sediment
36 37 41 51 53 54 55 56 58 59 60 61	Lake County Water PlantGerlica FarmTuttle Farm (goat)Rettger Milk Farm (cow)Neff PerkinsHale Rd. SchoolCenter Rd.Madison High SchoolAntioch Rd.Lake Shoreline at Green Rd.Lake Shoreline at Perry ParkKeller Milk Farm (goat)	3.9 1.5 5.8 9.6 0.5 4.6 2.5 4.0 0.8 4.0 1.0 7.4	WSW ENE SSE S WSW SW SW SSW ESE ENE ENE ENE SE	TLD, WaterFood ProductsMilkMilkTLDTLDTLDTLDWaterWaterMilk


Table 14: REMP Sampling Locations (1)

(1) chronologically missing location numbers denote deleted or retired sampling locations.


(2) AIP = Air, Iodine and Particulate

TLD = Thermoluminescent Dosimeter









0 1 2 3 4 5 10 MILES

Radiological Environmental Monitoring Page 27




Figure 5: REMP Sampling Locations Greater Than Eight Miles from the Plant Site

SAMPLE ANALYSIS

When environmental samples are analyzed for radioactivity, several types of measurements are performed to provide information about the types of radiation and radionuclides present. The major analyses that are performed are discussed below.

Gross beta activity measures the total amount of beta-emitting radioactivity present in a sample, and acts as a tool to identify samples that may require further analysis. Beta radiation may be released by many different radionuclides. Since beta decay results in a continuous energy spectrum rather than the discrete energy levels, or "peaks", associated with gamma radiation, identification of specific beta-emitting nuclides is much more difficult. Therefore, gross beta activity only indicates whether the sample contains normal or abnormal amounts of beta-emitting radioactivity; it does not specifically identify the radionuclides present.

Gamma spectral analysis provides more specific information than does the analysis for gross beta activity. Gamma spectral analysis identifies each radionuclide, and the amount of radioactivity, present in the sample emitting gamma radiation. Each radionuclide has a very specific "fingerprint" that allows for accurate identification and quantification.

Iodine activity analysis measures the amount of radioactive iodine present in a sample. Some media (for example, air sample charcoal cartridges) are analyzed directly by gamma spectral analysis. With other media (for example, milk), the radioiodines are extracted by chemical separation before being analyzed by gamma spectral analysis.

Tritium activity analysis measures the amount of the radionuclide tritium (H-3) present in a sample. Tritium is an isotope of hydrogen that emits low-energy beta particles. Tritium occurs naturally and is also man-made.

Gamma doses received by Thermoluminescent Dosimeters (TLD) while in the field are determined by a special laboratory procedure. Thermoluminescence is a process by which ionizing radiation interacts with the sensitive phosphor material in the TLD. Energy is trapped in the TLD material and can be stored for months or years. This capability provides an excellent method to measure the dose received over long periods of time. The amount of energy that was stored in the TLD as a result of interaction with radiation is released by a controlled heating process and measured in a calibrated reading system. As the TLD is heated, the phosphor releases the stored energy as light. The amount of light is directly proportional to the amount of radiation to which the TLD was exposed. The reading process also zeroes the TLD and prepares it for reuse. Table 15 provides a list of the analyses performed on environmental samples collected for the PNPP REMP in 2009.

Sample results are often reported as less than the lower limit of detection (< LLD), which is defined as the smallest amount of radioactive material that will show a positive result for which there can be confidence that radioactivity is present. This statistical parameter is used as a measure of the sensitivity of a sample analysis. When a measurement is reported as < LLD, it means that no radioactivity was detected at a value above, or equal to the appropriate ODCM table value. The NRC has established LLD values for REMP sample analyses. The vendor laboratory for REMP sample analyses complied with those values in 2009.

Туре	SAMPLE	FREQUENCY	ANALYSIS
Atmospheric Monitoring	Airborne Particulates	Weekly &	Gross Beta Activity & Gamma Spectral Analysis
	Airborne Radioiodine	Weekly	Iodine-131
Terrestrial Monitoring	Milk	Bi-Monthly	Gamma Spectral Analysis & Iodine-131
	Food Products	Monthly	Gamma Spectral Analysis
Aquatic Monitoring	Water	· Monthly	Gross Beta Activity & Gamma Spectral Analysis
. ·		Quarterly	Tritium Activity
	Fish	Annually	Gamma Spectral Analysis
	Sediment	Biannually	Gamma Spectral Analysis
Direct Radiation Monitoring	TLD	Quarterly & Annually	Gamma Dose

Table 15: REMP Sample Analyses

2009 SAMPLING PROGRAM

The contribution of radionuclides to the environment resulting from PNPP operation is assessed by comparing results from the 2009 program with pre-operational data (i.e., data from before 1986), operational data from previous years, and control location data. The results for each sample type are discussed below and compared to historical data to determine if there are any observable trends. All results are expressed as concentrations. Refer to Appendix B, 2009 REMP Data Summary Reports for a detailed listing of these results. The NRC requires special reporting whenever sample analysis results exceed set limits. No values exceeded these reporting levels in 2009.

Program Changes

The 2008 Land Use Census identified a new milking animal (goat) location within 3 miles of PNPP. The Kijauskas Farm (location #18) began participation in the REMP in 2009. The first milk samples were provided in April 2009. Additionally, the farm also agreed to participate in the REMP Food Products (Garden) program, providing their first food product samples in August 2009.

Missed Samples

On occasion, samples cannot be collected. This can be due to a variety of events, including equipment malfunction, animal husbandry practices, or lost shipments. Events may also occur which prevent a sample from being collected in the normal way, or prevent a complete sample from being collected. The drying period for goats is an annual occurrence, since unlike cows, goats cannot produce milk year-round. Food products are weather dependent and are susceptible to excessive spring rains or summer drought that can significantly impact the garden harvest. Shoreline lake water samples are collected by grab sample utilizing a container and scoop. During the winter months the shoreline can become inaccessible due to ice and snow buildup, preventing the safe collection of these samples. Shoreline sediment samples are collected with spoon and container. On occasion, the accessibility of these locations and sample collection may be impacted due to high lake levels, shifting lake bottom sediment, bluff erosion and shoreline collapse. For 2009, there was no impact to the program requirements as a result of any missed samples. Table 16 provides information on samples missed during 2009.

Media	LOCATION	DATE	REASON
Air Samples	N/A	N/A .	N/A
Food Products	All	JanJune, Dec. 2009	Insufficient growth/temperature. Die- off/Frost damage.
	18,20,70	July	Insufficient growth.
	16	Nov.	Die-off/Frost damage
Lake Water	59, 60	Jan., Feb., Dec. 2009	Sample unavailable due to frozen shoreline
Milk	-18	Jan., Feb., March 2009	Not participating at this time.
	41	Jan., Feb., Mar., Oct., Nov., Dec. 2009	Drying period for goats/sample availability
	61	Jan., Feb., Mar., Apr., Nov., Dec. 2009	Drying period for goats/sample availability
Sediment	63	June and September 2009	Location inaccessible
	65	June 2009	Shoreline under water. Location inaccessible
TLDs	7	3 rd quarter 2009	Annual TLD collected by mistake. Not ODCM required. CR 09-66741

Table 16: Missed REMP Samples in 2009

Atmospheric Monitoring

Air

Air sampling is conducted to detect any increase in the concentration of airborne radionuclides. The PNPP REMP maintains an additional 2 air sampling locations above the five locations (four indicators and one control) required by the ODCM. Six (6) of these locations are within four miles of the plant site; the seventh is used as a control location and is eleven miles from PNPP. Air sampling pumps are used to draw continuous samples at a rate of approximately two cubic feet per minute. The air is drawn through glass fiber filters (to collect particulate material) and a charcoal cartridge (to adsorb iodine). The samples are collected on a weekly basis, 52 weeks a year, from each of the seven air sampling stations.

On occasion, air sample locations can experience power losses associated with storms and/or malfunctioning equipment. On 10/26/09, ODCM location #35 was found not running during the weekly sample collection. It was determined that the sample location had lost power due to a breaker issue on a nearby utility pole. Power was restored and the sample location returned to service the same day. The amount of continuous run time provided adequate sample for laboratory analysis, resulting in no loss of sample. Condition report 09-57750 was generated for documentation purposes.

Air samples are analyzed weekly for gross beta activity and radioiodine activity. The air samples are also analyzed by gamma spectral analysis quarterly. A total of 364 air particulate and 364 air radioiodine samples were collected and analyzed in 2009.

Gross beta activity was detected in 363 of 364 air samples and ranged up to 0.04 pCi/m³. The average gross beta activity at both indicator and control locations was 0.02 pCi/m³ for 2009. Historically, the concentration of gross beta in air has been essentially identical at indicator and control locations. Figure 6 reflects the average gross beta activity for 2009 and the previous years.

Except for naturally occurring beryllium-7, no radionuclides were identified in the gamma spectral analysis above the LLD values. Iodine-131 was not detected in any sample above the LLD of 0.05 pCi/m^3 .




Figure 6: Annual Average Gross Beta Activity, in Air

Terrestrial Monitoring

Collecting and analyzing samples of milk and food products provides data to assess the build-up of radionuclides that may be ingested by humans. The historical data from soil and vegetation samples provides information on the atmospheric radionuclide deposition. The PNPP ODCM requires neither vegetation nor soil samples.

Milk

Samples of milk are collected once each month from November through March, and twice each month from April through October. Sampling is increased during the summer because animals usually feed outside on pasture and not on stored feed. For 2009, the PNPP REMP included four (4) milk locations located 2.5, 5.8, 7.4 and 9.6 miles away from the plant. The Kijauskas Farm, (location #18, 2.5 miles in the East sector) began participation in April 2009 after being identified during the 2008 Land Use Census.

Since the milk sampling locations do not meet the requirements of the ODCM (no milk-producing animals located within the required areas), food product sampling (discussed below) is performed. Milk is collected from the available locations for informational purposes, even though they do not meet the ODCM requirements. If new locations that meet the ODCM requirements are identified in the future, they will be added to the program.

Milk samples are analyzed by gamma spectral analysis for radioiodines and other radionuclides. A total of fifty-nine (59) milk samples were collected in 2009. Iodine was not detected in any of the samples above the LLD of 0.75 pCi/ L. The concentrations of all radionuclides, except naturally occurring potassium-40, were below LLDs in all samples collected.

Food Products

Food products can provide a direct pathway to humans by ingestion. They can absorb radionuclides from atmospheric deposition on soil or from irrigation water drawn from a lake or pond receiving airborne or liquid effluents. Also, radionuclides in the soil may be absorbed by the roots of the plants and become incorporated into the edible portions. Because there is not a sufficient number of

dependable milk sampling locations, the PNPP REMP is required to include two food product indicator locations and one control location. Food products are collected monthly during the growing season from six (6) gardens in the vicinity of PNPP. Location #18, Kijauskas Farm became the sixth (6) participant in August 2009. The control location for food products is 16.2 miles SSW from PNPP.

A total of sixty-six (66) food product samples were collected and analyzed by gamma spectral analysis in 2009. Limiting factors for the 2009 growing season included unseasonable temperatures and an early drought followed by excessive rain accounting for the missed samples referenced in Table 16. Four (4) food products were collected which included: beet greens, collard greens, turnip greens and swiss chard. Beryllium-7 and potassium-40, naturally-occurring radionuclides, were found in several samples, as expected. No other radionuclides were detected above the required LLDs.

Aquatic Monitoring

Radionuclides may be present in Lake Erie from many sources other than the PNPP. These sources include atmospheric deposition, run-off/soil erosion, and releases of radioactivity in liquid effluents from hospitals, universities or other industrial facilities. These sources provide two forms of potential radiation exposure, external and internal. External exposure can occur from contact with water or shoreline sediments, while internal exposure can occur from either direct ingestion of radionuclides or the transfer of radionuclides through the aquatic food chain. Direct ingestion can occur from drinking the water, while the transfer via the aquatic food chain occurs from the eventual consumption of aquatic organisms, such as fish. To monitor these pathways, PNPP samples water, shoreline sediments, and fish.

Water

Water is sampled from five locations along Lake Erie in the vicinity of the PNPP as required by the PNPP ODCM. Samples from three locations are collected using composite sample pumps. The pumps are designed to collect water at regular intervals and composite it in a sample container. Samples from the two other locations are manually collected weekly and combined. The containers are emptied monthly and the samples shipped to the vendor laboratory for analysis.

Fifty-four (54) water samples were collected and analyzed for gross beta activity and gamma spectral analysis in 2009. From these monthly samples, twenty (20) quarterly composite samples were obtained and analyzed for tritium activity.

Gross beta activity was detected in two (2) of the fifty-four (54) samples collected. For 2009, the detectable gross beta activity was 3.14 pCi/L vs. the lab LLD value of 3.00 pCi/L. Refer to Figure 7 for the annual average gross beta activity for both indicator and control locations. The significant difference between the pre-1988 data and post-1988 data has been attributed to a change in vendor laboratories in 1987/1988. A comprehensive explanation for the observed difference is provided in the 1988 Annual Environmental Operating Report.




Figure 7: Annual Average Gross Beta Activity, in Water

There were no radionuclides detected by gamma spectral analysis above the LLD.

Tritium was not detected above the LLD value in any of the twenty (20) samples analyzed. These results are well within the range of those measured in previous years, which have ranged from below the LLD to 2,200 pCi/L. Refer to Table 16 for an explanation of any missed samples.

Sediment

Sampling of lake bottom sediments can provide an indication of the accumulation of particulate radionuclides which may lead to internal exposure to humans through the ingestion of fish, the resuspension into drinking water, or as an external radiation source to fishermen and swimmers from shoreline exposure. Although the PNPP ODCM requires only one location, sediment is sampled twice each year from seven (7) locations. Two (2) of the sampling locations are also fish sampling locations. Sediment samples from offshore are collected using a hand dredge. Shoreline samples are collected using a scoop. Eleven (11) sediment samples were collected in 2009 and analyzed by gamma spectroscopy. Beginning in 2006, access to sample location 63 was lost due to shoreline erosion which resulted in a bluff collapse. Lack of safe access continues to prevent sample collection at location #63. The predominant radionuclide detected by gamma spectral analysis was naturally-occurring potassium-40. Potassium-40 has been detected in all samples, since the program began in 1981.

Cesium-137 activity was detected in four (4) of the eleven (11) samples collected and ranged from 301.33 pCi/kg to 699.30 pCi/kg. The annual average cesium-137 activity was 321.37 pCi/kg for the indicator locations and 689.11 pCi/kg at the control location. The average cesium-137 radioactivity for all locations was 505.24 pCi/kg and is within the maximum value of 864 pCi/kg established in 1981. Year-to-year variations in lake bottom sediment sample activity is expected and beyond the control of PNPP. For example, cesium-137 activity variations (refer to Figure 8) in the control locations from year-to-year may be contributed to:

- 1. The movement of sediment on the lake bottom due to wave action and currents.
- 2. Difficulty in duplicating exact location and composition of bottom sediment sample from year to year even with assistance of GPS.




Figure 8: Annual Average Cesium-137 Concentration in Sediment

In 1999, a sediment sample from location #64 (shoreline discharge point of the Northwest Drain Impoundment) was found to contain trace levels of cobalt-60. Ten (10) additional sample locations were established upstream from location #64 and within the Impoundment to identify the boundary of the cobalt-60 activity and to support supplemental monitoring activities. In recent years, the shoreline adjacent to the impoundment has experienced extensive bluff erosion and collapse, preventing access and sample collection for locations 64-4 and 64-5. For 2009, sample results for cobalt-60 from the eight (8) remaining locations confirm that no activity was identified at the discharge point (Location #64), and continues to remain within the Northwest Drain Impoundment with an activity range of <7 pCi/kg to 251 + 77 pCi/kg (Refer to Table 17). Additionally, Table 18 reflects Cesium-137 activity within the impoundment sediment for informational purposes.

LOCATION	06/18/09	06/29/09	9/16/09	10/13/09	
64	<17	**	**	<8.7	
64-1	**	<7	<12	**	
64-2	**	<22	<18	**	
64-3	**	<24	<24	**	
64-4	*	*	*	*	
64-5	*	*	*	*	
64-6	**	<70	111 +/- 38	**	
64-7	**	118 +/- 33	251 +/- 77	**	
64-8	**	<21	30 +/- 14	**	
64-9	**	210 +/- 77	<51	**	
64-10	**	138 +/- 39	236 +/- 56	**	

Table 17: Northwest Drain Impoundment Cobalt-60 Activity, pCi/kg (dry)

* No sample available or insufficient sample for analysis

** No sample collected on this date

LOCATION	06/18/09	06/29/09	. 09/16/09	10/13/09
64	<14.7	** `	**	<11.4
64-1	**	<19	44 +/- 18	**
64-2	**	494 +/- 46	416 +/- 36	**
64-3	**	71 +/- 42	145 +/- 32	**
64-4	*	*	*	* .
64-5	*	*	*	*
64-6	**	1638 +/- 135	2029 +/- 95	**
64-7	**	2630 +/- 98	1581 +/- 137	**
64-8	** .	586 +/- 48	776 +/- 34	**
64-9	**	1511 +/- 103	1478 +/- 100	**
64-10	** '	1912 +/- 83	2194 +/- 140	: , **

Table 18: Northwest Drain Impoundment Cesium-137 Activity, pCi/kg (dry)

No sample available or insufficient sample for analysis g

* No sample collected on this date

Fish

Fish are analyzed primarily to quantify the dietary radionuclide intake by humans, and secondarily to serve as indicators of radioactivity in the aquatic ecosystem. Fish are collected from two locations, annually during the fishing season as required by the ODCM. An important sport or commercial species is targeted, and only the fillets are sent to the laboratory for analysis. In 2009, fish sampling was performed for PNPP by a local licensed sport fisherman.

Eight (8) fish samples (yellow perch, white perch, white bass and walleye) were collected and analyzed by gamma spectral analysis in 2009. As expected, naturally occurring potassium-40 was found in all samples. No other radionuclides were detected above the LLD.

Direct Radiation Monitoring

Thermoluminescent Dosimeter (TLD)

Environmental radiation is measured directly at twenty-eight locations around the PNPP site, two of which are control locations. The locations are positioned in two rings around the plant as well as at the site boundary. The inner ring is within a one-mile radius of the plant site; the outer ring is four to five miles from the plant. The control locations are over ten miles from the plant in the two least prevalent wind directions. Each location is equipped with three TLDs, two of which are changed quarterly and one is changed annually.

A total of 253 TLDs were collected and analyzed in 2009. This includes 224 collected on a quarterly basis and twenty-seven (27) of twenty-eight (28) collected annually. During the 3rd quarter 2009 collection, annual TLD for location #7 was inadvertently collected and sent for analysis. Annual TLDs are not required per the ODCM and are used for supplemental data only. Condition report 09-66741 was generated for documentation purposes.

For 2009, the annual average dose for all indicator locations was 54.03 mrem, and 50.20 mrem for the control locations. The indicator annual average dose is believed to be influenced by location #36 (Figure 4) which has been consistently higher in dose than TLDs positioned closer to the plant (Figure 3). Referring to Figure 9, the average quarterly dose for all indicator locations was 12.82 mrem, and 12.27 mrem for all control locations. Please refer to Appendix B, 2009 REMP Detailed Data Report for all TLD results. Prior to 1988, the TLD results were higher due to a change in the vendor laboratory services. A comprehensive explanation of this difference was provided in the 1988 Annual Environmental Operating Report.




Figure 9: Average Quarterly TLD Dose

Conclusion

Sediment samples continue to confirm cobalt-60 in the northwest drain impoundment. Additional monitoring is being performed to monitor this location. An environmental evaluation determined that there would be less impact upon the environment by leaving this material in place. Atmospheric monitoring results were consistent with past results. The prevalent radionuclide in air was beryllium-7, which is naturally occurring. Naturally occurring potassium-40 was detected in all terrestrial samples, as expected.

Finally, direct radiation measurements are consistent with past data.

INTER-LABORATORY CROSS-CHECK COMPARISON PROGRAM

Introduction

The purpose of the Inter-laboratory Cross-Check Comparison Program (ICCCP) is to provide an independent check on the vendor laboratory's analytical procedures. Samples with a known concentration of specific radionuclides are provided to the vendor laboratory. The vendor laboratory measures and reports the concentration of specified radionuclides. The known values are then compared to the vendor results. Results consistently outside established acceptance criteria indicate a need to check instruments or procedures. Regulatory Guide 4.15 specifically required that contractor laboratories that performed environmental measurement participate in the EPA's Environmental Radioactivity Laboratory Inter-Comparison Studies Program, or an equivalent program.

The EPA's program is no longer funded or offered. The reason that the EPA program was referenced in the regulatory guide is that the EPA standards were traceable to National Bureau of Standards (now known as National Institute Standard Technology). In response to this problem, Teledyne (PNPP vendor lab) incorporated a program offered by Environmental Resource Associates (ERA Company), which covered the same analyses in the same matrix at the same frequency as the EPA program. The ERA Company has received NIST accreditation for its program, as an equivalent program. In addition to comparison cross checks performed with the ERA Company, the vendor laboratory routinely monitors the quality of their analyses by:

- Analyzing "spiked" samples (samples with a specific quantity of radioactive material present in them) and
- Participating in the Department of Energy's Mixed Analyte Performance Program (MAPEP).

Through 2004, Teledyne also participated in the Environmental Measurements Laboratory Quality Assessment Program (EML). This program was discontinued in 2005.

Conclusion

Appendix A, 2009 Inter-Laboratory Cross-Check Comparison Program Results, includes results from both the above referenced programs and the ERA Company cross-check program.

- 1) Table A-1, Environmental Resource Associates (ERA) Interlaboratory Comparison Crosscheck Program:
 - The vendor laboratory Cs-137 analysis results for water sample STW-1182 failed initially due to a deformed base of the Marinelli beaker. A new beaker (sitting directly on the detector) obtained the desired results within control limits.
 - Initial analysis of H-3 in sample STW-1186 failed. A reanlysis of the sample was performed and found to be within control limits.
- 2) Table A-2, Vendor Laboratory's Cross-Check testing of Thermoluminescent Dosimetry were found to be within the expected control limits.
- 3) Laboratory analysis results for Table A-3, In-House "Spike" Samples were within their expected control limits.
- 4) Analysis results for Table A-4, In-House "Blank" Samples were within their activity limits.
- 5) Table A-5, In-House "Duplicate" Samples were within their averaged results.

- 6) Table A-6, Department of Energy MAPEP:
 - Vendor laboratory Am-241 analysis for water sample STW-1170 initially failed. There was insufficient sample for reanalysis and no procedure or calculation errors were identified.
 - Acceptable results for Am-241 in water are included in the second round of testing (sample STW-1192) and ERA studies Tables A-7.
 - Initial Am-241 results for air sample STAP-1174 failed. One determination was eliminated due to poor recovery. The average of three determinations was within the control limits.
 - The analysis for Stontium 90 in air sample STAP-1174 initially failed high. No reason could be determined. Reanalysis was within the control limits.
 - The initial failure of Sr-90 analysis in soil sample STSO-1188 was due to the possible incomplete separation of strontium from calcium. Analysis was repeated and the results within the control limits.
- 7) The vendor laboratory results for Table A-7, Interlaboratory Comparison Crosscheck Program Environmental Resource Associates (ERA) laboratory were all within their control limits.

LAND USE CENSUS

Introduction

Each year a Land Use Census, which is required by Section 5.2 of the PNPP ODCM, is conducted to identify the locations of the nearest milk animal, garden (of greater than 500 square feet), and residence in each of the meteorological sectors that is over land. Information gathered during the Land Use Census is used for off-site dose assessment and to update sampling locations for the Radiological Environmental Monitoring Program. The census is conducted by traveling all roads within a five-mile radius of the plant site, and recording and mapping the location of the nearest resident, milk animal and vegetable garden. The 2009 Land Use Census, which was conducted August 10th and 11th provided the garden, residence and milk animal locations tabulated in Tables 19, 20 and 21 and depicted in Figure 10. Note that the W, WNW, NW, NNW, N, and NNE sectors extend over Lake Erie, and therefore, are not included in the survey.

Discussions and Results

In general, the predominant land use within the census area continues to be rural/ agricultural. In recent years however, it has been noted that tracts of land once used for farming are now being developed as mini-industrial parks and residential housing tracts. This is reflected in the loss of available milking animals within a five mile radius of PNPP to support the Radiological Environmental Monitoring Program (REMP). The 2009 Land Use Survey used the 1999 survey map produced by the Commercial Survey Co. of Cleveland. GPS units are also used for more accurate location identification.

Table 19 identifies the nearest residences, by sector, to the PNPP. The table is updated annually to reflect any changes identified during the annual Land Use Census. For 2009, there were no changes noted for the "nearest residence".

SECTOR	LOCATION ADDRESS	Miles from PNPP	X/Q VALUE, (SEC/M3)	MAP LOCATOR NUMBER
· NE	4384 Lockwood	0.7	2.66E-06	· 1
ENE	4412 Lockwood	0.7	1.96E-06	2 J
E	2626 Antioch	1.1	6.77E-07	3
ESE	2836 Antioch	· 1.0 ×	8.57E-07	4
SE	4537 North Ridge	1.3	3.44E-07	5
SSE	4225 Redmill Valley Rd.	·, ·, 1.1 · ·	5.52E-06	6
S.	3119 Parmly	0.9	2.25E-06	7
SSW	3121 Center	1.0	9.49E-07	8
SW ,	3440 Clark	1.3	4.42E-07	9
WSW -	3462 Parmly	1.1.	8.67E-07	10

Table 19: Nearest Residence, By Sector




Figure 10: Land Use Census Map

Radiological Environmental Monitoring Page 41

Table 20 identifies the nearest milking animal by sector, to the PNPP. The milking animal identified during the 2008 census began program participation in April of 2009. During the 2009 Land Use Census, no additional new milking animals were identified.

SECTOR	LOCATION ADDRESS	MILES FROM PNPP	MAP LOCATOR NUMBER
Е	2591 McMacken Rd.	2.51	21

Table 20: Nearest Milk Animal, By Sector

There was one (1) change in the nearest garden for the WSW sector during this year's census. Changes can include either the loss of the previous year's garden or the addition of a new garden identified in this year's census. The garden nearest the plant in the WSW sector returned for 2009. Table 21 lists the nearest gardens occupying at least 500 square feet identified during the 2009 Land Use Census.

Table 21: Nearest Garden, By Sector

SECTOR	LOCATION ADDRESS	MILES FROM PNPP	D/Q VALUE, (M ⁻²)	MAP LOCATOR NUMBER
NE	2330 Lakehurst	0.9	8.91E-09	11
ENE	4630 Lockwood	1.1	4.77E-09	12
Е	2626 Antioch	1.1	5.29E-09	3
ESE	2836 Antioch	1.0	3.96E-09	4
SE	3040 Antioch	1.3	1.01E-09	15
SSE	3288 Call Rd.	1.4	2.04E-09	16
S	3964 North Ridge	1.4	2.73E-09	17
SSW	3121 Center	1.0	4.66E-09	8
SW	3440 Clark	1.3	1.95E-09	9
WSW	2975 Perry Park	1.3	2.31E-09	20

CLAM/MUSSEL MONITORING

INTRODUCTION

Sampling for macro-invertebrates (clams and mussels) has been conducted in Lake Erie in the vicinity of PNPP, since 1971. The clam/mussel program currently focuses on two species: *Corbicula fluminea* (Asiatic clam) and *Dreissena polymorpha* (zebra mussel).

CORBICULA PROGRAM

Monitoring specifically for Corbicula was initiated in response to a NRC bulletin and concerns of the Atomic Safety and Licensing Board. The 2009 monitoring was done as part of the Environmental Protection Plan (Operating License, Appendix B). The program consists of visually inspecting the raw water systems, when they are opened for maintenance. The purpose of this program is to detect Corbicula, should it appear at PNPP.

No Corbicula have been found in any sample collected from PNPP. Two Corbicula were found in a sample collected from the Eastlake plant in June, 1987. No Corbicula have been found in any other sample collected since that time. A more detailed program history can be found in the 1986 and 1987 PNPP Annual Environmental Operating Reports.

Monitoring

In 2009, samples were collected from the Service Water (SW) and Emergency Service Water (ESW) pump houses at PNPP and examined for shells and fragments. Samples were either collected by hand scoop or scraper. In addition to sample collections, plant components that use raw water are inspected when opened for maintenance or repair. Sample collection/inspection dates are listed in Table 22.

DATE	SAMPLE LOCATION
2/28/09	Low pressure condenser water boxes
3/1/09	Intermediate pressure condenser water boxes
3/2/09	Auxiliary condenser 'A'
3/3/09	Emergency Service Water valve P45-F572
3/3/09	Auxiliary condenser 'B'
3/4/09	Emergency Service Water 'B' discharge pipe
3/5/09	High pressure condenser water boxes
3/26/09	Emergency Service Water 'C' discharge strainer
3/26/09	Division I Emergency diesel generator jacket water heat exchanger
3/27/09	Emergency Service Water 'A' coupon assembly
3/28/09	Emergency Service Water 'A' strainer
7/30/09	Main Turbine Lube Oil cooler 'B'
8/18/09	Charcoal filter intake strainer 0P54-D0742
8/19/09	Main Turbine Lube Oil cooler 'A'
9/23/09	Fire protection system piping in building RW 602'
9/25/09	Main Turbine Lube oil coolers
10/5/09	Fire Protection system valve 0P54-F0521
10/5/09	Fire Protection system valve 0P54-F0520
10/5/09	Fire Protection system valve 0P54-F0518
10/26/09	Fire Protection system piping
12/10/09	Service Water 'A' strainer

Table 22: 2009 Corbicula Monitoring

Conclusions

The sample collected in June, 1987, was the only indication of Corbicula in the vicinity of PNPP. Although the presence of Corbicula was detected at the Eastlake Power Plant, it has not been demonstrated that their presence has created any operational problems there, or at PNPP. As in the past, the 2009 monitoring program did not identify Corbicula in any sample collected.

14

DREISSENA PROGRAM

Dreissena, or Zebra mussels were first discovered at PNPP in September, 1988. The initial collection of 19 mussels was made as part of the Corbicula monitoring program. The Dreissena monitoring program began in 1989, with monitoring and testing. The current control program was designed and implemented in 1990.

Monitoring

In addition to visually inspecting the plant's raw water systems when they are opened for maintenance or repair, monitoring methods include the use of commercial divers and side-stream monitors. Commercial divers monitor mussel infestation during the inspection of forebays, basins, and the intake and discharge structures. Divers have also been used to take underwater videotapes of the water basins and intake tunnel. Side-stream monitors are flow-through containers that receive water diverted from plant systems and are set up at two in-plant locations during the mussel season. The side-stream monitors are fitted with slides and inspected for veliger settlement and growth of adult mussels.

Treatment

Chemicals used for mussel control in 2009 included chlorine and a commercial molluscicide. The chlorine is intermittently injected into the plant service water, emergency service water, and circulating water systems by metering sodium hypochlorite into each system's influent. Sodium bisulfite is added at the plant discharge structure for dechlorination prior to return into Lake Erie.

The use of a commercial molluscicide has been approved by the Ohio Environmental Protection Agency (OEPA). The chemical selected for use at the PNPP in 2009 was alkyl-dimethyl-benzyl-ammonium chloride. Treatment was applied twice in 2009, on June 2 and September 10. The active ingredients were detoxified by adsorption using bentonite clay, prior to discharge into Lake Erie.

Results

The effectiveness of the intermittent chlorination treatment has been determined in several ways. First, visual inspections of raw water system components are conducted when systems are open during maintenance or repair. In addition, settlement monitors were inspected for new settlement. No live settlement has been found in any plant component to date.

The effectiveness of the application of the commercial molluscicide was measured by observing mortality of mussels placed in a flow-through container placed in plant service water and subjected to the chemical treatment. The observed mortality rate utilizing the flow-through container for 2009 was 50% and 99.5% respectively. It is believed that the disparity between the Spring and Fall mortality rates were the result of initial colder water temperatures in the Spring and a bias in the use of larger and more mature Zebra mussels for mortality determination. The larger and more mature mussels have the ability to detect chemical changes in the water and hold their breath longer to avoid the effects of chemical treatment. Condition report 09-60254 was generated for documentation purposes. To date, PNPP has had no significant problems related to zebra mussels.

CONCLUSIONS

Perry Nuclear Power Plant has taken the approach that the best method for avoiding problems with zebra mussels is preventive treatment of plant water systems. The current program of monitoring and chemical treatment will be continued to minimize the possibility that PNPP will experience future problems due to zebra mussels.

HERBICIDE APPLICATIONS

Herbicides are used sparingly on the PNPP site. A request must be made to, and approved by the PNPP Chemistry Unit prior to spraying to ensure that only approved chemicals are used, and only in approved areas.

In 2009, three (3) general and one (1) specific herbicide requests were initiated for chemical applications. Each application was in compliance with the Ohio Environmental Protection Agency's rules and regulations. There were no adverse environmental impacts observed during weekly site environmental inspections as a result of these applications. The herbicides approved for use in the Owner-Controlled Area are Round-Up, Spyder, Karmex, Pramitol, Polaris, Tempo Ultra, and Oust. For each application, the type of weed to be treated dictated the herbicide and concentration to be used. Table 23 provides detailed documentation for each application in 2009. The quantity represents the amount of herbicide applied, prior to any dilution.

DATE APPLIED	LOCATION	AMOUNT	CHEMICAL NAME
4/28/09	Admin., Training buildings and long main roads	12.0 oz	Round-up
5/6/09	Admin., IPC, P&R Buildings	15.0 oz	Round-up
5/12/09	Protected area landscape beds/gravel areas	12.0 oz	Round-up
5/15/09	Transmission Yard	684.7 oz	Polaris
5/15/09	Transmission Yard	24.3 oz	Spyder
5/19/09	Admin. and Training buildings. OCA fence line.	51.0 oz	Round-up
5/26/09	Protected area landscape beds/gravel areas	18.0 oz	Round-up
5/27/09	Admin., Training, WHSE, IPC Buildings	54.0 oz	Round-up
5/28/09	OCA perimeter, Admin. building, and contractor parking lot	300.0 oz	Round-up
6/4/09	Admin., Training, WHSE, IPC, P&R Buildings and Hydrogen/gravel area	240.0 oz	Round-up
6/5/09	Fire training grounds, contractor park lot, and firing range	300.0 oz	Round-up
6/9/09	Security towers, booths and perifeld zones	50 gms	Tempo Ultra
6/11/09	Transformer Yard	330.0 oz	Round-up
6/16/09	OCA environmental pathways	9.0 oz	Round-up
6/26/09	Protected area perimeter and transformer yard	2760.0 oz	Round-up
6/29/09	North end of OCA	237.0 oz	Round-up
6/30/09	Training building	24.0 oz	Round-up
7/13/09	Admin., IPC, Training Buildings	300.0 oz	Round-up
7/14/09	WHSE building and contractor parking lot	12.0 oz	Round-up
7/21/09	Waste accumulation facility	90.0 oz	Round-up
7/27/09	Hydrogen/Gravel Area and Admin. building	600.0 oz	Round-up
8/6/09	Gravel areas on East and North side of plant	300.0 oz	Round-up
8/11/09	OCA perimeter and Training building	27.0 oz	Round-up
8/18/09	Transformer alleyway	90.0 oz	Round-up
8/25/09	Admin., Training, and IPC Buildings	30.0 oz	Round-up
9/1/09	General Protected area	18.0 oz	Round-up
9/2/09	Security towers, booths and perifeld zones	25 gms	Tempo Ultra
9/4/09	Protected area NE, NW, SE, SW quadrants	450.0 oz	Round-up
9/9/09	Admin., Training, and IPC Buildings	21.0 oz	Round-up

Table 23: 2009 Herbicide Applications

SPECIAL REPORTS

NON-COMPLIANCES

NPDES Permit

The National Pollutant Discharge Elimination System (NPDES) permit is issued by the Ohio Environmental Protection Agency (OEPA). It establishes monitoring requirements and limits for discharges from the PNPP. It also specifies the locations from which the plant is allowed to discharge.

One special report was submitted for 2009:

• On October 09, 2009, the Perry Plant reported a non-compliance to the Ohio EPA due to a spill of approximately 3-5gallons of hydraulic fluid that entered two storm drains and caused an oil sheen in the Minor steam impoundment. The spill was promptly cleaned up and all proper notifications were made.

Environmental Protection Plan

The Environmental Protection Plan (EPP), which is Appendix B of the PNPP Operating License, requires a non-radiological environmental monitoring and reporting program be established at the PNPP.

One special report was submitted for 2009:

• On October 09, 2009, the Perry Plant reported a non-compliance to the NRC due to a spill of approximately 3-5gallons of hydraulic fluid that entered two storm drains and caused an oil sheen in the Minor steam impoundment. The spill was promptly cleaned up and all proper notifications were made.

UNREVIEWED ENVIRONMENTAL QUESTIONS

All proposed changes to the PNPP design or operation, as well as tests or experiments, must be evaluated for potential environmental impacts in accordance with the EPP and administrative quality assurance procedures. In 2009 there were no proposed changes to the facility or programs that if performed, could have resulted in an adverse environmental impact. Therefore, there were no unreviewed environmental questions identified.

APPENDIX A

2009 INTER-LABORATORY CROSS CHECK COMPARISON PROGRAM RESULTS



700 Landwehr Road • Northbrook, IL 60062-2310 ph. (847) 564-0700 • fax (847) 564-4517

APPENDIX A

INTERLABORATORY COMPARISON PROGRAM RESULTS

NOTE: E

Environmental Inc., Midwest Laboratory participates in intercomparison studies administered by Environmental Resources Associates, and serves as a replacement for studies conducted previously by the U.S. EPA Environmental Monitoring Systems Laboratory, Las Vegas, Nevada. Results are reported in Appendix A. TLD Intercomparison results, in-house spikes, blanks, duplicates and mixed analyte performance evaluation program results are also reported. Appendix A is updated four times a year; the complete Appendix is included in March, June, September and December monthly progress reports only.

January, 2009 through December, 2009

Appendix A

Interlaboratory Comparison Program Results

Environmental, Inc., Midwest Laboratory has participated in interlaboratory comparison (crosscheck) programs since the formulation of it's quality control program in December 1971. These programs are operated by agencies which supply environmental type samples containing concentrations of radionuclides known to the issuing agency but not to participant laboratories. The purpose of such a program is to provide an independent check on a laboratory's analytical procedures and to alert it of any possible problems.

Participant laboratories measure the concentration of specified radionuclides and report them to the issuing agency. Several months later, the agency reports the known values to the participant laboratories and specifies control limits. Results consistently higher or lower than the known values or outside the control limits indicate a need to check the instruments or procedures used.

Results in Table A-1 were obtained through participation in the environmental sample crosscheck program administered by Environmental Resources Associates, serving as a replacement for studies conducted previously by the U.S. EPA Environmental Monitoring Systems Laboratory, Las Vegas, Nevada.

Table A-2 lists results for thermoluminescent dosimeters (TLDs), via International Intercomparison of Environmental Dosimeters, when available, and internal laboratory testing.

Table A-3 lists results of the analyses on in-house "spiked" samples for the past twelve months. All samples are prepared using NIST traceable sources. Data for previous years available upon request.

Table A-4 lists results of the analyses on in-house "blank" samples for the past twelve months. Data for previous years available upon request.

Table A-5 lists REMP specific analytical results from the in-house "duplicate" program for the past twelve months. Acceptance is based on the difference of the results being less than the sum of the errors. Complete analytical data for duplicate analyses is available upon request.

The results in Table A-6 were obtained through participation in the Mixed Analyte Performance Evaluation Program.

Results in Table A-7 were obtained through participation in the environmental sample crosscheck program administered by Environmental Resources Associates, serving as a replacement for studies conducted previously by the Environmental Measurement Laboratory Quality Assessment Program (EML).

Attachment A lists the laboratory precision at the 1 sigma level for various analyses. The acceptance criteria in Table A-3 is set at ± 2 sigma.

Out-of-limit results are explained directly below the result.

Attachment A

ACCEPTANCE CRITERIA FOR "SPIKED" SAMPLES

LABORATORY PRECISION: ONE STANDARD DEVIATION VALUES FOR VARIOUS ANALYSES^a

Analysis	Level	One standard deviation for single determination
Gamma Emitters	5 to 100 pCi/liter or kg	5.0 pCi/liter
	> 100 pCi/liter or kg	5% of known value
Strontium-89 ^b		E. 0 0:////
2001000-09	5 to 50 pCi/liter or kg > 50 pCi/liter or kg	5.0 pCi/liter 10% of known value
Strontium-90 ^b	2 to 30 pCi/liter or kg	5.0 pCi/liter
	> 30 pCi/liter or kg	10% of known value
Potassium-40	≥ 0.1 g/liter or kg	5% of known value
Gross alpha	≤ 20 pCi/liter	5.0 pCi/liter
	> 20 pCi/liter	25% of known value
Gross beta	≤ 100 pCi/liter	5.0 pCi/liter
	> 100 pCi/liter	5% of known value
Tritium	≤ 4,000 pCi/liter	$\pm 1\sigma =$
* .	> 4,000 pCi/liter	169.85 x (known) ^{0.0933} 10% of known value
Radium-226,-228	≥ 0.1 pCi/liter	15% of known value
Plutonium	≥ 0.1 pCi/liter, gram, or sample	10% of known value
lodine-131,	≤ 55 pCi/liter	6 pCi/liter
lodine-129 ^b	> 55 pCi/liter	10% of known value
Uranium-238,	≤ 35 pCi/liter	6 pCi/liter
Nickel-63 ^b Technetium-99 ^b	> 35 pCi/liter	15% of known value
Iron-55 ^b	50 to 100 pCi/liter	10 pCi/liter
	> 100 pCi/liter	10% of known value
	· · · ·	

^a From EPA publication, "Environmental Radioactivity Laboratory Intercomparison Studies Program, Fiscal Year, 1981-1982, EPA-600/4-81-004.

^b Laboratory limit.

•

			Concer	ntration (pCi/L))	
Lab Code	Date	Analysis	Laboratory	ERA	Control	
			Result ^b	Result ^c	Limits	Acceptanc
			· · · ·			
STW-1181	04/06/09	Sr-89	41.0 ± 5.8	48.3	37.8 - 55.7	Pass
STW-1181	04/06/09	Sr-90	32.4 ± 2.4	31.4	22.9 - 36.4	Pass
STW-1182	04/06/09	Ba-133	44.6 ± 3.1	52.7	43.4 - 58.3	Pass
STW-1182	04/06/09	Co-60	81.0 ± 3.1	88.9	80.0 - 100.0	Pass
STW-1182	04/06/09	Cs-134	65.6 ± 5.2	72.9	59.5 - 80.2	Pass
STW-1182 [°]	04/06/09	Cs-137	147.7 ± 5.3	168.0	151.0 - 187.0	Fail
STW-1182	04/06/09	Zn-65	79.8 ± 7.5	84.4	76.0 - 101.0	Pass
STW-1183	04/06/09	Gr. Alpha	47.6 ± 2.1	54.2	28.3 - 67.7	Pass
STW-1183	04/06/09	Gr. Beta	38.5 ± 1.3	43.5	29.1 - 50.8	Pass
STW-1184	04/06/09	I-131	24.4 ± 2.5	26.1	21.7 - 30.8	Pass
STW-1185	04/06/09	Ra-226	14.0 ± 0.7	15.1	11.2 - 17.3	Pass
STW-1185	04/06/09	Ra-228	14.3 ± 2.1	13.6	9.0 - 16.6	Pass
STW-1185	04/06/09	Uranium	25.0 ± 0.2	25.7	20.6 - 28.8	Pass
STW-1186 ^e	04/06/09	H-3	22819.0 ± 453.0	20300.0	17800.0 - 22300.0	Fail
STW-1193	10/05/09	Sr-89	53.0 ± 6.0	62.2	50.2 - 70.1	Pass
STW-1193	10/05/09	Sr-90	31.1 ± 2.2	30.7	22.4 - 35.6	Pass
STW-1194	10/05/09	Ba-133	82.5 ± 3.5	92.9	78.3 - 102.0	Pass
STW-1194	10/05/09	Co-60	116.8 ± 3.3	117.0	105.0 - 131.0	Pass
STW-1194	10/05/09	Cs-134	78.8 ± 5.7	78.8	65.0 - 87.3	Pass
STW-1194	10/05/09	Cs-137	54.2 ± 3.7	54.6	49.1 - 62.9	Pass
STW-1194	10/05/09	Zn-65	102.5 ± 6.2	99.5	89.6 - 119.0	Pass
STW-1195	10/05/09	Gr. Alpha	20.3 ± 2.0	23.2	11.6 - 31.1	Pass
STW-1195	10/05/09	Gr. Beta	23.7 ± 1.4	26.0	16.2 - 33.9	Pass
STW-1196	10/05/09	I-131	22.4 ± 1.4	22.2	18.4 - 26.5	Pass
STW-1197	10/05/09	Ra-226	15.0 ± 0.7	13.9	10.4 - 16.0	Pass
STW-1197	10/05/09	Ra-228	17.4 ± 2.0	14.9	10.0 - 18.0	Pass
STW-1197	10/05/09	Uranium	32.5 ± 0.4	33.8	27.3 - 37.8	Pass
STW-1198	10/05/09	H-3	17228.0 ± 694.0	16400.0	14300.0 - 18000.0	Pass

TABLE A-1. Interlaboratory Comparison Crosscheck program, Environmental Resource Associates (ERA)^a.

^a Results obtained by Environmental, Inc., Midwest Laboratory as a participant in the crosscheck program for proficiency testing in drinking water conducted by Environmental Resources Associates (ERA).

^b Unless otherwise indicated, the laboratory result is given as the mean ± standard deviation for three determinations.

^c Results are presented as the known values, expected laboratory precision (1 sigma, 1 determination) and control limits as provided by ERA.

^d All gamma -emitters showed a low bias. A large plastic burr found on the base of the Marinelli kept the beaker from sitting directly on the detector. Result of recount in a different beaker, Cs-137, 155.33 ± 14.55 pCi/L.

^e Samples were recounted and also reanalyzed. A recount of the original vials averaged 23,009 pCi/L.

Reanalysis results were acceptable, 19,170 pCi/L.

		1		mR			
Lab Code	Date		Known Lab Result		Control		
		Description	Value	± 2 sigma	Limits	Acceptance	
		· . · ·					
Environment	al. Inc.						
			۰.	• •			
2009-1	7/6/2009	40 cm.	41.82	45.43 ± 3.66	29.27 - 54.37	Pass	
2009-1	7/6/2009	50 cm.	26.76	32.17 ± 1.52	18.73 - 34.79	Pass	
2009-1	7/6/2009	60 cm.	18.58	20.23 ± 1.60	13.01 - 24.15	Pass	
2009-1	7/6/2009	70 cm.	13.65	15.28 ± 0.79	9.56 - 17.75	Pass	
2009-1	7/6/2009	90 cm.	8.26	7.97 ± 0.40	5.78 - 10.74	Pass	
2009-1	7/6/2009	90 cm.	8.26	7.37 ± 0.49	5.78 - 10.74	Pass	
2009-1	7/6/2009	100 cm.	6.69	6.16 ± 0.64	4.68 - 8.70	Pass	
2009-1	7/6/2009	110 cm.	5.53	4.38 ± 0.24	3.87 - 7.19	Pass	
2009-1	7/6/2009	120 cm.	4.65	4.34 ± 0.23	3.26 - 6.05	Pass	
2009-1	7/6/2009	150 cm.	2.97	2.92 ± 0.25	2.08 - 3.86	Pass	
Environment	tal, Inc.	ι.					
	x 						
2009-2	12/27/2009	40 cm.	44.83	51.38 ± 2.69	31.38 - 58.28	Pass	
2009-2	12/27/2009	50 cm.	28.69	31.65 ± 2.81	20.08 - 37.30	Pass	
2009-2	12/27/2009	60 cm.	19.92	21.38 ± 1.19	13.94 - 25.90	Pass	
2009-2	12/27/2009	60 cm.	19.92	22.30 ± 0.50	13.94 - 25.90	Pass	
2009-2	12/27/2009	75 cm.	12.75	13.48 ± 1.02	8.93 - 16.58	Pass	
2009-2	12/27/2009	90 cm.	8.85	9.62 ± 0.74	6.20 - 11.51	Pass	
2009-2	12/27/2009	90 cm.	8.85	8.39 ± 0.86	6.20 - 11.51	Pass	
2009-2	12/27/2009	100 cm.	7.17	6.65 ± 0.96	5.02 - 9.32	Pass	
2009-2	12/27/2009	120 cm.	4.98	4.89 ± 0.53	3.49 - 6.47	Pass	
2009-2	12/27/2009	120 cm.	4.98	4.92 ± 0.58	3.49 - 6.47	Pass	
2009-2	12/27/2009	150 cm.	3.19	2.74 ± 0.39	2.23 - 4.15	Pass	
2009-2	12/27/2009	180 cm.	2.21	1.65 ± 0.33	1.55 - 2.87	Pass	
2009-2	12/27/2009	180 cm.	2.21	2.12 ± 0.69	1.55 - 2.87	Pass	

TABLE A-2. Crosscheck program results; Thermoluminescent Dosimetry, (TLD, CaSO₄: Dy Cards).

1

,

.

.

TABLE A-3. In-House "Spike" Samples

.....

		Concentration (pCi/L) ^a					
Lab Code ^b	Date	Analysis			Control	•	
			2s, n=1 °	Activity	Limits ^d	Acceptanc	
W-12009	1/20/2009	Ra-226	12.88 ± 0.41	12.69	8.88 - 16.50	Pass	
W-12009 W-12009	1/27/2009	Gr. Alpha	20.20 ± 0.40	20.08	10.04 - 30.12	Pass	
W-12009 W-12709	1/27/2009	Gr. Beta	46.26 ± 0.42	45.60	35.60 - 55.60	Pass	
SPW-5553	1/27/2009	Ra-228	29.11 ± 2.53	28.66	20.06 - 37.26	Pass	
SPW-3333	1/29/2009	U-238	44.98 ± 2.30	41.70	29.19 - 54.21	Pass	
SPW-539	2/24/2009	0-230 Ni-63	167.93 ± 3.79	211.00	147.70 - 274.30	Pass	
SPW-539	3/6/2009	C-14	4893.50 ± 21.69	4740.20	2844.12 - 6636.28	Pass	
	3/16/2009	C-14 Cs-134	4695.50 ± 21.69 34.91 ± 3.85				
SPMI-814				35.70	25.70 - 45.70	Pass	
SPMI-814	3/16/2009	Cs-137	59.17 ± 6.70	55.60	45.60 - 65.60	Pass	
SPMI-814	3/16/2009	Sr-90	40.82 ± 1.59	44.07	35.26 - 52.88	Pass	
SPMI-815	3/16/2009	I-131	70.99 ± 0.62	69.60	55.68 - 83.52	Pass	
SPMI-815	3/16/2009	l-131(G)	63.08 ± 7.12	69.60	59.60 - 79.60	Pass	
SPW-817	3/16/2009	I-131	62.11 ± 0.59	69.60	55.68 - 83.52	Pass	
SPW-817	3/16/2009	I-131(G)	64.55 ± 8.32	69.60	59.60 - 79.60	Pass	
SPW-818	3/16/2009	Co-60	50.84 ± 4.70	51.99	41.99 - 61.99	Pass	
SPW-818	3/16/2009	Cs-134	33.78 ± 3.42	35.70	25.70 - 45.70	Pass	
SPW-818	3/16/2009	Cs-137	61.27 ± 7.18	55.64	45.64 - 65.64	Pass	
SPW-818	3/16/2009	Sr-90	47.26 ± 1.89	44.07	35.26 - 52.88	Pass	
SPAP-903	3/23/2009	Cs-134	13.29 ± 2.89	14.19	4.19 - 24.19	Pass	
SPAP-903	3/23/2009	Cs-137	103.24 ± 7:54	111.23	100.11 - 122.35	Pass	
SPCH-916	3/24/2009	I-131(G)	0.22 ± 0.02	0.22	0.13 - 0.31	Pass	
SPVE-888	4/1/2009	I-131(G)	0.40 ± 0.08	0.35	0.21 - 0.49	Pass	
SPF-820	4/7/2009	Cs-134	0.58 ± 0.02	0.56	0.34 - 0.78	Pass	
W-40909	4/9/2009	Gr. Alpha	19.26 ± 0.40	20.08	10.04 - 30.12	Pass	
W-40909 W-40909	4/9/2009	Gr. Beta	48.04 ± 0.42	45.60	35.60 - 55.60	Pass	
SPW-12641	4/10/2009	Ra-228	40.06 ± 2.79	40.54	28.38 - 52.70	Pass	
SPW-1267	4/10/2009	U-238	41.71 ± 2.25	40.34	29.19 - 54.21	Pass	
TWW-2124	4/21/2009	U-238 H-3	7932.00 ± 279.00	7063.00	5650.40 - 8475.60		
W-42809	4/21/2009	Ra-226	14.49 ± 0.53	16.78	11.75 - 21.81	Pass	
						Pass	
SPMI-2186	5/12/2009	Cs-134	32.55 ± 1.26	33.89	23.89 - 43.89	Pass	
SPMI-2186	5/12/2009	Cs-137	54.27 ± 2.60	55.60	45.60 - 65.60	Pass	
SPMI-2186	5/12/2009	I-131	60.81 ± 0.63	52.40	40.40 - 64.40	Pass	
SPMI-2186	5/12/2009	I-131(G)	56.89 ± 2.56	52.40	42.40 - 62.40	Pass	
SPMI-2186	5/12/2009	Sr-90	43.88 ± 1.68	52.40	41.92 - 62.88	Pass	
SPW-2497	5/27/2009	Fe-55	2472.37 ± 10.76	2106.35	1685.08 - 2527.62	Pass	
SPW-3448	7/14/2009	Cs-137	171.06 ± 9.21	166.10	149.49 - 182.71	Pass	
SPW-3497	7/15/2009	Ni-63	179.99 ± 3.06	210.40	147.28 - 273.52	Pass	
SPW-3499	7/15/2009	Tc-99	29.61 ± 0.81	32.34	20.34 - 44.34	Pass	
SPMI-3582	7/17/2009	Cs-134	32.86 ± 3.72	31.89	21.89 - 41.89	Pass	
SPMI-3582	7/17/2009	Cs-137	182.49 ± 10.54	166.10	149.49 - 182.71	Pass	
SPAP-3595	7/17/2009	Cs-134	13.01 ± 3.00	12.75	2.75 - 22.75	Pass	
SPAP-3595	7/17/2009	Cs-137	110.63 ± 6.58	110.73	99.66 - 121.80	Pass	

A3-1

TABLE A-3. In-House "Spike" Samples

		<u>.</u>	Concentration (p	Ci/L) ^a		
Lab Code ^b	Date	Analysis	Laboratory results	Known	Control	· · ·
	·:		2s, n=1	Activity	Limits ^c	Acceptance
SPF-3597	7/17/2009	Cs-134	0.53 ± 0.03	0.51	0.31 - 0.71	Pass
SPF-3597	7/17/2009	Cs-137	2.43 ± 0.05	2.22	1.33 - 3.10	Pass
SPW-3599	7/17/2009	H-3	63246.00 ± 725.00	62495.00	49996.00 - 74994.00	Pass
SPW-12643	8/3/2009	Ra-228	38.18 ± 2.72	40.54	28.38 - 52.70	Pass
W-80709	8/7/2009	Ra-226	16.28 ± 0.41	16.77	11.74 - 21.80	Pass
W-81009	8/10/2009	Gr. Alpha	20.58 ± 0.44	20.08	10.04 - 30.12	Pass
W-81009	8/10/2009	Gr. Beta	44.44 ± 0.40	45.60	35.60 - 55.60	Pass
W-100109	10/1/2009	Ra-226	15.68 ± 0.41	16.77	11.74 - 21.80	Pass
W-102709	10/27/2009	Gr. Alpha	21.50 ± 0.43	20.08	10.04 - 30.12	Pass
W-102709	10/27/2009	Gr. Beta	44.83 ± 0.40	45.60	35.60 - 55.60	Pass
SPW-5964	10/28/2009	U-238	40.20 ± 1.87	41.70	29.19 - 54.21	Pass
SPW-12647	11/6/2009	Ra-228	44.49 ± 3.33	40.54	28.38 - 52.70	Pass
SPAP-6769	12/14/2009	Gr. Beta	45.43 ± 0.11	49.48	29.69 - 69.27	Pass
SPAP-6774	12/14/2009	Cs-134	10.32 ± 0.83	11.11	1.11 - 21.11	Pass
SPAP-6774	12/14/2009	Cs-137	106.58 ± 2.51	109.70	98.73 - 120.67	Pass
SPF-6776	12/14/2009	Cs-134	0.43 ± 0.02	0.44	0.26 - 0.62	Pass
SPF-6776	12/14/2009	Cs-137	2.33 ± 0.05	2.19	1.31 - 3.07	Pass
SPW-6780	12/14/2009	Tc-99	30.71 ± 1.09	32.34	20.34 - 44.34	Pass
SPMI-6782	12/14/2009	[~] Co-60	74.30 ± 5.41	72.81	62.81 - 82.81	Pass
SPMI-6782	12/14/2009	Cs-134	58.82 ± 3.75	55.54	45.54 - 65.54	Pass
SPMI-6782	12/14/2009	Cs-137	178.18 ± 9.68	164.55	148.10 - 181.01	Pass
SPW-6784	12/14/2009	Co-60	74.03 ± 4.64	72.81	62.81 - 82.81	Pass
SPW-6784	12/14/2009	Cs-134	54.84 ± 3.83	55.54	45.54 - 65.54	Pass
SPW-6784	12/14/2009	Cs-137	180.06 ± 8.81	164.55	148.10 - 181.01	Pass

^a Liquid sample results are reported in pCi/Liter, air filters(pCi/filter), charcoal (pCi/m³), and solid samples (pCi/g).

^b Laboratory codes as follows: W (water), MI (milk), AP (air filter), SO (soil), VE (vegetation),

CH (charcoal canister), F (fish).

^c Results are based on single determinations.

^d Control limits are established from the precision values listed in Attachment A of this report, adjusted to $\pm 2\sigma$.

^e Control limits based on the laboratory limit, Attachment A ("Other Analyses").

NOTE: For fish, Jello is used for the Spike matrix. For Vegetation, cabbage is used for the Spike matrix.

TABLE A-4. In-House "Blank" Samples

3

, medistring

		•			Concentration (pCi/l	L) ^a
Lab Code	Sample	Date	Analysis ^b	Laborator	y results (4.66o)	Acceptance
	Туре	· · · ·	·	LLD	Activity ^c	Criteria (4.66 o
						· . ·
W-12009	Water	1/20/2009	Ra-226	0.05	0.06 ± 0.04	1
SPW-5554	Water	1/27/2009	Ra-228	0.08	0.17 ± 0.40	2
W-12709	Water	1/27/2009	Gr. Alpha	0.35	0.22 ± 0.27	1
W-12709	Water	1/27/2009	Gr. Beta	0.74	-0.08 ± 0.51	3.2
SPW-218	Water	1/29/2009	U-238	0.19	-0.06 ± 0.09	1
SPW-538	Water	2/24/2009	Ni-63	7.91	4.96 ± 4.93	20
SPW-717	Water	3/6/2009	C-14	7.66	3.03 ± 4.71	200
SPMI-816	Milk	3/16/2009	Cs-134	3.24	-	10
SPMI-816	Milk	3/16/2009	Cs-137	3.38	•	10
SPMI-816	Milk	3/16/2009	I-131	0.31	0.04 ± 0.17	0.5
SPMI-816	Milk	3/16/2009	I-131(G)	3.65	-	20
SPMI-816	Milk	3/16/2009	Sr-90	0.48	0.41 ± 0.27	1
SPW-819	Water	3/16/2009	Co-60	3.02	-	10
SPW-819	Water	3/16/2009	Cs-134	2.25	-	10
SPW-819	Water	3/16/2009	Cs-137	2.03	-	10
SPW-819	Water	3/16/2009	I-131	0.42	-0.06 ± 0.19	0.5
SPW-819	Water	3/16/2009	l-131(G)	3.02	-	20
SPW-819	Water	3/16/2009	Sr-90	1.10	-0.63 ± 0.44	. 1
SPAP-902	Air Filter	3/23/2009	Gr. Beta	0.003	0.006 ± 0.002	3.2
SPAP-904	Air Filter	3/23/2009	Cs-134	1.68	-	100
SPAP-904	Air Filter	3/23/2009	Cs-137	2.62	-	100
SPW-32709	Water	3/23/2009	Ni-63	2.84	1.37 ± 1.75	20
CDE 804	Fish	4/7/2000	Co 124	. 2.40		100
SPF-821 SPF-821	Fish Fish	4/7/2009 4/7/2009	Cs-134 Cs-137	3.12	· ·	100
			Gr. Alpha	3.93	-	100
W-40909	Water	4/9/2009	•	0.40	-0.25 ± 0.26 -0.30 ± 0.53	1
W-40909	Water	4/9/2009	Gr. Beta Ra-228	0.77	-0.30 ± 0.53 0.77 ± 0.45	3.2
SPW-12651	Water	4/10/2009		0.77		
SPW-1268	Water	4/10/2009	U-238	0.11	0.24 ± 0.17	1
W-42809	Water	4/28/2009	Ra-226	0.04	0.09 ± 0.04	1
SPMI-2186	Milk	5/12/2009	Sr-90	0.43	0.52 ± 0.26	1
SPMI-2187	Milk	5/12/2009	Cs-134	3.61	-	10
SPMI-2187	Milk	5/12/2009	Cs-137	3.13	•	10
SPMI-2187	Milk	5/12/2009	I-131	0.15	-0.02 ± 0.10	0.5
SPMI-2187	Milk	5/12/2009	I-131(G)	3.77	-	20
SPW-2498	Water	5/27/2009	Ni-63	1.60	0.00 ± 0.97	20

l

ŀ

ł

ľ

A4-1

TABLE A-4. In-House "Blank" Samples

	· · · · ·				Concentration (pCi/L	_) ^a
Lab Code	Sample	Date	Analysis ^b	Laborator	y results (4.66σ)	Acceptance
<u></u>	Туре			LLD	Activity ^c	Criteria (4.66 o
	· · · · •		· ·			
SPW-3497	Water	7/15/2009	Ni-63	1.55	-0.24 ± 0.94	20
SPW-3500	Water	7/15/2009	Tc-99	0.90	-1.71 ± 0.53	10, .
SPMI-3589	Milk	7/17/2009	l-131(G)	5.75	-	20
SPAP-3594	Air Filter	7/17/2009	Cs-134	1.14	-	100
SPAP-3594	Air Filter	7/17/2009	Cs-137	2.47	-	100
SPF-3596	Fish	7/17/2009	Co-60	5.00	-	100
SPF-3596	Fish	7/17/2009	Cs-134	8.00	-	100
SPF-3596	Fish	7/17/2009	Cs-137	11.50		100
SPW-3598	Water	7/17/2009	H-3	148.40	0.69 ± 73.60	200
SPW-12653	Water	8/3/2009	Ra-228	0.76	1.46 ± 0.51	2
W-80709	Water	8/7/2009	Ra-226	0.04	0.08 ± 0.03	1
W-81009	Water	8/10/2009	Gr. Alpha	0.44	0.08 ± 0.31	1
W-81009	Water	8/10/2009	Gr. Beta	0.75	-0.31 ± 0.52	· 3.2
W-100109	Water	10/1/2009	Ra-226	0.04	0.09 ± 0.03	、 1
W-102709	Water	10/27/2009	Gr. Alpha	0.38	0.33 ± 0.30	. 1
W-102709	Water	10/27/2009	Gr. Beta	0.81	-0.59 ± 0.55	3.2
SPW-5965	Water	10/28/2009	U-238	0.15	0.09 ± 0.13	1 .
SPW-12657	Water	11/6/2009	Ra-228	0.86	0.80 ± 0.50	2
SPAP-6769	Air Filter	12/14/2009	Gr. Beta	0.003	0.010 ± 0.002	3.2
SPAP-6773	Air Filter	12/14/2009	Cs-137	1.31	-	100
SPF-6775	Fish	12/14/2009	Cs-134	5.70	-	100
SPF-6775	Fish	12/14/2009	Cs-137	4.18	-	100
SPW-6777	Water	12/14/2009	Ni-63	2.29	0.25 ± 1.38	20
SPW-6779	Water	12/14/2009	Tc-99	1.16	-0.98 ± 0.69	10
SPMI-6781	Milk	12/14/2009	Cs-134	2.62	-	10
SPMI-6781	Milk	12/14/2009	Cs-137	3.29		10
SPMI-6781	Milk	12/14/2009	I-131(G)	2.65	-	20
SPW-6783	Water	12/14/2009	Cs-134	2.18	-	10
SPW-6783	Water	12/14/2009	Cs-137	2.90	-	10
SPW-6783	Water	12/14/2009	I-131(G)	2.30	_	20

^a Liquid sample results are reported in pCi/Liter, air filters(pCi/filter), charcoal (pCi/charcoal canister), and solid samples (pCi/kg).

^b I-131(G); iodine-131 as analyzed by gamma spectroscopy.

^c Activity reported is a net activity result. For gamma spectroscopic analysis, activity detected below the LLD value is not reported.

TABLE A-5. In-House "Duplicate" Samples

1

	·		(Concentration (pCi/L) ^a		
			. ,		Averaged	
Lab Code	Date	Analysis	First Result	Second Result	Result	Acceptanc
AP-7464, 7465	1/1/2009	Be-7	0.063 ± 0.012	0.065 ± 0.010	0.064 ± 0.008	Pass
E-20, 21	1/5/2009	K-40	1.34 ± 0.21	1.13 ± 0.13	1.24 ± 0.12	Pass
CF-67, 68	1/5/2009	Be-7	0.34 ± 0.12	0.39 ± 0.08	0.37 ± 0.07	Pass
CF-67, 68	1/5/2009	Gr. Beta	4.34 ± 0.11	4.38 ± 0.12	4.36 ± 0.08	Pass
CF-67, 68	1/5/2009	K-40	3.16 ± 0.26	3.00 ± 0.16	3.08 ± 0.15	Pass
DW-90010, 90011	1/9/2009	Ra-226	2.97 ± 0.22	2.76 ± 0.21	2.87 ± 0.15	Pass
DW-90010, 90011	1/9/2009	Ra-228	3.13 ± 0.71	3.55 ± 0.81	3.34 ± 0.54	Pass
SG-198, 199	1/23/2009	Gr. Alpha	101.90 ± 6.50	101.70 ± 6.10	101.80 ± 4.46	Pass
SG-198, 199	1/23/2009	Gr. Beta	97.80 ± 3.50	94.00 ± 3.20	95.90 ± 2.37	Pass .
SW-308, 309	1/27/2009	Gr. Beta	1.43 ± 0.58	1.41 ± 0.54	1.42 ± 0.40	Pass
LW-330, 331	1/27/2009	Gr. Beta	2.09 ± 0.58	2.33 ± 0.63	2.21 ± 0.43	Pass
SW-308, 309	1/29/2009	Gr. Beta	1.51 ± 0.56	1.61 ± 0.57	1.56 ± 0.40	Pass
DW-375, 376	2/4/2009	Gr. Beta	2.72 ± 0.65	3.06 ± 0.69	2.89 ± 0.47	Pass
SWU-606, 607	2/24/2009	Gr. Beta	2.66 ± 0.68	2.16 ± 0.67	2.41 ± 0.48	Pass
U-651, 652	2/27/2009	Beta-K40	3.90 ± 2.30	1.70 ± 2.50	2.80 ± 1.70	Pass
U-651, 652	2/27/2009	H-3	597.00 ± 292.00	507.00 ± 288.00	552.00 ± 205.07	Pass
SG-739, 740	3/2/2009	Ra-226	8.20 ± 0.20	8.30 ± 0.20	8.25 ± 0.14	Pass
MI-875, 876	3/17/2009	K-40	1286.50 ± 111.60	1471.70 ± 111.50	1379.10 ± 78.88	Pass
MI-875, 876	3/17/2009	Sr-90	0.67 ± 0.31	0.36 ± 0.36	0.52 ± 0.24	Pass
WW-970, 971	3/24/2009	Gr. Beta	13.59 ± 2.32	17.33 ± 2.69	15.46 ± 1.78	Pass
XWW-980, 981	3/24/2009	H-3	7143.00 ± 262.00	7262.00 ± 264.00	7202.50 ± 185.97	Pass
AP-1441, 1442	3/30/2009	Be-7	0.076 ± 0.012	0.075 ± 0.014	0.076 ± 0.009	Pass
SWT-1123, 1124	3/31/2009	Gr. Beta	1.40 ± 0.55	1.86 ± 0.62	1.63 ± 0.41	Pass
WW-1,102, 1103	4/1/2009	Gr. Beta	2.13 ± 1.34	2.30 ± 1.32	2.22 ± 0.94	Pass
XWW-1174, 1175	4/1/2009	H-3	2814 ± 176	2787 ± 176	2801 ± 124	Pass
AP-1462, 1463	4/2/2009	Be-7	0.085 ± 0.014	0.10 ± 0.016	0.091 ± 0.011	Pass
SL-2024, 2025	5/4/2009	Be-7	0.80 ± 0.18	0.82 ± 0.13	0.81 ± 0.11	Pass
SL-2024, 2025	5/4/2009	Gr. Beta	2.41 ± 0.19	2.68 ± 0.21	2.55 ± 0.14	Pass
SL-2024, 2025	5/4/2009	K-40	1.20 ± 0.21	1.30 ± 0.15	1.25 ± 0.13	Pass
SO-2045, 2046	5/4/2009	Gr. Alpha	6.22 ± 2.87	6.50 ± 3.26	6.36 ± 2.17	Pass
SO-2045, 2046	5/4/2009	Gr. Beta	28.85 ± 3.15	30.39 ± 3.34	29.62 ± 2.30	Pass
SO-2045, 2046	5/4/2009	Sr-90	0.036 ± 0.010	0.024 ± 0.010	0.030 ± 0.007	Pass
mi-2251, 2252	5/14/2009	K-40	1220.60 ± 155.10	1455.50 ± 118.20	1338.05 ± 97.50	Pass
mi-2381, 2382	5/19/2009	K-40	1472.50 ± 122.90	1412.80 ± 117.40	1442.65 ± 84.98	Pass
SWT-2534, 2535	5/26/2009	Gr. Beta	1.12 ± 0.57	1.66 ± 0.58	1.39 ± 0.41	Pass
G-2626, 2627	5/28/2009	Gr. Beta	6.32 ± 0.19	6.18 ± 0.19	6.25 ± 0.13	Pass
G-2626, 2627	5/28/2009	K-40	4.13 ± 0.35	4.05 ± 0.34	4.09 ± 0.24	Pass
WW-2732, 2733	6/1/2009	H-3	240.73 ± 93.21	190.39 ± 90.81	215.56 ± 65.07	Pass

TABLE A-5. In-House "Duplicate" Samples

				Concentration (pCi/L) ^a		
Lab Code	Date	Analysis	First Result	Second Result	Averaged Result	Acceptance
	Date	Analysis	- instructure	_ Gecond Result	1.6501	Acceptance
SO-3141, 3142	6/22/2009	Ac-228	1.07 ± 0.06	1.06 ± 0.05	1.07 ± 0.04	Pass
SO-3141, 3142	6/22/2009	Be-7	0.55 ± 0.14	0.62 ± 0.08	0.59 ± 0.08	Pass
SO-3141, 3142	6/22/2009	Bi-212	1.16 ± 0.17	1.14 ± 0.16	1.15 ± 0.12	Pass
SO-3141, 3142	6/22/2009	Bi-214	0.96 ± 0.03	1.01 ± 0.03	0.99 ± 0.02	Pass
SO-3141, 3142	6/22/2009	Cs-137	0.72 ± 0.07	0.76 ± 0.08	0.74 ± 0.05	Pass
SO-3141, 3142	6/22/2009	Pb-212	1.00 ± 0.02	1.03 ± 0.02	1.02 ± 0.01	Pass
SO-3141, 3142	6/22/2009	Pb-214	1.01 ± 0.03	1.04 ± 0.03	1.03 ± 0.02	Pass
SO-3141, 3142	6/22/2009	Pu-239/40	0.022 ± 0.008	0.030 ± 0.009	0.026 ± 0.006	Pass
SO-3141, 3142	6/22/2009	Th-232	0.51 ± 0.04	0.48 ± 0.05	0.50 ± 0.03	Pass
SO-3141, 3142	6/22/2009	TI-208	0.35 ± 0.02	0.36 ± 0.02	0.36 ± 0.01	Pass
SO-3141, 3142	6/22/2009	U-233/4	0.16 ± 0.02	0.18 ± 0.02	0.17 ± 0.01	Pass
SO-3141, 3142	6/22/2009	U-238	0.14 ± 0.02	0.18 ± 0.03	0.16 ± 0.02	Pass
SG-3187, 3188	6/25/2009	Ac-228	11.07 ± 0.33	10.88 ± 0.33	10.97 ± 0.24	Pass
SG-3187, 3188	6/25/2009	Pb-214	26.54 ± 0.23	26.17 ± 0.25	26.36 ± 0.17	Pass
SL-3297, 3298	7/1/2009	Be-7	1.15 ± 0.13	1.15 ± 0.12	1.15 ± 0.09	Pass
SL-3297, 3298	7/1/2009	Gr. Beta	3.38 ± 0.23	3.37 ± 0.12	3.38 ± 0.13	Pass
SL-3297, 3298	7/1/2009	K-40	1.43 ± 0.18	1.50 ± 0.19	1.47 ± 0.13	Pass
AP-3944, 3945	7/1/2009	Be-7	0.064 ± 0.009	0.068 ± 0.010	0.066 ± 0.007	Pass
DW-90222, 90223	7/15/2009	Ra-226	5.36 ± 0.60	4.62 ± 0.51	4.99 ± 0.39	Pass
DW-90222, 90223	7/15/2009	Ra-228	2.91 ± 0.73	2.80 ± 0.70	2.86 ± 0.51	Pass
DW-90237, 90238	7/17/2009	Gr. Alpha	3.54 ± 0.99	4.22 ± 1.09	3.88 ± 0.74	Pass
F-3790, 3791	7/21/2009	K-40	1.10 ± 0.35	1.41 ± 0.44	1.26 ± 0.28	Pass
DW-90250, 90251	7/22/2009	Ra-226	14.58 ± 0.39	15.13 ± 0.40	14.86 ± 0.28	Pass
DW-90250, 90251	7/22/2009	Ra-228	6.71 ± 1.05	6.10 ± 1.01	6.41 ± 0.73	Pass
VE-3965, 3966	7/28/2009	K-40	1.48 ± 0.16	1.56 ± 0.19	1.52 ± 0.13	Pass
VE-4098, 4099	8/3/2009	Be-7	0.54 ± 0.16	0.58 ± 0.16	0.56 ± 0.11	Pass
VE-4098, 4099	8/3/2009	Gr. Beta	5.15 ± 0.17	5.07 ± 0.18	5.11 ± 0.12	Pass
VE-4098, 4099	8/3/2009	K-40	4.91 ± 0.49	5.17 ± 0.15	5.04 ± 0.26	Pass
SO-4325, 4326	8/14/2009	Be-7	0.59 ± 0.21	0.68 ± 0.28	0.64 ± 0.18	Pass
SO-4325, 4326	8/14/2009	Cs-137	0.29 ± 0.05	0.28 ± 0.05	0.28 ± 0.03	Pass
SO-4325, 4326	8/14/2009	K-40	13.41 ± 0.77	13.46 ± 0.80	13.43 ± 0.56	Pass
SG-4283, 4284	8/17/2009	Ac-228	7.16 ± 0.28	7.10 ± 0.26	7.13 ± 0.19	Pass
SG-4283, 4284	8/17/2009	Pb-214	6.27 ± 0.13	6.21 ± 0.13	6.24 ± 0.09	Pass
VE-4436, 4437	8/25/2009	K-40	2.28 ± 0.28	2.67 ± 0.26	2.48 ± 0.19	Pass
SL-4589, 4590	9/1/2009	Be-7	1.25 ± 0.22	1.25 ± 0.16	1.25 ± 0.14	Pass
SL-4589, 4590	9/1/2009	K-40	2.96 ± 0.30	2.70 ± 0.27	2.83 ± 0.20	Pass
AV-4882, 4883	9/8/2009	Be-7	0.93 ± 0.18	0.95 ± 0.17	0.94 ± 0.12	Pass
AV-4882, 4883	9/8/2009	K-40	2.50 ± 0.26	2.47 ± 0.29	2.49 ± 0.20	Pass

TABLE A-5. In-House "Duplicate" Samples

				Concentration (pCi/L)	а	/
				······································	Averaged	
Lab Code	Date	Analysis	First Result	Second Result	Result	Acceptance
11/11/ 4704 4700	0/0/2000	11.2	10101 00 + 404 00	49677.00 + 200.00	18024.00 1.002.04	D-++
WW-4721, 4722	9/9/2009	H-3 H-3	19191.00 ± 404.00	18677.00 ± 399.00	18934.00 ± 283.91	Pass
WW-4903, 4904	9/11/2009		1075.00 ± 130.00	1281.00 ± 136.00	1178.00 ± 94.07	Pass
BS-5119, 5120	9/16/2009	Be-7	2067.50 ± 327.90	2225.40 ± 371.10	2146.45 ± 247.61	Pass
BS-5119, 5120	9/16/2009	Cs-137	86.24 ± 35.40	145.10 ± 31.54	115.67 ± 23.71	Pass
BS-5119, 5120	9/16/2009	K-40	16.85 ± 0.90	17.27 ± 0.79	17.06 ± 0.60	Pass
SS-5188, 5189	9/23/2009	Be-7	1.02 ± 0.31	1.04 ± 0.43	1.03 ± 0.26	Pass
SS-5188, 5189	9/23/2009	K-40	10.21 ± 0.65	9.94 ± 0.93	10.07 ± 0.57	Pass
AP-3944, 3945	9/29/2009	Be-7	0.09 ± 0.02	0.09 ± 0.02	0.09 ± 0.01	Pass
E-5251, 5252	10/1/2009	Gr. Beta	2.30 ± 0.10	2.10 ± 0.10	2.20 ± 0.07	Pass
E-5251, 5252	10/1/2009	K-40	1.18 ± 0.24	1.15 ± 0.18	1.17 ± 0.15	Pass
G-5272, 5273	10/1/2009	Be-7	3.31 ± 0.29	3.60 ± 0.26	3.46 ± 0.19	Pass
G-5272, 5273	10/1/2009	Gr. Alpha	19.81 ± 0.80	21.10 ± 0.74	20.46 ± 0.54	Pass
G-5272, 5273	10/1/2009	K-40	16.47 ± 0.75	17.00 ± 0.74	16.74 ± 0.53	Pass
F-5690, 5691	10/15/2009	H-3	8895.00 ± 250.00	9051.00 ± 252.00	8973.00 ± 177.49	Pass
F-5690, 5691	10/15/2009	K-40	3.62 ± 0.40	3.09 ± 0.48	3.36 ± 0.31	Pass
DW-90396, 90397	10/16/2009	Ra-226	0.54 ± 0.09	0.42 ± 0.08	0.48 ± 0.06	Pass
DW-90396, 90397	10/16/2009	Ra-228	1.44 ± 0.56	0.94 ± 0.51	1.19 ± 0.38	Pass
DW-90408, 90409	10/19/2009	Ra-226	0.99 ± 0.12	1.10 ± 0.14	1.05 ± 0.09	Pass
DW-90408, 90409	10/19/2009	Ra-228	2.76 ± 0.66	1.38 ± 0.92	2.07 ± 0.57	Pass
DW-90420, 90421	10/21/2009	Ra-226	1.95 ± 0.17	1.77 ± 0.15	1.86 ± 0.11	Pass
DW-90420, 90421	10/21/2009	Ra-228	3.10 ± 0.73	3.32 ± 0.80	3.21 ± 0.54	Pass
SG-5962, 5963	10/22/2009	Ac-228	16.39 ± 0.79	16.51 ± 0.63	16.45 ± 0.51	Pass
SG-5962, 5963	10/22/2009	Pb-214	18.03 ± 0.41	17.74 ± 0.42	17.89 ± 0.29	Pass
DW-90423, 90424	10/27/2009	Gr. Alpha	12.04 ± 1.68	15.28 ± 1.97	13.66 ± 1.29	Pass
ME-6116, 6117	11/3/2009	Gr. Beta	0.86 ± 0.03	0.83 ± 0.03	0.85 ± 0.02	Pass
ME-6116, 6117	11/3/2009	K-40	2.57 ± 0.08	2.65 ± 0.08	2.61 ± 0.06	Pass
F-6567, 6568	11/6/2009	Gr. Beta	2.72 ± 1.05	3.04 ± 0.92	2.88 ± 0.70	Pass
F-6567, 6568	11/6/2009	Sr-90	0.09 ± 0.03	0.12 ± 0.04	0.11 ± 0.02	Pass
W-6495, 6496	11/8/2009	H-3	2638.00 ± 173.00	2451.00 ± 168.00	2544.50 ± 120.57	Pass
WW-6313, 6314	11/9/2009	H-3	1514.00 ± 137.00	1483.00 ± 136.00	1498.50 ± 96.52	Pass
SWU-6611, 6612	11/24/2009	Gr. Beta	1.88 ± 0.60	1.67 ± 0.59	1.78 ± 0.42	Pass
DW-90446, 90447	12/30/2009	Ra-226	0.30 ± 0.10	0.54 ± 0.14	0.42 ± 0.09	Pass
DW-90446, 90447	12/30/2009	Ra-228	2.60 ± 0.64	2.65 ± 0.65	2.63 ± 0.46	Pass

and a second second second

.

Note: Duplicate analyses are performed on every twentieth sample received in-house. Results are not listed for those analyses with activities that measure below the LLD.

^a Results are reported in units of pCi/L, except for air filters (pCi/Filter), food products, vegetation, soil, sediment (pCi/g).

		······································		Concentration	0	
				Known	Control	
Lab Code ^c	Date	Analysis	Laboratory result	Activity	Limits ^d	Acceptanc
					· ·	
STW-1170 ¹	01/01/09	Am-241	1.15 ± 0.06	0.64	0.45 - 0.83	Fail
STW-1170	01/01/09	Co-57	19.60 ± 0.40	18.90	13.20 - 24.60	Pass
STW-1170	01/01/09	Co-60	16.60 ± 0.30	17.21	12.05 - 22.37	Pass
STW-1170	01/01/09	Cs-134	20.40 ± 0.50	22.50	15.80 - 29.30	Pass
STW-1170 °	01/01/09	Cs-137	0.10 ± 0.20	0.00	0.00 - 1.00	Pass
STW-1170	01/01/09	Fe-55	51.60 ± 20.60	48.20	33.70 - 62.70	Pass
STW-1170	01/01/09	H-3	359.90 ± 33.90	330.90	231.60 - 430.20	Pass.
STW-1170	01/01/09	Mn-54	15.00 ± 0.40	14.66	10.26 - 19.06	Pass
STW-1170	01/01/09	Ni-63	50.50 ± 3.25	53.50	37.45 - 69.55	Pass
STW-1170	01/01/09	Pu-238	1.17 ± 0.04	1.18	0.83 - 1.53	Pass
STW-1170	01/01/09	Pu-239/40	0.74 ± 0.03	0.85	0.60 - 1.11	Pass
STW-1170	01/01/09	Sr-90	7.87 ± 1.39	. 7.21	5.05 - 9.37	Pass
STW-1170	01/01/09	Tc-99	12.70 ± 0.80	14.46	10.12 - 18.80	Pass
STW-1170	01/01/09	U-233/4	2.78 ± 0.07	2.77	1.94 - 3.60	Pass
STW-1170	01/01/09	U-238	2.87 ± 0.07	2.88	2.02 - 3.74	Pass
STW-1170	01/01/09	Zn-65	14.00 ± 0.70	13.60	9.50 - 17.70	Pass
		1.1.00				1 400
STW-1171	01/01/09	Gr. Alpha	0.56 ± 0.06	0.64	0.00 - 1.27	Pass
STW-1171	01/01/09	Gr. Beta	1.29 ± 0.05	1.27	0.64 - 1.91	Pass
	01101100	01. 2014	1.20 2 0.00		0.04 1.01	1 235
	•					
STSO-1172°	01/01/09	Co-57	0.00 ± 0.00	0.00	0.00 - 1.00	Pass
STSO-1172	01/01/09	Cs-134	458.60 ± 7.40	467.00	327.00 - 607.00	Pass
STSO-1172	01/01/09	Cs-137	652.30 ± 3.50	605.00	424.00 - 787.00	Pass
STSO-1172	01/01/09	K-40	636.40 ± 9.50	570.00	360.40 - 669.40	Pass
STSO-1172	01/01/09	Mn-54	346.40 ± 3.10	307.00	215.00 - 399.00	Pass
STSO-1172	01/01/09	Pu-238	28.60 ± 2.20	25.30	17.70 - 32.90	Pass
STSO-1172 °	01/01/09	Pu-239/40	0.50 ± 0.40	0.00	0.00 - 1.00	Pass
STSO-1172	01/01/09	Sr-90	180.60 ± 12.10	257.00	180.00 - 334.00	Pass
STSO-1172	01/01/09	U-233/4	152.20 ± 4.30	149.00	104.00 - 194.00	Pass
STSO-1172	01/01/09	U-238	154.90 ± 4.40	155.00	109.00 - 202.00	Pass
STSO-1172	01/01/09	Zn-65	268.30 ± 4.00	242.00	169.00 - 315.00	Pass
0100 11/2	01/01/00	211 00	200.00 1 4.00	212.00	100.00 010.00	1 435
					:	
STVE-1173	01/01/09	Co-57	2.75 ± 0.11	2.36	1.65 - 3.07	Pass
STVE-1173 ^e	01/01/09	Co-60	0.06 ± 0.09	0.00	0.00 - 1.00	Pass
STVE-1173	01/01/09	Cs-134	3.49 ± 0.22	3.40	2.38 - 4.42	Pass
STVE-1173	01/01/09	Cs-137	1.01 ± 0.11	0.93	0.65 - 1.21	Pass
STVE-1173	01/01/09	Mn-54	2.52 ± 0.14	2.30	1.61 - 2.99	Pass
STVE-1173	01/01/09	Zn-65	1.52 ± 0.18	1.35	0.95 - 1.76	Pass

TABLE A-6. Department of Energy's Mixed Analyte Performance Evaluation Program (MAPEP)^a.

-			· .	Concentration ^b		
				Known	Control	
Lab Code ^c	Date	Analysis	Laboratory result	Activity	Limits ^d	Acceptance
STAP-1174 ⁹	01/01/09	Am-241	0.29 ± 0.03	0.21	0.14 - 0.27	Fail
STAP-1174	01/01/09	Co-57	1.25 ± 0.05	1.30	0.91 - 1.69	Pass
STAP-1174	01/01/09	Co-60	1.17 ± 0.06	1.22	0.85 - 1.59	Pass
STAP-1174	01/01/09	Cs-134	2.67 ± 0.14	2.93	2.05 - 3.81	Pass
STAP-1174	01/01/09	Cs-137	1.53 ± 0.08	1.52	1.06 - 1.98	Pass
STAP-1174	01/01/09	Mn-54	2.34 ± 0.09	2.27	1.59 - 2.95	Pass
STAP-1174 ^h	01/01/09	Sr-90	0.93 ± 0.14	0.64	0.45 - 0.83	Fail
STAP-1174	01/01/09	Zn-65	1.44 ± 0.14	1.36	0.95 - 1.77	Pass
STAP-1175	01/01/09	Gr. Alpha	0.22 ± 0.03	0.35	0.00 - 0.70	Pass
STAP-1175	01/01/09	Gr. Beta	0.36 ± 0.04	0.28	0.14 - 0.42	Pass
						-
STSO-1188	07/01/09	Co-57	674.60 ± 9.00	586.00	410.00 - 762.00	Pass
STSO-1188	07/01/09	Co-60	356.40 ± 6.30	327.00	229.00 - 425.00	Pass
STSO-1188	07/01/09	Cs-134	0.20 ± 1.90	0.00	0.00 - 1.00	Pass
STSO-1188	07/01/09	Cs-137	767.50 ± 12.00	669.00	468.00 - 870.00	Pass
STSO-1188	07/01/09	K-40	433.00 ± 37.20	.375.00	263.00 - 488.00	Pass
STSO-1188	07/01/09	Mn-54	931.60 ± 14.10	796.00	557.00 - 1035.00	Pass
STSO-1188	07/01/09	Pu-238	53.10 ± 9.00	63.20	44.20 - 82.20	Pass
STSO-1188	07/01/09	Pu-239/40	107.10 ± 12.60	116.30	81.40 - 151.20	Pass
STSO-1188 ¹	07/01/09	Sr-90	310.50 ± 12.20	455.00	319.00 - 592.00	Fail
STSO-1188	07/01/09	U-233/4	188.20 ± 11.90	209.00	146.00 - 272.00	Pass
STSO-1188	07/01/09	U-238	197.40 ± 12.20	217.00	152.00 - 282.00	Pass
STSO-1188	07/01/09	Zn-65	1433.90 ± 25.20	1178.00	825.00 - 1531.00	Pass
STAP-1189	07/01/09	Gr. Alpha	0.33 ± 0.04	0.66	0.00 - 1.32	Pass
STAP-1189	07/01/09	Gr. Beta	1.57 ± 0.07	1.32	0.66 - 1.98	Pass
				•	·	
STAP-1190	07/01/09	Am-241	0.01 ± 0.02	0.00	0.01 - 0.05	Pass
STAP-1190	07/01/09	Co-57	6.78 ± 0.27	6.48	4.54 - 8.42	Pass
STAP-1190	07/01/09	Co-60	1.06 ± 0.18	1.03	0.72 - 1.34	Pass
STAP-1190	07/01/09	Cs-134	0.01 ± 0.06	0.00	0.01 - 0.05	Pass
STAP-1190	07/01/09	Cs-137	1.49 ± 0.27	1.40	0.98 - 1.82	Pass
STAP-1190	07/01/09	Mn-54	6.00 ± 0.45	5.49	3.84 - 7.14	Pass
STAP-1190	07/01/09	Sr-90	0.79 ± 0.13	0.84	0.59 - 1.09	Pass
STAP-1190	07/01/09	Zn-65	4.55 ± 0.66	3.93	2.75 - 5.11	Pass
STVE-1190	07/01/09	Co-57	8.90 ± 0.60	8.00	5.60 - 10.40	Pass
STVE-1190	07/01/09	Co-60	2.50 ± 0.36	2.57	1.80 - 3.34	Pass
STVE-1190	07/01/09	Cs-134	0.01 ± 0.11	0.00	0.00 - 0.10	Pass
STVE-1190	07/01/09	Cs-137	2.42 ± 0.16	2.43	1.70 - 3.16	Pass
STVE-1190	07/01/09	Mn-54	8.35 ± 0.70	7.90	5.50 - 10.30	Pass
STVE-1190	07/01/09	Zn-65	0.01 ± 0.26	0.00	0.00 - 0.10	Pass

TABLE A-6. Department of Energy's Mixed Analyte Performance Evaluation Program (MAPEP)^a.

;

,

TABLE A-6. Department of Energy's Mixed Analyte Performance Evaluation Program (MAPEP)^a.

			· · · · ·	Concentration	D	
			······································	Known	Control	
Lab Code ^c	Date	Analysis	Laboratory result	Activity	Limits d	Acceptance
STW-1191	07/01/09	Gr. Alpha	0.88 ± 0.07	1.05	0.00 - 2.09	Pass
STW-1191	07/01/09	Gr. Beta	7.29 ± 0.10	7.53	3.77 - 11.30	Pass
STW-1192	07/01/09	Am-241	0.88 ± 0.08	1.04	0.73 - 1.35	Pass
STW-1192	07/01/09	Co-57	37.20 ± 1.50	36.60	25.60 - 47.60	Pass
STW-1192	07/01/09	Co-60	15.10 ± 0.90	15.40	10.80 ~ 20.00	Pass
STW-1192	07/01/09	Cs-134	30.30 ± 2.10	32.20	22.50 - 41.90	Pass
STW-1192	07/01/09	Cs-137	41.90 ± 1.80	41.20	28.80 - 53.60	Pass
STW-1192	07/01/09	Fe-55	54.50 ± 15.50	60.80	42.60 - 79.00	Pass
STW-1192	07/01/09	H-3	680.30 ± 33.60	634.10	443.90 - 824.30	Pass
STW-1192 °	07/01/09	Mn-54	0.01 ± 0.26	0.00	0.00 - 1.00	Pass
STW-1192	07/01/09	Ni-63	38.70 ± 2.60	44.20	30.90 - 57.50	Pass
STW-1192	07/01/09	Pu-238	0.02 ± 0.01	0.02	0.00 - 0.05	Pass
STW-1192	07/01/09	Pu-239/40	1.70 ± 0.10	1.64	1.15 - 2.13	Pass
STW-1192	07/01/09	Sr-90	12.90 ± 1.70	12.99	9.09 - 16.89	Pass
STW-1192	07/01/09	. Tc-99	7.60 ± 0.40	10.00	7.00 - 13.00	Pass
STW-1192	07/01/09	Tc-99	7.60 ± 0.40	10.00	7.00 - 13.00	Pass
STW-1192	07/01/09	U-233/4	2.90 ± 0.10	2.96	2.07 - 3.85	Pass
STW-1192	07/01/09	U-238	3.00 ± 0.10	3.03	2.12 - 3.94	Pass
STW-1192	07/01/09	Zn-65	28.50 ± 2.40	26.90	18.80 - 35.00	Pass

^a Results obtained by Environmental, Inc., Midwest Laboratory as a participant in the Department of Energy's

Mixed Analyte Performance Evaluation Program, Idaho Operations office, Idaho Falls, Idaho

^b Results are reported in units of Bq/kg (soil), Bq/L (water) or Bq/total sample (filters, vegetation).

^c Laboratory codes as follows: STW (water), STAP (air filter), STSO (soil), STVE (vegetation).

^d MAPEP results are presented as the known values and expected laboratory precision (1 sigma, 1 determination) and control limits as defined by the MAPEP.

^e Included in the testing series as a "false positive".

^f No errors were found in procedure or calculation. There was not enough sample for a reanalysis. Americium-241 in water was included in the ERA studies (Tbl. A-7) and also in the second round of MAPEP testing. Both analysis results were acceptable.

⁹ One determination was eliminated from the average, due to poor recovery. Average of three determinations, 0.25 ± 0.03 pCi/filter. ^h No reason was determined for the initial high results. The analysis was repeated; result of reanalysis; 0.54 ± 0.12 Bq/filter.

¹ Incomplete separation of strontium from calcium could result in a higher recovery percentage and consequently lower reported

activity. The analysis was repeated; result of reanalysis 363.3 ± 28.6 Bq/kg.

			Concentration (pC	Ci/L)	·	
Lab Code ^b	Date	Analysis	Laboratory	ERA	Control	
			Result ^c	Result ^d	Limits	Acceptance
STAP-1176	03/23/09	Am-241	47.20 ± 3.10	55.4	32.4 - 76.0	Pass
STAP-1176	03/23/09	Co-60	543.60 ± 8.90	490.0	379.0 - 612.0	Pass
STAP-1176	03/23/09	Cs-134	941.30 ± 30.70	865.0	563.0 - 1070.0	Pass
STAP-1176	03/23/09	Cs-137	850.60 ± 19.40	724.0	544.0 - 951.0	Pass
STAP-1176 °	03/23/09	Mn-54	0.00 ± 0.00	0.0	0.0 - 0.0	Pass
STAP-1176	03/23/09	Pu-238	64.50 ± 3.60	57.4	39.4 - 75.5	Pass
STAP-1176	03/23/09	Pu-239/40	88.50 ± 4.20	78.2	56.7 - 101.0	Pass
STAP-1176	03/23/09	Sr-90	93.90 ± 10.00	95.3	41.9 - 148.0	Pass
STAP-1176	03/23/09	U-233/4	50.00 ± 2.47	53.5	33.7 - 79.3	Pass
STAP-1176	03/23/09	U-238	50.40 ± 2.48	53.1	34.0 - 75.4	Pass
STAP-1176	03/23/09	Uranium	101.60 ± 5.30	109.0	55.7 - 173.0	Pass
STAP-1176	03/23/09	Zn-65	237.30 ± 23.70	185.0	128.0 - 256.0	Pass
STAP-1177	03/23/09	Gr. Alpha	76.30 ± 3.47	63.8	33.1 - 96.0	Pass
STAP-1177	03/23/09	Gr. Beta	98.50 ± 3.04	80.7	49.7 - 118.0	Pass
с.,						
			· · ·			
STSO-1178	03/23/09	Ac-228	1370.00 ± 121.00	1330.0	860.0 - 1880.0	Pass
STSO-1178	03/23/09	Am-241	1853.00 ± 185.50	1660.0	992.0 - 2130.0	Pass
STSO-1178	03/23/09	Bi-212	1449.00 ± 308.80	1550.0	406.0 - 2310.0	Pass
STSO-1178	03/23/09	Bi-214	1355.00 ± 66.20	1420.0	872.0 - 2050.0	Pass
STSO-1178	03/23/09	Co-60	7475.00 ± 46.40	7520.0	5470.0 - 10100.0	Pass
STSO-1178	03/23/09	Cs-134	5073.00 ± 74.70	5170.0	3330.0 - 6220.0	Pass
STSO-1178	03/23/09	Cs-137	5040.00 ± 49.70	4970.0	3800.0 - 6460.0	Pass
STSO-1178	03/23/09	K-40	10884.00 ± 292.70	11200.0	8060.0 - 15100.0	Pass
STSO-1178	03/23/09	Mn-54	0.00 ± 0.00	0.0	0.0 - 20.0	Pass
STSO-1178	03/23/09	Pb-212	1259.00 ± 28.40	1260.0	820.0 - 1780.0	Pass
STSO-1178	03/23/09	Pb-214	1464.00 ± 56.80	1510.0	902.0 - 2260.0	Pass
STSO-1178	03/23/09	Pu-238	1853.00 ± 185.50	1590.0	910.0 - 2240.0	Pass
STSO-1178	03/23/09	Pu-239/40	1516.50 ± 168.30	1360.0	928.0 - 1800.0	Pass
STSO-1178	03/23/09	Sr-90	5270.90 ± 290.20	5750.0	2080.0 - 9380.0	Pass
STSO-1178	03/23/09	U-233/4	1452.30 ± 114.40	1600.0	1010.0 - 1990.0	Pass
STSO-1178	03/23/09	Uranium	3013.70 ± 131.10	3270.0	1860.0 - 4410.0	Pass
STSO-1178	03/23/09	Zn-65	2083.00 ± 59.00	1940.0	1540.0 - 2600.0	Pass

1

TABLE A-7. Interlaboratory Comparison Crosscheck program, Environmental Resource Associates (ERA)^a.

			Concentration (pC	2i/L)		
Lab Code ^b	Date	Analysis	Laboratory Result ^c	ERA Result ^d	Control Limits	Acceptance
		<u></u>	······································			
					·	_
STVE-1179	03/23/09	Am-241	2849.70 ± 237.60	3660.0	2090.0 - 5030.0	Pass
STVE-1179	03/23/09	Cm-244	808.00 ± 85.70	954.0	470.0 - 1480.0	Pass
STVE-1179	03/23/09	Co-60	1546.80 ± 31.60	1710.0	1160.0 - 2460.0	Pass
STVE-1179	03/23/09	Cs-134	1706.00 ± 59.20	1880.0	1080.0 - 2600.0	Pass
STVE-1179	03/23/09	Cs-137	1940.50 ± 44.80	1800.0	1320.0 - 2500.0	Pass
STVE-1179	03/23/09	K-40	30107.30 ± 598.00	30800.0	22300.0 - 43700.0	Pass
STVE-1179	03/23/09	Mn-54	0.00 ± 0.00	0.0	0.0 - 0.0	Pass
STVE-1179	03/23/09	Sr-90	6604.80 ± 440.10	8860.0	4950.0 - 11800.0	Pass
STVE-1179	03/23/09	U-233/4	1718.00 ± 128.90	2040.0	1400.0 - 2710.0	Pass
STVE-1179	03/23/09	U-238	1718.30 ± 128.80	2020.0	1420.0 - 2550.0	Pass
STVE-1179	03/23/09	Uranium	3499.40 ± 371.00	4150.0	2850.0 - 5360.0	Pass
STVE-1179	03/23/09	Zn-65	869.40 ± 63.60	878.0	634.0 - 1200.0	Pass
STW-1180	03/23/09	Am-241	127.50 ± 5.10	132.0	90.4 - 178.0	Pass
STW-1180	03/23/09	Co-60	1174.10 ± 11.70	1230.0	1070.0 - 1450.0	Pass
STW-1180	03/23/09	Cs-134 .	742.20 ± 18.30	790.0	584.0 - 907.0	Pass
STW-1180	03/23/09	Cs-137	' 887.50 ± 14.00	913.0	776.0 - 1090.0	Pass
STW-1180	03/23/09	Fe-55	323.00 ± 362.00	492.0	286.0 - 657.0	Pass
STW-1180	03/23/09	Mn-54	0.00 ± 0.00	0.0	0.0 - 0.0	Pass
STW-1180	03/23/09	Pu-238	96.60 ± 2.20	108.0	81.7 - 134.0	Pass
STW-1180	03/23/09	Pu-239/40	89.50 ± 2.10	86.3	66.8 - 107.0	Pass
STW-1180	03/23/09	Sr-90	763.20 ± 12.90	834.0	530.0 - 1120.0	Pass
STW-1180	03/23/09	U-233/4	95.00 ± 1.80	96.6	72.8 - 124.0	Pass
STW-1180	03/23/09	U-238	97.40 ± 1.80	95.8	73.2 - 119.0	Pass
STW-1180	03/23/09	Uranium	195.50 ± 3.70	197.0	142.0 - 262.0	Pass
STW-1180	03/23/09	Zn-65	653.10 ± 24.10	631.0	535.0 - 786.0	Pass

TABLE A-7. Interlaboratory Comparison Crosscheck program, Environmental Resource Associates (ERA)^a.

^a Results obtained by Environmental, Inc., Midwest Laboratory as a participant in the crosscheck program for proficiency testing administered by Environmental Resources Associates, serving as a replacement for studies conducted previously by the Environmental Measurements Laboratory Quality Assessment Program (EML).

^b Laboratory codes as follows: STW (water), STAP (air filter), STSO (soil), STVE (vegetation).

^c Unless otherwise indicated, the laboratory result is given as the mean ± standard deviation for three determinations.

^d Results are presented as the known values, expected laboratory precision (1 sigma, 1 determination) and control limits as provided by ERA.

^e Included in the testing series as a "false positive". No activity expected.

^f The analysis was repeated by leaching and total dissolution methods. Total dissolution yielded results within expected range. Results of the reanalysis: U-233,4, 1655 ± 95 pCi/kg. U-238 1805 ± 97 pCi/kg.

APPENDIX B 2009 REMP DATA SUMMARY REPORTS

.

APPENDIX B

Air Gamma Spectral Summary Report 2009 Radiological Environmental Monitoring Program Data Summary

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Type and Units	Type and Number of Analyses Performed	Lower Limit (LLD)	Mean of Results from All Locations and Number Detected/Number Collected and Range	Mean of Results from All Indicator Locations and Number Detected/Number Collected and Range	Location # and	on with Highest Annual Mean: Mean and Number Detected/Number Collected and Range	Mean of Results from All Control Locations and Number Detected/Number Collected and Range
Air pCi/m3	Be-7 28	N/A	0.07 28 / 28 0.05 - 0.08	$\begin{array}{r} 0.07 \\ 24 \ / \ 24 \\ 0.05 \ - \ 0.08 \end{array}$	1 3.40 ENE	0.07 4 / 20 0.06 - 0.07	0.07 4 / 4 0.06 - 0.08
Air pCi/m3	Co-58 28	N/A	LLD	-	-	-	-
Air pCi/m3	Co-60 28	N/A	LLD	-	-	-	-
Air pCi/m3	Cs-134 28	0.04	LLD	-	-	_	-
Air pCi/m3	Cs-137 28	0.05	LLD	-	-	-	-

Air Gross Beta Summary Report 2009 Radiological Environmental Monitoring Program Data Summary Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440

Docket no. : 50-440/50-441

Sample Type and Units	Type and Number of Analyses Performed	Lower Limit (LLD)	Mean of Results from All Locations and Number Detected/Number Collected and Range	Mean of Results from All Indicator Locations and Number Detected/Number Collected and Range	Location # and	n with Highest Annual Mean: Mean and Number Detected/Number Collected and Range	Mean of Results from All Control Locations and Number Detected/Number Collected and Range
Air pCi/m3	Gross Beta 364	0.01	0.02 363 / 364 0.01 - 0.04	0.02 311 / 312 0.01 - 0.04	35 0.60 E	0.02 51 / 52 0.01 - 0.03	0.02 52 / 52 0.01 - 0.04
							· · ·
				· · · · · · · · · · · · · · · · · · ·			
					. · · ·		

Air Iodine Summary Report 2009 Radiological Environmental Monitoring Program Data Summary

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Type and Units	Type and Number of Analyses Performed	Lower Limit (LLD)	Mean of Results from All Locations and Number Detected/Number Collected and Range	Mean of Results from All Indicator Locations and Number Detected/Number Collected and Range	Locatio Location # and Distance and Direction	n with Highest Annual Mean: Mean and Number Detected/Number Collected and Range	Mean of Results from All Control Locations and Number Detected/Number Collected and Range
Air pCi/m3	I-131 364	0.05	LLD	-	-	-	_
			·				

Fish Gamma Spectral Summary Report 2009 Radiological Environmental Monitoring Program Data Summary

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Type and Units	Type and Number of Analyses Performed	Lower Limit (LLD)	Mean of Results from All Locations and Number Detected/Number Collected and Range	Mean of Results from All Indicator Locations and Number Detected/Number Collected and Range	Location # and	on with Highest Annual Mean: Mean and Number Detected/Number Collected and Range	Mean of Results from All Control Locations and Number Detected/Number Collected and Range
Fish pCi/kg wet	Co-58 8	97.00	LLD	-	-	-	-
Fish pCi/kg wet	Co-60 8	97.00	LLD	-	-	-	-
Fish pCi/kg wet	Cs-134 8	97.00	LLD	-	-	-	-
Fish pCi/kg wet	Cs-137 8	112.00	LLD	-	-	-	-
Fish pCi/kg wet	Fe-59 8	195.00	LLD	-	-	-	-
Fish pCi/kg wet	K-40 8	N/A	1,297.49 8 / 8 846.93 - 1,637.30	1,330.10 4 / 4 846.93 - 1,637.30	25 0.60 NNW	1,330.10 4 / 32 846.93 - 1,637.30	1,264.88 4 / 4 1,056.50 - 1,559.70
Fish pCi/kg wet	Mn-54 8	97.00	LLD	-	-	-	-
Fish pCi/kg wet	Zn-65 8	195.00	LLD	· · · ·	-		-

Food Products Gamma Spectral Summary Report 2009 Radiological Environmental Monitoring Program Data Summary

Perry Nuclear Power Plant, Lake Qounty Ohio Docket no. : 50-440/50-441

Sample Type and Units	Type and Number of Analyses Performed	Lower Limit (LLD)	Mean of Results from All Locations and Number Detected/Number Collected and Range	Mean of Results from All Indicator Locations and Number Detected/Number Collected and Range	Location # and	on with Highest Annual Mean: Mean and Number Detected/Number Collected and Range	Mean of Results from All Control Locations and Number Detected/Number Collected and Range
Food Products pCi/kg wet	Be-7 66	N/A	571.73 52 / 66 131.24 - 1,600.70	541.05 41 / 54 131.24 - 1,600.70	20 1.90 E	809.10 4 / 28 395.95 - 1,301.60	686.08 11 / 12 232.78 - 1,461.80
Food Products pCi/kg wet	Co-58 66	N/A	LLD	-	-	-	-
Food Products pCi/kg wet	Co-60 66	N/A	LLD	-	-		· · · · ·
Food Products pCi/kg wet	Cs-134 66	45.00	LLD	-	-	-	-
Food Products pCi/kg wet	Cs-137 66	60.00	LLD	-	-	-	-
Food Products pCi/kg wet	I-131 66	45.00	LLD	-	-	-	-
Food Products pCi/kg wet	K-40 66	N/A	5,699.12 66 / 66 3,043.25 - 10,368.00	5,644.35 54 / 54 3,043.25 - 10,368.00	18 2.50 E	6,644.13 11 / 77 4,589.20 - 10,368.00	5,945.58 12 / 12 3,466.80 - 9,186.10
						· · ·	

Milk Gamma Spectral Summary Report 2009 Radiological Environmental Monitoring Program Data Summary

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Type and Units	Type and Number of Analyses Performed	Lower Limit (LLD)	Mean of Results from All Locations and Number Detected/Number Collected and Range	Mean of Results from All Indicator Locations and Number Detected/Number Collected and Range	Location # and	on with Highest Annual Mean: Mean and Number Detected/Number Collected and Range	Mean of Results from All Control Locations and Number Detected/Number Collected and Range
Milk pCi/L	Ba-140 59	45.00	LLD	-	-	-	-
Milk pCi/L	Cs-134 59	11.00	LLD		-	-	-
Milk pCi/L	Cs-137 59	13.00	LLD	-	- .	-	-
Milk pCi/L	K-40 59	N/A	1,639.67 59 / 59 565.39 - 2,095.10	1,834.74 40 / 40 1,470.60 - 2,095.10	61 7.40 SE	1,871.13 13 / 65 1,673.40 - 2,043.50	1,228.99 19 / 19 565.39 - 1,438.70
Milk pCi/L	La-140 59	11.00	LLD	-	-	_	-
							· ·

Milk Iodine Summary Report 2009 Radiological Environmental Monitoring Program Data Summary

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Type and Units	Type and Number of Analyses Performed	Lower Limit (LLD)	Mean of Results from All Locations and Number Detected/Number Collected and Range	Mean of Results from All Indicator Locations and Number Detected/Number Collected and Range	Location # and	on with Highest Annual Mean: Mean and Number Detected/Number Collected and Range	Mean of Results from All Control Locations and Number Detected/Number Collected and Range
Milk pCi/L	I-131 59	0.75	LLD	-	-	-	-
				• • •			
	.						· · · · · · · · · · · · · · · · · · ·
							· · ·

Sediment Gamma Spectral Summary Report 2009Radiological Environmental Monitoring Program Data SummaryPerry Nuclear Power Plant, Lake County OhioDocket no. : 50-440/50-441

Sample Type and Units	Type and Number of Analyses Performed	Lower Limit (LLD)	Mean of Results from All Locations and Number Detected/Number Collected and Range	Mean of Results from All Indicator Locations and Number Detected/Number Collected and Range	Location # and	on with Highest Annual Mean: Mean and Number Detected/Number Collected and Range	Mean of Results from All Control Locations and Number Detected/Number Collected and Range
Sediment pCi/kg dry	Co-58 11	50.00	LLD	-	-	-	-
Sediment pCi/kg dry	Co-60 11	40.00	LLD	-	. <u>-</u>	-	-
Sediment pCi/kg dry	Cs-134 11	112.00	LLD	-	-	-	-
Sediment pCi/kg dry	Cs-137 11	135.00	505.24 4 / 11 301.33 - 699.30	321.37 2 / 9 301.33 - 341.42	32 15.80 WSW	689.11 2 / 10 678.91 - 699.30	689.11 2 / 2 678.91 - 699.30
Sediment pCi/kg dry	K-40 11	N/A	15,255.95 11 / 11 7,208.50 - 24,592.00	13,268.38 9 / 9 7,208.50 - 23,037.00	32 15.80 WSW	24,200.00 2 / 10 23,808.00 - 24,592.00	24,200.00 2 / 2 23,808.00 - 24,592.00
				-			
			· ·		· · · ·		
							· · · · ·
			· · ·				

TLD Gamma Dose Summary Report 2009 Radiological Environmental Monitoring Program Data Summary

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Type and Units	Type and Number of Analyses Performed	Lower Limit (LLD)	Mean of Results from All Locations and Number Detected/Number Collected and Range	Mean of Results from All Indicator Locations and Number Detected/Number Collected and Range	Location # and	on with Highest Annual Mean: Mean and Number Detected/Number Collected and Range	Mean of Results from All Control Locations and Number Detected/Number Collected and Range
TLD mR/91 days	Direct 112	1.00	12.75 112 / 112 8.26 - 17.48	12.78 104 / 104 8.26 - 17.48	33 4.50 S	16.73 4 / 4 15.42 - 17.48	12.47 8 / 8 11.62 - 13.40
TLD mR/91 days	Direct 112	1.00	12.80 112 / 112 9.31 - 17.53	12.86 104 / 104 9.31 - 17.53	33 4.50 S	16.48 4 / 4 14.74 - 17.36	12.07 8 / 8 10.74 - 13.33
TLD mR/365 days	Direct 27	1.00	53.75 27 / 27 41.66 - 70.94	54.03 25 / 25 41.66 - 70.94	33 4.50 S	70.94 1 / 1 70.94 - 70.94	50.20 2 / 2 45.94 - 54.45
							Al Agenti de Calendaria Al Alendaria
		÷	×				
	-		• •				
					· · ·		
			·				

Water Gamma Spectral Summary Report 2009Radiological Environmental Monitoring Program Data SummaryPerry Nuclear Power Plant, Lake County OhioDocket no. : 50-440/50-441

Sample Type and Units	Type and Number of Analyses Performed	Lower Limit (LLD)	Mean of Results from All Locations and Number Detected/Number Collected and Range	Mean of Results from All Indicator Locations and Number Detected/Number Collected and Range	Location # and	on with Highest Annual Mean: Mean and Number Detected/Number Collected and Range	Mean of Results from All Control Locations and Number Detected/Number Collected and Range
Water pCi/L	Ba-140 54	45.00	LLD	-	-	-	-
Water pCi/L	Co-58 54	11.00	LLD	-	-	-	_
Water pCi/L	Co-60 54	11.00	LLD	-	-	-	-
Water pCi/L	Cs-134 54	11.00	LLD	-	-	-	-
Water pCi/L	Cs-137 54	13.00	LLD	- -	-		_
Water pCi/L	Fe-59 54	22.00	LLD	-	• _	-	
Water pCi/L	La-140 54	11.00	LLD	-	-	-	-
Water pCi/L	Mn-54 54	11.00	LLD		-	-	
Water pCi/L	Nb-95 54	11.00	LLD	-	-	-	2 1. 1
Water pCi/L	Zn-65 54	22.00	LLD	-	-	-	- - -

Water Gamma Spectral Summary Report 2009 Radiological Environmental Monitoring Program Data Summary Perry Nuclear Power Plant, Lake County Ohio

Docket no. : 50-440/50-441

 $a \cdot c$

Sample Type and Units	Type and Number of Analyses Performed	Lower Limit (LLD)	Mean of Results from All Locations and Number Detected/Number Collected and Range	Mean of Results from All Indicator Locations and Number Detected/Number Collected and Range	Location # and	on with Highest Annual Mean: Mean and Number Detected/Number Collected and Range	Mean of Results from All Control Locations and Number Detected/Number Collected and Range
Water pCi/L	Zr-95 54	22.00	LLD	-	-	-	-
			-			· ·	
						· · · ·	
					· ·		

Water Gross Beta Summary Report 2009 Radiological Environmental Monitoring Program Data Summary

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Type and Units	Type and Number of Analyses Performed	Lower Limit (LLD)	Mean of Results from All Locations and Number Detected/Number Collected and Range	Mean of Results from All Indicator Locations and Number Detected/Number Collected and Range	Location # and	on with Highest Annual Mean: Mean and Number Detected/Number Collected and Range	Mean of Results from All Control Locations and Number Detected/Number Collected and Range
Water pCi/L	Gross Beta 54	3.00	3.14 2 / 54 3.09 - 3.19	3.09 1 / 42 3.09 - 3.09	28 22.00 ENE	3.19 1 / 12 3.19 - 3.19	3.19 1 / 12 3.19 - 3.19
	-						· · · · · · · · · · · · · · · · · · ·

Water Tritium Summary Report 2009 Radiological Environmental Monitoring Program Data Summary

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

ς

Sample Type and Units	Type and Number of Analyses Performed	Lower Limit (LLD)	Mean of Results from All Locations and Number Detected/Number Collected and Range	Mean of Results from All Indicator Locations and Number Detected/Number Collected and Range	Location # and	on with Highest Annual Mean: Mean and Number Detected/Number Collected and Range	Mean of Results from All Control Locations and Number Detected/Number Collected and Range
Water pCi/L	H-3 20	1,500.00	LLD	-	-	-	-
							· · ·
			,				· · ·
			· .·				· · ·

APPENDIX C 2009 REMP DETAILED DATA REPORT

2

Air Gamma Spectral Detail Report 2009

Radiological Environmental Monitoring Program Detail Data

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Frequency is: Quarterly Results in pCi/m3 +/- 2 Sigma

Location	Sample Type	Collection Date	Be-7	Co-58	Co-60	Cs-134	Cs-137	
1	Air	4/1/2009	0.074 +/- 0.008	< 0.000	< 0.000	< 0.000	< 0.000	
1	Air	7/1/2009	0.070 +/- 0.008	< 0.001	< 0.000	< 0.000 .	< 0.000	
1	Air	9/30/2009	0.073 +/- 0.010	< 0.001	< 0.000	< 0.000	< 0.000	
1	Air	12/30/2009	0.059 +/- 0.010	< 0.000	< 0.001	< 0.000	< 0.000	
3	Air	4/1/2009	0.074 +/- 0.006	< 0.000	< 0.000	< 0.000	< 0.000	
3	Air	7/1/2009	0.071 +/- 0.011	< 0.000	< 0.000	< 0.000	< 0.000	
3	Air	9/30/2009	0.055 +/- 0.009	< 0.001	< 0.001	< 0.000	< 0.000	
	,							
3	Air	12/30/2009	0.061 +/- 0.008	< 0.000	< 0.000	< 0.000	< 0.000	
4	Air	4/1/2009	0.061 +/- 0.007	< 0.000	< 0.000	< 0.000	< 0.000	
4	Air	7/1/2009	0.066 +/- 0.008	< 0.000	< 0.000	< 0.000	< 0.000	
4	Air	4/1/2009	0.061 +/- 0.007	< 0.000	< 0.000	< 0.000	< 0.000	

Air Gamma Spectral Detail Report 2009

Radiological Environmental Monitoring Program Detail Data

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Frequency is: Quarterly Results in pCi/m3 +/- 2 Sigma

	· · · · · ·			· · ·				
 Location	Sample Type	Collection Date	Be-7	Co-58	Co-60	Cs-134	Cs-137	
 4	Air	9/30/2009	0.069 +/- 0.008	< 0.000	< 0.000	< 0.000	< 0.000	
4	Air	12/30/2009	0.069 +/- 0.009	< 0.000	< 0.000	< 0.000	< 0.000	
5	Air	4/1/2009	0.072 +/- 0.007	< 0.000	< 0.000	< 0.000	< 0.000	
5	Air	7/1/2009	0.064 +/- 0.010	< 0.001	< 0.000	< 0.000	< 0.000	
5	Air	9/30/2009	0.062 +/- 0.008	< 0.000	< 0.000	< 0.000	< 0.000	
5	Air	12/30/2009	0.062 +/- 0.007	< 0.000	< 0.000	< 0.000	< 0.000	
6	Air	4/1/2009	0.080 +/- 0.009	< 0.000	< 0.000	< 0.000	< 0.000	
6	Air	7/1/2009	0.061 +/- 0.009	< 0.000	< 0.000	< 0.000	< 0.000	
6	Air	9/30/2009	0.063 +/- 0.008	< 0.000	< 0.000	< 0.000	< 0.000	
6	Air	12/30/2009	0.063 +/- 0.006	< 0.000	< 0.000	< 0.000	< 0.000	

· ·

2

Air Gamma Spectral Detail Report 2009

Radiological Environmental Monitoring Program Detail Data

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Frequency is: Quarterly Results in pCi/m3 +/- 2 Sigma

Location	Sample Type	Collection Date	Be-7	Co-58	Co-60	Cs-134	Cs-137
7	Air	4/1/2009	0.073 +/- 0.011	< 0.000	< 0.000	< 0.000	< 0.001
7	Air	7/1/2009	0.077 +/- 0.010	< 0.000	< 0.000	< 0.000	< 0.000
7	Air	9/30/2009	0.067 +/- 0.007	< 0.000	< 0.000	< 0.000	< 0.000
7	Air	12/30/2009	0.048 +/- 0.007	< 0.000	< 0.000	< 0.000	< 0.000
35	Air	4/1/2009	0.077 +/- 0.010	< 0.000	< 0.000	< 0.000	< 0.001
35	Air	7/1/2009	0.066 +/- 0.007	< 0.000	< 0.000	< 0.000	< 0.000
35	Air	9/30/2009	0.069 +/- 0.009	< 0.000	< 0.000	< 0.000	< 0.000
35	Air	12/30/2009	0.057 +/- 0.006	< 0.000	< 0.000	< 0.000	< 0.000

Air Gross Beta Detail Report 2009

Radiological Environmental Monitoring Program Data Summary

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Frequency is: Weekly

Results in pCi/m3 +/- 2 Sigma

			·	Location	• • •	
Collection Date	Sample Type	1 7	3 35	4	5	6
1/7/2009	Air	0.029 +/- 0.003 0.030 +/- 0.003	0.027 +/- 0.003 0.029 +/- 0.003	0.027 +/- 0.003	0.030 +/- 0.003	0.026 +/- 0.003
1/14/2009	Air	0.031 +/- 0.003 0.028 +/- 0.003	0.029 +/- 0.003 0.031 +/- 0.003	0.025 +/- 0.003	0.032 +/- 0.003	0.033 +/- 0.003
1/21/2009	Air	0.036 +/- 0.003 0.035 +/- 0.003	0.034 +/- 0.003 0.032 +/- 0.003	0.033 +/- 0.003	0.034 +/- 0.003	0.034 +/- 0.003
1/28/2009	Air	0.033 +/- 0.003 0.032 +/- 0.003	0.035 +/- 0.003 0.034 +/- 0.003	0.026 +/- 0.003	0.033 +/- 0.003	0.034 +/- 0.003
2/4/2009	Air	0.031 +/- 0.003 0.031 +/- 0.003	0.032 +/- 0.003 0.030 +/- 0.003	0.030 +/- 0.003	0.034 +/- 0.003	0.027 +/- 0.003
2/11/2009	Air	0.034 +/- 0.003 0.033 +/- 0.003	0.032 +/- 0.003 0.034 +/- 0.003	0.029 +/- 0.003	0.034 +/- 0.003	0.032 +/- 0.003
2/18/2009	Air	0.020 +/- 0.003 0.020 +/- 0.003	0.020 +/- 0.003 0.021 +/- 0.003	0.018 +/- 0.003	0.021 +/- 0.003	0.021 +/- 0.003
2/25/2009	Air	0.022 +/ - 0.003 0.025 +/- 0.003	0.025 +/- 0.003 0.025 +/- 0.003	0.023 +/- 0.003	0.023 +/- 0.003	0.023 +/- 0.003
3/4/2009	Air	0.028 +/- 0.003 0.029 +/- 0.003	0.028 +/- 0.003 0.027 +/- 0.003	0.028 +/- 0.003	0.027 +/- 0.003	0.027 +/- 0.003
3/11/2009	Air	0.025 +/- 0.003 0.025 +/- 0.003	0.023 +/- 0.003 0.026 +/- 0.003	0.023 +/- 0.003	0.025 +/- 0.003	0.023 +/- 0.003
3/18/2009	Air	0.032 +/- 0.003 0.035 +/- 0.003	0.031 +/- 0.003 0.032 +/- 0.003	0.029 +/- 0.003	0.032 +/- 0.003	0.029 +/- 0.003
3/25/2009	Air	0.024 +/- 0.003 0.025 +/- 0.003	0.024 +/- 0.003 0.023 +/- 0.003	0.025 +/- 0.003	0.026 +/- 0.003	0.023 +/- 0.003
4/1/2009	Air	0.016 +/- 0.003 0.019 +/- 0.003	0.016 +/- 0.003 0.019 +/- 0.003	0.016 +/- 0.002	0.017 +/- 0.003	0.014 +/- 0.003
4/8/2009	Air	0.015 +/- 0.003 0.015 +/- 0.003	0.014 +/- 0.003 0.017 +/- 0.003	0.013 +/- 0.002	0.015 +/- 0.002	0.015 +/- 0.003

Air Gross Beta Detail Report 2009

Radiological Environmental Monitoring Program Data Summary

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Frequency is: Weekly

Results in pCi/m3 +/- 2 Sigma

			· · · · · · · · · · · · · · · · · · ·	Location		
Collection Date	Sample Type	1 7	3 35	4	5	6
4/15/2009	Air	0.019 +/- 0.003 0.023 +/- 0.003	0.022 +/- 0.003 0.024 +/- 0.003	0.025 +/- 0.003	0.022 +/- 0.003	0.021 +/- 0.003
4/22/2009	Air	0.019 +/- 0.003 0.020 +/- 0.003	0.019 +/- 0.003 0.026 +/- 0.005	0.018 +/- 0.003	0.020 +/- 0.003	0.020 +/- 0.003
4/29/2009	Air	0.019 +/- 0.002 0.021 +/- 0.003	0.021 +/- 0.003 0.021 +/- 0.003	0.018 +/- 0.002	0.021 +/- 0.002	0.022 +/- 0.003
5/6/2009	Air	0.021 +/- 0.003 0.020 +/- 0.003	0.020 +/- 0.002 0.019 +/- 0.002	0.019 +/- 0.003	0.019 +/- 0.002	0.021 +/- 0.003
5/13/2009	Air	0.019 +/- 0.002 0.019 +/- 0.003	0.016 +/- 0.002 0.014 +/- 0.002	0.018 +/- 0.002	0.016 +/- 0.002	0.016 +/- 0.002
5/20/2009	Air	0.016 +/- 0.003 0.017 +/- 0.003	0.017 +/- 0.002 0.017 +/- 0.003	0.017 +/- 0.003	0.016 +/- 0.002	0.018 +/- 0.003
5/27/2009	Air	0.019 +/- 0.002 0.021 +/- 0.003	0.021 +/- 0.002 0.020 +/- 0.003	0.021 +/- 0.003	0.021 +/- 0.002	0.021 +/- 0.003
6/3/2009	Air	0.015 +/- 0.002 0.013 +/- 0.003	0.013 +/- 0.002 0.014 +/- 0.002	0.012 +/- 0.002	0.015 +/- 0.002	0.013 +/- 0.002
6/10/2009	Air	0.016 +/- 0.002 0.023 +/- 0.003	0.018 +/- 0.002 0.031 +/- 0.003	0.016 +/- 0.002	0.016 +/- 0.002	0.018 +/- 0.003
6/17/2009	Air	0.015 +/- 0.002 0.015 +/- 0.002	0.015 +/- 0.002 0.015 +/- 0.002	0.015 +/- 0.002	0.017 +/- 0.002	0.017 +/- 0.003
6/24/2009	Air	0.008 +/- 0.002 0.010 +/- 0.002	0.009 +/- 0.002 LLD	0.010 +/- 0.002	0.009 +/- 0.002	0.009 +/- 0.002
7/1/2009	Air	0.015 +/- 0.002 0.016 +/- 0.002	0.016 +/- 0.002 0.014 +/- 0.002	0.017 +/- 0.002	0.016 +/- 0.002	0.016 +/- 0.002
7/8/2009	Air	0.009 +/- 0.002 0.009 +/- 0.002	0.010 +/- 0.002 0.010 +/- 0.002	0.010 +/- 0.002	0.010 +/- 0.002	0.011 +/- 0.002
7/15/2009	Air	0.013 +/- 0.002 0.014 +/- 0.002	0.013 +/- 0.002 0.014 +/- 0.002	0.013 +/- 0.002	0.013 +/- 0.002	0.016 +/- 0.003

Air Gross Beta Detail Report 2009

Radiological Environmental Monitoring Program Data Summary

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Frequency is: Weekly

Results in pCi/m3 +/- 2 Sigma

				Location		
Collection Date	Sample Type	1 7	3 35	4	5	6
7/22/2009	Air	0.014 +/- 0.002 0.012 +/- 0.002	0.015 +/- 0.002 0.014 +/- 0.002	0.014 +/- 0.002	0.015 +/- 0.002	0.015 +/- 0.003
7/29/2009	Air	0.023 +/- 0.003 0.020 +/- 0.002	0.023 +/- 0.003 0.023 +/- 0.003	0.023 +/- 0.003	0.021 +/- 0.003	0.024 +/- 0.003
8/5/2009	Air	0.022 +/- 0.003 0.020 +/- 0.003	0.030 +/- 0.003 0.022 +/- 0.003	0.027 +/- 0.003	0.020 +/- 0.003	0.022 +/- 0.003
8/12/2009	Air	0.023 +/- 0.003 0.021 +/- 0.003	0.022 +/- 0.003 0.020 +/- 0.003	0.021 +/- 0.003	0.021 +/- 0.003	0.021 +/- 0.003
8/19/2009	Air	0.033 +/- 0.003 0.034 +/- 0.003	0.033 +/- 0.003 0.035 +/- 0.003	0.031 +/- 0.003	0.032 +/- 0.003	0.035 +/- 0.003
8/26/2009	Air	0.018 +/- 0.002 0.014 +/- 0.002	0.018 +/- 0.002 0.016 +/- 0.002	0.015 +/- 0.002	0.017 +/- 0.002	0.015 +/- 0.002
9/2/2009	Air	0.017 +/- 0.002 0.014 +/- 0.002	0.014 +/- 0.002 0.014 +/- 0.002	0.015 +/- 0.002	0.015 +/- 0.002	0.016 +/- 0.003
9/9/2009	Air	0.028 +/- 0.003 0.026 +/- 0.003	0.026 +/- 0.003 0.030 +/- 0.003	0.029 +/- 0.003	0.026 +/- 0.003	0.029 +/- 0.003
9/16/2009	Air	0.036 +/- 0.003 0.030 +/- 0.003	0.029 +/- 0.003 0.033 +/- 0.003	0.033 +/- 0.003	0.030 +/- 0.003	0.035 +/- 0.003
9/23/2009	Air	0.021 +/- 0.003 0.019 +/- 0.002	0.021 +/- 0.003 0.020 +/- 0.002	0.021 +/- 0.003	0.021 +/- 0.002	0.023 +/- 0.003
9/30/2009	Air	0.017 +/- 0.002 0.014 +/- 0.002	0.017 +/- 0.002 0.015 +/- 0.002	0.015 +/- 0.002	0.017 +/- 0.002	0.017 +/- 0.002
10/7/2009	Air	0.012 +/- 0.002 0.012 +/- 0.002	0.015 +/- 0.002 0.014 +/- 0.002	0.014 +/- 0.002	0.014 +/- 0.002	0.010 +/- 0.002
10/14/2009	Air	0.017 +/- 0.002 0.014 +/- 0.002	0.014 +/- 0.002 0.014 +/- 0.002	0.015 +/- 0.002	0.015 +/- 0.002	0.014 +/- 0.002
10/21/2009	Air	0.020 +/- 0.003 0.017 +/- 0.003	0.017 +/- 0.003 0.016 +/- 0.002	0.016 +/- 0.003	0.017 +/- 0.002	0.018 +/- 0.003

Air Gross Beta Detail Report 2009

Radiological Environmental Monitoring Program Data Summary

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Frequency is: Weekly Results in pCi/m3 +/- 2 Sigma

				Location		
Collection Date	Sample Type	1 7	3 35	4	5	6
10/28/2009	Air	0.023 +/- 0.003 0.017 +/- 0.003	0.020 +/- 0.003 0.020 +/- 0.003	0.019 +/- 0.003	0.022 +/- 0.003	0.021 +/- 0.003
11/4/2009	Air	0.018 +/- 0.003 0.014 +/- 0.002	0.015 +/- 0.002 0.016 +/- 0.003	0.016 +/- 0.002	0.015 +/- 0.002	0.017 +/- 0.002
11/11/2009	Air	0.034 +/- 0.003 0.030 +/- 0.003	0.033 +/- 0.003 0.032 +/- 0.003	0.030 +/- 0.003	0.031 +/- 0.003	0.032 +/- 0.003
11/18/2009	Air	0.021 +/- 0.003 0.021 +/- 0.003	0.022 +/- 0.003 0.022 +/- 0.002	0.020 +/- 0.003	0.021 +/- 0.003	0.024 +/- 0.003
11/25/2009	Air	0.033 +/- 0.003 0.033 +/- 0.003	0.032 +/- 0.003 0.033 +/- 0.003	0.033 +/- 0.003	0.035 +/- 0.003	0.035 +/- 0.003
12/2/2009	Air .	0.022 +/- 0.003 0.022 +/- 0.003	0.026 +/- 0.003 0.022 +/- 0.002	0.020 +/- 0.003	0.022 +/- 0.003	0.025 +/- 0.003
12/9/2009	Air	0.021 +/- 0.003 0.020 +/- 0.003	0.025 +/- 0.003 0.022 +/- 0.002	0.021 +/- 0.003	0.022 +/- 0.003	0.026 +/- 0.003
12/16/2009	Air	0.031 +/- 0.003 0.029 +/- 0.003	0.034 +/- 0.003 0.033 +/- 0.003	0.027 +/- 0.003	0.031 +/- 0.003	0.032 +/- 0.003
12/23/2009	Air	0.032 +/- 0.003 0.032 +/- 0.003	0.035 +/- 0.003 0.034 +/- 0.003	0.031 +/- 0.003	0.033 +/- 0.003	0.031 +/- 0.003
12/30/2009	Air	0.019 +/- 0.003 0.020 +/- 0.003	0.018 +/- 0.003 0.016 +/- 0.002	0.020 +/- 0.003	0.019 +/- 0.002	0.021 +/- 0.003

.....

.

Air Iodine Detail Report 2009

Radiological Environmental Monitoring Program Detail DataPerry Nuclear Power Plant, Lake County OhioDocket no. : 50-440/50-441Sample Frequency is: WeeklyResults in pCi/m3 +/- 2 Sigma

Location	Sample Type	Collection Date	I-131	
1	Air	1/7/2009	< 0.008	
1	Air	1/14/2009	< 0.006	
1	Air	1/21/2009	< 0.009	
1	Air	1/28/2009	< 0.009	
1	Air	2/4/2009	< 0.004	
1	Air	2/11/2009	< 0.010	
1	Air	2/18/2009	< 0.004	
1	Air	2/25/2009	< 0.006	
1	Air	3/4/2009	< 0.005	
1	Air	.3/11/2009	< 0.008	
1	Air	3/18/2009	< 0.008	
1	Air	3/25/2009	< 0.006	
1	Air	4/1/2009	< 0.005	
1	Air	4/8/2009	< 0.007	
1	Air	4/15/2009	< 0.009	
1	Air	4/22/2009	< 0.004	
1	Air	4/29/2009	< 0.004	
1	Air	5/6/2009	< 0.006	
1	Air	5/13/2009	< 0.006	
1	Air	5/20/2009	< 0.004	
1	Air	5/27/2009	< 0.005	
1	Air	6/3/2009	< 0.004	
1	Air	6/10/2009	< 0.007	
1	Air	6/17/2009	< 0.005	
1	Air	6/24/2009	< 0.007	
1	Air	7/1/2009	< 0.008	
1	Air	7/8/2009	< 0.005	
1	Air	7/15/2009	< 0.006	. · ·
1	Air	7/22/2009	< 0.008	
1	Air	7/29/2009	< 0.004	
1	Air	8/5/2009	< 0.007	
1	Air	8/12/2009	< 0.005	
1	Air	8/19/2009	< 0.009	
1	Air	8/26/2009	< 0.005	

N

Air Iodine Detail Report 2009Radiological Environmental Monitoring Program Detail DataPerry Nuclear Power Plant, Lake County OhioDocket no. : 50-440/50-441Sample Frequency is: WeeklyResults in pCi/m3 +/- 2 Sigma

Location	Sample Type	Collection Date	I-131	
1	Air	9/2/2009	< 0.011	
1	Air	9/9/2009	< 0.008	
1	Air	9/16/2009	< 0.007	
1	Air	9/23/2009	< 0.009	
1	Air	9/30/2009	< 0.006	
1	Air	10/7/2009	< 0.009	
1,	Air	10/14/2009	< 0.012	
1	Air	10/21/2009	< 0.009	
1	Air	10/28/2009	< 0.009	
1	Air	11/4/2009	< 0.009	
-1	Air	11/11/2009	< 0.006	
1	Air	11/18/2009	< 0.007	
1	Air	11/25/2009	< 0.005	
1	Air	12/2/2009	< 0.006	
1	Air	12/9/2009	< 0.005	
1	Air	12/16/2009	< 0.008	
1	Air	12/23/2009	< 0.006	
1	Air	12/30/2009	< 0.008	
3	Air	1/7/2009	< 0.007	
3	Air	1/14/2009	< 0.005	
3	Air	1/21/2009	< 0.008	
3	Air	1/28/2009	< 0.008	
3	Air	2/4/2009	< 0.003	· · · · · · · · · · · · · · · · · · ·
3	Air	2/11/2009	< 0.009	
3	Air	2/18/2009	< 0.004	
3	Air	2/25/2009	< 0.005	
3	Air	3/4/2009	< 0.005	
3	Air	3/11/2009	< 0.008	
3	Air	3/18/2009	< 0.008	
3	Air	3/25/2009	< 0.005	
3	Air	4/1/2009	< 0.005	
3	Air	4/8/2009	< 0.007	
3	Air	4/15/2009	< 0.008	

Air Iodine Detail Report 2009

Radiological Environmental Monitoring Program Detail DataPerry Nuclear Power Plant, Lake County OhioDocket no. : 50-440/50-441Sample Frequency is: WeeklyResults in pCi/m3 +/- 2 Sigma

Location	Sample Type	Collection Date	I-131	
3	Air	4/22/2009	< 0.005	
3	Air	4/29/2009	< 0.004	
3	Air	5/6/2009	< 0.006	
3	Air	5/13/2009	< 0.006	
3	Air	5/20/2009	< 0.004	
3	Air	5/27/2009	< 0.005	
3	Air	6/3/2009	< 0.004	
3	Air	6/10/2009	< 0.007	
3	Air	6/17/2009	< 0.005	
3	Air	6/24/2009	< 0.007	
3	Air	7/1/2009	< 0.007	
3	Air	7/8/2009	< 0.005	
3	Air	7/15/2009	< 0.006	
3	Air	7/22/2009	< 0.008	
3	Air	7/29/2009	< 0.004	
3	Air	8/5/2009	< 0.007	
3	Air	8/12/2009	< 0.005	
- 3	Air	8/19/2009	< 0.009	
3	Air	8/26/2009	< 0.005	
3	Air	9/2/2009	< 0.012	
3	Air	9/9/2009	< 0.008	
3	Air	9/16/2009	< 0.007	
3	Air	9/23/2009	< 0.009	
3	Air	9/30/2009	< 0.006	
3	Air	10/7/2009	< 0.009	
3	Air	10/14/2009	< 0.012	
3	Air	10/21/2009	< 0.008	
3	Air	10/28/2009	< 0.009	
3	Air	11/4/2009	< 0.009	
3	Air	11/11/2009	< 0.006	
3	Air	11/18/2009	< 0.007	
3	Air	11/25/2009	< 0.005	
3	Air	12/2/2009	< 0.006	
3	Air	12/9/2009	< 0.005	
3	Air	12/16/2009	< 0.008	

Air Iodine Detail Report 2009 Radiological Environmental Monitoring Program Detail Data Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Frequency is: Weekly Results in pCi/m3 +/- 2 Sigma

ſ.

Location	Sample Type	Collection Date	I-131	
3	Air	12/23/2009	< 0.006	
3	Air	12/30/2009	< 0.008	
4	Air	1/7/2009	< 0.007	
4	Air	1/14/2009	< 0.005	
4	Air	1/21/2009	< 0.008	
4	Air	1/28/2009	< 0.008	
4	Air	2/4/2009	< 0.004	
4	Air	2/11/2009	< 0.009	
4	Air	2/18/2009	< 0.004	
4	Air	2/25/2009	< 0.005	
4	Air	3/4/2009	< 0.005	
4	Air	3/11/2009	< 0.007	
4	Air	3/18/2009	< 0.008	
4	Air	3/25/2009	< 0.005	
4	Air	4/1/2009	< 0.005	
4	Air	4/8/2009	< 0.007	
4	Air	4/15/2009	< 0.008	
4	Air	4/22/2009	< 0.004	
4	Air	4/29/2009	< 0.004	
4	Air	5/6/2009	< 0.006	
4	Air	5/13/2009	< 0.006	
4	Air	5/20/2009	< 0.004	
4	Air	5/27/2009	< 0.005	
4	Air	6/3/2009	< 0.004	
4	Air	6/10/2009	< 0.007	
4	Air	6/17/2009	< 0.005	
4	Air	6/24/2009	< 0.007	
4	Air	7/1/2009	< 0.008	
4 .	Air	7/8/2009	< 0.005	
4	Air	7/15/2009	< 0.007	
4	Air	7/22/2009	< 0.008	
4	Air	7/29/2009	< 0.004	
4	Air	8/5/2009	< 0.007	

Air Iodine Detail Report 2009

Radiological Environmental Monitoring Program Detail DataPerry Nuclear Power Plant, Lake County OhioDocket no. : 50-440/50-441Sample Frequency is: WeeklyResults in pCi/m3 +/- 2 Sigma

Location	Sample Type	Collection Date	I-131	
4	Air	8/12/2009	< 0.005	· · · · · · · · · · · · · · · · · · ·
4	Air	8/19/2009	< 0.009	
4	Air	8/26/2009	< 0.005	
4	Air	9/2/2009	< 0.012	
4	Air	9/9/2009	< 0.009	
4	Air	9/16/2009	< 0.007	
4	Air	9/23/2009	< 0.009	
4	Air	9/30/2009	< 0.006	
4	Air	10/7/2009	< 0.009	
4	Air	10/14/2009	< 0.012	
4	Air	10/21/2009	< 0.009	
4	Air	10/28/2009	< 0.009	
4	Air	11/4/2009	< 0.009	
4	Air	11/11/2009	< 0.006	
4	Air	11/18/2009	< 0.007	
4	Air	11/25/2009	< 0.005	
4	Air	12/2/2009	< 0.006	
4	Air	12/9/2009	< 0.005	
4	Air	12/16/2009	< 0.008	
4	Air	12/23/2009	< 0.006	
4	Air	12/30/2009	< 0.008	
5	Air	1/7/2009	< 0.007	
5	Air	1/14/2009	< 0.005	
5	Air	1/21/2009	< 0.008	
5	Air	1/28/2009	< 0.008	
5	Air	2/4/2009	< 0.003	
5	Air	2/11/2009	< 0.009	
5	Air	2/18/2009	< 0.004	
5	Air	2/25/2009	< 0.005	
5	Air	3/4/2009	< 0.005	
5	Air	3/11/2009	< 0.007	
5	Air	3/18/2009	< 0.008	
5	Air	3/25/2009	< 0.005	
5	Air	4/1/2009	< 0.005	

Air Iodine Detail Report 2009Radiological Environmental Monitoring Program Detail DataPerry Nuclear Power Plant, Lake County OhioDocket no. : 50-440/50-441

Sample Frequency is: Weekly Results in pCi/m3 +/- 2 Sigma

5Air $4/8/2009$ < 0.006	
5Air $4/22/2009$ < 0.004	
5Air $4/29/2009$ < 0.004	
5Air $5/6/2009$ < 0.006 5Air $5/13/2009$ < 0.006 5Air $5/20/2009$ < 0.004 5Air $5/27/2009$ < 0.005 5Air $6/3/2009$ < 0.004 5Air $6/1/2009$ < 0.007 5Air $6/1/2009$ < 0.006 5Air $6/24/2009$ < 0.006 5Air $7/1/2009$ < 0.006 5Air $7/1/2009$ < 0.006 5Air $7/12/2009$ < 0.006 5Air $7/22/2009$ < 0.006 5Air $7/22/2009$ < 0.006 5Air $8/5/2009$ < 0.006 5Air $8/20209$ < 0.005 5Air $8/26/2009$ < 0.005 5Air $8/26/2009$ < 0.005 5Air $8/26/2009$ < 0.005 5Air $8/26/2009$ < 0.005	
5Air $5/13/2009$ < 0.006	
5Air $5/20/2009$ < 0.004 5Air $5/27/2009$ < 0.005 5Air $6/3/2009$ < 0.004 5Air $6/10/2009$ < 0.007 5Air $6/17/2009$ < 0.005 5Air $6/24/2009$ < 0.006 5Air $7/1/2009$ < 0.007 5Air $7/1/2009$ < 0.006 5Air $7/1/2009$ < 0.005 5Air $7/1/2009$ < 0.006 5Air $7/22/2009$ < 0.006 5Air $7/22/2009$ < 0.006 5Air $8/5/2009$ < 0.006 5Air $8/5/2009$ < 0.006 5Air $8/5/2009$ < 0.006 5Air $8/5/2009$ < 0.006 5Air $8/12/2009$ < 0.006 5Air $8/20209$ < 0.005 5Air $8/20209$ < 0.005 5Air $8/26/2009$ < 0.005 5Air $8/26/2009$ < 0.005	
5Air $5/27/209$ < 0.005 5Air $6/3/2009$ < 0.004 5Air $6/10/2009$ < 0.007 5Air $6/17/2009$ < 0.005 5Air $6/24/2009$ < 0.006 5Air $7/1/2009$ < 0.007 5Air $7/1/2009$ < 0.005 5Air $7/1/2009$ < 0.006 5Air $7/1/2009$ < 0.006 5Air $7/2/2009$ < 0.006 5Air $7/2/2009$ < 0.008 5Air $8/5/2009$ < 0.006 5Air $8/12/2009$ < 0.006 5Air $8/12/2009$ < 0.005 5Air $8/12/2009$ < 0.005 5Air $8/12/2009$ < 0.005 5Air $8/26/2009$ < 0.005 5Air $8/26/2009$ < 0.005 5Air $8/26/2009$ < 0.005 5Air $8/26/2009$ < 0.005	
5Air $6/3/2009$ < 0.004	
5Air $6/10/2009$ $<$ 0.007 5Air $6/17/2009$ $<$ 0.005 5Air $6/24/2009$ $<$ 0.006 5Air $7/1/2009$ $<$ 0.007 5Air $7/8/2009$ $<$ 0.005 5Air $7/15/2009$ $<$ 0.006 5Air $7/22/2009$ $<$ 0.008 5Air $7/29/2009$ $<$ 0.004 5Air $8/5/2009$ $<$ 0.006 5Air $8/12/2009$ $<$ 0.005 5Air $8/12/2009$ $<$ 0.005 5Air $8/12/2009$ $<$ 0.005 5Air $8/26/2009$ $<$ 0.005 5Air $8/26/2009$ $<$ 0.005 5Air $8/26/2009$ $<$ 0.005 5Air $8/26/2009$ $<$ 0.005 5Air $9/2/2009$ $<$ 0.011	
5Air $6/17/2009$ < 0.005 5Air $6/24/2009$ < 0.006 5Air $7/1/2009$ < 0.007 5Air $7/8/2009$ < 0.005 5Air $7/15/2009$ < 0.006 5Air $7/22/2009$ < 0.008 5Air $7/29/2009$ < 0.004 5Air $8/5/2009$ < 0.006 5Air $8/12/2009$ < 0.005 5Air $8/12/2009$ < 0.005 5Air $8/19/2009$ < 0.009 5Air $8/26/2009$ < 0.005 5Air $8/26/2009$ < 0.005 5Air $8/26/2009$ < 0.005 5Air $8/26/2009$ < 0.005 5Air $9/2/2009$ < 0.005	
5Air $6/24/2009$ < 0.006 5Air $7/1/2009$ < 0.007 5Air $7/8/2009$ < 0.005 5Air $7/15/2009$ < 0.006 5Air $7/22/2009$ < 0.008 5Air $7/29/2009$ < 0.004 5Air $8/5/2009$ < 0.006 5Air $8/12/2009$ < 0.006 5Air $8/12/2009$ < 0.005 5Air $8/12/2009$ < 0.009 5Air $8/26/2009$ < 0.005 5Air $8/26/2009$ < 0.005 5Air $9/2/2009$ < 0.011	
5Air $7/1/2009$ < 0.007	
5Air $7/8/2009$ < 0.005 5Air $7/15/2009$ < 0.006 5Air $7/22/2009$ < 0.008 5Air $7/29/2009$ < 0.004 5Air $8/5/2009$ < 0.006 5Air $8/12/2009$ < 0.005 5Air $8/12/2009$ < 0.009 5Air $8/26/2009$ < 0.005 5Air $8/26/2009$ < 0.005 5Air $8/26/2009$ < 0.005	
5Air $7/15/2009$ < 0.006	
5Air $7/22/2009$ < 0.008 5Air $7/29/2009$ < 0.004 5Air $8/5/2009$ < 0.006 5Air $8/12/2009$ < 0.005 5Air $8/19/2009$ < 0.009 5Air $8/26/2009$ < 0.005 5Air $9/2/2009$ < 0.011	
5Air $7/29/2009$ < 0.004 5Air $8/5/2009$ < 0.006 5Air $8/12/2009$ < 0.005 5Air $8/19/2009$ < 0.009 5Air $8/26/2009$ < 0.005 5Air $9/2/2009$ < 0.011	
5Air $8/5/2009$ < 0.006 5Air $8/12/2009$ < 0.005 5Air $8/19/2009$ < 0.009 5Air $8/26/2009$ < 0.005 5Air $9/2/2009$ < 0.011	
5 Air 8/12/2009 < 0.005	
5 Air 8/19/2009 < 0.009	
5 Air 8/26/2009 < 0.005	
5 Air 9/2/2009 < 0.011	
$5 \cdot 4ir = 0/9/2009 < 0.008$	
5 Air . 9/16/2009 < 0.007	
5 Air 9/23/2009 < 0.008	
5 Air 9/30/2009 < 0.005	
5 Air 10/7/2009 < 0.008	
5 Air 10/14/2009 < 0.011	
5 Air $10/21/2009 < 0.008$	
5 Air 10/28/2009 < 0.009	
5 Air 11/4/2009 < 0.009	
5 Air 11/11/2009 < 0.006	
5 Air 11/18/2009 < 0.008	· .
5 Air 11/25/2009 < 0.005	

Air Iodine Detail Report 2009

Radiological Environmental Monitoring Program Detail DataPerry Nuclear Power Plant, Lake County OhioDocket no. : 50-440/50-441Sample Frequency is: WeeklyResults in pCi/m3 +/- 2 Sigma

Location	Sample Type	Collection Date	I-131		
5	Air	12/2/2009	< 0.006	 	
5	Air	12/9/2009	< 0.005		
5	Air	12/16/2009	< 0.008		
5	Air	12/23/2009	< 0.006		
5	Air	12/30/2009	< 0.008		
6	Air	1/7/2009	< 0.008		
6	Air	1/14/2009	< 0.005		
6	Air	1/21/2009	< 0.009		
6	Air	1/28/2009	< 0.008		
6	Air	2/4/2009	< 0.004		
6	Air	2/11/2009	< 0.010		
6	Air	2/18/2009	< 0.004		
6	Air	2/25/2009	< 0.006		
6	Air	3/4/2009	< 0.005		
6	Air	3/11/2009	< 0.008		
6	Air	3/18/2009	< 0.008		
6	Air	3/25/2009	< 0.006		
6	Air	4/1/2009	< 0.006		
6	Air	4/8/2009	< 0.007		
6	Air	4/15/2009	< 0.009		
6	Air	4/22/2009	< 0.005		
6	Air	4/29/2009	< 0.004		
6	Air	5/6/2009	< 0.006		
6	Air	5/13/2009	< 0.007	,	
6	Air	5/20/2009	< 0.005		
6	Air	5/27/2009	< 0.006		
6	Air	6/3/2009	< 0.004		
6	Air	6/10/2009	< 0.008		
6	Air	6/17/2009	< 0.005		
6	Air	6/24/2009	< 0.007		
6	Air	7/1/2009	< 0.008		
6	Air	7/8/2009	< 0.006		
6	Air	7/15/2009	< 0.007		
6	Air	7/22/2009	< 0.009		

Air Iodine Detail Report 2009 Radiological Environmental Monitoring Program Detail Data Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Somple Ergeveney is Weekly Decults in pCi/m2 1/ 2 Sigme

Sample Frequency is: Weekly Results in pCi/m3 +/- 2 Sigma

Locatio	on Sample Type	Collection Date	I-131	
6	Air	7/29/2009	< 0.004	
6	Air	8/5/2009	< 0.007	
6	Air	8/12/2009	< 0.006	
6	Air	8/19/2009	< 0.009	
6	Air	8/26/2009	< 0.005	
6	Air	9/2/2009	< 0.012	
6	Air	9/9/2009	< 0.009	
6	Air	9/16/2009	< 0.007	
6	Air	9/23/2009	< 0.009	
6	Air	9/30/2009	< 0.006	
6	Air	10/7/2009	< 0.009	
6	Air	10/14/2009	< 0.012	
6	Air	10/21/2009	< 0.009	
6	Air	10/28/2009	< 0.009	
6	Air	11/4/2009	< 0.009	
6	Air	11/11/2009	< 0.006	
6	Air	11/18/2009	< 0.008	
6	Air	11/25/2009	< 0.005	
6	Air	12/2/2009	< 0.006	
6	Air	12/9/2009	< 0.005	
6	Air	12/16/2009	< 0.008	
6	Air	12/23/2009	< 0.006	
6	Air	12/30/2009	< 0.008	
7	Air	1/7/2009	< 0.008	
7	Air	1/14/2009	< 0.005	
7	Air	1/21/2009	< 0.009	
7	Air	1/28/2009	< 0.008	
7	Air	2/4/2009	< 0.004	
7	Air	2/11/2009	< 0.010	
7	Air	2/18/2009	< 0.004	
7	Air	2/25/2009	< 0.006	
7	Air	3/4/2009	< 0.005	
7	Air	3/11/2009	< 0.008	

Air Iodine Detail Report 2009

Radiological Environmental Monitoring Program Detail DataPerry Nuclear Power Plant, Lake County OhioDocket no. : 50-440/50-441Sample Frequency is: WeeklyResults in pCi/m3 +/- 2 Sigma

Location	Sample Type	Collection Date	I-131	
7	Air	3/18/2009	< 0.008	
7	Air	3/25/2009	< 0.006	
7	Air	4/1/2009	< 0.005	
7	Air	4/8/2009	< 0.007	
7	Air	4/15/2009	< 0.009	
7	Air	4/22/2009	< 0.005	
7	Air	4/29/2009	< 0.004	
7 ·	Air	5/6/2009	< 0.006	
7	Air	5/13/2009	< 0.007	
7	Air	5/20/2009	< 0.005	
7	Air	5/27/2009	< 0.006	
7	Air	6/3/2009	< 0.004	
7	Air	6/10/2009	< 0.008	
7	Air	6/17/2009	< 0.005	
7	Air	6/24/2009	< 0.007	
7	Air	7/1/2009	< 0.008	
7	Air	7/8/2009	< 0.005	
7	Air	7/15/2009	< 0.006	
7	Air	7/22/2009	< 0.008	
7	Air ·	7/29/2009	< 0.004	
7	Air	8/5/2009	< 0.006	
7	Air	8/12/2009	< 0.005	
7	Air	8/19/2009	< 0.009	
7	Air	8/26/2009	< 0.005	
7	Air	9/2/2009	< 0.011	
7	Air	9/9/2009	< 0.008	
7	Air	9/16/2009	< 0.007	
7	Air	9/23/2009	< 0.008	
7	Air	9/30/2009	< 0.005	
7	Air	10/7/2009	< 0.008	
7	Air	10/14/2009	< 0.012	
7	Air	10/21/2009	< 0.008	
7	Air	10/28/2009	< 0.009	
7	Air	11/4/2009	< 0.009	
7	Air	11/11/2009	< 0.006	

Air Iodine Detail Report 2009 Radiological Environmental Monitoring Program Detail Data Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Frequency is: Weekly Results in pCi/m3 +/- 2 Sigma

Location	Sample Type	Collection Date	I-131	
7	Air	11/18/2009	< 0.008	
7	Air	11/25/2009	< 0.005	
7	Air	12/2/2009	< 0.006	
. 7	Air	12/9/2009	< 0.005	
7	Air	12/16/2009	< 0.008	
7	Air	12/23/2009	< 0.006	
7	Air	12/30/2009	< 0.008	
35	Air	1/7/2009	< 0.009	
35	Air	1/14/2009	< 0.010	
35	Air	1/21/2009	< 0.009	
35	Air	1/28/2009	< 0.009	
35	Air	2/4/2009	< 0.005	
35	Air	2/11/2009	< 0.006	
35	Air	2/18/2009	< 0.007	
35	Air	2/25/2009	< 0.004	
35	Air	3/4/2009	< 0.005	
35	Air	3/11/2009	< 0.011	
35	Air	3/18/2009	< 0.007	
35	Air	3/25/2009	< 0.008	
35	Air	·. 4/1/2009	< 0.008	
35	Air	4/8/2009	< 0.010	
35	Air	4/15/2009	< 0.009	
35	Air	4/22/2009	< 0.021	
35	Air	4/29/2009	< 0.007	
35	Air	5/6/2009	< 0.009	
35	Air	5/13/2009	< 0.011	
35	Air	5/20/2009	< 0.010	
35	Air	5/27/2009	< 0.013	
35	Air	6/3/2009	< 0.010	
35	Air	6/10/2009	< 0.006	
35	Air	6/17/2009	< 0.008	
35	Air	6/24/2009	< 0.006	
35	Air	7/1/2009	< 0.010	

Air Iodine Detail Report 2009

Radiological Environmental Monitoring Program Detail DataPerry Nuclear Power Plant, Lake County OhioDocket no. : 50-440/50-441Sample Frequency is: WeeklyResults in pCi/m3 +/- 2 Sigma

Locatio	on Sample Type	Collection Date	I-131	
35	Air	7/8/2009	< 0.011	
35	Air	7/15/2009	< 0.012	
35	Air	7/22/2009	< 0.005	
35	Air	7/29/2009	< 0.008	
35	Air	8/5/2009	< 0.008	
35	Air	8/12/2009	< 0.011	
35	Air	8/19/2009	< 0.014	
35	Air	8/26/2009	< 0.010	
35	Air	9/2/2009	< 0.010	
35	Air	9/9/2009	< 0.012	
35	Air	9/16/2009	< 0.014	
35	Air	9/23/2009	< 0.006	
35	Air	9/30/2009	< 0.008	
35	Air	10/7/2009	< 0.008	·
35	Air	10/14/2009	< 0.010	
35	Air	10/21/2009	< 0.006	
35	Air	10/28/2009	< .0.006	
35	Air	11/4/2009	< 0.010	
35	Air	11/11/2009	< 0.006	
35	Air	11/18/2009	< 0.006	
35	Air	11/25/2009	< 0.015	
35	Air	12/2/2009	< 0.009	
35	Air	12/9/2009	< 0.007	
35	Air	12/16/2009	< 0.006	
35	Air	12/23/2009	< 0.008	
35	Air	12/30/2009	< 0.009	

Fish Gamma Spectral Detail Report 2009

Radiological Environmental Monitoring Program Detail Data

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Frequency is: Bi-Annually

Results in pCi/kg wet +/- 2 Sigma

Location	Sample Type	Collection Date	Co-58 K-40	Co-60 Mn-54	Cs-134 Zn-65	Cs-137	Fe-59
25	smallmouth bass	7/21/2009	< 16.17	< 12.68	< 20.61	< 20.18	< 57.79
			1,637.30 +/- 462.90	< 18.66	< 24.20		
25	white bass	7/21/2009	< 4.79	< 13.68	< 18.28	< 20.30	< 11.69
			846.93 +/- 284.90	< 13.46	< 10.60		
25	white perch	7/21/2009	< 14.31	< 8.54	< 19.72	< 21.13	< 40.02
			1,251.45 +/- 280.67	< 20.09	< 31.20		
25	yellow perch	7/21/2009	< 6.49	< 10.26	< 11.24	< 9.42	< 11.56
25	yenow peren		1,584.70 +/- 289.50	< 13.14	< 20.66	<). 	< 11.50
32	smallmouth bass	7/21/2009	< 22.35	< 12.96	< 18.24	< 20.14	< 39.59
			1,246.00 +/- 372.10	< 18.72	< 19.83		
32	white bass	7/21/2009	< 11.85	< 14.36	< 13.45	< 15.94	< 31.87
			1,197.30 +/- 287.40	< 9.76	< 36.15		
32	white perch	7/21/2009	< 8.63	< 11.21	< 11.49	< 14.77	< 25.48
	-		1,559.70 +/- 316.60	< 16.06	< 22.33		
32	yellow perch	7/21/2009	< 23.64	< 12.58	< 17.34	< 17.73	< 22.57
	· •		1,056.50 +/- 426.70	< 14.46	< 31.52		

Food Products Gamma Spectral Detail Report 2009

Radiological Environmental Monitoring Program Detail Data

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Frequency is: Monthly

Results in pCi/kg wet +/- 2 Sigma

Location	Sample Type	Collection Date	Be-7 I-131	Co-58 K-40	Co-60	Cs-134	Cs-137
2	collard greens	7/8/2009	< 71.74 < 14.75	< 5.93 4,687.90 +/- 293.10	< 4.87	< 5.58	< 7.98
2	kale	8/6/2009	< 126.01 < 14.84	< 7.67 4,706.60 +/- 332.20	< 8.48	< 8.07	< 8.58
2	swiss chard	8/6/2009	199.97 +/- 118.20 < 17.84	< 11.51 5,744.90 +/- 495.10	< 7.93	< 8.81	< 16.71
2	turnip greens	8/6/2009	315.66 +/- 113.90 < 11.41	< 8.59 5,772.30 +/- 368.30	< 7.92	< 9.03	< 12.21
2	kale	9/14/2009	< 107.99 < 17.74	< 5.59 4,730.80 +/- 343.70	< 9.35	< 9.31	< 10.08
2	swiss chard	9/14/2009	251.01 +/- 102.80 < 13.33	< 6.61 5,152.70 +/- 347.70	< 8.53	< 9.13	< 8.46
2	turnip greens	9/14/2009	201.01 +/- 98.54 < 16.79	< 9.67 4,937.20 +/- 338.40	< 9.57	< 7.66	< 12.35
2	collard greens	10/13/2009	529.71 +/- 136.10 < 25.64	< 12.05 4,615.40 +/- 353.40	< 8.32	< 12.51	< 11.53
2	swiss chard .	10/13/2009	551.51 +/- 123.20 < 19.84	< 9.17 6,013.30 +/- 386.40	< 10.20	< 11.32	< 13.12
2	turnip greens	10/13/2009	1,600.70 +/- 160.10 < 15.76	< 5.14 6,135.70 +/- 363.70	< 7.41	< 10.16	< 10.00
2	kale	11/10/2009	271.26 +/- 101.20 < 14.62	< 6.48 4,594.90 +/- 296.90	< 6.41	< 7.17	< 8.22

<u>C.20</u>

Food Products Gamma Spectral Detail Report 2009

Radiological Environmental Monitoring Program Detail Data

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Frequency is: Monthly Results in pCi/kg wet +/- 2 Sigma

Location	Sample Type	Collection Date	Be-7	0.50	a (a)		
			I-131	Co-58 K-40	Co-60	Cs-134	Cs-137
2	swiss chard	11/10/2009	530.50 +/- 119.10 < 18.64	< 9.68 6,382.60 +/- 336.10	< 7.18	< 7.94	< 9.57
16	beet greens	7/8/2009	131.24 +/- 76.63 < 17.05	< 9.21 5,756.80 +/- 362.10	< 5.98	< 8.17	< 10.04
16	swiss chard	7/8/2009	< 83.96 < 13.58	< 6.72 5,596.50 +/- 363.70	< 6.35	< 7.42	< 8.57
16	turnip greens	7/8/2009	< 107.15 < 18.00	< 10.19 5,521.30 +/- 354.90	< 4.91	< 9.36	< 7.74
16	collard greens	8/6/2009	< 69.89 < 18.69	< 8.60 4,206.70 +/- 292.90	< 7.14	< 8.16	< 7.77
16	swiss chard	8/6/2009	475.00 +/- 151.10 < 13.24	< 13.41 6.022.80 +/- 535.30	< 15.12	< 11.76	< 11.72
16	turnip greens	8/6/2009	433.41 +/- 105.30 < 13.76	< 4.33 4,784.00 +/- 334.40	< 6.81	< 7.44	< 6.28
16	beet greens	9/14/2009	348.28 +/- 116.20 < 16.91	< 7.93 5,821.70 +/- 369.40	< 8.45	< 8.42	< 11.70
16	collard greens	9/14/2009	< 97.21 < 16.87	< 10.19 4,641.70 +/- 388.10	< 6.60	< 10.57	< 12.02
16	swiss chard	9/14/2009	251.13 +/- 145.70 < 24.75	< 6.42 5,115.40 +/- 389.30	< 11.80	< 13.48	< 13.11

•

C-21

Food Products Gamma Spectral Detail Report 2009

Radiological Environmental Monitoring Program Detail Data

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Frequency is: Monthly Results

Results in pCi/kg wet +/- 2 Sigma

Location	Sample Type	Collection Date	Be-7 I-131	Co-58 K-40	Co-60	Cs-134	Cs-137
16	beet greens	10/13/2009	966.20 +/- 155.40 < 17.72	< 6.71 7,260.20 +/- 441.90	< 8.19	< 7.23	< 10.92
16	swiss chard	10/13/2009	432.12 +/- 107.10 < 15.39	< 2.64 5,379.60 +/- 357.70	< 10.99	< 7.25	< 7.86
16	turnip greens	10/13/2009	1,421.80 +/- 195.60 < 22.13	< 7.11 6,758.70 +/- 409.00	< 12.82	< 11.96	< 12.20
18	beet greens	8/6/2009	434.62 +/- 133.60 < 12.98	< 11.96 8,648.60 +/- 472.60	< 5.38	< 12.37	< 10.23
18	turnip greens	8/6/2009	510.99 +/- 152.30 < 15.48	< 8.88 5,426.50 +/- 377.30	< 11.85	< 12.24	< 11.77
18	beet greens	9/14/2009	446.75 +/- 164.90 < 23.68	< 13.79 10,368.00 +/- 491.20	< 13.38	< 9.93	< 13.23
18	collard greens	9/14/2009	< 81.25 < 14.98	< 7.45 5,554.40 +/- 313.20	< 8.27	< 7.59	< 8.58
18	swiss chard	9/14/2009	< 171.06 < 13.58	< 7.63 8,768.80 +/- 381.09	< 6.01	< 10.59	< 10.85
18	beet greens	10/13/2009	953.93 +/- 177.10 < 22.13	< 5.75 7,361.70 +/- 457.80	< 7.35	< 8.91	< 12.41
18	collard greens	10/13/2009	366.95 +/- 143.10 < 24.90	< 10.85 4,589.20 +/- 366.80	< 14.27	< 10.35	< 12.30

Food Products Gamma Spectral Detail Report 2009

Radiological Environmental Monitoring Program Detail Data

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Frequency is: Monthly Results in pCi/kg wet +/- 2 Sigma

Location	Sample Type	Collection Date	Be-7	Co-58	Co-60	Cs-134	Cs-137	
			I-131	K-40				
18	swiss chard	10/13/2009	519.45 +/- 133.50	< 12.67	< 7.22	< 9.76	< 11.51	
			< 17.43	5,730.80 +/- 405.30				
18	collard greens	11/10/2009	277.90 +/- 82.58	< 7.87	< 7.74	< 9.98	< 10.22	
			< 15.03	4,810.90 +/- 307.60				
18	swiss chard	11/10/2009	421.49 +/- 117.10	< 9.00	< 11.74	< 7.61	< 9.13	
			< 13.81	6,967.00 +/- 390.70				
18	turnip greens	11/10/2009	639.27 +/- 123.30	< 4.67	< 6.16	< 8.11	< 11.34	
			< 19.01	4,859.50 +/- 329.60				
20	turnip greens	8/6/2009	395.95 +/- 124.00	< 9.59	< 6.14	< 10.15	< 13.69	
			< 14.47	6,082.90 +/- 367.80		10.12	19109	
20	turnip greens	9/14/2009	402.35 +/- 107.00	< 7.33	< 8.82	< 9.33	< 9.55	
			< 18.56	5,284.70 +/- 347.30				
20	turnip greens	10/13/2009	1,136.50 +/- 143.60	< 9.70	< 6.75	< 8.65	< 11.60	
			< 21.82	5,541.90 +/- 371.20				
20	turnip greens	11/10/2009	1,301.60 +/- 148.90	< 4.83	< 6.80	< 8.02	< 11.60	
			< 14.74	4,953.90 +/- 331.00				
37	beet greens	7/8/2009	< 110.43	< 8.86	< 11.86	< 10.80	< 10.11	
			< 15.28	7,335.10 +/- 419.40				
37	collard greens	7/8/2009	< 98.01	< 5.01	< 5.82	< 7.06	< 9.79	
			< 15.09	4.023.40 +/- 286.20				

Food Products Gamma Spectral Detail Report 2009

Radiological Environmental Monitoring Program Detail Data

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Frequency is: Monthly R

Results in pCi/kg wet +/- 2 Sigma

Location	Sample Type	Collection Date	Be-7 I-131	Co-58 K-40	Co-60	Cs-134	Cs-137
37	turnip greens	7/8/2009	144.69 +/- 71.55 < 16.46	< 8.91 5,838.70 +/- 330.30	< 4.33	< 7.98	< 7.19
37	beet greens	8/6/2009	265.40 +/- 131.40 < 111.86	< 7.97 5,325.30 +/- 361.80	< 12.23	< 9.48	< 8.40
37	collard greens	8/6/2009	< 85.51 < 11.00	< 4.81 3,724.30 +/- 322.50	< 9.36	< 10.21	< 9.01
37	swiss chard	8/6/2009	215.31 +/- 128.70 < 13.49	< 5.33 6,465.40 +/- 386.70	< 6.34	< 7.44	< 9.50
37	beet greens	9/14/2009	375.37 +/- 109.40 < 17.49	< 10.06 5,961.00 +/- 341.60	< 11.16	< 9.57	< 10.64
37	swiss chard	9/14/2009	347.57 +/- 124.10 < 19.07	< 5.92 5,801.20 +/- 405.00	< 10.41	< 9.45	< 15.01
37	turnip greens	9/14/2009	463.36 +/- 159.40 < 24.55	< 11.42 6,006.70 +/- 405.90	< 11.62	< 10.53	< 14.05
37	beet greens	10/13/2009	774.79 +/- 153.90 < 12.94	< 10.60 5,023.70 +/- 367.10	< 7.14	< 8.12	< 9.18
37	collard greens	10/13/2009	256.99 +/- 100.60 < 14.24	< 8.13 3,120.70 +/- 270.00	< 6.01	< 7.86	< 10.51
37	swiss chard	10/13/2009	623.25 +/- 144.10 < 19.45	< 11.59 6,435.90 +/- 424.30	< 15.56	< 14.56	< 8.25
37	collard greens	11/10/2009	< 120.48 < 12.74	< 8.20 3,043.25 +/- 186.11	< 5.33	< 5.27	< 9.37

Food Products Gamma Spectral Detail Report 2009

Radiological Environmental Monitoring Program Detail Data

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Frequency is: Monthly Results in pCi/kg wet +/- 2 Sigma

Location	Sample Type	Collection Date	Be-7 I-131	Co-58 K-40	Co-60	Cs-134	Cs-137
37	swiss chard	11/10/2009	685.06 +/- 105.30 < 10.21	< 8.52 6,531.00 +/- 363.10	< 9.92	< 9.87	< 9.95
37	turnip greens	11/10/2009	1,313.10 +/- 148.70 < 14.16	< 11.84 4,870.50 +/- 337.30	< 9.95	< 8.38	< 9.90
70	beet greens	8/6/2009	365.69 +/- 87.96	< 6.83	. < 8.83	< 5.91	< 10.48
			< 7.64	5,988.50 +/- 321.20			
. 70	collard greens	8/6/2009	< 66.96 < 17.82	< 3.85 3,943.50 +/- 338.50	< 7.11	< 8.89	< 10.18
70	turnip greens	8/6/2009	963.97 +/- 139.80	< 11.31	< 12.54	< 6.76	< 10.66
			< 12.06	5,214.40 +/- 353.50			
70	beet greens	9/14/2009	636.67 +/- 127.20	< 8.39	< 7.37	< 7.91	< 10.95
			< 15.03	9,186.10 +/- 436.70			
70	collard greens	9/14/2009	232.78 +/- 119.80	< 4.73	< 6.95	< 10.02	< 11.69
			< 21.37	4,131.60 +/- 328.10			
70	swiss chard	9/14/2009	350.48 +/- 112.20	< 7.70	< 8.43	< 9.68	< 9.74
			< 16.41	7,690.70 +/- 396.80			
70	collard greens	10/13/2009	607.41 +/- 138.99	< 9.53	< 7.72	< 7.01	< 10.72
			< 14.27	4,495.80 +/- 335.84			
70	swiss chard	10/13/2009	570.71 +/- 164.70	< 10.80	< 15.73	< 13.35	< 16.68
			< 27.15	8,332.20 +/- 490.50			

.

Food Products Gamma Spectral Detail Report 2009

Radiological Environmental Monitoring Program Detail Data

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Frequency is: Monthly Results in

Results in pCi/kg wet +/- 2 Sigma

Location	Sample Type	Collection Date	Be-7 I-131	Co-58 K-40	Co-60	Cs-134	Cs-137
70	turnip greens	10/13/2009	1,461.80 +/- 205.80 < 24.10	< 13.33 5,118.10 +/- 383.50	< 6.12	< 12.19	< 11.48
70	collard greens	11/10/2009	332.88 +/- 153.20 < 18.83	< 8.19 3,466.80 +/- 299.50	< 6.05	< 11.47	< 7.06
70	swiss chard	11/10/2009	585.94 +/- 104.30 < 15.84	< 9.07 9,161.60 +/- 415.90	< 9.12	< 7.49	< 10.00
70	turnip greens	11/10/2009	1,438.50 +/- 167.80 < 20.29	< 8.05 4,617.70 +/- 386.90	< 11.88	< 10.70	< 8.00

.

. .

Milk Gamma Spectral Detail Report 2009

Radiological Environmental Monitoring Program Detail Data

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Location	Sample Type	Collection Date	Ba-140	Cs-134	Cs-137	K-40	La-140	
18	Milk	4/6/2009	< 15	< 4	< 4	1,750 +/- 112	< 3	
18	Milk	4/20/2009	< 12	< 3	< 4	1,775 +/- 126	< 2	
18	Milk	5/4/2009	< 15	< 3	< 4	1,909 +/- 121	< 3	
18	Milk	5/18/2009	< 15	< 2	< 2	1,831 +/- 131	. < 2	
18	Milk	6/1/2009	< 19	< 4	< 4	1,873 +/- 133	< 4	
18	Milk	6/16/2009	< 19	< 3	< 3	1,786 +/- 125	< 2	
18	Milk	7/6/2009	< 13	< 3	< 4	1,728 +/- 133	< 3	
18	Milk	7/20/2009	< 18	< 4	< 3	1,875 +/- 125	< 3	
18	Milk	8/3/2009	< 12	< 4	< 5	1,982 +/- 140	< 3	
18	Milk	8/17/2009	< 17	< 3	< 4	2,058 +/- 138	< 3	
18	Milk	9/8/2009	< 11	< 4 .	< 4	1,950 +/- 130	< 2	

Milk Gamma Spectral Detail Report 2009

Radiological Environmental Monitoring Program Detail Data

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Location	Sample Type	Collection Date	Ba-140	Cs-134	Cs-137	K-40	La-140
18	Milk	9/21/2009	< 16	< 4	< 5	1,987 +/- 137	< 3
18	Milk	10/5/2009	< 24	< 3	< 5	1,924 +/- 134	< 3
						1,924 17 134	
18	Milk	10/19/2009	< 10	< 3	< 4	2,095 +/- 136	< 3
18	Milk	11/2/2009	< 19	< 3	< 3	1.782 +/- 125	< 2
18	Milk	12/7/2009	< 15	< 3	< 4	1,471 +/- 115	< 2
41	Milk	4/6/2009	< 11	< 2	< 3	1,552 +/- 81	< 3
41	Milk	4/20/2009	< 14	< 2	< 3	1,795 +/- 112	< 4
41	Milk	5/4/2009	< 12	< 3	< 2	1,741 +/- 119	< 2
41	Milk	5/18/2009	< 21	< 4	< 4	1,709 +/- 113	< 5
41	Milk	6/1/2009	< 18	< 4	< 3	1,809 +/- 138	< 6

Milk Gamma Spectral Detail Report 2009

Radiological Environmental Monitoring Program Detail Data

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Location	Sample Type	Collection Date	Ba-140	Cs-134	Cs-137	K-40	La-140
-							
41	Milk	6/16/2009	< 17	< 3	< 4	1,882 +/- 127	< 2
41	Milk	7/6/2009	< 19	< 3	< 4	1,729 +/- 129	< 4
41	Milk	7/20/2009	< 15	< 2	< 4	1,661 +/- 107	< 2
41	Milk	8/3/2009	< 20	< 3	< 3	1,954 +/- 130	< 5
41	[.] Milk	8/17/2009	< 11	< 3	< 3	1,752 +/- 129	< 4
41	Milk	9/8/2009	< 21	< 2	< 4	1,703 +/- 130	< 4
					·		
51	Milk	1/5/2009	< 22	< 4	< 4	1,331 +/- 117	< 5
51	Milk	2/2/2009	< 20	< 5	< 7	565 +/- 114	< 4
51	´ Milk	3/2/2009	< 13	< 3	< 4	1,322 +/- 115	< 2
51	Milk	4/6/2009	< 18	< 3	< 4	1,217 +/- 106	< 3

Milk Gamma Spectral Detail Report 2009

Radiological Environmental Monitoring Program Detail Data

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Frequency is: Bi-Monthly Results in pCi/L +/- 2 Sigma

Location	Sample Type	Collection Date	Ba-140	Cs-134	Cs-137	K-40	La-140	
51	Milk	4/20/2009	< 15	< 4	< 5	1,439 +/- 119	< 4	
51	Milk	5/4/2009	< 13	< 2	< 3	1,322 +/- 103	< 2	
51	Milk	5/18/2009	< 30	< 5	< 4	1,375 +/- 119	< 7	
51	Milk	6/1/2009	< 19	< 2	< 3	1,406 +/- 118	< 2	
51	Milk	6/16/2009	< 12	< 2	< 3	1,404 +/- 105	< 4	
51	Milk	7/6/2009	< 17	< 2	< 3	1,244 +/- 92	< 2	
51	Milk	7/20/2009	< 16	< 3	< 4	1,354 +/- 110	< 3	
51	Milk	8/3/2009	< 10	< 2	< 3	967 +/- 95	< 3	
51	Milk	8/17/2009	< 14	< 3	< 3	930 +/- 85	< 4	
51	Milk	9/8/2009	< 15	< 3	< 2	1,332 +/- 113	< 2	
51	Milk	9/21/2009	< 13	< 3	.< 2	1,269 +/- 109	< 2	

•

Milk Gamma Spectral Detail Report 2009

Radiological Environmental Monitoring Program Detail Data

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Frequency is: Bi-Monthly R

Results in pCi/L +/- 2 Sigma

_	Location	Sample Type	Collection Date	Ba-140	Cs-134	Cs-137	K-40	La-140	
	51	Milk	10/5/2009	< 11	< 3	< 4	1,328 +/- 104	< 3	
	51	Milk	10/19/2009	< 12	< 3	< 4	1,133 +/- 90	< 3	
	51	Milk	11/2/2009	< 21	< 3	< 3	1,150 +/- 99	. < 4	
	51	Milk	12/7/2009	< 13	< 4	< 3	1,266 +/- 108	< 3	
	61	Milk	5/4/2009	< 10	< 3	< 4	1,679 +/- 116	< 2	
	61	Milk	5/18/2009	< 24	< 5	< 4	1,747 +/- 126	< 4	
	61	Milk	6/1/2009	< 17	< 4	< 4	1,673 +/- 130	< 3	
	61	Milk	6/16/2009	< 20	< 4	< 4	1,844 +/- 125	< 3	
	61	Milk	7/7/2009	< 21	< 3	< 4	1,899 +/- 127	< 3	
	61	Milk	7/20/2009	< 27	< 3	< 4	1,855 +/- 128	< 4	

ŧ

Milk Gamma Spectral Detail Report 2009

Radiological Environmental Monitoring Program Detail Data

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Location	Sample Type	Collection Date	Ba-140	Cs-134	Cs-137	K-40	La-140	
61	Milk	8/3/2009	< 16	< 3	< 4	1,956 +/- 99	< 3	
61	Milk	8/17/2009	< 25	< 2	< 5	2,044 +/- 139	< 4	
61	Milk	9/8/2009	< 19	< 3	< 3	1,980 +/- 138	< 3	
61	Milk	9/21/2009	< 17	< 3	< 3	1,928 +/- 127	< 2	
61	Milk	10/5/2009	< 24	< 3	< 5	1,979 +/- 128	< 3	
61	Milk	10/19/2009	< 18	< 3	< 4	1,997 +/- 137	< 2	
61	Milk	11/2/2009	< 25	< 2	< 4	1,744 +/- 124	< 2	

Milk Iodine Detail Report 2009

Radiological Environmental Monitoring Program Detail DataPerry Nuclear Power Plant, Lake County OhioDocket no. : 50-440/50-441Sample Frequency is: Bi-MonthlyResults in pCi/L +/- 2 Sigma

Location	Sample Type	Collection Date	I-131		
18	Milk	4/6/2009	< 0.42	· · · · · · · · · · · · · · · · · · ·	
18	Milk	4/20/2009	< 0.23		
18	Milk	5/4/2009	< 0.36		
18	Milk	5/18/2009	< 0.47		
18	Milk	6/1/2009	< 0.38		
18	Milk	6/16/2009	< 0.31		
18	Milk	7/6/2009	< 0.34		
18	Milk	7/20/2009	< 0.37		
18	Milk	8/3/2009	< 0.32		
18	Milk	8/17/2009	< 0.46		
18	Milk	9/8/2009	< 0.29		
18	Milk	9/21/2009	< 0.24		
18	Milk	10/5/2009	< 0.21		
18	Milk	10/19/2009	< 0.30		
18	Milk	11/2/2009	< 0.32		
18	Milk	12/7/2009	< 0.25		
41	Milk	1/5/2009			
41	Milk	2/2/2009			
41	Milk	3/2/2009			
41 ·	Milk	4/6/2009	< 0.35		
41	Milk	4/20/2009	< 0.36		
41	Milk	5/4/2009	< 0.36		
41	Milk	5/18/2009	< 0.38		
41	Milk	6/1/2009	< 0.34	· · · · · · · · · · · · · · · · · · ·	
41	Milk	6/16/2009	< 0.28		
41	Milk	7/6/2009	< 0.34		
41	Milk	7/20/2009	< 0.39		
41	Milk	8/3/2009	< 0.32		
41	Milk	8/17/2009	< 0.44		
41	Milk	9/8/2009	< 0.35		
51	Milk	1/5/2009	< 0.38		
51	Milk	2/2/2009	< 0.33		

Milk Iodine Detail Report 2009

Radiological Environmental Monitoring Program Detail DataPerry Nuclear Power Plant, Lake County OhioDocket no. : 50-440/50-441Sample Frequency is: Bi-MonthlyResults in pCi/L +/- 2 Sigma

Location	Sample Type	Collection Date	I-131		
51	Milk	3/2/2009	< 0.30		· · · · · · · · · · · · · · · · · · ·
51	Milk	4/6/2009	< 0.27		
51	Milk	4/20/2009	< 0.26		
51	Milk	5/4/2009	< 0.37		
51	Milk	5/18/2009	< 0.39		
51	Milk	6/1/2009	< 0.29		
51	Milk	6/16/2009	< 0.31		
51	Milk	7/6/2009	< 0.40		
51	Milk	7/20/2009	< 0.33		
51	Milk	8/3/2009	< 0.37		
51	Milk	8/17/2009	< 0.44		
51	Milk	9/8/2009	< 0.39		
51	Milk	9/21/2009	< 0.29		
51	Milk	10/5/2009	< 0.33		
51	Milk	10/19/2009	< 0.32		
51	Milk	11/2/2009	< 0.47		
51	Milk	12/7/2009	< 0.25		
61	Milk	1/5/2009			
61	Milk	2/2/2009			
61	Milk	3/2/2009			
61	Milk	4/6/2009			
61	Milk	4/20/2009			
61	Milk	5/4/2009	< 0.36		
61	Milk	5/18/2009	< 0.36		
61	Milk	6/1/2009	< 0.44		
61	Milk	6/16/2009	< 0.28		
61	Milk	7/7/2009	< 0.30		
61	Milk	7/20/2009	< 0.32		
61	Milk	8/3/2009	< 0.42		
61	Milk	8/17/2009	< 0.36	· · · ·	
61	Milk	9/8/2009	< 0.37		
61	Milk	9/21/2009	< 0.32		
61	Milk	10/5/2009	< 0.22		
61	Milk	10/19/2009	< 0.30		

Milk Iodine Detail Report 2009Radiological Environmental Monitoring Program Detail DataPerry Nuclear Power Plant, Lake County OhioDocket no. : 50-440/50-441Sample Frequency is: Bi-MonthlyResults in pCi/L +/- 2 Sigma

Location	Sample Type	Collection Date	I-131	
61	Milk	11/2/2009	< 0.31	
				· .
		N.		
		· · · ·		
		·.		
			•	
		• •		
		•		

Sediment Gamma Spectral Detail Report 2009

Radiological Environmental Monitoring Program Detail Data

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Frequency is: Bi-Annually Results in pCi/kg dry +/- 2 Sigma

							·······
Location	Sample Type	Collection Date	Co-58	Co-60	Cs-134	Cs-137	K-40
25	Sediment	6/15/2009	< 23.72	< 16.60	< 17.18	LLD	11,058.00 +/- 609.30
23	Sediment	0/13/2009	< 23.12	< 10.00	< 17.18	LLD	11,038.00 +/- 009.30
25	Sediment	10/6/2009	< 20.87	< 6.31	< 10.51	301.33 +/- 19.50	16,865.00 +/- 442.25
26	Sediment	6/15/2009	< 19.84	< 13.78	< 15.97	LLD	13,355.00 +/- 751.30
26	Sediment	10/6/2009	< 25.10	< 14.63	< 15.76	LLD	14,895.00 +/- 698.50
27	Sediment	6/15/2009	< 27.60	< 20.38	< 23.28	LLD	15,120.00 +/- 799.20
27	Sediment	10/6/2009	< 27.48	< 16.12	< 22.86	341.42 +/- 51.27	23,037.00 +/- 922.80
32	Sediment	6/15/2009	< 38.12	< 36.50	< 44.08	678.91 +/- 68.42	24,592.00 +/- 1,294.00
32	Sediment	10/6/2009	< 35.04	< 36.90	< 34.66	699.30 +/- 65.48	23,808.00 +/- 1,195.00
52	Soument	101012009	- 55.01	× 30.20			25,000.00 -7- 1,155.00
64	Sediment	6/18/2009	< 18.85	< 17.01	< 21.12	< 14.71	8,974.80 +/- 642.40

. . .

Sediment Gamma Spectral Detail Report 2009

Radiological Environmental Monitoring Program Detail Data

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Frequency is: Bi-Annually Results in pCi/kg dry +/- 2 Sigma

Location	Sample Type	Collection Date	Co-58	Co-60	Cs-134	Cs-137	K-40
		`					
64	Sediment	10/13/2009	< 11.73	< 8.65	< 7.70	< 11.39	7,208.50 +/- 438.70
65	Sediment	10/13/2009	< 8.72	< 9.83	< 9.22	< 14.89	8,902.10 +/- 490.40
			·	•			•
				· .			

TLD Gamma Dose Detail Report 2009

Radiological Environmental Monitoring Program Detail Data

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Location	Sample Type	Collection Period		Expos	sure				
1	TLD	1/6/2009 to 4/1	10/2009	10.92	+/-	0.69	 	· · · · · ·	
1	TLD	4/10/2009 to 7/	/1/2009	9.56	+/-	0.80			
1	TLD	7/1/2009 to 10/	/8/2009	11.16	+/-	0.76			
1	TLD	10/8/2009 to 1/1	13/2010	9.88	+/-	1.04			
3	TLD	1/6/2009 to 4/1	10/2009	11.21	+/-	0.63			
3	TLD	4/10/2009 to 7/	/1/2009	10.39	+/-	1.02			
3	TLD	7/1/2009 to 10/	/8/2009	11.72	+/-	0.67			
3	TLD	10/8/2009 to 1/1	13/2010	11.25	+/-	0.59			
4	TLD	1/6/2009 to 4/1	10/2009	11.86	+/-	0.51			·
4	TLD	4/10/2009 to 7/	/1/2009	12.03	+/-	0.61			
4	TLD	7/1/2009 to 10/	/8/2009	12.38	+/-	0.55			
4	TLD	10/8/2009 to 1/1	13/2010	12.03	+/-	0.57			
5	TLD	1/6/2009 to 4/1	10/2009	10.76	+/-	0.46			
5	TLD	4/10/2009 to 7/	/1/2009	11.34	+/-	0.56			
5	TLD	7/1/2009 to 10/	/8/2009	11.74	+/-	1.10			
5	TLD	10/8/2009 to 1/1	13/2010	11.96	+/-	0.75			
6	TLD	1/6/2009 to 4/1	10/2009	12.23	+/-	0.56		-	
6	TLD	4/10/2009 to 7/	/1/2009	12.99	+/-	0.55			
6	TLD	7/1/2009 to 10/	/8/2009	13.40	+/-	0.85			
6	TLD	10/8/2009 to 1/1	13/2010	13.07	+/-	0.61			
7	TLD	1/6/2009 to 4/1	10/2009	11.89	+/-	0.55			
7	TLD	4/10/2009 to 7/	/1/2009	11.97	+/-	0.64			
7	TLD	7/1/2009 to 10/	/8/2009	12.99	+/-	0.70			
7	TLD	10/8/2009 to 1/1	13/2010	12.87	+/-	0.69			
8	TLD	1/6/2009 to 4/1	10/2009	10.87	+/-	0.73			
8	TLD	4/10/2009 to 7/	/1/2009	11.89	+/-	0.84			
8	TLD	7/1/2009 to 10/	/8/2009	11.53	+/-	0.72			
8	TLD	10/8/2009 to 1/1	13/2010	12.01	+/-	0.52			
9	TLD	1/6/2009 to 4/1	10/2009	10.43	+/-	0.43			

TLD Gamma Dose Detail Report 2009

Radiological Environmental Monitoring Program Detail Data

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Location	Sample Type	Collection Period	Exposure	
9	TLD	4/10/2009 to 7/1/2009	10.73 +/- 0.62	
9	TLD	7/1/2009 to 10/8/2009	11.43 +/- 0.45	
9	TLD	10/8/2009 to 1/13/2010	11.31 +/- 0.59	
10	TLD	1/6/2009 to 4/10/2009	13.61 +/- 1.53	
10	TLD	4/10/2009 to 7/1/2009	14.48 +/- 0.76	
10	TLD	7/1/2009 to 10/8/2009	14.29 +/- 0.47	
10	TLD	10/8/2009 to 1/13/2010	14.46 +/- 0.83	
11	TLD	1/6/2009 to 4/10/2009	12.95 +/- 0.55	
11	TLD	4/10/2009 to 7/1/2009	12.73 +/- 0.54	
11	TLD	7/1/2009 to 10/8/2009	14.12 +/- 0.67	
11	TLD	10/8/2009 to 1/13/2010	12.86 +/- 0.57	
12	TLD	1/6/2009 to 4/10/2009	11.77 +/- 0.57	
12	TLD	4/10/2009 to 7/1/2009	11.71 +/- 0.73	
12	TLD	7/1/2009 to 10/8/2009	12.91 +/- 0.70	
12	TLD	10/8/2009 to 1/13/2010	12.74 +/- 0.79	
13	TLD	1/6/2009 to 4/10/2009	12.53 +/- 0.49	
13	TLD	4/10/2009 to 7/1/2009	12.08 +/- 0.98	
13	TLD	7/1/2009 to 10/8/2009	12.75 +/- 0.74	
13	TLD	10/8/2009 to 1/13/2010	12.52 +/- 0.85	
14	TLD	1/6/2009 to 4/10/2009	10.76 +/- 0.57	
14	TLD	4/10/2009 to 7/1/2009	11.28 +/- 0.62	
14	TLD	7/1/2009 to 10/8/2009	11.63 +/- 0.57	
14	TLD	10/8/2009 to 1/13/2010	11.58 +/- 0.63	
15	TLD	1/6/2009 to 4/10/2009	10.33 +/- 0.65	
- 15	TLD	4/10/2009 to 7/1/2009	8.27 +/- 1.29	
15	TLD	7/1/2009 to 10/8/2009	11.00 +/- 0.51	
15	TLD	10/8/2009 to 1/13/2010	8.26 +/- 0.62	
21	TLD	1/6/2009 to 4/10/2009	12.49 +/- 0.62	
21	TLD	4/10/2009 to 7/1/2009	13.16 +/- 0.78	
21	TLD	7/1/2009 to 10/8/2009	14.00 +/- 0.52	

TLD Gamma Dose Detail Report 2009

Radiological Environmental Monitoring Program Detail Data

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Location	Sample Type	Collection	Per	iod	Expos	ure	
21	TLD	10/8/2009	to	1/13/2010	13.42	+/-	0.67
23	TLD	1/6/2009	to	4/10/2009	13.59	+/-	0.68
23	TLD	4/10/2009	to	7/1/2009	13.57	+/-	0.70
23	TLD	7/1/2009	to	10/8/2009	15.01	+/-	0.54
23	TLD	10/8/2009	to	1/13/2010	14.16	+/-	0.98
24	TLD	1/6/2009	to	4/10/2009	11.62	+/-	0.64
24	TLD	4/10/2009	to	7/1/2009	11.87	+/-	0.82
24	TLD	7/1/2009	to	10/8/2009	12.11	+/-	0.64
24	TLD	10/8/2009	to	1/13/2010	12.50	+/-	0.68
29	TLD	1/6/2009	to	4/10/2009	15.02	+/-	0.74
29	TLD	4/10/2009	to	7/1/2009	15.90	+/-	0.57
29	TLD	7/1/2009	to	10/8/2009	16.57	+/-	0.59
29	TLD	10/8/2009	to	1/13/2010	15.52	+/-	0.66
30	TLD	1/6/2009	to	4/10/2009	13.61	+/-	0.71
30	TLD	4/10/2009	to	7/1/2009	14.67	+/-	0.51
30	TLD	7/1/2009	to	10/8/2009	15.11	+/-	0.64
30	TLD	10/8/2009	to	1/13/2010	14.73	+/-	0.60
31	TLD	1/6/2009	to	4/10/2009	13.99	+/-	0.62
31	TLD	4/10/2009	to	7/1/2009	15.96	+/-	0.56
31	TLD	7/1/2009	tó	10/8/2009	15.56	+/-	0.87
31	TLD	10/8/2009	to	1/13/2010	16.08	+/-	0.65
33	TLD	1/6/2009	to	4/10/2009	15.42	+/-	0.82
33	TLD	4/10/2009	to	7/1/2009	17.48	+/-	0.72
33	TLD	7/1/2009	to	10/8/2009	17.19	+/-	0.73
33	TLD	10/8/2009	to	1/13/2010	16.84	+/-	0.52
35	TLD	1/6/2009	to	4/10/2009	11.01	+/-	0.56
35	TLD	4/10/2009	to	7/1/2009	11.59	+/-	0.51
35	TLD	7/1/2009	to	10/8/2009	12.35	+/-	0.63
35	TLD	10/8/2009	to	1/13/2010	11.76	+/-	0.60

TLD Gamma Dose Detail Report 2009

Radiological Environmental Monitoring Program Detail Data

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Location	Sample Type	Collection Period	Exposure	
36	TLD	1/6/2009 to 4/10/2009	14.50 +/- 0.75	
36	TLD	4/10/2009 to 7/1/2009	15.96 +/- 0.66	
36	TLD	7/1/2009 to 10/8/2009	16.62 +/- 0.80	
36	TLD	10/8/2009 to 1/13/2010	15.42 +/- 0.51	
53	TLD	1/6/2009 to 4/10/2009	11.63 +/- 0.57	
53	TLD	4/10/2009 to 7/1/2009	13.56 +/- 1.66	
53	TLD	7/1/2009 to 10/8/2009	13.80 +/- 0.58	
53	TLD	10/8/2009 to 1/13/2010	13.36 +/- 0.69	
54	TLD	1/6/2009 to 4/10/2009	11.59 +/- 0.76	
54	TLD	4/10/2009 to 7/1/2009	12.28 +/- 0.54	
54	TLD	7/1/2009 to 10/8/2009	12.82 +/- 0.89	·
54	TLD	10/8/2009 to 1/13/2010	12.26 +/- 0.56	
55	TLD	1/6/2009 to 4/10/2009	12.12 +/- 1.42	
55	TLD	4/10/2009 to 7/1/2009	13.67 +/- 1.10	
55	TLD	7/1/2009 to 10/8/2009	14.11 +/- 1.41	
55	TLD	10/8/2009 to 1/13/2010	13.45 +/- 1.09	
56	TLD	1/6/2009 to 4/10/2009	11.73 +/- 0.61	
56	TLD	4/10/2009 to 7/1/2009	13.42 +/- 0.83	
56	TLD	7/1/2009 to 10/8/2009	13.12 +/- 0.58	
56	TLD	10/8/2009 to 1/13/2010	13.08 +/- 0.94	
58	TLD	1/6/2009 to 4/10/2009	9.67 +/- 0.53	
58	TLD	4/10/2009 to 7/1/2009	11.06 +/- 0.62	
58	TLD	7/1/2009 to 10/8/2009	10.84 +/- 0.52	
58	TLD	10/8/2009 to 1/13/2010	11.12 +/- 0.73	

TLD Gamma Dose Detail Report 2009

Radiological Environmental Monitoring Program Detail DataPerry Nuclear Power Plant, Lake County OhioDocket no. : 50-440/50-441Sample Frequency is:QuarterlyResults in mR/91 days +/- 2 Sigma

Location	Sample Type	Collection Period	Exposure		
1	TLB	1/6/2009 to 4/10/2009	9.31 +/- 0.66		
1	TLB	4/10/2009 to 7/1/2009	10.03 +/- 0.85		
1	TLB	7/1/2009 to 10/8/2009	10.64 +/- 0.91		
1	TLB	10/8/2009 to 1/13/2010	10.60 +/- 1.22		
3	TLB	1/6/2009 to 4/10/2009	10.13 +/- 0.56		
3	TLB	4/10/2009 to 7/1/2009	9.81 +/- 0.78		
3	TLB	7/1/2009 to 10/8/2009	12.06 +/- 0.54		
3	TLB	10/8/2009 to 1/13/2010	11.03 +/- 0.92		
4	TLB	1/6/2009 to 4/10/2009	10.88 +/- 0.50		
4	TLB	4/10/2009 to 7/1/2009	12.27 +/- 0.73		
4	TLB				
			12.84 +/- 0.57		
4	TLB	10/8/2009 to 1/13/2010	13.41 +/- 0.75		
5	TLB	1/6/2009 to 4/10/2009	10.98 +/- 0.59		
5	TLB	4/10/2009 to 7/1/2009	11.31 +/- 0.92		
5	TLB	7/1/2009 to 10/8/2009	12.55 +/- 0.59		
5	TLB	10/8/2009 to 1/13/2010	12.38 +/- 0.85		
				2	
6	TLB	1/6/2009 to 4/10/2009	10.74 +/- 0.58		
6	TLB	4/10/2009 to 7/1/2009	12.17 +/- 0.75		
6	TLB	7/1/2009 to 10/8/2009	13.03 +/- 0.52		
6	TLB	10/8/2009 to 1/13/2010	13.33 +/- 0.81		
			-		
7	TLB	1/6/2009 to 4/10/2009	11.50 +/- 0.66		
7	TLB	4/10/2009 to 7/1/2009	13.29 +/- 0.71		
7	TLB	7/1/2009 to 10/8/2009	13.36 +/- 0.61		
7	TLB	10/8/2009 to 1/13/2010	14.17 +/- 1.35		
8	TLB	1/6/2009 to 4/10/2009	10.51 +/- 0.63		
8	TLB	4/10/2009 to 7/1/2009			
	TLB				
8		7/1/2009 to $10/8/2009$	12.21 +/- 0.47		
8	TLB	10/8/2009 to 1/13/2010	12.64 +/- 0.77		
9	TLB	1/6/2009 to 4/10/2009	10.07 +/- 0.58		
9	TLB	4/10/2009 to 7/1/2009	10.88 +/- 0.75		

TLD Gamma Dose Detail Report 2009

Radiological Environmental Monitoring Program Detail Data Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Location	Sample Type	Collection Period	Exposure	
9	TLB	7/1/2009 to 10/8/2009	12.21 +/-	0.61
· 9 ·	TLB	10/8/2009 to 1/13/2010	12.36 +/-	1.23
10	TLB	1/6/2009 to 4/10/2009	12.12 +/-	0.50
10	TLB	4/10/2009 to 7/1/2009	14.37 +/-	0.73
10	TLB	7/1/2009 to 10/8/2009	15.22 +/-	0.60
10	TLB	10/8/2009 to 1/13/2010	15.21 +/-	0.94
11		1/6/2020 / //10/2020		1.00
11	TLB	1/6/2009 to 4/10/2009	11.14 +/-	1.22
11	TLB	4/10/2009 to 7/1/2009	13.23 +/-	0.84
11	TLB	7/1/2009 to 10/8/2009	13.78 +/-	1.33
11	TLB	10/8/2009 to 1/13/2010	13.60 +/-	0.86
12	TLB	1/6/2009 to 4/10/2009	10.92 +/-	0.47
12	TLB	4/10/2009 to 7/1/2009	12.05 +/-	0.59
12	TLB	7/1/2009 to 10/8/2009	13.38 +/-	0.53
12	TLB	10/8/2009 to 1/13/2010	13.02 +/-	0.77
1 🖛	1 L D	10/0/2009 10 1/15/2010	15.02 17	0.77
13	TLB	1/6/2009 to 4/10/2009	11.08 +/-	0.51
13	TLB	4/10/2009 to 7/1/2009	11.73 +/-	1.07
13	TLB	7/1/2009 to 10/8/2009	12.56 +/-	0.48
13	TLB	10/8/2009 to 1/13/2010	12.52 +/-	1.04
14	TLB	1/6/2009 to 4/10/2009	9.64 +/-	0.75
14	TLB	4/10/2009 to 7/1/2009	11.64 +/-	0.79
14	TLB	7/1/2009 to 10/8/2009	11.20 +/-	0.67
14	TLB	10/8/2009 to 1/13/2010	11.81 +/-	0.78
15	TLB	1/6/2009 to 4/10/2009		0.65
15	TLB	4/10/2009 to 7/1/2009	10.03 +/-	0.82
15	TLB	7/1/2009 to 10/8/2009	10.76 +/-	0.71 .
15	TLB	10/8/2009 to 1/13/2010	10.79 +/-	1.11 .
21		1/6/2000	10.10	
21	TLB	1/6/2009 to 4/10/2009	12.18 +/-	0.59
21	TLB	4/10/2009 to 7/1/2009	13.41 +/-	1.01
21	TLB	7/1/2009 to 10/8/2009	14.64 +/-	0.67
21	TLB	10/8/2009 to 1/13/2010	13.97 +/-	0.81

TLD Gamma Dose Detail Report 2009

Radiological Environmental Monitoring Program Detail DataPerry Nuclear Power Plant, Lake County OhioDocket no. : 50-440/50-441Sample Frequency is:QuarterlyResults in mR/91 days+/-2 Sigma

Location	Sample Type	Collection Period		Expos	ure		
23	TLB	1/6/2009 to 4/	(10/2009	11.57	+/-	.76	
23	TLB		7/1/2009		+/-	.95	
23	TLB		0/8/2009		+/-	.66	
23	TLB		/13/2010		+/-	.78	
24	TLB	1/6/2009 to 4/	/10/2009	11.70	+/-	.26	
24	TLB		7/1/2009	11.05	+/-	.66	
24	TLB		0/8/2009		+/-	.09	
24	TLB		/13/2010		+/-	.67	
29	TLB	1/6/2009 to 4/	/10/2009	14.58	+/-	.54	
29	TLB		7/1/2009	16.26	+/-	.03	
29	TLB		0/8/2009		+/-	.44	
29	TLB	10/8/2009 to 1/	/13/2010	16.25	+/	.01	
30	TLB	1/6/2009 to 4/	/10/2009	13.65	+/-	.80	
30	TLB		7/1/2009	14.17	+/-	.58	
30	TLB)/8/2009	15.80	+/-	.74	
30	TLB		13/2010		+/-	.79	
31	TLB	1/6/2009 to 4/	/10/2009	13.95	+/-	.92	<i>,</i>
31	TLB		7/1/2009	15.67	+/-	.96	
31	TLB		0/8/2009		+/-	.20	
31	TLB		13/2010		+/-	.91	
33	TLB	1/6/2009 to 4/	/10/2009	14.74	+/-	.82	
33	TLB		7/1/2009	16.70	+/-	.84	
33	TLB		0/8/2009		+/-	.72	
33	TLB		13/2010		+/-	.91	
35	TLB	1/6/2009 to 4/	/10/2009	11.65	+/-	.84	
35	TLB		7/1/2009		+/-	.51	- ·
35)/8/2009	12.45		.54	
35	TLB		/13/2010		+/-	.67	
36	TLB	1/6/2009 to 4/	10/2009	14.48	+/-	.77	

TLD Gamma Dose Detail Report 2009

Radiological Environmental Monitoring Program Detail Data

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Frequency is: Quarterly Results in mR/91 days +/- 2 Sigma

Location	Sample Type	Collection Period	Exposure	
36	TLB.	4/10/2009 to 7/1/2009	15.16 +/- 0.62	
36	TLB	7/1/2009 to 10/8/2009	17.53 +/- 0.67	
36	TLB	10/8/2009 to 1/13/2010	16.24 +/- 0.74	
53	TLB	1/6/2009 to 4/10/2009	12.42 +/- 0.58	
53	TLB	4/10/2009 to 7/1/2009	13.01 +/- 0.60	
53	TLB	7/1/2009 to 10/8/2009	14.76 +/- 0.61	
53	TLB	10/8/2009 to 1/13/2010	14.36 +/- 0.91	
54	TLB	1/6/2009 to 4/10/2009	12.64 +/- 0.84	
54	TLB	4/10/2009 to 7/1/2009	12.58 +/- 0.64	
54	TLB	7/1/2009 to 10/8/2009	13.70 +/- 0.79	
54	TLB	10/8/2009 to 1/13/2010	13.09 +/- 0.72	
55	TLB	1/6/2009 to 4/10/2009	12.65 +/- 0.61	
55	TLB	4/10/2009 to 7/1/2009	13.57 +/- 0.75	
55	TLB	7/1/2009 to 10/8/2009	14.75 +/- 0.55	
55	TLB	10/8/2009 to 1/13/2010	13.88 +/- 0.83	
56	TLB	1/6/2009 to 4/10/2009	12.41 +/- 0.73	
56	TLB	4/10/2009 to 7/1/2009	11.67 +/- 1.26	
56	TLB	7/1/2009 to 10/8/2009	13.88 +/- 0.57	
56	TLB	10/8/2009 to 1/13/2010	12.68 +/- 1.21	
58	TLB	1/6/2009 to 4/10/2009	9.70 +/- 0.72	
58	TLB	4/10/2009 to 7/1/2009	10.04 +/- 0.55	
58	TLB	7/1/2009 to 10/8/2009	10.94 +/- 0.75	
58	TLB	10/8/2009 to 1/13/2010	11.03 +/- 0.72	

C-45

TLD Gamma Dose Detail Report 2009

APPENDIX C

Radiological Environmental Monitoring Program Detail Data

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Results in mR/365 days +/- 2 Sigma Sample Frequency is: Annual

 Location	Sample Type	Collection Period	Exposure	
 1	TLA	1/6/2009 to 1/13/2010	44.10 +/- 1.90	
3	TLA	1/6/2009 to 1/13/2010	42.30 +/- 1.44	
4	TLA	1/6/2009 to 1/13/2010	55.08 +/- 2.01	
5	TLA	1/6/2009 to 1/13/2010	45.70 +/- 1.99	
6	TLA	1/6/2009 to 1/13/2010	54.45 +/- 1.25	
7	TLA	1/6/2009 to 1/13/2010		
8	TLA	1/6/2009 to 1/13/2010	50.66 +/- 2.01	
9	TLA	1/6/2009 to 1/13/2010	45.40 +/- 2.71	
10	TLA	1/6/2009 to 1/13/2010	63.99 +/- 2.52	
11	TLA	1/6/2009 to 1/13/2010	57.95 +/- 5.29	
12	TLA	1/6/2009 to 1/13/2010	52.76 +/- 1.75	
13	TLA	1/6/2009 to 1/13/2010	51.94 +/- 2.91	· · ·
14	TLA	1/6/2009 to 1/13/2010	41.66 +/- 2.60	
15	TLA	1/6/2009 to 1/13/2010	43.14 +/- 2.06	
21	TLA	1/6/2009 to 1/13/2010	59.20 +/- 5.12	
23	TLA	1/6/2009 to 1/13/2010	52.79 +/- 1.62	
24	TLA	1/6/2009 to 1/13/2010	45.94 +/- 1.83	
29	TLA	1/6/2009 to 1/13/2010	61.59 +/- 1.65	
30	TLA	1/6/2009 to 1/13/2010	59.57 +/- 1.63	
 			· · · · · · · · · · · · · · · · · · ·	

TLD Gamma Dose Detail Report 2009

Radiological Environmental Monitoring Program Detail Data Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441 Sample Frequency is: Annual Results in mR/365 days +/- 2 Sigma

 Location	Sample Type	Collection Period	Exposure	
 31	TLA	1/6/2009 to 1/13/2010	65.61 +/- 2.44	
33	TLA	1/6/2009 to 1/13/2010	70.94 +/- 3.56	
35	TLA	1/6/2009 to 1/13/2010	50.32 +/- 1.58	
36	TLA	1/6/2009 to 1/13/2010	69.24 +/- 2.49	
53	TLA	1/6/2009 to 1/13/2010	56.98 +/- 2.87	
54	TLA	1/6/2009 to 1/13/2010	53.94 +/- 4.55	
55	TLA	1/6/2009 to 1/13/2010	56.20 +/- 5.13	
56	TLA	1/6/2009 to 1/13/2010	56.54 +/- 2.62	
58	TLA	1/6/2009 to 1/13/2010	43.23 +/- 1.56	

C-47

Water Gamma Spectral Detail Report 2009

Radiological Environmental Monitoring Program Detail Data

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Frequency is: Monthly

Results in pCi/L +/- 2 Sigma

				-				
Location	Sample Type	Collection Period	Ba-140 Fe-59	Co-58 La-140	Co-60 Mn-54	Cs-134 Nb-95	Cs-137 Zn-65	
			Zr-95				·	
28	Water	12/30/2008 to 1/29/2009	< 10.48	< 3.11	< 1.82	< 3.57	< 3.44	
20	Water	12/30/2003 10 1/25/2005	< 4.56	< 2.09	< 2.82	< 1.66	< 4.67	
			< 4.71	\$ 2.09	\$ 2.02	\$ 1.00		
28	Water	1/29/2009 to 2/27/2009	< 9.14	< 3.45	< 1.25	< 2.84	< 3.64	
			< 4.72	< 2.81	< 2.74	< 3.17	< 6.50	
			< 5.36					
28	Water	2/27/2009 to 3/26/2009	< 16.80	< 2.56	< 1.93	< 2.38	< 2.75	
			< 5.67	< 3.09	< 1.96	< 3.96	< 3.60	
			< 3.49					
28	Water	3/26/2009 to 4/30/2009	< 10.80	< 2.16	< 1.85	< 2.61	< 2.74	
			< 2.85	< 1.95	< 2.26	< 2.56	< 1.81	
			< 3.00					
28	Water	4/30/2009 to 5/28/2009	< 16.61	< 2.90	< 1.93	< 3.61	< 4.03	
			< 6.31	< 2.88	< 2.13	< 3.84	< 4.52	
			< 5.29					
28	Water	5/28/2009 to 6/25/2009	< 20.78	< 1.97	< 1.56	< 2.16	< 2.95	
			< 4.18	< 5.69	< 2.63	< 2.10	< 4.68	
			< 4.96		·			
28	Water	6/25/2009 to 7/30/2009	< 22.71	< 2.56	< 2.03	< 2.27	< 2.58	
			< 4.37	< 4.17	< 2.94	< 3.32	< 3.80	
			< 5.22					
28	Water	7/30/2009 to 8/31/2009	< 10.20	< 2.60	< 2.46	< 2.06	< 2.64	
			< 3.84	< 3.35	< 2.19	< 2.49	< 2.69	
			< 3.96	,				
28	Water	8/31/2009 to 9/24/2009	< 15.62	< 2.41	< 1.79	< 2.71	< 3.42	
			< 6.19	< 3.35	< 3.38	< 1.71	< 3.70	
			< 4.71					
28	Water	9/24/2009 to 10/29/2009	< 14.70	< 2.37	< 1.96	< 2.23	< 2.55	
			< 2.42	< 1.52	< 2.53	< 3.63	< 2.25	
			< 4.26					
28	Water	10/29/2009 to 11/24/2009	< 30.59	< 5.48	< 2.90	< 5.24	< 6.34	
			< 6.33	< 3.54	< 4.86	< 5.80	< 4.85	
	•		< 6.11					

Water Gamma Spectral Detail Report 2009

Radiological Environmental Monitoring Program Detail Data

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Frequency is: Monthly

Results in pCi/L +/- 2 Sigma

		-						
Location	Sample Type	Collection Period	Ba-140 Fe-59 Zr-95	Co-58 La-140	Co-60 Mn-54	Cs-134 Nb-95	Cs-137 Zn-65	
28	Water	11/24/2009 to 12/23/2009	 < 15.14 < 3.24 < 4.13 	< 1.77 < 2.71	< 2.67 < 2.83	< 2.19 < 3.27	< 2.77 < 5.40	
34	Water	12/30/2008 to 1/29/2009	< 10.03 < 3.90 < 2.64	< 1.92 < 2.24	< 2.05 < 2.10	< 2.33 < 2.03	< 2.29 < 4.11	
34	Water	1/29/2009 to 2/27/2009	< 14.03 < 3.32 < 3.45	< 1.95 < 2.09	< 1.77 < 2.05	< 1.99< 3.30	< 2.45 < 3.50	
34	Water	2/27/2009 to 3/26/2009	< 16.15 < 5.65 < 5.57	< 1.78 < 3.62	< 1.75 < 2.12	< 3.31 < 2.75	< 2.72 < 4.51	
34	Water	3/26/2009 to 4/30/2009	< 9.26 < 3.47 < 2.92	< 1.83 < 2.93	< 1.38 < 2.09	< 2.34 < 2.96	< 2.40 < 4.35	
34	Water	5/28/2009 to 5/28/2009	< 17.02 < 2.78 < 4.56	< 1.71 < 2.57	< 2.50 < 1.34	< 2.02 < 2.57	< 3.50 < 3.22	
34	Water	5/28/2009 to 6/25/2009	< 16.66 < 6.91 < 6.98	< 2.89 < 3.38	< 2.35 < 3.17	< 4.21 < 4.68	< 2.33 < 3.81	
34	Water	6/25/2009 to 7/30/2009	< 20.82 < 7.05 < 2.97	< 1.75 < 4.49	< 2.31 < 2.83	< 2.25 < 2.93	< 2.26 < 4.65	
34	Water	8/31/2009 to 8/31/2009	< 10.16 < 4.74 < 4.55	< 1.25 < 3.21	< 1.98 < 2.33	< 2.19 < 2.55	< 1.80 < 3.37	
34	Water	8/31/2009 to 9/24/2009	< 20.35 < 4.55 < 5.16	< 2.86 < 3.38	< 2.35 < 2.55	< 2.76 < 3.68	< 3.81 < 3.73	

. ·

Water Gamma Spectral Detail Report 2009

Radiological Environmental Monitoring Program Detail Data

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Frequency is: Monthly

Results in pCi/L +/- 2 Sigma

Location	Sample Type	Collection Period	Ba-140 Fe-59 Zr-95	Co-58 La-140	Co-60 Mn-54	Cs-134 Nb-95	Cs-137 Zn-65
34	Water	9/24/2009 to 10/29/2009	< 11.68 < 2.31 < 6.54	< 1.54 < 5.61	< 3.12 < 2.88	< 2.76 < 3.45	< 2.52 < 3.86
34	Water	10/29/2009 to 11/24/2009	< 13.76 < 5.61 < 5.63	< 3.66 < 4.86	< 3.14 < 3.68	< 3.17 < 2.77	< 3.63 < 5.89
34	Water	11/24/2009 to 12/23/2009	< 14.27 < 3.16 < 5.04	< 2.27 < 3.19	< 2.54 < 1.71	< 2.40 < 3.75	< 2.93 < 5.88
36	Water	12/30/2008 to 1/29/2009	< 13.75 < 4.88 < 3.46	< 2.02 < 2.29	< 1.88 < 2.20	< 2.31 < 2.75	< 2.49 < 3.57
36	Water	1/29/2009 to 2/27/2009	< 9.98 < 4.49 < 4.64	< 1.85 < 2.08	< 1.86 < 2.40	< 3.01 < 2.50	< 3.20 < 2.01
36	Water	2/27/2009 to 3/26/2009	< 10.04 < 4.70 < 2.74	< 2.51 < 3.63	< 1.95 < 2.69	< 2.39 < 3.09	< 3.01 < 2.00
36	Water	3/26/2009 to 4/30/2009	< 10.26 < 5.84 < 4.05	< 1.21 < 2.87	< 1.92 < 3.24	< 2.41 < 3.13	< 3.41 < 3.72
36	Water	4/30/2009 to 5/28/2009	< 15.17 < 2.30 < 3.90	< 2.22 < 5.12	< 1.82 < 1.89	< 3.60 < 3.44	< 2.45 < 2.27
36	Water	5/28/2009 to 6/25/2009	< 12.08 < 5.04 < 5.13	< 3.00 < 5.61	< 2.01 < 2.15	< 2.46 < 2.94	< 3.16 < 3.84
36	Water	6/25/2009 to 7/30/2009	< 15.70 < 5.34 < 4.98	< 2.75 < 2.14	< 1.70 < 1.68	< 2.63 < 2.86	< 3.44 < 4.00

Water Gamma Spectral Detail Report 2009

0

Radiological Environmental Monitoring Program Detail Data

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Location	Sample Type	Collection Period	Ba-140 Fe-59 Zr-95	Co-58 La-140	Co-60 Mn-54	Cs-134 Nb-95	Cs-137 Zn-65
36	Water	7/30/2009 to 8/31/2009	< 8.75 < 2.54 < 3.48	< 1.72 < 2.34	< 2.60 < 2.48	< 2.02 < 2.98	< 1.38 < 4.54
36	Water	8/31/2009 to 9/24/2009	< 13.08 < 4.98 < 2.94	< 2.51 < 1.55	< 2.40 < 2.26	< 2.38 < 2.13	< 2.83 < 3.20
36	Water	9/24/2009 to 10/29/2009	< 13.87 < 4.57 < 5.24	< 1.14 < 4.18	< 2.00 < 2.87	< 2.49 < 2.92	< 2.76 < 2.16
36	Water	10/29/2009 to 11/24/2009	< 23.81 < 6.08 < 6.54	< 3.29 < 4.44	// < 3.61 < 3.29	< 3.16 < 2.65	< 4.22 < 5.42
36	Water	11/24/2009 to 12/23/2009	< 15.83 < 3.85 < 3.73	< 1.99 < 3.84	< 1.59 < 1.05	< 1.69 < 3.07	< 1.83 < 3.29
59	Water	3/18/2009 to 3/26/2009	< 19.70 < 3.79 < 5.09	< 1.99 < 3.75	< 1.48 < 2.03	< 2.82 < 3.14	< 2.69 < 4.60
59	Water	3/26/2009 to 4/30/2009	< 10.69 < 3.60 < 4.19	< 2.15 < 2.43	< 1.80 < 1.49	< 1.98 < 2.65	< 2.84 < 2.37
59	Water	4/30/2009 to 5/28/2009	< 17.57 < 3.26 < 5.25	< 1.33 < 2.61	< 3.37 < 2.43	< 1.79 < 2.93	< 3.17 < 4.49
59	Water	5/28/2009 to 6/25/2009	< 21.26 < 5.00 < 4.31	< 2.61 < 4.96	< 2.05 < 1.55	< 2.48 < 4.02	< 2.86 < 4.92
59	Water	6/25/2009 to 7/30/2009	< 20.45 < 4.71 < 3.57	< 2.10 < 3.68	< 1.87 < 2.25	< 2.60 < 3.14	< 2.80 < 4.10

Water Gamma Spectral Detail Report 2009

Radiological Environmental Monitoring Program Detail Data

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Frequency is: Monthly

Results in pCi/L +/- 2 Sigma

• •

Location	Sample Type	Collection Period	Ba-140 Fe-59 Zr-95	Co-58 La-140	Co-60 Mn-54	Cs-134 Nb-95	Cs-137 Zn-65
59	Water .	7/30/2009 to 8/31/2009	< 11.46 < 3.74 < 4.52	< 2.70 < 3.00	< 1.80 < 2.57	< 2.59 < 2.26	< 2.37 < 2.34
59	Water	8/31/2009 to 9/24/2009	< 15.11 < 4.14 < 3.68	< 1.48 < 2.65	< 2.72 < 2.78	< 2.88 < 3.48	< 3.70 < 2.89
59	Water	9/24/2009 to 10/29/2009	< 22.42 < 7.46 < 6.33	< 2.53 < 3.19	< 2.22 < 1.63	< 2.58 < 2.36	< 2.93 < 6.33
59	Water	10/29/2009 to 11/24/2009	< 14.97 < 5.57 < 4.60	< 2.01 < 2.36	< 2.92 < 2.97	< 3.46 < 2.14	< 3.86 < 5.12
60	Water	3/18/2009 to 3/26/2009	< 12.21 < 5.06 < 3.78	< 2.25 < 2.20	< 2.59 < 2.59	< 2.53 < 1.97	< 2.20 < 3.96
60	Water	3/26/2009 to 4/30/2009	< 14.73 < 3.63 < 4.64	< 1.77 < 3.73	< 2.24 < 1.77	< 1.99 < 2.38	< 2.50 < 3.48
60	Water	4/30/2009 to 5/28/2009	< 19.17 < 6.28 < 6.80	< 3.51 < 7.43	< 2.49 < 4.45	< 2.41 < 3.10	< 3.09< 6.85
60	Water	5/28/2009 to 6/25/2009	< 21.32 < 6.08 < 4.76	< 3.39 < 5.45	< 2.42 < 4.32	< 3.82 < 4.60	< 2.46 < 4.87
60	Water	6/25/2009 to 7/30/2009	< 20.27 < 6.58 < 5.22	< 3.68 < 3.13	< 2.01 < 2.54	< 2.21 < 3.30	< 2.31 < 4.18
60	Water	7/30/2009 to 8/31/2009	< 9.23 < 3.32 < 5.27	< 2.96 < 1.77	< 3.38 < 3.74	< 4.45 < 2.52	< 4.54 < 3.87

Water Gamma Spectral Detail Report 2009

Radiological Environmental Monitoring Program Detail Data

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Frequency is: Monthly Results in pCi/L +/- 2 Sigma

Location	Sample Type	Collection Period	Ba-140	Co-58	Co-60	Cs-134	Cs-137
			Fe-59	La-140	Mn-54	Nb-95	Zn-65
			Zr-95				
60	Water	8/31/2009 to 9/24/2009	< 22.55	< 3.31	< 2.61	< 4.07	< 4.09
			< 5.01	< 2.51	< 3.29	< 4.08	< 7.33
			< 6.07				
60	Water	9/24/2009 to 10/29/2009	< 17.02	< 2.64	< 1.70	< 2.03	< 1:90
			< 4.17	< 2.55	< 2.44	< 2.64	< 2.22
		·	< 5.20				
60	Water	10/29/2009 to 11/24/2009	< 15.95	< 2.17	< 2.22	< 2.28	< 2.77
			< 4.26	< 2.58	< 2.62	< 2.01	< 4.58
			< 5.13				

• .

Water Gross Beta Detail Report 2009

Radiological Environmental Monitoring Program Data Summary

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Frequency is: Monthly Resu

Results in pCi/L +/- 2 Sigma

			Location						
Collection Period	Sample Type	28	34	36	59	60			
12/30/2008 to 1/29/2009	Water	LLD	LLD	LLD					
1/29/2009 to 2/27/2009	Water	LLD	LLD	LLD					
2/27/2009 to 3/26/2009	Water	3.19 +/- 1.17	3.09 +/- 1.02	LLD					
3/18/2009 to 3/26/2009	Water				LLD	LLD			
3/26/2009 to 4/30/2009	Water	LLD	LLD	LLD	LLD	LLD			
4/30/2009 to 5/28/2009	Water	LLD		< 0.87	LLD	LLD			
5/28/2009 to 5/28/2009	Water		< 0.83						
5/28/2009 to 6/25/2009	Water	LLD	LLD	< 0.91.	< 0.86	< 0.91			
6/25/2009 to 7/30/2009	Water	LLD	< 0.85	LLD	LLD	LLD			
7/30/2009 to 8/31/2009	Water	LLD		< 0.91	LLD	LLD			
8/31/2009 to 8/31/2009	Water		LLD						

, ·

Water Gross Beta Detail Report 2009

Radiological Environmental Monitoring Program Data Summary

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

				Location					
Collection Period S	Sample Type	. 28	34	36	59	60			
8/31/2009 to 9/24/2009	Water	< 1.99	LLD	LLD	LLD	< 1.90			
9/24/2009 to 10/29/2009	Water	LLD	< 0.86	LLD	LLD	LLD			
0/29/2009 to 11/24/2009	Water	LLD	< 0.93	< 0.88	LLD	LLD			
1/24/2009 to 12/23/2009	Water	LLD	LLD	LLD					

Water Tritium Detail Report 2009

Radiological Environmental Monitoring Program Detail Data

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Frequency is: Quarterly Results in pCi/L +/- 2 Sigma

ocation	Sample Type	Collection Date	H-3	
28	Water	3/26/2009	< 158.22	
28	Water	6/25/2009	< 143.61	
28	Water	9/24/2009	< 150.69	
28	Water	12/23/2009	< 150.24	
34	Water	3/26/2009	< 158.22	
34	Water	6/25/2009	< 143.61	
34	Water	9/24/2009	< 150.69	
34	Water	12/23/2009	< 150.24	
36	Water	3/26/2009	< 158.22	
36	Water	6/25/2009	< 143.61	
36	Water	9/24/2009	< 150.69	
36	Water	12/23/2009	LLD	
59	Water	3/26/2009	LLD	
59	Water	6/25/2009	< 143.61	
59	Water	9/24/2009	< 150.69	
59	Water	11/24/2009	< 150.24	
60	Water	3/26/2009	< 158.22	,
60	Water	6/25/2009	< 147.74	
60	Water	9/24/2009	< 150.69	
60	Water	11/24/2009	< 150.24	

v.

4

Z)

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

APPENDIX D

CORRECTIONS TO PREVIOUS ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORTS

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

APPENDIX D

CORRECTIONS TO PREVIOUS ANUUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORTS:

There were no corrections identified during this reporting period to any of the previous Annual Environmental and Effluent Release Reports.

