



Serial: RNP-RA/11-0027

APR 26 2011

United States Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, DC 20555

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2  
DOCKET NO. 50-261/LICENSE NO. DPR-23

2010 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT

Ladies and Gentlemen:

Attached is the Annual Radioactive Effluent Release Report for the period of January 1, 2010, through December 31, 2010, for H. B. Robinson Steam Electric Plant (HBRSEP), Unit No. 2. This report is submitted in accordance with 10 CFR 50.36a(a)(2) and the HBRSEP, Unit No. 2, Technical Specifications Section 5.6.3.

If you have any questions concerning this report, please contact me at 843-857-1626.

Sincerely,

A handwritten signature in black ink that reads 'John R. Caves'.

J. Caves

Supervisor - Licensing/Regulatory Programs

RAC/rac

Attachment

- c: V. M. McCree, NRC, Region II
- B. Mozafari, NRC Project Manager, NRR (w/o Attachment)
- NRC Resident Inspector

IE48  
NRR

EFFLUENT AND WASTE DISPOSAL

ANNUAL REPORT

January 1, 2010 - December 31, 2010

PROGRESS ENERGY CAROLINAS

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2

FACILITY OPERATING LICENSE NO. DPR-23

DOCKET NO. 50-261

TABLE OF CONTENTS

	<u>Description</u> .....	<u>Page</u>
I.	EXECUTIVE SUMMARY.....	4
	A. Discussion.....	4
	B. Significant Variances.....	8
	C. Regulatory Compliance.....	8
II.	SUPPLEMENTAL INFORMATION.....	9
	A. Regulatory Limits.....	9
	B. Measurements and Approximations of Total Radioactivity.....	10
	C. Estimated Total Errors.....	11
III.	GASEOUS EFFLUENTS.....	12
	A. Batch Releases.....	12
	B. Abnormal Releases.....	12
	C. Data Tables.....	12
IV.	LIQUID EFFLUENTS.....	18
	A. Batch Releases.....	18
	B. Abnormal Releases.....	18
	C. Data Tables.....	18
V.	SOLID WASTE AND IRRADIATED FUEL SHIPMENTS.....	24
	A. Waste Class A.....	24
	B. Waste Class B.....	27
	C. Waste Class C.....	29
VI.	40 CFR 190 DOSE CONFORMANCE.....	31
VII.	METEOROLOGICAL DATA.....	31
	A. Continuous Release Diffusion Analysis.....	31

LIST OF TABLES

<u>Table</u>	<u>Description</u> .....	<u>Page</u>
Table III-A	Gaseous Effluents - Summation of All Releases .....	13
Table III-B	Gaseous Effluents - Ground Level and Mixed Mode Releases .....	15
Table III-C	Typical Lower Limits of Detection for Gaseous Effluents .....	17
Table IV-A	Liquid Effluents - Summation of All Releases .....	19
Table IV-B	Liquid Effluents - Continuous Mode and Batch Mode Releases .....	21
Table IV-C	Typical Lower Limits of Detection for Liquid Effluents .....	23
Table VII-A	Joint Occurrence Frequencies for LOWNDDEG and LOWNDSPD – Continuous Releases .....	32

## I. EXECUTIVE SUMMARY

### A. Discussion

#### 1. Effluent Controls

The H. B. Robinson Steam Electric Plant (HBRSEP), Unit No. 2, Offsite Dose Calculation Manual specifies controls and dose limits pertaining to releases of radioactivity to the environment. None of these controls or dose limits were exceeded during 2010.

#### 2. Protection Standards

The main objective in the control of radiation is to ensure that any exposure is kept not only within regulatory limits, but As Low As Reasonably Achievable (ALARA). The ALARA concept applies to reducing radiation exposure both to workers at HBRSEP, Unit No. 2, and to the general public. Reasonably achievable means that radiation exposure reduction is based on sound environmental practices, economic decisions, and operating practices. By practicing ALARA, HBRSEP and Progress Energy Carolinas, Inc., minimize health risk and environmental detriment, and ensure that exposures are maintained well below regulatory limits.

#### 3. Sources of Radioactivity Released

During normal operations of a nuclear power station, most of the fission products are retained within the fuel and fuel cladding. However, small quantities of radioactive fission and activation products are present in the reactor coolant water. The types of radioactive material released are noble gases, iodines and particulates, and tritium.

The noble gas fission products in the reactor coolant water are released as a gas when the coolant is depressurized. These gases are collected by a system designed for collection and storage for radioactive decay prior to release to the environment.

Small releases of radioactivity in liquids may occur from equipment associated with the reactor coolant system. These liquids are collected and processed for radioactivity removal, prior to and during release.

#### 4. Noble Gas

Some of the fission products released in airborne effluents are radioactive isotopes of noble gases, such as argon and xenon. Noble gases are by nature inert and do not concentrate in humans or other organisms. Noble gases contribute to human radiation exposure as external exposure.

5. Iodines and Particulates

The main contribution of radioactive iodine to human exposure is to the thyroid gland, where the body concentrates iodine. The particulates contribute to internal exposure of tissues such as the muscle, liver, and intestines. These particulates can also be a source of exposure if deposited on the ground.

6. Tritium

Tritium, a radioactive isotope of hydrogen, is a predominate radionuclide in liquid and gaseous effluents. Tritium is produced in the reactor via a number of processes. Tritium is a weak beta particle emitter and contributes very little radiation exposure to the human body, and when tritium is inhaled, ingested, or absorbed it is dispersed throughout the body until eliminated.

7. Processing and Monitoring

Effluents are strictly controlled and monitored to ensure that radioactivity released to the environment is minimal and within regulatory limits. Effluent controls include the operation of radiation monitoring systems, in-plant and environmental sampling and analyses, quality assurance programs for both in-plant and environmental sampling and analyses, and procedures that address effluent and environmental monitoring.

The plant radiation monitoring system provides monitors that are designed to ensure that releases are below regulatory limits. Each instrument provides indication of the amount of radioactivity present and is equipped with alarms and indicators in the control room. The alarm setpoints are set below the regulatory limits, i.e., typically at less than 50 percent of the regulatory limit, to ensure that the limits are not exceeded. If a monitor alarms, a release to the environment from a tank is automatically suspended. Additionally, releases are sampled and analyzed in the laboratory prior to discharge to the environment. The sampling and analysis done in the laboratory provides a more sensitive and precise method of determining pre-effluent composition than in-plant monitoring instruments.

The plant has a meteorological tower, which is linked to computers that record the meteorological data. This meteorological data and the results of the Land Use Census are used to verify the ground level dispersion factors contained in the ODCM that are used in calculating the dose to the public.

In addition to in-plant equipment, the company maintains a Radiological Environmental Monitoring Program, which consists of devices used to sample the air and water in the environment. The samples collected from the surrounding environment are analyzed to determine the presence of radioactive material in the environment.

## 8. Exposure Pathways

Radiological exposure pathways are the methods by which people may become exposed to radioactive material. The major pathways of concern are those which could cause the highest calculated radiation dose. The projected pathways are determined from the type and amount of radioactive material that may have been released, the environmental transport mechanism, and the use of the environment.

Environmental transport mechanisms include, but are not limited to, hydrological (i.e., water) and meteorological (i.e., weather) characteristics of the area. Information on water flow, wind speed and direction, dietary intake of residents, recreational use of the area, and location of homes and farms in the area are some of the many factors used to calculate the potential exposure to offsite personnel.

The release of radioactive gaseous effluents includes pathways such as external whole body exposure, deposition on plants and soils, and human inhalation. The release of radioactive material in liquid effluents includes pathways such as fish consumption and direct exposure from the lake at the shoreline.

Even though radionuclides can reach humans by many different pathways, some radionuclides result in more exposure than others. The critical pathway is the one that, for a specific radionuclide, will result in the greatest exposure to a population, or a specific group of the population, called the critical group. The critical group may vary depending on the radionuclides involved, the age and diet of the group, and other cultural factors. The exposure may be received by the whole body or to a specific organ, with the organ receiving the largest fraction of the exposure called the critical organ.

The exposures to the general public in the area surrounding HBRSEP, Unit No. 2, are calculated for gaseous and liquid releases. The exposure due to radioactive material released in gaseous effluents is calculated using factors such as the amount of radioactive material released, the concentration beyond the site boundary, locations of exposure pathways, and usage factors. The exposures calculated due to radioactive materials released in liquid effluents are calculated using factors such as the total volume of liquid, the total volume of dilution water, and usage factors.

9. Plant Operation

With the exception of March 29, thru July 19, September 9, thru September 14, and October 7, thru November 17, 2010, HBRSEP, Unit No. 2, operated continuously.

10. Results

The Radioactive Effluent Release Report is a detailed listing of the radioactivity released from the HBRSEP, Unit No. 2, during the period from January 1, 2010 through December 31, 2010. Some of the gaseous and liquid release parameters for this reporting period are summarized below:

GASEOUS EFFLUENTS

	<u>Units</u>	<u>1st Qtr</u>	<u>2nd Qtr</u>	<u>3rd Qtr</u>	<u>4th Qtr</u>
Fission & Act. Gas	Ci	2.92E-01	6.27E-02	1.11E-01	4.10E-02
I-131	Ci	8.39E-07	5.14E-07	ND <sup>1</sup>	ND
Part. >8 Day Half-Lives	Ci	ND	6.15E-08	3.77E-08	ND
Tritium	Ci	1.03E+00	1.93E+00	1.38E+00	1.51E+00

LIQUID EFFLUENTS

	<u>Units</u>	<u>1st Qtr</u>	<u>2nd Qtr</u>	<u>3rd Qtr</u>	<u>4th Qtr</u>
Fission & Act. Products	Ci	5.49E-04	1.21E-02	8.46E-04	2.83E-04
Tritium	Ci	2.94E+02	5.19E+01	7.83E+00	8.31E+01
Dilution Volume	Liters	2.72E+11	5.48E+10	2.55E+11	2.64E+11
Waste Volume	Liters	7.90E+05	1.16E+06	5.73E+05	5.68E+05

During the period of January 1, 2010 through December 31, 2010, the estimated maximum individual offsite dose due to radioactivity released in effluents was:

Liquid Effluents:

- Total Body Dose 0.000113 millirem
- Critical Organ Dose 0.000167 millirem, GI-LLi

Note – an additional 0.23 mrem was estimated based on the evaporation of tritium from Lake Robinson. This is based on Lake Robinson 2010 environmental sample results and represents the dose from the buildup in the lake. This conservatively bounds the dose due to 2010 tritium effluents.

<sup>1</sup> ND, No Detectable Activity

Gaseous Effluents:

- Beta Air Dose 0.00203 millirad
- Gamma Air Dose 0.00202 millirad
- Critical Organ Dose 0.0806 millirem, Thyroid

Note - Carbon-14 releases resulted in 0.052 mrem to the total body and 0.26 mrem to the bone, which is not included in the above doses. It is estimated that 5.04 curies of Carbon-14 were released during 2010.

B. Significant Variances

1. No variances in historical data of significance were identified during this period.

C. Regulatory Compliance

1. The 10 CFR 50, Appendix I, doses were calculated using the Canberra Effluent Management System (EMS<sup>1</sup>). The EMS Software provides day-by-day dose estimates that are conservative because all releases are assigned to the limiting receptor, using the continuous ground level dispersion factors calculated from 1978 meteorology. When projected on a day-by-day basis, utilizing conservative meteorological conditions, the dose commitment from gaseous and liquid effluents is a small fraction of the 10 CFR 50, Appendix I, limits. The direct radiation assessment to the most likely exposed member of the public is reported in the Annual Radiological Environmental Operating Report. During 2010, the results of the direct radiation assessment demonstrated no measurable effect above background for plant operations.
2. There were changes to the waste solidification Process Control Program (PCP) during this reporting period. See page 36.
3. There were no changes to the Radioactive Waste Systems (i.e., liquid, gaseous, or solid) during this reporting period. See page 36.
4. There were three reportable instrumentation inoperability events during this reporting period. See page 37.
5. There were no outside liquid holdup tanks that exceeded the 10 curie limit during this reporting period. See page 37.
6. There were no Waste Gas Decay Tanks that exceeded the 1.9E+04 curie limit during this reporting period. See page 37.
7. There were no instances of missed compensatory samples during this reporting period. See page 37.
8. There were two revisions to the ODCM during this reporting period. See page 35.

<sup>1</sup> EMS, Effluent Management System Software is a product of Canberra Nuclear Industries used for determining dose from radioactive effluent releases.

9. There were no dose calculations performed or special reports made as a result of any spills or leaks during this period. See page 37.
10. There were no events associated with a failure to meet an ODCM specified sampling frequency. See page 38.

## II. SUPPLEMENTAL INFORMATION

### A. Regulatory Limits

1. Fission and Activation Gases:
  - 10 CFR 20 Limits (Instantaneous Release Rate)
    - Total Body Dose  $\leq 500$  mrem/yr
    - Skin Dose  $\leq 3000$  mrem/yr
  - 10 CFR 50, Appendix I
    - For Calendar Quarter
      - Gamma Dose  $\leq 5$  mrad
      - Beta Dose  $\leq 10$  mrad
    - For Calendar Year
      - Gamma Dose  $\leq 10$  mrad
      - Beta Dose  $\leq 20$  mrad
2. Iodine-131 and 133, Tritium, and Particulates >8 day half-lives:
  - 10 CFR 20 Limits (Instantaneous Release Rate)
    - Dose from Inhalation (only) to a child to any organ  $\leq 1500$  mrem/yr
  - 10 CFR 50, Appendix I (Organ Doses)
    - For Calendar Quarter  $\leq 7.5$  mrem
    - For Calendar Year  $\leq 15$  mrem
3. Liquids:

Concentrations are specified in 10 CFR 20, Appendix B, Table 2, Column 2, for radionuclides other than dissolved or entrained noble gases. For dissolved or entrained noble gases, the concentration shall be limited to  $2.00E-04$   $\mu\text{Ci/ml}$  total activity.

  - 10 CFR 50, Appendix I
    - For Calendar Quarter
      - Total Body Dose  $\leq 1.5$  mrem
      - Any Organ Dose  $\leq 5$  mrem
    - For Calendar Year
      - Total Body Dose  $\leq 3$  mrem
      - Any Organ Dose  $\leq 10$  mrem

B. Measurements and Approximations of Total Radioactivity

1. Continuous Gaseous Releases

- a) Fission and Activation Gases - The total activity released is determined from the net count rate of the gaseous monitor, its calibration factor, and the total exhaust flow. The activity of radioactive gas is determined by the fraction of that radioactive gas in the isotopic analysis for that period.
- b) Iodines - The activity released as Iodine-131, 133, and 135 is based on isotopic analysis of the charcoal cartridge and particulate filter, and the total exhaust flow.
- c) Particulates - The activity released via particulates with half-lives greater than eight days is determined by isotopic analysis of particulate filters and the total exhaust flow.
- d) Tritium - The activity released as tritium is based on weekly grab sample analysis and total exhaust flow.
- e) Carbon 14 – The activity released is determined by using NUREG-0017 (GALE Code) Section 2.2.25 and corrected for Effective Full Power Days (EFPD) for 2010.

2. Batch Gaseous Releases

- a) Fission and Activation Gases - The activity released is based on the volume released and the activity of the individual nuclides obtained from an isotopic analysis of the grab sample taken prior to the release.
- b) Iodines - The iodines from mixed mode batch releases are included in the iodine determination from the mixed mode continuous Reactor Auxiliary Building release.
- c) Particulates - The particulates from mixed mode batch releases are included in the particulate determination from the mixed mode continuous Reactor Auxiliary Building release.
- d) Tritium - The activity released as tritium is based on the grab sample analysis of each batch and the batch volume.
- e) Carbon 14 – The activity released is determined by using NUREG-0017 (GALE Code) Section 2.2.25 and corrected for Effective Full Power Days (EFPD) for 2010.

3. Liquid Releases

- a) Fission and Activation Products - The total release values (not including tritium, gases, and alpha) are comprised of the sum of the individual radionuclide activities in each release to the discharge canal for the respective quarter. These values represent the activity known to be present in the liquid radwaste effluent.
- b) Tritium - The activity released as tritium is based on the grab sample analysis of each batch and the batch volume. For continuous releases, the activity released as tritium is based on analysis of a weekly composite sample. For continuous releases without a composite sampler, the tritium activity is based on analysis of daily grab samples or a composite of grab samples.
- c) Alpha - The measured alpha concentration in a monthly composite sample is used to calculate the total release and average diluted concentration during each period.
- d) Strontium-89, 90, and Iron-55 - The total release values are measured quarterly from composite samples.

C. Estimated Total Errors

1. Estimated total errors for gaseous effluents are based on uncertainties in counting equipment calibration, counting statistics, exhaust flow rates, exhaust sample flow rates, non-steady release rates, chemical yield factors, and sample losses for such items as charcoal cartridges.
2. Estimated total errors for liquid effluents are based on uncertainties in counting equipment calibration, counting statistics, non-steady release flow rate, sampling and mixing losses, and volume determinations.
3. Estimated total errors for solid waste are based on uncertainties in equipment calibration, dose rate measurements, geometry, and volume determinations.

III. GASEOUS EFFLUENTS

A. Batch Releases

	Jan - June 2010	July - Dec 2010
Number of batch releases	42	60
Total time period for batch releases	3.26E+04 min	1.68E+04 min
Maximum time period for a batch release	1.26E+04 min	7.28E+02 min
Average time period for a batch release	7.76E+02 min	2.79E+02 min
Minimum time period for a batch release	1.40E+01 min	2.00E+00 min

B. Abnormal Releases

	Jan - June 2010	July - Dec 2010
Number of releases	0	0
Total activity released	0.00E+00 Ci	0.00E+00 Ci

C. Data Tables

The following tables provide the details of gaseous releases:

- Table III-A Summation of All Releases
- Table III-B Ground Level and Mixed Mode Releases
- Table III-C Typical Lower Limits of Detection for Gaseous Effluents

TABLE III-A  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT - 2010  
GASEOUS EFFLUENTS - SUMMATION OF ALL RELEASES

	Unit	Quarter 1	Quarter 2	Est. Total Error %
<b>A. Fission and Activation Gases</b>				
1. Total release	Ci	2.92E-01	6.27E-02	3.63E+01
2. Average release rate for period	μCi/sec	3.75E-02	7.97E-03	
<b>B. Iodines</b>				
1. Total Iodine-131	Ci	8.39E-07	5.14E-07	1.74E+01
2. Average release rate for period	μCi/sec	1.08E-07	6.54E-08	
<b>C. Particulates</b>				
1. Particulates with half-lives >8 days	Ci	ND	6.15E-08	1.05E+01
2. Average release rate for period	μCi/sec	ND	7.82E-09	
3. Gross alpha radioactivity	Ci	ND	ND	
<b>D. Tritium</b>				
1. Total release	Ci	1.03E+00	1.93E+00	2.31E+01
2. Average release rate for period	μCi/sec	1.32E-01	2.45E-01	
<b>E. Carbon-14</b>				
1. Total release <sup>1</sup>	Ci	1.26E+00	1.26E+00	
2. Average release rate for period	μCi/sec	1.62E-01	1.60E-01	
<b>F. Percent of 10 CFR 50, Appendix I</b>				
1. Quarterly limit				
Gamma air	%	2.08E-02	4.76E-04	
Beta air	%	1.07E-02	2.56E-03	
Organ: Thyroid <sup>2</sup>	%	1.91E-01	3.54E-01	
2. Annual limit*				
Gamma air	%	1.04E-02	1.06E-02	
Beta air	%	5.35E-03	6.62E-03	
Organ: Thyroid <sup>2</sup>	%	9.53E-02	2.73E-01	

\*Cumulative total for the year-to-date using the methodology in the ODCM.

<sup>1</sup>The estimated releases of Carbon-14 are not based on measurements of effluents, but on the methodology of NUGEG-0017 adjusted for EFPD. The calculated annual release is divided equally among the four calendar quarters.

<sup>2</sup>The maximum organ dose (determined to be the thyroid from measured effluents) does not include Carbon-14 bone dose of 0.065 mrem per quarter. Total Body dose from Carbon-14 releases is 0.0129 mrem per quarter.

TABLE III-A  
(Continued)  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT - 2010  
GASEOUS EFFLUENTS - SUMMATION OF ALL RELEASES

	Unit	Quarter 3	Quarter 4	Est. Total Error %
<b>A. Fission and Activation Gases</b>				
1. Total release	Ci	1.11E-01	4.10E-02	3.63E+01
2. Average release rate for period	μCi/sec	1.40E-02	5.16E-03	
<b>B. Iodines</b>				
1. Total Iodine-131	Ci	ND	ND	1.74E+01
2. Average release rate for period	μCi/sec	ND	ND	
<b>C. Particulates</b>				
1. Particulates with half-lives >8 days	Ci	3.77E-08	ND	1.05E+01
2. Average release rate for period	μCi/sec	4.74E-09	ND	
3. Gross alpha radioactivity	Ci	ND	ND	
<b>D. Tritium</b>				
1. Total release	Ci	1.38E+00	1.51E+00	2.31E+01
2. Average release rate for period	μCi/sec	1.73E-01	1.90E-01	
<b>E. Carbon-14</b>				
1. Total release <sup>1</sup>	Ci	1.26E+00	1.26E+00	
2. Average release rate for period	μCi/sec	1.58E-01	1.58E-01	
<b>F. Percent of 10 CFR 50, Appendix I</b>				
1. Quarterly limit				
Gamma air	%	1.15E-02	7.61E-03	
Beta air	%	4.99E-03	2.03E-03	
Organ: Thyroid <sup>2</sup>	%	1.12E+00	1.14E+00	
2. Annual limit*				
Gamma air	%	1.64E-02	2.02E-02	
Beta air	%	9.13E-03	1.01E-02	
Organ: Thyroid <sup>2</sup>	%	3.99E-01	5.37E-01	

\*Cumulative total for the year-to-date using the methodology in the ODCM.

<sup>1</sup>The estimated releases of Carbon-14 are not based on measurements of effluents, but on the methodology of NUREG-0017 adjusted for EFPD. The calculated annual release is divided equally among the four calendar quarters

<sup>2</sup>The maximum organ dose (determined to be the thyroid from measured effluents) does not include Carbon-14 bone dose of 0.065 mrem per quarter. Total Body dose from Carbon-14 releases is 0.0129 mrem per quarter.

**TABLE III-B**  
**EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT - 2010**  
**GASEOUS EFFLUENTS - GROUND LEVEL AND MIXED MODE RELEASES**

Nuclides Released	Unit	Continuous Mode		Batch Mode	
		Quarter 1	Quarter 2	Quarter 1	Quarter 2
<b>1. Fission Gases</b>					
Ar-41	Ci	ND	ND	3.52E-02	ND
Kr-85	Ci	ND	ND	3.58E-02	3.78E-02
Xe-131m	Ci	ND	ND	1.41E-05	6.02E-04
Xe-133m	Ci	ND	ND	ND	4.11E-05
Xe-133	Ci	2.16E-01	ND	4.63E-03	2.42E-02
Total for Period	Ci	2.16E-01	ND	7.57E-02	6.27E-02
<b>2. Iodines<sup>1</sup></b>					
I-131	Ci	8.39E-07	5.14E-07	ND	ND
I-132	Ci	6.43E-06	1.35E-05	ND	ND
I-133	Ci	1.96E-06	ND	ND	ND
Total for Period	Ci	9.22E-06	1.41E-05	ND	ND
<b>3. Particulates<sup>1</sup></b>					
Co-57	Ci	ND	ND	ND	1.91E-09
Co-58	Ci	ND	ND	ND	2.93E-08
Co-60	Ci	ND	ND	ND	1.97E-08
Cs-137	Ci	ND	ND	ND	1.06E-08
Total for Period	Ci	ND	ND	ND	6.15E-08
<b>4. Carbon-14</b>					
C-14	Ci	1.05E+00	1.05E+00	2.07E-01	2.07E-01
Total for Period	Ci	1.05E+00	1.05E+00	2.07E-01	2.07E-01

<sup>1</sup>Mixed mode continuous accountability includes mixed mode batch accountability (excludes tritium).

TABLE III-B  
(Continued)  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT - 2010  
GASEOUS EFFLUENTS - GROUND LEVEL AND MIXED MODE RELEASES

Nuclides Released	Unit	Continuous Mode		Batch Mode	
		Quarter 3	Quarter 4	Quarter 3	Quarter 4
1. Fission Gases					
Ar-41	Ci	ND	ND	2.20E-02	1.51E-02
Kr-85	Ci	ND	ND	3.19E-02	2.82E-03
Xe-131m	Ci	ND	ND	2.04E-04	2.19E-04
Xe-133	Ci	3.24E-02	ND	2.47E-02	2.28E-02
Xe-133m	Ci	ND	ND	1.19E-04	ND
Xe-135	Ci	ND	ND	6.41E-05	8.24E-05
Total for Period	Ci	3.24E-02	ND	7.89E-02	4.10E-02
2. Iodines <sup>1</sup>					
I-131	Ci	ND	ND	ND	ND
I-133	Ci	ND	ND	ND	ND
Total for Period	Ci	ND	ND	ND	ND
3. Particulates <sup>1</sup>					
Co-58	Ci	3.77E-08	ND	ND	ND
Total for Period	Ci	3.77E-08	ND	ND	ND
4. Carbon-14					
C-14	Ci	1.05E+00	1.05E+00	2.07E-01	2.07E-01
Total for Period	Ci	1.05E+00	1.05E+00	2.07E-01	2.07E-01

<sup>1</sup>Mixed mode continuous accountability includes mixed mode batch accountability (excludes tritium).

TABLE III-C  
TYPICAL LOWER LIMITS OF DETECTION FOR GASEOUS EFFLUENTS

Nuclide	LLD ( $\mu\text{Ci/cc}$ )
H-3	6.85E-09
Ar-41	3.31E-08
Mn-54	9.55E-15
Co-58	9.62E-15
Fe-59	2.50E-14
Co-60	1.41E-14
Zn-65	2.66E-14
Br-82	1.25E-13
Kr-85	5.35E-06
Kr-85m	1.29E-08
Kr-87	6.22E-08
Kr-88	3.88E-08
Sr-89	1.92E-15
Sr-90	8.25E-16
Mo-99	2.17E-13
I-131	1.01E-14
Xe-131m	4.07E-07
I-133	7.11E-13
Xe-133	2.17E-08
Xe-133m	8.72E-08
Cs-134	1.05E-14
I-135	2.16E-08
Xe-135	1.14E-08
Xe-135m	3.32E-07
Cs-137	1.89E-14
Xe-138	1.00E-06
Ba-140	2.96E-14
La-140	2.65E-14
Ce-141	3.87E-15
Ce-144	3.02E-14
Gross Alpha	5.37E-15

IV. LIQUID EFFLUENTS

A. Batch Releases

	Jan - June 2010	July - Dec 2010
Number of batch releases	70	41
Total time period for batch releases	1.47E+04 min	8.94E+03 min
Maximum time period for a batch release	3.86E+02 min	4.30E+02 min
Average time period for a batch release	2.10E+02 min	2.18E+02 min
Minimum time period for a batch release	1.60E+01 min	6.10E+01 min
Average stream flow during release periods	2.08E+05 gpm	3.11E+05 gpm

B. Abnormal Releases

	Jan - June 2010	July - Dec 2010
Number of releases	0	0
Total activity released	0.00E+00 Ci	0.00E+00 Ci

C. Data Tables

The following tables provide the details of liquid releases:

- Table IV-A Summation of All Releases
- Table IV-B Continuous Mode and Batch Mode Releases
- Table IV-C Typical Lower Limits of Detection for Liquid Effluents

TABLE IV-A  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT - 2010  
LIQUID EFFLUENTS - SUMMATION OF ALL RELEASES

	Unit	Quarter 1	Quarter 2	Est. Total Error %
<b>A. Fission and Activation Products</b>				
1. Total release (not including tritium, gases, alpha)	Ci	5.49E-04	1.21E-02	1.07E+01
2. Average diluted concentration during period	µCi/ml	2.02E-12	2.20E-10	
<b>B. Tritium</b>				
1. Total release	Ci	2.94E+02	5.19E+01	9.20E+00
2. Average diluted concentration during period	µCi/ml	1.08E-06	9.47E-07	
<b>C. Dissolved and entrained gases</b>				
1. Total release	Ci	4.91E-02	1.08E-02	9.60E+00
2. Average diluted concentration during period	µCi/ml	1.80E-10	1.97E-10	
3. Percent of applicable limit	%	9.00E-05	9.85E-05	
<b>D. Gross alpha radioactivity</b>				
1. Total release	Ci	ND	ND	1.83E+01
<b>E. Volume of waste released prior to dilution</b>				
	Liters	7.90E+05	1.16E+06	
<b>F. Volume of dilution water used during period</b>				
	Liters	2.72E+11	5.48E+10	
<b>G. Percent of 10 CFR 50, Appendix I</b>				
1. Quarterly Limit				
Organ: Liver, GI-LLI <sup>1</sup>	%	6.17E-04	2.23E-03	
Total body	%	2.02E-03	3.84E-03	
2. Annual Limit*				
Organ: Liver, GI-LLI	%	3.09E-04	1.41E-03	
Total body	%	1.01E-03	2.93E-03	

\*Cumulative total for the year-to-date using the methodology in the ODCM.

<sup>1</sup> Liver for Quarter 1 & GI-LLI, gastrointestinal-lower large intestine for Quarter 2

TABLE IV-A  
 (Continued)  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT - 2009  
LIQUID EFFLUENTS - SUMMATION OF ALL RELEASES

	Unit	Quarter 3	Quarter 4	Est. Total Error %
<b>A. Fission and Activation Products</b>				
1. Total release (not including tritium, gases, alpha)	Ci	8.46E-04	2.83E-04	1.07E+01
2. Average diluted concentration during period	µCi/ml	3.32E-12	1.07E-12	
<b>B. Tritium</b>				
1. Total release	Ci	7.83E+00	8.31E+01	9.20E+00
2. Average diluted concentration during period	µCi/ml	3.07E-08	3.15E-07	
<b>C. Dissolved and entrained gases</b>				
1. Total release	Ci	1.22E-04	2.23E-03	9.60E+00
2. Average diluted concentration during period	µCi/ml	4.78E-13	8.46E-12	
3. Percent of applicable limit	%	2.39E-07	4.23E-06	
<b>D. Gross alpha radioactivity</b>				
1. Total release	Ci	ND	ND	1.83E+01
<b>E. Volume of waste released prior to dilution</b>				
	Liters	5.73E+05	5.68E+05	
<b>F. Volume of dilution water used during period</b>				
	Liters	2.55E+11	2.64E+11	
<b>G. Percent of 10 CFR 50, Appendix I</b>				
1. Quarterly Limit				
Organ: Liver, GI-LLI <sup>1</sup>	%	5.23E-05	4.59E-04	
Total body	%	1.49E-04	1.48E-03	
2. Annual Limit*				
Organ:, GI-LLI	%	1.44E-03	1.66E-03	
Total body	%	3.01E-03	3.75E-03	

<sup>1</sup> Liver for Quarter 3 & GI-LLI, gastrointestinal-lower large intestine for Quarter 4

\*Cumulative total for the year-to-date using the methodology in the ODCM.

TABLE IV-B  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT - 2010  
LIQUID EFFLUENTS - CONTINUOUS MODE AND BATCH MODE RELEASES

Nuclides Released	Unit	Continuous Mode		Batch Mode	
		Quarter 1	Quarter 2	Quarter 1	Quarter 2

H-3	Ci	ND	ND	2.94E+02	5.19E+01
-----	----	----	----	----------	----------

Fe-55	Ci	ND	ND	4.33E-05	ND
Mn-54	Ci	ND	ND	ND	1.75E-05
Co-57	Ci	ND	ND	ND	3.56E-05
Co-58	Ci	ND	ND	1.39E-05	9.30E-03
Co-60	Ci	ND	ND	4.32E-04	2.46E-03
Ag-110m	Ci	ND	ND	ND	7.58E-07
Sn-117m	Ci	ND	ND	ND	1.52E-05
Te-123m	Ci	ND	ND	ND	1.56E-05
Sb-125	Ci	ND	ND	5.11E-05	1.97E-04
Cs-134	Ci	ND	ND	2.01E-06	ND
Cs-137	Ci	ND	ND	7.00E-06	7.97E-06
Total for Period	Ci	ND	ND	5.49E-04	1.21E-02

Kr-85	Ci	ND	ND	3.02E-04	ND
Xe-131m	Ci	ND	ND	6.36E-04	1.04E-04
Xe-133	Ci	ND	ND	4.80E-02	1.07E-02
Xe-133m	Ci	ND	ND	1.61E-04	1.55E-05
Xe-135	Ci	ND	ND	2.86E-06	ND
Total for Period	Ci	ND	ND	4.91E-02	1.08E-02

TABLE IV-B  
(Continued)  
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT - 2010  
LIQUID EFFLUENTS - CONTINUOUS MODE AND BATCH MODE RELEASES

Nuclides Released	Unit	Continuous Mode		Batch Mode	
		Quarter 3	Quarter 4	Quarter 3	Quarter 4
H-3	Ci	ND	ND	7.83E+00	8.31E+01
Fe-55	Ci	ND	ND	ND	ND
Co-57	Ci	ND	ND	3.59E-06	ND
Co-58	Ci	ND	ND	5.06E-04	1.31E-04
Co-60	Ci	ND	ND	3.09E-04	1.05E-04
Sn-117m	Ci	ND	ND	6.61E-07	1.37E-06
Te-123m	Ci	ND	ND	6.76E-07	1.41E-06
Sb-124	Ci	ND	ND	ND	4.48E-06
Sb-125	Ci	ND	ND	2.30E-05	3.79E-05
I-133	Ci	ND	ND	2.53E-07	ND
Cs-137	Ci	ND	ND	2.64E-06	1.39E-06
Total for Period	Ci	ND	ND	8.46E-04	2.83E-04
Kr-85	Ci	ND	ND	6.53E-05	ND
Xe-131m	Ci	ND	ND	ND	4.95E-05
Xe-133	Ci	ND	ND	5.64E-05	2.18E-03
Total for Period	Ci	ND	ND	1.22E-04	2.23E-03

TABLE IV-C  
TYPICAL LOWER LIMITS OF DETECTION FOR LIQUID EFFLUENTS

Nuclide	LLD ( $\mu\text{Ci/ml}$ )
H-3	4.19E-06
Cr-51	1.35E-07
Mn-54	1.84E-08
Fe-55	8.64E-08
Co-57	9.66E-09
Co-58	1.82E-08
Fe-59	4.22E-08
Co-60	2.48E-08
Zn-65	4.70E-08
Sr-89	3.70E-08
Sr-90	1.36E-08
Nb-95	2.45E-08
Zr-95	3.73E-08
Mo-99	1.97E-07
Tc-99m	8.65E-09
Ag-110m	1.56E-08
Sn-113	2.42E-08
Sb-122	4.05E-08
Te-123m	1.40E-08
Sb-124	1.98E-08
Sb-125	3.34E-08
Xe-127	2.16E-08
I-131	1.13E-08
Xe-131m	6.44E-07
Te-132	1.57E-08
Xe-133	4.01E-08
Xe-133m	1.69E-07
Cs-134	2.06E-08
Xe-135	9.36E-08
Cs-137	3.90E-08
Ba-140	5.14E-08
La-140	3.57E-08
Ce-141	9.02E-09
Ce-144	7.75E-08
Gross Alpha	8.74E-08

V. SOLID WASTE AND IRRADIATED FUEL SHIPMENTS  
 Report Time Period: January 1, 2010, through December 31, 2010

A. SOLID WASTE SHIPPED OFFSITE FOR BURIAL OR DISPOSAL (not irradiated fuel)

Waste Class A

1. Type of Waste	Waste Volume (m <sup>3</sup> )	Activity (Ci)	Estimated Error (%)	No. Ship.
a. Spent resins, filter sludge, evaporator bottoms, etc.	3.41E+00	8.10E-01	2.00E+01	1
b. Dry compressible waste, contaminated equipment, etc.	3.07E+02	3.18E+00	2.00E+01	10
c. Irradiated components, control rods, etc.	N/A	N/A	N/A	N/A
d. Other: Oil	7.97E+00	1.37E-05	2.00E+01	1

2. Estimate of major nuclide composition (by type of waste)

	%	Ci
Resins		
Ni-63	4.66E+01	3.77E-01
Cs-134	2.32E+01	1.88E-01
Cs-137	1.94E+01	1.57E-01
Fe-55	3.46E+00	2.80E-02
Co-60	3.36E+00	2.72E-02
Co-58	1.15E+00	9.27E-03
C-14	8.39E-01	6.79E-03
H-3	7.56E-01	6.12E-03
Sr-90	5.09E-01	4.12E-03
Mn-54	4.22E-01	3.42E-03
Zn-65	1.40E-01	1.13E-03
Co-57	9.75E-02	7.89E-04
Ce-144	9.34E-02	7.56E-04
Dry Compressible Waste		
Fe-55	6.22E+01	1.98E+00
Co-60	1.40E+01	4.46E-01
Ni-63	9.78E+00	3.11E-01
Co-58	3.83E+00	1.22E-01
Nb-95	2.72E+00	8.63E-02
Cs-137	1.86E+00	5.89E-02
Sb-125	1.83E+00	5.80E-02
Zr-95	1.20E+00	3.81E-02
Cs-134	8.86E-01	2.82E-02
Mn-54	6.00E-01	1.90E-02
Ag-110m	4.38E-01	1.39E-02
Sn-113	1.66E-01	5.27E-03
Ce-144	1.52E-01	4.84E-03
Others *	3.24E-01	1.03E-02
Oil		
Cs-137	7.88E+01	1.08E-05
Co-60	1.67E+01	2.28E-06
Ce-144	4.23E+00	5.78E-07
Mn-54	1.79E-01	2.45E-08
Cs-134	5.54E-02	7.57E-09

\*\* Others include Co-57, H-3, Cr-51, Pu-241, Fe-59, Sr-90, Zn-65, Ru-103, Sr-89, Cm-242, Sn-117m, Pu-238, Cm-243, Pu-239, Am-241

Total Curie Quantity and Principle Radionuclides were determined by estimate.

3. Irradiated Fuel Shipments

<u>Number of Shipments:</u>	0
<u>Mode of Transportation</u>	N/A
<u>Destination</u>	N/A

4. Solid Waste

<u>Number of Shipments:</u>	12
<u>Mode of Transportation</u>	Exclusive Use – Highway
<u>Destination</u>	Duratek (Energy Solutions) / Barnwell

V. SOLID WASTE AND IRRADIATED FUEL SHIPMENTS

Report Time Period: January 1, 2010, through December 31, 2010

B. SOLID WASTE SHIPPED OFFSITE FOR BURIAL OR DISPOSAL (not irradiated fuel)

Waste Class B

1.	Type of Waste	Waste Volume (m <sup>3</sup> )	Activity (Ci)	Estimated Error (%)	No. Ship.
----	---------------	--------------------------------	---------------	---------------------	-----------

a.	Spent resins, filter sludge, evaporator bottoms, etc.	3.41E+00	1.14E+02	2.00E+01	1
b.	Dry compressible waste, contaminated equipment, etc.	N/A	N/A	N/A	N/A
c.	Irradiated components, control rods, etc.	N/A	N/A	N/A	N/A
d.	Other: N/A	N/A	N/A	N/A	N/A

2. Estimate of major nuclide composition (by type of waste)

	%	Ci
<b>Resins</b>		
Ni-63	6.17E+01	7.67E+01
Cs-134	7.75E+00	8.85E+00
Cs-137	7.65E+00	8.74E+00
Fe-55	6.98E+00	7.97E+00
Co-60	6.22E+00	7.11E+00
Co-58	1.65E+00	1.88E+00
C-14	9.80E-01	1.12E+00
Mn-54	6.06E-01	6.92E-01
Ni-59	4.32E-01	4.94E-01
Sr-90	3.98E-01	4.55E-01
Co-57	1.71E-01	1.95E-01
Pu-241	1.58E-02	1.81E-02
Others*	3.21E-02	3.67E-02

\* Others include Ce-144, Sn-113, Sr-89, Nb-95, Tc-99, Cm-242, Cm-243, Pu-138, Am-241, Pu-239

3. Irradiated fuel shipments

Number of Shipments: 0  
 Mode of Transportation: N/A  
 Destination: N/A

4. Solid Waste

Number of Shipments: 1  
 Mode of Transportation: Exclusive Use  
 Destination: Barnwell Disposal Facility

V. SOLID WASTE AND IRRADIATED FUEL SHIPMENTS

Report Time Period: January 1, 2010, through December 31, 2010

C. SOLID WASTE SHIPPED OFFSITE FOR BURIAL OR DISPOSAL (not irradiated fuel)

Waste Class C

1. Type of Waste	Waste Volume (m <sup>3</sup> )	Activity (Ci)	Estimated Error (%)	No. Ship.
------------------	--------------------------------	---------------	---------------------	-----------

a. Spent resins, filter sludge, evaporator bottoms, etc.	N/A	N/A	N/A	N/A
b. Dry compressible waste, contaminated equipment, etc.	N/A	N/A	N/A	N/A
c. Irradiated components, control rods, etc.	N/A	N/A	N/A	N/A
d. Other	N/A	N/A	N/A	N/A

2. Estimate of major nuclide composition (by type of waste)

N/A

3. Irradiated Fuel Shipments

Number of Shipments:	0
Mode of Transportation	N/A
Destination	N/A

4. Solid Waste

Number of Shipments:	0
Mode of Transportation	N/A
Destination	N/A

VI. 40 CFR 190 DOSE CONFORMANCE

The direct radiation assessment to the most likely exposed member of the public is reported in the Annual Radiological Environmental Operating Report. The results of the assessment demonstrate no measurable affect above background from plant operations. Since no 10 CFR 50, Appendix I, limits have been exceeded and the evaluation of the Independent Spent Fuel Storage Installations indicate only a small fraction of the total dose to the environs, this demonstrates conformance with 40 CFR 190, "Environmental Radiation Protection Standards for Nuclear Power Operation."

VII. METEOROLOGICAL DATA

A. Continuous Release Diffusion Analysis

Table VII-A presents the number and frequency of wind direction occurrences by wind speed class as recorded at the onsite meteorological system during continuous release, for the period January 1, 2010, through December 31, 2010.

The frequencies are presented as a percent of total occurrences for each stability class, as well as a summary for all classes for the lower (11 meter) sensor elevation.

Pertinent information available from the tables is as follows:

1. Stability

Percent occurrence Pasquill Stability categories based on lower level (11 meter) wind distribution:

A	B	C	D	E	F	G
5.05	5.90	8.21	39.77	21.87	8.92	10.64

2. Wind Speed 11 Meter

Average Speed (mph) 4.95  
 Percent Calm 5.35  
 Percent Less than 3.5 mph 37.67

3. Wind Direction 11 Meter

Prevailing NNW  
 Percent Occurrence 11.6

TABLE VII-A JOINT OCCURRENCE FREQUENCIES FOR LOWNDDEG AND LOWNDSPD – GROUND CONTINUOUS RELEASES

ATMOSPHERIC STABILITY CLASS A																	
Max (M/S)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL
0.34	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
1.56	0.00	0.00	0.01	0.00	0.00	0.03	0.01	0.00	0.00	0.00	0.03	0.01	0.01	0.01	0.00	0.00	0.12
3.35	0.08	0.08	0.04	0.13	0.11	0.27	0.20	0.10	0.20	0.39	0.45	0.58	0.13	0.00	0.01	0.01	2.78
5.59	0.13	0.00	0.00	0.00	0.00	0.00	0.00	0.02	0.32	0.62	0.28	0.21	0.24	0.03	0.18	0.03	2.07
8.27	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.01	0.03	0.01	0.00	0.00	0.00	0.01	0.00	0.08
11.18	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
24.59	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOTAL	0.21	0.08	0.06	0.13	0.11	0.30	0.21	0.13	0.53	1.04	0.77	0.80	0.39	0.04	0.20	0.04	5.05
ATMOSPHERIC STABILITY CLASS B																	
Max (M/S)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL
0.34	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
1.56	0.00	0.01	0.00	0.03	0.08	0.12	0.04	0.03	0.04	0.00	0.03	0.02	0.00	0.00	0.00	0.00	0.42
3.35	0.31	0.20	0.23	0.28	0.28	0.21	0.18	0.09	0.14	0.29	0.58	0.48	0.23	0.07	0.07	0.02	3.64
5.59	0.21	0.06	0.00	0.00	0.00	0.00	0.00	0.03	0.17	0.32	0.18	0.13	0.19	0.07	0.31	0.06	1.72
8.27	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.04	0.00	0.01	0.01	0.03	0.01	0.00	0.12
11.18	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
24.59	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOTAL	0.52	0.27	0.23	0.31	0.35	0.33	0.22	0.15	0.37	0.65	0.79	0.64	0.43	0.17	0.39	0.08	5.90
ATMOSPHERIC STABILITY CLASS C																	
Max (M/S)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL
0.34	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
1.56	0.01	0.04	0.07	0.09	0.16	0.27	0.13	0.02	0.06	0.08	0.00	0.04	0.03	0.03	0.00	0.00	1.03
3.35	0.69	0.31	0.30	0.34	0.22	0.22	0.23	0.11	0.22	0.34	0.71	0.28	0.39	0.23	0.21	0.14	4.95
5.59	0.35	0.03	0.00	0.00	0.00	0.01	0.02	0.06	0.09	0.29	0.13	0.04	0.18	0.19	0.40	0.18	1.97
8.27	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.01	0.07	0.02	0.02	0.01	0.01	0.07	0.03	0.26
11.18	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.00	0.00	0.01
24.59	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOTAL	1.05	0.39	0.37	0.43	0.38	0.50	0.39	0.20	0.38	0.77	0.86	0.39	0.61	0.48	0.68	0.35	8.21
ATMOSPHERIC STABILITY CLASS D																	
Max (M/S)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL
0.34	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.00	0.01	0.01	0.01	0.01	0.00	0.00	0.00	0.10
1.56	0.48	0.66	1.05	0.85	0.61	0.64	0.83	0.58	0.45	0.59	0.64	0.47	0.50	0.34	0.28	0.23	9.20
3.35	3.25	2.66	1.65	0.90	0.60	0.56	0.68	1.57	2.13	2.21	1.27	0.75	0.58	0.84	0.84	1.42	21.90
5.59	1.15	0.35	0.12	0.06	0.01	0.01	0.04	0.60	1.21	0.60	0.52	0.35	0.31	0.53	0.52	1.35	7.74
8.27	0.04	0.00	0.00	0.00	0.00	0.00	0.00	0.22	0.18	0.06	0.01	0.01	0.01	0.11	0.10	0.06	0.80
11.18	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.00	0.00	0.00	0.00	0.02	0.00	0.00	0.03
24.59	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOTAL	4.93	3.68	2.83	1.81	1.22	1.22	1.56	2.97	3.98	3.46	2.45	1.59	1.40	1.85	1.74	3.06	39.77

TABLE VII-A (Continued) JOINT OCCURRENCE FREQUENCIES FOR LOWNDDEG AND LOWNDSPD – GROUND CONTINUOUS RELEASES

ATMOSPHERIC STABILITY CLASS E																	
Max (M/S)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL
0.34	0.03	0.03	0.02	0.01	0.01	0.01	0.03	0.06	0.08	0.06	0.05	0.04	0.04	0.03	0.04	0.02	0.54
1.56	0.55	0.47	0.35	0.20	0.10	0.16	0.47	1.11	1.34	1.09	0.82	0.78	0.69	0.50	0.62	0.42	9.64
3.35	0.51	0.10	0.08	0.04	0.02	0.00	0.12	1.21	1.17	1.11	0.60	0.64	0.78	0.83	1.43	1.75	10.38
5.59	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.07	0.17	0.10	0.03	0.04	0.03	0.06	0.04	0.74	1.30
8.27	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01
11.18	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
24.59	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOTAL	1.10	0.59	0.45	0.25	0.13	0.16	0.61	2.44	2.76	2.35	1.50	1.50	1.53	1.41	2.13	2.93	21.87

ATMOSPHERIC STABILITY CLASS F																	
Max (M/S)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL
0.34	0.04	0.01	0.01	0.00	0.00	0.01	0.04	0.09	0.08	0.06	0.07	0.07	0.10	0.09	0.12	0.13	0.92
1.56	0.27	0.07	0.08	0.02	0.02	0.06	0.26	0.59	0.49	0.35	0.43	0.45	0.61	0.54	0.74	0.79	5.76
3.35	0.09	0.00	0.00	0.00	0.00	0.00	0.02	0.13	0.01	0.06	0.12	0.14	0.26	0.20	0.44	0.76	2.24
5.59	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.00	0.00	0.00	0.00	0.00	0.01
8.27	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
11.18	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
24.59	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOTAL	0.40	0.08	0.09	0.03	0.03	0.06	0.32	0.81	0.58	0.47	0.63	0.67	0.96	0.83	1.30	1.67	8.92

ATMOSPHERIC STABILITY CLASS G																	
Max (M/S)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL
0.34	0.26	0.02	0.01	0.01	0.03	0.02	0.12	0.21	0.25	0.08	0.16	0.28	0.26	0.27	0.63	1.19	3.79
1.56	0.42	0.03	0.01	0.01	0.04	0.03	0.19	0.33	0.41	0.13	0.27	0.45	0.42	0.44	1.02	1.94	6.15
3.35	0.28	0.00	0.01	0.00	0.00	0.00	0.00	0.01	0.00	0.00	0.04	0.01	0.01	0.00	0.04	0.28	0.69
5.59	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.01
8.27	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
11.18	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
24.59	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOTAL	0.96	0.05	0.03	0.02	0.07	0.05	0.30	0.55	0.66	0.21	0.47	0.74	0.69	0.71	1.69	3.42	10.64

ADDENDUM 1

CHANGES TO ODCM, PCP, AND  
RADIOACTIVE WASTE SYSTEMS

TABLE OF CONTENTS

<u>Description</u> .....	<u>Page</u>
I. Changes to the Offsite Dose Calculation Manual (ODCM) .....	35
II. Changes to the Radioactive Waste Systems .....	36
III. Changes to the Process Control Program (PCP).....	36
IV. Changes to the Land Use Census.....	36
V. Instrument Inoperability.....	37
VI. Liquid Holdup Tank Curie Limit.....	37
VII. Waste Gas Decay Tank Curie Limit .....	37
VIII. Missed Compensatory Samples .....	37
IX. Special Ground Water Protection Requirements .....	37
X. Missed ODCM Samples .....	38

I. CHANGES TO THE OFFSITE DOSE CALCULATION MANUAL (ODCM)

There were two revisions to the ODCM during this reporting period. Summaries of the revisions are shown below. A complete copy of the updated ODCM is being submitted in a separate letter.

ODCM, Revision 31  
Description of Changes

- 1) Revised page 3-85, Table 3.10-1 (Radioactive Gaseous Effluent Monitoring Instrumentation) Item 2.c for the R-11 Sample Flow Rate Monitor. Originally the compensatory actions for the sample flow rate monitor being out of service, allowed effluent releases to continue only if the flow rate was estimated once per 4 hours. This statement has been revised to allow effluent releases to continue if either R-14C is operable or the sample flow rate is estimated once per hours. This change will align item 2.c (R-11 Sample Flow Rate Monitor) with item 2.b (R-11 Radioparticulate Monitor) in that effluent releases may continue provided that R-14C is operable.
- 2) Revised page 4-8, Table 4.1-2 (Reporting Levels for Radioactivity Concentrations in Environmental Samples) to add the reporting levels of tritium and iodine for non-drinking water pathways per NUREG-1301.
- 3) Revised pages 4-9 & 4-11, Table 4.1-3 (Lower Limits of Detection) to add the LLDs of tritium and iodine for non-drinking water pathways per NUREG-1301.
- 4) Performed an editorial change on page 4-14 Section 4.4.1 to add a missing space between two words.
- 5) Performed an editorial change on page 4-20 Table 4.5-1 (H.B. Robinson Radiological Environmental Monitoring Program) to add the missing word "miles" in the distance for environmental TLD#65.
- 6) Performed an editorial change on page 4-25, Figure 4-2 (Radiological Sample Distant Locations) to remove sample location #64 from the statement which details sample locations that are not shown on the map. Sample location #64 is shown on the map.

ODCM, Revision 32  
Description of Changes

- 1) Page 2-20 was revised to move Section 2.5.2 from page 2-21. No content from Section 2.5.2 was changed.
- 2) Page 2-21 was revised to add new Section 2.5.3. This new section was added to model the dose from evaporation of tritium from Lake Robinson as a result of liquid effluents that were previously discharged. The methodology is consistent with the dose methodology already established in the RNP ODCM Section 3.5.3.1 for tritium gaseous effluents.
- 3) Pages 4-6, 4-21, 4-24, & 4-25 are being revised to reflect the recommendations made from Silar Services. In this revision two groundwater sampling points are being removed and one point is being added. The recommendations from Silar Services are captured in NTM 384762.

II. CHANGES TO THE RADIOACTIVE WASTE SYSTEMS

There were no changes to the Radioactive Waste Systems during this reporting period.

III. CHANGES TO THE PROCESS CONTROL PROGRAM (PCP)

There was one revision to the PCP during this reporting period. A summary of the revision is shown below.

PCP, Revision 12  
Description of Changes

- 1) Revised Section 2.0 to specify dewatering and solidification may be performed by qualified vendor or qualified Progress Energy personnel in accordance with a qualified PCP or a program approved by the NRC or burial site facility.
- 2) Revision 12 revised Section 3.1.2 to include a review of both vendor and RNP operating procedures, retention of both vendor and RNP completed records, and monitoring of both vendor and RNP operations for compliance with TRMS 3.22 requirements.
- 3) Revised Section 3.1.3 to include RC Supervisor (with accountability for radioactive waste processing) responsibility for advising the RC Superintendent on the adequacy of both vendor and RNP operating procedures.
- 4) Revised Section 3.2 to clarify that specified vendor requirements apply to vendors who supply both solidification and dewatering services to RNP.

IV. CHANGES TO THE LAND USE CENSUS

The Land Use Census is currently performed every 12 months and was last performed in 2010. The results of the 2010 Land Use Census and average meteorological data for the last 10 years identified no changes that required an ODCM change. The next Land Use Census will be performed in 2011.

V. INSTRUMENT INOPERABILITY

Steam Generator Blowdown Radiation Monitors R-19 A, B, & C were all removed from service on 4/7/10 for scheduled maintenance. Radiation Monitors R19A and R19 C were returned to service on 6/27/10. While R-19B was out of service a CPU card failure was determined on 4/9/10. Because the initial removal from service was not due to an equipment operation issue Engineering was not notified of the removal from service. Engineering was also not notified of the subsequent R-19 B failure and was therefore not tracking the 30 day out of service limit. The unit was down from 3/29/10 thru 7/19/10. Monitor R-19B was back in service 7/7/10. Work scheduling issues attributed to expanded and emergent refueling outage scope contributed to the failure to adequately track the 30 day out of service limit. The 30 day out of service limit was exceeded due to inadequate communication between Operations, Engineering, and E&C on the status of the radiation monitors. (NCR 398174)

VI. LIQUID HOLDUP TANK CURIE LIMIT

There were no outside liquid holdup tanks that exceeded the ten curie limit during this reporting period.

VII. WASTE GAS DECAY TANK CURIE LIMIT

There were no waste gas decay tanks with a curie content that exceeded the 1.90E+04 curie limit during this reporting period.

VIII. MISSED COMPENSATORY SAMPLES

There were no instances of missed compensatory samples during this reporting period.

IX. SPECIAL GROUND WATER PROTECTION REQUIREMENTS

There were no dose calculations performed or special reports made as a result of any spills or leaks during this period.

Additional groundwater monitoring wells were sampled and analyzed during 2010 as part of the NEI Groundwater Protection Initiative. There were a total of nineteen wells monitored, sixteen of which are described in the ODCM and will be addressed in the Annual Radiological Environmental Operating Report. For the three wells not in the ODCM program, no plant related gamma activity was detected. Low level tritium activity was found in two of the three wells. The following are the tritium results from the three additional wells:

<b>Groundwater Tritium - 2010</b>				
pCi/L				
<b>Well ID</b>	1 <sup>st</sup> Quarter	2 <sup>nd</sup> Quarter	3 <sup>rd</sup> Quarter	4 <sup>th</sup> Quarter
PDW-01	ND	ND	ND	ND
PSW-05	367	528	307	276
TS-07B	468	418	441	ND

X. MISSED ODCM SAMPLES

There were no failures to meet the ODCM specified sample frequencies or analyses during this reporting period.

ADDENDUM 2  
CORRECTIONS TO PREVIOUS  
REPORTS

TABLE OF CONTENTS

<u>Description</u>	<u>Page</u>
I. DISCUSSION .....	40

I. DISCUSSION

There are no corrections to previous reports.